

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 KV HUTATMA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.5228	.4294	.4108	.5228	.5487
2	.5228	.4668	.5228	.4294	.4668	.5228	.5487
3	.5228	.4668	.5228	.4294	.4668	.5228	.6283
4	.5975	.5041	.5228	.5601	.5228	.5228	.7023
5	.7095	.5788	.5601	.6722	.5228	.5601	.7468
6	.7468	.6722	.6722	.7655	.5601	.7095	.8402
7	.7842	.7095	.8029	.8215	.5975	.9335	.9335
8	.5914	.6535	.7655	.7207	.6348	.8402	.8145
9	.5121	.6348	.6535	.6348	.6722	.6161	.724
10	.5121	.5975	.5975	.5601	.3801	.543	.5853
11	.4572	.5601	.5601	.5601	.3801	.543	.5121
12	.4572	.3361	.5415	.4108	.3801	.5194	.2743
13	.4668	.5228	.4854	.4108	.3881	.5014	.3109
14	.4668	.5601	.4854	.5041	.3841	.5175	.4435
15	.4668	.5228	.4668	.5041	.439	.5194	.4805
16	.4294	.4755	.5415	.5601	.5544	.2353	.4706
17	.5228	.5041	.499	.5601	.5083	.439	.543
18	.6348	.6161	.6722	.6161	.6161	.5853	.6161
19	.7095	.7468	.8029	.8589	.7468	.7682	.7655
20	.8029	.8215	.7947	.4854	.8215	.8048	.7468
21	.6979	.8215	.8029	.9335	.7842	.7316	.7282
22	.6224	.6161	.7095	.7468	.7316	.695	.5788
23	.4715	.6161	.5601	.5601	.5601	.6348	.5228
24	.5041	.4668	.5041	.4294	.4108	.5228	.5487
Max	.8029	.8215	.8029	.9335	.8215	.9335	.9335
Min	.4294	.3361	.4668	.4108	.3801	.2353	.2743
Avg	.5743	.5807	.6070	.5901	.5392	.5963	.6089

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 KV WALWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4435	.3944	.2477	1.3717	1.2803	.6783
2	.3812	.3521	.3944	.2477	1.3717	1.2803	.6706
3	.3812	.3521	.3944	.2286	1.5432	1.2803	.7042
4	.4191	.3521	.3944	.3155	1.8861	1.4632	.7545
5	.503	.3814	.3944	.3549	1.9719	1.4632	.8288
6	.57	.3814	.4801	.3681	2.0233	1.829	.9116
7	.8139	.3961	.4801	.3702	2.0576	1.957	.9945
8	.9665		.4481	.3418	2.0576	.823	
9	1.1488		.4115	.3286	2.0576	2.2314	1.0288
10	1.3203	.4294	.4475	.3024	.4115	.3384	.3201
11	1.3375	.4458	2.1132	.3155	.4115	.3521	
12	1.4403	.6348	2.3998	.3155	.4115	.3521	
13	1.286	1.2696		.3018	.4115	.3521	
14	1.3032	1.7737		.3018	.4115	.3384	.3812
15	1.3375	1.8298	2.4983	.3155	.3944	.3429	.3384
16	1.4746	1.8298	2.524	.3155	.3944	.3286	.3243
17	1.4575	1.8298	2.2325	.3292	.3944	.3243	.3243
18	1.406	1.587	1.6164	.3292	.3944	.3418	.3384
19	.3384	.463	.3286	.3864	.4115	.3715	.3418
20	.3948	.463	.3418	.3864	.4458	.4458	.3286
21	.3807	.8215	.3549	.3864	.4458	.4268	.3549
22	.3807	.4854	.3549	.3765	.4458	.3963	.3447
23	.3384	.4458	.2572	.3913	.4115	.421	.2328
24	.4668	.4481	.4287	.2477	1.1694	1.2803	.6859
Max	1.4746	1.8298	2.524	.3913	2.0576	2.2314	1.0288
Min	.3384	.3521	.2572	.2286	.3944	.3243	.2328
Avg	.8629	.7916	.8950	.3252	.9711	.8342	.5443

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 KV.BAWACHI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.0538	2.0485	.9335	.7316
2	1.829		2.0119	2.0485	.9335	.7316
3	1.829		2.0538	2.0485	.9335	.7316
4	1.829		2.0538	2.2314	.9335	.7316
5	1.829		2.0538	2.524	.9335	.7316
6	1.829		2.4272	2.5423	1.0456	.7682
7	1.7375		2.4832	2.5789	1.0456	.9145
8	2.0119		2.3712	2.7069	1.0719	.9145
9	2.0485		2.6886	2.7801	1.2136	.9145
10	1.4377	.3658	2.6886	2.894	1.2071	.1829
11	1.8671	.3658	2.726	2.9874	1.2071	.8962
12	1.9605	.3658	2.3525	3.006	1.2986	.8596
13			2.838	2.9874	1.0242	.823
14	.8962	.8962	2.8567	2.9313	.8779	.823
15	.7842	1.8671	2.268		1.0242	.8596
16	.7468	.6584	.8962	1.0269	.9877	.7499
24			.5975			
Max	2.0485	1.8671	2.8567	3.006	1.2986	.9145
Min	.7468	.3658	.5975	1.0269	.8779	.1829
Avg	1.6168	.7532	2.2012	2.4895	1.0419	.7727

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV PADAWALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4083	1.094	1.085	.1886	.1867	.1886
2	.1509	1.4083	1.094	1.085	.1886	.1867	.1886
3	.1886	1.4083	1.094	1.085	.1886	.1867	.2263
4	.2241	1.4419	1.094	1.166	.2452	.1867	.2641
5	.2614	1.576	1.3717	1.3279	.2452	.1867	.2641
6	.2987	1.8442	1.442	1.6032	.2801	.2614	.2829
7	.2785	2.3152	2.0056	1.7652	.3361	.2987	.3206
8	.2229	2.2298	1.989	2.0567	.2801	.2987	.3018
9	.1802	2.1628	1.9062	2.251	.2801	.2241	.3018
10	.1829	1.9448	.2452	.3292	.2267	.2427	.2641
11	.1867	.1886	.2075	2.4863	2.4129	2.4531	1.6575
12	.1867	.1886	.1886	2.652	2.4129	2.5029	1.6741
13	.1867	.1867	.1886	2.7435	2.3805	2.4366	
14	.168	.1867	.1886	2.1548	2.3644	2.2542	1.4918
15	.1867	.2054	.2075	2.2045	2.2996	2.1216	1.5912
16	.1867	.2054	.1886	2.2045	2.0405	1.9227	1.4918
17	.1867	.2261	.2263	2.1548	1.9595	1.7404	1.4255
18	.2263	.2641	.2263	2.0233	2.0538	1.6766	1.3117
19	.2452	.2641	.2452	.2229	.2241	.2204	.2263
20	.2772	.2829	.2829	.2229	.2427	.2713	.2263
21	.2507	.2801	.3018	.1886	.2427	.2641	.2263
22	.2402	.2427	.2452	.1886	.2241	.2263	.1886
23	.2033	.2241	.2075	.1886	.1867	.1886	.1698
24	.1337	.1867	1.094	1.085	.1886	.1867	.1886
Max	.2987	2.3152	2.0056	2.7435	2.4129	2.5029	1.6741
Min	.1337	.1867	.1886	.1886	.1867	.1867	.1698
Avg	.211	.8697	.7223	1.4364	.9038	.8635	.6292



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV HUTATMA DUDH SANGH      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.2614	.3174	.3206	.2801	.3772
2	.3584	.2987	.2614	.3174	.3206	.2801	.3772
3	.3395	.3174	.2614	.3174	.3206	.2801	.3395
4	.3395	.3174	.2614	.3174	.3395	.2801	.3395
5	.3395	.3361	.2614	.3361	.3395	.2801	.3361
6	.3395	.3361	.2614	.3361	.3395	.2801	.3361
7	.3772	.3174	.2614	.3174	.3395	.2614	.3361
8	.3961	.3547	.3361	.3921	.2987		.3361
9	.3921	.3734	.3734	.4854	.2987	.3174	.3361
10	.5281	.3734	.4108	.4854	.4668	.3361	.3547
11	.4294	.4108	.4108	.4854	.4668	.3361	.3547
12	.4294	.4294	.4481	.5228	.3921	.3734	.3547
13	.4108	.4294	.2987	.4108	.3547	.3734	.3547
14	.3921	.3361	.0185	.3734	.3547	.3547	.2987
15	.4108	.3361	.2987	.4108	.3734	.3547	.2801
16	.4294	.3361	.3361	.4108	.3547	.3547	.3174
17	.4108	.3547	.3361	.3734	.3921	.3547	.3174
18	.4108	.3174	.3361	.3734	.3734	.2926	.3174
19	.4108	.3361	.2987	.4294	.3395	.2561	.4481
20	.3734	.3734	.3174	.4294	.2829	.2561	.3921
21	.3734	.4108	.3361	.4294	.3361	.3326	.2801
22	.3921	.4294	.3921	.3174	.4668	.3696	.3547
23	.3361	.3734	.3361	.2801	.2987	.3772	.3734
24	.3547	.3174	.3361	.3174	.3206	.2801	.3772
Max	.5281	.4294	.4481	.5228	.4668	.3772	.4481
Min	.3361	.2987	.0185	.2801	.2829	.2561	.2801
Avg	.3902	.3547	.3104	.3828	.3538	.3157	.3454

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV AHIRWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2427	.2427	.2427	.2241	.2801	.2614
2	.2241	.2427	.2427	.2427	.2241	.2801	.2614
3	.2241	.2427	.2427	.2427	.2241	.2801	.2614
4	.3361	.2427	.2427	.2402	.2801	.2801	.3326
5	.4108	.2987	.3361	.2772	.3361	.2801	.462
6	.5041	.3361	.4668	.3547	.4108	.3734	.499
7	.4668	.4108	.4668	.4668	.4668	.4481	.462
8	.3292	.3174	.4108	.3881	.3658	.3734	
9	.3109	.2801	.3174	.3142	.3658	.3174	.3696
10	.2241	.2801	.2987	.2801	.1867	.2743	.3174
11	.2241	.2427	.2801	.2801	.1867	.2378	.2614
12	.2614	.2427	.2614	.2427	.1848	.2328	.2241
13	.1867	.2427	.2614	.2427	.1663	.2172	.2054
14	.1867	.2241	.2427	.2614	.168	.1991	.1867
15	.1867	.2241	.2241	.1867	.1663	.1829	.1867
16	.2054	.2241	.2427	.1867	.168	.1829	.1867
17	.2241	.2614	.2534	.2241	.2402	.2172	.2614
18	.2614	.3174	.3881	.2987	.3174	.2743	.3012
19	.3361	.4108	.4251	.3772	.3734	.3658	.3841
20	.4108	.5228	.4668	.5014	.4108	.4755	.3734
21	.3734	.4481	.4481	.5014	.4108	.4854	.3696
22	.3361	.3734	.3881	.3772	.3734	.3361	.3881
23	.2614	.2801	.3206	.2865	.2987	.2829	.2614
24		.2614	.2427	.2801	.2801	.2801	.2614
Max	.5041	.5228	.4668	.5014	.4668	.4854	.499
Min	.1867	.2241	.2241	.1867	.1663	.1829	.1867
Avg	.2948	.2987	.3214	.3040	.2846	.2982	.3078

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0566	.0566	.4668	.4144	.2629
2	.1494	.0566	.0566	.0566	.4668	.4144	.2804
3	.1494	.0566	.0566	.0566	.5228	.4144	.2804
4	.168	.0566	.0566	.0566	.5228	.4144	.3012
5	.1867	.0566	.0566	.0754	.5975	.4144	.3012
6	.1867	.0566	.0566	.0754	.6535	.4973	.3189
7	.2427	.0549	.0566	.0754	.6908	.5138	.3258
8	.4024	.0566	.0566	.0754	.6722	.5801	.2743
9	.4024	.0566	.0566	.0754	.6722	.5967	.2743
10	.4755	.0566	.0566	.0566	.0566	.0566	.0566
11	.4755	.5144	.6299	.0566	.0566	.0566	.0566
12	.4938	.6344	.7127	.0566	.0754	.0566	.0566
13	.463	.6516	.7127	.0566	.0566	.0566	.0566
14	.4801	.6036	.7459	.0566	.0566	.0566	.0566
15	.463	.6219	.7625	.0566	.0566	.0566	.0566
16	.463	.6219	.7293	.0566	.0754	.0566	.0566
17	.5093	.6401	.7127	.0566	.0566	.0566	.0754
18	.4115	.6219	.4858	.0566	.0566		.0754
19	.0566	.0566	.0566	.0566	.0566		.0566
20	.0566	.0566	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0566	.0566	.0566	.0566	.0566
22	.0566	.0566	.0566	.0566	.0566	.0566	.0566
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.4294	.4144	.2801
Max	.5093	.6516	.7625	.0754	.6908	.5967	.3258
Min	.0566	.0549	.0566	.0566	.0566	.0566	.0566
Avg	.2810	.2422	.2665	.0605	.2719	.2433	.1554

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0189	.0183	.0185	.0183	.0183
2	.0183	.0189	.0183	.0185	.0183	.0189
3	.0183	.0189	.0183	.0185	.0183	.0189
4	.0183	.0189	.0183	.0185	.0189	.0183
5	.0183	.0189	.0183	.0185	.0183	.0183
6	.0183	.0189	.0183	.0185	.0189	.0183
7	.3658	.0189	.0183	.0185	.0189	.0183
8	.1097	.0189	.1097	.1109	.0189	.0183
9	.1097	.1097	.1097	.1109	.2195	.0183
10	.1097	.1097	.1097	.1097	.2218	.1109
11	.1097	.1132	.1109	.1097	.2218	.1109
12	.1097	.1097	.0185	.1097	.2402	.1109
13	.1097	.1097	.0185	.1097	.2402	.1109
14	.0183	.0189		.1097	.2402	
15	.0183	.0189			.2402	.1109
16	.0185	.0183	.0185		.2218	.1109
24			.0183			
Max	.3658	.1132	.1109	.1109	.2402	.1109
Min	.0183	.0183	.0183	.0185	.0183	.0183
Avg	.0780	.0475	.0428	.0643	.1247	.0554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9877	.9877	.9877	.2195	.1097
2	.0549	.9877	.9877	.9877	.2195	.1097
3	.0549	.9877	.9877	.9877	.2195	.1097
4	.0549	1.3443	.9877	1.3169	.2195	.1097
5	.3292	1.4563	1.4815	1.3169	.2195	1.4266
6	.5487	1.5123	1.4815	1.4266	.5487	1.4815
7	.5487	1.5123	1.4815	1.4815	.5487	1.5364
8	.5487	1.6244	1.4815	1.6461	.7133	1.9753
9	.5487	1.9753	1.9753	1.9753	.7133	1.9753
10	.7682	1.9753	1.9753	1.9753	.7133	1.9753
11	1.9204	1.9753	1.9753	1.7558	.7133	1.9753
12	1.9204	1.9753	1.9753	1.7558	.7133	1.9753
13	1.9204	1.9753	1.9753	1.6461	.7133	1.9753
14	1.9204	1.9753	1.9753	1.6461	.7133	1.9753
15	1.9204	1.9753	1.9753	1.6461	.7133	1.9753
16	1.3169	1.262	1.3169	1.0974	.2195	1.3169
24			.7133			
Max	1.9204	1.9753	1.9753	1.9753	.7133	1.9753
Min	.0549	.9877	.7133	.9877	.2195	.1097
Avg	.9584	1.5939	1.5138	1.4781	.5076	1.3752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 KV. SHIGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0305	.0229	.6622	.4755	.3715
2	.0509	.032	.0236	.7011	.4694	.3668
3	.0509	.032	.024	.7011	.4694	.3572
4	.0509	.0324	.0251	.6687	.4755	.3475
5	.0514	.0328	.0244	.7375	.4904	.3521
6	.0514	.0497	.0248	.8128	.5053	.3567
7	.052	.0492	.0248	1.0669	.6773	.3858
8	.0532	.0486	.024	1.0648	.301	.431
9	.0537	.0429	.0229	1.0385	.5117	.4161
10	.0343	.0251	.0532	.0179	.0549	.0259
11	1.0536	1.3125	.0526	.0229	.0362	.012
12	1.0837	1.4373	.0332	.0244	.0366	.0122
13	1.07	1.4864	.0351	.0248	.0328	.0194
14	.8916	1.4529	.0362	.0198	.0343	.0225
15	.8916	1.3748	.0324	.0191	.0335	.0232
16	.8916	1.1574	.0343	.0191	.0503	.024
17	.8429	1.1728	.0332	.0206	.0514	.0244
18	.823	1.0936	.0514	.0206	.0514	.0251
19	.0312	.0206	.0549	.0229	.0514	.0244
20	.0316	.0343	.0549	.0229	.0526	.0236
21	.0316	.024	.0549	.024	.0526	.0244
22	.0312	.0248	.0566	.0229	.0526	.0251
23	.0312	.024	.0549	.0229	.0532	.0263
24	.0503	.0312	.0259	.639	.4755	.3668
Max	1.0837	1.4864	.0566	1.0669	.6773	.431
Min	.0312	.0206	.0229	.0179	.0328	.012
Avg	.3440	.4592	.0367	.3499	.2290	.1693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 KV. BHADKAMBE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.2172	.2172	.0034	.0162
2	.056	.2195	.2172	.0034	.0143
3	.056	.2172		.0033	.0162
4	.3696	.2172	.2172	.0033	.0152
5	.3696	.2149	.0038	.0033	.0162
6	.3881	.1267	.0038	.0034	.0133
7	.3772	.2172	.0038	.0029	.0171
8	.3772	.3761	.0038	.0026	.0162
9	.3721	.3761	.0038	.0026	.0029
10	.3721	.3761	.0162	.0133	.0029
11	.3761	.3898	.0191	.0133	.0029
12	.3761	.3898	.0162	.0124	.0029
13	.3721	.3898	.0162	.0133	.0019
14	.3761	.3898	.0152	.0133	.0019
15	.3801	.3982	.0171	.0133	.0019
16	.2195	.0015	.0162	.0133	.0029
Max	.3881	.3982	.2172	.0133	.0171
Min	.056	.0015	.0038	.0026	.0019
Avg	.3059	.2823	.0525	.0075	.0091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 KV.POKHARNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0566	.0747	.0747	.0747	.0566
2	.0747	.0566	.0747	.0754	.0747	.0566
3	.0747		.0754	.0747	.0747	.0566
4	.0732	.0566	.0754	.0747	.0754	.0566
5	.0724	.0747	.0754	.0924	.0943	.0754
6	.1097	.0934	.0934	.112	.1132	.1132
7	.1267	.1109	.1097	.1109	.1132	.132
8	.1086	.0924	.0924	.0905	.1132	.0924
9	.0914	.0914	.0895	.0895	.0914	.0739
10	.0819	.1086	.0995	.0905	.1174	.0175
11	.0781	.1052	.0895	.0537	.0526	.0686
12	.0625	.1063	.1094	.0532	.1227	.0709
13	.061	.0709	.0914	.0709	.0526	.12
14	.0701	.0716	.0895	.0716	.0543	.1052
15	.0709	.0924	.0829	.0724	.0732	.0693
16	.0716	.0924	.0886	.0732	.0914	.1029
17	.1086	.1097	.1029	.0732	.1254	.0876
18	.1097	.0732	.1017	.0924	.0905	.12
19	.1097	.0739	.1075	.1109	.1267	.1086
20	.1109	.112	.1267	.1109	.1294	.112
21	.1109	.0943	.1132	.0934	.112	.112
22	.112	.112	.0943	.0747	.0934	.0747
23	.0747	.0747	.0754	.0747	.0754	.0747
24	.0739	.0747	.0747	.0754	.0754	.0566
Max	.1267	.112	.1267	.112	.1294	.132
Min	.061	.0566	.0747	.0532	.0526	.0175
Avg	.0880	.0872	.0920	.0827	.0924	.0839



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 KV SHIGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2263	.2427	.2263	.2263
2	.2614	.2263	.2263	.2452	.2263	.2241
3	.2587	.2263	.2263	.2641	.2263	.2452
4	.3018	.2263	.2263	.2614	.2263	.2641
5	.3174	.3395	.2641	.3206	.3361	.3174
6	.3734	.3772	.1132	.3772	.3734	.3584
7	.4294	.4108	.4668	.3961	.4108	.4294
8	.3475	.3696	.3734	.3772	.3326	.4024
9	.3045	.3258	.3326	.3077	.2896	.3109
10	.3012	.3224	.3012	.2507	.2835	.2534
11	.2126	.2896	.2686	.2149	.2534	
12	.2149	.2926	.2658	.2126	.2715	.3467
13	.2149	.2743	.3077	.2126	.2149	.2481
14	.181	.2715	.2378	.1772	.2012	.2534
15	.181	.2534	.2149	.1791	.2012	.2481
16	.1829		.2401	.1791	.2254	.2481
17	.2218	.2561	.2601	.181	.2713	.2507
18	.2587	.2561	.2743	.2195	.2629	.2658
19	.4108	.3109	.4024	.3326	.3801	.4024
20	.4481	.4251	.4435	.4066	.4066	.4251
21	.4108	.4066	.4294	.3734	.3734	.3696
22	.3734	.3772	.3696	.3361	.3206	.2987
23	.2641	.2829	.2641	.2641	.2263	.2641
24	.2427	.2263	.2641	.2452	.2263	.2263
Max	.4481	.4251	.4668	.4066	.4108	.4294
Min	.181	.2263	.1132	.1772	.2012	.2241
Avg	.2907	.3032	.2916	.2740	.2819	.2991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 KV POKHARNI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.3475	.3521	.0189	.0554	.0377
2	.4359	.3475	.3521	.0189	.0549	.0377
3	.463	.3475	.3567	.0189	.0549	.0377
4	.4527	.3521	.3715	.0189	.0549	.0566
5	.463	.3521	.4012	.0189	.0554	.0566
6	.5864	.3864	.431	.0377	.056	.0566
7	.7562	.602	.6773	.0566	.0566	.0754
8	.8688	.7621	.7042	.0377	.0566	.056
9	.8688	.9031	.8916	.0377	.0377	.056
10	.7827	.056	.0189	.0377	.0377	.037
11	.0373	.0351	1.2752	.743	.8535	.3521
12	.0377	.0351	.9362	.7727	.8993	.4401
13	.0377	.0177	.9482	.1806	.8535	.5647
14	.0377	.0177	.9297	.7827	.8179	.5053
15	.0377	.0377	.8509	.7926	.7773	.535
16	.0377	.0366	.7876	.7926	.7074	.4458
17	.0373	.0183	.8173	.7133	.6226	.4214
18	.0373	.0183	.6748	.6371	.5716	.3864
19	.037	.0183	.0377	.0373	.0377	.0351
20	.037	.0183	.0377	.0566	.0566	.0373
21	.037	.037	.0373	.0566	.0566	.037
22	.0373	.0373		.056	.0566	.0373
23	.0373	.0189	.0187	.0554	.0377	.0373
24	.0377	.2858	.3374	.0189	.0554	.0377
Max	.8688	.9031	1.2752	.7926	.8993	.5647
Min	.037	.0177	.0187	.0189	.0377	.0351
Avg	.2739	.2120	.5324	.2499	.2885	.1825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / HUTATMA SURESHKUMAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0023	.0191	.0029	.0191
2	.0191	.0023	.0191	.003	.0191
3	.0191	.0023	.0191	.003	.0191
4	.0191	.0027	.0191	.003	.0191
5	.0191	.0027	.0191	.0032	.0191
6	.2241	.0027	.0191	.0032	.0191
7	.2772	.0027	.2829	.0032	.1886
8	.2926	.2801	.2829	.2829	.2801
9	.2743	.2801	.2829	.2829	.2801
10	.2957	.2829	.2772	.2801	.2801
11	.2801	.2829	.2772	.2829	.2801
12	.2829	.2829	.2743	.2801	.2801
13	.2829	.2829	.2772	.2829	.2801
14	.2829	.2829	.2926	.2801	
15	.2829	.2829	.2743	.2829	.2801
16	.2829	.2829	.2772	.2801	.2614
Max	.2957	.2829	.2926	.2829	.2801
Min	.0191	.0023	.0191	.0029	.0191
Avg	.1971	.1599	.1821	.1598	.1684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0185	.0187	.381	.3227	.2258
2	.0189	.0183	.0187	.3704	.3227	.2258
3	.0189	.0183	.0187	.3763	.3227	.2526
4	.0189	.0181	.0185	.4268	.3269	.2896
5	.0189	.0181	.0183	.4938	.3567	.2896
6	.0189	.0183	.0183	.5401	.3864	.3048
7	.0189	.0187	.0179	.6944	.4515	.3201
8	.0189	.0189	.0179	.6472	.5117	.3715
9	.0189	.0189	.0185	.6249	.5053	.3715
10	.0189	.0189	.0189	.0181	.0189	
11	.5647	.5312	.0189	.0185	.0189	
12	.5944	.5937	.0187	.0185	.0189	.0175
13	.5944	.679	.0189	.0187	.0189	.0166
14	.5418	.679	.0189	.0187	.0189	.017
15	.4816	.6481	.0189	.0187	.0189	.0171
16	.4816	.679	.0189	.0187	.0187	.0171
17	.5182	.6562	.0189	.0189	.0189	.0173
18	.5182	.6249	.0189	.0189	.0189	.0187
19	.0183	.0175	.0189	.0189	.0189	.0185
20	.0185	.0183	.0189	.0189	.0187	.0185
21	.0185	.0185	.0189	.0189	.0185	.0185
22	.0187	.0187	.0189	.0189	.0185	.0187
23	.0187	.0189	.0189	.0189	.0189	.0187
24	.0189	.0183	.0187	.3161	.2934	.1932
Max	.5944	.679	.0189	.6944	.5117	.3715
Min	.0183	.0175	.0179	.0181	.0185	.0166
Avg	.1915	.2244	.0187	.2139	.1693	.1390

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3961	.4344	.3841	.5658
2	.3961	.3961	.4344	.3841	.5658
3	.4001	.3961	.4344	.3881	.5658
4	.5658	.3961	.4344	.3881	.5658
5	.5716	.3961	.4344	.3881	.6224
6	.5716	.4527	.4344	.4435	.5658
7	.6287	.4527	.5658	.7922	.5716
8	.8488	.7922	.8488	.7922	.8002
9	.8488	.7922	.7922	.7922	.5716
10	.8488	.8488	.8002	.8573	.4001
11	.7922	.8488	.8573	.8488	.3961
12	.7922	.8488	.8002	.7922	.2218
13	.7922	.8488	.8573	.8488	.2218
14	.7922	.8488	.8573	.8573	.2218
15	.7922	.8488	.8573	.8488	.2218
16	.7922	.7922	.012	.5658	.2218
Max	.8488	.8488	.8573	.8573	.8002
Min	.3961	.3961	.012	.3841	.2218
Avg	.6769	.6472	.6159	.6482	.4563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV KRISHNAMAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067			.4858	.4096	.3125
2	.108			.4801	.4096	.3125
3	.1067			.4801	.4096	.3125
4	.108			.4858	.4096	.3125
5	.108			.4858	.4096	.3125
6	.1054			.4801	.421	.3437
7	.1158			.5182	.5344	.3479
8	.2241			.5344	.5506	.4111
9	.3163			.4801	.5121	.3795
10	.3963					
11	.4321	.5441	.6722			
12	.4268	.5441	.7449			
13	.4268	.6401	.7202			
14	.4321	.6401	.7116			
15	.4374	.6722	.6882			
16	.4374	.6722	.7042			
17	.4374	.6478	.6958			
18	.4321	.5898	.6483			
24				.4915	.4424	.3277
Max	.4374	.6722	.7449	.5344	.5506	.4111
Min	.1054	.5441	.6483	.4801	.4096	.3125
Avg	.2865	.6188	.6982	.4922	.4509	.3372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV MAHALAXMI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0111	.3982	1.0498	.4755	1.0387	.0244
2	.0114	.3982	1.0498	.4805	1.0387	.0244
3	.0114	.3982	1.0498	.4755	1.0387	.0244
4	.0111	.3982	1.0498	.4755	1.0498	.0244
5	.0114	.3982	1.0498	.4755	1.0498	.0244
6	.0114	1.0425	1.0498	1.0566	1.0498	.0244
7	.6447	1.0242	1.0387	1.0566	1.0498	.0244
8	.6447	1.0608	1.0745	1.0924	1.0498	.0244
9	.6447	1.0608	1.0745	1.0566	1.086	.0244
10	.6516	1.0631	1.0985	1.0631	1.086	.0297
11	.009	1.0631	1.1104	1.0924	1.086	.0297
12	.0179	1.0631	1.1104	1.0924	1.086	.0362
13	.0175	1.0631	1.1104	1.0745	1.086	.0438
14	.0179	1.0631	1.0745	1.0745	.0488	.0419
15	.0179	1.0631	1.0566	1.0745	.0488	.0297
16	.0351	1.0631	1.0277	1.0566	.0488	.0236
Max	.6516	1.0631	1.1104	1.0924	1.086	.0438
Min	.009	.3982	1.0277	.4755	.0488	.0236
Avg	.1731	.8513	1.0672	.8858	.8713	.0284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV YASHWANT AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378			.6468	.394	.4252
2	.2481			.6535	.394	.4252
3	.2534			.6722	.394	.4252
4	.2534			.7095	.394	.4252
5	.2534			.7392	.394	.4252
6	.2534			.8402	.6268	.5731
7	.3174			.8962	.7522	.5373
8	.6036			.9709	.8326	.5373
9	.8029				.8688	.6447
10	.905					
11	1.1222	1.5364	1.5746			
12		1.5364	1.4299			
13	1.086	1.6289	1.4327			
14	1.0974	1.6289	1.576			
15		1.6289	1.5927			
16	1.0608	1.4842	1.379			
17	1.0242	1.267	1.3253			
18	.9671	1.2071	1.2357			
24				.6468	.394	.4252
Max	1.1222	1.6289	1.5927	.9709	.8688	.6447
Min	.2378	1.2071	1.2357	.6468	.394	.4252
Avg	.6554	1.4897	1.4432	.7528	.5444	.4844



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV ASHTA PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0709	.0709	.0701	.0701		.0709
2		.0709	.0709	.0709	.0701	.0709	.0709
3	.0709	.0709	.0724	.0709	.0701	.0709	.0709
4	.0709	.0709	.0709		.0701	.0709	.0709
5	.0709	.0709	.0709		.0701	.0709	.0716
6	.0709	.0709	.0709	.0709	.0701	.0709	.0716
7	.0701	.0709	.0709	.0709	.0701	.0709	.0716
8	.0701	.0709	.0709	.0709	.0701	.0701	.0716
9	.0701	.0709	.0709	.0709	.0701	.0709	.0709
10	.0709	.0709	.0701	.0709	.0693	.0709	.0701
11	.0701	.0709	.0709	.0709	.0701	.0709	.0701
12	.0701	.0709	.0716	.0709	.0701	.0709	.0701
13	.0701	.0709	.0709	.0709	.0701	.0709	.0701
14	.0701	.0709	.0709	.0709	.0701	.0709	.0701
15	.0701	.0709	.0709	.0709	.0701	.0709	.0709
16	.0701	.0709	.0701	.0709	.0701	.0709	.0693
17	.0701	.0709	.0701	.0709	.0701	.0709	.0701
18	.0709	.0709	.0701	.0709	.0693	.0709	.0701
19	.0709	.0709	.0701	.0709	.0693	.0709	.0701
20	.0709	.0701	.0693	.0709	.0693	.0709	.0701
21	.0709	.0701	.0693	.0709	.0709	.0709	.0709
22	.0709	.0701	.0686	.0701	.0709	.0709	.0709
23	.0709		.0693	.0709	.0709	.0709	.0701
24	.0701	.0709	.0709	.0701	.0709	.0709	.0709
Max	.0709	.0709	.0724	.0709	.0709	.0709	.0716
Min	.0701	.0701	.0686	.0701	.0693	.0701	.0693
Avg	.0705	.0708	.0705	.0708	.0701	.0709	.0706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV TRYAMBKESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0055	.0069	.0063	.0059	.0057	.1463
2	.0055	.0069	.0063	.0061	.0057	.1463
3	.0057	.0072	.0063	.0061	.0057	.1463
4	.0061	.0072	.0063	.0063	.0057	.1463
5	.0059	.0072	.0063	.0057	.0057	.1463
6	.0061	.0072	.0063	.0057	.0057	.1463
7	.0934	.0934	.112	.0059	.0057	.1463
8	.112	.0934	.1109	.1791	.0934	.1646
9	.1478	.1595	.1463	.1791	.128	.1646
10	.128	.1772	.1463	.1791	.1463	.1463
11	.128	.1772	.1791	.1791	.1463	.1463
12	.128	.1772	.1791	.1791	.1463	.1463
13	.128	.1772	.1791	.1791	.1463	.1463
14	.128	.1772	.1791	.1791	.1463	.1463
15	.128	.1772	.1791	.1791	.1463	.1463
16	.128	.1772	.1791	.1791	.1463	.1433
Max	.1478	.1772	.1791	.1791	.1463	.1646
Min	.0055	.0069	.0063	.0057	.0057	.1433
Avg	.0803	.1018	.1017	.1034	.0803	.1484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0895	.2012	.3052	.2321	.2743
2	.0905	.0895	.2012	.3052	.2321	.2743
3	.0895	.0895	.2012	.3018	.2321	.2743
4	.0895	.0895	.2012	.3018	.2321	.2743
5	.0905	.0905	.2012	.3018	.2321	.2743
6	.0895	.0905	.2012	.3149	.2652	.2743
7	.0867	.0724	.1966	.3315	.4359	.2743
8	.298	.3563	.3277	.4024	.6478	.4115
9	.298	.3563	.3277	.4191	.6478	.6036
10	.426	.3277	.4144	.5898	.6554	.2035
11	.2984	.3605	.4359	.6796	.6554	.2035
12	.2949	.3605	.4144	.6874	.6554	.2035
13	.2949	.3605	.4144	.788		.2012
14	.2949	.3605	.4096	.7293	.6554	.2012
15	.2984	.3605	.3932	.6718	.663	.2035
16		.3605	.3887	.6718	.5967	.2012
Max	.426	.3605	.4359	.788	.663	.6036
Min	.0867	.0724	.1966	.3018	.2321	.2012
Avg	.2086	.2384	.3081	.4876	.4692	.2721

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV BAGNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.7499	.5441	.8215	.0503	.056	.0554
2	.0549	.7682	.5441	.8122	.0503	.0554	.0543
3	.0549	.7682	.506	.8029	.0503	.0554	.0543
4	.0549	.7682	.5281	.8029	.0503	.056	.0543
5	.0549	.7811	.5668	.8122	.0509	.0554	.0543
6	.0732	.7907	.6226	.8215	.0678	.0739	.0732
7	.0716	.7968	.664	1.0852	.0716	.0739	.0732
8	.0701	.8065		1.3889	.0537	.056	.0554
9	.0537	.8592	.1865	2.0271	.0543	.0732	.0503
10	.0543	.8905	.0351	.0671	.0549	.0549	.0914
11	.0549	.8905	.0354	2.0271	1.5746	1.6004	.9054
12		.0532	.0709	2.2986	1.7741	1.6324	.6767
13	.0554	.0497	.0537	2.3529	1.7558	1.6385	.6979
14	.056	.0486	.0532	2.4072	1.8111	1.6244	.6979
15	.0554	.0497	.0537	2.3167	1.829	1.5581	.679
16	.0549	.0497	.0709	2.3167	1.8473	1.3272	.679
17	.0739	.0497	.0537	2.1176	1.8298	1.3108	.6224
18	.0739	.0497	.0543	1.9728	1.6632	1.2266	.5914
19	.0747	.0678	.0366	.0526	.056	.0543	.0503
20	.0739	.0701	.0537	.0532	.056	.0549	.0543
21	.0739	.0724	.0537	.0554	.0739	.0549	.0732
22	.0747	.0724	.0709	.0543	.0739	.0554	.0732
23	.0554	.0732	.0526	.0537	.0747	.0554	.0543
24	.0537	.0554	.5344	.8122	.0537	.0554	.055
Max	.0747	.8905	.664	2.4072	1.8473	1.6385	.9054
Min	.0537	.0486	.0351	.0526	.0503	.0543	.0503
Avg	.0621	.4013	.2367	1.1805	.6261	.5358	.2719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV ASHTA CHADOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.4858	.3201	.4207	.0566	.0554	.0549
2	.0566	.4858	.3048	.4252	.0566	.056	.0549
3	.0566	.4915	.2896	.4207	.0566	.0739	.0543
4	.0566	.5243	.2932	.4115	.0754	.0739	.0543
5	.0943	.5304	.3086	.4115	.0943	.1109	.0549
6	.132	.5636	.3658	.5028	.1132	.1294	.0914
7	.1132	.5571	.4938	.6135	.1132	.1307	.1097
8	.0943	.6133	.5468	.7442	.0754	.1097	.0943
9	.0754	.583	.6325	.7811	.0739		.1132
10	.0747	.5761	.0514	.0566	.0739		.0754
11	.0554	.0554	.0351	.8749	.7545	.6562	.4725
12	.0739	.0732	.0709	.9374	.7625	.6874	.431
13	.0747	.0549	.0709	.9842	.788	.6562	.4115
14	.037	.0549	.0701	.9646	.7293	.6325	.4115
15	.056	.0549	.0709	.9488	.6478	.6478	.3567
16	.0554	.0549	.0709	.9374	.6154	.6584	.3864
17	.056	.0554	.0709	.7811	.5967	.7018	.3715
18	.0554	.0549	.0895	.7011	.5182	.6882	.3763
19	.0549	.0543	.0724		.0732	.0739	.0566
20	.0739	.0724	.1097	.0943	.0739	.0914	.0754
21	.0924	.0543	.1075	.0943	.0747	.0914	.0754
22	.0934	.0543	.0886	.0754	.0739	.0914	.0754
23	.0747	.0549	.0709	.0566	.0554	.037	.056
24	.0566	.0566	.36	.4115	.0566	.056	.0739
Max	.132	.6133	.6325	.9842	.788	.7018	.4725
Min	.037	.0543	.0351	.0566	.0554	.037	.0543
Avg	.0717	.2590	.2069	.5500	.2754	.2959	.1828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.037	.0373	.0351	1.094	1.1191	.6882
2	.3277	.037	.0373	.0347	1.094	1.1191	.6882
3	.3277	.0373	.0373	.0351	1.094	1.073	.6914
4	.3277	.037	.0373	.0354	1.094	1.094	.6882
5	.3605	.0554	.0373	.0351	1.094	1.0814	.6882
6	.426	.0554	.0554	.0532	1.1603	1.094	.6964
7	.5121	.0739	.0554	.0526	1.4089	1.1469	.7042
8	.7293	.056	.0549	.0514	1.4918	1.1984	.7907
9	.8259	.0373	.0366	.0343	1.4419	1.3108	.8097
10	1.0277	.0351	.0366	.0312	.0373	.037	.0377
11	1.1142	1.4586	1.893	.0354	.037	.0377	.0377
12		1.5074	1.8781	.0347	.0747	.0377	.0377
13	.3978	1.5074	1.9982	.0343		.037	.0358
14	1.1797	1.5249	2.0199	.0351	.056	.0373	.0343
15	1.1934	1.4746	1.9982	.0335	.0554	.037	.0332
16	1.1822	1.4746	1.8781	.0354	.056	.0374	.0335
17	1.1523	1.4582	1.8804	.0366	.0554	.0373	.0343
18	1.1633	1.4752	1.7364	.0366	.056	.0373	.0351
19	.0554	.0526	.0354	.0373	.0554	.0373	.0335
20	.0366	.0532	.0358	.0373	.056	.0377	.0335
21	.0366	.037	.0358	.0373	.0554	.0377	.0358
22	.037	.037	.0358	.0373	.037	.0373	.0362
23	.037	.0373	.0358	.0373	.0373	.0373	.0354
24	.0377	.037	.037	.0354	1.0814	1.1065	.703
Max	1.1934	1.5249	2.0199	.0532	1.4918	1.3108	.8097
Min	.0366	.0351	.0354	.0312	.037	.037	.0332
Avg	.5572	.5249	.6635	.0376	.5532	.4944	.3184

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 204 / SWARAJYA AGRO INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1478	.1109	.1463	.1886	.112	.056
2	.1886	.1109	.1109	.1448	.1886	.1109	.0554
3	.1886	.112	.1307	.1433	.1886	.1478	.037
4	.1886	.1109	.1307	.1646	.1886	.1494	.0366
5	.1886	.1109	.168	.1829	.1886	.1478	.0554
6	.2218	.0747	.1698	.1463	.1848	.1663	.0373
7	.2195	.0554	.1478	.1086	.2195	.1867	.0377
8	.2328		.1478	.1075	.1612	.2241	.0739
9	.1109		.1463	.1829	.1848	.1509	.1097
10	.1494		.1254	.181	.0924	.1509	.1097
11	.1478		.181	.1791	.1494	.1307	.1433
12	.112		.1646	.1254	.1848	.1307	.1772
13	.0739		.1448	.0366	.2241	.1109	.1791
14	.0373		.1075		.1848	.0934	.181
15	.1109		.1075	.1478	.1829	.0943	.1829
16	.1494		.1791		.1848	.1494	.1478
17	.1463		.197		.1848	.1478	.1478
18	.1294	.0366	.1772		.1848	.1109	.1663
19	.1307	.0732	.1075		.1848	.0549	.2241
20	.1478	.0739	.1075	.1294	.1494	.0554	.1867
21	.1663	.1294	.1612	.2241	.1109	.0554	.1886
22	.1494	.1294	.2195	.1867	.0747	.0747	.1886
23	.1478	.128	.0914	.1886	.1132	.0747	.1132
24	.132	.1509	.168	.1867	.1886	.1132	.0566
Max	.2328	.1509	.2195	.2241	.2241	.2241	.2241
Min	.0373	.0366	.0914	.0366	.0747	.0549	.0366
Avg	.1524	.1031	.1459	.1533	.1703	.1226	.1205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2957	.2801	.3109	.2641	.2957	.2587
2	.3018	.2957	.2614	.3142	.2641	.2957	.2587
3	.3018	.2926	.2452	.3142	.2641	.2614	.2353
4	.3018	.2561	.2641	.3109	.2641	.2587	.2353
5	.3395	.2957	.2829	.3142	.2641	.2957	.2534
6	.3772	.3326	.3584	.3292	.3018	.3292	.3142
7	.3734	.3511	.3547	.3658	.3395	.3326	.3475
8	.3109	.2743	.3326	.3326	.2987	.2987	.3109
9	.2772	.2926	.2926	.3142	.2772	.2801	.2801
10	.2801	.2926	.3292	.2686	.2427	.2772	.2772
11	.2772	.2896	.3292	.2561	.1848	.2772	.2772
12	.2587	.3077	.3189	.2896		.2743	.2353
13	.2614		.3224	.2587		.2587	.2378
14	.2218	.2926	.3224	.2987	.2241	.2743	.2378
15	.2241	.2587	.3224	.2614	.2218	.2587	.2353
16	.2402	.2402	.2896	.2241	.2427	.2801	.2561
17	.2614	.3109	.3109	.2896	.2587	.2957	.2481
18	.2772	.3326	.3475	.3045	.3361	.3326	.2926
19	.3292	.3292	.3511	.3511	.3696	.333	.3326
20	.3696	.4252	.3841	.4668	.4108	.3658	.4108
21	.3696	.4207	.4251	.3772	.3696	.4024	.3961
22		.3658	.3898	.3584	.3881	.3696	.3772
23	.3326	.3292	.3403	.3206	.3361	.3326	.3206
24	.3018	.2957	.3206	.3109	.2641	.2957	.2926
Max	.3772	.4252	.4251	.4668	.4108	.4024	.4108
Min	.2218	.2402	.2452	.2241	.1848	.2587	.2353
Avg	.2996	.3120	.3240	.3143	.2903	.3032	.2884



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	1.1439	.7291	.9602	.1132	.0754	.1132
2	.1307	1.189		.9783	.0943	.0754	.1132
3	.132	1.1288	.78	1.0084	.0943	.0754	.132
4	.132	1.0974	.7122	1.0517	.1132	.0943	.1307
5	.1494	1.2041	.7291	1.1431	.1494	.112	.1307
6	.1698	1.2803	1.2378	1.2041	.2054	.1494	.1478
7	.1886	1.4022	1.3226	1.3426	.2427	.168	.1829
8	.1509	1.448	1.6617	1.5432	.2033	.1478	.1867
9		1.4352	1.5699	1.7223		.1494	.1109
10		1.4352	.1086	.1463		.1494	.1097
11		.112	.1267	1.8747		1.6288	.9783
12		.0934	.1097	1.9685		1.6248	1.0686
13		.0934	.1086	1.8976		1.6204	.9934
14		.0934	.1097	1.866		1.6004	1.0364
15		.0934	.1086	1.9292		1.6156	1.0669
16		.0934	.1294	2.0241	1.6385	1.0822	1.0212
17	.1086		.1294	1.8747	1.3441	1.3413	.9808
18	.1448		.1478	1.8435	1.2967	1.2955	.9783
19	.1463		.1478	.1509	.1646	.1478	.128
20	.1294		.1478	.1509	.1494	.1463	.132
21	.1494		.132	.1509	.1494	.1307	.132
22	.1307		.1132	.132	.1307	.1307	.1132
23	.1132		.1132	.1132	.0943	.112	.0943
24	.0943	.0943	1.153	.9332	.1132	.0754	.0943
Max	.1886	1.448	1.6617	2.0241	1.6385	1.6288	1.0686
Min	.0943	.0934	.1086	.1132	.0943	.0754	.0943
Avg	.1364	.7904	.5056	1.1671	.3704	.5729	.4240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.0772	.1581	.0983	1.2809	1.1544	.8482
2	.787	.0772	.1581	.0983	1.2334	1.1069	.8025
3	.8025	.0772	.1423	.1147	1.2018	1.0753	.828
4	.8179	.0926	.0949	.1147	1.2492	1.1385	.8381
5	.8179	.108	.0949	.1147	1.3283	1.2809	.8488
6	.8179	.1235	.0949	.1311	1.6288	1.4864	
7	.8333	.1543	.1107	.1638	1.8027		
8	1.0031	.1235	.1107	.1638	1.8818	1.7236	
9		.108	.1107	.1147		1.7869	
10		.0949	.0949	.0949		.096	
11		1.3441	1.9559	.0791		.064	.1898
12		1.4548	2.1548	.0791		.064	.1739
13		1.7394	2.4034	.0633		.08	.1265
14		1.7711	.0926	.0633		.064	.0949
15		1.7553	1.9725	.0633		.064	.0791
16		1.3599	2.3703	.0633	.0949	.048	.0949
17	1.3889		2.1548	.0633	.0949	.08	.0949
18	1.2346		2.0222	.0633	.0949	.112	.1107
19	.0926		.0995	.0949	.1107	.112	.1107
20	.0926		.116	.0949	.1107	.128	.1107
21	.108		.1147	.0949	.1265	.112	.1107
22	.108		.0983	.0949	.1265	.112	.0949
23	.0926		.0983	.0949	.1107	.096	.0949
24	.096	.0772	.1739	.0819	1.0437	.9804	.8322
Max	1.3889	1.7711	2.4034	.1638	1.8818	1.7869	.8488
Min	.0926	.0772	.0926	.0633	.0949	.048	.0791
Avg	.6165	.6199	.7082	.0960	.7953	.5637	.3413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV ASHTA GAOTHAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5373	.6984	.591	.6089	.5014	.5194
2	.5552	.5014	.6447	.6268	.6089	.4835	.5014
3	.5373	.4656	.591	.6268	.5552	.4477	.5194
4	.5373	.5014	.6089	.6089	.5731	.5194	.5194
5	.5731	.5731	.6984	.591	.6626	.6089	.5373
6	.6268	.6805	.7522	.5731	.7522	.7164	.5731
7	.8059	.7701	.8238	.8417	.8596	.8417	.8238
8	.7701	.7701	.8417	.8775	.8775	.8775	.788
9		.8059	.8417	.8775		.9313	.8238
10		.8059	.9313	.8059		.985	.7164
11		.8596	.7522	.9313		.9492	.7164
12		.8059	.7164	.9671		.9492	.7522
13		.7522	.6984	.9313		.9313	.6805
14		.7522	.6268	.9313		.8954	.6805
15		.7164	.8238	.9492		.7522	.6984
16		.7164	.8596	.9492	.5194	.8059	.788
17	.8059		.7522	.9313	.7522	.6805	.8596
18	.7522		.6984	.8238	.7164	.7522	.7522
19	.9671		.8059	.9313	.7701	.8954	.8417
20	1.0029		.9313	.985	.8417	.9671	.8954
21	.9313		.9391	.8596	.788	.8417	.8238
22	.8417		.7087	.7343	.7164	.8059	.7343
23	.7164		.6733	.6626	.6089	.6268	.6089
24	.5194	.5552	.7522	.5731	.6268	.5014	.5194
Max	1.0029	.8596	.9391	.985	.8775	.985	.8954
Min	.5194	.4656	.591	.5731	.5194	.4477	.5014
Avg	.7175	.6805	.7571	.7992	.6963	.7611	.6947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2263		.1886	.1698	.1886	.1698
2	.2241	.2263		.1848	.1698	.1886	.1509
3	.2427	.2075		.2054	.1698	.1698	.1509
4	.2587	.2241		.2241	.2054	.1886	.1698
5	.2743	.2614		.2218	.2614	.2427	.1867
6	.3326	.2957		.3142	.3142	.3174	.2402
7	.4066	.3292		.3658	.3841	.3696	.3696
8	.2957	.2534		.3109	.3292	.3142	.3142
9		.2353	.2427	.2012		.2402	.2743
10		.1663	.1867	.1886		.2012	.1829
11		.1663	.1494	.1402		.1433	.1772
12		.1663	.1494	.1402		.1433	.1772
13		.1867	.1494	.1612		.1433	.1578
14		.1867	.1478	.1612		.1448	.1052
15		.1867	.1663	.1433		.1448	.104
16		.112	.1663	.1402	.1829	.1267	.1387
17	.1214		.1663	.1753	.2103	.1448	.1387
18	.1772		.1848	.1907	.2035	.181	.208
19	.2353		.2218	.2402	.2353	.2378	.2353
20	.2378		.2587	.2587	.2772	.2772	.2587
21	.2772		.2641	.2427	.2987	.2587	.2614
22			.2452	.2241	.2427	.2218	.2241
23	.2427		.2075	.1886	.2263	.1867	.2075
24	.2075	.2452	.1867	.1886	.1886	.2075	.1698
Max	.4066	.3292	.2641	.3658	.3841	.3696	.3696
Min	.1214	.112	.1478	.1402	.1698	.1267	.104
Avg	.2504	.2162	.1933	.2084	.2394	.2076	.1989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV BAWACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.9633		.7926	.1509	.1132	.132
2	.1478	1.0235		.8383	.132	.1132	.1509
3	.1478	.9482		.8535	.132	.0943	.1494
4	.1478	.9297		.884	.132	.0943	.1494
5	.168	1.0059		.9145	.1494	.112	.132
6	.1663	1.0822		.9907	.1867	.1494	.1698
7	.1848	1.2041		1.0669	.2033	.168	.1663
8	.1294	1.358		1.2651	.1829	.1663	.1663
9		1.2963	1.2193	1.4022		.1463	.1646
10		1.2498	.12	.1227		.1307	.128
11		.112	.12	1.4373		1.5278	1.1589
12		.0934	.124	1.4327		1.5394	1.2191
13		.0934	.1227	1.7185		1.5699	1.174
14		.0934	.124	1.5935		1.5242	1.1443
15		.0934	.1448	1.6248		1.5089	1.1443
16		.0934	.1267	1.5741	1.5238	1.5242	1.1003
17	.1463		.1267	1.6766	1.3847	1.4327	1.1145
18	.1463		.1448	1.1888	1.2763	1.3717	.9659
19	.168		.1448	.1494	.1463	.1463	.1463
20	.168		.1629	.1867	.1494	.1478	.168
21	.168		.1494	.1867	.1494	.1478	.168
22	.1509		.1307	.1698	.1307	.1478	.1509
23	.132		.1294	.1509	.132	.1307	.132
24	.112	.132	.7042	.7621	.1509	.1132	.1132
Max	.1848	1.358	1.2193	1.7185	1.5238	1.5699	1.2191
Min	.112	.0934	.12	.1227	.1307	.0943	.1132
Avg	.1509	.6925	.2372	.9576	.3713	.5883	.4754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.5175		.5729	.4755	.4938	.499
2	.5359	.4805		.5729	.4207	.4572	.4805
3	.5544	.462		.5544	.3841	.4207	.4755
4	.5544	.4435		.5544	.4207	.439	.4755
5	.5544	.4805		.5914	.5121	.5121	.4805
6	.5729	.5359		.6099	.5853	.567	.5175
7	.6283	.5544		.6468	.695	.6584	.5359
8	.5914	.5359		.6653	.7682	.7499	.5914
9		.5914	.5658	.7207		.7316	.6653
10		.2561	.7095	.6584		.7316	.6653
11		.6584	.7095	.695		.7577	.7023
12		.695	.7023	.7133		.7392	.6653
13		.6584	.695	.695		.7023	.5729
14		.6584	.695	.695		.5914	.4435
15		.6584	.6401	.6584		.5359	.4805
16		.5121	.6468	.6401		.5544	.5359
17	.5729		.6653	.6767	.6584	.5359	.5359
18	.6468		.6838	.695	.6584	.5175	.7023
19	.7023		.6099	.7316	.7316	.5544	.7762
20	.7392		.6401	.7133	.7865	.6099	.9055
21	.7947		.6099	.6584	.823	.6099	.8501
22	.6653		.5914	.6036	.7133	.5544	.7577
23	.5914		.5914	.5487	.567	.499	.7023
24	.5175	.5175	.8413	.5544	.5121	.5121	.4805
Max	.7947	.695	.8413	.7316	.823	.7577	.9055
Min	.5175	.2561	.5658	.5487	.3841	.4207	.4435
Avg	.6099	.5421	.6623	.6427	.6070	.5848	.6041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.3018	.3584	.2987	.2987	.2641
2	.2829	.2801	.2987	.3395	.2987	.2957	.2641
3	.2829	.2801	.2987	.3395	.2987	.2957	.2641
4	.3018	.3395	.3326	.3395	.3395	.3174	.2641
5	.3395	.415	.4066	.3772	.415	.3734	.3206
6	.5601	.5601	.5228	.5281	.5658	.4435	.6036
7	.6283	.5228	.5914	.5914	.4668	.5729	.6722
8	.5121	.4298	.5068	.4887	.3734	.5068	.5359
9	.4298	.4031	.4961	.4031	.394	.4075	.4435
10	.4207	.3856	.3944	.3988	.3121	.4031	
11	.3814	.3561	.4115	.3467	.2481	.3641	.2303
12	.3258	.3086	.3681	.3086	.2172	.2947	.1715
13	.2915	.3086	.3366	.298	.2172	.2947	.3155
14	.3012	.2601	.3439	.2865	.1829	.3012	.333
15	.3012	.2743	.3841	.2835	.2012	.2658	.2804
16	.2658	.3121	.362	.3012	.2353	.298	.3012
17	.3086	.3429	.3681	.3189	.2835	.3086	.3544
18	.3391	.3601	.3681	.3506	.3189	.333	.3721
19	.4344	.4706	.4163	.4805	.4344	.543	.543
20	.499	.5544	.5415	.5544	.5175	.5792	.6036
21	.4435	.5041	.5228	.5228	.5041	.5228	.5041
22	.4108	.4715	.5228	.4715	.4527	.4338	.4527
23	.3584	.3395	.415	.3772	.3584	.3206	.3772
24	.3206	.3206	.3206	.3584	.3206	.3206	.2829
Max	.6283	.5601	.5914	.5914	.5658	.5792	.6722
Min	.2658	.2601	.2987	.2835	.1829	.2658	.1715
Avg	.3767	.3792	.4096	.3926	.3439	.3790	.3806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG  
(Koregaon) Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.1109	.1086	.0905	1.0753	.7811	.5792
2	.3048	.1109	.1097	.0914	1.0753	.7407	.5792
3	.3161	.112	.0914	.0914	1.1248	.7316	.5647
4	.3121	.1307	.0905	.0914	1.1248	.7621	.5647
5	.3161	.1307	.1097	.0914	1.1728	.8333	.5796
6	.4218	.1509	.1294	.128	1.2654	.8951	.6249
7	.6722	.1494	.1478	.128	1.5623	1.0364	.6539
8	.788	.1463	.1646	.1478	1.6091	1.0974	.6773
9	.7827	.1267	.1417	.1463	1.531	1.1111	.6687
10	.8796	.1402	.1372	.1478	.1147	.1052	.081
11	.9755	1.2342	1.8122	.128	.0671	.104	.0848
12	1.0105	1.3717	1.945	.1254	.104	.104	.0617
13	.9682	1.4449	1.9685	.1097	.1017	.1006	.0663
14	.9829	1.4175	2.0241	.112	.1017	.1017	.0838
15	.9659	1.4327	2.0557	.112	.104	.0819	.0819
16	.9659	1.4784	1.8343	.1307	.1075	.0995	.0648
17	.9511	1.4022	1.6975	.1463	.1267	.0983	.0686
18	.9242	1.2654	1.7029	.1829	.1214	.096	.0867
19	.1086	.1086	.1063	.1663	.1433	.1086	.1267
20	.1097	.1254	.1463	.1478	.1448	.128	.128
21	.1097	.128	.1417	.1307	.4938	.1294	.1097
22	.1109	.1294	.1254	.1307	.1097	.1097	.0914
23		.1052	.1086	.1307	.1075	.1097	.0857
24	.1086	.1097	.1075	.1086	1.0437	.7716	.6019
Max	1.0105	1.4784	2.0557	.1829	1.6091	1.1111	.6773
Min	.1086	.1052	.0905	.0905	.0671	.0819	.0617
Avg	.5818	.5443	.7086	.1257	.6055	.4265	.3048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.036	.381	.4054	.7225	.0452	.0366	.032
2	.024	.381	.3864	.7407	.0452	.0377	.032
3	.0244	.4321	.3913	.7407	.0446	.0377	.0309
4	.0244	.4321	.4161	.7621	.0594	.0383	.0297
5	.0377	.463	.4877	.828	.0587	.0343	.0309
6	.0492	.5247	.5639	.9842	.0724	.0526	.036
7	.0695	.6401	.7526	1.2346	.0705		.0572
8	.0429	.8173	.8535	1.5181	.0541	.0389	.0533
9	.0442	.7727	.9031	1.7869	.0526	.0314	.0297
10		.743	.0351	.0472	.0467	.0303	
11	.0419	.032	.0366	2.0557	1.7869	1.5813	.8592
12	.0373	.029	.0286	2.0715	1.8138	1.6248	.7375
13	.0381	.0389	.0389	2.1605	1.7869	1.5123	.7225
14	.0312	.0328	.048	2.2186	1.8027	1.5813	.6773
15	.0381	.0335	.0503	2.1605	1.8084	1.5623	.6308
16	.0391	.032	.0442	2.0805	1.7869	1.3735	.6401
17	.0333	.0335	.029	1.9766	1.7444	1.2803	.5792
18	.0276	.0518	.0303	1.8976	1.5741	1.2963	.5487
19	.0747	.0457	.0377	.0452	.0495	.0343	.0372
20	.0566	.0396	.0354	.0602	.0429	.036	.0372
21	.0412	.032	.0457	.0602	.0349	.0372	.0389
22	.036	.0314	.0419	.0602	.0303	.0337	.0406
23	.032	.04	.0377	.0452	.0291	.0343	.0343
24	.0309	.0326	.3841	.7316	.0452	.0354	.0332
Max	.0747	.8173	.9031	2.2186	1.8138	1.6248	.8592
Min	.024	.029	.0286	.0452	.0291	.0303	.0297
Avg	.0396	.2538	.2535	1.1245	.6202	.5374	.2586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1181
Max	.1181
Min	.1181
Avg	.1181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 401 / 33 KV MARDWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV ASHTA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.8002
Max	.8002
Min	.8002
Avg	.8002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV KASBE DIGRAJ  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.743
Max	.743
Min	.743
Avg	.743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV NAGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.4001
Max	.4001
Min	.4001
Avg	.4001



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV KOREGAON

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUL-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV KASTURI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.1203	.9979	1.0974	1.4937	1.267	1.0349
2	1.0829	1.1203	.9979	1.0974	1.4937	1.2936	1.0082
3	1.0829	1.0829	.9979	1.0608	1.4563	1.307	1.0082
4	1.1088	1.0719	.9979	1.0608	1.4563	1.2567	.9979
5	1.1458	1.1203	1.0349	1.0974	1.2197	1.2323	1.0082
6	1.2803	1.2936	1.1203	1.2197	1.2696	1.2567	1.2323
7	1.4784	1.4266	1.419	1.5524	1.4937	1.5364	1.5893
8	1.5154	1.4266	1.5089	1.5123	1.5154	1.5364	1.5524
9	1.419	1.419	1.5123	1.4937	1.419	1.419	1.5123
10	1.8111	1.7013	1.7558	1.7558	1.6095	2.0995	1.6827
11	1.5893	1.5364	1.5364	1.4632	1.1827	1.4415	1.3535
12	1.4415	1.4632	1.5154	1.4815	1.1088	1.3535	1.3352
13	1.5339	1.4415	1.3676	1.4784	1.1088	1.2437	1.2936
14	1.4784	1.3535	1.2803	1.423	1.1088	1.2197	1.2197
15	1.3676	1.4045	1.3443	1.3676	1.1088	1.1827	1.2382
16	1.3717	1.2851	1.3306	1.2567	1.1088	1.134	1.2197
17	1.39	1.3306	1.4784	1.3443	1.1088	1.2803	1.2936
18	1.5524	1.4632	1.5154	1.5524	1.1827	1.39	1.5893
19	1.7177	1.5729	1.7741	1.7741	1.5524	1.7741	1.7741
20	1.7558	1.5364	1.7193	1.7193	1.7372	1.8111	1.7741
21	1.6263	1.5364	1.6827	1.6095	1.5893	1.6804	1.5364
22	1.531	1.4415	1.5524	1.4784	1.5154	1.4937	1.3676
23	1.3443	1.2936	1.419	1.2803	1.3676	1.2696	1.1827
24	1.1088	1.1576	1.1088	1.1827	1.5893	1.307	1.0719
Max	1.8111	1.7013	1.7741	1.7741	1.7372	2.0995	1.7741
Min	1.0719	1.0719	.9979	1.0608	1.1088	1.134	.9979
Avg	1.4086	1.3583	1.3736	1.3900	1.3665	1.4077	1.3282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.4656	.0762	.2724	.0358	.4298
2	.4607	.4607	.0762	.3772	.0362	.4298
3	.4607	.4607	.0762	.3429	.0362	.4252
4	.4557	.4656	.0762	.3429	.0358	.4252
5	.4557	.4706	.0953	.4207	.0362	.4252
6	.4557	.5014	.0953	.4656	.0366	.4656
7	.8871	.815	.0823	.8326	.0362	.4344
8	.9145	.8859	.0789	.9054	.0724	1.2323
9	.9619	.9431	.0412	1.1949	.1214	1.1016
10	.9431	.9431	.2846	1.2936	.743	1.1203
11	.9054	.9242	.2881	1.2936	.8676	1.0829
12	.7922		.8676	1.2936	1.2936	1.0829
13	.7922	.6478	.8676	1.3306	.8865	1.0829
14	.8299	.2743	.8676	1.3306	.8676	1.0829
15	.811	.2812	.8676	1.3306	.8589	1.0829
16	.3395	.3395	.1543	.3277	.0945	.1296
Max	.9619	.9431	.8676	1.3306	1.2936	1.2323
Min	.3395	.2743	.0412	.2724	.0358	.1296
Avg	.6829	.5919	.3060	.8347	.3787	.7521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1494	.1509	.1478	.1478	.1494	.112
2	.1448	.1478	.1494	.1478	.1478	.1494	.112
3	.1448	.1109	.1494	.1494	.1494	.1494	.1109
4	.1463	.1494	.1494	.1494	.1494	.1478	.1109
5	.1463	.1478	.1494	.1478	.1494	.1478	.1478
6	.1848	.2241	.1494	.1848	.1848	.1867	.2241
7	.2195	.1867	.1867	.2218	.2241	.2218	.2587
8	.2587	.1829	.2241	.2218	.2218	.2218	.2587
9	.1478	.1463	.1829	.1829	.2033	.1829	.2241
10	.1478	.1433	.181	.1772	.1448	.1254	.1448
11	.1478	.1402	.1433	.1417	.1075	.1254	.124
12	.1063	.1402	.1402	.1372	.1075	.1052	.1109
13	.1052	.1417	.1448	.1063	.1052	.1075	.0876
14	.1086	.0886	.1463	.0701	.0905	.1052	.1052
15	.1086	.0886	.1478	.1097	.0905	.1063	.1075
16	.1448	.1097	.1448	.1075	.0732	.1063	.1052
17	.128	.1578	.181	.1463	.1848	.1086	.1075
18	.1294	.1629	.1463	.1463	.1478	.1448	.1433
19	.1867	.1448	.1829	.1848	.1463	.1829	.1829
20	.2195	.181	.2195	.1829	.1848	.2195	.2195
21	.2218	.2172	.2172	.2218	.1848	.2218	.2218
22	.2218	.1829	.2172	.1829	.1848	.2218	.1848
23	.1663	.1646	.1829	.1478	.1478	.1509	.1478
24	.1463	.1494	.1509	.1463	.1478	.1478	.112
Max	.2587	.2241	.2241	.2218	.2241	.2218	.2587
Min	.1052	.0886	.1402	.0701	.0732	.1052	.0876
Avg	.1595	.1524	.1682	.1568	.1511	.1557	.1527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0594	.1052	.0823	.0373	.0185	.0179	.0187
2	.0602	.1387	.0823	.0373	.0185	.0179	.0187
3	.0602	.1372	.0823	.0377	.0183	.0181	.0189
4	.0594	.1372	.0823	.0377	.0183	.0179	.0189
5	.0572	.1372	.0823	.0377	.0183	.0179	.0189
6	.0892	.1715	.1486	.0373	.037	.0358	.0377
7	.1783	.2427	.2187	.0373	.037	.0358	.0187
8	.2408	.2743	.2591	.0377	.0366	.0362	.0373
9	.2258	.2439	.2229	.037	.0189	.0366	.0189
10	.208	.2408	.0189	.056	.0189	.037	.0185
11	.056	.037	.0185	.3749	.301	.3048	.132
12	.0373	.037	.0185	.3749	.3395	.3353	.1467
13	.056	.037	.0189	.3658	.3658	.3048	.1486
14	.0373	.0189	.0189	.4012	.3311	.3048	.1505
15	.0366	.0191	.0185	.4062	.3353	.2778	.104
16	.0366	.0185	.0187	.3506	.3311	.2778	.1174
17	.037	.037	.0373	.3467	.4161	.2439	.1486
18		.0189	.056	.3506	.3429	.2439	.1486
19	.0362	.0189	.0373	.037	.0351	.0173	.0377
20	.0362	.0189	.0373	.037	.0354	.0185	.0377
21	.0366	.0189	.0373	.0366	.0351	.0373	.0373
22	.0189		.0377	.0185	.0347	.0373	.0373
23	.0705		.0377	.0183	.0347	.0373	.0373
24	.0187	.037	.0705	.0377	.0183	.0358	.0187
Max	.2408	.2743	.2591	.4062	.4161	.3353	.1505
Min	.0187	.0185	.0185	.0183	.0183	.0173	.0185
Avg	.0762	.0975	.0726	.1479	.1332	.1145	.0637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 206 / 11 KV Peth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6622	.823	.7716	.1478	.1734	.1715	.1097
2	.6539	.8383	.7716	.1478	.1715	.1715	.1109
3	.6539	.9602	.7716	.1463	.1715	.1715	.1109
4		.9835	.7716	.1463	.1734	.1734	.1109
5	.6836	1.0174	.8688	.1829	.1734	.1734	.1478
6	.8429	1.166	.9556	.1848	.208	.2058	.2195
7	1.2346	1.989	1.5455	.2172	.2058	.208	.2195
8	1.4998	2.268	1.9753	.2172	.1734	.1734	.2218
9	1.3245	1.6461	1.7901	.1433	.1326	.1402	.1463
10	1.2041	1.5051	.1063	.1402	.0693	.1433	.1433
11	.1052	.1387	.1448	2.1872	1.8663	1.6667	1.3413
12	.1402	.1402	.1433	2.3122	1.7284	1.768	1.4632
13	.1254	.1402	.124	2.3746	1.7459	1.829	1.3077
14	.1463	.1326	.1254	2.2497	1.6255	1.4861	1.3077
15	.1086	.1006	.1433	2.2497	1.6667	1.4861	1.2323
16	.1463	.1357	.1402	2.2222	1.6049	1.4083	1.1431
17	.1478	.1357	.2149	1.7337	1.0059	1.2742	1.2003
18	.1478	.1677	.181	1.5074	1.3717	1.2163	1.0014
19	.1867	.1677	.2195	.1753	.208	.1387	.1772
20	.1867	.1677	.2195	.1753	.1478	.1848	.1829
21	.1848	.1696	.2195	.1772	.1478	.1848	.1848
22	.1478	.1402	.1848	.1734	.1848	.1848	.1494
23	.1402	.1402	.1848	.1715	.1848	.1463	.1494
24	.1463	.1387	1.286	.1463	.1715	.1772	.1097
Max	1.4998	2.268	1.9753	2.3746	1.8663	1.829	1.4632
Min	.1052	.1006	.1063	.1402	.0693	.1387	.1097
Avg	.4704	.6338	.5775	.8137	.6380	.6201	.5205

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 401 / 33KV GANESH NAGAR  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.1845	1.262	2.1148	1.701	1.8296	2.0005
2	2.0576	2.0725	1.9753	2.1148	1.5524	1.7187	2.0005
3	2.1148	2.0165	1.9004	2.1719	1.6461	1.6632	1.9433
4	2.2291	2.0165	1.9753	2.1719	1.7375	1.7364	2.1719
5	2.4006	2.3285	2.1399	2.3434	1.9342	2.1285	2.2291
6	2.6292	2.8532	2.552	2.4577	2.4714	2.6886	1.4289
7	3.1436	3.0727	2.8275	2.1719	2.7166	2.7166	2.6292
8	3.0864	3.1824	3.315	2.1719	2.7435	2.7166	2.7435
9	2.5789	2.7435	2.915	2.1068	2.384	2.4577	2.4977
10	2.7938	2.9081	2.6863	2.3594	2.0302	2.4577	2.4177
11	2.0416	2.1622	2.0576	2.963	1.5912	3.2007	2.524
12	1.9547	1.8296	2.0576	3.0493	.168	3.0864	2.6063
13	1.9753	1.885	2.0576	2.8532	.1698	3.0864	1.7918
14	1.9753	1.8107	2.0005	2.4394	.1698	2.9721	1.773
15	1.9204	1.885	1.8861	2.524	1.1317	2.8006	1.5364
16	1.9753	1.9204	1.9433	2.8829	1.3717	2.8578	1.6632
17	1.9204	1.9404	2.0005	2.8532	2.4143	2.8578	2.552
18	1.9753	2.0302	1.9433	3.1047	2.1399	3.3722	2.7984
19	2.6057	2.5789	2.4006	2.6337	2.6886	2.6863	2.7166
20	3.0807	2.8235	2.9721	2.8778	3.1602	2.9721	2.8532
21	2.8006	2.6337	2.7435	2.5789	2.9384	2.7435	2.6063
22	2.6326	2.5503	2.6292	2.524	2.7166	2.5149	2.4143
23	2.2405	2.073	2.4006	2.2731	2.4646	2.2291	2.1068
24	2.0576	1.9605	1.1946	2.1148	1.885	2.1068	2.0576
Max	3.1436	3.1824	3.315	3.1047	3.1602	3.3722	2.8532
Min	1.9204	1.8107	1.1946	2.1068	.168	1.6632	1.4289
Avg	2.3437	2.3109	2.2432	2.4940	1.9136	2.5667	2.2526



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1317	1.2071	.9808	1.0562	.7545	1.1317
2	1.2071	1.1317	1.2071	.9808	1.0562	.7545	1.1317
3	1.2071	1.1317	1.2071	.9808	1.0562	.7545	1.1317
4	1.2071	1.1317	1.2071	.9808	1.0562	.2075	1.1317
5	1.2071	1.1317	1.0562	.9808	1.1317	.7167	1.1317
6	1.1317	1.2071	1.1694	1.1317	1.2826	.7922	1.1317
7	1.2071	1.2071	1.358	1.1317	.9808	.7167	1.1317
8	1.2449	1.1317	1.0562	1.0562	.9054	.7167	1.2826
9	1.3203	1.5089	1.2449	1.5089	.679	1.0185	1.3203
10	1.358	1.5655	1.5089	1.7353		1.358	1.4712
11	1.358	1.8861	1.5844	2.037		1.4712	1.5089
12	1.358	2.1125	1.5844	1.9616		1.4335	1.2071
13	1.4335	1.5844	1.5089	1.8484		1.5089	1.2071
14	1.4335	1.4335	1.4335	1.7353		1.5466	1.2071
15	1.5089	1.6975	1.5089	1.6975		1.4335	1.5089
16	1.5089	1.7353	1.5089	1.6975		1.5844	1.5089
17	1.5089	1.5844	1.5844	1.5089		1.5466	1.5089
18	1.5089	1.5089	1.4335	1.2071		1.5089	1.358
19	1.2826	1.358	1.2071	1.2826	.6036	1.2826	1.358
20	1.1317	1.1317	1.0517	1.0562	.6413	1.2071	.9808
21	1.1317	1.1694	1.0517	1.0562	.3887	1.1317	.9808
22	1.2826	1.1694	1.1919	1.0562	.7545	1.1317	.9808
23	1.2826	1.3203	1.1919	1.0562	.7545	1.2071	.9808
24	.9808	1.0562	1.2826	1.0562	.9808	.7922	1.1317
Max	1.5089	2.1125	1.5844	2.037	1.2826	1.5844	1.5089
Min	.9808	1.0562	1.0517	.9808	.3887	.2075	.9808
Avg	1.2920	1.3761	1.3061	1.3219	.8885	1.1073	1.2260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1463	.1494	.1463	.1463	.1646	.1463
2	.1463	.1463	.1494	.1463	.1463	.1646	.1463
3	.1463	.1509	.1494	.1463	.1463	.1646	.1463
4	.1463	.1463	.1494	.1463	.1463	.1646	.1463
5	.1463	.1829	.168	.1829	.1829	.2012	.1829
6	.2614	.2378	.2241	.2561	.2561	.2641	.2801
7	.2987	.2743	.2957	.2926	.2561	.2926	.3395
8	.2218	.2012	.2561	.2378	.2378	.2402	.2614
9	.1829	.1646	.1991	.1829	.1646	.2218	.2195
10	.1463	.1829	.2012			.1629	.181
11	.1646	.1829	.1791	.1595		.1646	.1433
12	.1698	.1829	.1595	.1612		.1646	.1463
13	.1646	.1629	.1612	.1448	.1629	.1629	.1463
14	.1646	.1612	.1646	.1433	.1448	.1433	.1463
15	.1097	.1463	.1646	.1448	.1463	.124	.1463
16	.1097	.1433	.1646	.1433	.1463	.1433	.1463
17	.1463	.1578	.1646	.1417	.1463	.181	.1509
18	.1463	.1595	.1791	.1829	.1629	.2012	.2012
19	.2195	.2218	.2195	.2263	.1829	.2614	.2195
20	.2195	.2772	.2195	.2378	.2195	.2378	.2195
21	.2195	.2195	.2195	.1829	.2378	.2195	.2012
22	.1829	.2195	.1829	.1829	.2195	.2054	.2012
23	.1646	.3292	.1829	.1463	.1829	.1698	.1463
24	.1463	.1463	.1494	.1646	.1463	.1646	.1463
Max	.2987	.3292	.2957	.2926	.2561	.2926	.3395
Min	.1097	.1433	.1494	.1417	.1448	.124	.1433
Avg	.1738	.1893	.1855	.1783	.1801	.1910	.1838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.5761	.5761	.5281	.4801
2		.0189	.0189	.5761	.5761	.5281	.4744
3	.0189	.0189	.0189	.5761	.5761	.5281	.4801
4	.0189	.0189	.0189	.5761	.5761	.5281	.4801
5	.0189	.0189	.0189	.5761	.5761	.5761	.4801
6	.0189	.0189	.0189	.6722	.7682	.6722	.5281
7		.0189	.0189	.5761	.9602	.8162	.5761
8	.0189	.0189	.0189	1.0562	1.0562	.9231	.6009
9	.0189	.0189	.1132	1.0562	.9602	.8745	.6249
10	.0189	.0189	.0189	.0189		.0189	.0189
11	.8642	1.1317	1.1523	.0189		.0189	.0189
12	.8642	1.3203	1.2631	.0189	.0189	.0189	.0189
13	.9602	1.3203	1.3603	.0189	.0189	.0189	.0189
14	.9602	1.3203	1.3117	.0189	.0189	.0189	.0189
15	.9602	1.1203	1.2483	.0189	.0189	.0189	.0189
16	.9602	1.0242	1.2483	.0189	.0189	.0189	.0189
17	.9602	.8642	1.1385	.0189	.0189	.0189	.0189
18	.5761	.9122	1.0311	.0189	.0189	.0189	.0189
19	.0189	.0189	.0189	.0189	.0189	.0189	.0189
20	.0189	.0189	.0189	.0189	.0189	.0189	
21	.0189	.0189	.0189	.0189	.0189	.0189	.0189
22	.0189	.0189	.0189	.0189	.0189	.0189	.0189
23	.0189	.0189	.0189	.4715	.0189	.0189	.0189
24	.0189	.0189	.0189	.5556	.5556	.5281	.4858
Max	.9602	1.3203	1.3603	1.0562	1.0562	.9231	.6249
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.3350	.3882	.4229	.3131	.3367	.2820	.2372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.4527	.4527	.3772	.415	.3772
2	.3772	.3395	.4527	.415	.3772	.415	.3772
3	.3772	.3395	.4527	.415	.3772	.415	.3772
4	.3772	.3395	.4527	.3772	.3772	.415	.3772
5	.3772	.3772	.3772	.3772	.3772	.415	.3772
6	.3395	.3772	.3395	.3772	.3772	.3772	.3395
7		.3772	.3772	.3772	.3772	.3584	.3395
8	.3772	.3395	.3772	.3961	.3772	.3584	.3772
9	.5658	.5281	.5658	.5093	.3772	.5658	.4715
10	.7545	.6036	.6224	.5658	.5658	.679	.6224
11	.7922	.6224	.679	.7167		.7545	.7356
12	.7922	.679	.8488	.811	.4961		.7545
13	.7922	.7545	.8299	.811	.4904	.7922	.7545
14	.679	.7545	.7922	.811	.3898	.7545	.7545
15	.5658	.7545	.7545	.7922	.415	.7545	.7545
16	.5281	.679	.7545	.7545	.415	.6979	.6979
17	.415		.7545	.7545	.415	.679	.6979
18	.415	.4527	.7356	.7545	.5093	.6413	.6413
19	.3961	.7545	.6413	.6979	.4527	.5658	.5658
20	.3961	.4715	.5093	.5281	.4527	.4904	.5281
21	.3961	.4715	.5093	.4715	.4338	.3961	.5281
22	.3395	.4715	.5658	.4715	.3961	.4904	.4715
23	.3395	.4527	.5658	.4715	.3961	.5093	.5281
24	.4527	.0189	.4527	.4527	.3772	.3395	.3961
Max	.7922	.7545	.8488	.811	.5658	.7922	.7545
Min	.3395	.0189	.3395	.3772	.3772	.3395	.3395
Avg	.4879	.4912	.5776	.5651	.4174	.5339	.5352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW  
FEEDER Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.3772	.3772	.3772	.3772	.3772
2	.3772	.3395	.3772	.3772	.3772	.3772	.3772
3	.3772	.3772	.3772	.415	.3772	.3772	.3772
4	.3772	.3772	.3772	.415	.3772	.3772	.3772
5	.3772	.415	.3772	.4527	.415	.4338	.3772
6	.4904	.4904	.415	.4527	.4527	.4715	.415
7		.4904	.4904	.4527	.4527	.4715	.4715
8	.4904	.4904	.4527	.4527	.4527	.4338	.4715
9	.4904	.5281	.4527	.4904	.4527	.4527	.4904
10	.415	.5281		.4904		.4904	.4715
11	.415	.4715	.4527	.415	.3206	.4527	.415
12	.415	.4715	.415	.3961	.1739	.415	.415
13	.4527	.4715	.4904	.4527	.04	.415	.415
14	.4527	.4527	.4904	.4527	.0429	.415	.415
15	.4527	.4527	.5281	.4715	.0743	.4527	.4527
16	.4527	.4527	.5658	.4904	.0718	.4904	.4527
17	.415	.4715	.5093	.4527	.08	.4527	.4527
18	.415	.4715	.4904	.4527	.2614	.4715	.3772
19	.2641	.415	.2641	.2641	.2801	.3772	.2263
20	.2641	.2515	.1886	.2641	.2801	.2401	.2195
21	.1886	.2515	.1886	.3018	.3018	.1524	.2263
22	.1886	.2452	.2641	.3018	.3206	.2743	.2263
23	.3395	.3206	.8535	.3395	.3206	.3772	.2263
24	.3584		.3772	.3772	.3772	.3772	.3772
Max	.4904	.5281	.8535	.4904	.4527	.4904	.4904
Min	.1886	.2452	.1886	.2641	.04	.1524	.2195
Avg	.3846	.4163	.425	.4087	.2904	.4011	.3793

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV KAPUSKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.1097	.1086	.1097	.1097	.128
2	.1097	.1097	.1097	.1086	.1097	.1097	.128
3	.1097	.1097	.1097	.1086	.1097	.1097	.128
4	.1097	.1097	.1097	.1086	.1097	.1097	.128
5	.1097	.1463	.1646	.1448	.1463	.1646	.1867
6	.2241	.2195	.2195	.181	.2195	.2195	.2614
7		.2195	.2587	.181	.1829	.2218	.2452
8	.1886	.1463	.1867	.181	.1463	.1663	.2241
9	.1663	.1097	.1629	.1097	.1097	.181	.1646
10	.1109	.1097	.1052	.104		.1448	.1448
11	.1109	.1109	.1063	.0886	.0709	.12	.1433
12	.1109	.1109	.0709	.0716	.0526	.1006	.0732
13	.0739	.1075	.1097	.0709	.0724	.0876	.0732
14	.0732	.0914	.0924	.0686	.0724	.0716	.0732
15	.0739	.1097	.128	.0693	.0724		.0732
16	.0739	.1097	.1097	.0701	.0905	.0716	.0732
17	.1109	.1448	.1075	.0886	.0905	.1063	.1097
18	.1109	.1448	.1448	.1097	.1052	.1086	.1463
19	.1829	.2195	.1829	.1509	.1753	.1791	.2195
20	.1829	.2218	.181	.2195	.2103	.2218	.1829
21	.1829	.1829	.181	.1829	.1829	.1867	.1463
22	.1463	.1829	.1448	.1463	.1646	.1509	
23	.1097	.1463	.1448	.1097	.128	.132	.1463
24	.1097	.1097	.1097	.1086	.1097	.1097	.112
Max	.2241	.2218	.2587	.2195	.2195	.2218	.2614
Min	.0732	.0914	.0709	.0686	.0526	.0716	.0732
Avg	.1257	.1409	.1396	.1205	.1235	.1384	.1440

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3887	.3749	.0189	.0189	.0147	.0171
2	.3429	.3887	.3795	.0189	.0189	.0147	.0171
3	.3429	.3887	.3795	.0189	.0189	.0147	.0171
4	.3429	.3887	.3795	.0189	.0189	.0147	.0171
5	.3429	.3887	.4111	.0189	.0189	.0147	.0171
6	.3429	.3841	.5087	.0189	.0189	.0128	.0171
7	.4908	.679	.6935	.0189	.0189	.0139	.0171
8	.5487		.7545	.0189	.0189	.0137	.0171
9	.5487	.679	.7922	.0189	.0189	.0154	.0171
10	.5853	.679	.0171	.0189		.0171	.0171
11	.0189	.0189	.0171	.9054	.7167	.9054	.5014
12	.0189	.0189	.0171	1.0562	.7922	.9431	.5014
13	.0189	.0177	.0189	1.0562	.5693	.9054	.5014
14		.0177	.0189	1.0562	.5851	.9054	.3582
15	.0189	.0177	.0189	1.0562	.7545	.8299	.3772
16	.0189	.0179	.0189	.9808	.9054	.7545	.3772
17	.0189	.0177	.0189		.7362	.7545	.3772
18	.0189	.0177	.0189		.7042	.7167	.3018
19	.0189	.0168	.0189	.0189	.017	.0171	.0189
20	.0189	.013	.0189	.0189	.016	.0171	.0189
21	.0189	.0131	.0189	.0189	.0168	.0171	.0189
22	.0189	.0168	.0189	.0189	.0168	.0171	.0189
23	.0189	.0131	.0189	.0189	.0141	.0171	.0189
24	.0171	.0189	.3704	.0189	.0189	.0137	.0171
Max	.5853	.679	.7922	1.0562	.9054	.9431	.5014
Min	.0171	.013	.0171	.0189	.0141	.0128	.0171
Avg	.1946	.2000	.2210	.2915	.2623	.2900	.1491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS  
feeder Feeder KV- 11 /  
OUTGOING

PURELY LIS FEEDERS

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0185	.0187
2					.0185	.0373
3					.0185	.0373
4			.1463	.2957	.0185	.2987
5			.3142	.2957	.0185	.2987
6		.056	.3511	.2957	.0185	.2987
7		.056	.3734	.3326	.0185	.2987
8	.0187	.3361	.3511	.2957	.1663	.2987
9	.3361		.3511	.3326	.3326	.2987
10	.3361	.3174	.3547	.3361	.3361	
11	.3734	.3361	.3547	.3547	.3361	
12	.3734	.3547	.3734	.3547	.3547	
13	.3734	.3547	.3734	.3547	.3547	
14	.3734	.3547	.3547	.3361	.3547	
15	.3734	.3547	.3547	.3361	.3361	
16	.3361	.3361	.3547	.3547	.2987	.2987
24			.0185			
Max	.3734	.3547	.3734	.3547	.3547	.2987
Min	.0187	.056	.0185	.2957	.0185	.0187
Avg	.3216	.2857	.3161	.3289	.1875	.2184



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.6975	1.7541	1.6975	1.6975	1.358	1.4861
2	1.7147	1.6975	1.7541	1.6975	1.6975	1.1883	1.4861
3	1.7147	1.6975	1.6804	1.6975	1.6975	1.1883	1.4861
4	1.7147	1.6975	1.6975	1.6975	1.6975	1.2449	1.4861
5	1.7147	1.6975	1.6409	1.6975	1.6975	1.358	1.4861
6	1.7147	1.6975	1.6409	1.6975	1.6975	1.1883	1.4861
7	1.7718	1.6975	1.6409	1.6975		1.2449	1.4861
8	1.6004	1.6975	1.6409	1.6975	1.8107	1.3014	1.4861
9	1.8861	1.9239	1.6975	1.8107	1.1431	1.5278	1.6004
10	1.9239	1.9239	1.7147	1.7718		1.6004	1.6004
11	1.9239	1.9805	1.7718	1.8861	1.0751	1.6004	1.4861
12	1.9239	1.9239	1.829	1.9433	1.1317	1.6004	1.4712
13	1.9239	1.8107	1.829	1.9433	1.1317	1.6004	1.358
14	1.9239	1.9805	1.829	1.9433	1.1317	1.6004	1.4712
15	1.9239	1.9805	1.829	1.9433	1.1317	1.6004	1.4712
16	1.9239	1.9805	1.829	1.9433	1.1883	1.6004	1.4712
17	1.9239	1.9805	1.829	1.8861	1.1883	1.6004	1.4712
18	1.8107	1.9239	1.829	1.8107	1.3014	1.4861	1.4712
19	1.9239	1.9239	1.6975	1.8107	1.1883	1.4861	1.4712
20	1.6975	1.8673	1.5844	1.8107	1.1883	1.4861	1.4712
21	1.6975	1.6975	1.5844	1.6975	1.2449	1.5432	1.4712
22	1.6975	1.8107	1.6975	1.6975	1.3014	1.6004	1.4712
23	1.6975	1.7541	1.6975	1.6975	1.3014	1.4861	1.4712
24	1.7147	1.6975	1.7541	1.6975	1.8107	1.358	1.4861
Max	1.9239	1.9805	1.829	1.9433	1.8107	1.6004	1.6004
Min	1.6004	1.6975	1.5844	1.6975	1.0751	1.1883	1.358
Avg	1.7990	1.8225	1.7272	1.7864	1.3843	1.4520	1.4835

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX &amp; TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4715	.3961	.3772	.415	.3772	.4854
2	.4338	.4715	.3772	.3772	.415	.3772	.4854
3	.4338	.4715	.3772	.3772	.415	.4668	.4854
4	.4715	.5093	.415	.4481	.4527	.5281	.5281
5	.5093	.5658	.4904	.5228	.547	.6413	.5658
6	.679	.7167	.679	.7282	.679	.6979	.6401
7	.7468	.7392	.7577	.7947	.7392	.7095	.724
8	.6697	.7059	.6878	.7499	.7392	.6697	.7133
9	.5853	.5792	.6335	.6626	.5359	.591	.5973
10	.5493	.5548	.5316	.5548	.4961	.4887	.5258
11	.567	.5434	.5544	.5258	.463	.5121	.4656
12	.591	.5258	.567	.5083	.4854	.5121	.4733
13	.543	.3814	.5731	.5138	.4908	.4477	.4733
14	.4755	.3898	.5792	.5138	.4161	.4706	.3761
15	.4525	.5373	.5731	.4908	.4382	.4938	.3982
16	.1372	.4854	.5493	.4801	.4382	.3982	.3814
17	.2629	.4557	.5493	.5487	.4607	.4344	.4031
18	.4382	.4973	.5959	.5959	.4973	.6602	.5434
19	.7522	.6626	.6588	.7265	.7265	.7282	.6556
20	.9694	.8779	.8688	.8596	.7964	.7316	.7362
21	.8131	.7282	.7133	.7392	.7023	.7602	.631
22	.6979	.6602	.695	.6722	.5729	.695	.6154
23	.5281	.547	.5359	.5658	.5415	.6722	.4338
24	.4715	.4904	.415	.4108	.4338	.415	.5658
Max	.9694	.8779	.8688	.8596	.7964	.7602	.7362
Min	.1372	.3814	.3772	.3772	.415	.3772	.3761
Avg	.5505	.5653	.5739	.5727	.5374	.5616	.5376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.285	.2439	.0566	.0754	.0566	.0566
2	.192	.2683	.2408	.0566	.0566	.0566	.056
3	.2241	.2652	.2258	.056	.0566	.0566	.056
4	.2294	.2652	.2439	.0739	.0566	.0754	.0754
5	.2294	.2915	.2896	.0924	.0566	.0747	.0754
6	.2561	.3479	.3749	.0914	.0934	.0934	.0754
7	.4588	.5121	.5468	.0924	.1132	.0934	.112
8	.5243	.7209	.68	.0934	.1132	.0747	.0943
9	.5281	.6802	.6483	.1132	.0754	.0943	.0934
10	.506	.6093	.0905	.0943	.0754	.0934	.0754
11	.0754	.0754	.0754	.8583	.5937	.4915	.5312
12	.1132	.0566	.0566	.9602	.6093	.5761	.4784
13	.0754	.0754	.0754	.9762	.6167	.5898	.4999
14	.0754	.0754	.0566	.9488	.7253	.4961	.5093
15	.0754	.0754	.0566	.933	.7343	.5079	
16	.056	.0754	.0943	.8796	.7253	.4801	.4938
17	.0934	.0943	.0943	.6481	.7186	.4858	.4938
18	.0943	.0754	.1132	.6019	.6401	.5079	.4167
19	.1132	.0754	.1132	.0943	.0943	.0754	.0754
20	.0943	.0754	.0943	.0754	.0754	.0747	.0754
21	.0943	.0754	.0754	.0754	.0754	.0754	.0754
22	.0754	.0566	.0754	.0754	.0754	.0747	.0754
23	.0754	.0566	.0754	.0754	.0754	.0566	.0754
24	.0566	.0754	.2286	.0754	.0754	.0754	.0566
Max	.5281	.7209	.68	.9762	.7343	.5898	.5312
Min	.056	.0566	.0566	.056	.0566	.0566	.056
Avg	.1880	.2193	.2029	.3374	.2753	.2224	.2012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL  
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0354	.0526	.5312	.3593	.3125	.3201
2	.0566	.0358	.0532	.5312	.3593	.3125	.3521
3	.056	.0366	.0526	.5693	.3593	.3637	.3437
4	.056	.0362	.0526	.6009	.3795	.3953	.3437
5	.0566	.0543	.0532	.6241		.4481	.3681
6	.056	.0537	.0709	.6401	.4268	.4641	.3841
7	.0943	.0701	.0876	.8749	.5792	.5851	.5079
8	.056	.0514	.0686	.9448	.5792	.6401	.5281
9	.0566	.0537	.0486	.8179	.4607	.6636	.5571
10	.032	.0617	.0617	.064	.0305	.6722	.0305
11	.8002	1.0437	1.1203	.064	.0316	.0566	.0316
12	.7432	1.0753	1.2955	.0343	.0312	.0373	.0316
13	.8065	1.0623	1.2803	.0332	.0316	.0566	.032
14	.8162	1.0623	1.1469	.0655	.061	.056	.0328
15	.8322	1.0911	1.1336	.0995	.0617	.0566	.0328
16	.6562	1.0185	1.0802	.0995	.061	.0747	.0457
17	.6325	.8951	1.0936	.1006	.0617	.056	.0463
18	.5693	.8078	.8592	.1029	.061	.0754	.0486
19	.0429	.0671	.061	.0905	.061	.0747	.0457
20	.0486	.0716	.0772	.0876	.0617	.0566	.0463
21	.0503	.0693	.0701	.0876	.061	.0566	.0633
22	.0532	.0701	.0617	.0701	.0678	.056	.0469
23	.0514		.0686	.0716	.0686	.0566	.0457
24	.056	.0343	.0526	.4784	.3658	.3353	.3201
Max	.8322	1.0911	1.2955	.9448	.5792	.6722	.5571
Min	.032	.0343	.0486	.0332	.0305	.0373	.0305
Avg	.2806	.3851	.4168	.3202	.2009	.2484	.1919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.6036		.583	.5693	.1638
2	.639	.6299	.6226	.5992	.5992	.2949
3	.6241	.6299	.6226	.6062	.5992	.2812
4	.6241	.6226	.6226	.6062	.5921	.3041
5	.639	.6226	.6226	.6133	.5992	.3041
6	.6241	.6299	.6299	.6133	.6062	.3113
7	.6226	.6464	.6226	.5898	.5992	.3005
8	.6081	.6539	.6226	.5967	.5992	.3041
9	.6226	.6539	.6226	.5668	.5992	.3005
10	.6371	.6316	.6133	.583	.5992	.2932
11	.6371	.6226	.6133	.5967	.6226	.3005
12	.6371	.6226	.6299	.6062	.6081	.2968
13	.6371	.6226	.6226	.5898	.6226	.2968
14	.6371	.6226	.6133	.5898	.6154	.3277
15	.6371	.6226	.6133	.5898	.6226	.3239
16	.0084	.6154	.6062	.583	.6154	.3077
Max	.639	.6539	.6299	.6133	.6226	.3277
Min	.0084	.6036	.6062	.5668	.5693	.1638
Avg	.5890	.6283	.62	.5946	.6043	.2944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.168	.1867	.1848	.168	.1494
2	.1494	.1886	.1663	.1867	.1867	.1663	.1509
3	.1478	.1886	.1646	.1867	.1886	.1646	.1494
4	.2195	.2263	.2218	.2241	.2427	.2195	.1509
5	.2743	.2829	.2561	.2987	.2801	.2561	.2772
6	.3326	.3547	.3326	.3921	.3395	.3439	.3734
7	.2743	.2896	.3077	.3292	.2772	.3258	.2743
8	.2481	.2126	.208	.2534	.2353	.2149	.2534
9	.2103	.208	.1715	.2149	.197	.2126	.2149
10	.1696	.1658	.1526	.1696	.1715	.1715	.1526
11	.1658	.1715	.1357	.1658	.1341	.1509	.1311
12	.1658	.1715	.1734	.1943	.1326	.1457	.1326
13	.1677	.1886	.2058	.1638	.1219	.1619	.128
14	.1715	.208	.1949	.1696	.1372	.1174	.128
15	.1734	.1886	.1949	.1823	.1387	.1311	.128
16	.1658	.1638	.2103	.1457	.1187	.1296	.1475
17	.1492	.2056	.2035	.1781	.1696	.1823	.176
18	.1802	.1966	.2035	.1658	.2035	.213	.2214
19	.2601	.2427	.2374	.1791	.2572	.2279	.2774
20	.2865	.2865	.3077	.2772	.2835	.2743	.2715
21	.2715	.2534	.2743	.2378	.2507	.2587	.2353
22	.2614	.2218		.2452	.2378	.2241	.2012
23	.2075	.168	.2054	.1867	.1886	.168	.168
24	.1509	.1886	.168	.1886	.1886	.168	.1509
Max	.3326	.3547	.3326	.3921	.3395	.3439	.3734
Min	.1478	.1638	.1357	.1457	.1187	.1174	.128
Avg	.2064	.2150	.2115	.2134	.2028	.1998	.1935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0417	.0556				
2	.0301	.0572	.0564				
3	.0301	.0572	.0648				
4	.0297	.0572					
5	.0293	.0572	.0995				
6	.0278	.0572	.1174			.0179	
7	.0602	.1174	.1505				
8	.0753	.1372	.1486				
9	.0556	.1337	.1524				
10	.0695	.1		.2881			
11				.3163	.2031	.1406	.0705
12				.3906	.2006	.1486	.0564
13				.3906	.2134	.1467	.0417
14				.4481	.216	.1174	.0267
15				.427	.2315	.1158	.0255
16				.3906	.2343	.1128	.0366
17				.3281	.1981	.1014	.0389
18				.3241	.1806	.1014	.0394
24			.0417				
Max	.0753	.1372	.1524	.4481	.2343	.1486	.0705
Min	.0278	.0417	.0417	.2881	.1806	.0179	.0255
Avg	.0438	.0816	.0985	.3671	.2097	.1114	.0420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0377	.6562	.6093	.3948	.3462
2	.037	.0377	.0373	.6562	.6241	.4054	.3418
3	.0377	.0377	.037	.7186	.6167	.4108	.3506
4	.0366	.0377	.0549	.7186	.6249	.4161	.3549
5	.0549	.0377	.0554	.7186	.6874	.4572	.3462
6	.0554	.0566	.0554	.7655	.7432	.5155	.3506
7	.0648	.0377	.0566	.9217	.8381	.5468	.3858
8	.0354	.0373	.037	.9804	.9172	.6405	.381
9	.0312	.0354	.037	1.012	.8065	.6562	.3858
10	.0309		.0366	.0566	.0316	.0343	.0312
11	.4784	.8488	.9488	.0554	.0316	.0185	.0312
12	.6249	.9722	1.1203	.032	.032	.0177	.0312
13	.7682	.9568	1.0911	.0554	.0316	.0366	.0332
14	.6944	.9259		.056	.0316	.0366	.0339
15	.6327	.9105	1.1043	.0543	.0316	.0181	.0339
16	.6481	.8642	1.0883	.0554	.0474	.0366	.0312
17	.7068	.8179	1.1203	.0554	.0474	.0351	.0312
18	.6773	.787	1.0402	.0554	.0474	.0537	.0469
19	.0543	.0309	.0566	.0549	.0633	.0377	.0469
20	.0747	.0463	.0566	.0739	.0633	.0373	.0469
21	.0373	.0309	.0566	.056	.0633	.0377	.0543
22	.0566	.0312		.0566	.0537	.037	.0366
23	.0377	.0312	.0377	.0554	.0474	.037	.037
24	.0373	.0377	.0377	.6481	.6241	.3666	.3418
Max	.7682	.9722	1.1203	1.012	.9172	.6562	.3858
Min	.0309	.0309	.0366	.032	.0316	.0177	.0312
Avg	.2479	.3325	.3729	.3570	.3214	.2202	.1713



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4338	.4338	.4715	.4527	.4382	.415
2	.415	.415	.415	.4527	.4527	.4382	.415
3	.415	.415	.415	.4572	.4527	.4854	.415
4	.415	.4338	.4527	.4527	.4527	.4338	.4338
5	.5093	.5093	.5281	.5335	.547	.5093	.4904
6	.7733	.8299	.7356	.8299	.7356	.8299	.7545
7	.7842	.8215	.8029	.7762	.7356	.8215	.8962
8	.6348	.6036	.7392	.6838	.6535	.7023	.8131
9	.5304	.543	.5853	.5611	.4854	.5973	.5853
10	.4525	.4477	.4706	.4119	.3841		.4835
11	.4075	.4298	.4835	.4252	.394		.443
12	.4607		.4344	.4031	.362		.4252
13	.3982	.1829	.4163	.333	.3582		.3544
14	.3801	.2507	.4163	.2715	.2896	.4557	.2804
15	.3142	.5194	.4024	.3045	.2896	.4656	.2896
16	.3045	.4119	.4119	.333	.2865	.4161	.3403
17	.3366	.4075	.4119	.4031	.394	.4908	.3898
18	.4961	.3721	.4298	.5316	.4252	.5434	.443
19	.5973	.5731	.543	.5973	.5853	.6878	.6154
20	.7947	.8131	.7762	.7762	.7577	.8596	.7762
21	.7282	.7095	.7282	.7095	.6908	.7282	.7095
22	.6413	.6722	.6602	.6036	.6348	.6535	.6224
23	.5093	.5281	.5658	.5093	.5281	.4904	.4527
24	.4338	.4527	.4527	.4715	.4527	.4715	.4338
Max	.7947	.8299	.8029	.8299	.7577	.8596	.8962
Min	.3045	.1829	.4024	.2715	.2865	.4161	.2804
Avg	.5061	.5120	.5296	.5126	.4917	.5759	.5116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.3005	.2778	.1158	.2134	.3567
2	.3704	.3637	.3749	.3121	.2778	.3567
3	.3704	.3593	.3637	.3353	.2778	.3567
4	.3658	.3593	.3637	.4999	.2812	.3521
5	.3658	.3637	.3479	.3321	.2656	.3567
6	.3749	.3637	.3521	.3437	.25	.3567
7	.3593	.3593	.3521	.3437	.2675	.3612
8	.3506	.3549	.3311	.3201	.2709	.3612
9	.3506	.3593	.3353	.3125	.2709	.3521
10	.3506	.3506	.3311		.3658	.3521
11	.3549	.3395	.3395	.3163	.3658	.3612
12	.3549	.3612	.3395	.104	.3418	.3612
13	.3549	.3269	.3353	.2439	.3374	.3567
14	.3549	.3311	.3353	.2187	.3269	.3612
15	.3549	.3395	.3353	.2688	.3269	.3612
16	.0505	.0606	.003	.0032	.3374	.3612
21						.3612
Max	.3749	.3637	.3749	.4999	.3658	.3612
Min	.0505	.0606	.003	.0032	.2134	.3521
Avg	.3242	.3308	.3199	.2713	.2986	.3580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1806	.1677	.0351	.0181	.0366	.0366
2	.1543	.1829	.1677	.0354	.0179	.0362	.0366
3	.1543	.1852	.1698	.0358	.0179	.0358	.0366
4	.1524	.2006	.1852	.0366	.0181	.037	.037
5	.1677	.2187	.2187	.0554	.0373	.056	.037
6	.2241	.3041	.2688	.056	.056	.0754	.056
7	.3953	.4268	.4012	.0724	.0724	.0747	.0732
8	.4268	.4268	.4572	.0686	.0549	.0543	.0532
9	.4161	.5556	.4458	.0701	.0537	.0537	.0532
10	.4064	.4755	.032	.0497	.052	.0362	.0347
11	.0347	.0332	.0358	.6554	.3864	.3048	.3311
12	.0358	.0324	.0335	.7407	.3963	.4161	.3462
13	.0358	.0316	.0332	.7468	.3807	.4458	.3567
14	.0358	.032	.0339	.7468	.4401	.4515	.3418
15	.0532	.0335	.0168	.7253	.4254	.4458	.3567
16	.0332	.0297	.0282	.5868	.4344	.4012	.3227
17	.0486	.0301	.0332	.5135	.3858	.3668	.3001
18	.0452	.0312	.0324	.4694	.3384	.3081	.2715
19	.0497	.0332	.0335	.0358	.0343	.0366	.0354
20	.0543	.0354	.0366	.037	.0358	.0366	.0358
21	.0549	.0537	.0366	.037	.0362	.037	.0354
22	.0554	.0537	.0366	.0373	.0354	.0362	.0354
23	.0554	.1783	.0362	.0366	.0343	.0354	.0366
24	.037	.0554		.0358	.0179	.0358	.0358
Max	.4268	.5556	.4572	.7468	.4401	.4515	.3567
Min	.0332	.0297	.0168	.0351	.0179	.0354	.0347
Avg	.1367	.1592	.1279	.2466	.1575	.1606	.1373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0469	.0497	.5441	.427	.3281	.2315
2	.0469	.0469	.0503	.5441	.4218	.3281	.2315
3	.0469	.0469	.0503	.5441	.4218	.3281	.2315
4	.0469	.0469	.0509	.5441	.427	.3281	.2315
5	.0625	.0625	.0686	.5441	.4687	.3437	.2469
6	.0625	.0781	.0857	.6483	.5468	.4218	.2932
7	.0781	.0937	.0867	.9014	.7655	.5468	.3858
8	.0781	.0781	.0867	.9488	.8124	.6562	.5093
9	.0625	.0469	.0693	.9488	.7811	.4531	.4784
10	.0625	.0469	.0686	.0633	.0625	.0625	.0463
11	.5937	.828	1.004	.0633	.0469	.0469	.0463
12	.6874	.7655	1.1336	.0474	.0312	.0469	.0617
13	.6405	.8592	1.2146	.0633	.0469	.0469	.0617
14	.6405	.8124	1.1984	.0474	.0469	.0469	.0463
15	.6405	.8124	1.1984	.0474	.0469	.0154	.0463
16	.6249	.8436	1.2003	.0633	.0625	.0309	.0617
17	.6249	.8124	1.1523	.0633	.0625	.0463	.0617
18	.578	.7655	1.0883	.0633	.0625	.0772	.0617
19	.0625	.0625	.064	.0633	.0625	.0617	.0617
20	.0781	.0781	.08	.0791	.0937	.0772	.0772
21	.0937	.0781	.08	.0633	.0781	.0617	.0772
22	.0781	.0781	.08	.0633	.0781	.0625	.0617
23	.0625	.0625	.064	.0474	.0625	.0625	.0617
24	.0625	.0625	.0625	.5441	.4111	.3437	.25
Max	.6874	.8592	1.2146	.9488	.8124	.6562	.5093
Min	.0469	.0469	.0497	.0474	.0312	.0154	.0463
Avg	.2526	.3131	.4286	.3146	.2636	.2010	.1635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 205 / 1KV Yede Lvanmachi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2824	.3185	.061	.0457	.061	.0452
2	.2229	.2824	.3185	.061	.0457	.061	.0452
3	.2229	.2824	.3041	.061	.0457	.061	.0452
4	.2229	.2972	.3081	.061	.0457	.061	.0452
5	.2378	.3418	.3521	.061	.061	.0762	.0602
6	.2972	.4607	.4694	.0914	.0762	.0914	.0903
7	.4607	.6687	.6836	.1067	.0914	.0762	.0903
8	.5647	.8025	.7579	.0914	.0762	.061	.0753
9	.535	.8025	.7676	.0762	.061	.0762	.0753
10	.4904	.743	.0753	.0914	.061	.061	.0602
11	.0602	.0594	.0602	.8993	.7099	.5487	.4967
12	.0594	.0594	.0602	.9755	.7253	.6097	.2408
13	.0753	.0594	.0602	1.0364	.7468	.6554	.2709
14	.0602	.0594	.0602	1.0822	.7468	.6554	.5117
15	.0594	.0594	.0602	1.0822	.6706	.6773	.5569
16	.0743	.0743	.0753	1.0364	.7164	.6773	.5117
17	.0743	.0743	.0753	.9145	.6859	.6622	.5117
18	.0743	.0743	.0753	.884	.6554	.6472	.5117
19	.0743	.0743		.0762	.0762	.0602	.0753
20	.0892	.0743	.0753	.0762	.0762	.0753	.0753
21	.0743	.0743	.0753	.061	.0762	.0753	.0753
22	.0594	.0743	.0753	.061	.0762	.0753	.0602
23	.0594	.0594	.0602	.061	.0762	.0602	.0602
24	.0594	.0594	.3286	.061	.061	.061	.0602
Max	.5647	.8025	.7676	1.0822	.7468	.6773	.5569
Min	.0594	.0594	.0602	.061	.0457	.0602	.0452
Avg	.1852	.2458	.2390	.3779	.2795	.2594	.1938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1867	.1829	.2286	.1646	.1867	.1905
2	.1715	.168	.1646	.2286	.1448	.168	.2096
3	.1715	.168	.1646	.2096	.1448	.168	.1905
4	.2096	.168	.1848	.1905	.1829	.168	.2286
5	.2096	.2054	.1829	.2096	.2218	.1867	.2096
6	.2096	.2241	.2012	.2477	.2587	.2241	.2286
7	.2477	.2427	.2587	.2858	.2957	.2614	.2667
8	.2667	.2614	.2957	.2858	.3109	.2987	.3048
9	.2172	.2241	.2667	.2957	.3142	.2667	.2926
10	.2195	.2378	.2477	.2743	.2561	.2477	.2218
11	.2561	.2218	.2477	.2561		.2286	.2195
12	.2195	.1829	.2477	.2402		.2096	.181
13	.2012	.1848	.2667	.2561		.1905	.1463
14	.2012	.2012	.2477	.2402		.1905	.1848
15	.2012	.181	.2477	.2402		.1715	.128
16	.2012	.1663	.2477	.2561		.2096	.1478
17	.2378	.2195	.2286	.2378	.2772	.2096	.181
18	.2218	.2033	.2286	.2195	.2402	.2286	.2149
19	.2427	.2378	.2667	.2772	.3174	.2477	.2715
20	.2614	.2957	.3048	.2896	.3174	.2858	.2865
21	.2427	.2561	.2858	.2534	.2987	.2667	.2507
22	.2241	.2587	.2858	.2686	.2801	.2477	.2353
23	.2054	.2378	.2667	.2743	.2614	.2096	.1991
24	.1905	.1867	.2033	.2477	.1991	.2054	.2096
Max	.2667	.2957	.3048	.2957	.3174	.2987	.3048
Min	.1715	.1663	.1646	.1905	.1448	.168	.128
Avg	.2175	.2133	.2386	.2506	.2492	.2199	.2166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7468		.9145	.6767	.695	.8383
2	.7811	.7095	.7682	.8954	.6468	.6584	.8002
3	.8383	.6908	.7316	.9145	.6584	.6401	.8002
4	.8573	.6722	.6767	.9717	.7421	.6584	.9145
5	.9717	.8215	.7392	.9907	.8326	.9145	.9717
6	1.086	1.0642	.9955	1.0288	1.0719	1.1949	
7	1.0098	1.0082	.9145	.9335	1.0974	1.0608	1.0669
8	.9145	.8871	.8779	.8192	.9795	.9511	.9907
9	.7865	.7682	.8764	.7392	.9511	.9145	.9694
10	.823	.8326	.7811	.8779	.8779	.9145	.961
11	.7133	.8048	.724	.7392		.8383	.7316
12	.7316	.5914	.7621	.7316		.7811	.6653
13	.695	.6036	.743	.6653		.743	
14	.7133	.6697	.724	.6219		.743	
15	.7133	.7392	.724	.6653		.7049	
16	.8048	.8326	.743	.7682		.7811	
17	.695	.7682	.7811	.7316	.961	.8002	.8869
18	.6722	.8131	.6859	.8131	.8962	.9335	.8775
19	1.0082	1.0425	.7811	.9511	1.0642	1.0098	.9774
20	1.1576	1.0974	1.105	1.0719	1.1576	1.1812	1.0974
21	1.1016	1.0164	1.0098	.9877	1.0974	1.086	.9955
22	1.0456	.9979	.9907	.9412	1.0242	.9717	.905
23	.9335	.8413	.9526	.8779	.8779	.9145	.7865
24	.8192	.8029		.8192	.7059	.7842	.8192
Max	1.1576	1.0974	1.105	1.0719	1.1576	1.1949	1.0974
Min	.6722	.5914	.6767	.6219	.6468	.6401	.6653
Avg	.8606	.8259	.8222	.8529	.9066	.8698	.8976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8215	.8131	.9145	.7762	.8962	.9145
2	.8954	.7842	.7316	.9145	.7207	.8215	.8954
3	.8954	.7468	.7392	.9907	.7577	.7842	.8954
4	.9717	.7468	.7762	1.0098	.8316	.8029	.9526
5	1.0098	.8962	.8775	1.086	.9145	.9335	1.0098
6	1.086	1.1576	.9511	1.1431	1.1888	1.1203	1.1431
7	1.2003	1.2567	1.0903	1.2003	1.2197	1.2752	1.2193
8	1.3146	1.3169	1.3352	.9593	1.4045	1.3306	1.3717
9	.9955	.9877	1.1241	.9955	1.0974	1.1431	1.2254
10	1.1403	1.1827	1.0479	1.1458	.8779	1.2574	1.2197
11	.9774	1.0242	1.0288	.9328	.823	1.0098	.9145
12	.8962	.961	1.0098	.9036	.1698	.9717	.8688
13	.9511	1.0059	.9907	.9036	.1698	.9717	.8417
14	.9511	.8326	.9717	.9214	.1698	.9335	.8682
15	.8779	.8326	.8764	.8063	.132	.7811	.724
16	.823	.8048	.8764	.7087	.1509	.8002	.8059
17	.823	.8871	.9145	.8048	1.1949	.8192	.8779
18	.961	.9511	.9717	1.0924	1.0642	1.2003	1.1088
19	1.2696	1.2197	1.2765	1.3213	1.3443	1.3527	1.3253
20	1.4937	1.39	1.5242	1.4784	1.5684	1.448	1.3611
21	1.3443	1.2403	1.4098	1.3169	1.419	1.3336	1.2536
22	1.2323	1.1999	1.2955	1.1949	1.307	1.2003	1.1403
23	1.0082	.9877	1.1241	1.0456	1.1949	1.0288	.9511
24	.9717	.8775	.8501	.9907	.8596	.9709	.9717
Max	1.4937	1.39	1.5242	1.4784	1.5684	1.448	1.3717
Min	.823	.7468	.7316	.7087	.132	.7811	.724
Avg	1.0418	1.0046	1.0253	1.0325	.8899	1.0494	1.0358



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.3521	.2743	.0762	.0732	.0747	.0762
2	.2286	.3521	.2713	.0762	.0732	.0747	.0953
3	.2286	.3521	.2458	.0762	.0739	.0747	.0953
4	.2096	.3681	.2949	.0762		.0747	.0762
5	.2477	.3887	.3391	.0762		.0934	.0762
6	.2858	.421	.3812	.0762		.0934	.0762
7	.5144	.5182	.5079	.0762	.1097	.1307	.0762
8	.6097	.6316	.6443	.0762	.0905	.112	.0762
9	.5761	.664	.6668	.0747		.1143	.0739
10	.583	.5898	.0762			.0762	.0732
11	.1494	.0995	.0762	.9602	.6802	1.1431	.6344
12	.112	.0914	.0762	.9488		1.1431	.6401
13	.112	.0924	.0762	.8802		1.2003	.6964
14	.112	.1097	.0762	.5376		1.1431	.6325
15	.1307	.0905	.0762	.6642	.8583	1.1431	.5693
16	.1494	.0924	.0762	.9667	1.0364	1.105	.6009
17	.1494	.0732	.0762	.9724		1.0479	.5601
18	.1307	.0732	.0762	.8718		1.0098	.502
19	.1307	.0739	.0762	.0886		.0762	.0886
20	.1494	.0732	.0762	.0914	.1307	.0762	.0791
21	.1307	.0739	.0762	.0924	.112	.0953	.08
22	.112	.0739	.0762	.0924	.0934	.0762	.08
23	.112	.0732	.0762	.0934	.0747	.0762	.0848
24	.0762	.0934	.2401	.0762	.0732	.0747	.0953
Max	.6097	.664	.6668	.9724	1.0364	1.2003	.6964
Min	.0762	.0732	.0762	.0747	.0732	.0747	.0732
Avg	.2263	.2426	.2055	.3487	.2676	.4304	.2558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.4763
Max	.4763
Min	.4763
Avg	.4763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.9909
Max	1.9909
Min	1.9909
Avg	1.9909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER  
Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUL-18
HR	Load (MW)
24	1.9547
Max	1.9547
Min	1.9547
Avg	1.9547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 403 / RATHARE BK

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	2.0005
Max	2.0005
Min	2.0005
Avg	2.0005



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 404 / 33KV BAHE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 405 / 33KV Walava

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 701 / Rajaram Bpau SSK Sakharale NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-JUL-18
HR	Load (MW)
24	.0229
Max	.0229
Min	.0229
Avg	.0229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-  
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2987	.3395	.2987	.3018	.2896	.2641
2	.2641	.2534	.3395	.2561	.3018	.2534	.2641
3	.2641	.2534	.3395	.2561	.3018	.2614	.2641
4	.2641	.3326	.3395	.3395	.3018	.3547	.2641
5	.3395	.4435	.3395	.4527	.3395	.4572	
6	.4904	.5249	.5281	.5304	.5281	.5304	
7	.5975	.6099	.5975	.6219	.6219	.6722	
8	.5228	.4854	.5544	.5375	.5853	1.0715	
9	.4066	.4755		.5175		.5529	.5487
10	.439	.462		.439		.3658	.5068
11	.4755	.4656		.4024		.4207	.4207
12	.3224	.2507		.3224		.3841	.394
13	.3326	.2587		.3086		.3292	.2149
14	.3292	.2507		.3326		.2987	.2149
15	.2926	.2195		.3506		.2926	.2195
16		.2195		.3506		.3258	
17	.3734	.2195	.3734			.3292	.3658
18	.5041	.3292	.439	.4755	.5359	.3658	.439
19	.4805	.4656	.5249	.4656		.4024	.5121
20	.567	.5544	.5544	.5731	.6878	.5121	.6348
21	.4805	.5544	.4706	.4298	.5914	.4805	.5304
22	.4561	.3772	.3881	.3772	.543	.3696	.4066
23	.3989	.3395	.3696	.3018	.3696	.3395	.3109
24	.2641	.2987	.3395	.2987	.3018	.2957	.2641
Max	.5975	.6099	.5975	.6219	.6878	1.0715	.6348
Min	.2641	.2195	.3395	.2561	.3018	.2534	.2149
Avg	.3969	.3726	.4273	.4017	.4508	.4148	.3705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4435	.4527	.415	.4527	.415	
2	.415	.415	.4527	.3658	.4527	.415	.415
3	.415	.415	.4527	.362	.4527	.439	.415
4	.415	.3582	.4527	.4344	.4527	.439	.415
5	.4904	.4298	.4527	.5281	.5281	.547	
6	.679	.5041	.6036	.5853	.6413	.6224	
7	.6283	.5853	.5658	.6535	.6413	.6535	
8	.6348	.5281	.6283	.6535	.5658	.6036	.415
9	.5975	.4854		.5228		.5415	.5121
10	.5544	.4435		.5544		.4668	.4805
11	.6283	.4066		.5914		.3841	.4344
12	.394	.439		.4481		.3734	.4656
13	.394	.4066		.4481		.3961	
14	.3898	.4066		.5175		.4108	
15	.4298	.4755		.5175		.4108	.4557
16	.4656	.4755		.5175		.4904	.4557
17	.5658	.4755	.5601		.3658	.4755	.5601
18	.6161	.6584	.3018	.6584	.4854	.5121	.5975
19	.7133	.7316	.7468	.7316	.5847	.5487	.6722
20	.8962	.8779	.9431	.8501	.7865	.8131	.7865
21	.7842	.7392	.8589	.7762	.695	.679	.695
22	.7316	.5544	.7545	.5658	.5487	.5658	.5487
23	.5601	.5281	.5788	.4904	.5415	.415	.4527
24	.4904	.4755	.4527	.4805	.4527	.4481	.415
Max	.8962	.8779	.9431	.8501	.7865	.8131	.7865
Min	.3898	.3582	.3018	.362	.3658	.3734	.415
Avg	.5543	.5108	.5786	.5508	.5405	.5027	.5107

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3361	.3258	.2614	.3292	.3258	.3258
2	.2896	.2614	.3258	.2561	.3292	.2481	.3258
3	.2896	.2534	.3258	.2195	.3292	.2481	.3258
4	.2896	.2534	.3258	.2241	.3292	.3142	.3258
5	.3658	.3511	.3258	.3547	.4024	.4066	
6	.4755	.4607	.4805	.439	.5175	.4755	
7	.5121	.5544	.5175	.5304	.5121	.5304	
8	.2987	.4805	.4706	.4344	.5068	.4481	
9	.2957	.4066		.4344		.3898	.439
10	.2743	.3658		.4115		.3292	.3982
11	.2896	.2172		.394		.3292	.3982
12	.2865	.2058		.3582		.2743	.2454
13	.2926	.2195		.3582		.2926	.2454
14	.2896	.2195		.3582		.2614	.2149
15	.2743	.2353				.2561	.2149
16	.2715	.2353				.2561	.2149
17	.2926	.2353	.2896		.3258	.2481	.3109
18	.2896	.2481	.2987		.3258	.3086	.3174
19	.3258	.3544	.3658	.4161	.3696	.3086	.3475
20	.4207	.3658	.4668	.4298	.4435	.4115	.4298
21	.4024	.3658	.4163	.394	.4115	.3982	.3292
22	.3721	.3658	.4066	.3658	.3856	.362	.3544
23	.3721	.3658	.4024	.3658	.3982	.3258	.3544
24	.3395	.3292	.3258	.3361	.3258	.3258	.3258
Max	.5121	.5544	.5175	.5304	.5175	.5304	.439
Min	.2715	.2058	.2896	.2195	.3258	.2481	.2149
Avg	.3291	.3203	.3794	.3671	.3901	.3364	.3222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2172	.1886	.2195	.2172	.2058	.1715
2	.1886	.1867	.1886	.1772	.2172	.1772	.1715
3	.1886	.1867	.1886	.1772	.2172	.1772	.1715
4	.1886	.2561	.1886	.2614	.2172	.2561	.1715
5	.2126	.2561	.1715	.2614	.2896	.2561	
6	.3121	.2835	.2378	.2926	.3155	.3174	
7	.3121	.3292	.3086	.3292	.3429	.3439	
8	.2812	.2804	.2743	.3292	.3086	.3658	
9	.2629	.2454		.2195		.3258	.2743
10	.2427	.2743		.2534		.2229	.2804
11	.2743	.2058		.2507		.2229	.2629
12	.1433	.1715		.2172		.1867	.2507
13	.1372	.1715		.2172		.1848	
14	.1715	.208		.1991		.1886	
15	.1715	.2401		.2149		.1886	.1829
16	.1753	.2401		.2149		.1715	.181
17	.2401	.2401	.2454		.168	.1715	.2534
18	.2401	.2401	.2926	.3898	.2241	.2743	.3174
19	.2743	.3258	.2743	.3772	.2401	.2743	.3658
20	.3898	.394	.4252	.4115	.3601	.3772	.3801
21	.3439	.3582	.4294	.3658	.3658	.3429	.3544
22	.3174	.3258	.3734		.3292	.2058	.3258
23	.2614	.2172	.2804	.2614	.2614	.1715	.2241
24	.1886	.2172	.1886	.2241	.2172	.2058	.1715
Max	.3898	.394	.4294	.4115	.3658	.3772	.3801
Min	.1372	.1715	.1715	.1772	.168	.1715	.1715
Avg	.2378	.2530	.2660	.2666	.2682	.2423	.2506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801		.0457		.0457	
2		.4801		.0457		.0457	
3		.6093		.0457		.0463	
4		.6093		.0463		.0617	
5		.7202		.0617		.061	
6		.7202		.061		.0914	
7		.7682		.1067		.1219	
8		1.1043		.1219		.1219	
9	.8802	1.0883		.1067		.0914	
10	.8436	1.0467		.0914		.9602	
11	.0781	.1094		1.5394		1.1843	.7968
12	.0625	.0926		1.656		1.1523	.8993
13	.0457	.0762		1.6716		1.1203	.9374
14	.0625	.0914		1.6872		1.1142	.9374
15	.0781	.0914		1.6613		1.0242	.9374
16		.0762		1.6766		.945	.953
17	.061		.0762		1.3279		.9061
18	.061		.0762		1.3279		.9061
19	.061		.1067				.061
20	.061		.061		.061		.0457
21	.0457		.061		.061		.0457
22	.0457		.061		.0457		.0457
23	.0457		.061		.0457		.0457
24		.0457		.0457		.0457	
Max	.8802	1.1043	.1067	1.6872	1.3279	1.1843	.953
Min	.0457	.0457	.061	.0457	.0457	.0457	.0457
Avg	.1737	.4829	.0719	.6277	.4782	.4843	.5783



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		1.0242		.9282	
2		.0457		1.1305		.9831	
3		.0463		1.1305		.9831	
4		.0463		1.2003		1.1843	
5		.061		1.3443		1.3763	
6		.061		1.4746		1.4746	
7		.061		1.5043		1.5364	
8		.061		1.6004		1.6004	
9	.0762	.0781		1.5844		1.6644	.9686
10	.0914	.0937		.064		1.6644	.0926
11	1.0936	1.6461		.0474		.0457	.1067
12	1.1561	1.6613		.0625		.0457	.1067
13	1.1873	1.6918		.048		.0457	
14	1.1717	1.6461		.064		.0457	
15	1.1561			.0781		.0457	.0937
16	1.1873			.0937		.0457	.0781
17	1.2803		2.1605		.061		.061
18	1.3283		1.9204		.0457		.061
19	.061		.0914		.0457		.061
20	.061		.0914		.061		.061
21	.061		.0762		.061		.061
22	.0457		.061		.0457		.0457
23	.0457		.061		.0457		.0457
24		.0457		1.0242		.9282	
Max	1.3283	1.6918	2.1605	1.6004	.061	1.6644	.9686
Min	.0457	.0457	.061	.0474	.0457	.0457	.0457
Avg	.6668	.4861	.6374	.7927	.0523	.8587	.1418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6554		.1219		.1219	
2		.6718		.0937		.0772	
3		.7811		.0937		.0772	
4		.8642		.0926		.0762	
5		.9922		.1235		.0937	
6		1.1469		.125		.0937	
7		1.2483		.1562		.1372	
8		1.4723		.1219		.1219	
9	1.1203	1.4563		.1067		.1219	.1094
10	1.0623	1.3916		.0937			.1094
11	.0781	.1094		1.9997		1.0242	.8802
12	.0914	.0937		1.9814		1.1523	.9282
13	.0914	.0926		2.0309		1.1043	.945
14	.0914	.0937		2.0309		1.065	.9842
15	.0781	.0781		2.0622		.9602	.9686
16	.0781	.0625		2.0934		.8642	.9842
17	.1219		.125		1.3443		.9374
18	.1219		.125		1.2483		.9374
19	.1219		.1406		.1219		.1219
20	.1219		.1406		.1562		.1219
21	.1219		.1406		.1219		.1219
22	.125		.1219		.1219		.0762
23	.125		.1219		.1219		.0762
24		.1067		.1219		.1219	
Max	1.1203	1.4723	.1406	2.0934	1.3443	1.1523	.9842
Min	.0781	.0625	.1219	.0926	.1219	.0762	.0762
Avg	.2367	.6657	.1308	.7911	.4623	.4508	.5535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		.061		.3201	
2		.0463		.0457		.3441	
3		.0463		.0463		.3441	
4		.0463		.0463		.3201	
5		.061		.0457		.3201	
6		.061		.061		.3277	
7		.061		.061		.3201	
8		.0457		.5921		.3521	
9	.0762	.061	.061	.5761		.4161	.3521
10	.0914	.0772	.703	.0781		.0457	.0937
11	.2134	.5624	.703	.0926		.0457	.0762
12	.2439	.5937		.0772		.0457	.0937
13	.2439	.6249				.0457	.0781
14	.2743	.6249				.0457	.08
15	.4115	.5937				.0457	.0937
16	.583					.0457	.0937
17	.5441		.8642		.0457		.0457
18	.5441		.8002		.0457		.0457
19	.061		.0457		.061		.0457
20	.061		.061		.061		.0457
21	.0457		.061		.0457		.0457
22	.0457		.0457		.0457		.0457
23	.0457		.0457		.0457		.0457
24		.0457		.0457		.3201	
Max	.583	.6249	.8642	.5921	.061	.4161	.3521
Min	.0457	.0457	.0457	.0457	.0457	.0457	.0457
Avg	.2323	.2248	.3391	.1407	.0501	.2179	.0854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0189	.0189	.0189	.0189	.0189
2		.0189	.0189	.0189	.0187	.0189
3		.0187	.0189	.0187	.0187	.0189
4		.0187	.0189	.0187	.0189	.0189
5		.0189	.0189	.0189	.0183	
6		.0189	.0189	.0189	.0183	
7	.0189	.0189	.0189	.0187	.0189	
8	.0189	.0189	.0189	.0187	.0189	
9	.0187	.112		.1463	.1991	.0187
10	.0185	.0943		.1646	.2054	.0185
11	.112	.1132		.181	.2054	.0187
12	.0934	.112		.2033	.2263	.0189
13	.0187	.112		.2033	.2103	.0187
14	.0185	.1294		.2195	.2195	.0187
15	.0185	.1307		.2195	.2195	.0185
16		.1307		.1848	.2195	.0185
Max	.112	.1307	.0189	.2195	.2263	.0189
Min	.0185	.0187	.0189	.0187	.0183	.0185
Avg	.0373	.0678	.0189	.1045	.1159	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.2229	.6093	.2229	.1543	
2	.0943	.2303	.6093	.2229	.1543	
3	.0943	.3544		.463	.1578	
4	.0943	.463	.6093	.6001	.3155	
5	.0943	.823	.6464	.8413	.463	
6	.0943	1.1043	.6464	1.0166	.583	
7	.9069	1.1488	1.0562	1.0802	.6173	
8		1.2003	1.2717	1.2346	.7888	
9	1.1401	1.3032		1.2742		
10	1.1736	1.3375		1.3413		
11	1.1934	1.3717		1.3748		
12	1.2239	1.406		1.4232		.1928
13	1.2239	1.406		1.4232		
14	1.2239	1.3717		1.406		
15	1.1603	.7209		1.3717		.3582
16	.6464	.7373		.9431		.3582
Max	1.2239	1.406	1.2717	1.4232	.7888	.3582
Min	.0943	.2229	.6093	.2229	.1543	.1928
Avg	.6972	.9501	.7784	1.0149	.4043	.3031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2829	.2641	.3018	.2614	.2641	.4668
2	.2561	.2641	.2452	.2829	.2561	.2452	.2218
3	.2507	.2641	.2452	.2829	.2534	.2452	.2195
4	.2534	.2829	.2829	.3018	.2835	.2829	.2534
5	.3224	.3206	.3395	.3584	.3258	.3395	.3224
6	.4207	.3584	.4108	.415	.439	.4108	.439
7	.4835	.4668	.4805	.5041	.499	.4805	.4854
8	.3982	.4251	.4207	.4527	.4854	.4207	.462
9	.3439	.3658	.362	.3547	.4024	.3801	.4108
10	.333	.2713	.3429	.2957	.3155	.3155	.439
11	.3395	.3018	.3429	.2534	.2743	.3086	.3292
12	.298	.2401	.3086	.2328	.2454	.2454	.2743
13	.3086	.2454	.2641	.181	.2454	.2454	.2454
14	.2401	.2401	.2454	.2195	.2058	.2454	.1753
15	.2058	.2454	.2401	.1829	.2103	.1928	.1753
16	.2103	.2401	.2454	.2241	.1886	.2454	.1715
17		.2058	.2572	.2481	.1928	.2743	.1715
18	.394	.3506	.3761	.2947	.3012	.2804	.3403
19	.4755	.3801	.4706	.4024	.4163	.4887	.4163
20	.5175	.4938	.5121	.4435	.4755	.5121	.439
21	.4668	.4251	.499	.4481	.4066	.3601	.3881
22	.415	.3547	.4481	.3772	.3734	.3772	.3547
23	.3395	.3206	.3772	.3018	.3018	.2452	.3206
24	.2987	.2829	.2829	.3018	.2829	.2829	.2641
Max	.5175	.4938	.5121	.5041	.499	.5121	.4854
Min	.2058	.2058	.2401	.181	.1886	.1928	.1715
Avg	.3420	.3179	.3443	.3192	.3184	.3204	.3244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2641	.2641	.3018	.2614	.2263	.2195
2	.2195	.2641	.2641	.2829	.2195	.2263	.1791
3	.2149	.2452	.2452	.2829	.2149	.2263	.181
4	.2804	.2452	.2829	.3018	.2804	.2452	.1848
5	.3258	.3018	.3395	.3772	.3258	.3395	.2614
6	.4252	.3772	.3921	.415	.3658	.3734	.3467
7	.4805	.4481	.4435	.4668	.4481	.4066	.5228
8	.4024	.4066	.439	.3921	.4024	.4024	.4527
9	.3361	.3475	.362	.2926	.3582	.2896	.4108
10	.2743	.3086	.3086	.2896	.3086	.2347	.3658
11	.2804	.3086	.2743	.2686	.2743	.2401	.2401
12		.2743	.3086	.2172	.2401	.2058	.2058
13	.2804	.2743	.3086	.2195	.2401	.2058	.2058
14	.2454	.2743	.3086	.2218	.2347	.2058	.2058
15	.2058	.2454	.2743	.2195	.2401	.2058	.2058
16	.2058	.2401	.2401	.2241	.2454	.2915	.2401
17		.2401	.2401	.2195	.2454	.3155	.3086
18		.3189	.2835	.2149	.2481	.3086	.3224
19	.4938	.3801	.3841	.3582	.3506	.362	.362
20	.5601	.4755	.462	.439	.439	.4024	.4572
21	.4904	.4251	.4481	.056	.4435	.5601	.4435
22	.4904	.3734	.4338	.3734	.3921	.3772	.3734
23	.3395	.3206	.3772	.2987	.3018	.2987	.3018
24	.2561	.2829	.2829	.3018	.2641	.2452	.2241
Max	.5601	.4755	.462	.4668	.4481	.5601	.5228
Min	.2058	.2401	.2401	.056	.2149	.2058	.1791
Avg	.3366	.3184	.3320	.2931	.3060	.2998	.3009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2263	.2075	.2452	.2241	.2075	.2241
2	.2195	.2075	.1886	.2263	.2195	.1886	.1829
3	.2614	.2075	.1886	.2263	.2507	.1886	.181
4	.3292	.2263	.2263	.2263	.2561	.2263	.2561
5	.4656	.3018	.2641	.3395	.2896	.2641	.3361
6	.4706	.3018	.3734	.415	.3658	.3361	.4066
7	.5121	.5228	.4435	.5041	.4481	.499	.4904
8	.4557	.462	.439	.462	.4024	.4572	.4481
9	.3582	.4207	.3077	.3292	.3544	.3258	.4024
10	.3506	.2743	.3155	.2896	.3086	.3155	.3582
11	.2454	.3155	.3155	.2686	.2804	.2743	.2587
12	.2103	.1715	.2804	.2149	.2454	.2743	.1715
13	.2103	.1715	.1753	.1848	.2454	.2743	.1753
14	.1753	.1715	.1402	.1463	.2713	.2058	.1753
15	.1753	.1753	.1715	.2241	.2347	.1753	.1715
16	.1715	.1715	.1715	.2195	.2401	.2103	.2058
17	.2058	.1715	.1753	.2149	.2401	.2103	.3086
18	.3582	.2804	.2865	.3258	.3506	.2103	.3224
19	.439	.3801	.362	.4108	.362	.4527	.3982
20	.4805	.4572	.4572	.439	.4755	.4854	.4755
21	.4294	.4251	.4435	.4481	.4251	.4527	.4066
22	.3395	.3361	.3921	.3395	.3361	.3361	.3174
23	.3018	.2641	.3018	.2614	.2452	.2241	.2641
24	.2195	.2263	.2075	.2452	.2263	.2263	.2241
Max	.5121	.5228	.4572	.5041	.4755	.499	.4904
Min	.1715	.1715	.1402	.1463	.2195	.1753	.1715
Avg	.3167	.2862	.2848	.3003	.3041	.2925	.2984



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0377	.0377	.4534	.5304	.4161	.3563
2	.0549	.0377	.0377	.4696	.5426	.3953	.3647
3	.0543	.0377	.0377	.4915	.5487	.3795	.4359
4	.0537	.0377	.0377	.5304	.631	.4161	.4801
5	.0549	.0377	.0377	.5636	.6859	.4481	.5258
6	.0747	.0566	.0566	.7209	.7202	.5376	.5373
7	.0754	.0566	.0754	.8288	.78	.6325	.4801
8	.0747	.0566	.0566	.7956	.7773	.6401	.4428
9	.0566	.0566	.0566	.7712	.7956	.6081	.0566
10	.0526	.0377	.0526	.0377	.0377	.0312	.056
11	.1753	1.0631	1.2269	.0377	.0351	.0312	.0754
12	.2103	.6859	1.3203	.0377	.0343		.0754
13		.6859	1.2003	.0377			.0754
14	.7011	.6859	1.0517	.0373			.0754
15	.7362	.6661	2.7778	.0377			.0701
16	.7202	.8573	1.0059				.0686
17	.7011	.8573	2.6216				.0351
18	.6485	.7461	1.0227			.0312	.0554
19	.0566	.0373	.0566	.0566	.056	.0486	.056
20	.0566	.0566	.0566	.056	.0566	.0503	.0566
21	.0566	.0566	.0566	.0566	.0566	.0509	.0566
22	.0566	.0566	.0566	.0373	.0566	.0526	.0566
23	.0377	.0566	.0566	.0566	.0377	.0566	.0566
24	.056	.0377	.0377	.4481	.4801	.4161	.3795
Max	.7362	1.0631	2.7778	.8288	.7956	.6401	.5373
Min	.0377	.0373	.0377	.0373	.0343	.0312	.0351
Avg	.2096	.2917	.5431	.3125	.3812	.2912	.2053

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.5312	.4428	.0377	.0732	.0566	.056
2	.394	.5312	.4161	.0377	.0747	.0566	.0549
3	.4207	.5535	.4161	.0377	.0554	.0566	.0724
4	.4344	.5693	.4586	.0377	.0543	.0566	.0732
5	.4607	.5851	.506	.0377	.056	.0754	.056
6	.4458	.6882	.5761	.0377	.0724	.0943	.0739
7	.4534	.8002	.7042	.0377	.0709	.0943	.0924
8	.5426	.9878	.8745	.0377	.0732	.0754	.0732
9	.7377	1.0364	.9069	.0377	.0532	.0566	.0566
10	.7202	1.0974	.9259	.0377	.0537	.0514	.0566
11	.0351	.0351	.0351	.6882	.7011	.8573	.4534
12	.0351	.0351	.0351	1.3592	.2743	1.0288	.4801
13	.0351	.0351	.0343	1.3565	.823	1.0288	.4908
14	.0351	.0343	.0351	.8817	.9503		.4801
15	.0351	.0343	.0351	1.3279	1.0059	.9114	.4801
16	.0343	.0351	.0377	1.3413	1.0288	.9431	.4458
17	.0876	.0343	.0351	1.2071	1.0288	.8299	.3856
18	.0549	.0914	.0724	1.0936	.7712	.7712	.3201
19	.0754	.0934	.0943	.0838	.112	.0943	.0739
20	.0754	.0943	.0943	.0934	.0934	.0934	.0747
21		.0754	.0943	.0943	.0754	.0754	.0754
22	.0754	.0754	.0943	.0747	.0754	.0754	.0754
23	.0754	.0754		.0754	.0754	.0566	.0754
24	.0549	.0754	.4428		.0724	.0566	.0566
Max	.7377	1.0974	.9259	1.3592	1.0288	1.0288	.4908
Min	.0343	.0343	.0343	.0377	.0532	.0514	.0549
Avg	.2487	.3418	.3203	.4371	.3219	.3259	.1930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0349	.8697	.7499	.0754	.056	.0754	.0934
2	1.0242	.8697	.7274	.0754	.056	.0566	.0732
3	1.1317	.8855	.7274	.0754	.0732	.0566	.0724
4	1.1222	.9442	.7682	.0754	.0739	.0566	.0732
5	1.134	.9762	.8322	.0943	.0732	.0754	.0934
6	1.182	1.1336	.9717	.1132	.0924	.0943	.0739
7	1.1142	1.2793	1.4575	.1132	.0943	.1132	.1109
8	1.2742	1.5257	1.7695	.132	.0934	.1132	.0934
9	1.2803	1.5927	1.7204	.1132	.0754	.0943	.0943
10	1.4022	1.5089	1.7147	.0943	.0747	.0876	.0934
11	.0351	.0509	.0701	2.2382	1.9281	2.0748	.9671
12	.0343	.0526	.0754	2.5484	2.0332	2.0748	.9465
13	.0701	.0514	.0701	2.4863	1.9281	1.7147	.9465
14	.0343	.0514	.0701	2.4531	1.97	1.7147	.929
15	.0351	.0514	.0701	2.5526	1.8861	1.7703	.9054
16	.0343	.0526	.0686	1.9113	1.9547	1.9281	.8478
17	.0351	.0514	.0857	2.0243	1.8861	1.8229	.8589
18	.0905	.0724		1.8138	1.4243	1.7528	.7545
19	.1132	.0924	.132	.1017	.0747	.0914	.0924
20	.1132	.112	.132	.0943	.0943	.0934	.112
21	.1132	.0943	.132	.0943	.0943	.0754	.1132
22	.0943	.0943	.1132	.0754	.0754	.1307	.0754
23	.0943	.0754	.0943	.0754	.0754	.1307	.0754
24	.0747	.0754	.7343	.0943	.0566	.0754	.1132
Max	1.4022	1.5927	1.7695	2.5526	2.0332	2.0748	.9671
Min	.0343	.0509	.0686	.0754	.056	.0566	.0724
Avg	.5280	.5235	.5777	.8136	.6768	.6781	.3587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0377	.0377	1.442	.9389	.8718	.6226
2	.0358	.0377	.0377	1.4586	.9602	.8288	.6173
3	.037	.0377	.0377	1.4586	1.1218	.8288	.5959
4	.0362	.0377	.0377	1.5089	1.2178	.9054	.6878
5	.0354	.0377	.0377	.8718	1.3756	.9724	.7316
6	.0543	.0566	.0566	1.5939	1.4883	.9945	.7442
7	.0554	.0566	.0754	1.6787	1.5432	1.1437	.7545
8	.0747	.0566	.0566	1.7147	1.5432	1.2574	.8764
9	.0686	.0566	.0566	1.749	1.6118	1.153	.8596
10	.0701	.0514	.0526	.0377	.0351	.0351	.0724
11	1.2269	1.7909	2.1033	.0377	.0351	.0351	.0747
12	1.262	1.7147	2.2786	.0377	.0351	.0351	
13	1.2269	1.7147	2.4539	.0377	.0351	.0351	
14	1.4022	1.9281	2.489	.0377	.0351	.0351	
15	1.6827	1.6834	2.3472	.0373	.0358	.0351	
16	1.5432	1.749	2.4006	.0377	.0351	.0351	
17	1.1218	1.7147	2.4539	.0377	.0351	.0351	.0351
18	1.2656	1.6632	2.4013	.056	.0362	.0351	.0549
19	.0566	.0732	.0566	.0566	.1097	.0566	.0747
20	.0566	.056	.0566	.0566	.056	.056	.056
21	.0566	.0566	.0566	.056	.0566	.0566	.0566
22	.0566	.0377	.0566	.0566	.0566	.0373	.0377
23	.0377	.0377	.0566	.0373	.0377	.0377	.0377
24	.056	.0377	.0377	1.442	.9831	.8718	.6401
Max	1.6827	1.9281	2.489	1.749	1.6118	1.2574	.8764
Min	.0354	.0377	.0377	.0373	.0351	.0351	.0351
Avg	.4822	.6135	.8223	.6474	.5591	.4328	.4016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1109	.0943	.7655	.9686	.9686	.8718
2	.0934	.0934	.0943	.7253	.9374	.9259	.8718
3	.0934	.0934	.0943	.7274	.9374	.9374	.8718
4	.0934	.0934	.0914	.7274	.9374	.9259	.8718
5	.0934	.1307	.1132	.7499	1.0364	.9686	.9602
6	.1294	.1509	.132	.9061	1.2809	1.0494	.9145
7	.1402	.0076	.1132	1.3123	1.9292	1.5364	1.2437
8	.1267	.1307	.0943	1.5043	1.7833	1.6964	1.3535
9	.1267	.1086	.0943	1.406	1.5699	1.6129	1.4335
10	.0934	.1132	.0983	.1063	.0876	.0716	.1097
11	1.6716	2.5606	1.8884	.1086	.0191	.0724	.0943
12	1.7747	2.6147	2.6871	.0924	.0191	.0709	.0747
13	1.829	2.524	2.7526	.0924	.0191	.0709	.0747
14	1.8404	2.4874	2.7854	.0934	.0191	.0701	.0747
15	1.7924	2.4874	2.6235	.0934	.0191	.0701	.0747
16	1.8084	2.3388	2.4326	.0924	.0191	.0701	.0857
17	1.7553	2.1948	2.2929	.0924	.0191	.0701	.0857
18	1.5935	1.9387	1.8519	.0924	.0191	.1097	.0857
19	.1448	.132	.1307	.1463	.1448	.128	.1478
20	.1698	.1886	.1494	.1646	.1646	.1509	.1294
21	.1698	.1646	.1294	.1448	.1663	.1509	.112
22	.1494	.1509	.112	.1448	.1307	.132	.112
23	.1307	.132	.0934	.1109	.112	.1132	.0924
24	.1097	.1478	.0943	.7811	.9804	1.1576	1.0185
Max	1.8404	2.6147	2.7854	1.5043	1.9292	1.6964	1.4335
Min	.0934	.0076	.0914	.0924	.0191	.0701	.0747
Avg	.6684	.8790	.8768	.4659	.5550	.5471	.4902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2195	.2561	.2195	.2218	.2195	.1829
2	.2218	.2195	.2561	.2195	.2218	.2195	.1829
3	.2218	.2195	.2561	.2195	.2218	.2195	.1829
4	.2218	.2195	.2561	.2195	.2218	.2195	.1829
5	.2587	.2561	.2743	.2561	.2587	.2561	.2195
6	.3511	.2926	.2926	.3475	.4066	.3292	.2926
7	.3511	.3475	.3658	.3658	.4066	.4024	.3292
8	.3142	.3109	.3292	.3292		.4024	.3658
9	.2957	.3292	.2926	.3292	.4066	.3109	.3658
10	.3109	.3292	.2454	.3881	.3292	.4525	.2896
11	.2915	.2561	.2172	.3511	.3292	.3856	.2896
12	.2172	.2926	.2454	.2957	.2772	.3224	.2957
13	.2572	.2926	.2195	.2772	.2772	.2561	.2957
14	.3012	.2926	.2195	.2402	.2772	.2865	.2957
15	.3475	.2561	.2195	.2402	.2772	.2195	.2957
16	.3109	.2561	.1848	.2402	.2534	.2195	.2195
17	.3012	.2926	.2126	.2402	.2561	.3258	.2865
18	.2835	.2926	.2896	.2402	.2926	.2587	.2715
19	.362	.3292	.3109	.3658	.3109	.3658	.3109
20	.4207	.4024	.3841	.4024	.4024	.4024	.4024
21	.4024	.3658	.3658	.3658	.3475	.3658	.3475
22	.3658	.3658	.3292	.3475		.3292	.3109
23	.3109	.3658	.3109	.2926	.3109	.2926	.2743
24	.2772	.2743	.2561	.2561	.2587	.2561	.1829
Max	.4207	.4024	.3841	.4024	.4066	.4525	.4024
Min	.2172	.2195	.1848	.2195	.2218	.2195	.1829
Avg	.3008	.2949	.2746	.2937	.2984	.3049	.2780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0126	.0149	.0126	.0095	.0118	.0149	.0126
2	.0133	.0133	.0126	.0111	.0114	.0133	.0126
3	.0133	.0137	.0126	.008	.0114	.0126	.0126
4	.0118	.0145	.0126	.0114	.0107	.0126	.0126
5	.0118	.0145	.0126	.0118	.0103	.0122	.013
6	.0133	.013	.0114	.013	.0103	.0126	.0084
7	.0118		.0053	.0072	.008	.0069	.0084
8	.0099	.008	.0053	.0084	.0088	.0072	.0084
9	.0076	.008	.0076	.0084	.0088	.0084	.0076
10	.0091	.0084	.008	.0084	.0091	.0084	.0088
11	.0091	.0084	.008	.0099	.0091	.0084	.0095
12	.0095	.0114	.0084	.0099	.0566	.0084	.0095
13	.0095	.0126	.0084	.0088	.0566	.0095	.008
14	.0091	.0126	.0084	.0095	.0091	.0091	.008
15	.0091	.0126	.0091	.008	.0095	.0091	.0084
16	.0091		.0091	.0114	.0095	.0091	.0084
17	.0099	.0126	.0091	.0103	.0095	.0103	.0095
18	.0099	.0114	.0095	.0118	.0076	.0084	.0095
19	.0133	.0126	.0088	.0095	.0088	.0084	.008
20	.0141	.0152	.008	.0111	.0095	.0084	.0095
21	.0137	.013	.0076	.0133	.008	.0084	.0126
22	.0145	.0194	.0095	.0122	.0114	.0076	.0133
23	.0149	.0114	.008	.0099	.0137	.0114	.0141
24	.0114	.0114	.0114	.0076	.0099	.0149	.0126
Max	.0149	.0194	.0126	.0133	.0566	.0149	.0141
Min	.0076	.008	.0053	.0072	.0076	.0069	.0076
Avg	.0113	.0124	.0093	.0100	.0137	.0100	.0102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2427	.2172	.2427	.2126	.2149	.2241
2	.1791	.2427	.2172	.2427	.2126	.2149	.2241
3	.1791	.2427	.2172	.2427	.2149	.2149	.2241
4	.2126	.2427	.2172	.2427	.2454	.2507	.2241
5	.2481	.2801	.2534	.2801	.2804	.2865	.2614
6	.3155	.3361	.3258	.3361	.3982	.3582	.3734
7	.3856	.3582	.362	.3734	.3258	.3582	.3734
8	.3155	.3467	.362	.3658	.3258	.3582	.3696
9	.4607	.4115	.362	.3582	.3224	.3224	.3292
10	.4458	.4024	.3856	.3189	.394	.362	.3224
11	.3121	.439	.3086	.2835	.3582	.2481	.2149
12	.2915	.2926	.3155	.3582	.4298	.2149	.2126
13	.2058	.3292	.3155	.2481	.2507	.2149	.2103
14	.1886	.3292	.298	.2126	.2507	.1663	.1753
15	.2743	.3658	.3045	.2149	.2865	.2033	.1772
16	.2743	.3658	.2865	.2507	.2865	.1848	.1772
17	.2401	.2926	.2686	.2658	.2865		.2454
18	.2229	.2195	.2507	.2804		.3511	.2835
19	.2454	.439	.3898	.3856	.4656	.4066	.3544
20	.5175	.4755	.5175	.4908	.5014	.5228	.4607
21	.4854	.4344	.4481	.4607	.4298	.4854	.4252
22		.3982	.3361	.3506	.3582	.3547	.3224
23	.2987	.2534	.2987	.2103	.2507	.2641	.2149
24	.181	.2427	.2195	.2427	.2103	.2149	.2241
Max	.5175	.4755	.5175	.4908	.5014	.5228	.4607
Min	.1791	.2195	.2172	.2103	.2103	.1663	.1753
Avg	.2895	.3326	.3116	.3024	.3173	.2945	.2760



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.1829	.2812				
2	.2469	.1829	.2656				
3	.2469	.1829	.2656				
4	.2778	.1829	.2812				
5	.2812	.2031	.3125				
6	.3125	.2561	.4062				
7	.4999	.6802	.6874				
8	.5792	.7773	.8436				
9	.6173	.7125	.7499				
10	.5792	.7773					
11				.9877	.9061	.8482	.3858
12				.9568	.9061	.9602	.4012
13				1.0936	.9374	.9602	.3963
14				1.2498	.9374		.3963
15				1.2498		.1981	.3858
16				1.2186		.1677	.3858
17				1.1561	.8124		.3858
18				.9259		.6325	.3353
24			.1753				
Max	.6173	.7773	.8436	1.2498	.9374	.9602	.4012
Min	.2439	.1829	.1753	.9259	.8124	.1677	.3353
Avg	.3885	.4138	.4269	1.1048	.8999	.6278	.3840

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0566	.0549	.1337	.1829	.0366	.1635
2	.0554	.0566	.0549	.1337	.1829	.0366	.1635
3	.0549	.0566	.0549	.1337	.1806	.0366	.1635
4	.0549	.0566	.0549	.1337	.1806	.0366	.1635
5	.0732	.0566	.0549	.1337	.2134	.0549	.1635
6	.0732	.0943	.0732	.2134	.2469	.0914	.2134
7	.0914	.1478	.1097	.506	.3048	.1097	.2286
8	.0724	.1294	.1463	.4687	.3395	.0914	.2932
9	.0914	.1097	.0914	.4687		.3125	.1486
10	.0914	.0732	.0914	.0701	.0463	.0549	.0732
11	.4054	.695	.4687	.0716	.0549	.0549	.0732
12	.4633	.4374	.6958	.0724	.0549	.0366	.0732
13	.4458	.5312	.7274	.0732	.0549	.0366	.0739
14	.4458	.5937	.7274	.0732	.0366		.0739
15	.4755	.6249	.7116	.0739	.0366		.0732
16	.3269	.5312	.6642	.0554	.0354	.1097	.0914
17	.3765	.4687	.6562	.0747	.0366	.0914	.0747
18	.362	.3749	.6097	.1109	.0366	.1109	.0739
19	.0914	.0914	.0924	.1109	.1097	.112	.0739
20	.0934	.0914	.0934	.1109	.1097	.112	.0739
21	.0943	.0549	.0747	.1109	.0732	.1132	.0739
22	.0754		.0566	.0924	.0549	.0943	.0747
23	.0754	.0549	.0566	.0924	.0549	.0754	.0554
24	.056	.0566	.0549	.1372	.1829	.1562	.1635
Max	.4755	.695	.7274	.506	.3395	.3125	.2932
Min	.0549	.0549	.0549	.0554	.0354	.0366	.0554
Avg	.1875	.2367	.2698	.1523	.1222	.0893	.1207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0171	.0543	.0686	.0543	.0566
2	.0181	.0171	.0543	.0686	.0543	.0566
3	.0181	.0171	.0543	.0686	.0543	.0566
4	.0181	.0171	.0543	.0686		.0566
5	.0181	.0171	.0543	.0686	.0543	.0566
6	.0181	.0171	.0724	.0747	.0905	.0943
7	.0181	.1494	.1448	.1867	.1086	.1132
8	.0181	.1494	.1448	.1848	.1086	.1132
9	.1086	.1494	.0724	.1848	.1086	.112
10	.1097	.1448	.0686	.181	.112	.1086
11	.112	.1448	.1494	.181	.112	.0181
12	.1109	.056	.1494	.181	.112	.0181
13	.1109	.056	.1494	.181	.112	.0181
14	.1109	.056	.1494	.181	.112	.0181
15	.1109	.1448	.1494	.2172	.112	.0181
16	.1109	.1448	.1867	.2353	.112	.0181
24			.0724			
Max	.112	.1494	.1867	.2353	.112	.1132
Min	.0181	.0171	.0543	.0686	.0543	.0181
Avg	.0644	.0811	.1047	.1457	.0945	.0583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 201 / 11 KV SURUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0514	.0358	.1082	.128	.0934	.1021
2	.0716	.052	.0358	.1113	.128	.0974	.0894
3	.0716	.052	.0362	.1	.128	.0987	.0894
4	.0701	.0526	.0543	.1	.128	.1692	.0894
5	.0701	.0537	.0732	.1467	.16	.2858	.1036
6	.0701	.0716	.0739	.1932	.2241	.3715	.1217
7	.0701	.0905	.0876	.3418	.3201	.4344	.2824
8	.0876	.0709	.0914	.4515	.3841	.4862	.3567
9		.0514	.0716	.3909	.3201	.0724	.2317
10		.0716	.3521	.0709	.0724		.052
11	.3948	.4001	.3521		.0526	.0351	.052
12	.423	.3572	.4755		.052	.0343	.0532
13	.423	.3572	.4778		.052	.0526	.052
14	.3755	.3477	.5068			.0351	.0543
15	.3477		.5068			.0514	.0549
16	.3338	.3525	.4633		.0716	.0509	.0549
17	.3199	.2841	.4054		.0543	.0671	
18	.04	.2705	.3338		.0693		.0709
19	.0532	.0693	.0732		.0914	.0914	.0693
20	.0537	.0724	.0554		.0914	.0724	.0709
21	.0549	.0724	.0747		.0739	.0732	.052
22	.0537	.0716	.0747		.0739	.0526	.0549
23	.0526	.052	.0739		.0543	.052	.0532
24	.0732	.0514	.0351	.1082	.128	.092	.1036
Max	.423	.4001	.5068	.4515	.3841	.4862	.3567
Min	.04	.0514	.0351	.0709	.052	.0343	.052
Avg	.1628	.1468	.2009	.1930	.1299	.1304	.1006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 202 / 11 KV RETHRE DHARAN  
GAOTHAN Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2452	.2075		.2452	.2452	.2075
2	.2263	.2452	.1886	.2263	.2263	.2427	.1886
3	.2263	.2452	.1886	.2263	.2263	.2427	.1886
4	.2263	.2801	.2263	.2452	.2263	.3361	.2263
5	.3361	.3547	.3018	.3961	.3174	.3881	.3018
6	.4294	.3921	.3961	.4715	.5041	.462	.415
7	.4435	.4294	.4108	.4527	.4435	.499	.5228
8	.3696	.3511	.3547	.4294	.4066	.4572	.462
9		.2561	.3658	.3258	.3696	.3761	.3326
10		.2835	.2957	.2865	.2865		.3077
11	.2481	.181	.2743		.2481	.2686	.2561
12	.2303	.2012	.2534		.2254	.439	.2195
13	.2126	.2172	.2715		.1886	.4572	.2195
14	.1949	.2378	.2353			.2303	.2012
15	.3045	.1991	.2195		.1928	.2012	.2012
16	.3658	.2172	.4066		.2149	.2804	.181
17	.4251	.1991	.4251		.2507	.2629	.2353
18	.2658	.2328	.5304		.2204	.4755	.3045
19	.3696	.362	.5914			.6161	.6036
20	.4251	.5544	.7842			.5228	.5175
21	.4854	.4668	.7282			.4668	.4481
22	.3018	.4294	.4715			.4108	.3961
23	.2641	.3174	.3584		.3206	.2987	.3395
24	.2263	.2641	.2452	.2829	.2829	.2452	.2452
Max	.4854	.5544	.7842	.4715	.5041	.6161	.6036
Min	.1949	.181	.1886	.2263	.1886	.2012	.181
Avg	.3092	.2984	.3638	.3343	.2840	.3663	.3134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 203 / 11 KV RETHRE DHARAN AG SEPARATED AG FEEDERS HAVING SPECIAL  
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.0983	.0591	.0362	.0358	.0358	.0358
2	.064	.096	.0591	.0366	.0358	.0358	.0358
3	.064	.0926	.0591	.0366	.0358	.0358	.0358
4	.064	.1204	.06	.0366	.0358	.0362	.0354
5	.096	.1635	.0732	.037	.0358	.0362	.0351
6	.112	.2494	.0867	.0373	.0358	.0362	.0351
7	.192	.2858	.1808	.037	.0358	.0362	.0366
8	.2561	.2643	.2029	.0362	.0358	.0354	.0366
9		.2469	.1734	.0358	.0358	.0343	.0543
10		.2	.0343	.0347	.0324		.0343
11	.032		.0347		.1894	.1943	.1296
12	.0312	.0343	.0332		.2134	.1555	.1446
13	.0305	.0312	.0335		.1684	.1709	.1578
14	.0301	.0316	.0347			.1425	.1709
15	.0297	.0305	.0366		.1709	.1467	.1709
16	.0293	.0328	.0347		.1578	.1115	.1867
17	.029	.0332	.0343		.1555	.1063	.1446
18	.0324	.032	.032		.1362	.108	.1149
19	.0347	.0312	.0347		.3511	.0347	.037
20	.0347	.0351	.0366		.3511	.0351	.0366
21	.0347	.0351	.0366		.4108	.0362	.0366
22	.0343	.0354	.0362		.4338	.0354	.0366
23	.0339	.0351	.0354		.0354	.0351	.0358
24	.0366	.0339	.0591	.0358	.0362	.0358	.0354
Max	.2561	.2858	.2029	.0373	.4338	.1943	.1867
Min	.029	.0305	.032	.0347	.0324	.0343	.0343
Avg	.0621	.0978	.0625	.0363	.1376	.0726	.0755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	4.7817
Max	4.7817
Min	4.7817
Avg	4.7817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	1.8673
Max	1.8673
Min	1.8673
Avg	1.8673



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	2.7161
Max	2.7161
Min	2.7161
Avg	2.7161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 702 / 132 KV Peth Wategaon NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Feeder Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING  
OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0617
Max	.0617
Min	.0617
Avg	.0617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.061	.081	.0469	.0457		.0457
2	.0486	.061	.081	.048	.0457		.0457
3	.0486	.061	.081	.0474	.0457		.0457
4	.0648	.061	.081	.064	.0457		.0457
5	.0648	.061	.0972	.0648	.0457		.0457
6	.081	.0914	.0972	.064			.061
7	.1296	.1067	.1296	.0625			.061
8	.1296	.1524	.1943	.0625			.061
9	.1296	.1829	.1296	.0469			.061
10	.1296	.125	.0469	.0469			.0469
11	.0324	.0648	.0312	.1562			.0914
12	.0324		.0486	.1619			
13	.0324	.0469	.0312	.125			.0625
14	.0324	.0486	.0312	.125	.125	.0914	.0937
15	.0324	.0305	.0305	.1094	.125	.125	.0762
16	.0486	.0486	.0469	.125	.1067	.1094	.0914
17		.0486	.0469	.0762	.0937	.125	.0937
18	.0457	.0486	.048	.1219	.128	.1067	.1296
19	.0457	.0486	.048	.0457	.048	.0457	.0486
20	.0457	.0486	.048	.0457	.0474	.061	.0486
21	.0457	.0486	.048	.0457	.048	.0457	.0486
22	.0457	.0486	.048	.0457		.0457	.0324
23	.0457	.0324	.0486	.0457		.0457	.0324
24	.0486	.0457	.0781	.0469	.0457		.0457
Max	.1296	.1829	.1943	.1619	.128	.125	.1296
Min	.0324	.0305	.0305	.0457	.0457	.0457	.0324
Avg	.0612	.0684	.0688	.0762	.0711	.0801	.0615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0457	.0324	.0312	.0305	.032	.0305
2	.0324	.0457	.0324	.032	.0305	.0316	.0305
3	.0324	.0457	.0324	.032	.0305	.032	.0305
4	.0324	.0457	.0324	.0316	.0305	.032	.0305
5	.0324	.0457	.0324	.032	.0305	.0324	.0305
6	.0324	.061	.0648	.032	.0305	.032	.0305
7	.0648	.061	.0648	.0324	.0305	.032	.0305
8	.081	.1524	.0972	.032	.0305	.032	.0305
9	.081	.1562	.0972	.032	.0305	.0305	.0305
10	.081	.1094	.0312	.0305	.0305	.0305	.0305
11	.0324	.0312	.0305	.1219	.0305	.0457	.0305
12	1.3279		.0312	.1562	.0914	.061	
13	.0324	.0305	.0312	.1406	.061	.0762	.0625
14	.0324	.0312	.0305	.125	.061		.0625
15	.0324	.0312	.0305	.0937	.061	.0625	.0781
16	.0324	.0312	.0305	.1372	.0625	.061	.0625
17		.0324	.0305	.125	.0914	.0914	.0457
18	.0305	.0324	.032	.1219	.0625	.0781	.0324
19	.0305	.0324	.0324	.0305	.032	.0305	.0324
20	.0305	.0324	.032	.0305	.032	.0305	.0324
21	.0305		.032	.0305	.032	.0305	.0324
22	.0305		.0324	.0305	.032	.0305	.0324
23	.0305	.0324	.032	.0305	.0312	.0305	.0324
24	.0324	.0305	.061	.032	.0305	.032	.0305
Max	1.3279	.1562	.0972	.1562	.0914	.0914	.0781
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.0960	.0532	.0411	.0635	.0423	.0425	.0379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0457	.0324	.0983	.1067	.0949	.061
2	.0324	.0457	.0324	.0949	.1094	.0949	.061
3	.0324	.0457	.0324	.1265	.1094	.0926	.061
4	.0324	.0457	.0324	.128	.1067	.1296	.0762
5	.0324	.0457	.0486	.128	.125	.1265	.0762
6	.0648	.061	.0648	.1581	.125	.1265	.0762
7	.081	.061	.0486	.16	.1981	.1581	.1067
8	.0648	.061	.0648	.1898	.2743	.1875	.1372
9	.0486	.061	.0625	.2241	.25	.2187	.1372
10	.0486	.0469	.0625	.0625		.0762	.125
11	.0648	.1094	.1619	.0469		.0625	.0469
12	.0972		.1875	.0469		.0781	
13	.0972	.1406	.1875	.0457		.0457	.0312
14	.0972	.125	.2187	.0469	.0312	.0469	.0312
15	.0972	.1296	.2187	.0324	.0469	.0457	.0457
16	.1296	.1909	.1875	.0457	.0469	.0594	.0312
17		.0972	.2591	.0469	.0625	.0625	.0469
18	.1219	.0972	.2267	.061	.064	.0781	.0486
19	.0762	.0486	.0648	.061	.064	.0762	.0486
20	.0762	.0648	.064	.061	.0633	.0762	.0648
21	.061	.0648	.0648	.0762	.0633	.061	.0486
22	.061	.0486	.0617	.061	.064	.061	.0324
23	.0457	.0324	.0474	.0457	.064	.061	.0324
24	.0324	.0457	.0312	.0949	.0914	.096	.061
Max	.1296	.1909	.2591	.2241	.2743	.2187	.1372
Min	.0324	.0324	.0312	.0324	.0312	.0457	.0312
Avg	.0664	.0745	.1026	.0893	.1033	.0923	.0647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.1311	.1296	.3563	.3605	.2241	.2458
2	.081	.144	.1296	.3841	.3605	.2561	.2458
3	.081	.144	.1296	.4062	.3605	.2591	.2486
4	.0972	.1638	.1619	.4161	.3521	.2846	.2622
5	.1296	.16	.1619	.4321	.3605	.2812	.2622
6	.1943	.1966	.2267	.5121	.3768	.3086	.2949
7	.2591	.2294	.2591	.6154	.6062	.4374	.426
8	.2267	.3113	.2591	.6478	.7209	.4062	.4588
9	.1943	.2949	.2187	.5376	.426	.3749	.4915
10	.1619	.1562	.1296	.0972	.1094	.0937	.4062
11	.3239	.4534	.6249	.2187	.1562	.0625	.0937
12	.421	.421	.6249	.2187	.1875	.1219	
13	.421	.3563	.6249	.2321	.125	.1296	.1296
14	.3887	.3887	.6874	.2187	.1296	.125	.0937
15	.3887	.3887	.6562	.1658	.125	.125	.1296
16	.3887	.3563	.7125	.2267	.125	.125	.1463
17		.3239	.6226	.1943	.1718	.1875	.1296
18	.3932	.3239	.583	.2458	.1943	.149	.1619
19	.0983	.1296	.1296	.1147	.0949	.1311	.1296
20	.1147	.1296	.128	.1311	.096	.1311	.1296
21	.1147	.1134	.128	.1475	.128	.1311	.1296
22	.1147	.0972	.1296	.1147	.112	.116	.0972
23	.0983	.081	.0937	.0983	.096	.0983	.081
24	.081	.0819		.3201	.3277	.2187	.2294
Max	.421	.4534	.7125	.6478	.7209	.4374	.4915
Min	.081	.081	.0937	.0972	.0949	.0625	.081
Avg	.211	.2323	.3283	.2938	.2543	.1991	.2184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2587	.181	.2587	.2957	.2195	.2402
2	.2534	.2587	.181	.2926	.2957	.2218	.2402
3	.2896	.2957	.181	.2957	.2957	.2561	.2402
4	.2896	.2957	.2534	.3326	.2957	.2587	.2957
5	.362	.3658	.2896	.3292	.3734	.2561	.3326
6	.3982	.462	.362	.3696	.4668	.2587	.4108
7	.3982	.462	.4344	.4435	.4294		.4854
8	.362	.3326	.362	.4435			.4294
9	.362	.3326	.3696	.3734			.3696
10	.2534	.2926	.3658	.3696			.3696
11	.2534		.2957	.3292			.2926
12	.2534		.2957	.2195		.439	.2561
13	.2534	.2926		.1829		.3292	.2587
14	.2172	.2743		.2218	.2926	.2926	.1848
15	.2172	.1829			.2218	.2587	.2218
16	.2172	.2561	.2957	.2195	.2561	.2957	.1463
17				.2587	.2957	.2957	.2926
18	.3881			.3547	.4108	.3734	.362
19	.4435		.4805	.4435	.439	.5359	.4344
20	.5415		.6283	.462	.4854	.4854	.4706
21	.4805		.5975	.4805	.4904	.4938	.4887
22	.3696		.5601	.4294	.3734	.4435	.4344
23	.2957		.2987	.2987		.3326	.362
24	.2534	.2561	.1829	.2614	.2987	.2218	.2587
Max	.5415	.462	.6283	.4805	.4904	.5359	.4887
Min	.2172	.1829	.181	.1829	.2218	.2195	.1463
Avg	.3220	.3079	.3482	.3335	.3539	.3299	.3282



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0366	.0362	.037	.0366	.037	.0366
2	.0362	.0366	.0362	.0373	.0373	.0366	.0366
3	.0362	.037	.0362	.037	.0366	.037	.0366
4	.0362	.037	.0362	.0373	.0366	.0373	.037
5	.0362	.037	.0362	.0366	.037	.0366	.0549
6	.0724	.0554	.0724	.037	.0549	.0373	.0739
7	.0724	.0457	.0724	.0373	.0914	.0373	.0914
8	.0724	.0549	.0724	.0373		.037	.0732
9	.0724			.037		.0366	.0739
10	.0724	.0366	.0366	.0366		.0366	.0305
11	.0724	.0366	.0366	.0366			.037
12	.0724		.0366	.0366		.0366	.0366
13	.0724	.0366		.0366		.0366	.037
14	.0362	.0549	.0366	.0366	.0366		.0366
15	.0362	.0366	.0366	.0366	.0366	.0366	.0366
16	.0362	.0366	.0366	.0366	.0366	.0366	.0343
17			.0366	.0366	.0366	.0343	.0366
18	.0549		.0366	.0549	.037	.0732	.0362
19	.0914		.037	.0549	.037	.0549	.0724
20	.0924		.0739	.0914	.0373	.0914	.0724
21	.0914		.0739	.0914	.037	.0739	.0724
22	.0732		.0747	.0554	.037	.0549	.0362
23	.0366		.037	.0366	.037	.0549	.0362
24	.0362	.0366		.037	.0373	.037	.0366
Max	.0924	.0554	.0747	.0914	.0914	.0914	.0914
Min	.0362	.0366	.0362	.0366	.0366	.0343	.0305
Avg	.0585	.0410	.0470	.0437	.0409	.0450	.0484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.3292	.181	.0747	.2587	.2241	.2033
2	.2172	.3326	.181	.112	.2402	.2241	.2033
3	.2172	.3292	.181	.112	.2402	.2561	.2033
4	.2534	.3292	.2172	.1463	.2427	.2587	.2033
5	.2896	.3658	.2172	.1478	.2614	.2987	.2195
6	.3258	.462	.2896	.1848	.2957	.2987	.2218
7	.2534	.3881	.2896	.2195	.3696	.3292	.2926
8	.2534	.4024	.2172	.2987	.3511	.3361	.2957
9	.2896	.3696	.2195	.2987	.3142	.2957	.2743
10	.3982	.3292	.2561	.2218	.2195	.2561	.2926
11	.3982	.3696	.2957	.1829	.2195		.3658
12	.3982	.3326	.2587	.2926	.1463	.1463	
13	.362	.2957	.2587	.2926	.1463	.1097	.2896
14	.3258	.2561	.2218	.2587	.1829	.2561	.1829
15	.2896	.2587	.2561	.2587	.2218	.2218	.2957
16	.2896	.2926	.1829	.2561	.1478	.1494	.2587
17			.2926	.2218	.2195	.1848	.2957
18	.3696		.2587	.2614	.1867	.3361	.2534
19	.3142		.2587	.2957	.1867	.3881	.2534
20	.2957		.3734	.3511	.2241	.3174	.2534
21	.3658		.3361	.3292	.2587	.3696	.2896
22	.3326		.2957	.3326	.3326	.3142	.2172
23	.3109		.2987	.2772	.3326	.2957	.2172
24	.2172	.3142	.1848	.0747	.2561	.2195	.2218
Max	.3982	.462	.3734	.3511	.3696	.3881	.3658
Min	.2172	.2561	.181	.0747	.1463	.1097	.1829
Avg	.3037	.3386	.2509	.2292	.2440	.2646	.2524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 402 / 33 KV RETHARE DHARAN

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.4115	.3258	.3887	.4115	.3841	.4115
2	.3258	.3978	.2915	.4321	.4161	.4372	.4115
3	.3258	.4115	.3258	.4687	.4115	.4801	.4115
4	.4344	.4115	.4344		.4115	.5218	.4115
5	.4858	.5144	.4344	.6093	.5144	.5693	.5144
6	.5973	.5658	.4858	.6642	.6173	.5556	.5658
7	.8145	.7802	.583	.7773	.9991	.7773	.7802
8	.543	.7202	.583	.7499	.8939	.7968	.7716
9	.543	.6836	.583	.7202	.4115	.4372	.6173
10	.2715	.5344	.2915	.2915			.3281
11	.543	.6562	.6316	.583		.3749	
12	.8145	.583	.6802	.5624	.3887	.5624	.3887
13	.7602	.5344	.7499	.6962	.3749	.6093	.3749
14	.7059	.5344	.7287	.7287	.3281	.1943	.3749
15	.7059	.1943	.7956	.4858	.3281	.3749	.3401
16	.7059	.6516	.9717	.6093	.3978	.4372	.3749
17		.6516	.7499	.6316	.3887	.3887	.3887
18	.6173	.6516	.8162	.6687	.4321	.6104	.4887
19	.4115	.4344	.5281	.7202	.3841	.6104	.4344
20	.7202	.543	.7202	.7202	.4801	.5658	.4344
21	.5144	.543	.6722	.5658	.4801	.5144	.4344
22	.5144	.4344	.4858	.463	.4321	.407	.4344
23	.4115	.3258	.3887	.3561	.3401	.3641	.3258
24	.3258	.3086	.2915	.3401	.3601	.3361	.4115
Max	.8145	.7802	.9717	.7773	.9991	.7968	.7802
Min	.2715	.1943	.2915	.2915	.3281	.1943	.3258
Avg	.5399	.5199	.5645	.5753	.4637	.4917	.4534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.1715	.1886	.1886	.2058	.2058
2	.2058	.2058	.1543	.1886	.1886	.1715	.1886
3	.2058	.2058	.1543	.1715	.1886	.1715	.1715
4	.2229	.2058	.1543	.1715	.2058	.1715	.1715
5	.2401	.2401	.2058	.2401	.2229	.2058	.2058
6	.2915	.2915	.2743	.3429	.2572	.2743	.2572
7	.4115	.4115	.4115	.4458	.3944	.4115	.3429
8	.4287	.4287	.4115	.4458	.4115	.4115	.3429
9	.3772	.3944	.4801	.4115	.3944	.3772	.3772
10	.3258	.3601	.4115	.3772		.3429	.3086
11	.3258	.4115	.4115	.3258		.2401	.2743
12	.2572	.3086	.3086	.2743	.2743	.3086	.2915
13	.2229	.2743	.2572	.2572	.2401	.2401	.2743
14	.2572	.2743	.3258	.2401	.2743	.2401	.2058
15	.2572	.2401	.3086	.2572		.2058	.2401
16	.3086	.3429	.3258	.2743	.3086	.2572	.2572
17	.3429	.3086	.3772	.2743	.3601	.2058	.3086
18	.3772	.3772	.4287	.3772	.4287	.3601	.3944
19	.463	.4458	.4458	.4115	.4801	.4973	.4801
20	.5487	.5144	.5144	.4973	.5487	.4973	.4973
21	.4973	.5144	.5144	.4458	.4973	.4458	.4458
22	.4115	.4458	.4287	.4115	.3772	.3601	.3429
23	.2743	.2743	.3258	.2401	.2915	.2743	.2229
24	.2229	.2229	.1886	.2058	.2058	.2229	.2229
Max	.5487	.5144	.5144	.4973	.5487	.4973	.4973
Min	.2058	.2058	.1543	.1715	.1886	.1715	.1715
Avg	.3201	.3294	.3329	.3115	.3209	.2958	.2929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1372	.1372
2	.1543	.1543	.1543	.1543	.1543	.1372	.1372
3	.1543	.1543	.1372	.1372	.1715	.1372	.1372
4	.1715	.1543	.1372	.1372	.1715	.1372	.1372
5	.2058	.2058	.1715	.2058	.2058	.1715	.1543
6	.2401	.2743	.2572	.3258	.2572	.2229	.2401
7	.4458	.4458	.4287	.4458	.4458	.4458	.4115
8	.4801	.4287	.4458	.5144	.463	.463	.4458
9	.4287	.3601	.463	.4287	.3944	.3772	.4115
10	.3601	.3258	.3772	.4115		.3429	.4115
11	.3086	.3429	.3429	.3258		.3086	.3086
12	.2743	.3429	.3086	.3429		.3429	.2743
13	.2743	.2229	.2743	.2743	.2915		.2401
14	.2572	.2401	.2572	.1543	.2915	.2572	.1886
15	.2401	.2229	.2401	.2572	.2572	.2229	.2058
16	.2229	.2572	.2572	.2572	.2572	.2743	.2229
17	.3258	.3086	.2572	.2915	.3086	.2743	.2743
18	.2915	.3258	.3429	.3772	.4287	.3429	.3772
19	.4458	.3772	.3601	.4801	.4287	.4458	.4287
20	.4973	.5316	.5144	.5487	.4801	.4973	.4973
21	.4458	.4801		.4458	.3944	.4115	.3772
22	.3258	.3772	.3772	.3258	.3258	.3429	.2915
23	.2572	.2572	.2915	.2401	.1886	.2058	.2058
24	.1715	.1715	.1886	.2058	.1886	.1715	.1543
Max	.4973	.5316	.5144	.5487	.4801	.4973	.4973
Min	.1543	.1543	.1372	.1372	.1543	.1372	.1372
Avg	.2979	.2972	.2937	.3108	.2989	.29	.2779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0171			
2	.0171		.0171			
3	.0171		.0171			
4	.0171		.0171			
5	.0171	.0171	.0171			
6	.0171	.0171	.0171			
7	.0171	.0171	.0171			
8	.0171	.0171	.0171			
9	.0171	.0171	.0171			
10	.0171	.0171				
11				.0171		.0171
12				.0171	.0171	.0171
13				.0171		.0171
14				.0171	.0171	.0171
15				.0171	.0171	.0171
16				.0171	.0171	.0171
17				.0171	.0171	
18				.0171	.0171	
24			.0514			
Max	.0171	.0171	.0514	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0205	.0171	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.0977	.0977	.0926	.1029	.0977
2	.0977	.108	.0977	.0977	.0926	.1029	.0977
3	.0977	.1029	.0977	.0977	.0926	.1029	.0977
4	.0977	.1132	.0977	.0977	.0874	.1029	.0977
5	.1029	.1132	.0977	.0977	.0823	.108	.0977
6	.1029	.1132	.0977	.0977	.0823	.1132	.0977
7	.1132	.108	.0977	.0977	.0977	.1132	.0977
8	.1029	.108	.1029	.1029	.1029	.0463	
9	.108	.1029	.0977	.0977	.1029	.1029	.0977
10	.0977	.0977	.108	.0874	.0977	.1029	.0977
11	.0874	.1029	.0977	.0926	.1029	.0926	.0874
12	.1183	.0874	.108	.0874	.0874	.0926	.108
13	.108	.0977	.0977	.1029	.0926	.1029	.108
14	.108	.0977	.0977	.0977	.0926	.0977	.1029
15	.1029	.0926	.0977	.0823	.0823	.0874	.0874
16	.0977	.0926	.0977	.0823	.0977	.0823	.0977
17	.0977	.1029	.0977	.0772	.0772	.0823	.1029
18	.1029	.0977	.0977	.0977	.108	.0977	.0206
19	.0977	.0977	.0977	.0977	.1029	.0926	.0926
20	.0977	.1029	.0977	.1029	.1029	.1029	.0977
21	.108	.0977	.1029	.0977	.1029	.1029	.0977
22	.1029	.0977	.1029	.0977	.1029	.1029	.0206
23	.0977	.0977	.0977	.1029	.1029	.108	.0309
24	.1029	.1029	.0977	.0977	.0977	.1029	.0977
Max	.1183	.1132	.108	.1029	.108	.1132	.108
Min	.0874	.0874	.0977	.0772	.0772	.0463	.0206
Avg	.1022	.1016	.0992	.0954	.0952	.0977	.0883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 402 / 33 KV GUDE PACHGANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.5432	.6687	1.749	1.4403	5.144	5.2469
2	1.2346	1.4403	.6173	1.5432	1.3375	4.8354	5.0412
3		1.749	.5658	1.0288	1.9547	4.6811	4.9383
4	.7716	1.8519	.5144	.3086	3.0864	5.1955	4.9383
5	.7202	1.0288	.5144	.3086	3.6008	4.9383	5.0412
6	1.3375	.7716	.6173	.4115	5.0926	4.4239	4.1152
7	.8745	.6687	.7202	.7202	2.572	3.4979	3.3951
8	1.4918	.4115	.5658	1.2346	2.9321	3.5494	2.572
9	1.6975	.2058	.6687	.9259	2.8292	1.9547	3.4979
10	1.6461	.3086	.7716	1.3375	2.1091	3.9609	2.7263
11	.7716	.4115	.823	1.1317	1.9033	4.9383	1.9547
12	1.2346	.3086	1.1317	1.0802	2.572	4.0638	4.5268
13	2.0062	1.3375	1.8519	2.2119	2.9835	5.0412	5.144
14	2.6749	2.2634	1.6461	3.6008	2.7778	4.8354	4.8354
15	3.3436	2.3663	.823	5.2984	4.784	5.0412	3.4979
16	2.1091	2.8292	1.9547	5.3498	3.7551	5.9671	3.9095
17	2.6235	.9259	1.749	6.07	4.6296	4.321	3.1893
18	1.749	1.1317	1.8519	4.9897	4.8868	5.3498	4.6296
19	2.4691	1.4918	1.2346	2.8292	4.784	4.4239	3.9095
20	1.9033	1.9033	2.0576	2.3663	3.8066	4.2696	1.4403
21	2.0576	.6687	2.7778	1.3375	3.6008	4.6296	2.8807
22	1.5432	.8745	1.0288	1.0288	3.7037	4.4753	3.3951
23	2.0576	.7716	1.749	.4115	4.2181	4.2696	2.6749
24	1.0288	2.0576	.6173	2.6749	.5144	4.321	5.3498
Max	3.3436	2.8292	2.7778	6.07	5.0926	5.9671	5.3498
Min	.7202	.2058	.5144	.3086	.5144	1.9547	1.4403
Avg	1.6662	1.2217	1.1467	2.0812	3.1614	4.5053	3.8687



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0972	.0934	.0324	.0671	.0373	.0244
2	.0648	.096	.1372	.0305	.0335	.0366	.0248
3	.0648	.096	.1372	.0305	.0335	.0366	.0255
4	.0648	.0937	.1372	.0305	.0503	.0373	.0259
5	.0648	.0914	.1417	.0305	.0503	.0373	.0259
6	.0972	.08	.1772	.0305	.0503	.0549	.04
7	.1619	.1269		.0486	.0335	.0514	.0457
8	.1875		.2606	.0503	.0503	.056	.064
9	.1858		.2429	.0503	.0335	.0514	
10	.1692	.1858	.0457	.0457	.0497	.0474	.0648
11	.064	.0434	.0457	.2012	.1677	.12	.1067
12	.0474		.0305	.2515	.1524	.108	.1067
13	.0446	.0343	.0305	.285	.1219	.1219	.1067
14	.0452	.0514	.0305	.2347	.1257	.1115	.1372
15	.0514	.029	.0305	.2515	.1524	.0991	.1524
16	.0686	.0343	.0305	.285	.1149	.0991	.1372
17	.0625	.0514	.0324	.2347	.0867	.1425	.1543
18	.0648	.0514	.0324	.2683	.1115	.1532	.1457
19	.0671	.0594	.0486	.0671	.0457	.0446	.0514
20	.0655	.0457	.0486	.0671	.0514	.0429	.0514
21	.0671		.0486	.0671	.0514	.0429	.0514
22	.0457	.0514	.0486	.0503	.0429	.0429	.0343
23	.0452	.0457	.0362	.0335		.0236	.0343
24	.0543	.0446	.0867	.0324	.0503	.0373	.024
Max	.1875	.1858	.2606	.285	.1677	.1532	.1543
Min	.0446	.029	.0305	.0305	.0335	.0236	.024
Avg	.0800	.0705	.0849	.1129	.0751	.0682	.0711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0328	.0267				
2	.0305	.0324	.0343				
3	.0305	.032	.0343				
4	.0305	.032	.0343				
5	.0305	.0312	.0343		.1219		
6	.0305	.0301	.0343				
7	.048	.0734					
8	.061		.1677				
9	.0579		.1781				
10	.0587	.0572					
11				.1341	.0686	.0533	.0305
12				.1509	.0686	.0676	.0305
13				.1341	.0701	.0705	.0305
14				.1341	.0549	.0549	.0305
15				.1174	.061	.04	.0305
16				.1341	.0724	.04	.0457
17				.1006	.0724	.0229	.0526
18				.1174	.0762	.0389	.0343
24			.0255				
Max	.061	.0734	.1781	.1509	.1219	.0705	.0526
Min	.0305	.0301	.0255	.1006	.0549	.0229	.0305
Avg	.0409	.0401	.0633	.1278	.0740	.0485	.0356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.0943	.0943	.1097	.1341	.1307	.1143
2	.1463	.0943	.0934	.1097	.1006	.132	.1143
3	.1463	.0943	.0943	.1097	.1006	.1307	.1143
4	.1463	.1132	.132	.1097	.1006	.132	.1132
5	.1829	.1509	.132	.1646	.1006	.132	.1509
6	.2195	.2075	.1886	.1829	.1006	.1886	.1715
7	.2614	.2054		.1829	.1677	.1867	.2195
8	.2218		.1494	.1715	.1677	.1867	.1867
9	.1829		.1463	.1677	.1341	.1867	
10	.1463	.1109	.1463	.1677	.1494	.1478	.128
11	.1109	.112	.1097	.1677	.1494	.1109	.128
12	.128		.1097	.1677	.1494	.1097	.1097
13	.1132	.0914	.1097	.1677	.112	.1109	.1097
14	.132	.1097	.1097	.1677	.0732	.1109	.1097
15	.1254	.1086	.1097	.1677	.1097	.1075	.1097
16	.1075	.1097	.1097	.1341	.0914	.1417	.128
17	.1417	.1463	.1086	.1341	.1402	.1214	.1463
18	.1753	.168	.1463	.1677	.1646	.1595	.1463
19	.1867	.1448	.1829	.2012	.181	.1646	.1829
20	.2054	.2241	.2195	.2012	.2614	.2054	.2195
21	.1867		.2012	.1677	.2241	.1886	.2195
22	.1509	.1886	.1448	.1677	.1509	.1509	.1829
23	.1132	.1509	.1463	.1219		.1143	.1463
24	.1463	.0943	.1509	.1097	.1341	.1307	.1143
Max	.2614	.2241	.2195	.2012	.2614	.2054	.2195
Min	.1075	.0914	.0934	.1097	.0732	.1075	.1097
Avg	.1593	.1360	.1363	.1550	.1390	.1450	.1463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543		.056	.0543	.0671	.056	
2	.0543		.0566	.0543	.0671	.056	
3	.0543		.0566	.0543	.0671	.056	
4	.0543		.0566	.0543	.0686	.056	
5	.0724		.0566	.0543	.0686	.056	
6	.0905	.0924	.1132	.0724	.0671	.0934	.0924
7	.1097	.0914		.0905	.1006	.0934	.1097
8	.0914		.0732	.0671	.1006	.0934	.0914
9			.0543	.1006	.1006	.1097	
10		.0701	.0543	.1006	.0509	.0686	.0543
11		.0532	.0543	.1006	.0514		.0543
12			.0543	.1006	.0514		.0543
13		.0312	.0543	.1006	.0514		.0543
14		.0514	.0543	.1006	.032		.0543
15			.0543	.1006	.0686		.0543
16	.064	.0549	.0543	.1006	.0497		.0543
17	.0701	.0857	.0543	.1006	.0819		.0543
18		.0857	.0724	.1006	.0857	.0972	.0543
19	.0732	.1052	.1086	.1006		.0716	.0724
20	.1267	.1448	.1267	.1341	.1494	.1086	.1086
21	.0924		.1086	.1006	.1097	.0914	.0905
22	.0739	.1097	.1086	.1006	.0934	.0579	.0701
23		.0747	.0905	.0671			.0543
24	.0543		.0747	.0724	.0671	.056	
Max	.1267	.1448	.1267	.1341	.1494	.1097	.1097
Min	.0543	.0312	.0543	.0543	.032	.056	.0543
Avg	.0757	.0808	.0716	.0868	.075	.0763	.0693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB  
STATIONFeeder No / Name : 401 / 33 KV JYOTIRLING LIS  
Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	30-JUN-18	02-JUL-18
HR	Load (MW)	Load (MW)
10	.5093	
11	.5093	.4024
12		.4024
13	.5093	.4024
14		.4024
15	.5093	.4024
16	.5093	.4024
Max	.5093	.4024
Min	.5093	.4024
Avg	.5093	.4024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB  
STATION

Feeder No / Name : 402 / 33 KV MANGLE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344		.4784	.5487	.7042	.2572	
2	.4207		.4887	.6173	.7042	.4115	
3	.439		.4887	.6173	.7042	.4481	
4	.4344		.4887	.631	.7042	.4115	
5	.4344		.5973	.7362	.7545	.3978	
6	.543		.7059	.7973	.8048	.543	
7				.9328	.9556	1.0288	
8			1.4563	1.3077	.9556	1.0288	.7888
9			1.278	1.2574	.9054	.7202	.6379
10		1.1797	.7865	.7545	.4218		.631
11		1.0059	1.3603	1.0059	.6642		.6447
12			1.0288	1.358	.6241		
13		.5155	.8842	1.4083	.6019		.8413
14			1.5089	1.2574	.5281		.4372
15		.6464	1.5089	1.2071	.5281		.8413
16		.639	1.4083	1.2071	.5796		.7407
17		.459	1.3077	1.0059	.6687		.6401
18		.5721	1.0974	1.0059	.6687		.6401
19		.6241	.6859	.6036	.503		.5624
20		.6802	.7042	.7042	.6036		.6802
21			.6104	.6036	.5533		.583
22		.583	.5487	.6036	.4372		.4858
23		.4858	.5487	.6036			.3887
24	.3932		.4973	.5624	.7042	.4115	
Max	.543	1.1797	1.5089	1.4083	.9556	1.0288	.8413
Min	.3932	.459	.4784	.5487	.4218	.2572	.3887
Avg	.4427	.6719	.8899	.8890	.6643	.5658	.6362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.0286	.0286	.0827	.0743	.0419	.0667
2	.0263	.0286	.0191	.092	.0743	.0419	.0695
3	.0267	.029	.0191	.0987	.072	.0419	.0667
4	.0267	.029	.0194	.0987	.072	.0419	.0676
5	.0263	.0282	.0194	.1355	.0743	.0419	.0667
6	.0267	.0274	.04	.1372	.0743	.0697	.08
7	.0394	.0429	.04	.1524	.125	.0827	.096
8	.0267	.0429	.0495	.2286	.1429	.1063	.1334
9	.0533	.029	.0488	.2054	.1486	.1006	.0533
10	.0533	.045	.0372	.0429	.0406	.04	.0267
11	.0827	.0814	.1829	.0429	.0389	.0267	.0286
12		.0995	.1898	.0429	.0225	.04	
13	.0495		.1898	.0429	.0332	.0394	.029
14	.0867	.0486	.1898	.0429	.0366	.04	.0286
15	.0743	.1578	.192	.0429	.0297	.0267	.0286
16	.0743	.1555	.1943	.0429	.0303	.0394	.0286
17	.1036	.192	.1898		.0286	.04	.0286
18	.12	.1646	.1898	.0286	.0434	.04	.0429
19	.0594	.0549	.04	.0572	.0442	.0533	.0579
20	.0594	.0714	.0394	.0572	.0549	.0667	.0572
21	.0594	.0705	.04	.0594	.0526	.0526	.0572
22	.0594	.0533	.04	.0446	.0457	.0406	.0412
23	.0429	.0314	.0278	.0446	.0337	.0406	.0412
24	.04	.0429	.0286	.0686	.0709	.041	.0686
Max	.12	.192	.1943	.2286	.1486	.1063	.1334
Min	.0263	.0274	.0191	.0286	.0225	.0267	.0267
Avg	.0541	.0676	.0856	.0822	.0610	.0498	.0550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.1429	.1758	.0625	.0701	.0617	.0791
2	.1581	.1572	.1758	.0633	.0709	.0625	.08
3	.176	.1572	.1758	.064	.0716	.0617	.0791
4	.1739	.1429	.1758	.064	.0716	.0617	.08
5	.2241	.1715	.1758	.0633	.0716	.0617	.08
6	.253	.2143	.2641	.064	.0716	.0678	.08
7	.3201	.3658	.4268	.08	.0914	.0867	.0949
8	.4111	.5535	.571	.0949	.0895	.1029	.096
9	.3163	.5376	.5937	.0791	.0886	.0791	.0819
10		.4725	.0791	.0949	.0876	.08	.0781
11	.0716	.1075	.096	.7116	.6483	.3953	.2751
12	.0716	.096	.0633	.8642	.6882	.3841	.2824
13	.1017	.0834	.0633	1.0202	.6706	.3795	.2896
14	.0838	.0791	.08	.9717	.703	.3841	.2896
15	.0848	.08	.0633	.8802	.7499	.3795	.3185
16	.0671	.108	.064	.8322	.7968	.3768	.3185
17	.0838	.0819			.7253	.3201	.3102
18	.0848	.08	.0949	.6958	.679	.3321	.2858
19	.0895	.0876	.08	.0857	.0903	.0791	.0781
20	.1086	.0924	.0633	.0857	.0857	.0949	.0848
21	.0905	.0905	.064	.0876	.0857	.0791	.0838
22	.0716	.0895	.064	.0876	.0671	.08	.0633
23	.0716	.0671	.0633	.0686	.0617	.0791	.0579
24	.0791	.0716	.1758	.0633	.0686	.0617	.0791
Max	.4111	.5535	.5937	1.0202	.7968	.3953	.3185
Min	.0671	.0671	.0633	.0625	.0617	.0617	.0579
Avg	.1457	.1721	.1673	.3124	.2877	.1730	.1519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0274	.0149	.096	.072	.0562	.08
2	.0377	.0267	.0149	.0974	.0709	.0572	.08
3	.0377	.0267	.0145	.096	.0743	.0572	
4	.0377	.0267	.0151	.0974	.0743	.0562	.08
5	.0377	.0282		.0987	.08	.0562	.08
6	.0377	.0286		.0974	.0857	.0676	.08
7	.0566	.0429		.096	.1219	.088	.0823
8	.0566	.0429		.1372	.1509	.1217	.08
9	.0377	.0286		.1486	.1143	.092	.1067
10	.0286	.0309	.0412	.0143	.0316	.04	.0274
11	.1417		.0305	.0143	.0316	.04	.0286
12	.1067		.1094	.0143	.0156	.0267	.0286
13	.1097		.128	.0286	.0236	.0263	.0286
14	.1097	.0777	.1739	.0286	.0301	.0259	.029
15	.096	.1097	.16	.0286	.0297	.0267	.029
16	.1097	.0867	.1581	.029	.021	.0263	.0286
17	.1097	.1235	.192		.0271	.0267	.0286
18	.1097	.1067	.1898	.029	.029	.0274	.0286
19	.0446	.0305	.0282	.0446	.0286	.0267	.0434
20	.0429	.032	.0267	.0457	.0312	.04	.0429
21	.0412	.032	.0267	.0457	.0312	.0267	.0429
22	.0267	.0316	.0263	.0446	.0312	.0263	.0434
23	.0267	.0305	.0366	.0286	.0305	.0267	.0274
24	.0377	.0267	.0151	.08	.072	.0562	.0812
Max	.1417	.1235	.192	.1486	.1509	.1217	.1067
Min	.0267	.0267	.0145	.0143	.0156	.0259	.0274
Avg	.0633	.0475	.0738	.0626	.0545	.0467	.0525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0905	.0934	.0924	.0924	.1075	.0914
2	.0924	.0905	.0934	.0914	.0924	.1075	.0924
3	.0914	.0914	.0934	.1109	.0924	.1075	.0914
4	.1109	.0914	.0934	.1109	.0914	.1075	.0924
5	.1494	.1478	.0934	.1463	.1478	.124	.1463
6	.1494	.1829	.168	.1991	.181	.197	.2033
7	.1772	.2402	.2195	.2218	.2353	.2279	.2195
8	.2126	.1772	.181	.2378	.2279	.2454	.2402
9	.1829	.1734	.1417	.2195	.1753	.2058	.2012
10	.128	.1526	.1848	.1629	.1372	.2012	.1578
11	.0876	.1341	.1463	.1174	.1029	.1227	.1578
12	.0857	.1341	.1109	.0838	.1029	.1075	.12
13	.1017	.0914	.1097	.0838	.0995	.1097	.1134
14	.1017	.0857	.128	.0838	.0671	.1109	.0983
15	.0838	.0671	.112	.0829	.0857	.128	.0819
16	.1006	.0693	.1097	.0829	.0972	.0739	.0983
17	.1017	.0876	.128		.1134	.1097	.1187
18	.1715	.104	.1848	.1578	.1543	.1646	.1715
19	.1949	.1433	.2126	.2172	.2058	.1848	.1991
20	.2378	.2033	.2561	.2534	.2507	.2218	.2172
21	.2195	.1848	.2012	.2195	.2149	.1829	.2012
22	.1848		.1509	.1829	.1991	.1433	.1646
23	.1478	.112	.128	.1109	.1448	.1254	.1086
24	.0924	.1075	.0934	.0914	.1097	.1075	.0905
Max	.2378	.2402	.2561	.2534	.2507	.2454	.2402
Min	.0838	.0671	.0934	.0829	.0671	.0739	.0819
Avg	.1374	.1288	.1431	.1461	.1425	.1468	.1449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1478	.1109	.1478	.1463	.1463	.0924
2	.1294	.1478	.1109	.1463	.1463	.1463	.0914
3	.1294	.1478	.1109	.1478	.1463	.1463	.0914
4	.1463	.1478	.1109	.1646	.1478	.1463	.0914
5	.2033	.1867	.1109	.1848	.1663	.1463	.1294
6	.2378	.2534	.2033	.2195	.2033	.2427	.1848
7	.2957	.2865	.2743	.2353	.2926	.2743	.2561
8	.2957	.2507	.2896	.2195	.2896	.2534	.2218
9	.2378	.2126	.2507	.2195	.2481	.2033	.2402
10	.1772	.1949	.2195	.2126	.181	.2012	.2012
11	.1433	.1772	.2149	.1772	.181	.1829	.1829
12	.1402	.1734	.1791	.1372	.1433	.1478	
13	.1543	.144	.1595	.1372	.1227	.1463	.1772
14	.1543	.1086	.1463	.1372	.124	.128	.1543
15	.156	.1543	.1646	.1372	.1097	.1097	.1526
16	.1227	.1387	.1772	.1387	.1402		.1696
17	.1402	.1844	.2195		.1823	.0924	.1865
18	.1928	.2058	.2195	.2374	.2543	.2195	.2601
19	.2481	.2715	.2957	.2896	.2835	.2561	.362
20	.3292	.3547	.4108	.3658	.3475	.3326	.3292
21	.3077	.3174	.3326	.3174	.2926	.2926	.2926
22	.2378	.2614	.2561	.2378	.2378	.1991	.2218
23	.1848	.1307	.1829	.1629	.1829	.1829	.1629
24	.1478	.1463	.1109	.1463	.1448	.1463	.0924
Max	.3292	.3547	.4108	.3658	.3475	.3326	.362
Min	.1227	.1086	.1109	.1372	.1097	.0924	.0914
Avg	.1941	.1977	.2026	.1965	.1964	.1888	.1889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1307	.1509	.1663	.1463	.1132	.1097
2	.1307	.132	.12	.1646	.1478	.1132	.1109
3	.1307	.132	.1187	.1663	.1494	.1132	.1109
4	.132	.132	.1187	.1463	.1494	.1132	.112
5	.168	.1494	.1147	.1848	.168	.1132	.1478
6	.2427	.2054	.197	.2195	.2054	.1698	.2218
7	.2957	.2801	.2772	.2957	.2957	.2987	.2801
8	.2402	.2743	.2614	.3109	.2987	.2587	.2957
9	.2241	.2561	.2772	.2054	.2987	.2263	.2561
10		.2195	.2075	.2328	.2218	.2012	.2126
11	.1848	.112	.1867	.1791	.181	.168	.1791
12	.181	.1417	.2012	.1772	.1612	.1463	.1417
13	.1402	.1509	.1829	.1254	.1254	.1254	.124
14	.1402	.1629	.1097	.124	.0934	.124	.1227
15	.1402	.1463	.1478	.0886	.0943	.1109	.1052
16	.1417	.1663	.128	.1433	.0934	.1109	.1052
17	.1595	.1294	.1109		.112	.1463	.1063
18	.1791	.128	.197	.1433	.197	.1829	
19	.2353	.2218	.2561	.2195	.2378	.197	.2926
20	.3292	.3734	.3326	.3109	.3361	.3109	.2561
21	.3174	.3361	.3109	.3142	.2987	.2957	.2378
22	.2987	.2801	.2987	.2587	.2614	.2195	.1867
23	.1867	.2075	.1867	.1543	.2075	.2033	.132
24	.128	.132		.168	.1646	.1509	.112
Max	.3292	.3734	.3326	.3142	.3361	.3109	.2957
Min	.128	.112	.1097	.0886	.0934	.1109	.1052
Avg	.1937	.1917	.1953	.1956	.1935	.1755	.1721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 401 / 33 KV SUZLON

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9044	1.4003	.3395	3.0247	2.5206	5.0926	6.6095
2	1.9044	1.3443	.5093	2.8006	2.6886	6.394	6.5535
3	1.9605	1.1203	.2263	2.8006	2.8006	6.7901	6.3855
4	2.1285	1.2323	.2263	.3361	2.5766	5.7716	5.8814
5	1.6804	1.4003	.2263	.3921	2.3525	5.4321	5.4332
6	1.7924	.3921	.1132	.3361	3.6969	4.6399	4.9291
7	2.0165	.8402	.3395	.2241	3.6969	5.6019	5.2652
8	2.2405	.112	.3395	.3361	3.3048	5.8282	4.313
9		.112	.3395	.4481	3.8089	4.4136	5.0412
10	4.369	.3395	1.2323	1.0082	2.5463	5.8253	7.0016
11	.6722	.1698	1.0082	1.2323	5.6584	7.0016	3.0247
12	1.4003	.7922	1.5684	1.1203	2.1502	6.3295	5.6573
13	3.6408	3.0556	1.9605	4.369	3.3951	4.8731	5.4893
14	4.0889	1.6409	2.1845	3.6969	3.3951	7.1696	6.8896
15	3.9209	2.9424	1.6804	5.6013	3.7346	7.1136	6.8336
16	2.5766	2.2634	4.7051	6.7215	4.8663	7.0016	5.8253
17	3.4728	1.6409	3.9209		7.0731	5.6573	6.4415
18	3.5288	1.4146	1.7924	5.7133	5.2624	4.6491	3.4168
19	2.7446	1.0751	2.9687	5.8814	6.2243	6.4975	5.0972
20	3.2487	1.6975	3.5288	4.481	6.3375	6.1614	4.0329
21	3.4728	1.4712	2.4646	3.0247	4.7531	6.4415	2.8006
22	3.0247	.9619	1.9044	1.9044	6.8467	6.8336	5.3772
23	1.0082	1.0185	3.3048	.168	6.7901	4.7051	5.8253
24	1.9044	1.1203		2.9127	.4481	6.4506	4.0329
Max	4.369	3.0556	4.7051	6.7215	7.0731	7.1696	7.0016
Min	.6722	.112	.1132	.168	.4481	4.4136	2.8006
Avg	2.5522	1.2316	1.6036	2.5449	4.0387	5.9448	5.3399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1578	.1387	.197	.1772	.1772	.1772
2	.1578	.1578	.1387	.1791	.1543	.1612	.1612
3	.1753	.1753	.1387	.1772	.1595	.1612	.1595
4	.1753	.1753	.1214	.181	.1595	.1612	.1612
5	.2103	.2103	.1214	.2149	.1772	.1791	.2126
6	.2454	.2454	.156	.2507	.2481	.2507	.2865
7	.2629	.2454	.208	.2865	.2835	.2865	.3224
8	.2629	.2279	.2254	.2865	.3045	.2865	.2865
9	.2454	.208	.2507	.2507	.2686	.2507	.2507
10	.2454	.2254	.2507	.1791	.2303	.2507	.2507
11	.2103		.2658	.2149	.2303	.2149	.197
12	.1578	.1907	.2126	.2149	.2254	.2328	
13	.1753	.208	.1949	.197	.2126	.2149	.1791
14	.1753	.208	.2149	.197	.1949	.197	.1791
15	.1928	.1928	.2126	.2149	.1949	.2149	.1791
16	.1928		.2481	.197	.2303		.197
17	.2454		.2454	.2149	.2658	.2507	.197
18	.2804	.3121	.2454	.2865	.2835	.3224	.3544
19	.3506	.3988	.3506	.333	.2835	.3544	.3544
20	.333	.3467	.4207	.3506	.3544	.3721	.3544
21	.3155	.2804	.3155	.333	.3189	.3366	
22	.2804	.208	.2804	.2804	.2835	.2835	.2658
23	.2103	.1907	.2454	.1949	.2303	.2126	.2126
24	.1753	.1928		.2126	.1772	.1772	.1772
Max	.3506	.3988	.4207	.3506	.3544	.3721	.3544
Min	.1578	.1578	.1214	.1772	.1543	.1612	.1595
Avg	.2264	.2266	.2262	.2352	.2353	.2413	.2325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1715	.1907	.0187	.016	.0187	.0179
2	.112	.1715	.1886	.0187	.0164	.0189	.0171
3	.1311	.1829	.1928	.0187	.0168	.0187	.0175
4	.1341	.1791	.2328	.0187	.016	.0189	.0152
5	.1457	.1791	.2658	.0187	.0166	.0189	.0152
6	.1543	.1677	.3772	.0185	.0335	.0187	.0175
7	.176	.2241	.4161	.0183	.0305	.0183	.0179
8	.2469	.2812	.4557	.0189	.0351	.0181	.0171
9	.2743	.3605	.4973	.0189	.0171	.0183	.0177
10	.192	.3391	.0173	.0358	.0177	.0181	.0179
11	.0373	.0343	.0179	.4908	.2743	.2623	.1612
12	.0358	.0177	.0171	.4321	.2949		
13	.0373	.0183	.0175	.463	.2915	.2656	.124
14	.0358	.0177	.0175	.4854	.2623	.2006	.1227
15	.0373	.0173	.0177	.4161	.2623	.2241	.1402
16	.0373		.0175	.3841	.2469	.1698	.1595
17	.0358	.0171	.0358	.3978	.2187	.192	.1949
18	.0347	.0177	.0358	.3437	.2214	.2035	.124
19	.0381	.0171	.0362	.032	.0179	.0171	.0354
20	.0373	.0177	.0183	.032	.0181	.0171	.0377
21	.0358	.0175	.0187	.032	.0183	.0173	.0377
22	.0343	.0179	.0187	.032	.0183	.0179	.0377
23	.0343	.0183	.0187	.032	.0187	.0179	.0187
24	.0366	.0343	.2126	.0187	.0168	.0187	.0187
Max	.2743	.3605	.4973	.4908	.2949	.2656	.1949
Min	.0343	.0171	.0171	.0183	.016	.0171	.0152
Avg	.0896	.1095	.1389	.1582	.0998	.0787	.0601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0151	.0305	.048	.0151	.0152	.0151	.0149
2	.0143	.0305	.0328	.0149	.0152	.0151	.0149
3	.0133	.0305	.0339	.0151	.0152	.0151	.0149
4	.0126	.0305	.0332	.0149	.0152	.0151	.0149
5	.0116	.0305	.048	.0147	.0152	.0151	.0149
6	.0133	.0457	.1029	.0151	.0152	.0151	.0149
7	.0278	.061	.1486	.0151	.0152	.0151	.0149
8	.0541	.0914	.1486	.0152	.0152	.0151	.0149
9	.0762	.1265	.1448	.0152	.0152	.0151	.0149
10	.1067	.0781	.0145	.0152	.0152	.0151	.0149
11	.0152	.016	.0145	.1372	.029	.0602	.0446
12	.0152	.0164	.0145	.1219	.0271	.0602	
13	.0152	.0156	.0145	.1372	.0267	.0452	.0297
14	.0152	.0156	.0145	.1219	.0259	.0452	.0149
15	.0152	.0154	.0145	.1219	.0259	.0301	.0297
16	.0187		.0145	.1372	.0263		.0446
17	.0152		.0145	.1372	.0251	.0301	.0743
18	.0152	.0164		.1219	.0594	.0301	.0267
19	.0152	.0154	.0145	.0151	.0149	.0149	.0267
20	.0152	.0152	.0145	.0151	.0149	.0149	.0149
21	.0152	.0158	.0145	.0151	.0149	.0149	.0149
22	.0152	.0164	.0145	.0151	.0151	.0149	.0149
23	.0152	.0164	.0149	.0152	.0151	.0149	.0145
24	.0152	.0152	.048	.0151	.0152	.0151	.0149
Max	.1067	.1265	.1486	.1372	.0594	.0602	.0743
Min	.0116	.0152	.0145	.0147	.0149	.0149	.0145
Avg	.0234	.0339	.0425	.0532	.0203	.0236	.0224



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.032	.0339	.2881	.2846	.128	.0949
2	.0324	.032	.032	.2881	.253	.128	.0949
3	.0335	.032	.0328	.2846	.253	.128	.0949
4	.0324	.032	.0343	.2846	.2846	.128	.0949
5	.032	.064	.0309	.2846	.253	.1265	.0949
6	.032	.064	.032	.3163	.253	.1562	.0949
7	.064	.064	.0655	.3795	.3479	.1875	.1581
8	.064	.064	.0633	.4744	.4428	.25	.1898
9	.032	.064	.0648	.4428	.3953	.2812	.1898
10	.032	.0655	.0648	.064	.4111	.0312	.0625
11	.16	.2713	.5087	.064	.0316	.0312	.0625
12	.2241	.2241	.5571	.064	.0316	.0625	
13	.3201	.2984	.4588	.064	.0316	.0625	.0633
14	.3201	.3277	.5506	.064	.0316	.0312	.0625
15	.3201	.373	.5761	.064	.0316	.0312	.0625
16	.3521	.3437	.5761	.064	.0316		
17	.3521	.3521	.583	.064	.0316	.0312	.0625
18	.3521	.3163	.6154	.064	.0633	.0625	.0625
19	.064	.064	.0648	.0633	.0633	.0312	.0625
20	.064	.0633	.0648	.0633	.0633	.0312	.0625
21	.064	.064	.0648	.0633	.0633	.0312	.0625
22	.064	.0655	.0655	.061	.0633	.0312	.0312
23	.064	.032	.0655	.0316	.0633	.0316	.0312
24	.032	.032	.0328	.2561	.2846	.0949	.0949
Max	.3521	.373	.6154	.4744	.4428	.2812	.1898
Min	.032	.032	.0309	.0316	.0316	.0312	.0312
Avg	.1308	.1392	.2183	.1732	.1693	.0917	.0859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0739	.0732	.0934	.0754	.0747	.0566
2	.0526	.056	.0537	.0754	.0739	.0754	.056
3	.0514	.0554	.0566	.0754	.056	.0754	.0554
4	.0543	.056	.056	.0754	.0754	.0754	.0754
5	.0754	.0943	.0732	.0934	.0934	.0934	.0934
6	.1227	.1494	.124	.1494	.1478	.1663	.128
7	.1463	.1294	.1402	.1629	.1254	.1463	.1791
8	.1433	.1254	.1543	.1578	.1463	.1417	.1448
9	.1227	.1463		.1254	.1227	.1052	.128
10	.1075	.1417	.1619	.1227	.1052	.1086	.1067
11	.0876	.124	.0972	.1187	.1132		.12
12	.0949	.104	.1134	.0838	.0895		
13	.0876	.1063	.0857	.0895	.0686	.0895	.0867
14	.0857	.0914	.0857	.0678	.052	.0686	.0709
15	.0772	.0943	.1029	.0497	.056	.0701	.0716
16	.0914		.112	.0625	.0537	.0526	.0543
17	.096	.0914	.1134	.096	.0625	.081	.1134
18	.0926	.1646	.1094	.108	.0848	.1107	.1174
19	.1492	.1949	.1696	.1372	.1254	.156	.1174
20	.1629	.1867	.1991	.1791	.1478	.1928	.0354
21	.1463	.1848	.1663	.1753	.1494	.1612	.1753
22	.1646	.1698	.1494	.1433	.1307	.1307	.1448
23	.0924	.1294	.1307	.0924	.0934	.0924	.112
24	.0943	.0747	.0943	.112	.0747	.0747	.056
Max	.1646	.1949	.1991	.1791	.1494	.1928	.1791
Min	.0514	.0554	.0537	.0497	.052	.0526	.0354
Avg	.1030	.1193	.1140	.1103	.0968	.1065	.0999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0091	.0091		.0095	.0099	.0084
4	.0095	.0091	.0084	.0103	.0095	.0084
5	.0091	.0091	.0099	.0095	.0103	.0084
6	.0091	.0091	.0099	.0099	.0099	.0084
7	.0091	.0091	.0091	.008	.0076	.0099
8	.0091	.0091	.0084	.0084	.0076	.0099
9	.0091	.0099	.008	.0084	.0088	.0099
10	.0091	.0099	.0091	.0084	.0076	.0099
11	.0091	.0107	.1578	.0084	.0076	.0076
12	.0091	.0107	.0762	.0084	.0076	
13	.0091	.0099	.0754	.0084	.0076	.0084
14	.0091	.0099	.0762	.0084	.0076	.0084
15	.0091	.0099	.0762	.0084	.0076	.0084
16	.0091	.0107	.0754	.0084	.0076	.0084
17	.0091	.0107	.0107	.0084	.0076	.0095
18	.0091	.0107	.0114	.0084	.0076	.0095
Max	.0095	.0107	.1578	.0103	.0103	.0099
Min	.0091	.0091	.008	.008	.0076	.0076
Avg	.0091	.0099	.0415	.0087	.0083	.0089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0257	.056		.0137	.0503	.056
2	.0269	.056		.0143	.0503	.056
3	.0274	.056		.0149	.0503	.056
4	.0269	.056		.0137	.0497	.056
5	.0269	.056		.0143	.0497	.056
6	.0269	.056	.1698	.0137	.0492	.056
7	.0269	.056	.1698	.0091	.168	.056
8	.1698	.112	.1698	.1698	.168	.056
9	.168	.1698	.1698	.168	.168	.056
10	.168	.1698	.168	.168	.1663	
11	.168	.168	.2263	.2241	.1663	.052
12	.112	.2241	.2263	.2241	.168	
13	.056	.2241	.2263	.2241	.1663	.1698
14	.056	.2241	.2263	.2241	.168	.052
15	.056	.2263	.2263	.2218	.056	.1698
16	.056	.1143	.0566	.2241	.056	.1698
Max	.1698	.2263	.2263	.2241	.168	.1698
Min	.0257	.056	.0566	.0091	.0492	.052
Avg	.0748	.1265	.1850	.1214	.1094	.0798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.016	.0156	.0173	.0179	.0185	.0185
2	.0152	.0152	.0158	.0181	.0181	.0185	.0187
3	.0154	.0154	.0158	.0183	.0185	.0185	.0181
4	.0152	.0156	.0152	.0185	.0183	.0183	.0179
5	.0154	.0156	.0152	.0187	.0187	.0185	.0177
6	.0154	.0152	.0137	.0175	.0185	.0185	.0175
7		.0156	.0316	.0179	.0179	.0181	.0173
8	.0152	.0162	.0305	.0171	.0183	.0177	.0181
9	.032	.0143	.0309	.0183	.0154	.0175	.0185
10	.0309	.0149	.0324	.0181	.0152	.0175	.0183
11	.0187	.0175	.0166	.048	.0297	.0181	.017
12	.0187	.0181	.0164	.0625	.0297	.0179	.0162
13	.0185	.0181	.0158	.061		.0175	.016
14	.0185	.0179	.0154	.0463	.0278		.016
15	.0187	.0179	.0152	.048	.0274		.0156
16	.0181	.0179	.016	.0312	.0274	.0181	.0158
17	.0183	.0179	.0152		.0267	.0171	.0156
18	.0181	.0179	.0158		.0124	.0162	.0152
19	.0185		.0154	.0175	.0183	.0166	.0168
20	.0183	.0181	.0147	.0171	.0183	.0137	.0168
21	.0185	.0183	.0149	.0179	.0183	.0147	.0171
22	.0187	.0183	.0137	.0175	.0181	.0135	.017
23	.0187	.0185	.0185	.0173	.0183	.0137	.016
24	.0185	.0185	.0185	.0183	.0175	.0183	.0143
Max	.032	.0185	.0324	.0625	.0297	.0185	.0187
Min	.0152	.0143	.0137	.0171	.0124	.0135	.0143
Avg	.0186	.0169	.0183	.0265	.0203	.0171	.0169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.112	.112	.1214	.112	.112	.1254
2	.0914	.112	.112	.1227	.112	.112	.124
3	.0914	.112	.1109	.1267	.112	.112	.1214
4	.1097	.112	.1294	.1433	.112	.1307	.1267
5	.1109	.1663	.1663	.1715	.1494	.1663	.1402
6	.1848	.2012	.1829	.2149	.1848	.2033	.1448
7	.1829	.1829	.2195	.197	.2195	.2195	.1772
8	.2149	.197	.2149	.1848	.1991	.1991	.1907
9	.1772	.2103	.2149	.1753	.1753	.1578	.1991
10	.1612	.1715	.1928	.1715	.1578	.1629	.1772
11	.1578	.1357	.1886	.1543	.1543	.1417	.1578
12		.1341	.1753	.1543	.1187	.1214	.1372
13	.1543	.1296	.1791	.1509			.1326
14	.1543	.1134	.1448	.1326	.112		.1134
15	.1187	.112	.1372	.1311	.128		.1134
16	.1475	.128	.1578	.1311	.1265	.1387	.1492
17	.1492	.1265	.1791		.1341	.181	.1865
18	.1638		.1734		.1696	.1791	.1715
19	.2279		.1753	.2401	.1772	.2835	.2103
20	.2507	.2601	.2534	.298	.2534	.298	.2686
21	.2172	.2507	.2629	.2507	.2033	.2561	.2353
22	.1829	.2172	.2149	.2195	.168	.2172	.1663
23	.1294	.1829	.1494	.1463	.1478	.1227	.1109
24	.0914	.112	.1109	.128	.1109	.112	.128
Max	.2507	.2601	.2629	.298	.2534	.298	.2686
Min	.0914	.112	.1109	.1214	.1109	.112	.1109
Avg	.1548	.1582	.1732	.1712	.1538	.1727	.1587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1132	.1132	.1227	.132	.1132	.1097
2	.132	.1132	.1132	.1307	.132	.1132	.1029
3	.132	.1132	.1143	.1307	.132	.1143	.112
4	.132	.1132	.1334	.1848	.1509	.1143	.104
5	.1698	.1509	.1715	.2172	.1886	.1524	.1772
6	.2096	.2075	.1905	.2279	.2263	.2096	.1907
7	.2427	.2614	.2241	.2353	.2614	.2452	.2715
8	.2427	.2241	.2218	.208	.2218	.2218	.2454
9	.1848	.1663	.2058	.1867	.2012	.2172	.2033
10	.1791	.168	.1829	.1629	.1772	.197	.1791
11	.1612	.1646	.156	.1433	.1595	.1928	.1629
12	.1433	.1595	.1578	.1402	.1991	.1612	.1433
13	.1448	.1543	.1698	.1402		.1543	.1433
14	.1433	.1357	.1629	.1372	.1463	.1629	.1433
15	.1578	.1341	.1629	.1372	.128	.1612	.1227
16	.1595	.1475	.1734	.1357	.1254	.1753	.1543
17	.1612	.1341	.1715	.1844	.124	.1848	.1928
18	.1753	.1844	.1753		.1417	.1734	.197
19	.2353	.2229	.1991	.2481	.2172	.2172	.2195
20	.2587	.2686	.2401	.2865	.2561	.2896	.2587
21	.2402	.2587	.2804	.2561	.2427	.2254	.2241
22	.2241	.2241	.2353	.2241	.2054	.2033	.1886
23	.1494	.2075	.2054	.1867	.1698	.1307	.132
24	.132	.1132	.132	.1448	.1509	.132	.1109
Max	.2587	.2686	.2804	.2865	.2614	.2896	.2715
Min	.132	.1132	.1132	.1227	.124	.1132	.1029
Avg	.1768	.1725	.1789	.1814	.1778	.1776	.1704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 204 / 11KV DATT LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	04-JUL-18
HR	Load (MW)
8	.0023
9	.0025
10	.0025
11	.0029
Max	.0029
Min	.0023
Avg	.0026



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.1509	.061	.0754	.0754	.0754	.0754
2	.064	.1357	.061	.0566	.0754	.0754	.0747
3	.0983	.1174	.061	.0566	.0754	.0754	.0747
4	.096	.1311	.061	.0943	.0754	.0754	.0739
5	.0949	.1526	.061	.0943	.0943	.0754	.1132
6	.1029	.1387	.0914	.1509	.132	.0943	.1509
7	.1387	.1492	.1677	.1509	.1698	.1886	.1509
8	.0983	.1341	.1677	.132	.1494	.1886	.1478
9	.0995	.1457	.1677	.0934	.1494	.1886	.1132
10	.0633	.1134	.0934	.0747	.1132	.1132	.0754
11	.0549	.132	.0934	.1235	.0914	.0754	.0633
12	.0554	.0754	.0747	.1204	.0914	.0903	.0617
13	.0724	.0943	.0747	.1355	.0914	.0846	.064
14	.0543	.0943	.0934	.1094	.0914	.0695	.08
15	.0537	.0943	.0747	.096	.0914	.0572	.08
16	.0532	.0943	.0934	.096	.0914	.0705	.081
17	.0543	.0943	.0934	.08	.061	.0572	.0829
18	.0914	.1132	.0924	.128	.0762	.0869	.0995
19	.1097	.1509	.1307	.1307	.1509	.1509	.1132
20	.1478	.1509	.1886	.2075	.1886	.1886	.1132
21	.1509	.1509	.1886	.2075	.1886	.1886	.1132
22	.132	.1509	.1509	.1509	.132	.1132	.0943
23	.0754	.1509	.0943	.0754	.0943	.08	.0754
24	.0617	.0754	.061	.0754	.0754	.0754	.0754
Max	.1509	.1526	.1886	.2075	.1886	.1886	.1509
Min	.0532	.0754	.061	.0566	.061	.0572	.0617
Avg	.0871	.1246	.1040	.1131	.1094	.1058	.0936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0556	.0389	.0343	.2164	.16	.1524	.1448
2	.0617	.0434	.0343	.1692	.1372	.1524	.1715
3	.0633	.0297	.0343	.1448	.0857	.1524	.1715
4	.064	.0305	.0343	.1692	.1429	.1524	.1738
5	.0648	.0469	.0343	.1738	.1715	.1524	.1974
6	.0655	.0633	.0514	.1669	.2286	.1829	.2
7	.1017	.0983	.0943	.2709	.2572	.1829	.2027
8	.096	.0848	.1132	.3506	.4218	.3048	.2606
9	.081	.0791	.0943	.3913	.3437	.3048	.2256
10	.064	.0762	.0362	.0633	.0514	.0514	.0648
11	.184	.2949	.3048	.0492	.0514	.0514	.0648
12	.2225	.3277	.2858	.0492	.0514	.0434	.0469
13	.2164	.2949	.3429	.0463	.0514	.044	.048
14	.1097	.2949		.0457	.0514	.0446	.048
15	.1027	.2949	.3765	.0469	.0514	.0452	.064
16	.104	.2949	.3858	.0474	.0514	.0457	.0648
17	.1429	.426	.3858	.0457	.0514	.0602	.0625
18	.1391	.3932	.3858	.0772	.0686	.0594	.0594
19	.0572	.0686	.0743	.061	.0686	.0579	.0579
20	.0429	.0686	.0791	.0633	.0686	.0587	.0594
21	.0572	.0686	.048	.064	.0686	.0594	.0594
22	.0423	.0686	.0474	.048	.0686	.0602	.0429
23	.029	.0686	.0469	.0324	.0686	.0914	.0423
24	.0587	.0383	.0343	.1578	.1555	.1524	.1524
Max	.2225	.426	.3858	.3913	.4218	.3048	.2606
Min	.029	.0297	.0343	.0324	.0514	.0434	.0423
Avg	.0928	.1497	.1460	.1229	.1220	.1109	.1119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	1.0185	.8488	1.0562	.8676	.3772	.8676
2	.8215	.9808	.8488	1.0185	.8779	.3772	.8865
3	.811	1.0185	.8488	.9054	.9054	.3772	.8865
4	.7922	1.0562	.8488	.9054	.8865	.3772	.9054
5	.7655	.9054	.8488	.7922	.8676	.3772	.9242
6	.7545	.8488	.811	.7167	.8488	.3395	.9431
7	.7733	1.0562	.7922	.7167	.8865	.5281	.9431
8	.811	1.0562	.7356	.9242	.811	.5658	.7733
9	.8299	.9808	.3772	.4251	.8299	.5658	.5658
10	.7922	.9242	.5658	.5658	.6224	1.0562	.8299
11	.7356	.8676	.6413	.6036	.5658	1.3392	.8299
12	.679	.679	.679	.6413	.5093	1.2449	.8299
13	.6602	.679	.6413	.5975	.5093	1.1694	1.1694
14	.679	.679	.679	.7167	.5093	1.094	1.1694
15	.8215	.7356	.6036	.6224	.4527	1.1317	1.1317
16	.7762	.679	.6036	.6348	.4527	1.1694	1.2826
17	.6036	.4904	.5658	.5601	.3395	1.3203	1.3203
18	.6602	.4904	.4904	.4904	.2829	1.1317	1.3203
19	.6036	.679	.4715	.2894	.3018	1.0374	1.3203
20	.547	.679	.5281	.6224	.3961	1.0269	1.2826
21	.811	1.0562	.8676	.679	.3395	1.1694	1.1317
22	1.1949	1.0562	1.0751	1.1317	.6036	1.0374	.8299
23	1.3014	1.1317	1.0562	1.094	.6036	.9431	.6602
24	.8488	.9808	.679	.7545	.8299	.4904	.8402
Max	1.3014	1.1317	1.0751	1.1317	.9054	1.3392	1.3203
Min	.547	.4904	.3772	.2894	.2829	.3395	.5658
Avg	.7876	.8637	.7128	.7277	.6292	.8436	.9852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0177	.0175	.0267	.016	.0145	.0133
2	.0173	.0177	.0177	.0267	.016	.0147	.0124
3	.0175	.0177	.0175	.0271	.0156	.0147	.0126
4	.0175	.0177	.0177	.0274	.0152	.0149	.0126
5	.0175	.0179	.0177	.0274	.0151	.0149	.0126
6	.0177	.0179	.0183	.0278	.0143	.0149	.013
7	.0179	.0183	.0181	.0278	.0135	.0149	.0141
8	.0179	.0181	.0183	.0271	.0145	.0149	.0143
9	.0173	.0189	.0183	.0282	.0143	.0149	.0145
10	.0187	.0189	.0183	.0175	.0185	.0149	.0187
11	.0168	.0324	.0286	.0175	.0187	.0185	.0173
12	.016	.0316	.0316	.0175	.0183	.0183	.0187
13	.016	.0152	.0147	.0175	.017	.0181	.0173
14	.016	.0154	.0145	.0168	.017	.016	.0171
15	.0143	.0152	.0139	.017	.0171	.016	.0173
16	.0141	.0154	.0139	.0171	.0173	.0164	.0179
17	.0135	.0305	.0271	.0175	.0175	.016	.0171
18	.0135	.0152	.0244	.0175	.0175	.016	.0166
19	.0175	.0179	.0166	.0171	.0175	.0162	.0179
20	.0179	.0175	.0177	.0171	.0175	.0166	.0185
21	.0177	.0187	.0177	.0168	.0185	.0162	.0177
22	.0177	.0179	.0177	.0173	.0177	.0156	.0177
23	.0179	.0175	.0175	.0173	.0177	.0156	.017
24	.0164	.0179	.0175	.0267	.0162	.0145	.0133
Max	.0187	.0324	.0316	.0282	.0187	.0185	.0187
Min	.0135	.0152	.0139	.0168	.0135	.0145	.0124
Avg	.0167	.0191	.0189	.0214	.0166	.0158	.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0038	.0046	.0191	.0191	.0191	.0191
2	.0042	.0046	.0046	.0191	.0191	.0191	.0191
3	.0038	.0046	.0042	.0191	.0191	.0191	.0191
4	.0042	.0042	.0038	.0191	.0191	.0191	.0191
5	.0042	.0046	.0046	.0191	.0191	.0191	.0191
6	.0042	.0046	.0042	.0191	.0191	.0191	.0191
7	.0042	.0046	.0042	.0191	.0191	.0191	.0191
8	.0042	.0042	.0084	.0191		.0191	.0191
9	.0194	.0133	.0042	.0191		.0191	.0191
10	.0122	.0046	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0061	.0023	.0023	.005
12	.0191	.0191	.0191	.0061	.0023	.0023	.0038
13	.0191	.0191	.0191	.0118	.0042	.005	.005
14	.0191	.0191	.0191	.0046	.0034	.0057	.0038
15	.0191	.0191	.0191	.0042	.0034	.0057	.005
16	.0191	.0191	.0191	.0046	.0038	.0046	.0046
17	.0191	.0191	.0191	.0042	.0038	.0038	.0038
18	.0191	.0191	.0191	.0042	.0046	.0038	.0046
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191		.0191	.0191	.0191	.0191
Max	.0194	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0019	.0038	.0038	.0042	.0023	.0023	.0038
Avg	.0137	.0134	.0135	.0146	.0134	.0141	.0142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2561	.2534	.2715	.2772	.2801	.2454
2	.2743	.2561	.2561	.2715	.2587	.2801	.2454
3	.2772	.2561	.2561	.2561	.2587	.2772	.2427
4	.2772	.3326	.2534	.2715	.3142	.3142	.2427
5	.3292	.4066	.362	.3475	.3921	.3696	.2743
6	.4755	.462	.439	.4207	.4435	.4251	.3772
7	.5853	.567	.5487	.6036	.567	.567	.5548
8	.5731	.567	.5792	.5552		.5973	.5487
9	.5493	.4525	.543	.4656		.5249	.5249
10	.4961	.4252	.4733	.4161	.4607	.4706	.4733
11	.3544	.4119	.4207	.3506	.4075	.4119	.1402
12	.4252	.3544	.3856	.3681	.3582	.3856	.3856
13	.3582	.3155	.3988	.3155	.3121	.3467	.3155
14	.3641	.3121	.3814	.3121	.2804	.3086	.3294
15	.3294	.3155	.3429	.2915	.2835		.2883
16	.3294	.3506	.39	.3641	.1595	.3155	.2683
17	.2915	.3467	.4024	.407	.1227	.3772	.4207
18	.4161	.4298	.4527	.4207	.4607	.4115	.5201
19	.567	.6878	.5609	.6201	.5552	.5487	.6268
20	.7133	.6805	.6878	.6447	.6283	.7164	.6697
21	.6099	.567	.5853	.567	.5729	.543	.6036
22	.4805	.4435	.3511	.4805	.4854	.4755	.4755
23	.3326	.3292	.3511	.4066	.3547	.3658	.3475
24	.2715	.2715	.2743	.2896	.2743	.2987	.2804
Max	.7133	.6878	.6878	.6447	.6283	.7164	.6697
Min	.2715	.2561	.2534	.2561	.1227	.2772	.1402
Avg	.4147	.4082	.4146	.4049	.3740	.4179	.3917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.1867	.1886	.2241	.4572	.373	.5144
2	.3772	.1867	.1886	.2241	.4572	.373	.5144
3	.3772	.1867	.1886	.2241	.4572	.3315	.5144
4	.5658	.1867	.2263	.2801	.5487	.3563	.5144
5	.6036	.2241	.3734	.3734	.9145	.6944	.6859
6	.6767	.5041	.4854	.5415	1.1218	.9221	.9088
7	.7716	.4294	.5093	.4481	.5601	.4096	.9431
8	.7316	.2987	.5788	.3361	.3772	.2984	.2572
9	.6584	.4862	.5144	.2241	.2641	.2515	.2572
10	.5533	.7209	.663	.1698		.218	.1886
11	.5935	.7956	.8048	.1698			.2054
12	.6554	.9339	.8886	.1698			.168
13	.8048	.7377	.9389	.1698			.168
14	.6706	.7127	.9389	.132			.1494
15	.6706		.9389	.132		.1677	.168
16	.6371	.4748	.1867	.2075		.1677	.1867
17	.2614	.1989		.2452		.1844	.1867
18	.2801	.1311	.2241	.2641	.2915	.2347	.2241
19	.3174	.2429	.2801	.2452	.2401	.3018	.2987
20	.3361	.3391	.3734	.3395	.3086	.3086	.3361
21	.2987	.216	.3361	.5658	.503	.5144	.4108
22	.2427	.1886	.2614	.5658	.39	.6001	.3174
23	.1867	.1543		.4904	.3353	.6001	.2987
24	.3772	.1867	.1886	.2241	.4572	.3429	.5144
Max	.8048	.9339	.9389	.5658	1.1218	.9221	.9431
Min	.1867	.1311	.1867	.132	.2401	.1677	.1494
Avg	.5010	.3792	.4671	.2903	.4802	.3825	.3721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2614	.2486	.2801	.7316	.8288	.8288
2	.3772	.2614	.2458	.2801	.7316	.8383	.8288
3	.3772	.2614	.2429	.2801	.7316	.8478	.8288
4	.5658	.2987	.2429	.3361	.9145	1.0288	.9945
5	.6602	.3734	.3239	.4108	1.2803	1.531	1.0774
6	.8488	.6535	.4858	.6161	2.0332	1.9113	1.6741
7	1.0631	.5041	.4915	.7095	.6535	.5426	1.9062
8	1.134	.3734	.4807	.5041	.3961	.3353	.3315
9	1.0974	.6859	.5571	.3547	.415		.3315
10	.6371	1.1401	1.0898	.3206	.2641		.2321
11	.9088	1.3904	1.1904	.3206	.2614	.2486	.2614
12	.9779	1.21	1.4754	.2641	.1658	.2486	.2054
13	.8573	1.3056	1.4754	.2641	.1619	.1658	.168
14	.9724	1.2574	1.4419	.1886	.1677		.168
15	.8383	1.1603	1.0898	.1886	.1457	.1823	.1494
16	.9892	1.2239	.2987	.2075	.1966	.1823	.2241
17	.1867	.1865		.2075	.1989	.2652	.2241
18	.2241	.2401	.2241	.2263	.2347	.2321	
19	.3174	.2753	.3174	.3206	.2785	.2818	.3921
20	.4481	.3812	.4108	.415	.4024	.3315	.4108
21	.4108	.3113	.3361	.811	.8785	.7459	.7655
22	.2987	.3077	.3174	.9242	.9717	.9116	.7655
23	.2801	.2321		.8299	.9221	.9116	.7468
24	.415	.2614	.2347	.2801	.7316	.8288	.8288
Max	1.134	1.3904	1.4754	.9242	2.0332	1.9113	1.9062
Min	.1867	.1865	.2241	.1886	.1457	.1658	.1494
Avg	.6360	.6065	.6010	.3975	.5779	.6381	.6236



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.3439	.3429	.4801	.1698	.1341	.1326
2	.1698	.3439	.3467	.4801	.1698	.1311	.1326
3	.1698	.3439	.3506	.4801	.1698	.1296	.1326
4	.2263	.4031	.6201	.5487	.2263	.1638	.1492
5	.2641	.6001	.7011	.6874	.2641	.1658	.2486
6	.3395	.9724	.8097	1.0898	.3961	.3086	.3149
7	.4527	1.1736	.3978	.4294	.4108		.3149
8	.3584	1.3413	.2785	.9945	.8238	.9431	.8288
9	.2829	.2241	.2012		1.0974	1.4251	1.1271
10	.1698	.1307	.1696	1.576	1.073	1.6741	1.3923
11	.1475	.1509	.168	1.6095	1.4746	1.7404	1.3413
12	.116	.1326	.1307	1.6095	1.5604	1.8233	1.4083
13	.1147	.1174	.2054	1.5927	1.647	1.8564	1.3413
14	.1307	.1357	.168	1.6598	1.6804	1.7404	1.3413
15	.1307	.1326	.1307	1.6263	1.6632	1.6741	1.4083
16	.1494	.1492	.168	.1886	.12		.112
17	.112	.1341		.2075	.1543	.1326	.1494
18	.1867	.1475	.168	.1698	.1802	.1658	.2054
19	.2614	.2591	.2054	.2452	.2347	.2321	.2614
20	.3361	.2683	.3361	.3206	.2652	.2652	.2987
21	.2987	.2374	.5228	.2452	.2321	.2321	.2614
22	.2241	.1715	.5249	.2452	.1989	.2321	.1867
23	.3361	.3429	.4801	.1886	.1174	.116	.1494
24	.1698	.3547	.3772	.4801	.1698	.1311	.1326
Max	.4527	1.3413	.8097	1.6598	1.6804	1.8564	1.4083
Min	.112	.1174	.1307	.1698	.1174	.116	.112
Avg	.2215	.3588	.3393	.7459	.6041	.7008	.5571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.1494	.0934	.1132	.1509	.112
2	.0943	.0934	.1494	.0934	.1132	.1509	.112
3	.0943	.0934	.1307	.0934	.1132	.1494	.112
4	.132	.0934	.132	.1307	.1509	.1494	.1307
5	.1698	.1494	.132	.168	.1698	.1886	.1494
6	.2075	.2427	.1509	.2054	.1886	.2241	.1494
7	.2452	.2241	.1509	.2054	.2263	.132	.1494
8	.2075	.2241	.1509	.2054	.2075	.1509	.1307
9	.1886	.1867	.1509	.168	.1886	.0943	.1307
10	.1509	.168	.1509	.132	.1509	.0934	.1494
11	.1509	.0943	.1494	.132	.1494	.0934	.1307
12	.0934	.112	.112	.1132		.0934	.0934
13	.168	.0895	.0934	.1132	.112	.0934	.0934
14	.168	.0934	.1494	.1132	.1132		.0747
15	.0747			.1132	.112	.0934	.0747
16	.0934	.1494		.1132	.1132	.0934	.112
17	.1307	.1509		.1886	.1132	.112	
18	.1494	.1494	.2427	.1886	.112	.1307	.1494
19	.2054	.132	.2054	.2075	.132	.112	.2241
20	.2054	.2263	.2614	.2452	.112	.1494	.2614
21	.168	.1698	.168	.2263	.1509	.1494	.2241
22	.1307	.1509	.1307	.1886	.132	.1307	.112
23	.0934	.1494	.112	.132	.132	.1307	.0934
24	.0943	.0934	.1509	.0934	.132	.1132	.112
Max	.2452	.2427	.2614	.2452	.2263	.2241	.2614
Min	.0747	.0895	.0934	.0934	.112	.0934	.0747
Avg	.1463	.1448	.1535	.1526	.1408	.1295	.1340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1494	.1494	.1307	.1132	.1307	.132
2	.132	.1494	.1494	.1307	.1132	.132	.1132
3	.132	.1494	.1294	.1307	.1132	.132	.1132
4	.132	.1494	.1307	.1307	.132	.132	.132
5	.132	.1494	.1494	.1307	.1698	.1307	.1509
6	.132	.168	.168	.168	.1886	.132	.1509
7	.1509	.1307	.1698	.2241	.168	.1886	.1509
8	.132	.1494	.1509	.1867	.1509		.132
9	.132	.112	.2054	.1307	.0943	.1509	.1132
10	.1132	.1494	.132	.1698	.1132	.1509	.1509
11	.1132	.132	.1307	.1698	.1132	.1509	.1307
12		.1307	.1307	.1132	.112	.1509	.1307
13	.1494	.1132	.1307	.1132	.1132	.0943	.112
14	.1307	.112	.1307	.0943	.112	.0943	.1494
15	.1307		.1494	.0943	.0943	.0943	.112
16	.112	.132	.1494	.1132	.0747	.0943	.112
17	.1494	.1494		.2075	.0754	.1132	.112
18	.168	.1132	.2241	.1509	.112	.1132	.1307
19	.1867	.1132	.2241	.1509	.132	.132	.1307
20	.2054	.1867	.2241	.2263	.1494	.1509	.168
21	.2054	.2075	.2241	.2075	.1698	.1509	.1867
22	.1867	.1867	.168	.1698	.1494	.1698	.168
23	.168	.132	.1307	.1509	.1509	.132	.168
24	.132	.1494	.1494	.1307	.132	.132	.132
Max	.2054	.2075	.2241	.2263	.1886	.1886	.1867
Min	.112	.112	.1294	.0943	.0747	.0943	.112
Avg	.1460	.1441	.1609	.1511	.1269	.1327	.1368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3801	.663	.8383	.3018	.2012	.2035
2	.2641	.3801	.6478	.8383	.3018	.1966	.2035
3	.2641	.3801	.6554	.8383	.3018	.1989	.2035
4	.3395	.4207	.9503	.9221	.3395	.3315	.2035
5	.5093	.6173	1.1934	1.1401	.415	.4239	.3222
6	.6602	.9221	1.8176	1.5927	.679	.5197	.4578
7	.7733	1.1401	.6133	.5788	.7095	.5967	.4578
8	.5281	1.3245	.503	1.2517	.9816	1.0562	1.0174
9	.415	.3361	.5087	1.7772	1.4266	1.1603	1.2887
10	.3772	.2614	.3601	1.9616	1.8275	1.9669	1.56
11	.3258	.2321	.3734	1.9951	2.0919	2.0348	
12	.3113	.2429	.2987	2.1293	1.8842	1.8652	
13	.2012	.2321	.2241	2.1125	1.989	2.1195	1.2574
14	.2801	.2347		2.2466	1.9433	2.0348	1.4419
15	.2801	.2486		2.2298	1.989	1.933	1.5257
16	.2427	.2458		.2075	.2515	.2543	.2427
17	.3361			.2641	.2321	.2035	
18	.3734		.3174	.3772	.2683	.2713	.4108
19	.4668	.4748	.3361	.4527	.2949	.2883	.4854
20	.2427	.5243	.4481	.4904	.421	.2883	.4481
21	.2054	.4578	.8507	.4527	.3605	.3391	.3734
22	.168	.2818	.8745	.3395	.2321	.2035	.2427
23	.3547	.4191	.8718	.3206	.2012	.2035	.2241
24	.2641	.3921	.6783	.8383	.3018	.2035	.2035
Max	.7733	1.3245	1.8176	2.2466	2.0919	2.1195	1.56
Min	.168	.2321	.2241	.2075	.2012	.1966	.2035
Avg	.3520	.4613	.6593	1.0915	.8227	.7873	.6083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.8288	.6478	.6783	.1187	.1753	.1715
2	.1492	.9945	.6478	.5935	.1187	.1372	.1696
3	.1715	1.3565	.6478	.6783	.1357	.1417	.2058
4	.1886	1.4089	.7125	.763	.1357	.1387	.2058
5	.2543	1.5261	.8097	.9326	.2374	.1867	.2804
6	.3391	1.5746		1.1869	.3391	.2401	.3658
7	.3391	1.6575	.2267	.3052	.2713	.3086	.4252
8	.2486	1.7814	.1781	1.1869	.8478		.9145
9		.1017	.1619	1.3565		1.0631	1.267
10	.1715	.1457	.1357	1.5261			1.1336
11	.1715	.1134	.1357	1.5261		1.2003	1.2793
12		.1134	.1526	1.5261	1.3717		1.2793
13		.1134	.1357	1.5261		1.3717	1.3117
14	.1017	.1134	.1526	1.5261	1.3717	1.0974	1.4251
15	.116	.1457	.1696		1.406	.8764	1.3927
16	.1492		.1357		.1619		.1134
17	.3772		.1526			.1619	.1134
18	.2058	.1134	.1696	.1696			.1619
19	.2374	.1619	.2035	.2035	.2591		.1943
20	.2713	.1943	.2543	.2543		.1619	.2267
21		.1619	.6783	.1696	.2401	.2058	.1943
22	.2652	.1619	.6783	.1696	.2195	.2195	.1943
23	.2652	.4858	.6783	.1696	.2058		.1781
24	.1696	.6104	.6478	.6783	.1357	.1715	.1829
Max	.3772	1.7814	.8097	1.5261	1.406	1.3717	1.4251
Min	.1017	.1017	.1357	.1696	.1187	.1372	.1134
Avg	.2172	.6302	.3701	.8155	.4456	.4622	.5578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8817	1.0774	.7125	.763	.763	.9602	1.2308
2	.8817	1.1869	.7125	.763	.763	1.307	1.3443
3	.8192	1.2717	.7287	.763	.8478	1.2346	1.2346
4	.9326	1.3565	.7935	.8478	.8478	1.4575	1.3169
5	1.0852	1.6575	.8745	1.1022	1.1869	1.8519	1.4563
6	1.326	1.8233	1.1822	1.5261	1.3565	2.3148	2.4539
7	1.6575	2.2043	.5668	.5087	.4239	.724	.6859
8	1.7404	2.2891	.8421	1.1869	.6783		.905
9		.5087	.9069	1.5261	.9326	1.1043	1.1022
10	1.749	1.4251	1.4413	1.6956	1.1869		1.3117
11	1.6804	1.8623	1.95	1.6956		1.4746	1.3603
12	1.6956	1.9271		1.6956	1.2689		1.2631
13	1.6956	2.1862	1.6108	1.5261		1.4575	1.247
14	1.6575	2.1376	1.8652	1.5261	.7716	1.1222	1.2146
15	.9431	1.8947	2.1195	1.2717		.9816	1.166
16	.9326	1.7004	.1696	.1696	.1619		.1781
17	.1357	.2591	.2035	.1696		.2429	.1943
18	.2543	.3239	.2543	.2374			
19	.3315	.3239	.4239	.373	.2429		
20	.431	.4372	.5087	.5087		.4049	.4049
21		.3725	.763	.8478	.7716		.8259
22	.3391	.3725	.9326	.9326	.9877	1.166	.8745
23	.8573	.5992	.8478	.8478	1.1222		.8745
24	.6859	.9012	.7125	.8478	.8478	.9945	1.166
Max	1.749	2.2891	2.1195	1.6956	1.3565	2.3148	2.4539
Min	.1357	.2591	.1696	.1696	.1619	.2429	.1781
Avg	1.0324	1.2541	.9184	.9722	.8423	1.1749	1.0823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962	.1966	.2591	.2035	.6783	.9511	.9511
2	.7459	.1823	.2591	.1696	.6783	.8916	1.0059
3	.7956	.1696	.2591	.1696	.6783	1.0829	1.0059
4	.8619		.2915	.2035	.8478	1.2136	1.0608
5	.9779		.3239	.3391	1.0174	1.3565	1.0517
6	1.6575		.5182	.5087	1.1869	1.8652	1.9004
7	2.3205		.4534	.4239	.5087	.5144	.5144
8	2.2377		.7125	.3391	.4239		.5068
9		.4973	.7773	.2543	.2543	.2429	.2896
10	1.8861	2.2672	1.2717	.1696	.2035		.1619
11	1.8652	2.5911	1.3565	.1357		.1619	.1296
12	.6001	2.5911	1.5261	.1187	.1619		.1296
13	1.8861	2.5263	1.5261	.1017		.1134	.1296
14	2.1195		1.5261	.1017	.1619		.1296
15	2.2977		1.5261		.1619	.0857	.1296
16	1.95		.1696	.1187	.1619		.1296
17		.1296	.1696	.1357		.081	.1619
18	.1658		.2035	.2035			.2591
19	.3315	.2591	.3391	.3391	.2915		.3239
20	.3944	.3563	.4239	.4239		.2591	.3563
21		.3239	.3391	.6783	.7316	.6859	.7125
22	.2818	.2915	.2883	.6783	.9955	.9431	.7287
23	.2486	.2591	.2543	.6783	.8916		.7287
24	.6783	.2321	.2591	.2543	.6783	.8573	.9511
Max	2.3205	2.5911	1.5261	.6783	1.1869	1.8652	1.9004
Min	.1658	.1296	.1696	.1017	.1619	.081	.1296
Avg	1.1904	.8582	.6264	.2934	.5639	.7066	.5603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1029	.1267	.1294	.112	.12	.128
2	.0995	.12	.1267	.112	.112	.1187	.124
3	.116	.1187	.1267	.112	.112	.1372	.1267
4	.1372	.1715	.1448	.112	.112	.1372	.1417
5	.1658	.1989	.1991	.1307	.1867	.1715	.1478
6	.2035	.2401	.2534	.2801	.2801	.2401	.2195
7	.2035	.2401	.2534	.2801	.2614	.2987	.2926
8	.1372	.1715	.2172	.2427	.1867		.3052
9		.1326	.2172	.2241	.168	.2401	.2743
10	.1017	.181	.168	.1867	.1307		.0905
11	.1017	.181	.1494	.1696		.1715	.0905
12	.1357	.181	.112	.1867	.1174		.0905
13	.2035	.1448	.112	.1307		.1134	.1267
14	.1696	.1448	.168	.112	.1029	.1402	.0905
15	.1017	.1448	.1307	.112	.1029	.1402	.0724
16	.1017	.1448	.1494	.112	.1029		.0905
17	.1029	.1448	.1867	.1307		.1715	.2172
18	.1326	.1267	.2241	.1848			.1991
19	.1865	.2172	.2204	.2241	.2058		.1991
20	.2321	.2715	.2801	.2801		.2743	.2896
21		.1991	.2241	.2427	.181	.2401	.2353
22	.1326	.1448	.1867	.1867	.1372	.2195	.1448
23	.0995	.1448	.168	.1867	.1463		.1267
24	.0848	.0995	.1267	.1357	.1494	.1187	.128
Max	.2321	.2715	.2801	.2801	.2801	.2987	.3052
Min	.0848	.0995	.112	.112	.1029	.1134	.0724
Avg	.1387	.1653	.1780	.1752	.1530	.1796	.1646



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.1658		.1357	.0339	.0343	.0366
2	.0339	.1989	.1619	.1357	.0339	.0343	.0343
3	.0497	.3086	.1619	.1357	.0339	.0343	.0362
4	.0514	.2984	.1619	.1696	.0339	.0343	.0543
5	.0678	.3315	.1943	.1696	.0509	.0514	.0543
6	.0686	.4475	.2267	.2543	.0848	.0514	.0732
7	.0686	.4475	.1134	.0848	.0848	.0514	.0543
8	.0686	.4144	.081	.2543	.1357		.2374
9		.0663	.0486	.3391	.1357	.1619	.3361
10	.0686	.0324	.0051	.4239	.1696		.2915
11	.0686	.0324	.0339	.4239			.2915
12	.0686	.0324	.0339	.4239	.1715		.2915
13	.0663	.0324	.0509	.4239		.2683	.3239
14	.0663	.0324	.0509	.4239	.1715	.2926	.3239
15	.0497	.0324	.0509	.3391	.2401	.3292	.3563
16	.0509	.0324	.0339	.0509	.0324		.0324
17	.0332	.0324	.0509	.0339			.0324
18	.0509	.0324	.0509	.0509			.0324
19	.0497	.0324	.0678	.0678	.0324		.0648
20	.0514	.0648	.0848	.0848		.0503	.081
21		.0486	.1357	.0678	.0514	.0343	.0648
22	.0509	.0486	.1357	.0509	.0514	.0366	.0324
23	.1029	.0486	.1357	.0509	.0514		.0324
24	.0678	.1372	.1619	.1357	.0339	.0343	.0366
Max	.1029	.4475	.2267	.4239	.2401	.3292	.3563
Min	.0332	.0324	.0051	.0339	.0324	.0343	.0324
Avg	.0586	.1396	.0971	.1971	.0860	.0999	.1335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.503	.663	.8619	.2263	.2033	.2054
2	.2263	.503	.7459	.8453	.2263	.2033	
3	.2263	.5365	.8453	.9831	.2263	.2402	
4	.2641	.6539	.9945	1.1797	.2263	.2772	
5	.2829	.9221	1.21	1.278	.3206	.3326	
6	.5847	1.4419	1.3108	1.4746	.5658	.5914	
7	.5658	1.9062	.5304	.5847	.5093	.5914	
8	.3772	1.7736	.2984	.9054	1.2449	1.1736	
9	.2452	.2865	.2652	1.5249	1.829	1.7269	
10	.2263	.3045	.2622	1.7901	1.9978	1.6933	
11	.2075	.2035	.2263	1.8442	2.2032	1.7269	.8619
12	.2075	.2035	.2452	1.6244	1.7939	1.6766	
13	.2263	.1696	.2452	1.7269	1.5089	1.8778	
14	.2263	.2012	.2263	1.6766	1.6598	1.5257	
15	.2263	.2012	.2641	1.5089	1.643	1.5927	1.5729
16	.2263	.2012	.2452	.2641	.181	.1991	.2818
17	.2263	.1989	.2829	.2075	.2172	.2172	.2818
18	.3018	.2818	.2829	.2452	.3292	.2715	.3315
19	.3361	.2321	.2829	.3018	.3547	.3547	.3315
20	.3921	.3647	.3961	.415	.3734	.3734	.4588
21	.3734	.3315	.8048	.3584	.3696	.3734	.3315
22	.2801	.2683	.8453	.2829	.2957	.2987	.2984
23	.4694	.4641	.7956	.2263	.2218	.2241	.2652
24	.2263	.503	.4115	.8288	.2263	.2033	.2054
Max	.5847	1.9062	1.3108	1.8442	2.2032	1.8778	1.5729
Min	.2075	.1696	.2263	.2075	.181	.1991	.2054
Avg	.2980	.5273	.5283	.9558	.7813	.7478	.4522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV kashilingwadi AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.8048	.8288	1.0277	.1132	.0747	.056
2	.0566	.8048	.779	.9614	.1132	.0747	
3	.0566	.8383	.779	.9175	.0943	.0747	
4	.0566	.8987	.8122	.9339	.0943	.0934	
5	.0754	.9835	.8619	.9503	.1132	.112	
6	.132	1.1361	.8785	.9995	.1509	.168	
7	.132	1.2548	.1006	.0943	.1698	.168	
8	.0754	1.2548	.0995	.9054	.9995	1.0227	
9	.0754	.0709	.0671	1.1934	1.3426		
10	.0754	.0709	.0671	1.1437	1.3599	1.0562	
11	.0754	.0678	.0943	1.5257	1.1105	1.0898	.7956
12	.0754	.0678	.0943	1.4586	1.2763	1.0059	
13	.0943	.0509	.0943	1.358	1.3426	.9892	
14	.0943	.0671	.0754	1.4419	1.326	1.3245	
15	.0754	.0671	.0943	1.4586	1.0774	1.291	1.0774
16	.0943	.0671	.0943	.0754	.0905	.1086	.1509
17	.0943	.0671	.0943	.1132	.1086	.0724	.1006
18	.0943	.0663	.0754	.0943	.0905	.0724	.1006
19	.112	.0829	.0943	.0943	.1132	.0747	.116
20	.0934	.0995	.0943	.132	.132	.0934	.0995
21	.0934	.0671	.7377	.132	.112	.0747	.0829
22	.0747	.0503	.9282	.132	.0934	.056	.0671
23	.7377	.8288	.9945	.1132	.0934	.056	.0671
24	.0566	.8048	1.3717	.9945	.1132	.0747	.056
Max	.7377	1.2548	1.3717	1.5257	1.3599	1.3245	1.0774
Min	.0566	.0503	.0671	.0754	.0905	.056	.056
Avg	.1107	.4405	.4255	.7605	.4846	.4012	.2308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV AWANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.1867	.1989	.2241	1.1961	1.2574	1.2929
2	1.065	.1867	.1844	.2218	1.21	1.2574	
3	1.0978	.1867	.1844	.2218	1.2125	1.291	
4	1.1142	.2241	.1844	.2772	1.2407	1.3245	
5	1.1469	.3734	.3353	.4066	1.4922	1.4754	
6	1.4419	.5975	.5304	.5601	2.2466	2.4478	
7	1.8351	.4481	.4973	.4854	.499	.4656	
8	1.8351	.4108		.3734	.3511	.3224	
9	1.4419	.7712		.2614	.2987	.2686	
10	1.1797	1.4922	1.2452	.1867	.2241	.2507	
11	1.4419	1.6575	2.2283	.1867	.2241	.1791	.2012
12	1.3272	1.5912	1.9989	.2054	.2054	.1433	
13	1.4255	1.326	1.9006	.2075	.1867	.1433	
14		1.326	1.9334	.1886	.1867	.1433	
15	.9995	1.5729	1.8842	.1886	.1867	.1433	.1677
16	1.3108	1.3108	.2987	.2263	.2054	.2172	.2321
17	.2254	.2321	.2614	.2075	.2241	.2172	.2652
18	.2427	.2652	.2614	.3018	.2801	.2715	
19	.3361	.2652	.3734	.3395	.3734	.3174	.3315
20	.4108	.3978	.4435	.6036	.4481	.4294	.4144
21	.3547	.3353	.4066	1.0852	1.3077	1.3592	1.5249
22	.2801	.2683	.3361	1.4074	1.4586	1.3426	1.5729
23	.2241	.1989	.2614	1.2407	1.2742	1.326	1.4746
24	.9614	.2054	1.5775	.2241	1.21	1.2574	1.2929
Max	1.8351	1.6575	2.2283	1.4074	2.2466	2.4478	1.5729
Min	.2241	.1867	.1844	.1867	.1867	.1433	.1677
Avg	.9861	.6596	.7966	.4096	.7393	.7438	.7973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0373	.0189	.0189	.0189	.037	.0373
2	.0189	.0373	.0189	.0189	.0189	.037	
3	.0189	.0373	.0189	.0189	.0189	.037	
4	.0189	.0373	.0189	.0189	.0189	.037	
5	.0377	.0373	.0373	.0377	.0377	.037	
6	.0566	.056	.0549	.0566	.0566	.0554	
7	.0377	.056	.037	.0377	.0566	.037	
8	.0377	.0373	.037	.0377	.0377	.037	
9	.0373	.0366	.0187	.0377	.0377	.0366	
10	.0373	.0366	.0373	.0373	.0377	.0366	
11	.0373	.0373	.0187	.0377	.0377	.0366	.0373
12	.0187	.0373	.037	.0189	.0189	.0366	
13	.0373	.0189	.037	.0189	.0189	.0183	
14	.0373	.0189	.0185	.0189	.0189	.0183	
15	.0373	.0189	.0373	.0189	.0189	.0183	.0373
16	.0187	.0189	.0373	.0189	.0189	.0183	.0373
17	.0187	.0187	.0373	.0189	.0377	.0366	.0373
18	.0373	.0554	.037	.0189	.0377	.0366	.0373
19	.056	.0554	.037	.0189	.0373	.0373	.0554
20	.056	.0554	.037	.0189	.056	.056	.0739
21	.056	.0549	.0373	.0566	.0554	.0373	.0554
22	.0373	.0373	.0377	.0377	.037	.0373	.0373
23	.0373	.0373	.0377	.0377	.037	.0373	.0373
24	.0189	.0373	.0189	.0189	.0377	.037	.0373
Max	.0566	.056	.0549	.0566	.0566	.056	.0739
Min	.0187	.0187	.0185	.0189	.0189	.0183	.0373
Avg	.0343	.0380	.0318	.0283	.0337	.0354	.0434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1494	.1307	.132	.132	.1307	.112
2	.132	.1307	.1307	.132	.132	.1307	
3	.132	.1307	.1307	.132	.132	.1307	
4	.132	.1494	.1307	.1698	.1494	.1307	
5	.1509	.168	.1663	.1886	.1509	.1307	
6	.2452	.2801	.2033	.2427	.2829	.2241	
7	.2427	.2054	.2587		.2641	.2054	
8	.2054	.2054	.2218	.2241	.2829	.168	
9	.168	.2772	.2195	.2241	.2075	.168	
10	.2033	.2033	.2012	.1867	.1698	.1494	
11	.1294	.2033	.2012	.168	.1698	.1494	.2241
12	.1478	.1848	.1629	.1886	.1132	.1307	
13	.1663	.1848	.181	.1494	.1132	.1494	
14	.1663	.1663	.1646	.1307	.132	.1341	
15	.1663	.1663	.1463	.1494	.132	.1494	.2614
16	.1663	.1478	.1848	.132	.132	.1494	.2801
17	.1848	.2195	.2033	.1698	.1132	.2241	.2772
18	.1848	.2743	.1663	.2452	.2075	.2801	.3326
19	.1867	.2743	.2218	.2075	.2241	.2614	.2896
20	.2054	.3109	.2987	.3395	.2427	.2987	.3077
21	.2241	.2218	.2801	.2452	.2054	.2241	.2195
22	.1867	.1663	.1886	.1886	.1867	.168	.1848
23	.168	.1307	.1698	.1509	.1307	.1494	.1294
24	.132	.1494	.1307	.132	.132	.1307	.1307
Max	.2452	.3109	.2987	.3395	.2829	.2987	.3326
Min	.1294	.1307	.1307	.1307	.1132	.1307	.112
Avg	.1733	.1958	.1872	.1839	.1724	.1736	.2291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.6706	.381		.132	.1307	
2	.0934	.6783	.3858		.132	.1494	
3	.0924	.6962	.4167		.1132	.1494	
4	.0943	.7127	.4687		.1132	.1494	
5	.0943	.8288	.5601		.1509	.1867	
6	.0943	.9717	1.0159		.2641	.2427	
7	.0943	1.7532	.1267		.2075	.2054	
8	.0943	1.6518	.1463		.5218	.7099	
9	.0934	.0366	.0924		1.0402	1.1683	
10	.0934	.0914		1.3443	.787	1.1683	
11	.0934	.0686		1.3443	1.0402	1.3279	
12	.0934	.0739		1.3763	1.0883		1.3117
13	.0934	.0739		1.4243	1.1405		1.3108
14	.0934	.0732		1.4243	1.1405		1.326
15	.0934	.0732		1.0562	.8951		1.3272
16	.0934	.0914		.0895	.0663		.0914
17	.0739	.0914		.0895	.0747		.1097
18	.0924	.112		.1086	.0747		.128
19	.0924	.1494		.1448	.1494		.1829
20	.0924	.168		.1886	.1867		.1829
21	.0747	.168		.1698	.1494		.1663
22	.0747	.1463		.1509	.112		.1478
23	.503	.2315		.1509	.1494		.128
24	.0934	.5935	.3506		.1509	.1307	
Max	.503	1.7532	1.0159	1.4243	1.1405	1.3279	1.3272
Min	.0739	.0366	.0924	.0895	.0663	.1307	.0914
Avg	.1081	.4252	.3944	.6473	.4117	.4766	.5344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.7087	1.7185		.4066	.3734	
2	.4251	.7087	1.7185		.4066	.3734	
3	.4435	.8859	1.7711		.4066	.3734	
4	.4481	.964	1.8185		.4435	.3734	
5	.5228	1.0517	1.9433		.4435	.4668	
6	.4854	1.7528	2.5484		.6099	.5415	
7	.5175	1.9281	.3734		.5544	.5041	
8	.4938		.4481		2.0622	2.1605	
9	.4572	.2012	.4668		2.8178	2.9127	
10	.3734	.4024		2.9959	2.8178	2.9127	
11	.3547	.3658		2.9959	3.199	2.8327	
12	.3734	.3326		2.8807	3.199		2.5463
13	.4854	.3696		2.2184	2.9165		2.4691
14	.5041	.3326		2.7515	2.9165		.0305
15	.4805	.3696		2.7515	2.6886		2.3403
16	.4805	.4031		.1829	.3142		.2926
17		.439		.3841	.4066		.3734
18	.499	.3921		.4066	.4066		.4481
19	.5487	.4108		.4251	.4066		.4854
20	.4572	.3734		.4294	.4251		.4668
21	.439	.3734		.4435	.4066		.4481
22	.439	.3361		.4435	.3734		.4108
23	.5487	1.3413		.4435	.3734		.4108
24	.3658	.6401	1.7394		.4251	.3658	
Max	.5487	1.9281	2.5484	2.9959	3.199	2.9127	2.5463
Min	.3547	.2012	.3734	.1829	.3142	.3658	.0305
Avg	.4579	.6558	1.4546	1.4109	1.2261	1.1825	.8935



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.0934	.0549		.5281	.5973	
2	.5735	.0934	.0549		.5281	.5973	
3	.5571	.0934	.0549		.5281	.5973	
4	.5407	.0924	.0554		.5761	.6584	
5	.547	.0934	.0739		.5761	.6249	
6	.5571	.0934	.0747		.6722	.8002	
7	.7287	.0905	.0732		.0934	.0934	.0732
8	.7209	.0905	.1981		.056	.0373	.0549
9	.7045	.362	.4049		.056	.0373	.0549
10	.3768	.8488		.0373	.056	.0373	.0732
11	.3768	.8078		.0373	.0373	.056	.0549
12	.5571	.7621		.0373	.0373		.0732
13	.5801	.8535		.0373	.0373		.0549
14	.663	.7045		.0373	.0373		.0549
15	.7459	.6554		.0373	.0373		
16	.7392	.6401		.0373	.0373		.0549
17	.0739	.0549		.0373	.0373		.0554
18	.0848	.0739		.0373	.0373		.0747
19	.0924	.0739		.0373	.0373		.0747
20	.0924	.0747		.056	.056		.0747
21	.0924	.0747		.3281	.4115		.2134
22	.0934	.0747		.4801	.5373		.3048
23	.0934	.0747		.4801	.5373		.3048
24	.5801	.0924	.0554		.4801	.5373	
Max	.7459	.8535	.4049	.4801	.6722	.8002	.3048
Min	.0739	.0549	.0549	.0373	.0373	.0373	.0549
Avg	.4477	.2904	.1100	.1227	.2512	.3895	.1032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.081	.0324		.0492	.0492	
2	.08	.081	.0324		.0492	.0492	
3	.064	.081	.0324		.0492	.0492	
4	.064	.0648	.0486		.0492	.0492	
5	.08	.081	.0648		.0983	.0983	
6	.081	.0972	.0648		.0983	.0983	
7	.0972	.0972	.081		.0655	.0655	
8	.0972	.0648	.0972		.0655	.0655	
9	.048	.0648	.0486		.0655	.0492	
10	.032	.0648		.0492	.0655	.0492	
11	.032	.0486		.0492	.0492	.0328	
12	.0486	.0486		.0328	.0492		.0324
13	.0486	.0648		.0328	.0492		.0324
14	.0486	.0648		.0328	.0328		.0324
15	.0486	.0648		.0328	.0328		.0324
16	.0648	.0648		.0328	.0492		.0486
17	.0648	.0486		.0328	.0328		.0648
18	.064	.1134		.1311	.0328		.0972
19	.08	.1134			.0655		.1134
20		.0972		.1638	.1147		.0972
21	.081	.081		.1475	.0983		.081
22	.081	.0648		.1311	.0983		.0648
23	.081	.0486		.0655	.0655		.0648
24	.081	.081	.0324		.0492	.0492	
Max	.0972	.1134	.0972	.1638	.1147	.0983	.1134
Min	.032	.0486	.0324	.0328	.0328	.0328	.0324
Avg	.0673	.0743	.0535	.0719	.0615	.0587	.0635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7116	.2372	.2214	.2214		1.2651	
2	.7907	.2372	.2214	.2214		1.2651	
3	.8223	.2372	.2214	.2214		1.2651	
4	.8539	.2372	.2027	.253		1.2651	
5	.8855	.2688	.2214	.2846		1.5023	
6	.9488	.3163	.2688	.3163		2.0873	1.2018
7	1.8027	.2846	.3005	.3321	.1739	.2056	.2372
8	1.5813	.3321	.8697	.2688	.2214	.2056	.2214
9	1.5023	.3953	1.5181	.2372	.1898	.1898	.1898
10	1.5497	1.8185	1.5813	.1898	.1423	.1581	.1265
11	1.6129	2.0557	1.8185	.1898	.1423	.1581	.1265
12	1.7394	2.0557	1.6762	.1581	.1423	.1265	.1265
13	1.6604	1.8976	1.5813	.1581	.1423	.1898	.1265
14	1.6129	1.8027	1.8027	.1581	.1265	.1265	.1265
15	1.5813	1.8185	1.8343	.1581	.1265	.1107	.1265
16	1.5971	1.7394	.2214	.1448	.0949	.1107	.1423
17	.0949		.2214	.1581	.1423	.1581	.1581
18	.1898		.253	.1265	.1581	.1898	.1898
19	.1898	.2056	.2214		.2214	.1898	.2372
20	.1898	.2214	.2214	.1898	.2214	.2214	.2372
21	.2056	.2214	.2214	.9172	.9488	1.0279	1.2018
22	.2214	.2214	.2214	1.0753	1.2651	1.3599	1.2967
23		.2214	.2056		1.2651	1.4706	
24	.7116	.2214	.2214	.2056		1.2651	1.4706
Max	1.8027	2.0557	1.8343	1.0753	1.2651	2.0873	1.4706
Min	.0949	.2056	.2027	.1265	.0949	.1107	.1265
Avg	1.0024	.7748	.6812	.2812	.3367	.6714	.4191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2027	.0579	.0724	.0579	.4633	.5068	.5792
2	.2027	.0579	.0724	.0579	.5068	.5268	.5792
3	.2027	.0579	.0724	.0579	.5792	.5068	.5792
4	.2751	.0579	.0724	.0579	.6081	.5792	.5792
5	.362	.0724	.0869	.0579	.6516	.7964	1.0425
6	.4344	.0724	.1014	.0724	.8688	.9267	.9556
7	.5502	.0579	.0869	.0724	.1158		.0724
8	.6371	.0579	.2606	.0579	.0869	.0869	.0579
9	.6081	.1448	.4633	.0724	.0579	.0579	.0579
10	.5502	.9412	.7964	.0724	.0579	.0579	.0579
11	.724	1.0136	.8398		.0579	.0579	
12	.8109	1.0136	.9122		.0579		.0648
13	.7964	.9412	.9991	.0579	.0579		.0648
14	.724	.9267	.9556	.0579	.0579		.0648
15	.7819	.9267	1.0136				.0579
16	.7529	.7674	.0579			.0434	.0579
17	.0579	.0579				.0434	.0579
18	.0434	.0724	.0579			.0434	.0579
19	.0434	.0724	.0579		.0724	.0434	.0579
20	.0434	.0724	.0579	.0724	.0724	.0579	.0724
21	.0434	.0724	.0579	.3041	.5068	.2896	.4199
22	.0579	.0724	.0579	.362	.5068	.5502	.5792
23		.0724	.0579	.4633	.5068	.6371	
24	.1448	.0579	.0724	.0579	.5182	.5068	.6371
Max	.8109	1.0136	1.0136	.4633	.8688	.9267	1.0425
Min	.0434	.0579	.0579	.0579	.0579	.0434	.0579
Avg	.3935	.3216	.3167	.1184	.3206	.3326	.3070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	1.7004	1.2146	1.4575	.2591	.2915	.2429
2	.1943	1.7004	1.2146	1.4575	.2591	.2915	.2429
3	.1943	1.7004	1.2146	1.4575	.2591	.2915	.2429
4	.1943	2.1376	1.2955	1.7814	.2915	.2915	.2915
5	.2429	2.332	1.4575	1.9109	.3239	.2915	.3239
6	.3239	2.4615	1.6518	2.0243	.3887	.3563	.3563
7	.3563	2.332	.2591	.2915	.3887	.3077	.3563
8	.2915	2.4291	.3563	1.4575	1.2955	.8097	1.4575
9	.2591	.2267	.2915	2.4291	1.7814	1.7004	2.1214
10	.2591	.2591	.2429	2.4291	2.1052	1.9757	2.2672
11	.2915	.2591	.2267	2.5101	2.2672	2.332	2.1052
12	.3563	.2591	.2105	1.8461		2.1862	2.1052
13	.3239	.2105	.1943	2.1376	2.3482	2.3644	2.1052
14	.2915	.1781	.2267	2.2348	1.5384	2.2996	2.1052
15	.3239	.2105	.2267	2.1538	1.3765	2.1052	2.17
16	.3239	.2105	.2267	.1296	.081	.2105	.1943
17	.3563	.2591	.2591	.181	.1943		.1943
18	.2915	.2915	.2915	.2429	.2267	.2591	.2267
19	.3239	.3077	.2915	.3239	.2915	.2915	.2591
20	.2915	.3401	.3239	.3563	.2915	.3239	.2753
21	.2591	.3401	.8907	.3239	.2915	.2267	.2105
22	.2915	.3401	1.166	.2753	.2915	.2591	.2027
23		.6478	1.3765	.2591	.2915	.2429	
24		.9393	1.2146	1.3765	.2591	.2915	.2267
Max	.3563	2.4615	1.6518	2.5101	2.3482	2.3644	2.2672
Min	.1943	.1781	.1943	.1296	.081	.2105	.1943
Avg	.2834	.9197	.6802	1.2936	.7435	.8696	.8819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0716	.0905	.0716	.0724	.0895	.0716
2	.0724	.0716	.0905	.0716	.0724	.0895	.0716
3	.0724	.0716	.0905	.0716	.0724	.0895	.0716
4	.0905	.0895	.0905	.1254	.0724	.0895	.0895
5	.1086	.1254	.0905	.1075	.0648	.1075	.0716
6	.1267	.1433	.1448	.0895	.0972	.1254	.1075
7	.1448	.1075	.1448	.1254	.081	.1254	.1075
8	.1075	.1086	.1448	.1075	.0543	.1254	.0895
9	.0716	.1086	.0716	.0905	.0543	.0895	.0905
10	.0895	.1086	.0716	.0905	.0724	.0716	.1267
11	.0716	.1086	.0716	.0724	.0724	.0895	.1086
12	.0537	.0724	.0895	.0724	.0724	.1075	.0905
13	.0537	.0724	.0716	.0724	.0724	.0895	.0905
14	.0716	.0905	.0537	.0543	.0905	.0716	.0905
15	.0716	.0905	.0716	.0543	.0543	.0716	.0905
16	.0716	.1086	.0716	.0724	.0543		.0905
17	.0716	.0905	.0895	.0724	.0905	.0895	.0905
18	.1075	.0905	.1075		.1086	.0716	.1086
19	.0895	.1086	.1075		.1629	.1075	.1448
20	.0716	.1629	.0895	.1267	.1629	.1254	.181
21	.0895	.1629	.0895	.0905	.1629	.1075	.0972
22	.1254	.1448	.1075	.0724	.1267	.1433	.0905
23		.1086	.1433	.0543	.1086	.0895	
24	.0724	.0895	.2963	.0895	.0543	.0895	.0716
Max	.1448	.1629	.2963	.1267	.1629	.1433	.181
Min	.0537	.0716	.0537	.0543	.0543	.0716	.0716
Avg	.0860	.1045	.1038	.0843	.0878	.0981	.0975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi  
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0185	.0181	.0185	.0181	.037	.0185
2	.0181	.0185	.0181	.0185	.0181	.037	.0185
3	.0181	.0185	.0181	.0185	.0362	.037	.0185
4	.0362	.0185	.0181	.0554	.0362	.037	.0554
5	.0543	.0554	.0181	.0554	.0362	.0554	.037
6	.0543	.0554	.0543	.0554	.0543	.0739	.037
7	.0543	.0739	.0724	.0554	.0724	.0554	.0554
8	.037	.0543	.0543	.0924	.0905	.0739	.037
9	.037	.0543	.037	.0905	.0543	.037	.0181
10	.0554	.0543	.037	.0543	.0543	.037	.0362
11	.0185	.0543	.037	.0543	.0543	.037	.0362
12	.0185	.0543	.0554	.0362	.0543	.037	.0362
13	.0185	.0543	.037	.0362	.0543	.0554	.0362
14	.0185	.0543	.037	.0173	.0543	.037	.0362
15	.0185	.0543	.037	.0181	.0543	.037	.0181
16	.0185	.0543	.037	.0181	.0181	.037	.0181
17	.037	.0543	.0554	.0181	.0181	.0185	.0362
18	.037	.0543	.037	.0181	.0181	.0185	.0362
19	.037	.0543	.037	.0362	.0724	.0185	.0362
20	.0185	.0543	.037	.0724	.0543	.037	.0724
21	.0185	.0543	.0554	.0362	.0543	.037	
22	.0554	.0181	.0739	.0373	.0543	.0554	
23		.0181	.0554	.0362	.0362	.0739	
24	.0181	.037	.0181	.037	.0362	.037	.037
Max	.0554	.0739	.0739	.0924	.0905	.0739	.0724
Min	.0181	.0181	.0181	.0173	.0181	.0185	.0181
Avg	.0311	.0455	.0398	.0411	.0460	.0424	.0348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.2401	.2401	.2229	1.0802	1.2689	1.1831
2	.5658	.2229	.2229	.2401	1.0974	1.3032	1.1831
3	.6001	.2229	.2229	.2401	1.0974	1.3546	1.2003
4	.6516	.2401	.2401	.2743	1.0974	1.4232	1.2174
5	.7545	.2572	.2401	.3258	1.1145	1.5261	1.2517
6	.9945	.3429	.3258	.3944	1.4746	1.6289	
7	1.0802	.3258	.4458	.3944	.3429	.3258	
8	1.1145	.2915	.5487	.3429	.3772	.2743	
9	1.0364	.6173	.7373	.2401	.3258	.3429	.2229
10		1.0802	1.3717	.2401	.3429	.3429	.3086
11	1.0288	1.3203	1.5089	.2915	.3429	.3258	.2915
12	1.1317	1.3375	1.4918	.3086	.3601	.3429	
13	1.1145	1.406	1.4746	.3086	.3429	.3429	.0343
14	1.166	1.4403	1.5432	.3258	.3429	.3429	
15	1.1317	.5144	1.5947	.3258	.3086	.3258	.2915
16	1.2517	.9259	.3601	.3086	.3772	.3429	.3429
17	.1715	.1543	.2915	.3429	.3429	.3429	.3429
18	.2401	.2058	.2915	.3429	.3258	.3429	.2058
19	.2401	.2229	.3258	.3944	.3429	.3429	.3086
20	.2915	.3429	.3429	.3601	.3601	.3429	.3429
21	.2743	.3086	.3258	.8573	.6173	.8745	.7716
22	.2401	.2743	.2915	1.0802	1.0974	1.2003	1.046
23	.2401	.2572	.2572	1.0802	1.2174	1.1831	1.0631
24	.5144	.2401	.2401	.2229	1.0802	1.2517	1.1831
Max	1.2517	1.4403	1.5947	1.0802	1.4746	1.6289	1.2517
Min	.1715	.1543	.2229	.2229	.3086	.2743	.0343
Avg	.7116	.5330	.6223	.3944	.6587	.7373	.6732



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.6344	.9259	1.0974	.2572	.2134	.2401
2	.1981	.6344	.9431	1.1279	.2572	.2134	.2401
3	.2286	.6516	.9431	1.1888	.2572	.2439	.2401
4	.2591	.6516	.9945	1.2803	.2743	.2896	.2572
5	.3353	.7716	1.0631	1.4632	.2915	.381	.2915
6	.442	1.3375	1.4918	1.6766	.4801	.4877	
7	.381	1.4575	.4801	.4725	.4973	.4877	
8	.3201	1.3889	.3601	1.3108	1.1831	1.2803	
9	.2743	.2058	.3086	1.829	1.3717	1.9376	.9774
10	.3258	.1715	.2896	2.5034	1.9204	1.989	1.8176
11	.3086	.2401	.3048		2.1795	2.0919	.4801
12	.3086	.2572	.2743		2.2405	2.1605	1.3546
13	.3429	.3086	.2896	2.4006	2.3015	2.0405	2.0405
14	.3601	.2915	.2743	2.5377	2.0576	1.6461	2.0919
15	.3601	.2915	.2743	2.452	2.332	1.6804	2.1776
16	.2915	.2743	.2591	.2743	.2743	.2915	.2401
17	.2572	.2915	.2743	.3086	.2896		.2058
18	.2401	.3429	.3048	.3086	.3506	.2915	.2572
19	.2401	.3429	.3506	.3258	.3506	.3429	.3258
20	.2572	.3944	.3201	.3601	.3658	.3944	.3772
21	.2572	.3429	.5944	.3429	.3201	.3601	.3429
22	.1715	.2572	.8688	.3086	.2743	.2915	.3086
23	.5487	.6859	1.0059	.2572	.2743	.2401	.2915
24	.1829	.6001	.8573	1.0669	.2572	.2439	.2401
Max	.5487	1.4575	1.4918	2.5377	2.332	2.1605	2.1776
Min	.1715	.1715	.2591	.2572	.2572	.2134	.2058
Avg	.2947	.5344	.5855	1.1315	.8607	.8521	.7047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1372	.1029	.1029	.1715	.12
2	.0857	.0857	.1372	.1029	.1029	.1543	.12
3	.12	.0857	.1372	.1029	.1029	.1543	.12
4	.1372	.0857	.1372	.12	.1029	.1715	.12
5	.1543	.12	.1372	.1543	.12	.1886	.1372
6	.2058	.2229	.1715	.2058	.2229	.2229	
7	.1715	.1886	.2058	.1886	.2229	.2401	
8	.1543	.1372	.2401	.1886	.1715	.2229	
9	.2572	.1715	.1715	.2401	.2401	.2401	.1372
10	.1543	.1715	.1543	.2401	.2572	.2401	.1715
11		.1715	.2572	.1029	.2572	.2058	.1372
12		.12	.2401	.2229	.2572	.2229	.1372
13	.0857	.0343	.2401	.1029	.1029		.0857
14	.0857		.1829	.1886	.1029		.12
15	.12		.1677	.1715	.1029	.12	.12
16	.1372	.0686	.1219	.2229	.1029	.1372	.12
17	.1543	.1715	.1524	.1715		.12	.1372
18	.1886	.2058	.1829	.1372	.1543	.1543	.1715
19	.2058	.2401	.1886	.1543	.2058	.1543	.1715
20	.2058	.2743	.2401	.2401	.2743	.1886	.2058
21	.2058	.2058	.1715	.2058	.2229	.1715	.1886
22	.1543	.12	.1715	.1543	.2058	.1543	.1543
23	.1372	.1372	.1372	.1029	.1715	.12	.12
24	.0762	.1029	.1372	.12	.1029	.1715	.12
Max	.2572	.2743	.2572	.2401	.2743	.2401	.2058
Min	.0762	.0343	.1219	.1029	.1029	.12	.0857
Avg	.1492	.1458	.1759	.1643	.1700	.1785	.1388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857	.12	.1029	.1029	.1029	.0343
2	.0686	.0857	.12	.0857	.1029	.0857	.0343
3	.0686	.0857	.12	.0857	.1029	.0857	.0343
4	.0857	.0857	.12	.1029	.1029	.1029	.0514
5	.0857	.12	.12	.12	.12	.1029	.0686
6	.1029	.12	.1715	.1715	.1372	.1029	
7	.0857	.1029	.1372	.1372	.12	.0857	
8	.0686	.0686	.0514	.0857	.0686	.0686	
9	.0514	.0686	.0514	.0686	.0686	.0514	.0514
10	.0343	.0686	.0514	.0514	.0514	.0514	.0514
11	.0514	.0343	.0514	.0514	.0343	.0514	.0514
12	.0514	.0514	.0514	.0514	.0514	.0514	.0514
13	.0343	.0514	.0686	.0514	.0514	.0343	.0343
14	.0343	.0343	.0686	.0343	.0514	.0343	.0343
15	.0343	.0343	.0514	.0343	.0514	.0514	.0514
16	.0514	.0343	.0514	.0343	.0514	.0343	.0514
17	.0514	.0343	.0514	.0514	.0686	.0514	.0514
18	.0514	.0343	.0514	.0514	.1029	.0686	.0514
19	.0686	.0343	.0857	.0686	.1029	.0857	.0686
20	.12	.1543	.0514	.12	.1372	.12	.0857
21	.12	.1543	.1543	.12	.12	.1029	.0857
22	.0857	.0343	.1543	.1029	.1029	.0514	.0686
23	.1029	.12	.12	.1029	.1029	.0686	.0514
24	.0686	.0572	.12	.12	.1029	.1029	.0514
Max	.12	.1543	.1715	.1715	.1372	.12	.0857
Min	.0343	.0343	.0514	.0343	.0343	.0343	.0343
Avg	.0686	.0731	.0914	.0836	.0879	.0729	.0531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.583	.583	.6859	.1543	.1372	.1886
2	.1067	.6173	.583	.7164	.1543	.1372	.1886
3	.1372	.6173	.6001	.7468	.1543	.1524	.1886
4	.1677	.6344	.6001	.7926	.1715	.2229	.1886
5	.2134	.7202	.6173	.884	.2058	.2915	.2058
6	.2591	1.2346	.9259	1.0517	.2743	.3201	
7	.2286	1.5775	.3772	.3201	.3429	.3201	
8	.2134	1.6289	.3086	1.0212	.9602	.8993	
9	.2439	.1543	.2401	1.4784	1.2346	1.2498	.7888
10	.1715	.2915	.2439	1.8347	1.6461	1.4746	1.5432
11	.1543	.1886	.2439	1.869	1.768	1.7661	1.5604
12	.1715	.1715	.2134	1.9547	1.6613	1.8176	1.6461
13	.1372	.2229	.1981	2.1262	1.7833	1.9204	1.8176
14	.1372	.2401	.1981	2.1605	1.7833	1.989	1.8861
15	.1372	.2229	.1829	2.0405	1.7223	1.869	1.8861
16	.1372	.2058	.1981	.2058	.1715	.1886	.2058
17	.1543	.2058	.2134	.2229	.2134	.2572	.1886
18	.1372	.2058	.2134	.2401	.2286	.2915	.2058
19	.1715	.2058	.2134	.2743	.2134	.2915	.2743
20	.2572	.2572	.2591	.2572	.1981	.2743	.2743
21	.2401	.2229	.5487	.2229	.1829	.2401	.2572
22	.2058	.2058	.6554	.2058	.1677	.2229	.2058
23	.5316	.3772	.6554	.1543	.1524	.1886	.1886
24	.1067	.583	.5658	.6706	.1543	.1524	.1886
Max	.5316	1.6289	.9259	2.1605	1.7833	1.989	1.8861
Min	.1067	.1543	.1829	.1543	.1524	.1372	.1886
Avg	.1886	.4823	.4016	.9224	.6541	.6948	.6704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.0686	.0514	.061	1.4232	1.2651	1.4746
2	.8383	.0686	.0514	.0457	1.4232	1.2955	1.4746
3	.8688	.0686	.0514	.0457	1.4403	1.326	1.4918
4	.9145	.0686	.0514	.061	1.4403	1.3717	1.4918
5	.9907	.0857	.0514	.0762	1.4918	1.4632	1.4918
6	1.1888	.0857	.0514	.0914	1.9033	1.6156	
7	1.4175	.0857	.12	.0762	.12	.0762	
8	1.448	.0686	.583	.061	.0857	.061	
9	1.387	.7716	1.0631	.0457	.0457	.0686	.0514
10	1.5089	1.3717	1.3565	.0514	.0457	.0686	.0514
11	1.5775	1.5775	1.6613	.0514	.0305	.0514	.0514
12	1.6804	1.5775	.0305	.0514	.0305	.0514	.0514
13	1.5432	1.8861	1.4327	.0514	.0457	.0514	.0343
14	1.6632	1.7147	1.4632	.0343	.0457	.0514	.0514
15	1.6461	1.4746	1.6309	.0343	.0457	.0343	.0514
16	1.5947	1.4575	.2134	.0514	.0305	.0343	.0514
17	.0514	.0343	.0457	.0514	.0457	.0514	.0514
18	.0686	.0343	.061	.0514	.0762	.0514	.0514
19	.0857	.0514	.0762	.0686	.0762	.0514	.0514
20	.12	.0686	.0914	.0686	.0914	.0857	.0686
21	.0857	.0686	.1067	.9431	.6097	1.1488	.9088
22	.0857	.0343	.0762	1.3717	1.1584	1.4746	1.3889
23	.0686	.0514	.061	1.406	1.2193	1.4746	1.3375
24	.7926	.0686	.0514	.061	1.4232	1.2498	1.4746
Max	1.6804	1.8861	1.6613	1.406	1.9033	1.6156	1.4918
Min	.0514	.0343	.0305	.0343	.0305	.0343	.0343
Avg	.9354	.5351	.4347	.2046	.5978	.6031	.6263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.0953	.0762	.0953	.2429	.2458	.1949
2	.1311	.0953	.0762	.0953	.2429	.2458	.1949
3	.1475	.0953	.0762	.0953	.2429	.2458	.2058
4	.1638	.0953	.0953	.0953	.2429	.3086	.2401
5	.1943	.1334	.1143	.1334	.3239	.463	.2915
6	.4534	.2286	.1905	.2286	.6478	.6481	.7956
7		.2286	.2286	.1905	.2858	.2667	.1715
8		.1715	.2058	.1524	.1905	.1905	.1524
9		.1254	.2401	.0953	.1143	.0953	.0953
10		.5801	.3395	.0953	.0953	.0762	.0762
11	.4843	.7459	.4515	.0762	.0762	.0381	.0762
12	.68	.7127	.4161	.0762	.0762	.0572	.0572
13	.6718	.7625	.4401	.0762	.0381	.0381	.0381
14	.6859	.7625	.5268	.0762	.0572	.0381	.0381
15	.3666	.7459	.5556	.0762	.0762	.0381	.0572
16	.5117	.7293	.0572	.0762	.0572	.0572	.0572
17	.1715	.0762	.0953	.0762	.0762	.0572	.0762
18	.0953	.0762	.1143	.0953	.0953	.0572	.0953
19	.1143	.1334	.1143	.1334	.1524	.0953	.1334
20	.1905	.1524	.1905	.381	.1715	.1334	.1715
21	.1524	.1143	.1524	.2429	.2458	.2328	.2214
22	.1334	.0953	.0953	.2429	.213	.2328	.1981
23	.0953	.0762	.0953	.2429	.2458	.2149	.1581
24	.1417	.0953	.0762	.0953	.2429	.2458	.197
Max	.6859	.7625	.5556	.381	.6478	.6481	.7956
Min	.0953	.0762	.0572	.0762	.0381	.0381	.0381
Avg	.2858	.2970	.2093	.1352	.1856	.1801	.1664

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2804	.056	.197	.1905	.2477	.3048
2	.2858	.2804	.056	.197	.1905	.2477	.3048
3	.2858	.2804	.056	.1991	.1905	.2477	.3048
4	.2858	.2947	.0747	.2172	.1905	.2858	.3048
5	.3239	.3155	.0747	.2715	.1905	.3429	.3239
6	.4191	.5935	.112	.4334	.381	.4572	.381
7		.9116	.1905	.4001	.4763	.4001	.4001
8		.7459	.1524	.4239	.2486	.2439	.2818
9		.2477	.1334	.5087	.2818	.4096	.2321
10		.2096	.2858	.6783	.3315	.6287	.4641
11	.2858	.2286	.2286	.663	.431	.6226	.4475
12	.2858	.2286	.1334	.663	.4062	.6554	.5304
13	.2286	.2477	.2477	.663	.4374	.6062	.4641
14	.2286	.2286	.2096	.5801	.6562	.6796	.4534
15	.2286	.2096	.1905	.5801	.5937	.4973	.4858
16	.1715		.2667	.1905	.1715	.2286	.1334
17	.1715		.2286	.1143	.1905	.1905	.1905
18	.2667		.2286	.1524	.2096	.2096	.1715
19	.3429	.1143	.2477		.2286	.2858	.2667
20	.4001	.1334	.362	.381	.362	.4001	.3048
21	.381	.1143	.2353	.2858	.3429	.362	.2858
22	.3239	.0762	.2172	.2858	.3048	.3429	.2477
23	.181	.0716	.1991	.2858	.2858	.3239	.2286
24	.2858	.2629	.0532	.1991	.1905	.2858	.3048
Max	.4191	.9116	.362	.6783	.6562	.6796	.5304
Min	.1715	.0716	.0532	.1143	.1715	.1905	.1334
Avg	.2834	.2893	.1767	.3726	.3118	.3834	.3257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0762	.0953	.0762	.0762
2	.0572	.0762	.0762	.0762	.0953	.0762	.0572
3	.0572	.0762	.0762	.0762	.0953	.0762	.0572
4	.0572	.0762	.0762	.0762	.0953	.0762	.0572
5	.0762	.0762	.0762	.0762	.0953	.0953	.0572
6	.0762	.1143	.1143	.1143	.0953	.1143	.0953
7		.1334	.1334	.1334	.1143	.1334	.1143
8		.0762	.0953	.0572	.0953	.0762	.0572
9		.0762	.0572	.0762	.0762	.0572	.0381
10		.0191	.0381	.0572	.0572	.0191	.0572
11	.0953	.0572	.0762	.0762	.0572	.0381	.0572
12	.0953	.0762	.0762	.0762	.0572	.0572	.0762
13	.0762	.0572	.0572	.0572	.0381	.0381	.0762
14	.0762	.0381	.0572	.0572	.0572	.0381	.0572
15	.0572		.0572	.0381	.0572	.0191	.0381
16	.0572	.0381	.0572	.0381	.0572	.0381	.0381
17	.0762	.0381	.0762	.0381	.0572	.0381	.0572
18	.0953	.0762	.0572	.0572	.0762	.0953	.0762
19	.1334	.0762	.0762		.0762	.1334	.1143
20	.1715	.1334	.1334	.1715	.1715	.1524	.1715
21	.1334	.1143	.1143	.1334	.1334	.1334	.0762
22	.0953	.0953	.1143	.1143	.0762	.1143	.1143
23	.0762		.0762	.0953	.0762	.0762	.0762
24	.0572	.0762	.0762	.0762	.0953	.0762	.0762
Max	.1715	.1334	.1334	.1715	.1715	.1524	.1715
Min	.0572	.0191	.0381	.0381	.0381	.0191	.0381
Avg	.0839	.0762	.0802	.0804	.0834	.0770	.0738



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2818			.1905	.2858	.2477
2	.2286	.2818			.1905	.2858	.2477
3	.2286	.2818			.1905	.2858	.2477
4	.2858	.3052			.1905	.3429	.3048
5	.3429	.3944			.1905	.381	.381
6	.4382	.6443			.4763	.4191	.4763
7		.8745		.4763	.4763	.4763	.5144
8		.9503		.5087	.4144	.3932	.4096
9		.2286		.5935	.4973	.426	.4915
10		.1905		.6783	.547	.4915	.5506
11	.2667			.6478	.6133	.5735	
12	.2286	.1715		.6478	.4321	.5243	.3858
13	.2096	.1334		.6478	.4321	.4915	.5247
14	.1143	.1334		.4858	.4167		.2469
15	.1143	.1334			.4167	.2949	.4572
16	.1715	.1334		.1905	.1143	.1715	.1715
17	.1905			.1905	.1524	.1334	.1905
18	.2096	.2096		.1905	.2096	.1905	.2286
19	.2858	.2667			.3429	.3048	.2477
20	.4001	.362		.381	.4382	.4191	.4001
21	.3239	.2858		.2858	.3239	.2858	.3429
22	.2477	.2286		.2858	.2858	.2477	.3239
23	.2543	.1886		.2858	.2858	.2286	.3048
24	.2286	.2883	.2229		.2858	.2858	.2477
Max	.4382	.9503	.2229	.6783	.6133	.5735	.5506
Min	.1143	.1334	.2229	.1905	.1143	.1334	.1715
Avg	.2499	.3167	.2229	.4331	.3381	.3452	.3454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 201 / 11KV WALEKHINDI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
24	1.4918
Max	1.4918
Min	1.4918
Avg	1.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 202 / 11KV BEVNOOR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 201 / 11 Kv Basargi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.8316	.5401	.6468	.1829	.1898	.1581
2	.1294	1.1088	.5468	.6535	.1829	.1898	.1581
3	.1294	1.2012	.6249	.7655	.2195	.1898	.1581
4	.1848	1.4784	.6173	.7655	.2195	.253	.2056
5	.2218	1.6632	.9014	1.0719	.2926	.2846	.2688
6	.2772	1.6817	.9922	1.3443	.2926	.3163	.3321
7		2.0328	.333	.2772	.3841	.2846	.3795
8	.3326	2.2361	.2378	1.5339	.4902	.8539	.7432
9	.2957	.2572	.181	2.0144	.6167	.9646	1.1544
10	.2402	.1829	.1478	1.7394	.8381	1.2651	1.0686
11	.2402		.1478	1.692	.9804	1.3125	1.2803
12	.2218	.156	.1663	1.5971	1.0911	1.3916	.9488
13	.2218	.2149	.1848	1.4232	1.0279	1.3283	1.0802
14	.2033		.1478	1.3916	1.0753	1.2651	1.3413
15	.2218	.1829	.0924	1.3094	.9488	1.3283	1.4784
16	.2218	.1294	.1478	.1698	.1898	.1423	.2328
17	.1848	.1629	.1478	.1886	.1739	.1423	.2033
18	.2218	.197	.1663	.2075	.1898	.1739	.2218
19	.2402	.1991	.1848	.2263	.2372	.1898	.2865
20	.2218	.2715	.2587	.2829	.1898	.2372	.3189
21	.1848	.2378	.5359	.2452	.2214	.1898	.2507
22	.2218	.1848	.5175	.2378	.1898	.1739	.2218
23	.2033	.3361	.5544	.2012	.1898	.1581	.2012
24	.1848	.8316	.4725	.5175	.1829	.1898	.1581
Max	.3326	2.2361	.9922	2.0144	1.0911	1.3916	1.4784
Min	.1294	.1294	.0924	.1698	.1739	.1423	.1581
Avg	.2153	.7172	.3686	.8543	.4420	.5423	.5354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 202 / 11 Kv Basargi Gavtaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0747	.0754	.0747	.168	.0747	.0747
2	.0943	.0747	.0754	.0747	.168	.0747	.0747
3	.0943	.0747	.0754	.0747	.2241	.0747	.0747
4	.0943	.112	.0754	.112	.2241	.1494	.112
5	.1886	.1494	.1307	.1494	.2427	.1867	.168
6	.2075	.168	.1848	.168	.2427	.2241	.2241
7		.1494	.1463	.1867	.2075	.2054	.2427
8	.2075	.1494	.1463	.1867	.2075	.2054	.168
9	.1494	.1307	.1509	.1494	.132	.1307	.1494
10	.0934	.0924	.1132	.1063	.0943	.0934	.1109
11	.056	.0754	.0754	.1063	.0754	.0747	.0747
12	.056	.0754	.0747	.0709	.0754	.0747	.0754
13	.0373	.0754	.056	.0532	.0377	.0373	.0566
14	.0373		.056	.0532	.0377	.0373	.0566
15	.0373	.0566	.056	.056	.0566	.0187	.0754
16	.056	.0747	.0747	.0747	.0566	.0373	.0747
17	.056	.1132	.0934	.168	.0754	.112	.1132
18	.112	.1307	.1307	.2054	.1132	.1307	.1509
19	.1494	.1663	.168	.1867	.1886	.168	.1478
20	.1494	.2012	.2427	.2054	.1886	.2427	.2195
21	.112	.1848	.1494	.168	.1886	.1494	.1848
22	.0934	.1867	.112	.1867	.1132	.0747	.112
23	.0934	.0943	.0934	.1867	.1509	.0747	.0943
24	.0754	.0747	.0943	.0934	.168	.0747	.0747
Max	.2075	.2012	.2427	.2054	.2427	.2427	.2427
Min	.0373	.0566	.056	.0532	.0377	.0187	.0566
Avg	.1019	.1167	.1104	.1291	.1432	.1136	.1212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 203 / 11 KV Sindur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.1943	.2195	.0463	1.2955	1.4746	.8848
2	.6554	.1943	.2218	.0463	1.5384	1.3108	.8848
3	.8192	.2591	.2218	.0463	1.7004	1.5402	.9831
4	1.2452	.3239	.2218	.108	1.749	1.5074	1.2125
5	1.6876	.3887	.3841	.1389	1.5074	1.8023	1.3272
6	2.5396	.502	.5611	.1543	1.4091	1.8679	1.4582
7		.3401	.5194	.1389		.2949	.4096
8	1.6876	.3401	.5087	.108		.3277	.3605
9	1.6356	.2591	.9831	.2469		.2458	.2458
10	1.6032	1.5586	1.6358	.2054		.1966	.2126
11	1.6518	1.9509		.168		.1638	.181
12	1.4575	1.8903	1.3426	.168	.1966	.168	.1646
13	1.6356	2.0153	1.4969	.2054	.1966	.1311	.1109
14	1.668		1.6358	.1867	.1147	.1311	.1478
15	1.5708		1.0802	.1734	.1475	.1475	.1663
16	.1943	1.4043	.1852	.1907	.1638	.1475	.1509
17	.1943	.1753	.1852	.2254	.1802	.213	.1886
18	.2105	.2865	.216	.2254	.1966	.2458	.2075
19	.2267	.3077		.3294	.2622	.2949	.3109
20	.1943	.394	.108	.3294	.2294	.2949	.3696
21	.2267	.3077	.0772	.9717	.6554	1.0322	.9945
22	.1943	.2172	.0617	1.4089	1.4746	.9831	1.1203
23	.1943	.2218	.0463	1.5384	1.4582	.9175	1.1336
24	.5243	.1943	.2195	.0463	1.587	1.4091	.852
Max	2.5396	2.0153	1.6358	1.5384	1.749	1.8679	1.4582
Min	.1943	.1753	.0463	.0463	.1147	.1311	.1109
Avg	.9857	.6239	.5514	.3086	.8454	.7020	.5866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18
HR	Load (MW)
24	.2401
Max	.2401
Min	.2401
Avg	.2401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.4918
Max	1.4918
Min	1.4918
Avg	1.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 209 / 11 Kv JATH West

Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	01-JUL-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11KV K. MAHANKAL GAO  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6516	.7373	.7373	.7701	
2	.6859	.6859	.6173	.6859	.7202	.7701	
3	.6516	.6516	.6173	.6859	.6859	.7701	
4	.7545	.7373	.6687	.6516	.823	.8059	
5	.823	.7716	.7202	.7888	.8916	.8059	.8596
6	.8916	.9774	.8059	.8916	1.0974	.8417	
7	1.0802	1.0974	.9945	1.0631	1.0974	1.0387	1.1104
8	1.0631	1.0802	.9602	1.046	1.1488	.9671	1.0924
9	1.0117	1.0117	.9088	1.0288	.9945	.9671	.985
10	.9602	.9602	.8573	.9602	.9259	.9671	.9134
11	.9259	1.0117	.823	.9259	.8745	.8775	.8238
12	.9088	.9774	.8059	.8573	.8573	.8417	.788
13	.8402	.8916	.823	.7888	.8059	.8238	.788
14	.7373	.8402	.7202	.7373	.7888	.8417	.7343
15	.7373	.7716	.7545	.7545	.7545	.8596	.6626
16	.8402	.7202	.7373	.7716	.7373	.8417	.7343
17	.7545	.7888	.7716	.8573	.823	.8954	.7343
18	.7716	.823	.8059	.8916	.8916	.9671	.9671
19	.9774	.9602	.8745		.9602	1.0745	1.0745
20	1.1145	1.1145	1.1488	1.2003	1.0117	1.1283	1.1104
21	.9774	.9945	1.0974	1.0631	1.046	1.0208	1.0745
22	.9259	.8916	.9774	.9431	.8916	.985	.8417
23	.7716	.7716	.8059	.7888	.823	.7701	.8059
24	.7202	.7202	.6859	.7716	.7716	.788	.7522
Max	1.1145	1.1145	1.1488	1.2003	1.1488	1.1283	1.1104
Min	.6516	.6516	.6173	.6516	.6859	.7701	.6626
Avg	.8588	.8723	.8180	.8648	.8816	.8925	.8870



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.1372	.1543	.1372	1.2003	1.5261	.9835
2	1.0288	.1372	.1372	.1372	1.3032	1.5939	1.153
3	1.0288	.12	.1372	.12	1.3717	1.6278	1.2209
4	1.0802	.1543	.1543	.1543	1.4575	1.6617	1.3226
5	1.166	.1886	.1715	.1715	1.5775	1.6448	1.3904
6	1.2346	.2743	.1886	.2058	1.6804	1.6787	1.4922
7	1.5604	.2743	.2058	.2229	.2058	.2543	.2035
8	1.6632	.2572	1.2346	.2058	.2058	.2035	.2204
9	1.749	1.2346	1.5089	.1715	.2058	.2374	.1696
10	1.8347	2.0576	1.7147	.1886	.1886	.2035	.1526
11	1.9547	2.3663	1.7833	.2058	.1715	.1865	.1865
12	1.7833	2.2462	1.8347	.1886	.1886	.1526	.1526
13	1.6118	2.4006	1.8861	.1715	.1715	.1526	.1017
14	1.5775	2.4348	1.869	.1543	.1715	.1696	.132
15	1.6975	2.1434	1.7833	.1715	.1029	.1357	.1017
16	1.7661	1.8176	.1029	.1543	.1543	.1187	.1187
17	.1372	.1372	.1372	.1372	.1696	.1357	.0678
18	.1543	.1372	.1886	.1715	.1865	.1526	.0509
19	.2058	.1715	.2058		.2229	.1865	.1696
20	.2058	.1886	.2058	.2229	.2401	.2035	.2035
21	.1886	.1886	.1886	1.3203	1.2887	1.0513	.8817
22	.1886	.1543	.1715	1.3203	1.3226	1.0852	.9619
23	.1715	.1372	.1543	1.2689	1.3904	1.0343	.8478
24	.9259	.1543	.1543	.1543	1.2346	1.4582	1.0174
Max	1.9547	2.4348	1.8861	1.3203	1.6804	1.6787	1.4922
Min	.1372	.12	.1029	.12	.1029	.1187	.0509
Avg	1.0781	.8130	.6780	.3198	.6838	.7023	.5543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV RANJANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1357	.1696	.1696	1.5261	1.8991	1.3904
2		.1357	.1696	.1696	1.6617	2.0856	1.5261
3		.1187	.1526	.1526	1.95	2.1365	1.6617
4		.1526	.1865	.1865	2.1026	2.2721	2.0008
5		.2204	.2204	.2543	2.2891	2.4756	2.0008
6		.3222	.2883	.3222	2.4587	2.5943	2.0687
7	1.95	.3222	.3561	.373	.4917	.3391	.3222
8	2.0687	.3052	1.3904	.2883	.4409	.3222	.2374
9	2.0348	1.2717	1.8652	.2713	.3561	.2713	.2035
10		2.6113	1.95	.2543	.3391	.2543	.1696
11		2.5943	2.0348	.2374	.3052	.2374	.1696
12		2.2043	2.4247	.2204	.3052	.2035	.1526
13		2.4756	2.5774	.2374		.2713	.1696
14		2.6282	2.5774	.2204		.2204	.2035
15		2.2382	2.5943	.2374		.1865	.2035
16	1.3395	2.0687	.2374	.2374		.2035	.2374
17	1.4413	.1696	.2713	.2204	.2713	.2204	.2543
18	2.0687	.2035	.3052	.2374	.2883	.2374	.3052
19	.3391	.2543	.2374		.3052	.2713	.3052
20	.2883	.3052	.2883	.3052	.3052	.2883	.3222
21	.2883	.2543	.2883	1.3395	1.7295	1.4413	1.2378
22	.2035	.2374	.2543	1.3565	1.6617	1.4074	1.153
23	.1696	.1865	.2035	1.3565	1.6278	1.4413	1.17
24		.1526	.1865	.1865	1.3226	1.7974	1.4074
Max	2.0687	2.6282	2.5943	1.3565	2.4587	2.5943	2.0687
Min	.1696	.1187	.1526	.1526	.2713	.1865	.1526
Avg	1.1083	.8987	.8846	.3841	1.0869	.9616	.7864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV LANGERPETH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.7122	.7461	1.1022	.1357	.12	.1029
2	.1017	.7122	.8139	1.1022	.1187	.12	.1029
3	.1017	.763	.8139	1.1869	.1696	.1372	.1372
4	.1357	.8478	.8987	1.2717	.1865	.1372	.1715
5	.1526	1.17	.9835	1.3565	.2204	.1543	.2229
6	.1865	1.4582	1.0682	1.4413	.2374	.2229	.2401
7	.2204	1.8313	.2035	.2374	.2204	.1715	.2229
8	.1696	1.6956	.1526	1.1869	1.2378	1.1145	1.0802
9	.1187	.0848	.1017	1.3904	1.3735	1.0117	1.2346
10	.1187	.0848	.1187	1.6108	1.6956	1.5432	1.3717
11	.1017	.0848	.1357	1.8482	1.8313	1.6632	1.0802
12	.1526	.0678	.1187	1.8991	1.6956	1.2003	1.286
13	.1017	.0848	.0848	1.9669	1.4922	1.7147	1.0974
14	.1187	.0848	.1187	1.8652	1.5091	1.6118	1.2346
15	.1017	.0848	.0848	1.7974	1.4922		1.3203
16	.1187	.0678	.1187	.1357	.1526	.1029	.12
17	.1357	.1017	.1357	.1187	.1865	.12	.12
18	.1187	.1357	.1526	.1526	.1865	.1372	.1543
19	.1696	.1526	.1357		.2035	.1715	.1715
20	.1696	.1696	.1865	.2204	.1865	.2058	.1886
21	.1865	.1526	.8817	.1696	.1991	.1715	.1029
22	.1357	.1357	.9835	.1526	.1448	.12	.1372
23	.6443	.763	1.0174	.1526	.1372	.12	.12
24	.1187	.6783	.7122	1.0513	.1357	.12	.12
Max	.6443	1.8313	1.0682	1.9669	1.8313	1.7147	1.3717
Min	.1017	.0678	.0848	.1187	.1187	.1029	.1029
Avg	.1583	.5052	.4486	1.0181	.6312	.5301	.5058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.FACTORY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.1543	.1715	.1886	.9602	1.5775	1.166
2	.7545	.1372	.1543	.1715	1.0288	1.5775	1.3375
3	.7888	.1372	.1372	.1715	1.1145	1.6118	1.4403
4	.7888	.1715	.1886	.1886	1.2003	1.6461	1.5432
5	.8573	.2058	.2743	.2572	1.3546	1.6118	1.6461
6	.8916	.3258	.3601	.3772	1.4575	1.6461	1.8519
7	1.0974	.3086	.3429	.3944	.3772	.3601	.3086
8	1.1488	.2915	.9431	.3772	.3086	.3429	.3258
9	1.2174	.8059		.3429	.3086	.3258	.2572
10	1.1317	1.4746	.9945	.2401	.2915	.3772	.2401
11	1.2003	1.6118	1.4918	.2401	.2572	.3086	.2229
12	1.2517	1.6461		.2058	.2401	.2915	.2401
13		1.7147		.2401	.2572	.2401	.2401
14	.9114	1.749	.3944	.2572	.2572	.2572	.2572
15	1.2003	1.6461	.7888	.3086	.2743	.2915	.2229
16	1.166	1.4575	.1372	.2229	.2572	.2865	.2229
17	.2229	.1543	.1543	.2572	.2915	.2401	.2572
18	.2058	.2229	.1886	.2915	.3086	.2572	.2915
19	.2572	.2572	.3086		.3258	.2743	.3086
20	.2743	.2743	.3258	.2743	.3086	.3429	.3601
21	.2743	.2401	.2572	1.0288	1.166	1.2003	1.0288
22	.2401	.2229	.2572	1.0288	1.3546	1.286	1.0802
23	.1715	.1886	.2229	1.0288	1.4403	1.2346	1.0288
24	.7202	.1646	.1715	.2058	.9945	1.4746	1.2003
Max	1.2517	1.749	1.4918	1.0288	1.4575	1.6461	1.8519
Min	.1715	.1372	.1372	.1715	.2401	.2401	.2229
Avg	.7620	.6484	.3936	.3608	.6723	.7943	.7116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV EXPRESS MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.0876	.0876	.0701	.0876	.0701	.1052
2	.1052	.0876	.0876	.0701	.0526	.0526	.0701
3	.0876	.0876	.0526	.0701	.0526	.0526	.0701
4	.0876	.0701	.0526	.0526	.0526	.0351	.0526
5	.0876	.0701	.0526	.0526	.0701	.0351	.0351
6	.0876	.0701	.0526	.0526	.0876	.0351	.0351
7	.1052	.1052	.0701	.0701	.0701	.0701	.0701
8	.0876	.0876	.0876	.0526	.0876	.0701	.0701
9	.0876	.0876	.0701	.0701	.0876	.0876	.0701
10	.0701	.1227	.1052	.0876	.0701	.1052	.0876
11	.1052	.1402	.1402	.1402	.0351	.1578	.1578
12	.1578	.1402	.1052	.1227	.0526	.1928	.1402
13	.1402	.1402	.1227	.1402	.0701	.1227	.1402
14	.1402	.1402	.1402	.1578	.0701	.1052	.1227
15	.1753	.1402	.1052	.1402	.0876	.1402	.0701
16	.1402	.1402	.1402	.0526	.0351	.1402	.0876
17	.1578	.1052	.0876	.0876	.0526	.1227	.0876
18	.1052	.0876	.0526	.1052	.0351	.1052	.0526
19	.1402	.0876	.0526		.0351	.1052	.0526
20	.1227	.1402	.0701	.0876	.0351	.0876	.0526
21	.1578	.1578	.0526	.0701	.0351	.0701	.0701
22	.3155	.1578	.1227	.1052	.0876	.1402	.1052
23	.1227	.1578	.1052	.1052	.0876	.1578	.0876
24	.1227	.1052	.1052	.0876	.0876	.0701	.1227
Max	.3155	.1578	.1402	.1578	.0876	.1928	.1578
Min	.0701	.0701	.0526	.0526	.0351	.0351	.0351
Avg	.1256	.1132	.0884	.0892	.0635	.0971	.0840

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV LANGERPETH GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1867	.2054	.2427	.1867	.2427	.2054
2	.1867	.168	.1867	.2054	.2241	.2427	.1867
3	.168	.168	.1715	.2054	.2427	.2054	.2241
4	.1867	.2054	.2054	.2427		.2054	.2427
5	.2427	.2427	.2241	.2987	.2987	.2801	.2801
6	.3174	.3174	.2614	.3734	.3361	.3174	.3174
7	.3361	.3547	.3361	.4294	.3734	.4294	.2054
8	.3361	.3361	.3174	.3734	.3921	.3547	.3174
9	.3547	.3547	.3174	.3361	.2987	.3361	.3174
10	.3361	.4668	.3361	.3361	.2614	.3174	.2241
11	.2987	.4294	.3734	.1867	.2801	.2801	.2801
12	.2801	.3921	.3361	.1867	.2195	.2801	.2801
13	.2054	.2915	.3734	.2054	.168	.168	.2054
14	.2987	.2427	.2614	.1867	.168	.1867	.168
15	.1867	.2241	.2241	.2241	.1494	.168	.168
16	.168	.2427	.2801	.2241	.1494	.168	.2241
17	.2241	.2427	.2801	.2054	.2378	.2241	.2614
18	.3361	.3174	.2987	.2241	.3109	.3174	.2614
19	.3361	.4294	.3734		.3734	.4108	.3734
20	.4108	.4108	.4294	.4481	.4108	.4481	.4294
21	.3547	.4108	.4108	.4108	.4294	.3921	.3734
22	.3174	.3547	.3734	.3361	.3547	.3361	.2801
23	.2241	.2987	.3361	.2241	.2801	.2427	
24	.2241	.1867	.2241	.2801	.2054	.2427	.2241
Max	.4108	.4668	.4294	.4481	.4294	.4481	.4294
Min	.168	.168	.1715	.1867	.1494	.168	.168
Avg	.2723	.3031	.2973	.2776	.2761	.2832	.2630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV SHIRDHON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.5944	.4744	.5967	.1734	.1433	.1494
2	.104	.6401	.4111	.5801	.1578	.1267	.1494
3	.1052	.6327	.3841	.6036	.1646	.1448	.1478
4	.1052	.6642	.3201	.6226	.1646	.1448	.1646
5	.1254	.7432	.1619	.6882	.1829	.1646	.1829
6	.1646	.8223	.1158	.7362	.2195	.2218	.2218
7	.1629	1.3443	.0886	.2149	.2926	.2507	.2957
8	.1595	1.3748	.0617	.8436	.8124	1.1544	.8539
9	.156	.156	.1311	1.3443		1.3763	1.2963
10	.1017	.1715	.1989	1.012		1.6356	1.4899
11	.1387	.1907	.1844	.9877		1.6194	1.0753
12	.1214	.1907	.1715	1.4083		1.5546	1.2498
13		.2058	.156	1.4083	1.3748		1.3916
14	.1214	.2012	.1402	1.2803	1.4563	1.4403	1.4548
15	.1448	.1966	.1417	1.4998	1.4883	1.5524	1.4998
16	.1417	.1844	.208	.1296	.1791	.1677	.0772
17	.156	.1886	.2103	.1357	.197	.1696	.1147
18	.1578	.1848	.197	.1715		.1928	.1772
19	.1772	.1646	.1949	.2149		.1991	.1772
20	.2195	.1663	.2561	.2353	.1772	.2218	.1848
21	.197	.1463	.5281	.2172	.1772	.1991	.1848
22	.1791	.1463	.6154	.197	.1595	.1829	.1478
23	.6241	.4167	.7537	.1753	.1612	.1663	.1267
24	.104	.5639	.4374	.6554	.1734	.1433	.1663
Max	.6241	1.3748	.7537	1.4998	1.4883	1.6356	1.4998
Min	.1017	.1463	.0617	.1296	.1578	.1267	.0772
Avg	.1640	.4288	.2726	.6649	.4284	.5727	.5408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV BORGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0762	.0943	.1132	.0934	.1509	.132
2	.0943	.0934	.0943	.1132	.0934	.132	.132
3	.0943	.0934	.0943	.0943	.112	.132	.132
4	.1132	.112	.1132	.1132	.0934	.132	.1509
5	.132	.1132	.132	.1509	.1132	.1509	.1509
6	.1698	.1509	.1698	.1698	.132	.1524	.1698
7	.1698	.2075	.1698	.1698	.1698	.2054	.1886
8	.1698	.1478	.1509	.1509	.132	.1494	.1698
9	.1791	.168	.132	.1509	.1307	.168	.1433
10	.1629	.1509	.132	.1646	.1433	.1663	.1509
11	.1254	.1509	.1132	.1494	.1433	.181	.1663
12	.1848	.132	.1132	.1494	.1612	.168	.1448
13	.132	.1132	.0934	.1132	.1663		.1109
14	.1478	.1307	.1109	.132	.1494	.1698	.0716
15	.1448	.1307	.1294	.1307	.1494	.1886	.128
16	.128	.1478	.1509	.1509	.1086	.1698	.128
17	.1063	.1402	.1509	.1294	.1063	.1886	.0924
18	.1387	.1595	.1886	.1629	.124	.2075	.132
19	.2172	.2012	.2054	.1646	.1433	.2263	.1698
20	.2075	.2263	.2452	.1886	.1791	.2452	.2241
21	.1698	.1886	.2263	.1886	.1829	.2075	.1509
22	.1698	.1698	.1886	.1509	.1663	.1698	.1494
23	.1109	.1294	.1698	.1109	.1509	.1509	.1109
24	.1132	.0934	.1132	.132	.0934	.1509	.1509
Max	.2172	.2263	.2452	.1886	.1829	.2452	.2241
Min	.0943	.0762	.0934	.0943	.0934	.132	.0716
Avg	.1456	.1428	.1451	.1435	.1349	.1723	.1438



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.7655	.8029	.8848	.1867	.1886	.1698
2	.1509	.7499	.8192	.7625	.1698	.1698	.1698
3	.1509	.7655	.7625	.7293	.1698	.1698	.1509
4	.1698	.8905	.7701	.8048	.1886	.1886	.1698
5	.2075	.9442	.7449	.8619	.2075	.2075	.2075
6	.2614	1.0242	.7773	.8848	.2452	.2641	.2452
7	.2614	1.5364	.2587	.2926	.3174	.2987	.2614
8	.2427	1.6446	.2561	1.2334	1.2498	1.3763	1.1544
9	.2378	.1791	.2218	1.5384	1.4899	1.5684	1.3603
10	.2926	.1991	.2054	1.5546	1.5524	1.8785	1.5844
11	.2561	.2195	.1867	1.749	1.6604	2.13	1.2018
12	.2241	.2378	.2033	1.9204	1.7654	1.989	1.2498
13	.2402	.2353	.1829	1.9845	1.7966		1.3283
14	.2033	.2561	.2033	1.9845	1.8404	1.6385	1.3283
15	.2033	.2378	.2218	1.7071	1.8564	1.7764	1.2346
16	.2218	.2402	.2772	.2172	.197	.181	.1433
17	.2172	.2172	.2587	.2195	.2149	.1829	.1595
18	.2353	.2012	.2427	.2195	.2195	.2033	.2012
19	.2402	.2033	.2402	.2587	.2402	.2402	
20	.2452	.2033	.2801	.2987	.2587	.2614	.2054
21	.2427	.1867	.8907	.2641	.2218	.2263	.2033
22	.2054	.1867	.9831	.2241	.2054	.2075	.168
23	.7499	.7537	1.0486	.1867	.2054	.2075	.1494
24	.1698	.7499	.7773	.9945	.1867	.1886	.1886
Max	.7499	1.6446	1.0486	1.9845	1.8564	2.13	1.5844
Min	.1509	.1791	.1829	.1867	.1698	.1698	.1433
Avg	.2416	.5345	.4840	.9073	.6936	.6845	.5754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV SHIVGANGA GAO  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.0949	.1134	.0781	.1143	.1204	.1509
2	.1075	.0914	.0972	.0781	.1143	.1082	.132
3	.0895	.0892	.0983	.0791	.1162	.1082	.132
4	.1075	.0892	.0819	.0949	.1278	.1082	.1509
5	.1075	.0892	.0829	.0937	.1278	.1269	.1509
6	.1227	.0892	.1017	.0937	.1278	.1486	.1629
7	.1029	.1578	.1772	.0987	.1326	.1509	.1791
8	.0949	.1174	.132	.1265	.1219	.1153	.1492
9	.168	.1294	.1698	.132	.1021	.2378	.0793
10	.1867	.1463	.2075	.2452	.1646	.2743	.1509
11	.2263	.1848	.2641	.2075	.1509	.2743	.1867
12	.2263	.2587	.2402	.2987	.1509	.3018	
13	.128	.2743	.2829	.2622	.1494		.1183
14	.1829	.2926	.3018	.2429	.1478	.3018	.298
15	.2641	.2926	.3018	.1886	.1478	.3018	.2303
16	.1698	.2801	.2427	.2402	.1478	.2075	.2033
17		.2829	.1867	.2033	.1848	.1886	.2031
18	.1509	.1886	.1219	.1886		.1524	
19	.1509	.132	.1107	.1486		.1505	.1387
20	.1509	.132	.144	.144	.1783	.1395	.1865
21	.1307	.1219	.0974	.1303	.1486	.132	.1734
22	.1267	.128	.1067	.1216	.1486	.1612	.16
23	.096	.1265	.108	.1257	.1337	.1402	.1457
24	.1075	.0949	.112	.0926	.1257	.1337	.1387
Max	.2641	.2926	.3018	.2987	.1848	.3018	.298
Min	.0895	.0892	.0819	.0781	.1021	.1082	.0793
Avg	.1437	.1618	.1618	.1548	.1393	.1776	.1646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV SHIRDHON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1698	.1698	.1698	.1886	.2075
2	.1698	.1509	.1509	.1509	.1698	.1886	.1886
3	.1698	.1509	.1509	.1509	.1698	.1886	.1886
4	.1886	.1509	.1698	.1698	.1509	.1886	.1698
5	.1886	.1886	.1886	.1886	.1698	.2075	.1886
6	.2263	.2263	.2263	.2263	.1886	.2263	.2075
7	.1867	.2402	.2534	.2378	.2452	.2614	.2402
8	.1848	.2012	.2378	.2195	.1867	.2241	.2012
9	.1991	.1949	.2218	.2033	.1867	.1867	.1663
10	.1663	.1791	.2012	.1848	.1791	.1698	.1663
11	.1663	.1991	.2012	.1991	.156	.168	.181
12	.1991	.1991	.1734	.1772	.156	.168	.1753
13		.197	.1629	.1791	.1629		.1629
14	.1612	.2126	.1791	.1612	.1612	.1478	.181
15	.1646	.2149	.1791	.1402	.1646	.1294	.1886
16	.1646	.1949	.1991	.1612	.1629	.1463	.1753
17	.1791	.1928	.2172	.1734	.1612	.1663	.1734
18	.1772	.2149	.2378	.1791		.2054	
19	.2328	.2353	.2534	.2507		.2195	.2195
20	.3511	.2987	.3326	.3206	.3582		.3361
21	.3018	.2641	.3018	.2829	.2743	.2829	.2829
22	.2641	.2452	.2263	.2452	.2452	.2452	.2263
23	.1886	.1886	.1886	.2075	.2075	.2075	.1698
24	.1886	.1698	.1698	.1698	.1698	.2075	.2075
Max	.3511	.2987	.3326	.3206	.3582	.2829	.3361
Min	.1612	.1509	.1509	.1402	.1509	.1294	.1629
Avg	.2003	.2033	.2080	.1979	.1907	.1965	.2002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV ALKUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.12	.1214	.1227	.3721	.4334	.4733
2	.3224	.12	.1214	.1227	.3582	.4161	.4382
3	.298	.12	.1052	.104	.3761	.4115	.4161
4	.3506	.1372	.1227	.12	.4119	.4458	.4784
5	.3944	.1526	.156	.156	.4835	.5487	.4961
6	.431	.1865	.2058	.1715	.5373	.763	.5194
7	.5548	.1753	.2126	.2103	.2126	.2172	.1562
8	.5316	.1578	.362	.1629	.176	.1663	.1433
9	.4973	.3294	.5243	.1595	.1772	.1494	.1772
10	.5304	.6516	.7127	.1387	.1417	.132	.1086
11	.547	.7545	.6874	.1387	.0895	.1075	
12	.5506	.78	.663	.124	.0895	.0895	
13	.5218	.7545	.6722	.1052	.0905		.0566
14	.506	.7202	.7865	.1075	.0905	.0905	.0377
15	.5344	.6401	.8029	.1086	.0914	.0895	.037
16	.583	.5735	.0905	.1267	.0914	.0924	.0373
17		.0886	.1097	.1267	.1086	.112	.1715
18	.0914	.1075	.1254	.1402		.128	
19	.1433	.1595	.1254	.1595		.124	.1448
20	.1578	.1772	.1734	.1928	.1753	.1578	.1734
21	.156	.156	.1734	.3841	.3856	.3439	.2772
22	.1387	.1387	.1543	.362	.4508	.3856	.2402
23	.1387	.1387	.156	.3721	.4334	.4508	.2561
24	.3582	.12	.12	.1387	.3721	.4334	.4681
Max	.583	.78	.8029	.3841	.5373	.763	.5194
Min	.0914	.0886	.0905	.104	.0895	.0895	.037
Avg	.3765	.3108	.3118	.1690	.2598	.2734	.2527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT  
HAVING WEEKLY STAGGERING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.8488	.6224	.679	.679	.2058	.9054
2	.5658	.9054	.679	.7356	.4527	.2058	.9054
3	.5658	.679	.7356	.7922	.3961	.2058	.7922
4	.5144	.7922	.679	.7922	.3395	.2058	.679
5	.5144	.7922	.6224	.7356	.3395	.2572	.679
6	.5658	.8488	.6224	.7356	.4527	.2572	.7356
7	.463	.3961	.5093	.3395	.2829	.3601	.3961
8	.1543	.5658	.3395	.2829	.2263	.2058	.2829
9	.5144	.2829	.2829	.2829	.1543	.2263	.3395
10	.2058	.2263	.1698	.2263	.2058	.2829	.0114
11	.1698	.1698	.1698	.2263	.2058	.3395	.3961
12	.4527	.4527	.1132	.0114	.2572	.3961	.1698
13	.3395	.3395	.1698	.3961	.2058		.0857
14	.2263	.5093	.2263	.4527	.2058	.3395	.4527
15	.0114	.4527	.2829	.1698	.2058	.1698	.2829
16	.2829	.3395	.3395	.3961	.2058	.5658	.3395
17	.5093	.3961	.5658	.6224	.1029	.3395	.679
18	.6224	.679	.3395	.8488	.1029	.3961	
19	.7922	.679	.5658	.679	.1029	.5658	.7922
20	.7356	.5093	.679	.4527	.2058	.7356	.679
21	.4527	.5093	.4527	.5093	.2058	.3961	.4527
22	.5093	.6224	.7356	.679	.2058	.5658	.7356
23	.5093	.4527	.679	.5093	.2058	.679	.5658
24	.5144	.7356	.5658	.6224	.679	.2058	.7922
Max	.7922	.9054	.7356	.8488	.679	.7356	.9054
Min	.0114	.1698	.1132	.0114	.1029	.1698	.0114
Avg	.4461	.5494	.4645	.5074	.2761	.3525	.5282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11KV DUDHEBHAVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.1526	.1677	.6859	1.0174
2	.964		.1526	.1696	.8745	1.0059
3	1.0288		.1696	.1715	.9431	1.0898
4	1.2269		.1865	.1886	1.2003	1.1736
5	1.3847		.1886	.2035	1.3847	1.358
6	1.7318		.1886	.2204	1.7318	.0335
7	1.8404		.1696	.2204	.2229	.2035
8	1.8347			.2035	.2058	.1844
9	1.7318				.1886	.1696
10		1.0174			.1715	
11		1.3565			.1677	
12		1.6108			.1509	
13		1.6278			.1341	
14		1.6448			.1526	
15		1.6617			.1526	
16		1.6956			.1696	
17					.1696	
18					.2012	
19					.2204	
20					.2204	
21					.763	
22					.9724	
23					1.0395	
24	.6859		.1509	.1865	.6516	1.0513
Max	1.8404	1.6956	.1886	.2204	1.7318	1.358
Min	.6859	1.0174	.1509	.1677	.1341	.0335
Avg	1.3286	1.5164	.1699	.1924	.5323	.7287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV NAGAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.1543	.2204	.1341	1.2003	1.0395	
2	.8745	.1715	.2374	.1357	1.286	1.0059	
3	.9431	.1715	.2515	.1543	1.3496	.9724	
4	1.0288	.1886	.2713	.2035	1.3889	1.1022	
5	1.1393	.2204	.3052	.2883	1.5432	1.4419	
6	1.3146	.2543	.3222	.3222	1.5432	1.8442	
7	1.4022	.2543	.3052	.2883	.3429	.3222	
8	1.3226		.6706	.1865	.2629	.2012	
9	1.3889		.9221	.2058	.2103	.1865	.2229
10		1.4582	.9835		.1696		.2035
11		1.4413	1.3226		.1357		.1886
12		1.4074	1.2887		.1187		.1715
13		1.3904	1.2574		.12		.1526
14		1.3395	1.2574		.12		.1372
15		1.1869	1.2574		.1187		.0857
16		1.2209	.1696		.1372		.1372
17		.3052	.1696		.1543		.1715
18		.2204	.1715		.2035		.2058
19		.2204	.1715		.2374		.1715
20		.2035	.2204		.2374		.2058
21		.2035	.2035		.8048		.5144
22		.2204	.1526		1.0059		.6935
23		.2204	.1526		1.0174		.6859
24	.7373	.1526	.2204	.1357	1.046	1.0174	
Max	1.4022	1.4582	1.3226	.3222	1.5432	1.8442	.6935
Min	.7373	.1526	.1526	.1341	.1187	.1865	.0857
Avg	1.1009	.5730	.5210	.2054	.6147	.9133	.2632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV CHOROCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12			.373	.1372	.1696
2	.12		.8573	.3688	.1372	.1696
3	.12		1.0174	.4191	.1372	.1696
4	.1372		1.1022	.5365	.1402	.2035
5	.1543		1.0682	.6371	.1372	.2204
6	.1372		1.1022	.7712	.1543	.2515
7	.1543		.2035	.2204	.1715	.2035
8	.1715			.6036	.5316	.1844
9	.1715			.5935	.6001	.8478
10		.1865			.6783	
11		.1696			.7042	
12		.1844				
13		.1526			.5533	
14		.1341			.7377	
15		.1526			.8718	
16		.1357			.1526	
17					.1526	
18					.1886	
19					.2229	
20					.2204	
21					.2035	
22					.1677	
23					.1677	
24	.1387		.6783	.3391	.1543	.1677
Max	.1715	.1865	1.1022	.7712	.8718	.8478
Min	.12	.1341	.2035	.2204	.1372	.1677
Avg	.1425	.1594	.8613	.4862	.3184	.2588



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV DHALEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6371	.8139	1.0174	.1372	.1543	
2	.6443	.6613	1.0059	.1372	.1526	
3	.6783	.763	1.0174	.1543	.1526	
4	.7042	.6783	1.2407	.1715	.2058	
5	.8048	.8478	1.3748	.1886	.2543	
6	.9389	1.1191	1.6095	.2103	.2883	
7	1.153	.1357	.3391	.1928	.3391	
8		.0678	1.073	1.1919	.2515	
9		.0678	1.1269	1.2174	1.0174	1.0288
10	.1187	.1187		1.2887		1.2003
11	.1187	.1187		1.3413		1.3717
12	.1357	.1006		1.3748		1.5947
13	.1357	.1017		1.3904		1.5947
14	.1357	.0848		1.3413		1.5947
15	.1357	.0848		1.3077		1.4918
16	.1357	.1187		.1341		1.4918
17	.0509	.1372		.1017		.1372
18	.0509	.1715		.1865		.0686
19	.0678	.2035		.2229		.0686
20	.0848	.2204		.2401		.0686
21	.0848	.8139		.2035		.0686
22	.0848	1.1065		.1696		.0686
23	.5087	1.1869		.1696		.0686
24	.6783	.964	1.1022	.1372	.1715	
Max	1.153	1.1869	1.6095	1.3904	1.0174	1.5947
Min	.0509	.0678	.3391	.1017	.1526	.0686
Avg	.3676	.4453	1.0907	.5504	.2987	.7945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV CHOROCHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1214	.1526	.1227	.1402	.1214	
2	.1029	.1029	.1543	.1227	.1402	.1214	
3	.1029	.1029	.1734	.1387	.1402	.12	
4	.12	.1387	.1886	.156	.1543	.1372	
5	.1029	.1734	.2058	.1907	.1928	.1907	
6	.1372	.208	.2058	.2254	.2058	.2058	
7	.208	.1886	.2229	.208	.2229	.208	
8	.2229		.1886	.1907	.1928	.1886	
9	.1886		.1715	.1734	.1578	.1734	.1543
10		.1526	.156		.1387		.1543
11		.1696	.1387		.052		.1372
12		.1526	.1387		.052		.12
13		.1526	.1543		.052		.1029
14		.1526	.156		.0701		.1029
15		.1357	.1387		.1387		.0914
16		.1341	.1402		.1387		.1029
17		.1372	.156		.1387		.1029
18		.1372	.1734		.1753		.12
19		.1372	.1734		.2279		.12
20		.1214	.2254		.208		.12
21		.12	.208		.1907		.1372
22		.12	.1734		.156		.1372
23		.1372	.1372		.1387		.1543
24	.12	.1387	.1357	.1214	.1372	.1227	
Max	.2229	.208	.2254	.2254	.2279	.208	.1543
Min	.1029	.1029	.1357	.1214	.052	.12	.0914
Avg	.1408	.1425	.1695	.1650	.1484	.1589	.1238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV DUDHEBHAVI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.104	.2401	.0876	.1372	.0867	
2	.12	.104	.2401	.0876	.1402	.0857	
3	.1029	.104	.2401	.1029	.1543	.104	
4	.1029	.12	.2743	.1214	.1372	.1402	
5	.12	.1372	.3086	.1907	.1543	.1734	
6	.12	.1907	.3086	.2254	.1753	.2058	
7	.1372	.1907	.2572	.2254	.1715	.2254	
8	.1372		.2601	.1907	.1753	.1886	
9	.1715		.2601	.1907	.1753	.208	.1715
10		.1715	.1227		.1214		.1886
11		.1715	.1214		.104		.2058
12		.1886	.1029		.0693		.2058
13		.1886	.104		.0693		.2058
14		.1715	.0867		.0701		.1715
15		.1886	.0867		.0693		.2058
16		.2915	.0867		.0876		.2058
17		.2601	.0867		.1052		.1886
18		.2572	.1214		.1214		.1715
19		.3086	.1387		.1387		.1886
20		.2543	.1214		.1372		.1715
21		.1907	.1214		.12		.1886
22		.2058	.104		.104		.1886
23		.2229			.104		.2058
24	.12	.1029	.2401	.104	.1372	.104	
Max	.1715	.3086	.3086	.2254	.1753	.2254	.2058
Min	.1029	.1029	.0867	.0876	.0693	.0857	.1715
Avg	.1252	.1875	.1754	.1526	.1241	.1522	.1909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV SHELKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.2427	.2054		.8029	.9831	.8962
2	.5898	.2427	.2054		.7459	.9602	.8962
3	.5967	.2427	.2054		.6796	.9717	1.0159
4	.6371	.2801	.2829		.8785	1.0437	1.1142
5	.6952	.415	.3961			1.1843	1.4251
6	1.0056	.5847	.547		1.6095	1.4083	1.7101
7	1.0898	.5093	.5281		.5601	.567	.5658
8	1.1904	.3734	.7537		.4854	.3982	.3734
9	1.1934	.8029	.9175	.0905		.2835	.2801
10	1.1142	1.3443	1.3757	.2012	.2987	.2427	.2402
11	1.1305	1.6409	1.5074	.181	.2561	.1991	.2402
12	.7968	1.5415	1.5927		.2149	.181	.2195
13	.9014	1.4251	1.491	.2195	.1772	.156	.2012
14	.9488	1.1984	1.6244		.1791	.1629	
15	1.0883	1.3117	1.3426	.2172	.1772	.1991	.1772
16	1.1174	1.186	.2896	.2172	.2195	.2402	.208
17	.1578	.2126	.2987	.2195	.2507	.3326	.2743
18	.2195	.2658	.3361	.2715	.2835	.4251	.2957
19	.3547	.3511	.3734		.3224	.3696	
20	.3772	.3547	.415	.3734	.394	.3921	.3772
21	.3395	.3174	.3584	.0754	.9831	1.0486	.7449
22	.2829	.2801	.2507	.9231	1.2018	1.0722	.8029
23	.2452	.2241			1.0883	1.004	.7209
24	.6226	.2427	.2054		.8029	1.0526	.8962
Max	1.1934	1.6409	1.6244	.9231	1.6095	1.4083	1.7101
Min	.1578	.2126	.2054	.0754	.1772	.156	.1772
Avg	.7202	.6496	.6740	.2718	.5732	.6199	.6216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.3725	.3041	.3361	.0377	.0905	.0924
2	.0566	.4049	.3041	.3361	.0377	.0895	.0924
3	.0566	.4049	.3041	.3563	.0377	.0886	.0924
4	.0566	.4748	.3725	.3768	.0566	.1097	.1307
5	.0566	.5426	.4372	.4096	.0754	.1267	.168
6	.0943	.8139	.6783	.6299	.1132	.1448	.2075
7	.1132	1.2431	.2614	.2452	.1132	.2172	.1886
8	.0943	1.1797	.2172	.6062	.1372	.4161	.3239
9	.0566	.0934	.132	.7611		.5121	.4858
10	.0373	.0732	.0934	.9012	.6483	.8029	.5506
11	.0366	.0716	.0732	.8745	.6401	.9116	.4062
12	.0362	.0739	.056		.6325	.8619	.3913
13	.0335	.0739	.0377	.8855	.6226	.1372	.2778
14	.0316	.0648	.0754		.6401		.3658
15	.0905	.0495	.0739	.8124	.6958	.3858	.4321
16	.0709	.0594	.0895	.0732	.0895	.0914	.0446
17	.0579	.0791	.0709	.0724	.0358		.0463
18	.112	.0791	.0732	.0549	.0354	.1294	.0678
19	.1494	.1086	.1132		.0895	.168	.0701
20	.1509	.1494	.1698	.0943	.1612	.1698	.1132
21	.132	.1307	.4024	.0754	.1595	.132	.0905
22	.112	.0886	.426	.0377	.1075	.112	.0716
23	.2543	.3521	.3887		.0905	.0914	.0526
24	.0943	.3725	.3041	.3521	.0377	.0895	.0924
Max	.2543	1.2431	.6783	.9012	.6958	.9116	.5506
Min	.0316	.0495	.0377	.0377	.0354	.0886	.0446
Avg	.0850	.3065	.2274	.4145	.2302	.2672	.2023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV RAIWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.2709	.2229	.2408	.0754	.0358	
2	.0566	.2709	.2229	.2408	.0566	.0362	
3	.0566	.301	.2229	.2439	.0566	.0354	
4	.0754	.3479	.2812	.2623	.0754	.0716	
5	.0943	.3953	.3593	.2812	.132	.0905	
6	.1698	.4915	.583	.4801	.2075	.1433	.1949
7	.1886	.6882	.2241	.1886	.2075	.2172	.1715
8	.1509	.759	.168	.4858	.3163	.4915	.3953
9	.1132	.0594	.1109	.6722		.5506	.5197
10	.0934	.0739	.0934	.68	.6718	.6173	.57
11	.0934	.0934	.0739	.6718	.6401	.6401	.4755
12	.0732	.0934	.0943		.6226	.6401	.4633
13	.0716	.0762	.1132	.5668	.5761	.6308	.4365
14	.0709	.0747	.0943			.6249	.4967
15	.0709	.0343	.0549	.5571	.6081	.5792	.4607
16	.0714	.0716	.0709	.1063	.0366	.1075	.0486
17	.0714	.0678	.0914	.128	.0366	.1075	.0514
18	.0924	.0678	.112	.1097	.1075		.1433
19	.0924	.1294	.1109		.1254	.1265	.1494
20	.1132	.1307	.132	.1478	.1448	.1448	.132
21	.0943	.112	.2721	.132	.1063	.1094	.1132
22	.0754	.0934	.3353	.0934	.0716	.0762	.0943
23	.192	.1943	.2675		.0354	.0625	.0754
24	.0566	.2709	.2229	.2347	.0754	.0354	
Max	.192	.759	.583	.68	.6718	.6401	.57
Min	.0566	.0343	.0549	.0934	.0354	.0354	.0486
Avg	.0956	.2153	.1889	.3262	.2266	.2684	.2773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV SHELKEWADI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.132	.132	.1524	.1509	.1448	.1509
2	.1524	.132	.132	.1524	.132	.1417	.1509
3	.1524	.132	.132	.1524	.132	.1448	.1509
4	.1698	.1698	.2263	.1715	.1509	.1829	.1886
5	.1886	.2641	.2829	.2096	.2263	.2126	.2829
6	.3772	.3772	.3584	.381	.3584	.2865	.3961
7	.3961	.3961	.3584	.3584	.3961	.3155	.3772
8	.2641	.2452	.2829	.2452	.3206	.2328	.2641
9	.2263	.1886	.2427	.2075		.1991	.2452
10	.2033	.2075	.2452	.168	.2195	.1829	.2054
11	.1848	.2054	.1886	.1509	.1791	.1848	.1663
12	.168	.1867	.1698		.1629	.1663	.1307
13	.1698	.1698	.1509	.1509	.1254	.132	.1494
14	.1509	.2054	.1698		.1267	.132	.132
15	.1867	.1829	.1886	.1494	.1075	.1463	.1494
16	.168		.1886	.1494	.1267	.128	.1307
17	.1698	.2172	.1886	.168	.1646	.1829	.1629
18	.2075	.2614	.2241	.2195	.1772	.2402	.2587
19	.2641	.2801	.2641		.2507	.3174	.2641
20	.3206	.3206	.3206	.3547	.3077	.3206	.3206
21	.2263	.2829	.3018	.2829	.2658	.2829	.2829
22	.1886	.2096	.2452	.2075	.2126	.2075	.2096
23	.1698	.1698	.1715		.1612	.1886	.1715
24	.1524	.1509	.1509	.1524	.1509	.1448	.1698
Max	.3961	.3961	.3584	.381	.3961	.3206	.3961
Min	.1509	.132	.132	.1494	.1075	.128	.1307
Avg	.2087	.2212	.2215	.2092	.2002	.2007	.2130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0754	.0754	.0943	.112	.0886	.0754
2	.0943	.0754	.0754	.0943	.0934	.0895	.0754
3	.0943	.0754	.0754	.0943	.0943	.0905	.0754
4	.1132	.1132	.1494	.1132	.1132	.1254	.1132
5	.132	.168	.2054	.132	.1698	.1417	.1494
6	.2452	.2801	.2614	.2075	.2641	.1791	.2054
7	.2641	.2801		.2829	.2241	.2481	.2427
8	.2263	.1867	.2241	.2263	.1886	.1991	.2054
9	.1509	.1294	.1494	.132		.124	.1867
10	.0934	.1109	.1494	.112	.112	.1097	.1097
11	.1109	.0924	.0914	.0732	.0895	.0914	.1097
12	.0924	.1109	.0934		.1086	.0914	.1109
13	.1109	.1294	.0934	.112	.0886	.0732	.0934
14	.0732	.0914	.0943		.0895	.0549	.0934
15	.1097	.0914	.112	.0914	.0905	.0549	.0754
16	.1097	.0732	.0924	.0732	.0895	.0716	.056
17	.128	.0914	.0934	.0924	.1267	.1075	.0914
18	.1478	.1109	.112	.1494	.1448	.168	.1867
19	.168	.1494	.1698		.1772	.2054	.1886
20	.2054	.2054	.2075	.2378	.2149	.2054	.1698
21	.168	.1478	.1886	.1829	.1595	.1867	.1886
22	.1294	.1097	.1509	.1463	.1254	.1132	.132
23	.0754	.0754	.1132		.0886	.0943	.1132
24	.0943	.0943	.0754	.0943	.112	.0895	.0754
Max	.2641	.2801	.2614	.2829	.2641	.2481	.2427
Min	.0732	.0732	.0754	.0732	.0886	.0549	.056
Avg	.1346	.1278	.1327	.1371	.1338	.1251	.1301



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV RAIWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0497	.0492	.0655	.0747	.0716	.0497
2	.0701	.0497	.0492	.0678	.0747	.0709	
3	.0701	.0497	.0492	.0686	.0566	.0724	.0497
4	.0709	.0857	.0739	.0876	.0566	.0716	.0701
5	.0895	.1063	.0924	.1075	.128	.0876	.0701
6	.0566	.1294	.1132	.128	.1646	.0905	.0895
7	.1132	.112	.0943	.0943	.132		.0943
8	.0754	.112	.0895	.0943	.132		.0754
9	.0739	.128	.0934	.0905		.0354	.0754
10	.0914	.0895	.0709	.0724	.1086	.0377	.0532
11	.0701	.1086	.0724	.056	.0886	.0373	.0351
12	.0686	.0876	.0716		.0895	.0526	.0549
13	.052	.0876	.0537	.0566	.0886	.0526	.0526
14	.0514	.0686	.0732		.0532	.0343	.0335
15	.1029		.0543	.0724	.0537	.0343	.0164
16	.0838		.0509	.0549	.0543	.0351	.0509
17	.0655		.0886	.0549	.0537	.0351	.0509
18	.1097		.0895	.0724	.0709	.0354	.0514
19	.1097		.0934		.0709	.056	.0943
20	.1109		.0754	.1294	.0895	.0739	.0943
21	.0905	.0934	.0754	.1267	.1086	.056	.0754
22	.0886	.0709	.0905	.1097	.0895	.0532	.0566
23	.0693	.0678	.0678		.0709	.0509	.0377
24		.0663	.0655	.0663	.0739	.0709	.0497
Max	.1132	.1294	.1132	.1294	.1646	.0905	.0943
Min	.0514	.0497	.0492	.0549	.0532	.0343	.0164
Avg	.0807	.0868	.0749	.0838	.0862	.0552	.0600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV JAKHAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0377	.0566	.0572	.1509	.096	.0972
2	.0655	.0377	.0566	.0572	.1341	.0972	.0972
3	.0671	.0377	.0566	.0572	.1341	.1311	.0972
4	.0686	.0566	.0943	.0572	.1509	.1581	.1638
5	.0876	.0934	.112	.0762	.2486	.1943	.2458
6	.1612	.112	.1494	.132	.3768	.2721	.2785
7	.2915	.1494	.1307	.1886	.128	.1772	.1494
8	.285	.112	.1677	.1509	.1646	.1086	.1307
9	.3521	.1509	.1509	.1132		.0709	.1132
10	.285	.3605	.2949	.1132	.12		.1132
11	.3353	.4588	.3277	.0754	.0905		.0572
12	.2683	.2984	.3688		.0709		.0566
13	.2683	.2818	.3277	.0566	.0358		.0754
14	.2515	.2486	.3856		.0354		.0572
15	.3018	.2984	.3688	.0754	.0366		.0754
16	.3018	.2984	.0924	.0754	.0354	.0943	.0934
17	.0377	.0377	.1307	.0943	.0716	.0943	.0747
18	.0566	.0566	.132	.0754	.1075	.0943	.1132
19	.0943	.0754	.0943		.0895	.0943	.0754
20	.0943	.0754	.132	.132	.0886	.0943	.0572
21	.0754	.0566	.0943	.1357	.192	.2622	.1509
22	.0566	.0566	.0762	.2012	.1966	.1943	.1326
23	.0377	.0754	.0572		.112	.1509	.1147
24	.0829	.0377	.0566	.0572	.1509	.0972	.0972
Max	.3521	.4588	.3856	.2012	.3768	.2721	.2785
Min	.0377	.0377	.0566	.0566	.0354	.0709	.0566
Avg	.1663	.1460	.1631	.0991	.1270	.1379	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0358	.0181	.0328	.0189	.0179	.0189
2	.0191	.0358	.0181	.0328	.0189	.0181	.0189
3	.0191	.0537	.0362	.0332	.0189	.0177	.0189
4	.0191	.0537	.0537	.0335	.0189	.0183	.0189
5	.0191	.0876	.0537	.0503	.0377	.0179	.0189
6	.0377	.1052	.0537	.0686	.0566	.0179	.0189
7	.0377	.1509	.0377	.0377	.0566	.0532	.0189
8	.0189	.1509	.0377	.0671	.0934	.144	.0181
9		.0189	.0189	.0671		.1802	.0905
10	.0189	.0189	.0189	.0671	.1509		
11	.0189	.0189	.0189	.1966	.1475		
12	.0189	.0189	.0189		.1457		.0648
13	.0189		.0189	.1638	.1638		.0819
14	.0189	.0189	.0189		.16		.1006
15	.0189	.0189	.0189	.213	.1898		.1006
16	.0189		.0185	.0189	.0183	.0189	.0175
17	.0189	.0377	.0187	.0377	.0177	.0189	.0181
18	.0189	.0189	.0377	.0377	.0179	.0189	.0187
19	.0189	.0189	.0377		.0362	.0377	.0189
20	.0189	.0377	.0377	.0377	.0354	.0189	.0189
21	.0189	.0189	.0526	.0377	.0179	.0377	.0189
22	.0189	.0189	.0514	.0189	.0181	.0189	.0191
23	.0358	.0181	.0332		.0179	.0189	.0191
24	.0191	.0358	.0181	.0328	.0189	.0177	.0189
Max	.0377	.1509	.0537	.213	.1898	.1802	.1006
Min	.0189	.0181	.0181	.0189	.0177	.0177	.0175
Avg	.0213	.0451	.0311	.0643	.0642	.0384	.0344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 401 / 33 KV Suzlon

Feeder KV- 33 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	1.9004
Max	1.9004
Min	1.9004
Avg	1.9004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2614			
2			.2561			
3			.2614			
4			.3734			
5			.4481			
6			.5228			
7			.4481			
8			1.1203			
9			1.363		.3109	.2195
10	1.2883	1.5684			.2641	
11	1.2936	1.7737			.2218	
12	1.363	1.7918			.1867	
13	1.2012	1.7364			.1886	
14	1.1506	1.6804			.1867	
15	1.307	1.4632			.1663	
16	1.386	1.4266				
17	.2402	.2012			.1663	
18		.2427			.2614	
19		.3361				
20		.4108				
21		.3658				
22		.3292				
23		.2987				
24		.2801		1.307		
Max	1.386	1.7918	1.363	1.307	.3109	.2195
Min	.2402	.2012	.2561	1.307	.1663	.2195
Avg	1.1537	.9270	.5616	1.307	.2170	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV KOKLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6348			
2			.6535			
3			.6908			
4			.7468			
5			.8215			
6			.9955			
7			.6161			
8			.4481			
9			.4108		.9522	1.1016
10		.2614			1.0534	
11	.4108	.2378			1.0185	
12	.2829	.2195			.9335	
13	.2452	.2195			1.1389	
14	.2075				1.1273	
15	.2054	.2353			1.3014	
16	.2263	.2427				
17	.2614	.2534			.2614	
18		.3361			.3142	
19		.4481				
20		.5228				
21		.4668				
22		.3734				
23		.5228				
24		.5975		.2896		
Max	.4108	.5975	.9955	.2896	1.3014	1.1016
Min	.2054	.2195	.4108	.2896	.2614	1.1016
Avg	.2628	.3527	.6687	.2896	.9001	1.1016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.307			
2			1.307			
3			1.4937			
4			1.643			
5			1.6804			
6			2.1472			
7			.5853			
8			.5975			
9			.6535		1.9978	2.3339
10	.4294	.4668			2.2068	
11	.4108	.5068			2.1472	
12	.4904	.5415				
13	.5175	.547			1.7551	
14	.5658	.5068			2.0182	
15	.4904	.4706			2.0165	
16		.4163			.2957	
17		.3439			.2241	
18		.4024			.3584	
19		.5853				
20		.6722				
21		.5853				
22		.5304				
23		1.2696				
24		1.2696		.4294		
Max	.5658	1.2696	2.1472	.4294	2.2068	2.3339
Min	.4108	.3439	.5853	.4294	.2241	2.3339
Avg	.4841	.6076	1.2683	.4294	1.4466	2.3339

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.112			
2			.112			
3			.0934			
4			.0934			
5			.112			
6			.1494			
7			.168			
8			.1494			
9			.1132		.112	.1307
10	.0924	.112			.1109	
11	.1109	.112			.112	
12	.0943	.1307			.0924	
13	.0934	.1307			.0934	
14	.0924	.1307			.0934	
15	.0739	.1307			.0934	
16	.0943	.112				
17	.0934	.1307			.132	
18		.1307			.168	
19		.1494				
20		.2054				
21		.168				
22		.1494				
23		.1307				
24		.1307		.1307		
Max	.1109	.2054	.168	.1307	.168	.1307
Min	.0739	.112	.0934	.1307	.0924	.1307
Avg	.0931	.1369	.1225	.1307	.1119	.1307



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1307			
2			.1307			
3			.112			
4			.112			
5			.056			
6			.056			
7			.056			
8			.1307			
9			.0934		.0914	.0943
10	.0934	.056			.0943	
11	.112	.1494			.0934	
12	.1494	.1494			.0943	
13	.1109	.1307			.0924	
14	.1132	.1267			.0934	
15	.0934	.0747			.0924	
16	.0943	.056			.0739	
17	.0739	.0747			.0747	
18		.0747			.0934	
19		.0934				
20		.1307				
21		.1494				
22		.1494				
23		.1307				
24		.1307		.112		
Max	.1494	.1494	.1307	.112	.0943	.0943
Min	.0739	.056	.056	.112	.0739	.0943
Avg	.1051	.1118	.0975	.112	.0894	.0943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.056		
2			.056		
3			.056		
4			.0747		
5			.0934		
6			.1307		
7			.112		
8			.0934		
9			.0739		.056
10	.0934	.056			.0739
11	.0934	.056			.0566
12	.0739	.0747			.056
13	.0566	.056			.0566
14	.056	.056			.0554
15	.056	.056			.0373
16	.0554	.056			.0373
17	.0754	.056			.0377
18		.056			.0739
19		.0934			
20		.112			
21		.112			
22		.0934			
23		.0732			
24		.0732		.0747	
Max	.0934	.112	.1307	.0747	.0739
Min	.0554	.056	.056	.0747	.0373
Avg	.0700	.0720	.0829	.0747	.0541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV SHINDEWADI (H) AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
23	.7545
24	.7373
Max	.7545
Min	.7373
Avg	.7459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV KUKTOLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.2218
2			.2402
3			.2218
4			.1848
5			.2218
6			.3511
7			.2957
8			2.0144
11		2.2377	
14		1.8896	
15		1.873	
18		.2587	
19		.2957	
20		.2957	
21		.2772	
22		.2772	
23		.2402	
24	.7545		.2218
Max	.7545	2.2377	2.0144
Min	.7545	.2402	.1848
Avg	.7545	.8494	.4415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV KONGNOLI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
23	.8573
24	.7712
Max	.8573
Min	.7712
Avg	.8143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV KAROLI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.2926
2			.3109
3			.3292
4			.4024
5			.439
6			.4207
7			.3475
8			.4755
11		.2926	
12		.2561	
13		.2012	
14		.2195	
15		.2378	
16		.2195	
17		.2926	
18		.3292	
19		.5121	
20		.5304	
21		.4572	
22		.4024	
23		.3109	
24	.6335		.2926
Max	.6335	.5304	.4755
Min	.6335	.2012	.2926
Avg	.6335	.3278	.3678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 205 / 11 KV SARATI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.8122
2			.8619
3			.8951
4			.9779
5			1.0277
6			1.2431
7			.2402
8			.2033
11		.1307	
12		.1494	
13		.1494	
14		.112	
15		.1307	
16		.1307	
17		.1494	
18		.168	
19		.168	
20		.168	
21		.7293	
22		.7459	
23		.7625	
24	.7888		.779
Max	.7888	.7625	1.2431
Min	.7888	.112	.2033
Avg	.7888	.2842	.7823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV DESHING GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.1829	.2195	.1829	.2195
2		.1829	.1829	.2195	.1829	.2378
3		.1829	.1886	.2195	.1829	.2378
4		.2743	.1829	.2378	.1829	.2561
5		.2926	.1829	.2743	.2195	.2561
6		.3109	.3109	.3292	.3658	.2743
7		.3475	.3292	.3109	.3658	.2926
8		.2378	.2743	.2926	.2561	.3475
9		.2195	.2926	.1829	.2195	.2926
10		.2195	.2743	.1829	.1829	.2561
11		.2195	.2743	.1646	.2012	.2195
12		.2012	.2561	.1829	.2195	.2195
13		.2012	.2743	.1646	.2561	.2195
14		.2012	.2926	.1646	.2378	.2195
15		.2012	.2561	.1463	.2378	.2195
16		.2195	.2743	.1463	.2378	.2378
17		.2195	.2926	.1463	.2561	.2561
18		.2195	.3292	.2561	.2743	.2926
19		.3658	.3658	.3658	.3658	.3658
20		.439	.4024	.3658	.4572	.3841
21		.3658	.4572	.3292	.3658	.2561
22		.2195	.2195	.2743	.2926	.2195
23		.2012	.2195	.1829	.2561	.2195
24	.1829	.1829	.1829	.2195	.1829	.2195
Max	.1829	.439	.4572	.3658	.4572	.3841
Min	.1829	.1829	.1829	.1463	.1829	.2195
Avg	.1829	.2462	.2708	.2324	.2576	.2591



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1006	.1006	1.1568	1.1736	.8048
2		.1006	.1006	1.1568	1.1736	.8383
3		.1006	.1006	1.1568	1.1736	.8718
4		.1006	.1006	1.3077	1.1736	.9389
5		.1509	.1006	1.6263	1.3413	.9724
6		.1844	.1844	1.7436	2.3137	1.073
7		.218	.1844	.218	.2347	.2012
8		.2347	1.291	.218	.2347	.1844
9		1.3413	1.4419	.2515	.285	.1174
10		1.6766	1.8442	.2515	.218	.1174
11		2.0119	2.0957	.2515	.2347	.1174
12		2.4143	2.5149	.2012	.2347	.1174
13		2.0119	2.4478	.2347	.2012	.1006
14		2.0119	2.431	.2012	.1677	.1006
15		1.8107	2.3472	.2012	.1677	.1006
16		1.7604	.1509	.2347	.1844	.1341
17		.1677	.2515		.1677	.1341
18		.1677	.2515		.1509	.1341
19		.1006	.2515	.2683	.1677	.1341
20		.0838	.2683	.2683	.1677	.1341
21		.0838	.2515	1.2574	.6036	.6706
22		.0838	.2515	1.1736	.6706	.7042
23		.0838	.2347	1.1736	.6706	.7545
24	.7545	.1006	.1006	1.0562	1.1736	.7545
Max	.7545	2.4143	2.5149	1.7436	2.3137	1.073
Min	.7545	.0838	.1006	.2012	.1509	.1006
Avg	.7545	.7126	.8041	.7095	.5952	.4254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1174	.0838	.8551	.7377	.6036
2		.1174	.0838	.8886	.7377	.6371
3		.1174	.0838	.8886	.7377	.6371
4		.1174	.0838	.8886	.7377	.6706
5		.1174	.0838	1.1904	.8383	.6706
6		.1509	.1341	1.0898	.9389	.6706
7		.2012	.1174	.1677	.1844	.1509
8		.1677	.8048	.1677	.1677	.1509
9		1.1233	.8718	.1677	.1677	.0671
10		1.3748	.9389	.1844	.1677	.0671
11		1.4754	.9724	.1677	.1341	.0671
12		1.643	1.0059	.1341		.0671
13		1.4754	1.1401	.1677	.1509	.0671
14		1.3413	1.1904	.1341	.1677	.0838
15		.9221	1.0898	.1509	.1677	.0838
16		.9389	.0838	.1509	.1509	.0838
17		.1006	.1174	.1509	.1341	.1006
18		.1006	.1341	.1509	.1341	.1006
19		.1006	.2012	.1509	.1509	.1174
20		.1341	.2012	.1509	.1509	.1174
21		.1006	.1677	.8718	.503	.4694
22		.0838	.1677	.8383	.5365	.503
23		.0838	.1509	.7377	.5365	.503
24	.7377	.1174	.0838	.6706	.7377	.57
Max	.7377	1.643	1.1904	1.1904	.9389	.6706
Min	.7377	.0838	.0838	.1341	.1341	.0671
Avg	.7377	.5093	.4164	.4632	.3944	.3025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1233	.9389	.0671	.0671	.0838
2		1.1233	.9389	.0671	.0671	.0838
3		1.1233	.9389	.0671	.0671	.1006
4		1.1233	.9389	.0838	.0671	.1006
5		1.4251	.9389	.1006	.0838	.1006
6		1.6263	1.0059	.1341	.1509	.1006
7		1.6933	.0838	.1174	.1341	.1006
8		1.7269	.1006	1.0562	1.1736	.503
9		.1006	.1006	1.6766	1.4419	1.0059
10		.1006	.1174	1.8945	1.5424	1.0059
11		.1006	.1174	1.6766	1.643	1.0898
12		.0838	.1174	1.8945	1.5089	1.1736
13		.0838	.1006	1.7436	1.5424	1.1401
14		.0838	.1006	1.5424	1.3413	.9724
15		.0838	.1174	1.5089	1.073	.9054
16		.0838	.1174	.0838	.1006	.0671
17		.0838	.0838	.0838	.0838	.0671
18		.0838	.0838	.1006	.0838	.0671
19		.0838	.1006	.1006	.1006	.0671
20		.0838	.1174	.1006	.1006	.0838
21		.0838	.503	.0838	.1006	.0838
22		.0838	.6706	.0838	.0671	.0838
23		.7545	.7545	.0671	.0671	.0671
24	.0503	.9054	.9389	.0671	.0671	.0671
Max	.0503	1.7269	1.0059	1.8945	1.643	1.1736
Min	.0503	.0838	.0838	.0671	.0671	.0671
Avg	.0503	.5770	.4178	.6001	.5281	.3800

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-JUN-18	01-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0671	.0503
2	.0671		.0671	.0503
3	.0671		.0671	.0335
4	.0671	.0503	.0671	.0335
5	.0671	.0671	.0671	.0335
6	.0671	.0671	.0671	.0671
7	.0671	.0671	.0671	.0671
8	.0671	.0671	.0671	.0671
9	.0671	.0671	.0671	.0671
10	.0671	.0671	.0671	.0671
11	.0671	.0671	.0671	.0671
12	.0671	.0671	.0671	.0671
13	.0671	.0671	.0671	
14	.0671	.0671	.0503	
15	.0671	.0671	.0503	
16	.0503	.0671	.0671	
Max	.0671	.0671	.0671	.0671
Min	.0503	.0503	.0503	.0335
Avg	.065	.0658	.065	.0559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9877	.695	.0732	.0732	.0838
2		1.0242	.695	.0732		.0914
3		1.0242	.695	.0732	.0732	.1097
4		1.0242	.695	.0732	.0732	.1097
5		1.0242	.695	.0914	.0914	.1097
6		1.1888	.7499	.1097	.0914	.1097
7		1.134	.0732	.1097	.1097	.1006
8		1.2254	.0732	.8413	1.0059	.4572
9		.0549	.0732	.9145	1.0608	.823
10		.0549	.0549	1.0059	1.1888	.9145
11		.0549	.0549	1.0059	1.2071	.9145
12		.0732	.0549	.9877	1.1888	.9511
13		.0732	.0732	.9694	1.1888	.9145
14		.0732	.0914	.9694	1.0974	.823
15		.0732	.0914	.9694	.9511	.8048
16		.0732	.0914	.0549	.0914	.0366
17		.0732	.0914	.0549	.0732	.0549
18		.0732	.0914	.1097	.0732	.0549
19		.0732	.1097	.1097	.0732	.0549
20		.0914	.1097	.1097	.0732	.0732
21		.0838	.3658	.1097	.0914	.0732
22		.0549	.4024	.0914	.0914	.0732
23		.6767	.4024	.0732	.0914	.0732
24	.0914	.7682	.695	.0732	.0732	.0914
Max	.0914	1.2254	.7499	1.0059	1.2071	.9511
Min	.0914	.0549	.0549	.0549	.0732	.0366
Avg	.0914	.4608	.3010	.3772	.4405	.3293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 201 / 11 KV VITTHALWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1448	.0934	.128	.128	.1663
2	.1097	.1307	.0934	.128	.128	.128
3	.0914	.1307	.0934	.1097	.128	.128
4		.1494	.112	.1086	.1307	.1494
5		.168	.112	.1267	.1494	.1494
6		.168	.1494	.1267	.128	.1478
7		.1494	.168	.1267	.1463	.1595
8		.168	.112	.128	.128	
9		.1867	.112	.1463	.1097	
10		.1829	.1928	.128	.0732	
11		.1463	.1791	.1463	.1097	
12		.197	.1612	.128	.1254	
13		.1791	.1612	.128	.1494	
14		.1086	.1294	.1463	.1494	
15		.1448	.0924	.1646	.1867	
16		.1448	.1478	.128	.1698	
17		.2054	.2427	.2012	.1698	
18		.116	.2427	.2378	.1227	
19		.2987	.2241	.2378	.104	
20		.2218	.2195	.2743	.2686	
21		.2033	.1646	.2241	.2303	
22		.2033	.1646	.1646	.2218	
23		.1109	.1646	.1646	.1109	
24	.1646	.1646	.0934	.1463	.1463	.1663
Max	.1646	.2987	.2427	.2743	.2686	.1663
Min	.0914	.1086	.0924	.1086	.0732	.128
Avg	.1234	.1676	.1511	.1562	.1464	.1493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 202 / 11 KV KEREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.4294	.3856	.4207	.7459	.811
2	.631	.4108	.3688	.4024	.7956	.7682
3	.6661	.4108	.3856	.4572	.8453	.7499
4	.7186	.4294	.3856	.4066	.9282	.9795
5	.9114	.4294	.4024	.4251	1.1934	1.5181
6	1.1393	.4668	.4527	.4435	1.4255	1.7193
7	1.3496	.4668	.4694	.4938	.4144	.4191
8	1.3847	.4108	.6706	.4525	.4481	
9	1.4198	.631	.9242	.4525	.4481	
10	1.5023	.9593	.3109	.4481	.4294	
11	1.4003	1.647	1.5384	.4294	.4294	
12	1.5497	1.7194	1.6651	.4294	.4108	
13	1.5684	1.5746	1.7375	.4294	.3521	
14	1.5123	1.647	1.829	.4294	.3688	
15	1.587	1.6108	1.9022	.4108	.3688	
16	1.643	1.5927	.3801	.5041	.3856	
17	.3681	.3521	.3982	.4108	.4024	
18	.4108	.3856	.4207	.4108	.3856	
19	.4294	.3856	.4572	.4294	.4024	
20	.4854	.4191	.439	.4668	.4359	
21	.4668	.4191	.4572	.6962	.9619	
22	.4481	.4024	.439	.7459	1.0164	
23	.4294	.4024	.4207	.7459	.9391	
24	.5959	.4294	.3856	.4207	.6796	.8299
Max	1.643	1.7194	1.9022	.7459	1.4255	1.7193
Min	.3681	.3521	.3109	.4024	.3521	.4191
Avg	.9687	.7513	.7177	.4734	.6339	.9744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 203 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.8684	1.1643	1.3923	.2427	.2218
2	.168	.9614	1.2012	1.4575	.2614	.2033
3	.1867	1.1105	1.1888	1.4575	.2614	.2012
4	.2054	1.2929	1.2254	1.587	.3174	.3206
5	.3174	1.5581	1.386	1.7004	.3921	.415
6	.3734	1.8067	1.6448	1.8138	.5041	.5281
7	.4481	2.2211	.4755	.4481	.5041	.5093
8	.3734	1.9725	.2881	1.4251	1.6244	1.5729
9	.2572	.2614	.2534	2.1052	1.989	
10	.2801	.197	.2515	2.1714	2.0719	
11	.1867	.197	.2229	2.1216	1.9393	
12	.168	.1772	.2241	1.8896	1.6575	
13	.1494	.1492	.1307	2.1051	1.5893	
14	.168	.1357	.1307	2.1714	1.5729	
15	.168	.1907	.112	2.2377	1.8515	
16	.1867		.112	.1494	.0848	
17	.1494		.1867	.168	.1772	
18	.2241	.1886	.2614	.2054	.2561	
19	.2987	.2401	.3174	.2987	.3018	
20	.3174	.3511	.3734	.3361	.3772	
21	.2987	.2957	1.2643	.2987	.3395	
22	.7095	.3142	1.3123	.2427	.2987	
23	.7842	.4251	1.3123	.2427	.2427	
24	.2263	.7842	1.1827	1.3603	.2427	.2218
Max	.7842	2.2211	1.6448	2.2377	2.0719	1.5729
Min	.1494	.1357	.112	.1494	.0848	.2012
Avg	.2854	.7136	.6759	1.2244	.7958	.466



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 246013 / 110/33KV Ranjani

Feeder No / Name : 409 / 33 KV MAKKA FACTORY  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-JUL-18
HR	Load (MW)
24	.8145
Max	.8145
Min	.8145
Avg	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.2477	.2286	.2286	.5868	.6104	.3795
2	.5868	.2477	.2286	.2286	.5868	.5868	.3479
3	.5801	.2667	.2286	.2286	.5801	.5868	.3479
4	.5967	.2667	.2286	.2286	.5967	.6613	.3437
5	.6464	.3048	.3429	.2286	.6882	.7373	.6722
6	.8356	.4572	.4001	.4382	1.1142	1.3094	.8785
7	1.1633	.4954	.4572	.4954	.4191	.04	.4001
8	1.4413	.381	.7116	.3467	.3429	.362	.3239
9	1.5061	.7291	1.0242	.3155	.2858	.2667	.3048
10	1.6057	1.7101	1.5384	.2947	.2477	.2286	.1715
11	1.6194	1.9271	1.9595	.3898	.1905	.1905	.1715
12	1.668	2.1628	2.0325	.2286	.1715		.1524
13	1.3108	2.0972	2.0243	.2096	.1715	.1905	.1524
14	1.4255		1.9595	.1905	.1715	.1524	.1524
15	1.5708	1.5844	2.0485	.1905	.1334	.1715	
16	1.7328	1.6712	.2477		.1524	.1334	
17	.1334	.1524	.2477	.1715	.1524	.1524	.1715
18	.1524	.2286	.2667	.2477	.1905	.2096	.2858
19	.3239	.2858	.3429	.2858	.2667	.2858	
20	.362	.362	.381	.3429	.3429	.3429	.3048
21	.3429	.3429	.3239	.6874	.7712	.6062	.4752
22	.2858	.2667	.2858	.663	.6706	.5506	.4424
23	.2477	.2477	.2477	.6299	.6104	.3521	.431
24	.5868	.2477	1.5242	.2286	.6036	.6274	.3795
Max	1.7328	2.1628	2.0485	.6874	1.1142	1.3094	.8785
Min	.1334	.1524	.2286	.1715	.1334	.04	.1524
Avg	.8880	.7253	.8034	.3261	.4186	.4067	.3471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	1.0774	.9014	1.1336	.1524	.1524	.1524
2	.1905	1.0774	.8697	1.1336	.1524	.1524	.1524
3	.1905	1.1219	.8592	1.1336	.1524	.1524	.1524
4	.1905	1.1797	.8124	1.1336	.1524	.1715	.1524
5	.2096	1.278	1.1336	1.1203	.1905	.1715	.1905
6	.2477	1.5384	1.4918	1.4243	.2667	.2477	.2286
7	.2858	1.7652	.3048	.2858	.2667	.2667	.2477
8	.2286	1.8351	.2858	1.2793	1.1633	1.1904	.8962
9	.1905	.1715	.2286	1.9845	1.3927	1.5912	1.3603
10	.1715	.1524	.2286	2.0891	1.9595	1.8233	1.6032
11	.2286	.1334	.2667	2.0081	2.0729	1.9334	1.5546
12	.2286	.1524	.1715	2.0805	1.9334	1.8884	1.4403
13	.1905	.1905	.1524	2.0081	1.8842	1.8724	1.4737
14	.2096	.2096	.1524	1.9498	1.8138	1.8244	1.4899
15		.1715	.1715	1.7814	1.8023	1.8785	1.5384
16	.1715	.1715	.2667	.1143	.1334	.1524	.1524
17	.1524	.1524	.2667	.1524	.1524	.1905	
18	.1715	.1715	.2667	.1524	.1715	.2096	
19	.1905	.2096	.2667	.1905	.1905	.2096	.2096
20	.2286	.2096	.2667	.2477	.2096	.2286	.2286
21	.2096	.2096	1.065	.2096	.1905	.1905	.2096
22	.1715	.1905	1.1797	.1715	.1715	.1905	.1715
23	.8718	.5601	1.1498	.1524	.1715	.1524	.1524
24	.1905	1.094	.9014	1.1336	.1524	.1524	.1524
Max	.8718	1.8351	1.4918	2.0891	2.0729	1.9334	1.6032
Min	.1524	.1334	.1524	.1143	.1334	.1524	.1524
Avg	.2309	.6260	.5692	1.0446	.7041	.7080	.6323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.5967	.5121	.639	.1334	.1334	.1334
2	.1143	.5967	.4801	.639		.1334	.1334
3	.1143	.6226	.4744	.639	.1334	.1334	.1334
4	.1143	.6554	.4428	.6478	.1334	.1715	.1334
5	.1524	.6964	.5761	.6802	.1905	.1715	.1524
6	.2096	.8259	.8288	.9442	.2477	.2477	.1905
7	.2477	1.3117	.2286	.2286	.2286	.2477	.2286
8	.1715	1.5565	.2286	1.1633	.6796	.5801	.4744
9	.1334	.1143	.1905	1.5546	.9831	.8383	.7522
10	.1715	.1524	.1715	1.7004	1.1305	1.2125	1.085
11	.1715	.1524	.1524	1.6644	1.2631	1.3272	1.1174
12	.2286	.1715	.1524	1.6644	1.2616	1.1702	1.1336
13	.1524	.1524	.1524	1.6032	1.1336	1.2809	1.1498
14	.1524	.1524	.1524	1.5384	1.1012	1.2334	1.1822
15	.1524	.1715	.1334	1.4899	1.065	1.0082	1.166
16	.1905	.1143	.1715	.1715	.1143	.1334	.1524
17	.1524	.1715	.1905	.1334	.1143	.1524	.1334
18	.1905	.1715	.2096	.1524	.1334	.1715	.1334
19	.2096	.1905	.2096	.1524	.1524	.2096	.1905
20	.2096	.2286	.2286	.1524	.2286	.1905	.2096
21	.1905	.2286	.5735	.2096	.2096	.1905	.1715
22	.1524	.1905	.6554	.1715	.1715	.1715	.1524
23	.431	.3932	.639	.1524	.1524	.1524	.1334
24	.1143	.6133	.5121	.639	.1334	.1334	.1334
Max	.431	1.5565	.8288	1.7004	1.2631	1.3272	1.1822
Min	.1143	.1143	.1334	.1334	.1143	.1334	.1334
Avg	.1767	.4263	.3444	.7805	.4824	.4748	.4407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1334	.2286	.0762	.1715	.1905	.1143
2	.1715	.0762	.1905	.0762	.1524	.1715	.1143
3	.0572	.0762	.1905	.0762	.2286	.1334	.1143
4	.1715	.0762	.1905	.0762	.0762	.1715	.1143
5	.0762	.0762	.1905	.0762	.0762	.0762	.0572
6	.0953	.0762	.0762	.0762	.0762	.1143	.0572
7	.1715	.2477	.0572	.0762	.0762	.0953	.0381
8	.2477	.0762	.2286	.3429	.2477	.2667	.1905
9	.1905	.0572	.0762	.1905	.0762	.1143	.1715
10	.4191	.2667	.0762	.362	.2286	.1524	.1524
11	.4001	.362	.1905	.2858	.1334	.2096	.1524
12	.0762	.2667	.3239	.1524	.2858	.3048	.1334
13	.3429	.1905	.2286	.1905	.362	.1715	.1524
14	.3429	.3048	.0762	.2477	.3048	.0762	.1715
15	.3429	.0572	.381	.1905	.2096	.0953	.0381
16	.2096	.362	.1524	.0572	.1143	.1524	.1334
17	.0762	.3239	.3048	.0572	.1334	.3239	.2286
18	.0762	.3239	.3429	.1905	.4001	.362	.2858
19	.2858	.2667	.2858	.2858	.381	.2096	.1143
20	.3048	.362	.3239	.3429	.0953	.1334	.1524
21	.1715	.1905	.0381	.0762	.0572	.0762	.1143
22	.0762	.0762	.0381	.0572	.0572	.0762	.0953
23	.2477	.2096	.1334	.0762	.3429	.1143	.1334
24	.1905	.1715	.2286	.0953	.0762	.2667	.1143
Max	.4191	.362	.381	.362	.4001	.362	.2858
Min	.0572	.0572	.0381	.0572	.0572	.0762	.0381
Avg	.2072	.1929	.1897	.1556	.1818	.1691	.1310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0953	.1334	.6874	.6371	.4744
2	.1143	.0953	.0953	.1334	.6874	.5967	.4374
3	.1143	.0953	.0953	.1334	.6796	.5967	.4374
4	.1334	.1334	.0953	.1334	.6882	.6464	.4218
5	.1524	.1715	.1905	.1715	.8029	.7045	.5761
6	.1905	.2477	.2286	.3048	1.1498	1.1305	.9282
7	.2286	.0762	.2667	.3048	.2667	.2477	.2667
8	.5735	.1524	.7202	.2096	.1905	.1524	.1524
9	.7287	.7122	1.0562	.1715	.1334	.1715	.1334
10	.6718	1.326	1.2955	.1715	.0953	.1715	.0762
11		1.4413	1.5708	.1905	.1143	.1524	.0762
12	.1094	1.7013	1.5223	.1524	.1143	.1524	.0762
13	1.1469	1.6834	1.4899	.1334	.1143	.1524	.0953
14	1.1305	1.5927	1.0202	.1143	.1143	.1334	.1143
15	1.1736	1.448	1.3603	.1334	.0953	.1334	.0953
16	1.0059	1.4299	.2286	.1334	.0953	.1334	.1143
17	.0762	.1334	.2096	.1334	.1143	.1334	.0953
18	.0953	.1334	.1715	.1334	.1143	.0953	.1143
19	.1715	.1524	.1905	.1905	.1524	.1334	.1524
20	.1905	.1905	.2286	.2286	.1715	.1715	.1715
21	.1905	.1715	.1905	.7545	.6274	.4534	.431
22	.1334	.1524	.1905	.7956	.6464	.5601	.4527
23	.1143	.1143	.1334	.7459	.7127	.5441	.463
24	.1143	.0953	.7621	.1334	.6962	.6539	.4744
Max	1.1736	1.7013	1.5708	.7956	1.1498	1.1305	.9282
Min	.0762	.0762	.0953	.1143	.0953	.0953	.0762
Avg	.3771	.5644	.5587	.2433	.3860	.3607	.2846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.1524	.1334	.1334	.1143	.1334
2	.1334	.1143	.1524	.1334	.1334	.1143	.1334
3	.1334	.1334	.1524	.1334	.1334	.1143	.1334
4	.1524	.1715	.1524	.1334	.1524	.1715	.1334
5	.1905	.2096	.2286	.1715	.1905	.2096	.2286
6	.2858	.3155	.2858	.3048	.3048	.3048	.3048
7	.381	.3189	.3048	.362	.2667	.3429	.3429
8	.3429	.2715	.3429	.2477	.2477	.2858	.2286
9	.2477	.2477	.3439	.2286	.2286	.2667	.2477
10	.3429	.2286	.3048	.1715	.2286	.2477	.2286
11	.2667	.2858	.2667	.1905	.1905	.3239	.2096
12	.2096	.2286	.1715	.1524	.2096	.2572	.2286
13	.1905	.1646	.1905	.1715	.1715	.2279	.1905
14	.1715	.1334	.2667	.1143	.1334	.168	.1334
15	.1905	.2294	.2286	.1334	.2477	.2279	.1334
16	.1905	.1898	.1715	.1143	.2096	.1448	.1905
17	.2858	.3155	.2096	.1334	.1905	.1991	.2667
18	.2667	.2804	.2286	.1524	.1905	.2534	.2667
19	.2667	.2896	.3048	.2286	.2286	.2477	.3048
20	.3048	.2858	.3048	.2858	.2667	.2667	.2858
21	.2286	.2286	.2477	.2286	.2286	.2477	.2286
22	.1905	.1905	.2286	.1715	.1905	.1715	.1715
23	.1334	.1524	.1334	.1524	.1334	.1524	.1143
24	.1334	.1143	.1524	.1334	.1334	.1143	.1334
Max	.381	.3189	.3439	.362	.3048	.3429	.3429
Min	.1334	.1143	.1334	.1143	.1334	.1143	.1143
Avg	.2239	.2173	.2302	.1826	.1977	.2156	.2072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18	02-JUL-18
HR	Load (MW)	Load (MW)
9		.1829
24	.7621	
Max	.7621	.1829
Min	.7621	.1829
Avg	.7621	.1829



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18	02-JUL-18
HR	Load (MW)	Load (MW)
24	.7621	.3429
Max	.7621	.3429
Min	.7621	.3429
Avg	.7621	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18	02-JUL-18
HR	Load (MW)	Load (MW)
9		.168
24	1.5242	
Max	1.5242	.168
Min	1.5242	.168
Avg	1.5242	.168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18	02-JUL-18
HR	Load (MW)	Load (MW)
24	.7621	.2587
Max	.7621	.2587
Min	.7621	.2587
Avg	.7621	.2587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18	02-JUL-18
HR	Load (MW)	Load (MW)
24	.7621	1.9757
Max	.7621	1.9757
Min	.7621	1.9757
Avg	.7621	1.9757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	1.8043
Max	1.8043
Min	1.8043
Avg	1.8043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1334	.1715	.1905	.1509	.1524	
2	.132	.1334		.1905	.1509	.1524	
3	.1524	.1334	.1524	.1715	.1509	.1524	
4	.1524	.1334	.1524	.1715	.1698	.1524	
5	.1715	.1698	.1524	.1524	.1698	.1524	
6	.1715	.1509	.1905	.1698	.1698	.1698	
7	.1509	.1509	.1494	.1478	.1698	.1132	.132
8	.1509	.1494	.1867	.1509	.168	.132	.1509
9	.1509		.1886	.1524		.1509	.1509
10	.1646	.1886	.1886	.1509	.1509	.1132	.1494
11	.168	.1509	.1867	.1663	.1478	.1097	.1294
12	.1494	.1294	.132	.1509	.112	.1267	.132
13	.1132	.1109	.1143	.1132	.1143	.1132	.1143
14	.0953	.1109	.1132	.0934	.0762	.0754	.0554
15	.0943	.1132	.1132	.0754	.0739	.1132	.0514
16	.0953	.0953		.0943	.0754	.0747	.0554
17		.208		.0762	.1097	.0754	.0747
18	.1417	.1753		.112	.0739	.1494	.1307
19	.1132	.1867	.2012	.1478	.181	.1478	.1886
20	.2263	.2957	.2987	.2957	.2587	.2896	.2452
21	.2686	.2401	.3018	.2801	.2427	.2402	.2096
22	.1848	.2195	.2641	.2263	.1886	.2054	.2075
23	.1524	.1905	.2452	.1524		.1509	.1886
24	.132	.1334	.1715	.2096	.1524	.1509	.132
Max	.2686	.2957	.3018	.2957	.2587	.2896	.2452
Min	.0943	.0953	.1132	.0754	.0739	.0747	.0514
Avg	.1506	.161	.1837	.1601	.1481	.1443	.1388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168		.2328	1.6804	.1143	.168	
2	.1509		1.6194	1.6842	.1143	.168	
3	.1509			1.6518	.1143	.168	
4	.1698		1.7814	1.6032		.168	
5	.1886		2.13	1.6356		.168	
6	.1886		2.1795	1.9919		.1698	
7	.2054		.208	.181		.197	.2149
8	.1848		.1848	1.9006		1.4083	1.2803
9	.1307		.1463	2.4863		2.0719	1.9938
10	.1867		.1848	2.5194	1.5893	2.3868	2.0553
11	.1867		.2587	2.8344	2.1628	2.6189	2.0645
12	.1867	.1663	.2427	2.7846		2.4531	2.13
13	.132	.1867	.1867	2.9835	1.8138	2.1464	2.1628
14	.1663	.1867	.1848	2.8012	2.0809	2.2348	
15	.168	.2241	.1646	2.6686	2.0553	2.2211	2.0243
16	.1663	.2926	.2835	.1311	.144	.0633	.0724
17	.1526	.2561	.1905	.2012	.1174	.0995	.1052
18	.2303	.2804		.2254	.1353	.1753	.1227
19	.2103	.2507	.2507	.181	.2454	.1772	.1387
20	.2012	.2534	.1829	.2402	.2328	.1595	.1372
21	.1829	.1629	1.6712	.2263	.2054	.1478	.1307
22	.1991	.1629	1.7814	.2075	.1867	.1494	.112
23		1.6057	1.7284	.1886		.1478	.1132
24	.168		1.6842	1.7124	.1867	.1867	.1294
Max	.2303	1.6057	2.1795	2.9835	2.1628	2.6189	2.1628
Min	.1307	.1629	.1463	.1311	.1143	.0633	.0724
Avg	.1772	.3357	.7944	1.4467	.7187	.8356	.8816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.7842	.7362	.8162	.0572	.0572	
2	.0762	.7935	.7362	.7842	.0572	.0572	
3	.0572	.8029	.7362	.7682	.0572	.0572	
4	.0572	.8029	.7362	.7842	.0572	.0572	
5	.0762	.8951		.8002	.0762	.0572	
6	.0953	.9878	.9122	1.0364	.0762	.0572	
7	.0762	1.1174	.0572	.0572	.0572	.0762	.0572
8	.0762	1.2631	.0762	1.1012	.8785	.6964	.6241
9	.0572		.0762	1.3927		.9945	.7682
10	.0762	.0572	.0762	1.3245	1.004	2.3045	.7449
11	.0953	.0762	.0762	1.4754	1.0814	1.0722	.7045
12	.0762	.0762	.0762	1.4922	.8951	1.0242	.852
13	.0762	.0762	.0762	1.4089	.9717	1.094	.8848
14	.0953	.0762	.0762	1.3748	1.0526	1.0883	.7209
15	.0953	.0762	.0762	1.2763	1.0608	1.0883	.8029
16	.0953	.0762		.0762	.0762	.0762	.0762
17	.0762	.0762		.0762	.0572	.0572	.0572
18	.0953	.0953		.0572	.0572	.0572	.0572
19	.0572	.0762	.0953	.0762	.0762	.0572	.0762
20	.0953	.0762	.1334	.0762	.0953	.0762	.0762
21	.0953	.0953	.8097	.0762	.0762	.0572	.0762
22	.0762	.0953	.8482	.0572	.0762	.0572	.0572
23	.6325	.6722	.8642	.0572		.0572	.0572
24	.0762	.7748	.7362	.8002	.0572	.0572	.0572
Max	.6325	1.2631	.9122	1.4922	1.0814	2.3045	.8848
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.1026	.4314	.4005	.7186	.3616	.4306	.3750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	.2829		.2667	1.8623	2.1052	
2	1.5844	.2829	.2328	.2667		2.0481	
3	1.5844	.2829	.2328	.2858		2.0243	
4	1.6194	.2829	.2328	.2858		2.0005	
5		.2829	.2715	.3018		1.9766	
6	2.0081	.3395		.3772		2.4577	
7	2.4615	.2641	.3658	.3921	.2987	.3361	.2587
8	2.7526	.2427	1.9608	.3395	.2801	.3109	.2279
9	2.7854		2.7854	.3547		.2987	.1867
10	3.0498	3.0167	3.0001		.2614	.2452	.1989
11		2.8178	2.9172	.2957	.2614	.2241	.216
12	2.9835	3.0333	3.0001		.2743	.2075	.2107
13	2.5232	2.9835	2.4577		.2743	.2241	.1858
14	2.6543	2.9835	2.4905		.2641	.2452	.2058
15	2.7854	3.0148			.168		.2332
16	2.6543	3.1161	.2743	.3048	.3812	.2614	.2713
17	.2126	.216	.2926	.4641		.2957	.2804
18	.3761	.2721		.4784	.4024	.3395	.2835
19	.3174		.3174	.3772	.3734	.2926	.3109
20	.3206	.3696	.415	.3772	.3395	.2987	.3174
21	.2987	.3174	.3772	2.3266	2.0005	1.5623	1.3748
22	.2926	.3206	.3584	2.652	2.2405	1.7185	1.3904
23	.2614	.2641	.3018	2.5263		1.6821	1.4198
24	1.5844	.2829	.7621	.2667	2.2996	2.2405	
Max	3.0498	3.1161	3.0001	2.652	2.2996	2.4577	1.4198
Min	.2126	.216	.2328	.2667	.168	.2075	.1858
Avg	1.6687	1.1486	1.1523	.6810	.7489	1.0172	.4454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1603	.415	.3395	.4572	1.576	1.5261	
2	1.1603	.415	.3395	.381	1.5581	1.5261	
3	1.3077	.415	.3395	.362	1.5746	1.3413	
4	1.3077	.415	.3395	.362	1.5565	1.3413	
5	1.4083	.4904	.3772	.4338	1.5729	1.3077	
6	1.6766	.5658		.5658	1.5546	1.8778	
7	1.6263	.5601	.4904	.679	.415	.5281	.3696
8	1.8945	.5359		.5658	.3961	.4338	.4527
9	1.9281			.5847		.415	.3395
10	2.2405	2.0972		.3361	.4481	.4854	.3395
11	1.9784	2.3807	2.2211	.4854	.5228	.4481	
12	1.9784	2.0454	2.1879			.415	
13	1.8778	1.989	2.1963		.1886	.5601	.3018
14	1.8442	1.989	2.079		.3921	.1886	.1867
15	1.7436	2.0553	1.8351		.3584	.1509	.3395
16	1.8442	2.2131		.3772	.3961	.1509	.2987
17	.3174	.2713		.5847	.5601	.3361	.3292
18	.3077	.4435		.6348	.5601	.5228	.4024
19	.3772	.4854	.3361	.5281	.5281	.5975	.4527
20	.6348	.6348	.679	.7545	.6224	.1524	.4904
21	.5847	.5601	.5847	1.286	1.3904	.9724	.9156
22	.6413	.5281	.7733	1.95	1.5424	1.2929	1.1401
23	.3772	.4854	.6413	1.8482		1.2597	1.0343
24	1.1271	.415	.3772	.6097	1.6766	1.56	1.1934
Max	2.2405	2.3807	2.2211	1.95	1.6766	1.8778	1.1934
Min	.3077	.2713	.3361	.3361	.1886	.1509	.1867
Avg	1.3060	.9742	.9492	.6893	.9233	.8079	.5366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3018	.3018	.3018	.2772	.2641	.2561
2	.2614	.3018	.3206	.3018	.2772	.2641	.2561
3	.2427	.3018	.3206	.3018	.2614	.2641	.2534
4	.2427	.3018	.3206	.3018	.2614	.2641	.2715
5	.2957	.3395	.3206	.3258	.2772	.3018	.3258
6	.3696	.4024	.3395	.3582	.3142	.3584	.362
7	.4024	.3801	.3961	.3721	.3921	.4163	
8	.3761	.2835	.4066	.3467	.3801	.3898	
9	.3761	.3544	.3801	.3155	.3189	.3544	.3856
10	.3506	.3721		.2947	.3544		.3294
11	.333	.2835		.3721	.3366		.2774
12	.3189	.3294		.3366	.298		.2743
13	.3155	.3467		.298	.298		.2743
14	.3012	.3294		.2835	.2835		.2572
15	.2629	.3294		.298	.2835		.3294
16	.2601	.3294		.3012	.2658		.3155
17	.3222	.2947		.3121	.2804		.333
18	.3086	.3155		.3189	.3045		.3506
19	.3582	.394		.3801	.3982		.3761
20	.4344	.499		.4344	.439		.4477
21	.3881	.4066		.4163	.3772		.2641
22	.3326	.3772		.3475	.3206		.3206
23	.2743	.3206		.2926	.2641		.2641
24	.2614	.2829	.3018	.2987	.2772	.2641	.2561
Max	.4344	.499	.4066	.4344	.439	.4163	.4477
Min	.2427	.2829	.3018	.2835	.2614	.2641	.2534
Avg	.3188	.3407	.3408	.3296	.3142	.3141	.3082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	1.5074	1.5927	1.8187	.2263	.2075	.1698
2	.2263	1.5074	1.5927	1.8023	.2263	.2075	.1698
3	.0189	1.5402	1.6263	1.7859	.2263	.2075	.1698
4	.1886	1.5729	1.7101	1.7859	.2452	.2075	.1886
5	.1886	1.704	1.7772	1.7859	.2641	.2075	.1886
6	.2452	2.2775	2.0885	2.0567	.2829	.2641	.2075
7	.2641	2.652	.2075	.2829	.2829	.1886	
8	.2075	2.6023	.2641	1.7695	1.1498	1.065	
9	.2641	.1698	.2641	1.9433	1.5729	1.4255	1.326
10	.2263	.1886		1.5546	1.9062		1.3763
11	.2263	.1886		2.6023	2.0222		1.1961
12	.2263	.1886		2.7018	1.7736		1.2597
13	.2452	.1886		2.7681	1.7368		1.1336
14	.2452	.2075		2.7018	1.6907		1.2163
15	.2263	.2075		2.7349	1.6078		1.2955
16	.2452	.2641		.1886	.1132		.1698
17	.2263	.2829		.2075			.1886
18	.2452	.3206		.2452	.1509		.2075
19	.2452	.3018		.2641	.2452		.2263
20	.3018	.3018		.2641	.3018		.2641
21	.2829	.3018		.2829	.2641		.2641
22	.2641	.2829		.2829	.2452		.2452
23	.9831	1.1233		.2452	.2075		.2263
24	.2075	1.4746	1.5424	1.917	.2263	.2075	.1698
Max	.9831	2.652	2.0885	2.7681	2.0222	1.4255	1.3763
Min	.0189	.1698	.2075	.1886	.1132	.1886	.1698
Avg	.2594	.8899	1.2666	1.4163	.7377	.4188	.5391



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	.2075	.1698	.1698	1.8023	1.2793	.9779
2	1.0364	.2075	.1698		1.7368	1.2631	.9614
3	.9717	.2075	.1698	.1698	1.6876	1.2631	.9503
4	.9717	.2075	.1698	.1698	1.6385	1.247	1.094
5	1.0202	.2075	.1698	.1698	1.6712	1.278	1.1128
6	1.3108	.2075	.1886	.1886	1.9662	1.8233	1.442
7	1.6409	.2075	.1886	.2263	.1886	.1886	
8	2.0719	.1509	1.3245	.2452	.1509	.132	
9	2.0719	1.1336	1.7204	.1698	.1509	.1509	.1132
10	2.1382	2.1051		.1698	.1132		.1132
11	2.0056	2.2186		.1886	.1132		.1132
12	2.1216	2.3102			.1132		.0943
13	2.0553	2.3266					.0943
14	1.9334	2.3102			.1132		.0943
15	2.1548	2.3102			.1132		.0754
16	2.2283	2.0729		.1509	.132		.0754
17	.132	.0943		.1886	.1509		.1132
18	.1509	.2075		.2263	.132		.132
19	.2075	.2263		.2452	.1886		.132
20	.2452	.2641		.2452	.2452		.1886
21	.2452	.2263		1.4089	1.2452		.7907
22	.2263	.2452		1.9725	1.3765		.8065
23	.2075	.1886		1.9062	1.3279		.8162
24	1.1012	.2075	.1698	.2075	1.8023	1.2793	.9667
Max	2.2283	2.3266	1.7204	1.9725	1.9662	1.8233	1.442
Min	.132	.0943	.1698	.1509	.1132	.132	.0754
Avg	1.2243	.8354	.4441	.4431	.7895	.9905	.5117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.1698	.132		.9503	.7125	.7293
2	.4858	.1509	.132		.9012	.7042	.7293
3	.4858	.1509	.132		.852	.7042	.7293
4	.4858	.1509	.1509		.9831	.7042	.7373
5	.4858	.1698	.1509	.132	.8356	.7042	.7537
6	.583	.1509	.1509	.1509	.9503	.8684	.9012
7	.8029	.132	.1509	.1509	.1509	.1509	
8	.9175	.1132	.8029	.1886	.1509	.1509	
9	.9831	.6483	1.0322	.1509	.132	.1509	.1509
10	1.094	1.0082		.1132	.1132		.1509
11	1.1174	1.1934		.1132	.0943		.132
12	1.166	1.0159			.1132		.1132
13	1.1012	1.2289					.132
14	1.0688	1.2452			.1132		.1132
15	1.1797	1.2616			.1132		.1132
16	1.1498	1.3435		.132	.1132		.1132
17	.0754	.1132		.1698	.132		.1132
18	.0943	.1509		.1509	.132		.1509
19	.1698	.1698		.1698	.1509		.1509
20	.1886	.1698		.1698	.1698		.1698
21	.1886	.1698		.7701	.6882		.5281
22	.1886	.1509		.9339	.7449		.5121
23	.1698	.132		.9945			.502
24	.4858	.1698	.132		.9503	.7287	.7127
Max	1.1797	1.3435	1.0322	.9945	.9831	.8684	.9012
Min	.0754	.1132	.132	.1132	.0943	.1509	.1132
Avg	.6314	.4733	.2967	.2994	.4334	.5579	.3836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	1.2146	1.3565	1.491	.1509	.1132	.0754
2	.1132	1.2289	1.3413	1.4746	.1509	.1132	.0754
3	.1132	1.2452	1.358	1.4419	.1509	.1132	.0754
4	.1132	1.278	1.4089	1.4582		.1132	.0943
5	.1132	1.3435	1.442			.1132	.1132
6	.1509	1.7004	1.7101			.132	.1509
7	.1698	2.0153	.1509	.2452		.1886	
8	.1509	2.1628	.1698	1.8842			
9	.1509	.0754	.1509	1.9757	.583	1.6575	1.442
10	.1698	.0943		1.6221	.8356		1.6385
11	.1886	.1698		2.2377	.8848		1.5746
12	.1886	.1509		2.5194	.6478		1.6004
13	.1132	.1698		2.2542	.7449		1.7166
14	.1509	.1698		2.4863	.5992		1.7695
15	.132	.1698		2.5194	1.5402		1.7814
16	.1698	.1698		.1509			.0943
17	.1698	.1698		.1698	.132		.1132
18	.1886	.1886		.1698	.1509		.132
19	.2075	.2075		.2263	.1886		.1698
20	.2075	.2263		.2263	.2075		.3018
21	.1886	.1886		.2641	.1886		.1698
22	.1698	.1509		.1886	.1509		.132
23	.9831	1.0608		.1698	.1132		.1132
24	.1132	1.1984	.7621	1.491	.1509	.1132	.0754
Max	.9831	2.1628	1.7101	2.5194	1.5402	1.6575	1.7814
Min	.1132	.0754	.1509	.1509	.1132	.1132	.0754
Avg	.1887	.6979	.9851	1.2121	.4206	.2953	.6095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 201 / Salgare Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 202 / Chabukswarwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 203 / Janraowadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.4918
Max	1.4918
Min	1.4918
Avg	1.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.5775
Max	1.5775
Min	1.5775
Avg	1.5775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962	.1334	.1715	.1524	1.3435	.9831	1.3923
2	.7127	.1334	.1524	.1524	1.3279	1.0159	1.4091
3	.7373	.1143	.1715	.1715	1.4232	1.1012	1.4586
4	.8288	.1524	.1715	.1715	1.4842	1.1984	1.4419
5	.9831	.1715	.1905	.1715	1.6358	1.3927	1.4746
6	1.2742	.2477	.1905	.2286	2.1971	1.5384	
7	1.4754	.2286	.2858	.2477	.3429	.2477	.3048
8	1.4586	.2477	.5571	.2477	.2667	.2667	.3239
9	1.4899		1.085	.2096	.2477	.2477	.3048
10	1.5402		1.5565	.2667	.2286	.2096	.2667
11	1.4413		1.8842	.2286	.2096	.1905	.2477
12	1.5203	.8192	1.9109	.2477	.2096	.1715	.1905
13	1.3603	1.6194	1.917	.2286	.1524	.1905	.1715
14	.852	1.8404	1.8564	.2096	.2096	.2286	.1905
15	1.3763	1.9109	1.917	.1905	.1715	.2286	.1905
16	1.6194	1.8023	.1905	.2096	.1715	.2096	.1905
17	.1143	.0953	.1715	.1905	.1715	.1905	.2096
18	.1524	.1715	.1715	.1905	.2096	.2096	.1905
19	.1905	.2286	.2286	.2096	.2096	.1524	.2286
20	.1905	.2477	.2096	.2286	.2286	.2286	.2286
21	.1715	.2096	.1905	.8619	.8907	.8848	.9069
22	.1334	.1715	.1524	1.1797	1.1797	1.3923	1.2289
23	.1334	.1715	.1524	1.2018	1.0159	1.4419	1.5729
24	.6718	.1334	.1524	.1524	1.2803	1.0202	1.3923
Max	1.6194	1.9109	1.917	1.2018	2.1971	1.5384	1.5729
Min	.1143	.0953	.1524	.1524	.1524	.1524	.1715
Avg	.8802	.5167	.6516	.3146	.7003	.6225	.6746

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	1.3443	1.3611	1.1462	.1715	.1905	.1905
2	.1905	1.4899	1.4175	1.1744	.1524	.1905	.1905
3	.2286	1.5123	1.6476	1.2269	.1715	.2096	.2286
4	.2286	1.7394	1.9136	1.3112	.2286	.2477	.2286
5	.2667	2.0005	2.4177	1.3847	.2667	.2858	.2667
6	.362	2.3365	2.1616	1.8031	.362	.362	.362
7	.4001	2.5934	.5525	.4763	.381	.362	.4001
8	.3048	2.5606	.3048	1.5947	1.2955	2.0553	1.6991
9	.2858	.1905	.3239	2.3487	2.2834	2.8045	2.9447
10	.2667	.2096	.2667	2.4539	2.6707	2.9944	3.1375
11	.2667	.1905	.1715	2.556	3.0121	3.0476	2.4274
12	.2858	.1905	.2096	2.4615	3.0445	1.858	2.774
13	.2858	.1715	.1524	2.4646	2.9729	2.5659	2.7995
14	.2286	.1715	.1905	2.2929	2.8349	2.822	2.6787
15	.2096	.1143	.1905	2.3967	2.8833	2.7463	1.5546
16	.2286	.1715	.2096	.1334	.2096	.1715	.1524
17	.1905	.0953	.1905	.1715	.1524	.1715	.1715
18	.2858	.1715	.1715	.1905	.1524	.1715	.2286
19	.3239	.2477	.2667	.2858	.3239	.2286	.2858
20	.4001	.3048	.2858	.3239	.3429	.3239	.3239
21	.2858	.2858	.9671	.2858	.2667	.2477	.2667
22	.2286	.2286	1.0454	.1905	.2096		.2286
23	.7811	.8939	1.0631	.1905	.1905	.1715	.2096
24	.1905	1.2176	1.2536	1.0631	.1715	.1905	.1905
Max	.7811	2.5934	2.4177	2.556	3.0445	3.0476	3.1375
Min	.1905	.0953	.1524	.1334	.1524	.1715	.1524
Avg	.2882	.8513	.7806	1.2470	1.0313	1.0617	.9975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0808	.2286	.2286	.2286	1.4243	1.7364	1.773
2	1.1641	.2096	.2096	.2286	1.4883	1.773	1.7528
3	1.2048	.1905	.2286	.2477	1.5813	1.825	1.8604
4	1.3466	.2477	.2477	.2858	1.8623	2.0595	2.0553
5	1.4529	.2858	.3239	.3429	2.1605	2.4177	2.226
6	2.0332	.4763	.4382	.4954	3.0639	3.0445	2.9797
7	2.516	.381	.3429	.4763	.3239	.4191	.4954
8	2.2611	.2858	.8417	.362	.381	.3239	.4191
9	2.3487	.6379	1.382	.3239	.3239	.2858	.3429
10	2.3579	1.9342	2.364	.3239	.3239	.2286	.3429
11	2.4274	2.1262	2.7641	.2858	.3239	.3429	
12	2.3838	2.5431	2.9447	.3048	.3048	.3048	.1524
13	2.268	2.4806	2.0953	.2858	.2667	.2667	.1715
14	2.2805	2.4714	2.524	.2477	.2477	.2477	.2096
15	2.226	1.3073	2.4806	.2286	.2477	.2667	.2286
16	2.2565	2.3388	.3429	.2286	.2096	.0572	.2096
17	.2096	.1905	.2858	.2286	.2477	.0572	.2286
18	.2477	.2096	.3429	.2667	.1715	.0572	.2667
19	.3239	.2477	.3429	.3048	.3239	.2477	.3048
20	.3429	.362	.381	.3429	.4001	.381	.3239
21	.3239	.3239	.3048	1.1385	1.8054	1.5947	.7442
22	.2858	.2667	.2477	1.3763	2.0199	1.858	.8238
23	.2286	.2286	.2286		1.949	1.8073	.9412
24	1.0166	.2286	.2286	.2286	1.4251	1.9342	1.7551
Max	2.516	2.5431	2.9447	1.3763	3.0639	3.0445	2.9797
Min	.2096	.1905	.2096	.2286	.1715	.0572	.1524
Avg	1.4411	.8418	.9217	.3819	.9532	.9807	.8960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0762	.0572	.0572	.0762	.0762	.0572
5	.0762	.0953	.0953	.0572	.0953	.1143	.0762
6	.1334	.1143	.1334	.1143	.0572	.0953	.0953
7	.0953	.0953	.0953	.1143	.0953	.0953	.0953
8	.0572	.0762	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572	.0572	.0572	.0572	.0572	.0572	.0572
11	.0572	.0572	.0572	.0572	.0572	.0572	.0572
12	.0572	.0572	.0572	.0572	.0572	.0572	.0572
13	.0572	.0572	.0572	.0572	.0572	.0572	.0572
14	.0572	.0572		.0572	.0572	.0572	.0572
15	.0572	.0572	.0572	.0572	.0572	.0572	.0572
16	.0572	.0572	.0572	.0572	.0572	.0572	.0572
17	.0762	.0762	.0572	.0953	.0572	.0572	.1143
18	.0953	.1143	.0572	.0953	.0953	.0572	.1143
19	.1143	.1143	.0953	.1143	.1143	.1143	.1143
20	.1143	.1524	.1524	.1524	.1524	.1524	.1143
21	.0762	.1143	.0953	.1143	.0953	.1143	.0953
22	.0572	.0762	.0572	.0762	.0762	.0572	.0762
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.1334	.1524	.1524	.1524	.1524	.1524	.1143
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0707	.0770	.0713	.0747	.0715	.0723	.0731



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0953	.0953	.1143	.0953	.0953
2	.0953	.0953	.0953	.0953	.1143	.0953	.0953
3	.1334	.1143	.1143	.1143	.1334	.1334	.1524
4	.1715	.1334	.1524	.1524	.1715	.1334	.1905
5		.1905	.1905	.1715	.1905	.1715	.2667
6	.2477	.2667	.2477	.2477	.2477	.2477	.2286
7	.2096	.2096	.2096	.1905	.2286	.2286	.2096
8	.1524	.1334	.1334	.1524	.1334	.1715	.1524
9	.1143	.1524	.1143	.1334	.1143	.0953	.1143
10	.1143	.1143	.1143	.0953	.1143	.0953	.1143
11	.0762	.1143	.1143	.1143	.0762	.0762	.1143
12	.0762	.1143	.0953	.0953	.0572	.1143	.0953
13	.0953	.0953	.0953	.0762	.0572	.0762	.0953
14	.0953	.1143	.0762	.1143	.0762	.0953	.1143
15	.1334	.0953	.0762	.1334	.0762	.0762	.0953
16	.1143	.1143	.1143	.1334	.0762	.0953	.1143
17	.1143	.1334	.1143	.1905	.1143	.1334	.1524
18	.1334	.2096	.1715	.1905	.1715	.1524	.1715
19	.1905	.2286	.2096	.2477	.2096	.2096	.1905
20	.1905	.2096	.2477	.2858	.2286	.2667	.2286
21	.1715	.2286	.1905	.1905	.2096	.2286	.2096
22	.1334	.1524	.1524	.0953	.1334	.1334	.1524
23	.1143	.1334	.1143	.1143	.0953	.0953	.1143
24	.0953	.1143	.1143	.0953	.1143	.0953	.0953
Max	.2477	.2667	.2477	.2858	.2477	.2667	.2667
Min	.0762	.0953	.0762	.0762	.0572	.0762	.0953
Avg	.1334	.1492	.1397	.1469	.1358	.1381	.1485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631		.2229	.3315	1.8023	1.7375	1.8187
2	1.4419		.2397	.3149	1.8067	1.4632	1.8023
3	1.5912		.2641	.3647	2.13	1.7394	2.13
4	1.6221		.2751	.3932	2.2672	2.2672	2.6216
5	1.6194		.2675	.426	2.9473	2.5888	2.7183
6	1.6712		.286	.4588	2.9165	2.2775	2.5777
7	2.1136		.3269	.4641	.2949	.2984	.3749
8	2.332		.9511	.4641	.3647	.3647	.3201
9		.3269	1.9509	.4641	.3647	.3932	.301
10		1.7833	2.0557	.3647		.3605	.2824
11		1.9204	2.1348	.2984		.2984	.1448
12		2.1559	2.0805	.2622		.2949	.176
13		2.1186	2.1216	.2785	.2374	.2984	.2027
14		2.1674	2.1136	.2984	.2713	.3647	.061
15		1.8278	2.1879	.2984	.3052	.3647	.0894
16		1.9662	.1989	.2652	.2713	.2321	.1217
17		1.8827	.2652	.2713	.1715	.2652	.176
18		.1875	.2949	.2294	.2401	.3113	.2027
19		.2105	.2984	.2294	.3086	.4475	.2641
20		.2458	.2652	.2294	.2743	.3605	.2972
21		.25	.3978	1.0774	1.0117	1.4918	1.2483
22		.2347	.3978	1.6385	1.6461	1.8023	1.247
23		.2229	.3605	1.6575	1.7375	1.8564	1.39
24	1.0311		.2107	.3315	1.6385	1.7558	1.9006
Max	2.332	2.1674	2.1879	1.6575	2.9473	2.5888	2.7183
Min	1.0311	.1875	.1989	.2294	.1715	.2321	.061
Avg	1.6317	1.1667	.8403	.4755	1.0956	.9848	.9362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3881	.3258	.2713	.2743	.3189	.2987
2	.4024	.3841	.3506	.2572	.2743	.3544	.3361
3	.3881	.362	.3681	.2835	.3292	.4252	.3326
4	.3734	.4024	.3772	.3189	.3258	.4344	.4435
5	.3801	.4435	.3681	.4024	.3429	.4706	.4607
6	.4024	.439	.394	.4252	.4115	.5249	.4961
7	.362	.3721	.4287	.462	.4334	.4706	.4961
8	.3366		.3429	.3467	.439	.3982	.3856
9	.285	.285	.3681	.3121	.3841	.439	.3294
10	.2881	.2984	.3222	.3121		.4755	.2743
11	.2458	.3353	.2949	.2926		.4024	
12	.2591	.3561	.2984	.3142		.3658	.2818
13	.2656	.3315	.2652	.3326	.2713	.3292	.2949
14	.2591	.3561	.2321	.3292	.3121	.3544	.2591
15	.285	.2683	.2652	.3292	.3189	.3189	.2622
16	.2258	.2818	.2486	.3292	.3366	.3292	.2785
17	.2667	.3018	.2984	.4024	.3721	.3292	
18	.3321	.2652	.3605	.4755	.4961	.3721	.3353
19	.4024	.285	.431	.5121	.5138	.5304	.4424
20	.4681	.2949	.4641	.4807	.5138	.4961	.5138
21	.3721	.3077	.3113	.3978	.5138	.3544	.4607
22	.3467	.3353	.2652	.3441	.4607	.3189	.4096
23	.3185	.3149	.2622	.3052	.4252	.3189	.421
24	.3681	.3734	.3052	.2622	.3086	.3189	.2926
Max	.4681	.4435	.4641	.5121	.5138	.5304	.5138
Min	.2258	.2652	.2321	.2572	.2713	.3189	.2591
Avg	.3331	.3383	.3312	.3541	.3837	.3938	.3684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	1.3763	1.4022	1.6804	.6535	.5975	.5601
2	.6468	1.4255	1.4998	1.6804	.7468	.6348	.5601
3	.6283	1.576	1.6842	1.8861	.8215	.6348	.7655
4	.6908	1.9826	2.0645	2.3777	.8962	.6535	.8402
5	.7167	2.1795	2.0778	2.4006	.9145	.7842	.9335
6	.7282	2.3537	1.5497	2.5265	.9877	.8589	.9709
7	.7733	2.9504	.4805	.5426	.9979	.8589	.9709
8	.7468		.5601	1.6956	1.5091	1.4937	1.8484
9		2.6825	.6413	2.4417	1.576	2.0119	2.2043
10	.7468	.6468	.7023	1.442		2.3205	2.3703
11	.6468	.7095		2.7349		2.9492	2.7161
12	.7577	.7392		2.9007		2.9492	2.7515
13	.8215	.7842		2.7349	1.587	2.7854	2.556
14	.8402	.679		2.6852	2.13	2.7362	1.7604
15	.8871	.4066	.5914	2.7846	2.6216		2.4413
16	.961	.5975	.5544	.2984	.4915	.4973	.2926
17	.924	.7023	.6283	.3113	.407	.4915	.499
18	.8962	.6722	.5544	.3647	.4409	.6413	.5975
19	.8029	.6602	.5914	.4748	.4854	.6413	.7545
20	.7468	.6722	.6283	.3258	.4481	.6653	.8775
21	.6535	.6979	1.6632	.4334	.5121	.6348	.8402
22	.5975	.6099	1.6632	.5228	.5975	.5788	.8029
23	1.2574	.6348	1.7002	.5175	.6722	.5975	.8676
24	.5975	1.1736	1.2037	1.7556	.4108	.2469	.5975
Max	1.2574	2.9504	2.0778	2.9007	2.6216	2.9492	2.7515
Min	.5975	.4066	.4805	.2984	.407	.2469	.2926
Avg	.7700	1.1701	1.1220	1.5633	.9480	1.1854	1.2658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7045	1.7604	1.829	2.1795	.9614	.5967	.6882
2	.7449	1.9595	1.9997	2.4143	.9831	.5636	.7293
3	.7701	2.4413	2.1506	2.4981	.9831	.5571	.7209
4	.7682	2.5606	2.3045	2.7664	1.0486	.7293	.8951
5	.7935	2.8018	2.5263	2.7854	1.1469	.7537	.9831
6	.7935	2.8664	1.9925	3.0639	1.1797	.7865	1.0486
7	.852	3.1327	.6478	.6874	1.2125	.9282	1.1934
8	.9069		.4801	2.5819	2.0454	1.8233	2.1125
9	.7842	2.5101	.6226	3.0498	2.2211	2.1956	2.6189
10	.7116	.4877	.8421	3.1161		2.4863	3.0476
11	.6964		.7956	3.0498		3.0967	1.3565
12	.6722	.3479	.7865	3.0639		2.9721	2.1628
13	.7611	.3725	.7625	3.0148	1.5746	2.9492	2.2611
14	.6325	.4424	.8288	3.0167	2.2672	3.0011	2.4352
15	.5921	.4641	.852	2.9492	3.0148	2.7183	3.0769
16	.6154	.7537	.9667	.663		.6554	.3563
17	.6401	.8583	.9503	.6962		.663	.4752
18	.7287	.8383	.9282	.6882	1.004	.7209	.6154
19	.6882	.7865	.8848	.6554	.9831	.8122	.7537
20	.639	.6962	.9282	.6718	.6802	.8848	.9503
21	.5668	.6706	1.8233	.8192	.6802	.7625	.8029
22	.5079	.6316	1.8233	.8951	.7865	.6478	.7773
23	1.3283	.6226	1.8351	.9175	.6226	.639	.8029
24	.6962	1.4864	1.656	1.8842	.9282	.6226	.6226
Max	1.3283	3.1327	2.5263	3.1161	3.0148	3.0967	3.0769
Min	.5079	.3479	.4801	.6554	.6226	.5571	.3563
Avg	.7331	1.3405	1.3007	2.0053	1.2802	1.3569	1.3119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.128	.0747	.0497	.0497	.0549	.0549
2	.0739	.1109	.0566	.0492	.0328	.0732	.0554
3	.0566	.0934	.056	.0497	.0332	.0905	.0732
4	.0754	.1294	.0943	.0819	.0655	.0905	.0914
5	.112	.1463	.112	.0995	.0829	.1267	.0924
6	.1509	.1509	.132	.1326	.1326	.181	.1017
7	.1109	.1109	.1109	.1492	.1326	.1448	.1147
8	.0905		.0724	.1341	.1017	.128	.0857
9	.1029	.0686	.0732	.116	.0829	.128	.0701
10	.0716	.0819	.0543	.0829		.1109	.0693
11	.0554	.0663	.0537	.0819		.1097	.0848
12	.0366	.0671	.0724	.0655		.128	.0686
13	.0503	.0503	.0366	.0663	.0678	.0914	.0537
14	.0339	.0701	.0366	.0497	.0693	.0732	.0532
15	.0739	.0537	.0732	.0663	.0867	.0914	.0339
16	.0543	.061	.0914	.0312	.0867	.0732	.0347
17	.104	.08	.1109	.0655	.0867	.0732	.0686
18	.1107	.0671	.1294		.1214	.0914	.0895
19	.0983	.0686	.1646	.0819	.1387	.128	.1052
20	.1294	.056	.1463	.0492	.1214	.1097	.1387
21	.112	.0566	.128	.0655	.0886	.128	.1132
22	.0943	.0747	.0995	.0663	.124	.0924	.1086
23	.0754	.0566	.0819	.0497	.0732	.0739	.1097
24	.1109	.1086	.0754	.0655	.0332	.0732	.0732
Max	.1509	.1509	.1646	.1492	.1387	.181	.1387
Min	.0339	.0503	.0366	.0312	.0328	.0549	.0339
Avg	.0857	.0851	.0890	.0761	.0863	.1027	.0810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.2629	.2629	.2743	1.086	1.3108	1.2269
2	.6268	.2601	.2658	.2743	1.0517	1.3108	1.2403
3	.7164	.2601	.2686	.2715	1.0631	1.3108	1.2269
4	.7888	.3121	.3292	.3258	1.267	1.6575	1.2483
5	.9412	.3121	.3582	.4525	1.6651	1.989	1.3176
6	1.7193	.3429	.631	.6173	2.4272	2.4863	2.774
7	1.9845	.3658	.7087	.7164	.7602	.3715	.7316
8	1.7833	.3721	.9145	.3506	.5316	.4298	.4961
9	1.5089	.6783	1.3112	.3582	.3898	.3582	.3898
10	1.6766	1.989	1.7295	.362	.3224	.2835	.4108
11	1.6575	1.8842	2.1195	.3292	.3224	.2534	.3696
12	1.6575	1.8564	2.1795	.2896	.3292	.2218	.3658
13	1.0174	1.8023	2.2177	.2957	.3395	.2172	.3658
14	.8478	1.6644	2.2634	.3018	.3292	.1791	
15	1.0526	1.7204	2.2634	.2218	.2926	.2263	
16	1.3108	1.6518	.3018	.2241	.2241	.2195	
17	.4024	.2054	.3582	.2561	.2218	.2033	
18	.4066	.2686	.462	.3326	.2218	.1848	
19	.4024	.439	.3658	.4572	.4108	.2926	
20	.4024	.462	.3658	.5544	.4668	.4961	.3801
21	.362	.4024	.4382	1.1462	1.0517	1.2757	.543
22	.3544	.3582	.3086	1.2971	1.2146	1.5257	1.1888
23	.3898	.3189	.2172	1.267	1.2717	1.4022	1.4937
24	.6401	.2686	.3224	.2743	1.267	1.3108	1.2269
Max	1.9845	1.989	2.2634	1.2971	2.4272	2.4863	2.774
Min	.3544	.2054	.2172	.2218	.2218	.1791	.3658
Avg	.9701	.7691	.8735	.4688	.7720	.8132	.9442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.1094	.1829	.2134	.032	.0324	.0316
2	.0312	.1619	.1875	.2134	.0316	.0324	.032
3	.032	.1619	.2187	.2134	.0316	.0324	.032
4	.0486	.2343	.2372	.2812	.032	.0486	.0486
5	.0995	.25	.3201	.3201	.064	.0492	.0655
6	.1638	.4096	.3841	.4001	.0983	.0819	.1311
7	.1311	.5243	.1718	.1406	.1311	.0972	.1311
8	.081	.3395	.0926	.3125	.1875	.1783	.2214
9	.08	.0457	.0648	.3858	.2743	.3201	.3395
10	.081	.0469	.0316	.3858	.3612	.4001	.3658
11	.0324	.0474	.0316	.381	.3763	.3906	.3395
12	.0332	.0469	.0316	.301	.381	.3292	.3437
13	.032	.0309	.0305	.301	.381	.3658	.3086
14	.032	.0305	.0324	.3311	.3858	.3704	.3353
15	.0312	.0305	.0324	.3353	.3858	.4064	.3567
16	.0486	.0309	.0312	.0301		.0305	.0255
17	.0633	.0328	.0286	.0312		.0309	.0293
18	.0791	.048	.029	.0316		.032	.0293
19	.096	.0648	.0328	.048	.0463	.0633	.0316
20	.096	.081	.0492	.0648	.064	.0972	.048
21	.081	.064	.1898	.0655	.0486	.0732	.048
22	.0648	.064	.1829	.0486	.048	.0474	.0486
23	.0762	.1311	.1783	.032	.0316	.0474	.0324
24	.032	.1094	.2107	.2134	.032	.032	.0316
Max	.1638	.5243	.3841	.4001	.3858	.4064	.3658
Min	.0312	.0305	.0286	.0301	.0316	.0305	.0255
Avg	.0657	.1290	.1243	.2117	.1630	.1495	.1419



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1852	.0486	.0316	.0486	.2343	.3572	.3475
2	.1875	.0486	.0316	.0492	.2343	.362	.3521
3	.2187	.0492	.0312	.0492	.2372	.362	.3521
4	.2343	.0819	.0633	.0655	.3163	.5201	.3429
5	.3086	.0983	.096	.1638	.4687	.8383	.3567
6	.7186	.1475	.2622	.1966	.9962	.9488	.8642
7	.6321	.1475	.2105	.1943	.2622	.1475	.1619
8	.5647	.0983	.2214	.1638	.1638	.1457	.0983
9	.4858	.3086	.3121	.0486	.1265	.0819	.0983
10	.4287	.4512	.4988	.0486	.1134	.0492	.0648
11	.3525	.4512	.5135	.0469	.0486	.0312	.064
12	.2782	.4572	.5868	.0316	.048	.0267	.032
13	.2705	.4572		.0474	.0474	.0297	.032
14	.3246	.439	.3572	.064	.0457	.0316	.0312
15	.3572	.5001	.5001	.0819	.0452	.0648	.0293
16	.4054	.5281	.0457	.0625	.0625	.0474	.0255
17	.0617		.0457	.0633	.0625	.064	.0469
18	.0972		.0781	.08	.0625	.0983	.0633
19	.1311	.1629	.081	.1265	.1457	.112	.1475
20	.0819	.1463	.0819	.1966	.1457	.1638	.1457
21	.0469	.1109	.0995	.4515	.4458	.4515	.4374
22	.0469	.0617	.0492	.4108	.3572	.4401	.4268
23	.0469		.0452	.3763	.2801	.3572	.2782
24	.1829	.0486	.0316	.0486	.3048	.3572	.362
Max	.7186	.5281	.5868	.4515	.9962	.9488	.8642
Min	.0469	.0486	.0312	.0316	.0452	.0267	.0255
Avg	.2770	.2306	.1858	.1298	.2189	.2537	.2150

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1109	.1132	.0943	.112	.1132	.112
2	.0934	.1109	.112	.0943	.112	.1132	.1109
3	.0943	.1097	.1097	.0943	.1109	.1132	.112
4	.132	.1463	.1463	.1132	.1463	.1509	.1478
5	.2263	.1829	.2241	.1509	.168	.2195	.1886
6	.3772	.2218	.3395	.2987	.415	.3292	.3395
7	.3018	.1848	.2829	.2195	.3395	.2926	.3395
8	.2641	.1646	.1867	.1829	.2829	.2195	.2263
9	.2218	.1463	.1848	.1463	.1867	.1829	.132
10	.1848	.0914	.1109	.1097	.112	.1463	.1509
11	.1097	.0914	.0924	.0914		.1097	.1097
12	.0914	.0732	.0554	.0732	.0914	.112	.1097
13	.0914	.0914	.0739	.0732	.1097	.1097	.1097
14	.1097	.0934	.1097	.0739	.1097	.1132	.1097
15	.1097	.1097	.1097	.1097	.1097	.1086	.1097
16	.1097	.1109	.1097	.1052		.0754	.0549
17	.1433	.1478	.1463	.1433		.1463	.0914
18	.2012	.1463	.1646	.1907		.1753	.1463
19	.2534	.2149	.2743	.2507	.2218	.2561	.2195
20	.1463	.2561	.2743	.2957	.2957	.3258	.2195
21	.1097	.2012	.2195	.2587	.1829	.2241	.1463
22	.1097	.1867	.1463	.1509	.1463	.1867	.112
23	.1097		.0914	.1132		.1494	.1132
24	.0943	.1109	.1132	.0943	.1132	.1132	.112
Max	.3772	.2561	.3395	.2987	.415	.3292	.3395
Min	.0914	.0732	.0554	.0732	.0914	.0754	.0549
Avg	.1574	.1436	.1580	.1470	.1771	.1703	.1510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPEETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0189	.0175	.0189	.0187	.0189	.0187
2	.0187	.0189	.0179	.0189	.0183	.0189	.0187
3	.0183	.0189	.0183	.0189	.0185	.0189	.0185
4	.0187	.0189	.0187	.0189	.0187	.0189	.0187
5	.0189	.0185	.0183	.0189	.0183	.0181	.0183
6	.0185	.0183	.0175	.0377	.0181	.0354	.0354
7	.0354	.0377	.0377		.0185	.0362	.0377
8	.0343	.0566	.0183	.0358	.037	.0377	.0347
9	.0175	.0526	.0181	.0366	.0373	.0181	.0187
10	.0181	.0366	.0347	.0373	.0377	.0362	.0189
11	.0183	.0366	.0312	.0554	.0358	.037	.0183
12	.0183	.0739	.032	.0732	.0358	.0549	.0366
13	.0183	.0732	.056	.0554	.0358	.0554	.0362
14	.0183	.0724	.056	.0566	.0362	.0732	.0362
15	.0358	.0732	.0362	.0754	.0358	.0526	.0181
16	.0189	.0754	.0358	.0747	.0532	.0709	.056
17	.0183	.0754	.0537	.0739	.0532	.0724	.0532
18	.0185		.0532	.0732	.0532	.0732	.0732
19	.0183	.0693	.0373	.0554	.0724	.0732	.0732
20	.0366	.0732	.0373	.0366	.0716	.0905	.037
21	.0377	.0362	.0377	.0354	.0362	.0693	.0373
22	.0377	.0373	.0377	.0181	.0362	.0183	.0189
23	.0377		.0377	.0183	.0373		.0189
24	.0183	.0189	.0175	.0189	.0187	.0187	.0187
Max	.0377	.0754	.056	.0754	.0724	.0905	.0732
Min	.0175	.0183	.0175	.0181	.0181	.0181	.0181
Avg	.0237	.0460	.0323	.0418	.0355	.0442	.0321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 207 / 11 KV JADAR BOBALAD AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.7373	.6773	1.3108	.2241	.2515	.2715
2	.2587	.9012	.703	1.3108	.2241	.2515	.2743
3	.2561	.9012	.759	1.3565	.2218	.2515	.2957
4	.2865	1.0526	.9602	1.6956	.2801	.2949	.3361
5	.4108	1.1336	1.2289	1.8652	.3658	.3277	.3696
6	.7468	1.9662	1.5546	2.0687	.7095	.4049	.7095
7	.7468	2.1464	.5853	.5087	.7095	.5668	.6653
8	.6348	1.9433	.5121	1.2955	.8642	.9717	1.1843
9	.543	.2591	.4024	1.6194	1.2803	1.6194	1.6842
10	.4049	.2591	.4435	1.6194	1.6842	1.6194	1.9433
11	.3239	.3326	.4481	1.6194	1.7004	1.6604	1.6194
12	.2429	.3658	.4481	1.6712	1.7004	1.7814	1.6194
13	.2429		.3239	1.5384	1.5223	1.4403	.9717
14	.2915	.3582	.3239	1.3748	1.6194	1.1702	.9717
15	.3563	.3734	.3239	1.5223	1.6194	1.1584	.8583
16	.2534	.4066	.3239	.3224		.3361	.2267
17	.4805	.2926	.3239	.3258		.4066	.2915
18	.4572		.5668	.2865		.4755	.4096
19	.5601	.5228	.4858	.462	.3887	.5121	.4096
20	.3239	.5544	.4858	.5601	.3887	.5544	.4049
21	.2915	.4668	.6802	.4108	.3887	.4854	.2915
22	.2591	.3292	.8745	.3018	.3239	.4344	.2591
23	.5182		.9717	.2801	.2429	.3658	.2591
24	.2241	.7373	.6661	1.3108	.2241	.2515	.2896
Max	.7468	2.1464	1.5546	2.0687	1.7004	1.7814	1.9433
Min	.2218	.2591	.3239	.2801	.2218	.2515	.2267
Avg	.3890	.7638	.6280	1.1099	.7944	.7330	.6923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.1638	.1638	.1638	.6554	.9831	.9831
2	.9831	.1638	.1638	.1638	.6554	.9831	.9831
3	1.1317	.1638	.1638	.1638	.6554	.9831	.9831
4	.9831	.1638	.1638	.1638	.8192	1.1469	.9831
5	1.3108	.2458	.1638	.1638	1.1469	1.4746	1.4746
6	1.6385	.2458	.2458	.1638	1.3108	1.6385	1.6385
7	1.7204	.2458	.2458	.1638	.1638	.1638	.1638
8	1.6385	.1638	.6554	.1638	.1638	.1638	.1638
9	1.4746	.6554	1.3108	.1638	.0819	.1638	.1638
10	1.4746	1.6385	1.6385	.0819	.0819	.1638	.1638
11	1.4746	1.8842	1.9662	.0819	.0819	.1638	.0819
12	1.4746	1.8842	1.9662	.0819	.0819	.1638	.0819
13	1.5565	1.8023	1.9662	.0819	.0819	.1638	.0819
14	1.6385	1.8023	1.9662	.0819	.0819	.0819	
15	1.6385	1.8023	1.9662	.0819	.0819	.0819	
16	1.6385	1.8023	.3277	.0819	.0819	.0819	.0819
17	.1638	.1638	.1638	.0819	.1638	.0819	.0819
18	.1638	.1638	.0819	.0819	.1638	.0819	.0819
19	.1638	.1638	.0819	.1638	.1886	.1638	.1638
20	.1638	.1638	.1638	.1638	.1638	.1886	.1638
21	.2458	.2458	.1638	.3277	.6554	.9831	.4915
22	.1638	.1638	.1638	.6554	.9831	.9831	.7373
23	.1638	.1638	.1638	.6554	.9831	.9831	.8192
24	.8192	.1638	.1638	.1638	.6554	.9831	.9831
Max	1.7204	1.8842	1.9662	.6554	1.3108	1.6385	1.6385
Min	.1638	.1638	.0819	.0819	.0819	.0819	.0819
Avg	1.0336	.6758	.6759	.1809	.4243	.5438	.5250

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.4915	.3277	.4915	.0819	.0819	.0819
2	.0819	.4915	.3277	.4915	.0819	.0819	.0819
3	.0819	.4915	.3277	.4915	.0819		.0819
4	.0819	.4915	.4915	.4915	.0819	.0819	.0819
5	.0819	.6554	.4915	.6554	.0819	.0819	.0819
6	.1638	.9831	.8192	.1638	.1638	.1638	.1638
7	.1638	1.3108	.1638		.1638	.1638	.1638
8		1.3108	.1638	.6554	.4915	.4915	.4915
9	.0819	.0819	.1638	1.3108	.8192	.9831	.8192
10	.0819	.1638	.0819	1.1469	.9831	1.1469	.9831
11	.0819	.0819	.0819	1.1469	.9831	1.1469	1.1469
12	.0819	.0819	.0819	1.1469	1.1469	.9831	1.1469
13	.0819	.0819	.0819	.9831	1.1469	.9831	1.1469
14	.0819	.0819	.0819	.9831	1.0174	.9831	1.1469
15	.0819	.0819	.0819	.9831		.9831	1.1469
16	.0819	.0819	.0819	.1638		.0819	.0819
17	.0819	.0819	.0819	.1638	.0819		.0819
18	.0819	.0819	.0819	.1638	.0819	.0819	.0819
19	.0819	.1638	.0819	.1638	.0819	.0819	.1638
20	.1638	.1638	.0819	.1638	.1638	.1638	.1638
21	.1638	.1638	.3277	.1638	.1638	.1638	.1638
22	.0819	.1638	.3277	.1638	.0819	.0819	.1638
23	.3277	.1638	.4915	.0819	.0819	.0819	.0819
24	.0819	.4915	.3277	.4915	.0819	.0819	.0819
Max	.3277	1.3108	.8192	1.3108	1.1469	1.1469	1.1469
Min	.0819	.0819	.0819	.0819	.0819	.0819	.0819
Avg	.1068	.3516	.2355	.5592	.3702	.4170	.4096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0754	.0754	.0943	.0566	.0943	.0754	.0754
7	.0754	.0754	.0943	.0566	.0943	1.2071	.0566
8	.0754	.0566	.0943	.0943	.0943	.0754	.0754
9	.0754	.0566	.0754	.0943	.0943	.0566	.0566
10	.0566	.0566	.0566	.0754	.0566	.0566	.0566
11	.0566	.0566	.0566	.0754	.0566	.0566	.0566
12	.0566	.0566	.0566	.0566	.0566	.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.0566	.0566	.0566	.0566	.0566
15	.0566	.0566	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566	.0566	.0566	.0566	.0566
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0566	.0943	.0566	.0566	.0566	.0566	.0566
19	.0943	.1132	.0566	.0943	.0943	.0943	.1132
20	.1132	.1132	.1509	.0943	.0943	.0943	.1132
21	.1132	.1132	.0943	.0943	.0943	.0754	.1132
22	.0754	.0754	.0943	.0943	.0754	.0754	.1132
23	.0754	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.1132	.1132	.1509	.0943	.0943	1.2071	.1132
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0676	.0676	.0692	.0676	.0684	.1108	.0676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.5087	.6783	.6783	.0848	.0848	.0848
2	.0848	.5087	.6783	.6783	.1696	.0848	.0848
3	.0848	.5087	.6783	.6783	.1696	.0848	.0848
4	.0848	.5087	.6783	.8478	.1696	.0678	.0848
5	.1696	1.1869	1.0174	1.0174	.1696	.1696	.0848
6	.1696	1.1869	.6783	1.1869	.1696	.1696	.1696
7	.1696	.5087	.1638	.1696	.1696	.1696	.1696
8	.0848	.8478	.1696	.6783	.6783	.6783	.8478
9	.0848		.1696	1.3565	1.2717	1.3565	1.2717
10	.0848	.0848	.0848	1.5261	1.3565	1.6956	1.3565
11	.0848	.0848	.0848	1.6956	1.6956	1.6956	1.0174
12	.0848		.0848	1.6956	1.8652	1.6956	1.0174
13	.0848	.0848	.0848	1.6956	1.8652	1.6956	1.1869
14		.0848	.0848	1.6956	1.7804	1.6956	1.3565
15	.0848	.0848	.0848	1.8652	1.8652	1.6956	1.6956
16	.0848	.0848	.0848	.1696	.0848	.0848	.0848
17	.0848	.0848	.0848	.1696	.0848	.0848	.0848
18	.0848	.0848	.0848	.1696	.0848		.0848
19	.0848	.1696	.1696	.1696	.1696	.1696	.1696
20	.1696	.1696	.1696	.1696	.1696	.1696	.1696
21	.1696	.1696	.6783	.1696	.1696	.1696	.1696
22	.1696	.1696	.6783	.1696	.0848	.1696	.1696
23	.5087	.3391	.6783	.1696	.0848	.0848	.0848
24	.0848	.5087	.5935	.6783	.0848	.0848	.0848
Max	.5087	1.1869	1.0174	1.8652	1.8652	1.6956	1.6956
Min	.0848	.0848	.0848	.1696	.0848	.0678	.0848
Avg	.1254	.3623	.3601	.8125	.6041	.6112	.4840



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0943	.0566	.0943	.0566	.0566
7	.0566	.0566	.0943	.0566	.0943	.0566	.0566
8	.0566	.0566	.0943	.0943	.0943	.0566	.0566
9	.0566	.0566	.0754	.0943	.0943	.0754	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566	.0566	.0566	.0377	.0566	.0566	.0566
13	.0566	.0566	.0566	.0377	.0377	.0566	.0566
14	.0566	.0566	.0566	.0377	.0377	.0377	
15	.0377	.0566	.0566	.0377	.0377	.0377	.0566
16	.0377	.0566	.0566	.0566	.0566	.0377	.0566
17	.0566	.0566	.0566	.0566	.0377	.0377	.0566
18	.0566	.0943	.0566	.0566	.0566	.0566	.0566
19	.0943	.0943	.0566	.0943	.0754	.0754	.1132
20	.0943	.0943	.0943	.0943	.0943	.0754	.1132
21	.0754	.0943	.0943	.0943	.0754	.0754	.1132
22	.0566	.0754	.0943	.0943	.0566	.0566	.1132
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.0943	.0754	.1132
Min	.0377	.0566	.0566	.0377	.0377	.0377	.0566
Avg	.0590	.0637	.0668	.0629	.0629	.0566	.0664

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0943	.0754	.0943	.0754	.0754	.0754	.0754
4	.0754	.0754	.0943	.0754	.0754	.0754	.0754
5	.0943	.0943	.0943	.0754	.0754	.0754	.0754
6	.0943	.1132	.0943	.0943	.0943	.1132	.0943
7	.0943	.1132	.0943	.0943	.0943	.1132	.0943
8	.0943	.0754	.0943	.0943	.132	.0754	.0943
9	.0943	.0754	.0943	.0943	.132	.0754	.0943
10	.0943	.0754	.0754	.0754	.0754	.0754	.0754
11	.0943	.0754	.0754	.0754	.0754	.0754	.0754
12	.0754	.0754	.0754	.0754	.0754	.0754	.0754
13	.0754	.0566	.0754	.0754	.0566	.0754	.0754
14	.0754	.0566	.0754	.0754	.0566	.0566	.0754
15	.0754	.0754	.0754	.0754	.0566	.0566	.0754
16	.0566	.0754	.0754	.0754	.0754	.0566	.0754
17	.0566	.0943	.0754	.0943	.0754	.0754	.0754
18	.0943	.0943	.0943	.0943	.0754	.0754	.0754
19	.132	.1509	.0943	.1509	.132	.132	.1509
20	.1509	.1509	.1509	.1509	.132	.132	.1509
21	.1509	.1509	.1509	.1509	.0943	.132	.1509
22	.1132	.0943	.0943	.0943	.0754	.0943	.1509
23	.0943	.0754	.0943	.0754	.0754	.0943	.0754
24	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Max	.1509	.1509	.1509	.1509	.132	.132	.1509
Min	.0566	.0566	.0754	.0754	.0566	.0566	.0754
Avg	.0919	.0896	.0904	.0904	.0848	.0849	.0911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	.3391	.3391	.3391	1.6956	1.5261	1.8652
2	1.0174	.3391	.3391	.3391	1.6956	1.5261	1.8652
3	1.0174	.3391	.3391	.3391	1.6956	1.5261	1.8652
4	1.0174	.3391	.3391	.3391	1.8652	2.0348	1.8652
5	1.3565	.3391	.3391	.3391	2.0348	2.2043	2.0348
6	1.6108	.4239	.4239	.3391	2.5434	2.3739	2.2043
7	1.6108	.4239	.4239	.3391	.4239	.3391	.3391
8	1.7804	.4239	.8478	.3391	.4239	.5087	.5087
9		.6783	1.3565	.3391	.3391	.5087	.5087
10	.6783	1.6956	2.3739	.3391	.3391		.4239
11	1.8652	2.2043	2.713	.3391	.1696		.4239
12	1.8652	2.2043	2.713	.3391	.3391	.3391	.4239
13	1.95	2.3739	2.713	.3391	.3391	.3391	.3391
14	2.0348	2.3739	2.713	.3391	.3391	.3391	.3391
15	2.0348	2.3739	2.713	.3391	.3391	.3391	.3391
16	2.0348	2.2043	.3391	.3391	.3391	.3391	.4239
17	.3391	.2543	.3391	.4239	.4239	.4239	.4239
18	.3391	.4239	.3391	.4239	.5087	.4239	
19	.3391	.4239	.3391	.4239	.5087	.4239	.5087
20	.4239	.4239	.3391	.4239	.5087	.5087	.5087
21	.4239	.4239	.3391	1.0174	.6783	1.3565	.8478
22	.4239	.4239	.3391	1.6956	1.5261	2.0348	1.6956
23	.3391	.3391	.3391	1.6956	1.5261	2.0348	1.6956
24	.8478	.3391	.3391	.3391	1.6956	1.5261	1.8652
Max	2.0348	2.3739	2.713	1.6956	2.5434	2.3739	2.2043
Min	.3391	.2543	.3391	.3391	.1696	.3391	.3391
Avg	1.1464	.9220	.9891	.4945	.9291	1.0444	1.0137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	1.0174	.8478	.8478	.1696	.1696	.1696
2	.1696	1.0174	1.0174	.8478	.1696	.1696	.1696
3	.1696	1.0174	1.0174	.8478	.1696	.1696	.1696
4	.1696	1.0174	1.0174	.8478	.1696	.1696	.1696
5	.1696	1.5261	1.3565	1.1869	.1696	.1696	.1696
6	.1696	1.8652	1.6956	1.5261	.2543	.2543	.1696
7	.1696	1.95	.2543	.3391	.2543	.2543	.3391
8	.1696	2.0348	.2543	.8478	.6783	.6783	1.3565
9	.1696	.1696	.2543	1.5261	1.1869	1.6108	1.6956
10	.1696	.1696	.1696	1.8652	1.6956	1.8652	2.0348
11	.1696	.1696	.1696	2.0348	1.6956	2.0348	1.8652
12	.1696	.1696	.1696	1.8652	1.8652	2.0348	1.8652
13	.1696	.0848	.1696	1.8652	1.8652	1.6956	1.6956
14	.1696	.1696	.1696	1.8652	1.6956	1.6956	1.6956
15	.1696	.1696	.1696	1.8652	1.6956	1.6956	1.7804
16	.1696	.1696	.2543	.1696	.1696	.1696	.0848
17	.1696	.1696	.2543	.1696	.1696	.1696	.0848
18	.1696	.1696	.2543	.1696	.1696	.1696	.0848
19	.1696	.1696	.2543	.1696	.1696	.1696	.1696
20	.2543	.2543	.1696	.1696	.1696	.1696	.1696
21	.1696	.2543	.6783	.1696	.1696	.2543	.1696
22	.1696	.1696	.6783	.1696	.1696	.1696	.1696
23	.5087	.3391	.8478	.1696	.1696	.1696	.1696
24	.1696	1.0174	.8478	.8478	.1696	.1696	.1696
Max	.5087	2.0348	1.6956	2.0348	1.8652	2.0348	2.0348
Min	.1696	.0848	.1696	.1696	.1696	.1696	.0848
Avg	.1873	.6359	.5405	.9326	.6359	.6783	.6924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	1.21	1.3748	1.3426	.2883	.2683	.2883
2	.3149	1.2407	1.3592	1.3916	.2713	.2515	.2713
3	.3315	1.3748	1.3923	1.4251	.2683	.2515	.2683
4	.3481	1.4586	1.4918	1.4255	.2683	.2683	.2012
5	.4144	1.5249	1.7736	1.5249	.3018	.3018	.2347
6	.4144	2.1628	2.13	2.0481	.4475	.431	.3978
7	.5898	2.8182	.4588	.3353	.5365	.4641	.5596
8	.431	2.6216	.4527	1.4754	1.2431	1.6575	1.8107
9	.431	.218	.4191	2.0719	1.7404	2.13	2.2131
10	.4024	.3018	.3647	2.2542	2.1628	2.3594	2.5095
11	.3353	.3391	.3812	2.2283	2.13	2.343	2.4531
12	.3521	.2035	.3647	2.1628	2.1376	2.0972	2.1216
13	.3647	.3353	.3688	2.0481	2.17	1.9227	2.1216
14	.3812	.3521	.3856		1.1469	1.9227	1.3763
15	.2984	.3688	.3353	1.7901	1.9062	1.989	2.13
16	.3018	.3978	.3326	.2054	.1658	.2033	.2587
17	.3658	.4144	.3881	.3326	.2486	.2587	.2587
18	.3841	.3978	.2957	.3511	.3521	.2614	.3326
19	.4805	.4359	.3658	.4066	.3768	.3326	.3696
20	.4755	.4527	.4435	.4805	.3978	.4435	.4572
21	.439	.4191	1.0974	.407	.3647	.373	.3561
22	.4024	.3856	1.3413	.3222	.2652	.3391	.285
23	.8916	.8718	1.3413	.3018	.2652	.3018	.2683
24	.3315	1.2071	1.3413	1.326	.285	.2652	.285
Max	.8916	2.8182	2.13	2.2542	2.17	2.3594	2.5095
Min	.2984	.2035	.2957	.2054	.1658	.2033	.2012
Avg	.4089	.8964	.8333	1.2025	.8225	.8932	.9095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	.4207	.4294	.4075	1.6956	1.8442	1.8442
2	1.0456	.4207	.4066	.3856	1.7126	1.8564	1.8107
3	1.1203	.4207	.4108	.3856	1.7101	1.8399	1.6907
4	1.2136	.4334	.4481	.4207	1.7269	1.9062	1.5415
5	1.3443	.5028	.5281	.4733	1.9062	2.2939	1.8067
6	1.5947	.6588	.679		2.536	2.8182	2.5069
7	1.9113	.6762	.7468	.7455	.6783	.7122	.6836
8	1.8275	.631	1.0242	.7537	.5959	.7537	.6836
9	1.7101	.8886	1.4632	.6135	.5434	.6447	.6733
10	1.2431	1.757	2.2539	.3856	.3681	.6036	.6379
11	.663	2.0553	2.2043	.4508	.4854	.5487	.6135
12	1.1271	1.2452	2.2298	.3641	.3988	.6154	.5258
13	.5868	2.1792	2.1795	.4508	.4334	.4706	.4908
14	1.5424	2.13	2.2466	.5258	.2865	.5373	.4252
15	1.7072	2.0405	2.3868	.4908	.4024	.5014	.4607
16	1.8564	2.1214	.4572	.5304	.4938	.6219	.5249
17	.2195	.2543	.462	.5121	.5729	.6401	.6219
18	.4435	.4119	.462	.5544	.5853	.695	.6036
19	.6099	.5487	.5304	.6099	.6516	.6653	.6219
20	.6219	.567	.695	.6468	.5548	.7577	.6653
21	.4938	.5175	.5914	1.2003	1.6278	1.6278	1.6108
22	.4938	.4854	.5249	1.6278	2.0348	1.9839	1.1233
23	.4207	.4668	.4656	1.6933	1.9784	2.0119	1.3748
24	.9522	.4031	.4294	.4075	1.6933	1.861	1.8778
Max	1.9113	2.1792	2.3868	1.6933	2.536	2.8182	2.5069
Min	.2195	.2543	.4066	.3641	.2865	.4706	.4252
Avg	1.0748	.9265	1.0106	.6363	1.0697	1.2005	1.0591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0934	.0754	.0747	.0754	.0943
2	.0754	.0754	.0934	.0754	.0754	.0754	.0754
3	.0754	.0747	.0934	.0747	.0754	.0747	.0747
4	.1132	.0934	.1132	.0934	.0754	.0934	.0747
5	.1509	.112	.1509	.112	.0934	.132	.0934
6	.2263	.1494	.2075	.1478	.1494	.2075	.1294
7	.1867	.1848	.1698	.1848	.1848	.1698	.2218
8	.1494	.1294	.168	.1478	.1663	.1307	.1848
9	.1307	.112	.1307	.0934	.1294	.0934	.1307
10	.1109	.0934	.1307	.0934	.0934	.0747	.1109
11	.0924	.0924	.1132	.0739	.0934	.0747	.0924
12	.0739	.0924	.0934	.0739	.0924	.0739	.0739
13	.0924	.1109	.0934	.0739	.0739	.0739	.0924
14	.0732	.0732	.0739	.0732	.0914	.0739	.0914
15	.0914	.0739	.0739	.0549	.0924	.0732	.0914
16	.0732	.0739	.0739	.0732	.0924	.0732	.0914
17	.1097	.0924	.0924		.0924	.0739	.0924
18	.1109	.112	.0934	.0554	.112	.0924	.1109
19	.1294	.1698	.1494	.1478	.1307	.168	.112
20	.168	.1698	.1494	.1867	.1509	.1494	.1867
21	.1494	.1509	.1494	.168	.1509	.112	.168
22	.112	.1132	.112	.1132	.1132	.112	.1132
23	.1132	.0934	.0943	.0943	.0943	.0943	.0943
24	.0943	.0754	.0943	.0754	.0754	.0754	.0943
Max	.2263	.1848	.2075	.1867	.1848	.2075	.2218
Min	.0732	.0732	.0739	.0549	.0739	.0732	.0739
Avg	.1157	.1081	.1170	.1027	.1072	.1020	.1123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0373	.0566	.0566	.0566	.0566
2	.0566	.0566	.0377	.0377	.0566	.056	.0377
3	.0566	.0566	.0377	.0566	.0566	.056	.0373
4	.0566	.0566	.0566	.056	.056	.056	.0373
5	.0754	.056	.0747	.0747	.056	.0754	.056
6	.1494	.1307	.0747	.112	.1294	.1494	.0934
7	.1307	.112	.112	.1109	.0924	.132	.1294
8	.0747	.1109	.0554	.0924	.0924	.0934	.0924
9	.0934	.0554	.037	.0924	.056	.056	.0554
10	.0739	.0554	.056	.056	.056	.056	.0554
11	.0554	.0373	.0747	.056	.037	.0373	.0366
12	.0554	.0187	.037	.037	.037	.056	.0366
13	.0549	.0185	.037	.037		.037	.037
14	.0366	.0185	.0554	.056	.0185	.037	.037
15	.0549	.0183	.0366	.037	.0366	.037	.037
16	.0366	.0366	.0549	.037	.0366	.0554	.0554
17	.0554	.0373	.0549	.037	.037	.0549	.0554
18	.0739	.0373	.0739	.0747	.0739	.0549	
19	.0739	.0377	.0924	.056	.0747	.0924	
20	.0924		.112	.112	.0934	.1109	.056
21	.0747	.0566	.0934	.112	.0934	.0747	1.587
22	.0747	.0377	.0747	.0747	.0754	.0747	.0566
23	.056	.0373	.0566	.056	.0566	.056	.0377
24	.0566	.0566	.0373	.0566	.0566	.0566	.0566
Max	.1494	.1307	.112	.112	.1294	.1494	1.587
Min	.0366	.0183	.0366	.037	.0185	.037	.0366
Avg	.0698	.0520	.0612	.0660	.0624	.0676	.1245



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.4287	.3429	.4287	1.4413	1.3904	1.3226
2	.9602	.4287	.3258	.4409	1.4582	1.3904	1.2717
3	.9945	.4239	.3258	.4409	1.4922	1.4243	1.2548
4	1.0288	.4578	.3429	.4409	1.5089	1.4243	1.2378
5	1.1145	.4578	.4115	.4578	1.5257	1.5424	1.2239
6	1.3889	.5087	.4458	.5256	1.7269	1.8442	1.291
7	1.6787	.57	.583	.703	.3052	.4024	.407
8	1.4413	.503	1.0174	.6344	.3772	.4359	.5426
9	1.5089	.8785	1.2209	.6104	.39	.5087	.5426
10	1.3245	1.4752	1.8652	.2572	.4578	.4917	.5365
11	1.4754	1.7072	1.933	.3258	.5658	.5426	.3018
12	1.6278	1.1603	1.9281	.3222	.5658	.5765	.373
13	1.5939	1.6741	2.0287	.5256		.503	.4748
14	1.576	1.2209	1.9616	.4409	.3561	.5533	.5365
15	1.6766	1.7974	1.8821	.4527	.5087	.4748	.4694
16	1.5592	1.757	.2218	.5487	.6104	.5256	.5853
17	.1109	.2543	.2033	.462	.6443	.6283	.5853
18	.3511	.39	.3658	.5729	.5935	.5729	.5729
19	.4572		.5487	.6653	.5596	.499	.5487
20	.4938		.499	.6036	.5256	.439	.4755
21	.4938	.2915	.4733	.8478	1.0059	1.1869	.9774
22	.462	.3086	.463	1.2378	1.3413	1.4243	1.2378
23	.4334	.3391	.4458	1.3056	1.3735	1.3226	1.1191
24	.9259	.4287	.3429	.4458	1.4243	1.3565	1.3735
Max	1.6787	1.7974	2.0287	1.3056	1.7269	1.8442	1.3735
Min	.1109	.2543	.2033	.2572	.3052	.4024	.3018
Avg	1.0682	.7937	.8408	.5707	.9025	.8942	.8026

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.9221	1.0442	1.094	.2515	.2486	.2347
2	.2155	.9614	1.0442	1.1271	.2652	.2321	.2321
3	.2321	.9945	1.0774	1.0774	.2652	.2321	.2321
4	.2321	1.0277	1.1603	.9945	.2652	.2486	.2486
5	.2652	1.0774	1.3426	1.0608	.2984	.2818	.2984
6	.3978	1.6057	1.5238	1.5402	.3149	.3441	.2984
7	.3441	1.9989	.3113	.3185	.3353	.3277	.4359
8	.4144	1.9334	.3149		.6539	1.1469	1.2574
9	.2984	.1677	.3481	1.5415	1.326	1.7004	1.7901
10	.218	.2347	.3647	1.2944	1.8233	1.9433	2.0553
11	.3018	.3149	.3441	1.6221	1.7695	2.0081	2.0153
12	.2652	.2818	.2949	1.8023	1.8461	1.9006	1.8187
13	.2652	.2486	.3441	1.7404		1.6712	1.8515
14	.2652	.1638	.3481	1.5912	1.0978	1.9334	1.7736
15	.2949	.1966	.3481	1.7604	1.8187	1.0111	1.8233
16	.2785	.2458	.2402	.168	.1802	.2378	.1829
17	.2587	.3149	.3142	.1848	.3315	.2561	.2195
18	.2957	.3647	.3511	.2402	.3149	.2743	.2587
19	.2957	.3812	.3734	.2218	.3149	.4066	.3734
20	.4207	.3812	.4854	.3547	.2984	.3881	.4854
21	.3475	.3812	.7209	.333	.3018	.285	.3052
22	.3475	.3353	1.0111	.2743	.2652	.2515	.3018
23	.4578	.5365	1.094	.2543	.2486	.2347	.285
24	.2155	.788	.9945	1.094	.2515	.2486	.2347
Max	.4578	1.9989	1.5238	1.8023	1.8461	2.0081	2.0553
Min	.2155	.1638	.2402	.168	.1802	.2321	.1829
Avg	.2976	.6608	.6582	.9430	.6451	.7422	.7922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 208 / 11 KV DHULKARWADI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.2804	.1753	.2454	1.2574	1.3003	1.2717
2	.9259	.2804	.1753	.2481	1.2574	1.3003	1.2717
3	.9431	.2774	.1928	.2481	1.2597	1.335	1.2574
4	1.0288	.2947	.208	.2629	1.2763	1.3717	1.2742
5	1.0631	.3121	.3121	.298	1.3094	1.4746	1.3413
6	1.3735	.4973	.3814	.3856	1.5402	1.8004	1.5581
7	1.6108	.5316	.5658	.5028	.3506	.4508	.4508
8	1.6598	.463	.7888	.5548	.4557	.5721	.4733
9	1.6598	.6104	1.1317	.5375	.4382	.5434	.4908
10	1.4251	1.4074	1.6118	.333	.4681	.5258	.4557
11	1.6108	1.5927	1.1361	.4382	.5028	.5895	.5258
12	1.543	1.0395	1.861	.4382	.5548	.5721	.4854
13	1.5261	1.6448	1.8778	.4207		.4161	.5375
14	1.5424	1.2039	1.8275	.3155	.333	.5258	.5375
15		1.5261	1.7901	.3155	.4207	.5083	.4382
16	1.6263	1.56	.4066	.4251	.5258	.591	.4525
17	.2012	.2401	.3511	.499	.4733	.5611	.5249
18	.4066	.3814	.4572	.567	.5258	.6516	
19	.3696	.5201	.5304	.5121	.5258	.6401	
20	.3696	.5258	.4251	.4207	.4508	.5487	.2378
21	.3475	.4031	.362	.8916	.9882	.9602	.9259
22	.3109	.3506	.2658	1.2209	1.3146	1.2003	1.17
23	.2804	.2103	.2454	1.2039	1.3176	1.3226	1.1065
24	.8573	.2804	.1753	.2454	1.2574	1.3032	1.2717
Max	1.6598	1.6448	1.8778	1.2209	1.5402	1.8004	1.5581
Min	.2012	.2103	.1753	.2454	.333	.4161	.2378
Avg	1.0249	.6847	.7189	.4804	.8175	.8777	.8209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0943	.0895	.0914	.0895	.0876	.0857
2	.0876	.0943	.1029	.0934	.0943	.0943	.0943
3	.0943	.0943	.1097	.0943	.0886	.0876	.0857
4	.0924	.1143	.1254	.1132	.1109	.0819	.1097
5	.0895	.1524	.1307	.132	.1448	.1006	.112
6	.1143	.1334	.1334	.1524	.2075	.1334	.1143
7	.132	.1334	.132	.1524	.1698	.1334	.1132
8	.132	.1334	.132	.1524	.1509	.132	.0943
9	.0934	.0943	.0943	.132	.1307	.1307	.0943
10	.0924	.0924	.0943	.0943	.1109	.0914	
11	.0934	.0914	.0943	.0905	.0914	.0905	.0953
12	.0924	.0914	.0943	.0905	.0924	.0914	.0943
13	.0914	.0876	.0943	.0895	.0934	.0924	.0934
14	.0914	.0895	.0943	.0905	.0934	.0924	.0934
15	.0943	.0895	.0943	.0905	.0934	.0914	.0934
16	.0934	.0876	.0914	.0867	.0895	.0934	.0886
17	.0876	.0876	.0905	.0867	.0886	.0934	.0857
18	.0886	.0886	.0924	.1029	.1075	.1463	.0848
19	.1267	.1417	.0876	.1052	.1227	.1433	.1006
20	.1267	.1372	.1417	.1075	.1097	.1029	.1029
21	.1463	.1463	.1663	.1029	.1494	.1132	.1478
22	.1132	.1402	.1086	.0914	.1227	.0857	.112
23	.0953	.0857	.1097	.0876	.0857	.0895	.0895
24	.0943	.0953	.0953	.0895	.0943	.0953	.0934
Max	.1463	.1524	.1663	.1524	.2075	.1463	.1478
Min	.0876	.0857	.0876	.0867	.0857	.0819	.0848
Avg	.1022	.1082	.1083	.1050	.1138	.1039	.0991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.12	.1562	.1134	.0934	.0876	.0934
2	.0943	.1509	.1966	.1311	.0953	.0943	.0953
3	.1132	.218	.3201	.1457	.0895	.0905	.0914
4	.0914	.2785	.3932	.1802	.1417	.0924	.0924
5	.112	.3481	.381	.3018	.1029	.1402	.0943
6	.1509	.4527	.4973	.4144	.1509	.1698	.1715
7	.1132	.4161	.1006	.132	.1097	.132	.1509
8	.0934	.4161	.0943	.2881	.1802	.1134	.2372
9	.0934	.0943	.0914	.3361	.3521	.4744	.3185
10	.0953	.0943	.0838	.421	.4531	.506	.3113
11	.0953	.0943	.0838	.583	.4268	.506	.1128
12	.0953	.0914	.0772	.5335	.4531	.4999	
13	.0943	.0924	.0791	.5268	.4214	.4843	
14	.0943	.0924	.081	.4666		.4784	
15	.0762	.0895	.0857	.4365	.2675	.4843	
16	.0914	.0914	.0876	.0934	.0934	.0886	
17	.0924	.0924	.0914	.0934	.0914	.0934	
18	.0943		.0934	.0914	.0876	.0934	.0924
19	.0943	.0934	.0934	.0886	.0934	.0914	.0934
20	.0943	.0857	.1097	.0895	.0924	.0934	.0934
21	.1132	.0943	.1492	.0934	.0953	.0953	.0953
22	.1132	.0924	.1006	.0876	.0914	.0895	.0914
23	.0867	.0895	.1174	.0857	.0895	.0876	.0895
24	.1132	.12	.081	.1147	.0943	.0943	.0895
Max	.1509	.4527	.4973	.583	.4531	.506	.3185
Min	.0762	.0857	.0772	.0857	.0876	.0876	.0895
Avg	.1000	.1656	.1519	.2437	.1811	.2159	.1341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.1307	.0895	.0886	1.6324	1.4922	1.2803
2	.7926	.1109	.0886	.0914	.1509	.1433	.1494
3	.9448	.112	.1829	.1086	.168	.1734	.1075
4	.2865	.1132	.2103	.1448	.2328	.2058	.1646
5	.2058	.1698	.1715	.1612	.2401	.2587	.1753
6	.2614	.2263	.2241	.2328	.2103	.3018	.2452
7	.2686	.168	.2012	.2172	.1949	.2012	.1629
8	.1509	.1494	.7274	.181	.2012	.1629	.1629
9	.9922	1.6598	1.6032	.1463	.1646	.1254	.112
10	.8482	1.8023	1.587	.1294	.1663	.0914	.1097
11	1.1174	1.668	1.5844	.1294	.1509	.1109	.1132
12	1.6194	1.3603		.1267	.1463	.0914	.1017
13	1.4746	1.1203		.128	.1509	.0914	.0995
14	.1086	.0762		.1097	.1006	.1086	.0762
15	.1097	.0914	.1526	.1097	.0983	.132	.1204
16	.1109	.0924	.2012	.1109	.1006	.132	.1107
17	.1734		.1991	.1132	.0819	.1524	.1147
18	.168		.1494	.1307	.0972	.1509	.1578
19	.1886	.112	.1463	.1494	.1254	.168	.1772
20	.1463	.1029	.1629	.1219	.1372	.3086	.2187
21	.1595	.1791	.1629	.1658	1.5912	1.3603	1.278
22	.1612	.1097	.1097	1.3108	1.531	1.6156	.9602
23	.1417	.0876	.0914	1.406	1.3717	1.406	1.1218
24	.9503	.1267	.0905	.0934	1.5565	1.5061	1.5043
Max	1.6194	1.8023	1.6032	1.406	1.6324	1.6156	1.5043
Min	.1086	.0762	.0886	.0886	.0819	.0914	.0762
Avg	.5075	.4440	.3874	.2378	.4417	.4371	.3677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0943	.0876	.0934	.0934	.0876	.0934
2	.0876	.0943	.0857	.0914	***	.0953	.1524
3	.0943	.0943	.0914	.0934	.0886	.1029	.0857
4	.1372	.0943	.1075	.1494	.1715	.1387	.1075
5	.1791	.132	.1543	.1494	.2195	.1753	.1402
6	.2614	.2641	.1791	.2263	.2641	.2149	.2452
7	.2012	.2012	.2641	.1463	.2103	.2303	.168
8	.2427	.1791	.1612	.1307	.1663	.1928	.1646
9	.1509	.1402	.1402	.132	.1526	.1214	.1543
10	.112	.1402	.1402	.1509	.1509	.12	.1235
11	.1109	.0914	.1063	.1357	.0876	.1052	.1389
12	.1097	.0914	.1075	.0857		.0886	
13	.1086	.0857	.0886	.0886	.0886	.0886	
14	.1109	.0867	.0934	.104		.0886	
15	.1052	.1052	.0934	.104	.0838	.0905	.1326
16	.1063	.1029	.0857	.104	.1006	.1029	.1638
17	.0949	.1307	.1063	.1219	.0983	.1718	.1638
18	.1372	.1307	.1341	.1509	.144	.1739	.1715
19	.1886	.2572	.1543	.1802	.1715	.1989	.1715
20	.2126	.1753	.2254	.2012	.1791	.1677	.1029
21	.1629	.1991	.1886	.1886	.1867	.1698	.1509
22	.132		.1132	.2075	.0895	.0876	.0876
23	.1132		.1097	.0895	.0857	.0895	.0895
24	.0943	.1132	.0953	.1109	.0943	.0943	.0876
Max	.2614	.2641	.2641	.2263	172.3444	.2303	.2452
Min	.0876	.0857	.0857	.0857	.0838	.0876	.0857
Avg	.1393	.1365	.1297	.1348	7.9669	.1332	.1379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.2561	.2949	.4752	.1578	.1402	.1387
2	.1753	.2721	.4161	.5197	.1509	.132	.1307
3	.1509	.3113	.5182	.5407	.1791	.168	.1772
4	.1715	.503	.6706	.6539	.2401	.2401	.2427
5	.2454	.7122	.6706	.7108	.3155	.3155	.2804
6	.415	1.0004	.7956	.9431	.4338	.4338	.4527
7	.3366	.9488	1.0004	.3547	.3898	.4108	.39
8	.2883	.9878	.2614	.6062	.4858	.7045	.664
9	.1341	.1494	.12	.7373	.9231	.8802	.7748
10	.1029	.1307	.1402	.8886	.9922	1.0082	.7968
11	.1063	.0914	.1417	1.0852	.9995	1.0722	.8025
12	.0934	.0739	.1433	1.0402	.9602	.9962	
13	.1063	.0905	.0886	1.0279	.8796	.953	
14	.1086	.0895	.0934	.9842		.8124	
15	.1086	.0886	.112	.9962	.9282	.8869	
16	.128	.0914	.1086	.1006	.2012	.2347	
17	.1492	.1109	.1294	.1638	.1791	.2155	
18	.1715	.2241	.1494	.1867	.1753	.2303	
19	.2587	.2241	.1595	.2033	.2378	.2587	.2926
20	.197	.1791	.2218	.2058	.2103	.2103	.2401
21	.2195	.2452	.3856	.2641	.2452	.2452	.2263
22	.2054	.1753	.3978	.2614	.1402	.1753	.1734
23	.1406	.1698	.4424	.1791	.1402	.1372	.12
24	.1509	.2056	.2401	.4424	.1509	.132	.1612
Max	.415	1.0004	1.0004	1.0852	.9995	1.0722	.8025
Min	.0934	.0739	.0886	.1006	.1402	.132	.12
Avg	.1802	.3055	.3209	.5655	.4224	.4581	.3567



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 207 / 11 KV YELAVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2012	.2172	.2054	.192	.2881	.2915
2	.1715	.168	.1734	.1663	.5312	.4902	.4458
3	.168	.168	.2743	.1698	.9816	.8048	.8688
4	1.0288	.132	.3086	.2075	1.0648	1.1142	1.4998
5	1.1142	.2075	.3582	.3547	1.3717	1.6004	
6	1.3916	.3772		.3921	1.9559	1.8896	2.0622
7	1.4582	.2378		.3475	.3185	.3292	.3475
8	.2195	.2195		.2957	.2926	.2896	.3174
9	.2641	.2218		.2149	.2561	.2743	.2896
10	.1991	.1663		.2012		.2743	.2481
11	.2402	.1867		.1848	.2195	.2195	.2229
12	.1663	.1829	.8482	.1949	.197	.2012	.1372
13	.1791	.2054	1.9989	.1928	.2149	.2172	.1823
14	1.3763	1.2003	2.364	.197	.2172	.2103	.1526
15	1.5655	.6622	2.146	.2353	.2378	.1595	.2126
16	1.4083	1.8299	.2103	.2883	.2195	.1886	.2204
17	.208	.2587	.2103	.2883	.2126	.218	.2374
18	.2229	.2195	.2328	.2896	.2204	.2279	.2743
19	.2328	.2481	.2561	.2865	.3292	.2481	.2804
20	.2353	.2507	.2957	.1867	.2743	.2743	.3086
21	.2481	.2587	.3174	.2641	.3174	.2801	.2987
22	.2561	.2058	.2987	.2241	.2279	.2743	.1829
23	.2012	.2103	.2561	.2507	.2401	.1772	.1402
24	.168	.1991	.1848	.2561	.2054	.2427	.2058
Max	1.5655	1.8299	2.364	.3921	1.9559	1.8896	2.0622
Min	.1663	.132	.1734	.1663	.192	.1595	.1372
Avg	.5398	.3424	.6084	.2456	.4477	.4372	.4099

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.7373	.6554	.7459	.1334	.1905
2	.1524	.7373	.7373	.7956	.1143	.2096
3	.1715	.7459	.8192	.7459	.1524	.2286
4	.1905	.8192	.9945	.7956	.1715	.2096
5	.2096	.9012	1.1797	.8288	.1905	.2286
6	.2286	1.2431	1.1437	.9116	.2286	.2286
7	.2858	1.326	.3429	.2286	.2667	.1905
8	.1143	1.3927	.2667	.663	.4801	.4973
9	.3429	.1905	.2286	.8288	.7373	.9614
10	.2667	.2286	.1905	.8619	.8122	.9945
11	.2286	.2477	.2096	.9614	.9116	.9614
12	.1905	.2858		.9945	1.0774	1.0442
13	.1905	.1905		1.1271	1.065	1.1271
14	.1905			1.2431	1.1603	1.1271
15	.1905	.1905	.1524		.9831	1.2266
16	.2286	.1905	.1143		.1905	.1905
17	.2858	.2096	.1905		.2286	.2286
18	.2858	.1905	.2286	.1905	.1905	.2858
19	.2858	.2096	.1905	.2667	.1905	.2667
20	.2858	.2286	.2286	.2858	.2286	.3429
21	.2286	.2477	.5335	.2477	.2286	.362
22	.2858	.2858	.6706	.1905	.2286	.3239
23	.381	.4001	.7459	.1715	.1905	.2858
24	.1524	.6554	.5441	.663	.1524	.1715
Max	.381	1.3927	1.1797	1.2431	1.1603	1.2266
Min	.1143	.1905	.1143	.1715	.1143	.1715
Avg	.231	.5154	.4937	.6546	.4297	.4951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.9945		.9945	.2858	.2667
2	.1905	1.1603		1.0774	.1905	.2858
3	.2286	1.2431		1.2574	.1715	.3429
4	.1905	1.2431		1.4251	.2858	.3429
5	.2858	1.326		1.5746	.3429	.4191
6	.3429	1.8399		1.6907	.4191	.5716
7	.4763	1.9919		.2286	.5144	.4763
8	.381	2.13		1.4918	.7202	1.4752
9	.4191	.2667		1.6907	1.5402	1.7901
10	.4001	.381		1.9559	1.6575	1.9725
11	.4191	.4001		2.0222	1.7901	1.8233
12	.381	.3429		1.8233	1.8896	1.8233
13	.381	.4382		1.6244	1.8023	1.8233
14	.381	.4382		1.4586	1.3927	1.989
15	.4572	.4382		1.442	1.9393	2.0222
16	.4382	.4001		.2667	.2286	.3239
17	.4001	.381		.3239	.2858	.362
18	.381			.362	.2858	.4572
19	.4191			.4382	.362	.5335
20	.4191			.4382	.4763	.5144
21	.4763			.4572	.5335	.5144
22	.4763			.4382	.4763	.4954
23	.7773			.381	.4763	.4763
24	.2286	.9221	.9922	.7459	.3429	.2286
Max	.7773	2.13	.9922	2.0222	1.9393	2.0222
Min	.1905	.2667	.9922	.2286	.1715	.2286
Avg	.3809	.9076	.9922	1.0670	.7671	.8887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.1143	.0572	.1334	.7865	.663
2	.4973	.1143	.0762	.0762	.852	.6226
3	.5801	.0953	.0953	.0762	.9175	.6962
4	.6299	.0953	.1143	.0762	.9945	.7459
5	.663	.1143	.1715	.0953	1.0774	.7625
6	.7373	.1524	.2096	.1143	1.1271	.9116
7	.8192	.1524	.1905	.1143	.1905	.0762
8	1.2929	.0953	.4024	.0762	.1143	.0572
9	1.5746	.2858	.7459	.0953	.0762	.0572
10	.9116	.663	1.0322	.0762	.0762	.0762
11	.9945	.8288	.9945	.0762	.0762	.0762
12	.9116	.8288	.8951	.0762	.0953	.0762
13	.8192	.8785	.9614	.0762	.0762	.0762
14	.8288	1.0277	.9945	.0762	.0762	.0762
15	.7373	.9779	.9614	.0572	.0572	.0762
16	.663	1.0111	.1143	.0762	.0953	.0953
17	.0953	.0762		.0762	.1143	.0953
18	.0953		.1143	.0762	.1143	.0953
19	.0953		.0762	.0762	.0953	.0953
20	.1143		.1143	.0953	.0953	.1143
21	.1334		.0762	.4001	.4973	.2881
22	.0953		.0572	.6316	.6554	.4696
23	.1143		.0762	.6802	.6962	.5182
24	.3353	.1334	.0762	.0762	.7209	.663
Max	1.5746	1.0277	1.0322	.6802	1.1271	.9116
Min	.0953	.0762	.0572	.0572	.0572	.0572
Avg	.5864	.4247	.3742	.1452	.4032	.3118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9116	.0762		.1143	1.3108	1.326
2	1.0898	.0762		.1334	1.3927	1.4089
3	1.1736	.1143		.1143	1.4752	1.4918
4	1.2431	.1524		.1524	1.5249	1.5927
5	1.3592	.1905		.1715	1.5746	1.6575
6	1.3108	.2667		.1905	1.4918	1.7072
7	1.4255	.2667		.2286	.2096	.1905
8	1.4586	.2477		.1905	.1524	.2096
9	1.5746	.8288		.2096	.0953	.1715
10	1.6907	1.5249		.1905	.0953	.1905
11	1.7404	1.6712		.1715	.1143	.1715
12	1.6907	1.5223		.1524	.1143	.1143
13	1.7204	1.7238		.1524	.1334	.1143
14	1.6194	1.7736		.1524	.1524	
15	1.6549	1.8067		.1524	.1905	.1524
16	1.6907	1.6244		.1334	.3048	.1524
17	.1143			.1524	.2858	.1715
18	.1905			.1715	.1905	.2096
19	.1905			.1715	.2286	.2477
20	.1905			.1524	.2286	.2667
21	.2477			.7202	1.1437	.8097
22	.1905			1.166	1.4255	1.3272
23	.0762			1.2146	1.4251	1.4582
24	.663	.0762	.1715	.0953	1.278	1.1603
Max	1.7404	1.8067	.1715	1.2146	1.5746	1.7072
Min	.0762	.0762	.1715	.0953	.0953	.1143
Avg	1.0507	.8202	.1715	.2689	.6891	.7088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 201 / 11 KV HALLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
24	1.406
Max	1.406
Min	1.406
Avg	1.406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 202 / 11 KV LAMAN TANDA AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUL-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	1.4083	1.3108	1.1561	.0709	.0532	.0747
2	.052	1.4083	1.1469	1.1336	.0709	.0532	.0747
3	.052	1.3923	1.1469	1.1336	.0709	.0532	.0747
4	.052	1.3923	1.1469	1.1336	.0709	.0532	.0747
5	.052	1.3923	1.1469	1.1984	.0709	.0532	.0747
6	.0693	1.5043	1.1633	1.2146	.0709	.0709	.0747
7	.0867	1.5684	1.3272	1.2308	.0886	.0709	.0747
8	.052	.0509	1.278	1.2346	.0709	.0532	.0701
9	.052	.0509	.0328	.0509	.0532	.0354	.0526
10	.0347	.0509	.0328	1.4548	1.4723	1.4352	.8333
11	.0347	.0339	.0492	1.5971	1.5203	1.5769	.9105
12	.0347	.0335	.0492	1.7236	1.6518	1.5769	.9105
13	.0693	.0509	.0526	1.692	1.3117	1.6655	.8333
14	.0347	.0678	.0351	1.8027	1.3717	1.7896	1.0957
15	.0693	.0514	.0526	1.8185	1.5364	1.7718	1.0957
16	.052	.0701	.0526	1.7394		1.8073	
17	.052	.0328	.0701	1.6762	1.1069	1.1163	.9722
18	.0347	.0655	.0526	.0474	.0532		.0463
19	.052	.0492	.0543	.0532	.0532	.0886	.0701
20		.0655	.0724	.0709	.0709	.0716	.0876
21	.0693	.0655	.0724	.0709	.0655	.0716	.1227
22	1.3923	1.3108	.0747	.0709	.0492	.0732	.1227
23	1.4563	1.3927	1.1203	.0709	.0532	.0739	.1227
24	.052	1.4563	1.3108	1.1561	.0709	.0532	.0747
Max	1.4563	1.5684	1.3272	1.8185	1.6518	1.8073	1.0957
Min	.0347	.0328	.0328	.0474	.0492	.0354	.0463
Avg	.1721	.6235	.5355	1.0221	.4794	.5943	.3454



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4119	.4344	.5093	.4755	.4031	.415
2	.4298	.4119	.4344	.4527	.4572	.4031	.415
3	.4119	.4119	.4525	.4527	.4572	.4382	.415
4	.4298	.4119	.4525	.4527	.4207	.4382	.415
5	.4298	.4119	.4525	.4527		.4382	.415
6	.4477	.5014	.4706	.4904	.3658	.4557	.547
7	.5194	.4835	.4801	.6224	.3475	.4908	.5658
8	.4835	.4668	.4973	.4854	.3109	.4908	.5415
9	.4298	.4668	.5316	.4755	.2561	.4557	.4805
10	.4298	.4481	.5316	.4207	.3658	.4382	.3881
11	.4119	.4481	.4973	.5121		.4031	.4066
12	.4656	.4294	.4973	.5121	.6201	.3856	.3881
13	.4119	.4251	.463	.5121	.4557	.4031	.3881
14	.4119	.4066	.5316	.4938		.3856	.3696
15	.5194	.4066	.5144	.4572	.4252	.3681	.4251
16	.5014	.4024	.5144	.439		.3155	.4251
17	.4835	.4161	.5316	.5121	.4557	.5258	.462
18	.5552	.4161	.5316	.5487	.4733	.5609	.5175
19	.6626	.4854	.6447	.6036	.6485	.6661	.6653
20	.7701	.6762	.8417	.7865	.7186	.7865	.7577
21	.6984	.6697	.8059	.7865	.6516	.7499	.6653
22	.6447	.5548	.7282	.7133	.5973	.6413	.6099
23	.5373	.4681	.6413	.5853	.4733	.4715	.4805
24	.4477	.4298	.4161	.5658	.4938	.3988	.4338
Max	.7701	.6762	.8417	.7865	.7186	.7865	.7577
Min	.4119	.4024	.4161	.4207	.2561	.3155	.3696
Avg	.4985	.4609	.5374	.5351	.4735	.4797	.4830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8886				1.1401	.8383	.7377
2	.8886				1.1401	.8048	.7377
3	.8886				1.1401	.8048	.7377
4	.8886				1.0059	.8048	.7377
5	.8886				1.0395	.8048	.7377
6	.8886				1.0227	.8383	.7545
7	.9556				.9892	.9054	.7377
8					.9724	.8383	.7625
9	1.0059	1.2239					
10	1.2407	1.4419	1.3117				
11	1.073	1.4754	1.3603				
12	1.291	1.5089	1.3117				
13	1.3748	1.5089	1.3603				
14	1.2574	1.2742	1.3441				
15	1.0395	1.291	1.4089				
16	1.2407	1.1768	1.3441				
17			1.247				
23				1.1401	.8048	.7625	.6706
24	.9054				1.1736	.8383	.7377
Max	1.3748	1.5089	1.4089	1.1401	1.1736	.9054	.7625
Min	.8886	1.1768	1.247	1.1401	.8048	.7625	.6706
Avg	1.0447	1.3626	1.3360	1.1401	1.0428	.8240	.7352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.6249	.6472	.6097	.0747	.0537	.0754
2	.0537	.6249	.6773	.6097	.0747	.0537	.0754
3	.0537	.6249	.7225	.6097	.0747	.0537	.0754
4	.0537	.6249	.7225	.6097	.0747	.0716	.0754
5	.0537	.6249	.7225	.6097	.0747	.0716	.0754
6	.0716	.8535	.8278	.7621	.0747	.0895	.0943
7	.0716	.9907	1.0837	.884	.0934	.0716	.0739
8	.0537	.0701	.888	.8535	.0934	.0716	.0934
9	.0716	.0876	.0693	.0876	.0934	.0716	.0732
10	.0537	.0526	.0693	.8333	.6636	.8238	.5792
11	.0537	.0876	.0693	1.0648	.8951	1.1641	.5639
12	.0537	.052	.0693	1.034	.933	1.1283	.6859
13	.0716	.052	.0747	1.0648	1.1883	1.0924	.6249
14	.0537	.0693	.0934	.9259	.724	1.0029	.5335
15	.0537	.0693	.0747	.9414	.7716	.985	.6249
16	.0537	.0701	.0934	.9414		1.0029	.6706
17	.0537	.0709	.112	.8642	.5401	.8954	.6859
18	.0895	.0701	.0934	.0772	.0895	.0537	.0305
19	.0895	.0876	.0924	.112	.0716	.0895	.0747
20	.1075	.1052	.1109	.1307	.1075	.0905	.0934
21	.1075	.0983	.1109	.1307	.0819	.0905	.0747
22	.7968	.929	.1307	.0934	.0819	.0895	.056
23	.7468	.8238	.6249	.0747	.0537	.0732	.056
24	.0537	.6859	.6472	.6455	.0747	.0537	.0732
Max	.7968	.9907	1.0837	1.0648	1.1883	1.1641	.6859
Min	.0537	.052	.0693	.0747	.0537	.0537	.0305
Avg	.1240	.3521	.3678	.6071	.3046	.3852	.2558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3283		.0857	.0754	1.5432	1.2757	1.1069
2	1.3123	.0848	.0686	.0732	1.5278	1.2403	1.1069
3	1.2963	.0848	.0686	.0732	1.5123	1.2403	1.1069
4	1.2803	.0848	.0686	.0732	1.4815	1.2403	1.1069
5	1.2803	.0848	.0686	.0732	1.4815	1.2757	1.1544
6	1.3123	.0848	.0686	.0914	1.4969	1.3112	1.2492
7	1.4243	.0848	.0686	.0914	1.6358	1.6832	1.4706
8	.08	.1017	.0686	.0867	1.6512	1.7718	1.5154
9	1.7284	2.0645	.0857	.0648	.0693	.0709	.0526
10	2.0965	2.2245	2.332	.0693	.0693	.0709	.0526
11	2.0805	2.3365		.0693	.0693	.0709	.0526
12	2.0805	2.2405	2.5377	.0693	.0532	.0532	.0526
13	2.0805	2.2138	2.6235	.0693	.0732	.0709	.0526
14	1.9524	2.0645	2.21	.0693	.064	.0709	.0351
15		1.9925	2.1338	.052	.0709	.0709	.0526
16	1.8404	.1981	1.9814	.0693		.0709	.0351
17	.064	.0819	1.89	.0693	.0709	.0709	.0701
18	.064	.1029	.061	.0693	.0886	.0709	.0701
19	.1017	.0686	.0724	.0693	.0709	.0671	.0701
20	.0848	.0686	.0905	.0867	.0709	.0686	.0701
21	.1017	.0655	.0905	.0867	.0655	.0686	.0701
22	.0848	.0686	.0732	.0693	.0655	.0709	.0701
23	.0848	.0686	.0739	1.4969	1.2403	1.0936	.8539
24	1.3603	.0848	.0857	.0754	1.6049	1.2757	1.0936
Max	2.0965	2.3365	2.6235	1.4969	1.6512	1.7718	1.5154
Min	.064	.0655	.061	.052	.0532	.0532	.0351
Avg	1.0921	.7198	.7351	.1331	.6990	.5989	.5238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV MALIWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0351	.0347	.0347	.0173	.0351
2	.0343	.0343	.0351	.0347	.0347	.0173	.0351
3	.0343	.0343	.0351	.0347	.0347	.0347	.0351
4	.0343	.0343	.0351	.0347	.0347	.0347	.0351
5	.0343	.0343	.0351	.0347	.0347	.0347	.0362
6	.0343	.0343	.0351	.0347	.0347	.0347	.0351
7	.0343	.0343	.0351	.0347	.0347	.0173	.0351
8	.0343	.0171	.0351	.0347	.0347	.0173	.0347
9	.0343	.0343	.0175	.0347	.0347	.0347	.0347
10	.0343	.0171	.0351	.0347	.0347	.0173	.0347
11	.0343	.0343	.0351	.0173	.0347	.0347	.0347
12	.0343	.037	.0351	.0173	.0347	.0347	.0347
13	.0171	.0175	.0351	.0347	.0347	.0347	.0347
14	.0343	.0351	.0175	.0347	.0347	.0347	.0347
15	.0343	.0175	.037	.0173	.0347	.0347	.0347
16	.0343	.0351	.037	.0347		.0347	.0347
17	.0343	.0351	.037	.0173	.0347	.0347	.0347
18	.0343	.0351	.037	.0347	.0347	.0347	.0347
19	.0343	.0351	.0351	.0347	.0347	.0347	.0347
20	.0343	.0351	.0351	.0347	.0347	.037	.0347
21	.0343	.0328	.0351	.0347	.0347	.037	.1227
22	.0343	.0351	.0351	.0347	.0173	.0373	.0347
23	.0171	.0351	.0351	.0347	.0347	.0347	.0347
24	.0343	.0171	.0351	.0347	.0347	.0173	.0347
Max	.0343	.037	.037	.0347	.0347	.0373	.1227
Min	.0171	.0171	.0175	.0173	.0173	.0173	.0347
Avg	.0329	.0311	.0340	.0318	.0339	.0307	.0385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0305	.0316	.0328	.0819		.0328
2	.0324	.0305	.0316	.0328	.0819		.0328
3	.0324	.0305	.0316	.0328	.0819		.0328
4	.0324	.0305	.0316	.0328	.0983		.0328
5	.0324	.0305	.0316	.0328	.0819	.0156	.0328
6	.0324	.0305	.0316	.0328	.0655		.0335
7	.0324	.0305	.0316	.0328	.0655		.0497
8	.0324	.0305	.0316	.032	.0655	.0156	.0514
9	.0324	.0305	.0316	.048	.0819	.0156	.0526
10	.0324	.0162	.0316	.0492	.0819	.0156	.052
11	.0324	.0162	.0316	.0328	.0819	.0469	.0347
12	.0324	.0332	.0316	.0328	.0617	.0469	.0347
13	.0324	.0497	.0316	.0328	.0572	.0469	.0347
14	.0324	.0463	.0316	.0328	.0417	.0469	.0347
15	.0324	.0772	.0316	.0328	.016	.0469	.0347
16	.0324	.0762	.0316	.0492		.0469	.0347
17	.0324	.0753	.0316	.0655	.0156	.0469	.0347
18	.0324	.0316	.0316	.0819	.0156	.0469	.0347
19	.0305	.0316	.0328	.0819	.0156	.0625	.0347
20	.0305	.0316	.0328	.0819	.0156	.0156	.0347
21	.0305	.0362	.0328	.0819	.0154	.0156	.0347
22	.0305	.0316	.0324	.0819	.0154	.0152	.0347
23	.0305	.0316	.0335	.0819	.0156	.0328	.0347
24	.0324	.0305	.0316	.0335	.0819		.0328
Max	.0324	.0772	.0335	.0819	.0983	.0625	.0526
Min	.0305	.0162	.0316	.032	.0154	.0152	.0328
Avg	.0320	.0371	.0319	.0484	.0537	.0341	.0370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	1.5424	1.4089	1.4403	.0191	.0191	.0191
2	.0191	1.5424	1.4089	1.4403	.0191	.0191	.0191
3	.0191	1.5424	1.4089	1.4403	.0191	.0191	.0191
4	.0191	1.5424	1.4089	1.4403		.0191	
5	.0191	1.5424	1.4089	1.5089		.0191	
6	.0191	1.5424	1.5089	1.5775		.0191	.0191
7	.0191	1.4922	1.5424	1.576		.0191	.0191
8	.0191	.0191	1.0852			.0191	.0191
9	.0191		.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	2.1365	.7377	1.7901	1.3565
11	.0191	.0191	.0191	1.9204	1.0059	2.0008	1.4918
12	.0191	.0191	.0191	2.1948	1.5775	1.9281	1.5249
13	.0191	.0191	.0191	2.2291	1.5775	1.8778	1.5089
14	.0191	.0191	.0191	2.1948	1.3413	1.8778	1.5249
15	.0191	.0191	.0191	2.1948	1.4083	1.8442	1.4255
16	.0191	.0191	.0191	1.5775	1.4083	1.7436	1.326
17	.0191	.0191	.0191	1.4922	1.4403	1.3748	1.0814
18	.0191	.0191		.0191	.0191	.0191	.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22		1.0442	.0191	.0191	.0191	.0191	.0191
23	1.5424	1.4754	1.4403	.0191	.0191	.0191	.0191
24	.0191	1.5424	1.4255	1.4403	.0191	.0191	.0191
Max	1.5424	1.5424	1.5424	2.2291	1.5775	2.0008	1.5249
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0853	.6546	.6489	1.2147	.5635	.6143	.5231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962	.0191	.0191	.0191	1.2239	.9496	.6962
2	.663	.0191	.0191	.0191	1.2239	.9326	.6962
3	.663	.0191	.0191	.0191	1.1736	.9326	.6962
4	.663	.0191	.0191	.0191	1.1869	.9326	.6962
5	.6706	.0191	.0191	.0191	.1696	.9326	.6722
6	.7042	.0191	.0191	.0191	1.2717	.9496	.7545
7	.7701	.0191	.0191	.0191	1.2548	1.1022	.8383
8	.0191	.0191	.0191	.0191	1.2887	1.1361	.8383
9	1.1233	1.4746	.0191	.0191	.0191	.0191	.0191
10	1.4074	1.7147	1.6289	.0191	.0191	.0191	.0191
11	1.5432	1.749	1.8861	.0191	.0191	.0191	.0191
12	1.4582	1.7318		.0191	.0382	.0191	.0191
13	1.4251	1.749	1.8861	.0191	.0191	.0191	.0191
14	1.4243	1.749	1.8861	.0191	.0191	.0191	.0191
15	1.4413	1.6804	1.8861	.0191	.0191	.0191	.0191
16	1.4582	1.6804	1.7974	.0191	.0191	.0191	.0191
17	.0191	.0191	1.7295	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191		.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	1.2574	.9156	.6962	.5243
24	.6962	.0191	.0191	.0191	1.2574	.9496	.6962
Max	1.5432	1.749	1.8861	1.2574	1.2887	1.1361	.8383
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.7067	.5764	.5655	.0729	.4689	.4075	.3073



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2772	.2218	.2534	.2195	.2402	.2054
2	.2172	.2772	.2218	.2534	.2195	.2402	.2054
3	.2172	.2486	.2218	.2534	.2218	.2402	.2054
4	.2172	.2772	.2218	.2534		.2402	.2054
5	.3258	.2772	.2534	.3045	.2218	.2587	.2587
6	.3721	.3898	.3506	.3856	.2218	.3582	.3292
7	.3721	.4031	.3189	.4031	.2241	.3814	.3077
8	.4161	.4382	.3988	.4239	.2378	.3814	.3045
9	.8322	.4161	.3944	.4409	.298	.3641	.3045
10	.4409	.463	.4458	.4973	.3258	.3429	.2103
11	.4917	.4239	.4862	.4973	.3086	.373	.2835
12	.3772	.4191	.5197	.4807	.3086	.3772	.2774
13	.3391	.4409	.5144	.4807	.3121	.3772	.2401
14	.2454	.4409	.4287	.39	.3086	.3772	.2641
15	.3294	.4409	.463	.4239	.2865	.3467	.2279
16	.3772	.4409	.4641	.3978	.3224	.3121	.2279
17	.3561	.3856	.4359	.3647	.3121	.3521	.2454
18	.3353	.2374	.4359	.3688	.2543	.3121	.2303
19	.373	.2629	.4191	.3429	.3121	.3121	.2353
20	.3222	.3475	.4298	.3189	.3258	.3224	.2241
21	.3506	.3258	.3395	.2896	.3109	.2926	.2427
22	.3326	.2772	.3801	.2743	.2772	.2926	.2452
23	.2772	.2772	.3439	.2743	.2772	.2054	.1905
24	.2195	.2772	.2409	.2896	.2561	.2587	.2054
Max	.8322	.463	.5197	.4973	.3258	.3814	.3292
Min	.2172	.2374	.2218	.2534	.2195	.2054	.1905
Avg	.3481	.3527	.3729	.3609	.2766	.3150	.2448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.8951	1.1142	1.073	.1267	.1214	.1463
2	.1448	.8951	1.1142		.1267	.1214	.1463
3	.1448	.8951	1.1142		.1267	.1214	.1463
4	.1448	.8951	1.1142			.1214	.1463
5	.1448	.8951	1.1142			.1214	.1463
6	.1791	1.1065	1.3108			.1372	.1433
7	.1886	1.2071	1.4419	.0617		.1402	.1463
8	.168	.1307	1.3108	.8619		.1433	.1402
9	.1646		.1478	.0754	.1646	.124	.1402
10	.1478	.1294	.1478	1.1934		1.4746	
11	.1509	.112	.1478	1.3108	1.166	1.6385	1.0277
12	.112	.0754	.1294	1.5074	1.3923	1.7204	1.1934
13	.1132	.0943	.1294		1.4083	1.7532	1.3923
14	.1132	.0943	.1307	1.9559	1.3763	1.7204	1.326
15	.112	.0943	.132		1.4419	1.6549	1.3923
16	.1294	.1132	.132			1.6244	1.3923
17	.1494	.132	.132	1.4918		1.5384	1.3108
18	.132	.1307	.1132	.1509		.1254	.1097
19	.1509	.1478	.1509	.1463	.1417	.1402	.1227
20	.1698	.2263	.1433	.1791	.168	.1463	.1372
21	.1698	.181	.1772	.181	.168	.1433	.1372
22		1.2597	.1772	.1448	.1387	.1463	.1357
23	.9614	1.2266	1.0277	.1448	.1372	.1463	.12
24	.1478	.8951	1.1469	1.073	.1267	.1387	
Max	.9614	1.2597	1.4419	1.9559	1.4419	1.7532	1.3923
Min	.112	.0754	.1132	.0617	.1267	.1214	.1097
Avg	.1819	.5144	.5750	.7220	.5473	.6360	.5045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.2263	.2263	.2263	.2263
2	.2263	.2263	.2263	.2263	.2263	.2263	.2263
3	.2263	.2263	.2263	.2263	.2263	.2263	.2263
4	.2263	.2263	.2263	.2263	.2263	.2263	.2263
5	.2641	.2263	.2263	.2263	.2829	.2195	.2641
6	.2829	.2641	.2641	.2641	.3018	.2829	.3018
7	.3584	.2641	.2829	.2641	.3018	.2641	.3018
8	.3018	.2452	.2641	.2263	.2452	.2452	.2641
9	.2641	.2075	.2452	.2263	.2263	.2263	.2641
10	.2561	.2075	.2452	.2452	.2263	.2075	.1698
11	.1509	.1509	.2452	.2075	.2263	.1886	.1698
12	.1886	.1509	.2452	.2263	.2263	.1886	.2075
13	.1698	.1886	.2263	.2452	.1886	.1886	.1698
14	.1886		.2075	.1886	.1886	.1886	.1509
15	.1886	.1886	.2075	.1698	.1886	.1698	.1886
16	.1886	.1886	.2263	.2263	.1509		.2263
17	.1886	.1886	.1886	.2263	.1509	.2641	.2263
18	.2263	.1886	.2641		.1886	.2641	.2641
19	.2641	.2263	.2641	.3018	.2263	.3018	.3018
20	.3018	.2641	.3018	.3018	.2641	.3018	.3206
21	.2641	.2641	.3018	.2829	.2452	.2641	.2829
22	.2641	.2641	.2641	.2641	.2452	.2263	.2452
23	.2452	.2641	.2263	.2452	.2452	.2263	.2263
24	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Max	.3584	.2641	.3018	.3018	.3018	.3018	.3206
Min	.1509	.1509	.1886	.1698	.1509	.1698	.1509
Avg	.2370	.2206	.2428	.2378	.2271	.2326	.2366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1886	.1886	.1886	.1886	.1698
2	.1698	.1886	.1886	.1886	.1886	.1886	.1698
3	.1698	.1886	.1886	.1886	.1886	.1886	.1698
4	.1698	.1886	.1886	.1886	.1886	.1886	.1698
5	.2075	.2075	.2075	.2263	.2263	.2075	.1886
6	.3018	.2641	.2614	.2801	.2829	.2263	.2241
7	.2263	.2452	.2801	.2614	.2263	.2829	.2801
8	.2054	.2263	.2241	.2427	.2614	.2263	.2614
9	.168	.168	.2054	.1867	.2241	.2075	.168
10	.168		.2054	.2054	.1494	.1867	.1494
11	.1307		.168	.2054	.1307	.1494	.112
12	.112	.168	.1494	.1867	.1875	.1307	.168
13	.1494	.2054	.168	.1867	.0934	.112	.168
14	.1494	.1867	.1867	.168	.0934	.0934	.1494
15	.1494	.1867	.168	.1494	.0934		.168
16	.1494	.168	.168	.112	.0934	.168	.1494
17	.1867	.2054	.168	.1867	.0747	.1307	.168
18	.2075	.2241	.2241	.2241	.1307		.2614
19	.3018	.2801	.2801	.2987	.3018	.2987	.2987
20	.3395	.3547	.3921	.3772	.3584	.3174	.3174
21	.3395	.3361	.3734	.3206	.3206		.3395
22	.2829	.2801	.3206	.3018	.2641	.3018	.2452
23	.2263	.2241	.2263	.2075	.2075	.1886	.2075
24	.1698	.1886	.2054	.2263	.1886	.1886	.1698
Max	.3395	.3547	.3921	.3772	.3584	.3174	.3395
Min	.112	.168	.1494	.112	.0747	.0934	.112
Avg	.2021	.2215	.2224	.2212	.1943	.1986	.2030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2263	.2452	.1509	.2452	.2263	.132
2	.2452	.2263	.2452	.1509	.2452	.2263	.132
3	.2452	.2263	.2452	.1509	.2452	.2263	.132
4	.2452	.2263	.2452	.1509	.2452	.2452	.132
5	.2829	.2641	.2452	.1886	.2641	.2641	.1886
6	.3206	.3206	.2614	.2241	.3018	.3018	.2241
7	.2075	.3772	.2054	.2054	.2829	.2075	.2241
8	.2801	.4527	.4668	.1867	.168	.2075	.2054
9	.3734	.3734	.4108	.5415	.168	.2075	.168
10	.4938		.3174	.5041	.3361	.2987	.1509
11	.3109		.1494	.5228	.3734	.5487	.2452
12	.3142	.5601	.112	.2614	.3361	.567	.415
13	.3841	.2987	.2427	.4294	.2427	.5304	.5281
14	.2033	.168	.1307	.2801	.2801	.2218	.3772
15	.5304	.4481		.2614	.3174		.5093
16		.4108	.2614	.4481	.3734	.3547	.4715
17		.3921	.3361	.5415	.4108	.168	.6224
18	.3772	.2054	.2427	.4108	.168	.2801	.2614
19	.3772	.2054	.2987	.2054	.1886	.2054	.1867
20	.3395	.2241	.3921	.2452	.2452	.1867	.2054
21	.2452	.2054	.2241	.2075	.2263	.1867	.1886
22	.1886	.2427	.2075	.2452	.1886	.1698	.1698
23	.2075	.2614	.1886	.2641	.2641	.132	.2263
24	.2452	.2263	.2614	.1509	.2452	.2452	.132
Max	.5304	.5601	.4668	.5415	.4108	.567	.6224
Min	.1886	.168	.112	.1509	.168	.132	.132
Avg	.3028	.2974	.2581	.2887	.2651	.2699	.2595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV PATGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.3401	.2915	.2267	.0754	.0754	.0754
2	.0754	.3401	.2915	.2267	.0754	.0754	.0754
3	.0754	.3401	.2915	.2267	.0754	.0754	.0754
4	.0754	.3563	.2915	.2429	.0754	.0754	.0754
5	.0754	.4049	.3563	.2915	.0754	.0943	.0943
6	.1132	.664	.5182	.3725	.0943	.132	.1307
7	.0943	.8907	.6964	.502	.0943	.0943	.1307
8	.0747	.0943	.5344	.5182	.0934	.0754	.0934
9	.0747	.0934	.0934	.0934	.0747	.0754	.0747
10	.0934		.0934	.7287	.7773	.5506	.2267
11	.0934		.0934	.7611	.8583	.7611	.3725
12		.112	.0747	.4534	.8745	.8097	.421
13		.1307	.0934	.5668	.8259	.8097	.4534
14	.0934	.0934	.0747	.5668	.8583	.7449	.3725
15	.0747	.112	.0747	.5668	.8642		.3725
16	.112	.0747	.0747	.583	.8802	.5668	.4372
17	.1307	.112	.0934	.6478	.8162	.3077	.4049
18	.0943	.0934	.0914	.0934	.0747		.0747
19	.0943	.0934	.0732	.0747	.0943	.0934	.0747
20	.1132	.112	.0732	.1132	.0943	.0934	.1132
21	.1132	.0934	.0943	.0943	.0943		.1132
22	.421	.3077	.0754	.0754	.0754	.0943	.0943
23	.4049	.2915	.2267	.0754	.0754	.0754	.0754
24	.0754	.3725	.2915	.2267	.0754	.0754	.0754
Max	.421	.8907	.6964	.7611	.8802	.8097	.4534
Min	.0747	.0747	.0732	.0747	.0747	.0754	.0747
Avg	.1204	.2510	.2068	.3470	.3364	.2741	.1878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.3239	.3563	.2915	.0943	.0943	.0566
2	.0754	.3239	.3563	.2915	.0943	.0943	.0566
3	.0754	.3239	.3563	.2915	.0943	.0943	.0566
4	.0754	.3239	.3563	.3563	.0943	.0943	.0566
5	.0943	.3401	.421	.4049	.1132	.1132	.0943
6	.1132	.583	.5992	.4858	.132	.1509	.112
7	.132	.583	.7611	.6478	.1698	.1509	.112
8	.112	.1509	.6478	.7935	.0934	.1698	.0934
9	.1494	.1867	.1307	.1494	.112	.1509	.112
10	.1307		.1307	.7611	.7287	.6478	.3239
11	.1307		.112	.9555		.8907	.3401
12	.112	.1307	.1307	.9555	.7287	.8421	.3887
13	.1307	.112	.1307	.8097	.7287	.8421	.421
14	.0934	.112	.112	.7773	.6316	.7125	.4372
15	.0934	.112	.112	.7935	.6722		.502
16	.0934	.112	.1494	.8583	.7362	.4372	.5182
17		.0934	.1494	.421	.6401	.1134	.4534
18	.132	.0934	.168	.0934	.168		.0747
19	.1509	.1494	.168	.112	.132	.1307	.112
20	.132	.1494	.1494	.132	.132	.1307	.1132
21	.0943	.1494	.1494	.132	.132		.1132
22	.4858	.421	.1509	.132	.132	.0754	.0754
23	.421	.3887	.3239	.0943	.1132	.0566	.0754
24	.0754	.3563	.3725	.2915	.0943	.0943	.0566
Max	.4858	.583	.7611	.9555	.7362	.8907	.5182
Min	.0754	.0934	.112	.0934	.0934	.0566	.0566
Avg	.1382	.2509	.2706	.4596	.2942	.2898	.1981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.3401	.3401	.2915	.1509	.1509	.1509
2	.1509	.3239	.3401	.2915	.1509	.1509	.1509
3	.1509	.3239	.3401	.2915	.1509	.1509	.1509
4	.1509	.3401	.3401	.3239	.1509	.1698	.1509
5	.2263	.3887	.4534	.4049	.2263	.2075	.2263
6	.3206	.7773	.8745	.5668	.3206	.3018	.2987
7	.3018	.7611	1.1012	.8421	.3018	.3395	.2987
8	.2241	.2452	.8421	.7773	.2427	.1132	.2614
9	.1867	.1867	.1867	.2054	.1867	.2641	
10	.1494		.168	.6802	.583	.5182	.1619
11	.1494		.1867	.7287		.6802	.3563
12	.168	.1494	.168	.7611	.4858	.6964	.421
13	.1494	.168	.1867	.8097	.6562	.6802	.4696
14	.1867		.168	.8097		.6316	.502
15	.168	.168	.2054	.7449	.7202	.6316	.5992
16	.2054	.2054	.2241	.664	.7202	.5668	.6154
17		.2054	.2241	.6478	.6722	.3239	.583
18	.2075	.2241	.2926	.2241	.1867	.1867	.1867
19	.2452	.2241	.2926	.2427	.2452	.2054	.2241
20	.2263	.2801	.2561	.2452	.2641	.2427	.2263
21	.2075	.2241	.2587	.2263	.2452	.2054	.1886
22	.4534	.4696	.2263	.1886	.2075	.2075	.1698
23	.3887	.4049	.3239	.1698	.1698	.1698	.1509
24	.1509	.3563	.3401	.3077	.1509	.1698	.1509
Max	.4534	.7773	1.1012	.8421	.7202	.6964	.6154
Min	.1494	.1494	.168	.1698	.1509	.1132	.1509
Avg	.2139	.3222	.3475	.4769	.3268	.3319	.2911



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9393	.0943	.0754	.132	1.004	1.0202	.6802
2	.6964	.0943	.0754	.132	.9717	1.0202	.6802
3	.6964	.0943	.0754	.132	.9717	1.0202	.6802
4	.6964	.0943	.0754	.132	1.0202	1.0526	.6802
5	.7773	.1132	.0934	.132	1.1174	1.166	.7287
6	.9878	.1509	.1307	.168	1.5546	1.4251	.7682
7	1.1984	.1509	.112	.1494	1.8623	2.0243	.8802
8	.1307	.1509	.1307	.168	2.0081	2.1538	1.1174
9	1.3441	1.9595	.1307	.112	.0934	.1132	
10	1.9433		1.8947	.1307	.1494	.1494	
11	2.0729		2.2996	.112	.1307	.112	.0754
12	2.1052	2.652	2.3967	.112	.168	.1307	.0566
13	2.0405	2.5425	2.2024	.1307	.168	.1307	.0754
14	2.0405	2.3158	2.2348	.1307	.0934	.1307	.0754
15	2.3158	2.4006	2.2348	.1494	.0934		.0943
16	2.332	2.0405	2.2186	.1494	.0934	.0747	.0754
17		.0934	2.1628	.112	.1307	.0747	.0943
18	.1886	.112	.168	.112	.1307	.0934	.112
19	.2075	.0934	.168	.1494	.1509	.112	.1494
20	.1886	.1494	.1867	.1867	.1698	.1307	.132
21	.1698	.1307	.168	.1867	.1509	.1307	.132
22	.1132	.0934	.1509	.1509		.1132	.1132
23	.1132	.0934	.1132	1.0202	1.0688	.6802	.502
24	.9393	.1132	.0934	.132	1.004	1.0526	.6802
Max	2.332	2.652	2.3967	1.0202	2.0081	2.1538	1.1174
Min	.1132	.0934	.0754	.112	.0934	.0747	.0566
Avg	1.0538	.7151	.8163	.1759	.6220	.6135	.3901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.1886	.1867	.1867	.3734	.499	.5228
2	.4805	.2054	.1886	.1867	.5228	.4938	.5601
3	.4854	.2075	.1886	.1867	.4481	.5041	.5601
4	.4805	.2241	.1867	.1867	.4854	.4938	.5601
5	.5487	.2263	.1886	.1867	.5975	.7023	.6535
6	.5914	.2614	.2241	.2427	.5601	.8589	.7468
7	.7655	.2641	.2263	.2614	1.1949	1.2803	.8029
8	.1646	.1867	.2241	.2241	1.1203	1.2323	.8589
9	.7392	.4527	.2241	.2241	.112	.1478	.1494
10		1.0082	1.0974	.2241	.1307	.168	.1494
11	.8589	1.2696	1.307	.2241	.168	.1886	.112
12	.9335	1.1949		.2987	.168	.1494	.112
13	.9808	1.1576		.1867	.1494	.1509	.112
14	1.0082	1.1576		.1494	.1494	.1307	.112
15	1.0185	1.1389		.1494	.168	.112	.1494
16	.9335	1.0082		.1494	.168	.132	.1494
17	.1132	.1307		.1494	.168	.1494	.0747
18	.1494	.1494	.2241	.1867	.1646	.168	.0747
19	.1698	.1509	.2427	.1867	.168	.2054	.1494
20	.1867	.2241	.2614	.1867	.1848	.2054	.1867
21	.2263	.2241	.2241	.1867	.2012	.1867	.1867
22	.2241	.2263	.2241		.1867	.1867	.1867
23	.1886	.1867	.2054	.3734	.499	.4854	.4481
24	.4805	.1867	.1886	.2054	.2614	.4938	.5228
Max	1.0185	1.2696	1.307	.3734	1.1949	1.2803	.8589
Min	.1132	.1307	.1867	.1494	.112	.112	.0747
Avg	.5310	.4846	.3229	.2062	.3479	.3885	.3392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4527	.5041	.5041	.3734	.3658	.5975
2	.5175	.4294	.4904	.5228	.3361	.3696	.5788
3	.4938	.4108	.4904	.5228	.3361	.3658	.5788
4	.5041	.3772	.4668	.4854	.3547	.3734	.5788
5	.4805	.3734	.4715	.5228	.3734	.4066	.5601
6	.4668	.3772	.4668	.5228	.3921	.4481	.5228
7	.4251	.415	.4854	.4294	.4108	.439	.5041
8	.4481	.4481	.4904	.4481	.4108	.4435	.4854
9	.462	.4527	.4854	.4668	.4108	.4108	.5228
10		.6348		.7282	.4481	.5281	.4668
11	.6722	.6908		.6722		.5975	.6535
12	.7095	.6535		.5975	.4481	.6413	.7468
13	.6413	.6348		.5415		.6722	.6535
14	.6722	.7095		.5975		.9054	.7468
15	.7167	.8215		.6161		.9709	.7468
16	.7095	.8029		.6535		.9431	.7468
17	.7545	.8029		.6722	.4294	.9335	.8299
18	.6722	.7842	.7095	.5975	.4251	.8589	.7545
19	.5975	.811	.5601	.4854	.4207	.6908	.5975
20	.5658	.6348	.5975	.4668	.4294	.5975	.5093
21	.5228	.5041	.5228	.3921	.4251	.6161	.4668
22	.4715	.5093	.4668	.3734	.4207	.6161	.5415
23	.4481	.5228	.4854	.3921	.3881	.5975	.5975
24	.5121	.4481	.5093	.5041	.3734	.3734	.5975
Max	.7545	.8215	.7095	.7282	.4481	.9709	.8299
Min	.4251	.3734	.4668	.3734	.3361	.3658	.4668
Avg	.5646	.5709	.5127	.5298	.4003	.5902	.6077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1867	.1886	.2241	.1698	.168	.168
2	.1646	.1886	.168	.2054	.1463	.1663	.168
3	.168	.2075	.1698	.2054	.1646	.1646	.168
4	.168	.2054	.1698	.2054	.1097	.1663	.168
5	.1848	.2241	.1698	.2054	.168	.1867	.168
6	.2033	.2263	.1886	.2054	.168	.2012	.1867
7	.2378	.2263	.1867	.2427	.1867	.2054	.2054
8	.2054	.1867	.2054	.1867	.2054	.1848	.2054
9	.2033	.1886	.1867	.1867	.1867	.1867	.1867
10		.1867		.1867	.168	.1886	.1867
11	.2012	.2054		.1867	.168	.2054	.2241
12	.168	.2054		.168	.112	.1698	.2054
13	.1494	.2054		.1494	.112	.1307	.1494
14	.1663	.1867		.1307	.112	.1494	.1307
15	.1867	.1867		.1307	.0934	.1698	.1307
16	.1886	.1494		.1494	.0934	.1494	.1307
17	.1494	.1307		.1494	.1494	.168	.1494
18	.1886	.2075	.2241	.2054	.1829	.2427	.2427
19	.2614	.2614	.2427	.2241	.1848	.2614	.2801
20	.2641	.2801	.2801	.2054	.2987	.2614	.2614
21	.2427	.2829	.2614		.2743	.2427	.2427
22	.2452	.2614	.2427	.2241	.2218	.2241	.2241
23	.2241	.1886	.2241	.1867	.1867	.1867	.1867
24	.1663	.2054	.1867	.2241	.168	.1848	.1867
Max	.2641	.2829	.2801	.2427	.2987	.2614	.2801
Min	.1494	.1307	.168	.1307	.0934	.1307	.1307
Avg	.1957	.2077	.2060	.1908	.1679	.1902	.1898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.5975	.8299	.7095	.4854	.3658	.6161
2	.7762	.5601	.8215	.7282	.4481	.3734	.6161
3	.7682	.5658	.7922	.6908	.4294	.3696	.6348
4	.7468	.5281	.7095	.6722	.4435	.3658	.6348
5	.7023	.4854	.679	.6722	.4481	.3734	.6348
6	.6401	.4481	.679	.6348	.4481	.3326	.6348
7	.6348	.415	.7095	.6161	.4108	.3292	.5601
8	.5544	.5228	.4108	.3547	.3361	.3326	.4668
9	.5853	.5281	.679	.3734	.2987	.4108	.5601
10		.9335	.695	.4481	.3921	.4527	.5228
11	.7392	1.1389	.7282	.5601	.3921	.1494	.4294
12	.7545	1.0082	.7023	.5601	.4108	.3018	.8962
13	.7468	.5975	.7682	.4108	.3734	.3734	
14	.7922	.7282	.7762	.4854	.3921		.0747
15	.8215	.8775	.7468	.5228	.3361	.4854	.1494
16	.8676	.7468	.823	.5228	.3921	.5658	.4854
17	.7468	.7468	.7842	.6348	.3174	.6722	.4854
18	.6413	.7468	.6908	.4481	.3658	.4294	.2614
19	.6348	.7545	.7095	.5228	.3734	.5228	.1867
20	.6036	.7095	.6722	.3734	.3696	.5228	.4481
21	.5601	.679	.6535	.3734	.3734	.6722	.4668
22	.5228	.7842	.5975	.4854	.3696	.6348	
23	.5658	.9054	.7468	.5228	.3658	.6161	.5975
24	.8316	.679	.8589	.7468	.4854	.3696	.6348
Max	.8676	1.1389	.8589	.7468	.4854	.6722	.8962
Min	.5228	.415	.4108	.3547	.2987	.1494	.0747
Avg	.6990	.6953	.7193	.5446	.3941	.4357	.4999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.8962	.7545	.9709	.499	.7762	.8215
2	.961	.8676	.7468	.9709	.5041	.7842	.8215
3	.9145	.8488	.7167	.9709	.4668	.7762	.8029
4	.9335	.8215	.6722	.9709	.6348	.7682	.8029
5	.924	.8402	.679	.9335	.5601	.7682	.7842
6	.9145	.8676	.7167	.8962	.5975	.7842	.7468
7	.8779	.8676	.7095	.8962	.8215	.7023	.7468
8	.9335	.7468	.7095	.7282	.3734	.5853	.7655
9	.9145	.7922	.679	.8962	.8962	.6348	.7468
10		.8589	.823	.3361	.8589	.5658	.7468
11	.9709	.8962	.8962	.7842	.8402	.5228	.7842
12	.9335	.8962	1.0349	.7468	.8589	.4904	.7842
13	.9808	.8962	.9877	.8215	.8589	.4854	.8589
14	1.0082	.8962	1.0082	.3734	.8589	.5281	.8215
15	1.0562	.8962	.961	.6348	.8215	.5601	.8962
16	.9335	.8402	.9709	.7468	.7468	.4904	.8775
17	1.094	.8589	.961	.7468	.8402	.4108	.8962
18	.9709	.8589	.9709	.7468	.823	.3734	.8962
19	.9808	.8215	.7468	.7468	.8316	.5788	.7842
20	.9431	.8215	.8962	.7468	.8402	.7095	.8215
21	.9335	.7922	1.0082	.7468	.823	.8215	.8215
22	.9335	.7842	.9522	.7095	.8871	.8215	.0934
23	.9054	.8299	1.0456	.5544	.7842	.8589	.9335
24	.961	.8962	.7095	1.0082	.7095	.7682	.8402
Max	1.094	.8962	1.0456	1.0082	.8962	.8589	.9335
Min	.8779	.7468	.6722	.3361	.3734	.3734	.0934
Avg	.9543	.8497	.8482	.7785	.7390	.6486	.7873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.1307	.1494	.1494	.112	.1307
2	.1494	.1307	.1132	.1307	.1307	.1109	.112
3	.1294	.132	.0934	.1307	.1294	.1097	.112
4	.128	.1132	.0943	.1307	.1494	.112	.112
5	.1307	.112	.0934	.1307	.1494	.1109	.0934
6	.0924	.0934	.0943	.1307	.0934	.112	.0934
7	.1109	.0943	.112	.0934	1.0456	.0924	.0934
8	.1463	.112	.0943	.0747		.112	.0934
9	.1478	.1132	.0934	.1307	.0934	.1109	.112
10		.1494	.1097	.168	.0934	.1494	.112
11	.1494	.168	.112	.1307	.056	.1698	.1307
12	.1494	.1307	.1109	.1307	.0747	.1307	.1307
13	.132	.112	.1097	.0747	.0747	.112	.1307
14	.1307	.112	.112	.0747	.0747	.1494	.1494
15	.132	.1307	.1646	.168	.0747	.1494	.1307
16	.1307	.1307	.1867	.112	.056	.132	.1307
17	.1509	.1494	.1294	.1294	.0747	.1494	.1307
18	.1307	.1509	.1494	.1294	.0732	.168	.1494
19	.1132	.1307	.1867	.1294	.0924	.1494	.1307
20	.0943	.1509	.1494	.1294	.0934	.112	.2054
21	.112	.1307	.0934	.1294	.0914	.0934	.1494
22	.0934	.132	.0934		.0924	.0934	.0747
23	.132	.1307	.1494	.168	.112	.1307	.0934
24	.1494	.1509	.1509	.1494	.1307	.1109	.1494
Max	.1509	.168	.1867	.168	1.0456	.1698	.2054
Min	.0924	.0934	.0934	.0747	.056	.0924	.0747
Avg	.1298	.1296	.1219	.1272	.1394	.1243	.1229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 201 / 11 KV malgaon Gavthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.462	.4066	.439	.3696	.4435	.4108
2	.4854	.462	.4066	.4024	.3696	.4435	.3696
3	.4066	.462	.4066	.4066	.3511	.4435	.3734
4	.4066	.462	.4066	.4108	.3696	.4435	.4108
5	.462	.462	.462	.4294	.462	.4435	.3921
6	.5729	.499	.499	.5041	.5544	.462	.4854
7	.5544	.5175	.5359	.5914	.5729	.5544	.5788
8	.5544	.5175	.6468	.4938	.499	.5544	.499
9	.5175	.4938	.5359	.4755	.462	.5853	.5175
10	.462	.4572	.5729	.462	.462	.5359	.4572
11	.5175	.5487	.5175	.499	.462	.499	.4755
12		.5121	.5359	.4938	.462	.4755	.4572
13		.4755	.4805	.4755	.462	.3696	.4207
14	.5544	.3841	.4572	.3841	.462	.3696	.3109
15	.5544	.5121	.5304	.3292	.462	.3921	.3658
16	.5175	.4572	.5121	.3841		.4668	.439
17	.5175		.5914	.5121	.4805	.5415	.4755
18	.499	.6767	.6401	.4572	.5175	.6535	
19	.5359	.6584	.7133	.5359	.6468	.7282	
20	.5914	.7392	.7499	.6838	.6838	.6535	.8316
21	.6468	.6653	.7316	.6099	.6838	.5415	.6653
22	.6468	.5914	.6283	.499	.5544	.4854	.499
23	.5914	.4805	.5359	.4251	.462	.4294	.4251
24	.5228	.5544	.4251	.4572	.3881	.4435	.4108
Max	.6468	.7392	.7499	.6838	.6838	.7282	.8316
Min	.4066	.3841	.4066	.3292	.3511	.3696	.3109
Avg	.5274	.5239	.5387	.4734	.4869	.4983	.4669



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 202 / 11 KV Cannal AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.6478	.5624	.6554	.1715	.1905	.1715
2	.1905	.6478	.5624	.6554	.1715	.1524	.1715
3	.1905	.6478	.5624	.6874	.1715	.1524	.1524
4	.2096	.6478	.6249	.6718	.1905	.1524	.1715
5	.2667	.7287	.8697	.7499	.2286	.1524	.1715
6	.3048	1.0526	1.0279	.8688	.2858	.1905	.2286
7	.3239	1.3765	1.4842	1.1203	.2858	.2286	.3048
8	.2858	.1905	1.2498	1.2334	.2858	.2858	.2477
9	.2667	.2858	.3048	.2667	.2858	.2286	.2286
10	.2477	.2858	.3239	1.2651	1.247	.8381	.7468
11	.2286	.1905	.3429	1.5844	1.2146	1.2811	.8078
12	.2286	.2477	.3239	1.5971	1.2146	1.3123	.8688
13	.2286	.2477	.2858	1.5497	1.2631	1.3125	.884
14	.2286	.2286	.2477	1.4529	1.2146	.6722	.9842
15	.2286	.2096	.2096	1.2811	1.1336	1.012	1.0467
16	.2286	.2477	.2477	1.3272		1.0311	1.0311
17	.2286		.2667	1.1574	.8907	1.0437	.9145
18	.3239	.2667	.2858	.1905	.2286	.2096	
19	.3239	.2667	.3048	.2667	.2667	.2667	
20	.2858	.2667	.3239	.2096	.2667	.2667	.2858
21	.2858	.2477	.3048	.2477	.2667	.2477	.2477
22	.8573	.68	.2858	.1905	.2477	.2096	.2096
23	.6478	.6173	.5647	.1905	.1905	.1905	.1905
24	.2096	.7621	.5556	.6321	.1905	.1905	.1905
Max	.8573	1.3765	1.4842	1.5971	1.2631	1.3125	1.0467
Min	.1905	.1905	.2096	.1905	.1715	.1524	.1524
Avg	.2921	.4778	.5051	.8355	.5179	.4924	.4662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 203 / 11KV RAMNAGAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.0953	.1905	.1905	.3906	.4049	.463
2	.4915	.0953	.1905	.1715	.3906	.4049	.4557
3	.4915	.0953	.1905	.1715	.3858	.4049	.4557
4	.5182	.0953	.1905	.1715	.4687	.4049	.4458
5	.5376	.0953	.2286	.1715	.578	.4049	.4862
6	.5851	.1143	.2667	.2477	.6405	.4858	.7293
7	.7522	.1334	.3048	.2858	.9374	.7287	.8745
8	.0953	.1334	.2667	.2286	.8951	.8097	.7682
9	1.1336	.8855	.2667	.1905	.8907	.1334	.1524
10	1.0526	1.1544	1.1336	.1715	.1143	.1334	.1334
11	1.004	1.2346		.1524	.1143	.1143	.0953
12	.9717	1.2191	1.5023	.1524	.0953	.1143	.0953
13	.9717	1.2809	1.4582	.1524	.0953	.1143	.0762
14	.9393	1.2037	1.3763	.1524	.0953	.1143	.0762
15	.8907	1.1584	1.3435	.1334	.1143	.1143	.0953
16	.9393	1.1431	1.4232	.1524		.1334	.0953
17	.0953		1.1248	.1524	.1334	.1524	.1143
18	.1334	.1715	.1524	.1524		.1715	
19	.1524	.2858	.2286	.1905	.1524	.2096	
20	.1905	.2286	.2667	.1905	.2286	.1905	.2096
21	.2286	.2096	.2477	.2477	.2286	.1715	.1715
22	.1905	.1905	.2286	.1524	.1524	.1524	.1334
23	.1524	.1905	.2096	.4374	.3239	.463	.362
24	.5079	.1334	.1905	.1905	.4374	.4049	.4748
Max	1.1336	1.2809	1.5023	.4374	.9374	.8097	.8745
Min	.0953	.0953	.1524	.1334	.0953	.1143	.0762
Avg	.5632	.5021	.5644	.1921	.3574	.2890	.3165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.68	.4534	.3841	.132	.132	.112
2	.1509	.7562	.4588	.3841	.1463	.132	.1132
3	.132	.828	.4641	.3841	.1478	.132	.1109
4	.1509	.9172	.4915	.3841	.1886	.132	.112
5	.1698	.9922	.6478	.4801	.1867	.1509	.1294
6	.1791	1.0978	.8002	.6882	.1867	.2263	.1867
7	.1886	1.1822	.9069	.8962	.1886	.2263	.2263
8	.1494	.1867	.7125	.8962	.2075	.1886	.1509
9	.1307	.1698	.1132	.1109	.168	.1509	.1307
10	.112	.168	.1132	.68	.7042	.7907	.3856
11	.1132	.168	.0754	.9014	.8065	.9488	.4167
12	.1307	.1509	.0934	.9646	.8642	.8124	.463
13	.0914	.1307	.0924	.8065	.9122	.8848	
14	.112	.1307	.132	.759	.8381	.4024	.4374
15	.1307	.1132	.1132	.7116	.7842	.4938	.381
16	.0934	.112	.1307	.4062	.7748	.5937	.6325
17	.1494	.1307	.168	.5535	.3715	.4999	.6249
18	.1509	.132	.1494	.0924	.0934	.0747	.1463
19	.1886	.1307	.1886	.1494	.132	.1886	.1494
20	.2075	.2427	.2263	.1886	.1886	.1494	.1886
21	.2075	.2075	.2452	.1698	.1698	.1509	.1698
22	.7449	.503	.1886	.1509	.1698	.1294	.132
23	.7042	.4915	.3563	.132	.1509	.112	.1132
24	.1132	.6401	.4641	.3841	.132	.132	.1132
Max	.7449	1.1822	.9069	.9646	.9122	.9488	.6325
Min	.0914	.112	.0754	.0924	.0934	.0747	.1109
Avg	.1929	.4276	.3244	.4858	.3602	.3264	.2446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.112	.132	.1097	.1132	.112
2	.1509	.128	.1132	.132	.1109	.1132	.1132
3	.132	.1109	.0924	.132	.1132	.1132	.1109
4	.1509	.1132	.0934	.132	.128	.1132	.112
5	.1509	.1307	.1109	.132	.1294	.1132	.1294
6	.132	.1294	.1307	.132	.1307	.132	.1307
7	.1509	.132	.132	.1132	.132	.1698	.1509
8	.1463	.1848	.1294	.1991	.1509	.1478	.1509
9	.1478	.3982	.168	.1772	.1478	.1612	.2378
10	.1433	.4024	.1886	.1578	.1109	.2629	.2378
11	.128	.1448	.2012	.124	.112	.3142	.2452
12	.2149	.2401	.1772	.1372	.1307	.0366	.1612
13	.1829		.1848	.1715	.1294	.1075	.2402
14	.1294	.2561	.132	.1715	.112	.1402	.1463
15	.1372	.2587	.1578	.1791	.2452	.2743	.0754
16	.2218	.3142	.2241	.2279	.1478	.2452	.2835
17	.7577	.2303	.1991	.1715	.2033	.2075	.2454
18	.2947	.2033	.2561	.1433	.1991	.3189	.2149
19	.2126	.1646	.168	.1646	.1867	.2263	.1991
20	.2075	.2218	.1886	.1886	.1886	.168	.1698
21	.1698	.1886	.1886	.1509	.1698	.168	.1509
22	.1698	.1867	.1698	.1509	.1509	.1509	.132
23	.128	.1478	.1509	.1307	.132	.112	.1109
24	.132	.132	.128	.132	.112	.1132	.1132
Max	.7577	.4024	.2561	.2279	.2452	.3189	.2835
Min	.128	.1109	.0924	.1132	.1097	.0366	.0754
Avg	.1885	.1979	.1582	.1535	.1451	.1676	.1656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2435	.0943	.0924	.1294	.333	.2462	.2134
2	.2679	.112	.0934	.132	.4214	.2462	.2054
3	.2858	.1097	.1132	.1294	.4938	.2462	.208
4	.2679	.1109	.1174	.1294	.5487	.2462	.2054
5	.2858	.1509	.1478	.1294	.6443	.2934	.2896
6	.3429	.1463	.168	.168	.6249	.4064	.3521
7	.443	.1494	.1867	.1848	.6718	.5944	.4161
8	.0905	.1097	.1829	.1494	.5719	.5721	.4161
9	.3961	.5498	.1886	.1663	.0905	.0914	.1097
10	.5502	.6321	.5792	.0914	.1097	.0914	.0739
11	.5796	.6923	.6539	.1109	.112	.0754	.0724
12	.5721	.743	.6748	.0914	.1109	.0543	.0876
13	.5647	.5498	.5428	.0886	.0709	.0537	.0701
14	.5944	.5135	.5721	.0716	.0709	.0526	.0895
15	.3715	.4923	.6001	.0886	.0701	.0526	.0693
16	.4172	.4512	.6805	.0947	.1254	.0732	.0709
17	.0905	.1646	.6516	.1052	.0876	.1086	.0716
18	.0716	.168	.128	.128	.1433	.0739	.1086
19	.0914	.1848	.1663	.128	.1646	.1478	.1109
20	.1494	.1848	.1848	.128	.1478	.1307	.1478
21	.1294	.1478	.1867	.1478	.1494	.132	.1109
22	.1132	.132	.1478	.112	.1294	.112	.112
23	.1109	.1294	.1294	.3921	.2824	.208	
24	.257	.0943	.112	.1294	.2715	.2462	.2107
Max	.5944	.743	.6805	.3921	.6718	.5944	.4161
Min	.0716	.0943	.0924	.0716	.0701	.0526	.0693
Avg	.3036	.2839	.3042	.1344	.2686	.1898	.1662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0554	.0747	.0747	.0943	.056
2	.0747	.0747	.0549	.0739	.0747	.0747	.0554
3	.0739	.0754	.0549		.0754	.0754	.0554
4	.0739	.0934	.0739		.0747	.0747	.0554
5	.0924	.0943	.0914		.0754	.0934	.0739
6	.0934	.112	.0924		.0934	.0943	.0739
7	.0934	.112	.0934		.112	.112	.0934
8	.1307	.1132	.0943		.1132	.1132	.112
9	.112	.0934	.1086		.0934	.0934	.0934
10	.0934	.0934	.0905		.0943	.056	.0934
11	.0934	.0943	.0905		.0934	.0747	.0747
12	.0943	.0943	.0914		.0934	.0934	.0754
13	.0943	.0934	.0914		.0754	.056	.0747
14	.0943	.0943	.0934		.0566	.056	.0943
15	.0934	.0934	.112		.056	.056	.0739
16	.0934	.0943	.112		.0934	.0754	.0754
17	.0934	.0943	.0934			.132	.056
18	.1132	.1132	.056		.1307	.1132	.112
19	.1494	.1294	.0747		.132	.132	.1132
20	.1494	.1478	.1494		.1509	.132	.112
21	.1509	.1494	.168		.1307	.132	.1132
22	.112	.0934	.1307		.112	.1132	.0934
23	.0934	.0754	.0934		.112	.0943	.0754
24	.0754	.0943	.056	.0747	.0754	.0943	.0754
Max	.1509	.1494	.168	.0747	.1509	.132	.1132
Min	.0739	.0747	.0549	.0739	.056	.056	.0554
Avg	.1006	.1007	.0926	.0744	.0954	.0932	.0826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.8322	.8962	.0934	.0934	.0747
2	.0754	.8002	.8697	.0934	.0754	.0747
3	.0762	.8381	.8907	.0943	.0747	.0566
4	.0953	.9442	.8907	.0943	.0934	.0566
5	.0953	.9962	1.0159	.0934	.0943	.0754
6	.112	1.1523	1.2289	.112	.0943	.0934
7	.0943	1.3603	1.3279	.1132	.0934	.0747
8	.112	.0943	.0953	.0934	.0943	.0934
9	.0934	.0754	.1334	.0943	.0943	.0934
10	.0934	.0762	.0953	.9282	.7748	.4801
11	.0943	.0754		.9804	.8223	.5761
12	.112	.0377	.056	.9172	.8697	.6167
13	.112	.0373	.0566	.8802	.8697	.6325
14	.1132	.0373	.0566	.8162	.8855	.6325
15	.1132	.0189	.0566	.7748	.8539	.6562
16	.0934	.0189	.0377	.8162	.8002	.6882
17	.1132	.0187	.0566		.6401	.6882
18	.132	.0187	.0377	.0943	.0747	.0747
19	.1307	.0185		.0943	.112	.0943
20	.1509	.0732	.132	.112	.112	.0934
21	.1307	.1254		.0943	.0934	.0934
22	.8802	.9602	.1307	.0943	.0747	.0754
23	.933	.933	.8002	.0934	.0747	.0747
24	.0747	.8855	.9172	.0934	.0934	.0747
Max	.933	1.3603	1.3279	.9804	.8855	.6882
Min	.0747	.0185	.0377	.0934	.0747	.0566
Avg	.1711	.4345	.4658	.3335	.3316	.2602

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.9962	1.1523	.0943	.0934	.0754
2	.0747	.9488	1.1336	.0934	.0943	.0747
3	.056	.9804	1.1203	.0934	.0943	.0747
4	.0747	1.1203	1.1203	.0934	.0934	.0934
5	.0747	1.1843	1.2651	.0943	.112	.0934
6	.0747	1.2651	1.4074	.0943	.1132	.0943
7	.0934	1.3757	1.5364	.112	.0943	.0943
8	.112	.0943	.132	.1132	.0934	.0943
9	.112	.1132	.1267	.112	.0943	.0943
10	.1307	.1132	.0943	.8223	.7186	.5218
11	.1132	.112	.0754	.9488	.7811	.6009
12	.132	.1307	.1132	.9602	.8855	.7116
13	.1307	.132	.132	.9804	.9646	.6958
14	.1307	.132	.132	1.0279	.9488	.7116
15	.132	.1307	.1494	.9804	.9962	.6483
16	.1132	.132	.1307	.9488	.9602	.6167
17	.1307	.132	.1494		.8002	.5693
18	.132	.1509	.168	.112	.0943	.0934
19	.1509	.2075	.1494	.1307	.0943	.0943
20	.168	.1698	.1307	.1132	.0943	.0934
21	.1307	.1698	.1494	.1132	.0943	.0934
22	.9962	1.1683	.1307	.0934	.0943	.0754
23	1.0753	1.2003	.8749	.0943	.0754	.056
24	.0754	1.0402	1.1702	.0934	.0943	.0754
Max	1.0753	1.3757	1.5364	1.0279	.9962	.7116
Min	.056	.0943	.0754	.0934	.0754	.056
Avg	.1870	.5500	.5310	.3617	.3575	.2686



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 248019 / 220KV Narwad Substation

Feeder No / Name : 804 / 220KV Mhaishal

Feeder KV- 220 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2709	.3086	.3353	.048	.0463	.0457	.0469
2	.2743	.3086	.3521	.0469	.0469	.048	.0474
3	.2778	.301	.3749	.0791	.0474	.0474	.0474
4	.3125	.3269	.4858	.096	.064	.08	.0791
5	.3269	.3462	.6154	.128	.0648	.0949	.1107
6	.4999	.4755	.6882	.1457	.1311	.1296	.1265
7	.6622	.7316	.8539	.1311	.1475	.1147	
8	.0949	.1107	.6874	.096	.112	.128	.144
9	.0949	.108	.0903	.104	.0533	.1067	.0857
10	.0857	.1094	.112	1.012		.933	
11	.0903	.0937		1.2163		1.0437	
12	.0949	.0695		1.1544		.884	.543
13	.08	.0686	.088	1.1248			.5357
14	.0686	.0514		.9877			.5281
15	.0602	.0674		.8796		.8078	.4311
16	.0772	.0372	.0762	1.0031		.8429	.4729
17	.0724	.0533	.0892	.8749	.7655	.7133	.431
18	.1158	.0686	.0753	.0556	.1174	.0823	
19	.1	.0937	.0937	.0791	.1235		.0807
20	.1235	.0903	.096	.0781	.108	.0743	
21	.0914	.0937	.0972	.0617	.0949	.0762	.0823
22	.3506	.3749	.0625	.0617	.0772	.0625	.1134
23	.3549		.0633	.0469	.0474	.0625	.1614
24	.2675	.3125	.3462	.0474	.0463	.0469	.0469
Max	.6622	.7316	.8539	1.2163	.7655	1.0437	.543
Min	.0602	.0372	.0625	.0469	.0463	.0457	.0469
Avg	.2020	.2001	.2841	.3983	.1231	.3059	.2165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1463	.132	.3041	.3239	.2743	.3077
2	.1478	.1478	.132	.3005	.3277	.2812	.3113
3	.1463	.1402	.132	.3077	.3277	.3201	.3113
4	.1448	1.4706	.1509	.3812	.3841	.3795	.3441
5	.1829	.181	.1886	.4588	.421	.4374	.4096
6	.2534	.2835	.3018	.5801	.6081	.5506	.4588
7	.2896	.2896	.3395	.8907	1.0688	.9762	
8	.2561	.2561	.2987	.4961	1.004	.9762	.8192
9	.6554	.5898	.1867	.1646	.0335	.2075	.1494
10	.7773	.6327	.8002	.181		.2241	
11	.7865			.1829		.1494	
12	.7537			.1478		.1494	.0924
13	.6478	.602	.9282	.1463			.0934
14	.6554	.7827		.1109			.1109
15	.6478			.112		.1307	.1109
16	.6554	.0617	.8322	.037		.112	.1109
17	.1448	.1448	.4915	.1463	.1463	.1494	.1307
18	.1791	.1448	.1494	.1448	.1646	.1494	
19	.1829	.1663	.1663	.1848	.2614		.1663
20	.2218	.2241	.2427	.2195	.2452	.2075	
21	.1867	.1886	.1886	.1848	.2263	.1886	.1698
22	.1848	.1698	.1698	.1829	.1698	.1698	.168
23	.1829		.3041	.3277	.3361		.132
24	.1448	.1448	.132	.3005	.3201	.2932	.3239
Max	.7865	1.4706	.9282	.8907	1.0688	.9762	.8192
Min	.1448	.0617	.132	.037	.0335	.112	.0924
Avg	.3573	.3384	.3134	.2705	.3746	.3163	.2485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.2622	.2241	.5468	.5735	.5182	.5992
2	.2984	.2469	.2241	.5335	.5801	.5571	.583
3	.3018	.2652	.3734	.6062	.5868	.583	.583
4	.3605	.3315	.415	.6706	.6706	.6962	.583
5	.4862		.6036	.9614	.7625	.9503	.7865
6	.664	.639	.7733	1.1145	1.2146	1.153	.9667
7	.5921	.502	.6224	1.3592	1.7764	1.6385	
8	.3601	.2881	.4668	.8381	1.2308	1.4737	1.3603
9	1.4419	1.0364	.3292	.2715	.3224	.2743	.3174
10	1.5061	1.0311	1.3763	.2149		.2402	
11	1.2631	1.1385		.2012		.2241	
12	1.3272	1.1405		.1791		.2241	.1867
13	1.166	.9362	1.2163	.1029			.1907
14	1.0364	1.0987		.0526			.1848
15	1.0722	1.1574		.0332		.2241	.1829
16	1.1142	.7095	1.4083	.0492		.2241	.1991
17	.285	.2149	.8029	.0497	.2743	.2614	.2561
18	.2743	.2715	.3174	.2865	.3801	.3361	
19	.3814	.2772	.3326	.394	.4066		.3921
20	.4557	.3921	.3921	.4706	.4294	.4527	
21	.3721	.3921	.3772	.4344	.3772	.3961	.3734
22	.2622	.2987	.3174	.2772	.2801	.2829	.3547
23	.2652	.2987	.5937	.5735	.6009	.6316	.2263
24	.2915	.2591	.2218	.5868	.5668	.5247	.6154
Max	1.5061	1.1574	1.4083	1.3592	1.7764	1.6385	1.3603
Min	.2622	.2149	.2218	.0332	.2743	.2241	.1829
Avg	.6614	.5734	.5694	.4503	.6490	.5651	.4706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.112	.0655	.1581	.2105	.176	.176
2	.1326	.1107	.0648	.1619	.2105	.1802	.16
3	.1296	.1094	.0995	.1966	.213	.2105	.16
4	.1619	.1543	.125	.3077	.2429	.3239	.2401
5	.1989	.1718	.16	.3315	.2915	.3841	.3077
6	.2294	.2622	.2294	.4915	.5636	.4752	.3725
7	.2458	.1966	.2294	.7125	.8583	.7449	
8	.1457	.1475	.1296	.3681	.7202	.5535	.4687
9	.583	.5601	.096	.0949	.112	.1311	.0949
10	.4588	.6009	.5218	.1134		.112	
11	.5312	.6081		.0972		.096	
12		.6405		.08		.096	.0625
13	.5335	.6327	.6718	.0791			.0625
14	.5268	.6562		.0791			.0587
15	.5944	.5335		.08		.0949	.0594
16	.547	.4816	.8002	.0781		.112	.0743
17	.0937	.061	.6401	.0772		.1235	.0791
18	.1235	.0926	.176	.0937		.1423	
19	.1389	.1296	.1619	.144	.1781		.128
20	.1802	.1638	.1638	.1619	.1781	.1581	
21	.1457	.1147	.1475	.1619	.1147	.1265	.128
22	.1147	.0983	.1134	.0972	.0972	.1107	.1265
23			.1898	.2031	.2056	.192	.0617
24	.128	.1147	.0648	.1524	.208	.1677	.192
Max	.5944	.6562	.8002	.7125	.8583	.7449	.4687
Min	.0937	.061	.0648	.0772	.0972	.0949	.0587
Avg	.2761	.2936	.2425	.1884	.2936	.2243	.1586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2957	.2263	.2452	.2587	.2452	.2452
2	.3018	.2957	.2263	.2452	.2614	.2452	.2452
3	.3018	.2926	.2641	.2855	.2534	.3018	.2263
4	.3326	.3258	.3206	.3772	.2743	.3772	.2829
5	.3292	.3292	.415	.4527	.3109	.4527	.415
6	.4887	.5249	.547	.5281	.4835	.5093	.4854
7	.5121	.5121	.5281	.547	.5487	.5658	
8	.4435	.3982	.4668	.4563	.4163	.4854	.4435
9	.362	.3475	.3982	.3658	.3475	.3841	.3511
10	.3292	.3475	.3658	.3258		.3326	
11	.2353	.3142		.2686		.2957	
12	.2926	.3109		.2561		.3142	.3174
13	.2896	.2772	.3109	.2534			.3174
14	.3077	.3142		.2507			.2987
15	.2743	.2957		.2715		.3142	.2614
16	.2896	.2896	.2957	.2561		.2772	.2353
17	.3292	.2743	.3326	.2865		.3511	.3224
18	.3439	.3366	.3734	.3292		.4251	
19	.439	.4572	.4024	.4163	.6516		.5041
20	.5249	.5175	.5281	.5121	.5729	.5281	
21	.4755	.4668	.5041	.4805	.5544	.4338	.4668
22	.4024	.415	.415	.3658	.4481	.3772	.3734
23	.3696		.3018	.2896	.3206	.2829	.2829
24	.2957	.2987	.2452	.2641	.2561	.2641	.2641
Max	.5249	.5249	.547	.547	.6516	.5658	.5041
Min	.2353	.2743	.2263	.2452	.2534	.2452	.2263
Avg	.3570	.3581	.3734	.3471	.3972	.3697	.3336

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply      NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING      UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0164	.0149	.0152	.0151	.0149	.0149
2	.0152	.0154	.0145	.016	.0151	.0152	.0149
3	.0152		.0137	.0166	.0152	.0145	.0149
4	.0154	.0158	.016	.0164	.0154	.0141	.0152
5	.0154	.016	.0156	.0152	.0151	.0152	.0156
6	.0151	.0301	.0166	.0145	.0149	.0152	.0156
7	.0151	.0297	.0164	.0312	.0149	.0301	
8	.0149	.0301	.0152	.032	.0301	.0332	.0312
9	.0151	.0297	.0147	.0141	.0309	.0312	.0152
10	.0149	.0312	.0152	.0297		.0156	
11	.0151	.0158		.0301		.0156	
12	.0151	.0143		.0149		.0156	.0152
13	.0147	.013	.0152	.0151			.0152
14	.0147	.013		.0151			.0152
15	.0145	.0131		.0149		.0156	.0152
16	.0149	.0126	.0152	.0149		.0152	.0152
17	.0301	.0149	.0152	.0149	.0149	.0152	.0152
18	.061	.0147	.0152	.0149	.0151	.0149	
19	.0617	.0139	.0154	.0151	.0149		.0152
20	.061	.013	.0147	.0297	.029	.0156	
21	.0316	.0135	.0139	.0301	.0602	.0156	.0152
22	.032	.0147	.0141	.0297	.0602	.0152	.0162
23	.0297		.0297	.0151	.0305	.0149	.0152
24	.0147	.0181	.0141	.0147	.0149	.029	.0149
Max	.0617	.0312	.0297	.032	.0602	.0332	.0312
Min	.0145	.0126	.0137	.0141	.0149	.0141	.0149
Avg	.0234	.0181	.0158	.0196	.0239	.0182	.0161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.7293	.6371	.2641	.2987	.3174	.2075
2	.4973	.7125	.5937	.2641	.2987	.3174	.1886
3	.4973	.679	.6401	.3018	.2957	.3361	.1886
4	.5571	.703	.9069	.3772	.3658	.3772	.2829
5	.6554	.7449	1.1203	.4715	.4344	.415	.3584
6	.9602	1.2651	1.5074	.547	.5014	.5281	.4904
7	1.4575	1.6358	1.6484	.4904	.543	.5228	
8	.3734	.2987	1.2963	.3961	.439	.4481	.3881
9	.2957	.2926	.2587	.3511	.362	.3547	.1478
10	.2926	.3326	.2614	1.4723		1.3763	
11	.2218	.2241		1.4899		1.6644	
12	.2218	.2378		1.2803		1.2003	.9393
13	.2195	.2561	.2614	1.2483			.9892
14	.2587	.2926		1.4419			.9878
15	.2926	.181		1.3123		1.2003	.9962
16	.3258	.2149	.2241	1.4864		1.2643	1.0402
17	.2926	.2103	.2987	1.3603	.3201	1.4083	.6554
18	.2896	.2686	.3547	.2896	.3326	.2614	
19	.3582	.3174	.3696	.3658	.4755		.2241
20	.362	.3547	.3921	.4024	.4854	.3772	
21	.2987	.3361	.3206	.362	.4108	.3018	.3174
22	.7682	.6958	.2987	.2926	.3547	.2829	.2801
23	.7362		.2829	.2957	.3174		.5138
24	.4858	.7125	.6019	.2641	.2987	.3174	.2263
Max	1.4575	1.6358	1.6484	1.4899	.543	1.6644	1.0402
Min	.2195	.181	.2241	.2641	.2957	.2614	.1478
Avg	.4671	.5085	.6138	.7011	.3843	.6636	.4959



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7362	.3189	.3641	.3544	1.1203	.9414	.8745
2	.7362	.3258	.3439	.3658	1.0911	.9503	.8642
3	.7116	.3224	.3155	.3506	1.1174	.8749	.8785
4	.7611	.3155	.3582	.4024	1.1633	1.0402	.8962
5	.7811	.3898	.5121	.5121	1.3763		.0572
6	1.0688	.567	.631	.6348	1.7166	1.587	1.2803
7	1.3603	.631	.5847	.6335	2.1872	1.8884	1.4403
8	.443	.4961	.5201	.5601	2.1664	1.8976	1.5546
9	1.2955	1.6964	.5609	.5601	.4344	.5028	.3898
10	1.4232	1.8461	1.917	.4656		.4207	.362
11	1.4737	1.6975	1.8842	.4163		.4252	.3292
12	1.5581	1.8084	1.8947	.4066		.394	.2378
13	1.4723	1.3441	1.8747	.394		.3544	.2427
14	1.5415	1.587	1.9919	.4075		.3582	.2427
15	1.6518	1.5895	2.0481	.4075		.3856	.2614
16	1.7901	1.0623	2.0934	.3258		.3856	.2561
17	.394	.5014	1.9334	.4207	.4607	.4477	.2743
18	.4344	.5028	.5601	.4525	.5068	.4344	.3361
19	.4961	.4961	.5853	.4572	.567	.4031	.3361
20	.4656	.4733	.5487	.4607	.5731	.394	.3734
21	.4075	.4656	.4887	.4656	.5316	.3544	.4024
22	.3506	.4207	.4572	.4572	.4854	.2896	.3439
23	.3258	.362	.4024	1.0883	1.0562	.9945	.8097
24	.7432	.3224	.3366	.3429	1.1069	.9962	.8962
Max	1.7901	1.8461	2.0934	1.0883	2.1872	1.8976	1.5546
Min	.3258	.3155	.3155	.3258	.4344	.2896	.0572
Avg	.9342	.8143	.9670	.4726	1.0389	.7270	.5808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1928	.6478	.6722	.7209	.1991	.1949	.1753
2	.1772	.6325	.7099	.7545	.197	.2254	.1791
3	.1791	.6401	.8421	.7625	.1949	.2507	.1772
4	.1949	.6642	.9172	.7865	.2378	.3012	.2103
5	.2328	.7449	1.0486	.9116	.2896	.3801	.2715
6	.3403	.8745	1.1363	.9995	.3658	.4207	.3721
7	.3012	1.4403	1.2342	1.3592	.4525	.4508	.3982
8	.3366	.3224	1.2809	1.278	.3898	.4298	.362
9	.3582	.3189	.4298	.3658	.3292	.3856	.3189
10	.3801	.3224	.4031	1.1336		1.2498	.8288
11	.3544	.3366	.3772	1.3108		.828	.852
12	.3045	.3982	.2926	1.2163		1.2955	.8951
13	.2804	.3641	.3174	.8848		1.2803	.9012
14	.2686	.333	.3109	1.4175		1.2651	.9116
15	.2835	.3544	.3174	1.3279		1.3279	.8288
16	.2507	.1991	.3361	1.4352		1.2929	.6249
17	.2454	.2865		1.267	1.2191	.9602	.6464
18	.2865	.3155	.3109	.2353	.3366	.2804	.2241
19	.3258	.3294	.3109	.2481	.3077	.2658	.2614
20	.3224	.2715	.2987	.2507	.3294	.2481	.2427
21	.2481	.2835	.2926	.2658	.3045	.2507	.2172
22	.7956	.6241	.2896	.2534	.2629	.2126	.2033
23	.7202	.6882	.7537	.2149	.2427	.2103	.1867
24	.1949	.6642	.6093	.7377	.1949	.2149	.1772
Max	.7956	1.4403	1.2809	1.4352	1.2191	1.3279	.9116
Min	.1772	.1991	.2896	.2149	.1949	.1949	.1753
Avg	.3156	.5023	.5866	.8391	.3443	.5926	.4361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.6401	.4586	.503	.181	.156	.0701
2	.1063	.6478	.463	.4915	.1829	.1791	.0709
3	.1075	.6325	.4696	.4973	.1772	.1578	.0716
4	.1086		.5312	.5533	.2033	.1991	.0724
5	.181	1.3927	.6081	.5735	.2218	.2254	.0895
6	.2149	.8002	.5243	.6133	.2534	.2561	.1254
7	.2126	1.0277	.8642	.9892	.2865	.2686	.124
8	.2149	.2172	.9646	1.1401	.3258	.2926	.1267
9	.2303	.2303	.3403	.3658	.3012	.3045	.128
10	.2534	.2896	.2947	1.004		.9646	
11	.2481	.2601	.3109	1.3603		1.0277	
12	.2328	.2507	.3361	1.3763		.9717	
13	.2126	.2103	.2801	1.3923		.9282	.547
14	.1753	.1949	.2378	1.3283		.5304	.503
15	.1791	.1448	.2378	1.3279		.9717	.5801
16	.181	.1578	.2926	1.2334		.9175	.6874
17	.2126	.2427	.3658	1.1822	.9804	.6958	.7468
18	.2534	.2865	.3841	.2172	.2601	.1791	.168
19	.2865	.2601	.3921	.2303	.2328	.1791	.2241
20	.2835	.2279	.3734	.2328	.2534	.181	.2229
21	.2328	.2126	.3258	.2195	.1772	.1433	.1772
22	.7362	.3795	.2896	.1949	.1402	.1448	.1227
23	.6642	.426	.5407	.181	.156	.1433	.128
24	.1086	.6478	.4321	.5304	.1772	.1612	.1063
Max	.7362	1.3927	.9646	1.3923	.9804	1.0277	.7468
Min	.1063	.1448	.2378	.181	.1402	.1433	.0701
Avg	.2393	.4252	.4299	.7391	.2653	.4241	.2425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1478	.1267	.1867	.1886	.132	.1463
2	.1848	.1463	.1509	.1715	.1698	.1463	.1478
3	.1698	.1494	.1663	.1829	.1663	.1307	.1494
4	.1698	.1478	.1829	.1886	.1848	.1663	.1478
5	.1867	.1867	.2075	.2012	.1848	.1886	.1494
6	.1886	.1886	.1867	.2195	.2054	.2195	.1848
7	.1867	.2218	.2534	.2103	.2263	.2172	.2241
8	.3018	.2263	.2957	.3361	.4668	.2033	.1867
9	.4435	.1494	.2743	.3361	.3511	.2263	.2263
10	.3584	.1829	.2641	.3921		.2195	.3109
11	.3361	.4108	.2987	.3772		.2218	.3109
12	.2587	.4344	.3361	.2587		.1829	.3292
13	.2195	.3881	.3109	.1886		.1417	.1867
14	.4668	.2561	.3174	.2587		.1463	.1867
15	.4481	.1886	.3109	.3547		.1267	.2427
16	.4108	.1848	.2614	.3772		.1478	.3174
17	.3326	.2012	.2926	.2641	.181	.1867	.3734
18	.4527	.2241	.3174	.3881	.2561	.1848	.4108
19	.5228	.2534	.4108	.3696	.3584	.2561	.5975
20	.4066	.2829	.3658	.3142	.3982	.2402	.5487
21	.2241	.2587	.3292	.2452	.3734	.1867	.3658
22	.2218	.2378	.2172	.2241	.3395	.1848	.2172
23	.1886	.181	.1991	.1848	.1829	.1463	.2012
24	.1848	.1867	.1494	.1829	.1848	.1448	.1494
Max	.5228	.4344	.4108	.3921	.4668	.2561	.5975
Min	.1698	.1463	.1267	.1715	.1663	.1267	.1463
Avg	.2937	.2265	.2594	.2672	.2599	.1811	.2630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0351	.0179			
8	.0358	.0354	.0366		.0177	
9	.0362	.0526	.0354		.0358	
10	.0732	.0532	.0366	.0358	.0366	.0373
11	.0724	.0732	.0366	.0362	.0358	.0373
12	.0739	.0716	.0373	.0366	.0362	.0373
13	.0724	.0724	.0373	.037	.0358	.0373
14	.0716	.0739	.0366	.0354		.0373
15	.0732	.0732	.0373	.0366	.0351	.0377
16	.0537	.0716	.0377	.037	.0351	.0377
17				.037		
24			.0177			
Max	.0739	.0739	.0377	.037	.0366	.0377
Min	.0358	.0351	.0177	.0354	.0177	.0373
Avg	.0625	.0612	.0334	.0365	.0335	.0374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1848	.1829	.181	.1848	.2054	.1463
2	.1848	.1886	.1629	.181	.1848	.1848	.1494
3	.1524	.1867	.1867	.1829	.1698	.1646	.1478
4	.1886	.1829	.2033	.2054	.1886	.1698	.1494
5	.2075	.2241	.2195	.2195	.2218	.1867	.1886
6	.2772	.2801	.2452	.2561	.2641	.2012	.2614
7	.2641	.2218	.2896	.2172	.2452	.2218	.2801
8	.3734	.3395	.3696	.2241	.1867	.3018	.3772
9	.5658	.7095	.6401	.2241	.1886	.3841	.439
10	.8215	.499	.7655	.8215		.2987	.5487
11	.8215	.679	.7468	.8488		.2829	.6036
12	.7545	.8215	.6219	.6099		.2218	.6584
13	.7167	.6335	.5487	.2452		.2402	.5544
14	.5975	.3658	.2561	.2587		.2195	.1463
15	.5041	.2829	.2427	.2801		.4527	.2987
16	.7167	.1478	.0747	.5729		.4108	.4108
17	.6224	.1829	.0914	.4338	.2054	.3881	.4481
18	.5228	.2054	.168	.6908	.3584	.3734	.4668
19	.4435	.2452	.168	.5281	.4207	.1867	.3734
20	.3361	.2534	.1829	.3206	.4706	.1848	.3292
21	.2218	.2218	.2012	.2033	.3696	.1867	.2629
22	.2241	.1829	.2195	.2075	.3018	.1463	.1928
23	.1848	.1991	.2012	.2054	.2054	.1494	.181
24	.2075	.1867	.2932	.1791	.1867	.2012	.1478
Max	.8215	.8215	.7655	.8488	.4706	.4527	.6584
Min	.1524	.1478	.0747	.1791	.1698	.1463	.1463
Avg	.4214	.3177	.3034	.3457	.2561	.2485	.3234

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV WAIFALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0953	.0762	.0762	.1143
2	.0762	.0762	.0953	.0762	.0762	.1143
3	.0762	.0762	.0953	.0762	.0762	.1143
4	.0762	.0762	.0953	.1143	.0953	.0953
5	.1143	.0953	.1334	.1524	.1143	.1143
6	.1905	.1715	.2096	.1905	.1905	.1524
7	.2096	.1715	.1905	.2096	.2286	.2096
8	.1334	.1524	.1524	.1524	.2286	.1524
9	.1143	.1143	.1143	.0953	.1143	.1334
10	.0953	.0953	.0953		.0953	.1143
11	.0762	.0953	.0762		.0953	.0953
12	.0762	.0762	.0762		.0953	.0762
13	.0953	.0762	.0572		.0953	.0762
14	.0953	.0762	.0572		.0953	.0572
15	.0762	.0762	.0572		.0953	.0762
16		.0762	.0572		.0762	.0762
17	.1143	.1143	.1334	.0953	.0762	.0762
18	.1143	.1524	.1715	.1143	.1143	.1143
19		.1905		.0953	.1524	.1715
20		.2096	.1905	.1143	.1715	.1905
21		.1524	.1524	.1905	.1715	.1334
22		.1334	.1143	.0953	.1143	.1143
23		.0953	.0762	.0953	.1143	.1143
24	.0762	.0762	.0953	.0762	.0762	.1143
Max	.2096	.2096	.2096	.2096	.2286	.2096
Min	.0762	.0762	.0572	.0762	.0762	.0572
Avg	.1048	.1127	.1127	.1188	.1183	.1167

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.1867	.1867	.1715	.1753
2	.0953	.1143	.1867	.1867	.1715	.1772
3	.0953	.1143	.1867	.1867	.1696	.1791
4	.0953	.1143	.1867	.1867	.1715	.1791
5	.1524	.1905	.3142	.2957	.2743	.2896
6	.3429	.3429	.5487	.4938	.4458	.4458
7	.381	.2858	.6219	.8507	.6859	.6516
8	.2477	.2477	.4938	.7783	.6516	.583
9	.6697	.1905	.1905	.1524	.1334	.1715
10	.0076	.5487	.1143		.1143	.1143
11	.5487	.5487	.0762		.1143	.1143
12	.5121	.567	.0953		.0762	.0953
13	.4938	.6036	.0953		.0762	.0953
14	.5487	.6036	.0953		.0762	.0953
15	.5304	.6219	.0572		.0762	.0762
16	.5304	.5487	.0762		.0762	.0572
17	.1524	.2987	.1143	.1334	.0762	.0762
18	.1334	.1524	.1334	.1715	.1143	.1524
19		.1715	.1905	.1524	.2096	.1715
20		.2096	.2286	.1715	.1905	.2096
21		.1905	.1715	.1715	.1715	.1715
22		.1715	.1524	.1715	.1715	.1524
23		.1867	.168	.1715	.1543	.1524
24	.0953	.1143	.1867	.1867	.1715	.1734
Max	.6697	.6219	.6219	.8507	.6859	.6516
Min	.0076	.1143	.0572	.1334	.0762	.0572
Avg	.3015	.3022	.2030	.2734	.1977	.1983



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.4525	.2858	.1715	.1524	.1715	.1524
2	.3475	.4525	.2858	.1715	.1524	.1524	.1524
3	.3475	.4525	.2858	.1715	.1524	.1524	.1524
4	.3475	.4525	.2858	.1715	.1524	.1715	.1715
5	.724		.381	.2477	.2477	.2477	.2096
6	1.1765		.7621	.4572	.4191	.4191	.2286
7	1.262		1.1393	.381	.4572	.4763	.4572
8	.3048		.7087	.3048	.3429	.381	.362
9	.2096		.2096	.2667	.2477	.2096	.2286
10	.1715		.1905	.8688		.7621	.4801
11	.1524		.1715	.8507		.6859	.4382
12	.1524		.1524	.905		.7888	.4031
13	.1524		.1524	.905		.6859	.4252
14	.1524		.1524	.9231		.703	.4382
15	.2096			.8507		.6859	.4207
16	.2096			.8326		.8745	.3856
17	.1905			.4805	.7202	.8745	.3856
18	.2096			.2096	.2667	.2667	.2286
19				.3048	.2667	.2667	.2667
20				.3429	.2667	.2477	.2858
21				.2667	.2667	.2477	.2667
22				.1715	.1715	.1905	.2286
23			.1715	.1715	.1715	.1715	.2858
24	.3439	.4525	.2858	.1715	.1524	.1715	.1524
Max	1.262	.4525	1.1393	.9231	.7202	.8745	.4801
Min	.1524	.4525	.1524	.1715	.1524	.1524	.1524
Avg	.3690	.4525	.3513	.4416	.2710	.4169	.3003

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express      NON SHEDDABLE EXPRESS HV FEEDERS  
 fdr Feeder KV- 11 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.04	.0305	.021	.0457	.0248	.0248
2	.04	.0305	.0229	.0419	.0248	.021
3	.0191	.0324	.0248	.0381	.0248	.0191
4	.0381	.0305	.0324	.0419	.0229	.0171
5	.0419	.0305	.0362	.0362	.0267	.0171
6	.0457	.0305	.0267	.0343	.0229	.0114
7	.0514	.0324	.0343	.0457	.0267	.0267
8	.021	.0343	.0248	.0267	.0191	.0229
9	.1715	.0286	.0305	.021	.0191	.0229
10		.021	.0133		.021	.0229
11	.0476	.0229	.0171		.0171	.021
12	.0171	.021	.0076		.0057	.0191
13	.0019	.0229	.0133		.0057	.0381
14	.0095	.0133	.0057		.0057	.04
15	.021	.0152	.0114		.0248	.0381
16	.0038	.0114	.0076		.0381	.0191
17	.0191	.0057	.0191	.0267	.04	.0229
18	.0191	.0114	.0248	.04	.04	.0267
19		.0229	.0229	.04	.0381	.0381
20		.0381	.0191		.0248	.0457
21		.0324	.0267	.04	.0267	.0248
22		.0362		.04	.0248	.0229
23		.0457	.0267	.0191	.0229	.0191
24	.0419	.0324	.0362	.0572	.0191	.0229
Max	.1715	.0457	.0362	.0572	.04	.0457
Min	.0019	.0057	.0057	.0191	.0057	.0114
Avg	.0361	.0264	.0220	.0372	.0236	.0252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2241	.2054	.6081	.6097	.4321	.4572
2	.2587	.2075	.1867	.6401	.6562	.4012	.4572
3	.2561	.2452	.2054	.6722	.703	.3858	.442
4	.2772	.2829	.2241	.7362	.8002	.4167	.4572
5	.2801	.3206	.2263	.8002	.8322	.4999	.4572
6	.3018	.3772	.3584	.8802	.8436	.7842	.6554
7	.3772	.3961	.3018	1.2643	1.2651	1.0753	.9217
8	.3206	.3734	.3018	1.1544	1.2018	1.1227	.8592
9	.9282	1.0883	.4294	.1494	.2987	.2587	.1829
10	1.0402	1.2483	1.0911	.4338		.3174	.2195
11	.9804	1.2323	.8962	.4338		.3547	.168
12	1.0402	1.1227	1.1203	.415		.3547	.1663
13	1.0155	.8535	1.2803	.3961		.2641	.1698
14	.8124		1.0562	.3174		.2452	.168
15	.759	.7621	1.2323	.3018		.2641	.1848
16	.9488	.6097	1.3599	.3584		.2987	.2033
17	.3174	.3439	1.2492	.3772	.3921	.2987	.1867
18	.3547	.3547	.4481	.3734	.4668	.2614	.2402
19	.3921	.3772	.3921	.3206	.3921	.3174	.2054
20	.3174	.3174	.3734	.3018	.415	.2801	.2241
21	.2614	.2829	.3206	.2801	.3206	.2241	.2075
22	.2263	.2452	.2075	.2427	.2829	.2075	.1698
23	.2054	.2452	.5601	.5487	.4938	.5155	.1698
24	.2054	.2054	.2054	.5761	.5792	.463	.4784
Max	1.0402	1.2483	1.3599	1.2643	1.2651	1.1227	.9217
Min	.2054	.2054	.1867	.1494	.2829	.2075	.1663
Avg	.5041	.5094	.593	.5243	.6208	.4185	.3355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.112	.1307	.3269	.5792	.4458	.3961
2	.1629	.1132	.1509	.3521	.6173	.4161	.3961
3	.181	.132	.132	.3814	.6481	.4268	.3814
4	.1829	.1509	.132	.4515	.703	.4515	.3961
5	.2033	.1886	.1509	.5487	.7499	.4967	.3961
6	.2241	.2452	.2452	.6173	.8002	.6859	.5721
7	.2801	.2614	.3018	.9568	1.2193	1.1736	.8916
8	.2012	.2218	.2054	.884	1.1888	1.1888	.9214
9	.8179	.7225	.1829	.1629	.2075	.1829	.1086
10	.9907	.8535	.8993	.1867		.2241	.1109
11	.7964	.8579	.8688	.1478		.1848	.1017
12	.7482	.6984	.7773	.168		.1646	.0848
13	.535	.9659	.945	.1663		.1463	.1214
14	.7145	.8916	1.0517	.181		.1663	.1595
15	.7042	.8215	1.0311	.1829		.1848	.1417
16	.6748	.5281	1.0623	.1267		.1848	.1063
17	.1372	.181	.9686	.1448	.2033	.1867	.1646
18	.1433	.2033	.1829	.2172	.2743	.1867	.1829
19		.2172	.1829	.181	.2772	.1867	.2195
20	.1663	.2402	.2402	.1848	.2987	.1494	.2033
21	.1829	.1867	.1867	.1663	.2241	.1494	.1867
22	.1478	.168	.1663	.1294	.2241	.132	.168
23	.128	.1307	.2675	.3418	.5053	.431	.1698
24	.1829	.128	.1307	.2972	.5335	.4755	.4108
Max	.9907	.9659	1.0623	.9568	1.2193	1.1888	.9214
Min	.128	.112	.1307	.1267	.2033	.132	.0848
Avg	.3770	.3842	.4414	.3126	.5443	.3592	.2913

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 207 / 11 KV Sawarde Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1132	.1132	.132	.168	.1132	.0943
2	.1478	.1132	.132	.132	.1848	.0943	.0943
3	.1478	.132	.1132	.132	.1867	.0943	.1132
4	.168	.1509	.1132	.1509	.168	.1132	.0943
5	.1886	.1698	.132	.1698	.1886	.132	.1132
6	.1698	.2075	.2075	.2075	.1886	.2263	.2263
7	.1867	.2054	.1886	.1867	.1698	.2075	.2263
8	.1294	.1294	.168	.1478	.1646	.168	.168
9	.1307	.1294	.1267	.1402	.128	.128	.1267
10	.1097	.1086	.124	.0724		.1267	.1109
11	.1075	.1063	.1267	.0732		.1063	.1063
12	.1075	.1063	.128	.0914		.1052	.0886
13	.1086	.1052	.112	.0914		.0876	.0732
14	.1086	.1052	.1097	.0732		.0905	.0895
15	.0914	.104	.1294	.0924		.0905	.0895
16	.0914	.1063	.128	.0924		.0895	.1063
17	.1052	.0886	.1097	.1052	.0914	.1086	.0905
18	.1227	.1254	.1086	.1387	.1387	.128	.1227
19	.1753	.1791	.1646	.1991	.2149	.2033	.181
20	.2378	.2587	.2033	.2353	.2801	.2614	.2353
21	.2195	.2054	.2241	.2241	.2614	.2241	.2054
22	.1698	.1886	.168	.1698	.1886	.1698	.1509
23	.132	.132	.1509	.132	.132	.132	.1132
24	.1307	.132	.1132	.1509	.1494	.1132	.1132
Max	.2378	.2587	.2241	.2353	.2801	.2614	.2353
Min	.0914	.0886	.1086	.0724	.0914	.0876	.0732
Avg	.1424	.1418	.1414	.1392	.1767	.1381	.1305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2622	.213	.0943	.0754	.0943	.0953
2	.2347	.2652	.213	.0943	.0754	.0943	.0953
3	.2486	.2818	.2321	.0943	.0943	.0943	.0953
4	.285	.3018	.2984	.1132	.132	.132	.1334
5	.3258	.3353	.3647	.1698	.2075	.1886	.1886
6	.3988	.8048	.547	.3395	.3018	.2829	.2641
7	.8162	1.1174	.9374	.3206	.2614	.2829	.3018
8	.1509	.2452	.5792	.2263	.2218	.2263	.1698
9	.1698	.1509	.1509	.1509	.1886	.1886	.132
10	.1132	.1509	.1629	.9922		.9014	.3953
11	.0943	.1886	.1433	.9995		1.012	.4475
12	.1075	.168	.1109	.9568		.9297	.4967
13	.1029	.1663		.7926		.7716	.4666
14	.0754			.7811		.7773	.5182
15	.0747			.8539		.7716	.4607
16	.0934			.8642		.6859	.4778
17	.1052	.1097		.7316	.7811	.6401	.4755
18	.1433	.1494		.168	.1494	.2054	.1494
19	.1698	.1848	.181	.1848	.168	.1509	.1867
20	.1867	.168	.1698	.2033	.1886	.2075	.1698
21	.1509	.1509	.1509	.112	.1509	.1509	.132
22	.2622	.2561	.132	.1132	.1509	.1132	.1143
23	.2622	.2105	.1132	.0943	.1132	.0943	.1802
24	.2229	.2622	.2105	.0943	.0943	.0943	.0953
Max	.8162	1.1174	.9374	.9995	.7811	1.012	.5182
Min	.0747	.1097	.1109	.0943	.0754	.0943	.0953
Avg	.2091	.2824	.2728	.3977	.1973	.3788	.2601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2477	.1886	.2096	.2075	.2263	.1905
2	.2263	.2477	.1886	.2096	.2075	.2263	.1905
3	.2641	.2477	.2075	.2096	.2452	.2452	.1905
4	.3584	.2858	.2641	.2477	.3206	.2829	.2477
5	.3961	.3395	.3395	.3584	.415	.3772	.3584
6	.4904	.4904	.4527	.5281	.5093	.5658	.4715
7	.4715	.415	.4527	.4338	.4527	.5041	.4904
8	.3361	.2801	.2957	.3326	.3547	.3326	.3547
9	.2926	.2218	.2481	.2534	.2241	.3439	.2772
10	.2012	.1848	.2033	.2378		.2353	.2054
11	.2172	.1663	.1991	.2172		.2328	.1848
12	.1991	.1848	.2172	.2218		.2303	.1646
13	.2012	.168	.2033	.2012		.2172	.1663
14	.168	.1886	.2218	.2033		.1663	.1478
15	.1886	.168	.1867	.2012		.181	.1478
16	.1867	.1867	.1867	.1494		.1494	.1629
17	.1867	.1991	.2241	.2012	.2195	.2195	.168
18	.2378	.2195	.2054	.2427	.2835	.2801	.2561
19	.3511	.3142	.2614	.3511	.3547	.3511	.3361
20	.4481	.4338	.4294	.4668	.4668	.4481	.4338
21	.3772	.3734	.415	.3395	.415	.415	.3395
22	.3018	.3018	.3395	.2829	.3206	.2829	.3018
23	.2452	.2452	.2667	.2452	.2641	.2263	.2096
24	.2452	.2477	.2075	.2286	.2263	.2263	.2096
Max	.4904	.4904	.4527	.5281	.5093	.5658	.4904
Min	.168	.1663	.1867	.1494	.2075	.1494	.1478
Avg	.2840	.2649	.2669	.2739	.3228	.2902	.2586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.0953	.0754	.6401	.7865	.6478	.6882
2	.1509	.0953	.0754	.6478	.7682	.6554	.7127
3	.1698	.0953	.0943	.6316	.8192	.6882	.7127
4	.1886	.1334	.1132	.6802	.8642	.7537	.7712
5	.2075	.1698	.1698	.8097	.8962	.8192	.8383
6	.2641	.2263	.2263	1.1142	1.065	1.0159	.9326
7	.2641	.2263	.2641	1.3763	1.3603	1.3599	1.0562
8	.3361	.1494	.1867	1.4089	1.5708	1.4737	1.0562
9	1.1336	1.3603	.1663	.1494	.1109	.124	.1663
10	1.4575	1.5546	1.4899	.1494		.1867	.112
11	1.5223	1.7204	1.5546	.1698		.2075	.0739
12	1.5061	1.587	1.4413	.168		.2054	.0739
13	1.4083	1.4575	1.668	.1494		.1698	.0934
14	1.4899	1.6385	1.6484	.1478		.1307	.0739
15	1.5893	1.4083	1.7284	.1307		.1478	.0739
16	1.5565	1.4575	1.7124	.132		.168	.0914
17	.1478	.112	1.6032	.1494	.168	.168	.0934
18	.1646	.128	.1848	.0934	.2241	.0895	.1478
19	.1867	.1698	.2075	.1478	.2452	.168	.1867
20	.2075	.1886	.2075	.1829	.2641	.1867	.168
21	.168	.132	.1698	.1494	.1698	.1509	.1509
22	.1132	.132	.132	.1132	.1509	.132	.1132
23	.0943	.0943	.7125	.6964	.7125	.6882	.0943
24	.1132	.0953	.0754	.6722	.7202	.6802	.6802
Max	1.5893	1.7204	1.7284	1.4089	1.5708	1.4737	1.0562
Min	.0943	.0943	.0754	.0934	.1109	.0895	.0739
Avg	.6072	.6011	.6628	.4463	.6409	.4591	.3817



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.2031	.1875	.0762	.0566	.0754	.0754
2	.2012	.2056	.1677	.0762	.0566	.056	.0754
3	.1966	.2056	.1677	.0566	.0566	.0554	.0754
4	.2458	.2267	.1875	.0754	.0754	.0732	.0754
5	.3353	.2429	.2401	.1132	.1132	.1307	.1334
6	.4578	.5281	.4191	.1886	.2075	.2075	.1905
7	.6401	.7274	.6882	.2075	.2075	.2263	.2263
8	.1509	.132	.4641	.1494	.1698	.1698	.1886
9	.1307	.0905	.1307	.1097	.0934	.0934	.132
10	.0554	.0554	.0934	.3913		.4012	.2469
11	.0532	.0747	.0747	.3864		.4012	.2543
12	.0549	.0934	.056	.3715		.4199	.2378
13	.0354	.0924	.0732	.362		.4489	.301
14	.0339	.0549	.0549	.3715		.4054	.2743
15	.056	.0554	.0747	.3227		.4054	.3269
16	.0554	.0747	.0732	.3567		.3243	.2347
17	.0366	.0934	.0709	.3041	.3749	.3144	.2559
18	.0724	.0934	.0732	.0895	.1267	.0732	.0739
19	.112	.112	.0934	.1109	.1294	.0934	.1132
20	.1509	.132	.132	.132	.132	.132	.1132
21	.132	.132	.132	.1132	.132	.1132	.1132
22	.2561	.2241	.0566	.1132	.1132	.0943	.0943
23	.2401	.192	.1132	.0754	.0943	.0943	.0754
24	.2031	.2031	.1875	.0953	.0566	.0754	.0754
Max	.6401	.7274	.6882	.3913	.3749	.4489	.3269
Min	.0339	.0549	.0549	.0566	.0566	.0554	.0739
Avg	.1719	.1769	.1671	.1937	.1292	.2035	.1651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0693	.052	.1715	.1296	.1429	.1372
2	.0514	.0709	.052	.176	.1238	.1486	.1235
3	.0526	.0709	.0526	.1524	.1257	.1524	.1217
4	.0701	.0716	.0532	.1875	.1315	.1852	.1269
5	.0914	.0724	.0709	.25	.1488	.2812	.1656
6	.1109	.1478	.1307	.3163	.2787	.3437	.2846
7	.1448	.1478	.168	.4111	.4666	.4167	.4108
8	.0191	.0895	.1086	.3121	.362	.3311	.3913
9	.0511	.3477	.0895	.0648	.0838	.0678	.1075
10	.0511	.3567	.3161	.0693		.0686	.0914
11		.4344	.3338	.0332		.0663	.0732
12	.4054	.5213	.443	.0469		.0655	.0648
13	.3894	.4938	.443	.0633		.0617	.0446
14	.3755	.4715	.3286	.1097		.064	.0312
15	.4344	.423	.3814	.0716		.0663	.064
16	.4607	.3292	.4371	.0701		.0671	.0417
17	.0701	.0663		.0663	.0716	.0655	.0532
18	.0886	.0905	.0503	.0655	.0886	.0886	.0886
19	.0678	.0914	.1097	.0876	.0914	.0895	.1294
20	.1075	.1109	.112	.1075	.112	.1307	.1109
21	.1086	.1109	.112	.0914	.1132	.1132	.1109
22	.0895	.0914	.0914	.0724	.0924	.0943	.0934
23	.0876	.0732	.1829	.1555	.1692	.1715	.0934
24	.0503	.0693	.052	.1669	.1425	.2503	.141
Max	.4607	.5213	.443	.4111	.4666	.4167	.4108
Min	.0191	.0663	.0503	.0332	.0716	.0617	.0312
Avg	.1498	.2009	.1813	.1383	.1607	.1472	.1292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0474	.0486	.0762	.0446	.0572	.0503
2	.0572	.0474	.0486	.0572	.0503	.0572	.0497
3	.0572	.0503	.0492	.0572	.0503	.0572	.0497
4	.0762	.0503	.0503	.0762	.0509	.0572	.0509
5	.0953	.0671	.0678	.0953	.0678	.0762	.0701
6	.1143	.1097	.1097	.1143	.0905	.0953	.0905
7	.1334	.1132	.1132	.0953	.1132	.1334	.1109
8	.1905	.0953	.1132	.0762	.0739	.0762	.1109
9	.2263	.1494	.3018	.1524	.0724	.1524	.1463
10	.2286	.1267	.2452	.2641		.2286	.1488
11	.3174	.2452	.2641	.2801		.2477	.1905
12	.2263	.2452	.2286	.2667		.2452	.1905
13	.0476	.2263	.0495	.0412		.2075	.1524
14	.048	.1463	.0739	.032		.0417	.1905
15	.2641	.1867	.2957	.2715		.2286	.2452
16	.1698	.2096	.2477	.2614		.1905	.1905
17	.1265	.1886	.3258	.1848	.0953	.2477	.2507
18	.2829	.1886	.0762	.3109	.0953	.2452	.2801
19	.0934	.1886	.0953	.2054	.0953	.1698	.1143
20	.1143	.1509	.1143	.0943	.1143	.1132	.0953
21	.0934	.1132	.1143	.0924	.0762	.0934	.0953
22	.0732	.0754	.0762	.0701	.0762	.0716	.0953
23	.0625	.0655	.0762	.0486	.0762	.0716	.0953
24	.0572	.0474	.0463	.0762	.0446	.0572	.0686
Max	.3174	.2452	.3258	.3109	.1143	.2477	.2801
Min	.0381	.0474	.0463	.032	.0446	.0417	.0497
Avg	.1331	.1306	.1347	.1375	.0757	.1342	.1305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1132	.1109	.1109	.1132	.1132
2	.132	.132	.0943	.1109	.1109	.1132	.0943
3	.132	.132	.0943	.1109	.1109	.0943	.0943
4	.132	.132	.132	.1109	.1109	.1132	.132
5	.1886	.1886	.1698	.1478	.1478	.132	.1698
6	.3361	.3547	.2241	.2427	.2641	.2987	.2241
7	.3511	.3174	.2829	.2772	.2829	.2801	.2772
8		.2195	.1867	.1829	.2561	.2054	.2054
9	.2587	.1791	.1478	.1543	.2103	.1494	.1698
10	.181	.1494	.1663	.1402		.132	.1494
11	.1509	.2054	.1463	.1448		.1132	.1478
12	.0943	.0934	.1463	.1063		.1132	.1097
13	.0747	.1132	.128	.1052		.0943	.1097
14	.0943	.132	.1254	.1227		.0943	.1097
15	.0943	.0934	.1214	.1227		.0943	.1227
16	.0943	.1109	.1372	.124		.1109	.1227
17	.1267	.132	.1341	.1886	.1509	.1494	.1227
18	.1463	.168	.1907	.1907	.1829	.1829	.1612
19	.1829	.2054	.1907	.2353	.2218	.2587	.2012
20	.2614	.2402	.2686	.2427	.2926	.3258	.2402
21	.1886	.1886	.1848	.1698	.2054	.2241	.1848
22	.1509	.1509	.1478	.1509	.1698	.1848	.132
23	.1509	.132	.1294	.1307	.132	.1494	.0943
24	.132	.132	.132	.1109	.112	.112	.1132
Max	.3511	.3547	.2829	.2772	.2926	.3258	.2772
Min	.0747	.0934	.0943	.1052	.1109	.0943	.0943
Avg	.1646	.1681	.1581	.1556	.1807	.1600	.1501

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0754	.0754	.2286		.2267	.253
2	.056	.0747	.0566	.2258		.2214	.2812
3	.056	.0747	.0566	.2286		.2561	.2267
4	.056	.0747	.0943	.2315		.2949	.1966
5	.112	.1307	.132	.2688		.3593	.2652
6	.2075	.2263	.1494	.3647		.759	.3163
7	.2075	.2263	.1886	.5992		.6478	.4481
8	.1509	.168	.1698	.3593		.5601	.3749
9	.5761	.5247	.0924	.112		.112	.1294
10	.5851	.4744	.4428	.0732		.0943	.0739
11	.4687	.578	.463	.0739		.0934	.056
12		.6019	.4572	.0526			.0549
13		.6642	.4877	.0526			.0362
14	.5864	.6401	.5335	.0354			.0362
15	.6249	.6009	.5487	.0554			.0537
16	.6636	.4725	.5792	.0543			.0543
17	.1097	.1109	.4401	.0739	.0754		.0543
18	.0914	.0934	.0716	.0554	.1898	.0924	.0934
19	.1307	.112	.0943	.1132	.1132	.1867	.1132
20	.1698	.132	.1509	.1698	.168	.1663	.1494
21	.1509	.1132	.132	.132	.132	.132	.112
22	.1132	.0934	.0943	.0943	.1132	.0943	.0943
23	.0943	.0754	.2656		.2591	.2591	.0566
24	.0566	.0754	.0566	.2439		.192	.2561
Max	.6636	.6642	.5792	.5992	.2591	.759	.4481
Min	.056	.0747	.0566	.0354	.0754	.0924	.0362
Avg	.2420	.2672	.2430	.1695	.1501	.2638	.1577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.0625	.0983	.0566	.0566	.0566	.056
2	.1006	.0633	.1006	.0566	.0566	.0566	.0566
3	.1017	.0633	.1372	.0566	.0566	.0754	.0754
4		.0633	.1417	.0566	.0566	.0754	.0943
5		.0633	.1886	.1132	.1132	.1478	.1294
6		.2452	.25	.1698	.2075	.2241	.2054
7		.1886	.4744	.1698	.1886	.1886	.1886
8		.1109	.3077	.1307	.1494	.1509	.1509
9	.112	.0924	.0739	.1109	.0716	.0934	.0924
10	.0686	.0934	.0554	.3041		.2561	.208
11	.0549	.0747	.0549	.3361		.3321	.1219
12	.0554	.0747	.0549	.2846		.4475	.1337
13	.0554	.0747	.0366	.2932		.4744	.1337
14	.0543	.0739	.0366	.2881		.3395	.1486
15	.0732	.0566	.0537	.2846		.3163	.2347
16	.0781	.0566	.0537	.1981		.2896	.2027
17	.0857	.0754	.0716	.2031	.2801	.2561	.1303
18	.0876	.0934	.0724	.0701	.0924	.1109	.0543
19	.1267	.1132	.0732	.1086	.1307	.168	.0934
20	.132	.1478	.0943	.1307	.1478	.1294	.0943
21	.112	.112	.0754	.0934	.112	.0943	.0566
22	.1562	.1372	.0754	.0747	.0754	.0754	.0566
23	.1389	.0937		.056	.0566	.0566	.081
24	.1067	.061	.0914	.0566	.056	.0566	.0566
Max	.1562	.2452	.4744	.3361	.2801	.4744	.2347
Min	.0543	.0566	.0366	.056	.056	.0566	.0543
Avg	.0944	.0955	.1162	.1543	.1122	.1863	.1190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2241	.1867	.1867	.2303	.2263	.2058
2	.2103	.2012	.1848	.1867	.2103	.2263	.1907
3	.208	.1991	.1829	.181	.2058	.2263	.1949
4	.1886	.2033	.1867	.1848	.1991	.2452	.1928
5	.1949	.2195	.2033	.2054	.1949	.2829	.2353
6	.2629	.3109	.2614	.2957	.2507	.3206	.2303
7	.2896	.2614	.2402	.2743	.2715	.3206	.2686
8	.2587	.2218	.2427	.2033	.1928	.2402	.2926
9	.2096	.2241	.2033	.2054	.2172	.2075	.1905
10	.1715	.1848	.1991	.1663			.1478
11	.132	.1848	.1848	.1595		.1478	.1463
12	.132	.1905	.1663	.1254		.128	.1307
13	.1509	.1698	.1848	.12		.1772	.1307
14	.1494	.1698	.1478	.0905		.1753	.1294
15	.1494	.1698	.1478	.0867			.1494
16	.1524	.168	.1448	.0876			.1663
17	.1524	.1698	.1578	.1629	.2561		.168
18	.1867	.2054	.1646	.2103	.2263		.2263
19	.2402	.2427	.2353	.2686	.2641	.2865	.2641
20	.2801	.2987	.3077	.3292	.3142	.3439	.3206
21	.3292	.2772	.3018	.2804	.3018	.2629	.2829
22	.2801	.2743	.2772	.2481	.2829	.2481	.2477
23	.2427	.2427	.2218	.2587		.2534	.1848
24	.2402	.2263	.2033	.2054	.2353		.2103
Max	.3292	.3109	.3077	.3292	.3142	.3439	.3206
Min	.132	.168	.1448	.0867	.1928	.128	.1294
Avg	.2102	.2183	.2057	.1968	.2408	.2399	.2045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3593	.1829	.1867	.1829	.7562	.5138	.571
2	.3563	.1867	.1848	.168	.8078	.5668	.6325
3	.3241	.1848	.1848	.1663	.8905	.5535	.6962
4	.3361	.181	.1829	.1629	.9555	.6249	.703
5	.4144	.2012	.1867	.1867	1.0082	.7468	.7682
6	.442	.2987	.2033	.2402	1.1603	.9482	.8192
7	.5937	.2587	.2801	.2743	1.4074	1.3094	.8583
8	.2286	.2427	.2218	.2402	1.4506	1.3077	.6483
9	.7432	1.1584	.2195	.2241	.1905	.2075	.1524
10	.9722	1.3717	1.9959	.2286		.2096	.1097
11	1.078	1.3735	1.7976	.2096		.2096	.0934
12	1.0082	1.3748	1.6549	.2096		.2096	.112
13	.8745	1.4083	1.5364	.2096		.2096	.0924
14	.953	1.2651	1.5623	.1905		.1905	.0754
15	.9842	1.4575	1.4815	.1905			.0747
16	1.1111	1.4582	1.448	.1905		.1905	.0924
17	.1698		1.0562	.1715	.1829	.1334	.1494
18	.1848	.1867	.2241	.2096	.2218	.1334	.1509
19	.2241	.1867	.2033	.2096	.1848	.1715	.1509
20	.2614	.2218	.2427	.2286	.2033	.1905	.2075
21	.2587	.2241	.2195	.2096	.2054	.1715	.2075
22	.2241	.2218	.1991	.2096	.2054	.1715	.1715
23	.1867	.2054	.1867	.6562		.4999	.3887
24	.3506	.1848	.1829	.1848	.7125		.5335
Max	1.1111	1.4582	1.9959	.6562	1.4506	1.3094	.8583
Min	.1698	.181	.1829	.1629	.1829	.1334	.0747
Avg	.5266	.6102	.6601	.2231	.6589	.4304	.3525



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.5668	.6401	.5243	.1509	.132	
2	.1509	.5441	.6226	.4687	.132	.1509	
3	.1509	.5121	.6009	.4572	.132	.132	
4	.1886	.5312	.6154	.463	.132	.132	
5	.2075	.6009	.6722	.5376	.1698	.1698	
6	.2452	.9374	.9755	.679	.2263	.2075	
7	.2641	1.2803	1.2654	1.1248	.2641	.2427	
8	.2054	.1848	1.1043	1.2809	.2641	.2614	
9	.1848	.1867	.2378		.1867	.168	
10	.1478			1.166		.8688	
11	.1478			1.2643		.9122	.192
12	.1097			1.358		.9511	.3277
13	.1097			1.4089		1.1336	.7042
14	.0914			1.2654		1.1683	.7748
15	.0914			1.2483			.7682
16				1.0623		1.1728	.703
17				.9181	.9297	.6859	.8078
18	.1307			.1928	.1646	.1949	.1267
19	.1267			.1991	.1663	.2012	.1867
20	.1867	.2195	.2743	.1886	.1663	.2241	.168
21	.1663	.1867	.2218	.1886	.1663	.1886	.1509
22	.6097	.8078	.2054	.1494	.1478	.1698	.132
23	.5937	.759	.6062	.1509		.1698	.1132
24	.1698	.5693	.6562	.5601	.1509		
Max	.6097	1.2803	1.2654	1.4089	.9297	1.1728	.8078
Min	.0914	.1848	.2054	.1494	.132	.132	.1132
Avg	.2022	.5633	.6213	.7329	.2219	.4381	.3966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2896	.2561	.3292	.3584	.3142	.2829
2	.3018	.2987	.2427	.3174	.3018	.2957	.2452
3	.3018	.3018	.2402	.3077	.3018	.2957	.2452
4	.3206	.2987	.2402	.3142	.2829	.3142	.2641
5	.3206	.2987	.2743	.3174	.2829	.3511	.2829
6	.3395	.3361	.3174	.3292	.3206	.3696	.3395
7	.3395	.2772	.3511	.3547	.3206	.3326	.3772
8	.2987	.2614	.2987	.3326	.2829	.2957	.3361
9	.2957	.2561	.2926		.2427	.2772	.3109
10	.2402	.2402	.2378	.2103		.2378	.2801
11	.2402	.2218	.2378	.2229		.2303	.2402
12	.2587	.2402	.2378	.1928		.2218	.2241
13	.2772	.2402	.2195	.2402		.2328	.2195
14	.2772	.2772	.2195	.2427		.2402	.2241
15	.2772	.2587	.2402	.2149			.2218
16	.2587	.2587	.2801	.2743		.2534	.2427
17	.2772	.2587	.2801	.2534	.2772	.2658	.2561
18	.3077	.3109	.3077	.298	.3511	.3439	.3326
19	.3734	.3982	.4066	.394	.4066	.3841	.4435
20	.439	.4572	.4706	.462	.462	.4481	.4251
21	.4251	.4251	.4024	.415	.4066	.3961	.3696
22	.3696	.3921	.4108	.3772	.3696	.3584	.3326
23	.3361	.3258	.3881	.3584		.3206	.2772
24	.3395	.3142	.2772	.3734	.3584		.2829
Max	.439	.4572	.4706	.462	.462	.4481	.4435
Min	.2402	.2218	.2195	.1928	.2427	.2218	.2195
Avg	.3148	.3016	.2971	.3101	.3329	.3082	.2940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.0554	.0566	.056	.0876	.3953	.3001
2	.2778	.0543	.056	.0554	.0857	.4744	.2896
3		.0554	.0566	.056	.0709	.4687	.2972
4	.3077	.056	.0566	.056	.0693	.5155	.3462
5	.3361	.0747	.056	.0924	.0716	.578	.3429
6	.3658	.0914	.0914	.112	.0924	.6327	.4715
7	.3807	.128	.0934	.1109	.0905	.8173	.5639
8	.0716	.112	.0914	.112	.4877	.888	.6226
9	.4108	.7968	.0934	.0934	.0537	.0655	.0655
10	.5719	1.25	.953	.0886		.0876	.0739
11	.679	.9722	1.0648	.0924		.0905	.056
12	.6773	.9842	1.0957	.0876		.0857	.0747
13	.6923	1.0155	1.1111	.0857		.0876	.0554
14	.6923	.9332	1.0802	.0905		.0724	.056
15	.7225	.945	1.0974	.0876			.0554
16	.7526	.9602	1.1138	.0895		.0497	.056
17	.0686	.0983	.743	.0876	.0732	.0676	.0566
18	.0747	.0934	.0747	.0876	.0743	.0762	.0463
19	.0914	.0739	.0914	.0895	.0663	.0648	.0492
20	.0924	.0934	.0747	.0886	.0663	.064	.0514
21	.0747	.0739	.0747	.0876	.0526	.0625	.0537
22	.0739	.0747	.0934	.0886	.0526	.064	.0537
23	.0739	.0747	.0732	.0895		.333	.2787
24	.301	.056	.056	.0747	.0867		.2881
Max	.7526	1.25	1.1138	.112	.4877	.888	.6226
Min	.0686	.0543	.056	.0554	.0526	.0497	.0463
Avg	.3519	.3801	.3937	.0858	.0988	.2746	.1919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.8421						
23	.1372		.132			.2968	.2968
24	.4531	.1372	.1478	.132	.3715	.6268	.3864
Max	.8421	.1372	.1478	.132	.3715	.6268	.3864
Min	.1372	.1372	.132	.132	.3715	.2968	.2968
Avg	.4775	.1372	.1399	.132	.3715	.4618	.3416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0514						
23	.4755		.1823			.0857	.1132
24	.0943	.4755	.4515	.2949	.0739	.1698	.0857
Max	.4755	.4755	.4515	.2949	.0739	.1698	.1132
Min	.0514	.4755	.1823	.2949	.0739	.0857	.0857
Avg	.2071	.4755	.3169	.2949	.0739	.1278	.0995

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.1494						
23	.2427		.2263			.1646	.2075
24	.2263	.2241	.2957	.2075	.1886	.2641	.1463
Max	.2427	.2241	.2957	.2075	.1886	.2641	.2075
Min	.1494	.2241	.2263	.2075	.1886	.1646	.1463
Avg	.2061	.2241	.261	.2075	.1886	.2144	.1769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0373						
23	.0732		.0754			.0732	***
24	.0762	.0732	.112	.0754	.0566	.0754	.0732
Max	.0762	.0732	.112	.0754	.0566	.0754	17.0508
Min	.0373	.0732	.0754	.0754	.0566	.0732	.0732
Avg	.0622	.0732	.0937	.0754	.0566	.0743	8.562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.7209						
23	.0343		.1886			.4458	.415
24	.5344	.1715	.1867	.1509	.4858	.6173	.4755
Max	.7209	.1715	.1886	.1509	.4858	.6173	.4755
Min	.0343	.1715	.1867	.1509	.4858	.4458	.415
Avg	.4299	.1715	.1877	.1509	.4858	.5316	.4453



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.3239						
23	.0343		.0377			.1337	.1475
24	.144	.0343	.056	.0377	.1486	.0566	.1337
Max	.3239	.0343	.056	.0377	.1486	.1337	.1475
Min	.0343	.0343	.0377	.0377	.1486	.0566	.1337
Avg	.1674	.0343	.0469	.0377	.1486	.0952	.1406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.8223	.6882	.6478	.0572		.132
2	.1494	.8002	.6722	.6154	.0566	.1334	.132
3	.1494	.7865	.6478	.6226	.0572	.1307	.132
4	.1698	.7865	.6478	.663	.056	.1509	.1509
5	.1905	.8619	.664	.6796	.0943	.1524	.1509
6	.2075	.9945	.7537	.7377	.1219	.1905	.2075
7	.2263	1.2452	.9175	.8684	.1132	.2075	.2075
8	.168	.1867	.852	.9069	.1056	.1698	.1509
9	.2054	.2614	.1848	.1494	.0943	.1494	.1698
10	.2263	.2641	.1886	1.2431	.421	1.4918	1.1469
11	.2075	.2641	.1886	1.4746	.4641	1.6575	1.2452
12	.1886	.2801	.2054	1.5893	.5121	1.7404	1.2955
13	.2263	.2263	.2241	1.8785	.5281	1.6766	1.3117
14	.2452	.2241	.2075	1.6385	1.8679	1.7901	1.3272
15	.2452	.2054	.1886	1.5402	1.7404	1.8564	1.3435
16	.2218	.2241	.2263	1.3757	1.4752	1.4419	1.3927
17	.2241	.2241	.1848	1.3765	1.5074	1.5074	1.3123
18	.2241	.2033	.2378	.0943	.1829	.181	.1753
19	.2218	.1494	.2218	.1307	.168	.0381	.1646
20	.2241	.1867	.2263	.1509	.1698	.1886	.1829
21	.2054	.1698			.1698	.1698	.1774
22	.8745	.7682	.2075	.0754	.1698	.1698	.1646
23	.9012	.7042	.7209	.0754	.1509	.1509	.1463
24	.1698	.8381	.6958	.7045	.0572	.1509	.132
Max	.9012	1.2452	.9175	1.8785	1.8679	1.8564	1.3927
Min	.1494	.1494	.1848	.0754	.056	.0381	.132
Avg	.2601	.4866	.4327	.8365	.4309	.6737	.5397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1509	.1524	.1334	.1334	.1143
2	.132	.132	.1524	.132	.1132	.1132	.1143
3	.1307	.112	.1334	.1307	.112	.112	.1143
4	.1307	.1097	.1334	.168	.0914	.1307	.1524
5	.1886	.1494	.1524	.1886	.1294	.1698	.1509
6	.2075	.2263	.1886	.2263	.2096	.2075	.1905
7	.2075	.2241	.2054	.2427	.1886	.2452	.2452
8	.1494	.1829	.1867	.168	.168	.1867	.2075
9	.1494	.1494	.1478	.1494	.1494	.1494	.1478
10	.1267	.0924	.1478	.1463	.0924	.1478	.1463
11	.1463		.0549	.1086	.0914	.1097	.1109
12	.1463	.1463	.056	.0914	.0914	.0732	.0934
13	.0934	.1097	.056	.0924	.0747	.0366	.0747
14	.0754	.0943	.1478	.0747	.0924	.0732	.0747
15	.0943	.0934	.1478	.0934	.0739	.0739	.056
16	.0943	.0747	.1478	.0934	.0934	.037	.0924
17	.0739	.1086	.1509	.1109	.0739	.0724	.1086
18	.128	.1448	.1448	.1463	.1463	.1791	.128
19	.181	.1646	.1753	.1867	.181	.2241	.2012
20	.2378	.2402	.2402	.2402	.2241	.2427	.2218
21	.2263	.2218	.2263	.2241	.2075	.2427	.2241
22	.1886	.1886	.2263	.1886	.1886	.2075	.2054
23	.168	.1509	.1698	.168	.1509	.1524	.1524
24	.1524	.1524	.1509	.1524	.1334	.1334	.1143
Max	.2378	.2402	.2402	.2427	.2241	.2452	.2452
Min	.0739	.0747	.0549	.0747	.0739	.0366	.056
Avg	.1492	.1487	.1539	.1531	.1338	.1439	.1434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2075	.2667	.2241	.2241	.2075
2	.2263	.2075	.2075	.2427	.2075	.2263	
3	.1886	.2012	.2096	.2241	.1886	.2263	.1886
4	.2667	.1867	.2286	.2534	.1905	.2477	.2075
5	.3048	.2587	.2477	.3018	.2641	.2858	.2263
6	.4001	.3881	.3772	.4001	.3961	.362	.3584
7	.4481	.3547	.3772	.4294	.3547	.415	.381
8	.3658	.2829	.3174	.3696	.3048	.3584	.3206
9	.3326	.2218	.2926	.2587	.2286	.2743	.2452
10	.2804	.2587	.2561	.2896	.2328	.2402	.1905
11	.2715	.2957	.2743	.2507	.2481	.2172	.2263
12	.3258	.2896	.2561	.2481	.2481	.2401	.2054
13	.2957	.2402	.2263	.1524	.1867	.2402	.2427
14	.2641	.2218	.2427	.1698	.1509	.2218	.2241
15	.3224	.2402	.2801	.1886	.1753	.2328	.2075
16	.2743	.2481	.2427	.2353	.1928	.2195	.2561
17	.2263	.2534	.2896	.2172	.208	.2865	.2229
18	.2614	.2507	.3506	.2561	.2865	.415	.2561
19	.3206	.2772	.2926	.3511	.2987	.3696	.3361
20	.4294	.4024	.4481	.3841	.3584	.4108	.3841
21	.3921	.3734	.4294	.3696	.3584	.3429	.3584
22	.2987	.2829	.3772	.2987	.3206	.2858	.2987
23	.2614	.2452	.3018	.2829	.2641	.2263	.2263
24	.2427	.2263	.2075	.2667	.2241	.2427	.2054
Max	.4481	.4024	.4481	.4294	.3961	.415	.3841
Min	.1886	.1867	.2075	.1524	.1509	.2172	.1886
Avg	.3010	.2680	.2892	.2795	.2547	.2838	.2598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9012	.2614	.1509	.2477	1.2289	1.065	1.0202
2	.8583	.2378	.1509	.2286	1.1934	1.0322	1.0202
3	.9667	.2402	.1509	.1867	1.1469	.9945	1.0159
4	.9945	.2427	.1698	.2054	1.1603	1.0608	1.065
5	1.0277	.2829	.1886	.2641	1.2452	1.1469	1.0814
6	1.073	.3395	.2614	.3395	1.4255	1.2431	1.1797
7	1.1633	.2987	.2241	.3395	1.6057	1.5249	1.3426
8	.2075	.2772	.2427	.2772	1.7368	1.7404	1.4586
9	1.4746	1.7901	.2427	.2957	.2427	.2402	.2241
10	1.6712	1.8364	1.8564	.1829	.2241	.2427	.1867
11	1.8842	2.0153	1.917	.1646	.2241	.2614	.1867
12	1.7695	2.1216	1.9725	.2534	.2587	.2427	.1663
13	1.8023	1.8187	1.989	.2218	.2033	.2241	.1848
14	1.8187	1.8515	1.9725	.2033	.2218	.2241	.168
15	1.7859	1.6004	1.9725	.2241	.1663	.2241	.1867
16	1.8351	1.5813	1.9006	.2402	.1867	.1867	.1663
17	.2033	.1991	1.7204	.2801	.2218	.1867	.1867
18	.2427	.1848	.2378	.2614	.2427	.1867	.2054
19	.2587	.2241	.2587	.2641	.2054	.2054	.2054
20	.2926	.2427	.2987	.2829	.2452	.2427	.2241
21	.2987	.2263	.3018	.2614	.2452	.1867	.2075
22	.2987	.2075	.2641	.2075	.2263	.168	.1886
23	.2801	.1886	.2452	1.2616	1.1469	1.085	1.1273
24	.9503	.2614	.1698	.2452	1.2616	1.1142	1.0364
Max	1.8842	2.1216	1.989	1.2616	1.7368	1.7404	1.4586
Min	.2033	.1848	.1509	.1646	.1663	.168	.1663
Avg	1.0025	.7721	.7858	.2891	.6777	.6262	.5848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	1.2651	1.0623	1.1203	.1494	.1494	.1509
2	.1143	1.2643	1.0467	1.1012	.1509	.1494	.132
3	.1143	1.2483	1.0437	1.065	.1334	.132	.132
4	.1334	1.2018	1.0279	1.1305	.132	.1524	.1509
5	.1886	1.4083	1.0437	1.1984	.168	.1905	.1509
6	.2241	1.6842	1.2323	1.2308	.2452	.2263	.2075
7	.2801	1.704	1.6004	1.5364	.2427	.2987	.2263
8	.2218	.2241	1.4074	1.7124	.2427	.2614	.2614
9	.2427	.2263	.2195	.1829	.2033	.2241	.1663
10	.1463	.1848	.2033	2.251	1.9204	2.13	1.6385
11	.1646	.2054	.2033	2.3644	2.1285	2.3644	1.6842
12	.168	.2241	.2172	2.4905	2.4006	2.3685	1.5971
13	.1663	.2054	.362	2.5286	2.3685	2.4291	1.5813
14	.1478	.1867	.2402	2.5101	2.4413		1.6324
15	.1494	.1867	.2587	2.4291	2.1628	2.2885	1.7444
16	.1478	.1848	.2218	2.0557	2.1605	1.9524	1.8884
17	.1478	.1791	.1991	1.4403	2.2939	1.8884	1.6964
18	.1494	.1991	.3086	.1772	.1433	.2012	.1417
19	.1629	.2353	.2328	.2195	.1867	.2172	.1663
20	.1829	.2195	.2427	.2427	.2218	.2195	.1829
21	.1829	.2033	.2075	.2195	.2054	.2075	.168
22	1.3599	1.2492	.2218	.1886	.1867	.1886	.1663
23	1.3603	1.1544	1.1523	.168	.1509		.1494
24	.132	1.2498	1.078	1.1363	.1494	.1698	.1509
Max	1.3603	1.704	1.6004	2.5286	2.4413	2.4291	1.8884
Min	.1143	.1791	.1991	.168	.132	.132	.132
Avg	.2675	.6789	.6264	1.2791	.8662	.8368	.6736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0747	.0754	.0754	.0754	.0754	.0754
2	.056	.0754	.0566	.0754	.0747	.056	.0754
3	.056	.0549	.0566	.056	.0549	.056	.0754
4	.0754	.056	.0754	.056	.0554	.0747	.0754
5	.0953	.0953	.0754	.0953	.0747	.0953	.0943
6	.1334	.1334	.0934	.1334	.1143	.1143	.1334
7	.1478	.112	.1307	.1478	.132	.112	.1509
8	.1109	.1086	.1294	.128	.1109	.1267	.0943
9	.0934	.0934	.0905	.1052	.0754	.1063	.0747
10	.0732	.0924	.0566	.0732	.0572	.0716	.0732
11	.0732	.0867	.0709	.0566	.0724	.0709	.0549
12	.0566	.0914	.0905	.0572	.0549	.0709	.0366
13	.0566	.0732		.0724	.0739	.0366	.056
14	.0566	.0572	.0754	.0732	.0924	.0532	.056
15	.056	.0381	.0566	.0914	.0924	.0543	.0754
16	.0754	.0762	.0543	.0566	.0739	.0381	.0362
17	.0754	.0532	.0724	.0754	.052	.0377	.0366
18	.0943	.0537	.0876	.0532	.0701	.0566	.0924
19	.104	.1075	.1075	.1097	.0905	.1132	.1254
20	.1829		.1829	.1646	.1791	.1698	.1463
21	.1663	.1478	.1848	.1294	.1663	.1494	.1478
22	.1132	.1132	.1478	.1132	.1307	.112	.128
23	.0934	.0943	.1132	.0934	.0943	.0934	.0876
24	.0762	.0754	.0754	.0914	.0754	.0762	.0754
Max	.1829	.1478	.1848	.1646	.1791	.1698	.1509
Min	.056	.0381	.0543	.0532	.052	.0366	.0362
Avg	.0916	.0854	.0939	.0910	.0893	.0842	.0865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9503	.1494	.0762	.1524	1.326	1.1469	.9831
2	.9116	.132	.0762	.1334	1.278	1.1271	.9667
3	.8785	.1334	.0953	.132	1.2597	1.0774	.9555
4	.9175	.1143	.1143	.1509	1.2574	1.1305	.9831
5	.9945	.1509	.1143	.1698	1.3108	1.1961	1.0159
6	1.0608	.1886	.132	.2096	1.4752	1.4089	1.1797
7	1.2289	.168	.132	.2075	1.6575	1.7238	1.4419
8	.132	.1478	.1132	.2263	1.9227	1.8399	1.6078
9	1.5565	2.0388	.0747	.2241	.1307	.132	.0747
10	1.9227	2.4813	1.8233	.2054	.1307	.1509	.1132
11	1.989	2.6322	2.2045	.168	.1494	.132	.132
12	2.1548	2.649	2.1216	.132	.1294	.132	.0934
13	2.1879	2.3205	2.0885	.132	.1307	.132	.112
14	2.0885	2.1879	2.1714	.1132	.1509	.0762	.132
15	2.2801	1.8138	2.2045	.0566	.132	.0373	.1132
16	2.2045	1.8244	1.9498	.0554	.1307	.0943	.1478
17	.112	.1494	1.9334	.2427	.1109	.0747	.168
18	.132	.1509	.1494	.2054	.1307	.132	.1494
19	.1698	.1886	.2241	.1886	.1509	.112	.1509
20	.168	.1867	.2075	.1509	.1509	.1494	.1509
21	.1698	.1494	.1715	.1509	.1509	.1143	.1509
22	.1698	.1307	.1698	.1334	.132	.1143	.1307
23	.168	.1143	.1509	1.4255	1.1797	.9393	.8583
24	.9831	.1509	.0762	.1524	1.3125	1.1633	.9831
Max	2.2801	2.649	2.2045	1.4255	1.9227	1.8399	1.6078
Min	.112	.1143	.0747	.0554	.1109	.0373	.0747
Avg	1.0638	.8481	.7739	.2133	.6621	.5974	.5331



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.5218	.1296	.3563	.1132	.0943	.0953
2	.112	.5121	.1296	.3201	.0934	.0943	.0953
3	.1143	.4858	.1296	.3201	.0914	.0953	.0953
4	.1334	.4801	.1296	.3563	.0924	.1143	.1143
5	.1524	.5601	.1457	.3605	.1109	.132	.1143
6	.1698	.7293	.1943	.3932	.1698	.1524	.1509
7	.2075	.7773	.3163	.4534	.2075	.1509	.1886
8	.2054	.1886	.2915	.5506	.2054	.1307	.132
9	.168	.1463	.1524	.1109		.0934	.0914
10	.1294	.1086	.1478	.7611		.664	.4744
11	.1307		.056	.7748		.7748	.5468
12	.112	.1433	.0747	.9922		.8179	.5468
13	.1267	.1267	.112	1.012		.9488	.5864
14	.1086	.1448	.1307	1.0883		.9878	.68
15	.1086	.1086	.1307	1.0082		.9172	.7432
16	.128	.1097	.1433	.8078		.8482	.7099
17	.1307	.1063	.1448	.8539		.7432	.6401
18	.1307	.1109	.1829	.1307		.1097	.1307
19	.1294	.1307	.1294	.1494		.1109	.1132
20	.1463	.1494	.1509	.1509		.1307	.1494
21	.1509	.132	.1509	.1509		.1132	.1415
22	.5441	.1943	.1509	.1509		.1132	.1307
23	.5735	.1457	.3563	.1307		.0953	.1097
24	.132	.5155	.1296	.3563	.1132	.1143	.0953
Max	.5735	.7773	.3563	1.0883	.2075	.9878	.7432
Min	.1086	.1063	.056	.1109	.0914	.0934	.0914
Avg	.1740	.2882	.1587	.4891	.1330	.3561	.2865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1372	.1372	.1372	.1372	.12
2	.1029	.1029	.1372	.1372	.1372	.1372	.12
3	.1029	.1029	.1372	.1372	.1372	.1372	.12
4	.1715	.1029	.1715	.1715	.1715	.1715	.1372
5	.2058	.1372	.1715	.1715	.2058	.1715	.1715
6	.2572	.2058	.2229	.2058	.2229	.2058	.2058
7	.2401	.2401	.2401	.2401	.1886	.2401	.2401
8	.1886	.2058	.1715	.1715	.1715	.2058	.2058
9	.1715	.1715	.1886	.1715	.1372	.1715	.1715
10	.12	.1372	.1543	.1372	.1029	.1372	.1629
11	.1715	.1372	.1715	.1543	.1029	.1715	.1372
12	.1715	.1715	.1715	.1372	.1029	.1715	.1372
13	.1372	.1372	.1715	.1372	.1029	.1715	.1372
14	.1715	.1372	.1715	.1372	.1029	.1886	.1029
15	.1715	.1715	.1715	.1372	.0686	.1715	.1029
16	.1715	.1715	.1715	.1372	.0686	.1715	.1372
17	.1715	.1715	.1715	.1886	.1029	.1715	.1372
18	.2058	.1715	.1715	.1886	.1029	.1715	.1715
19	.2058	.2058	.2401	.2058	.1372	.2058	.2058
20	.2401	.2915	.2743	.2401	.2058	.2401	.2401
21	.2401	.2401	.2743	.2401	.2058	.2058	.2058
22	.1715	.1886	.2401	.2058	.1715	.2058	.1715
23	.1715	.1715	.1715	.1715	.1372	.1543	.1372
24	.1372	.12	.1372	.1715	.1372	.1372	.12
Max	.2572	.2915	.2743	.2401	.2229	.2401	.2401
Min	.1029	.1029	.1372	.1372	.0686	.1372	.1029
Avg	.1751	.1672	.1851	.1722	.1401	.1772	.1583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1543	.1372	.1372	.1372	.12
2	.1029	.1029	.1543	.1372	.1372	.1372	.12
3	.1029	.1029	.1543	.1372	.1372	.1715	.12
4	.1715	.1029	.1543	.1372	.1715	.1715	.1715
5	.2058	.1029	.1543	.1715	.2058	.2058	.2058
6	.2401	.1886	.2058	.2058	.2572	.2058	.2572
7	.2401	.1886	.2058	.2401	.2058	.2401	.2401
8	.1372	.1372	.1715	.1715	.1372	.1715	.1715
9	.12	.1372	.1543	.1372	.1029	.1715	.1372
10	.1029	.1029	.12	.1372	.1029	.1372	.1029
11		.1029	.1029	.1372	.1029	.1372	.1029
12		.0514	.1029	.1372	.1029	.1372	.1029
13		.1029	.1029	.1372	.1029	.1372	.1029
14		.1372	.1372	.1372	.1029	.1372	.1029
15		.1029	.1372	.1372	.1029	.1543	
16		.1372	.1372	.1372	.1029	.1372	.1372
17		.1372	.1372	.1372	.1372	.1372	.1372
18	.1715	.1372	.1715	.1372	.1372	.1715	.1715
19	.1715	.2058	.2058	.1715	.1715		.2058
20	.2058	.2572	.2401	.1715	.2401	.2058	.2401
21	.1886	.2058	.2058	.2058	.2401	.1715	.2058
22	.1372	.1886	.1715	.2058	.2058	.1715	.1715
23	.1372	.1543	.1372	.1543	.1715	.1372	.1715
24	.1029	.12	.1372	.1372	.1372	.1372	.12
Max	.2401	.2572	.2401	.2401	.2572	.2401	.2572
Min	.1029	.0514	.1029	.1372	.1029	.1372	.1029
Avg	.1554	.1379	.1565	.1565	.1522	.1618	.1573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4801	.4458	.4458	.4115	.4458	.4115
2	.3772	.4115	.4287	.4115	.4115	.4115	.4115
3	.3772	.4115	.4115	.4115	.4115	.4115	.4115
4	.4458	.4115	.4115	.4801	.4801	.4115	.5144
5	.5144	.4801	.4801	.5487	.5487	.4458	.583
6	.6516	.5487	.6173	.6516	.6687	.5144	.6687
7	.6173	.6516	.583	.6859	.6859	.6516	.6859
8	.4973	.4115	.4801	.5487	.5316	.5487	.5144
9	.4458	.3944	.3772	.4458	.3944	.4115	.4287
10	.3944	.3772	.3772	.4458	.3601	.3429	.3772
11	.12	.5144	.3772	.3772	.3429	.3429	.3429
12	.12	.3772	.4115	.3772	.3429	.3429	.3086
13	.12	.3429	.4115	.3772	.3086	.3429	.3086
14	.12	.4115	.4115	.3772	.2743	.3429	.3086
15	.12	.4115	.4458	.3944	.3086	.3772	.3086
16	.1372	.3944	.4458	.4115	.3429	.3772	.3429
17	.1543	.4458	.4801	.4287	.3772	.4801	.4115
18	.4801	.5144	.4801	.5144	.4115	.4801	.6173
19	.5144	.583	.583	.5487	.5144	.5487	.6859
20	.583	.6859	.6859	.583	.6173	.6344	.6516
21	.583	.6516	.6859	.6173	.6173	.5658	.6173
22	.5487	.583	.6516	.583	.583	.463	.5487
23	.4801	.4801	.583	.5144	.5487	.463	.4801
24	.4458	.4287	.4115	.4801	.4458	.4801	.4115
Max	.6516	.6859	.6859	.6859	.6859	.6516	.6859
Min	.12	.3429	.3772	.3772	.2743	.3429	.3086
Avg	.3858	.4751	.4865	.4858	.4558	.4515	.4730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2572	.2401	.2401	.2401	.2743	.2401
2	.2058	.2401	.2058	.2058	.2401	.2401	.2401
3	.2058	.2401	.2058	.2058	.2743	.2743	.2401
4	.2743	.3086	.2058	.2401	.3429	.2743	.3429
5	.3429	.4115	.3086	.3086	.3772	.3429	.4458
6	.4115	.4801	.463	.3429	.4458		.5144
7	.3944	.4801	.4115	.4115	.3429		.5144
8	.2915	.3429	.3429	.3086	.2915	.3086	.3429
9	.2401	.2915	.2915	.2743	.2401	.2743	.3086
10	.2743	.2401	.1886	.2743	.2058	.2401	.2572
11	.1715	.1886	.1715	.1715	.1715	.2401	.2401
12	.1372	.1715	.1715	.1715	.1372		.2058
13	.2058	.1886	.2058	.1715	.1372		.2058
14	.2229	.2401	.2401	.1715	.1715	.2229	.1715
15	.2229	.2401	.2401	.2058	.1372	.2229	.1715
16	.2915	.2401	.2058		.1372	.2401	.2058
17	.2401	.2743	.2058		.1715	.2058	.2401
18	.3086	.2572	.2058	.2572	.2401	.2743	.4115
19	.3429	.2915	.3086	.3429	.3429	.3429	.4458
20	.3429	.4115	.4115	.3772	.4115	.4287	.4115
21	.3601	.3944	.4115	.3601	.3772	.4115	.3429
22	.2743	.3429	.3429	.3429	.3429	.3772	.3086
23	.2743	.2572	.3086	.2572	.3086	.3086	.2743
24	.2229	.2572	.2401	.2743	.2401	.2743	.2401
Max	.4115	.4801	.463	.4115	.4458	.4287	.5144
Min	.1372	.1715	.1715	.1715	.1372	.2058	.1715
Avg	.2693	.2936	.2722	.2689	.2636	.2889	.3051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.4115	.5144	.6516	.0343	.0343	.0343
2	.0343	.3944	.5144	.6859	.0343	.0343	.0343
3	.0343	.4115	.5144	.6859	.0343	.0343	.0343
4	.0343	.4115	.5144	.6859	.0343	.0343	.0343
5	.0343	.4801	.583	.7202	.0343	.0343	.0343
6	.0343	.5316	.6859	.7888	.0343	.0343	.0343
7	.0343	.583	.7545	.9945	.0343	.0343	.0343
8	.0343	.0343	.7202	1.166	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	1.2689	1.2003	1.2003	.9945
11	.0343	.0343	.0343	1.4403	1.2689	1.286	1.166
12		.0343	.0343	1.3717	1.3032	1.406	1.406
13	.0343	.0343	.0343	1.3717	1.3032	1.3717	1.3032
14	.0343	.0343	.0343	1.3375	1.3375	1.3375	1.0974
15	.0343	.0343	.0343	1.3032	1.3032	1.2346	1.0631
16	.0343	.0343	.0343	1.3032	1.2689	1.166	1.0288
17	.0343	.0343	.0343	1.3032	1.2003	1.0974	.9259
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.4115	.583	.0343	.0343	.0343	.0343	.0343
23	.4115	.5487	.6173	.0343	.0343	.0343	.0343
24	.0343	.4115	.5487	.6173	.0343	.0343	.0343
Max	.4115	.583	.7545	1.4403	1.3375	1.406	1.406
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0671	.2186	.2686	.7473	.4473	.4437	.3972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	1.1317	.9774	1.3032	.0343	.0343	.0343
2	.0343	1.0288	.9774	1.3375	.0343	.0343	.0343
3	.0343	1.0288	.9431	1.3717	.0343	.0343	.0343
4	.0343	1.0631	.9431	1.3717	.0343	.0343	.0343
5	.0343	1.166	1.0631	1.3717	.0343	.0343	.0343
6	.0343	1.2003	1.1145	1.5775	.0343	.0343	.0343
7	.0343	1.3032	1.2003	1.8176	.0343	.0343	.0343
8	.0343	.0343	1.0802	2.0576	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	2.572	2.4006	2.6749	.0343
11	.0343	.0343	.0343	2.8121	2.572	2.7435	1.9547
12	.0343	.0343	.0343	2.8121	2.6406	2.7778	1.9204
13	.0343	.0343	.0343	2.8292	2.6406	2.7092	1.8861
14	.0343	.0343		2.8635	2.6406	2.6578	1.8861
15	.0343	.0343	.0343	2.8635	2.5377	2.6749	
16	.0343	.0343	.0343	2.7435	2.5034	2.6749	1.7833
17	.0343	.0343	.0343	2.6749	2.4348	2.4006	1.6461
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343		.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	1.2003	1.0288	.0343	.0343	.0343	.0343	.0343
23	1.2346	1.0631	1.2689	.0343	.0343	.0343	.0343
24	.0343	1.1145	1.0288	1.3032	.0343	.0343	.0343
Max	1.2346	1.3032	1.2689	2.8635	2.6406	2.7778	1.9547
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.1329	.4837	.4801	1.4968	.8716	.9490	.5069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.0343	.0343	.0343	1.4746	1.4746	1.4403
2	1.0631	.0343	.0343	.0343	1.4746	1.4746	1.4403
3	1.0631	.0343	.0343	.0343	1.5089	1.5089	1.3717
4	1.0631	.0343	.0343	.0343	1.5089	1.5089	1.3717
5	1.0974	.0343	.0343	.0343	1.749	1.5089	1.3717
6	1.0974		.0343	.0343	1.7833	1.5432	1.3717
7	1.2346	.0343	.0343	.0343	1.8861	1.5432	1.3717
8	.0343	.0343	.0343	.0343	1.8861	1.5775	1.3032
9	1.9204	2.4691	.3944	.0343	.0343	.0343	.0343
10	2.1262	2.4006	2.6749	.0343	.0343	.0343	.0343
11	2.1948	2.4006	2.9835	.0343	.0343	.0343	.0343
12	2.332	2.6749	3.155	.0343	.0343	.0343	.0343
13	2.332	2.8121	2.9492	.0343	.0343	.0343	.0343
14	2.332	2.5377	2.8807	.0343	.0343	.0343	.0343
15	2.2291	2.5377	2.8121	.0343	.0343	.0343	.0343
16	2.2291	2.5377	2.7435	.0343	.0343	.0343	.0343
17	.0343	.0343	2.6406	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	1.6461	1.3717	1.3717	.823
24	1.0974	.0343	.1372	.0343	1.406	1.406	1.4403
Max	2.332	2.8121	3.155	1.6461	1.8861	1.5775	1.4403
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.1146	.9080	.9938	.1015	.6887	.6416	.5744



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.0686	.0686	.1372	1.0288	.9259	
2	.2401	.0686	.0686	.0686	1.0288	.9259	
3	.2401	.0686	.0686	.0686	1.0631	.9602	
4	.2401	.1372	.1372	.0686	1.166	.9602	
5	.3086	.1372	.1372	.0686	1.3032	.9602	
6	.3429	.1372	.1372	.0686	1.3717	1.0288	
7	.4801	.1372	.1372	.1372	1.5775	1.3032	
8	.1372	.1372	.1372	.1372	1.4403	1.5089	
9	1.0974	1.3717	.1372	.1372	.1372	.1372	
10	1.3032	1.3717	2.2634	.1372	.1372	.1372	.1372
11	1.3717	1.7147	2.4691	.1372	.0686	.1372	.1372
12	1.3717	1.6461	2.6749	.1372	.0686		.1372
13	1.3375	1.6461	2.6063	.1372	.0686		.1372
14	1.2689	1.6461	2.4691	.1372	.0686	.1372	.1372
15	1.2689	1.4403	2.4691	.1372	.0686	.1372	.1372
16	1.166	1.166	2.4691		.0686	.1372	.1372
17	.0686	.1372	2.3663		.0686	.1372	.1372
18	.0686	.0686	.1372	.1372	.1372	.1372	.1372
19	.1372	.0686	.1372	.1372	.1372	.1372	.1372
20	.1372	.1372	.1372	.1372	.1372	.1372	.1372
21	.1372	.1372	.1372	.1372	.1372	.1372	.1372
22	.0686	.1372	.1372	.1372	.1372	.1372	.1372
23	.0686	.0686	.1372	1.166	.8916	.6516	.4115
24	.2743	.0686	.0686	.1372	1.0288	.8916	
Max	1.3717	1.7147	2.6749	1.166	1.5775	1.5089	.4115
Min	.0686	.0686	.0686	.0686	.0686	.1372	.1372
Avg	.5573	.5716	.9045	.1684	.5559	.5347	.1568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.5155	.5792	.4531	.132	.132	.1132
2	.0943	.4999	.578	.4586	.132	.1132	.1132
3	.0943	.4999	.5693	.4801	.1509	.1132	.1132
4	.1132	.5218	.5864	.4961	.1698	.1509	.132
5	.1698	.5218	.5937	.506	.2075	.1886	.1509
6	.2263	.7907	.8642	.6554	.2452	.2452	.2263
7	.2263	1.0082	.9503	.8583	.2075	.2452	.2829
8	.1886	.2427	.9602	.9488	.2075	.2452	.2263
9	.168	.2195	.1698	.1848	.2218	.2033	.1886
10	.1886	.2452	.1867	.9172		.8855	.6642
11	.1867	.2075	.2241	1.2323		1.0562	.6958
12	.2033	.2075	.2075	1.2483			.6962
13	.2218	.2054	.1698	1.2334		1.3279	.759
14	.1494	.2241	.1698	1.3123		1.0883	.7907
15	.1867	.2075	.2075	1.2342		1.1385	.7811
16	.1867	.1886	.2241	1.3123		1.2163	.7655
17	.1867	.2033	.2218	1.0185	.9231	.9998	.7562
18	.2033	.1867	.2218	.1646	.2054	.1463	.1109
19	.1463	.1867	.168	.1494	.2218	.1478	.1509
20	.2054	.1886	.2241	.1867	.2075	.168	.1509
21	.1867	.1698	.1886	.1886	.1886	.1509	.1509
22	.5601	.6882	.1886	.1509	.1886	.1509	.132
23	.5468	.6325	.4801	.1509	.1698	.1307	.1132
24	.1132	.5093	.5864	.4687	.1509	.132	.1132
Max	.5601	1.0082	.9602	1.3123	.9231	1.3279	.7907
Min	.0943	.1698	.168	.1494	.132	.1132	.1109
Avg	.2027	.3780	.3967	.6671	.2312	.4511	.3491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.448	1.5061	1.0513	.884	1.647
2	1.1517	1.448	1.5415	1.0802	.9374	1.6827
3	1.1871	1.4842	1.5927	1.1145		1.6832
4	1.4148	1.5565	1.6827	1.1096		1.7741
5	1.5203	1.6827	1.848	1.3146		1.8107
6	1.6461	2.0911	2.3388	1.7375	1.829	2.0328
7	1.9605	2.3011	2.3577	2.3577		2.0911
8	2.32	2.6783	2.6406	2.6217	2.6406	2.1691
9	2.8292	2.7726	2.7161	2.9235	2.8669	2.3011
10	2.9801	2.8858	2.8858	3.0556	3.3008	2.2822
11	2.8669	2.9613	3.2065	3.0178	2.6406	2.32
12	2.9235	2.9801	3.2819	3.3008		2.3388
13	2.9801	3.0744	3.2065	3.131	2.3011	2.3577
14	2.9235	3.0933	3.2253	3.3008	2.9424	2.3765
15	2.9424	3.1121	3.2253	2.9235	2.7161	2.3577
16	2.3954	2.3388	2.3954	2.4709	2.0182	
Max	2.9801	3.1121	3.2819	3.3008	3.3008	2.3765
Min	1.0288	1.448	1.5061	1.0513	.884	1.647
Avg	2.1919	2.3693	2.4782	2.2819	2.2797	2.0816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3961	.3961	.415	.3395	.3772	.3584
2	.3395	.3961	.3772	.4338	.3206	.3584	.3584
3	.3395	.415	.3961	.4338	.3206	.3772	.3772
4	.3961	.4715	.1886	.4527	.415	.415	.3772
5	.5281	.547	.2075	.5658	.6036	.2075	.4715
6	.679	.7356	.2641	.7167	.7356	.3018	.7167
7	.6602	.6161	.2614	.6348	.6602	.2801	.679
8	.5041	.462	.2195	.462	.4481	.2012	.5041
9	.3841	.3841	.4706	.3841	.3658	.1448	.4207
10	.3109	.3544	.4163	.3206		.1254	.3475
11	.3012	.2686	.3439	.2507			.3077
12	.3077	.3077	.362	.2507			.2715
13	.2896	.3155	.3801	.2865		.394	.2534
14	.2896	.3439	.3658	.2926		.3077	.2378
15	.2957	.2926	.3475			.2481	.2149
16	.3077	.2865	.3801	.3045		.3224	.2481
17	.298	.3155	.3721	.3155	.5014	.4031	.3121
18	.3467	.2774	.2427	.3721	.4908	.4557	.3881
19	.4477	.5014	.6379	.4706	.5249	.5731	.5249
20	.6283	.6653	.7207	.6099	.6468	.6468	.5975
21	.5788	.5975	.6722	.5788	.5975	.5658	
22	.5281	.5658	.5847	.5281	.5658	.5093	.4904
23	.4527	.4904	.4715	.415	.4527	.415	.3772
24	.3772	.3961	.415	.4527	.3772	.415	.3772
Max	.679	.7356	.7207	.7167	.7356	.6468	.7167
Min	.2896	.2686	.1886	.2507	.3206	.1254	.2149
Avg	.4145	.4334	.3956	.4325	.4921	.3657	.4005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2751	.2751	.2715	.3155	.2947	.2778	.2705
2	.2534	.3201	.2667	.2623	.2623	.2559	.2606
3	.2469	.2896	.2366	.2968	.253	.2317	.2932
4	.2503	.2606	.2462	.2947	.2256	.2201	.3121
5	.2715	.2824	.2968	.2753	.2462	.23	.2606
6	.2751	.2366	.2294	.2534	.2675	.2481	.2572
7	.3366	.3258	.217	.3475	.3121	.3326	.3439
8	.3366	.2721	.1814	.3761	.3506	.2947	.2984
9	.4344	.3721	.2134	.6413	.3403	.3881	.3881
10	.5658	.3761	.2683	.5658		.5228	.5914
11	.4706	.394	.5544	.6413		.4904	.6908
12	.6224	.4207	.5601	.4527			.6979
13	.5093	.4163	.4908	.5093		.5658	.6722
14	.547	.4904	.1846	.8676		.6036	.5415
15	.547	.4904	.2439	.5544		.6413	.5093
16	.4904	.5415	.3547	.8488		.679	.4481
17	.4904	.4904	.3772	.5601	.2561	.4527	.4108
18	.4527	.3584	.3696	.4715	.2713	.4294	.3921
19	.4338	.362	.3012	.4527	.2915	.4527	.415
20	.2896	.3481	.4066	.394	.3681	.4715	.3315
21	.3292	.3005	.3801	.4251	.4024	.4904	.4344
22	.3856	.5415	.3544	.3982	.3921	.4715	.394
23	.3239	.2972	.3239	.3294	.3149	.3077	.3521
24	.3048	.3121	.2896	.362	.3326	.3163	.3113
Max	.6224	.5415	.5601	.8676	.4024	.679	.6979
Min	.2469	.2366	.1814	.2534	.2256	.2201	.2572
Avg	.3934	.3656	.3174	.4540	.3048	.4076	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.4712	1.3203	1.4146	1.4335	1.3203	1.4146
2	1.4335	1.4523	1.3014	1.4523	1.4523	1.3392	1.358
3	1.4712	1.4146	1.3957	1.4146	1.4335	1.3014	1.4146
4	1.4712	1.4335	1.3203	1.4523	1.4523	1.358	1.4335
5	1.5278	1.4146	1.358	1.5466	1.4712	1.4523	1.4523
6	1.5844	1.6032	1.5655	1.4335	1.5089	1.5466	1.5466
7	1.5089	1.5844	1.6598	1.5466	1.6221	1.4901	1.4146
8	1.6221	1.6975	1.773	1.5089	1.8107	1.4335	1.6032
9	1.1317	1.2449	1.226	1.2449	1.2826	1.1317	1.3203
10	1.0185	1.3392	1.3203	1.4712		1.094	1.358
11	1.1317	1.5089	1.4712	1.6032		1.3203	1.3957
12	1.6221	1.3957	1.6409	1.5089		1.2826	1.5655
13	1.6975	1.905	2.0182	1.905		1.8484	1.773
14	1.7918	1.8484	1.9427	2.0559		1.9239	1.9239
15	1.6409	1.8673	1.9239	1.7918		1.7164	1.9427
16	1.6409	1.6975	1.8296	1.7353		1.6975	1.7353
17	1.5655	1.5655	1.6975	1.7353	.7545	1.5466	1.6598
18	.9431	1.6032	1.5844	1.6032	1.4901	1.1317	1.226
19	.9431	.9054	1.094	1.1317	1.226	1.0185	1.0185
20	.9242	.8299	1.0374	1.0562	.9242	.9054	1.0374
21	.9054	.8299	.9619	.9997	.7545	.9054	.8676
22	1.1317	1.0751	.9808	1.226	.7167	1.094	.9431
23	1.6032	1.5844	1.5089	1.6032	1.3769	1.5089	1.4146
24	1.2449	1.5089	1.2826	1.358	1.4335	1.358	1.358
Max	1.7918	1.905	2.0182	2.0559	1.8107	1.9239	1.9427
Min	.9054	.8299	.9619	.9997	.7167	.9054	.8676
Avg	1.3714	1.4492	1.4673	1.4916	1.3026	1.3635	1.4240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.021	.7127	.7712	.5535	.0189	.0105	.0147
2	.0248	.6962	.7293	.5761	.0171	.0076	.0206
3	.0293	.7042	.6802	.5468	.0171	.0114	.0251
4	.0171	.7045	.6882	.5624	.0343	.0114	.032
5	.0244	.7362	.6478	.6327	.0381	.0187	.0171
6	.0335	1.2944	1.0402	1.0279	.0419	.0251	.016
7	.06	1.5746	1.4251	1.4074	.06	.0545	.0343
8	.0572	.0579	1.1271	1.6549	.0486	.0543	.0229
9	.0713	.0732	.0533	.0693	.0892	.0724	.0453
10	.0615	.0774	.0486	1.704		1.6876	.9175
11	.068	.0427	.0427	1.8023		2.0891	1.0486
12	.0587	.048		1.8947			1.3108
13	.0572	.0686		1.7736		2.0965	1.1271
14	.0714	.0434		1.8399		1.7976	1.1142
15	.0657	.0434		1.8461		1.8785	1.3108
16	.0594	.04		1.8564		1.8842	1.326
17	.0594	.0686		1.576	1.4251	1.5912	1.153
18	.0934	.061		.0587	.0615	.0587	.057
19	.0772	.0579		.048	.0724	.0427	.0543
20	.0905	.0617	.052	.0343	.0495	.0259	.0335
21	.0615	.0291	.0362	.0324	.0274	.0274	.0133
22	.9892	.9282	.0377	.0267	.0421	.0213	.0114
23	.8215	.8288	.6241	.0229	.0223	.0149	.0126
24	.0251	.7712	.78	.5898	.0251	.0147	.0137
Max	.9892	1.5746	1.4251	1.8947	1.4251	2.0965	1.326
Min	.0171	.0291	.0362	.0229	.0171	.0076	.0114
Avg	.1249	.4052	.5490	.9224	.1230	.5868	.4055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1086	.1086	.1097			.1086
2	.1086	.1097	.1097	.1097			.1097
3	.1097	.1086	.0895	.1097			.0924
4	.0914	.1097	.0914	.1109			.0914
5	.1267	.1086	.1086	.128			.1086
6	.1612	.1097	.181	.1646			.1629
7	.181	.1086	.1463	.1829			.1612
8	.1463	.1097	.1267	.128			.1267
9	.1267	.1086	.128	.128		.1097	.1086
10	.1075	.0914	.128			.1086	.1086
11	.1086	.0905	.1097			.1075	.1086
12	.1097	.1097	.1097			.1075	.0914
13	.1086	.1086	.1097			.1086	.1509
14	.1097	.1097	.1097			.1097	.1509
15	.1086	.1086	.1097			.1086	.128
16	.1097	.1086	.1097			.1097	.128
17	.1086	.1075	.1097			.1097	.128
18	.0914	.1097	.1097			.1097	.1463
19	.1086	.1629	.128			.181	.1829
20	.1463	.2149	.1463			.2195	.2195
21	.1448	.2172	.2195			.2172	.1829
22	.2195	.1791	.1829			.1791	.1829
23	.1448	.1629	.128		.1463	.1448	.1463
24	.1254	.1097	.128	.1097		.1463	.128
Max	.2195	.2172	.2195	.1829	.1463	.2195	.2195
Min	.0914	.0905	.0895	.1097	.1463	.1075	.0914
Avg	.1255	.1239	.1262	.1281	.1463	.1361	.1356



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1086	.1086	.1097			.1086
2	.1075	.1097	.1097	.1097			.1097
3	.1097	.1086	.0895	.1109			.1086
4	.1086	.1463	.0905	.1109			.0924
5	.1448	.2172	.1267	.1463			.128
6	.1829	.2195	.197	.1829			.181
7	.181	.2172	.1448	.2012			.1463
8	.1433	.2561	.1433	.1463			.1463
9	.1267	.1086	.1254	.1463		.2534	.1086
10	.1254	.128	.1267			.1097	.1075
11	.1086	.1086	.1075			.1086	.1086
12	.1097	.1097	.1097			.0895	.0914
13	.0905	.1086	.1097			.1086	.1097
14	.0914	.1075	.1097			.1086	.128
15	.0905	.1086	.1097			.1075	.128
16	.1097	.1086	.104			.1086	.128
17	.0914	.1097	.128			.1097	.1463
18	.0914	.1097	.1097			.1097	.1509
19	.1086	.1629	.1294			.1991	.1829
20	.1829	.2328	.1646			.2378	.2195
21	.2195	.2172	.2195			.2149	.2195
22	.1463	.1829	.1829			.1791	.1463
23	.1448	.1629	.1646		.1448	.1448	.128
24	.1075	.1097	.128	.128		.1448	.1463
Max	.2195	.2561	.2195	.2012	.1448	.2534	.2195
Min	.0905	.1075	.0895	.1097	.1448	.0895	.0914
Avg	.1263	.1483	.1308	.1392	.1448	.1459	.1363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	1.4632	1.4529	1.4563			.1086
2	.0905	1.448	1.4529	1.4723			.0905
3	.0914	1.4632	1.4175	1.4563			.0914
4	.0905	1.5203	1.4327	1.4403			.0905
5	.1086	1.5729	1.4232	1.4737			.1075
6	.1433	1.7013	1.5083	1.4899			.1254
7	.1629	1.829	1.5775	1.6118			.1267
8	.1433	.181	1.6124	1.9071			.1254
9	.1629	.1829	.1829	.1829		.2195	.1448
10	.1612	.1829	.181			2.5339	1.7833
11	.1097	.1629	.1829			2.5591	
12	.1086	.1629	.181			2.5206	1.95
13	.1463	.1629	.1829			2.6223	1.8861
14	.1448	.1791	.181			2.4348	1.8861
15	.1463	.0905	.1829			2.4272	1.9719
16	.1448	.0716	.1829			2.332	1.749
17	.128	.1086	.1791			2.0576	1.5432
18	.1448	.1097	.1829			.1791	.128
19	.1829	.1448	.1791			.181	.128
20	.1848	.1254	.2012			.1463	.128
21	.1829	.1086	.1612			.1267	.1463
22	1.4118	1.4403	.1629			.1075	.128
23	1.4632	1.4779	1.4723		.2195	.1086	.128
24	.0914	1.448	1.5043	1.5223		.1829	.1075
Max	1.4632	1.829	1.6124	1.9071	.2195	2.6223	1.9719
Min	.0905	.0716	.1612	.1829	.2195	.1075	.0905
Avg	.2431	.7224	.7241	1.4013	.2195	1.2962	.6380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487	.4801	.4801		.4908
2		.5068	.4409	.4508		.4801
3		.5121	.4508	.4458		.4508
4		.5068	.4508	.4458		.4557
5		.5121	.4557	.4801		.4801
6		.543	.4458	.4801		.4854
7	.5258	.5487	.4508			.4908
8		.4887	.4557	.3429		.4801
9		.439	.4458		.3658	.4854
10	.4409	.4706	.4458		.4755	
11	.5487	.4656			.4706	
12	.4755	.4557	.4458			
13	.5068	.4607	.4854			
14	.5121	.4607	.4801			
15	.5068	.4607	.4458		.4557	
16		.5014	.4801		.4607	
Max	.5487	.5487	.4854	.4801	.4755	.4908
Min	.4409	.439	.4409	.3429	.3658	.4508
Avg	.5024	.4926	.4573	.4465	.4457	.4777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167			.7733			.679
2	.679			.7545			.6602
3	.6602			.7167			.6413
4	.679			.6979			.6602
5	.6979		.724	.7167	.7392	.7167	.6979
6	.811		.7356	.8215	.7545	.7545	.7733
7	.8316	.7762	.7922	.8402	.7468	.8775	.8029
8	.7392	.7682	.7762	.8048	.7468	.8131	.8029
9	.7682		.7133			.7865	.7947
10	.7343	.7783	.7499			.8326	
11	.8326	.8048	.7499			.8326	
12		.8417	.8326		.7655	.8859	.5121
13		.7964	.7343		.6908	.8869	.7701
14			.7577			.8688	
15			.8048			.8507	.7343
16		1.0029				.8059	
17	.7522		.8775			.8238	
18		.8682	.8596		.8688	.8775	.8954
19		.9877	.8596		.8596	.9511	
20	1.0903	1.0903	1.0642		1.0269	1.0534	.9795
21		.9896	.9997		.9522	.9896	
22		.9709	.9431		.9431	.8865	
23	.8676		.8865		.8676	.811	
24	.1886	.7733	.811	.7922	.7545	.7922	.6979
Max	1.0903	1.0903	1.0642	.8402	1.0269	1.0534	.9795
Min	.1886	.7682	.7133	.6979	.6908	.7167	.5121
Avg	.7366	.8807	.8248	.7686	.8243	.8548	.7401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413			.7373			.6327
2	.8413			.7045			.6249
3	.8149			.6802			.6093
4	.8328			.6802			.6325
5	.8682		.6882	.6964	.7712	.6562	.6562
6	1.0242		.7045	.8505	.7712	.7969	.815
7	1.0456	1.0829	.8059	.8507	.788	.8688	.8507
8	.961	.9425	.7442	.7265	.7362	.7701	.7362
9	.9055		.6836			.7164	.6859
10	.9425	.9425	.7343			.6661	
11	.961	.9425	.7164			.7059	
12		1.0164	.7522		.6516	.7682	.6733
13		1.0164	.7186		.6516	.7421	.6836
14			.7282			.6836	
15		.9694	.7282			.6661	.6104
16		.961				.724	
17	.9877		.823			.7577	
18		.8402	.8501		.8871	.8589	.8501
19		.9335	.924		.9709	1.0185	
20	1.3443	1.1016	1.1203		1.0903	1.1389	1.1016
21		1.0719	1.0903		.9593	1.0059	
22		.9313	1.0059		.9313	.8954	
23	1.0059		.8669		.8139	.8059	
24	.8589	.9134	.7209	.7537	.7964	.7209	.6722
Max	1.3443	1.1016	1.1203	.8507	1.0903	1.1389	1.1016
Min	.8149	.8402	.6836	.6802	.6516	.6562	.6093
Avg	.9490	.9761	.8108	.7422	.8322	.7983	.7223

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772			.2772			.2772
2	.2772			.2772			.2772
3	.2772			.2743			.2743
4	.2957			.3109			.3109
5	.3142		.3109	.3292	.4108	.2772	.3109
6	.3841		.4163	.3982	.4207	.4163	.4163
7	.3801	.394	.439	.4163	.4066	.4119	
8	.3801	.394	.4298	.4119	.3982	.4163	.4344
9	.3801		.3801			.4163	.1905
10	.3475	.3109	.3292			.3658	
11	.2241	.2614	.2772			.2075	
12		.2772	.2772		.2641	.1698	.3292
13		.2743	.2772		.2452	.2957	.2614
14			.2957			.2587	
15		.2263	.3109			.2263	.3109
16		.362				.2772	
17	.3403		.2772			.2772	
18		.3801	.3658		.3439	.3658	.362
19		.3326	.3292		.3292	.3475	
20	.3109	.2772	.3292		.3292	.3475	.3292
21		.1715	.2801		.2801	.3292	
22		.2801	.2587			.2772	
23	.1886		.1886		.2801	.2772	
24	.2772	.2772	.2614	.2402	.2641	.2957	.2587
Max	.3841	.394	.439	.4163	.4207	.4163	.4344
Min	.1886	.1715	.1886	.2402	.2452	.1698	.1905
Avg	.3103	.3013	.3176	.3262	.3310	.3128	.3102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267			.0648			.0686
2	.0267			.0648			.0686
3	.0259			.0633			.0686
4	.0259			.0633			.0686
5	.0267		.032	.0633	.0762	.0549	.0671
6	.0305		.0312	.0648	.0754	.0343	.0701
7	.0251	.0343	.0251	.0633	.0747	.0533	.0693
8	.0693	.0328	.0617	.0671	.0754	.0427	.0335
9	.1109		.0972			.0823	.1109
10	.0754	.112	.2263			.112	
11	.1524	.1132	.1509			.1886	
12		.1886	.2427		.0747	.2641	.1132
13		.1848	.1433			.0701	.1509
14			.1867			.1086	
15		.1867	.0754			.1478	.1132
16		.1143	.0754			.112	
17	.1109		.0739			.1509	
18		.0732	.1509		.0701	.0754	.0754
19		.112	.1132		.0335	.0754	
20	.112	.0709	.0747		.0335	.0754	.1132
21		.0594	.0739		.0324	.0754	
22		.0312	.0754			.0716	
23	.0678		.0663		.0282	.0701	
24	.0267	.0678	.0229	.0648	.0747	.0602	.0701
Max	.1524	.1886	.2427	.0671	.0762	.2641	.1509
Min	.0251	.0312	.0229	.0633	.0282	.0343	.0335
Avg	.0609	.0987	.1	.0644	.0590	.0963	.0841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV Bendri - Nimani

GAOTHAN FEEDER

GAONTHA Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377			.0377			.037
2	.0373			.0377			.037
3	.0373			.0377			.037
4				.0373			.037
5	.037		.0377	.0373	.0377	.0373	.0373
6	.0377		.0377	.0377	.0377	.0377	.0377
7	.0377	.0762	.0377	.0377	.0377	.0377	.0377
8	.0377		.0377	.0377	.0377	.0377	.0377
9	.0762		.0377			.0377	.0377
10	.0381	.0693	.0377			.0377	
11	.0754	.0377	.0377			.0377	
12		.0377	.0377		.0377	.0377	.0377
13		.0377	.0377		.0377	.0377	.0381
14			.0377			.0377	
15		.0377	.0377			.0377	.0381
16		.0381	.0377			.0377	
17	.0377		.0373			.0377	
18		.0373	.0373		.0362	.0377	.0362
19		.0373	.0373		.0373	.0377	
20	.0762	.0373	.0377		.0754	.0377	.0754
21		.0377	.0377		.0762	.0377	
22		.0762	.0377			.0377	
23	.0377		.0377		.0377	.0373	
24	.0377	.0373	.0373	.0377	.0377	.0373	.0373
Max	.0762	.0762	.0377	.0377	.0762	.0377	.0754
Min	.037	.0373	.0373	.0373	.0362	.0373	.0362
Avg	.0458	.0460	.0376	.0376	.0439	.0376	.0399



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.9804	.9722	.8381	.1334	.1334	.1334
2	.0953	.953	.9259	.7811	.1334	.1334	.1334
3	.0953	.9374	.9259	.7522	.1334	.1334	.1334
4	.1143	.9282	.9686	.7343	.1524	.1334	.1524
5	.1334	.9488	1.0467	.7655	.1715		.1143
6	.1905	1.3441	1.3889	.9061	.2286		.2096
7	.2096	1.6518	1.6204	1.2809	.2286	.2096	.2477
8	.1905	.2105	1.4352	1.4403	.2286	.1905	.2096
9	.2096	.2286	.1524		.2096	.1905	.1524
10	.2096	.2286		.3239		1.9216	1.2498
11	.1905	.2477	.2286	1.9753		1.8976	1.5043
12	.2096	.2477	.2096	2.0309		2.2771	1.5546
13	.2096	.2286	.2096	1.9997		2.2497	1.4685
14	.2096		.2286	2.0216		2.1348	1.491
15	.2096	.2286	.2286	1.9136		2.1664	1.4403
16	.2286	.2286	.2477	1.8903		2.1605	1.5061
17	.2286	.2096	.2477	1.6248	1.6842	1.9134	1.3279
18	.2096	.1905	.2286	.1905	.1715	.1905	.1524
19	.2096	.1905	.2286	.2096	.1715	.1905	.1905
20	.2286	.1905	.2096	.2096	.1905	.2096	.1905
21	.2096	.1715	.2096	.1905	.1715	.1905	
22	1.1385	1.1574	.1715	.1715	.1715	.1715	.1143
23	1.1069	1.0936	.8539	.1715	.1334	.1524	.1143
24	.1143	1.0402	1.0311	.8905	.1524	.1334	.1524
Max	1.1385	1.6518	1.6204	2.0309	1.6842	2.2771	1.5546
Min	.0953	.1715	.1524	.1715	.1334	.1334	.1143
Avg	.2603	.6016	.6074	1.0136	.2627	.8674	.6062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4816	.0762	.0572	.0762	.7316	.9175	.7202
2	.4515	.0572	.0572	.0572	.7253	.8718	.7116
3	.4458	.0572	.0572	.0572	.7253	.8718	.7125
4	.4816	.0572	.0572	.0762	.7316	.8718	.7449
5	.5182	.0762	.0762	.0762	.7926	.8962	.7432
6	.6019	.0762	.0953	.0953	1.1138		.8124
7	.7407	.0953	.0953	.1143	1.2944	1.3094	1.0753
8	.0762	.1143	.0953	.1143	1.3565	1.2342	1.0437
9	.8796	1.0595	.0762	.1143	.0762		.1143
10	1.1069	1.2018		.0953			.0953
11	1.1544	1.3426	1.4548	.0953			.0762
12	1.2176	1.2498	1.5023	.0953		.0953	.0762
13	1.186		1.5023	.0572		.1143	.0762
14	1.0883		1.5023	.0572		.1143	.0762
15	1.0753	1.2809	1.4706	.0762		.0953	.0762
16	1.0911	1.3435	1.406	.0762		.0953	.0762
17	.0762	.0762	1.4706	.0762	.0762		.0762
18	.1334	.0953	.0953	.0762	.0762	.0762	.0762
19	.0762	.0953	.1143	.0953	.0762	.0953	.0953
20	.0953	.0762	.1334	.0762	.0953	.1143	.0953
21	.0953	.0762	.1334	.0762	.0953	.1143	.0953
22	.0953	.0762	.2096	.0762	.0762	.0953	.0762
23	.0762	.0762	.1143	.8179	.9556	.6642	.5601
24	.4904	.0762	.0572	.0953	.7811	.9282	.7274
Max	1.2176	1.3435	1.5023	.8179	1.3565	1.3094	1.0753
Min	.0762	.0572	.0572	.0572	.0762	.0762	.0762
Avg	.5723	.3971	.5145	.1135	.5753	.5039	.3764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2427	.2452	.2452	.2641	.2641	.2263
2	.2263	.2263	.2263	.2263	.2452	.2452	.2263
3	.2263	.2263	.2263	.2241	.2452	.2452	.3921
4	.2452	.2402	.2452	.2241	.2641	.2452	.2402
5	.2829	.2801	.2829	.2614	.3395	.2829	.2829
6	.3961	.3921	.3961	.3584	.4481	.4294	.3921
7	.4066	.462	.4108	.4251	.4435	.462	.4854
8	.3841	.3658	.3292	.4108	.4024	.4207	.4207
9	.3258	.3292	.3224	.3326	.3403	.3439	.4066
10	.2896	.2743		.2926		.2926	.3439
11	.2561	.3045	.3077	.2353		.2743	.2804
12	.2896	.2804	.2896	.2534		.2353	.1791
13	.2743		.2957	.2328		.2353	.1772
14	.2507		.3109	.2686		.2378	.1991
15	.2561	.2126	.3142	.2481		.2402	.1772
16	.2353	.2454	.2926	.2743		.2743	.1715
17	.2561	.2601	.2926	.3086	.3224	.2957	.197
18	.2743	.3086	.2772	.3012	.3982	.3439	.2534
19	.3881	.4024	.3721	.4207	.4755	.4024	.333
20	.5359	.4805	.4481	.4805	.5014	.462	.4119
21	.4481	.4294	.4066	.4108	.4607	.3801	.3982
22	.4108	.3361	.3658	.3361	.394	.3475	.3292
23	.3326	.2829	.7714	.3018	.2926	.2772	.2614
24	.2641	.2926	.7213	.2772	.2829	.2641	.2402
Max	.5359	.4805	.7714	.4805	.5014	.462	.4854
Min	.2263	.2126	.2263	.2241	.2452	.2353	.1715
Avg	.3125	.3125	.3544	.3063	.3600	.3126	.2927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.0762	.0572	.0762	1.0311	.9998	.9488
2	.6472	.0762	.0572	.0762	1.0279	.9922	.9061
3	.6321	.0762	.0572	.0762	1.0279	1.0395	.9172
4	.6539	.0762	.0572	.0953	1.0437	1.0159	.933
5	.7164	.0953	.0953	.1143	1.0936	1.0688	.9488
6	.9217	.1143	.1524	.1524	1.3435	1.1523	1.0311
7	1.034	.1524	.1524	.1905	1.6667	1.4251	1.186
8	.1143	.1524	.1524	.1905	1.6404	1.6004	1.2963
9	1.25	1.3435	.1334	.1715	.1715	.0953	.1334
10	1.3599	1.692		.1524		.1143	.1334
11	1.4232	1.7124	1.9292	.1905		.1143	.1143
12	1.4548	1.8404	1.9925	.1524		.1143	.1143
13	1.4883		1.9216	.1715		.1334	.1143
14	1.5023		1.866	.1524		.1334	.1143
15	1.4998	1.6964	1.9134	.1334		.1143	.1143
16	1.5497	1.6446	1.9608	.1524		.1143	.1334
17	.0762	.0953	1.8244	.1524	.1524	.0953	.1143
18	.0953	.0953	.1334	.1334	.1143	.0762	.1143
19	.0762	.1143	.1334	.1715	.1334	.1143	.1143
20	.0953	.0953	.1334	.1334	.1524	.1334	.1143
21	.0953	.0953	.1334	.1334	.1143	.1334	.0953
22	.0953	.0953	.1334	.1334	.1143	.1334	.0953
23	.0953	.0762	.1143	1.0936	1.1012	.9804	.7773
24	.6984	.0953	.0762	.1143	1.0311	1.0814	.9602
Max	1.5497	1.8404	1.9925	1.0936	1.6667	1.6004	1.2963
Min	.0762	.0762	.0572	.0762	.1143	.0762	.0953
Avg	.7602	.5232	.6600	.1797	.7623	.5406	.4802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 205 / 11 KV Nimani Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1463	.1886	.168	.1698	.168	.1478
2	.1509	.1448	.1886	.1698	.1509	.1698	.1448
3	.1509	.1478	.1698	.1463	.1509	.1698	.1267
4	.1698	.1463	.1886	.1448	.1698	.1698	.1463
5	.2075	.1646	.2263	.1848	.2075	.1886	.168
6	.3772	.2353	.3395	.2353	.3734	.3734	.2378
7	.3361	.3734	.3326	.3439		.3658	.3511
8	.2561	.2195	.2743	.2378	.2561	.2241	.2896
9	.1991	.197	.2172	.2012	.181	.1829	.2353
10	.181	.1254		.1629		.2195	.181
11	.1463	.1433	.181	.0895		.1791	.1463
12	.1267	.1595	.1267	.0895		.1267	
13	.1267	.1227	.1448	.1417		.1463	.1254
14	.1254	.124	.1848	.1417		.1267	.0701
15	.1267	.1595	.1829	.1433		.128	.0895
16	.1448	.1254	.1829	.1387		.128	.1086
17	.1629	.1448	.181	.1578	.1578	.1646	.1402
18	.1829	.1448	.1646	.1612	.2328	.1848	.1791
19	.2743	.2402	.2353	.2587	.2534	.2561	.2534
20	.3511	.3174	.3439	.3174	.362	.3292	.3258
21	.3174	.2987	.3258	.3174	.3224	.2896	.2926
22	.2801	.2641	1.3717	.2801	.2896	.2715	.2402
23	.2378	.2263	.2353	.2075	.2033	.2012	.1867
24	.1886	.1848	.1886	.2033	.1886	.1867	.1629
Max	.3772	.3734	1.3717	.3439	.3734	.3734	.3511
Min	.1254	.1227	.1267	.0895	.1509	.1267	.0701
Avg	.2079	.1898	.2685	.1934	.2293	.2063	.1891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi ( Malwadi )

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0943	.0943	.0594	.0333	.0892	.0579
2	.0351	.0943	.0857	.0518	.0533	.0892	.0533
3	.0412	.0943	.0823	.0442	.044	.0869	.0457
4	.0457	.0943	.0686	.0366	.036	.0412	.0457
5	.0351	.0943	.061	.0564	.0307	.0549	.0427
6	.0305	.0943	.0686	.0579	.0412	.0583	.0518
7	.0381	.0943	.0747	.0716	.0463	.072	.0579
8	.061	.0943	.0671	.0806	.0583	.0613	.06
9	.061	.0943	.061	.061	.0442	.068	.0583
10	.1448	.0838	.1113	.0869	.1067	.0874	.1629
11	.181	.0974	.1629	.1303	.168	.1183	.1629
12	.181	.1526	.1663	.1269	.1753		.181
13	.181	.1235	.1463	.1753	.168	.1355	.181
14	.1448		.1478	.1715	.1094	.0472	.181
15	.1629	.093	.1269	.1143	.1187	.1029	.1267
16	.1448	.1183	.1389	.1217	.1027	.1658	.1267
17	.1267	.0814	.1269	.1372	.1	.0772	.1448
18	.1448	.064	.0945	.064	.0594	.0617	.1267
19	.1629	.064	.072	.064	.0617	.0549	.1267
20	.1629	.0686	.0806	.0701	.064	.0564	.1267
21	.1629	.0716	.0808	.0701	.076	.0991	.1267
22	.1629	.0777	.0857	.0732	.0854	.0625	
23	.1629	.1097	.0701	.0573	.0709	.0701	.1267
24	.0503	.1629	.1012	.0625	.06	.0892	.061
Max	.181	.1629	.1663	.1753	.1753	.1658	.181
Min	.0305	.064	.061	.0366	.0307	.0412	.0427
Avg	.1106	.0964	.0990	.0852	.0797	.0804	.1059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi ( Malwadi )

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.1134	.0934	.1109	.8642	.8745	.7842
2	.4816	.1134	.0934	.112	.8078	.8421	.7865
3	.4961	.1134	.0934	.112	.7968	.7842	.7865
4	.4481	.1134	.1109	.112	.7621	.7935	.7449
5	.4531	.1134	.1663	.132	.8796	.8356	.7287
6	.5182	.1457	.2033	.1663	1.0595	.9282	.8322
7	.6009	.1457	.1848	.1629	1.1574	1.0722	.8962
8	.0789	.1457	.1829	.1663	1.1717	1.0936	.4696
9	1.1822	1.3765	.1829	.1829	.1086	.1075	.0905
10	1.647	1.5708	1.704	.1629	.1294	.1448	.0724
11	1.647	1.704	1.8785	.128	.1267	.1448	.0905
12	1.647	1.6549	1.8679	.1254	.1478		.0905
13	1.6108	1.6484	1.8138	.128	.1294	.1663	.0724
14	1.5746		1.6842	.128	.128	.0857	.0905
15	1.5927	1.2289	1.668	.1463	.1109	.0886	.0905
16	1.448	1.5364	1.5278	.1829	.1267	.1267	.0905
17	.1086	.0838	1.3435	.181	.1448	.124	.1267
18	.1629	.12	.1612	.1612	.1402	.104	.1267
19	.1448	.12	.1949	.1612	.1612	.1075	.1448
20	.1629	.1254	.1848	.1663	.1663	.128	.1448
21	.1267	.1307	.1478	.1663	.168	.1307	.1267
22	.1267	.1307	.1478	.1478	.1463	.1307	.1267
23	.1267	.112	.112	.9122	.8583	.8097	.543
24	.5312	.1267	.0934	.1109	.8905	.8583	.7842
Max	1.647	1.704	1.8785	.9122	1.1717	1.0936	.8962
Min	.0789	.0838	.0934	.1109	.1086	.0857	.0724
Avg	.7265	.5510	.6600	.1777	.4659	.4557	.3683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282			.2321			1.2597
2	.8951			.2321			1.2597
3	.8619			.1966			1.2266
4	.8619			.1966			1.2266
5	.8951		.2321	.2294	1.8233	1.7101	1.2266
6	1.0608		.2652	.2984	1.9227	1.8778	1.4918
7	1.2597	.2591	.2818	.3315	2.0317	2.2801	1.6575
8	.2294	.2785	.3149	.3315	2.1879	2.2466	1.6575
9	1.5581		.2622		.2486	.2294	.1781
10	1.4918	2.0287	2.3868			.2622	
11	1.8399	2.0454	2.5857			.3932	
12		2.079	1.6575			.2652	.1457
13		2.0119	2.3537			.2321	.1619
14			2.5194			.1989	
15		1.643	2.6189			.1638	.1619
16			2.5857			.1311	
17	.2429	.2321	2.2211			.2294	
18		.2486	.1966		.3647	.2321	.2294
19		.2818	.2949		.3481	.2652	
20	.2622	.2984	.2949		.3481	.2984	.2622
21		.2818	.2984		.3315	.2622	
22		.2818	.2984		.2984	.2294	
23	.2267		.2321		1.6095	1.1934	
24	.9282	.2105	.2486	.2321	1.4083	1.6766	1.2597
Max	1.8399	2.079	2.6189	.3315	2.1879	2.2801	1.6575
Min	.2267	.2105	.1966	.1966	.2486	.1311	.1457
Avg	.9028	.8700	1.1074	.2534	1.0769	.7189	.8937



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0427			1.1142			.112
2	.0396			1.0814			.112
3	.0381			1.0608			.112
4	.0381			1.0277			.1494
5	.0351		1.0364	1.0277	.0343	.1698	.1509
6	.0412		1.2763	1.2742	.0412	.2263	.2263
7	.0526	1.6575	1.5261	1.4255	.048	.2402	.1886
8	.064	.0514	1.2407	1.6575	.0572	.2218	.1867
9	.0572		.0514		.0617	.1829	.1646
10	.0438	.0572	.0549			2.3266	
11	.0572	.0587	.0572			2.3594	
12		.0587	.064			2.5232	.4784
13		.0644	.0663			2.3403	1.3283
14			.064				
15		.0718	.0495			2.1956	1.7604
16		.0648	.0572			2.3594	
17	.0724	.0583	.0667			2.17	
18		.0724	.0869		.1844	.1372	.156
19		.0686	.0629		.2402	.1848	
20		.0514	.0663		.2241	.1829	.1848
21		.0457	.0549		.2054		
22		1.2452	.0438		.168	.1494	
23	1.3279		1.1603		.1698	.1494	
24	.0427	1.1523	1.0562	1.1142	.0518	.1509	.1132
Max	1.3279	1.6575	1.5261	1.6575	.2402	2.5232	1.7604
Min	.0351	.0457	.0438	1.0277	.0343	.1372	.112
Avg	.1395	.3186	.4071	1.1981	.1238	1.0150	.3616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926			.0754			.9568
2	.7621			.0754			.9259
3	.7811			.0754			.884
4	.7811			.0754			.884
5			.1132	.0754	1.4899	1.2483	.9259
6	.8436		.1132	.0747	1.4723	1.2483	1.1069
7	.945	.112	.1494	.1097	1.7695	1.5043	1.1561
8	.1097	.0739	.112	.1097	1.8679	1.4864	1.1702
9	1.4403		.112			.1097	.1097
10	1.6004	1.9685	1.9989			.112	
11		2.0317	2.2024			.112	
12	1.7604	1.6518	2.2348			.1494	.112
13		1.5181	2.1765			.112	.112
14			2.2024			.112	
15		1.7814	2.2024			.112	.112
16		1.7166	2.1125			.112	
17	.1063	.1052	1.906				
18		.1075	.1075		.2149	.1063	.1478
19		.1097	.1478		.1448	.1109	
20		.112	.112		.1494	.1478	.1494
21		.1132	.1132		.112	.1494	
22		.1132	.1132		.112	.112	
23	.0709		.0754		1.2803	.9374	
24	.7926	.0716	.1132	.0754	1.3927	1.3123	.9686
Max	1.7604	2.0317	2.2348	.1097	1.8679	1.5043	1.1702
Min	.0709	.0716	.0754	.0747	.112	.1063	.1097
Avg	.8297	.7724	.9209	.0829	.9096	.4892	.6481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029			2.5766			2.3765
2	2.4897			2.4646			
3	2.3765			2.4646			2.1502
4	2.4897			2.4646			2.2405
5	2.4897		2.4897	2.5766	2.7161	1.9959	2.2405
6	2.9424		2.7161	3.0556	2.6886	2.4897	2.8292
7	2.9424	3.0556	2.7161	2.8292	2.5766	2.7435	2.7161
8	2.8292	2.9127	2.7435	2.6029	2.5766	2.5149	2.4897
9	2.7161		2.4897			2.4897	2.2634
10	2.8006	2.9127	2.7161			2.4897	
11	3.1047	3.3608	2.9424			2.6029	
12		3.6591	3.1367			2.8292	2.6029
13		3.3265	2.9127			2.7161	2.6029
14			2.9424			2.1502	
15		1.829	2.9424			2.6029	2.4897
16		3.4728				2.8292	
17	3.1047	3.4019				2.8006	
18		2.9127	2.8292		2.4897	2.7161	2.7161
19		3.1687	3.0556		2.6292	3.1687	
20	3.6969	3.315	3.5082		3.0864	3.2819	2.9721
21			3.2819		2.7161	3.1687	
22		3.0864	3.0556		2.6029	2.7161	
23	2.9721		2.9424		2.4646	2.7161	
24	2.6029	2.8578	2.6029	2.5766	2.4646	2.3525	2.4646
Max	3.6969	3.6591	3.5082	3.0556	3.0864	3.2819	2.9721
Min	2.3765	1.829	2.4897	2.4646	2.4646	1.9959	2.1502
Avg	2.8107	3.0908	2.8902	2.6235	2.6374	2.6687	2.5110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	1.5844
Max	1.5844
Min	1.5844
Avg	1.5844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV KASABE DIGRAJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5658	.5093	.5281	.3584	.3584	.3395
2	.5068	.6036	.5093	.5281	.3584	.3584	.3395
3	.5068	.6036	.5093	.5281	.3584	.3584	.3395
4	.5068	.6036	.5093	.6413	.3772	.3584	.3395
5	.5068	.6413	.5658	.679	.3772	.3772	.3772
6	.4525	.6602	.6979	.4527	.4338	.4338	.415
7	.543	.6602	.6602	.415	.3772	.3961	.4527
8	.5068	.5658	.7167	.5281	.3584	.3772	.5281
9	.4706	.547	.6036	.5093	.3206	.3395	.5658
10	.3395	.5611	.4668	.3961	.3018	.3395	.3961
11	.3921	.7059	.4294	.3395	.3018	.3772	.3584
12	.5788	.6878	.4668	.547	.3018	.3584	.3395
13	.5415	.3475	.5041	.4715	.2641	.2829	.3018
14	.4854	.5853	.6908	.4715	.2641	.2641	.2452
15	.4854	.5611	.6535	.3018	.2641	.2452	.2452
16	.5041	.5611	.5601	.3206	.2829	.2829	.547
17	.3921	.591	.4108	.5093	.2829	.3018	.415
18	.5975	.3921	.6348	.4527	.3206	.3018	
19	.5975	.5415	.6722	.4854	.3961	.4715	.6447
20	.5415	.5788	.7095	.5041	.5093	.5093	.691
21	.7356	.7922	.6722	.7095	.4904	.5093	.7087
22	.6979	.6413	.6224	.6224	.4715	.4904	.6379
23	.3961	.5093	.4338	.5658	.3961	.3772	.6024
24	.5611	.4527	.5281	.547	.5658	.3584	.3395
Max	.7356	.7922	.7167	.7095	.5658	.5093	.7087
Min	.3395	.3475	.4108	.3018	.2641	.2452	.2452
Avg	.5147	.5817	.5724	.5022	.3639	.3678	.4421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1543	.208	.2774	.0754	.0754	.0566
2	.0747	.1543	.208	.2774	.0754	.0754	.0566
3	.0747	.1543	.208	.2774	.0754	.0754	.0566
4	.0747	.1543	.208	.2774	.0754	.0754	.0566
5	.0747	.1543	.208	.2774	.0754	.0754	.0566
6	.0747	.1543	.208	.2947	.0754	.0754	.0566
7	.0747	.0566	.208	.3294	.0566	.0754	.0566
8	.0747	.0566	.2254	.3988	.0754	.0754	.0566
9	.0747	.0566	.0754	.0754	.0754	.0754	.0566
10	.0566	.056	.0566	.5256	.6001	.6344	.3561
11	.0566	.056	.0566	.7122	.6173	.7202	
12	.0566	.056	.0566	.7461	.6516	.7888	.0678
13	.0566	.0747	.0566	.763	.6173	.7202	.0678
14	.0566	.0747	.0566	.763	.6173	.703	.1696
15	.0566	.0747	.0566	.7291	.6173	.7202	.2883
16	.0566	.0747	.0566	.6952	.6401	.6687	.2883
17	.0566	.0747	.0754	.6613	.6001	.6516	.2713
18	.0566	.0754	.0566	.0754	.0566	.0566	
19	.0754	.0754	.0566	.0566	.0566	.0754	.0187
20	.0754	.0754	.0566	.0754	.0754	.0754	.0187
21	.12	.0754	.0754	.0754	.0754	.0566	.0187
22	.1543	.2254	.0754	.0754	.0754	.0566	.0187
23	.1543	.208	.2427	.0754	.0754	.0566	.0187
24	.0747	.1543	.3795	.2601	.0566	.0566	.0566
Max	.1543	.2254	.3795	.763	.6516	.7888	.3561
Min	.0566	.056	.0566	.0566	.0566	.0566	.0187
Avg	.0765	.1053	.1321	.3656	.2538	.2800	.0986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1509	.1509	.1509	.132	.1886	.1509
2	.1448	.1509	.1509	.1509	.132	.1698	.1509
3	.1448	.1509	.1509	.1509	.132	.1698	.1509
4	.1448	.1509	.132	.1698	.1509	.1698	.1509
5	.181	.2263	.1886	.1886	.1698	.1886	.1886
6	.2896	.2829	.2829	.2829	.2641	.3206	.3018
7	.2715	.2641	.2641	.2829	.2452	.3018	.3018
8	.2534	.2263	.2452	.2263	.2075	.2829	.2829
9		.2075	.2263	.2075	.2075	.2075	.2263
10	.2195	.2561	.2263	.2075	.1698	.2452	.1886
11	.2378	.2012	.1886	.1698	.1509	.2263	.1886
12	.1829	.2012	.1886	.1886	.1509	.1886	.1886
13	.2195	.1829	.2075	.1698	.132	.2075	.1886
14	.1509	.2012	.1886	.1698	.132	.1698	.1886
15	.1509	.1463	.2263	.1698	.132	.1698	.1698
16	.1698	.1463	.1509	.132	.1132	.132	.132
17	.2263	.2172	.1886	.1698	.1698	.1886	.1698
18	.1886	.168	.2075	.1886	.132	.2263	
19	.2012	.2987	.2452	.2075	.1886	.2452	.2328
20	.2452	.3018	.3018	.2641	.2829	.2641	.2507
21	.2195	.2641	.2829	.2452	.2641	.2641	.2686
22	.2241	.2452	.2641	.2452	.2452	.2263	.2328
23	.2075	.2263	.2452	.2263	.2263	.2075	.1991
24	.1463	.1509	.1698	.1698	.1509	.2075	.1509
Max	.2896	.3018	.3018	.2829	.2829	.3206	.3018
Min	.1448	.1463	.132	.132	.1132	.132	.132
Avg	.1985	.2091	.2114	.1973	.1784	.2153	.2024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6613	.6722	.8356	.0377	.0566	.0566
2	.056	.6613	.6722	.8356	.0377	.0566	.0566
3	.056	.6443	.6722	.8356	.0377	.0566	.0566
4	.056	.6443	.6722	.8356	.0377	.0566	.0566
5	.056	.6443	.6882	.8356	.0377	.0566	.0566
6	.056	.6613	.7522	.9339	.0566	.0566	.0566
7	.056	.0943	.8065	1.1142	.0566	.0566	.0566
8	.0747	.0943	.759	1.3272	.0566	.0754	.0566
9	.0747	.1132	.0754	.0754	.0566	.0754	.0566
10	.0943	.112	.0754	1.7695	1.6617	1.2548	.7287
11	.0754	.0934	.0943	1.9498	1.8821	1.56	.6802
12	.0754	.0934	.0943	1.9989	1.8313	1.56	.6964
13	.0754	.0934	.0754	1.9334	1.7465	1.543	.6478
14	.0943	.0934	.0754	1.917	1.7126	1.3565	.6154
15	.0754	.0747	.0754	1.8023	1.6448	1.3565	.5898
16	.0754	.0747	.0754	1.7976	1.56	1.3056	.5601
17	.0754	.0934	.0943	1.7166	1.4582	1.17	.4801
18	.0754	.0943	.0943	.0754	.0754	.0754	
19	.0754	.0943	.0754	.0943	.0566	.0754	.056
20	.0943	.0754	.0754	.0566	.0566	.0566	.056
21	.6443	.0566	.0754	.0566	.0566	.0566	
22	.6952	.7449	.0566	.0566	.0566	.0566	.056
23	.6613	.7362	.7045	.0566	.0566	.0566	.0373
24	.056	.6613	.6642	.8356	.0566	.0566	.0566
Max	.6952	.7449	.8065	1.9989	1.8821	1.56	.7287
Min	.056	.0566	.0566	.0566	.0377	.0566	.0373
Avg	.1491	.3088	.3407	.9894	.5970	.5036	.2623



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV VASANT LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0566	.0566	.0566	.0566	.0566
2	.0686	.0566	.0566	.0566	.0566	.0566
3	.0686	.0566	.0566	.0566	.0566	.1132
4	.0686	.0566	.0566	.0943	.0566	.1132
5	.0686	.0566	.0566	.1132	.0566	.132
6	.0686	.0566	.1132	.1509	.132	.132
7	.0686	.0566	.1132	.1509	.1509	
8	.0686	.0566	.2452	.2829	.2075	.2263
9	.1372	.1886	.3395	.3206	.2641	.2452
10	.1509	.1753	.3395	.3395	.3018	.2829
11	.132	.2279	.3395	.3395	.3018	.2263
12	.132	.2454	.3395	.3395	.3206	.2263
13	.132	.2279	.3206	.3395	.3206	.2263
14	.132	.2279	.3395	.3395	.3206	
15	.132	.2279	.3206	.3395	.3206	.0566
16	.132	.2279	.3206	.3395	.3206	.0566
Max	.1509	.2454	.3395	.3395	.3206	.2829
Min	.0686	.0566	.0566	.0566	.0566	.0566
Avg	.1018	.1376	.2134	.2287	.2028	.1536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0149	.0154	.0373			
2		.0149	.0154	.0373			
3		.0149	.0158	.0373			
4		.0152	.0158	.0373			
5		.0152	.0158	.0373			
6		.0152	.0158	.0373			
7		.0152	.0158	.0373			
8			.0158	.0373			
10					.0324	.0162	.0187
11				.0324	.0324	.0324	.0187
12				.0324	.0312	.0324	.0187
13				.0324	.0324	.0324	.0187
14				.0324	.0324	.0324	.0187
15				.0324	.0324	.0162	.0187
16				.0312	.0324	.0162	.0187
17				.0316	.0324		.0187
22	.0149	.0154					
23	.0151		.0187				
24	.0151	.0154		.0187			
Max	.0151	.0154	.0187	.0373	.0324	.0324	.0187
Min	.0149	.0149	.0154	.0187	.0312	.0162	.0187
Avg	.0150	.0151	.0160	.0339	.0323	.0255	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 KV PWV BRAMHNAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.197	.1417	.1494	.0373	.0187	.0895
2	.1867	.197	.1417	.1494	.0373	.0187	.0549
3	.1867	.197	.1417	.1494	.0373	.0187	.0549
4	.1867	.197	.1612	.1494	.0373	.0187	.0549
5	.1867	.2149	.1612	.1494	.0373	.0187	.0549
6	.1867	.2401	.1612	.1494	.0373	.0187	.0549
7	.2241	.2401	.1612	.1494	.0934	.1494	.0549
8	.2241	.2103	.1109	.1494	.0934	.1494	.0549
9	.2614	.2103	.1478	.1494	.0934	.1494	.0732
10	.2401	.2328	.1478	.2328	.0934	.1254	.0732
11	.2401	.2328	.1478	.2328	.0358	.1254	.0732
12	.1612	.2149	.1478	.2328		.1254	.0732
13	.1612	.2149	.2241	.2328	.0366	.0716	.056
14	.1612	.2103	.2241	.1791	.0366	.0716	.056
15	.1612	.1227	.2172	.1791	.0366		.056
16	.1612	.1227	.2241	.1791	.0366		.056
17	.056	.1753	.1867	.1715	.0366		.056
18	.056	.1578	.1867	.0377	.0377	.1075	.0373
19	.0509	.1227	.1867	.1867	.0373	.0189	.0373
20	.056	.1227	.1867	.1867	.0373	.0189	.0373
21	.056	.1949	.1867	.1867	.0373	.0189	.0187
22	.197	.1417	.1867	.1867	.0187	.0895	.0187
23	.197	.1417	.1867	.0373	.0187	.0895	.0187
24	.197	.1417	1.3716	.112	.0187	.0895	
Max	.2614	.2401	1.3716	.2328	.0934	.1494	.0895
Min	.0509	.1227	.1109	.0373	.0187	.0187	.0187
Avg	.1659	.1856	.2225	.1633	.0444	.0720	.0528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV EXPRESS LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0934	.2195	.0739	.0924
2	.0747	.0754	.0934	.2241	.0739	.0924
3	.0747	.0754	.0934	.2241	.0739	.0924
4	.0747	.0754	.0934	.2241	.0739	.0924
5	.0747	.0754	.0934	.2241	.0747	.0924
6	.0747	.0747	.0934	.2241	.0747	.0924
7	.0747	.0747	.0934	.2241	.2218	.0924
8	.112	.0747	.2033	.2195	.1867	.0934
9	.112	.0747	.3361	.1463	.3734	.0747
10	.2054	.2328	.3361	.3361	.3734	.0747
11	.2054	.2241	.3361	.3361	.3361	.0747
12	.2054	.2241	.3361	.3361	.3361	.0747
13	.2054	.2241	.2987	.3361	.3361	.056
14	.2054	.2241	.2987	.3361	.3361	.056
15	.2054	.2241	.2987	.3361	.3361	.056
16	.2054	.2241	.2987	.3361	.3361	.056
Max	.2054	.2328	.3361	.3361	.3734	.0934
Min	.0747	.0747	.0934	.1463	.0739	.056
Avg	.1365	.1408	.2123	.2677	.2261	.0789

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV YESHWANT EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.3544	.7442	1.6827	1.3253	1.3466
2	.7164	.3544		1.6827	1.3611	1.3466
3	.7164	.3544	.7442	1.6827	1.3969	1.3466
4	.7164	.3544	.7442	1.701	1.3969	1.3466
5	.7164	1.4175	.7973	1.701	1.3969	1.5238
6	.7164	1.4175	1.2757	1.701	1.3969	1.5238
7	1.182	1.4175	1.2757	1.701	1.5402	1.5415
8	1.3253	1.4175	1.5238	1.701	1.7193	1.5947
9	1.3969	1.4529	1.6827	1.701	1.7909	1.4327
10	1.4883	1.6478	1.6827	1.7364	1.7541	1.4327
11	.9602	1.6478	1.6827	1.701	1.7718	1.4327
12	1.0082	1.382	1.701	1.7187	1.7718	1.4327
13	1.5061	1.382	1.4022	1.7187	1.7718	1.4632
14	1.5061	1.382	1.4022	1.7177		1.4632
15	1.5061	1.382	1.4022	1.7364	1.6301	1.4632
16	1.3289	.7973	1.4022	1.5238	1.2403	1.4632
17						1.4632
24			.1715			
Max	1.5061	1.6478	1.701	1.7364	1.7909	1.5947
Min	.5731	.3544	.1715	1.5238	1.2403	1.3466
Avg	1.0852	1.1351	1.2272	1.6942	1.5510	1.4481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2058	.0857	.0187	.0187	.0189
2	.2218	.2058	.0857	.0187	.0187	.0189
3	.2218	.2058	.0857	.0187	.0187	.0189
4	.2218	.2058	.0857	.0187	.0187	.0189
5	.2218	.2058	.0857	.0187	.0187	.0189
6	.2218	.2229	.0857	.0187	.0187	.0189
7	.2218	.2058	.0857	.0187	.0187	.1187
8	.3142	.2229	.1187	.0187	.0187	.1187
9	.3142	.208	.0686	.0187	.0187	.0857
10	.298	.2774	.0686	.1063	.0867	.0857
11	.298	.3086	.0678	.0886	.0857	.0857
12	.298	.3086	.0678	.0886	.0867	.0857
13	.3155	.3086	.0343	.0886	.0867	.0876
14	.3155	.3086	.0343	.0886		.0876
15	.3155	.0857	.0343	.0886		.0876
16	.298	.0876	.0343	.0886	.0867	.0876
17			.0343			
Max	.3155	.3086	.1187	.1063	.0867	.1187
Min	.1848	.0857	.0343	.0187	.0187	.0189
Avg	.2677	.2234	.0684	.0504	.0429	.0653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV HARIPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	.0189	.0189	.0189	.7935	.7537	.4428
2	.3163	.0189	.0189	.0189	.7935	.7537	.4428
3	.3163	.0189	.0189	.0189	.7935	.7865	.4321
4	.3041	.0189	.0189	.0189	.7935	.7865	.4321
5	.3041	.0189	.0189	.0189	.7865	.7865	.4321
6	.3041	.0189	.0189	.0189	.8583	.7625	.4321
7	.3163	.0189	.0189	.0189	.8583	.8192	.4428
8	.0377	.0189	.0189	.0189	.9069	.8192	.4586
9	.639	.8421	.0189	.0189	.0189	.0189	.0189
10	.7537	.9012	1.0442	.0189	.0189	.0189	
11	.7865	.9448	1.1142	.0189	.0189	.0189	.0189
12	.8122	.9503	1.1934	.0189	.0189	.0189	.0189
13	.3593	.9602	1.1797	.0189	.0189	.0189	.0189
14	.7293	.8962	1.1934	.0189	.0189	.0189	.0189
15	.8048	.8848	1.1934	.0189	.0189	.0189	.0189
16	.7209	.8421	1.1142	.0189	.0189	.0189	.0189
17	.0189	.0189	1.0486	.0189	.0189	.0189	.0189
18	.0189	.0189	.0189	.0189	.0189	.0189	.0189
19	.0189	.0189	.0189	.0189	.0189	.0189	.0189
20	.0189	.0189	.0189	.0189	.0189	.0189	.0189
21	.0189	.0189	.0189	.0377	.0189	.0189	.0189
22	.0189	.0189	.0189	.0189	.0189	.0189	.0189
23	.0189	.0189	.0189	.7362	.7537	.4111	.1852
24	.3125	.0189	.0189	.0189	.7842	.7865	.4374
Max	.8122	.9602	1.1934	.7362	.9069	.8192	.4586
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.3444	.3135	.3910	.0496	.3494	.3221	.1906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 KV DUDHGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.0185	.0187	.0189	.463	.3749	.2439
2	.1907	.0189	.0187	.0189	.4687	.3953	.2439
3	.1907	.0187	.0187	.0189	.4744	.4012	.2439
4	.1932	.0187	.0187	.0189	.4687	.3749	.2439
5	.208	.0189	.0187	.0189	.4784	.3549	.2439
6	.2054	.0189	.0187	.0189	.4843	.3479	.2134
7	.2054	.0187	.0187	.0189	.4938	.3906	.1981
8	.0189	.0183	.0187	.0185	.4784	.4062	.1829
9	.3005	.5668	.0187	.0183	.0189	.0187	.0187
10	.3593	.6802	.6203	.0189	.0187	.0187	.0187
11	.4167	.6478	.5967	.0189	.0185	.0187	.0187
12	.4666	.6154	.5571	.0189	.0185	.0187	.0187
13	.4784	.5506	.6478	.0189	.0183	.0187	.0185
14	.4843	.5668	.6554	.0189	.0185	.0187	.0187
15	.4902	.583	.6554	.0189	.0189	.0187	.0187
16	.4475	.5506	.6722	.0189	.0187	.0187	.0187
17	.0185	.0187	.6154	.0189	.0173	.0187	.0187
18	.0189	.0187	.0187	.0185	.0185	.0187	.0187
19	.0187	.0187	.0187	.0189	.0187	.0187	.0187
20	.0187	.0187	.0189	.0189	.0189	.0187	.0189
21	.0189	.0187	.0189	.0189	.0187	.0187	.0189
22	.0187	.0187	.0187	.0189	.0189	.0187	.0189
23	.0189	.0187	.0187	.4531	.4111	.2439	.1128
24	.1783	.0187	.1902	.0189	.4531	.4161	.2439
Max	.4902	.6802	.6722	.4531	.4938	.4161	.2439
Min	.0185	.0183	.0187	.0183	.0173	.0187	.0185
Avg	.2142	.2109	.2288	.0369	.2056	.1653	.1014



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV KAVATHE PIRAN

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2801	.2801	.2987	.2987	.2667	.2614
2	.2614	.2667	.2801	.2987	.2987	.2801	.2614
3	.2614	.3018	.2801	.3018	.2987	.3018	.2614
4	.2614	.3361	.2801	.2987	.2987	.2667	.2614
5	.2614	.3921	.2801	.3361	.2987	.3395	.2614
6	.3361	.4338	.4108	.4527	.3361	.4338	.4294
7	.4108	.3898	.4108	.3395	.3921	.415	.4294
8	.4108	.3361	.3361	.3395	.3921	.3547	.4108
9	.2614	.2743	.2801	.2614	.3174	.3142	.2801
10	.2804	.2507	.2801	.2452	.2743	.2561	.2801
11	.2686	.2507	.2263	.2054	.2149	.2195	.2801
12	.2481	.2561	.2641	.2241	.1848	.1829	.2427
13	.2561	.2561	.2641	.2427	.2195	.1829	.2241
14	.2218	.2195	.2614	.2241	.1867	.1829	.1867
15	.2587	.1829	.2614	.2054	.168	.1829	.1848
16	.1629	.2195	.2263	.2054	.2012	.2012	.2195
17	.197	.2561	.2263		.1848	.2195	.2561
18	.2254	.2926	.3018	.2614	.2715	.2561	.2772
19	.3224	.3326	.3395	.3174	.3841	.3921	.3547
20	.4251	.4066	.4527	.4338	.4805	.4294	.4108
21	.4435	.4108	.4527	.4527	.4527	.4294	.3921
22	.3734	.3734	.3772	.3921	.4108	.3734	.3734
23	.3206	.3361	.3361	.3174	.3018	.2801	.2987
24	.2987	.3018	.2987	.3018	.3174	.2829	.2614
Max	.4435	.4338	.4527	.4527	.4805	.4338	.4294
Min	.1629	.1829	.2263	.2054	.168	.1829	.1848
Avg	.2929	.3065	.3086	.3024	.2993	.2935	.2958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV KAVATHE PIRAN AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.0097	.0095	.0088	.8383	.7202	.503
2	.2401	.0101	.0095	.009	.8817	.7291	.503
3	.2429	.0101	.0095	.009	.8718	.7042	.503
4	.2591	.0103	.0095	.0091	.8886	.7461	.503
5	.2721	.0103	.0095	.0091	.8987	.7209	.503
6	.2915	.0101	.0095	.0097	.9054	.7461	.4527
7	.2881	.0103	.0095	.0095	.9221	.7373	.4191
8	.0084	.0101	.0095	.0099	.8551	.7122	.3521
9	.6859	.9431	.0095	.0099	.0086	.0103	.0095
10	.7461	.9945	1.2346	.0084	.0084	.0095	.0095
11	.7969	.9945	1.2346	.0082	.0082	.0095	.0101
12	.8215	.9945	1.2346	.0084	.008	.0095	.0099
13	.8048	.9945	1.1191	.0084	.0082	.0095	.0099
14	.7969	.9602	1.1869	.0086	.008	.0095	.0099
15	.7461	.9259	1.1869	.0086	.0082	.0095	.0101
16	.7209	.9259	.9945	.0086	.0084	.0095	.0099
17	.0082	.0095	1.0631	.0084	.0082	.0095	.0097
18	.0088	.0095	.0084	.0082	.0084	.0095	.0097
19	.0086	.0095	.0088	.009	.0082	.0095	.0097
20	.0088	.0095	.0091	.0086	.3326	.0095	.0097
21	.0091	.0095	.0091	.0091	.0084	.0095	.0099
22		.0095	.009	.0091	.0086	.0095	.0099
23	.0088	.0095	.0091	.8215	.7202	.5256	.1658
24	.2267	.009	.0095	.0091	.8383	.7291	.503
Max	.8215	.9945	1.2346	.8215	.9221	.7461	.503
Min	.0082	.009	.0084	.0082	.008	.0095	.0095
Avg	.3577	.3287	.3918	.0428	.3775	.3002	.1894

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV SAMDOLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.2054	.2263	.2075	.2241	.1867
2	.1886	.2075	.2054	.2263	.2054	.2054	.1867
3	.1886	.2378	.2054	.2263	.2054	.2263	.1867
4	.1886	.2172	.2054	.2263	.2054	.1886	.1867
5	.1886	.2402	.2054	.2263	.2075	.2218	.1867
6	.2263	.2587	.2427	.2641	.2075	.2614	.2614
7	.2641	.2427	.2054	.2641	.2452	.2452	.2241
8	.2263	.2033	.1867	.2241	.1886	.2218	.2241
9	.2075	.1867	.1867	.1867	.1886	.2054	.1867
10	.2012	.1867	.2241	.2241	.168	.1886	.1867
11	.2149	.1867	.1886	.1494	.1494	.1867	.1867
12	.2172	.1867	.1886	.168	.1402	.1867	.1867
13	.1886	.1867	.2263	.1867	.1463	.168	.1867
14	.2012	.1867	.2263	.1867	.1294	.168	.1494
15	.1886	.1867	.2263	.1867	.1294	.168	.1494
16	.2012	.168	.1886	.2054	.1478	.168	.1663
17	.1867	.1867	.2263	.2241	.132	.1867	.1848
18	.2126	.2241	.2263	.2054	.2303	.2241	.2054
19	.3258	.2987	.2641	.2263	.2896	.2987	.2263
20	.3696	.3361	.3395	.3174	.3326	.3361	.3395
21	.3326	.3174	.3395	.3206	.3018	.3361	.3018
22	.3174	.2987	.3018	.3018	.2801	.3361	.2829
23	.2402	.2427	.2641	.2641	.2263	.2427	.2263
24	.1886	.2241	.2054	.2263	.2263	.1886	.1867
Max	.3696	.3361	.3395	.3206	.3326	.3361	.3395
Min	.1867	.168	.1867	.1494	.1294	.168	.1494
Avg	.2272	.2258	.2285	.2276	.2038	.2243	.2081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV SAMDOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.3222	.4481	.5731	.0189	.0175	.0187
2	.0187	.3353	.4481	.567	.0189	.0179	.0187
3	.0187	.373	.4481	.567	.0189	.0175	.0187
4	.0187	.3481	.4481	.5731	.0189	.0177	.0187
5	.0187	.3353	.4481	.6024	.0189	.0175	.0187
6	.0187	.3647	.4961	.6447	.0189	.0173	.0187
7	.0187	.426	.5121	.9259	.0189	.0177	.0187
8	.0187	.0164	.5121	1.134	.0189	.017	.0187
9	.0187	.0147	.0187	.0158	.0189	.0175	.0187
10	.0173	.0187	.0187	1.4998	1.3575	1.3203	.6348
11	.0175	.0187	.0187	1.4403	1.3643	1.3375	.6348
12	.0173	.0187	.0187	1.4575	1.2763	1.3546	.5601
13	.0168	.0187	.0187	1.4575	1.3643	1.3546	.5228
14	.017	.0187	.0187	1.3927	1.3289	1.3032	.4481
15	.0175	.0187	.0187	1.3108	1.3112	1.2346	.4108
16	.0143	.0187	.0187	1.2944	1.2757	1.166	.3734
17	.0158	.0187	.0187	1.2929	1.2894	1.1317	
18	.0168	.0187	.0187	.0187	.0166	.0187	
19	.0171	.0187	.0187	.0187	.0171	.0187	.3734
20	.0175	.0187	.0185	.0189	.0175	.0187	.0187
21	.0181	.0187	.0185	.0189	.0177	.0187	.0187
22	.39	.4481	.0187	.0189	.0175	.0187	.0187
23	.373	.4481	.567	.0189	.0183	.0187	.0187
24	.0187		.4481	.567	.0189	.0177	.0187
Max	.39	.4481	.567	1.4998	1.3643	1.3546	.6348
Min	.0143	.0147	.0185	.0158	.0166	.017	.0187
Avg	.0480	.1590	.2099	.7262	.4526	.4371	.1918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV SHAURYA INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0924	.112	.112	.1307	.052	.112
2	.056	.1132	.112	.112	.1307	.0526	.112
3	.056	.0924	.112	.112	.1307	.0514	.112
4	.056	.0747	.112	.112	.1307	.0509	.112
5	.056	.1097	.112	.112	.1307	.052	.112
6	.056	.0934	.1494	.1307	.1307	.0526	.0934
7	.056	.1097	.1494	.0747	.1307	.052	.0934
8	.056	.0739	.1307	.0934	.0373	.052	.0934
9	.1494	.1132	.1494	.0934	.0373	.1867	.1307
10	.2075	.1494	.1867	.1307	.0362	.1494	.1494
11	.168	.1307	.1494	.1307	.0532	.1494	.1494
12	.1132	.1307	.112	.112	.0532	.1494	.168
13	.1494	.1307	.1494	.112	.052	.1867	.1867
14	.0943	.1494	.2075	.1307	.0526	.168	.1494
15	.1698	.1494	.2075	.1494	.052	.168	.1494
16	.1886	.1307	.168	.1494	.0537	.168	.1494
17	.1097	.1494	.1886	.1307	.0526	.168	.1494
18	.1132	.1867	.112	.0934	.0532	.168	.1307
19	.128	.0373	.112	.112	.0514	.0934	.112
20	.0709	.0373	.0747	.1307		.0747	.056
21	.1109	.168	.0747	.1494	.0509	.0747	.0747
22	.1307	.0747	.0934	.1307	.0175	.0187	.0747
23	.1509	.0934	.1494	.1494	.0701	.0187	.112
24	.056	.1307	.0934	.112	.1494	.0532	.112
Max	.2075	.1867	.2075	.1494	.1494	.1867	.1867
Min	.056	.0373	.0747	.0747	.0175	.0187	.056
Avg	.1066	.1134	.1341	.1198	.0777	.1004	.1206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 KV WARANA KATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875				.5735	.4862	
2	.2031				.5735	.5144	
3	.2031				.5407	.4854	
4	.2031				.5344	.4917	
5	.2214				.5182	.5197	
6	.2187				.5182	.5304	
7	.2187				.5182	.5079	
8					.502	.5243	
9	.4641	.6226					
10	.5182	.6062	.7701				
11	.5079	.6062	.7865				
12	.5304	.6226	.7537				
13	.5506	.8029	.7209				
14	.4534	.7865	.7293				
15	.4915	.7373	.7293				
16	.5243	.7045	.7209				
17			.6882				
23				.5668	.4915		.16
24	.1875				.5668	.4973	
Max	.5506	.8029	.7865	.5668	.5735	.5304	.16
Min	.1875	.6062	.6882	.5668	.4915	.4854	.16
Avg	.3552	.6861	.7374	.5668	.5337	.5064	.16

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV BUDHGAON GAONTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.663		.5967	.583		
2		.7468		.6464	.6173		
3		.7095		.5304	.7373		
4		.7095		.5967	.6859		
5	.6344			.5304	.6173		.5304
6	.6001	.5601		.6464	.6173		.5304
7	.6859			.663	.5487		.663
8	.6001				.583		.5801
9	.7373						
10		.6962	.7468			.4973	.5801
11			.6535			.4973	.5801
12			.4973				.5801
13			.4973			.4144	.5601
14		.5304	.4144			.4144	.4973
15			.4144			.4641	.4144
16			.4144				.4144
17	.6464	.5801					
18	.663						
19	.7459						
20	.8962					.7127	
21	.8288						
22						.663	
24		.8871		.5967	.583		
Max	.8962	.8871	.7468	.663	.7373	.7127	.663
Min	.6001	.5304	.4144	.5304	.5487	.4144	.4144
Avg	.7038	.6759	.5197	.6008	.6192	.5233	.5391

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV KALERAN ( KAVALPUR ) SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3315		.5967	.0663		
2		.3315		.663	.116		
3		.3391		.6464	.0663		
4		.3315		.5967	.0829		
5	.0829	.4144		.547	.0663		.0829
6	.0829	.4144			.0829		.0829
7	.0829			.6299	.116		.0829
8	.0829				.116		.0829
9	.0829					.0497	
10		.0663	.0747			.4144	.1658
11						.4973	.2486
12						.5801	.2486
13			.0747			.4973	.2984
14		.0829				.5801	.2984
15						.4973	.2984
16			.0663				.0373
17	.0995	.0829					
18	.0829						
20						.0663	
21	.0829						
22						.0663	
24		.3315		.547	.0663		
Max	.0995	.4144	.0747	.663	.116	.5801	.2984
Min	.0829	.0663	.0663	.547	.0663	.0497	.0373
Avg	.0850	.2726	.0719	.6038	.0866	.3610	.1752



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV BISUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.12		
2				.1715	.12		
3				.1543	.0686		
4				.1715	.12		
5	.1715			.1886	.12		.1886
6	.1886	.1494		.2058	.1715		.2058
7	.2058			.1543	.1886		.1886
8	.1372				.1715		.1715
9	.1372						
10		.12	.1307			.1494	.1494
11			.1307			.1326	.1494
12			.1307			.1494	
13			.1307			.1494	.1326
14		.1029					
15						.1494	
16			.1326				.1494
17	.0934	.1029					
18	.112						
19	.1494						
20	.1867					.2401	
21	.1867						
22						.1715	
24		.1658		.1543	.12		
Max	.2058	.1658	.1326	.2058	.1886	.2401	.2058
Min	.0934	.1029	.1307	.1543	.0686	.1326	.1326
Avg	.1569	.1282	.1311	.1736	.1334	.1631	.1669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV BUDHGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0663		.0497	.2058		
2		.0663		.0497	.1715		
3				.0497	.1886		
4				.0497	.1715		
5	.0857			.0497	.2572		.1658
6	.0857	.0663		.0497	.2572		.1658
7	.0514			.0663	.3772		.1823
8	.0514				.3772		.2321
9	.2572					.3315	
10		.463	.2772			.0497	.0497
11			.3734			.0497	
12			.4144			.0497	
13			.4144			.0497	
14		.5316	.4668			.0497	
15			.4144				
16			.4144				.0497
17		.0514					
18	.0663						
20						.0497	
21	.0497						
22						.0497	
24		.0663		.0497	.1715		
Max	.2572	.5316	.4668	.0663	.3772	.3315	.2321
Min	.0497	.0514	.2772	.0497	.1715	.0497	.0497
Avg	.0925	.1873	.3964	.0518	.2420	.0849	.1409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV EXPRESS COLLEGE

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0514	.0514		
2				.0514	.0514		
3				.0514	.0514		
4				.0514	.0514		
5	.1029			.0514	.0514		.0343
6	.0857	.112		.0514	.0514		.0514
7	.0514			.0514	.0514		.0514
8	.1372				.0514		.0343
9	.1372						.037
10		.1715	.1326			.0747	
11			.1494			.0934	
12			.112			.0924	
13			.0747				
14		.1543					
16			.1029				
17	.1307	.0514					
18	.112						
20	.112					.0514	
21	.112						
22						.0514	
24		.0934		.0514	.0514		
Max	.1372	.1715	.1494	.0514	.0514	.0934	.0514
Min	.0514	.0514	.0747	.0514	.0514	.0514	.0343
Avg	.1090	.1165	.1143	.0514	.0514	.0727	.0417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV JYPTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056		.0171	.0171		
2		.056		.0343	.0171		
3		.056		.0343	.0171		
4		.0747		.0857	.0171		
5	.0857	.0747		.0857	.0171		.0343
6	.0686	.0075		.0857	.0171		.0514
7	.0857			.0857	.0171		.0514
8	.0857				.0171		.0514
9	.0857						
10		.0857	.0373			.056	
11			.0373				
12			.0373				
13			.0747				
14		.0857					
15						.056	
16	.112		.056				.056
24				.0171	.0171		
Max	.112	.0857	.0747	.0857	.0171	.056	.056
Min	.0686	.0075	.0373	.0171	.0171	.056	.0343
Avg	.0872	.0620	.0485	.0557	.0171	.056	.0489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV BISUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3315		.4973	.0332		
2		.3315		.4973	.0497		
3		.3315		.431	.0497		
4		.4144		.5304	.0497		
5	.0497	.4973		.4973	.0332		.0497
6	.0497	.0497		.4973	.0663		.0497
7	.0497			.5801	.0497		.0663
8	.0497				.0497		.0497
9	.0497						
10		.0332	.0497				
13			.0497				.1357
14		.0332					.1867
15							.1867
16			.0497				.2801
17	.0332	.0332					
20						.0332	
21	.0747						
22						.0332	
24		.3315		.4144	.0332		
Max	.0747	.4973	.0497	.5801	.0663	.0332	.2801
Min	.0332	.0332	.0497	.4144	.0332	.0332	.0497
Avg	.0509	.2387	.0497	.4931	.0460	.0332	.1256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 KV DUDHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2801	.2801	.2801	.2801	.2641	.2614
2	.2614	.2801	.2801	.2801	.2801	.2641	.2427
3	.2614	.2801	.2801	.2801	.2801	.2641	.2427
4	.2614	.2801	.2801	.3174	.2801	.2641	.2801
5	.2801	.3174	.2801		.3361	.2641	.3361
6	.3734	.3921	.3361	.3734	.3361	.3018	.3734
7	.4481	.4481	.3361	.4435	.3174	.3961	.4066
8	.4294	.3921	.3361	.4435	.3547	.3395	.3547
9	.3734	.3734	.3361	.3921	.2987	.3174	.3361
10	.3361	.3174	.3734	.3921	.2801	.2987	
11	.3361	.3361	.3547	.3734	.2801	.3174	.2987
12	.3174	.3547	.2987	.3361	.0943	.3361	.3547
13	.3921	.3361	.2614	.3547	.0566	.2987	.3601
14	.3921	.3547	.3361	.3547	.0943	.2987	.3734
15	.3921	.3734	.3734	.3547	.0943	.3174	.3547
16	.3921	.3734	.3734		.3174	.3174	.3921
17	.3734	.3921	.3547	.4108	.3174	.3361	.4108
18	.4294	.4108	.3174	.3174	.2987	.3734	.4481
19	.4481	.4854	.3881	.4294	.3361	.4668	.4481
20	.4294	.4854	.4938	.5415	.4108	.499	.5041
21	.3734	.4294	.4435	.4481	.4338	.462	.4668
22	.3361	.3921	.4066	.3921	.3772	.4108	.3734
23	.2987	.3174	.3361	.3174	.3206	.3361	.2987
24	.2801	.2801	.2801	.2987	.2801	.2829	.2801
Max	.4481	.4854	.4938	.5415	.4338	.499	.5041
Min	.2614	.2801	.2614	.2801	.0566	.2641	.2427
Avg	.3532	.3618	.3390	.3696	.2815	.3345	.3564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 KV SAWALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.2187	.218	.2378	.0191	.0191	.0191
2	.0191	.2187	.218	.2378	.0191	.0191	.0191
3	.0191	.2031	.218	.2675	.0191	.0191	.0191
4	.0191	.2031	.218	.2675	.0191	.0191	.0191
5	.0191	.1562	.218	.2972	.0381		.0191
6	.0381	.1562	.218	.3269	.0381	.0381	.0381
7	.0381	.2031	.2515	.4161	.0381	.0381	.0381
8	.0381	.0191	.2515	.6093	.0381	.0381	.0381
9	.0381	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.7133	.823	.9069	.4268
11	.0191	.0191	.0191	.8768	.7773	.9717	.2743
12	.0191	.0191	.0191	.9659	.8993	.9231	.1829
13	.0381	.0191	.0191	.8768	.884	.9878	.1677
14	.0191	.0191	.0191	.9362	.8993	.9393	.1677
15	.0191	.0191	.0191	.9065	.0943	.9069	.1677
16	.0191	.0191	.0191	.9065	.8688	.8745	.1524
17	.0191	.0191	.0191	.945	.8688	.7748	.1372
18	.0191	.0191	.0191	.0381	.0381	.0191	.0191
19	.0191	.0191	.0191	.0381	.0381	.0381	.0191
20	.0191	.0191	.0191	.0381	.0191	.0381	.0191
21	.0191	.0191	.0191	.0381	.0191	.0191	.0381
22	.0469	.2347	.0191	.0381	.0191	.0191	.0191
23	.1718	.2347	.1486	.0381	.0191	.0191	.0191
24	.0191	.2343	.218	.2378	.0191	.0191	.0191
Max	.1718	.2347	.2515	.9659	.8993	.9878	.4268
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0306	.0971	.1019	.4280	.2723	.3333	.0858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 KV DHARAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671				.3048	.2683	.1781
2	.0671				.3048	.2683	.1781
3	.0671				.3048	.2683	.1781
4	.0671				.3048	.2683	.1619
5	.0671				.3353	.2683	.1619
6	.1174				.3353	.2683	.1619
7	.1341				.3658	.2683	.218
8					.3963	.3688	.1677
9	.3353	.4694					
10	.3521	.5533	.6203				
11	.3688	.5533	.6539				
12	.3688	.6036	.6203				
13	.3856	.6036	.6036				
14	.3856	.57	.5868				
15	.3688	.5197	.57				
16	.3856	.5197	.57				
22						.1781	
23				.3353	.2683	.1781	.0838
24	.0671				.3048	.285	.1781
Max	.3856	.6036	.6539	.3353	.3963	.3688	.218
Min	.0671	.4694	.57	.3353	.2683	.1781	.0838
Avg	.2253	.5491	.6036	.3353	.3225	.2626	.1668



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 KV BAGANI ROAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.192	.1677	.1943	.0381	.0381	.0191
2	.0191	.192	.1677	.1943	.0381	.0381	.0191
3	.0191	.176	.1677	.1781	.0381	.0381	.0191
4	.0191	.176	.1677	.2267	.0381	.0381	.0191
5	.0191	.176	.1677	.2267	.0381	.0381	.0381
6	.0381	.176	.2012	.1943	.0381	.0381	.0381
7	.0381	.2401	.2515	.2267	.0381	.0191	.0381
8	.0381	.0381	.2683	.2753	.0572	.0381	.0381
9	.0381	.0191	.0191	.0191	.0191	.0191	.0191
10	.0381	.0191	.0191	.4365	.4475	.3795	.2812
11	.0191	.0191	.0191	.4666	.4938	.5668	.2031
12	.0191	.0191	.0191	.5569	.4784	.4481	.1718
13	.0191	.0191	.0191	.5268	.463	.5344	.1718
14	.0191	.0191	.0191	.5418	.4475	.5182	.1718
15	.0191	.0191	.0191	.4816	.4475	.4858	.1718
16	.0191	.0191	.0191	.4816	.463	.4534	.1718
17	.0191	.0191	.0191	.4572	.4475	.4161	.1562
18	.0191	.0191	.0191	.0381	.0381	.0191	.0191
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.176	.1823	.0381	.0381	.0381	.0381	.0191
23	.192	.2012	.1943	.0381	.0381	.0191	.0191
24	.0191	.192	.2035	.2429	.0381	.0381	.0191
Max	.192	.2401	.2683	.5569	.4938	.5668	.2812
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0392	.0936	.0959	.2565	.1791	.1807	.0808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0934	.112	.1132	.1867	.2263
2	.0566	.0934	.112	.1509	.1867	.2263
3	.0566	.0934	.112	.1886	.1867	.2263
4	.0566	.112	.112	.2075	.1867	.2452
5	.0566	.112	.112	.2263	.1867	.2641
6	.0754	.112	.112	.2263	.2241	.2641
7	.0754	.112	.3174	.3584	.4294	.2452
8	.2241	.168	.3734	.3961	.4294	.2452
9	.1867	.168	.3734	.415	.4481	.3961
10	.2054	.2054	.3361	.4294	.5041	.3772
11	.2054	.2054	.3547	.3361	.4668	.3772
12	.2054	.2054	.3547	.3361	.4668	.3772
13	.2054	.2054	.3547	.3921	.4108	.3584
14	.2054	.2054	.3547	.3921	.4108	.3395
15	.2054	.2241	.3547	.4108	.4108	.3772
16	.2054	.2054	.3547	.4108	.4294	.3772
Max	.2241	.2241	.3734	.4294	.5041	.3961
Min	.0566	.0934	.112	.1132	.1867	.2263
Avg	.1427	.1575	.2625	.3119	.3478	.3077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV NANDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7733	.7733	.7545	.7356	.724	.7545
2	.7167	.7922	.7545	.7167	.7356	.7059	.7356
3	.7167	.7733	.7545	.7167	.7545	.6805	.7356
4	.7167	.811	.7545	.7167	.7545	.6984	.7356
5	.8215	1.0751	1.0185	.7922	.8865	.8775	.9055
6	.9795	.9979	.9979	1.0269	.9149	.9774	.9511
7	.9511	.9511	.9425	.9709	.9149	1.0608	.9511
8	.823	.8059	.8596	.8596	.7682	1.0208	.8869
9	.8596	.8059	.823	.7619	.6984	.8059	.8688
10	.7701	.6984	.8596	.7796		.8059	.037
11	.7164	.7265	.815	.7537		.7265	.1663
12	.7164	.7442	.7796	.7087		.7537	.8779
13	.6984	.6485	.8059			.691	.7783
14	.6089	.631	.7343	.6219		.6089	.6447
15	.6335	.6379	.7207	.6089		.6089	.6201
16	.5121	.6447	.7602	.591		.6024	.4961
17	.567	.6697	.7265	.5853	.8326	.6001	.5611
18	.6687	.6767	.7059	.6241	.8238	.7316	.7783
19	.8059	.8131	.8145	.8507	.9955	.9055	.9145
20	1.1016	1.0903	1.1273	1.0719	1.2254	1.0719	1.1088
21	1.0082	1.0164	1.1203	1.0642	1.0745	1.0456	1.0456
22	.9808	1.0082	1.0374	1.0751	.985	.9522	.9431
23	.8299	.8676	.9054	.8299	.8413	.8299	.7655
24	.811	.7545	.8299	.811	.7545	.7682	.7733
Max	1.1016	1.0903	1.1273	1.0751	1.2254	1.0719	1.1088
Min	.5121	.631	.7059	.5853	.6984	.6001	.037
Avg	.7820	.8089	.8509	.7953	.8645	.8022	.7515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0347	.1734	.1808	.1894		.0358	.0362
2	.0343	.1669	.1783	.192		.0362	.0362
3	.0343	.1833	.1783	.192		.0549	.0366
4	.0343	.1623	.1808	.1894		.0554	.0366
5	.0343	.1692	.2115	.192		.0554	.0366
6	.0335	.1833	.2115	.2225		.0549	.0366
7	.0503	.2	.2286	.2782		.0543	.0366
8	.037	.0339	.2143	.3144	.0886	.0905	.0366
9	.037	.0366	.0339	.0351	.0867	.0724	.0362
10	.0366	.0543	.0366	.4572		.431	.3418
11	.0335	.0362	.0358	.503		.503	.3269
12	.032	.0358	.0189	.4666		.5117	.3612
13	.032	.0354	.0189			.5117	.3612
14	.032	.0354	.032	.4108		.4967	.3374
15	.032	.0354	.032	.4001		.4694	.3418
16	.0339	.0358	.048	.4012		.4755	.3462
17	.0316	.0537	.032	.3763	.3666	.4254	.3311
18	.0324		.0537	.0469	.0633	.0347	.0724
19	.0335	.0549	.0537	.0716	.0671	.0532	.0549
20	.056	.0554	.0537	.0732	.0537	.0537	.0914
21	.0373	.0554	.0554	.0724	.0537	.0358	.0554
22	.1833	.2286	.0554	.0914	.0537	.0362	.0554
23	.1858	.2143	.1947	.0526	.0362	.0362	.037
24	.0351	.1709		.1894	.0526	.0358	.0362
Max	.1858	.2286	.2286	.503	.3666	.5117	.3612
Min	.0316	.0339	.0189	.0351	.0362	.0347	.0362
Avg	.0482	.1048	.1017	.2356	.0922	.1925	.1449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV MALBHAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.0362	.056	.0554	.2743	.2107	.216
2	.1158	.037	.0566	.0554	.2559	.2056	.2006
3	.1158	.0362	.0566	.0554	.2623	.216	.1981
4	.1158	.0366	.0566	.0554	.2591	.2343	.1981
5	.1174	.0366	.0566	.0543	.2559	.2187	.2315
6	.132	.037	.0566	.0709	.2347	.2439	.2286
7	.1448	.0549	.0549	.0709	.2709	.2559	.2469
8	.0554	.0366	.0914	.0526	.2896	.2675	.2439
9	.1932	.3161	.0543	.0709	.0876	.052	.1097
10	.2408	.3567	.4012	.124		.0876	.128
11	.3048	.3715	.4268	.1254		.1187	.0914
12	.3241	.3913	.442	.1227		.1387	.0914
13	.3612	.3864	.4268			.104	.1109
14	.3462	.3763	.3858	.1086		.0838	.1109
15	.3395	.3612	.381	.1109		.0838	.1109
16	.3201	.3658	.3462	.1097		.1052	.1109
17	.0739	.0549	.3311	.1075	.0532	.1063	.1086
18	.0747	.0549	.0905	.0709	.0514	.0895	.0724
19	.056	.0549	.0895	.0716	.0514	.1254	.0724
20	.0366	.0554	.0724	.0724	.0526		.0739
21	.0373	.0554	.0739		.0532	.1086	.0701
22	.037	.056	.0747	.0709	.0526	.0905	.0701
23	.0373	.056	.0754	.2469	.2006	.2134	.1337
24	.132	.0549		.0724		.2134	.2134
Max	.3612	.3913	.442	.2469	.2896	.2675	.2469
Min	.0366	.0362	.0543	.0526	.0514	.052	.0701
Avg	.1595	.1533	.1807	.0889	.1691	.1554	.1434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3658	.415	.415	.3584	.3734	.3206
2	.3395	.3439	.415	.3961	.3734	.3696	.3206
3	.3206	.3224	.3961	.3961	.4024	.3658	.3361
4	.3395	.3258	.3921	.3772	.4435	.3658	.3361
5	.3584	.3475	.4294	.3772	.4525	.4108	.3772
6	.4527	.462	.4715	.3961	.3696	.5041	.4715
7	.4854	.5121	.4668	.4527	.5041	.4805	.4668
8	.4668	.4207	.4024	.4251	.4066	.4066	.4294
9	.3841	.3475	.4119	.4119	.3641	.4066	.4024
10	.2865	.3045	.3582	.3142		.3326	.2896
11	.3292	.3224	.3582	.3142		.2947	.2715
12	.3109	.3189	.3721	.3224		.2947	.2865
13	.2743	.3582	.3801	.3142		.2658	.2534
14	.2926	.3475	.3547	.2743			.2353
15	.0183	.3292	.3734	.2561			.2149
16	.0366	.2896	.3475	.2374		.3012	.1753
17	.3292	.3544	.3403	.2401	.3641	.2427	.2126
18	.3109	.4287	.3898	.2658	.3511	.3721	.3898
19	.5121	.4656	.4755	.3582	.4938	.5552	.4835
20	.6219	.6036	.5601	.567	.5121	.5359	.5304
21	.5304	.5487	.547	.5658	.499	.4668	.4854
22	.4938	.5415	.5281	.4572	.5041	.4251	.4715
23	.4572	.4338	.4527	.3734	.5041	.3772	.3772
24	.5601	.3475	.3961	.415	.3584		.3206
Max	.6219	.6036	.5601	.567	.5121	.5552	.5304
Min	.0183	.2896	.3403	.2374	.3511	.2427	.1753
Avg	.3688	.3934	.4181	.3718	.4271	.3880	.3524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 KV TUKAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.3121	.3658	.3593	.0754	.0678	.0747
2	.0566	.3311	.4687	.3479	.0747	.0732	.0747
3	.0566	.3353	.4755	.3361	.0924	.0732	.0754
4	.0566	.286	.5418	.3401	.0924	.0747	.0934
5	.0566	.2972	.6019	.3605	.112	.0924	.1132
6	.0943	.5335	.5624	.4534	.0943	.0934	.132
7	.112	.6944	.7186	.4481	.112	.0934	.1132
8	.0747	.0934	.0914	.6718	.112	.1109	.0934
9	.0724	.0724	.1494	.0924	.0924	.0876	.0747
10	.0914	.0709	.0709	.7907		.8796	.3241
11	.0724	.0886	.0867	.8482		1.012	.3749
12	.0716	.0905	.0848	.8179		.9259	.4167
13	.0716	.1063	.0686	.8322			.3506
14	.0469	.1097	.0914	.8381			.3612
15	.0514	.0886	.1097	.8025			.3567
16	.0663	.1052	.0709	.6481		.679	.3612
17	.0716	.1052	.0701	.68	.6097	.3749	.3715
18	.0716	.0905	.0886	.0543	.0791	.0732	.0914
19	.0886	.0895	.0914	.0732	.1029	.0739	.0943
20	.0934	.0934	.1132	.0934	.104	.0943	.0943
21	.0934	.0934	.132	.0934	.0876	.0943	.0943
22	.3437	.3887	.1132	.0924	.0867	.0943	.0943
23		.3462	.4001	.0732		.0754	.0754
24	.056	.301	.3121	.3593	.0747		.0754
Max	.3437	.6944	.7186	.8482	.6097	1.012	.4167
Min	.0469	.0709	.0686	.0543	.0747	.0678	.0747
Avg	.0838	.2135	.2450	.4378	.1251	.2572	.1825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.216	.1509	.1494	.1494	.2972	.2743	.216
2	.2031	.1294	.1509	.132	.4816	.3353	.2286
3	.2056	.1307	.168	.132	.3311	.3858	.2439
4	.208	.132	.1494	.132	.4458	.381	.2778
5	.2241	.132	.1698	.1509	.6687	.5556	.2812
6	.2846	.1494	.1494	.1698	.7621	.6097	.2812
7	.4374	.1848	.1494	.2054	.8065	.6859	.4167
8	.1698	.168	.1663	.168	.7274	.7562	.4167
9	.5556	.6327	.1463	.2054	.1372	.1433	.1294
10	.6097	.7074	.703	.1478		.1494	.0934
11	.6859	.743	.8688	.1478		.128	.0924
12	.7099	.743	.7225	.1463		.1267	.1097
13	.7407	.7674	.9105	.1294		.1109	.0895
14	.7682	.7716	.9686	.112		.1227	.0895
15	.7562	.8488	1.0467	.1294			.0886
16	.7842	.6093	.9907	.128		.1075	.0709
17	.128	.1086	.4877	.128	.1214	.1097	.0886
18	.1463	.1646	.1307	.1478	.1619	.1294	.0924
19	.1494	.1663	.1494	.168	.1677	.1307	.1132
20	.2054	.2033	.2054	.1886	.1543	.1509	.1132
21	.1867	.1848	.1886	.1867	.1578	.1509	.132
22	.168	.1698	.1698	.1698	.1646	.1509	.1132
23	.168	.1509	.1509	.3715		.2134	.1852
24	.216	.168	.168	.1494	.3311		
Max	.7842	.8488	1.0467	.3715	.8065	.7562	.4167
Min	.128	.1086	.1307	.112	.1214	.1075	.0709
Avg	.3720	.3465	.3858	.1623	.3698	.2686	.1723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 400 / STATION TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6089	.6154	.6154	.543	.5973	.543
2	.5973	.5792	.5973	.5792	.5068	.5792	.5249
3	.5792	.543	.5792	.5487	.5068	.543	.5249
4	.5792	.5121	.543	.5487	.4755	.5611	.5068
5	.5487	.5175	.543	.5914	.4755	.543	.5068
6	.5487	.5601	.4887	.5914	.5121	.543	.5068
7	.6036	.6584	.5973	.6584	.5853	.6335	.6154
8	.6468	.6516	.5973	.6516	.695	.6697	.6697
9	.6878	.6878	.6219	.724	.6219	.6468	.7316
10	.7602	.724	.7023	.724	.6878	.7682	.7602
11	.7964	.8596	.6697	.7964	.6878	.7964	.7964
12	.7421	.823	.724	.7059	.6767	.8238	.724
13	.6878	.7602	.6878	.724	.6219	.6697	.6447
14	.7059	.6401	.6733	.724	.5973	.6767	.6733
15	.724	.7392	.6733	.6878	.6401	.6697	.6447
16	.7421	.6468	.6626	.6878	.6584	.724	.6024
17	.7602	.724	.6805	.6626	.5611	.6516	.6626
18	.788	.724	.7522	.7522	.6697	.8507	.7602
19	.9922	.9774	.8596	.9745	.9231	1.0136	.9114
20	1.0631	1.1041	1.0029	1.0454	1.0498	1.086	.9391
21	.8859	.9955	.9313	.8859	.9593	.9774	.7522
22	.7796	.8869	.8413	.815	.8145	.8145	.7164
23	.7164	.724	.7164	.6268	.6697	.6878	.6154
24	.5792	.6447	.6335	.6516	.543	.6154	.5792
Max	1.0631	1.1041	1.0029	1.0454	1.0498	1.086	.9391
Min	.5487	.5121	.4887	.5487	.4755	.543	.5068
Avg	.7122	.7205	.6831	.7072	.6534	.7143	.6630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5487	.543	.5601	.5544	.4706	.6154
2	.499	.5175	.5249	.5601	.5175	.4525	.6154
3	.4805	.4854	.5068	.5281	.5175	.4525	.5973
4	.4854	.4854	.5249	.4904	.5228	.4344	.5792
5	.4854	.5281	.4887	.4854	.5415	.4344	.5973
6	.4668	.5121	.4887	.5281	.5228	.4344	.5973
7	.4668	.5175	.4887	.5228	.5415	.4344	.4525
8	.4668	.5121	.5249	.4805	.5041	.4344	.4525
9	.6468	.5792	.5175	.6335	.5175	.6838	.5544
10	.6878	.6697	.6468	.6516	.5175	.695	.6584
11	.7964	.7762	.6161	.7468	.6468	.8596	.8688
12	.7421	.7392	.5544	.6878	.5975	.788	.7964
13	.8326	.8326	.5487	.6516	.6535	.823	.7316
14	.7421	.7682	.5544	.6516	.499	.8316	.724
15	.8145	.8131	.5544	.7421	.5601	.8413	.724
16	.7421	.7392	.5487	.7602	.6099	.8688	.724
17	.8048	.6584	.5487	.6767	.5611	.8145	.724
18	.724	.6516	.6516	.7095	.6335	.7964	.7964
19	.7964	.8326	.7164	.8326	.7421	.9955	.9313
20	.8688	.8869	.8048	.9412	.7964	1.0136	.9774
21	.8048	.7964	.7316	.8145	.6697	.8688	.8779
22	.7316	.724	.6878	.6653	.5973	.7783	.8316
23	.6584	.6335	.6584	.6283	.543	.724	.7468
24	.5175	.5853	.5611	.5975	.5544	.4706	.6516
Max	.8688	.8869	.8048	.9412	.7964	1.0136	.9774
Min	.4668	.4854	.4887	.4805	.499	.4344	.4525
Avg	.6575	.6580	.583	.6478	.5801	.6834	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5792	.5611	.5975	.5601	.5792	.4887
2	.5228	.5487	.543	.5601	.5228	.543	.4706
3	.5228	.4805	.5249	.5281	.4854	.543	.4706
4	.5228	.4805	.5068	.5281	.4435	.543	.4887
5	.4904	.4854	.4887	.5601	.4435	.5611	.4887
6	.4904	.5281	.4706	.5658	.4481	.5792	.4887
7	.5658	.5658	.4887		.4715	.5611	.5249
8	.5658	.5601	.543	.6036	.5281	.5973	.543
9	.6722	.6036	.6413	.6154	.6036	.6224	.5853
10	.7059	.7842	.7545	.6878	.7095	.7095	.7167
11	1.0136	.9808	.8676	1.0317	.7842	.9335	.8299
12	.9593	.9431	.8865	1.0136	.8488	.9145	.8326
13	1.0317	.9979	.9335	.905	.8402	.8676	.8596
14	1.0136	.961	.9335	.9412	.8215	.9054	.905
15	.8779	1.0082	.8871	.9593	.9054	.8488	.8589
16	.9774		.9145	.8688	.3077	.8775	.8299
17	1.0136	.9709	.8871	.8962	.724	.8688	.7922
18	1.0562	.9774	.961	.9522	.9231	.9231	.8215
19	1.0829	1.0317	1.1203	1.0082	.9593	1.0317	.961
20	1.1088	1.1584	1.1088	1.0903	1.0498	1.0498	1.0719
21	.9145	.9593	1.1088	1.0425	.9593	.9231	.924
22	.7964	.8326	.8779	.8131	.7421	.7783	.7392
23	.724	.6516	.7316	.6653	.6335	.543	.6036
24	.5601	.6154	.5792	.6348	.5601	.5792	.5068
Max	1.1088	1.1584	1.1203	1.0903	1.0498	1.0498	1.0719
Min	.4904	.4805	.4706	.5281	.3077	.543	.4706
Avg	.7812	.7698	.7633	.7856	.6781	.7451	.7001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4481	.5201	.4481	.4534	.4641	.4424
2	.4801	.4161	.4748	.4428	.4534	.4475	.4475
3	.4424	.4062	.4588	.4218	.4372	.4424	.4915
4	.4424	.4062	.4218	.4321	.427	.426	.4807
5	.4588	.4115	.3963	.4115	.427	.4372	.5365
6	.4534	.4054	.3909	.4321	.4218	.4481	
7	.4862	.4531	.3814	.4641	.4534	.4534	.4409
8	.463	.4752	.4218	.4374	.4588	.4424	.4961
9	.5144	.4807	.431	.4167	.4409	.4424	.4733
10	.5784	.5596	.4973	.463	.4801	.5973	.463
11	.6379	.6001	.4801	.4254	.4641	.5847	
12	.583	.583	.5847	.4268	.4214	.5847	.5914
13	.5658	.5258	.543	.4428	.4534	.6268	.5914
14	.5658	.5792	.6036	.463	.4531	.5721	.5784
15	.5365	.6154	.5973	.5093	.4973	.567	.5316
16	.583	.6219	.567	.4321	.503	.5201	.4733
17	.5138	.5611	.4755	.4321	.5144	.5014	.3978
18	.5258	.5249	.4887	.4111	.4681	.431	.4287
19	.591	.4854	.5373	.4801	.5792	.6099	.4973
20	.6154	.5552	.5847	.5792	.5792	.6219	.6154
21	.5493	.5548	.5609	.5792	.6335	.5853	.6584
22	.6335	.7023	.5609	.6024	.6838	.591	.6379
23	.5609	.6335	.5658	.6036	.5731	.4801	.5721
24	.4973	.4807	.5201	.4807	.4801	.4694	.4641
Max	.6379	.7023	.6036	.6036	.6838	.6268	.6584
Min	.4424	.4054	.3814	.4111	.4214	.426	.3978
Avg	.5323	.5202	.5027	.4682	.4899	.5144	.5141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.2075	.2075	.2075	.1886	.1494
2	.1698	.1509	.2075	.2075	.1886	.1886	.1478
3	.1698	.1509	.1886	.1867	.1886	.1698	.1478
4	.1509	.1509	.1886	.1867	.1886	.1698	.168
5	.1509	.1698	.1698	.1698	.1698	.1663	.1698
6	.1698	.1698	.1448	.1663	.1698	.1629	.1886
7	.1886	.1698	.1494	.1698	.1886	.1867	.2263
8	.2075	.2075	.1867	.2075	.2075	.2075	.2263
9	.2075	.2829	.2263	.1886	.1886	.1886	.2452
10	.2075	.2452	.2263	.2263	.2263	.1886	.2263
11	.2263	.2263	.2075	.1698	.1886	.2075	.2263
12	.1509	.2075	.2263	.1698	.1698	.2263	.1698
13	.1509	.1509	.2263	.2263	.1886	.2263	.1698
14	.1509	.1698	.2452		.1886	.2263	.1698
15	.1698	.2263	.2075	.2075	.1886	.2075	.1509
16	.1886	.1886	.2263	.1886	.1698	.1698	.1509
17	.2075	.2263	.2263	.2075	.1698	.2075	.1698
18	.2641	.2263	.2452	.2075	.2452	.1698	.2075
19	.3361	.3018	.2829	.2829	.2829	.2452	.2452
20	.2829	.3206	.3206	.2829	.3206	.2452	.2452
21	.2829	.3395	.3018	.3206	.2452	.2641	.2452
22	.2829	.2829	.2829	.2641	.2263	.2829	.2452
23	.2641	.2829	.2452	.2263	.2263	.2263	.2263
24	.1698	.2263	.2263	.2263	.2075	.1886	.1698
Max	.3361	.3395	.3206	.3206	.3206	.2829	.2452
Min	.1509	.1509	.1448	.1663	.1698	.1629	.1478
Avg	.2050	.2185	.2236	.2129	.2059	.2046	.1953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 203 / 11 KV Timber Area

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3206	.3206	.3395	.3395	.3206	.2829
2	.3018	.2829	.3018	.3326	.3018	.3018	.2641
3	.3018	.2829	.3018	.3142	.3018	.3018	.2641
4	.3018	.2829	.2829	.3109	.3018	.2829	.2587
5	.3018	.3018	.2829	.2926	.3018	.2801	.2715
6	.3206	.3018	.2957	.2896	.3206	.2957	.2715
7	.3395	.3206	.2427	.3224	.3395	.3142	.3258
8	.3018	.3174	.2835	.2957	.3206	.3142	.3326
9	.3772	.3772	.3206	.3395	.3018	.3174	.3584
10	.3961	.3772	.3395	.3921	.3395	.3584	.3961
11	.415	.415	.3584	.3961	.3206	.3584	.3584
12	.3772	.3961	.3395	.3772	.2772	.3584	.3395
13	.3395	.3395	.3206	.3772	.2427	.3395	.3395
14	.2785	.3395	.3018	.3018	.2402	.3018	.2572
15	.3395	.3395	.3584	.3395		.3584	.3018
16	.3584	.3206	.3018	.3961		.3772	.3206
17	.3772	.3395	.3584	.3584		.415	.3395
18	.3961	.3584	.3584	.3772	.3961	.4338	.3961
19	.4854	.3961	.3772	.4527	.4715	.5175	.4527
20	.4481	.4715	.4338	.4715	.4338	.5041	.4715
21	.4108	.3772	.3921	.3961	.3961	.3772	.9431
22	.415	.3584	.415	.3961	.3772	.3772	.3772
23	.3772	.3395	.3772	.3772	.3584	.3206	.3395
24	.3206	.3395	.3206	.3395	.3395		.2987
Max	.4854	.4715	.4338	.4715	.4715	.5175	.9431
Min	.2785	.2829	.2427	.2896	.2402	.2801	.2572
Avg	.3584	.3457	.3327	.3577	.3344	.3533	.3567



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658		.5281	.6224	.3772	.4715
2		.547		.5281	.5658	.3772	.4715
3		.547		.5093	.5658	.3772	.4715
4		.5281		.5281	.547	.3772	.4715
5		.5281		.5658	.4715	.3772	.4715
6		.5281		.5658	.4715	.3772	.4715
7		.5281		.5281	.5281	.4715	.5658
8		.5658	.547	.5281	.5281	.547	.6036
9	.6161	.7545	.679	.6036	.4904	.6602	.6224
10	.7167	.7922	.811	.8488	.4715	.7733	.6036
11	.7922	.8488	.7922	.7545	.4527	.7545	.6036
12	.7167	.8676	.811	.7167	.415	.7545	.6602
13	.6413	.7733	.8299	.6979	.3961	.7733	.679
14	.7167	.811	.8488	.7545	.3772	.7733	.7167
15	.7922	.8676	.8299	.811	.3772	.7922	.7545
16	.8676	.8488	.811	.8488	.3772	.7922	.7545
17			.7733	.8299	.4527	.7922	.7545
18			.7545	.8299	.547	.7545	.7545
19			.7545	.8402	.5847	.811	.8215
20			.7733	.7842	.547	.8299	.7655
21			.7167	.7545	.5281	.7167	.7282
22	.7167		.6602	.6602	.4904	.6036	.6348
23	.6224		.6413	.5847	.415	.6036	.5415
24				.5281	.6413	.3584	.4715
Max	.8676	.8676	.8488	.8488	.6413	.8299	.8215
Min	.6161	.5281	.547	.5093	.3772	.3584	.4715
Avg	.7199	.6814	.7521	.6720	.4943	.6177	.6194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2136		1.2136	1.1763	1.1949	1.2323
2		1.1763		1.1949	1.1763	1.1949	1.2323
3		1.1763		1.1949	1.1763	1.1949	1.2323
4		1.1763		1.1949	1.1763	1.1949	1.2323
5		1.1576		1.1949	1.1763	1.1949	1.2323
6		1.1576		1.1949	1.1763	1.1949	1.2323
7		1.1576		1.1949	1.1016	1.1763	1.2136
8		1.2136	1.2637	1.1949	.1307	1.2136	1.1949
9	1.2323	1.251	1.251	1.2323	.1307	1.251	1.1763
10	1.2323	1.2883	1.2696	1.2696	.1494	1.2883	1.1763
11	1.2323	1.2323	1.2136	1.1949	.1494	1.2136	1.1576
12	1.2323	1.251	1.1949		.1494	1.1763	1.1389
13	1.2883	1.2323	1.2136	1.1949	.1494	1.1763	1.1576
14	1.2803	1.251	1.2136		.1494	1.1949	1.1576
15	1.307	1.2696	1.2323	1.2323	.1494	1.2136	1.2323
16	1.2696	1.1949	1.2696	1.2136	.0373	1.251	1.2323
17			1.2323	1.1949	.0377	1.2323	1.1949
18			1.1949	1.2136	.0377	1.2136	1.1763
19			1.1949	1.2449	1.0374	1.1949	1.2637
20			1.2136	1.2136	1.094	1.1763	1.251
21			1.1949	1.1949	1.1317	1.1763	1.2323
22	1.1949		1.1949	1.2136	1.1506	1.1763	1.2136
23	1.1949		1.1576	1.1949	1.1949	1.1576	1.1763
24				1.2323	1.1949	1.1694	1.2323
Max	1.307	1.2883	1.2696	1.2696	1.1949	1.2883	1.2637
Min	1.1949	1.1576	1.1576	1.1949	.0373	1.1576	1.1389
Avg	1.2464	1.2125	1.2191	1.2099	.6764	1.2009	1.2072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8676		.811	.6348	.6036	.679
2		.8299		.7922	.6348	.6036	.679
3		.7922		.7545	.6348	.6036	.6602
4		.7922		.7545	.6348	.6036	.6602
5		.7922		.7167	.6161	.6413	.6602
6		.7545		.6602	.6348	.6413	.6602
7		.7356		.7922	.5975	.7545	.679
8		.9997	.811	.8402	.5415	.6602	.679
9	.7545	1.0562	.9997	1.0269	.5415	.9431	.7356
10	.8676	1.1317	1.2637	1.1203	.5415	1.1883	.7922
11	.9431	1.2449	1.094	1.0829	.4108	1.0185	.8299
12	.9054	1.226	.9242		.3547	.8488	.8488
13	.811	1.0751	.9808	***	.3547	.811	.9242
14	.8299	1.1694	1.0562	.9335	.3547	.7922	1.0185
15	.8676	1.2637	.9431	.8962	.3547	.8299	1.094
16	.8488	1.0751	.8488	1.0082	.3547	.8676	1.094
17			.8488	1.0269	.3395	.8299	1.0751
18			.9054	1.0456	.3395	.8299	1.0751
19			.8676	.7922	.3395	.7545	.7545
20			.8676	.7095	.5281	.6224	.7167
21			.9431	.6535	.5281	.6224	.679
22	.9431		.9619	.6348	.5658	.6413	.6979
23	.9242		.7922	.6535	.5658	.6413	.7167
24				.8488	.6348	.6036	.679
Max	.9431	1.2637	1.2637	10.3997	.6348	1.1883	1.094
Min	.7545	.7356	.7922	.6348	.3395	.6036	.6602
Avg	.8695	.9879	.9443	1.2589	.5016	.7482	.7953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 207 / 11KV SPARE 1 FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132		.132	.1132	.1132	.132
2		.132		.1132	.1132	.1132	.1132
3		.132		.1132	.1132	.1132	.1132
4		.132		.1132	.1132	.1132	.1132
5		.132		.1132	.1132	.1132	.1132
6		.132		.1132	.1132	.1132	.1132
7		.128		.1132	.1132	.1132	.1132
8		.2743	.132	.1132	.1132	.1307	.1132
9	.1698	.2829	.2075	.1132	.1132	.1509	.3018
10	.2075	.2829	.3018	.1132	.1132	.1698	.3018
11	.2641	.132	.2075	.1886	.0943	.1698	.3018
12	.2263	.132	.132	.2263	.0943	.1509	.3206
13	.2075	.1509	.1509	.2829	.1132	.2075	.3395
14	.2075	.1509	.1509	.2829	.1132	.3395	.3395
15	.2075	.1509	.2075	.2829	.0943	.3206	.3772
16	.1509	.1509	.2829	.3018	.0754	.3206	.3395
17			.2263	.2829	.0754	.3206	.3395
18	.1509		.1698	.2829	.0754	.132	.3206
19	.1886		.1509	.2263	.0943	.1509	.3584
20	.1698		.132	.1509	.1132	.1509	.2075
21	.1698		.132	.1132	.1132	.132	.1132
22	.1509		.132	.132	.1132	.132	.132
23	.132		.132	.1132	.1132	.132	.1509
24				.132	.1132	.1132	.132
Max	.2641	.2829	.3018	.3018	.1132	.3395	.3772
Min	.132	.128	.132	.1132	.0754	.1132	.1132
Avg	.1859	.1642	.178	.1729	.1053	.1673	.2208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2949		.1886	.1132	.0943	.0943
2		.2949		.2075	.1132	.0943	.0943
3		.2949		.2263	.1132	.0943	.0943
4		.3277		.2263	.1132	.0943	.1132
5		.3605		.2452	.1132	.0943	.1132
6		.3768		.2452	.132	.0943	.1132
7		.3768		.3772	.1509	.0943	.1132
8		.426	.3612	.3772	.132	.0943	.0943
9	.0943	.4096	.3462	.426	.1509	.0943	.0943
10	.0943	.1147	.1132	.1132	.1509	.0943	.0943
11	.0943	.0983	.132	.3277	.5281	.2641	.1677
12	.0943	.0983	.1132	.4096	.5847	.5847	.1677
13	.1132	.0983	.0943	.4588	.5658	.5281	.1677
14	.1132	.0819	.0943	.426	.547	.4904	.1677
15	.1132	.0819	.0943	.4096	.3772	.4904	.1829
16	.0943	.1147	.0943	.3932	.3584	.5093	.2134
17	.1132		.1132	.3441	.2709	.4527	.2134
18	.132		.1132	.3113	.3052	.415	.2134
19	.1509		.132	.1132	.1132	.1509	.0754
20	.1698		.132	.132	.1132	.132	.0943
21	.1698		.132	.1509	.1132	.1132	.1132
22	.1509		.132	.1509	.1132	.1132	.1132
23	.132		.132	.132	.0943	.1132	.0943
24				.1698	.1132	.0943	.0943
Max	.1698	.426	.3612	.4588	.5847	.5847	.2134
Min	.0943	.0819	.0943	.1132	.0943	.0943	.0754
Avg	.1220	.2406	.1456	.2734	.2283	.2248	.1291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3765		2.3765		2.2634		
2	2.3388		2.3388		2.2257		
3	2.2634		2.3388		2.1879		
4	2.1879		2.3011		2.0748		
5	2.2257		2.3388		2.2257		
6			2.4143		2.1879		
7	2.1691	2.32			2.0182	1.5278	
8	2.1502	2.2068			1.5844	1.8484	
9	2.2634		2.4331				
10	2.3765					2.5086	2.7349
11	2.7161			2.6783		2.6972	2.6783
12	2.6595			2.9613		2.7915	2.9801
13	2.7538					2.6406	2.4897
14	2.4709			2.7161		2.5086	2.6029
15	2.0559					2.7349	2.8669
16	2.6029		2.6406	2.5652		2.6972	2.7349
17		2.7161		2.4897			
18	2.6783	2.6029		2.5086	1.2449		
19	2.5274	2.6406			1.2071		2.2068
20	2.4143			2.1125			2.3388
21				2.2634	1.4335		2.6029
22	2.4143			2.3954	1.358		2.452
23	2.4143			2.4709	1.3769		2.1879
24	2.4143		2.3954		2.32		
Max	2.7538	2.7161	2.6406	2.9613	2.32	2.7915	2.9801
Min	2.0559	2.2068	2.3011	2.1125	1.2071	1.5278	2.1879
Avg	2.4035	2.4973	2.3975	2.5161	1.8363	2.4394	2.5730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335		1.5278		1.5089		
2	1.3957		1.5278		1.4712		
3	1.3203		1.5089		1.3957		
4	1.2826		1.5278		1.3203		
5	1.3203		1.5466		1.4335		
6	1.3957		1.5844		1.3957		
7	1.358	1.6598			1.3769	1.4146	
8	1.5844	1.8296			1.358	1.4901	
9	1.6221		2.037				
10	1.8296					1.9427	2.5274
11	2.2634			2.452		2.2445	2.3577
12	2.1313			2.2634		2.1502	2.4709
13	2.037					2.0559	2.1502
14	2.0182			2.0559		2.0182	2.5274
15	2.1879					2.32	2.6595
16	2.0182		1.9427	2.1125		2.1313	2.5274
17		2.1879		1.9993			
18	2.2257	1.7918		1.8673	1.4146		
19	1.9993	1.8107			1.3769		2.0559
20	1.6975			1.6032			1.8861
21				1.4901	1.3014		1.773
22	1.6221			1.5278	1.3203		1.7541
23	1.7164			1.5655	1.3203		1.8484
24	1.4712		1.5466		1.5466		
Max	2.2634	2.1879	2.037	2.452	1.5466	2.32	2.6595
Min	1.2826	1.6598	1.5089	1.4901	1.3014	1.4146	1.7541
Avg	1.7241	1.8560	1.6388	1.8937	1.3957	1.9742	2.2115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712		1.4146		1.358		
2	1.4335		1.3957		1.3203		
3	1.358		1.3957		1.2826		
4	1.2449				1.2071		
5	1.3014		1.4335		1.2826		
6	1.358		1.4523		1.2071		
7	1.3203	1.4901			1.2449	1.3392	
8	1.358	1.4146			.8299	.8299	
9	1.4335		1.5655				
10	1.094					1.6032	1.6409
11	1.6787			1.6409		1.5844	1.6787
12	1.5278			.9808		1.5466	1.773
13	1.5466					1.4712	1.5466
14	1.5655			.9619		.9808	1.7164
15	.9808					1.5844	.8488
16	1.4901		1.4712	1.1883		1.5844	1.5466
17		1.4901		1.4335			
18	1.4712	1.5278		1.5466	.3584		
19	1.5278	1.4335			.3395		1.4712
20	1.4146			.7922			1.358
21				1.2449	1.1506		1.3957
22	.9242			1.358	1.226		1.4335
23	1.4901			1.3957	.3018		1.4523
24	.9431		1.4335		1.3769		
Max	1.6787	1.5278	1.5655	1.6409	1.3769	1.6032	1.773
Min	.9242	1.4146	1.3957	.7922	.3018	.8299	.8488
Avg	1.3606	1.4712	1.4453	1.2543	1.0347	1.3916	1.4885



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808		1.0185		1.0562		
2	.9431		.9997		1.0185		
3	.9054		.9997		.9808		
4	.8676		.9997		.9431		
5	.9054		1.0185		.9808		
6	.9431		1.0562		.9431		
7	1.1128	1.2637			.9242	1.2637	
8	.6979	1.1694			.8676	1.1128	
9	1.5089		1.4335				
10	1.6221					1.9616	1.7353
11	1.7541			1.773		1.7353	2.0182
12	1.7918			1.6975		1.6975	1.8673
13	1.7353					1.5844	1.4523
14	1.5844			1.6787		1.6221	1.7353
15	1.773					2.037	2.2822
16	1.6787		1.5655			2.1125	2.1502
17		1.5844		1.5844			
18	1.4901	1.4523		1.3957	.6979		
19	1.4335	1.2637			.8488		1.4901
20	1.1694			1.0185			1.358
21				1.094	.8676		1.1883
22	1.094			1.1317	1.0185		1.1317
23	1.0374			1.1128	.8865		.9808
24	.679		1.094		1.094		
Max	1.7918	1.5844	1.5655	1.773	1.094	2.1125	2.2822
Min	.679	1.1694	.9997	1.0185	.6979	1.1128	.9808
Avg	1.2594	1.3467	1.1317	1.3874	.9377	1.6808	1.6158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353				1.7353		
2	1.6975		1.5278		1.6975		
3	1.6598		1.5089		1.6598		
4	1.5844		1.5089		1.5844		
5	1.6598		1.5844		1.6787		
6	1.6221		1.773		1.6598		
7	1.0185	1.3203			.6036	.9431	
8	1.6032	1.7918			.6036	1.2071	
9	1.6221		1.6221				
10	1.7918					1.5844	1.7353
11	2.0936			2.0936		1.8484	1.905
12	1.4712			1.8861		1.773	1.4146
13	1.4523					1.6975	2.0182
14	1.4335			1.8296		1.9993	1.9993
15	2.2634					1.7541	1.9427
16	1.4712		1.2449	2.1313		1.7918	1.8861
17		1.6787		1.9239			
18	1.7918	1.1883		1.6975	.6602		
19	1.1883	1.1883			.6413		1.8484
20	1.9427			1.5278			1.6975
21				1.6787	.6036		1.8107
22	1.5844			1.3392	.6979		1.6975
23	1.5466			1.8673	.6036		1.6032
24	1.5089		1.5844		1.226		
Max	2.2634	1.7918	1.773	2.1313	1.7353	1.9993	2.0182
Min	1.0185	1.1883	1.2449	1.3392	.6036	.9431	1.4146
Avg	1.6247	1.4335	1.5443	1.7975	1.1182	1.6221	1.7965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694		1.094		1.2071		
2	1.1317		1.0751		1.1694		
3	1.094		1.0562		1.1317		
4	1.0562		1.0562		1.0562		
5	1.094		1.0374		1.094		
6	1.1317		1.0562		1.0185		
7	1.1128	1.2826			.8676	.9619	
8	1.1506	1.358			.8676	1.1317	
9	1.358		1.6787				
10	1.8484					1.6975	1.773
11	1.9805			1.8107		1.8107	1.9616
12				1.9239		1.773	1.7164
13	1.7353					1.6975	1.6409
14	1.8107			1.8673		1.8107	1.9616
15	1.7164					1.8296	2.1313
16	1.5844		1.6221	1.773		1.7541	1.9239
17		1.8107		1.6975			
18	1.5089	1.5844		1.3769	.8865		
19	1.5089	1.3769			.8299		1.3957
20	1.3203			1.1506			1.2449
21				1.0374	.9054		1.1883
22	1.2826			1.0751	.8865		1.2071
23	1.3203			1.1128	.9619		1.2826
24	1.0562		1.1317		1.1317		
Max	1.9805	1.8107	1.6787	1.9239	1.2071	1.8296	2.1313
Min	1.0562	1.2826	1.0374	1.0374	.8299	.9619	1.1883
Avg	1.3796	1.4825	1.2008	1.4825	1.001	1.6074	1.6189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221		1.1694		1.5466		
2	1.5844		1.1506		1.5089		
3	1.5089		1.1506		1.4712		
4	1.3957		1.1506		1.3957		
5	1.4712		1.1694		1.4335		
6	1.4335		1.2071		1.358		
7	1.0751	1.094			1.0751	.8676	
8	1.358	1.4146			.8676	.9808	
9	1.4712		1.4712				
10	1.6787					1.4712	1.9616
11	2.0182			1.9805		1.773	1.8673
12	2.0936			2.1502		1.7353	1.8484
13	2.037					1.6598	1.1883
14	1.9427			1.4712		1.6975	1.9239
15	1.9616					1.7164	1.7541
16	1.905		1.7541	1.8296		1.4335	1.6975
17		1.7164		1.6975			
18	1.5844	1.6221		1.4335	.7922		
19	1.6975	1.6975			.811		1.4523
20	1.5466			1.5655			1.3957
21				1.5089	.7356		1.4335
22	1.4712			1.5278	.7545		1.358
23	1.2826			1.5089	.7545		1.3392
24	1.6975		1.1883		1.3769		
Max	2.0936	1.7164	1.7541	2.1502	1.5466	1.773	1.9616
Min	1.0751	1.094	1.1506	1.4335	.7356	.8676	1.1883
Avg	1.6289	1.5089	1.2679	1.6674	1.1344	1.4817	1.6017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075		.1886		.2075		
2	.1886		.1886		.2075		
3	.1886		.1886		.1886		
4	.1698		.1698		.1886		
5	.1698		.1698		.1886		
6	.1886		.1886		.2075		
7	.1886	.2263			.2075	.1886	
8	.2075	.2452			.2452	.2263	
9	.2452		.2452				
10	.2641					.2452	.2829
11	.2829			.3395		.3206	.2829
12	.2829			.3018		.3018	.2452
13	.2641					.3018	.2829
14	.2641			.2829		.2641	.3206
15	.2641					.3018	.3395
16	.2263		.2452	.3584		.3206	.3018
17		.3018		.3395			
18	.2075	.2829		.2641	.2075		
19	.2075	.2641			.2075		.2263
20	.2263			.1886			.2263
21				.1886	.2075		.1886
22	.2075			.1886	.2075		
23	.2075			.1886	.2075		.1886
24	.2075		.1886		.1886		
Max	.2829	.3018	.2452	.3584	.2452	.3206	.3395
Min	.1698	.2263	.1698	.1886	.1886	.1886	.1886
Avg	.2212	.2641	.197	.2641	.2048	.2745	.2623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS  
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1698		.1698		
2	.1358		.1698				
3	.1811		.1698		.1698		
4	.1698		.1698		.1358		
5	.1358		.1698		.1698		
6	.1698		.2207		.1132		
7	.1132	.2094			.2263	.1754	
8	.2603	.1811			.2094	.1754	
9	.2037		.2263				
10	.1698					.1698	.198
11	.1754			.8092		.1811	.2207
12	.1811			.2377		.1698	.1415
13						1.2449	.4866
14	.1924			1.2505		.2603	1.0185
15	1.2788					.894	1.2845
16	.2546		1.0185			.5489	.945
17		.5772		1.2901			
18	.9959	.1528		1.2166	.1867		
19	1.2788	1.2675			.2263		.249
20	.2207			1.3184			.1698
21				.2263	.1867		.1132
22	.198			.1698	.1698		.1698
23	.2263			.198	.2263		.1132
24	.1471		.1867		.2263		
Max	1.2788	1.2675	1.0185	1.3184	.2263	1.2449	1.2845
Min	.1132	.1528	.1698	.1698	.1132	.1698	.1132
Avg	.3266	.4776	.2779	.7463	.1859	.4244	.4258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 407 / 33KV SUYESH DUCTILE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0412		.8827		1.2675		
2	.9393		.8714		1.1543		
3	.9846		.8488		1.0525		
4	.8148		.8601		.9336		
5	.9393		.9054		.9902		
6	1.0298		.9619		1.0355		
7	1.0242	.7356			1.6183	.249	
8	.2603	1.4599			.2263	.2263	
9	1.4938		.7582				
10	1.5844					.9846	.9167
11	.2603			.9619		.9733	1.7428
12	.2094			1.0185		.928	.9506
13	.215					1.0412	1.4712
14	.2263			.6337		.3395	1.3014
15	.9619					.9733	
16	.7356		.9223	.928		.928	.5828
17		.9506		.8035			
18	.43	.9393		.3395	.1867		
19	.9506	1.0298			.1698		.3961
20	.2263			.8601			1.4938
21				1.0977	.1867		1.6975
22	.464			1.2505	.2263		1.6183
23	.2263	1.6749		.4527	.1867		1.7315
24	.9054		.9054		.5489		
Max	1.5844	1.6749	.9619	1.2505	1.6183	1.0412	1.7428
Min	.2094	.7356	.7582	.3395	.1698	.2263	.3961
Avg	.7238	1.1317	.8796	.8346	.6988	.7381	1.2639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 201 / 11 KV Mahavir  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 202 / DATTANAND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.1334
Max	.1334
Min	.1334
Avg	.1334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 204 / 11 KV Galaxy

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 205 / 11 KV Bamnoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0572
Max	.0572
Min	.0572
Avg	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.4001
Max	.4001
Min	.4001
Avg	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8619	.9145	1.0029	.9922	.128	.1467	.8139
2	.0083	.8596	.9313	.9015	.1467	.1467	.7888
3	.7449	.8596	.9412	.9015	.1677	.1509	.7888
4	.7449	.815		.9214	.2012	.1677	.7975
5	.7362	.815	.9922	.8596	.2138	.2667	.8669
6	.7407	.7796	.7537	.8596	.2221	.4999	.9362
7	.7042	.815	.7682	.8063	.1718	.663	.9496
8	.3231	.9922	.9156	.8954	.0793	.663	1.0631
9	1.0402	1.0166	1.086	1.3535	.0644		1.2936
10	1.2851	1.4266	1.307	.9313	.1227	1.4937	
11	1.2752	1.5893	1.423	.7773	.1536	1.5466	1.5364
12	1.2094		.5304	.7432	.1189	1.6617	1.4632
13	1.1946	1.3676	1.1888	.6622	.0743	1.5364	1.531
14	1.2403	1.1946	.6588		.0446	1.6095	1.5684
15	1.2851	1.5684	1.4146	.815	.0594	1.1827	1.6263
16	1.134	1.5708	.8871	.7802	.0446	1.3169	1.6598
17	1.1584	1.3253	1.3169	.5992		1.6078	1.3817
18	1.1706	1.358	1.4784				1.4377
19	1.0985	1.3443	1.3169				1.2449
20	1.0631	1.0974	1.134				1.0208
21	.9156	1.0242	1.134				1.0136
22	.8916	1.0517	.5068				.9511
23	1.0349	.9816	1.0517				.9313
24	.8817	.9511	.9922	.9816	.1097	.0793	.8048
Max	1.2851	1.5893	1.4784	1.3535	.2221	1.6617	1.6598
Min	.0083	.7796	.5068	.5992	.0446	.0793	.7888
Avg	.9476	1.1182	1.0318	.8695	.1249	.8670	1.1508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.2641	.3567	.3567	.3384	.1635	.4344
2	.2789	.2362	.3201	.3517	.2515	.1593	.3948
3	.2606	.2324	.3155	.3109	.2347	.1593	.3616
4	.2515	.2599	.3109	.3064	.218	.1551	.3567
5	.2599	.2557	.3319	.3319	.2096	.1509	.3467
6	.2606	.2743	.3254	.317	.2195	.16	.3944
7	.2423	.2652	.4641	.3121	.2606	.1646	.2923
8	.3147	.3319	.3658	.3467	.2103	.2286	.3094
9	.6859	.583	.6935	.6878	.1833	.7011	.724
10	.9709	.815	.8238	.8596	.1555	.8413	.9335
11	1.094	.9522	.7922	1.0082	.1844	.9709	1.1694
12	1.1694		.961	.8686	.1509	1.1883	1.0562
13	.823	.759	.8589	.7377	.1417	.9114	.7712
14	.924	.9522	.9335		.16	1.2071	1.0562
15	.924	.961	.9997	1.0562	.1524	1.0269	1.0185
16	.9709	.8962	.9335	.8962	.1593	1.094	1.1317
17	.9335	.7712	.8962	.8779		.5544	.9335
18	.7964	.7087	.8326				.8326
19	.724	.6783	.5967				.6443
20		.5967	.4694				.5121
21	.3521	.5898	.3628				.4199
22	.3521	.423	.3064				.4548
23	.3319	.423	.3418				.3338
24	.2881	.2683	.3894	.3715	.3475	.1341	.4401
Max	1.1694	.961	.9997	1.0562	.3475	1.2071	1.1694
Min	.2423	.2324	.3064	.3064	.1417	.1341	.2923
Avg	.5868	.5434	.5826	.5881	.2104	.5539	.6384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.037	.037	.037	.037	.037	.037
2	.037	.037	.037	.037	.037	.037	.037
3	.037	.037	.037	.037	.037	.037	.037
4	.037	.037	.037	.037	.037	.037	.037
5	.037	.037	.037	.037	.037	.037	.037
6	.037	.037	.037	.037	.037	.037	.037
7	.037	.037	.037	.037	.037	.0554	.037
8	.037	.037	.037	.037	.037	.037	.037
9	.037	.037	.037	.037	.037	.037	.037
10	.037	.037	.037	.037	.037	.037	.037
11	.037	.037	.037	.037	.037	.037	.037
12	.037		.037	.037	.037	.037	.037
13	.037	.037	.037	.037	.037	.037	.037
14	.037	.037	.037		.037	.037	.037
15	.037	.037	.037	.037	.037	.037	.037
16	.037	.037	.037	.037	.037	.037	.037
17	.037	.0373	.037	.037		.037	.037
18	.037	.037	.037				.037
19	.037	.037	.037				.037
20	.037	.037	.037				.037
21	.037	.037	.037				.037
22	.037	.037	.037				.037
23	.037	.037	.037				.037
24	.037	.037	.037	.037	.037	.037	.037
Max	.037	.0373	.037	.037	.037	.0554	.037
Min	.037	.037	.037	.037	.037	.037	.037
Avg	.037	.0370	.037	.037	.037	.0380	.037



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0095	.0133	.0152	.0095	.0191	.0076	.0091
2	.1524	.0171	.0191	.0152	.0122	.0152	.0122
3	.0114	.0229	.0191	.1715	.0122	.0152	.0152
4	.0171	.0267	.0229	.0229	.0091	.0191	.0152
5	.0229	.0324	.0305	.0229	.0091	.0229	.0213
6	.0095	.0095	.0533	.0095	.0091	.0286	.0259
7	.0057	.0057	.0152	.0038	.0091	.0343	.0442
8	.0057	.0057	.0038	.0381	.0091	.2058	.1829
9	.0495	.0057	.0038	.0038	.0038	1.5089	1.5089
10	.0533	.0038	.0076	.0038	.0438	.3205	2.1437
11	.3384	.0076	.0154	.0229	.0495	1.1765	1.1203
12	1.2048		.12	.0076	.0046	1.2934	.3338
13	1.3969	.0057	.0057	.0076	.0069	1.386	1.4335
14	.2561	.0114	.0057		.0046	1.4563	1.7558
15	1.363	.0057	.0069	.012	.0069	.9105	1.4335
16	.4525	.0114	.0154	.024	.0069	.9412	.3048
17	1.9753	.1829	.0107	.0189		.7125	.9335
18	1.8671	.0114	.0114				1.1883
19	.0095	.0114	.0038				.0057
20	.0057	.0152	.0095				.0137
21	.0057	.0152	.0076				.0274
22	.0057	.0152	.0114				.0206
23	.0095	.0152	.0095				.0114
24	.0057	.0095		.0076	.0191	.0076	.0057
Max	1.9753	.1829	.12	.1715	.0495	1.5089	2.1437
Min	.0057	.0038	.0038	.0038	.0038	.0076	.0057
Avg	.3847	.0200	.0184	.0236	.0138	.5590	.5236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641	1.182	1.134	1.3535	1.1403	1.2012	1.1088
2	1.1403	1.1584	1.0745	1.2894	1.1283	1.1706	1.1088
3	1.1403	1.1462	1.0745	1.267	1.1403	1.0974	1.0719
4	1.1403	1.1584	1.086	1.2357	1.1523	1.0974	1.0719
5	1.267	1.1584	1.0745	1.3535	1.1403	1.2437	1.2012
6	1.379	1.3253	1.1517	1.5565	1.3756	1.3535	1.2936
7	1.4506	1.3253	1.2489	1.6278	1.4661	1.4083	1.4784
8	1.5402	1.4685	1.4299	1.7002	1.4661	1.4969	1.5154
9	1.382	1.4864	1.5565	1.6095	1.448	1.4266	1.3306
10	1.4506	1.4998	1.6461	1.7187	1.4632	1.4998	1.2536
11	1.4449	1.5181	1.6632	1.5364	1.3756	1.5364	1.0808
12	1.3575	1.4266	1.6804	1.5364	1.2536	1.448	1.1163
13	1.3032	1.2752	1.5181	1.3352	1.2437	1.4118	1.1096
14	1.262	1.2803	1.448	1.3352	1.1765	1.0608	1.0923
15	1.2986	1.3169	1.5023	1.1643	.6219	1.1827	.9882
16	1.3676	1.3491	1.5565	1.2567	.7023	1.2071	1.0166
17	1.386	1.4415	1.6278	1.4266	1.3535	1.3121	.9816
18	1.3756	1.3213	1.7737	1.3937	1.3491	1.2803	1.0867
19	1.5939	1.7194	1.7909	1.6832	1.6448	1.5893	1.5775
20	1.7737	1.6651	1.9728	1.8461	1.7741	1.7741	1.6476
21	1.7551	1.7193	1.8473	1.7551	1.7556	1.7187	1.6118
22	1.6651	1.4118	1.7372	1.5746	1.5524	1.5154	1.4864
23	1.3969	1.3756	1.5729	1.3575	1.386	1.2936	1.2178
24	1.1744	1.2489	1.2178	1.4045	1.1946	1.2254	1.1458
Max	1.7737	1.7194	1.9728	1.8461	1.7741	1.7741	1.6476
Min	1.1403	1.1462	1.0745	1.1643	.6219	1.0608	.9816
Avg	1.3837	1.3741	1.4744	1.4716	1.3043	1.3563	1.2331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1433	.1448	.1646	.1433	.1478	.1629
2	.132	.1463	.1463	.1612	.1448	.1294	.1463
3	.132	.1448	.1448	.1629	.1433	.128	.1478
4	.132	.1448	.1463	.1612	.1448	.1463	.1663
5	.1509	.1448	.1463	.1829	.1629	.1463	.1663
6	.1698	.2172	.1448	.2353	.1791	.1646	.1478
7	.2263	.2172	.1629	.2012	.1829	.1829	.1848
8	.2054	.2195	.1448	.2218	.181	.2561	.2033
9	.2427	.2896	.2172	.2926	.2195	.2743	.2957
10	.3582	.3109	.2378	.3326	.2378	.2378	.2772
11	.2715	.2926	.2402	.2957	.2353	.2378	
12	.2534	.2743	.2054	.2402	.2353	.2353	.2772
13	.2715	.1829	.1646	.2012	.1829	.2172	.2772
14	.2378	.2012	.1991	.2012	.181	.1463	.2075
15	.1991	.2218	.181	.1646	.1646	.1663	.1698
16	.1991	.2218	.1448	.1646	.1478	.1646	.1509
17	.1663	.2012	.1463	.2172	.1646	.1663	.1698
18	.1791	.1612	.1448	.1612	.1478	.128	.132
19	.1991	.181	.1433	.181	.1663	.1663	.1448
20	.181	.1629	.181	.181	.1478	.1663	.1463
21	.181	.1612	.1829	.1829	.1663	.1478	.1448
22	.2172	.181	.1848	.1991	.1663	.1848	.1448
23	.1629		.1829	.181	.1848	.1663	.1646
24	.1509	.1448	.1448	.1663	.1612	.1478	.1663
Max	.3582	.3109	.2402	.3326	.2378	.2743	.2957
Min	.132	.1433	.1433	.1612	.1433	.128	.132
Avg	.1988	.1985	.1701	.2022	.1746	.1773	.1824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6767	.6485	.6878	.6401	.7023	.6838
2	.6348	.6468	.6268	.6805	.5973	.7023	.6653
3	.6348	.6219	.6089	.6653	.5973	.7023	.6722
4	.6348	.6283	.6154	.6584	.5973	.6838	.6535
5	.6348	.6219	.6154	.6468	.6584	.7282	.7023
6	.6722	.6401	.6219	.6468	.7133	.7468	.7282
7	.7392	.7577	.6468	.695	.6878	.7392	.7392
8	.7023	.7133	.6401	.7207	.7499	.7947	.7762
9	.8131	.7682	.7577		.823	.8131	.8029
10	.8488	.7842	.7421	.924	.8048	.8316	.8316
11	.8865	.8775	.6984	.8686	.8131	.8686	.8596
12	.9149	.8962	.6447	.8686	.823	.8413	.8589
13	.9149	.8775	.6401	.8871	.7701	.8402	.8686
14	.8402	.8402	.6089	.9055	.7316	.8316	.8131
15	.8589	.8029	.6584	.8131	.7522	.8048	.7207
16	.8215	.6036	.695	.7947	.8131	.6653	.7392
17	.8048	.8775	.6838	.8402	.1646	.7865	.6653
18	.7865	.7964	.7392	.7682	.8871	.7947	.7947
19	1.086	1.0059	.8048	1.0498	1.0164	1.0349	.197
20	1.0679	1.0608	.9774	1.0317	.9979	1.0719	1.0242
21	1.0242	.9774	1.0534	.9877	.9795	.9795	1.0164
22	.9877	.9694	.9145	.9328	.924	.9055	.961
23	.8779	.8413	.8326	.8048	.7947	.7947	.7762
24	.7095	.7682	.7762	.7316	.7316	.7282	.6838
Max	1.086	1.0608	1.0534	1.0498	1.0164	1.0719	1.0242
Min	.6348	.6036	.6089	.6468	.1646	.6653	.197
Avg	.8154	.7939	.7188	.8091	.7528	.808	.7597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5611	.5434	.6335	.543	.5975	.5601
2	.5601	.543	.5552	.6089	.543	.5544	.5359
3	.5601	.5487	.5373	.6099	.543	.5228	.5175
4	.5601	.5487	.543	.6036	.543	.5041	.5175
5	.5975	.5792	.543	.6099	.5611	.5041	.5601
6	.6348	.6219	.5487	.6838	.5792	.5601	.5914
7	.6283	.6036	.6468	.6219	.6268	.6468	.6161
8	.6099	.567	.6219	.6653	.5973	.6283	.6348
9	.6224	.5611	.6283		.5853	.6099	.5601
10	.6224	.5853	.5792	.5975	.5487	.5729	.5304
11	.5304	.5601	.5194	.5359	.5544	.5175	.4887
12	.5415	.5359	.5552	.499	.439	.4755	.4163
13	.5228	.5415	.5487	.4805	.4119	.4854	
14	.5544	.5175	.5552	.5121	.4755	.499	
15	.5041	.5359	.567	.439	.4477	.4755	.631
16	.5228	.4108	.567	.4294	.4435	.4251	.4733
17	.4938	.4668	.5544	.4435	.439	.4572	.4908
18	.4887	.5304	.6468	.5068	.5175	.5729	.5609
19	.7421	.7421	.6401	.724		.7762	.7712
20	.8596	.8688	.8326	.8145		.8316	.8059
21	.8326	.7865	.8686	.7701	.8871	.8131	.7964
22	.8326	.7964	.823	.7421	.8316	.7392	.724
23	.7059	.7316	.7602	.6697	.6838	.6468	.6219
24	.6099	.6219	.6283	.6584	.5973	.6099	.5544
Max	.8596	.8688	.8686	.8145	.8871	.8316	.8059
Min	.4887	.4108	.5194	.4294	.4119	.4251	.4163
Avg	.6139	.5986	.6172	.6026	.5636	.5844	.5890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(  
Crossove Feeder KV- 33 /  
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7125	6.2186	6.2157	7.8464	6.046	5.487	4.784
2	4.6639	6.3152	6.17	7.5755	5.4698	6.0357	5.3155
3	4.6639	6.17	5.7613	7.6017	5.407	5.3155	5.5281
4	4.8663	6.17	6.1214	7.5217	4.3747	6.877	6.1128
5	5.407	6.7833	6.5867	8.2305		7.1994	6.857
6	5.9477	7.3097	8.5528	10.4253	6.2672	7.0696	7.2822
7	7.6189	11.5627	2.6235	2.8532	2.3148	2.392	2.4451
8	8.4534	9.1427	6.7341	10.2012	6.0728	6.9102	6.4615
9	8.8477	1.749	8.7986	13.498	7.7172	8.7174	7.2748
10	9.8337	8.8769	10.9191	13.6609	9.6022	9.9932	5.7019
11	10.7453	7.1228	12.2525	9.3553	8.6877	10.8436	5.7185
12	9.249	8.239	11.1466	13.4854	6.6621	10.9139	5.407
13	9.5679	10.9499	11.9067	10.0995	6.2552	10.4796	5.6527
14	9.6742	11.322	12.2171	12.2171	6.1357	9.8766	5.4561
15	9.1427	8.4517	12.2171	6.5381	6.1454	10.0349	8.3042
16	9.7805	11.1626	2.552	1.9456	1.5524	1.9204	1.4198
17	2.2325	2.0805	2.6886	1.9879	1.6461	1.885	1.4255
18	2.4691	2.3663	2.7692	2.1091	2.9767	2.0199	1.917
19	2.6749	2.5206	2.8475	2.4177	2.1794	2.3388	2.2119
20	2.9321	2.8807	3.1493	2.7778	2.5514	2.5514	2.2611
21	2.6749	2.5943	8.6146	6.6358	6.1128	5.9002	2.1382
22	2.4177	2.3908	9.2587	6.8324	5.7407	5.6344	4.3256
23	2.9835	3.5391	8.6146	6.4392	5.2092	5.0497	1.6221
24	4.7125	6.39	6.1443	8.1499	6.1443	4.8903	4.7308
Max	10.7453	11.5627	12.2525	13.6609	9.6022	10.9139	8.3042
Min	2.2325	1.749	2.552	1.9456	1.5524	1.885	1.4198
Avg	6.0947	6.3462	7.2859	7.5169	5.2726	6.2640	4.5981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)
12		.1715
24	.0382	
Max	.0382	.1715
Min	.0382	.1715
Avg	.0382	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 202 / 11 KV GMIE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 204 / 11KV WATER FILTER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 206 / 11KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.1313	1.5844		2.1338		1.8296
2	2.0957	1.6221	1.6221		2.2862		1.9239
3	2.0957	1.9616	1.4712		2.2068		2.21
4	1.9052	2.0748	1.3957		1.8484		2.0559
5	1.9052	2.037	1.6221		1.9616		2.1338
6	1.6975	2.2672	1.5242		2.0957		2.2481
7	1.5089	1.905	1.4712		2.1148		1.6409
8	1.4335	1.5123	.9149		2.1148		1.7164
9	1.5623	2.2481	.9877	1.2826	.3467		1.0479
10	1.6409	1.7528	2.1313	1.773	.2829	1.4146	2.0182
11	1.5089	1.6221	2.2257	1.7164	.2827	2.0182	2.32
12	2.32	1.1317	1.9805	2.2068	.2652	2.1148	1.5278
13	2.1313	1.4712	.8871	1.7164	.213	1.8861	1.4712
14	1.5278	2.0767	1.6956	.4715		1.7353	1.0374
15	1.905	1.1317		1.6598		2.3577	1.5844
16	2.2634	1.3336	2.0957	1.7337		2.1691	
17	2.2445	1.7147	2.1313	2.1313		2.2481	
18	1.5844	1.1317		3.0556		1.1317	
19	2.0005	2.3434		2.2634		1.6787	
20	2.1125	2.1313		2.1338		2.1338	
21	2.21	1.094		2.2481		.9808	
22	2.2291	2.21		2.1719		2.21	
23	1.9814	1.5844		2.3243		1.8296	
24	2.1719	1.9993	1.6409		2.2481		1.7337
Max	2.32	2.3434	2.2257	3.0556	2.2862	2.3577	2.32
Min	1.4335	1.094	.8871	.4715	.213	.9808	1.0374
Avg	1.9253	1.7703	1.6107	1.9259	1.4572	1.8506	1.7812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.226	1.3392		1.3203		1.3392
2	.9709	1.0562	1.3957		1.226		1.3957
3	.9709	1.3203	1.5278		1.358		1.2826
4	.9425	1.3392	1.3769		1.3203		1.358
5	.9425	1.0456	1.3203		1.2826		1.3203
6	.9709	.3191	.961		1.4901		1.4146
7	1.0082	.3549	.9522		.9522		.788
8	.9709	.591	1.2826		.9425		.7522
9	1.2193	.6908	1.1128	1.5278	1.4861		.8383
10	.7655	.8048	1.2449	1.7164	1.2637	2.0559	1.6385
11	.8865	.7762	1.8484	1.4146		1.8107	1.9616
12	1.2384	.8215		1.6032		1.5089	1.3769
13	1.1506	.6584	.5093	1.358		1.3527	1.6385
14	1.358	.8676	.6036	1.6787		1.6032	1.8107
15	1.8107	.8215	.5658	2.0748		1.8296	1.7353
16	1.1694	.7316	.8865	1.2449		1.8107	
17	1.9239	.5959	1.094	1.9616		1.9427	
18	1.6194	.431		.9709		1.6004	
19	.9055	.4218		1.6004		1.5844	
20	1.5844	.9522		1.0562		1.5089	
21	1.5089	1.6004		1.0374		1.1128	
22	1.3957	1.6004		.4687		1.0642	
23	.7964	1.5655		1.0082		1.0269	
24	1.0082	1.094	1.5655		1.2449		1.1016
Max	1.9239	1.6004	1.8484	2.0748	1.4901	2.0559	1.9616
Min	.7655	.3191	.5093	.4687	.9425	1.0269	.7522
Avg	1.1719	.9036	1.1521	1.3815	1.2624	1.558	1.3595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045	.2896	.2835		.3189		.3696
2	.3258	.3142	.3292		.3224		.3361
3	.3258	.3361	.3109		.2947		.3547
4	.3403	.3547	.3109		.298		.3511
5	.3403	.3326	.2896		.3403		.3326
6	.3224	.3174	.2715		.3258		.3584
7	.2896	.2896	.3052		.3326		.2957
8	.3292	.4904	.2713		.1006		.2957
9	.6097	.5847	.4904	.6287	.0857		.5281
10	.6979	.6859	.6036	.7356	.0892	.6283	.679
11	.6602	.6478	.679	.6602	.1029	.6224	.743
12	.6859	.6097	.6036	.6413	.0772	.6036	.547
13	.547	.3982	.3584	.5847	.0857	.5847	.5525
14	.7356	.6668	.679	.7356		.7356	.811
15	.7545	.6668	.679	.6602		.743	.7356
16	.6602	.6097	.6413	.6413		.6979	
17	.6602	.5716	.6224	.6224		.6413	
18	.547	.5847		.5853		.6478	
19	.4668	.4904		.3961		.5525	
20	.3012	.2896		.2652		.3961	
21	.2481	.2713		.3206		.3018	
22	.1932	.1932		.2641		.2801	
23	.3734	.3189		.2896		.4108	
24	.3045		.3109		.333		.3921
Max	.7545	.6859	.679	.7356	.3403	.743	.811
Min	.1932	.1932	.2713	.2641	.0772	.2801	.2957
Avg	.4593	.4484	.4467	.5354	.2219	.5604	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4143		2.452		1.7924		1.5893
2	2.2862		2.4331		2.0559		1.6644
3	1.0288		1.8111		1.6617		1.6448
4	.8573		2.3388		2.0538		1.7002
5			2.1879		1.9616		1.6263
6	2.0957		2.3525		2.2405		1.8111
7	2.553	2.0883	1.2717		.651		1.4415
8	2.6673	2.3712	2.6595		.535		1.2986
9	2.2862	2.2445	1.9231	1.3957	.4733		1.8861
10	2.5274	2.3243	1.8484	1.358	.4321	2.6972	2.0559
11	3.1876	2.6673	3.4294	1.5089		2.7538	3.0933
12	2.2445	3.0102	1.5278	1.4712		2.037	2.4143
13	1.9427	2.7726	1.283	1.773			1.1393
14	2.452	1.8858	1.3889	2.7349		1.0974	2.3011
15	3.1876	1.4661	2.5149	2.8858			1.5089
16	2.584	1.6598	2.6406	2.999		1.7541	
17	2.1691	1.9052	2.8481	2.9801		.0716	
18	2.7625	1.8656		1.5912		.5104	
19	1.9791	2.4143		2.8104		1.2357	
20	2.4897	2.2822		2.4897		2.4897	
21	1.5364	2.2218		2.0559		1.6461	
22	2.7915	1.8858		1.4864		1.6095	
23	2.2068	2.6595		1.1269		1.5729	
24	2.4143	1.0562	2.5463		1.7187		1.6448
Max	3.1876	3.0102	3.4294	2.999	2.2405	2.7538	3.0933
Min	.8573	1.0562	1.2717	1.1269	.4321	.0716	1.1393
Avg	2.2897	2.1545	2.1921	2.0445	1.416	1.6230	1.8012



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8063	1.5844		.9979		.9511
2	.9145	.9328	1.6409		.8962		.9979
3	.9145	.9412	1.4712		.9425		.8869
4	.9231	.8596	1.5278		.8326		1.0349
5	.9231	.8962	1.5655		.8775		.9313
6	.9511	.9979	1.6194		.8589		1.0317
7	.9511	.9425	.8316		.7209		.964
8	.924	1.2637	.7343		.2915		.9214
9	1.1694	1.3203	1.226	1.4712	.176		1.3957
10	1.2637	1.7528	1.5813	1.9427	.1602	1.226	1.8484
11	1.8861	1.9052	1.5466	1.9616	.1492	1.2574	1.9993
12	1.7147	2.1879	1.4712	1.8484	.0343	1.4523	1.9993
13	1.4901	1.9427	1.4146	1.6975	.1547	1.8861	1.6766
14	1.6975	1.9616	1.226	1.7541		2.0195	1.3203
15	2.1313	1.905	1.358	2.0182		1.4335	1.6032
16	1.9993	1.829	1.2574	1.5655		1.8484	
17	2.1148	1.7528	1.358	2.0748		1.773	
18	1.8296	1.7541		1.4861		1.1203	
19	1.358	2.0748		1.4712		1.3203	
20	1.2826	2.0195		1.3392		1.1389	
21	1.358	1.8671		1.4146		.9694	
22	1.1389	1.829		1.1576		1.1827	
23	1.0534	1.4901		1.1088		.8682	
24	.8688	.8596	1.6956		1.0903		.9134
Max	2.1313	2.1879	1.6956	2.0748	1.0903	2.0195	1.9993
Min	.8688	.8063	.7343	1.1088	.0343	.8682	.8869
Avg	1.3219	1.5038	1.3950	1.6208	.5845	1.3926	1.2797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.6241	.7733		1.3535		.4668
2	.8383	.7316	.7468		1.4815		.4066
3	.8383	.7522	.6722		1.3969		.4435
4	.7922	.5434	.7655		1.1584		.4805
5	.7922	.6556	.7842		1.2894		.4207
6	.7468	.4854	.7392		1.2971		.4805
7	.724	.3018	.7023		.8128		.4706
8	.6219	.8131	.6401		.6908		.4031
9	.7023	.7947	.3601	.8676	.8817		.6224
10		.5609	.9242	.8676	.1463	.3961	.9808
11	.4527	.8048	.9242	.8865	.1783	.5281	.9808
12	.5914	.8962	.8299	.7167	.1115	.4715	1.0751
13	.547	.4578	.8676	.7545	.2204	.5906	1.0751
14	.5281	.5487	.6767	.7577		.6036	.8402
15	.5281	.9431	.7545	.8299		.6979	.7922
16	.7922	.9431	.7733	.5121		.6224	
17	.5658	.9907	.3772	.5658		.5658	
18	.3395	.7655		.8299		.6478	
19	.3361	.6767		.6838		.5093	
20	.2976	.4557		.3688		.3881	
21	.3222	.8775		.7023		.3641	
22	.8299	.8215		1.6817		.4527	
23	.4477	.8488		1.3717		.4715	
24	.8764	.7265	.8488		1.5565		.4527
Max	.8764	.9907	.9242	1.6817	1.5565	.6979	1.0751
Min	.2976	.3018	.3601	.3688	.1115	.3641	.4031
Avg	.6255	.7091	.7311	.8264	.8982	.5221	.6495

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	04-JUL-18
HR	Load (MW)
18	.5104
Max	.5104
Min	.5104
Avg	.5104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.8316	.6379		1.1506		.8501
2	1.0562	.6767	.7343		1.0456		.6984
3	1.0562	.7343	.6836		.8871		.7186
4	.9709	.6089	.7522		.7499		.6241
5	.9709	.6485	.7186		.8316		.5895
6	.9145	.6588	.7712		.5053		.4999
7	.6661	.7362	.6299		1.0903		.5121
8	.7087	.6516	.7122		.9774		.463
9	.961	.8048	.8871	.8299	.9671		.7421
10	1.4901	1.0082	1.2955	1.5089	.112	.7762	.9149
11	1.3014	1.3336	1.6975	1.6221	.3887	1.2449	.9808
12	1.0751	1.6766	1.2071	.7545	.3944	1.1317	1.1317
13	1.1128	1.0456	1.6221	.9431	.4058	1.2449	1.5089
14	.8299	1.094	1.5844	1.1128		1.3203	1.5466
15	1.1694	1.6975	1.1128	1.1694		.9808	.9431
16	1.0562	1.5242	1.3203	1.1317		1.1128	
17	1.0562	1.6385	1.4335	1.094		1.2449	
18	1.3957	.9335		1.2449		1.3203	
19	1.5844	.7842		1.2637		1.1694	
20	1.358	1.358		1.2449		1.1203	
21	.5426	.6104		.8779		.5487	
22	.7499	1.0642		1.0751		.7682	
23	1.3392	1.4335		1.3392		1.0082	
24	1.094	1.3957	.5609		1.3769		.9709
Max	1.5844	1.6975	1.6975	1.6221	1.3769	1.3203	1.5466
Min	.5426	.6089	.5609	.7545	.112	.5487	.463
Avg	1.0647	1.0395	1.0201	1.1475	.7773	1.0708	.8559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.8858	3.0556		2.999		3.5082
2	2.4897	.2366	2.7726		2.8858		3.0556
3	2.4897	2.6029	3.1121		3.0556		2.7161
4	2.8292	2.0725	3.4517		3.3951		3.4517
5	2.8292	1.8107	3.1121		3.1687		3.2253
6	3.1687	3.5648	3.0556		3.5082		3.0556
7	3.5082	.2241	2.7161		2.7161		3.5082
8	3.1687	.2058	2.0576		.2972		1.4712
9	3.1121	.1715	3.6214	3.4517	.1183		3.4517
10	3.2253	.1315	2.9424	1.8107	.1257	2.32	2.8858
11	1.8673	.1372	1.7541	2.6029	.132	3.5082	2.7726
12	.3704	.1315	1.8673	1.7541	.0617	2.999	3.4517
13	3.1687	.1543	2.3765	3.3385	.096	3.1687	1.7541
14	.6762		1.5278	2.6595		2.8858	1.7541
15	3.678	3.1687	1.6409	2.7161			1.5278
16	2.1502	2.9424	3.0556	1.9805		2.7161	
17	2.1502	1.9239	2.6029	1.8673		3.2819	
18	1.829	2.6595		3.1121		2.9424	
19	2.8858	1.9433		2.6029		2.999	
20	2.7161	3.5082		2.0005		1.4146	
21	3.0556	2.0005		2.7726		1.4712	
22	3.1121	1.4861		3.5082		3.0556	
23	2.8858	3.1121		2.8858		3.4517	
24	1.7147	2.999	2.999		1.9433		3.3385
Max	3.678	3.5648	3.6214	3.5082	3.5082	3.5082	3.5082
Min	.3704	.1315	1.5278	1.7541	.0617	1.4146	1.4712
Avg	2.5332	1.7423	2.6512	2.6042	1.7502	2.7857	2.8080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 201 / 11 KV Shivaji Road Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)
12		.1715
24	.1715	
Max	.1715	.1715
Min	.1715	.1715
Avg	.1715	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 203 / 11 KV Darga Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 204 / 11 KV Laxmi Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 205 / 11 KV Shivneri Chowk

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7922	.7392	.7545	.811	.7167	.7545
2		.7922	.7207	.7733	.811	.7282	.7545
3		.7922	.7468	.7545	.811	.7545	.7545
4		.811	.7023	.6668	.811	.7655	.7468
5		.811	.7282	.6097	.811	.7392	.7545
6		.811	.7392	.6668	.811	.7842	.7545
7		.7922	.7762	.7356	.811	.7733	.7545
8		.811	.811	.7356	.811	.7842	.7545
9	.6287	.8029	.7842	.7356	.6602	.6602	.5975
10	.7356	.7468	.8299	.6224	.7545	.6478	.6036
11	.811	.7468	.8029	.7922	.7356	.8326	.7842
12	.7922	.7316	.7762	.7655	.7545	.7973	.7922
13	.7733	.7207	.811	.7733	.5093	.8238	.7207
14	.7499	.7207	.7762	.7733	.4904	.8059	.7282
15	.7733	.7392	.7842	.7733	.5093	.788	.7282
16	.7922	.7468	.7602	.7922	.7545	.8059	.7842
17	.7468	.7468	.7499	.7922	.7545	.8238	.7577
18	.7545	.7356	.6668		.7167	.6556	.7733
19	.7733	.6097	.6859		.7545	.6556	.7733
20	.7922	.5847	.6859	.7922	.6036	.6805	.6478
21	.6224	.5788	.6668	.7922	.6224	.6805	.6478
22	.6602	.6283	.6097	.6602	.6413	.6036	.6859
23	.6602	.7733	.7356	.7922	.6535	.7545	.8299
24		.7922	.7421	.7545	.811	.7922	.7545
Max	.811	.811	.8299	.7922	.811	.8326	.8299
Min	.6224	.5788	.6097	.6097	.4904	.6036	.5975
Avg	.7377	.7424	.7430	.7413	.7172	.7439	.7349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7628	.7265	.7701	.7619	.7343	.691
2		.7682	.7164	.7619	.7421	.7164	.6089
3		.695	.7343	.7442	.6767	.724	.6089
4		.6878	.7087	.7164	.6767	.7343	.6219
5		.7059	.7343	.724	.6697	.724	.6447
6		.695	.7087	.6878	.6878	.6984	.6584
7		.7783	.7164	.7602	.8131	.7619	.823
8		.7265	.7442	.7522	.7762	.7522	.7783
9	.788	.7796	.7701	.7362	.7964	.7783	.7964
10	.9774	.8505	.8596	.788	.8939	.8842	.8328
11	.9877	.9145	.9593	.8063	.9391	1.0341	.9313
12	1.0164	.924	.9671	.9214	.9214	.9602	.8869
13	.8859	1.0903	.9922	.8495	.8939	.9134	.9313
14	.9922	.9425	.985	.815	.8954	.9231	.8688
15	.9593	.9328	.9568	.8238	.8869	.8688	.8326
16	.9593	.9335	.9671	.7265	.8145	.8775	.8779
17	1.0242	.8962	.9774	.7888		.8328	.924
18	1.0749	1.0242	1.0985	.7716	1.0317	.9816	1.0166
19	1.3112	1.448	1.258	.9945	1.2715	1.3523	1.3696
20	1.5565	1.587	1.4706	1.283	1.4175	1.4723	1.3696
21	1.2308	1.1643	1.3998	1.1022	1.1462	1.0867	1.0692
22	1.0498	1.0425	1.0341	.9774	1.0679	.9745	.9465
23	.9425	.8939	.9214	.9036	.9145	.8326	.7973
24		.7628	.8215	.8238	.7619	.7701	.691
Max	1.5565	1.587	1.4706	1.283	1.4175	1.4723	1.3696
Min	.788	.6878	.7087	.6878	.6697	.6984	.6089
Avg	1.0504	.9169	.9262	.8345	.8894	.8912	.8574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535	.6036	.695	.6413	.6602	.5601
2		.6348	.6468	.6653	.6348	.6348	.5601
3		.5544	.6653	.6653	.6161	.6468	.5359
4		.5601	.6401	.7468	.6161	.679	.5975
5		.5847	.6722	.7316	.6535	.6535	.6348
6		.679	.6838	.6653	.7167	.6653	.6478
7		.6653	.7095	.6219	.7655	.6767	.7095
8		.6838	.7468	.6099	.7421	.7392	.6908
9	.6516	.7468	.7468	.8059	.7059	.7282	.6401
10	.6767	.7133	.788	.8596	.6335	.7973	.567
11	.6584	.7023	.788	.8063	.6335	.6089	.462
12	.567	.6584	.7783	.7973	.6036	.7282	.5415
13	.5487	.6653	.8048	.7796	.5611	.7796	.4805
14	.5853	.6838	.7783	.7783	.5853	.7421	.4854
15	.5175	.6838	.7865	.7421	.5544	.7164	.4668
16	.5304	.6348	.7392	.7164	.5359	.7442	.5041
17	.5853	.6283	.8316	.7265		.7796	.499
18	.6859	.6722	.8417	.7442	.567	.7059	.6024
19	.8402	.8573	.8954	.8507	.7947	.8417	.7783
20	.9465	.8775	1.0242	.9694	.8413	.8871	.823
21	.8589	.7842	.9145	.924	.8316	.8131	.7762
22	.8507	.6283	.924	.8688	.8686	.7682	.7577
23	.724	.6908	.8215	.7059	.7282	.6036	.6224
24		.6535	.6468	.7095	.6413	.6224	.5601
Max	.9465	.8775	1.0242	.9694	.8686	.8871	.823
Min	.5175	.5544	.6036	.6099	.5359	.6036	.462
Avg	.6818	.6790	.7699	.7577	.6727	.7176	.6043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0317	1.1431	1.086	1.0425	1.0288	.9877
2		1.0534	.9717	1.0974	.9877	1.0288	1.0082
3		.9979	1.086	1.0317	1.0082	1.086	.9522
4		.9425	1.0288	1.0317	.9979	1.086	.9425
5		1.0082	1.0288	.9877	1.0082	1.0288	.9522
6		.9979	.9717	.9979	1.0082	1.0288	.5041
7		.9877	.9717	.9231	1.0534	1.086	1.0534
8		.9231	1.0288	.9774	.9877	1.086	1.0534
9	1.1431	1.0317	1.0288	1.0208	.9231	1.0642	1.1431
10	1.2003	1.0974	1.1283	1.1403	.9774	1.0517	1.086
11	1.3146	1.1088	1.086	1.1431	.9671	1.0631	.6287
12	1.2574	1.1088	1.0288	1.086	.9231	1.0562	1.086
13	1.1431	1.0974	1.0288	1.0099	.9134	1.0802	1.1431
14	1.1431	1.0974	1.2003	1.086	.7059	1.0402	1.086
15	1.1431	1.1643	1.2003	1.086	.7682	1.0288	1.0288
16	1.1431	1.1403	1.086	.9671	.7682	1.0288	1.0288
17	1.1088	1.1431	1.0425	1.0208		1.0288	1.0082
18	1.1043	2.2862	.9991	.9665	1.2003	.9882	1.0745
19	1.262	1.3146	1.1163	1.0288	1.3717	1.2483	1.182
20	1.3432	1.4289	1.2757	1.2894	2.6292	1.2757	1.3032
21	1.2357	1.3146	1.2894	1.2357	1.3717	1.2226	1.2489
22	1.3032	1.4289	1.2894	1.2489	1.3717	1.1946	1.262
23	1.1403	1.3146	1.2489	1.1523	1.2574	1.0974	1.1088
24		1.0317	1.1203	1.1403	1.0425	1.1431	.9877
Max	1.3432	2.2862	1.2894	1.2894	2.6292	1.2757	1.3032
Min	1.1043	.9231	.9717	.9231	.7059	.9882	.5041
Avg	1.1990	1.1688	1.1000	1.0731	1.0993	1.0863	1.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS  
 NO- Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1646	.1715	.1646
2		.1646	.1715	.168
3		.3361	.1143	.168
4		.3326	.1715	.1663
5		.3361	.1715	.3361
6		.3361	.1715	.3361
7		.3326	.1715	.3326
8		.3292	.3429	.1663
9		.1086	.3361	.1715
10			.1578	.3429
11			.1595	.3429
12			.3018	.1715
13	.3189	.3224	.1543	.3429
14	.3258	.3258	.156	.1715
15	.3258	.1646	.1543	.1715
16	.3224		.1543	.1715
17	.1612		.1543	.3361
18	.1526	.3429	.3121	.1612
19	.3086	.1715	.3121	.1612
20	.3224	.1715	.1595	.1629
21	.1612	.1715	.1595	.3258
22	.3258	.3429	.1629	.1646
23	.3292		.3292	.1663
24		.1646		.1646
Max	.3292	.3429	.3429	.3429
Min	.1526	.1086	.1143	.1612
Avg	.2776	.2566	.2022	.2236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8192		.7316	.8383	.8383	.6219
2	.743	.743	.7167	.6878	.8192	.8192	.5973
3	.724	.7049	.7167	.695	.8002	.8002	.5853
4	.7049	.6668	.679	.695	.7621	.7621	.5853
5	.6668	.6859	.6413	.6584	.7049	.7049	.5853
6	.7049	.6668	.6036	.6219	.6478	.724	.5853
7	.7621	.6859	.6413	.695		.7621	.7133
8	.7811	.6859	.679	.6767		.743	.695
9	.743	.724	.7167	.7133	.743	.743	.695
10	.6697	.743	.7049	.6878		.7621	.724
11	.695	.7621	.6668	.7468	.7865	.7811	.724
12	.6878	.7811	.6859	.7356	.6401	.8002	.6097
13	.6767	.7621	.6478	.7356	.6401	.7621	.6668
14	.6401	.7811	.6097	.7167	.6219	.7811	.6287
15	.6401	.743	.6478	.7167	.6219	.7621	.6478
16	.6767	.7621	.6668	.679	.6219	.743	.6668
17	.6584	.743	.7049		.6219	.724	.6287
18	.8002	.743	.6767			.7316	.724
19	1.0098	.8589	.7133	1.086	.8764		1.086
20	1.0288	1.1016	1.0059	1.1812	1.1431	1.3535	1.1241
21	1.1241	1.0829	1.0059	1.086	1.0288	1.1157	1.0288
22	1.0479	.9808	.9593	1.0098	.9907	.9694	.9717
23	.9717	.8589	.9145		.9335	.8413	.9145
24	.8383	.8954	.8299	.7865	.8764	.8954	.8048
Max	1.1241	1.1016	1.0059	1.1812	1.1431	1.3535	1.1241
Min	.6401	.6668	.6036	.6219	.6219	.7049	.5853
Avg	.7831	.7909	.7319	.7782	.7859	.8226	.7339



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8383	.811	.7316		.8764	.6653
2	.7621	.7811	.7545	.7023		.8383	.6468
3	.724	.724	.7167	.7023		.8002	.6468
4	.6668	.6668	.679	.6722		.7621	.6219
5	.6287	.6287	.6602	.6653		.724	.6283
6	.6859	.6478	.6224	.6468		.7049	.6401
7	.724	.6668	.6602	.6838		.7049	.7392
8		.6668	.7167	.6838		.724	.7207
9	.7049	.7049	.7167	.6653	.7621	.743	.6838
10	.6838	.8002	.743	.7392		.7621	.7621
11	.7392	.8192	.7621	.7545	.6468	.7621	.7811
12	.6584	.8383	.724	.7545	.5729	.7811	.743
13	.6838	.8383	.724	.679	.5544	.8002	.6478
14	.6468	.8573	.724	.6602	.5729	.7811	.6859
15	.6653	.7811	.724	.6413	.5914	.7811	.6859
16	.6653	.7621	.724	.5658	.5544	.7621	.6478
17	.6099	.7621	.724		.5544	.7621	.5906
18	.7621	.8002	.6468			.7947	.7621
19	.9335	.8299	.7133	.9526	.8192	.961	1.0288
20	1.086	1.1317	.961	1.1241	1.0288	1.0534	1.086
21	1.0479	.9808	.9795	1.086	.9717	.9795	.9717
22	.9907	.9808	.9795	1.0669	.9526	.9425	.9145
23	.9335	.9054	.924		.9335	.8501	.8764
24	.8764	.8954	.8488	.8316		.9145	.8131
Max	1.086	1.1317	.9795	1.1241	1.0288	1.0534	1.086
Min	.6099	.6287	.6224	.5658	.5544	.7049	.5906
Avg	.7703	.8045	.7600	.7623	.7319	.8152	.7496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7049	.679	.6722	.6859	.7049	.6348
2	.6668	.6859	.6413	.6535	.6668	.6859	.5975
3	.6478	.6478	.6036	.6535	.6287	.6478	.5975
4	.6478	.6287	.6602	.5975	.6097	.6097	.6161
5	.6287	.6287	.5658	.6161	.5335	.5525	.5601
6	.6097	.5906	.5658	.6348	.4954	.6478	.6161
7	.7049	.5716	.5658	.7282	.5144	.7049	.6722
8	.724	.5525	.3772	.5601	.7811	.6668	.6348
9	.6859	.7049	.6413	.8029	.7811	.6478	.5415
10	.7655	.743	.6859	.7282		.6668	.6287
11	.7655	.7621	.6859	.4904	.5228	.6859	.7049
12	.6348	.7621	.6478	.6413	.6535	.6859	.5906
13	.6908	.5716	.6478	.6413		.6668	.6478
14	.6908	.6097	.6478	.6413		.6859	.6668
15	.6908	.7049	.6287	.679	.7095	.6668	.6287
16	.6535	.6668	.6287	.6036	.5975	.6097	
17	.6535	.6478	.4954		.5975	.5716	.4763
18	.724	.6668	.6535			.7282	.6668
19	.743	.7468	.6722	.6859	.724	.8029	.7621
20	.7811	.7468	.7842	.5335	.724	.8775	.8002
21	.7621	.7468	.7842	.8002	.7811	.8029	.7811
22	.743	.6348	.7655	.7811	.7621	.7655	.7621
23	.743	.7282	.5601		.743	.7095	.743
24	.7049	.724	.7167	.7095	.724	.724	.6722
Max	.7811	.7621	.7842	.8029	.7811	.8775	.8002
Min	.6097	.5525	.3772	.4904	.4954	.5525	.4763
Avg	.6978	.6741	.6377	.6597	.6618	.6883	.6523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6097	.5658	.5544	.6478	.6859	.4805
2	.5525	.5716	.5658	.5487	.6478	.6478	.4435
3	.5144	.5335	.5281	.5359	.6287	.6287	.4435
4	.4954	.5144	.5281	.5175	.6097	.5906	.4251
5	.4763	.5335	.4904	.5175	.5906	.5716	.439
6	.5335	.5335	.4904	.5544	.5716	.6097	.5359
7	.5716	.5525	.5281	.5359	.5525	.6287	.5544
8	.5716	.5525	.5281	.5359	.5335	.5335	.5359
9	.4763	.4954	.4904	.499	.5335	.4954	.499
10	.462	.4572	.4763	.4805			.4382
11	.4251	.4763	.4572	.3772	.4251	.4191	.381
12	.4251	.4954	.4572	.3772	.3696	.4191	.3048
13	.4435	.4191	.4572	.415	.3511	.4191	.381
14	.4251	.4191	.4572	.3395	.3511	.4382	.381
15	.4066	.4572	.4763	.3395	.3511	.4572	.4001
16	.4024	.381	.4954	.3395	.3326	.381	.3239
17	.4251	.362	.4572		.3326	.3429	.3239
18	.4572	.4001	.4805			.3881	.381
19	.6287	.5041	.4938	.6478	.4954	.6468	.6478
20	.8192	.7545	.7842	.7811	.743	.7762	.743
21	.8002	.7095	.7947	.7621	.7621	.7762	.7621
22	.743	.7095	.7762	.743	.743	.6838	.724
23	.6859	.6348	.7207		.724	.5914	.6668
24	.6097	.6478	.6036	.6283	.6668	.7049	.5544
Max	.8192	.7545	.7947	.7811	.7621	.7762	.7621
Min	.4024	.362	.4572	.3395	.3326	.3429	.3048
Avg	.5384	.5302	.5460	.5252	.5438	.5581	.4904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.8002	.6602	.6161	.724	.7621	.4854
2	.6668	.6859	.6036	.5975	.6859	.724	.4854
3	.6097	.6097	.5658	.5975	.6478	.6859	.4854
4	.5525	.5335	.5281	.5601	.6287	.6478	.4854
5	.5144	.5906	.4904	.5601	.6097	.6097	.5041
6	.5716	.6097	.5093	.5788	.5716	.6287	.5601
7	.6668	.6287	.5658	.6535	.5525	.6287	.6535
8		.6287	.6036	.6535	.7621	.6859	.6535
9	.743	.6859	.6602	.7095	.8192	.724	.7095
10	.9709	.9526	.7621	.8962		.8002	.8192
11	.9896	.9717	.8002	.9054	.8962	1.086	.8954
12	1.0082	.9717	.8002	.9808	.8962	1.0288	.8764
13	.9709	1.0479	.8192	.9054	.8029	.9717	.8764
14	.8962	1.0669	.7811	.8676	.3547	.9907	.8383
15	.9896	.9717	.8002	.8676	.3361	1.0098	.8573
16	.9335	1.0098	.7811	.8676	.3174	.9526	.8002
17	.9522	.9907	.7811		.9896	.9145	.8002
18	.8764	.9526	.8215			.9149	.8192
19	1.0479	.9808	.8775	.9145	1.0098	1.1016	1.1431
20	1.086	1.1203	1.1389	1.1431	1.1241	1.1203	1.0288
21	1.0098	.9335	1.0642	1.1812	1.0479	1.0456	.9717
22	.9526	.7842	.9149	.8764	.9907	.8589	.9145
23	.9145	.7468	.8029		.9145	.6722	.8383
24	.8764	.8764	.7167	.6535	.7811	.8002	.6348
Max	1.086	1.1203	1.1389	1.1812	1.1241	1.1203	1.1431
Min	.5144	.5335	.4904	.5601	.3174	.6097	.4854
Avg	.8513	.8396	.7437	.7898	.7483	.8485	.7557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.6863	2.2405	2.2805	2.5149	2.1719	1.9753
2	2.2862	2.5149	2.1502	2.1948	2.4006	2.1148	1.8656
3	2.0576	2.3434	2.1502	2.0633		2.0576	1.8656
4	1.829	2.1719	2.037	1.8656	2.1719	1.9433	1.7375
5	1.7147	1.8861	1.9805	1.8461	2.0576	1.9433	1.7558
6	2.0005	2.0576	1.8107	1.9004	1.9433	2.0005	1.9204
7	2.2862	2.2291	1.9239	2.1948	2.0005	2.0576	2.0851
8	2.1719	2.3434	2.1502	2.2262	2.1719	2.1719	2.1399
9	2.5149	2.4006	2.1502	2.3891	2.3434	2.5149	2.3045
10	2.7149	2.9721	2.572	2.6337	2.4434		2.915
11	3.095	3.0293	2.915	3.1927	2.7435	3.4294	3.1436
12	3.1824	3.0864	2.8578	3.1367	2.6337	3.4865	3.0293
13	3.2036	3.4865	2.8578	2.999	2.7149	3.2579	2.9721
14	3.1276	3.5437	2.8578	2.8567	2.524	3.315	2.8578
15	3.1276	3.2007	2.915	2.8858	2.6606	3.315	2.915
16	3.1276		2.8006	2.9424	2.2262	3.3722	2.915
17	3.0178		2.8006		2.7692	3.2579	2.915
18	3.2579	3.2007	2.7149			2.9864	2.9721
19	3.658	3.4517	2.9081	3.7151	3.2579	3.8552	4.0009
20	4.2295	3.9609	3.6923	4.1152	3.7723	4.0604	4.0009
21	3.658	3.5848		3.7151	3.315	3.6214	3.4865
22	3.0864	3.0556	3.2036	3.1436	2.9721	2.9864	2.915
23	2.9721	2.4646	2.7984		2.4006	2.6337	2.6863
24	2.7435	2.8578	2.3525	2.2805	2.6863	2.2291	2.3045
Max	4.2295	3.9609	3.6923	4.1152	3.7723	4.0604	4.0009
Min	1.7147	1.8861	1.8107	1.8461	1.9433	1.9433	1.7375
Avg	2.8157	2.8422	2.5583	2.6942	2.5784	2.8166	2.6533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8866	4.0581	4.2438	4.201	4.9154	4.0009	3.6969
2	3.7151	3.8295	4.0741	4.0329	4.8011	3.8866	3.5848
3	3.6008	3.6008	3.9609	4.0329	4.6868	3.7723	3.5848
4	3.4865	3.3722	3.8477	3.9209	4.5725	3.7723	3.4728
5	3.315	3.315	3.7346	3.8089	4.4582	3.8295	3.4728
6	3.5437	3.6008	3.6214	3.8649	4.3439	4.0581	3.5848
7	3.9438	3.8295	3.7346	4.0329	4.401	4.1724	4.537
8	3.8866	4.0009	3.8477	4.0889	4.2867	4.401	4.369
9	3.9438	4.1724	4.0741	4.0329	4.2295	4.4582	4.425
10	4.481	4.4582	4.5153	4.481	4.201		4.1152
11	4.5931		4.6296	4.481	4.257	3.658	4.2295
12	4.6491	4.6868	4.6868	4.7051	4.0889	4.4582	4.5153
13	4.481	4.6296	4.5725	4.5931	4.257	5.0869	4.4582
14	4.257	4.7439	4.3439	4.6965	4.201	5.2012	4.401
15	4.313	4.7439	4.4582	4.6399	3.5288	5.2012	4.3439
16	4.481		4.5153	4.4136	3.8089	5.0297	4.0581
17	4.537		4.5153		3.9769	4.8583	4.4582
18	4.8583	4.5153	4.481			4.5931	4.5725
19	5.3155	4.8097	4.425	4.8583	5.0297	5.8814	5.8871
20	5.8871	5.4893	5.8253	6.1728	5.6013	5.8253	5.6013
21	5.0297	5.0926	5.6013	5.7728	5.144	5.4332	5.2012
22	4.9154	4.7611	5.1532	5.6013	5.0869	4.9851	4.8011
23	4.6296	4.481	4.9291		4.2867	4.481	4.5725
24	4.0009	4.2867	4.4136	4.369	5.144	4.1152	4.257
Max	5.8871	5.4893	5.8253	6.1728	5.6013	5.8814	5.8871
Min	3.315	3.315	3.6214	3.8089	3.5288	3.658	3.4728
Avg	4.3229	4.3084	4.4252	4.5143	4.4916	4.5721	4.3417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7545			1.509	.7545	.6979
2	.6979	.7545			1.4334	.7356	.6602
3	.6979	.7545			1.4334	.7167	.6602
4	.6979	.7545			.83	.7167	.6602
5	.7167	.7733			1.509	.7356	.6979
6	.7545	.7922			1.5844	.811	.7545
7	.8299	.8676			1.5844	.8865	.8676
8	.8299	.9242			1.7352	.8865	.8865
9	.8402	.8676			.8865	.9242	.9054
10	.8745	.9619			.8676	.9619	.9431
11	.8916	1.0374			.9431	1.0751	.9808
12	.9602	1.0374			1.0751	1.0751	.9997
13	.9259	1.0185			.9242	.9619	.8865
14	.8745	.9808			.9054	.9808	.9054
15	.8573	.9619			.8865	.9808	.8865
16	.8573	.9054		.9431	.8488	.9054	.8676
17	.9808	.9808		.9242	.9619	1.0374	.9054
18	1.094	.9431		.9431	.9242	1.0374	.9997
19	1.2071	1.0117		1.1694	1.1694	1.2637	1.2071
20	1.2826	1.166		1.2826	1.2449	1.2637	1.226
21	1.226	1.0802		1.2071	1.1694	1.1506	1.1317
22	1.1694	1.0288		1.1128	1.094	1.094	1.0562
23	1.0374	.9259		.9808	.9808	.9242	.8865
24	.7922	.8299	.7888		1.5844		.7545
Max	1.2826	1.166	.7888	1.2826	1.7352	1.2637	1.226
Min	.6979	.7545	.7888	.9242	.83	.7167	.6602
Avg	.9096	.9214	.7888	1.0704	1.1702	.9513	.8928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0857	.1132	.1132	.0943	.0943
2	.0943	.0943	.0686	.1132	.1132	.0943	.0943
3	.0943	.0943	.0686	.1132	.1132	.0943	.0943
4	.0943	.0943	.0686	.1132	.1132	.0943	.0943
5	.0943	.0943	.0686	.1132	.1132	.0943	.0943
6	.0754	.0754	.0686	.0943	.0754	.0943	.0943
7	.0754	.0754	.0686	.0754	.0943	.0754	.0754
8	.0566	.0943	.0857	.0943	.0943	.0754	.0754
9	.0857	.1132	.1132	.132	.0943	.1132	.1132
10	.1372	.1509	.132	.1886	.0943	.1509	.132
11	.1543	.1698	.132	.1698	.1132	.1509	.132
12	.1715	.1509	.1509	.1886	.1132	.1509	.1509
13	.1029	.1886	.132	.1698	.0943	.1509	.1509
14	.12	.1509	.132	.1698	.0943	.132	.1509
15	.12	.1886	.132	.2075	.0943	.1509	.1646
16	.1543	.1698	.1509	.1509	.1132	.1509	.1886
17	.1509		.1886	.1509	.1132	.1698	.1509
18	.1132	.132	.1132	.1132	.1132	.1509	.1698
19	.1698	.12	.132	.132	.1509	.1509	.1132
20	.1509	.12	.132	.132	.1509	.132	.132
21	.1509		.132	.132	.132	.132	.132
22	.1509	.12	.132	.132	.1132	.132	.132
23	.1132	.1029	.1132	.1132	.1132	.1132	.1132
24	.0943	.1132	.1029	.1132	.1132	.0943	.0943
Max	.1715	.1886	.1886	.2075	.1509	.1698	.1886
Min	.0566	.0754	.0686	.0754	.0754	.0754	.0754
Avg	.1185	.1231	.1127	.1344	.1100	.1226	.1224



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9424	3.1121	2.8807	3.2253	3.1687	3.1687	2.9424
2	2.8292	3.1121	2.7263	2.999	2.999	3.1687	2.7726
3	2.8292	3.1121	2.7263	2.9424	2.999	3.1687	2.7726
4	2.8292	3.1121	2.7263	2.9424	3.1121	3.1687	2.7726
5	2.9424	3.1121	2.7263	2.999	3.1121	3.2253	2.9424
6	2.999	3.1121	2.7778	3.1121	3.2819	3.3385	3.2819
7	3.1121	3.2253	2.8292	3.2819	3.3951	3.5648	3.678
8	3.0556	3.2819	2.9835	2.4897	3.678	3.678	3.5082
9	2.8807	3.5082	3.3951	3.3385	3.2819	3.3951	3.4517
10	3.2407	3.4517	3.678	3.3385	3.2819	3.678	3.678
11	3.3951	3.7912	3.7912	3.4517	3.2819	3.9609	3.2253
12	3.2922	3.6214	3.7912	3.5648	3.2253	5.0926	3.6214
13	3.0864	3.5082	3.678	3.7346	3.3385	3.9609	3.7346
14	3.1379	3.5082	3.678	3.7346	3.0556	3.7912	3.5648
15	3.0864	3.5648	3.7346	3.8477	2.8858	3.7912	3.2819
16	3.1893	3.4517	3.6214	3.5648	2.9424	3.8477	3.3385
17	3.5648	3.5082	3.678	3.6214	2.8858	3.9043	3.5648
18	3.9043	3.5082	3.678	2.7726	3.8477	3.9609	3.7346
19	4.4702	3.7037	4.0741	3.5082	4.4136	4.6399	4.4702
20	4.6965	4.0638	4.5833	4.8097	4.5268	4.6399	4.4702
21	4.0175	3.6008	4.2438	4.357	4.0741	4.1307	4.2438
22	3.9043	3.5494	3.9609	4.1872	4.2438	3.7912	3.8477
23	3.5648	3.4979	3.7346	3.9609	3.5082	3.678	3.6214
24	3.0556	3.1121	3.0864	3.4517	3.3951	3.2253	3.1687
Max	4.6965	4.0638	4.5833	4.8097	4.5268	5.0926	4.4702
Min	2.8292	3.1121	2.7263	2.4897	2.8858	3.1687	2.7726
Avg	3.3344	3.4221	3.4493	3.4682	3.4139	3.7487	3.4870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024		.499	.5544	.5228	.4435	.4251
2	.4066		.4435	.5601	.5281	.4435	.4251
3	.4066		.4435	.5601	.5281	.4435	.4251
4	.4108		.4435	.5601	.5228	.4435	.4294
5	.4668		.4435	.5601	.5228	.499	.4668
6	.5658		.499	.6224	.5658	.5544	.547
7	.6224		.5175	.5658	.6161	.6099	.6036
8	.547		.5175	.5658	.547	.5544	.6036
9	.4854	.5415	.499	.5415	.4805	.462	.4854
10	.4668	.5041	.4805	.3921	.4435	.4066	.4108
11	.3547	.4338	.4805	.3921	.3881	.3734	
12		.4108	.462	.3921	.3734	.3658	.2772
13	.3734	.3921	.4435	.3921	.3142	.4294	
14	.3921	.3881	.4435	.3921	.3511	.2987	
15	.3921	.3881	.4481	.3547	.3206	.2801	
16		.3547	.4854	.3547	.3361		
17		.3511	.4435	.3547	.3174	.3361	
18		.3881	.499	.3841	.3734	.3881	
19		.6219	.6036	.4887	.5415	.695	.5121
20		.6878	.7392	.6626	.6697	.7087	.6468
21		.7059	.7762	.6878	.6036	.7164	.6653
22		.6584	.7392	.6767	.5853	.6401	.6653
23		.6219	.6468	.6099	.5853	.463	.5544
24	.4755		.5304	.5544		.499	.4435
Max	.6224	.7059	.7762	.6878	.6697	.7164	.6653
Min	.3547	.3511	.4435	.3547	.3142	.2801	.2772
Avg	.4512	.4966	.5220	.5075	.4799	.4806	.5051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326		.3361	.3696	.3734	.3361	.3326
2	.3361		.3361		.3395	.3361	.3326
3	.3361		.3361	.3361	.3395	.3361	.3326
4	.3361		.3361	.3361	.3361	.3361	.3361
5	.3772		.3361	.3734	.3395	.3361	.3361
6	.3961		.3696	.415	.3772	.3696	.3961
7	.4715		.3881	.5093	.4527	.4805	.4715
8	.4715		.4066	.4715	.4715	.4435	.4904
9	.4854	.3361	.4066	.4854	.4668	.4066	.4481
10	.3921	.3734	.4108	.4481	.4294	.4481	
11	.3921	.3734	.4668	.3921	.4251	.4435	
12		.3734	.4481	.4294	.4066	.4481	
13	.4108	.3696	.4435	.3921	.4066	.4108	
14	.3921	.3696	.4066	.3921	.3881	.3547	
15			.4066	.3734	.3772	.3361	
16		.3696	.3734	.3734	.3361		
17		.3696	.3921	.3734	.3547	.3547	
18		.3696	.4066	.3841	.3734	.3921	
19		.5121	.499	.4572	.4854	.5487	.5175
20		.6036	.6283	.5792	.5487	.5731	.5175
21		.6219	.6468		.4938	.5304	.5729
22		.6036	.6099	.567	.4572	.4938	.5359
23		.4938	.5175	.4805	.4572	.4572	.4066
24	.3511		.3881	.4251	.3921	.3881	.3881
Max	.4854	.6219	.6468	.5792	.5487	.5731	.5729
Min	.3326	.3361	.3361	.3361	.3361	.3361	.3326
Avg	.3915	.4385	.4290	.4256	.4095	.4157	.4276

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.0191			.0709	
11	.0373	.0381	.0377	.0953	.0895	
12		.0377	.0377	.0762	.1132	
13	.0373	.0377	.0377	.0953	.0953	
14	.0373	.0373	.0377	.0762	.0747	
15		.0373	.0377	.0953	.0754	
16		.0189	.0377	.0953		
17		.0377	.0377	.0953	.0943	
18		.0377	.0747	.0381	.0566	
19		.0377	.0701	.0191	.0189	.0377
20		.0189		.0191	.0189	
Max	.0373	.0381	.0747	.0953	.1132	.0377
Min	.0373	.0189	.0377	.0191	.0189	.0377
Avg	.0373	.0326	.0454	.0705	.0708	.0377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 402 / 33 KV KUPWAD CITY FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7364		1.8296	1.8296	1.7924	1.6632	1.6078
2	1.6804		1.6632	1.6804	1.8107	1.6632	1.6078
3			1.6632	1.5684	1.7541	1.6632	1.5684
4	1.6975		1.6632	1.5684	1.7541	1.6632	1.6244
5	1.6975		1.6632	1.5684	1.7541	1.6632	1.6244
6	1.9239		1.7364	1.5844	1.7541	1.7741	1.7541
7	2.0165		1.8296	2.037	1.9605	1.9404	1.9805
8	1.8484		1.8296	1.9605	1.8484	1.9404	2.0513
9	1.885	1.7558	1.8296	1.9204	1.7741	1.7741	1.8296
10	1.6632	1.701	1.8296	1.6461	1.5912	1.7187	
11	1.6078	1.701	1.6461	1.5364	1.4815	1.6289	
12	1.5524	1.701	1.6632	1.5364	1.262	1.5415	
13	1.5524	1.6832	1.6461	1.4969	1.3169	1.4815	
14	1.4969	1.5524	1.5912	1.386	1.2752	1.4815	
15		1.5524	1.6078	1.3306	1.2883	1.4969	
16		1.386	1.701	1.3306	1.2883		
17		1.5203	1.701	1.386	1.3443	1.3717	
18		1.5364	1.5746	1.5043	1.4563	1.6289	
19		2.3348	2.1399	1.7541	1.9404	2.1719	2.1176
20		2.552	2.552	2.5252	2.4143	2.4977	2.3891
21		2.4434	2.552	2.552	2.1948	2.3348	2.3045
22		2.3045	2.4691	2.3045	1.9753	2.1719	2.1399
23		2.0851	2.2731	2.1068	1.9204	1.8656	1.7558
24	1.8484		1.9404	1.9959	1.8296	1.8296	1.7187
Max	2.0165	2.552	2.552	2.552	2.4143	2.4977	2.3891
Min	1.4969	1.386	1.5746	1.3306	1.262	1.3717	1.5684
Avg	1.7291	1.8540	1.8581	1.7546	1.6992	1.7811	1.8716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 201 / 11 KV Doordarshan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5121		.6283		.5014	.4706
2		.5121		.6099		.5014	.4706
3		.5121		.6099		.5068	.4706
4		.5121		.5914		.5068	.4706
5		.5487		.5914		.5068	.4706
6		.6154		.6653		.5792	.5731
7		.6805		.7762		.7602	.7087
8	.6283	.6805	.6283	.6908	.695	.8326	.7682
9	.7023	.6805	.679	.6838	.6283	.6335	
10	.6697	.6401	.7392	.6283	.6584	.7059	
11	.6697	.6584	.7468	.5729	.6401	.567	
12	.6219	.6767	.7095	.6219	.6219	.6036	
13	.5487	.567	.5914	.5487	.6099	.5487	
14	.6584	.5304	.5487	.4706	.4251	.4938	
15	.6584	.6036	.5487	.4887	.4805	.4755	
16	.567	.4755	.543	.4887	.4435	.4755	.4298
17	.5068		.543	.5121	.4938	.5121	.5068
18	.6154		.5973	.5304	.5121	.5914	.5731
19	.8238		.724	.7343	.7087	.7442	.8238
20	.8326		.7964	.8417	.788	.7712	.8326
21	.7964		.8686		.788	.7362	.7682
22	.7964		.7947	.7865	.7087	.7522	.7865
23	.6584		.7207		.6024	.6089	.6584
24	.5853	.5853		.6468		.567	.5014
Max	.8326	.6805	.8686	.8417	.788	.8326	.8326
Min	.5068	.4755	.543	.4706	.4251	.4755	.4298
Avg	.6670	.5877	.6737	.6236	.6128	.6034	.6049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 202 / 11 KV WALCHAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4755		.4755		.5487	.4024
2		.4755		.4755		.5175	.4066
3		.4755		.439		.4805	.4066
4		.4755		.439		.4805	.4066
5		.4755		.4481		.4805	.4066
6		.5853		.5228		.4435	.6283
7		.6516		.5847		.5175	.6722
8	.6348	.6516	.4435	.5788	.6348	.6653	.6722
9	.7392	.6878	.6219	.5729	.7392	.7499	
10	.8131		.6219	.8501	.7577	.7499	
11	.7947		.5487	.7762	.8131	.7577	
12	.8316		.5121	.7964	.8501	.7762	
13	.6283		.4572	.695	.7207	.7133	
14	.6468		.3982	.6984	.8316	.4207	
15	.6838		.543	.6268	.7682	.7602	
16	.7392		.5068	.7421	.7133	.695	.7468
17	.6219	.6878	.5068	.7059	.6722	.4755	.6283
18			.5068	.4938	.5601	.5175	.6283
19	.6401		.6154	.567	.5853	.6348	.5975
20	.5853		.6219	.5731	.6584	.6283	.6283
21	.5853		.695	.5249	.5853	.6219	.5975
22	.5853		.6036	.4887	.5853	.4572	.5788
23	.5487		.5487		.567	.439	.5228
24	.4668	.5121		.5121		.567	.439
Max	.8316	.6878	.695	.8501	.8501	.7762	.7468
Min	.4668	.4755	.3982	.439	.5601	.4207	.4024
Avg	.6591	.5594	.5470	.5907	.6901	.5874	.5511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.134		1.1273		1.2437	.9979
2		1.134		1.1273		1.1827	.9979
3		1.134		1.1088		1.1088	.9979
4		1.134		1.1088		1.0534	.9979
5		1.134		1.1088		1.0534	1.0534
6		1.2437		1.1458		1.2012	1.134
7		1.4118		1.3817		1.3676	1.3535
8	1.4045	1.3756	1.1827	1.3817	1.4045	1.3306	1.3717
9	1.4415		1.1949	1.7372	1.307	1.4083	
10	1.251		1.2437	1.3491	1.2936	1.3535	
11	1.4377		1.1458	1.3491	1.1827	1.3121	
12	1.3443		1.1458	1.3169	1.2012	1.423	
13	1.3256		1.0974	1.2803		1.3535	
14	1.307		1.2308	1.1462		1.2071	
15	1.3817		1.086	1.1584		1.134	
16	1.3256		1.1222	1.1946		1.1827	1.2567
17	1.5154		1.1584	1.2851		1.3717	1.1088
18	1.5912		1.1765	1.39	1.9022	1.4784	1.2803
19	1.9022		1.448	1.6655	1.9022	1.5927	1.6095
20	2.0851		1.6651	1.7896	1.9753	1.7737	1.7737
21	1.8656		1.5154	1.6297	1.7558	1.5729	1.7013
22	1.7558		1.4969	1.5384	1.6461	1.4998	1.3394
23	1.39		1.386		1.3169	1.1706	1.2308
24	1.0791	1.2071		1.2012		1.1706	1.0608
Max	2.0851	1.4118	1.6651	1.7896	1.9753	1.7737	1.7737
Min	1.0791	1.134	1.086	1.1088	1.1827	1.0534	.9979
Avg	1.4943	1.2120	1.2685	1.3270	1.5352	1.3144	1.2509



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 206 / 11 KV DATTANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4706		.4706		.4252	.3898
2		.4706		.4344		.4298	.3898
3		.4706		.4344		.4298	.3898
4		.4706		.3982		.4298	.3898
5		.4344		.4024		.4298	.3898
6		.5731		.4938		.5014	.4908
7		.6024		.6584		.5373	.631
8	.6219	.567	.5914	.5853		.5731	.6089
9	.5544		.5975	.5914	.5544	.5552	
10	.4607		.5487	.5359	.4835	.4835	
11	.4607		.5121	.439	.2865	.4706	
12	.4075		.4805	.4572	.197	.4344	
13	.3801		.439	.4207	.2172	.3841	
14	.3801		.4344	.4163	.2353	.3841	
15	.3801		.4344	.4024	.2378	.3696	
16	.362		.4344	.3841	.3841	.3881	.4359
17	.394		.5068	.4207	.3681	.4066	.3429
18	.4607		.4887	.4298	.3856	.5258	.443
19	.6089		.5792	.5548	.5258	.5895	.567
20	.5731		.724	.7011	.631	.631	.6661
21	.6805		.6697	.7265	.5959	.631	.6447
22	.6447		.5792	.6447	.5609	.5959	.5731
23	.5373		.543		.4908	.4908	.5373
24	.5014	.4706		.5068		.4557	.4207
Max	.6805	.6024	.724	.7265	.631	.631	.6661
Min	.362	.4344	.4344	.3841	.197	.3696	.3429
Avg	.4946	.5033	.5352	.5004	.4103	.4813	.4888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	.1829	.3109	.2172	1.9004	1.4632	2.268
2	1.134	.1829	.3258	.2172	1.829	1.6289	2.3411
3	1.1946	.2195	.3109	.2172	2.0328	2.1948	2.5606
4	1.4118	.2561	.2896	.2507	2.2862	2.3529	2.9264
5	1.6289	.2896	.2926	.2507	2.7435	2.5606	3.0361
6	2.1948	.362	.2896	.2865	2.9502	2.7149	3.219
7	.2926	.3582	.5669	.2865	3.2922	2.9264	3.2922
8	2.0995	2.0119	.2896		3.0045	2.9864	3.3653
9	2.7435	2.1948	.2896		.2561	2.8959	2.9995
10		2.1719	1.448	.2534	.2534	.2896	.2534
11	2.4143	2.3777	3.2922	.2561	.2561	.2926	.2561
12	2.5606	2.5339	3.3105	.2172	.2534	.2926	.2926
13	2.6337	2.552	3.2922	.2561	.2534	.2926	.2534
14	2.9264	2.5606	3.0769	.2218	.2378	.2561	.2195
15	2.9264		2.8959	.2195	.2353	.2561	.2218
16	.2865	.2896	2.8898	.2195	.2561	.2534	.2561
17	.3224	.2926	2.9264	.2561	.2534	.2172	.2172
18	.3582	.2896		.2534	.2172	.2507	.2561
19	.3582	.2926		.2926	.2195	.3224	.2534
20	.3582	.2896		.2534	.2172	.3582	.2926
21	.3258	.2926		.2195	.2378	.3224	.2534
22	.2896	.2715		.2172	.2353	.2896	.2195
23	.2561	.2715		1.8099	.2353	.2896	.2172
24	1.1706	.2195	1.5432	.2534	2.0302	1.0974	2.1948
Max	2.9264	2.5606	3.3105	1.8099	3.2922	2.9864	3.3653
Min	.2561	.1829	.2896	.2172	.2172	.2172	.2172
Avg	1.3487	.9027	1.5356	.3148	1.0703	1.1169	1.3194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029	.9511	1.0608	.9412	.9511	.9511	.9145
2	.9671	.9145	1.0136	.905	.9955	.9593	.9145
3	.9671	.9145	1.0242	.9511	1.0608	.9877	.9145
4	1.0136	.9511	1.086	.9877	1.086	1.0136	.9877
5	1.0498	1.0136	1.1157	1.0242	1.134	1.0425	1.086
6	1.086	1.1584	1.1222	1.1458	1.1584	1.0498	1.1946
7	1.1584	1.1462	1.1888	1.2567	1.3169	1.0608	1.3756
8	1.1706	1.1104	1.086		1.2308	1.086	1.267
9	1.1765	1.1523	1.2071		1.0974	1.1222	1.2536
10	1.1584	1.1584	1.2308	1.0608	1.086	1.267	1.1584
11	1.1222	1.1706	1.2308	1.267	1.1157	1.2894	1.3169
12	1.182	1.1765	1.2071	1.3169	1.1222	1.2536	1.1584
13	1.1462	1.1765	1.1706	1.3169	1.1222	1.2536	1.1222
14	1.0745		1.2071	1.3676	1.1157	1.2178	1.0974
15	1.0387		1.2308	1.2936	1.1041	1.182	1.086
16	1.0029		1.267	1.2071	1.0974	1.1462	1.1706
17	1.0029	1.2071	1.3169	1.267	1.1222	1.182	1.2936
18	1.0745	1.2127		1.3717	1.0974	1.2178	1.3169
19	1.2894	1.2308		1.4266	1.0608	1.2536	1.3032
20	1.3253	1.2489		1.267	1.0498	1.3611	1.3535
21	1.3032	1.2437		1.1706	1.0425	1.2536	1.086
22	1.1946	1.1946		1.086	1.0136	1.1222	1.0136
23	1.0974	1.1888		1.0242		1.0136	.9877
24	1.0498	1.0242	1.5432	.9774	.9412	.9511	.9511
Max	1.3253	1.2489	1.5432	1.4266	1.3169	1.3611	1.3756
Min	.9671	.9145	1.0136	.905	.9412	.9511	.9145
Avg	1.1106	1.1212	1.1838	1.1651	1.0922	1.1349	1.1385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.1829	.3658		.0549	.1097	.0549
2	.0549	.1829	.3801		.0554	.1086	.0549
3	.0549	.1829	.4572		.0549	.0914	.0549
4	.0543	.1829	.4572		.0724	.0905	.0543
5	.0724	.181	.4572		.0732	.0914	.0543
6	.0905	.2172	.4706		.0905	.0905	.0724
7	.0905	.0537	.1829		.0914	.1097	.0549
8	.0914	.0543	.181		.0543	.1086	.0366
9	.0905	.0724	.0549		.0914	.1086	.0366
10	.0543	.0905	.0724	.2926	.181	.2172	.181
11	.0366	.0914	.0549	.439	.2195	.3658	.2195
12	.0362	.0905	.0732	.3801		.3658	.2896
13	.0362	.1097	.0543	.3658	.2896	.3658	.3658
14	.0358	.1086	.0543	.362	.362	.3658	.362
15	.0362	.1086	.0537	.3109	.3801	.2926	.3982
16	.0358	.1086	.0537	.2896	.3841	.2195	.2561
17	.0358	.1097	.0537	.2865	.3982	.2195	.2896
18	.0358	.1086		.0543	.1629	.0358	.0366
19	.0716	.1097		.0366	.1646	.0716	.0543
20	.0895	.1086		.0543	.1448	.0895	.0732
21	.181	.2172		.0732	.1463	.0716	.0724
22	.181	.2896		.0543	.1448	.0543	.0732
23	.1829	.3258		.0549	.1267	.0543	.0543
24	.0549	.1829	1.5432		.0543	.1097	.0549
Max	.1829	.3258	1.5432	.439	.3982	.3658	.3982
Min	.0358	.0537	.0537	.0366	.0543	.0358	.0366
Avg	.0732	.1446	.2789	.2182	.1651	.1587	.1356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2195	.1829	.2195	.2534	.1463	.2195
2	.2353	.2195	.1991	.2172	.2926	.1448	.2195
3	.2172	.2195	.2012	.2172	.2896	.128	.2561
4	.2195	.2561	.2172	.2353	.3292	.1267	.3258
5	.2378	.2534	.2195	.2534	.362	.128	.362
6	.2743	.3258	.2172	.2507	.3658	.1448	.3982
7	.3109	.3224	.2353	.2865	.4706	.1463	.3982
8	.2926	.2865	.181		.2926	.1629	.2896
9	.2926	.2715	.2353		.2534	.1448	.394
10	.2534	.2534	.2172	.2534	.2353	.181	.2896
11	.2195	.2561	.2195	.2195	.2378	.2149	.2926
12	.2149	.2561	.2195	.181	.2172	.2149	.2715
13	.2149	.2378	.2172		.2172	.2149	.2561
14	.2149	.2378	.2195	.2172	.2012	.2149	.2534
15	.2149	.2353	.2195	.2561	.1991	.2149	.2926
16	.2149	.2172	.2195	.2534	.2012	.2149	.2534
17	.2149	.2195	.2195	.2561	.1991	.2507	.2926
18	.2507	.2172		.2896	.181	.2507	.2353
19	.2865	.2012		.3077	.1829	.2507	.2926
20	.2865	.1991		.2926	.181	.2865	.362
21	.2534	.2012		.2896	.2012	.2507	.3258
22	.2172			.2743	.1991	.2172	.2926
23	.2195	.1829		.2534	.1629	.2534	.2534
24	.2534	.2195		.2195	.2561	.1463	.2561
Max	.3109	.3258	.2353	.3077	.4706	.2865	.3982
Min	.2149	.1829	.181	.181	.1629	.1267	.2195
Avg	.2443	.2395	.2141	.2497	.2492	.1937	.2951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.3475	.2743	.181	.2172	.2195	.2195
2	.2195	.3258	.2715	.181	.2195	.2353	.2195
3	.2172	.1829	.2743	.1791	.2534	.2378	.2195
4	.2172	.2195	.2896	.197	.2926	.2534	.2561
5	.2378	.2534	.2896	.2172	.3258	.2743	.2896
6	.2743	.362	.3077	.2534	.3658	.2896	.362
7	.2926	.3582	.3109	.2896	.3801	.3109	.362
8	.2896	.3582	.2534		.3292	.3258	.3258
9	.2715				.2896	.3439	.2865
10			.2561	.2896	.2896	.3258	.2896
11	.2534	.3292	.2534	.2534	.2743	.2865	.2534
12	.2149	.3077	.2195	.2561	.2715	.2507	.2561
13	.2149	.2896	.2195	.2402	.2715	.2507	.2715
14	.2507	.2926	.2195	.2743	.2378	.2507	.2172
15	.2507	.2715	.2195	.2896	.2353	.2507	.2561
16	.2149		.2195	.2561	.2561	.2507	.2534
17	.2507	.2534	.2195	.2172	.2534	.2149	.2926
18	.2507	***		.2195	.2534	.2507	.2896
19	.3224	.2279		.2896	.2353	.3224	.2743
20	.3224	.2378		.2561	.2378	.3582	.2534
21	.2896	.2353		.2172	.2353	.3224	.2743
22	.2534	.1334		.2195	.2353	.2896	.2353
23	.2195	.2561		.2172	.2172	.2896	.2353
24	.2561	.1829	1.5432	.2172	.1829	.2172	.2561
Max	.3224	32.8121	1.5432	.2896	.3801	.3582	.362
Min	.2149	.1334	.2195	.1791	.1829	.2149	.2172
Avg	.2531	1.8208	.3318	.2369	.2650	.2759	.2687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.8779	1.0974	1.0974	.3982	.1646	.3658
2	.2149	.8413	1.267	1.0608	.3658	.1629	.3658
3	.2172	.8779		1.1222	.3258	.1463	.3658
4	.2353	.9145	1.3535	1.267	.3658	.1448	.3658
5	.2507	1.1584	1.3717	1.5384	.4066	.1463	.3982
6	.2689	1.5203	1.3575	1.7375	.439	.1629	.4344
7	.2865	.394	.1991	2.1948	.4344	.1646	.439
8	.2865	.362	.1991		.4024	.1629	.4024
9	.2865	.3475	.181		.362	.1629	.4024
10	.362	.3258	.181	1.448	.724	1.086	1.0974
11	.3658	.3292	.181	1.9728	1.0974	1.829	1.5203
12	.362	.3077	.181	2.0119	1.448	1.829	1.829
13	.3982	.2896	.181	1.8099	1.448	1.829	2.1033
14	.394	.2926	.1829	1.7558	1.0974	1.829	1.9909
15	.3982	.2896	.1829	1.6651	1.086	1.7558	1.829
16	.394	.2715	.1829	1.4632	1.1888	1.6095	1.9185
17	.394	.2743	.2195	1.4842	1.086	1.0974	1.829
18	.394	.2715		.3658	.2195	.394	.3982
19	.4298	.2926		.3982	.2172	.4298	.439
20	.4656			.4572	.2012	.4656	.4525
21	.8688	.7316		.4525	.1991	.4656	.439
22	.905	.905		.439	.1991	.4344	
23	.9145	1.0974		.439	.181	.4344	.439
24	.2507	.9145	1.5432	1.134	.4024	.1829	.4024
Max	.9145	1.5203	1.5432	2.1948	1.448	1.829	2.1033
Min	.2149	.2715	.181	.3658	.181	.1448	.3658
Avg	.3983	.6038	.5919	1.2416	.5956	.7121	.8794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8532	2.963	2.7435	2.8235	3.0727	2.8532	3.0727
2	2.8532	2.8532	2.7149	2.8235	2.9321	2.8235	3.2922
3	2.8532	2.963	2.7435	2.7435	2.963	2.7984	3.2922
4	2.9938	3.0727	2.8235	2.7435	3.1047	2.7149	3.0407
5	2.9938	3.0407	2.9081	2.7435	2.7435	2.6886	3.0407
6	3.1047	2.9321	2.963	2.6337	2.4977	2.4434	3.0407
7		2.7938	2.963		2.7984	2.3045	3.0407
8	2.8532	2.7149	2.9321		2.7149	2.2262	2.963
9	2.6063	.439	2.9321		2.7435	2.3891	2.7435
10	2.7149	2.6606	2.3891	3.1493	2.7692	2.7149	2.3348
11	2.7435	2.6886	2.3891	2.9012	2.8532	2.8532	2.3045
12	2.963	2.4434	2.3891	2.552	2.8778	2.963	2.9321
13	2.9321	2.4977	2.3891	2.524	2.9321	3.0727	2.3594
14	3.0407	2.524	2.4977	2.6063	2.8532	3.0727	2.7435
15	3.0727	2.524	2.6063	2.6337		2.9321	3.0407
16	2.7938	2.3348	2.6063	2.9321	2.8532	2.7149	2.8532
17	2.9012	2.3594	2.7435	2.7984	2.7692	2.963	2.9321
18	3.0087	2.4691		2.7149		3.0087	2.963
19	2.9012	2.552		2.6337		2.7938	2.9321
20	2.9012	2.7435		2.8235	2.6886	2.5789	2.8532
21	2.9321			3.0727	2.7149	2.7938	2.8235
22	2.9321	2.7692		2.9864	2.7984	2.9321	2.9321
23	2.963	2.7435		2.963	2.8235	2.8235	3.0727
24	2.963	2.963	4.6296	2.8235	3.0407	2.8532	3.0727
Max	3.1047	3.0727	4.6296	3.1493	3.1047	3.0727	3.2922
Min	2.6063	.439	2.3891	2.524	2.4977	2.2262	2.3045
Avg	2.9076	2.6107	2.7980	2.7917	2.8355	2.7630	2.9032



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,  
KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
1	.7087
2	.7087
3	.7087
4	.7087
5	.7087
6	.7442
24	.7087
Max	.7442
Min	.7087
Avg	.7138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,  
KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
1	.0924
2	.0924
3	.0924
4	.0924
5	.0924
6	.0924
7	.0924
8	.0924
24	.0924
Max	.0924
Min	.0924
Avg	.0924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,  
KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
1	.362
2	.3506
3	.3506
4	.3506
5	.3856
6	.3856
24	.3506
Max	.3856
Min	.3506
Avg	.3622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,  
KHARSUNDIFeeder No / Name : 204 / 11 KV Nelkaranji Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUL-18
HR	Load (MW)
1	.0914
2	.0914
3	.0857
4	.0914
5	.1097
6	.1463
24	.0914
Max	.1463
Min	.0857
Avg	.1010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
1	.0937
2	.0937
3	.0937
4	.0937
5	.0937
6	.0937
24	.0781
Max	.0937
Min	.0781
Avg	.0915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3479	.1372	.1463	.1448	.3189	.3858	.2058
2	.3048	.1227	.128	.1448	.2846	.4687	.1974
3	.3086	.1227	.1267	.1448	.3239	.4687	.1974
4	.3437	.1227	.1448	.1829	.3086	.5401	.3048
5	.4374	.1387	.1848	.2587	.4218	.7074	.4268
6	.6622	.156	.3361	.3174	.7202	.8619	.68
7	.2623	.1715	.3109	.3224	1.5927	1.1584	1.0155
8	.3401	.4694	.2686	.2896	1.5061	1.1111	1.1111
9	.8002	.8509	.2172	.2743	1.0364	1.2803	.9998
10	.9717	.9511	.4096	.2658	.156	.2126	.1715
11	1.0402	.9998	.9374	.2534	.1448	.2561	.156
12	1.0402	1.1873	1.6446	.2195	.1478	.2172	.1578
13	.9602	.3161	1.4661	.2126	.1433	.1898	.1753
14	1.0526		1.5089	.2534	.1448	.1772	.1829
15	1.1203		1.5223	.2195	.1433	.2149	.156
16	.1715		1.4548	.1772	.1448	.1097	.1734
17	.156	.1734	1.1431	.181	.1612	.1107	.1928
18	.1372	.2454	.1696		.1791	.0716	.2103
19	.1715	.2715	.2561	.2126	.2715	.1372	.2658
20	.1715	.3109	.3326	.1772	.3109	.2926	.298
21	.1753	.2614	.2957	.1753	.2715	.2561	.2835
22	.1402	.2218	.2587	.1772	.2534	.1829	.2658
23	.1402	.1829	.2033	.1433	.2195	.124	.2229
24	.3906	.1387	.1478	.1829	.2683	.3353	.2029
Max	1.1203	1.1873	1.6446	.3224	1.5927	1.2803	1.1111
Min	.1372	.1227	.1267	.1433	.1433	.0716	.156
Avg	.4853	.3596	.5673	.2144	.3947	.4113	.3439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.1214	.0905	.0716	.1063	.0876	.0739
2	.0716	.12	.0724	.0716	.1086	.0701	.0724
3	.0709	.1372	.0716	.0724	.1097	.0709	.0732
4	.0895	.12	.0914	.0914	.0905	.0886	.0914
5	.1075	.1372	.1294	.1097	.1086	.1254	.1294
6	.1629	.1372	.1867	.1698	.1463	.1629	.2054
7	.1829	.1715	.1848	.2353	.1791	.1791	.1867
8	.1448	.1543	.2103	.1734	.1629	.1629	.1294
9	.1433	.0867	.1791	.1629	.124	.1463	.1448
10	.1417	.08	.1433	.1463	.0848	.1063	.1463
11	.1254	.0995	.128	.128	.0857	.1267	.1267
12	.1417	.116	.124	.128	.0867	.1463	.1267
13	.1417	.1075	.1254	.1267	.0848	.1109	.128
14	.1254		.1086	.1097	.1475	.1829	.1448
15			.1086	.1097	.1017	.1417	.1463
16			.128	.1267	.1658	.1086	.1463
17	.1629	.1802	.104	.128	.1509	.1054	.1629
18	.1612	.1311	.16	.1417	.1696	.1187	.1629
19	.1791	.1646	.1187	.1629	.1696	.12	.1791
20	.1772	.181	.1448	.1772	.1715	.1612	.181
21	.1612	.1478	.1294	.181	.1543	.1463	.1629
22	.1417	.1294	.1109	.1829	.1402	.128	.1463
23	.1417	.1097	.0924	.1629	.1063	.0914	.1086
24	.1086	.1372	.0905	.0724	.104	.0886	.0747
Max	.1829	.181	.2103	.2353	.1791	.1829	.2054
Min	.0709	.08	.0716	.0716	.0848	.0701	.0724
Avg	.1351	.1319	.1264	.1351	.1275	.1240	.1354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.5801	.9717	.6962	.1097	.1143	.0686
2	.1143	.503	.9282	.6706	.1086	.1143	.0686
3	.0953	.503	.9282	.6706	.1143	.1143	.0678
4	.0953	.8383	.9717	.7209	.128	.1334	.0867
5	.1143	1.0898	1.0486	.7956	.132	.1524	.1029
6	.1524	1.3413	1.5257	1.0395	.132	.1715	.1357
7	.1905	.1905	.1715	1.326	.1753	.1905	.1526
8	.1524	.1524	.1387	1.4255	.1772	.1715	.1402
9	.1524	.0895	.1433	1.5623	.1254	.2126	.1715
10	.1524	.1086	.1433	1.2574	.9503	1.2403	.7459
11	.1524	.1017	.1448	1.531	1.4918	1.406	1.4251
12	.1334	.104	.1829	1.4842	.9995	1.4661	1.406
13	.1334	.056	.1448	1.3413	1.3603	1.3435	1.5249
14	.1334		.1646	1.8073	1.647	1.2226	1.5261
15	.1334		.1448	1.3889	1.5074	1.2403	1.4083
16	.1334		.1646	1.2651	.9503	1.4232	1.5927
17	.1334	.128	.1448	1.1336	1.1934	1.2597	1.5249
18	.1524	.1086	.0886	.1875	.1715	.0905	.1524
19	.1905	.1402	.1254	.1543	.1905	.1029	.1905
20	.1905	.1543	.1715	.1595	.1905	.1326	.1715
21	.6706	.9054	.1402	.1402	.1715	.1187	.1715
22	.6706	1.0608	.1227	.1417	.1715	.1029	.1524
23	.6783	1.0159	.1029	.1086	.1524	.0678	.1334
24	.1334	.6706	.9717	.7293	.1097	.1334	.0686
Max	.6783	1.3413	1.5257	1.8073	1.647	1.4661	1.5927
Min	.0953	.056	.0886	.1086	.1086	.0678	.0678
Avg	.2072	.4687	.4077	.9057	.5192	.5302	.5495



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.8855		.6173	.1494		
2	.112	.8802		.6249	.1509		
3	.112	.9393		.6478	.1509		
4	.132	1.3108		.7773	.1886		
5	.1698	1.8233		.9069	.2075		
6	.2263	2.079		1.065	.2263		
7	.2402			1.5565	.2218		
8	.1753			1.4746			
9				1.4746			
10				1.0883			
11				1.6385			
12			.1417				
13			.1214				
14			.124				1.6385
15							2.4356
16			.1463				2.0645
17			.1402				2.0805
18			.1463				.1134
19							.1791
20							.2454
21							.2149
22							.181
23							.1433
24	.112	.8749	.7164	.6173	.1494	.1829	
Max	.2402	2.079	.7164	1.6385	.2263	.1829	2.4356
Min	.112	.8749	.1214	.6173	.1494	.1829	.1134
Avg	.1546	1.2561	.2195	1.0408	.1806	.1829	.9296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2778			.2075	.4744		
2	.2915	.1848		.2075	.4744		
3	.2915	.2241		.2075	.4744		
4	.4049			.2641	.6478		
5	.503	.3018		.2829	.9175		
6	.6344	.3772		.3395	1.1736		
7	.3658			.2926	1.2431		
8	.4374			.3658			
9				.3292			
10			.7773	.1612			.1848
11			1.1603	.156			.1646
12			1.0402				.1629
13			.9831				.1417
14			1.065				.1372
15			1.1142				.2149
16							.2347
17			.9686				.1833
18			.1829				.1578
19							.1867
20							.2195
21							.2401
22							.2454
23							.2126
24	.2778	.1829	.1848	.2054	.4744	.6299	
Max	.6344	.3772	1.1603	.3658	1.2431	.6299	.2454
Min	.2778	.1829	.1829	.156	.4744	.6299	.1372
Avg	.3871	.2542	.8307	.2516	.7350	.6299	.1919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932			.1067	.463		
2	.3887	.1294		.1372	.463		
3	.4096	.1494		.1448	.4858		
4	.421	.1886		.1829	.6882		
5	.4744	.2452		.2075	.9555		
6	.6104	.2987		.3018	1.0774		
7	.1612			.2378	1.576		
8	.6478			.1829			
9				.2012			
10			.8848	.1294			.1094
11			1.2431	.1109			.096
12			1.2955				.0983
13			1.2289				.0829
14			1.4746				.0943
15			1.4091				.1254
16			1.2955				.104
17			1.1203				.1187
18			.1463				.1326
19							.1677
20							.2229
21							.1734
22							.1646
23							.1448
24	.3887		.1848	.1067	.463	.5636	
Max	.6478	.2987	1.4746	.3018	1.576	.5636	.2229
Min	.1612	.1294	.1463	.1067	.463	.5636	.0829
Avg	.4328	.2023	1.0283	.1708	.7715	.5636	.1311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1294		.0914	.128		
2	.1097	.1109		.0914	.128		
3	.1109	.1097		.0934	.1294		
4	.1307	.1494		.1307	.1463		
5	.168	.1867		.1867	.1848		
6	.1829	.2452		.2241	.2195		
7	.1829			.2012	.2195		
8	.1463			.1829			
9				.1663			
10				.128			.1372
11				.1254			.1254
12							.1387
13							.128
14			.128				.0895
15			.1097				.1075
16			.124				.0926
17			.1463				.096
18			.1463				.1134
19							.16
20							.1943
21							.1619
22							.128
23							.1006
24	.1097	.128	.1646	.0914	.128	.1294	
Max	.1829	.2452	.1646	.2241	.2195	.1294	.1943
Min	.1097	.1097	.1097	.0914	.128	.1294	.0895
Avg	.1390	.1513	.1365	.1427	.1604	.1294	.1267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2987		.3018	.2743		
2	.3018	.2987		.3018	.2743		
3	.3018	.3361		.3018	.2743		
4	.3772	.415		.3395	.3696		
5	.415	.4527		.415	.4668		
6		.5658		.5281	.5658		
7	.5658			.5601	.5847		
8	.3734			.5228			
9				.4108			
10			.2772	.2772			.3326
11			.2926	.2195			.2926
12			.2686				.2801
13			.2715				.2218
14			.2896				.2012
15			.2743				.2195
16			.2835				.1991
17			.3109				.2507
18			.2926				.3086
19							.4477
20							.5258
21							.5014
22							.4024
23							.2896
24	.3018	.3206	.2987	.3018	.2743	.3395	
Max	.5658	.5658	.3109	.5601	.5847	.3395	.5258
Min	.3018	.2987	.2686	.2195	.2743	.3395	.1991
Avg	.3673	.3839	.2860	.3734	.3855	.3395	.3195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0987		.1067	.1311		
2	.0823	.1014		.1067	.125		
3	.0834	.1158		.1067	.125		
4	.1143	.1337		.1296	.1406		
5	.1486	.1524		.1429	.1619		
6	.1829	.208		.1739	.1844		
7	.1739			.1656	.1907		
8	.108			.1429			
9				.1355			
10			.0995	.1097			.0814
11			.084	.084			.0827
12			.0874				.0975
13			.0838				.088
14			.0899				.0754
15			.0914				.0657
16			.1063				.5571
17			.0909				.0995
18			.1063				.1105
19							.1143
20							.1257
21							.1105
22							.1132
23							.1067
24	.0823	.1067		.1067	.1311	.1189	
Max	.1829	.208	.1063	.1739	.1907	.1189	.5571
Min	.0823	.0987	.0838	.084	.125	.1189	.0657
Avg	.1179	.1310	.0933	.1259	.1487	.1189	.1306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.2713		.3932	.0549		
2	.037	.2683		.3887	.0549		
3	.0366	.2591		.3978	.0549		
4	.1097	.3647		.4973	.0732		
5		.663		.4915	.0914		
6		.779		.4915	.1097		
7				.7125	.0914		
8				.7537			
9				.8192			
10				.6554			
11				.8848			
13							.9335
14							1.1883
15							1.166
16							1.1361
17							1.0288
18							.112
19							.1463
20							.1612
21							.1646
22							.1254
23							.0914
24	.0549	.2915	.9774	.3932	.0549	.0549	
Max	.1097	.779	.9774	.8848	.1097	.0549	1.1883
Min	.0366	.2591	.9774	.3887	.0549	.0549	.0914
Avg	.0550	.4138	.9774	.5732	.0732	.0549	.5685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9189	.1143	.0953	.1143	.9036	.9816	1.0498
2	.9036	.1143	.0953	.1143	.8859	1.0056	1.0029
3	.9036	.1143	.0953	.1143	.9134	1.0631	1.0208
4	.929	.1143	.0953	.1143	.8939	1.0808	1.1163
5	1.0454	.1143	.0953	.1143	1.0341	1.2269	1.2536
6	1.1283	.1334	.1524	.1334	1.4148	1.3432	1.4815
7	.1143	.1524	.1524	.1143	1.4815	1.7193	1.4842
8	1.3112	1.1041	.1334	.1524	1.258	1.6297	1.5223
9	1.3969	1.4842	.1143	.1334	1.3003	1.5402	1.5023
10	1.4198	1.5257	.8669	.1143	.1143	.1143	.1143
11	1.382	1.5592	1.7372	.1334	.1334	.1143	.0953
12	1.3969	1.5769	1.858	.1143	.1334	.0953	.0953
13	1.3146	1.4746	1.7511	.1143	.1143	.0953	.0953
14	1.3672	1.4723	1.6832	.1143	.1143	.0953	.1143
15	1.4352	1.5384	1.6832	.1143	.1143	.0953	.1143
16	.1143	.0953	1.4548	.0953	.1143	.0953	.0953
17	.1143	.0762	1.4864	.0953	.1143	.0762	.0953
18	.0953	.0953	.1143	.1143	.1143	.0953	.0953
19	.0762		.1524	.1524	.1334	.0762	.1143
20	.1143	.1524	.1524		.1524	.1334	.1715
21	.1334	.1524	.1334	.1334	.1524	.1334	.1715
22	.1334	.1334	.1334	.1143	.1143	.1143	.1524
23	.1143	.1143	.1334	.1143	.1143	.1143	.1334
24	.9114	.1143	.1143	.1143	.8145	1.0029	1.0208
Max	1.4352	1.5769	1.858	.1524	1.4815	1.7193	1.5223
Min	.0762	.0762	.0953	.0953	.1143	.0762	.0953
Avg	.7822	.5881	.6035	.1193	.5264	.5851	.5880



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.8596	.9922	.7459	.1143	.1143	.1143
2	.0953	.8682	.9671	.78	.0953	.1143	.1143
3	.0953	.8682	.9465	.7373	.0953	.0953	.0953
4	.0953	.9134	.9955	.7545	.0953	.0953	.1143
5	.1143	.9774	.9922	.8063	.1143	.1143	.1143
6	.1143	1.1765	1.0608	.9671	.1143	.1334	.1334
7	.1334	.1334	.1334	1.0534	.1524	.1524	.1524
8	.1334	.1143	.1334	.7964	.1334	.1524	.1524
9	.1143	.1143	.1143	.7716	.1143	.1334	.1334
10	.1143	.1143	.1143	.6133	.7373	.8238	.9816
11	.1143		.1334	1.0498	1.3394	1.182	1.0387
12	.1143		.1334	1.0692	1.3496	1.4118	1.5769
13			.1524	1.2178	1.2757	1.4118	1.5402
14	.0953	.1334	.1524	1.1041	1.1694	1.2178	1.4685
15	.0953	.1334	.1334	.9391	1.1041	.9922	1.1218
16	.0953	.1334	.1334	.9745	1.0692	.9816	1.0631
17	.1143	.1143	.1143	.8669	1.0242	1.0498	.9816
18	.0953	.1334	.1334	.1143	.1143	.1334	.1143
19	.1143	.1334	.1524	.1143	.1143	.1334	.1334
20	.1715	.1334	.1715	.1334	.1334	.1715	.1524
21	.815	.7537	.1715	.1334	.1143	.1715	.1524
22	.9991	1.0566	.1334	.1143	.1143	.1715	.1524
23	.9922	.9955	.1334	.1143	.1334	.1524	.1334
24	.1143	.9568	.9922	.788	.1143	.1334	.1334
Max	.9991	1.1765	1.0608	1.2178	1.3496	1.4118	1.5769
Min	.0953	.1143	.1143	.1143	.0953	.0953	.0953
Avg	.2198	.5151	.3871	.6983	.4557	.4685	.4945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,  
Dighanchi Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.0762	.0953	.0953	.5201	.6379	.7842
2	.7133	.0762	.0762	.0953	.5194	.6516	.7577
3	.7282	.0762	.0762	.0953	.5194	.6588	.7499
4	.7207	.0762	.0762	.0953	.5083	.7164	.8501
5	.7947	.0953	.0953	.0953	.5548	.7888	1.0269
6	.8962	.1143	.1334	.1143	.8145	.9134	1.226
7	.0953	.1334	.1143	.1334	.9492	1.2308	1.251
8	1.086	.8501	.1143	.1334		1.1871	1.2752
9	1.1706	1.2254	.0953	.1143		1.0679	1.2254
10	1.2803	1.0454	.5194	.1143		.0953	.1143
11	1.2012	1.0341	1.262	.1143	.0762	.0953	.0953
12	1.1523	1.0692	1.3672	.1143	.0953	.0953	.0762
13	1.1576	1.0387	1.2757	.1143	.0953	.0762	.0762
14	1.1643	.9709	1.1317	.0953	.0953	.0762	.0953
15	1.2012	1.0454	1.1744	.1143	.1143	.0762	.0953
16	.0953	.0953	.9922	.0953	.1143	.0953	.0762
17	.0762	.0953	1.0208	.0762	.0953	.0572	.0953
18	.0572	.1143	.1143	.1143	.1143	.0762	.0953
19	.0572	.1143	.1334	.1334	.1143	.0572	.0762
20	.0953	.1334	.1334	.1334	.1334	.0953	.1143
21	.1143	.1334	.1334	.1334	.1143	.1143	.1143
22	.0953	.1143	.1143	.1143	.1143	.0953	.1143
23	.0953	.1143	.0953	.0953	.0953	.0953	.0953
24	.7207	.0762	.0953	.1143	.4607	.6068	.7577
Max	1.2803	1.2254	1.3672	.1334	.9492	1.2308	1.2752
Min	.0572	.0762	.0762	.0762	.0762	.0572	.0762
Avg	.6443	.4132	.4350	.1104	.2961	.4025	.4682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0934	.1214	.1294	.1097	.1227	.0943
2	.0739	.0739	.1029	.1214	.1006	.1097	.0934
3	.0747	.0747	.1063	.0983	.081	.0838	.0934
4	.0934	.9619	.0838	.0848	.0886	.0867	.0924
5	.1132	.132	.104	.104	.0857	.0819	.1307
6	.1509	.1132	.1433	.1417	.1463	.1448	.1698
7	.1663	.1463	.2263	.2241	.2054	.1829	.1494
8	.112	.128	.1646	.181	.1629	.1509	.1109
9	.0895	.0716	.1254	.1478	.1097	.1227	.0867
10	.0867	.0549	.0924	.0876	.1052	.1063	.0701
11	.0701		.0724	.0686	.0905	.0709	.0709
12	.0532	.0537	.0701	.0905	.0693	.0347	.0716
13	.0709	.0724	.0686	.0732	.0716	.0526	.0724
14	.0716	.1029	.0819	.052	.0686	.0686	.0532
15	.0895	.0876	.0838	.0671	.0876	.0671	.0537
16	.0876	.0914	.0693	.0686	.0905	.052	.0537
17	.0886	.0934	.0716	.0709	.0867	.0655	.0532
18	.0693	.1086	.1097	.0867	.0724	.0876	.0867
19	.1063	.1848	.1772	.1294	.1227	.1267	.124
20	.1294	.2263	.1907	.2427	.1848	.1848	.1646
21	.1307	.197	.2241	.197	.197	.1867	.168
22	.1132	.1646	.181	.1387	.1646	.1663	.1509
23	.0943	.1494	.1663	.1448	.1402	.1307	.0943
24	.0943	.0943	.1267	.1227	.1214	.1254	.1132
Max	.1663	.9619	.2263	.2427	.2054	.1867	.1698
Min	.0532	.0537	.0686	.052	.0686	.0347	.0532
Avg	.0967	.1511	.1235	.1197	.1151	.1088	.1009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4883	.1294	.1357	.2195	2.2283	1.6278	1.7833
2	1.4327	.1294	.1357	.2149	2.1548	1.6278	1.8991
3	1.4506	.1463	.1357	.2454	2.2085	1.8107	2.0008
4	1.5384	.1629	.1372	.1829	2.2939	1.8778	2.1365
5	1.8604	.1949	.1372	.197	2.332	1.9227	2.1605
6	2.1735	.3155	.1372	.208	3.1047	1.989	2.6749
7	.3366	.2947	.2149	.1715	2.8988	2.6155	2.8487
8	1.7337	1.9839		.2614		2.7808	3.0521
9	2.6452	2.8837	.208	.2926	.2321	2.5484	2.9508
10	2.934	3.0333	.583	.2507	.2743	.2058	.2926
11	2.2708	3.315	2.9492	.2195	.1357	.2058	.2401
12	2.3205	2.9508	3.2819	.2378	.1357	.2058	.2012
13	2.1628	2.9508	3.1131	.1829	.1357	.2058	.1791
14	2.1216	2.713	3.2156	.1791	.1357	.1357	.1829
15	2.2801	2.6452	3.4568	.1991	.1357	.1357	.197
16	.1029	.2058	3.219	.2378	.1357	.1372	.1907
17	.1387	.2103	3.1327	.2507	.2012	.1372	.2561
18	.1928	.2103	.181	.3403	.2035	.2103	.2743
19	.2481	.2103		.2561	.1052	.2126	.3045
20	.2865	.2103	.2915	.3045	.2149	.2149	.3292
21	.2353	.2058		.8413	.2149	.2149	
22	.2012	.2058	.2401	.3045	.2172	.1448	
23	.1829	.1357		.7209	.2743	1.4922	
24	1.4883	.1478		.2561	1.8884	1.3413	1.5927
Max	2.934	3.315	3.4568	.8413	3.1047	2.7808	3.0521
Min	.1029	.1294	.1357	.1715	.1052	.1357	.1791
Avg	1.3261	1.0663	1.3108	.2823	.9505	1.0000	1.2261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	1.5223	1.3565	1.5089	.3109	.1753	.1372
2	.1478	1.4352	1.4243	1.278	.2172	.1753	.1372
3	.1294	1.4352	1.4922	1.7551	.2058	.1715	.1372
4	.1463	1.5249	1.749	1.5729	.2401	.2058	.1715
5	.1991	1.6124	1.9204	1.5581	.333	.2058	.1715
6	.2686	1.9719	2.0348	1.5074	.2743	.2401	.2058
7	.2658	.2427	.2149	1.6766	.2743	.2058	.2374
8	.1907	.1543	.1753	1.8442		.1753	.1715
9	.1715	.1696	.1387	1.6575	.2149	.1696	.1543
10	.1187	.1509	.1543	.663	.9831	1.0608	1.6575
11	.1174	.1509	.1886	1.8652	1.4918	1.5581	2.13
12	.1174	.1357	.1772	2.0233	1.989	1.9662	2.0972
13	.0995	.1357	.1829	1.8679	1.9227	2.2874	2.0553
14	.0995	.1372	.1612	1.989	1.8896	2.0553	1.9662
15	.1006	.1372	.1372	1.9334	1.7695	1.9559	1.9547
16	.12	.1372	.1612	1.9547	1.704	1.8564	1.9334
17	.1214	.1372	.1791	1.8023	1.6244	1.757	1.9559
18	.1402	.1402	.1646	.1715	.1696	.1753	.1715
19	.1595	.1753	.6935	.2197	.2103	.1772	.2507
20	.197	.1753		.2507	.2507	.2658	.2926
21	1.4022	1.3375	.2035	.2561	.1791	.2126	
22	1.6301	1.6278		.2195	.181	.181	
23	1.6478	1.5424	.1715	.2686	.181	.181	
24	.1646	1.5581	1.3748	1.4746	.1829	.1753	.1448
Max	1.6478	1.9719	2.0348	2.0233	1.989	2.2874	2.13
Min	.0995	.1357	.1372	.1715	.1696	.1696	.1372
Avg	.3292	.7395	.6571	1.3049	.7304	.7329	.8635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1478	.1029	.1097	.1791	.1227	.1448
2	.1109	.1494	.1029	.1254	.1928	.1052	.1238
3	.0924	.1307	.1029	.3506	.1829	.1029	.1372
4	.128	.1663	.12	.2012	.1612	.12	.1715
5	.181	.2012	.1372	.1791	.2915	.1372	.1715
6	.197	.2353	.1886	.2427	.2427	.1886	.2229
7	.2481	.2279	.1791	.2279	.2229	.2279	.2374
8	.156	.2229	.2103	.1829		.2629	.1372
9	.1715	.2204	.2427	.1543		.1865	.1543
10	.1357	.1677	.197	.1907	.2058	.1715	.1734
11	.1341	.1341	.12	.1715	.12	.1372	.1715
12	.1174	.1526	.104	.1417	.1029	.1372	.1063
13	.116	.1187	.2058	.0914	.0857	.1372	.0895
14	.116	.1029	.2254	.0716	.0686	.1029	.0867
15	.1006	.1029	.2401		.0857	.1029	.1029
16	.1029	.12	.2054	.104	.0857	.12	.1772
17	.1227	.1402	.2103	.1646	.1187	.1543	.1734
18	.1578	.1753	.1886	.2401	.2204	.1753	.2058
19	.2126	.2454	.2401	.2804	.1227	.2126	.1734
20	.2149	.2103	.2641	.3258	.2149	.2149	.1143
21	.1991	.1715	.2172	.2743	.1629	.2149	
22	.1646	.1372	.2401	.3155	.1448	.181	
23	.1646	.1372		.176	.1448	.1629	
24	.1097	.1663	.1187	.104	.2865	.1267	.1372
Max	.2481	.2454	.2641	.3506	.2915	.2629	.2374
Min	.0924	.1029	.1029	.0716	.0686	.1029	.0867
Avg	.1485	.1660	.1810	.1924	.1656	.1586	.1530

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1663	.1372	.2195	.208	.1753	.1753
2	.1848	.1494	.1372	.2507	.1715	.1578	.1753
3	.1663	.1494	.1372	.1715	.1928	.1543	.1867
4	.2012	.1646	.1715	.1715	.2454	.1715	.2058
5	.2534	.1991	.1715	.2012	.2774	.2058	.0171
6	.3012	.7619	.2058	.1791	.2058	.2401	.2743
7	.2804	.2427	.2507	.2058	.2058	.2629	.2987
8	.208	.2229	.2454	.1734	.2454	.2804	.2058
9	.2058	.1696	.2427	.2195	.2058	.2713	.2926
10	.1696	.1341	.2058	.2507	.2507	.2401	.2507
11	.1509		.2561	.1715	.2058	.2058	.2058
12	.1509	.1696	.1907	.2012	.1715	.2058	.2378
13	.1492	.1696	.1543	.2561	.1372	.2058	.2149
14	.1326	.1715	.2054	.1791	.1372	.1715	.1734
15	.1677	.1715	.1715		.1372	.1715	.2058
16	.1543	.1715	.2126	.2012	.1372	.1715	.1772
17	.156	.2103	.2378	.2328	.1696	.1715	.0351
18	.1928	.2103	.2149	.1886	.1696	.2103	.2865
19	.2303	.2804	.2926	.2743	.2103	.2481	.2427
20	.2149	.2454	.2561	.333	.2507	.2507	.2804
21	.3077	.2058	.2507	.3292	.2896	.2507	
22	.2743	.1715	.2601	.2561	.2172	.2172	
23	.2195	.1715	.2561	.2743	.2172	.181	
24	.2195	.1848	.1526	.2427	.2401	.181	.1715
Max	.3077	.7619	.2926	.333	.2896	.2804	.2987
Min	.1326	.1341	.1372	.1715	.1372	.1543	.0171
Avg	.2031	.2128	.2090	.2253	.2041	.2084	.2054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.7459
Max	.7459
Min	.7459
Avg	.7459



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
23	2.1091
24	1.0852
Max	2.1091
Min	1.0852
Avg	1.5972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	1.448
Max	1.448
Min	1.448
Avg	1.448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
23	1.5432
24	2.3148
Max	2.3148
Min	1.5432
Avg	1.929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 406 / 110 KV SADGURU SUGAR  
FACTORY C Feeder KV- 132 /  
OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUL-18
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.2949	.2486	.2572	.0905	.0886	.0686
2	.1075	.2949	.2321	.2629	.0876	.0895	.0701
3	.0905	.2949	.2321	.2572	.0886	.0895	.0686
4	.0886	.3113	.2652	.2915	.0872	.0895	.0876
5	.1097	.3277	.2652	.3429	.124	.0895	.0857
6	.1612	.9339	.6796	.4409	.1791	.1772	.1715
7	.2279	.2058	.6962	.5765	.2126	.1949	.2103
8	.1543	.2058	.5898	.6859	.1578	.1753	.1886
9	.1214	.1029	.4588	.6859	.1595	.1052	.12
10	.1029	.0857	.0857	.4144	.4915	.4409	.4144
11	.0848	.1029	.0857	.5461	.6964	.5087	.4752
12	.0678	.1029	.0857	.6062	.5668	.6687	.5304
13	.0848	.1029	.0857	.7042	.3563		.5365
14	.1029	.1029	.0848	.6882	.4372		.3647
15	.1017	.1029	.0838	.6796	.4534		.3374
16	.1017	.12	.0838	.6539	.4961		.3745
17	.104	.1372	.12	.0857	.502	.3561	.4641
18	.1214	.1372	.1357	.1214	.1029	.1341	.12
19	.1578	.1543	.1526	.1372	.1052	.1677	.1696
20	.2103	.1715	.1715	.1791	.1753	.1696	.1844
21	.5571	.4359	.1715	.1595	.1578	.1357	.1543
22	.4424	.3688	.1543	.1227	.1227	.12	.112
23	.3605	.2652		.0886	.1063	.0857	.1086
24	.124	.2949	.2486	.2543	.0857	.0886	.0686
Max	.5571	.9339	.6962	.7042	.6964	.6687	.5365
Min	.0678	.0857	.0838	.0857	.0857	.0857	.0686
Avg	.1622	.2357	.2355	.3851	.2518	.1988	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.0876	.0857	.0848	.192	.1802	.2347
2	.2686	.0876	.0857	.0838	.1966	.1638	.2321
3	.2572	.0876	.0857	.0848	.2515	.1638	.2374
4	.2321	.0876	.0857	.0838	.2458	.1802	.2543
5	.208	.1052	.0857	.1017	.2915	.1966	.2204
6	.3239	.1214	.12	.1372	.4111	.3768	.3391
7	.1509	.1372	.1543	.1696	.5868	.5735	.5087
8	.3149	.3647	.12	.1341	.5156	.4588	.5087
9	.3932	.4096	.12	.1017	.3429	.4424	.5087
10	.4588	.4096	.39	.0686	.1341	.0678	.1029
11	.3932	.4424	.4409	.0671	.0671	.0678	.1097
12	.426	.4588	.4578	.0848	.0671	.0678	.1214
13	.2818	.4588	.4917	.0671	.0671		.0857
14	.2984	.3932	.4917	.0663	.0671		.1187
15	.3605	.3932	.4917	.0693	.1006		.1214
16	.0857	.0857	.373	.0857	.0838		.12
17	.0686	.0857	.407	.0791	.0838	.1187	.1543
18	.0686	.0857	.1017	.1029	.1017	.1357	.1326
19	.0857	.12	.1017	.1029	.1187	.1526	.1357
20	.1214	.1372	.1017	.1387	.1372	.1526	.156
21	.1214	.1029	.1017	.1227	.1372	.1543	.1578
22	.104	.1029	.1187	.104	.12	.1357	.1417
23	.0876	.0857		.2204	.1029	.1357	.1227
24		.0876	.0857	.0838	.2012	.1802	.2374
Max	.4588	.4588	.4917	.2204	.5868	.5735	.5087
Min	.0686	.0857	.0857	.0663	.0671	.0678	.0857
Avg	.2345	.2057	.2216	.1019	.1926	.2053	.2109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.1052	.0686	.0678	.3353	.3113	.39
2	.4409	.1052	.0686	.0671	.373	.2949	.3856
3	.4191	.1052	.0686	.0678	.3932	.2949	.3856
4	.4409	.1052	.0686	.0838	.4534	.2949	.39
5	.3647	.1052	.0857	.0848	.4801	.2949	.4239
6	.5079	.1227	.1029	.1006	.5441	.4424	.4917
7	.1174	.1214	.1543	.1509	.7537	.639	.7377
8	.5407	.4973	.1372	.1357	.6836	.7701	
9	.6906	.7373	.1372	.1187	.6401	.7373	.5765
10	.6062	.7865	.5596	.0914	.0848	.1187	.1086
11	.639	.5243	.8383	.0857	.0848	.1174	.0716
12	.639	.7537	.8478	.1029	.1017	.1174	.0876
13	.7373	.8848	.7712	.1223	.0838		.0972
14	.3978	.5571	.7461	.1029	.0838		.0983
15	.5304	.6226	.7209	.116	.0838		.0857
16	.0509	.0686	.6952		.0838		.0838
17	.0686	.0686	.6613	.1187	.1017	.1017	.096
18	.0857	.1029	.1017		.1187	.1006	.1006
19	.1029	.1029	.1006		.1187	.1017	.0876
20	.1387	.12	.1187	.1183	.1372	.1174	.12
21	.1214	.1029	.1174	.1174	.12	.1017	.1052
22	.1214	.1029	.0848	.0848	.12	.2374	.0838
23	.104	.1029		.3481	.12	.1865	.1017
24	.4578	.1052	.0686	.0678	.3481	.3113	.39
Max	.7373	.8848	.8478	.3481	.7537	.7701	.7377
Min	.0509	.0686	.0686	.0671	.0838	.1006	.0716
Avg	.3643	.2921	.3184	.1121	.2686	.2846	.2391



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.1772	.1578	.1844	.2126	.1753	.1677
2	.2101	.1772	.1578	.1865	.1886	.1753	.1715
3	.1928	.1772	.1578	.2035	.1715	.1595	.1715
4	.1928	.1772	.1753	.2229	.2261	.1595	.1677
5	.1909	.1928	.1928	.2572	.2629	.1772	.1696
6	.3155	.4382	.2629	.3052	.3189	.333	.3052
7	.4115	.4557	.3856	.4359	.3856	.4382	.407
8	.3814	.333	.3681	.3391	.3641	.3856	.3353
9	.3117	.3121	.3681	.2883	.2572	.3467	.3222
10	.2401	.2774	.2572	.2743	.2229	.2543	.2401
11	.2229	.208	.2572	.2507	.2374	.2035	.208
12	.2035	.2427	.2035	.1715	.2058	.1844	.2058
13	.2035	.2427	.2012	.206	.1696		.1734
14	.2374	.2427	.2035	.2601	.2374		.1886
15	.2204	.2427	.2012	.2743			.2058
16	.2374	.2774	.2543	.2774	.1696		.2229
17	.2035	.3155	.2543		.2713	.2374	.2601
18	.2572	.298	.2543	.2303	.2915	.2883	.3155
19	.2915	.333	.3018		.2915	.3391	.3258
20	.3814	.3856	.3561	.3772	.3467	.3772	.3761
21	.3294	.333	.3391	.3155	.3121	.2883	.2983
22	.3155	.2454	.2915	.2572	.2629		.2401
23	.2103	.2103		.1949	.2103		.2603
24	.2281	.1753	.1578	.1865	.1928	.1753	.1696
Max	.4115	.4557	.3856	.4359	.3856	.4382	.407
Min	.1909	.1753	.1578	.1715	.1696	.1595	.1677
Avg	.2584	.2696	.2504	.2590	.2526	.2610	.2462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1075	.1029	.0848	.104	.1075	.0857
2	.0886	.1075	.1029	.0857	.0886	.1075	.0701
3	.0895	.1075	.1029	.0876	.0876	.1075	.0701
4	.0905	.1075	.1029	.1052	.1029	.1075	.0701
5	.0914	.1063	.1029	.12	.1223	.1075	.0686
6	.1629	.1578	.1543		.1417	.1417	.1187
7	.1928	.1928	.2229	.1886	.1928	.1949	.1715
8	.1949	.1578	.1372	.1865	.1715	.1928	.1696
9	.1402	.1734	.1543	.1715	.1372	.1928	.1543
10	.1214	.156	.1715	.1646	.1187	.1341	.1214
11	.1543	.156	.1715	.156	.1017	.1509	.1214
12	.1372	.1734	.1543	.1543	.1696	.1526	.12
13	.0857	.1734	.1372	.1372	.1187		.1214
14	.0848	.104	.1341	.1214	.1017		.1097
15	.1017	.104	.1187	.1214	.1006		.0857
16	.0686	.1214	.1029	.12	.0678		.104
17	.0857	.12	.12	.1214	.1187	.1029	.1029
18	.0857	.12	.1187	.12	.1029	.1357	.1387
19	.1372	.1372	.1677	.1214	.1372	.2058	.156
20	.1753	.1372	.2035	.1772	.2103	.1844	.1663
21	.1753	.1715	.1865	.1578	.2103	.1696	.1433
22	.1578	.1715	.1543	.1417	.1578	.1677	.124
23	.124	.12		.1063	.124	.1006	.1052
24	.1214	.1063	.1029	.1029	.1052	.1063	.0857
Max	.1949	.1928	.2229	.1886	.2103	.2058	.1715
Min	.0686	.104	.1029	.0848	.0678	.1006	.0686
Avg	.1238	.1371	.1403	.1328	.1289	.1435	.1160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0358	.0526	.0339	.0351	.0177	.0335
2	.0179	.0179	.0351	.0339	.0179	.0177	.0339
3	.0181	.0179	.0351	.0339	.0177	.0179	.0335
4	.0358	.0179	.0351	.0335	.0359	.0179	.0339
5	.0543	.0354	.0526	.0503	.0549	.0354	.0335
6	.0549	.0532	.0876	.0848	.0716	.0526	.0509
7	.0724	.0876	.1052	.1017	.0709	.0701	.0678
8	.0709	.0701	.1052	.1017	.0693	.0876	.0678
9	.0693	.0701	.0876	.0838	.0514	.0693	.0678
10	.0347	.0701	.0678	.0678	.0514	.0509	.0514
11	.0686	.0701	.0509	.0686	.0339	.0339	.052
12	.0343	.0701	.0509	.0693	.0339	.0339	.0701
13	.0343	.0701	.0509	.0532	.0339		.0693
14	.0343	.0701	.0509	.052	.0339		.0701
15	.0343	.0701	.0509	.0532	.0335		.0514
16	.0343	.0701	.0509	.052	.0339		.0693
17	.0347	.0701	.0509	.052	.0339	.0339	.0686
18	.052	.0876	.0509	.0686	.0509	.0509	.0686
19	.0701	.1227	.0678	.104	.0686	.0678	.124
20	.0876	.1227	.0848	.1254	.0867	.0848	.1052
21	.0886	.1052	.0848	.1063	.0867	.0678	.0886
22	.0709	.0876	.0678	.0701	.0526	.0509	.0693
23	.0532	.0701		.0532	.0351	.0339	.0702
24	.0358	.0354	.0526	.0339	.0354	.0351	.0339
Max	.0886	.1227	.1052	.1254	.0867	.0876	.124
Min	.0179	.0179	.0351	.0335	.0177	.0177	.0335
Avg	.0499	.0666	.0621	.0661	.0470	.0465	.0619

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2818	.1844	.2103	.1433	.1372	.1402
2	.2347	.2622	.1823	.2103	.124	.1227	.12
3	.2515	.2622	.1823	.2103	.124	.12	.1187
4	.2486	.2622	.1844	.2103	.1417	.1357	.1357
5	.3018	.3353	.213	.218	.2103	.1844	.1844
6	.7459	.7888	.5533	.4144	.3109	.3052	.3222
7	.4298	.3366	.6962	.5735		.3772	.3258
8	.2454	.2279	.5596	.6371	.2715	.2713	.2279
9	.2035	.1928	.4801	.6371	.2279	.218	.2103
10	.1341	.1772	.1715	.2427		.3149	.2401
11	.1326	.1543	.1715	.4359		.7377	.3222
12	.1578	.1753	.168	.3772		.5468	.3681
13	.1578	.1907	.1715	.4096		.6443	.3953
14	.1578	.1907	.1715	.3688		.39	.3637
15	.1402	.1509	.1463	.4588		.4694	.4801
16	.1791	.1526	.1772	.4424		.6464	.5281
17	.2172	.2103	.2096	.4424	.547	.57	.5281
18	.1991	.2035	.2096	.1753	.2035	.2103	.1595
19	.2378	.2667	.2587	.2172	.2279	.2328	.2427
20	.3174	.3048	.3239	.2987	.2865	.2534	.2987
21	.4908	.373	.2858	.2614	.2715	.2686	.2427
22	.4115	.2774	.2286	.2033	.197	.1991	.1867
23	.3429	.2126	.1524	.1629	.1629	.1433	.1307
24	.2347	.285	.1844	.2195	.1433	.1402	.1402
Max	.7459	.7888	.6962	.6371	.547	.7377	.5281
Min	.1326	.1509	.1463	.1629	.124	.12	.1187
Avg	.2668	.2615	.2611	.3349	.2246	.3183	.2672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1753	.1715	.2096	.2058	.2012	
2	.1696	.1753	.1715	.2096	.1844	.1823	
3	.1677	.1753	.1715	.2096	.1844	.1966	
4	.1658	.1753	.1715	.2096	.2347	.2321	
5	.2035	.1949	.1905	.2286	.3772	.3353	
6	.3185	.3475	.2926	.3582	.6661	.7127	
7	.4207	.4481	.4119	.4382	.8402	1.17	
8	.6783	.6706	.3761	.3391	.7209	1.1105	
9	.8383	.9069	.3429	.2804	.7045	.3978	
10	.8951	.57	.4191	.2477		.2374	.6274
11	.9724	.7956	.9503	.2172		.2058	.2229
12	.9389	.9069	.9779	.2172		.2035	.2572
13	.8987	.8648	.9339	.2149		.2058	.2427
14	.8886	.9448	1.0227	.2149			.2103
15	.6554	.9614	1.0774	.2149		.2454	.2279
16	.2058	.1886	1.0227	.2149		.2401	.2254
17	.2454	.2477	.8192	.2715	.285	.2454	.2279
18	.3045	.2587	.2229	.2328	.3429	.3045	.2481
19	.3258	.2858	.3429	.3109	.3506	.3077	.3547
20	.3921	.362	.4191	.3921	.3841	.3292	.3734
21	.3511	.3239	.381	.3734	.3224	.3258	.3174
22	.2686	.2096	.3048	.2743	.2534	.2507	.2427
23	.2328	.1715	.2286	.1949	.197	.1928	.1867
24	.1753	.1949	.1715	.2096	.2058	.2035	.2401
Max	.9724	.9614	1.0774	.4382	.8402	1.17	.6274
Min	.1658	.1715	.1715	.1949	.1844	.1823	.1867
Avg	.4535	.4398	.4831	.2618	.3800	.3494	.2803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0354	.0179	.0351	.0354	.0351	.0362
2	.0358	.0354	.0179	.0351	.0351	.0354	.0362
3	.0351	.0354	.0179	.0351	.0351	.0358	.0351
4	.0351	.0354	.0177	.0354	.0351	.0358	.0358
5	.0351	.0354	.0347	.0354	.0537	.0351	.0362
6	.0351	.0543	.0532	.0686	.0543	.0701	.0537
7	.0732	.0732	.0693	.0857	.0732	.0686	.0724
8	.0537	.0724	.0693	.0995	.0358	.0876	.0716
9	.0905	.0532	.0848	.0857	.0354	.0716	
10	.0716	.0358	.0857	.0671		.0701	.0537
11	.0701	.0701	.0857	.0671		.0716	.0526
12	.0701	.0678	.0663	.0343		.0526	.0686
13	.0526	.0678	.0848	.0671		.0537	.0686
14	.0686	.0686	.0693	.0343		.0351	.0686
15	.0503	.0526	.0838	.0514		.0537	.0514
16	.0514	.0526	.0686	.0671		.0543	.0686
17	.0514	.052	.0848	.0343	.1052	.0732	.0347
18	.0701	.0166	.0693	.0526	.0895	.0747	.0857
19	.0701	.0848	.0829	.0724	.0905	.0566	.0526
20	.0914	.0701	.0857	.0934	.0716	.0572	.0709
21	.0914	.0514	.0671	.0554	.0747	.0566	.0716
22	.0716	.0514	.052	.0543	.0762	.056	.0709
23	.0537	.052	.0354	.0537	.056	.0362	.0526
24	.0362	.0354	.0179	.0351	.0354	.0358	.0358
Max	.0914	.0848	.0857	.0995	.1052	.0876	.0857
Min	.0351	.0166	.0177	.0343	.0351	.0351	.0347
Avg	.0583	.0525	.0593	.0565	.0584	.0547	.0558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.0543	.0463	.0514	.1475	.1235	.1543
2	.1265	.0537	.0309	.0509	.1475	.1235	.1543
3	.128	.0537	.0309	.0514	.1475	.1389	.1543
4	.1265	.0543	.0463	.0514	.1802	.1543	.1543
5	.128	.0739	.0463	.052	.2267	.1543	.1698
6	.1739	.0739	.0617	.0514	.2561	.1698	.1852
7	.0509	.0739		.0509	.3563	.216	.1852
8	.2688	.2056	.0926	.0686	.2915	.216	.2315
9	.2656	.2315	.0772	.0509	.2458	.216	.2469
10	.2623	.2778	.2469	.0514	.0339	.0617	.0339
11	.3241	.3086	.3258	.0526	.0309	.0463	.0343
12		.3086	.3906	.052	.0309	.0526	.0332
13	.2623	.3549	.4687	.052	.0309	.0526	.0339
14		.3858	.4744	.0526	.0309	.0701	.0343
15	.1852	.3395	.4843	.0526	.0463	.052	.0339
16	.052	.0617	.4428	.0514	.0463	.052	.0343
17	.0347	.0463	.2187	.0509	.0463	.0617	.0509
18	.052	.0617	.0509	.052	.0463	.0693	.0514
19	.0693	.0617	.0514	.0514	.0463	.0686	.0678
20	.0693	.0617	.0678	.0693		.0686	.0686
21	.0693	.0617	.0686	.0701	.0463	.0701	.0678
22	.0724	.0617	.0509	.0693	.0463	.0709	.0678
23	.0724	.0617	.0514	.052	.0463	.0532	.0686
24	.1265	.0724	.0463	.0509	.1492	.1543	.1543
Max	.3241	.3858	.4843	.0701	.3563	.216	.2469
Min	.0347	.0463	.0309	.0509	.0309	.0463	.0332
Avg	.1384	.1417	.1683	.0546	.1164	.1048	.1030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0747	.0732	.0895	.0747	.0732	.0747
2	.0895	.0747	.0732	.0905	.0747	.0732	.0747
3	.0886	.0739	.1097	.0886	.0747	.0914	.0747
4	.0895	.0739	.128	.0895	.0747	.1097	.0747
5	.1086	.1109	.128	.1086	.1109	.1097	.112
6	.1433	.1478	.1463	.1433	.1478	.128	.1494
7	.181	.1478	.1829	.181	.1829	.1829	.1663
8	.1433	.1463	.1829	.1791	.1463	.1646	.1463
9	.1086	.1086	.1463	.1267	.1097	.1646	.1463
10	.0905	.0732	.128	.0895	.1097	.0732	.0716
11	.0895	.1097	.1267	.1097	.0732	.0724	.0724
12		.1097	.1254	.1063	.0732	.0701	.0914
13	.0895	.0914	.0724	.0905	.0732	.1075	.0905
14		.0732	.0716	.0732	.0732	.0701	.0537
15	.0724	.0732	.0895	.0724	.0732	.0701	.0543
16	.0732	.0732	.1086	.0724	.0732	.0514	.0537
17	.0709	.0732	.1086	.0905	.0732	.0716	.0905
18	.0732	.0732	.1254	.1086	.0914	.1063	.0905
19	.1267	.128	.1267	.128	.1463	.1417	.1254
20	.1478	.1829	.1433	.1463	.1463	.1663	.1448
21	.1307	.1463	.1448	.1294	.128	.1478	.1433
22	.0934	.1097	.1254	.112	.0914	.1294	.1086
23	.0747	.0914	.1086	.0747	.0732	.1109	.0724
24	.0895	.0747	.0732	.0895	.0747	.0732	.0934
Max	.181	.1829	.1829	.181	.1829	.1829	.1663
Min	.0709	.0732	.0716	.0724	.0732	.0514	.0537
Avg	.1030	.1017	.1187	.1079	.0987	.1066	.0990



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0789	.6001	.4595	.5007	.0667	.0819	.0789
2	.0754	.5681	.4595	.5075	.0707	.0838	.0895
3	.084	.5681	.4733	.5075	.1052	.08	.0895
4	.0772	.6081	.4938	.5007	.0854	.0857	.0857
5	.1046	.6859	.5007	.5792	.1132	.0983	.0876
6	.1257	.7407	.5075	.6481	.12	.1303	.1105
7	.1212	.1069	.1048	.8436	.1143	.1189	.1235
8	.1012	.0857	.0754	1.0562	.0895	.0926	.1166
9	.0674	.0627	.0686	1.2631	.1067	.096	.1029
10	.0814	.0991	.0793	1.4746	1.5912	1.6907	.7682
11	.0446	.0991	.0869	1.989	1.749	1.8679	.6241
12	.0297	.1052	.0693	1.9433	1.8679	1.9204	.6767
13	.0286	.0564	.0667	.5418	1.8461	1.989	.7922
14	.0278	.0452	.068	.5556	1.8244	1.8679	.7922
15	.0537	.0876	.0309	.7407	.3567	1.7695	.8579
16	.0145	.1006	.0823	.2258	.3475	1.6518	.8145
17	.0143	.1097	.0895	1.4403	1.4232	1.5181	.7928
18	.0789	.0838	.1029	.0874	.1052	.0737	.1029
19	.0737	.0838	.0983	.0953	.0892	.0914	.1115
20	.112	.0983	.112	.1029	.1166	.1174	.1174
21	.5424	.4938	.1212	.112	.1097	.0991	.0943
22	.6321	.5007	.1143	.0909	.0983	.0972	.0953
23	.643	.487	.0983	.0627	.0983	.0671	.0914
24	.0857	.6161	.5084	.5487	.0613	.0838	.0772
Max	.643	.7407	.5084	1.989	1.8679	1.989	.8579
Min	.0143	.0452	.0309	.0627	.0613	.0671	.0772
Avg	.1374	.2955	.2030	.6841	.5232	.6572	.3206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.2263	.3018	.3018	.3018	.2641
2	.3018	.2641	.2263	.3018	.3018	.2641	.2263
3	.2614	.2641	.2263	.2641	.3018	.2641	.2263
4	.3018	.2641	.2263	.2641	.3018	.2641	.2263
5	.3395	.3395		.3018	.3772	.3018	.2641
6	.3772	.415	.3395	.3772	.3772	.415	.3772
7	.3734	.4854	.3772	.4527	.4481	.4527	.4481
8	.4481	.4108	.4108	.4527	.4344	.3772	.4904
9	.5792	.4706	.5068	.4481	.4961	.4435	.4481
10	.5316	.5548	.4908	.5068	.394	.567	.5258
11	.6089	.4908	.5895	.5609	.3544	.5087	.4557
12	.4344	.4207	.439	.439	.3258	.3982	.3898
13	.4527	.3734	.4066	.3696	.2534	.439	.3326
14	.4908	.4298	.5068	.5014	.2534	.3982	.3326
15	.4298	.4656	.439	.4908	.2534	.431	.3429
16	.5548	.4801	.4252	.5548	.2774	.4161	.4161
17	.4344	.4854	.4252	.4344	.2481	.4252	.4607
18	.4344	.3658	.4298	.4961	.3224	.4755	.4298
19	.4656	.4961	.5175	.567	.3658	.5175	.5175
20	.5544	.4805	.5175	.5853	.4108	.5601	.4854
21	.415	.4066	.4435	.4527	.3734	.4854	.4527
22	.415	.3772	.4527	.4527	.3772	.4527	.415
23	.3772	.3395	.3772	.3772	.3018	.4527	.3772
24	.3772	.3395	.2641	.3018	.3772	.3018	.3018
Max	.6089	.5548	.5895	.5853	.4961	.567	.5258
Min	.2614	.2641	.2263	.2641	.2481	.2641	.2263
Avg	.4275	.4051	.4028	.4273	.3429	.4131	.3836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.3292	.3384	.4268	.0526	.0572	.0762
2	.0633	.3201	.3384	.4214	.0541	.0579	.0625
3	.0648	.3155	.3384	.4108	.0587	.0594	.0602
4	.0617	.3201	.3429	.4108	.064	.0594	.0602
5	.0633	.4512	.4012	.4877	.0772	.0762	.0625
6	.081	.5944	.4816	.5312	.08	.0633	.0819
7	.0617	.0695	.0808	.759	.0846	.0705	.0791
8	.061	.0638	.0594	.8749	.0812	.0705	.096
9	.0564	.0734	.0676	1.0883	.0914	.0714	.0846
10	.0503	.0834	.0657	1.1523	.8855	.8215	.4012
11	.0488	.0846	.0667	1.2803	1.2193	1.0974	.5868
12	.0564	.0846	.0823	1.5364	1.1111	1.1888	.5792
13	.0564	.048	.0907	1.5181	1.2193	1.1736	.5487
14	.0526	.0686	.0657	1.5181	1.3565	1.0562	.4938
15	.0564	.0705	.0686	1.5364	1.0974	1.0425	.5007
16	.0676	.0823	.0556	1.3748	1.0974	1.0288	.4938
17	.0667	.0812	.0772	.9633	.9633	1.0425	.3395
18	.0869	.0812	.0947	.0686	.0695	.061	.0583
19	.0724	.0686	.0869	.06	.0503	.0762	.0629
20	.0734	.0823	.0892	.0857	.0695	.0926	.0789
21	.3909	.3292	.0926	.088	.0734	.0949	.0695
22	.4755	.4633	.096	.0734	.0734	.0937	.0695
23	.4572	.4512	.0926	.0579	.0579	.0753	.0572
24	.0602	.3292	.3755	.4268	.0587	.0564	.0762
Max	.4755	.5944	.4816	1.5364	1.3565	1.1888	.5868
Min	.0488	.048	.0556	.0579	.0503	.0564	.0572
Avg	.1103	.2061	.1645	.7146	.4186	.3995	.2116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4527	.4527	.4527	.4527	.415
2	.4527	.4527	.4527	.4527	.4527	.415	.3772
3	.415	.4527	.415	.415	.3772	.415	.3772
4	.4527	.4904	.4527	.415	.4481	.415	.3772
5	.5281	.5281	.5281	.4527	.6036	.5281	.4527
6	.7167	.7545	.6036	.6036	.679	.679	.7167
7	.6036	.679	.679	.7167	.6036	.7167	.7545
8	.679	.5975	.6348	.6348	.5975	.5975	.679
9	.6722	.5658	.6722	.5975	.4481	.6516	.6653
10	.5914		.5544	.5914	.415	.6089	.6348
11	.5853	.6653	.5228	.5068	.3658	.4908	.5487
12	.4527	.4527	.4527	.4481	.2957	.4024	.4706
13	.5228	.5014	.3772	.4527	.3326	.4435	.4481
14	.5487	.5914	.4481	.5068	.2926	.5068	.4481
15	.5914	.5544	.4481	.5228	.2926	.4481	.4435
16	.5601	.5121	.5175	.4481	.3258	.3982	.4024
17	.4481	.4706	.4066	.3734	.2957	.4024	.3982
18	.4805	.4435	.4481	.5068	.362	.5228	.4527
19	.5121	.5601	.5281	.6722	.5228	.6036	.6413
20	.6413	.7167	.7167	.6722	.679	.7167	.679
21	.6036	.6413	.679	.679	.6036	.6036	.6036
22	.6036	.6036	.6036	.6036	.6036	.5658	.5658
23	.5281	.4527	.5281	.5281	.4904	.4904	.4904
24	.5281	.4904	.4527	.4527	.5281	.4527	.4527
Max	.7167	.7545	.7167	.7167	.679	.7167	.7545
Min	.415	.4435	.3772	.3734	.2926	.3982	.3772
Avg	.5488	.5491	.5239	.5294	.4612	.5220	.5206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 401 / 33 KV KBL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.112
Max	.112
Min	.112
Avg	.112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV DUDHONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.0937	.2187	.0554	.0549	.0747	.037
2	.1875	.096	.2214	.0549	.0549	.056	.037
3	.2267	.0937	.2187	.0366		.0566	.0373
4	.2267	.0926	.25	.0554	.0549	.0566	.056
5	.2622	.0937	.2846	.056	.0739	.0566	.0554
6	.4111	.0937	.427	.0747	.0747	.0566	.0566
7	.1097	.0351	.1097	.0914	.0732	.0724	.0943
8	.1075	.0716	.128	.0549	.0716	.0526	.0549
9	.0914	.0724	.1075	.0543	.0724	.0537	.0474
10	.0701	.0886	.0716	.3437	.2469	.216	.1372
11	.0686	.0895	.0724	.4428	.3048	.3163	.1543
12	.0716	.0886	.0732	.4687	.3395	.3637	.1524
13	.0724	.0914		.4687	.3353	.3549	.1389
14	.0709	.0732	.0532	.4475	.3201	.2778	.1524
15	.0716		.0537	.4475	.3048	.2968	.1562
16	.0724	.0724	.052	.4687	.2896	.2778	.1677
17	.0701	.0693	.0532	.4268	.2591	.2656	
18	.0686	.1029	.0526	.0693	.048	.0633	.061
19	.0716	.0857	.0549	.0701	.0537	.0537	.0701
20	.0686	.1017	.056	.0724	.0549	.0543	.1075
21	.0914	.25	.056	.0732	.056	.0543	.1052
22	.108	.25	.0554	.0739	.0554	.0554	.0724
23	.0937	.25	.056	.0543	.0554	.037	.0739
24	.1981	.0926	.2378	.0554	.0554	.0554	.037
Max	.4111	.25	.427	.4687	.3395	.3637	.1677
Min	.0686	.0351	.052	.0366	.048	.037	.037
Avg	.1283	.1065	.1289	.1882	.1439	.1366	.0897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV NAGRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0686	.0867	.3086	.3125	.2778	.1875
2	.0633	.0701	.0693	.3086	.2812	.2932	.1718
3	.0633	.0671	.0701	.3086	.2846	.2968	.1581
4	.081	.1029	.0693	.3281	.3163	.3163	.1581
5	.0983	.1052	.0886	.4111	.4161	.3795	.1875
6	.0876	.1086	.0905	.5281	.4481	.3953	.2056
7	.0905	.1029	.1097	.6478	.6249	.5312	.2469
8	.1898	.2103	.0838	.6802	.6562	.6722	.3681
9	.6226	1.1065	.0772	.6483	.5624	.6483	.3795
10	.6401	1.2125	.6962	.0747	.0754	.0781	.0914
11	.7537	1.0486	.9831	.0754	.0943	.0937	.0625
12	.9061	1.0978	1.065	.0739	.0709	.0625	.0633
13	.9282	.9995	1.0688	.0678	.0678	.0781	.0617
14	.8745	.9393	1.0562	.0625	.0655	.0781	.0617
15	.9175		.9831	.0724	.061	.0781	.0625
16	.0625	.0648	1.0688	.0732	.0648	.0772	.0914
17	.0648	.0648	.9995	.0781	.0943	.0937	.0533
18	.096	.0772	.0625	.0772	.0791	.0937	.0701
19	.0995	.096	.0671	.0949	.081	.1063	.0857
20	.0648	.1017	.0886	.0995	.0838	.1052	.104
21	.1029	.0983	.0693	.1063	.1029	.1063	.1052
22	.0693	.0791	.0686	.0867	.0819	.0829	.0686
23	.0655	.0937	.0686	.0633	.081	.0648	.0686
24	.0819	.0648	.0937	.3086	.3086	.2591	.1852
Max	.9282	1.2125	1.0688	.6802	.6562	.6722	.3795
Min	.0625	.0648	.0625	.0625	.061	.0625	.0533
Avg	.2960	.3470	.3827	.2327	.2214	.2195	.1374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV TAKARI EXPS

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6219	.4706	.5544	.5487	.439	.4854
2	.5068	.5792	.439	.5415	.5068	.439	.4854
3	.5068	.5487	.4344	.4904	.5068	.4251	.4435
4	.4938	.5014	.4344	.5228	.5487	.462	.4435
5	.4904	.543	.4755	.5359	.5914	.462	.4481
6	.5975	.7316	.5544	.5853	.5914	.4755	.5228
7	.6413	.5487	.5121	.6219	.6283	.4854	
8	.6722	.695	.5601	.6722	.6722	.4715	.4904
9	.6348	.7842	.5601	.6878	.6348	.5228	.2103
10	.6584	.5373	.5975	.5914	.4854	.5544	.4207
11	.7095	.5975	.5788	.5975	.4527	.4066	.4344
12	.7602	.5601	.6348	.6348	.4251		.3898
13	.6661	.5544	.6722	.5975	.3605	.4108	.6516
14	.7316	.5487	.7468	.6283	.4207	.3326	.7468
15	.7095		.6584	.5792	.5658	.2957	.6516
16	.5914	.5487	.6516	.6219	.4904	.2896	.7468
17	.5792	.5121	.695	.5487	.4527	.4481	.3982
18	.5853	.5175	.7682	.6283	.4854	.439	.5975
19	.7842	.5121	.5914	.5914	.4854	.4805	.5853
20	.7392	.4108	.6219	.5853	.499	.439	.5792
21	.7468	.4706	.6036	.5601	.4755	.4755	.5373
22	.6348	.5853	.5853	.5975	.462	.4706	.5792
23	.6283	.6283	.6283	.5853	.4435	.4481	.5853
24	.5544	.6653	.4755	.5853	.5487	.462	.4854
Max	.7842	.7842	.7682	.6878	.6722	.5544	.7468
Min	.4904	.4108	.4344	.4904	.3605	.2896	.2103
Avg	.6321	.5740	.5812	.5894	.5117	.4406	.5182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV NAGRALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5975	.5228	.6036	.6413	.5847	.5281
2	.5544	.5975	.5228	.5847	.5975	.5658	.5228
3	.5601	.5658	.5544	.5847	.5975	.5847	.5601
4	.679	.7095	.6722	.6036	.7545	.6224	.6036
5	.7922	.9054	.7922	.7922	.7922	.8299	.7167
6	1.0402	1.1317	1.0185	1.094	1.094	1.1317	.8865
7	1.0456	1.1203	1.1128	1.1203	1.0456	1.1203	1.2826
8	.8131	.7392	.9335	.9055	.8501	.8871	.9896
9	.6653	.695	.695	.6401	.6878	.7133	.8048
10	.6348	.5373	.6268	.5853	.5611	.5487	.5853
11	.5731	.5975	.5373	.543	.5373	.543	.543
12	.543	.5601	.5373	.567	.4477		.5258
13	.5014	.4706	.543	.5373	.5373	.4908	.5792
14	.4706	.362	.5487	.5068	.5068	.5014	.3658
15	.5487		.543	.5316	.4755	.4075	.5792
16	.2686	.4298	.5014	.5731	.4961	.5014	.5201
17	.543	.4733	.5373	.5316	.5316	.5258	.3429
18	.5609	.5258	.5316	.5609	.5258	.5201	.5731
19	.6878	.6878	.7059	.724	.7316	.7316	.7316
20	.8413	.8686	.9335	.8589	.7762	.8962	.924
21	.8962	.8029	.9054	.8962	.8215	.8676	.8779
22	.9431	.7842	.8865	.8676	.7655	.8299	.7842
23	.7316	.6413	.7545	.7167	.679	.7167	.6036
24	.6036	.6036	.5906	.6413	.6413	.6036	.547
Max	1.0456	1.1317	1.1128	1.1203	1.094	1.1317	1.2826
Min	.2686	.362	.5014	.5068	.4477	.4075	.3429
Avg	.6706	.6699	.6878	.6904	.6706	.6837	.6657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / SATTESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4481	.4481	.3361	.132	.4481
2	.4904	.4854	.4481	.3361	.132	.4481
3	.4904	.4904	.4715	.3361	.132	.4481
4	.5041	.5041	.4904	.3206	.1509	.4251
5	.5041	.4854	.4904	.3206	.1509	.3361
6	.5041	.5041	.4854	.3206	.1509	.1109
7	.6161	.5975	.5975	.4338	.3206	.2801
8	.6161	.6161	.6036	.4338	.3584	.2801
9	.6161	.6161	.6036	.4338	.3395	.4435
10	.6348	.5975	.5847	.4338	.3547	.4481
11	.6224	.6161	.5658	.4527	.415	.4481
12	.5975	.5975	.5658	.4481	.4481	.4481
13	.6219	.5788	.5658	.4338	.4108	.4435
14	.6161	.5788	.5847	.4338	.415	.4481
15	.5975		.5658	.4527	.4108	.4481
16	.5601		.5415	.4527	.3921	.4294
Max	.6348	.6161	.6036	.4527	.4481	.4481
Min	.4481	.4481	.4481	.3206	.132	.1109
Avg	.5650	.5511	.5383	.3987	.2946	.3958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.0374	.9431	.9808	.9619	.9808	.9054
2	.9431	1.0185	.9054	.9242	.9431	.9431	.8676
3		.9808	.8676	.9054	.9431	.9431	.9242
4	1.0374	1.0374	.9431	.8865	.9619	1.0374	.9808
5	1.2826	1.1694	1.2826	1.1694	1.1694	1.2826	1.2637
6	1.5655	1.5655	1.3957	1.3957	1.5278		1.4146
7	1.5655	1.5684	1.5655	1.6057	1.643	1.5497	1.6617
8	1.4523	1.3676	1.419	1.3256	1.5154	1.3535	1.419
9	1.2803	1.2382	1.3169	1.3169	1.2851	1.262	1.262
10	1.267	1.2127	1.3756	1.1946	1.2071	1.2071	1.262
11	1.2308	1.2308	1.3394	1.3032		1.1462	1.1403
12	1.1584	1.2489	1.2489	1.2127		1.2048	1.0924
13	1.1222	1.1462	1.1584	1.1765		1.1104	.9955
14	1.0498	1.1104	1.1706	1.1222		1.0317	.9955
15	1.1041	1.1222	1.1694	1.0924	1.1946	1.0136	.9593
16	1.1706	1.0924	1.262	1.1999	1.1584	1.0566	.9313
17	1.1888	1.2071	1.2357	1.182	1.2127	1.134	1.0808
18	1.2357	1.182	1.2403	1.1462	1.262	1.3611	1.3213
19	1.448		1.4632	1.4632	1.5912	1.5912	
20	1.7187	1.6804	1.7541	1.7364	1.6632	1.6278	1.6244
21	1.5497	1.4377	1.6244	1.5497	1.475	1.475	1.4937
22	1.3957	1.358	1.3957	1.3392	1.358	1.3014	1.226
23	1.1883	1.1128	1.226	1.1506	1.1694	1.0751	1.0185
24	1.0374	1.0751	.9619		.9997	.9997	.9431
Max	1.7187	1.6804	1.7541	1.7364	1.6632	1.6278	1.6617
Min	.9431	.9808	.8676	.8865	.9431	.9431	.8676
Avg	1.2597	1.2261	1.2610	1.2339	1.2621	1.2038	1.1645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5847	.547	.547	.5658	.5658	.6224
2	.5281	.5658	.5658	.547	.547	.5658	.6036
3	.5658	.5847	.5281	.547	.547	.6036	.5658
4	.5847	.5658	.547	.547	.5658	.6036	.547
5	.5658	.6036	.5658	.5658	.547	.6224	.6036
6	.6036	.6036	.5658	.5658	.5658	.6224	.6413
7	.5658	.5847	.547	.547	.5281	.5847	.6224
8	.5847	.6413	.5658	.547	.547	.5847	.5281
9	.8865	.9425	.9808	.8328	.5658	.8676	.7922
10	1.1883	1.1128	1.1317	1.1576	.5281	1.094	1.1506
11	1.1317	1.226	1.0374	1.3203	.5281	1.1694	1.2826
12	1.1317	1.094	1.1317	.9997		.8488	1.0374
13	.9808	1.0751	1.6221	1.1128	.5847	.8865	1.1568
14	1.7164	1.4523	1.773	1.1128	.5281	.7701	1.358
15	1.4335	1.3203	1.9616	1.1506	.547	1.1273	.9593
16	1.5655	1.3957	1.9239	.9431	.5281	1.1694	1.0829
17	1.5466	1.2071	1.2826	.9619	.6036	.9795	.8299
18	.8589	.7545	.9997	.9242	.6036	.8299	.7733
19	.8676	.6602	1.0185	.6413	.6036	.6602	
20	.7922	.5847	.6602	.6602	.5847	.6413	.7167
21	.5847	.5658	.6224	.5847	.5847	.6413	.6602
22	.5847	.5658	.6036	.5658	.5658	.6602	.7167
23	.547	.5093	.547	.5658	.5658	.6413	.6602
24	.5658	.5847	.547	.547	.5658	.5658	.6602
Max	1.7164	1.4523	1.9616	1.3203	.6036	1.1694	1.358
Min	.5281	.5093	.5281	.547	.5281	.5658	.5281
Avg	.8728	.8244	.9281	.7706	.5609	.7627	.8074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.6562	.5601	.5921	.2075	.2263	.1886
2	.2075	.6327	.5243	.5441	.1886	.2075	.1698
3	.1886	.6481	.663	.5601	.1698	.1886	.1698
4	.2452	.6874	.7287	.5506	.1886	.1886	.1886
5	.3018	.7682	.8002	.6154	.2075	.3018	.2641
6	.3772	1.1797	.8697	.7287	.3395	.3361	.3206
7	.3547	.3547	.3734	.9602	.3734	.3361	.3206
8	.3174	.3174	.4251	1.2483	.3734	.3584	.3206
9	.3174	.2427	.3361	1.5524	.3018	.3174	.2641
10	.3547	.2957	.3584	1.3441	.2934	.9282	.7655
11	.3547	.2987	.3547	1.8623	.6093	1.5043	1.012
12	.3174	.2801	.3734	1.8084	1.5813	1.5384	.9722
13	.2957	.2614	.3174	2.0325	1.4969	1.3763	.9105
14	.2614	.2641	.3142	1.7604	1.4022	1.3435	.9998
15	.2427	.2263	.2801	1.6288	1.4043	1.4232	1.0494
16	.2614	.2263	.3174	1.3757	1.3735	1.3916	1.0185
17	.2801	.3395	.2987	1.3123	.4108	1.1736	1.0385
18	.2454	.2241	.2957	.197	.037	.2033	.1791
19	.2378	.2614	.2587	.2587	.2427	.2195	.2427
20	.3018	.2829	.3206	.2829	.2614	.2829	.2641
21	.8065	.6241	.3206	.2641	.2801	.2452	.2452
22	.8642	.6405	.3018	.2641	.2801	.2452	.2263
23	.6958	.571	.2641	.2452	.2452	.2075	.1886
24	.2452	.6562	.5335	.5556	.2263	.3395	.1886
Max	.8642	1.1797	.8697	2.0325	1.5813	1.5384	1.0494
Min	.1886	.2241	.2587	.197	.037	.1886	.1698
Avg	.3459	.4558	.4246	.9393	.5206	.6201	.4795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.1509	.2075	.1698	.1698	.1886
2	.132	.1509	.132	.2075	.1698	.1509	.1698
3	.1132	.1698	.1132	.1886	.1509	.1509	.1698
4	.132	.1509	.132	.1886	.1509	.1509	.1509
5	.1509	.1698	.1509	.1698	.1509	.1698	.1698
6	.1509	.1886	.1509	.1698	.1698	.1698	.1698
7	.1509	.1886	.1698	.1886	.1509	.1886	.2263
8	.3206	.3206	.3395	.2829	.1698	.3584	
9	.4715	.4715	.4904	.4338	.1509	.3772	.2075
10	.4715	.4715	.4338	.4338	.1698	.3961	.2452
11	.4715	.4338	.4338	.4527	.1886	.3961	.0943
12	.1886	.3584	.3018	.2829	.1509	.2641	.3395
13	.0943	.415	.3772	.3395	.132	.3206	.3395
14	.1132	.4904	.4338	.3772	.1698	.4527	.3961
15	.4527	.4338	.3772	.415	.1509	.3961	.415
16	.4715	.4527	.4338	.4338	.1886	.415	.4338
17	.3961	.3395	.3395	.3772	.1886	.3206	.4527
18	.2829	.3018	.3206	.3584	.1509	.3018	.3018
19	.2641	.2452	.3018	.2829	.1886	.2452	.3018
20	.2263	.208	.2452	.2829	.1698	.2641	.2829
21	.1698	.1509	.1886	.2075	.1509	.1886	.1696
22	.1698	.1886	.2452	.2263	.1698	.2452	.2452
23	.1698	.1509	.2075	.1886	.1698	.2263	.2263
24	.132	.1509	.1509	.2263	.1698		.1886
Max	.4715	.4904	.4904	.4527	.1886	.4527	.4527
Min	.0943	.1509	.1132	.1698	.132	.1509	.0943
Avg	.2428	.2814	.2758	.2884	.1643	.2747	.2559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0943	.0914	.1109	.0924	.0934	.0914
2	.0895	.0943	.0905	.0924	.0924	.0943	.0905
3	.1086	.0943	.0914	.0934	.0924	.0943	.0895
4	.1075	.0943	.1086	.0373	.0934	.1132	.1097
5	.128	.1132	.1075	.132	.112	.1132	.1294
6	.1494	.1509	.112	.1494	.1494	.1132	.1494
7	.1629	.1829	.181	.1629	.2012	.1646	.2012
8	.1433	.1463	.197	.181	.1791	.1417	.1463
9	.1402	.1417	.1734	.1595	.1402	.1417	.1227
10	.1357	.1311	.1526	.1387	.1052	.1387	.1357
11	.1341	.1326	.1715	.1311	.1017	.1147	.1147
12	.1677	.1341	.1715	.1147	.0995	.0914	.096
13	.1147	.1341	.1387	.1341	.0857	.0983	.0848
14	.0983	.1017	.1595	.1341	.0838	.0995	.1006
15	.1147	.1187	.1214	.1187	.0829	.0829	.08
16	.1017	.1187	.1214	.1006	.0838	.08	.08
17	.1174	.1543	.1357	.1174	.0819	.0848	.1134
18	.1311	.128	.1739	.1457	.1006	.1174	.1187
19	.1402	.1387	.1509	.156	.1387	.156	.1509
20	.1629	.1629	.1791	.1791	.1595	.1463	.1646
21	.1646	.1478	.1646	.1478	.128	.128	.1494
22	.1494	.1478	.1646	.1494	.1294	.1294	.1294
23	.1132	.112	.128	.1294	.112	.112	.0934
24	.0924	.0943	.0934	.1109	.0924	.0934	.0924
Max	.1677	.1829	.197	.181	.2012	.1646	.2012
Min	.0895	.0943	.0905	.0373	.0819	.08	.08
Avg	.1275	.1279	.1408	.1303	.1141	.1143	.1181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY  
VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.5847	.4904	.547	.547	.6036	.4904
2	.7356	.6036	.4715	.547	.5281	.5847	.4715
3	.7545	.6036	.4904	.5281	.5093	.5658	.4904
4	.7733	.5658	.5281	.5281	.5281	.5658	.547
5	.7545	.5847	.547	.5658	.5281	.6036	.5658
6	.7733	.6036	.5281	.5658	.5281	.6036	.6036
7	.811	.5847	.4904	.5847	.4338	.6036	.5658
8	.7545	.5658	.4904	.5847	.5281	.6036	.6224
9	.6036	.679	.3772	.5658	.547	.5281	.6413
10	.6979	.6602	.9431	.679	.4715	.6979	.679
11	.6413	.6979	1.3957	.6602	.4527	.679	.6413
12	.5658	.547	.8676	.6036	.5847	.5658	.6979
13	.8865	.5093	1.1317	.5093	.547	.5281	.4527
14	.9619	.5658	1.226	.9054	.5847	.6224	1.0166
15	1.1694	.5847	1.1694	.9431	.5847	.5658	.9955
16	1.2449	.6036	.7167	.9431	.5847	.6413	1.2803
17	.5093	.4904	.6979	.6979	.6036	.6413	1.1157
18	.5281	.5658	.6602	.5093	.5847	.4715	.415
19	.4904	.5847	.6979	.547	.6036	.5093	.5658
20	.5281	.5658	.6602	.7167	.6036	.4527	.547
21	.547	.6036	.4338		.6036	.4904	.5658
22	.5658	.5847	.4527	.7356	.5847	.5093	.5658
23	.5847	.5658	.4715	.5847	.6036	.4904	.5658
24	.7545	.5847	.4904	.5658	.5281	.6036	.4904
Max	1.2449	.6979	1.3957	.9431	.6036	.6979	1.2803
Min	.4904	.4904	.3772	.5093	.4338	.4527	.415
Avg	.7238	.5871	.6845	.6356	.5501	.5721	.6497



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3932	.4409		.0343	.0343	.0328
2	.3521	.3932	.4239		.0343	.0343	.0328
3	.3521	.3932	.4239		.0343	.0343	.0328
4	.3521	.3932	.407		.0343	.0343	.0328
5	.4001	.3932	.4191		.0343	.0343	.0328
6	.4321	.3932	.4694		.0343	.0343	.0328
7	.0328	.4458	.0335		.0514	.0343	.0492
8	.0492	.0343	.0328		.0343	.0343	.0492
9	.0328	.0343	.0328		.0343	.0343	.0328
10	.0343	.0514	.0492	1.0059	.8718	.8215	.6706
11	.0343	.0503	.0492	1.2239	.9724	.8048	.6874
12	.0343	.0503	.0671	1.3245	.9724	.8551	.0671
13	.0343	.0335	.032	1.358	.9831	.8356	.788
14	.0343		.032	1.3108	1.0159	.9175	.8215
15	.0343	.0335	.032	1.3108	.9995	.9175	.788
16	.0343	.0335	.032	1.2944	.9995	.8848	.7701
17	.0343	.0503	.048	1.2452	.9503	.9389	.7045
18	.0343	.0503	.032	.0343	.0343	.0492	.0343
19	.0343		.0469	.0514	.0343	.0492	.0514
20	.0343	.0335	.0469	.0514	.0343	.0492	.0514
21	.3932	.4527	.0469	.0514	.0343	.0328	.0514
22	.3932	.5256	.0312	.0343	.0343	.0492	.0514
23	.3932	.5087	.0312	.0343	.0343	.0328	.0343
24	.3521	.3932	.4748	.048	.0343	.0343	.0328
Max	.4321	.5256	.4748	1.358	1.0159	.9389	.8215
Min	.0328	.0335	.0312	.0343	.0343	.0328	.0328
Avg	.1777	.2337	.1556	.6919	.3471	.3159	.2472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV M WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0686	.0678		1.2452		
2	.0819	.0343	.0678		1.2125	1.1142	
3	.0819	.0686	.0671			1.1142	
4	.0819	.0686	.0671			1.1142	
5	.0819	.0686	.0838				
6	.0819	.061	.0838		1.4091		
7	.0983	.1029	.0838		1.4746		
8	1.2323	1.6385	.0655		1.3763	1.4746	
9	1.4563	1.8351	.0655			1.3927	
10	1.6385	1.9334	1.8244	.0492	.0671	.0671	
11	1.6712	2.0481	.7209	.0328	.0335	.0671	.0655
12	1.5893	2.0153	.7773	.0671	.0503	.0671	.0819
13	1.6549	1.917		.0671		.0514	.0819
14	1.7204		2.1052	.0671		.0819	.0655
15	1.7695		2.251	.0335		.0655	.0655
16	.0686	.0671	2.2024	.0503		.0655	.0671
17	.0686	.0838	2.17			.0655	.0838
18	.0686	.0671	.0983			.0983	.0686
19	.0686	.0838	.0983	.0686	.0686	.0983	.0857
20	.0686	.0838	.0983	.0686	.0686	.0983	.0857
21	.0686	.0671	.0983	.0686	.0686	.0819	.0857
22	.0343	.0678	.0983	.0686	.0686	.0819	.0686
23	.0686	.0678	.0655	.0686	.0686	.0655	.0686
24	.0819	.0686	.0678	1.4737	1.278	1.1142	
Max	1.7695	2.0481	2.251	1.4737	1.4746	1.4746	.0857
Min	.0343	.0343	.0655	.0328	.0335	.0514	.0655
Avg	.5799	.5690	.5795	.1680	.6064	.4190	.0749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	.0343	.052		.0514	.0686	.0503
2	.0693	.0343	.0347		.0343	.0686	.0503
3	.0693	.0343	.0347		.0514	.0686	.0503
4	.052	.0343	.0343		.0343	.0686	.0492
5	.052	.0343	.0514		.0514	.0686	.0492
6	.052	.0343	.0343		.0514	.0686	.0655
7	.052	.0343	.0514		.0514	.0686	.0655
8	.052	.0343	.0857		.0514	.0686	.0655
9	.052	.0343	.0343		.0514	.0686	.1147
10	.0343	.0514	.0343	.0693	.0693	.0876	.0838
11	.0343	.0343	.0343	.0347	.0693	.0701	.0671
12	.0343	.0343	.0164	.052	.0867	.0876	.0671
13	.0343	.0343	.0164	.052	.052	.0343	.0492
14	.0343		.0164	.0686	.0701	.0686	.0655
15	.0343	.0514	.0164	.0514	.0701	.0857	.0655
16	.0343	.0686	.0164	.0686	.0351	.1029	.0819
17	.0343	.0686	.0164	.0686	.1227	.1029	.0983
18	.0343	.0876	.0328	.0686	.1029	.0838	.0686
19	.0343	.0526	.0655	.0686	.1029	.0838	.0686
20	.0343	.0701	.0819	.0686	.0686	.0671	.0514
21	.0343	.0526	.0819	.0686	.0701	.0838	.0686
22	.0343	.052	.0648	.0686	.0701	.0671	.0514
23	.0343	.052	.0648	.0514	.0686	.0671	.0686
24	.0693	.0343	.052	.0648	.0514	.0686	.0503
Max	.0693	.0876	.0857	.0693	.1227	.1029	.1147
Min	.0343	.0343	.0164	.0347	.0343	.0343	.0492
Avg	.0446	.0458	.0426	.0616	.0641	.0741	.0653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV M WADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3658	.439		.3658	.3292	.3109
2	.3292	.3292	.4108		.3292	.3292	.2926
3	.3292	.3292	.4108		.3292	.3292	.2926
4	.3475	.3292	.4481		.3658	.3658	.3292
5	.4572	.439	.4854		.439	.439	.3658
6	.6219	.5121	.6535		.5121	.5121	.6036
7	.7421	.7316	.7468		.695	.695	.7682
8	.5973	.4755	.6161		.6219	.5853	.6401
9	.4344	.4024	.4572		.439	.4024	.4938
10	.439	.4344	.439	.4108	.3547	.3361	.3801
11	.4024	.3801	.3801	.3734	.3361	.3361	.3258
12	.3292	.3801	.3696	.3734	.3361	.2987	.2534
13	.3292	.362	.3881	.3361	.2743	.2896	.2896
14	.2926		.3696	.2715	.2743	.2534	.2801
15	.2926	.4163	.3881	.2715	.2743	.2353	.2614
16	.3658	.3439	.4066	.3077	.3292	.2561	.3361
17	.3658	.3801	.3881	.3292	.3475	.3292	.3361
18	.4024	.4481	.4435	.4024	.4024	.4572	.439
19	.5853	.4854	.4938	.5487	.5121	.6036	.5487
20	.6584	.6722	.695	.6219	.6219	.6767	.6584
21	.6219	.6161	.6219	.5487	.5487	.567	.5853
22	.5121	.4755	.5487	.4755	.439	.5121	.4755
23	.439	.439	.439	.3658	.3658	.3841	.3658
24	.3658	.4024	.3841	.3658	.3658	.3292	.3292
Max	.7421	.7316	.7468	.6219	.695	.695	.7682
Min	.2926	.3292	.3696	.2715	.2743	.2353	.2534
Avg	.4420	.4413	.4760	.4002	.4116	.4105	.4151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.0838		1.004	.9831	.8848
2		.0686	.0838		.9717	.9831	.852
3		.0686	.0686		1.0364	.9503	.8356
4		.0686	.0686		1.085	.9503	.8356
5		.0686	.0838		1.166		.8192
6		.0686	.1006		1.2793	1.0486	.852
7		.1029	.1006		1.3603	1.1142	.9503
8		1.7695	.0983		1.3603	1.1797	1.065
9		2.0809	.0983		1.1012	1.1469	1.0486
10	2.0645	2.1956	2.0081	.0335	.0328	.0671	.0492
11	2.1136	2.2119	2.1464	.0335	.0328	.0671	.0486
12		2.2775	2.2775	.0335	.0492		.0486
13	2.1136	2.2611		.0335		.0328	.0486
14	2.0481		2.2611	.0328		.0328	.0503
15	1.9989	2.0317	2.2611	.0328		.0328	.0335
16	.0686	.0671	2.1136	.0328		.0328	.0335
17	.0343	.0671	1.8842	.0328		.0324	.0503
18	.0343	.0671	.064	.0343		.0324	.0686
19	.0343	.0671	.096	.0686	.0686	.081	.0686
20	.0343	.0671	.096	.0857	.0686	.0655	.0686
21	.0686	.0686	.096	.0857	.0686	.0838	.0686
22	.0686	.0686	.08	.0686	.0686	.0671	.0514
23	.0686	.0838	.064	.0686	.0686	.0503	.0514
24		.0686	.0838	1.0936	1.004	.9831	.9175
Max	2.1136	2.2775	2.2775	1.0936	1.3603	1.1797	1.065
Min	.0343	.0671	.064	.0328	.0328	.0324	.0335
Avg	.8269	.6943	.7095	.1180	.657	.4553	.4084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6554	.5735		.0686	.0686	.0686
2		.6226	.5407		.0686	.0686	.0686
3		.6226	.57		.0686	.0686	.0686
4		.6226	.57		.0686	.0686	.0686
5		.6554	.6371		.0686	.0686	.0686
6		.8192	.7545		.0857	.0686	.0686
7		.9602	.0838		.1029	.0686	.0857
8		.0686	.0983		.1029	.0686	.0686
9		.0686	.0655		.0686	.0686	.0686
10	.0686	.0686	.0655	1.0974	1.1797	1.1401	.8848
11	.0686	.0503	.0655	1.4746	1.3599	1.2407	.9503
12	.0686	.0335	.096	1.5261	1.3108	1.2742	.9175
13	.0857	.0328	.096	1.6632	1.3763	1.3272	.9995
14	.0686		.112	1.6876	1.4083	1.3435	1.0395
15	.0686	.0655	.112		1.4754	1.3763	1.073
16	.0857	.0819	.112	.8192	1.4754	1.3763	.9724
17	.0857	.0983	.112	.7865	1.4083	1.2616	.9724
18	.0857	.0671	.096	.0343	.0514	.0655	.0686
19	.0857	.0671	.096	.0686	.0671	.0655	.0686
20	.0857	.0671	.0983	.0686	.0686	.0671	.0686
21	.6718	.6516	.0983	.0686	.0671	.0671	.0686
22	.6718	.6859	.0983	.0686	.0686	.0671	.0686
23	.6718	.6226	.0983	.0686	.0686	.0503	.0686
24		.6718	.5898	.0983	.0686	.0686	.0686
Max	.6718	.9602	.7545	1.6876	1.4754	1.3763	1.073
Min	.0686	.0328	.0655	.0343	.0514	.0503	.0686
Avg	.2052	.3634	.2433	.6807	.5066	.4754	.3718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.8192	.8718		.0686	.0857	.0686
2	.6722	.7865	.8718		.0686	.0857	.0686
3	.6401	.7865	.8886		.0686	.0857	.0686
4	.6241	.7865	.8551		.1029	.1029	.0857
5	.6562	.7865	.852		.1372	.1372	.0857
6	.6882	.8192	.9831		.1372	.1372	.1372
7	.0983	.8916	.1311		.1715	.1372	.1543
8	.0983	.1029	.0819		.1372	.1029	.1372
9	.0819	.1029	.0983		.1372	.0857	.12
10	.1029	.1029	.1147	1.1469	1.1401	1.1904	1.0059
11	.1029	.1174	.1475	1.5402	1.3413	1.3077	1.3077
12	.0686	.1174	.112	1.6712	1.4586	1.3077	1.3245
13	.1029	.1174	.128	1.7204	1.4255	1.1305	1.3272
14	.1029		.112	1.7436	1.4091	1.1797	1.3272
15	.0686	.1341	.16	1.7604	1.2944	1.2944	1.3108
16	.0857	.1509	.16	1.6766		1.3272	1.278
17	.0857	.1174	.16	1.576	1.1142	1.278	1.1797
18	.1029	.1677	.1638	.12		.0838	.1029
19	.1029	.1543	.1475	.12	.1029	.1341	.12
20	.1029	.9602	.1475	.12	.1372	.0838	.12
21	.8192	.9602	.1311	.12	.1372	.1174	.1029
22	.852	.9602	.1311	.1029	.1029	.1006	.1029
23	.852	.9221	.1006	.1029	.1029	.0671	.0686
24	.6722	.852	.8886	.1006	.1029	.0857	.0686
Max	.852	.9602	.9831	1.7604	1.4586	1.3272	1.3272
Min	.0686	.1029	.0819	.1006	.0686	.0671	.0686
Avg	.3523	.5094	.3516	.9081	.4954	.4853	.4864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV WINE PARK 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1852	.1886	.112	.2263	.1886	.1143	
2	.1981	.1886	.112	.2263	.1886	.1067	
3		.1886	.1006	.2263	.1886	.101	
4	.1783	.1886	.1069	.2263	.1886	.1658	
5	.1806	.1886	.1195	.2263	.1886	.1734	
6	.1989	.1886		.2263	.2263	.181	
7	.5548	.1886	.1395	.3584	.2263	.4294	
8	.3429	.1734	.1658	.9054	.2263	.9431	
9	1.2071	.6036	1.0562	.9054	.2263	.7392	
10	.6413	.9242				1.6975	
11	.7733	1.1317				1.6598	1.1317
12	.6036	.7392				.7356	.5281
13	1.0562	1.1317				1.0185	1.1317
14	1.1694	1.1317				1.1317	.9431
15	1.2826	1.9616				1.358	1.3203
16	1.358	.9997				1.5844	1.5089
17	.5281	.6036		.8488		1.5844	.7545
18	.7545	.4801	.679	.7545		1.0374	.2829
19	.2263	.4287	.3961	.7545		.7392	
20	.2263	.2204	.3395	.1886	.128	.1425	
21	.2263	.1852	.3018	.1886	.1029	.1326	
22		.1783	.2641	.1886	.1067	.1174	
23	.2075	.1943	.2263	.1886	.0991	.1067	
24	.1829	.1886	.1075	.2263	.1886	.1105	.0817
Max	1.358	1.9616	1.0562	.9054	.2263	1.6975	1.5089
Min	.1783	.1734	.1006	.1886	.0991	.101	.0817
Avg	.5583	.5248	.2818	.4039	.1767	.6713	.8537



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV ANDHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2452	.2263	1.4251	1.3599	1.2041	1.2029
2	.2263	.2263	.2263	1.4251	1.3763	1.2346	1.1717
3	.2263	.2263	.2452	1.4251	1.3763	1.2346	1.1873
4	.2263	.2263	.2452	1.4413	1.3763	1.2492	1.1843
5	.2641	.2263	.3018	1.6518	1.4746	1.2654	1.186
6	.3206	.3206	.3772	1.7284	1.6385	1.3125	1.2163
7	.4715	.3395	.3961	1.7764	2.0805	1.5813	1.2809
8	1.8023	2.1628	.3584	1.9204	2.0481	1.7394	1.5023
9	1.7901	2.332	.3584	1.9433	2.0481	1.6804	1.7353
10	2.0972	2.1376				.3584	.2263
11	2.1464	1.9204				.3395	.2829
12	2.13	2.7526				.3018	.2641
13	2.1628	2.3205				.2263	.2829
14	2.1765	2.2874				.2263	.2263
15	2.2672	2.4863				.3018	.3018
16		.3206			.2622	.3018	.3018
17		.3018		.3395	.2294	.3018	.3018
18	.3961	.3018	.3772	.3734	.1966	.2452	.3018
19	.4527	.3206	.3584	.3018	.3206	.2452	
20	.3961	.3018	.3584	.3018	.3584	.2452	
21	.3961	.3018	.3395	.3018	.7545	.2263	
22	.3018	.2829	.3206	.2829	.2829	.2263	
23	.2641	.2263	.3018	.2452	.2263	.1698	
24	.2263	.2452	.2263	1.4251	1.3435	1.2193	1.2029
Max	2.2672	2.7526	.3961	1.9433	2.0805	1.7394	1.7353
Min	.2263	.2263	.2263	.2452	.1966	.1698	.2263
Avg	.9531	.9505	.3136	1.0770	1.0418	.7265	.8084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11KV ANDHALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2266	.2286	.2452	.2241	.2286	.2829
2	.2263	.2075	.2286	.2452	.2263	.2286	.2829
3	.2263	.2075	.2286	.2452	.2263	.2477	.3018
4	.2829	.2075	.2667	.2452	.2263	.2667	.3395
5	.3584	.2075	.3584	.2641	.2829	.3584	.4108
6	.4527	.3772	.4338	.4904	.4527	.4527	.5175
7	.5281	.4527	.5093	.5093	.4527	.547	.6036
8	.4715	.3961	.4338	.4527	.3734	.4527	.3772
9	.3584	.3018	.2303	.3772	.3174	.3584	.3582
10	.3018	.3018				.3772	.2896
11	.3018	.3018				.3018	.2835
12	.3018	.2279				.2263	.2303
13	.3018	.2058				.2263	.2172
14	.2641	.208				.2263	.2126
15	.2263	.2353				.1886	.2126
16	.2452	.1991			.2241	.1886	.1772
17	.2263	.2658		.2427	.2241	.3018	.2303
18	.3018	.2957	.3772	.3734	.2241	.3547	.2926
19		.3326	.4338	.4298	.3658	.3961	
20	.4527	.4338	.4904	.4108	.4481	.4715	
21	.3961	.3584	.3961	.3734	.3772	.4527	
22	.3018	.2263	.3395	.3292	.3206	.3772	
23	.2641	.2263	.3018	.2427	.3206	.3584	
24	.2263	.2263	.2286	.2452	.2241	.2286	.3239
Max	.5281	.4527	.5093	.5093	.4527	.547	.6036
Min	.2263	.1991	.2286	.2427	.2241	.1886	.1772
Avg	.3149	.2762	.3428	.3366	.3062	.3257	.3129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3637	.4481	.4218	.1423	.112	.125	.1265
2	.3479	.4481	.4062	.1423	.112	.125	.1265
3	.3637	.4481	.4374	.1581	.112	.125	.1423
4	.3953	.4641	.4999	.1581	.112	.125	.1423
5	.4428	.4641	.6249	.1898	.16	.1406	.1581
6	.5693	.4961	.7811	.192	.176	.1562	.1898
7	.2056	.208	.2187	.1898	.176	.1718	.1898
8	.1739	.128	.1875	.144	.16	.125	.1581
9	.1581	.0949	.1094	.1581	.144	.1406	.1423
10	.128	.0949				.9061	.5121
11	.128	.112				1.1544	.5761
12	.128	.128				1.3599	.5921
13	.128	.112				1.2651	.5921
14	.128	.112				1.1544	.6401
15	.128	.0949				1.1069	.7202
16	.128					1.0279	.7202
17	.112	.1107		.9602	.9762	.9804	.7202
18	.112	.1265	.1581	.128	.08	.1094	.048
19	.16	.1265	.1581	.144	.125	.1718	
20	.16	.1739	.1739	.16	.1718	.1718	
21	.4961	.4428	.176	.144	.1562	.1718	
22	.4961	.5218	.16	.128	.1562	.1581	
23	.4801	.4744	.1423	.112	.112	.1423	
24	.3637	.4481	.4218	.1423	.112	.125	.1265
Max	.5693	.5218	.7811	.9602	.9762	1.3599	.7202
Min	.112	.0949	.1094	.112	.08	.1094	.048
Avg	.2623	.2730	.3173	.1996	.1855	.4683	.3486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9172	1.0526	.953	.0791	.048	.0781	.0633
2	.9172	1.0526	.9374	.0791	.048	.0781	.0633
3	.933	1.0526	.9842	.0791	.048		.0633
4	.933	1.0526	.9842	.0949	.048	.0781	.0633
5	.9488	1.1174	1.0311	.0949	.048	.0781	.0791
6	.9962	1.2146	1.0936	.096	.064	.0781	.0949
7	.0949	.096	.0937	.096	.064	.0937	.0949
8	.0949	.08	.0937	.096	.048	.0937	.0791
9	.1107	.096	.1094	.0949	.048	.0781	.0633
10	.096	.096				1.4842	1.2163
11	.08	.08				1.7078	1.4083
12	.064					1.8027	1.4403
13	.064					1.7711	1.4243
14	.064					1.7711	1.4083
15	.064	.0474				1.7711	
16	.096	.0791				1.7869	1.3283
17	.096	.0949		1.8185	1.7236	1.6288	1.3123
18	.096	.0949	.1107		.0791	.0625	.08
19	.096	.0949	.1107		.0937	.0781	
20	.096	.1107	.0949		.0937	.0781	
21	1.0883	.9488	.08		.0781	.0781	
22	1.1043	1.0279	.08	.048	.0781	.081	
23	1.0402	1.012	.0791	.048	.0781	.0791	
24	.933	1.0082	.9374	.0791	.048	.0781	.0633
Max	1.1043	1.2146	1.0936	1.8185	1.7236	1.8027	1.4403
Min	.064	.0474	.0791	.048	.048	.0625	.0633
Avg	.4593	.5481	.4858	.2157	.1610	.6485	.5748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	.1578	.1578	.1578	.1663
2	.1646	.1629	.1578	.1578	.1578	.1663
3	.1646	.1629	.1578	.1578	.1578	.168
4	.1629	.1629	.1578	.1578	.1578	.1663
5	.1629	.1646	.1578	.1578	.1612	.1663
6	.1629	.1646	.1578	.0086	.1578	.1663
7	.3772	.4715	.3584	.415	.3361	.3361
8	.5093	.5093	.4904	.4904	.4904	.5093
9	.5093	.5281	.4904	.4904	.4904	.5093
10	.5281	.5281			.4904	.5093
11	.5281	.5281			.5093	.547
12	.5281	.5228			.4715	.547
13	.5281	.5093			.5093	.547
14	.5121	.5093			.5093	.5658
15	.5281	.5093			.5093	.547
16	.5093	.4904			.5093	.547
23						.547
24			.0362			
Max	.5281	.5281	.4904	.4904	.5093	.5658
Min	.1629	.1629	.0362	.0086	.1578	.1663
Avg	.3774	.3804	.2322	.2437	.3610	.3948

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 207 / 11 KV Kranti LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0006	.0006	.0006	.0006	.0006	
2	.0006	.0006	.0006	.0006	.0006	
3	.0006	.0006	.0006	.0006	.0006	
4	.0006	.0006	.0006	.0006	.0006	
5	.0006	.0006	.0006	.0006	.0006	
6	.0006	.0006	.0006	.0006	.0006	
7	.0006	.0008	.0006	.0004	.0006	
8	.2229	.2452	.2058	.2254	.2058	.0006
9	.1907	.2058	.2058	.2263	.2254	.1214
10	.1715	.2058			.2058	.0164
11	.1715	.2058			.2229	.0166
12	.1715	.2035			.0171	.0166
13	.1886	.2058			.0171	.0004
14	.1886	.2058			.0171	.0004
15	.1753	.2058			.0171	.0004
16	.1734	.2058			.0171	.0004
24			.0006			
Max	.2229	.2452	.2058	.2263	.2254	.1214
Min	.0006	.0006	.0006	.0004	.0006	.0004
Avg	.1036	.1184	.0416	.0506	.0594	.0192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.8107	1.4712	1.6804	1.5123	1.4712	1.4563
2	1.4712	1.8107	1.4712	1.6804	1.5123	1.4712	1.4563
3	1.4712	1.8107	1.4712	1.6804	1.5123	1.4712	1.4712
4	1.4712	1.6975	1.4712	1.6804	1.5684	1.5844	1.5684
5	1.4712	1.6975	1.4712	1.6975	1.5123	1.4712	1.4712
6	1.4712	1.6975	1.4712	1.6975	1.4563	1.4712	1.4712
7	1.6975	1.7924	1.4712	1.6975	1.5684	1.5844	1.4712
8	1.5844	1.7924	1.1317	1.6975	1.6804	1.4712	1.5844
9	1.4712	1.5684	1.4712	1.6804	1.5684	1.4712	1.4712
10	1.4563	1.5684				1.2449	1.4146
11	1.4563	1.4563				1.358	1.3443
12	1.4563	1.358				1.358	1.3443
13	1.5684	1.358				1.358	1.5684
14	1.5684	1.358				1.358	1.4563
15	1.7924	1.358				1.358	1.5123
16	1.7924	1.4712			1.5684	1.358	1.5684
17	1.6804	1.4712		1.5684	1.5684	1.5844	1.4003
18	1.7924	1.4712	1.6804	1.5684	1.4563	1.5844	1.5684
19	1.6804	1.4712	1.6804	1.3443	1.5844	1.6975	
20	1.6804	1.4712	1.6804	1.3443	1.5844	1.5844	
21	1.6804	1.3014	1.6804	1.3443	1.358	1.4712	
22	1.7924	1.5844	1.5684	1.4003	1.5844	1.5844	
23	1.7924	1.4712	1.5684	1.3443	1.5844	1.4712	
24	1.5844	1.8107	1.4712	1.6804	1.5123	1.5844	1.5844
Max	1.7924	1.8107	1.6804	1.6975	1.6804	1.6975	1.5844
Min	1.4563	1.3014	1.1317	1.3443	1.358	1.2449	1.3443
Avg	1.5981	1.5691	1.5144	1.5757	1.5385	1.4759	1.4833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.4268	.583	.0343	.0305	.0305	.0232
2	.3841	.4268	.5487	.0343	.0305	.0305	.0232
3	.3841	.4268	.5487	.0343	.0305		.0267
4	.4161	.4268	.5487	.0343	.0305	.0305	.0267
5	.4481	.4572	.5487	.0343	.0305	.0305	.0274
6		.4877	.5639	.0343		.0305	.0297
7		.0297	.0305	.0343		.0305	.0297
8			.0305	.0343		.0305	.0286
9		.0305		.9602	.0305	.0286	.0274
10		.0305		1.4403	1.0364	1.085	.703
11		.0305		1.5844		1.1336	.8124
12		.0305		1.6324	.6097	1.166	.8322
13		.0305		1.6324		1.166	.8322
14		.0305		.8962	1.1126		.8162
15		.0305		.9442	1.0669	1.0437	.8322
16		.0305		.8962	1.1279	1.0753	.7842
17		.0305		.8962	.0305	1.0753	.7842
18		.0305			.0305	.0221	.0305
19		.0305		.0305	.0305		.0305
20		.0305		.0305	.0305		
21		.503		.0305	.0305		
22		.5487		.0305	.0305		.0305
23		.5487		.0305	.0305		.0305
24	.3658	.4572	.5487	.0343	.0305	.0305	.0259
Max	.4481	.5487	.583	1.6324	1.1279	1.166	.8322
Min	.3658	.0297	.0305	.0305	.0305	.0221	.0232
Avg	.3955	.2220	.4390	.4932	.2832	.4729	.3085



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3772	.3658		.3292	.362	.3772
2	.3258	.3395	.362		.3292	.362	.3772
3	.3258	.3395	.362		.3292	.362	.3772
4	.3258	.3395	.4344		.362	.362	.415
5	.4108	.3772	.4344		.5792	.543	.5658
6	.6348	.5658	.543	.5121		.362	.7468
7		.6161	.6516	.6584	.7619	.6154	.8775
8	.5973		.6516	.6219	.4961	.6516	.7762
9	.5544	.4706		.4755	.362	.4938	.4938
10	.5121	.4344		.3658	.362	.3475	.4938
11	.3258	.3982		.2378		.3077	.3174
12		.362		.2353	.2534	.2896	.3142
13		.3258		.2534	.362	.2743	.3142
14		.3258		.2534	.2534	.2743	.2772
15		.3258		.2534	.2534	.2743	.2587
16		.3155		.2172	.2896	.2743	.2587
17		.3258		.2353	.3258	.2926	.2614
18		.362		.3801	.3982	.394	.362
19		.4706		.5068	.5068	.499	.543
20		.6154		.5788	.6154	.6653	.6878
21		.543		.5228	.5792	.6722	.6516
22		.4706		.4481	.362	.6224	.5068
23		.4344		.3734	.362	.5658	.3982
24	.3658	.3772	.362		.3292	.362	.4527
Max	.6348	.6161	.6516	.6584	.7619	.6722	.8775
Min	.3258	.3155	.362	.2172	.2534	.2743	.2587
Avg	.4277	.4136	.4630	.3961	.4001	.4262	.4627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.044	.0332	.0486	1.065	1.0159	.7125	.6401
2	.044	.0332	.0486	1.0486	1.0159	.7125	.5792
3	.044	.0332	.0486	1.0978	1.0159	.6478	.5792
4	.044	.0297	.0486	1.1305	1.0322	.6478	.5792
5	.044	.0286	.0486	1.1797	1.0486	.6478	.5792
6	.044	.0286	.0486	1.2125		.6478	.6097
7	.044	.0549	.0486	1.2452	1.0486	.8097	.6718
8	.4843		.0486	1.278	1.065	.8421	.6958
9		1.0202		1.2125	1.0364		.6325
10		1.2308		.0297	.0486		.0474
11		1.2308		.0297			.0474
12		1.2308		.0297	.0486		.0474
13		1.2308		.0297	.0324		.0457
14		1.1336		.0297	.0324		.0457
15		1.1336		.0297	.0324		.0446
16		.0486		.0297	.0324		.0446
17		.0486		.0446			.0446
18		.0486		.0446	.0486		.0743
19		.0486		.0446	.0324		.0594
20		.0486		.0446	.0324		.0594
21		.0486		.0446	.0324		.0446
22		.0486		.0446	.0324		.0446
23		.0486		.8886	.7125		.0446
24	.0446	.0472	.0486	1.0978	.9831	.7125	.6097
Max	.4843	1.2308	.0486	1.278	1.065	.8421	.6958
Min	.044	.0286	.0486	.0297	.0324	.6478	.0446
Avg	.0930	.3864	.0486	.5388	.4942	.7089	.2863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 201 / 11 KV DEORASHTRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 202 / 11KV KUNDAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 204 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 205 / 11 KV TAKARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUL-18
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 401 / 33 KV KIRLOSKAR WADI NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 403 / 33 KV PALUS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 404 / 33 KV MOHITE VADGAON NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 405 / 33 KV EBARA NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 406 / 33 KV SANDGEWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 407 / 33KV KRANTI CO-GENERATION NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 408 / KRANTI CO-GEN-II NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 259009 / 400KV KARAD STN.

Feeder No / Name : 807 / 220 KV KARAD KOP LINE 2 ND NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
CRT Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUL-18
HR	Load (MW)
24	.7468
Max	.7468
Min	.7468
Avg	.7468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / 11 KV KADEPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1797	1.1797	1.1012	.1097	.1463	.0701	.0655
2	1.1797	1.1797	1.1012	.1097	.0732	.0716	.0655
3	1.1797	1.1797	1.166	.1097	.0724	.0716	.0671
4	1.2125	1.1142	1.166	.1097	.1448	.0732	.0686
5	1.2452	1.1142	1.166	.1097	.1433	.0739	.0701
6	1.3108	1.1142	1.2308	.1097	.1417	.0747	.0716
7	.1097	.1463	1.3603	.1097	.1417	.1109	.1463
8	.1097	.1311	1.3763	.1097	.1448	.1417	.1433
9	.0732	.1463	1.3603	.1097	.1463	.1417	.1433
10	.1448	.1463	.1463	1.7238	2.1714	1.7695	1.692
11	.1311	.1326	.1463	2.1628	2.1628	2.0873	1.6164
12	.1433	.1387	.1463	2.3967	2.2045	2.1506	
13	.1463	.1387	.1463	2.1376	2.3266	2.0805	
14	.1463	.1387	.1463	2.3868	2.0809	1.9685	1.7976
15	.2195	.1494	.1463	2.2542	2.2211	2.1506	1.8023
16	.1433	.1372	.1463	2.2283	2.3537	2.0005	
17	.2103	.1372	.1463	2.2283	2.2775	2.0729	1.9387
18	.2195	.1372	.1463	.1448	.1578	.1311	.1097
19	.1067	.1326	.1463	.1296	.1265	.1204	.4207
20	.1372	.1326	.1463	.1372	.1296	.0678	.1097
21	1.1012	1.1523	.1463	.1402	.128	.0655	.1097
22	1.1142	1.1523	.1463	.1417	.1341	.064	.1097
23	1.1797	1.1523	.1463	.1463	.1029	.0625	.1097
24	1.1797	1.1797	1.1012	.1097	.1463	.0625	.064
Max	1.3108	1.1797	1.3763	2.3967	2.3537	2.1506	1.9387
Min	.0732	.1311	.1463	.1097	.0724	.0625	.064
Avg	.5801	.5610	.5907	.8106	.8283	.7368	.5105



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1463	.0693	.852	1.0242	.8223	.7926
2	.0732	.1463	.0693	.852	1.0242	.8124	.7316
3	.0732	.1448	.0693	.852	1.0242	.8322	.7316
4	.0732	.1448	.0693	.852	1.0883	.8223	.8025
5	.0732	.1463	.1402	1.0486	1.166	.9922	.8642
6	.0732	.1463	.1417	1.1797	1.2803	1.0242	.8642
7	.0732	.0724	.1372	1.3108	1.4083	1.0562	.9877
8	1.0974	1.2651	.1326	1.3763	1.3443	1.1469	.9877
9	1.3108	1.4723	.1326	1.3763	1.2803	1.1203	.9755
10	1.4373	1.6644	1.3108	.1326	.0655	.1296	.0686
11	1.5546	1.7078	1.4746	.1463	.0648	.128	.0602
12	1.6385	1.7284	.3277	.1372	.0655	.1341	.0533
13	1.2498	1.5623	1.9662		.0655		.0572
14		1.5813	1.9662	.1448	.0716	.1341	.0556
15	1.4899	1.5181	1.9662	.1372	.0701	.1372	.0732
16	.1296	.1296	1.9662	.1372	.0716	.1372	.0732
17	.1372		1.7695		.0362	.1311	.0732
18	.1357	.0686	.1097		.024	.0594	.0732
19	.1174	.1357	.1097	.1265	.061	.0594	.0732
20	.1372	.128	.1097	.1219	.0324	.0655	.0732
21	.1372	.1326	.1097	.1372	.0747	.0648	.0732
22	.1372	.0663	.1097	.0671	.2241	.064	.0732
23	.1463	.0678	.1097	.0678	.032	.064	.0732
24	.0732	.1463	.0693	.852	1.0242	.8322	.8025
Max	1.6385	1.7284	1.9662	1.3763	1.4083	1.1469	.9877
Min	.0732	.0663	.0693	.0671	.024	.0594	.0533
Avg	.4975	.6227	.6015	.5670	.5260	.4682	.3956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1867	.168	.1463	.1463	.1294	.1494
2	.1829	.1867	.1494	.1463	.1463	.128	.168
3	.1829	.1867	.1494	.1463	.1463	.1267	.1867
4	.1829	.1829	.1494	.1463	.1463	.1254	.2241
5	.2195	.2241	.1867	.1463	.1829	.1829	.2427
6	.2561	.2614	.2054	.1463	.2241	.2241	.2614
7	.2743	.2378	.2614	.1463	.2801	.2218	.2772
8	.1829	.1629	.1848	.1646	.2561	.2103	.2054
9	.128	.1052	.1448	.1463	.1791	.197	.168
10	.1402	.1052	.1448	.1433	.1595	.1254	.1663
11	.1187	.104	.1463	.1174	.1227	.1075	.1433
12	.12	.0876	.128	.1252	.124	.1075	.1227
13	.0983	.0709	.128		.104	.0886	.1052
14	.0857	.1075	.128	.1029	.0886	.0905	.1086
15	.0857	.0905	.1097	.081	.1052	.0886	.1097
16	.0857	.1052	.1097	.1463	.1227	.0895	.0732
17	.0532	.104	.1463	.1372	.1254	.1063	.0732
18	.1646	.1029	.1463	.1658	.1311	.1402	.128
19	.1753	.1417	.2561	.2126	.181	.1402	.1646
20	.2012	.2012	.2561		.2218	.2195	.1646
21	.2012	.2033	.2195	.2195	.181	.1867	.2012
22	.1829	.1848	.2012	.1646	.1509	.1848	.1829
23	.168	.1848	.1829	.1463	.132	.1307	.1097
24	.1829	.168	.168	.1829	.1463	.1307	.1307
Max	.2743	.2614	.2614	.2195	.2801	.2241	.2772
Min	.0532	.0709	.1097	.081	.0886	.0886	.0732
Avg	.1607	.154	.1696	.1491	.1585	.1451	.1611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1646	.1646	.1829	.1829	.1478	.132
2	.1829	.1646	.1646	.1829	.1829	.1463	.1509
3		.1646	.1478	.1829	.1829	.1478	.1698
4	.2195	.1829	.1848	.1829	.1829	.1463	.1886
5	.2561	.2241	.2241	.1829	.2012	.1663	.2263
6	.2926	.2641	.2614	.1829	.2241	.1886	.2641
7	.2926	.2587	.2641	.2195	.2801	.1867	.2829
8	.2561	.2195	.2427	.2378	.2378	.2033	.2452
9	.2561	.2378	.2195	.2926	.1829	.2353	.2054
10	.1989	.2378	.2743	.2374	.2149		.1663
11	.2012	.1698	.2561	.2347	.181		.1448
12	.1829	.1989	.2195	.2103	.1433	.2294	.1254
13	.1387	.1658	.1829	.1463	.1254	.2241	.0732
14	.1214	.1595	.1829	.1387	.112	.2035	.1267
15	.1214	.1581	.1829	.2279	.1294	.2012	.128
16	.1357	.1677	.1829	.2343	.1372	.2006	.1463
17	.1629	.1677	.2195	.2401	.1372	.1943	.1463
18	.2012	.1753	.2743	.2378	.1867	.1357	.1646
19	.1991	.2303	.2378	.2012	.1494	.2254	.1646
20	.2195	.2378	.2378	.2058	.2241	.2054	.1829
21	.2427	.2303	.2378	.2303	.2195	.2075	.2195
22	.2241	.2149	.2378	.2012	.2033	.2075	.1829
23	.1646	.1991	.2195	.1829	.1886	.132	.1463
24	.1829	.1646	.181	.2195	.1829	.1494	.132
Max	.2926	.2641	.2743	.2926	.2801	.2353	.2829
Min	.1214	.1581	.1478	.1387	.112	.132	.0732
Avg	.2016	.1983	.2167	.2082	.1830	.1857	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142	1.3108	1.2955	.0914	.0655	.1052	.0671
2	1.1142	1.3108	1.2955	.0914	.0671	.1075	.0671
3	1.1142	1.3603	1.2955	.0914	.0686	.1086	.1029
4	1.1469	1.3603	1.3763	.0914	.0686	.1075	.1029
5	1.1797	1.4251	1.3763	.0914	.0686	.128	.1052
6	1.3169	1.4419	1.4419	.0914	.1387	.1494	.1086
7	.1097	.1341	1.3763	.0914	.1417	.1433	.1463
8	.1097	.0995	1.2452	.0914	.1387	.1417	.1052
9	.1097	.1017	1.2955	.0914	.1311	.1006	.1006
10	.061	.1097	.0914	1.6004	1.6712	2.0553	1.7368
11	.0617	.0937	.0914	2.1216	1.6324	2.0553	1.5565
12	.0617	.0972	.0914	2.3045	.4321	2.6825	1.6907
13	.0625	.0903	.0732			2.3868	
14	.0633	.0949	.0732	2.3967	1.7238	2.332	1.6876
15	.0633	.0949	.0732	2.2024	2.3205	2.4813	1.6385
16	.0663	.088	.0732	2.0729	2.3102	2.1879	1.6385
17	.0625	.088	.1097	2.0081	2.3922	2.1216	1.6385
18	.064	.0914	.1097		.0985	.1235	.0914
19	.0903	.0579	.1097	.1219	.1372	.1402	.0914
20	.0926	.0914	.1097	.1372	.0686	.1326	.0914
21	1.2163	1.3603	.1097	.1143	.1372	.0995	.0914
22	1.2163	1.3603	.0914	.061		.0972	.0914
23	1.2955	1.3603	.0914	.061	.104	.0937	.1097
24	1.1142	1.2955	1.2955	.0914	.061	.104	.0655
Max	1.3169	1.4419	1.4419	2.3967	2.3922	2.6825	1.7368
Min	.061	.0579	.0732	.061	.061	.0937	.0655
Avg	.5378	.6216	.6080	.7325	.6353	.8411	.5707

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / 11 KV KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3584	.3584	.3174	.2452	.1646	.3772
2	.3361	.3584	.3584	.3174	.2452	.1646	.415
3	.3361	.3584	.3772	.3174	.2452	.1629	.4527
4	.3547	.415	.3772	.3174	.2641	.2195	.4904
5	.3734	.4715	.3961	.3174	.3018	.3696	.5658
6	.4755	.6036	.415	.4668	.3395	.4108	.6036
7	.4207	.4715	.4338	.3734	.4338	.3696	.6413
8	.3292	.4715	.3206	.3361	.3395	.2587	.4715
9	.2926	.3772	.3395	.3361	.2427	.2957	.415
10	.3206	.3045	.2829	.2641	.2241	.2641	.3361
11	.3772	.415	.2829	.3206	.1848	.2402	.2587
12	.3772	.3772	.3018	.2641	.1867	.2402	.2587
13	.3772	.3395	.2926	.1698	.1294	.2641	.3395
14	.2641	.3395	.2641	.2263	.1463	.2263	.2641
15	.3584	.3772	.2452	.2427	.1227	.2075	.2561
16	.3772	.3206	.2452	.2829	.1227	.2263	.3174
17	.415	.3206	.2263	.2641	.2033	.2075	.3361
18	.415	.2926	.2452	.2452	.1907	.2641	.3734
19	.3961	.3206	.2641	.2641	.2033	.2829	.3734
20	.415	.3206	.3174	.2829	.2614	.3772	.3921
21	.4338	.2829	.3174	.2829	.2614	.3395	.4294
22	.415	.3018	.3361	.2641	.2241	.3395	.3734
23	.3772	.3395	.3174	.2452	.1663	.3206	.3361
24	.3361		.3395	.3174	.2452	.1663	.3018
Max	.4755	.6036	.4338	.4668	.4338	.4108	.6413
Min	.2641	.2829	.2263	.1698	.1227	.1629	.2561
Avg	.3712	.3712	.3189	.2932	.2304	.2659	.3908

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / 33 KV SAGARESHWAR SAHAKARI NON SHEDDABLE EHV INDUSTRIAL FEEDERS

SOO Feeder KV- 33 / OUTGOING

(NON CONTINOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3765	2.4897	2.5463	2.32	2.4897	1.0751	2.3765
2	2.3765	2.4897	2.5463	2.32	2.4897	1.0751	2.3765
3	2.3765	2.4897	2.6029	2.3765	2.4331	1.0751	2.4331
4	2.3765	2.4331	2.6029	2.3765	2.4897	1.0751	2.4331
5	2.3765	2.4897	2.6029	2.3765	2.4897	1.1317	2.4331
6	2.6595	2.5463	2.7161	2.4897	2.4897	1.1883	2.5463
7	2.4331	2.3765	2.5463	2.4897	2.5463	1.358	2.4331
8	2.4897	2.4331	2.5463	2.5463	2.2634	1.6409	2.6029
9	2.2068	2.4897	2.4331	2.3765	1.3014	2.2068	2.4331
10	2.32	2.32	2.4331	2.32	1.358	2.3765	2.32
11	2.32	2.4331	2.3594	2.4331	1.2449	2.2634	2.3765
12	2.3765	2.4331	2.4331	2.6029	1.2449	2.6029	2.3765
13	2.4331	2.5463	2.4897	2.6029	1.1883	2.6029	2.3765
14	2.0936	2.6029	2.6029	2.5463	1.3014	2.5463	2.5463
15	2.5463	2.32	2.6595	2.6595	1.1883	2.4331	2.3765
16	2.4897	2.4331	2.6029	2.5463	1.1883	2.4331	2.3765
17	2.32	2.2634	2.32	2.32	1.2449	2.3765	2.2634
18	2.3765	2.32	2.4331	2.2634	1.1317	2.3765	2.32
19	2.1502	2.2068	2.3765	2.2634	1.0751	2.32	2.2634
20	2.2634	2.32	2.32	2.32		2.32	2.2634
21	2.4897	2.3765	2.2634	2.2634	1.1317	2.32	2.2068
22	2.4897	2.3765	2.2634	2.3765	1.0751	2.4331	2.2634
23	2.5463	2.4897	2.2634	2.4897	1.0751	2.2634	2.4331
24	2.32	2.5463	2.4897	2.2634	2.4897	1.0751	2.4331
Max	2.6595	2.6029	2.7161	2.6595	2.5463	2.6029	2.6029
Min	2.0936	2.2068	2.2634	2.2634	1.0751	1.0751	2.2068
Avg	2.3836	2.4261	2.4772	2.4143	1.6926	1.9404	2.3860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / 11 KV KADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7316	.6602	.679	.6584	.5729	.6036
2	.7468	.6653	.6602	.6413	.5544	.5601	.5847
3	.7545	.5487	.6602	.6413	.5487	.5601	.5658
4	.7167	.724	.679	.679	.6516	.6036	.5658
5	.7922	1.0608	.7545	.7545	.8413	.679	.7167
6	1.226	1.1458	1.1317	1.1694	1.1088	1.0719	1.1694
7	1.3443	1.2071	1.4146	1.4937	1.2986	1.4563	1.4712
8	1.3817	.8871	1.307	1.2567	1.0974	1.2197	1.2826
9	1.1088	1.0242	1.1458	1.1827	.9145	1.0719	1.0456
10	.9877	.8507	.924	.9511	.8131	.9522	.961
11	.9511	.8779	.9145	.905	.7164	.8589	
12	.905	.823	.8413	.8779	.695	.8402	
13	.7682		.8048	.7865	.6219	.7796	.823
14	.6653	.9313	.8048	.7316	.6089	.7522	.7682
15	.6584	.724	.8048	.724	.6335	.724	.7682
16	.543	.724	.8048		.642	.7164	.8145
17	.5853	.724	.8413	.788	.5853	.7522	.8145
18	.6653	.8145	.9313	.8688	.7316	.9412	.9955
19	.6584	1.0059	1.0242	1.0242	.8596	1.0608	1.0974
20	.724	1.2012	1.2696	1.2197	1.0719	1.2197	1.2136
21	.9145	1.1203	1.1576	1.0974	1.0082	1.0082	1.1203
22	1.1088	.9808	1.1317	1.0349	.8962	.8962	.9431
23	1.0059	.8488	.9431	.8779	.7023	.7922	.7167
24	.8029	.8871	.679	.7545	.7392	.5975	.6413
Max	1.3817	1.2071	1.4146	1.4937	1.2986	1.4563	1.4712
Min	.543	.5487	.6602	.6413	.5487	.5601	.5658
Avg	.8666	.8917	.9288	.9191	.7916	.8620	.8947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / 11 KV MIDC NO.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2934	1.3203	1.3032	1.2986	1.3306	1.2357	1.262
2	1.2934	1.3443	1.2536	1.2803	1.3169	1.2357	1.262
3	1.2757	1.3676	1.2536	1.2803	1.267	1.2437	1.2437
4	1.2894	1.2803		1.2851	1.2803	1.2437	1.2308
5	1.2715	1.3032	1.3253	1.3032	1.2567	1.2178	1.2489
6	1.2894	1.3169	1.3756	1.3032	1.2803	1.2048	1.267
7	1.2715	1.3169	1.3032	1.267	1.3032	1.2894	1.2178
8	1.2536	1.2936	1.3032	1.2489	1.0288	1.2357	1.1163
9	1.3169	1.3169	1.3535	1.3352	.8223	1.39	1.2178
10	1.3717	1.3756	1.39	1.3121	.7682	1.307	1.3535
11	1.3394	1.4045	1.3352	1.3306	.7676	1.3535	1.267
12	1.3169	1.3676	1.3535	1.3394	.8025	1.2803	1.2803
13	1.3676	1.267	1.3535	1.3169	.5658	1.2437	1.2757
14	1.3535	1.3676	1.3535	1.2936	.5756	1.262	1.267
15	1.3756	1.4045	1.386	1.3169	.7676	1.2936	1.3032
16	1.1088	1.4045	1.3535	1.3676	.5746	1.2437	1.3676
17	1.2803	1.3169	1.3535	1.3169	.5647	1.2127	1.3169
18	1.3169	1.3169	1.267	1.3169	.4359	1.2803	1.3169
19	1.2012	1.3169	1.267	1.3253	.535	1.2803	1.3169
20	1.2936	1.3169	1.3032	1.3535	.5548	1.2986	1.267
21	1.3169	1.3169	1.3032	1.267	1.2254	1.3169	1.3169
22	1.3676	1.3169	1.267	1.3169	1.2437	1.2986	1.267
23	1.3817	1.3032	1.267	1.2936	1.2357	1.2803	1.267
24	1.3112	1.358	1.3032	1.2986	1.2986	1.2357	1.2803
Max	1.3817	1.4045	1.39	1.3676	1.3306	1.39	1.3676
Min	1.1088	1.267	1.2536	1.2489	.4359	1.2048	1.1163
Avg	1.3024	1.3339	1.3186	1.3070	.9501	1.2702	1.2721



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / 11 KV SHALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0905	.0754	.8124	.421	.3763	.4428
2	.0924	.0914	.0754	.8124	.4915	.3311	.4111
3	.0934	.0739	.0754	.8223	.4973	.3715	.3795
4	.112	.0732	.0754	.8539	.5243	.3567	.3749
5	.132	.1075	.0754	.9602	.6401	.3612	.4687
6	.1509	.1417	.1509	1.0722	.7449	.5093	.4999
7	.1509	.1463	.1886	1.1544	.9503	.6401	.6642
8	.6636	1.1523	.1294	1.1248	.8642	.7968	.7274
9	.9842	1.1797	.1267	1.0467	.8745	.6562	.6327
10	1.1843	1.1768	1.2955	.1109	.0732	.1307	.112
11	1.2803	1.2308	1.6842	.1097	.1294	.0934	.0934
12	1.3603	.6325	1.6404	.0924	.1463	.0716	.112
13	1.4091	1.2967	1.6644	.0924	.1294	.0678	.0747
14	1.3123	1.3123	1.6964	.0732	.1109		.0924
15	1.2967	1.2803	1.749	.0739	.0914		.0724
16	.1097	.0686	1.5181	.0732	.0934	.0686	.0724
17	.1109	.0876	1.4232	.0724	.1478	.0693	.0701
18	.128	.1063	.1029	.0914	.112	.1052	.0867
19	.1448	.1448	.1029	.1097	.1075	.1254	.1052
20	.1463	.1463	.1052	.128	.1478	.1463	.1478
21	.1294	.1307	.1075	.1294	.1097	.128	.1294
22	.128	.0943	.1097	.1097	.0943	.1109	.112
23	.1097	.0754	.112	.0924	.0924	.0924	.0747
24	.1109	.0905	.0754	.787	.3841	.3913	.506
Max	1.4091	1.3123	1.749	1.1544	.9503	.7968	.7274
Min	.0924	.0686	.0754	.0724	.0732	.0678	.0701
Avg	.4764	.4554	.5983	.4502	.3324	.2727	.2693

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / 11 KV KADEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.4801	.6097	.1254	.0914	.1097	.0876
2	.4572	.4915	.5487	.1254	.0924	.1109	.0914
3	.4572	.5304	.5418	.128	.0732	.1097	.0914
4	.463	.5898	.5418	.1463	.0724	.1097	.112
5	.5247	.6401	.5418	.1478	.0914	.1307	.112
6	.5864	.6874	.8223	.1478	.1109	.1478	.132
7	.1448	.0914	.9717	.2033	.1463	.1478	.1494
8	.1463	.0924	.8322	.1629	.128	.1829	.1629
9	.1417	.0914	.7907	.1829	.1086	.1478	.1448
10	.1097	.1086	.1433	1.2018	1.0242	1.166	.8855
11	.1075	.1086	.1075	1.8244		1.5074	.8855
12	.0905	.1075	.1052	1.9433		1.5364	.7274
13	.0732	.1075	.1227	1.9006	1.2342	1.5497	.7186
14	.0924	.128	.1372	1.7604	1.2342	1.4232	.7907
15	.1097	.1402	.1326	1.6385	1.2342	1.3441	.8223
16	.0914	.1387	.1326			1.0936	.8855
17	.0924	.1387	.1326	.3048	1.1092	1.0364	.8223
18	.1097	.1387	.1638	.0914	.108	.1174	.116
19	.1109	.1791	.1509	.0924	.1509	.12	.12
20	.1494	.1463	.1543	.1097	.1463	.1254	.1417
21	.5967	.6958	.1402	.1267	.1294	.1052	.1075
22	.5898	.6874	.1433	.128	.1294	.0867	.1063
23	.5506	.6481	.1267	.1294	.128	.0857	.1052
24	.503	.5243	.6097	.1254	.1097	.1109	.0857
Max	.5967	.6958	.9717	1.9433	1.2342	1.5497	.8855
Min	.0732	.0914	.1052	.0914	.0724	.0857	.0857
Avg	.2827	.3205	.3626	.5542	.3644	.5252	.3502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 205 / 11 KV MIDC NO.2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.0974	1.0631	1.0166	1.2803	.9877	.9774
2	1.2803	1.1222	1.1104	1.0166	1.3306	1.0242	.9412
3	1.2803	1.1706	1.1222	.9816	1.086	1.0425	.9511
4	1.1888	1.1827	1.1706	.9709	1.1104	1.0534	1.0242
5	1.1765	1.0974	1.1706	.9882	1.0974	1.0719	1.0719
6	1.1222	.9412	1.1104	.9882	1.0349	1.1088	1.1088
7	1.1462	1.0974	1.0631	1.0402	1.0242	.9511	1.0387
8	1.0924	.9979	.9602	.8619	.7621	.9671	.7074
9	1.1443	1.2803	.9709	.9745	.5281	1.134	1.3032
10	1.4045	1.6651	1.0059	1.0608	.5365	1.4335	2.037
11	1.3169	2.0748	1.4563	1.0974	.5784	1.5844	2.4143
12	1.3676		1.2803	1.1462	.5533	1.3817	2.3765
13	1.2936	1.4335	1.1765	1.3169	.6358	1.2752	2.037
14	1.3535	1.4937	1.1888	1.3032	.2707	1.3535	1.9993
15	1.1946	1.4937	1.1888	1.6461	.2835	1.4563	1.9993
16	1.0974	1.5844	1.2803	1.5154		1.419	2.2634
17	1.267	1.6804	1.3443	1.5684	.2881	1.3443	1.6221
18	1.2803	1.2936	1.386	1.4784	.2599	1.2752	1.2449
19	.7392	1.3443	1.3676	1.4998	.3018	1.0631	1.8861
20	1.0974	1.3443	1.3169	1.4045	.6371	.7274	1.0029
21	1.2012	1.2936	1.2803	1.3535	.8589	.9259	1.2197
22	1.307	1.2936	1.2437	1.2936	.8048	1.0166	1.419
23	1.3306	1.2323	1.1706	1.2803	.9465	1.1041	1.2936
24	1.363		1.0631	1.0517	1.2197	.9313	1.086
Max	1.4045	2.0748	1.4563	1.6461	1.3306	1.5844	2.4143
Min	.7392	.9412	.9602	.8619	.2599	.7274	.7074
Avg	1.2245	1.3279	1.1871	1.2023	.7578	1.1513	1.4594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / 11 KV SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2926	.1886	.2241	.2534	.2054	.1698
2	.1867	.2587	.1886	.1867	.1829	.1886	.1698
3	.1867	.2561	.1886	.1867	.1848	.1829	.1698
4	.2263	.2896	.2241	.2263	.2195	.2033	.1886
5	.415	.3658	.2614	.2641	.2896	.2614	.3018
6	.5281	.3978	.5281	.5281	.439	.4755	.5281
7	.5601	.4755	.5975	.5788	.5914	.6036	.5975
8	.3881	.4435	.4805	.4572	.4755	.4024	.462
9	.3814	.3658	.3658	.362	.3696	.3841	.3658
10	.3481	.2896	.3315	.3222	.2957	.3467	.3077
11	.3429		.3401	.3326	.2865	.2328	.2865
12	.3224		.3086	.2587	.3277	.2058	.2172
13	.2896		.2427	.2172	.2865	.1696	.181
14	.2561	.3121	.3086	.2195	.1791	.1966	.181
15	.2454	.3239	.3239	.1848	.2149	.2214	.2743
16	.2507	.3563	.3605	.2195		.2683	.2321
17		.3086	.3768	.2195	.3814	.3052	.2915
18		.3521	.3353	.3292	.373	.3561	.3429
19	.2195	.394	.4115	.4066	.3761	.4298	.362
20	.2896	.4805	.4458	.4755	.4572	.4755	.4435
21	.439	.4435	.3467	.4344	.3841	.439	.4108
22	.4805	.3734	.3224	.439	.3475	.3734	.3326
23	.3658	.2987	.2801	.3696	.2587	.2075	.2241
24	.2987	.2896	.2241	.2427	.2926	.2241	.1886
Max	.5601	.4805	.5975	.5788	.5914	.6036	.5975
Min	.1867	.2561	.1886	.1848	.1791	.1696	.1698
Avg	.3310	.3508	.3326	.3202	.3246	.3066	.3012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0914	.0566	.3353	.3841	.2286	.2881
2	.0747	.0739	.0566	.3437	.3932	.2258	.253
3	.0943	.0732	.0566	.3437	.3647	.2258	.1898
4	.0943	.0724	.0566	.3749	.3277	.2286	.192
5	.0943	.0914	.0566	.4111	.3521	.2469	.2241
6	.0943	.0934	.0943	.427	.421	.3749	.2881
7	.1132	.1097	.1132	.4843	.5243	.5182	.3521
8	.5218	.6249	.0943	.4572	.4744	.4744	.3887
9	.6167	.6401	.0754	.4784	.4807	.3906	.3521
10	.7362	.6722	.4801	.0924	.1097	.0716	.056
11	.8002	.6401	.5601	.0914	.1097	.056	.056
12	.852	.5624	.6401	.0724	.0914	.0526	.0554
13	.8322	.4938	.6483	.112	.0914	.0509	.056
14	.7773	.4167	.6642	.0943	.0549	.0526	.056
15	.7811	.4374	.68	.0934	.0554	.0543	.056
16	.0914	.0554	.6642	.0739	.0554	.0716	.0554
17	.1086	.056	.6249	.0732	.056	.0716	
18	.1097	.0532	.0732	.0732	.0732	.0732	.0537
19	.1109	.056	.0732	.0924	.0739	.0747	.0549
20	.128	.0747	.0739	.0914	.0732	.0754	.0716
21	.1086	.0754	.056	.1109	.0739	.0754	.0549
22	.1097	.0566	.056	.0905	.056	.056	.0554
23	.0924	.0566	.056	.0924	.056	.0554	.0366
24	.0747	.0914	.0566	.3201	.3125	.2469	.3201
Max	.852	.6722	.68	.4843	.5243	.5182	.3887
Min	.0747	.0532	.056	.0724	.0549	.0509	.0366
Avg	.3121	.2362	.2528	.2179	.2110	.1688	.1550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 201 / 11 KV TONDOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.7737	1.5257	2.0748	.3475		.2561	.3361
7	.3772	.3658	2.1472	.3841	.2587	.3109	.3734
8	.3361	.2957	2.0328	.3292		.2926	.2829
9	.3772	.2865	1.9605	.2926		.1829	.2241
10	.2328	.3734	.3292	2.0687	1.9725	2.1253	1.7556
11	.2641	.2829	.2561	3.2156	2.0481	2.894	1.5912
12	.2801	.2801	.3109	3.4145	2.0809	3.0178	1.6194
13		.2801	.3326	3.3532		3.1741	1.6194
14		.3206	.3292	3.3813		3.0178	1.587
15		.3361	.3475	3.493		2.7073	1.4723
16		.4715	.1829	3.3867		2.7349	1.4723
17		.4668	.439	3.2895	2.0972	2.4272	1.3916
18		.3772	.439	2.7515	.2195	.1886	
19		.3361	.3658	.2641	.2561	.2241	.2218
24	1.5089		1.7737	.2195		.1829	.1886
Max	1.7737	1.5257	2.1472	3.493	2.0972	3.1741	1.7556
Min	.2328	.2801	.1829	.2195	.2195	.1829	.1886
Avg	.6438	.4285	.8881	2.0127	1.2761	1.5824	1.0097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 202 / 11 KV RAIGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1402	.1886	.2263	1.8842		1.6385	
7	.1494	.1829	.1928	2.1628	1.8564	1.8515	
8	1.4746	2.4417	.181	2.13	.1989	2.0645	
9	2.3472	3.1017	.2195	2.13		2.0317	
10	3.0498	3.1017	2.556	.1848	.2743	.1581	
11	3.0664	3.2693	3.0803	.1867	.2772	.2172	
12	.4748	3.1855	2.982	.1829	.2561		.0924
13		3.2693	3.1786	.2149			
14		3.2693	2.982			.2353	
15		3.1855	2.9984			.2743	.112
16		.1753		.2195		.2241	.112
17		.2195	2.8509	.2507	.2743	.2263	.1109
18		.2218	.2195	.2743	.2926	.2241	
19		.2172	.2012	.2804	.2561	.2263	.168
24	.0905		.1448	1.8515		1.6549	
Max	3.0664	3.2693	3.1786	2.1628	1.8564	2.0645	.168
Min	.0905	.1753	.1448	.1829	.1989	.1581	.0924
Avg	1.3491	1.8592	1.5724	.9194	.4607	.8482	.1191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 203 / 11 KV SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8402	.8299	.7468	.7392		.7207	.7316
7	.9431	.823	.8488	.8131	.8676	.8501	.9955
8	.7545	.7167	.8402	.6283	.6653	.7023	.7316
9	.7545	.5853	.7545	.6283	.6036	.5544	.5544
10	.5853	.6602	.6283	.6219	.5175	.5601	.5601
11	.6089	.6535	.5914	.5975	.5359	.6602	.4854
12	.6722	.6535	.5729	.5373	.5544	.5601	.4904
13		.5853	.5729	.5853		.5658	.4854
14		.6468	.5359	.4706		.4668	.415
15		.5601	.5729	.3734		.4668	.4527
16		.5658		.4527		.4668	.439
17		.6535	.6468	.4755	.4435	.4715	.5373
18		.8488	.5729	.5975	.5729	.5601	
19		.9335	.6468	.6268	.6283	.6602	.7095
24	.5281		.5658	.4805		.439	.4668
Max	.9431	.9335	.8488	.8131	.8676	.8501	.9955
Min	.5281	.5601	.5359	.3734	.4435	.439	.415
Avg	.7109	.6940	.6498	.5752	.5988	.5803	.5753



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.5546	1.0174	1.1203	.1802		.1802	.1753
7	.3696	.2452	1.226	.1966	.0549	.1966	.1753
8	.1829	.1254	1.1203	.1475	.0377	.1638	.1867
9	.2218	.0934	1.0374	.0819	.0362	.1311	.1097
10	.2054	.132	.1147	1.3748		1.5089	1.386
11	.2218	.1307	.1147	1.5402	.3605	2.0348	1.21
12	.2263	.1509	.1147	1.9669	.4752	1.9719	1.2929
13		.1494	.1475	2.0957		2.191	1.21
14		.1509	.1311	1.989		2.1719	1.1961
15		.0934	.1311	2.0687			1.1142
16		.0943	.1638	2.0222			1.1305
17		.1307	.1475	2.0119	1.3599	1.9204	1.065
18		.1132	.1147	.0943	.1311	.1267	
19		.1494	.1475	.1646	.1638	.128	.116
24	1.3717		1.0374	.0983		.0983	.0905
Max	1.5546	1.0174	1.226	2.0957	1.3599	2.191	1.386
Min	.1829	.0934	.1147	.0819	.0362	.0983	.0905
Avg	.5443	.1983	.4579	1.0689	.3274	.9864	.7470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1867	.128	.132	.8029		.639	.6036
7	.1886	.128	.1886	.8848	.1463	.7701	.6335
8	.4668	.7461	.1307	.8684	.128	.7209	.6401
9	.7545	.8886	.1132	.8192	.0995	.7701	.6335
10	.961	.9326	1.1142	.1109		.1844	.0914
11	.9808	.9221	1.1961	.0905		.0678	.08
12	.9997	1.0174	1.2616	.0876		.0838	.064
13		1.0059	1.3927	.1494			.064
14		1.0174	1.4091	.1097		.0848	.064
15		1.0898	1.4419	.1132			.064
16		.0934	1.3435	.1478			.064
17		.1063	1.2289	.1463		.0876	.064
18		.1307	.0819	.1433		.0905	
19		.1132	.0983	.1629	.1147	.1463	.0983
24	.0934		.056	.639		.5898	.5792
Max	.9997	1.0898	1.4419	.8848	.1463	.7701	.6401
Min	.0934	.0934	.056	.0876	.0995	.0678	.064
Avg	.5789	.5943	.7459	.3517	.1221	.3529	.2674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2353	.1646	.1886	.1663		
7	.2378	.1494	.1886	.1663	.1698	
8	.2353	.1629	.1867	.1663	.1612	
9	.2378	.3772	.6602	.7392	.6401	
10	.2452	.6161	.7023	.7167		
11	.3696	.6036	.6838	.6805	.4066	
12	.4854	.4715	.6653	.6979	.4066	
13		.4108	.6653	.6602		
14		.6036	.6653	.6516		.2195
15		.6535	.6653	.6908		
16		.1698	.1478	.168		
19				.7167		
Max	.4854	.6535	.7023	.7392	.6401	.2195
Min	.2353	.1494	.1478	.1663	.1612	.2195
Avg	.2923	.3985	.4927	.5184	.3569	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1248	1.3441	1.278	.1448	.1254	.1214	.1448
2	1.0957	1.3108	1.278	.1448	.1254	.1214	.1646
3	1.0802	1.3108	1.2146	.1629	.1086	.1029	.1646
4	1.0669	1.2793	1.2793	.1991	.1296	.1029	.1448
5	1.1431	1.2793	1.2811	.2353	.1612	.1357	.1791
6	1.3565	1.5074	1.5238	.2715	.2303	.2374	.2149
7	.2155	.2105	1.587	.3077	.2686	.2347	.2507
8	.1989	.1966	1.3923	.2715	.197	.218	.2195
9	.2012	.2105	1.4582	.2172	.1646	.2204	.181
10	.1844	.1886	.1966	1.6804	2.0715		2.2314
11	.1526	.1865	.2353	2.2672			1.9271
12	.1886	.2149	.2353	2.4577	2.2245		1.9271
13	.1886	.2149	.2534	2.4413	2.0485		1.9109
14	.1772	.197	.2172	2.4291	2.1125		1.9433
15	.181	.2012	.2534	2.4291	2.1538		1.8299
16	.1991	.1463	.2534	2.4905	1.9919		1.8299
17	.2012	.2054	.2353	1.9919	1.8947		1.7004
18	.2012	.1886	.1991		.1715	.1629	.1433
19	.2012	.2075	.2172	.1991	.1734	.1829	.1433
20	.2195	.2263	.2172	.1829	.1734	.2012	.1629
21	1.2955	1.3763	.1991	.1829	.1753	.1433	.1433
22	1.4255	1.3108	.181	.1629	.1578	.1254	.1433
23	1.4089	1.3763	.1629	.1463	.1227	.1254	.1254
24		1.4091	1.3599	.1629	.1267	.1214	.1829
Max	1.4255	1.5074	1.587	2.4905	2.2245	.2374	2.2314
Min	.1526	.1463	.1629	.1448	.1086	.1029	.1254
Avg	.5960	.6791	.6962	.9208	.7439	.1598	.7504

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2172	.1718	.9374	1.186	.7133	.7537
2	.1505	.2229	.1875	.9842	1.1843	.6859	.7011
3	.1505	.2317	.1875		1.1984	.6493	.7682
4	.1486	.2172	.2187	1.0623	1.2308	.6493	.7343
5	.208	.2317	.1829	1.0936	1.2018	.7335	.7655
6	.2494	.3041	.2968	1.2029	1.2163	.8935	.8688
7	.2751	.3041	.3241	1.3435	1.5384	.9869	1.0957
8	.8802	1.326	.3395	1.4373	1.2955	1.0416	1.1888
9	1.2269	1.6204	.3749	1.3592	1.2289	1.0669	1.1405
10	1.2445	1.6821	1.5466	.2968	.2622	.23	.2056
11	1.3527	1.7497	1.7497	.3321	.3041	.2667	.2035
12	1.454	1.7341	1.7966	.3163	.2721	.2435	.1865
13	1.4678	1.8278	1.8747	.3361	.208	.2	.2204
14	1.387	1.768	1.9841	.3521	.2721	.2029	.2374
15	1.3662	1.7901	1.7654	.3521	.3479	.16	.2035
16	.2534	.2743	1.7966	.3521	.2846	.1353	.2543
17		.2968	1.6716	.1475	.2812	.1217	.2713
18	.3549	.2932	.3814	.1943	.3437	.2606	.2883
19	.3658	.3241	.3294	.3113	.25	.2058	.2713
20	.2968	.3125	.3294	.2267	.2656	.192	.3052
21	.2623	.25	.3121	.2622	.2778	.1808	.2374
22	.2134	.2214	.2427	.2753	.2439	.1551	.2035
23	.2134	.2006	.9414	.2294	.2286	.1581	.1865
24	.1524	.2317	.1698	.9686	1.186	.727	.7164
Max	1.4678	1.8278	1.9841	1.4373	1.5384	1.0669	1.1888
Min	.1486	.2006	.1698	.1475	.208	.1217	.1865
Avg	.6011	.7347	.7990	.6249	.6795	.4525	.5003

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0732	.056	.5281	.5344	.4428	.5506
2	.0693	.0905	.056	.5441	.5407	.4218	.5281
3	.0693	.0923	.0566	.5761	.5243	.4218	.4801
4	.0686	.0724	.0754	.5601	.5243	.4012	.4744
5	.12	.0732	.112	.6081	.5407	.4321	.506
6	.1696	.1629	.1307	.6882	.5182	.4268	.4858
7	.1677	.2195	.1886	.7362	.6226	.6401	.5735
8	.7011	.8326	.1494	.7682	.6226	.6554	.5668
9	.8488	.7701	.132	.7842	.5992	.5639	.5898
10	.8905	.7522	.7522	.0895	.0914	.1075	.081
11	.9014	.8356	.8642	.0716	.128	.0914	.0905
12	.8962	.8002	.8482	.0895	.1097	.0914	.0724
13	.8482	.787	.8482	.1075	.1097	.1086	.0543
14	.7935	.7562	.8802	.0914	.1097	.1075	.0905
15	.9175	.6405	.8482	.0914	.1097	.1254	.0905
16	.1097	.08	.8162	.0648		.0716	.1086
17	.1646		.8162	.081			.0905
18	.1448	.112	.1075		.1086	.0914	.0905
19	.1097	.1494	.1612	.1086	.1267	.128	.0905
20	.1267	.1509	.1433	.1086	.1254	.128	.1086
21	.0914	.112	.1075	.0914	.0895	.1086	.1086
22	.0914	.0754	.1075	.0914	.0709	.0914	.0724
23	.0914	.0754	.5761	.0724	.0709	.0732	.0724
24	.0701	.0724	.0754	.5601	.5506	.4586	.5668
Max	.9175	.8356	.8802	.7842	.6226	.6554	.5898
Min	.0686	.0724	.056	.0648	.0709	.0716	.0543
Avg	.3555	.3385	.3712	.3266	.3104	.2691	.2726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.7373	.5761	.0678	.0686	.0693	.0819
2	.6249	.7373	.5376	.0509	.0857	.0693	.0648
3	.5864	.6958	.5121	.0509	.0867	.0686	.0655
4	.571	.7287	.5182	.0678	.0693	.0686	.0486
5	.6097	.7373	.5693	.0678	.0857	.0678	.0655
6	.7011	.7773	.6401	.1017	.0686	.1017	.0655
7	.0663	.0819	.6882	.0848	.104	.1006	.081
8	.0497	.081	.6722	.0514	.104	.1006	.0655
9	.1006	.0819	.6401	.0686	.0514	.0848	.0492
10	.1017	.096	.0625	.8059	.8495	.7316	.7116
11	.1029	.0983	.0678	1.0402	.9488	.8025	.7407
12	.0867	.096	.1017	1.2136	.933	.9088	.7716
13	.0867	.096	.1187	1.1317	.9646	.823	.7716
14	.1029	.0949	.1187		.9602	.8025	.8025
15	.0867	.096	.1017		.9442	.7926	.8025
16	.12	.096	.1187		.9231	.953	.7562
17	.104	.112	.1187		.9069		.8488
18	.1029	.1147	.0848			.081	.0509
19	.1029	.0914	.1017	.1029	.104	.0829	.0848
20	.1029	.0819	.1017	.0867	.104	.1147	.1017
21	.7099	.6241	.0848	.0867	.0876	.0819	.0678
22	.7407	.6316	.0848	.0867	.0876	.0648	.0678
23	.7274	.6081	.0678	.0857	.0701	.0655	.0509
24	.6562	.7274	.5761	.0678	.0678	.0693	.0648
Max	.7407	.7773	.6882	1.2136	.9646	.953	.8488
Min	.0497	.081	.0625	.0509	.0514	.0648	.0486
Avg	.3279	.3468	.3027	.2800	.3772	.3089	.3034

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.1311	.8951	.8669	.7907	.7748
2	.1017	.0857	.1134	.9105	.8322	.7499	.7907
3	.1017	.1017	.128	.9259	.823	.7343	.7499
4	.1017	.0838	.128	.9568	.8669	.7186	.7499
5	.1341	.1006	.128	1.0031	.9088	.7407	.7748
6	.218	.213	.1981	1.0648	.9774	.8796	.8539
7	.2321	.1619	.192	1.2963	1.2309	1.0517	1.0402
8	.9602	1.3599	.16	1.1111	1.3003	1.0669	1.012
9	1.1883	1.5061	.144	1.1574	1.2517	1.0517	.9646
10	1.3904	1.5364			.1387	.1107	.081
11	1.4373	1.5043	1.6204		.1402	.1107	.1017
12	1.4737	1.5043	1.6975		.1949	.096	.1029
13	1.4899	1.4883	1.713		.1791	.112	.1029
14	1.6221	1.4243	1.6204		.181	.1581	.1029
15	1.7924	1.3443	1.5432		.181	.112	.0857
16	.1781	.112	1.5895		.2012	.1134	.1029
17	.2713	.144	1.5432		.2195	.1457	.1029
18	.2515	.1581	.1886		.2054	.1638	.12
19	.2347	.176	.1543	.1772	.2353	.1296	.1372
20	.1267	.176	.1715	.1772	.181	.0983	.1543
21	.1448	.16	.1886	.1612	.1629	.1311	.1372
22	.1227	.1638	.1543	.1417	.1595	.1134	.12
23	.12	.1311	1.046	.1254	.1417	.0983	.1029
24	.1029	.1017	.1311	.9259	.8402	.8065	.759
Max	1.7924	1.5364	1.713	1.2963	1.3003	1.0669	1.0402
Min	.1017	.0838	.1134	.1254	.1387	.096	.081
Avg	.5791	.5760	.6384	.7353	.5175	.4285	.4177



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2303	.2865	.2507	.2507	.2126	.2303	.2303
2	.2126	.3045	.2507	.2149	.2149	.2103	.2481
3	.2103	.2835	.2686	.2328	.2303	.2103	.2481
4	.2279	.3189	.2686	.3224	.3189	.208	.2279
5	.3467	.2835	.3403	.3898	.2507	.3467	.3189
6	.5487	.5552	.5014	.5138	.4298	.5316	.5316
7	.4973	.5014	.5792	.5316	.5194	.5316	.591
8	.3772	.4298	.4477	.4252	.3761	.4801	.4656
9	.3641	.3224	.3403	.3224	.3045	.3814	.3045
10	.3155	.3544	.3045		.2865	.3772	.2507
11	.298	.3761	.3045		.2328	.3294	.2686
12	.3045	.3189	.3224		.2353	.3366	.2686
13	.2507	.2686	.3403		.2561	.3012	.2328
14	.2328	.2686	.3045		.2587	.2507	.2507
15	.3224	.3045	.3403		.2587	.2149	.2149
16		.3224	.3045		.2587	.2149	.2149
17	.3109	.3475	.3224		.2378	.2328	.2686
18	.2896	.3582	.3403		.3658	.3761	.2865
19	.3658	.394	.4075	.394	.4207	.4298	.3582
20	.394	.4835	.4961	.4119	.4163	.4481	.4835
21	.4119	.4119	.443	.3721	.3982	.4119	.4298
22	.3475	.3582	.3721	.3012	.3403	.3403	.3403
23	.3292	.2686	.3045	.2507	.2686	.2865	.2686
24	.2303	.3045	.2686	.2686	.2328	.2303	.2328
Max	.5487	.5552	.5792	.5316	.5194	.5316	.591
Min	.2103	.2686	.2507	.2149	.2126	.208	.2149
Avg	.3225	.3511	.3510	.3468	.3052	.3296	.3140

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2926	.3395	.3326	.2801	.2452	.2402
2	.2801	.2772	.3395	.3547	.2801	.2229	.2241
3	.2829	.3475	.3547	.3696	.2987	.2241	.2218
4	.2829	.4251	.3584	.4108	.2801	.2241	.2614
5	.3361	.4572	.4715	.4481	.4294	.2427	.3326
6	.5601	.499	.5975	.5544	.462	.4715	.4481
7	.6348	.6535	.679	.6161	.5487	.5415	.5914
8	.5788	.5729	.5975	.5544	.5175	.4481	.5228
9	.499	.4572	.5093	.5415	.3921	.4668	.2587
10	.5544	.5175	.4481	.6099	.439	.3206	.3174
11	.4668	.5788	.3696	.543	.3361	.3734	.2987
12	.4251	.547	.3921	.4572	.2427	.3511	.2614
13	.4066	.3921	.3881	.3292	.2829	.3361	.2241
14	.3921	.415	.3921	.3881	.2614	.3142	.2241
15	.3881	.4668	.4066	.462	.2641	.3696	.2427
16	.3658	.3547	.4066	.4854	.3734	.3696	.2402
17	.462	.5093	.4481	.5228	.3395	.4108	.2772
18	.5544	.5228	.462	.499	.3921	.4435	.3326
19	.5853	.5415	.4805	.462	.4715	.5544	.462
20	.6535	.6979	.6535	.3841	.5788	.6161	.462
21	.5175	.5601	.5729	.3696	.4715	.5914	.4435
22	.4572	.4904	.4854	.4024	.3547	.4481	.4066
23	.3696	.3734	.3696	.2772	.2641	.3174	.2957
24	.3142	.2743	.3361	.3174	.2614	.2427	.2587
Max	.6535	.6979	.679	.6161	.5788	.6161	.5914
Min	.2801	.2743	.3361	.2772	.2427	.2229	.2218
Avg	.4443	.4677	.4524	.4455	.3676	.3811	.327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8817	1.0688	.1109	.0924	.132	
2	.7712	.9156	1.0562	.112	.112	.1307	
3	.7377	.8478	1.065	.1109	.0934	.1307	
4	.7377	.78	1.0774	.1294	.112	.132	
5	.7712	.8478	1.1012	.1494	.1307	.1494	.0924
6	.9556	.8916	1.1633	.168	.1494	.1509	.0747
7	.1134	.1696	1.21	.1663	.1848	.1509	.1478
8	.1494	.1543	1.0402	.1629	.168	.168	.1448
9	.128	.1357	1.0159	.1612	.1478	.132	
10	.128	.1543	.1867	1.5604	1.4243	1.3123	1.2174
11	.128	.1867	.2218	2.2291	1.587	1.6975	1.3203
12	.1294	.2263	.2801	2.2382	1.6876	1.8204	1.3717
13	.1663	.2054	.2402	2.2721	1.7204	1.8861	1.3717
14	.1829	.2241	.2614	2.2634	1.5684	1.8347	1.3375
15	.2033		.2772	2.2291	1.6446	1.9071	1.3375
16	.1829		.2172	2.0683	1.5497	1.6289	1.286
17	.1663	.168	.2534	1.9631	1.5623	1.3546	1.2174
18	.1646	.1886	.2561	.1772	.1307	.1109	.1372
19	.1478	.1867	.2534	.1629	.1509	.1494	.1267
20	.1478	.1886	.197	.1463	.1307	.168	.1267
21	1.046	1.065	.181	.1294	.1509	.1663	.1086
22	1.0174	1.1736	.168	.1086	.1494	.1267	.0905
23	1.0004	1.1043	.1307	.0914	.132	.1097	.0905
24	.8718	.9665	1.0814	.1109	.0924	.1307	.0924
Max	1.046	1.1736	1.21	2.2721	1.7204	1.9071	1.3717
Min	.1134	.1357	.1307	.0914	.0924	.1097	.0747
Avg	.4536	.5301	.5835	.7926	.6197	.6533	.6154

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1848	.1698		1.6956	1.4419	1.4922
2	.181	.168	.1698		1.7126	1.4089	1.4586
3	.1629	.1848	.1698		1.6907	1.3763	1.5089
4	.181	.168	.1698		1.6741	1.3279	1.442
5	.181	.1867	.2241		1.7532	1.4746	1.5089
6	.2896	.2054	.2801		1.8067	1.7924	1.5939
7	.2865	.2772	.3174		1.9989	1.9334	1.8004
8	1.9909	2.6155	.2452	2.2291	2.2377	2.0719	1.8176
9	2.431	2.6379	.1867	1.9591	.1696	1.917	1.773
10	2.8502	2.3967	2.6707	.156	.1629	.168	.181
11	2.6355	2.6886	2.8147	.1629	.1867	.1663	.1629
12	2.6052	2.769	2.7978	.1629	.1867	.168	.1629
13	2.6216	2.7183	2.7435	.1646	.1698	.1663	.1629
14	2.5911	2.5232	2.8607	.1663	.1867	.168	.1448
15	2.5888	2.4486	2.7435	.1848	.1886	.1848	.1629
16		.1867	2.7149	.1867	.1867	.1867	.1629
17	.1848	.1698	2.6063	.1867	.1886	.1867	.181
18	.2054	.2427	.1734	.1848	.168	.1848	.1629
19	.2241	.2614	.181	.168	.2075	.2033	.1829
20	.2241	.2829	.2195	.1463	.2427	.2427	.181
21	.2218	.2614	.2241	.168	.2075	.2218	.2172
22	.1848	.2452	.1848	.168	.168	.1791	.2172
23	.1646	.1867	.1663	.1663	.168	.1629	.1629
24	.181	.168	.168	1.7147	1.7295	1.4419	1.4413
Max	2.8502	2.769	2.8607	2.2291	2.2377	2.0719	1.8176
Min	.1629	.168	.1663	.1463	.1629	.1629	.1448
Avg	1.0160	1.0074	1.0501	.4868	.7953	.7823	.7618

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.0924	.0934		1.1797	.9995	.9156
2	.0829	.0747	.0934		1.1469	.9945	.8619
3	.0829	.112	.0934		1.1437	.9831	.8383
4	.0829	.1294	.0934		1.065	1.004	.9116
5	.0829	.112	.1509		1.6078	1.0402	1.0059
6	.1492	.1478	.1886		1.6575	1.4563	1.2431
7	.1658	.1307	.2263		1.6221	1.704	1.6118
8	1.7238	2.1807	.1494	2.1948	1.7072	1.6842	1.6832
9	2.4034	2.3371	.1509	1.2656	.1052	1.6741	1.5565
10		2.4291	1.7204	.0905	.0886	.0934	.0732
11	2.5888	2.7035	2.7183	.0905	.0934	.1109	.0686
12	2.5692	2.3537	2.6686	.128	.0943	.1109	.0686
13	2.3703	2.1765	2.649	.128	.0747	.0934	.0655
14	2.3644	2.4129	2.7664	.1294	.0754	.0924	.0663
15	2.343	2.13	2.5604	.1294	.112	.128	.0663
16	.1448	.1307	2.4417	.112	.1698	.1294	.0663
17	.1663	.1867	2.5194	.112	.0934	.1448	.0829
18	.1463	.1886	.1357	.112	.1132	.1463	.0829
19	.1848	.168	.1448	.112	.1307	.1463	.0995
20	.1829	.1886	.1791	.112	.168	.1448	.0995
21	.1663	.168	.181	.112	.1509	.1372	.116
22	.1294	.1494	.1867	.1109	.112	.104	.116
23	.0934	.1132	.128	.112	1.0486	.0895	.0829
24	.0829	.0934	.0934	1.3546	1.1797	.9878	.9602
Max	2.5888	2.7035	2.7664	2.1948	1.7072	1.704	1.6832
Min	.0829	.0747	.0934	.0905	.0747	.0895	.0655
Avg	.7995	.8712	.9305	.3768	.6225	.5916	.5309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.056	.056		.4409	.3277	.2984
2	.0486	.056	.056		.4424	.3401	.2683
3	.0497	.0554	.0566		.4641	.3361	.2984
4	.0497	.056	.056		.5243	.3768	.3353
5	.0497	.0747	.0716		.5636	.3906	.3353
6	.0663	.0747	.0747		.5735	.4428	.3353
7	.0663	.0739	.0934		.6299	.4915	.4115
8	.3856	.5316	.0943	.6516	.5898	.4641	.4161
9	.6133	.4917	.0934	.4287	.0543	.4915	.3772
10	.779	.4752	.6882	.0362	.0554	.0373	.0347
11	.7956	.5898	.9156	.037	.056	.0554	.0335
12	.7373	.6554	.9221	.0537	.0373	.056	.0335
13	.5967	.5761	.8785	.0549	.0566	.0554	.0335
14	.5571	.7373	.7712		.056	.0362	.0503
15	.5801		.9496	.0747	.0747	.0358	.0332
16	.0732	.0747	.9259	.0739	.0566		.0332
17	.0747	.0686	.8551	.0739	.0566	.0362	.0332
18	.0747	.0934	.0848	.0934	.0747	.0549	.0332
19	.0747	.1132	.0905	.0373	.0377	.0543	.0332
20	.0739	.112	.0724	.037	.056	.0543	.0324
21	.056	.0754	.0543	.0373	.0566	.0543	.0324
22	.056	.0747	.0554	.037	.0373	.0358	.0324
23	.056	.0747	.0543	.056	.0373	.0343	.0324
24	.0497	.056	.056	.463	.463	.3391	.3052
Max	.7956	.7373	.9496	.6516	.6299	.4915	.4161
Min	.0486	.0554	.0543	.0362	.0373	.0343	.0324
Avg	.2506	.2281	.3344	.1404	.2289	.2000	.1609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1797	1.1961	1.3108		.0732	.056	.0543
2	1.1469	1.21	1.2631		.0739	.056	.0543
3	1.1469	1.1961	1.2163		.0914	.0566	.0526
4	1.1469	1.1603	1.2003		.0739	.056	.0543
5	1.166	1.1797	1.2289		.0739	.0754	.0716
6	1.2452	1.278	1.2483		.0934	.0747	.0724
7	.0655	.0829	1.278		.0739	.0747	.0724
8	.0655	.0914	1.2323	.1086	.0934	.0747	.0537
9	.0983	.0924	1.2643	.0549	.0739	.0943	.0537
10	.0648	.0934	.0983	1.869	1.8842	1.6876	1.6289
11	.0716	.0943	.0848	2.0805	2.0005	2.0687	1.6632
12	.0732	.112	.0905	2.1434	2.0805	2.1605	1.3736
13	.1463	.1132	.0905	2.2462	2.1464	2.2291	1.7661
14	.1663	.1307	.0716	2.2377	2.0805	2.0957	1.7661
15	.1663	.0943	.0905	2.2611	2.2119	2.0719	1.7147
16	.0934	.0934	.0724	2.1795	2.0891	2.0576	1.6804
17	.0924	.0934	.1075	2.0222	2.0485	1.95	1.5947
18	.0914	.112	.0543	.0701	.0566	.0686	.0514
19	.0739	.1097	.0724	.0724	.0747	.0732	.0497
20	.0924	.0934	.128	.0914	.0754	.0724	.0497
21	1.2125	.0934	.1254	.0895	.0747	.0724	.0497
22	1.2125	1.3123	.1267	.0895	.0747	.0537	.0332
23		1.3763	.1086	.0724	.056	.0514	.0332
24	1.1822	1.2597	1.2803	.0876	.0739	.0566	.0732
Max	1.2452	1.3763	1.3108	2.2611	2.2119	2.2291	1.7661
Min	.0648	.0829	.0543	.0549	.056	.0514	.0332
Avg	.5217	.5279	.5768	1.0456	.7395	.7245	.5861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0625	1.6446	1.5623	1.406	1.439
2	.0533		.0625	1.6604	1.5181	1.406	1.4373
3	.0638		.0617	1.656	1.5684		1.4217
4	.0503		.0781	1.692	1.6004		1.4706
5	.0511		.0926	1.7284	1.6004		1.4563
6	.0638		.096	1.7444	1.7328		1.4563
7			.1387	1.9044			1.668
8	1.078	1.7976	.156	1.9044	1.9433	1.7166	1.7652
9	1.406	1.9919	.1357	1.8724	1.7236	1.749	1.6964
10	1.6446	2.0891	2.2447	.112	.1067	.0857	.0724
11	1.8138	2.1628	2.3758	.0753	.112	.116	.0667
12	1.7124	2.2672	2.4615	.0914	.0892	.1158	.0581
13	1.8244	2.3158	2.4006	.0914	.0947	.0949	.0581
14	1.8461	2.2405	2.5911	.0892	.0926	.0949	.0572
15	1.9006	2.1605	2.5101	.088	.0903	.0949	.0697
16	.0648	.0734	2.3205	.0892	.0846	.0914	.08
17	.0572	.0781	2.2245	.0869	.0724	.0705	.0686
18	.0629	.1014	.1128	.088	.0734	.0812	.0743
19	.0562		.108	.0869	.0937	.0695	.0732
20	.0476	.0743	.0995	.0823	.0714	.0657	.0648
21	.0457	.0791	.1006	.0823	.0724	.0695	.0667
22	.0472	.08	.0914	.0974	.0724	.0695	.0541
23		.081	.0762	.0987	.0724		.0556
24	.0495		.08	1.6288	1.6667	1.439	1.439
Max	1.9006	2.3158	2.5911	1.9044	1.9433	1.749	1.7652
Min	.0457	.0734	.0617	.0753	.0714	.0657	.0541
Avg	.6359	1.1728	.8617	.7790	.7006	.4909	.6737



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061		1.2498	.1294	.0903	.0686	.0678
2	.9122		1.2342	.1294	.0903	.0693	.0867
3	.9339		1.2186	.1478	.0903	.0678	.0678
4	.9374		1.2176	.1294	.12	.0671	.0867
5	.9414		1.2176	.1294	.128	.0671	.1063
6	1.0467		1.3763	.1478	.168	.1075	.1086
7	.1227		1.4083	.1848	.1509	.1254	.1267
8	.0857	.0867	1.3599	.1433	.1294	.0857	.1063
9	.0914	.0995	1.3125	.1478	.096	.0655	.081
10	.0857	.1254	.0655	1.7764	1.8343	1.8023	1.6004
11	.0895	.1267	.08	2.1862	2.251	2.0081	1.6164
12	.1075	.1254		2.2939	2.2672	2.1125	1.6804
13	.1254	.1063		2.3644	2.1925	2.1538	1.643
14	.1086	.124	.0983	2.3266	2.0645	2.0891	1.5623
15	.1254	.116	.1448	2.2447	1.9919	1.9524	1.7004
16	.1433	.124	.124	2.2186	2.0243	1.9433	1.5813
17	.1214	.1254	.1433	2.251	1.9757	1.8244	1.5023
18	.1214	.1227	.1578	.1017	.08	.1006	.0734
19	.1433	.1063	.1543	.12	.0972	.1075	.0743
20	.1254	.1433	.1646	.12	.1017	.1227	.1017
21	1.1385	1.2651	.1663	.1214	.1029	.124	.1006
22		1.2809	.1463	.104	.0857	.104	.0762
23		1.2809	.128	.1054	.0848	.0848	.0663
24	.9374		1.2651	.1294	.0892	.0848	.0678
Max	1.1385	1.2809	1.4083	2.3644	2.2672	2.1538	1.7004
Min	.0857	.0867	.0655	.1017	.08	.0655	.0663
Avg	.4250	.3349	.6561	.8230	.7628	.7224	.5952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658		.4527	.4108	.3584	.3395	.3395
2	.3511		.415	.4668	.3174	.3018	.3881
3	.3584		.415	.5041		.3018	.4435
4	.4108		.415	.5601		.3018	.5228
5			.4294	.5788		.3361	.5601
6	.6161		.6348	.5975		.5847	.5975
7	.6767		.6653	.6516		.6722	.6283
8	.5552	.567	.567	.6154	.6535	.543	.5973
9	.5548	.5731	.5609	.4917	.4119	.5121	.4298
10	.4917	.5316	.5083	.3681	.4578	.4656	.394
11	.407	.5083	.4801	.3978	.3641	.4409	.3086
12	.4681	.4656	.4458	.3481	.39	.4207	.2804
13	.3641	.4908	.3641	.3086	.3641	.3761	.2804
14	.3988	.4477	.4298	.3641	.3988	.3224	.2686
15	.4252	.4119	.4784	.3772	.3258	.4656	.2835
16	.3856	.4557	.4458	.3481	.3086	.4163	.3366
17	.4191	.4163	.4854	.3641	.3353	.3898	.3366
18	.4409	.4252	.4115	.463	.4024	.4239	.4359
19	.5721	.6556	.5434		.4681	.4557	.6001
20	.6268	.7164	.6516	.5014	.5792	.5611	.6859
21	.6219	.6099	.6099	.5121	.567	.5175	.7011
22		.5729	.5359	.4435	.4805	.4338	.6335
23		.5228	.4435	.4294	.4481	.2987	.3921
24	.3658		.4668	.3734	.3772	.3734	.2641
Max	.6767	.7164	.6653	.6516	.6535	.6722	.7011
Min	.3511	.4119	.3641	.3086	.3086	.2987	.2641
Avg	.4703	.5232	.4940	.4555	.4215	.4273	.4462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 400 / STATION TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
24	.8488
Max	.8488
Min	.8488
Avg	.8488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 401 / 33 KV SHIRSGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	2.5463
Max	2.5463
Min	2.5463
Avg	2.5463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 406 / 33 KV ACORN-I (Wind Mill) NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	1.4003
Max	1.4003
Min	1.4003
Avg	1.4003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 407 / 33 KV WANGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	4.3004
Max	4.3004
Min	4.3004
Avg	4.3004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 410 / 33 KV SHIVANI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	3.2819
Max	3.2819
Min	3.2819
Avg	3.2819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 411 / 33 KV BHIKWADI (KH.)

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / INCOMING

(NON CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	4.6965
Max	4.6965
Min	4.6965
Avg	4.6965



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 601 / SONHIRA S.S.K.LTD

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUL-18
HR	Load (MW)
24	18.107
Max	18.107
Min	18.107
Avg	18.107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.1336	1.387	1.1984	1.1702	.5765	1.2003
2	1.1142	1.2163	1.3523	1.1797	1.1736	.5658	1.2003
3	1.0852	1.2308	1.283	1.1869	1.1462	.5121	1.166
4	1.1317	1.2048	1.1789	1.1919	1.1458	.5914	1.0974
5	1.2536	1.2269	1.1789	1.262	1.2071	.6413	1.166
6	1.3535	1.2003	1.1736	1.3112	.9774	.7392	1.2209
7	1.3077	1.3413	1.2742	1.3413	.4572	.9335	1.2346
8	1.5402	1.4548	1.4899	1.4899		1.2548	1.5912
9	1.7078	1.7185	1.6667	1.656	.8131	1.4548	1.5242
10	1.7985	1.821	1.8122	1.7901	.7095	1.6358	1.6667
11	1.776	1.7593	2.0348	1.768	.7167	1.6975	1.8351
12	1.1065	1.1012	1.2334	1.2803		1.1203	1.1469
13	1.1797	1.094	1.1523	1.2163		1.2018	1.0395
14	1.7071	1.7593	1.6556	1.6255		1.2483	1.5653
15	1.821	1.6975	1.7375	1.6156		1.8233	1.6644
16	1.5432	1.5432	1.5242	1.475		1.5741	1.4632
17	1.656	1.6347	1.6049	.4534		1.6049	
18	1.4998	1.3123	1.2803	1.3916	.7621	.9335	1.406
19	1.5364	1.4723	1.4506	1.4864	.7922	1.5497	1.5935
20	1.5074	1.3603	1.5364	1.4864	.8962	1.387	1.4723
21	1.0136	.9671	.9922	.9568	.8589	1.0402	1.0166
22	1.3763	1.3763	1.278	1.3599	.7842	1.3443	
23	1.3279	1.4243	1.2955	1.3916	.7095	1.3123	
24	1.1142	1.2125	1.4403	1.166	1.1984	.6413	1.1843
Max	1.821	1.821	2.0348	1.7901	1.2071	1.8233	1.8351
Min	1.0136	.9671	.9922	.4534	.4572	.5121	1.0166
Avg	1.3996	1.3859	1.4172	1.3450	.9128	1.1410	1.3550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.6935	.7628	.7122	.7202	.5175	.7522
2	.6661	.7202	.7628	.6783	.7087	.4805	.7522
3	.6241	.6783	.7282	.6516	.6653	.4481	.7164
4	.583	.695	.6935	.7282	.6722	.5228	.6805
5	.6516	.788	.7282	.8063	.7682	.5601	.7164
6	.7122	.8238	.7042	.8764	.7964	.6722	.8326
7	1.0029	.9816	.7842	1.0277	.9511	.8215	1.0029
8	1.0166	1.0059	1.1443	1.0631	.9313	.9568	.9922
9	1.0395	1.0159	1.1065	1.1065		.9602	
10	.9503	1.0486	1.0852	1.073	.7712	.8951	.9389
11	.6097	1.0753	1.1012	1.1142	.7628	.8619	.9175
12	.8619	1.0242	1.0688	.9282	.6859	.8025	.8745
13	.8288	.8478	.9724	.9282	.5959	.663	.6706
14	.852	1.0486	.8817	.9717	.567	.6962	.7209
15	1.0277	.9922	1.0688	1.0242	.567	1.0395	.8097
16	1.0242	1.0311	1.0688	1.0562	.6588	.8745	.8539
17	.421	1.1069	1.2018	1.0437	.6661	.9922	.9374
18	.9503	.9717	1.1843	.9724	.6661	.8962	.7537
19	1.0174	.9282	1.0608	1.0513	.6878	.9724	.9156
20	1.0974	1.0402	1.2209	.9945	.8131	.9259	.9362
21	.8596	.8413	.9602	.8322	.7316	.7888	.7712
22	.8505	.9114	.9602	.8063	.695	.8505	.7282
23	.8322	.8596	.8478	.7975	.5914	.7628	.6859
24	.78	.7545	.8238	.8048	.7461	.5175	.7282
Max	1.0974	1.1069	1.2209	1.1142	.9511	1.0395	1.0029
Min	.421	.6783	.6935	.6516	.567	.4481	.6706
Avg	.8314	.9118	.9551	.9187	.7139	.7699	.8125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	1.0867	1.2536	1.1789	1.1443	.4805	.9877
2	.9671	1.0631	1.1462	1.1096	1.1104	.4435	.9145
3	.9145	1.0517	1.0745	1.0517	1.0456	.3734	.9145
4	.9511	1.0349	1.0387	1.0277	.9907	.4108	.8779
5	1.0608	1.0608	1.0745	1.1222	1.0562	.5228	.8779
6	1.1706	1.0974	1.1222	1.1946	.9054	.6584	.9335
7	1.3032	1.2894	1.1946	1.3032	.9526	.905	1.2197
8	1.4175	1.3523	1.3466	1.4022	.8505	1.2308	1.2894
9	1.4403	1.4403	1.387	1.3176	.7545	1.2757	1.2483
10	1.4255	1.4586	1.5089	1.4243	.6588	1.3748	1.2346
11	1.3443	1.4403	1.4918	1.4419	.5959	1.3592	1.3077
12	1.0402	1.0402	1.153	1.166	.4344	.9602	1.0517
13	.9816	.9709	1.0631	1.0631	.415	.9602	1.0288
14	1.326	1.3763	1.326	1.2955	.4344	1.0056	1.2266
15	1.3748	1.3763	1.3923	1.3279	.439	1.3176	1.3108
16	1.2597	1.2266	1.2887	1.2452	.3982	1.2308	1.2955
17	1.3592	1.3435	1.3603	1.2631	.5121	1.278	1.2811
18	1.3904	1.2407	1.326	1.3226	.5258	1.2071	1.2597
19	1.4754	1.4243	1.4582	1.3565	.6024	1.3413	1.2548
20	1.4403	1.4217	1.5089	1.4563	.7602	1.1789	1.3672
21	.9808	1.0349	1.0456	1.0456	.7023	.9015	.9979
22	1.2178	1.2536	1.2403	1.2403	.6878	1.1946	1.0517
23	1.1919	1.2536	1.262	1.2483	.5792	1.1104	1.1568
24	1.0631	1.0985	1.2894	1.1919	1.1568	.5487	1.0631
Max	1.4754	1.4586	1.5089	1.4563	1.1568	1.3748	1.3672
Min	.9145	.9709	1.0387	1.0277	.3982	.3734	.8779
Avg	1.2135	1.2265	1.2647	1.2415	.7380	.9696	1.1313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 402 / 33kv NEW VITA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUL-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1824	3.1024	3.2236	4.0832	3.3065	2.7343	3.2236
2	2.963	2.9973	3.2236	3.9758	3.2407	2.6292	3.2236
3	2.7721	2.9973	3.2236	3.7609	3.2773	2.524	3.2236
4	2.9938	3.2236	3.2236	4.1907	3.4385	2.7343	3.2236
5	3.4019	3.638	3.7609	4.6205	3.8803	2.8921	3.2236
6	4.1701	3.922	4.2981	5.4801	4.5222	3.5757	3.2236
7	1.9753	2.3594	2.1948	5.8025	5.4298	4.8377	4.784
8	4.1701	5.3224	1.8267	5.695	5.0297	4.8377	4.6811
9	5.4801	5.715	1.6118	4.8285	3.3128	4.8377	1.6118
10	5.9934	6.653	6.9845		1.9982	5.2012	4.1907
11	3.5082	6.653	6.6621	5.4527	2.2085	5.3727	5.9099
12	6.1111	6.0357	7.7366	4.9343	.9465	4.8354	5.1578
13	5.1303	6.5844	7.3068	4.6016	4.7325	5.3727	4.8354
14	5.3315	6.0357	7.0919	1.5769	4.7325	5.3727	4.7279
15	5.2624	6.5844	6.877	5.0972	4.7325	5.3727	4.2981
16	1.6289	2.1491	6.877	5.2126	4.3118	5.3155	4.513
17	1.5775	1.6118	6.3397	6.8621	4.417	4.513	4.4056
18	2.0199	1.6118	2.2565	1.9033	.4207	1.6118	1.5043
19	2.7109		2.1491	1.6289	1.0517	2.6863	1.9342
20	1.8804	1.6118	2.7938	1.6461	1.1568	1.6461	1.8267
21	3.5082	3.1207	1.7193	1.5364	1.1568	1.6632	1.5043
22	3.5082	3.2236	1.5043	1.386	1.1568	1.6118	1.2894
23	3.4019	3.2236	4.1907	3.4848	.9465	2.6863	1.0745
24	3.3311	4.2696	3.2236	4.1907	3.2693	2.7343	3.2236
Max	6.1111	6.653	7.7366	6.8621	5.4298	5.3727	5.9099
Min	1.5775	1.6118	1.5043	1.386	.4207	1.6118	1.0745
Avg	3.5839	4.0281	4.1792	3.9979	3.0282	3.6499	3.3672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	1.587	1.6004	1.5364	.1509	.1134	.1357
2	.168	1.587	1.5524	1.4883	.1509	.1134	.1187
3	.168	1.5565	1.5708	1.4883	.1494	.1357	.1174
4	.168	1.5565	1.5546	1.4883	.1494	.1357	.1174
5		1.5729	1.587	1.4883	.1478	.1372	.1227
6	.1698	1.6057	1.6484	1.5708	.1848	.1734	.1402
7	.2263	.1844	.2715	1.7004	.2033	.1907	.1753
8	.1886	.1898	.2507	2.0481	.2263	.197	.1715
9	.2075	.1619	.2481	2.2283	.2075	.2328	.2035
10	.1949	.144	.2149	2.0965	2.0481	1.8023	1.9662
11	.2629	.1677	.2303	2.2405	2.1792	2.3266	1.9989
12	.2303	.2058	.2303	2.3158	2.3922	2.4577	2.1136
13	.1417	.2454	.2126	2.4291	2.3205	2.4905	.6173
14	.1094	.2507	.2126	2.5587	2.4863	2.4905	2.0972
15	.1341	.2328	.2835	2.4291	2.5194	2.2775	.6081
16	.1311	.2401	.362	2.3685	2.3102	2.2611	2.1052
17	.1311	.2103	.3224	2.2565	2.3266	2.0081	2.0405
18	.1457	.2149	.298	.2263	.1981	.2214	.1739
19	.1739	.197	.3189	.1886	.2303	.192	.1638
20	.1739	.2303	.2865	.1886	.1698	.16	.1802
21	1.6004	1.6518	.2896	.2054	.1677	.1677	.1781
22	1.5844		.2715	.1509	.1524	.1326	.1619
23	1.668	1.7166	.2534	.1509	.1337	.1341	.1475
24	.168	1.6194	1.6164	1.5684	.1509	.1265	.1372
Max	1.668	1.7166	1.6484	2.5587	2.5194	2.4905	2.1136
Min	.1094	.144	.2126	.1509	.1337	.1134	.1174
Avg	.3615	.7534	.6536	1.5171	.8898	.8616	.6663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0936	.0724	.0732	.0183	1.5729	1.4403	1.4251
2	1.0623	.0724	.0739	.0183	1.5402	1.4575	1.4089
3	1.0311	.0732	.0739	.0183	1.5074	1.4251	1.4089
4	1.0562	.0732	.0747	.0183	1.6057	1.4251	1.3927
5	1.0883	.0747	.0747	.0183	1.8351	1.5249	1.3763
6	1.0883	.0747	.112	.0943	1.9227	1.5912	1.4403
7	.112	.0732	.112	.1109	1.989	1.8138	1.5524
8	1.4723		.1478	.1109	2.0056	1.8785	1.6484
9	1.9334		.0924	.0747	1.6804	1.8138	1.6194
10	2.0317	2.2611	2.1538	.1097	.0709	.0924	.0328
11	2.0972	2.3594	2.5857	.1097	.0732	.0914	.0181
12	2.1628	2.4577	2.8178	.1097	.0724	.1433	.0187
13	2.1628	2.4905	2.652	.0716	.0724	.1254	.0187
14	2.1628	2.4577	2.6686	.0716	.0686	.1052	.0166
15	2.2542	2.3758	2.6686	.0701	.0739	.1052	.017
16	.0724	.0732	2.5232	.0754	.1109	.1075	.0175
17	.0724	.0709	2.3644	.0754	.0747	.081	.0701
18	.1097	.064	.0693	.0732	.1075	.1029	.0617
19	.0716	.1132	.0693	.112	.0732	.1075	.0701
20	.0724	.1654	.0924	.112	.0739	.1086	.1097
21	.0739	.1294	.0924	.112	.0732	.1086	.0914
22	.0732	.1097	.0924	.0373	.0709	.0716	.0914
23	.0724	.0914	.0739	.0373	.0709	.0716	.0724
24	1.1092	.0724	.0724	.0732	1.5893	1.4723	1.4403
Max	2.2542	2.4905	2.8178	.112	2.0056	1.8785	1.6484
Min	.0716	.064	.0693	.0183	.0686	.0716	.0166
Avg	1.0223	.7184	.9096	.0722	.7640	.7194	.6425



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	.2241	.2347	.2427	1.989	1.6385	1.6385
2	1.4083	.2241	.2347	.2427	1.9559	1.5546	1.587
3	1.3763	.2241	.2454	.2427	1.9227	1.5912	1.587
4	1.3443	.2218	.2149	.2427	1.9559	1.6575	1.5384
5	1.3603	.2218	.2195	.2427	1.989	1.7238	1.6221
6	1.3765	.3326	.2957	.3018	2.304	1.7238	1.704
7	.2987	.3366	.3326	.4527	2.4863	2.1216	1.9334
8	1.7695	2.2542	.2683	.4108	2.2211	2.1879	1.8351
9	2.3371	2.4531	.2294	.4481	2.1548	2.1879	1.7436
10	2.5857	2.5232	2.0153	.2987	.1791	.1677	.1578
11	2.5857	2.5232	2.8012	.2987	.1417	.1658	.1595
12	2.4531	2.556	2.9508	.3361	.1494	.1658	.1509
13	2.4531	2.556	2.7831	.3734	.1886	.1638	.2402
14	2.4531	2.4905	3.0346	.3734	.1867	.1966	.2614
15	2.5484	2.4249	3.1855	.3734	.1867	.2622	.3018
16	.1791	.2294	1.576	.3315	.2614		.3206
17	.2686	.2294	.463	.3647	.2926	.2984	.3174
18	.2926	.2294		.3696	.2772	.2984	.3326
19	.2686	.2321	.3045	.3696	.2829	.2652	.3174
20	.2957	.2294	.2987	.3361	.2829	.1989	.3174
21	.2614	.2458	.2926	.3361	.2641	.1989	.2987
22	.2241	.2294	.2641	.2614	.2263	.1658	.2987
23	.2241	.2294	.2452	.2614	.1886	.1492	.2263
24	1.4723	.2241	.2321	.2402	2.0222	1.6194	1.6356
Max	2.5857	2.556	3.1855	.4527	2.4863	2.1879	1.9334
Min	.1791	.2218	.2149	.2402	.1417	.1492	.1509
Avg	1.3032	.9852	.9879	.3230	1.0045	.9001	.8552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1086	.1132	.1097	.1097	.1052	.112
2	.1109	.1086	.1132	.1063	.1097	.0701	.112
3	.112	.0732	.1143	.1063	.1097	.0716	.0747
4	.112	.0732	.1143		.1097	.0716	.0747
5	.1132	.0732	.1143		.1509	.0724	.0747
6	.1509	.1463	.1509	.1848	.1509	.1267	.1132
7	.1848	.1886	.1886	.1886	.1886	.1886	.1886
8	.1886	.1905	.1867	.1886	.1494	.1905	.1886
9	.1509	.1132	.168	.1509	.1509	.112	.1509
10	.1307	.1132	.1132	.0732	.0739	.112	.0953
11	.112	.1132		.0739	.0709	.1097	.0754
12	.112	.1132	.132	.0739	.0716		.0747
13	.0693	.1132	.1132	.0316	.0739		.0754
14	.0693	.1132	.1132	.0316	.0701	.0895	.0191
15	.0686	.1132	.1075	.0754	.132	.0754	.0648
16	.0732	.0934	.0189	.1132	.0724	.0754	.0934
17	.0732	.0934	.0754	.1132	.0732	.0724	.1132
18	.0739	.112	.0943	.1132	.0754	.1132	.0914
19	.1132	.1132	.0754	.1886	.1132	.1509	.1848
20	.1905	.2096	.2096	.1886	.1905	.1905	.1848
21	.1886	.1867	.1886	.1448	.1509	.1509	.1698
22	.1478	.1463	.168	.1086	.1086	.1509	.1132
23	.1086	.1075	.1267	.1086	.1086	.1132	.1132
24	.1109	.1086	.1132	.112	.1097	.1052	.112
Max	.1905	.2096	.2096	.1886	.1905	.1905	.1886
Min	.0686	.0732	.0189	.0316	.0701	.0701	.0191
Avg	.1198	.1219	.1266	.1175	.1135	.1145	.1112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2614	.2561	.2614	.2987	.2641	.2195
2	.2957	.2614	.2561	.2614	.2987	.2641	.2218
3	.2957	.2614	.2561	.2614	.2987	.2263	.2218
4	.3734	.2641	.2378	.2801	.3734	.2263	.2587
5	.4108	.2641	.2926	.3361	.4481	.2263	.3326
6	.4854	.5281	.4656	.5415	.5228	.5281	.4706
7	.6653	.6283	.6089	.5228	.7095	.6722	.6089
8	.5121	.4755	.5373	.4706	.5544	.4755	.5552
9	.3258	.3582	.3224	.3658	.4024	.362	.394
10	.3294	.3582	.3544	.2743	.3582	.2896	.1772
11	.2713	.3258	.3294	.1715	.2804	.2534	.1753
12	.2572	.2896	.2774	.1696	.2629	.2534	.1595
13	.2572	.2896	.2915	.2743	.2804	.2534	.2883
14	.2427	.2896	.3155	.3155	.2103	.2534	.2454
15	.2481	.3582	.333	.3155	.2658	.2534	.2254
16	.2454	.3224	.3018	.3734	.2774		.2427
17	.2454	.3224	.3277	.3315	.3086	.3258	.2883
18	.2743	.3582	.3856	.3696	.3294	.4477	.3856
19	.3772	.394	.4557	.4805	.4298	.4656	.4344
20	.4344	.4477	.2865	.543	.4805	.5194	.4572
21	1.5339	.394	.4207	.4755	.4108	.4656	.4435
22	.3734	.3224	.3881	.3658	.3734	.362	.3696
23	.2987	.2507	.3326	.2987	.3018	.2534	.2987
24	.2957	.2614	.2534	.2587	.2987	.2641	.2561
Max	1.5339	.6283	.6089	.543	.7095	.6722	.6089
Min	.2427	.2507	.2378	.1696	.2103	.2263	.1595
Avg	.3893	.3453	.3453	.3466	.3656	.3437	.3221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 206 / 11 KV Umar Kanchan AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	1.5364	1.5364	1.3443	.1433	.1097	.1109
2	.1448	1.5364	1.5364	1.3443	.1433	.1097	.1109
3	.1448	1.5089	1.0402	1.3443	.1433	.1097	.1109
4	.1448	1.5089	1.6324	1.3443	.1433	.112	.1109
5	.1417	1.5729	1.7236		.1791	.112	.112
6	.1772	1.5729	1.8185	1.4089	.1791	.168	.112
7	.2561	.2218	.1867	1.5708	.2149	.168	.168
8	.2149	.2241	.1478	1.6842	.181	.1663	.1494
9	.1829	.1646	.1109	1.9757	.1463	.1663	.128
10	.2033	.1646	.1494	1.9524	1.749	1.7814	1.2597
11	.1829	.1646	.1867	2.1125	1.9662	1.9433	1.9662
12	.2218	.1463	.1494	2.7252	1.9662	1.9757	2.1051
13	.2218	.1663	.1867		2.1628	1.9757	1.9595
14	.2218	.1494	.1698	2.4741	2.2611	1.9204	2.0081
15	.2033	.1478	.1886	2.4006	2.0645	1.9662	1.8947
16	.2241	.1829	.2263	2.4006	2.0405	.8745	1.8461
17	.2241	.1463	.2075	2.4006	1.9433	.9069	1.8138
18	.1848	.1494	.1791	.168	.104		.1326
19	.2054	.168	.1791	.181	.1086	.1097	.1387
20	.2075	.112	.1307	.181	.1109	.1109	.1433
21	1.5364	1.6324	.1294	.1829	.1109	.1478	.128
22	1.6324	1.6004	.1294	.1448	.1109	.1478	.128
23	1.6324	1.5684	.1109	.1448	.1097	.1463	.1097
24	.1448	1.6004	1.5684	1.3443	.1433	.1097	.1097
Max	1.6324	1.6324	1.8185	2.7252	2.2611	1.9757	2.1051
Min	.1417	.112	.1109	.1448	.104	.1097	.1097
Avg	.3666	.7478	.5677	1.4013	.7677	.6669	.7023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2267	.2294	.213	.2294	.2267	.2294
2	.2294	.2267	.2294	.213	.2294	.2267	.2294
3	.2294	.2294	.2321	.213		.2294	.2294
4	.2785	.2294	.2321	.1311	.2321	.2294	.2267
5	.2294	.2294	.2294	.213	.2321	.2347	.2267
6	.2294	.2347	.2294	.2155	.2321	.2347	.2294
7	.2294	.2267	.2294	.2155	.2321	.2294	
8	.2294	.2294	.2294	.2155	.2321	.2321	
9	.2321	.2294	.2294	.2267	.2321	.2321	
10	.2294	.2294	.2321	.2294	.2294		
11	.2294	.2294	.2294	.2294	.2294	.2294	
12	.2321	.2294	.2294	.2321	.2321	.2294	
13	.2321	.2267	.2294	.2321	.2294	.2294	
14	.2294	.2294	.2486	.2321	.2321	.2294	.128
15	.2321	.2294	.2321	.2294	.2321	.2294	.2294
16	.2294	.2267	.2294	.2294	.2321	.2267	.2321
17	.2294	.2294	.2321	.2294	.2321	.2267	
18	.2294	.2294	.2294	.0339		.2294	.213
19	.2267	.2294	.2294	.2294	.2294	.2294	.213
20	.2241			.2294	.2294	.2294	.213
21	.2267	.2267	.2155	.2294	.2267	.2294	.2294
22	.2267	.2294	.213	.2321	.1943	.2294	.213
23	.2267	.2294	.213	.2321	.1943	.2294	
24	.2294	.2267	.2294	.2294	.2294	.2267	.2294
Max	.2785	.2347	.2486	.2321	.2321	.2347	.2321
Min	.2241	.2267	.213	.0339	.1943	.2267	.128
Avg	.2312	.2288	.2288	.2131	.2274	.2295	.2181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 201 / 11 KV GARDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0814	.8223	.6325	.4938
2				1.065	.759	.6483	.4938
3				1.065	.759	.6401	.4999
4				1.094	.759	.6401	.4999
5				1.1271	.8322	.6478	.4938
6				1.1934	.9717	.6882	.5556
7	.0549	.0648	.0518	1.3592	.9602	.703	.6249
8	.6097	1.1469		1.3592	1.012	.7907	.7796
9	.9717	1.3757		1.3094	.8749	.8025	.6097
10	1.1012	1.643	1.7635			.0648	
11	1.1203	1.5415	2.0119		.0351		
12	1.2125	1.5746	1.9951		.0351	.0457	
13	1.278	1.7901	2.146			.0389	
14	1.326	1.5249	2.1293			.0351	
15	1.2616	1.5249	1.9784			.0488	
16			1.8233			.0427	
17			1.6385				
18		.0434					
19				.0541		.0472	
20	.0457	.0549					
21	.0549		.0511			.0427	
24			.0511	1.0814	.8223	.6483	.5624
Max	1.326	1.7901	2.146	1.3592	1.012	.8025	.7796
Min	.0457	.0434	.0511	.0541	.0351	.0351	.4938
Avg	.8215	1.1168	1.4218	1.0717	.7202	.4004	.5613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 202 / 11KV PRABHAT STEEL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0069	.0061	.0086	.0122	.0046	.0091
2	.0152	.0069	.0046	.0086	.0152	.003	.0091
3	.0076	.0051	.003	.0069	.0152	.003	.0076
4	.0152	.0051	.0046	.0069	.0122	.0046	.0061
5	.0213	.0086	.0061	.0069	.0091	.003	.0076
6	.0366	.0103	.0061	.0069	.0061	.0061	.0076
7	.029	.0259	.0061	.032	.0061	.0023	.0305
8	.0732	.029	.4294	.064	.003	.0854	.0335
9	.9054	.0469	.2614	.8865	.0137	.2241	.9054
10	.5228	1.1317	1.2323	.4338	.0046	.499	.2263
11	.2829	1.0185	.7468	.6036	.0061	.7468	.2641
12	.3772	.2263	1.2323	.8131	.0061	.2263	.8676
13	.5281	.6979	.3395	.2241	.0061	.2241	.3048
14	.3395	.2218	.2263	.3772	.0061	.3018	.2829
15	.4191	.2587	.7922	.8962	.0061	.5228	.2641
16	.362	.5544	.2452	.5228	.0061	.5228	.3048
17		.2641	.3048	.2263	.0046	.1036	.2641
18	.7922	.3018	.7545	.2263	.0061	.2263	.2263
19	.3734	.3772	.6348	.1219	.0061	.8299	.362
20	.0573	.3772	.0493	.029	.0061	.0518	1.0669
21	.0137	.0061	.0229	.0152	.0061	.0168	.0114
22	.0103	.0061	.012	.0137	.0061	.0122	.0076
23	.0103	.0061	.0103	.0122	.0061	.0122	.0086
24	.0091	.0086	.0061	.0086	.0091	.0046	.0107
Max	.9054	1.1317	1.2323	.8962	.0152	.8299	1.0669
Min	.0076	.0051	.003	.0069	.003	.0023	.0061
Avg	.2269	.2334	.3057	.2313	.0077	.1932	.2287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 203 / 11 KV YETGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8991	2.0008	2.2291	.2096	.1509	.1698	.1509
2	1.8991	2.0008	2.2043	.2096	.1509	.1509	.1509
3	1.8991	1.9669	2.1874	.1905	.1509	.1509	.1509
4	1.8991	2.0348	2.2382	.1905	.1509	.1698	.1509
5	1.9669	2.0687	2.2977	.2263	.1905	.1698	.1509
6	2.1026	2.1534	2.5377	.2452	.2286	.2075	.1509
7	.2286	.1905	.2286	.3048	.2286	.2641	.2263
8	.2263	.2286	.2667	.3048	.2286	.2096	.1509
9	.2263	.2667	.2667	.2667	.2263	.2263	.1509
10	.2263	.2667	.2858	2.5434	.7682	2.4756	2.3061
11	.2641	.2667	.2667	3.3913	1.0688	3.0849	2.3061
12	.2641	.3048	.3048	2.8166		3.12	2.6282
13	.2477	.3048	.3429	2.9165	3.476	3.2526	2.713
14	.2477	.3429	.3239	3.2556	3.6286	3.1878	2.7978
15	.3761	.3429	.3429	2.9165	3.2217	3.3234	2.6113
16	.2263	.3048	.3429	2.8487	3.1369	3.0521	2.4756
17		.2286	.3429	2.9165	3.12	2.9165	2.323
18	.2286	.2641	.3395	.1524		.1509	.112
19	.2452	.2452	.3429	.1524	.1886	.1524	.1698
20	.2477	.2667	.3429	.2286	.2263	.1509	.1886
21	1.6766	1.9161	.3048	.2286	.1886		.1698
22	2.0348	2.2382	.2667	.1524	.1698	.1509	.1307
23	2.0348	2.2721	.2477	.1509	.1698	.1509	.112
24	1.8991	2.0348	1.7295	.2286	.1509	.1698	.1509
Max	2.1026	2.2721	2.5377	3.3913	3.6286	3.3234	2.7978
Min	.2263	.1905	.2286	.1509	.1509	.1509	.112
Avg	.9811	1.0213	.8576	1.1270	.9646	1.1764	.9429



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1886	.2454	1.4083	1.153	1.1022	1.0059
2	.2263	.1698	.2103	1.3748	1.153	1.1191	.9945
3	.2263	.1698	.2103	1.3748	1.153	1.1191	1.0395
4	.2263	.2075	.2481	1.4251	1.2071	1.1233	1.073
5	.2263	.2452	.2896	1.6448	1.2742	1.1904	1.1401
6	.3018	.3772	.4344	2.0748	1.6095	1.5257	1.2071
7	.3772	.4207	.4805	2.5095	2.0119	1.8778	1.6766
8	1.3923	1.861	.4163	2.3739	1.9227	1.9448	1.6766
9	2.0348	2.4417	.3506	2.1195	2.0454	1.8107	1.5424
10	2.1704	2.6113	2.3838	.2587	.3018	.2957	.1448
11	2.1628	2.6825	2.6113	.3018	.2614	.2987	.2658
12	2.2634	2.5819	2.713	.2263	.2614	.2987	.2801
13	2.0622	2.8012	3.0182	.3018	.2614	.2987	.2601
14	2.2298	2.8502	3.0182	.2263	.2743	.2865	.2054
15	2.2891	2.7664	2.6452		.1848	.2103	.2263
16	.2641		2.7808	.2263	.0061	.2713	.2096
17			2.6282	.2241	.2279	.2241	.2641
18	.5601		.3206	.2218	.2103	.2896	.3395
19	.2658	.362	.3772	.2241	.2454	.2241	.3361
20	.3018	.3801	.415	.2926	.2804	.2195	.2987
21	.3018	.3439		.2218	.2957	.2218	.2801
22	.2641	.2896		.1494	.2507	.1509	.2241
23	.2263	.2454	.2263	.1494	.2149	.1494	.2054
24	.3018	.1886	.2454	1.4083	1.2346	1.1191	1.0059
Max	2.2891	2.8502	3.0182	2.5095	2.0454	1.9448	1.6766
Min	.2263	.1698	.2103	.1494	.0061	.1494	.1448
Avg	.9087	1.1516	1.1940	.9017	.7517	.7238	.6626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 206 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3018	.2641	.2452	.2263	.2641	.2263
2	.2641	.2829	.2641	.2075	.1886	.2641	.2241
3	.2641	.2641	.2641	.2075	.1867	.2641	.2241
4	.3018	.2829	.3018	.2263	.2263	.2829	.2614
5	.3772	.3547	.3772	.3174	.3018	.3206	.3395
6	.5093	.5041	.5093	.4854	.4904	.5281	.4715
7	.547	.5415	.5788	.5914	.5415	.5281	.5281
8	.4066	.3982	.439	.4024	.4435	.3696	.415
9	.4031	.3721	.4031	.4298	.3814	.3086	.3258
10	.2947	.3012	.4163	.3366	.3149	.3077	.3012
11	.3052	.3429	.3121	.2804	.2753	.1753	.2401
12	.2804	.333	.3814	.3052	.2652	.2486	.2652
13	.3155	.3601	.3294	.1696	.2321	.2321	.2347
14	.2481	.3439	.2865	.2774	.2543	.2984	.2401
15	.2427	.3258	.2896	.2804	.2401	.2372	.2294
16	.3155	.333	.3121	.2949	.2267	.2241	.2035
17		.3988	.3601	.3222	.2294	.2401	.2347
18	.2984	.3814	.2984	.2481		.2947	.2374
19	.3772	.5068	.4075	.3801	.462	.3681	.4031
20	.5316	.567	.5304	.4435	.4435	.4572	.439
21	.4755	.4715	.4938	.4294	.4338	.3921	.4108
22	.4108	.415	.4294	.3584	.3361	.3361	.3206
23	.3734	.3206	.3361	.2641	.2641	.2641	.2452
24	.3018	.3206	.2801	.3018	.2641	.2641	.2641
Max	.547	.567	.5788	.5914	.5415	.5281	.5281
Min	.2427	.2641	.2641	.1696	.1867	.1753	.2035
Avg	.3525	.3760	.3694	.3252	.3143	.3113	.3035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 201 / 11 KV LENGARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0434	.061	.0488	.3185	.176	.1898	.1486
2	.0434	.061	.04	.2972	.1543	.2303	.1315
3	.0617	.0625	.0423	.3418	.1562	.192	.1524
4	.0617	.064	.048	.4268	.16	.2031	.16
5	.0857	.064	.0625	.4877	.2006	.1852	.2107
6	.0867	.0648	.0671	.4877	.2258	.1981	.2286
7	.0848	.061	.0625	.4938	.3241	.1829	.2667
8	.3567	.2896	.0594	.4793	.2896	.4572	.2921
9	.3612		.0594	.4868	.2462	.061	.0442
10	.3384	.3906	.3715	.0556	.0354	.061	.0495
11	.443	.4001	.7133	.0263	.0354	.0427	.0518
12	.4458	.4801		.0274	.0354	.0434	.0526
13	.4458	.6554	.8025	.0293	.0354	.0549	.0488
14	.5201	.78	.8642	.0263	.0354	.0594	.0488
15	.5636	.7011	.8642	.0263	.0532	.0655	.0472
16		.0686	.8429	.08	.0532	.061	.0591
17	.0663	.0524	.8069	.076	.0354	.0495	.0709
18	.0663	.0434	.0781	.0248	.0354	.0648	.0777
19	.0663	.0526	.0781	.0762	.0354	.0667	.0648
20	.0663	.0625	.0781	.0762	.0354	.0705	.0686
21	.0829	.064	.0781	.0734	.0532	.0686	.0686
22	.061	.0533	.0594	.0734	.0532	.0657	.0594
23	.061	.0518	.0556	.0753	.2481	.1532	.0446
24	.0417	.061	.0488	.3185	.1623	.2126	.2008
Max	.5636	.78	.8642	.4938	.3241	.4572	.2921
Min	.0417	.0434	.04	.0248	.0354	.0427	.0442
Avg	.1936	.2019	.2709	.2035	.1198	.1266	.1103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 202 / 11 KV VEJEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.4696	.5312	.0747	.0572	.0886	.0572
2	.3201	.4915	.4973	.0747	.0572	.0886	.0572
3	.3932	.4752	.5087	.0934	.0762	.0943	.0572
4	.4588	.5801	.57	.0934	.0762	.0943	.0572
5	.5243	.6316	.6859	.0934	.0762	.0943	.0762
6	.5344	.6783	.6882	.0934	.0754	.132	.0943
7	.1086		.1097	.124	.1143	.132	.1052
8	.1029	.0648	.0914	.1595	.112	.132	.124
9	.0857	.081	.0709	.1595	.128	.1294	.104
10	.0671	.081	.048	.9231	1.0562	1.0562	.852
11	.0671		.0671	1.4754	1.2193	1.0669	.852
12	.0678		.0838	1.5083	1.0059	1.2003	.8848
13	.0678	.1147	.0876	1.6933	.9602	.9374	.9172
14	.0686	.1174	.0876	1.6263	.9842	1.0402	.8539
15		.1067	.0895		.9842	1.085	.8381
16		.0937	.1086	.4161	.9842	1.0269	.8539
17	.0716	.08	.1086	.333	1.0311	.9808	.8539
18	.0724	.0857	.1581	.08	.1265	.1829	.1543
19	.0716	.0876	.1402	.1006	.1265	.0857	.1372
20	.0895	.0762	.1227	.1029	.0791	.0914	.1227
21	.5249	.5556	.1075	.0895	.0886	.0857	.1052
22	.543	.5335	.1075	.0732	.0914	.0895	.0739
23	.543		.0914	.0566	.0886	.0739	.0739
24	.3506	.4696	.5182	.0747	.0566	.0886	.0724
Max	.543	.6783	.6882	1.6933	1.2193	1.2003	.9172
Min	.0671	.0648	.048	.0566	.0566	.0739	.0572
Avg	.2501	.2937	.2367	.4139	.4023	.4199	.3491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 203 / 11 KV SALSHINGE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1128	.1772	.1097	.5487	.5117	.4687	.4915
2	.1128	.1772	.1158	.5312	.4999	.506	.4999
3	.1303	.1886	.1189	.4687	.5121	.5281	.4877
4	.1448	.1886	.1094	.6562	.5243	.5344	.5304
5	.1823	.1886	.116	.6874	.6062	.5571	.583
6	.1844	.1886	.1326	.7274	.6019	.5801	.5792
7	.176	.1772	.1448	.7316	.8223	.6706	.6722
8	.7316	1.0936	.1614	.7316	.8333	.7499	.6706
9	.7621		.1718	.7282	.7042	.1562	.1372
10	.7676	.7907	.7099	.1158	.1372	.1562	.1269
11	.6836	.8383	.8124	.1303	.1067	.1029	.1269
12	.6836	.9374	.9061	.1337	.1067	.1181	.1235
13	.7468	.9922	1.004	.1337	.1067	.0914	.1166
14		.9755	1.2146	.132	.1067	.0884	.1132
15		.7202	1.2146	.1286	.1067	.1593	.1132
16		.1238	1.1336	.1105	.1067	.16	.1257
17	.1372	.1395	1.0648	.1362	.125	.1143	.1383
18	.1334	.1334	.1698	.1467	.125	.1362	.1783
19	.1334	.1593	.192	.1783	.125	.176	.1783
20	.1467	.1524	.1875	.1783	.1562	.1829	.1738
21	.1677	.1781	.1875	.1806	.1562	.1334	.1738
22	.1772	.1738	.1486	.1677	.1562	.1551	.1355
23	.1772	.1128	.1429	.1543	.4999	.4816	.1204
24	.1082	.1772	.1067	.5639	.5053	.5312	.4801
Max	.7676	1.0936	1.2146	.7316	.8333	.7499	.6722
Min	.1082	.1128	.1067	.1105	.1067	.0884	.1132
Avg	.3143	.3906	.4323	.3501	.3434	.3141	.2948

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 204 / 11 KV LENGARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.3155	.1905	.2263	.1715	.1772	.1715
2	.1991	.3189	.1715	.2033	.1524	.1886	.1715
3	.1991	.2686	.1715	.2033	.1524	.1886	.1524
4	.2534	.2715	.1905	.2772	.1524	.2075	.1524
5	.3258	.2743	.2801	.3326	.2452	.2263	.2801
6	.3511	.2772	.3142	.3696	.3326	.2452	.3326
7	.362	.2658	.2743	.3155	.3511	.2641	.298
8	.3155	.2715	.3224	.298	.3077	.2641	.3189
9	.2804		.2629	.2774	.2658	.2452	.2804
10	.2401	.2715	.2229	.2254	.2629		.2572
11	.1772	.1791	.2058	.1907	.1715	.1562	.2572
12	.2126	.2058	.2507	.1928	.1791	.1638	.2401
13	.2149	.1928	.2328	.1949		.1646	.2481
14	.1791	.2126	.2149	.1928	.1791	.1578	.1772
15	.2149	.1753	.197	.1907	.1791	.1543	.1417
16		.1886	.197	.1844	.1791	.1753	.1715
17	.2328	.2035	.1949	.1886	.1991	.197	.218
18	.2149	.2686	.2267	.181	.1991	.2058	.2629
19	.2328	.2743	.3224	.2835	.1991	.3224	.298
20	.3403	.3077	.394	.3658	.3439	.3696	.3506
21	.3467	.3361	.3881	.3361	.2715	.2507	.3547
22	.2915	.3658	.3395	.2614	.2896	.2801	.2641
23	.3086	.2241	.2641	.1867	.1886	.1867	.2075
24	.1848	.298	.2054	.2263	.1698	.1772	.1791
Max	.362	.3658	.394	.3696	.3511	.3696	.3547
Min	.1772	.1753	.1715	.181	.1524	.1543	.1417
Avg	.2549	.2594	.2514	.2460	.2236	.2160	.2411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1772	.1698	.1612	.1509	.1509	.1524
2	.1612	.1791	.1524	.1612	.1334	.1509	.1334
3	.1848	.181	.1524	.1753	.1334	.1698	.1334
4	.1848	.1886	.1715	.1928	.1334	.1698	.1524
5	.2033	.1886	.1905	.2103	.1524	.1698	.1715
6	.2075	.1886	.2075	.2279	.1848	.1698	.1905
7	.2263	.1791	.1848	.2229	.2241	.1886	.2012
8	.1928	.197	.168	.2401	.1886	.1772	.2241
9	.1753		.168	.2401	.1509	1.6478	.1698
10	.1753	.2149	.1663	.2058	.1494	.2126	.1829
11	.1753	.1753	.1848	.208	.1227	.2058	.1829
12	.1772	.1886	.1848	.1928		.2204	.1829
13	.1772	.1791	.1867	.1772	.1791	.116	.168
14	.1772		.1867	.1629	.0924	.1402	.168
15			.1867	.1629	.0857	.128	.168
16		.1715	.2195	.1829		.1387	.1417
17	.1772	.1949	.2195	.1829	.1372	.1578	.1417
18	.1791	.2572	.2195	.2195	.1372	.1629	.1509
19	.1991	.2658	.2804	.2149	.12	.2103	.1677
20	.2715	.2149	.2629	.2149	.2126	.2614	.2347
21	.2715	.2427	.2279	.2149	.2126	.1402	.2012
22	.2126	.2218	.2149	.1991	.2126	.1698	.1677
23	.1949	.1886	.197	.1646	.1417	.1524	.1509
24	.1612	.1772	.168	.1612	.1494	.1417	.1524
Max	.2715	.2658	.2804	.2401	.2241	1.6478	.2347
Min	.1612	.1715	.1524	.1612	.0857	.116	.1334
Avg	.1930	.1987	.1946	.1957	.1548	.2314	.1704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1715	.2075	.1494	.1829	.1663
2	.1715	.1886	.1524	.1848	.1509	.1509	.1494
3	.1844	.1886	.1524	.1848	.1524	.1509	.1524
4	.218	.1886	.1905	.2402	.1524	.1509	.1524
5	.2347	.1886	.2096	.2587	.1905	.1509	.2096
6	.2515	.2126	.2263	.2587	.2614	.1698	.2452
7	.2515	.2126	.2058	.2378	.2641	.1886	.2058
8	.2804	.2126	.3012	.2195	.2427	.2033	.2378
9	.298	.2303	.3052	.2033	.2218	.2801	.2204
10	.3155	.2658	.2683	.1848	.2427	.2427	.2103
11	.2401	.3437	.3086	.2427	.2402	.2286	.2454
12	.2572	.4049	.3429	.168	.1294	.2721	.3155
13	.2572	.1928	.4115	.168	.1478	.2439	.3582
14	.2572	.2204	.3086	.1448	.1478	.2846	.3224
15	.3155	.3467	.2572	.2353	.1848	.3048	.3224
16		.3906	.3772	.128	.2218	.3395	.3772
17	.2658	.427	.3944	.2195	.2012	.176	.4287
18	.2835	.197	.2401	.3292	.2012	.1524	.3429
19	.3012	.1715	.2957	.3315	.2012	.2572	.3155
20	.3189	.2454	.3326	.3506	.2561	.3109	.2804
21	.2481	.2957	.3142	.2658	.1638	.2103	.2804
22	.2126	.2614	.2587	.2328	.1524	.2427	.2103
23	.1949	.2075	.2218	.1772	.1638	.1886	.1753
24	.1886	.1698		.2075	.1646	.1638	.1663
Max	.3189	.427	.4115	.3506	.2641	.3395	.4287
Min	.1715	.1698	.1524	.128	.1294	.1509	.1494
Avg	.2493	.2480	.2716	.2242	.1919	.2186	.2538



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 207 / 11KV KANDESARWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.141	.1875	.1734	.0377	.0381	.0566	.0381
2	.1269	.1898	.141	.0377	.0381	.0566	.0381
3	.1337	.2241	.1829	.0566	.0381	.0566	.0381
4	.208	.2105	.2881	.0566	.0381	.0566	.0373
5	.2378	.2949	.301	.0566	.0377	.0566	.0377
6	.2709	.3315	.3269	.0566	.0377	.0566	.0566
7	.0566	.0693		.0566	.0377	.0566	.0747
8	.0566	.0693	.0754	.0566	.0377	.0566	.0754
9	.0566	.0686		.0566	.0377	.0566	.0754
10	.0566	.0857		.3715	.2641	.2494	.3227
11	.0514	.0373		.4904	.3963	.3601	.3311
12	.0526	.0377		.4988	.3749	.4115	.3567
13	.0532	.037	.0537	.535	.3593	.4054	.3567
14	.0543	.0373	.0537	.535	.3125	.423	.4161
15	.0543	.0358	.0537	.5135	.3125	.4451	.3715
16		.0366	.0537	.5144	.3048	.4033	.3666
17	.0543	.0686	.0537	.4311	.3086	.3765	.3948
18	.0549	.0732	.0537	.0377	.0686		.0566
19	.0739	.0701		.037	.0709	.0358	.0566
20	.0747	.0686	.0554	.0381	.0709	.0377	.0566
21	.0739	.2286	.0554	.0381	.0709	.0549	.0566
22	.218	.2187		.0381	.0709	.056	.0566
23	.1829	.1882		.0381	.0532	.0566	.0566
24	.1372	.1875	.1882		.0381	.0566	.0373
Max	.2709	.3315	.3269	.535	.3963	.4451	.4161
Min	.0514	.0358	.0537	.037	.0377	.0358	.0373
Avg	.1078	.1274	.1319	.1995	.1424	.1688	.1569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6539	.57	.6036	.4694	.5407	.1658	.6371
2	.6036	.6036	.6203	.4694		.1658	.57
3	.5365	.57	.5868	.4694	.5636	.2155	.5197
4	.5533	.57	.5868	.4694	.5967	.2652	.5365
5	.5197	.57	.6203	.503		.3149	.5533
6	.5365	.5868	.6036	.503		.3481	.503
7	.5365	.5365	.57	.503	.5304	.3812	.5365
8	.5868	.57	.5533	.5365	.431	.4144	.5365
9	.6036	.57	.5533	.5365	.2321	.5801	.5365
10	.5533	.57	.5365	.57	.1989	.5967	.6371
11	.5533	.6203	.5365	.5365	.1326	.5426	.6539
12	.5868	.6036	.6036	.5967	.1658	.5533	.5365
13	.57	.57	.57	.57	.1823	.5868	.57
14	.5365	.57	.57	.5533	.1823	.6036	.5533
15	.6203	.5533	.5533	.5533	.1658	.5365	.57
16	.6036	.6203	.6371	.5365	.1326	.5533	.6036
17	.5533	.6203	.6706	.5243	.116	.5868	.5868
18	.5197	.6203	.6706	.503	.1326	.57	.5365
19	.5365	.5868	.6371	.5079	.1326	.5197	.57
20	.5197	.5365	.4694	.4915	.1492	.503	.57
21	.5365	.5868	.503	.5243	.1658	.5868	.57
22	.6036	.5868	.503	.5571	.1658	.6036	.5533
23	.5868	.6371	.4694	.5571	.1658	.6539	.57
24	.6371	.5868	.6371	.4694	.5407	.1658	.6706
Max	.6539	.6371	.6706	.5967	.5967	.6539	.6706
Min	.5197	.5365	.4694	.4694	.116	.1658	.503
Avg	.5686	.5840	.5777	.5213	.2678	.4589	.5700

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 202 / 11 KV PARE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4999	.6226	.4572	.1478	.1478	.1448	.0934
2	.4572	.6539	.4687	.1478	.1463	.1448	.0934
3	.4572	.6874	.4687	.1109	.1307	.1086	.112
4	.5182	.6882	.4877	.1097	.1307	.1086	.1463
5	.6009	.6882	.5693	.1463	.1433	.1448	.1848
6	.6325	.7969	.6325	.1463	.1829	.1448	.1848
7	.1829	.1829	.1848	.1848	.2149	.1448	.1848
8	.1612	.1791	.181	.1848	.2012	.1448	.1829
9	.156	.1595	.1629	.1848	.1612	.181	.1772
10	.1791	.1772	.1109	.9602	.9602	1.3937	.7716
11	.1612	.1772	.1294	1.5203	1.1248	1.2809	.7499
12	.1646	.1612	.1294	1.5708	1.4723	1.4217	.7499
13	.1663	.2103	.1478	1.5729	1.4403	1.5813	.7537
14	.1791	.181	.1478	1.5684	1.2186	1.5813	.7225
15	.1646	.1478	.1478	1.6078	1.2186	1.4373	.7968
16	.1433	.181	.1478	1.4864	1.2186	1.406	.8078
17	.1663	.181	.1478	1.4746	1.2186	1.2963	.7926
18	.2149	.1417	.1478	.1433	.1448	.1214	.12
19	.2241	.1463	.1478	.1848	.1372	.1463	.1433
20	.2218	.1663	.1848	.1829	.181	.1478	.1478
21	.5401	.5418	.1848	.1867	.181	.1478	.1494
22	.6173	.5418	.1848	.1494	.181	.1478	.1463
23	.6718	.5117	.1848	.1494	.1448	.1463	.1174
24	.5624	.6401	.5117	.1478	.1463	.1448	.0914
Max	.6718	.7969	.6325	1.6078	1.4723	1.5813	.8078
Min	.1433	.1417	.1109	.1097	.1307	.1086	.0914
Avg	.3351	.3652	.2612	.5945	.5186	.5695	.3508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.0983	.0602	.9393	.9831	1.0277	1.0395
2	.096	.1006	.0602	.9393	.9503	1.1105	.9614
3	.0983	.0983	.0633	.9922	.9389	1.1437	.9282
4	.1311	.08	.0949	.9922	.9389	1.1603	.9282
5	.1638	.0838	.1265	1.1043	.9779	1.1768	1.1065
6	.1677	.1311	.1311	1.1174	1.2071	1.1934	1.1736
7	.1677	.1406	.1341	1.166	1.3916	1.1934	1.1934
8	1.2239	1.7695	.1265	1.166	1.4918	1.326	1.1934
9	1.5257	1.933	.0903	1.1469	1.442	1.4586	1.0774
10	.2378	1.9951	1.643	.0472	.0573	.048	.0366
11	.2641	2.146	1.8442	.0869	.0434	.0594	.0495
12	.2829	2.3137	1.5089	.0366	.0457	.0602	.0503
13	.2829	1.861	1.5089	.1147	.0465		.0732
14	.3018	1.861	1.5089	.128	.0457	.061	.0629
15	.3584	1.7772	1.5089	.1326	.0495	.125	.0709
16	.0526	.0777	1.5089	.1235	.0549	.1235	.0495
17	.0812	.0926	1.4754	.0926	.0556	.0572	.06
18	.1021	.0937	.0619	.0743	.0857	.0657	.0789
19	.1097	.1097	.0619	.104	.0396	.0903	.0823
20	.1204	.0739	.0743	.1027	.0617	.0914	.06
21	.125	.1311	.0743	.104	.0412	.0914	.0629
22	.1235	.128	.0743	.0846	.0404	.0846	.0581
23	.1311	.1054	.0495	.0892	.0404	.0695	.061
24	.1296	.12	.061	.8745	1.0277	1.0277	1.0898
Max	1.5257	2.3137	1.8442	1.166	1.4918	1.4586	1.1934
Min	.0526	.0739	.0495	.0366	.0396	.048	.0366
Avg	.2656	.7217	.5771	.4900	.5024	.5585	.4811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1886	.2075	.1886	.1905	.1524	.1715
2	.0754	.1698	.1698	.1886	.1524	.1524	.2286
3	.0754	.2263	.1886	.1886	.1715	.1524	.2096
4	.0754	.2263	.2263	.1698	.2096	.1524	.1905
5	.1132	.1698	.2075	.1698	.1905	.1524	.2096
6	.1132	.1698	.2452	.1698	.1524	.1524	.2096
7	.0754	.1886	.1886	.1698	.1143	.1524	.1905
8	.2075	.1698	.1886	.1698	.1334	.1905	.1905
9	.132	.132	.1698	.1698	.1143	.1524	.1715
10		.1698	.3018	.1886	.1334	.1524	.1143
11		.1886	.2829	.2667	.2096	.2858	.2667
12	.2829	.2263	.3206	.2667	.1905	.2096	.1905
13		.1886	.3584	.2286	.1524	.2286	.2286
14		.1886	.3772	.2667	.1524	.2286	.1905
15		.2263	.4338	.2667	.1524	.1905	.2096
16	.3206	.2641	.3772	.1905	.1334	.1905	.2477
17	.3018	.2641	.3772	.1524	.1334	.1905	.1524
18	.3475	.2263	.3395	.1143	.1524	.1905	.1905
19	.2829	.2263	.2641	.1334	.1524	.2096	.2096
20	.1698	.2263	.3772	.1334	.1524	.2477	.2096
21	.1132	.2075	.2641	.1524	.1524	.2286	.2096
22	.1886	.2075	.1698	.1905	.1524	.1143	.1905
23	.2263	.1698	.1886	.1905	.1524	.1715	.2286
24	.0943	.2075	.1886	.1886	.1715	.1524	.1905
Max	.3475	.2641	.4338	.2667	.2096	.2858	.2667
Min	.0754	.132	.1698	.1143	.1143	.1143	.1143
Avg	.1731	.2012	.2672	.1881	.1572	.1834	.2000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.415	.4001	.3772	.3584	.3429	.4191
2	.3772	.415	.381	.3772	.3584	.3429	.4191
3	.3772	.415	.381	.3961	.3584	.362	.4191
4	.3772	.415	.381	.381	.3584	.3429	.4191
5	.3772	.415	.381	.381	.3584	.362	.4191
6	.3772	.3961	.381	.4001	.3584	.381	.4191
7	.3772	.3961	.381	.381	.3584	.4001	.4191
8	.3772	.381	.381	.3429	.3395	.3961	.4382
9	.415	.3961	.381	.3239	.2614	.3772	.4527
10	.3961	.4572	.4001	.3856	.1943	.415	.4191
11	.4191	.4191	.4001	.415	.1905	.4191	.4001
12	.415	.4001	.4191	.3961	.2149	.4001	.4001
13	.3547	.4191	.4001	.3961	.2477	.4001	.3395
14	.381	.4572	.381	.3961	.1829	.4001	.4001
15	.4001	.4572	.381	.3961	.2286	.4001	.415
16	.4001	.4191	.4382	.3961	.2286	.4001	.415
17		.4191	.4382	.3772	.2477	.4001	.415
18	.3961	.4191	.4572	.415	.2286	.4001	.4191
19	.4001	.4191	.4382	.4338	.2477	.4382	.3961
20	.415	.4191	.4338	.415	.2667	.4382	.3961
21	.4191	.4001	.4001	.3584	.4001	.4382	.381
22	.4191	.4382	.4191	.3584	.381	.4191	.4001
23	.4191	.4191	.4527	.3395	.362	.4001	.4001
24	.3772	.415	.4001	.4001	.3584	.3395	.4191
Max	.4191	.4572	.4572	.4338	.4001	.4382	.4527
Min	.3547	.381	.381	.3239	.1829	.3395	.3395
Avg	.3932	.4176	.4045	.3850	.2954	.3923	.4100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0905	.2561	.2321	.2279	.1791
2	.0754	.0754	.0934	.2743	.2321	.2378	.1448
3	.0754	.0739	.0747	.2778	.2321	.2103	.1448
4	.0754	.0739	.0747	.2949	.2321	.2229	.1448
5	.0754	.0747	.0732	.3429	.3315	.2622	.181
6	.0747	.0953	.1097	.4359	.3647	.3048	.2896
7	.0876	.0934	.1267	.4481	.3978	.3681	.362
8	.3201	.2721	.1109	.4424		.3725	.3582
9	.3725	.3681	.0943	.3704	.3315	.3052	.3544
10	.3563	.4372	.333	.061	.0754	.0533	
11	.381	.4694	.502	.0724	.0686	.0914	
12	.3086	.5144	.5441	.0747	.0693	.0914	
13	.2932	.5144	.4801	.0747	.0533	.0895	
14	.2932	.4801	.5487	.0754	.061	.0701	
15		.463	.5373	.0716	.0564	.0701	
16		.0934	.5847	.0905	.061	.0709	
17		.0934	.6135	.0895	.0724	.0716	
18	.0739	.0924	.061	.0895	.0762	.0716	
19	.0934	.0914	.096	.1086	.0762	.0886	.0747
20	.1132	.1109	.1219	.1478	.128	.0886	.0739
21	.0754	.1109	.1509	.112	.108	.0701	.0739
22	.0762	.1109	.1267	.0934	.1067	.0701	
23	.0754	.0934	.2957	.0943	.1875		
24	.0943	.0754	.0934	.2267	.2155	.192	.1791
Max	.381	.5144	.6135	.4481	.3978	.3725	.362
Min	.0739	.0739	.061	.061	.0533	.0533	.0739
Avg	.1650	.2063	.2474	.1927	.1639	.1609	.1969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.2926	.2987	.2835	.2804	.2686	.3658
2	.3052	.2835	.2987	.2865	.2804	.2507	.2987
3	.3018	.2865	.2987	.3109	.2743	.2561	.2987
4	.3018	.2896	.3326	.2774	.2743	.2481	.2987
5	.4115	.3982	.4066	.3224	.3429	.3224	.3734
6	.5144	.6099	.5175	.5258	.4908	.5544	.5228
7	.5144	.6024	.6283	.6984	.631	.6626	.7095
8	.5487	.4854	.6001	.631	.631	.5847	.6219
9	.583	.547	.6104	.583	.4973	.5138	.4961
10	.5304	.4862	.4784	.503	.4801	.4915	.426
11	.5093	.4694	.4287	.431	.4961	.4588	.426
12	.427	.3521	.431	.4359	.4835	.4372	.3856
13	.3185	.3521	.4287	.3688	.3544	.4287	.3521
14	.3353	.373	.3658	.3688	.3605	.3944	.3224
15	.3467	.3856	.4001	.3353	.3841	.4024	.4167
16	.3361	.3688	.4424	.3353	.3768	.4144	.4475
17		.3768	.4801	.3772	.3887	.4096	.4012
18	.373	.4287	.5201	.3521		.4854	.3481
19	.5487	.5014	.6447	.4908	.5014	.5493	.5258
20	.6089	.5249	.6516	.5121	.5258	.6089	.6089
21	.4938	.5544	.5853	.503	.4755	.5544	.5068
22	.4108	.4338	.5258	.4359	.4119	.4755	.4163
23	.3292	.3734	.4024	.3429	.2915	.3982	.3475
24	.3429	.2896	.7655	.3258	.2896	.2804	.3658
Max	.6089	.6099	.7655	.6984	.631	.6626	.7095
Min	.3018	.2835	.2987	.2774	.2743	.2481	.2987
Avg	.4216	.4194	.4809	.4182	.4140	.4354	.4284



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2858	.3048	.2743	.3048	.3048
2	.2667	.2477	.2667	.2858	.2614	.2858	.3048
3	.2667	.2477	.2667	.2858	.2614	.2858	.3048
4		.2477	.2667	.2858	.2772	.2858	.3239
5	.2587	.2667	.3048	.3429	.3658	.3239	.362
6	.3841	.3361	.3696	.4382	.4525	.4191	.4572
7	.4668	.4572	.4525	.5093	.4961	.547	.5228
8	.4191	.4066	.4298	.4108	.4525	.462	.4715
9	.3048	.3696	.4207	.3734	.3326	.362	.3547
10	.3048	.3403	.3439	.2743	.3326	.2865	.3142
11	.3326	.3258	.3292	.2926		.2743	.3142
12	.2957	.3292	.3475	.2378		.2378	.3292
13		.2328	.3206	.2218		.2195	.2743
14	.2957	.2534	.3018	.2218	.3258	.2149	.2402
15	.2477	.2561	.3018	.2378	.3224	.2172	.4805
16	.2477	.2481	.2987	.2378	.3109	.1991	.1848
17	.2477	.3077	.2987	.2033	.3801	.2378	.2033
18	.2667	.2686	.3206	.2772	.3403	.2641	.2402
19	.439	.3696	.381	.3658	.4435	.3961	.4207
20	.5068	.5359	.5144	.4835	.5359	.4954	.499
21	.3982	.462	.4954	.4119	.5041	.4572	.4481
22	.3658	.4108	.4954	.362	.4481	.4001	.4481
23	.2957	.3361	.4001	.3109	.3429	.3429	.4481
24	.2641	.2801	.3048	.3429	.2743	.3239	.3239
Max	.5068	.5359	.5144	.5093	.5359	.547	.5228
Min	.2477	.2328	.2667	.2033	.2614	.1991	.1848
Avg	.3246	.3251	.3549	.3216	.3683	.3268	.3573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2214	.1898	.1898	.0381	.0381	.0381	.0381
2	.2056	.1898	.1852	.0381	.0381	.0381	.0381
3	.2056	.208	.176	.0381	.0381	.0381	.0381
4	.2056	.2214	.1718	.0572	.0381	.0381	.0381
5	.2056	.2214	.2214	.0572	.0381	.0381	.0572
6	.2812	.2846	.2778	.0572	.0572	.0572	.0572
7	.0762	.0762	.0572	.0762	.0572	.0572	.0762
8	.0762	.0762	.0572	.0572	.0762	.0572	.0762
9	.0381	.0572	.0572	.0572	.0762	.0572	.0572
10	.0381	.0381	.0572	.3637	.2968	.4321	.2343
11		.0381	.0572	.4999	.3353	.4321	.2812
12	.0381	.0381	.0572	.4784		.5155	.2812
13	.0572	.0381	.0381	.5093		.2778	.3704
14	.0572	.0381	.0381	.5182	.4012	.2623	
15	.0381	.0381	.0572	.4938	.4531	.2623	.4115
16	.0572	.0381	.0572	.4938	.4475	.2623	.3125
17	.0572	.0381	.0572	.463	.4218		.3906
18	.0381	.0381	.0572	.0572	.0762		.0762
19	.0572	.0572	.0572	.0572	.0381	.0572	.0572
20	.0762	.0572	.0762	.0572	.0572	.0762	.0762
21	.2214	.2286	.0953	.0762	.0572	.0762	.0572
22	.2214	.2343	.0572	.0762	.0381	.0762	.0572
23	.2214	.216	.0572	.0762	.0381	.0572	.0572
24	.2214	.2214	.2031	.0572	.0572	.0381	.0381
Max	.2812	.2846	.2778	.5182	.4531	.5155	.4115
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1268	.1201	.1007	.1981	.1443	.1475	.1381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2187	.2187	.0953	.0762	.0953	.0953
2	.2267	.2056	.2006	.0953	.0762	.0762	.0953
3	.2267	.2056	.2056	.0953	.0762	.0762	.0953
4	.2241	.2214	.208	.1143	.0953	.0953	.1143
5	.2372	.2812	.2372	.1334	.1143	.1143	.1334
6	.3704	.4843	.3125	.1524	.1334	.1524	.1524
7	.1715	.1524	.1905	.2096	.1524	.1715	.1715
8	.1715	.1715	.2096	.2096	.1905	.2477	.2477
9	.1143	.1143	.1715	.1524	.1524	.1715	.1905
10	.0953	.1143	.1524	.3637	.3395	.3593	.3048
11	.0762	.1143	.1334	.4475	.2812	.3704	.2187
12		.1143	.1334	.3437		.3858	.2343
13	.1143	.1143	.1143	.4475		.3858	.2812
14	.0762	.0953	.1143	.4321	.2778	.4218	
15	.0762	.0953	.0953	.4167	.5468	.3906	
16	.0953	.1143	.0953		.5247	.3437	.3125
17	.0762	.1143	.0953		.4784	.3241	.3125
18	.0762	.1143	.1143	.1334	.1334	.1143	.1524
19	.1524	.1334	.1334	.1905	.1524	.1715	.1905
20	.2096	.1905	.1905	.1905	.2096	.1905	.2096
21	.2968	.3281	.1715	.1715	.1905	.1715	.1905
22	.2812	.2968	.1334	.1143	.1524	.1524	.1524
23	.2656	.2372	.1143	.0762	.1143	.0953	.0953
24	.2429	.2343	.2214	.0953	.0762	.0953	.0953
Max	.3704	.4843	.3125	.4475	.5468	.4218	.3125
Min	.0762	.0953	.0953	.0762	.0762	.0762	.0953
Avg	.1791	.1861	.1653	.2128	.2066	.2155	.1839

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2865	.3155	.2947	.2774	.3258	.3294
2	.2254	.2865	.3155	.298	.2658	.3155	.2883
3	.2254	.2896	.3012	.2804	.2507	.3155	.2572
4	.2401	.2896	.2915	.2629	.2641	.3189	.2601
5	.2572	.2865	.3121	.3222	.2658	.3189	.2947
6	.2713	.2865	.3258		.2804	.3189	.3429
7		.4359	.3647	.4641	.3772	.39	.3944
8	.3277	.3772	.4588	.5668	.3647	.431	.4694
9	.3812	.4973	.4534	.5312	.3932	.431	.4641
10	.4287	.583	.4641	.5992	.4527	.5197	.4807
11	.4917	.5898	.5304	.6706	.4588	.5243	.4858
12	.5087	.5735	.547	.6274	.503	.5668	.4359
13	.57	.5636	.6104	.5735	.5365	.583	.4475
14	.57	.5868	.6706	.6226	.5533	.5636	.4694
15	.57	.6036	.7293	.6203	.5935	.6299	.427
16	.547	.5668	.7373	.5693	.57	.5992	.4409
17	.4588	.5182	.7373	.5304	.5571	.6062	.4481
18	.4915	.502	.7209	.4475	.5376	.6554	
19	.4409	.5197	.6154	.3856	.4527	.5079	.3681
20	.407	.4917	.5426	.4681	.4191	.4694	.3353
21	.3721	.4161	.4917	.4508	.4191	.4409	.3258
22	.333	.4161	.4287	.4115	.3856	.4239	.3258
23	.3189	.3814	.3814	.3467	.3561	.3944	.3391
24	.2572	.3045	.3467	.3467	.298	.3258	.3772
Max	.57	.6036	.7373	.6706	.5935	.6554	.4858
Min	.2254	.2865	.2915	.2629	.2507	.3155	.2572
Avg	.3884	.4439	.4872	.4648	.4097	.4573	.3829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 203 / 11 K V NEWARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1875	.1524	.0754	.0754	.0754	.0754
2	.0914	.1875	.1677	.0754	.0566	.0754	.0566
3	.0914	.1875	.1698	.0566	.0566	.0754	.0566
4	.0753	.1875	.1505	.0566	.0566	.0754	.0566
5	.0892	.1875	.1852	.0754	.0754	.0754	.0762
6	.1219	.1875	.2031	.0943	.0943	.0943	.0762
7	.0762	.1132	.1981	.132	.1132	.1132	.1509
8	.0953	.0943	.1635	.132	.1132	.1132	.1132
9	.0762	.0943	.1505	.0943	.0943	.1132	.1132
10	.0953	.0943	.0754	.3052	.2896	.3441	.2315
11	.0754	.0754	.0754	.4578	.3681	.3521	.2286
12	.0924	.0754	.0754	.431	.3593	.4428	.25
13		.0754	.0754	.4424	.3593	.5121	.2372
14	.0566	.0754	.0754	.421	.4161	.4641	.2343
15	.0566	.0566	.0754	.4641	.4481	.4481	.2187
16	.0377	.0754	.0943	.421	.4801	.3437	.208
17	.0754	.0754	.0747	.3953	.4687	.3125	.208
18	.0754	.0754	.0943	.0566	.0566	.0953	.1143
19	.0943	.0943	.1132	.0754	.0943	.0953	.0762
20	.0943	.0943	.0943	.0943	.0943	.1143	.0762
21	.1806	.2134	.1132	.0943	.0943	.1143	.0953
22	.1806	.2315	.0943	.0943	.0943	.0953	.0762
23	.1806	.2286	.0943	.0754	.0754	.0754	.0762
24	.104	.1829	.6478	.0754	.0754	.0943	.0943
Max	.1806	.2315	.6478	.4641	.4801	.5121	.25
Min	.0377	.0566	.0747	.0566	.0566	.0754	.0566
Avg	.0960	.1313	.1422	.1956	.1879	.1964	.1333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.197	.3142	.2033	.2926	.2033	.2033
2	.1991	.2149	.3292	.2218	.2715	.2012	.2033
3	.1991	.2353	.3475	.2402	.2865	.2012	.2195
4	.1991	.2743	.3475	.2772	.3077	.2195	.2195
5	.2534	.3292	.3658	.2957	.3292	.2378	.2561
6	.3292	.3761	.4024	.3326	.3109	.3439	.2715
7	.3544	.4024	.4207	.3658	.3142	.3761	.2896
8	.3403	.3439	.3582	.3439	.3077	.3582	.3292
9	.3224	.3012	.3189	.3506	.2481	.3045	.2658
10	.2601	.2629	.3121	.2601	.2229	.2507	.2601
11		.2427	.2058	.2401	.2035	.2804	.2254
12		.2279	.2012	.2204	.2035	.2374	.1886
13	.2279	.2103	.2058	.2254	.1696	.208	.1715
14	.1772	.2103	.2058	.2279	.1865	.1928	.1646
15	.1448	.181	.2328	.2279	.2058	.1578	.1372
16	.1753	.2254	.2328	.2254	.2058	.1928	.2012
17	.1753	.208	.2515	.2229	.2204	.208	.2374
18	.2658	.2454	.2401	.2454	.2507	.2481	.2427
19	.3189	.2865	.2865	.3224	.3258	.2507	.3077
20	.3841	.3439	.3511	.3439	.3841	.2353	.3439
21	.3475	.3142	.3142	.3109	.3292	.2378	.2896
22	.2743	.2587	.2926	.2715	.2801	.2402	.2614
23	.2378	.2772	.2241	.2402	.2054	.2054	.2241
24	.2126	.2033	.3142	.2033	.3109	.2054	.1848
Max	.3841	.4024	.4207	.3658	.3841	.3761	.3439
Min	.1448	.181	.2012	.2033	.1696	.1578	.1372
Avg	.2552	.2655	.2948	.2675	.2655	.2415	.2374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.5182	.4877	.3475	.1267	.0924	.0905
2	.0914	.5468	.4877	.3715	.1086	.0924	.0867
3	.0914	.583	.5182	.3763	.1086	.0914	.0867
4	.0914	.6274	.5182	.3963	.128	.1097	.1052
5	.1097	.5693	.5487	.4115	.128	.128	.1052
6	.128	.5401	.5418	.4268	.1448	.1417	.124
7	.1543	.1463	.5418	.5268	.1478	.1629	.1254
8	.156	.1629	.4841	.6773	.1254	.1494	.1267
9	.156	.1612	.4287	.1174	.1311	.2012	.1075
10	.1387	.1595	.0905	.787	.9488	1.0608	.5639
11	.1595	.1595	.0857	.9414	1.1069	.6562	.5792
12	.1578	.1595	.1006	1.1111	1.1523	1.0957	.6554
13	.1646	.1402	.0983	1.186	1.2176	1.0802	.7773
14	.1629	.1387	.0983	1.1873	1.1069	1.0623	.7621
15	.1595	.1267	.1029	1.0031	1.0936	1.0311	
16	.1433	.1187	.1029	1.0031	1.0753	.953	
17	.1063	.1063	.1214	1.0437	.9842	.8905	.6944
18	.12	.1254	.128	.1029	.1097	.0876	.1357
19	.1326	.1086	.1075	.1063	.1109	.0876	.124
20	.1612	.1267	.128	.1063	.1307	.1063	.1417
21	.5117	.4218	.128	.1075	.112	.1063	.124
22	.5335	.4515	.1097	.1097	.0943	.1063	.1063
23	.5247	.4515	.3185	.0895	.0934	.0867	.0867
24	.1075	.4904	.4515	.3429	.1063	.0934	.0857
Max	.5335	.6274	.5487	1.1873	1.2176	1.0957	.7773
Min	.0914	.1063	.0857	.0895	.0934	.0867	.0857
Avg	.1821	.2975	.2804	.5366	.4413	.4030	.2634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-JUN-18	30-JUN-18	01-JUL-18	02-JUL-18	03-JUL-18	04-JUL-18	05-JUL-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8223	.1578	.1753	.156	1.2809	1.0688	1.0059
2	.8002	.1612	.1595	.1595	1.3123	1.0402	1.0517
3	.8002	.181	.1595	.1629	1.3603	1.0526	1.1092
4	.8002	.1991	.1772	.1991	1.4413	1.0526	1.1561
5	.7907	.197	.1791	.2353	1.4737	1.1336	1.2029
6	.8642	.2195	.1791	.2534	1.4883	1.2163	1.2492
7	.2303	.2402	.181	.3109	1.4864	1.5203	1.2967
8	1.0911	1.6324	.1791	.2926	1.6091	1.6484	1.3441
9	1.4685	1.9204	.1949	.2507	.128	1.6484	1.3283
10	1.5023	1.8404	1.749	.2507	.1715	.208	.1526
11	1.5844	1.7604	1.9595	.2481		.2149	.1372
12	1.7284	1.7869	1.7711	.2715	.1907	.2279	.12
13	1.7711	1.781	1.9766	.2715	.2507	.2303	.1227
14	1.7394	1.9685	1.945	.2715	.2454	.2507	.1227
15	1.692	1.7124	1.8976	.2743	.2427	.2534	.1543
16	.1829	.3841	1.8501	.2658	.2427	.3045	.1715
17	.1595	.208	1.8027	.2774	.2454	.2303	.1715
18	.1075	.2401	.1802	.2658	.2279	.2353	.1734
19	.0876	.2279	.208	.2629	.1949	.2328	.197
20	.197	.197	.2353	.2601	.1791	.2149	.1791
21	.2012	.181	.2353	.2481	.1646	.1949	.1629
22	.1646	.1753	.2012	.1578	.1646	.1772	.1227
23	.1433	.1753	.1928	1.1265	.1612	.1595	.8078
24	.8381	.1417	.1753	.1734	1.2651	1.4255	.9755
Max	1.7711	1.9685	1.9766	1.1265	1.6091	1.6484	1.3441
Min	.0876	.1417	.1595	.156	.128	.1595	.12
Avg	.8236	.7370	.7485	.2769	.6751	.6642	.6048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-18 and 05-JUL-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 248001 / 220/33 VITA EHV KARVE S/STN

Feeder No / Name : 208 / EHV CONSUMER TEMBHU SHEDDABLE EHV(AGRICULTURE)

Feeder KV- 220 / OUTGOING

DATE	01-JUL-18
HR	Load (MW)
23	5.0869
Max	5.0869
Min	5.0869
Avg	5.0869