

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 KV HUTATMA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8402	.7762	.7577	.8215	.6535	.5853
2	.8501	.8402	.7762	.7577	.8215	.6535	.5853
3	.8501	.8402	.7762	.7577	.8215	.6535	.5853
4	.7602	.8402	.7842	.7421	.8215	.6908	.5853
5	.7602	.8402	.8215	.8326	.8215	.7207	.6219
6	.7316	.8962	.8589	.8688	.8048	.7577	.7207
7	.7392	.8596	.8775	.8507	.7865	.8029	.7577
8	.6653	.724	.8029	.7577	.695	.6468	.6767
9	.5975	.7619	.7947	.6268	.6219	.7095	.6219
10		.7842	.7947	.7655		.7095	.439
11		.8029	.6268	.7655	.7095	.6626	.3567
12		.8029	.8059	.7655	.6805	.6268	.6401
13		.8029	.7522	.8029	.6516	.6984	.6401
14		.8589	.8145	.8029	.6516	.6984	.6219
15		.8215	.7783	.7095	.6283	.6767	.6219
16		.8029	.7947	.6908	.7468	.6767	.6219
17		.8215	.7207	.7468	.6468	.6584	.5487
18		.9694	.7207	.7468	.7762	.6219	.5853
19		1.0608	.7207	.8402	.7947	.7499	.8048
20	1.0679	1.0425	.9709		.7655		.8779
21	1.0791	1.0059	.9335		.7468	.695	.8048
22	.9979	.8686	.8962	.9335	.7468	.6219	.8131
23	.9055	.8316	.8215	.9335	.7023	.5853	.7023
24	.8501	.8402	.7522	.7655	.8402	.6535	.5853
Max	1.0791	1.0608	.9709	.9335	.8402	.8029	.8779
Min	.5975	.724	.6268	.6268	.6219	.5853	.3567
Avg	.8361	.8566	.7988	.7828	.7436	.6793	.6418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 KV WALWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8193	2.7435	2.6981	2.2405		.3418	
2	2.8193	2.7435	2.6981	2.2405		.3418	
3	2.95	2.7435	2.6981	2.809		.3096	
4	2.9938	2.7435	2.7069	2.809		.3096	
5	3.2895	2.8349	2.8532	2.8054		.3096	
6	3.4004	3.091	3.0361	2.8778		.322	
7	3.7515	3.3665	3.1855	2.9569		.3549	
8	3.4355	3.2579	2.8416	3.3048		.3109	.3384
9	.2905	.3239	.3429	3.1276		.2016	.3384
10		.3368	.3429	3.1824		.2016	.3567
11		.3368	.3096	3.2922	1.0111	1.9605	.3567
12		.4854			.9448	1.9044	.3567
13		.3368	.2972	3.0178	.9282	1.7737	.3567
14		.3368	.3155	2.8715	.9282	1.8107	.2972
15		.3368	.3155	2.9264	1.1822	1.8107	.3418
16		.3368	.3064	2.9995	1.1361	1.7541	.3418
17		.4854	.2972	2.7435	1.1694		.3506
18		.3414	.3096	2.4326	1.1694	1.0751	.3658
19		.3658	.3418	.3567	.4715	.4715	.4481
20	.4572	.3963	.3944		.3286		.5121
21	.4089	.3963	.3944		.3418		.5373
22	.4172	.423	.3574	.4207	.3574		.5373
23	2.9014	2.7618	.3681	.4207	.3549		.5014
24	2.8193	2.7618	2.7166	.3035		.3418	
Max	3.7515	3.3665	3.1855	3.3048	1.1822	1.9605	.5373
Min	.2905	.3239	.2972	.3035	.3286	.2016	.2972
Avg	2.3396	1.4286	1.3099	2.3876	.7941	.8372	.3961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 KV.BAWACHI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	2.1582	2.1948		1.6461	2.1216
2	2.7435	2.7069	2.2314		1.6461	2.1216
3	2.8349	2.8166	2.8166		1.7193	2.1216
4	2.8349	2.8166	2.963		1.7924	2.1216
5	2.8349	2.8898			1.8107	2.1582
6	3.0544	3.0727			1.8473	2.1948
7	2.9081	3.0178			1.8839	2.2314
8	3.1459	3.0727	.8596		2.0119	2.3228
9	3.1093	3.1093	1.4632		2.3777	2.4326
10	3.0727	2.9813	1.4937		2.268	2.3777
11	3.2065	3.1276		.4207	2.524	1.8656
12	2.8006	3.1093		.4755	2.6703	1.8473
13	3.1741	3.1093		1.6461	2.7801	2.2497
14	3.1741	3.091	2.9874	2.1399	2.8166	.0566
15	3.1741	2.959	2.9874	2.0851	2.8166	2.1948
16	1.1389	.9511	1.251	.5121	.6767	.7316
Max	3.2065	3.1276	2.9874	2.1399	2.8166	2.4326
Min	1.1389	.9511	.8596	.4207	.6767	.0566
Avg	2.7919	2.8118	2.1248	1.2132	2.0805	1.9468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV PADAWALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2801	.2743	.2452	.1867	1.6518	1.073
2	.2829	.2801	.2743	.2452	.1867	1.6518	1.073
3	.2263	.2801	.2743	.2452	.1867	1.6518	1.073
4	.2263	.2801	.2801	.2452	.1867	1.6518	1.073
5	.2829	.2801	.3174	.2829	.1867	1.8623	
6	.3584	.3921	.3174	.3206	.3361	1.9109	1.1603
7	.3961	.3921	.3361	.3584	.3174	1.9757	1.1934
8	.3961	.3734	.3174	.3018	.2801	1.7976	1.3094
9	2.7692	3.195	3.2007	.2263	.2801	1.749	1.6078
10		3.1493	2.6566	.2241		1.5546	1.6575
11		3.315	2.5888	.2241		.2641	1.8564
12		.3315	2.3158	.2427		.2452	1.7126
13		.3315	2.2672	.2012		.1886	1.6975
14		2.7349	2.2834	.2054		.2075	1.6118
15		2.9007	2.2348	.2241	1.8785	.2263	1.5939
16		2.9007	2.4777	.2427	.2641	.2452	1.3717
17		.2614	.2829	.2801	.2829	.3206	1.3717
18		.2987	.3018	.3174	.3206	.2452	.2454
19		.3174	.3206	.3174	.3206	.2829	.2454
20	.5041	.3361	.3395		.3206		.2454
21	.3174	.2987	.3395		.3395	.2075	.2629
22	.3361	.3142	.2829	.2801	.2641	.1886	.2629
23	.2801	.3142	.2641	.1867	.2452	.1886	.1772
24	.2829	.2801	.2743	.2452	.1867	.2263	.2075
Max	2.7692	3.315	3.2007	.3584	1.8785	1.9757	1.8564
Min	.2263	.2614	.2641	.1867	.1867	.1886	.1772
Avg	.4958	.9932	1.0342	.2574	.3458	.8910	1.0471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV HUTATMA DUDH SANGH NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.9335	.8029	.8402	.6535	1.0269	.8029
2	.7842	.9335	.8029	.8402	.6535	1.0269	.8029
3	.7842	.9335	.7842	.7842	.6535	.9709	.8029
4	.7842	.9335	.7842	.7842	.6535	.9709	.8215
5	.7842	.9335	.8215	.7842	.7095	1.0269	.7842
6	.7468	.9149	.8215	.7842	.8215	1.0456	.7468
7	.7468	.9522	.8215	.7842	.8589	1.0456	.7282
8	.7282	.9709	.7842	.8029	.8215	.9896	.7282
9	.8402	1.0642	.7468	.9149	.8589	1.0269	.8402
10		1.1203	.7468	.9149		1.0642	.9335
11		1.1203	.8215	.8775	.5788	1.0642	1.0642
12		1.1576	.9335	.8589	.9149	1.0082	1.0642
13		1.1203	.8962		.8962	1.0456	1.0642
14		.9335	.8402	.8215	.8962	.8962	1.0642
15		1.0456	.8402	.8402	.8589	.8029	1.0562
16		1.0456	.8402	.8413	.8589	.8962	1.0374
17		1.0456	.8962	.8402	.7842	.9896	1.0185
18		1.0456	.8775	.8402	.8402	.9709	.9808
19		.9709	.8775	.8402	.8402	1.0082	.9808
20	.6535	.8962	.8962		.8962		.9431
21	.9335	.8589	.8402		1.0269	.9335	.9431
22	.9709	.8402	.8402	.1867	1.1203	.9335	.9431
23	.9709	.8402	.8402	.6722	1.0829	.9149	.9431
24	.7842	.9335	.8215	.8402	.6535	1.0269	.8215
Max	.9709	1.1576	.9335	.9149	1.1203	1.0642	1.0642
Min	.6535	.8402	.7468	.1867	.5788	.8029	.7282
Avg	.8069	.981	.8324	.7949	.8232	.9863	.9132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV AHIRWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3772	.3395	.3547	.2987	.2957	.0566
2	.3511	.3772	.3395	.3361	.2987	.2957	.0566
3	.3511	.3772	.3395	.3361	.2987	.2957	.0566
4	.3511	.3772	.3395	.3361	.2987	.2957	.0566
5	.3734	.3772	.3584	.3326	.2987	.3142	.0566
6	.4481	.415	.3772	.3696	.3174	.3547	.0754
7	.4805	.4904	.415	.3881	.3174	.4294	.0754
8	.4108	.415	.415	.3547	.2801	.4294	.0754
9	.3326	.3641	.3189	.3361	.2427	.3361	.0754
10		.3086	.3506	.2801		.3734	.2452
11		.3361	.3121	.3361	.2587	.3361	.4904
12		.3361	.3681	.3658	.2801	.3174	.4527
13		.3734	.3155	.3658		.2641	.4527
14		.3734	.3258	.3734		.3395	.415
15		.3734	.298	.3174	.3584	.3772	.3361
16		.3734	.3224	.3174	.3921	.2641	.3174
17		.3734	.3224	.3734	.1991	.415	.3772
18		.4481	.3511	.4108	.3326	.3018	.415
19		.5228	.4525		.3881	.4715	.4715
20	.6878	.5601	.5729		.3881	.3772	.5281
21	.5601	.5041	.5175		.4108		.5093
22	.5415	.4805	.4066	.2801	.4668		.4715
23	.4108	.4108	.4108	.2987	.3511		.3772
24	.3511	.3734	.3475	.3734	.2987	.3142	.0566
Max	.6878	.5601	.5729	.4108	.4668	.4715	.5281
Min	.3326	.3086	.298	.2801	.1991	.2641	.0566
Avg	.4287	.4049	.3715	.3446	.3227	.3428	.2709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.852	.7537	.7449		.0566	.0566
2	.8097	.852	.7537	.7449		.0566	.0566
3	.8097	.852	.7537	.7449		.0566	.0566
4	.8097	.852	.7537	.7449		.0566	.0566
5	.8421	.9012	.7865	.7773		.0566	.0566
6	.8907	.9503	.7865	.8421		.0566	.0566
7	1.0364	1.0486	.8192	.8745	.0566	.0566	.0566
8	1.0364	1.0159	.9012	.9555	.0566	.0566	.0566
9	.0566	.0747	.0566	1.085	.0566	.0566	.056
10		.0566	.0566	1.1603		.0566	.0566
11		.0566	.0566	1.1603	.4534	.4641	.0754
12		.0566	.0566	1.1603	.3563	.4973	
13		.0566	.0566	1.1603	.3563	.4973	
14		.0566	.0566	1.1603	.3725	.4973	.0566
15		.0566	.0566	1.1603	.3725	.4973	.0566
16			.0566	1.1603	.3401	.4973	.0566
17		.0566	.0566	1.1603	.3725	.4641	.0754
18		.0566	.0566	1.0442	.39	.431	.0754
19		.0566	.0566	.0566	.0754	.0566	.0566
20	.0566	.0566	.0754		.0566		.0566
21	.0566	.0566	.0566	.0566	.0566	.0566	.0566
22	.0566	.0566	.0754	.0566	.0566	.0566	.0566
23	.8848	.7865	.0754	.0566	.0566	.0566	.0566
24	.8097	.852	.7537	.0566		.0754	.0566
Max	1.0364	1.0486	.9012	1.1603	.4534	.4973	.0754
Min	.0566	.0566	.0566	.0566	.0566	.0566	.056
Avg	.6404	.4225	.3320	.7880	.2178	.2049	.0591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0185	.0185		.0185	.0185
2	.0185	.0185	.0185		.0185	.0185
3	.0185	.0185	.0185		.0185	.0185
4	.0185	.0185	.0185		.0185	.0185
5	.0185	.0185	.0185		.0185	.0185
6	.0185	.0185			.0185	.0185
7	.0185	.0185			.0739	.0185
8	.0185	.0185			.1109	.0185
9	.0185	.0185			.1294	.1109
10	.0189	.0185			.1109	.1109
11	.0566	.0185	.0183	.0185	.1109	.1109
12	.0566	.0185	.0183	.0185	.1109	.0377
13	.0189	.0185	.0183	.0185	.1109	.0377
14	.0549	.0185	.0183	.0185	.1109	.0189
15	.0189	.0185	.0183	.0185	.1109	.0189
16	.0189	.0185	.0183		.1109	.0189
Max	.0566	.0185	.0185	.0185	.1294	.1109
Min	.0185	.0185	.0183	.0185	.0185	.0185
Avg	.0256	.0185	.0184	.0185	.0751	.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6461	1.6461		.9877	1.5364
2	1.9753	1.9753	1.6461		.9877	1.5364
3	1.9753	2.0302	1.6461		.9877	1.5364
4	1.9753	2.0302	1.7558		1.2071	1.5364
5	1.9753	2.0302	1.8656		1.2071	1.5364
6	2.0851	2.0302	1.8656		1.3717	1.5364
7	2.0302	2.0302	1.9753		1.5364	1.5364
8	2.0302	2.0302	1.9753		1.5364	1.5912
9	1.9753	2.0302	2.0302		1.5364	1.4815
10	2.0302	1.9753	2.0302		1.5364	1.5364
11	2.0302	2.0302		.8779	1.701	1.5364
12	1.9753	2.0302	2.0302	1.5364	1.8656	1.8673
13	2.0302	1.9753	2.0302	1.5364	1.5364	1.8673
14	2.0302	1.9753	1.0974	1.5364	1.5364	1.8673
15	2.0302	1.9753	1.8656	1.5912	1.5364	1.358
16	1.3169	1.3169	1.6461	1.0425	.9877	1.358
Max	2.0851	2.0302	2.0302	1.5912	1.8656	1.8673
Min	1.3169	1.3169	1.0974	.8779	.9877	1.358
Avg	1.9445	1.9445	1.8071	1.3535	1.3786	1.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 KV. SHIGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2191	1.0364	.9808	.7876	.0263	.024	.0263
2	1.2193	1.0364	.9808	.7977	.0259	.0244	.0263
3	1.2498	1.0364	.9808	.823	.0259	.0244	.0259
4	1.25	1.0494	1.0105	.7876	.0263	.0251	.0259
5	1.2809	1.0802	1.0402	.7977	.04	.0255	.0263
6	1.2498	1.1248	1.0402	.7827	.04	.0259	.0394
7	1.3565	1.0974	1.1888	.7977	.0372	.0263	.0389
8	1.2037	1.0536	1.0402	.9145	.036	.0267	.0259
9	.0549	.0198	.0514	1.0494	.0221	.021	.0267
10	.0282	.0514	.0328	1.2186	.0372	.0225	.0267
11	.0282	.0343	.0509	1.2186	1.2963	1.3546	.0274
12	.0457	.0343	.0497	1.2186	1.3279	1.448	.0267
13	.048	.04	.0332	1.2186	1.2346	1.3108	.0206
14	.048	.0267	.0537	1.0059	1.1111	1.2498	.0225
15	.0469	.0267	.0514	.9934	1.0669	1.1888	.0236
16	.0457	.0305	.0514	.9633	1.0059	1.1584	.0263
17	.0469	.0305	.0543	.743	.8642		.0225
18	.0469	.0305	.0739	.7133	.7926	.9633	.021
19	.0457		.0747	.0354	.0412	.0267	.0248
20	.0423	.0343	.0747	.0354	.0377	.0267	.0377
21	.0423	.0267	.0754	.04	.0394	.0274	.0232
22	.0412	.0305	.0754	.0274	.0232	.0297	.0244
23	1.2186	1.0402	.0566	.0274	.0229	.0301	.0248
24	1.2346	1.1873	1.0997	.056	.0263	.0229	.0259
Max	1.3565	1.1873	1.1888	1.2186	1.3279	1.448	.0394
Min	.0282	.0198	.0328	.0274	.0221	.021	.0206
Avg	.5456	.4851	.4259	.7105	.3836	.3949	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 KV. BHADKAMBE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.3544	.4031	.0373	.3856	.0373
2	.3898	.3544	.3982	.0373	.3856	.0377
3	.3898	.3544	.4119	.0566	.3898	.0377
4	.3898	.3721	.4075	.0566	.394	.0377
5	.4031	.3721	.4075	.0566	.394	.0377
6	.4031	.3721	.4031	.0566	.394	.394
7	.3898	.3544	.3856	.394	.394	.3898
8	.394	.3582	.3982	.3898	.394	.3898
9	.3856	.3582	.0011	.3898	.3898	.394
10	.3544	.4031	.0026	.3898	.3898	.394
11	.3544	.4031	.0025	.4163	.4075	.3898
12	.3544	.3856	.0025	.4119	.4075	.3898
13	.3189	.3898	.0025	.4163	.4119	.3898
14	.3721	.3898	.0025	.4119	.4119	.394
15	.3544	.394	.0025	.4119	.4119	.394
16	.2303	.2401	.0024	.2534	.2507	.2507
Max	.4031	.4031	.4119	.4163	.4119	.394
Min	.2303	.2401	.0011	.0373	.2507	.0373
Avg	.3668	.3660	.2021	.2616	.3883	.2724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 KV.POKHARNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1109	.1132	.1132	.0747	.0754	.0747
2	.1307	.1109	.0943	.0943	.0747	.0754	.0747
3	.1307	.1109	.0943	.0943	.0739	.0747	.0747
4	.1478	.1097	.0943	.0934	.0739	.0747	.0739
5	.1494	.1097	.1132		.0914	.0747	.0924
6	.168	.1097	.1132	.0934	.1097	.112	.1097
7	.168	.1294	.1132	.1132	.1086	.0924	.0905
8	.1227	.1294	.0838	.0905	.0905	.0739	.0716
9	.0876	.0895	.0857	.1063	.0716	.0709	.0724
10	.0905	.1017	.0972	.0934	.0686	.0701	.1086
11	.0732	.1029	.0937	.0686	.0686	.1029	.1063
12	.0716	.0876	.0762	.0686	.0678		.0724
13	.0895	.0905	.0343	.0671	.0886		.1029
14	.1063	.0914	.0339	.1402	.0924	.1086	.0876
15	.0895	.1097	.0514	.1402	.1097	.1097	.0709
16	.0716	.1097	.0753	.1543	.0739	.1097	.0724
17		.1109	.1029	.1402	.0709	.1109	.0724
18		.0924	.1052	.1052	.0701	.104	.1086
19	.112	.0924	.1254	.1267	.1063	.1052	.1109
20	.132	.1063	.1646		.1063	.0724	.1307
21	.132	.1372	.1494	.1097	.112	.0739	.112
22	.1132	.1402	.132	.0739	.1063	.0934	.0934
23	.112	.1402	.1132	.0739	.1109	.0754	.1132
24	.1307	.112	.1052	.1132	.0747	.112	.0747
Max	.168	.1402	.1646	.1543	.112	.112	.1307
Min	.0716	.0876	.0339	.0671	.0678	.0701	.0709
Avg	.1163	.1098	.0985	.1034	.0873	.0897	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 KV SHIGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3395	.3395	.3395	.3395	.3395	.3018
2	.3584	.3395	.3395	.3326	.3395	.3395	.3018
3	.3547	.3395	.3395	.3395	.3395	.3395	.3018
4	.3734	.3395	.3772	.3547	.3395	.3395	.3018
5	.4294	.3772	.415	.3734	.3772	.3395	.3395
6	.4904	.4527	.415	.3734	.415	.415	.3772
7	.4251	.4481	.4024	.3921	.4108	.4108	.3734
8	.3439	.3696	.3326	.3475	.3658	.3326	.3326
9	.3012	.3224	.3189	.3361	.3258	.3439	.3292
10	.2507	.3174	.3366	.3224	.3189	.3045	.3258
11	.2507	.3142	.3582	.3258	.2835	.3224	.3224
12	.2896	.2957	.3801	.3292	.2865	.3224	.3258
13	.2896	.3292	.3801	.3658	.3077	.3403	.1629
14	.2896	.3109	.3658	.3292	.3077	.3439	.2715
15	.2561	.3109	.362	.3292	.3109	.3475	.3189
16	.2561	.2896	.362	.3326	.2896		.3582
17	.3224	.3292	.3658	.3258	.2835	.2896	.362
18	.3506	.3292	.3582	.3224	.3077	.2774	.362
19	.3982	.4481	.4298	.3982	.3721	.4207	.4024
20	.439	.5228	.5175		.4805	.4435	.4481
21	.4435	.4854	.462	.439	.4481	.3734	.415
22	.4108	.4854	.4527	.4481	.4108	.3361	.415
23	.3772	.4066	.3961	.3395	.3772	.3018	.3772
24	.3584	.3395	.3734	.3584	.3395	.3395	.3018
Max	.4904	.5228	.5175	.4481	.4805	.4435	.4481
Min	.2507	.2896	.3189	.3224	.2835	.2774	.1629
Avg	.3507	.3684	.3825	.3545	.3490	.3462	.3387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 KV POKHARNI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0543	.0362	.0566	.3749	.3567	.1783
2	.0566	.0543	.0362	.0566		.3384	.1783
3	.056	.0549	.0362	.056	.3749	.3567	.176
4	.056	.0549	.0914	.0554	.3658	.3612	.176
5	.0747	.0554	.0549		.3963	.3814	.2054
6	.0934	.0554	.0732	.0549	.4268	.4108	.2317
7	.0943	.0747	.0747	.0747	.535	.602	.2972
8	.0943	.0754	.0709	.0566	.6161	.6706	.3913
9	.888	.8215	1.3375	.0377	.4858	.5144	.4515
10	.9031	1.0997	.9808	.0566	.3201	.4858	.4988
11	.9031	1.0402	.9332	.0566	.0514	.0509	.5053
12	.6241	.9214	.9145	.0566	.0514	.0526	.5117
13	.6161	.8345	.7674	.0566	.0543	.0549	.5053
14	.6161	.8619	.7674	.0566	.0554	.0549	.4904
15	.6661	.7727	.8655	.0566	.0554	.0554	.5117
16	.6661	.4344	.8655	.0566	.056	.0549	.4755
17	.0373	.0446	.056	.0754	.0549	.0554	.4515
18	.0566	.0297	.0566	.0754	.0549	.0543	.0566
19	.0549	.0343	.0554	.0754	.0566	.0549	.0566
20	.0732	.0514	.056		.0554	.056	.056
21	.0739	.0514	.0554	.0747	.056	.0566	.056
22	.0554	.0343	.0566	.056	.0566	.0566	.056
23	.056	.037	.056	.056	.0566	.0377	.0566
24	.0566	.0549	.0332	.056	.0554	.0566	.0377
Max	.9031	1.0997	1.3375	.0754	.6161	.6706	.5117
Min	.0373	.0297	.0332	.0377	.0514	.0377	.0377
Avg	.2887	.3168	.3471	.0597	.2029	.2179	.2755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / HUTATMA SURESHKUMAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.2743	.2614	.0191	.2641
2	.132	.132	.2957	.2801	.2829	.2801
3	.132	.132	.2987	.2801	.2829	.2801
4	.132	.132	.2772	.2801	.2829	.2801
5	.132	.1509	.2801	.2801	.2829	.2801
6	.132	.1509	.2957	.2801	.2829	.2801
7	.132	.1509	.2957	.2801	.2829	.2801
8	.132	.1509	.2987	.2801	.2829	.2801
9	.132	.1509	.2957	.2801	.2801	.2829
10	.132	.1509	.2987	.2801	.2801	.2829
11	.132	.1509	.2801	.2801	.2801	.2829
12	.1509	.0191	.2801	.2801	.2801	.2829
13	.1886	.2957	.2801	.2801	.2801	.2829
14	.2829	.2987	.2801	.2801	.2801	.2829
15	.2829	.2957	.2801	.2801	.2801	.2641
16	.1097	.2743	.2801	.2614		
17					.2614	
Max	.2829	.2987	.2987	.2801	.2829	.2829
Min	.1097	.0191	.2743	.2614	.0191	.2641
Avg	.1530	.1730	.2869	.2778	.2638	.2791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4515	.4572	.4344	.2972	.0179	.0189	.0181
2	.4572	.4515	.4458	.2934	.0177	.0187	.0183
3	.4572	.4515	.4458	.301	.0177	.0187	.0183
4	.4666	.4515	.4401	.286	.0177	.0185	.0185
5	.4607	.4755	.4572		.0175	.0185	.0185
6	.4607	.5053	.4572	.1467	.0175	.0183	.0187
7	.6015	.4755	.5944	.1486	.0187	.0185	.0185
8	.4489	.4515	.5502	.1614	.0189	.0183	.0185
9	.0189	.0189	.0377	.1907	.0189	.0189	.0187
10	.0189	.0189	.0189	.3144	.0189	.0185	.0183
11	.0189	.0177	.0189	.3185	.3658	.4108	.0189
12	.0189	.0177	.0189	.3185	.4572	.4012	.0189
13	.0189	.0189	.0189	.1486	.3704	.4816	.0185
14	.0189	.0189	.0189	.3227	.3395	.4816	.0183
15	.0189	.0189	.0189	.3227	.3658	.4816	.0185
16	.0189	.0111	.0189	.2934	.3658	.4064	.0185
17		.0114	.0189	.3185	.3241	.4572	.0189
18		.0114	.0189	.2858	.3506	.4287	.0189
19	.0181	.0189		.0189	.0189	.0152	.0189
20	.0183	.0189			.0185	.0177	.0189
21	.0183	.0114		.0185	.0185	.0181	.0189
22	.0185	.0267	.0191	.0185	.0183	.0179	.0189
23	.3913	.3715	.0189	.0183	.0185	.0177	.0189
24	.4816	.4572	.4374	.0189	.0179	.0189	.0179
Max	.6015	.5053	.5944	.3227	.4572	.4816	.0189
Min	.0181	.0111	.0189	.0183	.0175	.0152	.0179
Avg	.2228	.1995	.2147	.2073	.1346	.1600	.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.5093	.9619	.9054	.679	.7922
2	.2195	.5093	.9619	.9054	.679	.7922
3	.2195	.5093	.9619	.9054	.679	.7922
4	.2218	.5093	.9619	.9054	.9054	.7922
5	.2218	.5093	.9619	.9619	.9619	.8488
6	.2218	.5093	.9619	.9619	.9619	.8488
7	.5093	.5093	.9619	.9619	.9619	.9619
8	.5093	.5658	.9619	.9054	.9619	.9619
9	.5093	.9619	.9619	.9619	.9619	.9619
10	.4572	.9619	.9619	.9619	.9619	.9619
11	.4572	.9619	.9619	.9619	.9619	.9619
12	.4572	.9619	.9619	.9619	.9619	.9619
13	.4572	.9619	.9054	.9619	.9619	.9619
14	.5144	.9619	.9522	.9619	.9619	.9619
15	.5144	.9619	.9522	.9619	.9619	.9619
16	.4001	.8488	.9522	.8488	.8488	.9619
Max	.5144	.9619	.9619	.9619	.9619	.9619
Min	.2195	.5093	.9054	.8488	.679	.7922
Avg	.3818	.7321	.9566	.9372	.8983	.9053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV KRISHNAMAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7042	.7682	.663		
2		.7042	.759	.6299		
3		.7042	.759	.6226		
4		.7042	.7432	.6133		
5		.7042	.7432	.583		
6		.7042	.7099	.5376		
7		.7682	.7287	.5967		
8		.7682	.7202	.6371		
9				.7209		
10				.6722		
11	.5441			.7682	.7537	.7611
12	.6081			.8097	.7537	.7935
13				.8097	.6554	.7842
14				.8097	.7209	.6882
15				.8097	.6882	.7701
16				.8002	.6882	.7611
17				.8478	.6962	.7701
18				.7362	.6962	.7449
23		.7274				
24		.7042	.7935			
Max	.6081	.7682	.7935	.8478	.7537	.7935
Min	.5441	.7042	.7099	.5376	.6554	.6882
Avg	.5761	.7193	.7472	.7038	.7066	.7592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV MAHALAXMI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	1.2403	1.2226	1.2226	1.2226	1.1568
2	.6878	1.2715	1.2536	1.2226	1.2226	1.1568
3	.6878	1.2536	1.2715	1.2226	1.2226	1.1694
4	.6878	1.2536	1.2536		1.2226	1.1694
5	.6878	1.258	1.2851	1.2226	1.2226	1.1568
6	.6878	1.2715	1.2715	1.2226	1.2226	1.1694
7	.6878	1.2894	1.2715	1.2536	1.2226	1.1871
8	.6878	1.2894	1.2715	1.2403	1.2757	1.1871
9	.6154	1.3073	1.2894	1.2894	1.2757	1.1919
10	.6154	1.262	1.2894	1.2757	1.2934	1.2048
11	.9214	1.262	1.2894	1.2757	1.3432	1.2178
12	1.2757	1.258	1.2757	1.2757	1.2971	1.182
13	1.2757	1.258	1.2757	1.2757	1.2934	1.1871
14	1.2934	1.258	1.2894	1.2757	1.3073	1.1999
15	1.2757	1.2445	1.2536	1.2757	1.3073	1.1871
16	1.258	1.2136	1.2536	1.2757	1.2795	.9465
Max	1.2934	1.3073	1.2894	1.2894	1.3432	1.2178
Min	.6154	1.2136	1.2226	1.2226	1.2226	.9465
Avg	.8771	1.2619	1.2698	1.2551	1.2644	1.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV YASHWANT AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3226	1.4746	1.3748	.9259		
2	1.2929	1.4746	1.3904	.9259		
3	1.3077	1.4746	1.3565	.8987		
4	1.3077	1.4746	1.3413	.9088		
5	1.3077	1.4746	1.3245	.8987		
6	1.3245	1.4746	1.3056	.8987		
7	1.4083	1.5432	1.3904	.9665		
8		1.5432	1.2742	.9326		
9		1.5432		1.3565		
10				1.4083		
11				1.4419	1.6297	1.7295
12				1.4746	1.0867	1.4083
13				1.4754	1.4723	1.5424
14				1.4754	1.5775	1.543
15				1.5424	1.56	1.6617
16				1.5775	1.3717	1.4089
17				1.5432	1.4083	1.4752
18				1.4746	1.4083	1.3413
23	1.3748	1.3735				
24	1.3226	1.4403	1.4074			
Max	1.4083	1.5432	1.4074	1.5775	1.6297	1.7295
Min	1.2929	1.3735	1.2742	.8987	1.0867	1.3413
Avg	1.3299	1.481	1.3517	1.2292	1.4393	1.5138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV ASHTA PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0709	.0716	.0709		.0709	.0709
2	.0701	.0709	.0716	.0709	.0709	.0709	.0709
3	.0701	.0709	.0716	.0716	.0709	.0709	.0709
4	.0701	.0709		.0716	.0709	.0709	
5	.0701	.0709	.0716	.0709	.0709	.0709	.0709
6	.0693	.0709	.0716	.0716	.0709	.0709	.0709
7	.0693	.0709	.0716	.0716	.0709	.0709	.0709
8	.0701	.0709	.0709	.0709	.0701	.0709	.0709
9	.0701	.0709	.0716	.0716	.0709	.0709	.0709
10	.0709	.0701	.0701	.0709	.0701	.0709	.0709
11	.0709	.0709	.0709	.0709	.0701	.0716	.0716
12	.0709	.0709	.0709	.0709	.0701	.0709	.0709
13	.0709	.0709	.0701	.0709	.0701	.0709	.0716
14	.0709	.0709	.0701	.0709	.0701	.0716	.0716
15	.0709	.0709	.0709	.0709	.0701	.0716	.0709
16	.0709	.0709	.0351	.0709	.0701	.0709	.0709
17	.0709	.0701	.0709	.0709	.0701	.0716	.0701
18	.0701	.0693	.0709	.0709	.0701	.0716	.0709
19	.0701	.0693	.0709	.0709	.0709	.0701	.0701
20	.0701	.0693	.0709	.0709	.0709	.0709	.0709
21	.0701	.0701	.0709	.0709	.0709	.0701	.0709
22	.0701	.0701	.0709	.0709	.0709	.0701	.0709
23	.0701	.0709	.0709	.0709	.0709	.0701	.0709
24	.0701	.0701	.0716	.0701	.0709	.0709	.0701
Max	.0709	.0709	.0716	.0716	.0709	.0716	.0716
Min	.0693	.0693	.0351	.0701	.0701	.0701	.0701
Avg	.0703	.0705	.0695	.0710	.0706	.0709	.0709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV TRYAMBKESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.2303	.0175	.0091	.112	.0051
2	.128	.2279	.0177	.0091	.112	.0051
3	.128	.2279	.0175	.0091	.112	.0053
4	.128	.2279	.0175	.0091	.112	.0053
5	.128	.2303	.0177	.0091	.0747	.0051
6	.128	.2303	.1448	.0084	.112	.0053
7	.128	.2279	.2103	.1267	.112	.1267
8	.128	.2279	.2126	.1612	.197	.2279
9	.128	.2279	.2126	.2149	.2328	.2279
10	.128	.2254	.2103	.2279	.2279	.2126
11	.128	.2279	.2103	.2279	.2279	.2126
12	.128	.1227	.2126	.2303	.2279	.2126
13	.128	.1214	.2126	.2303	.2279	.2126
14	.1267	.1227	.2126	.2303	.2279	.2126
15	.1267	.124	.2126	.2303	.2279	.2126
16	.1463	.1595	.2126	.3605	.2279	.2103
Max	.1463	.2303	.2126	.3605	.2328	.2279
Min	.1267	.1214	.0175	.0084	.0747	.0051
Avg	.1290	.1976	.1470	.1434	.1732	.1312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7461	.3018	.3605	.2984	.3647	.0724
2	.7461	.3185	.3647	.2984	.3647	.0724
3	.7461	.3561	.3688	.2984	.3647	.0732
4	.7461	.3521	.3647	.3018	.3647	.0914
5	.7461	.3521	.3647	.3018	.3647	.0724
6	.7461	.373	.3688	.3688	.3647	.0732
7	.6443	.3688	.3688	.3605	.3647	.0732
8	.6443	.3688	.3978	.3277	.4915	.5079
9	.6443	.4144	.4024	.3605	.6226	.6371
10	.6539	.4372	.4024	.3605	.6874	.6036
11	.6706	.4475	.4024	.3605	.6783	.6371
12	.663	.4144	.3018	.3605	.6874	.6464
13	.663	.4144	.3018	.3605	.7042	.6539
14	.6706	.4096	.3018	.3605	.7122	.6706
15	.6539	.4049	.2683	.3605	.7122	.6706
16	.6539	.4001	.2683	.3605	.6796	.6539
Max	.7461	.4475	.4024	.3688	.7122	.6706
Min	.6443	.3018	.2683	.2984	.3647	.0724
Avg	.6899	.3834	.3505	.3400	.5330	.3881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV BAGNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0732	.112	.037	.1524	2.0416	1.8983
2	.0709	.0732	.112	.0373	.1524	2.0271	1.8983
3	.0716	.0739	.1109	.037	.1524	2.0302	1.8983
4	.0709	.0739	.1109	.037	.1524	2.0485	1.8781
5	.0716	.0924	.112	.0373	.1524	2.0851	1.858
6	.0886	.1116	.1294	.0377	.1829	2.1357	1.9667
7	.1052	.1097	.1494	.056	.2709	2.2443	2.0953
8	.1063	.128	.1478	.0924	.2824	2.4691	2.2386
9	2.8054	2.7018	2.8349	.0754	2.0199	2.2207	2.364
10	2.95	2.7496	3.0445	.056	2.1742	2.1765	2.4356
11		2.372	2.8166	.0754	.0924	.0701	2.6235
12		2.372	2.7639	.0754	.0905	.0709	2.4806
13		2.4646	2.2969	.0566	.0905	.0701	2.6863
14		2.4059	2.3061	.0566	.0924	.0732	2.6863
15		2.4985	2.2721	.0566	.0924	.0716	2.6863
16		2.5152	2.2298	.1109	.0914	.0716	2.5072
17		.0934	.0747	.1109	.1267	.0716	2.4806
18		.1109	.0924	.0924	.0724	.0716	2.2443
19	.1294	.112	.0934	.1097	.0905	.0895	.0709
20	.1294	.1294	.1109		.0919	.0895	.0914
21	.1267	.1307		.112	.0905	.0701	.0924
22	.1097	.1294	.0377		.0905	.0532	.1307
23	.1097	.1307	.0377	.0716	.0739	.0532	.1307
24	.0716	.0924	.1109	.0373	.0554	.0739	.0537
Max	2.95	2.7496	3.0445	.112	2.1742	2.4691	2.6863
Min	.0701	.0732	.0377	.037	.0554	.0532	.0537
Avg	.4429	.9060	.9612	.0668	.2889	.9366	1.7290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV ASHTA CHADOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0739	.0747	.0924	.4999	.6958	.7087
2	.0867	.0724	.0739	.0934	.4999	.6562	.7164
3	.0876	.0724	.0739	.0934	.4999	.6327	.7011
4	.0886	.0732	.0747	.0924	.5624	.6327	.7087
5	.0886	.0914	.1109	.1294	.6481	.6562	.7164
6	.1052	.128	.112	.1478	.7716	.703	.7202
7	.124	.1267	.0924	.1132	.9602	.8124	.7545
8	.0716	.1267	.056	.0934	.7727		.823
9	.9488	1.0883	1.0467	.112	.7011	.5921	.8128
10	1.0311	1.0437	.9686	.0739	.7011	.6226	.8128
11		.9962	.9804	.0934	.0732	.0829	.884
12		.8745	.9922	.112	.0554	.0678	.8535
13		.9054	.9717	.1132	.0554	.0686	.7827
14		.9282	.9614	.0943	.0732	.0526	.7827
15		.9175	.9175	.0943	.0732	.0532	.7926
16		.9448	.852	.112	.0732	.0709	.743
17		.0747	.0934	.112	.0732	.0895	.6455
18		.0739	.0924	.1109	.0732	.0724	.6455
19	.112	.0934	.0934	.1109	.0914	.0914	.0754
20	.1109	.0924	.0924		.0914	.1109	1.5844
21	.1109	.0934	.0934	.1132	.1097	.0895	.1132
22	.1109	.0924	.0924	.1132	.1109	.0895	.132
23	.1097	.0747	.0934	.415	.0934	.0895	.1132
24	.0886	.0924	.0739	.4478	.0943	.0934	.0895
Max	1.0311	1.0883	1.0467	.4478	.9602	.8124	1.5844
Min	.0716	.0724	.056	.0739	.0554	.0526	.0754
Avg	.2102	.3813	.3785	.1341	.3233	.3098	.6547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2283	2.1464	2.2874	1.6575	.0377	.0373	.0526
2	2.2542	2.0972	2.2611	1.6766	.0377	.037	.0526
3	2.2542	2.1051	2.2611	1.6907	.0377	.0377	.0532
4	2.2283	2.0885	2.3205	1.6907	.0377	.0377	.0526
5	2.2542	2.1795	2.3807	1.7101	.0377	.0377	.0526
6	2.2775	2.2377	2.3703	1.7101	.0377	.0566	.0532
7	2.3537	2.3922	2.332	1.7072	.0566	.0566	.0709
8	2.3266	2.4366	2.3371	2.0119	.0554	.0373	.0716
9	.037	.0373	.0377	2.079	.0373	.0366	.0709
10	.0377	.0377	.0377	2.4646	.0373	.0366	.0732
11		.0373	.0373	2.5652	2.5149	2.7343	.0716
12		.037	.0377	2.6322	2.6189	2.5377	.0701
13			.0373	2.649	2.5396	2.8045	.0537
14			.038	2.73	2.5526	3.0476	.0362
15			.0373	2.6993	2.6023	2.8296	.0366
16		.0373	.037	2.6825	2.536	2.8959	.0351
17		.0554		2.323		2.8715	.0358
18		.0373		2.2969	2.2045	2.552	.0362
19	.056	.037		.0373	.037	.0351	.0554
20	.0566	.037			.056	.0354	.037
21	.056	.0373		.0373	.056	.0532	.0366
22	.0566	.037		.0373	.0566	.0709	.0373
23	2.2131	2.5579		.0377	.0373	.0532	.0373
24	2.2708	2.2045	2.2969	.0373	.0377	.0373	.0709
Max	2.3537	2.5579	2.3807	2.73	2.6189	3.0476	.0732
Min	.037	.037	.037	.0373	.037	.0351	.0351
Avg	1.4351	1.0892	1.2439	1.7028	.7940	.9571	.0522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 204 / SWARAJYA AGRO INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0566	.037	.0943	.0747	.056	
2	.0526	.0566	.0747	.0924	.0747	.037	
3	.0709	.0373	.0747	.0934	.0747	.0554	
4	.0537	.056	.0754	.0924	.0747	.056	
5	.0537	.0554	.0754	.112	.0739	.0754	
6	.0709	.0554	.0754	.1109	.0732	.0758	
7	.0362	.0373	.0747	.112	.0716	.0554	
8	.0732	.037	.037	.1109	.0358		
9	.0739	.0747	.0739	.0366	.0724	.0181	
10	.0549	.0739	.0554	.0716	.0362	.0724	.0358
11		.0549	.0373	.0724	.0543	.0732	.0716
12		.0554	.037	.0716	.0554	.0366	.0701
13		.056	.0373	.0716	.0732	.0358	.0354
14		.0754	.037	.0732	.0747	.0179	.0362
15		.0747	.056	.0876	.0747	.0358	.0724
16		.0754	.0747	.0876	.0747	.0724	.0716
17		.0373	.0739	.1086	.0739	.0183	.0876
18		.0739	.0373	.037	.0554	.0185	.0867
19	.0183	.0934	.037	.0366	.1097	.0175	.0358
20	.0366	.0924	.0747		.0924		.0543
21	.0549		.0739		.0943		
22	.0185	.0739	.112	.037	.132		.0366
23	.0732	.0739	.1294	.0373	.0943		.1109
24	.0716	.0549	.037	.1132	.0754	.0566	
Max	.0739	.0934	.1294	.1132	.132	.0758	.1109
Min	.0183	.037	.037	.0366	.0358	.0175	.0354
Avg	.0541	.0622	.0628	.0800	.0748	.0465	.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3761	.3841	.4066	.4066	.3395	.3658	.3189
2	.3761	.3658	.3696	.3734	.3395	.3658	.3224
3	.3841	.362	.3734	.3696	.3395	.3439	.3189
4	.3761	.3439	.3696	.3696	.3395	.3292	.3224
5	.3801	.3658	.4066	.3734	.3395	.3658	.2896
6	.4024	.4251	.4066	.3326	.3772	.3881	.2561
7	.3475	.4207	.3734	.2801	.3174	.3696	.2587
8	.3109	.3511	.2957	.2402	.2743		.2743
9		.3361	.3511	.2561	.2561	.3292	.2279
10	.2743	.3696	.3696	.3582	.3109	.3326	
11		.4108	.3734	.3582	.2926	.3475	.3224
12		.3696	.3696	.4163	.2402	.3292	.3582
13		.3734	.4108	.3658	.2957	.3292	.3292
14		.3696	.4066	.4024	.3511	.3696	.3658
15		.3696	.3734	.4024	.3696	.3658	.3881
16		.3734	.3881	.3475	.3696	.3511	.3982
17		.4435	.4108	.3982	.3881	.3841	.394
18		.4854	.4251	.4607	.4066	.3403	.4298
19	.5175	.5544	.4435	.4887	.4066	.4344	.4298
20	.5359	.5359	.5228		.4938	.4252	.499
21	.5359	.5228	.4805	.4668	.5068	.4163	.5041
22	.5121	.4805	.4854	.4527	.4755	.3801	.4715
23	.4755	.4435	.4607	.415	.4435	.3582	.415
24	.439	.4251		.439	.3772	.4066	.3258
Max	.5359	.5544	.5228	.4887	.5068	.4344	.5041
Min	.2743	.3361	.2957	.2402	.2402	.3292	.2279
Avg	.4162	.4117	.4032	.3815	.3604	.3664	.3574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1886	.1772	1.3735		1.1431
2	.1698		.1698	.1772	1.4022		1.2037
3	.1509		.1509	.1417	1.3717		1.2193
4	.132		.1509	.1949	1.3108		1.25
5	.168		.1867		1.3565		1.2654
6	.2241		.2427		1.4815		1.2955
7	.2772		.2402		1.5741		1.3735
8	.2402				1.5394		1.5394
9				.1949	1.4937	1.4373	1.5546
10		2.2929			1.4937	1.2803	1.6461
11		2.2028		.1509	.1109	.1646	1.6358
12		2.0622		.1886	.1109	.1448	1.6512
13		1.9444		.2263	.1097	.1433	1.6667
14		1.8364		.1867	.1097	.1463	1.6204
15		1.7497		.2054	.1086	.1629	1.6248
16		1.6716		.2241		.1448	1.656
17		.1791		.168			1.4327
18		.2012		.168		.197	1.2037
19		.2218		.1867		.1991	.1829
20		.2614				.1829	.2054
21		.2427				.1646	.2054
22		.2263				.1463	.2075
23		.2075		.0943		.128	.1886
24	.1886		.1886		.0943		.1097
Max	.2772	2.2929	.2427	.2263	1.5741	1.4373	1.6667
Min	.132	.1791	.1509	.0943	.0943	.128	.1097
Avg	.1912	1.0929	.1898	.1790	.9401	.3316	1.1284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8027		1.5655	.7748	.096		.096
2	1.7553		1.5023	.7274	.096		.096
3	1.7078		1.4548	.68	.08		.112
4	1.7711		1.5497	.7748	.08		.112
5	1.8185		1.7078	.8381	.096		.1094
6	1.9292		1.8343	.9488	.128		.125
7	2.1506		1.692		.144		.1406
8	1.7869		1.5181		.144		.125
9					.144	.16	.1094
10		.1265			.064	.16	.1094
11		.1107		1.5813		1.8564	.0625
12		.1107		1.3603	1.3117	1.8724	
13		.0949		1.1523	1.3923		.0781
14		.0949		1.3123	1.4083	1.6004	.0781
15		.1107		1.3443	1.4083	1.4232	.0781
16		.1107		1.3603	1.3283	1.2651	.0781
17		.1107		1.3763		1.0437	.0937
18		.1107		1.1843		.933	.0937
19		.1265		.16		.1107	.0937
20		.1423		.096		.1107	.1094
21		.1423		.096		.1107	.1094
22		.1265		.096		.096	.0937
23		1.5339		.096		.096	.0937
24	1.8501		1.5971	.9014	.096		.096
Max	2.1506	1.5339	1.8343	1.5813	1.4083	1.8724	.1406
Min	1.7078	.0949	1.4548	.096	.064	.096	.0625
Avg	1.8414	.218	1.6024	.8430	.5011	.7742	.0997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV ASHTA GAOTHAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9922		.8505	.691	.6379		.7522
2	.9391		.7973	.7265	.6024		.7522
3	.8682		.7265	.6024	.5493		.7701
4	.8505		.7796	.567	.5847		.7701
5	.9036		.8682	.6733	.691		.788
6	.9568		.9568	.9391	.7796		.8059
7	1.0631		.9568	.9568	.9214		.8238
8	.9745		.9391	1.0099	.9036		.8238
9	.8682			1.0631	.9214	.8059	.8238
10		1.2048			1.0454	1.0566	.9671
11		1.0099		1.0631	1.0208	1.1283	1.0387
12		1.0985		1.0277	.985	1.1104	1.0745
13		1.2403		.9745	1.1104	1.1104	1.0924
14		1.2048		1.0631	1.1462	1.0745	1.0745
15		1.1694		1.0631	1.1641	1.0566	1.0924
16		1.1871		1.0985	1.1462	.985	1.1104
17		1.1694		1.2048		.9492	1.0924
18		1.1517		1.0277		.9671	1.1104
19		1.2048		1.0454		.9313	1.1104
20		1.258				.9313	1.1104
21		1.2226		.9391		.9313	1.0924
22		1.0985		.8859		.8954	1.0924
23		.9745		.7442		.7701	.9134
24	1.0454		.9036	.8682	.691		.7343
Max	1.0631	1.258	.9568	1.2048	1.1641	1.1283	1.1104
Min	.8505	.9745	.7265	.567	.5493	.7701	.7343
Avg	.9462	1.1567	.8643	.9197	.8765	.9802	.9507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641		.2263	.1991		.2587
2	.2263		.2075	.2172		.2743
3	.2075		.2263	.2172		.2743
4	.2427		.2987	.2715		.2957
5	.2987		.3921	.3439		.3109
6	.3511		.462	.4163		.3292
7	.4207		.3881	.3801		.3475
8	.3801		.3475	.3439		.2926
9				.2896	.2353	.2328
10		.2686		.2715	.2353	.2328
11		.2279		.2926	.2715	.1928
12		.2629		.2926	.2534	
13		.2774		.2926	.2378	.2658
14		.2658		.2743	.2378	.2715
15		.2534		.2743	.2378	.2534
16		.2614		.2561	.1829	.2378
17		.2715		.2561	.1646	.2353
18		.2658		.2743	.2534	.2303
19		.3077		.2561	.2172	.2896
20		.3658			.2195	.3511
21		.3921		.2402	.2195	.3142
22		.3584		.2829	.2743	.2801
23		.3206		.2263	.2743	.2987
24	.3018		.2641	.1991		.2587
Max	.4207	.3921	.462	.4163	.2743	.3511
Min	.2075	.2279	.2075	.1991	.1646	.1928
Avg	.2992	.2928	.3125	.2769	.2343	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV BAWACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1886	.1867			.7621
2	.1509		.1698	.1867			.7926
3	.1509		.1494	.168			.8488
4	.1307		.168	.2054			
5	.168		.1848	.2054			.9105
6	.2033		.2195	.2241			.9145
7	.2378		.2012	.2241			.945
8	.1646		.181	.2054			.9907
9				.2054		1.1126	1.07
10		1.8519		.1867		1.0364	1.07
11		1.8442		.1867		.1267	1.1439
12		1.768		.168		.1448	1.1138
13		1.6049		.168		.1448	1.0848
14		1.5432		.1867		.1267	1.0686
15		1.4327		.1867		.1267	1.0669
16		1.326		.1867		.128	1.0517
17		.1753				.1097	.9414
18		.1791		.168		.1086	.8333
19		.2012		.1867		.1086	.1772
20		.2218		.1867		.1097	.1829
21		.2241			.1867		.1848
22		.2075			.1509		.2054
23		.1886			.1509	.128	.1867
24	.1698		.1886	.2054	.132		.1294
Max	.2378	1.8519	.2195	.2241	.1867	1.1126	1.1439
Min	.1307	.1753	.1494	.168	.132	.1086	.1294
Avg	.1718	.9120	.1834	.1914	.1551	.2701	.7685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.8048	.7499		.7316
2	.7499		.7682	.7865		.7499
3	.695		.7133	.7133		.7316
4	.6767		.695	.439		.7316
5	.7316		.7316	.4755		.7499
6	.7682		.7682	.3658		.7499
7	.8413		.7499	.5304		.7682
8	.7865		.7316	.567		.7682
9				.6767	.695	.6584
10		.8048		.695	.7865	.7316
11		.7682		.7316	.7865	.823
12		.7865		.7682	.7682	.7682
13		.8048		.7499	.7499	.7499
14		.7865		.7316	.7682	.7682
15		.7682		.695	.7865	.7316
16		.7682		.695	.7682	.7499
17		.7865		.6767	.7499	.7316
18		.8048		.7499	.7133	.7316
19		.8962		.7682	.695	.7865
20		.9877		.3841	.6767	.8779
21		1.0608		.8962	.6767	.9328
22		1.0608		.8779	.5487	.8779
23		.9328		.8048	.4572	.8048
24	.8779		.8596	.7682		.7316
Max	.8779	1.0608	.8596	.8962	.7865	.9328
Min	.6767	.7682	.695	.3658	.4572	.6584
Avg	.7722	.8583	.7580	.6790	.7084	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 401 / 33KV WALWA LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
22	.6224
23	.5658
24	.2658
Max	.6224
Min	.2658
Avg	.4847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.5601	.4668	.3961	.4108	.3772
2	.4527	.4338	.5175	.4435	.3772	.4066	.3734
3	.4481	.4338	.5041	.4435	.3772	.3696	.3734
4	.4904	.4338	.499	.4854	.3772	.4108	.415
5	.5228	.4904	.5601	.5228	.4338	.5041	.4854
6	.5788	.6283	.6468	.6099	.5228	.5788	.5601
7	.5729	.5973	.6154	.5853	.5544	.567	.5304
8	.4252	.5068	.4733	.4908	.4477	.4784	.4477
9	.4733	.4207	.4784	.4908	.4477	.4908	.4382
10	.3944	.4382	.5028	.4508	.4031	.4854	.4207
11	.3681	.4252	.4733	.4733	.4031	.4557	.4334
12	.3761	.4252	.4908	.3898	.4252	.4334	.443
13	.3982	.4477	.4835	.4525	.4298	.3761	.4298
14	.4207	.4525	.5068	.4344	.4344	.439	.4252
15	.4207	.4706	.5014	.4938	.4344	.394	.439
16	.362	.4656	.5249	.4887	.4525	.3898	.4298
17	.3224	.4733	.4334	.4784	.4298	.4298	.5028
18	.3366	.463	.4681	.463	.4161	.4207	.4075
19	.4334	.6036	.5258	.5973	.5373	.543	.543
20	.6468	.7133	.695		.6401		.6099
21	.6161	.6653	.6838		.6219		.6099
22	.5788	.6468	.6161	.5544	.6099	.4668	.5415
23	.5093	.5914	.5228	.4338	.5041	.415	.4715
24	.5041	.4715	.5601	.4854	.3961	.4668	.3961
Max	.6468	.7133	.695	.6099	.6401	.5788	.6099
Min	.3224	.4207	.4334	.3898	.3772	.3696	.3734
Avg	.4643	.5063	.5351	.4879	.4613	.4515	.4627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6518	1.531	1.5623	1.262		.1052	
2	1.6518	1.4685	1.5813	1.2894		.1063	
3	1.6004	1.4175		1.267		.124	
4	1.5935	1.4327	1.5466	1.2803		.1254	
5	1.6248	1.448	1.5466			.1254	
6	1.6821	1.6512	1.5466			.1267	
7	1.7593	1.8747	1.656			.124	
8	1.821	1.7341	1.6667			.124	
9	.1254	.104	.1227			.1227	
10	.1734	.1433	.1417	.9259	.1417	.1254	
11	.1417		.1227		1.1092	1.4232	
12	.1417	.124	.1372	1.439	1.1405	1.4685	
13	.1433	.1433	.1417	1.6404	1.1561	1.4815	
14	.1463	.1448	.1433	1.7394	1.1873	1.5844	
15	.1402	.1448	.1402	1.7764	1.2029	1.5154	.1063
16	.116	.1629	.1387	1.9044	1.2037	1.4661	.1357
17	.1254	.1433	.156	1.8244	1.0802	1.5223	.1578
18	.1595	.1387	.156	1.656	1.0467	1.3125	.1402
19	.1433	.1612	.1578	.1417	.1227	.1187	.1612
20	.1663	.1848	.1646		.1254		.1448
21	.1463	.1663	.1646		.124		.1448
22	.1463	.1663	.1829		.1227		.128
23	1.5971	1.6091	.1463		.1052		.1075
24	1.6484	1.6129	1.5935	.1433		.1052	
Max	1.821	1.8747	1.6667	1.9044	1.2037	1.5844	.1612
Min	.116	.104	.1227	.1417	.1052	.1052	.1063
Avg	.7769	.7699	.6485	1.3064	.7049	.6603	.1363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.04	.04	.0377	.0354	.945	.8592	.6401
2	.04	.0383	.0389	.0366	.945	.8592	.6173
3	.0406	.0427	.0389	.0377	.8916	.8855	.5937
4	.0389	.0465	.0389	.0377	.8916	.8855	.5937
5	.0457	.0457	.04	.0389	.9031	.9061	.6173
6	.0524	.0553	.0412	.0541	.9998	.9686	.6325
7	.0553	.0448	.0518	.0556	1.078	1.034	.7343
8	.0324	.0442	.0389	.0438	1.1584	1.1405	.8905
9	2.3525	2.3245	2.3967	.0303	1.1574	1.1265	.9842
10	2.2653	2.6566	2.2929	.0465	1.1092	1.078	1.0595
11	2.4486	2.6406	2.5286	.0533	.0406	.0366	1.1544
12		2.6086	2.4383	.0326	.0419	.0297	1.0467
13	2.3365	2.5143	2.3685	.0381	.0366	.0337	1.0437
14	2.3967	2.4326	2.4453	.036	.0389	.0263	
15	2.2138	2.4006	2.2725	.036	.0314	.0269	1.5023
16	2.1715	2.3525	2.198	.0427	.0343	.0335	1.5278
17	.0332	.0343	.0412	.0309	.0314	.0389	1.4842
18		.0314	.0309	.0396	.0314	.0419	1.406
19	.0417	.0343	.0404	.0383	.032	.0389	.0372
20	.0434	.036	.0488		.0326		.0349
21	.044	.0366	.0495	.036	.0326		.0332
22	.0417	.0366	.0472	.0354	.0434	.0358	.0417
23	.0394	.0488	.0396	.04	.0412	.0297	.0377
24	.0412	.044	.0372	.0326	.0286	.0373	.0269
Max	2.4486	2.6566	2.5286	.0556	1.1584	1.1405	1.5278
Min	.0324	.0314	.0309	.0303	.0286	.0263	.0269
Avg	.7643	.8579	.8167	.0395	.4407	.4615	.7278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2195
Max	.2195
Min	.2195
Avg	.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3264
Max	.3264
Min	.3264
Avg	.3264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2703
Max	.2703
Min	.2703
Avg	.2703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 401 / 33 KV MARDWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.6379
Max	.6379
Min	.6379
Avg	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 402 / ANKALKHOP

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.4983
Max	2.4983
Min	2.4983
Avg	2.4983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV ASHTA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
17	1.8604
24	1.2574
Max	1.8604
Min	1.2574
Avg	1.5589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV KASBE DIGRAJ
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.9136
Max	1.9136
Min	1.9136
Avg	1.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV NAGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV KOREGAON

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	.7442
Max	.7442
Min	.7442
Avg	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV KASTURI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.8272
Max	3.8272
Min	3.8272
Avg	3.8272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.9589	1.9022	2.0119		1.848	1.6095
2	1.8111	1.9791	1.885	1.9387		1.7741	1.4998
3	1.7741	1.922	1.885	1.885	2.2207	1.7372	1.4266
4	1.7924	1.885	1.885	1.829	2.0328	1.7372	1.4266
5	1.8298	1.829	1.885	1.829	1.9589	1.7372	1.4415
6	1.9044	1.829	1.885	1.922	1.9022	1.7002	1.6263
7	1.848	1.7909	1.8671	1.848	1.9589	1.7924	1.6827
8	1.885	1.848	1.848	1.9022	1.922	1.7177	1.7193
9	1.7924	1.7558	1.922	1.848	1.922	1.7002	1.7741
10	2.3285	2.2805	2.4508	2.4508	2.3045	2.2131	2.2805
11	1.9753	2.0995	2.3045	2.1948	1.9387	1.9753	2.0119
12	1.9387	2.2081	2.268	2.1582	1.4998	1.9936	1.957
13	1.9959	2.0058	2.2314		1.7193	2.0119	2.0119
14	2.0119	2.0774	2.1948	2.2916	1.2437	1.9753	2.0119
15	2.0328	2.1132	2.2805	2.2546	1.3611	1.9753	2.0633
16	1.9959	2.2443	2.3411	2.3285	1.6448	1.957	2.1807
17	1.922	2.2314	2.3411	2.3045	2.2443		2.1437
18	2.1033	2.3899	2.1582	2.3285	2.0119	2.0851	2.1437
19	2.3282	2.6612	2.5972	2.4539	2.4874	2.4508	2.4272
20	2.3891	2.5873	2.5606		2.4764		2.3285
21	2.3411	2.5393	2.4764		2.3655	2.3777	2.1948
22	2.268	2.4025	2.3655	2.3045	2.2916	2.0851	2.1068
23	2.2177	2.2177	2.3045	2.3285	2.1582	1.885	1.922
24	2.1658	1.9753	2.0485	2.0851		1.9022	1.7372
Max	2.3891	2.6612	2.5972	2.4539	2.4874	2.4508	2.4272
Min	1.7741	1.7558	1.848	1.829	1.2437	1.7002	1.4266
Avg	2.0216	2.1180	2.1620	2.1189	1.9840	1.9378	1.9053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.9431	.7621	.0362	.04	.7468
2	.3898	1.2696	.7922	.0366	.04	.7468
3	.6379	1.2696	.8299	.0351	.04	.7468
4	.7522	1.2696	.8676	.037	.04	.7468
5	.9671	1.2696	.9145	.0358	.0394	.7545
6	1.2894	1.307	.9145	.0362	.04	.7545
7	1.2536	1.4003	.9054	.0358	.0417	.7842
8	1.267	1.3443	.9054	.0362	.0417	1.3203
9	.9054	1.3352	.9242	.0377	.7167	1.3306
10	1.2696	1.3169	.9431	.7733	1.2936	1.3306
11	1.2696	1.3717	1.2936	.8865	1.2567	1.2752
12	1.2696	1.3352	.8865	.0566	1.2567	1.2752
13	1.307	1.2803	.0943	.0554	1.2752	1.2382
14	1.307	1.262	.0777	.0554	1.2752	1.2567
15	1.307	1.262	.0709	.0554	1.2567	1.2567
16	.1143	.3772	.0377	.0732	.0274	.0343
Max	1.307	1.4003	1.2936	.8865	1.2936	1.3306
Min	.1143	.3772	.0377	.0351	.0274	.0343
Avg	.9746	1.2259	.7012	.1427	.5426	.9749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2218	.2218	.2218	.2172	.2033	.1829
2	.2218	.2218	.2218	.2218	.1829	.2033	.1848
3	.2218	.2195	.2218	.2195	.1829	.2033	.1829
4	.2241	.2012	.2218	.2561	.2218	.2054	.1829
5	.2241	.2054	.2218	.2561	.2241	.2054	.1848
6	.2241	.2218	.2402	.2561	.2241	.2801	.1848
7	.2218	.2218	.2427	.2587	.2218	.1867	.2218
8	.2218	.1848	.2033	.2614	.1848	.1848	.1867
9	.1848	.1949	.1791	.1772	.1886	.1829	.1463
10	.1848	.1928	.2126	.1772	.2149	.1753	.1578
11	.1848	.1753	.181	.1696	.1734	.1612	.124
12	.1867	.1928	.208	.208	.1772	.1772	.1753
13	.1478	.1928	.1402	.1772	.1772	.1629	.1417
14	.1848	.1753	.1791	.197	.1791	.1433	.1448
15	.1829	.1949	.1791	.1928	.1753	.181	.1448
16	.1829	.1772	.1791	.181	.1829	.1734	.1867
17	.1463	.1433	.2172	.2195	.1772		.1829
18	.1402	.1417	.181	.1478	.1595	.1791	.1848
19	.2103	.2353	.2561	.2218	.1991	.2561	.2241
20	.2454	.2172	.2926		.2561		.2218
21	.2507	.2926	.2926	.2926	.2587	.2561	.2614
22	.2561	.2926	.2957	.2587	.2587	.2218	.2641
23	.2587	.2561	.2957	.2195	.2587	.2218	.2241
24	.2614	.2195	.2378	.2587	.2172	.2218	.1829
Max	.2614	.2926	.2957	.2926	.2587	.2801	.2641
Min	.1402	.1417	.1402	.1478	.1595	.1433	.124
Avg	.2096	.2080	.2218	.2196	.2047	.1994	.1866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0351	.0373	.2347	.0366	.1524	.0189
2	.0187	.0358	.0373	.2347	.0183	.1524	.0189
3	.0189	.0358	.0373	.2317	.0183	.1524	.0187
4	.0189	.0358	.0373	.2317	.0185	.1524	.0187
5	.0377	.0358	.0373	.2347	.0185	.1524	.0189
6	.0373	.0351	.0373	.2675	.0185	.1852	.0187
7	.0747	.0358	.0373	.3048	.0185	.2688	.0373
8	.0377	.0351	.0554	.3353	.0185	.2343	.0187
9	.4908	.4858	.3563	.3048		.216	.0187
10	.4854	.4858	.3163	.2743		.2134	.0173
11	.4805	.4534	.4049	.0189		.0185	.216
12	.4908	.4161	.3637	.0554		.0377	.2469
13	.4961	.4001	.3479	.0373		.037	.2469
14	.4557	.3201	.3506	.0377		.0189	.216
15	.4557	.2846	.3353	.0366		.0189	.216
16	.4161	.2846	.3353	.0185		.0366	.2006
17	.0351	.0189	.0362	.0183	.0377		.1715
18	.0351	.0189	.0362	.0183	.0187	.037	.1753
19	.0351	.0377	.0373	.0366	.0377	.0187	.0358
20	.0351	.0373	.0373		.0377		.0362
21	.0351	.0373	.0373		.0377	.0373	.0366
22	.0347	.0373	.037	.0179	.0377	.0373	.0366
23	.0347	.0373	.0554	.0179	.0377	.0373	.037
24	.0379	.0351	.0373	.0373	.0183	.0377	.0377
Max	.4961	.4858	.4049	.3353	.0377	.2688	.2469
Min	.0187	.0189	.0362	.0179	.0183	.0185	.0173
Avg	.1799	.1531	.1434	.1366	.0268	.1024	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 206 / 11 KV Peth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.208	.2241		.9362	.8535	.1867
2	.2218	.2103	.2241	.9457	.8779	.8535	.1867
3	.2587	.2454	.2241	1.0151	.7964	.8535	.1867
4	.2587	.2507	.2241	1.0151	.8413	.8535	.1867
5	.2614	.2401	.2241	1.0715	.823	.9755	.1848
6	.2587	.2401	.2614	1.4861	1.2346	1.3108	.2218
7	.2218	.2743	.2614	2.2497	1.7147	1.9997	.2241
8	.2241	.2058	.2481	1.9372	1.989	1.8122	.2241
9	2.713	2.1605	2.1506	1.467	1.4861	1.5455	.1417
10	2.713	2.2809	2.2771	1.291	1.3672	1.291	.1658
11	2.4691	2.1559	2.2497	.1387	.1372	.1341	1.6667
12	2.2885	1.9997	2.0622	.1907	.1433	.1387	1.6644
13	2.0576	1.8747	1.8747	.1753	.1417	.1341	1.6049
14	1.8519	1.7497	1.6461	.1402	.1433	.1075	1.5653
15	1.9418	1.781	1.7071	.1772	.1448	.1433	1.4632
16	2.0458	1.8122	1.7901	.1326	.1772	.2103	1.3672
17	.1734	.2012	.1372	.2058	.208		
18	.208	.1898	.1829	.1734	.1928	.2126	1.1096
19	.2103		.2195	.2103	.2149	.2195	.1734
20	.208	.2561	.2195		.1829		.2103
21	.2058	.2195	.2218	.2103	.2195	.1829	.2149
22	.208	.2587	.2218	.2058	.1829	.1848	.1753
23	.2454	.2587	.1867	.1734	.1829	.1867	.1715
24	.2195	.208	.2218	.1848	.1715	.1663	.1886
Max	2.713	2.2809	2.2771	2.2497	1.989	1.9997	1.6667
Min	.1734	.1898	.1372	.1326	.1372	.1075	.1417
Avg	.9035	.8383	.8025	.6726	.6046	.6532	.5863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.7167	1.3203	1.226	.9431	1.1694	.9808
2	.9431	.7167	1.3336	1.226	.9431	1.1694	.9808
3	.9431	.7167	1.3203	1.226	.9431	1.1694	.9808
4	.9431	.7167	1.3203	1.226	.9431	1.1694	.9808
5	.7545	.679	1.2826	1.0374	.9431	1.1694	.9808
6	.9431	.679	1.2449	1.0185	.9431	1.1694	.9997
7	.9054	.7545	1.2071	.9431	1.0185	1.1694	.9619
8	.6224	.7545	1.1694	.9054	.7545	.7167	.9808
9	.6413	1.3957	1.3769	1.094	.9808	1.1317	1.1317
10	.6036	1.3957	1.773	1.5089	1.0562	1.4712	1.5089
11	.6036	1.3957	1.773	1.5844	1.3203	1.6975	1.7541
12	.6036	1.3957	1.773	1.5089	1.5844	1.5278	
13		1.3203	1.5655	1.358	1.2826	1.5844	1.3957
14	.6036	1.6975	1.6787	1.4712	1.358	1.5466	1.5844
15	.5853	1.6975	1.9239	1.6032	1.39	1.5844	1.7164
16	.5853	1.7353	1.6598	1.5089	1.5089	1.5844	1.7918
17	.6036	1.773	1.6787	1.4335	1.4712		1.8861
18	.6413	1.6598	1.5089	1.358	1.358		1.5655
19	.6219	1.4335	1.4146	1.1694	1.2826	.7545	
20	.6413	1.1883	1.358		1.1694	.9054	1.2637
21	.679	1.2449	1.2071		1.2449	.9431	1.1883
22	.7167	1.1506	1.0751	.4527	1.2449	.9808	1.3203
23	.7167	1.1317	1.1157	.7545	1.2449	1.0185	1.2637
24	1.0288	.7167	1.3203	1.2637	.8676	1.0751	.9431
Max	1.0288	1.773	1.9239	1.6032	1.5844	1.6975	1.8861
Min	.5853	.679	1.0751	.4527	.7545	.7167	.9431
Avg	.7336	1.1694	1.4334	1.2217	1.1582	1.2140	1.2800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2195	.2427	.2427	.2195	.1829	.1867
2	.2378	.2195	.2427	.2427	.2195	.1829	.1867
3	.2378	.2195	.2427	.2427	.2195	.1886	.1867
4	.2378	.2195	.2427	.2427	.2195	.1829	.1867
5	.2378	.2561	.2614	.2614	.2561	.2561	.2054
6	.2561	.2561	.3018	.3018	.2926	.2561	.2614
7	.2195	.2561	.2801	.2614	.3109	.2561	.2987
8	.2012	.2195	.2561	.2378	.2378	.2926	.2561
9	.1829	.1829	.2012	.2195	.1829	.1829	.2012
10	.1463	.1829	.2012	.1829	.1829	.3772	.1829
11	.1463	.1829	.2075	.1772	.1829	.1886	.128
12	.1646	.2012	.2378	.197	.1829	.1886	.128
13		.2012	.2378	.2126	.1829	.2018	.1829
14	.1829	.2012	.2195	.2126	.1949	.2075	.1829
15	.1829	.2012	.2328	.2172	.2012	.2075	.1829
16	.1829	.2012	.2149	.1907	.1463	.2075	.2195
17	.1829	.2012	.197	.2149	.1097		.1829
18	.1829	.2012	.197	.2328	.1097		.1646
19	.2195	.2561	.2561	.2926			.2378
20	.2561	.3395	.3142		.3292		.3109
21	.2561	.2987	.2772	.3018	.3189	.2987	.2561
22	.2561	.3018	.2772	.2561	.3018	.2263	.2561
23	.2195	.2641	.2772	.2195	.2452		.2195
24	.2378	.2195	.2452	.2427	.2195	.2012	.1867
Max	.2561	.3395	.3142	.3018	.3292	.3772	.3109
Min	.1463	.1829	.197	.1772	.1097	.1829	.128
Avg	.2115	.2293	.2443	.2349	.2203	.2256	.2080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.1469	1.0311	.0189	.0189	.0171	
2	1.0562	1.0814	.9602	.0189	.0189	.0171	
3	1.0562	1.0814	.9602	.0189	.0189	.0171	
4	1.0562	1.0814	.9602	.0189	.0189	.0171	
5	.8642	1.0486	.9014	.0189	.0189	.0171	
6	1.0562	1.1142	.9374	.0189	.0189	.0171	
7	1.0562	1.278	1.0311	.0189	.0189	.0171	
8	1.0562	1.1248	.9145	.0189	.0189	.0171	
9	.0189	.0189	.0189	.0189	.0189	.0171	
10	.0171	.0189	.0189	.0189	.0189	.0189	
11	.0171	.0189	.0189	1.5364	1.4083	1.5181	
12	.0171	.0189	.0189	1.6518	1.4083	1.4232	
13		.0189	.0189	1.5364	1.2483	1.3123	
14	.0171	.0189	.0189	1.4403	1.1203	1.2483	.0189
15	.0171	.0189	.0189	1.3443	1.2163	1.2483	.0189
16	.0171	.0189	.0189	1.2483	1.2163	1.2483	.0189
17	.0171	.0189	.0189	1.1888	.9831		.0189
18	.0171	.0189	.0189	1.07	.9602		
19	.0187	.0189	.0189	.0189	.0171	.0189	.0189
20	.0187	.0189	.0189		.0171	.0189	.0189
21	.0189	.0189	.0189		.0171	.0189	
22	.0183	.0189	.0189	.0189	.0171	.0189	.0189
23	1.1317	1.0311	.0189	.0189	.0171		.0189
24	1.0562	1.2003	1.0311	.0189	.0189	.0171	
Max	1.1317	1.278	1.0311	1.6518	1.4083	1.5181	.0189
Min	.0171	.0189	.0189	.0189	.0171	.0171	.0189
Avg	.4642	.4772	.3754	.5128	.4106	.3935	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.415	.6036	.679	.5658	.5658	
2	.5658	.415	.6036	.679	.5658	.5658	.5281
3	.5658	.415	.6036	.679	.5658	.5658	.5281
4	.5658	.415	.6036	.679	.5658	.5658	.5281
5	.4715	.4024	.5281	.6036	.5658	.5281	.5281
6	.5658	.3772	.4904	.415	.4527	.4338	.3772
7	.4527	.3584	.4527	.4527	.5093	.3772	.3018
8	.3961	.5093	.415	.5093	.4715	.415	.3772
9	.415	.8488	.5281	.679	.4527	.5093	.415
10	.415	.8488	.679	.7356	.5658	.7545	.5658
11	.5281	.8488	.6979	.8488	.7356	.7922	.6979
12	.5121	.8488	.6979	.8676	.7356	.8488	.6979
13		.811	.8299	.7545	.7356	.7922	.6979
14	.3961	.7545	.8488	.7545	.7133	.7356	.6224
15	.439	.7545	.8488	.7167	.7356	.679	.6413
16	.4572	.7545	.7922	.6979	.7356	.679	.679
17	.4527	.7545	.811	.7545	.7545		.7545
18	.4527	.7545	.811	.811	.7545		.811
19	.4527	.7922	.7356	.7545	.7167	.7545	.7167
20	.4527	.6979	.7545		.7167	.7545	.7356
21	.439	.679	.7356	.5658	.679	.679	.6979
22	.439	.679	.5658	.5658	.6224	.6413	.7356
23	.415	.6224	.6979	.5093	.6224	.6224	.5658
24	.5658	.3584	.6036	.679	.5658	.5658	.5658
Max	.5658	.8488	.8488	.8676	.7545	.8488	.811
Min	.3961	.3584	.415	.415	.4527	.3772	.3018
Avg	.4775	.6298	.6641	.6692	.6293	.6284	.5986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PW

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4527	.3772	.415	.4904	.3772	.3772
2	.3772	.4527	.3772	.415	.4904	.3772	.3772
3	.3772	.4527	.3772	.415	.4904	.3772	.3772
4	.3772	.4527	.3772	.415	.4904	.3772	.3772
5	.2641	.4338	.3772	.415	.4904	.3772	.3395
6	.4527	.4527	.3772	.4904	.4904	.4527	.3772
7	.415	.4715	.4527	.4904	.4904	.4527	.2012
8	.4527	.4527	.4904	.4904	.4904	.4527	.415
9	.4527	.4527	.4904	.4904	.4527	.4527	.4527
10	.4527	.4527	.5093	.4904	.5093	.4904	.5281
11	.4904	.4527	.4904	.4904	.5093	.4904	.4904
12	.4527	.4527	.5281	.4904	.4904	.4527	.4904
13		.4527	.415	.4527	.4904	.4904	.4904
14	.4527	.4904	.4527	.4527	.4904	.4904	.4904
15	.439	.4904	.4527	.4527	.5093	.4904	.4904
16	.4904	.415	.2195	.4527	.4904	.4904	.4904
17	.4904	.415	.2195	.4527	.4904		.4904
18	.4338	.4527	.4715	.4904	.4904		.2658
19	.3772	.3584	.415	.3772	.4527	.4527	
20	.2641	.2401	.2835		.3395	.3395	
21	.2641	.1886	.192	.3772	.3018	.2401	.2835
22	.2641	.2401	.1646	.3772	.3018	.1981	.2658
23	.2926	.3772	.3584	.3772	.3018	.2058	.3584
24	.3772	.3584	.3772	.415	.3395	.3772	.3772
Max	.4904	.4904	.5281	.4904	.5093	.4904	.5281
Min	.2641	.1886	.1646	.3772	.3018	.1981	.2012
Avg	.3951	.4130	.3853	.4428	.4535	.4048	.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV KAPUSKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.1867	.2054	.1463	.1772	.1509
2	.1829	.1829	.1867	.2054	.1463	.1715	.1509
3	.1829	.1829	.1867	.2054	.1463	.1829	.1509
4	.1829	.1829	.1867	.2054	.1463	.1829	.1509
5	.1829	.1829	.1867	.2241	.1829	.2012	.1698
6	.2561	.2743	.2263	.2614	.2561	.2561	.2241
7	.2195	.2012	.2641	.2801	.2561	.2378	.1867
8	.2195	.2561	.1867	.1646	.1463	.2012	.1097
9	.1829	.1829	.1097	.1753	.1829	.1829	.0914
10	.1463	.1463	.1753	.1578	.1463	.1829	.0549
11	.128	.1463	.1578	.1063	.1463	.1829	.0549
12		.1829	.1578	.1372	.1463	.1463	
13		.1829	.1646	.1696	.128	.1448	
14		.1829	.1646	.1772	.1463	.1612	.2481
15		.1829	.1629	.1753	.1463	.1509	.1791
16		.1463	.1772	.1753	.1829	.1463	.1629
17		.2195	.1791	.1753	.1772		.1629
18		.1463	.197	.1772	.2012		.2378
19	.2241	.2303	.1886	.2195	.2561	.2195	
20	.2614	.2587	.2587		.2561	.1829	.2378
21	.2561	.2241	.2743		.2561	.2241	.2378
22	.2195	.2427	.2561	.2658	.2195	.2427	.2195
23	.2195	.1886	.2218	.1772	.1949	.1494	.1886
24	.1829	.1829	.1867	.2033	.1463	.1829	.1509
Max	.2614	.2743	.2743	.2801	.2561	.2561	.2481
Min	.128	.1463	.1097	.1063	.128	.1448	.0549
Avg	.2018	.1955	.1935	.1929	.1816	.1868	.1676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0171	.0171	.4801	.2263	.3932	
2	.0189	.0171	.0171	.4801	.2263	.3932	
3	.0189	.0171	.0171	.4801	.2263	.3932	
4	.0189	.0183	.0171	.4801	.2263	.3932	
5	.0189	.0171	.0171	.5441	.2263	.3932	
6	.0189	.0171	.0171	.6036	.3018	.4588	
7	.0189	.0171	.0171	.7011	.3018	.5571	
8	.0189	.0189	.0171	.7316	.3018	.3277	
9	1.0349	1.0562	.9922	.6325	.3018	.3932	.0171
10	1.0745	1.0562	.9172	.6154	.3018	.5281	
11	1.0745	1.0562	1.0029	.0171	.0189	.0189	
12	1.0029	1.0562	.961	.0171	.0171	.0189	
13		.9808	.8779	.0171	.0171	.0189	.3201
14	.8238	.9054	.8871	.0171	.0171	.0189	.2881
15	.8238	.7964	.8413	.0171	.0171	.0189	.2881
16	.8238		.8413	.0171	.0171	.0189	
17	.0171	.0189	.0183	.0171	.0171		
18	.0171	.0189	.0185	.0171	.0171		.25
19	.0187	.0171	.0185	.0189	.0171		.0189
20	.0187	.0171	.0137		.0171		
21	.0183	.0171	.0137	.0189	.0171		.016
22	.0171	.0171	.0137	.0189	.0171		.0137
23	.0171	.0171	.0137	.0189	.0171		.0137
24	.0189	.0171	.0171	.0133	.0189	.0171	
Max	1.0745	1.0562	1.0029	.7316	.3018	.5571	.3201
Min	.0171	.0171	.0137	.0133	.0171	.0171	.0137
Avg	.3023	.3125	.3160	.2598	.1201	.2566	.1362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3441	.3734	.3734	.3734	.3277	
2		.3441	.3734	.3734	.3734	.3277	
3		.3441	.3734	.3734	.3734	.3277	
4		.3441	.3734	.3734	.3734	.3277	
5		.3441	.3734	.3734	.3734	.3277	
6		.3441	.3734	.3734	.3734	.3277	
7		.3441	.3734	.3734	.3734	.3277	.0747
8		.3734	.3734	.3734	.3361	.3277	.2987
9		.3734	.3734	.3734	.3361	.3277	.3361
10		.3734	.3734	.3734	.3506	.3277	.2987
11		.3734	.3734	.3734	.3772	.2949	.2987
12		.3734	.3734	.3734	.3277	.3277	.2987
13		.3734	.3734	.3734	.3277	.3734	.2987
14		.3734	.3734	.3734	.0328	.3734	.2987
15		.3734		.3734	.2949	.3734	.2987
16		.3734		.3361	.3113	.3361	.2987
24	.3361						
Max	.3361	.3734	.3734	.3734	.3772	.3734	.3361
Min	.3361	.3441	.3734	.3361	.0328	.2949	.0747
Avg	.3361	.3606	.3734	.3711	.3318	.3347	.2800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.4861	1.9433	1.8673	1.8107	1.7147	1.7147
2	1.5844	1.4861	2.0576	1.8673	1.8107	1.7147	1.7147
3	1.5844	1.4861	2.0576	1.8673	1.8107	1.7147	1.7147
4	1.0185	1.4861	2.0576	1.8673	1.8107	1.7147	1.7147
5		1.4861	1.9433	1.7541	1.8107	1.7147	1.7147
6	1.5844	1.5432	1.9433	1.8673	1.8107	1.7147	1.7147
7	1.5844	1.4861	1.9433	1.8107	1.5844	1.7541	1.7718
8	1.2449	1.4712	1.9433	1.7541	1.6975	1.8107	1.7718
9	1.1317	1.8107	1.9433	1.6975	1.6975	1.9239	1.7718
10	1.2574	1.8107	2.037	1.9433	1.829	1.6975	1.8673
11	1.3717	1.8107	2.0936	1.829	1.829	1.5844	1.8107
12	1.4861	1.8107	2.1502	1.9433	1.829	1.6975	1.9239
13		1.8107	1.9805	2.0005	1.829	1.7147	1.713
14	1.3717	2.037	1.9239	2.0005	1.9433	1.5844	1.7541
15	1.6004	2.037	2.1502	2.0576	1.9433	1.5844	1.7541
16	1.6004	1.9239	1.8673	1.829	1.9433	1.5844	1.7541
17	1.6004	1.9239	1.6975	1.829	1.829		1.6975
18	1.2574	1.8107	1.6975	1.7147	1.829		1.6409
19	1.4861	1.7147	1.8107	1.6975	1.829	1.5844	1.6409
20	1.4861	1.7147	1.7541		1.7147	1.5844	1.6409
21	1.6004	1.9433	1.7541	1.8107	1.7147	1.6004	1.6409
22	1.6004	1.9433	1.7541	1.8107	1.7147	1.7147	1.6975
23	1.6004	1.829	1.7541	1.8107		1.7147	1.6975
24	1.5844	1.6004	1.9433	1.8673	1.6975	1.7718	1.7147
Max	1.6004	2.037	2.1502	2.0576	1.9433	1.9239	1.9239
Min	1.0185	1.4712	1.6975	1.6975	1.5844	1.5844	1.6409
Avg	1.4646	1.7276	1.9250	1.8477	1.7964	1.6907	1.7313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7095	.7167	.7167		.679	.5601
2	.7167	.6908	.6979			.6602	.5788
3	.7167	.7095	.6979	.7356		.6602	.5788
4	.7282	.7282	.7468	.7545		.679	.5975
5	.7842	.7655	.8215	.811		.679	.6161
6	.8589	.8589	.8589	.8402		.7167	.6908
7	.8676	.823	.8326	.823		.7499	.6878
8	.8029	.7964	.7973	.7712		.6805	.6733
9	.7545	.7186	.7186	.7011		.631	.5721
10		.7291	.7619	.7421	.2454	.5533	.631
11		.7373	.7442	.695	.2195	.6661	.5959
12		.7282	.8328	.7783	.2328	.6588	.6201
13		.7537	.8238	.7499	.1772	.6733	.6733
14		.724	.7973	.8871	.394	.691	.6733
15	.7442	.7343	.815	.7865	.9313	.7164	.7602
16	.8505	.7265	.8589	.8686	.8764	.703	.7343
17	.7888	.7362	.8063	.823	.8764		.7421
18	.7802	.8501	.7628	.8779	.8322	.6241	.7442
19	.8775	.8842	.9816		.8764		.8775
20	1.0719	1.0608	1.1088		1.0136		
21	.9335	.9425	1.0164		.9511	.2534	.8962
22	.8589	.8596	.9335		.9335	.2427	.7655
23	.8215	.7842	.8775		.8402	.6283	.7282
24	.7545	.7468	.7468	.7356		.7468	.5359
Max	1.0719	1.0608	1.1088	.8871	1.0136	.7499	.8962
Min	.7095	.6908	.6979	.695	.1772	.2427	.5359
Avg	.8116	.7832	.8232	.7832	.6714	.6330	.6753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0943	.6154		.2688	.0166
2	.0754	.0943	.0943	.6081		.2688	.0166
3	.0747	.0943	.1132	.6241		.2656	.0164
4	.1307	.1132	.112	.6241		.2846	.0164
5	.132	.1132	.1307	.6097		.3361	.016
6	.132	.112	.1307	.7449		.3932	
7	.1494	.1132	.1509	.8333		.5506	.0152
8	.1509	.1132	.1509	.7926		.4687	.0274
9	1.1797	1.1683	1.2616	.7468		.421	.0156
10		1.2967	1.3927	.7202		.3637	.0187
11		1.3123	1.4091	.112		.0754	.3201
12		1.2967	1.3108	.1132		.0943	.3401
13		1.2654	1.2163	.1307	.0754	.0754	.2846
14		1.2803	1.0936	.132	.1132	.0754	.2846
15	1.2163	1.2651	1.0936	.1307	.1132	.0754	.25
16	1.3283	1.1561	1.0364	.132	.1132	.0754	.253
17	.1132	.1132	.132	.1307	.0754		.253
18	.1132	.1132	.132	.132	.0754	.0566	.2743
19	.132	.1509	.1132		.0943		.0943
20	.1294	.1509	.1132		.1132		.0943
21	.112	.1307	.132		.0943		.0943
22	.0934	.1132	.132		.0754		.0754
23	.0934	.1132	.1132		.0754	.0162	.0754
24	.0754	.0943	.0943	.0943	.0566	.0754	.0168
Max	1.3283	1.3123	1.4091	.8333	.1132	.5506	.3401
Min	.0747	.0943	.0943	.0943	.0566	.0162	.0152
Avg	.2898	.5119	.4897	.4225	.0896	.2232	.1247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322	.9217	.9061	.0886	.0373	.0701	.2812
2	.852	.8951	.9172	.0895	.0377	.0701	.2812
3	.8745	.8688	.9488	.0895	.0377	.0693	.2846
4	.8848	.8688	1.0402	.0895	.0377	.0701	.3005
5	.9614	.8688	1.0562	.0886	.056	.0716	.2968
6	1.0562	1.0595	1.0595	.0886	.056	.0716	.3048
7	1.278	1.1544	1.2003	.0829	.0754	.0678	.2934
8	1.2308	1.1227	1.1561	.1006	.0747	.0671	.3361
9	.1132	.0876	.112	.0838	.0377	.0678	.3125
10		.0876	.0678	.112	.0328	.0876	.2896
11		.0886	.0895	1.5893	.6554	.9326	.0347
12		.0701	.0895	1.5364	.3887	.787	.0347
13		.0709	.0701	1.5746	.144	.8383	.0514
14		.0905	.0876	1.4899		.7773	.052
15	.0867	.0886	.0857	1.3603	.5335	.7621	.0543
16	.1029	.0857	.0829	1.3435	.5639	.7655	.0549
17	.1017	.104	.0829	1.2483	.4607		.0543
18	.1029	.1086	.1006	1.1012	.4515	.2134	.0474
19	.1075	.0983	.1063		.0829		.0633
20	.1109	.0972	.1086		.0857		.0655
21	.0739	.1017	.0905		.0886	.0633	.0655
22	.0732	.1006	.0895		.0716		.0663
23	.9061	.8905	.0886		.0701	.052	.0655
24	.8029	.9217	.9061	.0876	.0377	.0693	.0686
Max	1.278	1.1544	1.2003	1.5893	.6554	.9326	.3361
Min	.0732	.0701	.0678	.0829	.0328	.052	.0347
Avg	.5554	.4522	.4393	.6445	.1790	.2987	.1566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0069	.4531	.4973	.008	.5344	.0084
2	.0065	.4687	.4858	.008	.5344	.0088
3	.0065	.4744	.4858	.008		.0084
4	.0069	.4801	.4744	.0091	.5344	.0084
5	.0065	.4801	.4744	.0091	.5344	.008
6	.0072	.4858		.008	.5407	.008
7	.0072	.502		.0076	.5344	.0088
8	.0072	.4801		.008	.5344	.0084
9	.0069	.502		.0076	.5506	.0076
10	.144	.4801		.0065	.5218	.0076
11	.2372	.4915			.547	.008
12	.2401	.4858		.0061	.5407	.0076
13	.2372	.0061		.0065	.5344	.0076
14	.5079	.1943	.3749	.0065	.5344	.0076
15	.4961	.4801	.5571	.0069	.5281	.008
16	.4961	.4687	.5281	.5506	.5218	.0084
Max	.5079	.502	.5571	.5506	.5506	.0088
Min	.0065	.0061	.3749	.0061	.5218	.0076
Avg	.1513	.4333	.4847	.0438	.5351	.0081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2614	.2402	.2402	.2614	.2195	.1463
2	.2402	.2614	.2378	.2378	.2614	.2218	.1463
3	.2378	.2614	.2402	.2378	.2614	.2195	.1448
4	.2587	.2987	.2561	.2715	.2801	.2353	.1612
5	.3109	.3174	.2957	.3109	.2987	.2865	.2534
6	.2957	.3547	.3292	.3511	.3921	.3841	.3077
7	.2378	.3045	.3012	.2804	.3292	.2835	.2328
8	.2454	.2427	.2229	.2321	.2254	.2401	.2254
9	.2204	.2347	.2204	.2321	.2204	.2347	.1658
10		.2187	.2321	.1943	.2012	.2012	.1844
11		.2012	.2374	.1802	.2012	.218	.1509
12		.2229	.2652	.2347	.2229	.2229	.1823
13		.2427	.2772	.2279	.208	.2401	.1492
14	.2804	.2454	.2629	.2804	.2303	.2401	.2254
15	.298	.2303	.2629	.2804	.2126	.2401	.2401
16	.298	.2543	.2374	.2774	.2427	.2374	.2321
17	.2427	.2267	.2321	.2515	.1943		.2372
18	.2591	.2401	.2561	.2652	.2267		2.536
19	.2774	.2629	.2652	.2103	.2454		.3189
20	.3109	.3045	.3045		.2865		.3224
21	.3077	.3077	.3109		.2772		.2896
22	.2772	.3109	.3142		.2772		.2801
23	.2427	.2772	.2587	.2772	.2561		.2614
24	.2427	.2587	.2587	.2427	.2614	.2402	.0366
Max	.3109	.3547	.3292	.3511	.3921	.3841	2.536
Min	.2204	.2012	.2204	.1802	.1943	.2012	.0366
Avg	.2663	.2642	.2633	.2531	.2531	.245	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5144	.2187	
2				.5087	.216	
3				.4973	.2187	
4				.4915	.2214	
5				.4973	.2343	
6				.4902	.253	
7			.1907	.5155	.2688	
8				.5601	.3163	
9	.6964	.7373	.7611	.5281	.2968	
10		.6882	.7287	.5121	.2846	
11		.6718	.7935			.1027
12		.6964	.6722			.1235
13		.7287	.7202			.1027
14	.6718	.7449	.7287			.0892
15	.6722	.7449	.6964			.1054
16	.7202	.7362	.6964			.1219
17						.1
18						.088
Max	.7202	.7449	.7935	.5601	.3163	.1235
Min	.6718	.6718	.1907	.4902	.216	.088
Avg	.6902	.7186	.6653	.5115	.2529	.1042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.0364	1.0402	.0747	.0566	.0377	.4807
2	.9962	1.0364	1.0526	.0747	.0566	.0373	.4807
3	1.0082	1.0364	1.0402	.0754	.0566	.037	.4752
4	1.0082	1.0364	1.0688	.0754	.0566	.0373	.4641
5	1.012	1.0688	1.1142	.0747	.0754	.0566	.4424
6	1.012	1.1012	1.1069	.0754	.0754	.0754	.4049
7	.9602	1.2323	1.2003	.0754	.0754	.0754	.3841
8	1.0242	1.2323	1.1683	.0554	.0754	.0566	.4001
9	.048	.0532	.032	.0554	.0373	.0754	.3521
10		.016	.048	.0566	.0554	.056	.3239
11		.032	.0566	1.6194	1.1843	1.3441	.0332
12		.032	.056	1.7652	1.2018	1.3765	.0532
13		.048	.037	1.7328	1.2163	1.4251	.0526
14	.0324	.0486	.0566	1.668	1.2003	1.3927	.0532
15	.048	.032	.056	1.6518	1.2018	1.3765	.0554
16	.0492	.0509	.0566	1.6356	1.2163	1.3603	.0492
17	.0335	.048	.0566	1.5384	1.1069		.0648
18	.0305	.048		1.5043			.0532
19	.0532	.064	.0739	.0566			.0554
20	.0754	.0537	.0754		.0754		.0554
21	.0566	.0754	.0754		.0754		.0554
22	.0754	.064	.0754		.0566		.0554
23	1.0402	1.0753	.0566	.0566	.0377	.0514	.0554
24	1.0242	1.0364	1.0402	.0754	.0566	.0377	.0514
Max	1.0402	1.2323	1.2003	1.7652	1.2163	1.4251	.4807
Min	.0305	.016	.032	.0554	.0373	.037	.0332
Avg	.5298	.4816	.4628	.6665	.4205	.4949	.2063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6224	.6348	.6413	.5658	.6036	
2	.6224	.6036	.6224	.6224	.5658	.5847	
3	.6224	.6036	.6224	.6224	.5847	.5847	.5847
4	.6224	.6224	.6413	.6224	.6036	.6036	.5658
5	.6979	.7167	.7356	.7167	.679	.679	.6602
6	.7733	.8402	.8215	.811	.8215	.7733	.8215
7	.6535	.7577	.7392	.7392	.7207	.7392	.7392
8	.5729	.6219	.6089	.5973	.6335	.6401	.6335
9	.5121	.6268	.591	.5973	.5138	.5792	.6447
10		.5316	.6024	.4835	.5316	.591	.4961
11		.567	.6626	.6379	.5552	.5552	.5609
12		.6379	.6154		.591	.591	.5373
13		.6733	.6154	.6268		.5611	.5373
14	.4706	.6379	.5487	.7059		.5853	.5068
15	.6878	.567	.6335	.7164		.6036	.4572
16	.6447	.5731	.591	.6024		.567	.5304
17	.5552	.5609	.591	.5373	.6805	.4961	.5373
18	.567	.5784	.5609	.5847	.6733	.5373	.6024
19	.7059	.788	.6984		.7265	.7865	.724
20	.8686	.8962	.924		.8779	.7865	.8686
21	.8686	.8871	.8962	.8131	.8402	.7468	.8316
22	.8501	.8316	.8402	.6838	.8029	.6908	.7468
23	.7095	.7655	.7282	.6535	.7167	.6036	.6413
24	.6602	.6535	.6535	.6535	.5658	.6413	
Max	.8686	.8962	.924	.8131	.8779	.7865	.8686
Min	.4706	.5316	.5487	.4835	.5138	.4961	.4572
Avg	.6644	.6735	.6741	.6509	.6625	.6304	.6299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.4858	.0036	.0034	.0038	
2	.0034	.5761	.0034	.0034	.0038	
3	.0034	.5761	.0034	.0032	.0036	
4	.0034	.5761	.0036		.0036	
5	.0036	.5761	.0034	.0032	.0036	
6	.0036	.5761	.0032	.0038	.004	
7	.0034	.5693	.0032	.0034	.0034	
8	.104	.5624	.0034	.0032	.0036	
9	.4321	.5761	.0032	.0032	.0036	
10	.4999	.5624	.003	.0034	.0036	
11	.5693	.5761	.004	.0036	.0036	
12	.5693	.5693	.0032	.0034	.0034	.0036
13	.5693	.5556	.0032	.003	.0034	.0034
14	.5693	.5624	.0034	.0034	.0032	.0034
15	.5693	.016	.003	.0034	.0034	.0034
16	.5761	.003	.003	.0034	.0032	.0034
Max	.5761	.5761	.004	.0038	.004	.0036
Min	.0034	.003	.003	.003	.0032	.0034
Avg	.2802	.4949	.0033	.0034	.0036	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0532	.0732	.4054	.362	.3041	.0549
2	.0701	.0532	.0732	.4108	.3668	.3041	.0549
3	.0709	.0532	.0739	.4108	.3668	.2934	.0543
4	.0709	.0537	.0739	.4161	.362	.3121	.0554
5	.0709	.0537	.0747	.4401	.3765	.3715	.0549
6	.0739	.0905	.0747	.6241	.4755	.5182	.0739
7	.0857	.0886	.0914	.7482	.5502	.6097	.0716
8	.0663	.0671	.0867	.6748	.6093	.7011	.0732
9	.8128	.8535	.8642	.5796	.5573	.5647	.0366
10		.9297	.9934	.5285	.4793	.4694	.0324
11		.9031	.8951	.0537	.0532	.0358	.3814
12		.884	.8278	.0625	.0358	.0537	
13		.8128	.7145	.052	.052	.0347	.3765
14	.6874	.7827	.7133		.052	.0514	.4458
15	.9414	.743	.695	.0486	.052	.0526	.4108
16	.8951	.6836	.598	.0497	.0492	.0492	.3814
17	.0503	.0509	.0351	.0509	.0514	.0469	.333
18	.0678	.048	.0347	.0648	.0486	.0663	.2921
19	.0693	.0543	.0362		.052	.0693	.0362
20	.0716	.0732	.0532		.0537		.0373
21	.0701	.0732	.0724	.0526	.0724	.0543	.0554
22	.0716	.0732	.0724	.0549	.0716	.0537	.0554
23	.0716	.0732	.0543	.0543	.0724	.0543	.037
24	.0709	.0543	.0724	.0537	.0549	.0537	.0537
Max	.9414	.9297	.9934	.7482	.6093	.7011	.4458
Min	.0503	.048	.0347	.0486	.0358	.0347	.0324
Avg	.2230	.3169	.3064	.2779	.2199	.2228	.1504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.166	1.2146	.0819		.0829	.547
2	1.2308	1.1498	1.1984	.0848		.0829	.5304
3	1.2308	1.1498	1.1984	.0848		.0829	.5304
4	1.247	1.166	1.2146	.0838		.0829	.5304
5	1.2793	1.2631	1.2631	.0848		.0829	.5304
6	1.5223	1.5061	1.4413	.1029		.116	.5304
7	1.7004	1.6842	1.6518	.1214		.0995	.5138
8	1.6842	1.6194	1.6032	.1029		.0995	.5138
9	.081	.081	.081	.0857	.0332	.0829	.4641
10		.081	.081	.0848	.0332	.0829	.431
11		.0648	.081	2.3975	1.4089	2.0719	.0655
12		.081	.0972	2.3703	1.4089	2.1216	
13		.081	.081	2.4366	1.3923	2.1216	
14		.081	.081	2.4863	1.5581	1.8067	
15	.081	.0972	.081	2.3868	1.9227	2.0553	
16	.0486	.0972	.0972	2.304	1.9227	1.989	.1147
17	.0972	.0972	.081	2.1382	1.8896	1.7736	.0983
18	.0972	.081	.0972	1.9393	1.757	1.5415	.1147
19	.0972	.0972	.0972		.0995	.0995	.0983
20	.1134	.1134	.0972		.0995		.1147
21	.1134	.1134	.1134	.0663	.0995	.116	.1147
22	.1134	.1134	.1134	.0497	.0995	.116	.0983
23	1.1336	1.2308	.0972		.0829	.0995	.0983
24	1.247	1.1984	1.2146	.0972			.0995
Max	1.7004	1.6842	1.6518	2.4863	1.9227	2.1216	.547
Min	.0486	.0648	.081	.0497	.0332	.0829	.0655
Avg	.7552	.6006	.5574	.9329	.9205	.7640	.3069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 205 / 1KV Yede Lvanmachi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0781	.0625	.679	.5487	.6321	.0602
2	.0781	.0781	.0625	.6327	.5418	.6622	.0602
3	.0781	.0781	.0625	.6249	.5487	.6321	.0602
4	.0781	.0781	.0781	.6327	.5569	.6241	.0602
5	.0937	.0781	.0781	.6944	.5944	.6241	.0602
6	.0937	.0937	.0937	.9332	.6984	.7727	.0753
7	.0781	.0937	.0937	1.0686	.8471	.9214	.0903
8	.0781	.0781	.0937	1.0517	.8619	.9482	.0753
9	1.2498	1.406	1.3748	.8993	.8471	.9031	.0753
10		1.5154	1.4529	.8078	.7133	.7977	.0753
11		1.4217	1.3279	.061	.0594	.0753	.4967
12		1.3904	1.2967	.0762	.0743	.0753	
13		1.3748	1.2654	.061	.0743	.0753	
14	1.0467	1.2654	1.1561	.061	.0743	.0903	
15	1.406	1.2342	1.1561	.061	.0594	.0903	.4064
16	1.3904	1.1873	1.1405	.0914	.0743	.0903	.4515
17	.0781	.0781	.0937	.0914	.0743	.0903	.4214
18	.0937	.1094	.1094	.0914	.0743	.0903	.3913
19	.1094	.0937	.1094		.0892	.0753	.0753
20	.1094	.0937	.1094		.0892		.0753
21	.1094	.0937	.1094	.1067	.0892	.0753	.0753
22	.1094	.0937	.1094	.1067	.0892	.0753	.0753
23	.0937	.0781	.1094	.0914	.0743	.0753	.0602
24	.0781	.0781	.0781	.0937	.0914	.0743	.0753
Max	1.406	1.5154	1.4529	1.0686	.8619	.9482	.4967
Min	.0781	.0781	.0625	.061	.0594	.0743	.0602
Avg	.3265	.5071	.4843	.4099	.3269	.3726	.1570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2614	.2378	.2561		.2561	.2477
2	.2477	.2427	.2378	.2195		.2378	.2477
3	.2286	.2241	.2218	.2195	.2667	.2402	.2477
4	.2096	.2241	.2195	.2195	.2477	.2427	.2667
5	.2286	.2241	.2218	.2195	.2477	.2561	.2477
6	.2477	.2427	.2195	.2149	.2477	.2743	.2667
7	.2477	.2801	.2772	.2507	.2667	.2926	.2667
8	.2286	.2743	.2957	.2561	.2858	.2926	.2858
9	.2561	.2561	.2195	.2667	.2743	.3048	.2534
10	.2561	.3077	.2195	.2667	.2534	.2858	.2561
11	.1829	.3109	.2926	.2667	.2743	.2858	.2195
12	.1829	.3109	.2987	.2667		.2667	.2195
13		.2743	.2987	.2667	.2561	.2667	.2195
14		.2743	.2614	.2667	.2378	.2858	.2507
15		.2896	.2987	.2858	.2378	.2858	.2507
16	.2218	.2507	.2987	.3239	.2561	.3048	.2195
17	.2218	.3109	.2926	.362	.2772		.2561
18	.2033	.2772	.2804	.3048	.2561	.2667	.2507
19	.2801	.3142	.2507	.2667	.2957	.2858	.2507
20	.3361	.3109	.3361		.3292		.2926
21	.3174	.2957	.2987		.3292		.2926
22	.2987	.2926	.2987		.3326	.2858	.2926
23	.2801	.2743	.2926		.2957	.2096	.2507
24	.2286	.2614	.2587	.2507		.2772	.2667
Max	.3361	.3142	.3361	.362	.3326	.3048	.2926
Min	.1829	.2241	.2195	.2149	.2378	.2096	.2195
Avg	.2444	.2744	.2678	.2625	.2734	.2716	.2549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0719	1.0829	1.0974	1.2384	.9511	.9145
2	.9145	1.0349	1.0349	1.0719	1.2003	.924	.9526
3	.9145	.9979	.9795	1.0719	1.2003	.9145	.9526
4	1.0098	.9979	.9694	1.0974	1.1622	.961	1.0098
5	1.086	1.2012	.9979	1.0974	1.2003	1.0277	1.0288
6	1.2955	1.2136	1.2197	1.2071	1.2574	1.1393	1.1812
7	1.1622	1.0242	1.0349	1.0608	1.1622	.9511	1.1622
8	.9145	.9694	.961	.9313	1.0098	.8779	.9145
9	.961	1.0425	.9979	.9907	1.0059	.9335	.9412
10	1.0534	1.0317	1.134	1.1431	1.0608	1.0288	1.0029
11	.9425	1.0534	1.1706	1.1241		.9907	.9671
12	.961	1.0425	1.0974	1.105	1.0242	.9717	.9511
13	.9694	1.0425	1.1706	1.1431	.9877	1.0479	.9145
14	1.0242	1.0425	1.134	1.1431	1.0608		.9671
15	1.0059	1.0719	1.134	1.1622	1.0719	1.1431	.9671
16	1.134	1.2071	1.2803	1.1431	.9694	1.1812	1.2071
17	.9877	1.0349	1.0974	1.1622	.9055		.9877
18	.9328		.9671	1.1812	.9055	.8002	
19	1.134	1.2936	1.1706	1.4289		1.1241	
20	1.2567	1.4083	1.3535		1.0242		.7522
21	1.2567	1.3535	1.3169		1.0242	1.2765	1.3611
22	1.2567	1.3169	1.2803		1.3169	1.2384	1.2437
23	1.1827	1.2382		1.2765	1.2012	.9907	1.0745
24	.9717	1.1088	1.134	1.134	1.2765	1.0719	.9717
Max	1.2955	1.4083	1.3535	1.4289	1.3169	1.2765	1.3611
Min	.9145	.9694	.961	.9313	.9055	.8002	.7522
Avg	1.0533	1.1217	1.1182	1.1320	1.1030	1.0260	1.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.1949	1.2136	1.2071	1.1622	1.0425	.9145
2	1.1622	1.1576	1.1763	1.1458	1.0098	.9795	.8192
3	1.1431	1.1203	1.1273	1.1088	.9526	.9511	.8192
4	1.1812	1.1088	1.1088	1.0974	.9526	.961	.9717
5	1.2193	1.1458	1.0974	1.134	1.0098	1.0059	1.0098
6	1.2384	1.251	1.1706	1.1706	1.105	1.1088	1.0479
7	1.2193	1.1643	1.1458	1.0745	1.1431	1.0059	1.105
8	1.2955	1.3717	1.262	1.182	1.1622	1.1706	1.1622
9	1.0608	1.0425	1.0425	1.0288	1.1157	1.0288	1.0317
10	1.3717	1.3352	1.2437	1.2955	1.1643	1.1812	1.134
11	1.1706	1.3121	1.2071	1.2765	1.1157	1.1622	1.0974
12	1.1888	1.2254	1.0608	1.2384	1.0059	1.105	1.0242
13	1.2437	1.3169	1.1706	1.2193	.9877	1.1431	.9877
14		1.2803	1.2803	1.2193	1.0059	1.1812	1.0608
15	1.2254	1.2936	1.2071	1.2574	1.0719	1.1622	1.0242
16	1.1888	1.3352	1.2437	1.2574	1.1643	1.105	1.0242
17	1.2254		1.2071	1.2955	1.0974		1.0974
18	1.1706	1.4266	1.1462	1.3336	1.0349	1.105	1.1706
19	1.5123	1.5524	1.4632	1.5623	1.3352	1.1622	1.4266
20	1.8484	1.7741	1.6095		1.4784		1.4685
21	1.7177	1.3937	1.4632		1.3491	1.3146	1.2894
22	1.5684	1.423	1.4632		1.3169	1.2765	1.3169
23	1.4563	1.3717	1.3969	1.2955	1.1765	.9145	1.1462
24	1.2003	1.363	1.2382	1.2803	1.2955	1.134	.8573
Max	1.8484	1.7741	1.6095	1.5623	1.4784	1.3146	1.4685
Min	1.0608	1.0425	1.0425	1.0288	.9526	.9145	.8192
Avg	1.2952	1.3026	1.2394	1.2229	1.1339	1.1000	1.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0747	.0732	.3841		.3601	.0762
2	.0953	.0747	.0747	.3749		.3605	.0762
3	.0762	.0747	.0747	.4062		.3605	.0762
4	.0762	.0754	.0739	.4062		.3681	.0762
5	.0762	.0754	.0739	.4374		.3795	.0762
6	.0762	.0747	.0732	.5624		.4687	.0762
7	.0762	.1494	.0732	.6722		.5898	.0762
8	.0762	.112	.1097	.6722		.5937	.0762
9	1.0978	1.1576	1.0159			.6859	.0732
10	1.1336	1.0402	1.0486	.6668		.5716	.0686
11	.9878	1.065	1.0242	.0762	.0732	.0762	.5373
12	.9069	1.0526	1.0242	.0762	.0739	.0762	.5731
13	.8583	.9339	.8962	.0762	.0732		.5014
14	.8259	.8848	.8002	.0762	.0732	.0762	.5731
15	.1619	.8785	.6882	.0762		.0762	.5731
16	.7449	.8029	.6554	.0762		.0762	.5014
17	.081	.1097	.112	.0762	.1463		.4557
18	.0972	.1294	.0747	.0762	.0924	.0762	.4207
19	.112	.0732	.112	.0762	.0732	.0762	.0732
20	.112	.0914	.112		.0739		
21	.112	.0924	.1097		.0732	.0762	.0732
22	.112	.0914	.0732		.0724	.0762	.0732
23	.0934	.0732	.0732		.0732	.0762	.0716
24	.0762	.0747	.0739	.0747		.0732	.0762
Max	1.1336	1.1576	1.0486	.6722	.1463	.6859	.5731
Min	.0762	.0732	.0732	.0747	.0724	.0732	.0686
Avg	.3392	.3859	.3550	.2812	.0816	.2654	.2285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER
Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 403 / RATHARE BK

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	5.7156
Max	5.7156
Min	5.7156
Avg	5.7156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 404 / 33KV BAHE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 405 / 33KV Walava

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
23	1.3146
Max	1.3146
Min	1.3146
Avg	1.3146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 701 / Rajaram Bpau SSK Sakharale NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	.0229
Max	.0229
Min	.0229
Avg	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4527	.4435	.4904	.3658	.415	.4344
2	.4108	.4527	.4252	.4904	.2835	.415	.4066
3	.3258	.4527	.3898	.4904	.2835	.415	.3696
4	.3658		.3982	.4904	.2926	.415	.3544
5		.5281	.4706	.4904	.3366		.4252
6		.5658	.5544	.5601	.3366		.5304
7		.6283	.6283	.6653	.5729		.5853
8		.5914	.6036	.5792	.5487		.5975
9			.5415	.5792	.499		.5175
10			.543		.4887		.499
11			.5175		.4755		.4435
12			.5175		.5121		.4755
13			.5121		.4854		.4755
14	.7468		.5121		.4755		.4382
15	.6584		.5138		.4252		.5121
16	.6653		.5304		.4115		.5175
17	.567	.543	.5316	.5487	.4252	.5316	.5175
18	.567	.4755	.6024	.5487	.4252	.6219	.5544
19	.6024	.5041	.7087		.6447	.7392	.6584
20	.7087	.8131	.7316	.3658	.6219		.6584
21	.5975	.7316	.6584	.3658	.6283		.5175
22	.5658	.6468	.6348	.4525	.5601		.5175
23	.5281	.5359	.5601	.5544	.5228		.415
24	.4854	.4904	.4805	.5281	.439	.4527	.5249
Max	.7468	.8131	.7316	.6653	.6447	.7392	.6584
Min	.3258	.4527	.3898	.3658	.2835	.415	.3544
Avg	.5470	.5608	.5421	.5125	.4608	.5007	.4977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036		.6602	.7167	.4108	.6036	.4481
2	.5601	.7167	.5658	.679	.3326	.6036	.3772
3	.5281	.7167	.4706	.679	.3395	.6036	.3772
4	.5281	.7167	.4706	.679	.3544	.6036	.2896
5		.7167	.5415	.679	.3544		.2896
6		.7545	.547	.679	.439		.3582
7		.7762	.6535	.7762	.4755		.4481
8		.7392	.6413	.7392	.3584		.4527
9			.7282	.543	.6535		.7023
10			.7167		.6805		.7762
11			.5975		.7545		.8215
12			.5975		.8215		.7922
13			.8488		.724		.7922
14	.679		.9431		.7095		.8215
15	.8962		.9335		.7545		.7316
16	.9431		.8775		.7922		.6722
17	.6653	.7922	.8589	.8589	.7316	.5658	.6722
18	.6653	.5601		.8676	.788	.5121	.7468
19	.7392	.9431	.8501		.8596		.7392
20	1.1203	1.1203	.9145	.8299	.8871		.924
21	.9431	1.0059	.9877	.8215	.9335		.9335
22	.8676	.9431	.8871	.7468	.7922		.7922
23	.8676	.7842	.7545	.6413	.7922		.7545
24	.7095	.8299	.7682	.7545	.4668	.679	.4854
Max	1.1203	1.1203	.9877	.8676	.9335	.679	.9335
Min	.5281	.5601	.4706	.543	.3326	.5121	.2896
Avg	.7544	.8077	.7311	.7307	.6336	.5959	.6333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.7167		.4298	.3292	.3292	
2	.3696	.4344		.4298	.3326	.3292	.2058
3	.3326	.4344		.4298	.2926	.3292	.2103
4	.3258	.4344	.3898	.4298	.2804	.3292	.2804
5		.5068	.4607	.4298	.3506		.3696
6		.5068	.4706	.543	.3658		.4108
7		.5316	.5068	.4755	.4344		.439
8		.4607	.4887	.4458	.4075		.4557
9			.4525	.407	.3982		.3801
10			.439		.3601		.7762
11			.4805		.2229		.3601
12			.4805		.3326		.3681
13			.439		.362		.3801
14	.4706		.439		.3881		.4024
15	.4706		.4207		.3189		.2572
16	.3658		.4115		.3189		.2572
17		.3292	.4115	.3982	.3506	.3982	.3086
18	.4458	.2172	.4207	.3982	.3467	.3982	.3086
19	.5144	.4887	.4908		.4252	.4344	
20	.5487	.5487	.5609	.3881	.4252		.4252
21	.5373	.4733	.5258	.3841	.3982		.3982
22	.5487	.5138	.5316	.439	.4108		.5068
23	.5487	.5304	.4252	.4706	.4108		.3982
24	.4344	.4344	.4344	.4252	.439	.394	
Max	.5487	.7167	.5609	.543	.439	.4344	.7762
Min	.3258	.2172	.3898	.3841	.2229	.3292	.2058
Avg	.4482	.4726	.4610	.4327	.3626	.3677	.3761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.3898	.362	.362	.3439	.3189	.3086
2	.2454	.3898	.3734	.3582	.1753	.3189	.3258
3	.2454	.3898	.2987	.3582	.1753	.3189	.2454
4	.3544	.3814	.2835	.3582	.1715	.3224	.2454
5		.4161	.3366	.3506	.2658		.2987
6		.4508	.3439	.4207	.3366		.2987
7		.3772	.3982	.3856	.3601		.362
8		.3429	.4024	.3429	.3921		.3582
9			.4024	.3429	.3801		.3601
10			.4066		.3429		.3601
11			.4115		.3582		.2804
12			.4115		.362		.3292
13			.3544		.2835		.3292
14	.5487		.4344		.2926		.3258
15	.4458		.4294		.3544		.2804
16	.4382		.4294		.4024		.2804
17	.3429	.3506	.4119	.4115	.3982	.2804	.2743
18	.3429	.4031	.4075	.4458	.3856	.2743	.3429
19	.3772	.5121		.4458	.3856	.463	.3772
20	.4801	.5853	.567	.3658	.4298		.4458
21	.4801	.5601	.4961	.439	.4904		.4527
22	.4115	.4908	.5014	.362	.407		.415
23	.4252	.4525	.3982	.362	.373		.3258
24	.4075	.3898	.4163	.3982	.3439	.3544	.362
Max	.5487	.5853	.567	.4458	.4904	.463	.4527
Min	.2454	.3429	.2835	.3429	.1715	.2743	.2454
Avg	.3909	.4301	.4033	.3829	.3421	.3314	.3327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914		.0914		1.2193		.061
2	.0914		.0914		1.2803		.061
3	.1219				1.3763		.0457
4	.1219		.0617		1.406		.0457
5			.0781		1.7185		.0914
6			.0781		1.8023		.0914
7			.1219		1.8351		
8			.1219		2.0645		
9			1.1633		1.9826		.0914
10			2.8967		1.8351		.0762
11			2.7526		.0762		1.0402
12			2.7526		.1067		1.5684
13			2.5606		.0914		1.7284
14	2.9492		2.5724		.0914		1.6324
15	3.0312		2.4006		.0914		1.6057
16	2.982		2.3266		.0914		1.6057
17		.1219		.1524		.1219	
18		.1219				.1219	
19		.1219				.1219	
20		.1372					
21		.1219				.061	
22		.1219				.061	
23		.1219				.061	
24	.1219		.0914		.0914		.061
Max	3.0312	.1372	2.8967	.1524	2.0645	.1219	1.7284
Min	.0914	.1219	.0617	.1524	.0762	.061	.0457
Avg	1.1889	.1241	1.2601	.1524	1.0094	.0915	.6537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7532		1.5238		.061		
2	1.8724		1.5524		.061		
3	1.8724		1.5524		.061		
4	1.9662		1.8023		.0457		
5			2.0809		.0457		
6			2.1125		.0762		
7			2.1765		.0762		
8			2.0645		.0762		
9			.0914		.0762		1.2163
10			.0914		.0762		1.2163
11			.0914		2.2939		.0762
12			.0914		2.4086		.061
13			.0914		2.2405		.061
14			.0914		2.1628		
15			.0914		2.0805		
16			.0914		1.9364		.0457
17		.0762		2.0325		1.9204	
18		.0762		1.8564		1.9204	
19		.0914				.0762	
20		.0914					
21		.0914					
22		.0914					
23		1.9989					
24	1.7532		1.5238		.061		.061
Max	1.9662	1.9989	2.1765	2.0325	2.4086	1.9204	1.2163
Min	1.7532	.0762	.0914	1.8564	.0457	.0762	.0457
Avg	1.8435	.3596	1.0071	1.9445	.8141	1.3057	.3911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.25				.1524
2	.1524		.2031				.1406
3	.1067		.2006				.1406
4	.1524		.1852				.1219
5			.1829				.1219
6			.2286				.1875
7			.2343				.1875
8			.1981				.1875
9			2.0153				.1829
10			2.1136		1.2803		.1372
11			1.7859		.1829		1.704
12			1.7859		.1981		1.7284
13			1.6004		.1829		1.7695
14	2.2611		1.3108		.1875		1.6004
15	2.3758		1.3123		.1829		1.4243
16	2.0153		1.3123		.1829		1.2803
17		.25		.25		.1829	
18		.25		.2591		.1829	
19		.2439				.1829	
20		.25					
21		.25				.1829	
22		.25				.1875	
23		.2804				.1875	
24	.1829		.25				.1829
Max	2.3758	.2804	2.1136	.2591	1.2803	.1875	1.7695
Min	.1067	.2439	.1829	.25	.1829	.1829	.1219
Avg	.9249	.2535	.8923	.2546	.3425	.1844	.6618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6216		2.343				.7865
2	2.5606		2.4086				.7865
3	2.5286		2.3525				.7042
4	2.4486		2.4006				.7042
5			2.3434				.6958
6			2.4059				.6325
7			2.5232				.6401
8			2.4905				.5921
9			.1219				.5761
10			.061				.5921
11			.061		2.556		
12			.061				
13			.061				
14	.0762		.061				.0914
15	.061		.061				.0914
16	.061		.061		2.8346		.0914
17		.061		3.0407		2.7206	
18				2.9127		2.7206	
19						.0914	
20		.0914					
21		.0914				.0914	
22		.0983				.0914	
23		2.5617					
24	2.5069		2.343				
Max	2.6216	2.5617	2.5232	3.0407	2.8346	2.7206	.7865
Min	.061	.061	.061	2.9127	2.556	.0914	.0914
Avg	1.6081	.5808	1.3035	2.9767	2.6953	1.1431	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.4031	.9055	.0857	.8686	.1543
2	.1698	.4031	.9055	.0905	.8686	.1578
3	.1698	.5194	.9055	.0905	.8686	.1578
4	.1698	.5194	.9055	.1595	.8686	.1097
5	.1698	.7373	.9055	.1595		.112
6	.1698	.7373	.9055	.1886		.0377
7	.961	.8238	.924	.1886		.0377
8	.961	.8413	.924	.2033		.0343
9		.8413	.924	.1886		.0343
10		.8413		.1886		.0343
11		.9149		.1886		
12		.9149		.1886		
13		.8505		.8413		
14		.8962		.823		.0189
15		.8059		.8059		.0171
16		.8059		.8238		.0189
Max	.961	.9149	.924	.8413	.8686	.1578
Min	.1698	.4031	.9055	.0857	.8686	.0171
Avg	.3676	.7410	.9117	.3259	.8686	.0711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.3375	1.8229		1.6651	.3086
2	1.3375	1.3375	1.7528		1.6651	.3155
3	1.3375	1.3672	1.7528		1.6651	.3155
4	1.0802	1.56	1.7528		1.6651	.2401
5	1.0802	1.5261	1.6804			.2401
6	1.286	1.6118	1.6617			.2058
7	1.6297	1.6975	1.6975			.2401
8	1.6297	1.6975	1.5604			.2561
9		1.7353	1.5604			.3944
10		1.5089				.3944
11		1.749		.6001		.3544
12		1.749		1.3203		.3429
13		1.7353		1.5432		1.2689
14		1.6975		1.6632		.8939
15		1.4022		1.6301		.8916
16		1.4232		1.3889		.8916
Max	1.6297	1.749	1.8229	1.6632	1.6651	1.2689
Min	1.0802	1.3375	1.5604	.6001	1.6651	.2058
Avg	1.3398	1.5710	1.6935	1.3576	1.6651	.4721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3961	.415	.3961	.3772	.3772	.3395
2	.3961	.3734	.3961	.3772	.3734	.3772	.3206
3	.3772	.3658	.3961	.3772	.3086	.3961	.3018
4	.3772	.3292	.3961	.415	.3224	.3961	.3395
5	.415	.3361	.415	.4527	.3189	.3961	.3961
6	.5415	.415	.4527	.4854	.4108	.415	.4481
7	.4938	.4904	.5228	.499	.4066	.4338	.499
8	.4938	.4344	.4572	.4024	.4024	.4066	.4207
9	.4119	.4607	.4163	.362	.3696	.3475	.3801
10	.3856	.4115	.4031	.3086	.3086	.3155	.3086
11	.3506	.3772	.3429	.3052	.2804	.3086	.3429
12	.3601	.3506	.3506	.3086	.2454	.3155	.3155
13	.3086	.3506	.3601	.3086	.2454	.3155	.3155
14	.2804	.3506	.3429	.3856	.2454	.3086	.3086
15	.3155	.2804	.3429	.3856	.3155	.333	.2804
16	.3506	.3155	.3506	.3506	.3506	.3155	.333
17	.333	.3429	.333	.3506	.3086	.3155	.3155
18	.3721	.4119	.394	.4024	.4119	.3155	.394
19	.439	.543	.4887	.4656	.5068	.543	.5304
20	.5914	.6219	.6036	.4656	.5487		.5544
21	.5788	.5914	.5359	.4656	.5175	.4805	.5041
22	.4904	.5601	.5041		.4668	.4294	.4668
23	.415	.4904	.4527	.5068	.4338	.3961	.4338
24	.4715	.3961	.4338	.415	.3772	.3772	.3395
Max	.5914	.6219	.6036	.5068	.5487	.543	.5544
Min	.2804	.2804	.333	.3052	.2454	.3086	.2804
Avg	.4144	.4165	.4211	.3996	.3689	.3746	.3829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4024	.3772	.3961	.1509	.415	.3206
2	.3961	.3582	.3772	.3772	.1433	.3961	.3018
3	.3961	.3506	.3584	.3772	.1402	.3961	.3018
4	.3772	.3224	.3018	.415	.1448	.3772	.3395
5	.3772	.3982	.415	.4527	.1772	.3772	.3772
6	.3961	.4298	.4338	.4854	.181	.3961	.4294
7	.4338	.4706	.4854	.4251	.1772	.4338	.4435
8	.4668	.439	.439	.4024	.181	.4066	.4024
9	.4572	.3582	.3982	.3982	.1829	.362	.362
10	.3506	.3506	.3506	.3506	.1886	.3429	.3429
11	.3982	.3772	.3429	.3856	.1753	.3429	.3155
12	.2454	.4207	.3429	.3506	.1753	.3155	.3086
13	.3086	.3772	.3856	.3429	.1753	.3086	.3086
14	.2743	.3506	.3429	.3429	.1753	.2743	
15	.3086	.3429	.3086	.3429	.1715	.3086	
16	.3772	.3506	.3506	.3429	.3086	.3155	
17	.3772	.3506	.3506	.3429	.2804	.4031	
18	.4115	.394	.394		.4119	.4031	
19	.4854	.4887	.4706		.4887	.4706	
20	.5258	.5487	.6219		.5304		.5729
21	.5014	.5175	.5544		.5175	.4805	.5975
22	.4557	.4668	.5041		.5041	.4668	.5415
23	.4298	.4338	.4527		.4715	.415	.4715
24	.415	.394	.3961	.415	.1829	.415	.3395
Max	.5258	.5487	.6219	.4854	.5304	.4805	.5975
Min	.2454	.3224	.3018	.3429	.1402	.2743	.3018
Avg	.3984	.4039	.4064	.3859	.2598	.3836	.3932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.362	.3584	.3584		.3395	
2	.3395	.3544	.3395	.3395		.3206	
3	.3395	.3258	.3395	.3395		.3206	
4	.3395	.3292	.3395	.3772		.3584	
5	.3772	.394	.3584	.4527		.3772	
6	.3961	.4298	.3921	.4854		.3961	
7	.4108	.4656	.462	.4435		.4108	.3881
8	.4338	.4557	.5121	.4755		.3881	.4572
9	.362	.4908	.5249	.362	.0732	.3658	.362
10	.3506	.4115	.4115	.3224	.0716	.3086	.3506
11	.3506	.3429	.4115	.3155	.0526	.2683	.3429
12	.2743	.3155	.3429	.3086	.0526	.2743	
13	.2743	.3155	.3155	.2804	.2279	.2743	.3086
14	.2743	.3155	.3086	.2804	.2229	.2804	.3086
15	.3155	.2454	.2058	.2804	.3155	.2804	.2804
16	.3155	.2804	.3086	.3155	.3506	.2804	.3155
17	.3155	.3155	.3429	.3506	.3155	.333	.3086
18	.3467	.4835	.394		.3761	.3506	.4163
19	.4508	.5853	.4163		.4207	.4344	.5304
20	.5731	.6099	.6036		.499		.5175
21	.3734	.5788	.5544		.4668	.462	.4854
22	.4298	.5093	.5228		.4527	.4108	.4294
23	.362	.4338	.415		.3961	.3584	.3772
24	.3584	.4024	.3584	.3772		.3395	
Max	.5731	.6099	.6036	.4854	.499	.462	.5304
Min	.2743	.2454	.2058	.2804	.0526	.2683	.2804
Avg	.3634	.4064	.3974	.3592	.2863	.3449	.3862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8652	1.9044	1.6263	.0566		.0377	.7701
2	1.8519	1.829	1.6095	.0566		.0377	.7625
3	1.8347	1.7909	1.6278	.0566		.0377	.7293
4	1.8143	1.8823	1.6108	.0566		.0377	.7545
5	1.7804	1.9753	1.6787	.0566		.0377	.7956
6	1.8519	1.9136	1.749	.0566		.0566	.8619
7	1.8861	1.8861	1.8176	.0754		.0566	1.1233
8	1.8347	1.7295	1.7661	.0566		.0566	1.1401
9	.0566	.0343	.0377	.0566		.0566	1.1022
10	.0377	.0351	.0351	.0566		.0566	1.1317
11	.0351	.0343	.0343	1.6975		1.7147	.0328
12	.0351	.0351	.0351	1.6126		1.8229	
13	.0343	.0343	.0351	1.5432	.8413	1.7528	
14	.0343	.0343	.0343	2.0576	1.2826	1.7147	
15	.0351		.0343	2.3838	1.2269	1.5775	
16	.0351		.0351	2.2786	1.3253	1.6126	
17			.0351	2.2085		1.6461	
18	.0377		.0366		1.6446	1.4419	
19	.0377	.0754	.037		1.1145	.0566	
20	.0549	.0754	.056		.0754		.0754
21	.056	.0754	.0566		.0754	.0566	.0754
22	.0943	.0754	.0566		.0754	.0566	.0754
23	1.7974	1.576	.0566		.0566	.0566	.0754
24	1.8652	1.749	1.6263	.0566		.0566	.0566
Max	1.8861	1.9753	1.8176	2.3838	1.6446	1.8229	1.1401
Min	.0343	.0343	.0343	.0566	.0566	.0377	.0328
Avg	.8246	.9373	.6553	.8013	.7718	.6103	.5976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.5535	.132	.5312	.0754
2	.0943	.0914	.0943	.5376	.112	.5312	.0754
3	.0943	.0716	.0943	.5441	.1097	.5155	.0754
4	.0943	.0716	.0943	.5921	.1063	.506	.0754
5	.0943	.0701	.0943	.6478	.1402		.0754
6	.1132	.0895	.0943	.9878	.0903	.7362	.0943
7	.132	.1063	.1132	1.2483	.1715	1.0562	.0943
8	.132	.0914	.1132	.9602	.2561	.9442	.0934
9	1.7126	1.9281	1.6448	.6964		.7907	.0924
10	1.7147	1.7528	1.5432	.6554		.8573	.0876
11	1.2689	1.9281	1.5432	.0671	.0526	.0671	1.2269
12	1.2689	1.4022	1.2003	.0686	.0526	.0343	
13	1.2003	1.1218	1.0288	.0686	.0526	.0343	1.2269
14	1.262	1.0867	1.0288	.0701	.0526	.0343	1.166
15	1.1218	1.1919	1.0517	.0701	.0537	.1052	1.1393
16	.9816	1.1218	1.0517	.0686	.0526	.1029	.8573
17	.1052	.1052	.0701	.0701	.0526	.1029	.8916
18	.1132	.0905	.1086		.6859	.1227	.7888
19	.0934	.1132	.1097		.1132	.0934	.1097
20	.1075	.1132	.1109				.1132
21	.0537	.1132	.112		.1132	.0943	.1132
22	.0537	.0943	.1132		.1132	.0943	.1132
23	.0867	.0943	.0943		.0943	.0754	.0943
24	.0943	.0943	.0943	.0943	.0187	.0943	.0754
Max	1.7147	1.9281	1.6448	1.2483	.6859	1.0562	1.2269
Min	.0537	.0701	.0701	.0671	.0187	.0343	.0754
Avg	.5036	.5432	.4874	.4445	.1250	.3420	.3806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.8482	.1524	.8002	.0754
2	.0943	.112	.1132	.8322	.128	.8002	.0754
3	.0857	.132	.1132	.7935	.0655	.8421	.0754
4	.0943	.128	.1132	.8097	.0671	.7935	.0754
5	.0943	.0895	.1132	.8848	.064	.9012	.0754
6	.1132	.0905	.132	1.1305	.0463	1.1437	.0943
7	.1132	.1307	.132	1.5708	.112	1.4918	.0943
8	.1132	.0886	.1132	1.5546	.9831	1.4746	.0934
9	2.4587	2.5526	2.1795	1.1142	.9945	1.4419	.0924
10	2.4006	2.2291	2.1795	1.0059	1.0288	1.5089	.0905
11	2.191	2.1948	2.2043	.0678	.0876	.1006	1.6461
12	2.191	1.8861	1.8861	.0686	.0701	.0701	1.8861
13	1.7528	1.8054	1.7147	.0701	.0701	.0701	1.9281
14	1.7528	1.7528	1.4937	.0701	.0686	.0701	1.7147
15	1.6461	1.5432	1.5402		.0701	.0701	1.7528
16	1.6476	1.5432	1.5775	.0686	.0857	.0686	1.5249
17	.1052	.0876	.0701	.0686	.0857	.1052	1.5775
18	.1086	.128		.128	.0895	.1052	1.4403
19	.1254	.1509	.128	.1075	.0943	.112	.1132
20	.132	.1509	.1663		.0943		.1132
21	.132	.1509	.1494		.0943		.1132
22	.132	.132	.1509		.0943	.0189	.1132
23	.132	.132	.132	.0358	.0943	.0943	.1132
24	.132	.1132	.1132	.132	.0351	.0754	.0943
Max	2.4587	2.5526	2.2043	1.5708	1.0288	1.5089	1.9281
Min	.0857	.0876	.0701	.0358	.0351	.0189	.0754
Avg	.7442	.7266	.7230	.5681	.1990	.5527	.6239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2611	2.2211	2.1434	.0566	.0543	.0377	1.6956
2	2.1776	2.34	2.1434	.0377	.0532	.0377	1.643
3	2.1776	2.3663	2.1325	.0377	.0537	.0377	1.643
4	2.191	2.524	2.1325	.0377	.0543	.0377	1.5912
5	2.1672	2.6505	2.1672	.0566	.0537	.0377	1.6244
6	2.2611	2.7511	2.2961	.0566	.0549	.0566	1.7101
7	2.3487	2.7435	2.4539	.0566	.0537	.0566	1.95
8	2.2786	2.5072	2.4013	.0566	.0362	.0566	1.7635
9	.0566	.0358	.0377	.056	.0366	.0566	1.749
10	.0566	.0343	.0377	.0537	.0343	.0514	1.7528
11	.0514	.0343	.0343	1.5775	2.5377	2.6292	.0351
12	.0351	.0351	.0351	1.5432	2.5606	2.6993	.0351
13	.0343	.0526	.0351	1.5432	2.4539	2.572	.0351
14	.0351	.0526	.0343	2.8045	.1715	2.6292	.0343
15	.0351	.0514	.0343	2.8807		2.5591	.0351
16	.0351	.0526	.0343	2.6993		2.4539	.0351
17	.0362	.0526	.0351		.3506	2.2291	.0351
18	.0377	.0549	.0537		.2743	2.0008	.0724
19	.0373	.0566	.0543		.0754	.056	.0943
20	.0549	.0754	.0549		.0754		.0943
21	.056	.0754	.0554		.0754	.0943	.0943
22	.0943	.0754	.056		.0566	.0943	.0943
23	1.7974	2.1091	.0566		.0566	.0943	.0943
24	2.2786	2.2283	2.1845	.0566	.0537	.0566	.0754
Max	2.3487	2.7511	2.4539	2.8807	2.5606	2.6993	1.95
Min	.0343	.0343	.0343	.0377	.0343	.0377	.0343
Avg	.9414	1.0492	.8627	.8006	.4194	.8971	.7495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3599	1.3077	.1267	.112	.1132	
2	1.1888	1.3441	1.3077	.1294	.112	.1132	.4687
3	1.1294	1.3283	1.3077	.1294	.1132	.1097	.4687
4	1.1003	1.3283	1.2483	.1294	.112	.1132	.4428
5	1.2342	1.4232	1.3443	.1463	.1494	.132	.4999
6	1.6204	1.7394	1.7147		.2218	.1509	.6562
7	2.1605	2.332	2.5606	.0747	.1991	.1509	1.0623
8	1.9766	1.9292	2.3045	.128	.2218	.1646	.9998
9	.1433	.1478	.1509	.128	.1629	.132	.884
10	.128	.1463	.128	.1543	.1509	.1629	.7716
11	.1267	.1463	.1294	1.8947	1.6461	1.9608	.0914
12	.1109	.1663	.1294	1.0437	1.6476	1.9608	.0914
13	.1109	.1463	.1086	1.8501	1.5089	1.8903	.0924
14	.128	.1463	.112	2.0005	1.6461	1.6404	.1109
15	.128	.156	.1294	2.3482	1.7558	1.4815	.1109
16	.128	.1629	.1267	2.0466	1.6095	1.2929	.0934
17	.1612	.1753	.1478	1.9372	1.4632	1.0997	.0934
18	.1463	.1753	.1478	1.5432	1.1706	.9659	.1109
19	.1646	.1886	.1791	.168	.1509	.1494	.1448
20	.1829	.2263	.2149		.1886		.1848
21	.2195	.2263	.2172		.1886	.168	.1848
22	.2054	.1829	.1848	.1494	.1509	.1494	.1463
23	1.4232	1.5402	.1848	.1307	.128	.112	.128
24	1.3735	1.4232	1.4083	.1267	.1132	.1132	.112
Max	2.1605	2.332	2.5606	2.3482	1.7558	1.9608	1.0623
Min	.1109	.1463	.1086	.0747	.112	.1097	.0914
Avg	.6905	.7559	.6998	.7802	.6218	.6229	.3456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.3292	.3696	.3292	.2561	.2561
2	.2926	.2926	.2926	.3696	.3292	.2561	.2561
3	.2926	.2926	.2926	.3696	.3292	.2561	.2561
4	.3018	.2926	.2926	.3696	.2926	.2561	.2561
5	.3206	.3292	.3658	.4066	.3292	.2926	.2926
6	.4435	.3658	.439	.2957	.3658	.3292	.3292
7	.4207	.4024	.439	.3142	.3292	.3292	.3292
8	.4207	.3658	.4024	.3142	.3292	.2926	.3109
9	.4938	.5304	.439	.3881	.3475	.2926	.439
10	.499	.5316	.4207	.4938	.2926	.362	.3881
11	.462	.5316	.3841	.4607	.4024	.394	.3142
12	.462	.4656	.3841	.4656	.3658	.394	.3696
13	.4938	.3982	.4024	.3982	.3658	.394	.3326
14	.4572	.362	.4572	.3658	.2926	.362	.3696
15	.4572	.4656	.4572	.3475	.0366	.3841	.3696
16	.5487	.362	.4755	.362	.1063	.3841	.3696
17	.5304	.362	.4435	.362	.1097	.4298	.3696
18	.4938	.3658	.4024	.4024	.3658	.3366	.3696
19	.5121	.439	.4755	.4755	.3658	.3982	.4024
20	.5487	.5487	.4755		.4755		.4572
21	.567	.5487	.4572		.4572	.4024	.3841
22	.5304	.5121	.439	.4024	.3658	.3292	.3658
23	.4572	.439	.4066	.3841	.2926	.2926	.3326
24	.3292	.3841	.3658	.3881	.3658	.2481	.2926
Max	.567	.5487	.4755	.4938	.4755	.4298	.4572
Min	.2926	.2926	.2926	.2957	.0366	.2481	.2561
Avg	.4428	.4132	.4058	.3866	.3184	.3336	.3422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0088	.0084	.0061	.0114	.0126	.0126
2	.0114	.0095	.0084	.0061	.0111	.0126	.0114
3	.0114	.0076	.0084	.0061	.0107	.0126	.0057
4	.0122	.0072	.0126	.0061	.0091	.0126	.0061
5	.0122	.0072	.0126	.0061	.0095	.0099	.0095
6	.0107	.0084	.0126	.0076	.0091	.0114	.0061
7	.008	.008	.0084	.0088	.008	.0084	.0072
8	.0072	.0084	.0084	.008	.008	.0084	.0057
9	.0076	.0373	.0084	.008	.008	.0053	.0057
10	.0099	.0377	.0747	.0377	.0084	.0377	.0046
11	.0554	.0377	.056	.052	.0084	.0057	.0046
12	.0554	.013	.056	.0057	.0084	.0053	.0046
13	.0554	.013	.0554	.0057	.0084	.0084	.0046
14	.0532	.0122	.0554	.0057	.0084	.0084	.0046
15	.0543	.0053	.0554	.0057	.0084	.008	.0046
16	.0549	.0053	.0111	.0057	.008	.008	.0046
17	.0133	.0053	.008	.0057	.0053	.0084	.0053
18	.0099	.0053	.0069	.0053	.0084	.008	.0053
19	.0072	.0061	.0095	.0057	.0084	.0072	.0076
20	.0084	.0053	.0072		.0084		.008
21	.0126	.0084	.0061		.0126	.0072	.0091
22	.0122	.0084	.0061	.0053	.0084	.008	.0103
23	.0114	.0053	.0057	.0072	.0084	.0122	.0095
24	.0118	.0095	.0084	.0061	.0126	.0084	.0126
Max	.0554	.0377	.0747	.052	.0126	.0377	.0126
Min	.0072	.0053	.0057	.0053	.0053	.0053	.0046
Avg	.0216	.0117	.0213	.0098	.0090	.0102	.0071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	.4252	.5014	.4298	.2896	.362	.2987
2	.4298	.3898	.4835	.4298	.2896	.362	.2987
3	.4298	.3856	.4656	.4298	.2534	.362	.2801
4	.394	.4207	.4477	.4298	.2534	.3982	.2801
5	.394	.4207	.4298	.4252	.2896	.3982	.2987
6	.394	.443	.4119	.443	.3258	.4163	.3361
7	.394	.4252	.3582	.4252	.3258	.3439	.3109
8	.4298	.443	.4835	.5487	.3258	.4163	.3155
9	.3582	.4557	.4656	.4706	.4344	.4163	.4458
10	.4344	.394	.4252	.4706	.4887	.3506	.4557
11	.394	.394	.3856	.4706	.4887	.3429	
12	.3189	.4298	.3506	.4706	.4706	.4287	.3544
13		.394	.3544	.362	.3982	.3772	.3506
14	.3224	.3403	.3544	.4344	.3258	.3772	.3155
15	.3224	.3224	.3506	.4706	.3439	.3772	.4557
16	.3224	.2865	.3155	.4706	.362	.3944	.4252
17	.3258	.3403	.3224	.4706	.3439	.3429	.4961
18	.362	.394	.3582	.3258	.3801	.3429	.3155
19	.4572	.5194	.4298		.5068	.5316	.4344
20	.6219	.6626	.6733		.6878		.724
21	.5792	.5373	.6379		.5249		.5731
22	.5014	.5014	.5792	.3982	.4887	.1494	.4656
23	.394	.4298	.4344	.2896	.4887	.3547	.3582
24	.5373	.5014	.5014	.4706	.2896	.362	.3174
Max	.6219	.6626	.6733	.5487	.6878	.5316	.724
Min	.3189	.2865	.3155	.2896	.2534	.1494	.2801
Avg	.4166	.4273	.4383	.4351	.3907	.3730	.3872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9686		.5624	
2				.9259		.5624	
3				.9259		.5624	
4				.9568		.5624	
5				1.0753		.6249	
6				1.3283		.7655	
7				1.7924			
8				1.866		1.1405	
9	2.3122	2.0934	2.3122	1.5043		.9374	
10	2.5621	2.2809	2.4684	1.4083	.5937	.884	
11	2.3457		2.1559				
12	2.1559	2.0153	1.7497				.2812
13	1.8027	1.9528	1.8519				.463
14	1.9204	1.8747	1.821				.9877
15	1.7394	1.7966	1.9444				.9877
16	1.6129	1.7029	1.6248				.9755
17							.8642
18							.7811
24				.5144			
Max	2.5621	2.2809	2.4684	1.866	.5937	1.1405	.9877
Min	1.6129	1.7029	1.6248	.5144	.5937	.5624	.2812
Avg	2.0564	1.9595	1.9910	1.2060	.5937	.7335	.7629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.3749	.3841	.0924	.0549	.0724	.1303
2	.3749	.3749	.3841	.0924	.0549	.0724	.1158
3	.3749	.3749	.3841	.1075	.0549	.0724	.1014
4	.4687	.4062	.4161	.112	.0549	.0905	.1014
5	.4999	.4938	.4481	.112	.0549	.1086	.104
6	.6249	.6249	.6081		.0549	.1086	.1189
7	.9686	.9061	.8962	.1075	.0732	.1267	.1932
8	.6874	.7186	.7202	.1109	.0732	.0905	.1882
9	.0914	.0914	.0983	.112	.0905	.0724	.1981
10	.0924	.0914	.0732	.1097	.1097	.0724	.1524
11	.0739	.0905	.0905	.7499	.1829	.506	.0914
12	.0739	.0732	.1086	.6874	.3292	.5851	.1097
13	.1109	.0732	.1097		.5068		.0554
14	.112	.0732	.1097	.6562	.3439	.4999	.037
15	.1109	.0914	.1109	.6562	.543	.4321	.1852
16	.1109	.0914	.0739	.6874	.4344	.5487	.0914
17	.112	.0914	.0739	.6874	.4887	.4161	.0732
18	.112	.1097	.0732	.1562	.4163	.3185	.1097
19	.112	.128	.112		.0905	.0914	.112
20	.1294	.1463	.1109		.1086		.112
21	.112	.128	.1109		.1086	.056	.1097
22	.112	.128	.0924	.0549	.1086	.056	.0924
23	.4012	.4481	.0924	.0549	.0724	.056	.0924
24	.3749	.3704	.3749	.0924	.0549	.0724	.0566
Max	.9686	.9061	.8962	.7499	.543	.5851	.1981
Min	.0739	.0732	.0732	.0549	.0549	.056	.037
Avg	.2757	.2708	.2524	.2863	.1860	.2057	.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2353	.2353	.0724	.0905	.0171
2	.2353	.2353	.2353	.0724	.0905	.0171
3	.2353	.2353	.2353	.0724	.0905	.0171
4	.2353	.2353	.2353	.0724	.0905	.0171
5	.2353	.2353	.2353	.0724	.0905	.0171
6	.2353	.2353	.2353	.0724	.1086	.0171
7	.2353	.2353	.2353	.0905	.0724	.0171
8	.2353	.2353	.2353	.0724	.0724	.0171
9	.2353	.2353	.2353	.0905	.1086	.0171
10	.2353	.2353	.2353	.1086	.1086	.0181
11	.2353	.2353	.2353	.1086	.0905	.0181
12	.2353	.2353	.2353	.0724	.0362	.0181
13	.2353	.2353	.2353	.1086	.1086	.0181
14	.2353	.2353	.2353	.181	.1086	.0181
15	.2353	.2353	.2353	.181	.0724	.0181
16	.2353	.0724	.2353	.181	.0724	.0181
Max	.2353	.2353	.2353	.181	.1086	.0181
Min	.2353	.0724	.2353	.0724	.0362	.0171
Avg	.2353	.2251	.2353	.1018	.0882	.0175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 201 / 11 KV SURUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1646	.1623	.0914		.056	.0709
2	.16	.1692	.1623	.0716		.056	.084
3	.16	.1692	.1623	.0716		.056	.084
4	.1947	.2115	.1738	.0701		.0747	.0894
5	.2572	.2679	.2494	.0876		.0747	.1021
6	.3374	.4161	.3269	.1052		.0747	.1276
7	.7621	.7621	.6773	.1029		.1097	.1758
8	.3429	.4199	.5868	.0857		.0732	.2225
9	.0724	.0895	.0732			.0716	.1488
10	.0886	.0709	.0716			.0709	.0894
11	.0724	.0693	.0537	.602		.4548	.048
12	.0532	.0543	.0526	.5575	.3475	.362	.048
13	.052	.0537	.0526	.4287	.3144	.3041	.048
14	.0532	.0532	.0526	.3338	.3102	.3001	.032
15	.052	.0532	.0701	.3467	.2921	.2881	.032
16		.0532	.0876	.3681	.2553	.2841	.064
17	.0693	.0709	.0914	.3829	.1915	.2667	.064
18	.0709		.0914		.161	.1886	.064
19	.1097	.0924	.1097		.0709	.0895	.0732
20	.104	.0934	.1097		.0716		.0914
21		.0934	.1097		.0724	.0347	.0934
22	.1097	.0943	.1097		.0732	.0732	.0747
23	.1758	.1734	.0914		.0732	.0739	.0739
24	.1758	.1758	.1758	.0914		.0543	.0732
Max	.7621	.7621	.6773	.602	.3475	.4548	.2225
Min	.052	.0532	.0526	.0701	.0709	.0347	.032
Avg	.1652	.1683	.1627	.2373	.1861	.1518	.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 202 / 11 KV RETHRE DHARAN
GAOTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3961	.3961	.3772		.3395	.2829
2	.3395	.3772	.3429	.3772		.3018	.2452
3	.3395	.3772	.3584	.3772		.3018	.2452
4	.3772	.3584	.3584	.3734		.3395	.2829
5	.415	.3961	.3961	.4108		.3772	.3395
6	.4527	.415	.4338	.4481		.4338	.3772
7	.3511	.439	.4481	.439		.4066	.3881
8	.4024	.362	.4075	.4207		.4805	.4344
9	.6036	.3761	.3721			.3801	.3898
10	.543	.3681	.443			.3366	.3681
11	.3801	.3544	.4382	.3544	.3077	.3641	.3506
12	.394	.3582	.4207	.3761	.4525	.3856	.298
13	.3801	.3841	.4207	.4119	.6036	.4344	.3506
14	.3841	.4024	.4207	.4344	.4477	.3841	.3681
15	.3077	.6283	.4207	.3898	.5487	.4298	.333
16	.2534	.394	.4031	.3506	.567	.3761	.298
17	.2427	.3898	.4755	.3121	.3681	.3222	.3224
18	.2572	.3856	.5121		.6154	.3258	.3403
19	.4334	.7499	.6161		.6154	.4706	.5175
20	.6283	.6722	.6722		.6401		.6283
21	.6348		.6224		.5914	.1646	.5658
22	.5601	.5788	.5281		.5228	.3921	.5281
23	.4904	.4904	.4904		.4668	.3584	.4527
24	.3961	.415	.4338	.415		.3772	.3018
Max	.6348	.7499	.6722	.4481	.6401	.4805	.6283
Min	.2427	.3544	.3429	.3121	.3077	.1646	.2452
Avg	.4143	.4378	.4513	.3917	.5190	.3688	.3754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 203 / 11 KV RETHRE DHARAN AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0347	.0347	.128		.1036	.032
2	.0366	.0351	.0366	.128		.1036	.0347
3	.037	.0366	.0366	.128		.1036	.0347
4	.037	.0362	.0362	.128		.1334	.0351
5	.037	.037	.037	.192		.1623	.0351
6	.0366	.0373	.0373	.2241		.192	.0532
7	.0343	.0347	.0347	.3201		.3765	.052
8	.0358	.0343	.0358	.2881		.2921	.0469
9	.3102	.2787	.2503			.1635	.0406
10	.257	.2961	.2705			.1486	.0263
11	.1115	.2503	.2469	.0514		.0347	.2401
12	.1383	.2164	.1783	.0343	.032	.0309	.2401
13	.1404	.1814	.1783	.0339	.0328	.0312	.2401
14	.1425	.1532	.1646	.0339	.0486	.0347	.208
15	.1734	.1509	.1783	.0339	.048	.0324	.208
16	.1894	.1578	.2058	.0339	.0434	.0497	.192
17	.0339	.0347	.0366		.0671	.0406	.192
18	.0305	.0423	.0366		.0305	.0297	.16
19	.0347	.0339	.0366		.0474	.0312	.0366
20	.0554		.0366		.0503		.0366
21	.037	.0354	.0366		.0492	.0347	.0373
22	.0362	.0905	.1783		.0328	.0457	.0373
23	.0362	.0347	.0366		.0332	.052	.037
24	.0362	.0366	.0343	.0366		.0316	.0316
Max	.3102	.2961	.2705	.3201	.0671	.3765	.2401
Min	.0305	.0339	.0343	.0339	.0305	.0297	.0263
Avg	.0856	.0991	.0998	.1196	.0429	.0982	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
13	3.9769
24	3.9769
Max	3.9769
Min	3.9769
Avg	3.9769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.6244
Max	1.6244
Min	1.6244
Avg	1.6244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.9044
Max	1.9044
Min	1.9044
Avg	1.9044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.7161
Max	2.7161
Min	2.7161
Avg	2.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 702 / 132 KV Peth Wategaon NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder Feeder KV- 132 / (CONTINOUS PROCESS)(NO STAGGERING
OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.6379
Max	.6379
Min	.6379
Avg	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0633	.0617	.7316		.4321	
2	.0457	.0926	.064	.7316		.4321	
3	.0457	.0617	.0625	.7621		.4744	
4	.0457	.0625	.0617	.7621		.4938	
5	.061	.0617	.0617	.7773		.5312	
6	.061	.0625	.0617	.7773		.5937	
7	.0457	.0617	.0617	.8688		.6642	
8	.0457	.0617	.0617	.9145	.5506	.7099	
9	.9145	1.0802	1.0802	.7621	.5182	.679	.0324
10	.9374	1.0623	1.1126	.8097	.463	.6249	.0312
11	1.1873	1.0364	1.1405	.0648	.0463	.0625	.583
12	1.1336	1.004	1.0974	.0486	.0617	.0625	.5506
13	1.0936	1.0364	1.0059	.0486	.0617	.0625	.5624
14	1.0688	.9374	.9907	.0486	.0617	.0457	.5312
15	1.0623	.9374	.9602	.0486	.0633	.0457	.5624
16	.9374	.9686	.8535	.0648	.0625	.0625	.6097
17	.0457	.0469	.061	.0648	.0633	.0625	.5937
18	.0949	.0617	.061	.0648	.0625	.0625	.5487
19	.0926	.0625	.0762	.0648	.0617	.0469	.061
20	.0625	.0617	.0762		.064		.061
21	.0617	.0617	.0762		.0617		.0457
22	.0625	.0617	.0762		.0309		.0457
23	.0617	.0617	.0762		.0617		.0457
24	.0457	.0625	.0633	.0762		.0617	
Max	1.1873	1.0802	1.1405	.9145	.5506	.7099	.6097
Min	.0457	.0469	.061	.0486	.0309	.0457	.0312
Avg	.3858	.3780	.3877	.4246	.1434	.3105	.3243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0316	.0312	.2134	.0324	.1852	.0324
2	.0305	.0316	.0312	.2134	.0324	.1875	.0324
3	.0305	.0316	.0316	.2134	.0324	.1852	.0324
4	.0305	.0312	.0309	.2134	.0324	.2214	.0324
5	.0305	.0309	.0309	.2439	.0324	.2241	.0324
6	.0305	.0316	.0316	.2439	.0324	.2187	.0324
7	.0305	.0312	.0309	.2896	.1619	.2881	.0324
8	.0305	.0316	.0309	.3048	.1943	.2778	.0324
9	.4268	.4062	.3395	.3048	.1943	.2591	.0324
10	.4062	.3563	.3353	.2591	.1852	.2439	.0305
11	.4062	.3658	.3048	.0324	.0309	.0305	.2134
12	.3437	.3437	.3048	.0324	.0312	.0305	.2187
13	.3749	.3048	.3048	.0324	.0309	.0305	.1875
14	.3125	.2439	.3048	.0324	.0309	.0305	.1829
15	.3048	.25	.2743	.0324	.0312	.0305	.1524
16	.3125	.2378	.2439	.0324	.0309	.0305	.1524
17	.0305	.0312	.0305	.0324	.0312	.0305	.1219
18	.0309	.0309	.0305	.0324	.0309	.0312	.0914
19	.0312	.0312	.0305	.0324	.0309	.0305	.0305
20	.0309	.0316	.0305	.0324	.0316		.0305
21	.0312	.0309	.0305	.0324	.032	.0324	.0305
22	.0316	.0312	.0305	.0324	.0309	.0324	.0305
23	.0316	.032	.0305	.0324	.0316	.0324	.0305
24	.0305	.0309	.0309	.0305	.0324	.0309	.0324
Max	.4268	.4062	.3395	.3048	.1943	.2881	.2187
Min	.0305	.0309	.0305	.0305	.0309	.0305	.0305
Avg	.1408	.1254	.1211	.1230	.0570	.1171	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.4744	.4938	.061	.0324	.0633	.0324
2	.5792	.506	.506	.061	.0324	.064	.0324
3	.5487	.463	.4938	.061	.0324	.0648	.0324
4	.5487	.463	.5247	.061	.0324	.0617	.0324
5	.5639	.4938	.5441	.061	.0324	.0617	.0486
6	.5639	.506	.5247	.061	.0324	.064	.0486
7	.6706	.6481	.7099	.0762	.0324	.0617	.1943
8	.7011	.6173	.6009	.0762	.0324	.0617	.1943
9	.0762	.0633	.0633	.0762	.0309	.064	.1619
10	.0312	.0781	.061	.081	.0309	.0457	.1718
11	.0312	.0457	.061	.6802	.0617	.4877	1.2967
12	.0324	.0469	.061	.8097	.0617	.5506	.0312
13	.0305	.0469	.0762	.7125			.0469
14	.0781	.0469	.061	.6478		.4999	.0486
15	.0457	.0625	.061	.583		.5312	.0457
16	.0762		.0762	.5506	.463	.6802	.0469
17	.0781		.0762	.4534	.2778	.6249	.0625
18	.0625	.0633	.0762		.4012	.4999	.0457
19	.0617	.0633	.0914		.0633	.0469	.061
20	.0926	.0633	.0914		.0617		.061
21	.0633	.0617	.0762	.0324	.0617	.0324	.061
22	.0617	.0617	.0762	.0324	.0617	.0324	.061
23	.5312	.5376	.0762	.0324	.0617	.0324	.061
24	.5792	.506	.5247	.061	.0324	.0625	.0648
Max	.7011	.6481	.7099	.8097	.463	.6802	1.2967
Min	.0305	.0457	.061	.0324	.0309	.0324	.0312
Avg	.2786	.2690	.2503	.251	.0919	.2133	.1226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8642	.8223	.8124	.3932	.0972	.2881	.0324
2	.8848	.8333	.8333	.3841	.0972	.2881	.0324
3	.9175	.8223	.8962	.3841	.0972	.3201	.0324
4	.8962	.8025	.8436	.4161	.0972	.3201	.0324
5	.9667	.8749	.9172	.4321	.1296	.3479	.0324
6	.9995	.9374	.9259	.4321	.1943	.3704	.0324
7	1.4419		1.3123	.4915	.3239	.4534	.0324
8	1.3272	1.0936	1.0494	.5407	.3239	.4161	.0324
9	.6062	.5247	.4938	.4534	.3163	.3704	.0324
10	.4999	.4534	.4801	.4534	.4321	.3125	.1562
11	.5182	.5624	.4641	1.2955	.679	.7811	.2812
12	.3563	.431	.4915	1.5223	.7099	.7773	.2591
13	.3749	.3978	.4588	1.4575	.7274	.7499	.2187
14	.4374	.3437	.4588	1.3603	.6874	.7811	.2187
15	.4062	.3887	.426	1.247	.6173	.8097	.2812
16	.4374	.3563	.426	1.1984	.679	.8745	.1875
17	.1562	.1562	.1638		.6481	.7811	.1875
18	.1852	.192	.1966	.0324	.5247	.5182	.1802
19	.1852	.216	.208	.0324	.1235	.1296	.1638
20	.192	.1852	.213	.0324	.1543		.1638
21	.1852	.1875	.213	.0324	.125	.0324	.1802
22	.1898	.192	.213	.0972	.1543	.0324	.1475
23	.8333	.8025	.176	.1296	.1543	.0324	.1475
24	.8848	.7716	.8025		.1296	.125	.0324
Max	1.4419	1.0936	1.3123	1.5223	.7274	.8745	.2812
Min	.1562	.1562	.1638	.0324	.0972	.0324	.0324
Avg	.6144	.5368	.5615	.5826	.3426	.4309	.1290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.4481	.4108	.4251	.2957	.3361
2	.3881	.4435	.4108	.4066	.2957	.3326
3	.4066	.4755	.4435	.4108	.2957	.3658
4	.4066	.4481	.439	.4251	.2926	.3696
5	.4294	.4108	.4024	.4294	.3326	.4108
6	.4435	.4066	.4435	.4435	.4435	.4066
7	.5415	.4481	.4854	.4481	.5228	.4481
8	.4108	.3658	.5175	.4294	.4805	.4108
9	.4108	.4066	.3734	.4294	.3696	.3361
10	.4066	.3326	.3921		.3696	.3696
11	.3326	.4066	.3547		.4066	.2926
12	.3326	.2957	.3511		.3734	.3658
13	.2957	.3696	.3696	.3258	.3361	.4066
14	.2926	.3292	.3696	.3258	.3734	.3658
15	.2926	.3696	.3511	.3258	.3696	.3658
16	.2926	.2587	.3734	.2534	.3292	.3696
17		.3696	.3734	.2534	.3326	.3658
18	.2926	.3734	.3881	.2534	.3292	.3658
19	.3326	.5175	.4435	.2896	.3734	.4024
20	.5544	.5175	.6283	.362	.5175	
21	.5228	.5228	.5601	.362	.5121	.362
22	.4481	.5121	.4805	.3258	.4805	
23	.4066	.4435	.499	.2534	.3696	
24	.4108	.439	.4024	.4294	.3326	.3292
Max	.5544	.5228	.6283	.4481	.5228	.4481
Min	.2926	.2587	.3511	.2534	.2926	.2926
Avg	.3930	.4129	.4276	.3622	.3806	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
16	.0362
17	.0362
18	.0362
19	.0724
20	.0724
21	.0724
22	.0724
23	.0362
Max	.0724
Min	.0362
Avg	.0543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9979	.7392	.9709	.8962	.4435	.8131
2	.9795	.7316	.9511	.8501	.439	.8048
3	.9896	.6722	.8871	.8501	.4435	.8871
4	.961	.7392	.8962	.8962	.5853	.8962
5	.9709	.6722	.8779	.924	.6653	.8131
6	.961	.6653	.8871	.9425	.7392	.8779
7	.924	.6584	.961	.8962	.7392	.8048
8	.8215	.7468	.8962	.8962	.7392	.7316
9	.8775	.6653	.8131	.8589		.7392
10	.8131	.8131	1.0456	.8688		.8131
11	.8871	1.1827	1.0082	.8688	1.0349	.8871
12	.8871	.8871	1.0082	.9412	1.0242	.8131
13	.8131	.8779	1.0456	.9412	1.0456	.8131
14	.8131	.8779	1.0456		.9709	.8131
15	.8871	.961	1.0349	.9412	1.0349	.8131
16	.8779	.961	1.0456	.8688	.961	.7392
17	.7392	.8871	.9425	.8688	.8131	.8779
18	.7392	.961	.9335			
19	.8871	.8779	1.0349	1.0136		.8871
20		.961	1.251		1.2567	
21	1.0349	1.0974			1.0349	
22	.9511	.9709	1.0829		1.0456	
23	.8871	.9709	.9709		.8215	
24	1.0082	.7392	.9709	.8962	.3658	.8131
Max	1.0349	1.1827	1.251	1.0136	1.2567	.8962
Min	.7392	.6584	.8131	.8501	.3658	.7316
Avg	.9004	.8465	.9809	.9011	.8102	.8230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1478	.2218	.1848	.0739	.112	
2	.1848	.1848	.1867	.1848	.0732	.1494	
3	.1848	.1829	.1867	.2033	.0739	.1494	
4	.2218	.1867	.1848	.2033	.0739	.1109	
5	.2241	.1478	.2195	.2033	.112	.1478	
6	.2218	.1494	.1848	.2033	.1109	.1494	
7	.2218	.1848	.1848	.2402	.1109	.1478	
8	.1848	.1478	.1829	.1848	.1097	.112	
9	.1663	.1848	.1848	.1848	.112	.1463	
10		.1848	.2402	.4344	.2587	.1478	.2926
11		.2218	.2587	.362	.2587	.2561	
12	.2218	.2195	.2587	.3258	.2241	.1463	
13	.1848	.1463	.2218	.2172	.2218	.1848	.2195
14	.1478	.1829	.2402	.2534	.1848	.1463	.1848
15	.1848	.2218	.2587	.2534	.2195	.1478	.2195
16	.1848	.2561	.2402	.2896	.2587	.1848	
17	.1463	.2218	.3142	.2896	.2614	.2587	
18	.1478	.1543	.4066	.2896		.1478	.1663
19	.1867	.2241	.4251	.2172		.1478	.2402
20	.1848	.2614	.4435	.2534	.2614		.2614
21	.2195	.2587	.4108	.2534	.2561		.2772
22	.2218	.2587	.3696	.2534	.1829		.2427
23	.1867	.2218	.2218	.2534	.1867		.2218
24	.2218	.1494	.2218	.2033	.1109	.112	
Max	.2241	.2614	.4435	.4344	.2614	.2587	.2926
Min	.1463	.1463	.1829	.1848	.0732	.1109	.1663
Avg	.1925	.1958	.2612	.2476	.1698	.1553	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 402 / 33 KV RETHARE DHARAN
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.5624	.6093	.5144		.4167	.3749
2	.7202	.5556	.5556	.5596		.4744	.3887
3	.7122	.6167	.5624	.5596		.5218	.3749
4	.7202	.6019	.6019	.5658		.5761	.3749
5	.7716	.6562	.6481	.5665		.6167	.4858
6	.823	.7202	.6562	.6173		.6802	.4858
7	1.1317	1.2186	1.0911	.823		.7773	.5967
8	.8139	.9259	.8539	.7202		.7116	.6464
9	.8139	.6944	.6093	.5596		.5155	.547
10	.8259	.6802	.823	.5973		.1875	.4372
11	.5344		.7202	1.086	.2778	.8905	.5624
12	.5155	.583	.7122	1.1946	.7116	.7499	.4218
13	.6316	.5487	.7122	1.086	.7968	.703	.703
14	.9231	.5155	.6173	.9774	.8065	.6093	.5344
15	.5155	.7499	.6173	.8145	.759	.7287	.5344
16	.5155	.5624	.7202	1.3032	.8333	.7773	.5155
17	.3401	.3887	.4578	.8688	.6562	.6802	.583
18	.4167	.3795	.4115		.703	.5344	.4915
19	.5218	.6481	.5144	.2429	.5693	.4372	.6173
20	.5761	.5693	.6687		.6167	.2172	.6173
21	.5693	.5624	.6687		.5693	.2172	.5658
22	.5093	.5556	.6173		.5218	.2172	.5087
23	.5693	.6019	.5087		.463	.3258	.4578
24	.7202	.5155	.6019	.463		.3704	.3401
Max	1.1317	1.2186	1.0911	1.3032	.8333	.8905	.703
Min	.3401	.3795	.4115	.2429	.2778	.1875	.3401
Avg	.6630	.6266	.6483	.7431	.6373	.5390	.5069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18
HR	Load (MW)
9	.0171
10	.0171
14	.0171
15	.0171
16	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3944	.3772	.3772	.2401	.3429	.2743
2	.4115	.3772	.3601	.3772	.2229	.3258	.2572
3	.3944	.3772	.3601	.3429	.2229	.3258	.2572
4	.4115	.3601	.3601	.3429	.2229	.3086	.2572
5	.4287	.3944	.4115	.4115	.2401	.3601	.2572
6	.4801	.4287	.4801	.463	.2743	.4115	.3086
7	.5316	.5144	.5487	.4458	.3086	.4801	.3772
8	.5487	.4801	.5144	.4287	.3086	.5487	.3944
9	.5316	.5144	.4973	.4458	.2401	.5144	.3944
10	.5487	.5316	.4973	.4458		.5144	.4458
11	.5144	.4801	.463	.5316	.4973	.4287	.4458
12	.3944	.3772	.4458	.5144	.5144	.4801	.4458
13	.4115	.3601	.4115	.463	.4801	.4973	.4115
14	.3601	.4458	.463	.4458	.4115	.4801	.4115
15	.3772	.4115	.4458	.4973	.4115	.4801	.4115
16	.3944	.4287	.463	.5316	.4458	.4801	.4458
17	.4115	.463	.5487	.4973	.4458	.4801	
18	.4801	.5487	.583	.5144	.5487	.5144	.1715
19	.6173	.6859	.6344	.6173	.6001		.3429
20	.7545	.7545	.7716		.6859	.2572	.583
21	.6859	.6687	.6859		.6516		.5658
22	.6001	.583	.6173		.6001	.2058	.4801
23	.5144	.5144	.5144	.2915	.5144	.1715	.3944
24	.463	.4115	.4458	.4115	.2743	.3944	.3258
Max	.7545	.7545	.7716	.6173	.6859	.5487	.583
Min	.3601	.3601	.3601	.2915	.2229	.1715	.1715
Avg	.4873	.4794	.4958	.4475	.4070	.4092	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3258	.3086	.3086		.3086	.5486
2	.3429	.3086	.2915	.3086		.2915	.5144
3	.3258	.2915	.2915	.3086		.2743	.5144
4	.3429	.2915	.3086	.3086		.2743	.5144
5	.3429	.3429	.3429	.3429		.3086	.6172
6	.3944	.3944	.4115	.3944		.3772	.6172
7	.5487	.463	.463	.4801		.463	.4115
8	.5144	.4458	.463	.4287		.4801	.4458
9	.4801	.5144	.463	.3944		.4458	.463
10	.463	.463	.463	.4458	.2229	.463	.4458
11	.4801	.463	.5487	.4458	.6173	.5144	.4287
12	.4458	.463	.5144	.4115	.5144	.4801	.3772
13	.4115	.3944	.5144	.4287	.5144	.4458	.3772
14	.3772	.4458	.4458	.4973	.5144	.4115	.3772
15	.3429	.4115	.4801	.4801	.5316	.3944	.3429
16	.3601	.4458	.5316	.463	.4458	.4458	.3601
17	.463	.4458	.5487	.5144	.4458	.463	.4115
18	.3944	.3258	.4801	.4801	.4801	.463	.4287
19	.4973	.4115	.5487	.583	.5487	.5144	.4458
20	.6516	.6859	.6516	.5144	.6516	.6001	.5316
21	.5487	.6516	.583		.6001		.4801
22	.4973	.5316	.5144		.5487	.3772	.4115
23	.4115	.463	.4287	.3944	.4115	.3086	.3258
24	.4115	.3429	.3944	.3429		.3429	.5486
Max	.6516	.6859	.6516	.583	.6516	.6001	.6172
Min	.3258	.2915	.2915	.3086	.2229	.2743	.3258
Avg	.4330	.4301	.4580	.4217	.5034	.4108	.4558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0857	.0686	.0514	
2				.0857	.0686	.0686	
3				.0857	.0686	.0686	
4				.0857	.0686	.0686	
5				.1029	.0686	.0686	
6				.1543	.0686	.1029	
7				.2229	.0686	.1543	
8				.2401	.0686	.1715	
9	.0686	.2401	.2401	.2229	.0514	.1715	
10	.1029	.2401	.2572	.2058		.1372	
11	.12	.2572	.2058				.0343
12	.12	.2229	.2229				.0343
13	.2058	.2058	.2058				.0514
14	.1715	.2401	.2229				.0343
15	.1543	.2229	.2229				.0343
16	.1886	.2229	.2743				.0343
Max	.2058	.2572	.2743	.2401	.0686	.1715	.0514
Min	.0686	.2058	.2058	.0857	.0514	.0514	.0343
Avg	.1415	.2315	.2315	.1492	.0667	.1063	.0372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 33 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0669	.0823	.0926	.0772		.0823	.0977
2	.0669	.0823	.0926	.0772		.0823	.0977
3	.0669	.0823	.0926	.0823		.0823	.0977
4	.0669	.0823	.0926	.0823		.0823	.0977
5	.0669	.0874	.0977	.0874		.0823	.0977
6	.0669	.0926	.0977	.0977		.0874	.0977
7	.0669	.0977	.0977	.0977		.0977	.1029
8	.072	.0926	.0977	.0926		.0926	.1029
9	.072	.0874	.0977	.0977		.0977	.0977
10	.0669	.0977	.0926	.0977		.0874	.0977
11	.0669	.0977	.0926	.0926		.0874	.0926
12	.0669	.0977	.0926	.0926	.0823	.0772	.0926
13	.0669	.0977	.0926	.0977	.0874	.0823	.0977
14	.0669	.0977	.0977	.1029	.072	.0823	.1029
15	.0669	.0977	.0772	.1029	.0874	.0823	.1029
16	.0617	.0926	.0772	.0977	.0823	.0874	.1029
17	.0566	.0926	.0772	.1183	.0823	.0977	.0977
18	.0617	.0823	.0772	.0926	.0874	.0977	
19	.0617	.0874	.0823	.0926	.0823	.0977	
20	.0566	.0874	.0772		.0772	.1029	.0206
21	.0566	.0926	.0772		.0874		.072
22	.0566	.0926	.0772		.0823	.0977	.072
23	.0823	.0926	.0772		.0823	.0977	.072
24	.0926	.0823	.0926	.0772		.0823	.0977
Max	.0926	.0977	.0977	.1183	.0874	.1029	.1029
Min	.0566	.0823	.0772	.0772	.072	.0772	.0206
Avg	.0667	.0906	.0883	.0928	.0827	.0890	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 402 / 33 KV GUDE PACHGANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	2.1605	1.5432	1.0288		.6173	.4115
2	1.6461	2.2634	1.9547	.823		.6687	
3	1.749	1.9547	2.1605			.7202	
4	1.1831	1.749	2.8807			.7202	
5	1.2346	1.8519	1.749			.823	
6	1.0802	1.6461	2.1091			.7716	.2572
7	.7202	1.4403	1.6461			.7202	
8	.2572	1.3375	.823			.2058	.2058
9	.7202	1.3889	.5658	.3086			.2058
10	.9774	2.4177	.5144				.5144
11	1.749	2.9835	.3086	.2058			.823
12	1.4918	1.5432	.4115	.2058			
13	.3601	1.6975	.3086			.7202	
14	1.1317	1.5947	.823	.2058		1.1317	.3086
15	2.1605	.9774	1.2346	.2572	.2572	1.0288	.3086
16	2.5206	1.6461	1.3375	1.4918	1.4403	2.2119	.6173
17	2.8292	1.2346	2.572	1.9033	.3601	2.7263	2.2634
18	2.7778	.9259	2.4691	2.6749	.7202	2.8292	1.0288
19	2.5206	.7202	2.3663	2.0576	.823	1.0288	1.4403
20	2.6235	1.286	1.3375		1.1317	.5144	1.5432
21	2.8292	.9774	1.1317		1.0802		1.5432
22	1.749	.7716	1.5432		.6173		1.6461
23	2.4691	1.3375	1.749		.5144		1.1317
24	.7202	2.2119	1.2346	1.3375		.5658	.5144
Max	2.8292	2.9835	2.8807	2.6749	1.4403	2.8292	2.2634
Min	.2572	.7202	.3086	.2058	.2572	.2058	.2058
Avg	1.6182	1.5882	1.4489	1.0417	.7716	1.0591	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.1227	.0693	1.1603		.4096	
2	.1006	.1052	.0693	1.1603		.4096	
3	.1029	.1052	.0693	1.1603		.4049	
4	.1006	.104	.0693	1.1603		.421	
5		.104	.0693	1.2266		.4111	
6	.1174	.104	.0693	1.2929		.4167	
7	.1174	.1029	.1029	1.5424			
8	.1341	.1417	.1372	1.6095			
9	1.3435	1.7101	1.9227	1.4922			
10		1.6766	2.0222	1.3916			
11		1.8107	2.0222	.1006			.4694
12	1.4918	1.6933	1.989	.1509			.4862
13	1.4575	1.643	1.989	.1509	.5868		.4862
14	1.4746	1.6598	1.9559	.1341	.0671		.4862
15	1.5083	1.6095	1.8233	.1341	.0848		.4694
16	1.4255	1.643	1.7238	.1341	.1029		.4862
17	.1387	.1006	.1227	.1509	.0829		.4024
18	.1578	.12	.1402	.1341		.0949	
19	.1595	.1254	.1402	.1341	.0876	.0781	.0671
20	.1227	.0876	.1578		.1017	.061	.0671
21	.1227	.0857	.1402	.1341	.1017	.061	.0503
22	.124	.112	.104		.1006		.0503
23	.124	.0934	.0876		.0829	.0617	.0335
24	.1174	.1227	.0867	.0876		.0829	
Max	1.5083	1.8107	2.0222	1.6095	.5868	.421	.4862
Min	.1006	.0857	.0693	.0876	.0671	.061	.0335
Avg	.5028	.6326	.7118	.6972	.1399	.2427	.2962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3048	.2149	
2				.3048	.2103	
3				.3048	.2058	
4				.3048	.2229	
5				.3048	.2267	
6				.3353	.2408	
7				.4694		
8				.503		
9	.3048	.4115	.4572	.4024		
10		.4641	.4877	.3688		
11		.463	.4877			.2012
12	.3161	.4191	.4877	.0168		.1658
13	.2787	.4191	.4877	.0168		.1677
14	.3521	.3856	.4877			.1677
15	.381	.4024	.4877			.1677
16	.3418	.4527	.4572			.1677
17					.0168	.1174
18					.0156	.1341
19					.0162	
20					.0179	
Max	.381	.4641	.4877	.503	.2408	.2012
Min	.2787	.3856	.4572	.0168	.0156	.1174
Avg	.3291	.4272	.4801	.3030	.1388	.1612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1886	.1886	.1829	.1677	.1494	.1494
2	.1341	.1886	.1886	.1829	.1677	.1509	.1494
3	.1341	.1886	.1886	.1829	.1677	.1509	.1494
4	.1341	.1886	.1886	.1829	.1677	.1509	.1494
5	.2012	.1867	.1886	.1829	.1341	.1698	.1886
6	.1677	.2054	.2263	.2195	.1677	.2054	.1867
7	.2058	.2402	.1886	.2012	.1677		.1848
8	.2012	.2195	.1715	.2012	.1677		.1829
9	.1772	.1677	.1629	.1677	.1791		.1677
10	.1753	.1677	.1448	.1677	.2172		.1341
11		.1677	.1448	.1677			.1677
12	.1772	.1677	.1448	.1677		.0724	.1677
13	.1928	.1677	.1448	.1341	.1949	.0724	.1372
14	.197	.1677	.1448	.1677	.2254	.2172	.1677
15	.1629	.1677	.1448	.1677	.2149	.1829	.1341
16	.1578	.2012	.1448	.1677	.2353	.1791	.1341
17	.1715	.1677	.208	.1677	.1844	.208	.1715
18	.2204	.2347	.208	.1677		.2058	.1677
19	.2303	.2534	.2454	.1677	.2481	.2896	.1677
20	.2926	.2957	.2896		.2896	.2772	.2401
21	.2587	.2957	.2926	.1677	.2743	.2587	.2012
22	.2427	.2614	.2926	.1677	.2402		.1715
23	.2241	.2241	.2561	.1677	.2054	.2241	.1677
24	.1677	.2054	.2263	.2195	.1677	.168	.1867
Max	.2926	.2957	.2926	.2195	.2896	.2896	.2401
Min	.1341	.1677	.1448	.1341	.1341	.0724	.1341
Avg	.1896	.2050	.1969	.1770	.1993	.1852	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.0747	.0747	.0732	.0671	.0747	.056
2	.1006	.0754	.0747	.0732	.0671	.0747	.056
3	.1006	.0754	.0747	.0732	.0671	.0747	.056
4	.0671	.0754	.0747	.1829	.1006	.0739	.056
5	.0671	.0934	.0747	.0732	.0671	.0739	.0747
6	.1006	.112	.112	.1097	.1006	.0924	.0747
7	.1006	.0934	.1097	.0838	.1006		.0732
8	.0983	.0924	.0701	.0671	.1006		.0358
9	.1029	.1006	.0686	.1006	.0857		.0671
10	.1006	.0503	.0686	.1006			.1006
11	.1029	.1006	.0686	.1029			.0671
12	.0886	.1006	.0857	.1006	.0671	.0701	.0686
13	.0867	.1006	.0857	.1017	.0838	.0701	.1006
14	.1052	.1006	.1029	.1006	.0829	.0701	.1006
15	.1075	.1006	.1029	.1006	.096	.0686	.1006
16	.0848	.1006	.1052	.1006	.1311	.0838	.1006
17	.0655	.1006	.1029	.1006	.0949	.0663	.1006
18		.1134	.0857	.1006	.081	.064	.1006
19	.0709	.1052	.0857		.0663	.1254	.1006
20	.1097	.1448	.1402		.1387	.1267	.1341
21	.1109	.1478	.128	.1006	.1097	.1267	.1341
22	.0934	.1294	.1097	.1006	.1109	.0934	.1341
23	.0934	.1109	.0914	.1006	.0934	.0747	.1006
24	.1341	.0934	.0934	.0732	.1006	.0747	.0747
Max	.1341	.1478	.1402	.1829	.1387	.1267	.1341
Min	.0655	.0503	.0686	.0671	.0663	.064	.0358
Avg	.0953	.0997	.0913	.0964	.0915	.0831	.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4527		.056	
2	.4527	.5093	.4527		.056	
3	.4527	.5093	.5093		.056	
4	.4527	.5093	.5093		.0554	.0572
5	.4527	.5093	.5093		.0554	
6	.5144	.5093	.5093		.1663	
7	.5093	.5093	.5093	.2012		
8	.5093	.5093	.4527	.4024		.5093
9	.4527	.5093	.4527	.4572		.4527
10	.4527	.5093	.4527	.4572		.4527
11	.4527	.5093	.4527			.4527
12	.4527	.5093	.4527	.0514	.5144	.463
13	.4527	.5093	.4527	.3086	.5144	.4527
14	.4527	.5093	.4527	.0514	.5093	.4527
15	.4527	.5093	.4527	.0514	.5093	.4527
16	.4527	.5093	.4527	.0572	.5093	.4527
Max	.5144	.5093	.5093	.4572	.5144	.5093
Min	.4527	.4527	.4527	.0514	.0554	.0572
Avg	.4636	.5058	.4704	.2264	.2729	.4198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 402 / 33 KV MANGLE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3772
2				.3772
3				.4527
4				.4527
5				.5281
6				.5201
7				.5498
8				.5721
9				.7042
10				.6539
11				.0503
12			1.7147	.4527
13				.4527
14			1.8107	1.2071
15			1.8673	1.358
16				.4024
17			1.6004	.7042
18			1.5844	.6173
19			.5573	.8048
20			.535	.6539
21			.2623	.7545
22			.2675	.5944
23	1.5546		.2675	.7545
24		.6099		.2378
Max	1.5546	.6099	1.8673	1.358
Min	1.5546	.6099	.2623	.0503
Avg	1.5546	.6099	1.0467	.5930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	1.1271	1.5249	.0629	.0429	.0511	.3563
2	1.0526	1.1271	1.5592	.061	.0446	.0503	.3563
3	1.0402	1.1271	1.5592	.061	.0446	.0503	.3605
4	1.0402	1.1271	1.5592	.061	.0446	.0495	.3605
5	1.0722	1.1271	1.6108	.0676	.0452	.0503	.3563
6	1.1336	.9945	1.643	.0857	.0457	.0533	.3563
7	1.5083	1.2452	1.8778	.0857	.0429	.0823	.3812
8	1.4255	1.326	1.7404	.0667	.0429	.0667	.3932
9	.0657	.032	.0714	.0695	.0297	.0812	.3932
10	.024	.0572	.0846	.0714		.0823	.3113
11		.0286		1.9227	.8987	1.6575	.0372
12	.024	.0429		1.4922		1.1437	.0419
13	.024	.0429		2.1382	.7293	1.5912	.0404
14	.032	.0429		2.2298	1.2548	1.1142	.0389
15	.0343	.0429		2.2969	1.2071	1.1142	.0404
16	.032	.0572		2.146	1.0486	1.5083	.0381
17	.032	.0714	.076	1.9784		1.5581	.0476
18	.0358	.0857	.0533	1.7238	1.2266	1.4754	.0486
19	.0312	.0857	.1067	.0686	.0846	.0714	.0572
20	.0351	.0857	.1143	.0714	.0857	.0714	.0667
21	.0351	.0857	.1	.0714	.0834		.0648
22	.0351	.0743	.0823	.0667	.0686	.0572	.0629
23	1.1271	1.4754	.0777	.0549	.0533	.0429	.0457
24	1.0526	1.1271	1.5249	.0754	.0429	.0526	.0446
Max	1.5083	1.4754	1.8778	2.2969	1.2548	1.6575	.3932
Min	.024	.0286	.0533	.0549	.0297	.0429	.0372
Avg	.5194	.5266	.8537	.7095	.3413	.5250	.1792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1075	.0905	1.1336	.5868	.9717	.0354
2	.1227	.1075	.0914	1.1363	.5801	.9804	.0351
3	.1227	.1097	.0914	1.1363	.5801	.9804	.0351
4	.1227	.1052	.0914	1.1363	.5735	.9804	.0347
5	.1227	.1109	.0924	1.1363	.5898	.9488	.0347
6	.1433	.1109	.0914	1.4746	.6226	1.1523	.0347
7	.1791	.1402	.1463	1.8233	.6144	1.5238	.0362
8	.1612	.1417	.1463	1.6712	.7537	1.4089	.0354
9	1.9227	1.8233		1.4737	.6464	1.247	.0343
10	2.0222	1.9725		1.3763	.5921	1.1633	.0366
11		1.8564		.1097	.0886	.1187	.547
12	1.8442	1.8067	2.1548	.1448	.1526	.1187	.5735
13	1.8442	1.7404	2.1628	.1448	.1417	.1017	1.2616
14	1.7924	1.6907	2.1125	.1267	.1417	.1029	1.3927
15	1.7924	1.6409	1.8399	.1267	.1134	.0867	1.2929
16	1.5364	1.5581	1.6842	.1267	.1492	.1214	1.4089
17	.1341	.1387	.1492	.0686	.1475	.1187	1.1385
18	.1357	.108	.1595	.0693	.1578	.1187	1.0311
19	.1387	.1433	.156	.052	.1417	.1341	.1753
20	.1433		.1629	.0701	.1448	.1187	.1463
21	.1433	.1433	.1629	.0701	.1267		.1254
22	.0716	.1254	.1433	.0686	.0905		.1267
23	.1075	.1254	.1448	.0509	.128	.0514	.1086
24	.1433	.1075	.1086	.1433	.0509	.1086	.0354
Max	2.0222	1.9725	2.1628	1.8233	.7537	1.5238	1.4089
Min	.0716	.1052	.0905	.0509	.0509	.0514	.0343
Avg	.6465	.6919	.5706	.6196	.3298	.5753	.4048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.3841	.4111	.0305		.0309	
2	.4111	.4024	.4111	.0305		.0305	
3	.4111	.4207	.4049	.0305		.0305	
4	.4111	.4207	.4001	.0305		.0305	
5	.4111	.4344	.4321	.0312		.0469	
6	.4321	.4344	.4801	.0648		.0633	
7	.5693	.4374	.5535	.0633		.0625	
8	.5376	.4374	.5535	.0474		.0617	
9	.061	.0442	.0372	.061		.061	
10	.0343	.0495	.0633	.061		.0625	.2949
11	.0343	.0495	.0474	.5693		.5312	
12	.0274	.0495	.0446	.6009		.506	.032
13	.0274	.0389	.044	.6325		.506	
14	.0274	.0389	.0457	.6167		.5693	.0579
15	.0269	.0518	.0457	.6167		.1526	.044
16	.0269	.0533	.044	.6009		.5624	.044
17	.0404	.0572	.0602	.5535	.4744	.5468	.0452
18	.0381	.0572	.061	.5761	.4428	.4999	.0446
19	.0465	.0572	.061	.0572	.0791	.0572	.0602
20	.0533	.0594	.08	.0572	.0791		.0474
21	.0533	.0594	.064		.0633		.0463
22	.0667	.0572	.0633		.0633		.0305
23	.3841	.3637	.0617		.0474		.0301
24	.4321	.3841	.3953	.0305		.0309	
Max	.5693	.4374	.5535	.6325	.4744	.5693	.2949
Min	.0269	.0389	.0372	.0305	.0474	.0305	.0301
Avg	.2073	.2018	.2027	.2553	.1785	.2221	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1478	.1629	.1848	.1463	.168	.0549
2	.1663	.1478	.1646	.1848	.1463	.168	.0543
3	.1663	.1478	.1463	.1848	.1478	.168	.0543
4	.1663	.1463	.1463	.1848	.1478	.168	.0537
5	.1646	.1463	.1663	.1991	.1463	.2012	.0537
6	.1829	.1463	.181	.2172	.1829	.2378	.0686
7	.2103	.208	.2353	.2279	.2172	.2481	.0701
8	.2058	.2035	.2103	.2279	.1753	.208	.0686
9	.1715	.1989	.1886	.2035	.1543	.1715	.0678
10	.1311	.1844	.1734	.1696	.1715	.1217	.1734
11	.1311	.1638	.1715	.1509	.1492	.1543	.1865
12	.0743	.1638	.1677	.1509	.1638	.1006	.1715
13	.0743	.1619	.1696	.1677	.1357	.1677	.1387
14	.128	.1457	.1696	.1526	.1433	.1357	.1402
15	.128	.1296	.1543	.1357	.1402		.1214
16	.128	.1638	.0995	.1357	.1357	.1696	.1372
17	.1296	.1638	.0949	.1696	.1341	.1696	.12
18	.1341	.1638	.1943	.1865	.1638	.1696	.1886
19	.1943	.2328	.2058	.2103	.2279	.2279	.1928
20	.2172	.2896	.3224	.2195	.2534		.2686
21	.2172	.2534	.3077	.2195	.2743		.2378
22	.1478	.2353	.2587	.181	.2378		.2195
23	.1478	.1991	.2218	.181	.1867	.0503	.1509
24	.1698	.1478	.1629	.1848	.1478	.168	.056
Max	.2172	.2896	.3224	.2279	.2743	.2481	.2686
Min	.0743	.1296	.0949	.1357	.1341	.0503	.0537
Avg	.1564	.1788	.1865	.1846	.1721	.1687	.1270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2896	.2743	.2172	.1867	.2054	.1663
2	.2195	.2896	.2587	.2172	.1867	.2054	.1663
3	.2195	.2896	.2587	.2172	.1848	.2054	.1646
4	.2195	.2896	.2587	.2172	.1848	.2054	.1646
5	.2195	.2987	.2743	.2561	.2195	.2054	.1629
6	.3292	.2987	.2957	.3077	.2534	.2614	.1928
7	.362	.2835	.2715	.3012	.2534	.2587	.2172
8	.3189	.2804	.3292	.3506	.2454	.2481	.1928
9	.2947	.2713	.3696	.3086	.2743	.2427	.1715
10	.2058	.2713	.2915	.2462		.2103	.2126
11		.2543		.2652	.2883	.2401	.2481
12	.2804	.218		.2347		.2229	.208
13	.2103	.2374		.285	.2743	.2058	.2254
14	.2103	.2204		.2713	.2804	.2254	
15	.2103	.2347		.2883	.2804	.2572	.2254
16	.2683	.2515		.2883	.2155	.2401	.2543
17	.2622	.2713	.3605	.3561		.2713	.2949
18	.2713	.2947	.2753	.3258	.2949	.2683	.2883
19	.3467	.2926	.426	.3761	.3582	.3391	.333
20	.439	.439	.5316	.3258	.4344	.2543	.4024
21	.439	.3841	.4784	.2896	.3696	.2279	.3361
22	.2896	.3475	.4525	.2353	.3326	.1991	.2987
23	.2896	.2926	.3292	.2172	.2614	.181	.2241
24	.2587	.2896	.2743	.2172	.1867	.2054	.1646
Max	.439	.439	.5316	.3761	.4344	.3391	.4024
Min	.2058	.218	.2587	.2172	.1848	.181	.1629
Avg	.2777	.2871	.3339	.2756	.2650	.2328	.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1486	.1814	.2241	.1257	.1303	.0953	.1303
2	.1486	.1814	.2241	.1236	.1303	.0953	.1143
3	.1463	.1734	.2218	.1236	.132	.0953	.1143
4	.1463	.1734	.2218	.1257	.132	.0934	.1158
5	.1417	.1734	.2402	.1257	.1486	.0934	.1286
6	.2225	.1734	.2957	.168	.1738	.1627	.1252
7	.2675	.2538	.3475	.2606	.2286	.2366	.2286
8	.2225	.2538	.2896	.2462	.2195	.1867	.2195
9	.2229	.1829	.3475	.2027	.2378	.2397	.2
10	.2134	.2686	.2256	.2229	.168	.2	.2115
11		.2507	.2397	.1656	.176	.1715	.1509
12	.2926	.2103	.25	.2	.1802	.1715	.2
13	.2195	.2126	.2214	.2	.2372	.1715	.1578
14	.1829	.1949	.208	.1738	.1334	.1593	.1299
15	.1829	.2126	.1833	.1783	.1334	.1715	.0953
16	.2534	.1949	.1882	.2	.1334	.1269	.1174
17	.2241	.1949	.208	.1783	.1353	.1429	.1372
18	.2134	.2328	.2372	.1858	.1429	.1429	.1907
19	.2675	.2926	.2932	.192	.2	.2143	.2115
20	.3064	.4435	.3807	.2715	.2481		.2553
21	.3064	.4066	.3525	.2143	.2808		.2023
22	.2378	.3921	.3338	.1882	.2515	.2286	.1768
23	.2378	.3361	.1707	.1448	.1547	.1572	.1111
24	.1814	.1814	.2218	.1349	.1286	.1288	.1303
Max	.3064	.4435	.3807	.2715	.2808	.2397	.2553
Min	.1417	.1734	.1707	.1236	.1286	.0934	.0953
Avg	.2168	.2405	.2553	.1813	.1765	.1584	.1606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 401 / 33 KV SUZLON

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	4.5268	4.369	2.7726	1.2323	2.2634	.168
2	4.4136	4.4136	4.201	3.0556	1.0082	2.0936	.112
3	5.6584	5.6584	4.481	.1132	.168	2.2634	.112
4	6.3375	6.3375	3.6408	.1132	1.0082	1.9805	.112
5	5.9414	5.9414	3.9209	.1132	.8962	1.7541	.112
6	6.1111	5.998	1.7924	.1132	.9522	1.1317	.2801
7	4.9228	2.999	1.5684	.1132	1.5123	1.0185	.112
8	3.3951	2.32	.6722	.1132	.112	.1132	.112
9	5.0926	3.0556	.4481	.1132	.6722	.1132	.112
10	7.1296	4.537	.2263	.112	.7922	.112	1.2449
11		3.9209	.1132	.112	.1132	.112	.679
12		4.145	.9619	.112	.1132	.112	.1132
13		3.1367	.8488	.112	.1132	.3921	.1132
14		2.8006	.679	.112	.1132	1.9044	.1132
15		2.5206	1.358	1.0082	1.4146	3.9209	.2829
16	6.2243	1.5684	2.9424	3.3048	3.0556	5.0297	1.6975
17	6.6204	2.1285	5.7716	4.6491	3.1121	6.0494	1.1883
18	5.1492	1.5684	6.3375	6.1614	4.357	6.3855	2.3765
19	6.0545	1.9605	5.9414	5.3772	6.7901	3.0247	3.7346
20	5.7716	3.1927	3.7346		4.6399	.168	2.5463
21	6.0545	3.2487	1.8673		2.4897	.2241	4.6399
22	6.6204	5.1532	4.0741	1.6804	1.6975	.112	3.5082
23	7.1862	4.8731	4.5833	2.6886	1.8673	.168	2.1502
24	.679	6.5072	4.537		2.5766	1.358	.168
Max	7.1862	6.5072	6.3375	6.1614	6.7901	6.3855	4.6399
Min	.679	1.5684	.1132	.112	.112	.112	.112
Avg	5.4678	3.8547	2.8779	1.5262	1.7003	1.7419	1.0745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.2454	.2601	.2743	.2229	.2401	
2	.2427	.2427	.2774	.2401	.2058	.2427	
3	.2601	.2279	.2601	.2401	.2229	.2401	
4	.2601	.2103	.2774	.2401	.2204	.2427	
5	.2774	.208	.2774	.2401	.2401	.2427	
6	.2774	.2454	.2947	.2401	.2572	.2774	
7	.2947	.2427	.3121	.3086	.2572	.2601	
8	.2947	.2601	.2947	.2743	.2572	.2774	
9	.2804	.2601	.2427	.2572	.2401	.2774	
10	.2774	.2427	.2774	.2683	.2572	.2427	
11	.2629	.2774	.3467	.2683		.2774	
12	.2601	.2947	.3121	.2818	.2572	.2774	.2601
13	.2629	.2774	.3121	.2652	.2572	.2774	.2427
14	.2427	.2947	.3467	.285		.2774	.2601
15	.2481	.3121	.3467	.285	.2915	.3121	.2601
16	.2774	.2947		.3052	.3086	.3467	.2601
17	.3155	.3467	.4287			.3121	.2774
18	.3391	.3467	.4115	.373	.3772	.3121	.2743
19	.3772	.3988	.4458	.39	.4115	.3814	.3086
20	.4409	.4854	.4801		.4115	.3467	.3429
21	.4161	.4508	.4458		.3772		.3641
22	.3856	.3856	.4115	.3206	.3429		.3294
23	.3189	.3294	.3429	.2543	.2401		.2947
24	.3121	.2774	.2774		.2401	.2572	
Max	.4409	.4854	.4801	.39	.4115	.3814	.3641
Min	.2427	.208	.2427	.2401	.2058	.2401	.2427
Avg	.3001	.2982	.334	.2806	.2808	.2820	.2895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0332	.0358	1.2178		.5144	
2	.0343	.0335	.0358	1.2894		.4858	
3	.0366	.0328	.0354	1.3394		.4534	
4	.037	.032	.0354	1.448		.4858	
5	.0358	.032	.0358	1.5043		.5182	
6	.0351	.0332	.0354	1.6476		.5992	
7	.037	.0328	.0358	1.8031		.6964	
8	.037	.032	.0358	1.8778		.583	
9	1.6907	1.7532	1.8778	1.8519		.6316	
10	1.8442	1.8187	1.9784	1.4737		.583	
11	1.8991	1.6876	1.8299			.0171	
12	1.8778	1.704	2.0243				
13	1.757	1.6876	1.8138		.0332		
14	1.7436	1.6194	1.9433			.0171	.6722
15	1.7072	1.587	1.9433		.0335	.0857	.6401
16	1.6933	1.5708			.0339	.0343	
17	.037	.0324	.0351				
18	.0328	.0324	.0179		.0339	.0175	
19	.0474	.0328	.0366	.0347	.0339	.0179	.0366
20	.0503	.0328	.0362		.0343	.0181	.0377
21	.0497	.0328	.0181		.0343		.0373
22	.0164	.0324	.0181		.0324		.0377
23	.032	.0358	.0183		.0343		.037
24	.0351	.0339	.0358	.0183		.0343	
Max	1.8991	1.8187	2.0243	1.8778	.0343	.6964	.6722
Min	.0164	.032	.0179	.0183	.0324	.0171	.0366
Avg	.6167	.5815	.6049	1.2922	.0337	.3218	.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0168	.0166	.5506	.0164	.1134	.0158
2	.0166	.0166	.0166	.583	.016	.1296	.0158
3	.0164	.0164	.0166	.583	.0162	.1296	.0158
4	.0166	.016	.0166	.583	.0162	.1134	.0158
5	.0166	.0158	.0166	.6081	.016	.1134	.0158
6	.0166	.0166	.0166	.6401	.2343	.1423	.0158
7	.0166	.0164	.0166	.7042	.2881	.2056	.0158
8	.0166	.0166	.0166	.7362	.25	.2214	.0158
9	.7209	.7956	.8951	.6874	.2343	.2214	
10	.7293		.9945	.6097	.2187	.1581	
11	.78	.8453	.9945	.0154		.0158	
12	.788	.8453	1.0277	.016	.0156	.0158	.253
13	.7625	.8288	.9945	.016	.0156	.0158	.253
14	.7537	.8288	.9116	.016		.0158	.2315
15	.7293	.8453	.8951	.016	.0156	.0158	.1829
16	.7045	.8288		.016	.0166	.0158	.1486
17	.0316	.0166	.0166	.016		.0158	.1738
18	.0332	.0166	.0166	.016	.016	.0158	.1974
19	.0339	.0166	.0166	.016	.016	.0158	.0152
20	.0164	.0166	.0166		.0162	.0158	.0152
21	.0168	.0166	.0332		.0166	.0158	.0158
22	.0166	.0166	.0166	.016	.0166	.0158	.0158
23	.0164	.0166	.0166	.016	.0162	.0158	.0158
24	.0154	.017	.0166	.0166	.016	.0162	.0158
Max	.788	.8453	1.0277	.7362	.2881	.2214	.253
Min	.0154	.0158	.0166	.0154	.0156	.0158	.0152
Avg	.2617	.2644	.3041	.2944	.0706	.0737	.0791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0774	1.0159	1.2071	.1006	.0671	.0663	.3932
2	1.0364	1.0277	1.1736	.0671	.0663	.0663	.3605
3	1.0486	1.0395	1.1736	.0671	.0663	.0663	.3277
4	1.0774	1.0486	1.2071	.0671	.0678	.0663	.3277
5	1.1065	1.1271	1.2407	.1006	.0671	.0663	.3277
6	1.3748	1.2209	1.2742	.1006	.0671	.0671	.3277
7	1.4586	1.3108	1.576	.1006	.0671	.0671	.3277
8	1.5089	1.3435	1.4419	.1006	.0671	.0671	.3932
9	.0678	.0671	.1006	.1075	.0678	.0671	.4096
10	.1017	.0671	.1006	.112	.0678	.0671	.3932
11		.0671	.1006	2.3777		1.1401	.0655
12		.0671	.1006	2.2977	.6783	1.3413	.0655
13	.0995	.0671			.6104	1.3077	
14	.064	.0671		2.1026		1.2929	
15	.0655	.0671		2.0622	.5426	1.2929	
16	.1006	.1006		2.0454	.57	1.2929	.0655
17	.1017	.1006				1.1603	.0655
18	.0332	.1006		1.7551	.8619	1.0277	.0655
19	.1296	.1006	.1006	.112	.0663	.0663	.0663
20	.1311	.1006	.1006		.0663	.0663	.0655
21	.0995	.1006	.1006		.0663	.0663	.0655
22	.1006	.1006	.1006	.1006	.0663	.0995	.0655
23	1.153	1.2742	.1006	.0983	.0663	.0995	.0655
24	1.0898	1.073	1.2742	.1006	.0983	.0663	.0995
Max	1.5089	1.3435	1.576	2.3777	.8619	1.3413	.4096
Min	.0332	.0671	.1006	.0671	.0663	.0663	.0655
Avg	.5921	.5273	.6930	.6988	.2078	.4578	.2068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.1097	.112	.1307		.1132	.112
2	.0686	.0924	.1132	.1132		.1132	.0934
3	.0895	.0895	.112	.1132		.112	.0934
4	.0914	.1307	.1109	.1132		.1029	.0934
5	.1307	.1509		.1307		.1307	.1109
6	.1227	.1646	.1509	.1663		.1698	.1629
7	.1448	.1402	.1478	.1595		.1402	.1543
8	.1402	.12	.1326	.12		.1357	.1578
9	.1543	.1326	.1638	.1267			.156
10	.1387	.1311	.1677	.1341		.1357	.144
11	.124	.144	.1357	.1372		.1475	
12	.1097	.116	.1509	.1475			
13	.104	.1006	.0949	.112	.1791		
14	.1029	.0857	.124	.1052		.1658	.1526
15	.0747	.0709	.1254	.12	.1254	.1696	.1296
16	.1097	.1254		.1372	.1753	.1543	.1492
17	.112	.1463	.1663				.1094
18	.1097	.1296	.1562	.1457	.2229	.1852	.0983
19	.1494	.1543	.1753	.1658	.2035		.1372
20	.2195	.2012	.2103		.1753	.1753	.1629
21	.2402	.2035	.197		.1753	.181	.1829
22	.1949	.1848	.181		.1612	.1448	.1663
23	.1463	.1494	.1478		.1294	.128	.1267
24	.1294	.1132	.1109	.1307		.1132	.1294
Max	.2402	.2035	.2103	.1663	.2229	.1852	.1829
Min	.0686	.0709	.0949	.1052	.1254	.1029	.0934
Avg	.1290	.1328	.1448	.1320	.1719	.1431	.1344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0693	.1595	.1595	.0381	.0343	.0358
4	.2254	.1595	.1595	.0381	.0343	.0358
5	.2254	.1595	.1595	.0381	.0343	.0358
6	.2254	.1595	.1595	.0381	.0343	.0895
7	.2254	.1595	.2254	.0381	.0686	.0895
8	.2254	.1595	.2229	.0381	.0686	.0754
9	.2229	.2229	.2229	.0381	.0914	.0566
10	.2229	.2254	.2204	.0381	.0914	.0566
11	.2229	.2279	.2229		.0905	.056
12	.2229	.2229	.2254	.0381	.0895	.0566
13	.2229	.2229	.2254	.0381	.0886	.0566
14	.2229	.2204	.2254		.0895	.0572
15	.2229	.2204	.2229	.0381	.0914	.0572
16	.2229		.2204	.0381	.0895	.0381
17	.2229	.218			.0905	.0381
18	.2229	.2229	.208	.0381	.0905	.0381
Max	.2254	.2279	.2254	.0381	.0914	.0895
Min	.0693	.1595	.1595	.0381	.0343	.0358
Avg	.2141	.1974	.2053	.0381	.0736	.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6099	.6099		.0566
2	.6099	.6099	.6099		.0566
3	.6099	.6099	.6099		.0566
4	.6099	.6099	.6099		.0566
5	.6099	.6099	.6099		.0566
6	.6099	.6099	.6653		.0566
7	.6161	.6099	.6516		.0566
8	.6099	.6099	.6516	.1143	.0566
9	.6584	.6653	.6516	.1132	.0566
10	.6584	.6653	.6584		.0566
11	.6653	.6653	.1086		.0566
12	.6653	.6653	.6516	.1132	.112
13	.6653	.6653	.6516	.1132	.1132
14	.6653	.6099	.6516	.1132	.1132
15	.6653	.6161	.6516	.1132	.1132
16	.1109	.112	.1086	.1132	.1132
Max	.6653	.6653	.6653	.1143	.1132
Min	.1109	.112	.1086	.1132	.0566
Avg	.6025	.5965	.5720	.1134	.0742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0278	.0343	.0335	.2115	.125	.1406	
2	.0274	.0347	.0332	.2086	.1219	.1406	
3	.0267	.0351	.0332	.192	.1219	.144	
4	.0282	.0343	.0328	.23	.1204	.1875	
5	.0297	.0335	.0328	.2667	.1337	.253	
6	.0248	.0332	.0332	.3161	.1783	.3681	
7	.0255	.032	.0324		.3048	.5121	
8	.024	.0309	.0312	.4687	.3241	.4999	
9	.1852	.2372	.5801		.3593	.5601	
10	.1698	.2343	.6327		.3125		.0347
11	.1698	.2343	.6722	.0335	.0324	.0309	.125
12	.1524	.2721	.6718	.0339	.0305	.0316	.1235
13	.1524	.2458	.6802	.0335	.0312	.032	.1235
14	.1355	.3005	.7209	.0328	.0316	.0328	.0914
15	.1219	.3041	.6093	.032	.0312	.0335	.0926
16		.25	.5992	.0328	.0312	.0309	.0914
17		.0324	.0297	.0324	.0328	.0351	.0625
18		.0301	.0274	.0324	.0328	.0347	.032
19		.0343	.029	.0324	.0332	.0358	.032
20	.0351	.0339	.0305	.0305	.032	.0362	.032
21		.0343	.0312	.0305	.0312	.0351	.0316
22	.0351	.0347	.0297	.0312	.0305	.0354	.0312
23	.0347	.0343	.0312	.0324	.0301		.0316
24	.0293	.0343	.0339	.0297	.032	.0305	
Max	.1852	.3041	.7209	.4687	.3593	.5601	.125
Min	.024	.0301	.0274	.0297	.0301	.0305	.0312
Avg	.0755	.1089	.2363	.1116	.1060	.1473	.0668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.1829	.1867	.1753	.1478	.1867	.1543
2	.0819	.1848	.1867	.1629	.1478	.1867	.1433
3	.0772	.1848	.0373	.156	.1494	.1867	.1311
4	.0762	.2012	.1867	.1543	.1494	.1867	.1296
5	.104	.2195	.2241	.1991	.1663	.2033	.1265
6	.1294	.2534	.2587	.2126	.1646	.2218	.1823
7	.1227	.2279	.2534	.2149	.1772	.2353	.2195
8	.1134	.2347	.2279	.1823	.1715	.2328	.197
9	.1214	.218	.2229	.2204	.1619	.2279	.1734
10	.1017	.213	.2218	.2035	.1638	.2543	.1734
11	.1006	.1823	.2279	.1677	.1658	.2229	.1696
12	.0857	.2012	.2534	.2035	.1638	.2103	.1578
13	.0867	.1966	.2401	.2012	.1619	.1991	.1612
14	.0895	.2035	.2149	.218	.2103	.2058	.1715
15	.0886	.2347	.2481	.2204	.2229	.2172	.1844
16		.2321	.2629	.1823	.2229	.2279	.1943
17		.2915	.2572	.2012	.176	.2481	.218
18		.2321	.2601	.2035	.1989	.208	.2204
19	.0886	.2058	.2401	.2229	.2058	.2401	.2401
20	.3366	.333	.333	.2804	.3045	.298	.2658
21		.3224	.2915		.2896	.2534	.2534
22	.2896	.2896	.2804	.2587	.2743	.2149	.2195
23	.2561	.2402	.2058		.2402	.1772	.2033
24	.0781	.2012	.2033	.1848	.168	.1848	.156
Max	.3366	.333	.333	.2804	.3045	.298	.2658
Min	.0762	.1823	.0373	.1543	.1478	.1772	.1265
Avg	.1254	.2286	.2302	.2012	.1919	.2179	.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1886	.1886	.1715	.1886	.1886	.1734
2	.1772	.1698	.1886	.1772	.1698	.1886	.1772
3	.1715	.1698		.1753	.1698	.1886	.1753
4	.1791	.1886	.1886	.181	.1886	.2075	.1715
5	.2534	.2075	.2263	.2328	.2075	.2241	.1949
6	.2427	.2263	.2614	.2534	.2263	.2614	.2149
7	.2195	.2427	.2378	.2058	.2241	.2033	.2058
8	.2033	.2195	.2172	.2353	.0373	.2012	.2103
9	.197	.2172	.2126	.1928	.2012	.1734	.1753
10	.1772	.1715	.2033	.208	.181	.1791	.1578
11	.1772	.1928	.1907	.2254	.197	.1886	.1372
12	.197	.1928	.1715	.2058	.1753	.1734	.1578
13	.197	.1928	.1753	.2058	.1715	.1753	.1791
14	.1991	.1991	.1772	.218	.1829	.1734	.1753
15	.1991	.197	.2601	.2204	.181	.1753	.1865
16	.1791	.2328	.2103	.208	.2149	.1886	.1802
17	.1417	.2103	.2126	.1907	.1372	.2172	.1989
18	.1753	.1949	.2149	.2126	.1734	.1753	.2103
19	.2328	.2507	.2601	.2195	.2149	.2126	.2353
20	.3142	.3109	.3045	.2926	.2743	.2743	.2715
21	.2772	.2957	.3077	.2614	.2587	.2507	.2587
22	.2427	.2987	.2572	.2263	.2427	.2353	.2427
23	.2054	.2614	.2263	.2075	.2241	.2149	.2075
24	.1928	.1867	.2054		.1886	.2054	.1715
Max	.3142	.3109	.3077	.2926	.2743	.2743	.2715
Min	.1417	.1698	.1715	.1715	.0373	.1734	.1372
Avg	.2053	.2174	.2217	.2142	.1929	.2032	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 204 / 11KV DATT LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307			
2		.1307			
3		.1307			
4		.1307			
5		.1307			
6		.1307			
7		.1307			
8		.1307	.0566	.1307	.0754
9		.1307	.0566	.1307	.0754
10		.1307	.0566	.1307	.0754
11		.1307	.0566	.1307	.0754
12		.1294	.1307	.1307	.0754
13		.1307	.1294	.1307	.0754
14		.1307	.1294	.1307	.0754
15	.1307	.1307	.1294	.1307	.0747
16	.1307	.1307	.1294	.1307	.0747
Max	.1307	.1307	.1307	.1307	.0754
Min	.1307	.1294	.0566	.1307	.0747
Avg	.1307	.1306	.0972	.1307	.0752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1097	.1132	.1658		.1372	.0732
2	.1132	.0924	.1132	.2012		.1524	.0732
3	.0943	.0914	.1132	.1989		.1524	.0739
4	.0943	.1097	.1509	.1638		.1524	.0747
5	.0943	.1294	.1509	.1658		.1524	.112
6	.132	.1478	.1698	.2035		.1677	.1097
7	.1886	.1646	.1307	.2743		.1829	.1509
8	.1886	.1097	.168	.2321		.1981	.112
9	.1677	.1406	.1844	.1907		.1829	.1097
10	.1829	.128	.1781	.1562		.125	.0924
11	.1219	.16	.1823	.1097			.1475
12		.176	.1718	.1097		.1097	.1475
13	.1219	.176	.1802	.1097	.0943	.1097	.1943
14	.1219	.1781	.1966	.128		.1097	.128
15	.1562	.1781	.2	.128	.0377	.128	.1852
16	.1562	.1781	.1802	.128	.0377		.1806
17		.1494	.1063	.1294		.128	.1235
18	.1463	.1494	.1063	.1097	.1509	.1109	.128
19	.1646	.2241	.1433	.1478	.1886	.1646	.1311
20	.2012	.2241	.1448	.128	.1886	.1478	.1886
21	.1829	.2263	.1829	.1097	.1886	.1494	.1698
22	.1829	.2075	.1848		.1509	.112	.1132
23	.1109	.1132	.112		.1132	.112	.0943
24	.1132	.1097	.132	.1132		.1132	.0732
Max	.2012	.2263	.2	.2743	.1886	.1981	.1943
Min	.0943	.0914	.1063	.1097	.0377	.1097	.0732
Avg	.1431	.1531	.1540	.1547	.1278	.1408	.1244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	2.0348	1.9784	.1006	.0848	.0857	1.4243
2	1.9204	2.0119	1.9784	.1017	.0838	.0857	1.4243
3	1.9204	2.0517	1.9784	.0838	.0848	.0857	1.4083
4	1.9204	2.0287	1.9784	.0829	.1006	.1029	1.3916
5	1.9204	2.0856	2.0119	.0983	.1017	.1029	1.3757
6	1.9845	2.1365	2.0957	.1107	.1187	.1372	1.3904
7	2.13	2.3061	2.1293	.1311	.1187	.1372	1.3565
8	2.1628	2.3061	2.1125	.1578	.1017	.0857	1.3056
9	.12	.1187	.1357	.1029	.1187	.0857	.9326
10	.12	.116	.12	.1147	.0857	.1017	1.1437
11	.1017	.1174	.0867	2.3371	2.2939	2.3739	.081
12	.1029	.1017	.116	2.2775	2.3266	2.452	.0594
13	.1029	.1029	.1029	2.0972	2.4577	2.4863	.0734
14	.0857	.12	.1017	2.4806		2.4926	.0819
15	.0857	.1357	.1029	2.5692	2.7199	2.4926	.0762
16	.1372	.1526	.1214	2.4086	2.6543	2.452	.0846
17	.1372	.1357	.1296	2.343	2.6216	2.3739	.0903
18	.1372	.1029	.1341	2.2939	2.5232	2.1195	.0892
19	.1357	.1029	.1357	.1017	.1029	.1029	.0937
20	.12	.12	.1029	.0848	.1029	.1017	.0781
21	.1017	.12	.104	.0678	.1029	.1029	.1372
22	.1017	.12	.1029	.0678	.1029	.0848	.0926
23	1.9006	1.8652	.1006	.1017	.1029	.0848	.0762
24	2.0165	1.989	2.0119	.0995	.0848	.1029	.0678
Max	2.1628	2.3061	2.1293	2.5692	2.7199	2.4926	1.4243
Min	.0857	.1017	.0867	.0678	.0838	.0848	.0594
Avg	.8911	.9368	.8322	.8506	.8346	.8681	.5973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.5281	1.3203	1.1694	1.0751	1.1317	1.226
2	1.1317	.4904	1.3203	1.1317	1.0751	1.1317	1.0751
3	1.1317	.4527	1.2826	1.1317	1.0562	1.1317	1.0185
4	1.1317	.4527	.7922	1.1317	1.0185	1.1317	1.0185
5	1.1317	.4338	.8676	1.0185		1.1317	1.0185
6	1.1317	.3961	.8488	.6979	1.0185	1.0185	.9431
7	.8488	.547	1.1317	.8299	1.0751	.9054	1.0374
8	.679	.5658	.5847	1.1317	.4527	.5658	1.0562
9	.9054	.6413	.5847	.6413	.679	.5093	.415
10	.4715	.9431	.7922	.7733	.7922	.547	.6979
11	.5281	.9431	.7922	.7545	.8488	.6979	.8215
12	.5093	.9431	.6979	.7545	.811	.811	.6722
13	.4904	.9054	.7167	.7167	.7545	.811	.6653
14	.4904	.811	.7922	.8676		.7922	.6722
15	.5847	.7545	.8488	.6413	.7356	.6413	.7095
16	.4338	.7356	.8488	.7733	.679	.2263	.6413
17	.4527	.7545	.8299	.7167	.679	.2075	.5658
18	.3772	.7922	.6722	.6413	.679	.4904	.5847
19	.3772	.7922	.6602	.7356	.679	.5281	.6036
20	.415	.7922	.7545	.6602	.6413	.5281	.6224
21	.547	.8676	.8676	.6036	.6979	.5658	.7167
22	.5658	.9054	.9054	.8865	1.1317	.811	.679
23	.5281	1.094	1.3443	1.1694	1.0562	1.0374	.5658
24	1.1317	.5658	1.2637	1.226	1.1317	1.0562	1.0751
Max	1.1317	1.094	1.3443	1.226	1.1317	1.1317	1.226
Min	.3772	.3961	.5847	.6036	.4527	.2075	.415
Avg	.7136	.7128	.8966	.8668	.8531	.7670	.7959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0926	.1677	.0173	.0164	.0168	.0903
2	.0983	.108	.1696	.0173	.0166	.0171	.0914
3	.0972	.1094	.1715	.0175	.0166	.0171	.1067
4	.0972	.1094	.1715	.0175	.0164	.0171	.1235
5	.1147	.1406	.1886	.0179	.0164	.0183	.125
6	.1619	.1543	.2058	.0179	.0166	.0183	.1423
7	.1844	.2006	.2374	.0185	.0166	.0183	.1094
8	.1844	.2347	.2652	.0185	.0332	.0183	.108
9	.0151	.0181	.0183	.0185	.0168	.0183	.0781
10	.016	.0181	.0173	.0183	.0168	.0158	.0743
11	.016	.0181	.0189	.4641	.3241	.6783	.0173
12		.0183		.4973	.3549	.788	.0166
13		.0171	.0187	.5304	.3479	.7545	.016
14		.0171	.0177	.4096	.3812	.788	.0156
15		.017	.0179	.5735	.3978	.7042	.0158
16		.0166	.0179	.5601	.4024	.6133	.0158
17		.0171	.0179	.506	.3481	.583	.0156
18	.017	.0156	.0156	.427	.3521	.4481	.017
19	.0179	.0181	.0164	.0162	.0181	.0166	.0162
20	.0168	.0185	.0168		.0166	.0164	.0164
21	.0168	.0183	.017	.0164	.0166	.0187	.0166
22	.0168	.0185	.0164	.0162	.0166	.0185	.0168
23	.096	.1844	.0171	.0164	.0166		.0168
24	.0983	.0926	.1677	.0171	.0162	.0168	.0173
Max	.1844	.2347	.2652	.5735	.4024	.788	.1423
Min	.0151	.0156	.0156	.0162	.0162	.0158	.0156
Avg	.0757	.0697	.0865	.1839	.1330	.2443	.0533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.1486		.032	.0191
2	.0191	.0191	.0191	.1486		.032	.0191
3	.0191	.0191	.0191	.1486		.032	.0191
4	.0191	.0191	.0191	.1656		.0617	.0191
5	.0191	.0191	.0191	.1806		.0617	.0191
6	.0191	.0191	.0191	.2286		.0617	.0191
7	.0191	.0191	.0191	.3479		.1235	.0191
8	.0191	.0191	.0191	.3637		.1219	.0191
9	.216	.3437	.3241	.3125		.1235	.0191
10	.2469	.3858	.3549	.2932		.1219	.0191
11	.3086	.3549	.3704	.0191		.0191	.0781
12		.3395	.381	.0191		.0191	.0781
13		.3048	.4167	.0191		.0191	.0903
14		.286	.4115	.0191		.0191	.1067
15		.2896	.3763	.0191	.0191	.0191	.1372
16		.2743	.3658	.0191	.0191	.0191	.1505
17		.0191	.0191	.0191	.0191	.0191	
18	.0191	.0191	.0191	.0191	.0191	.0191	.1372
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191		.0191	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	.0191
22	.0191	.0191	.0191		.0191	.0191	.0191
23	.0191	.0191	.0191		.0191		.0191
24	.0191	.0191	.0191	.0191		.0191	.0191
Max	.3086	.3858	.4167	.3637	.0191	.1235	.1505
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0588	.1202	.1378	.1264	.0191	.0444	.0471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458	.4805	.4938	.4344	.3841	.3841
2		.3772	.4805	.4938	.3658	.3841	.3658
3		.3772	.4668	.4805	.3506	.3841	.3658
4		.3601	.462	.4805	.3506	.4066	.3658
5		.4917	.5175	.5175	.4252	.499	.4024
6		.5365	.5729	.5729	.5175	.5544	.4572
7		.6104	.6283	.6219	.5792	.5914	.5194
8		.567	.567	.6036	.6516	.5373	.4961
9		.5316	.567	.6415	.543	.5548	.4607
10		.5426	.5721	.5658	.5548	.5258	.4733
11		.4973	.5201	.5548	.5375	.5144	.4508
12		.5316	.5426	.5375	.5375	.5316	.4115
13		.5548	.5316	.4854	.463	.5028	.3988
14	.1524	.5083	.4854	.4075	.5548	.4508	.4161
15		.5375	.5487	.4557	.5014		.5258
16		.5596	.5316	.426	.5552	.4748	.503
17		.5304	.5548	.5506	.4854	.4862	.5596
18	.5967	.5571	.5967	.5506	.5731	.5636	.5935
19	.7461	.6661	.6783	.7011	.6935		.6733
20	.7969	.8688	.823	.631	.7343	.7133	.691
21	.7377	.7865	.7628	.5258	.6984		.6379
22	.6443	.7133	.7316	.5434	.6089	.2427	.5316
23	.5197	.5914	.567	.4938	.5138		.462
24		.4862	.499	.5304	.439	.4298	.3841
Max	.7969	.8688	.823	.7011	.7343	.7133	.691
Min	.1524	.3601	.462	.4075	.3506	.2427	.3658
Avg	.5991	.5512	.5703	.5361	.5279	.4866	.4804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7459	1.0059	.4481	.1658	.2075	.2054
2		.7287	1.0059	.4481	.1638	.2075	.2054
3		.7545	1.0059	.4481	.16	.2075	.2054
4		.8097	1.1736	.5068	.16	.3018	.2054
5		.9831	1.3413	.6001	.3201	.415	.2614
6		1.358	1.4586	.8059	.2591	.547	.4294
7	1.358	1.7736	1.7101	.9221	.4024	.4338	.4481
8	1.6095	1.7736		1.0395		.3772	.3547
9	1.6766	1.7604	1.7101	1.1401		.788	.3174
10	1.3077	1.0227	1.5424	1.2742		1.2742	.2054
11	.1307	.2075	.2054	1.4089	1.1065	1.576	.1638
12	.1494		.1867	1.1633		1.7269	.1658
13	.2058	.2263	.2054	1.3413	1.5927	1.7436	.1372
14	.1715	.1886	.2054	1.2146	1.6598	1.6095	.1526
15	.1823	.2263	.2241	2.1714	1.5424	1.6766	.1509
16	.2915	.2263	.2427	1.442	1.6598	1.6933	.1823
17	.1989	.2452			.2263	.2614	.2012
18	.2155	.2641	.2427	.2652	.2452		.1658
19	.285	.3772	.2801		.3018		.2429
20	.3189	.3961	.3547	.2785	.3584		.2652
21	.3077	.3395	.3361	.2486	.3206	.3361	.2294
22	.2452	.3018	.2801	.2515	.2829	.2801	.3391
23	.1907	.2452	.2427	.1966	.2452	.2054	.4024
24		.1658	.2452	.2054	.1823	.2263	.2054
Max	1.6766	1.7736	1.7101	2.1714	1.6598	1.7436	.4481
Min	.1307	.1658	.1867	.1966	.16	.2054	.1372
Avg	.5203	.6574	.6911	.8100	.5678	.7664	.2434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6859	1.2574	.3439	.1875	.2263	.2427
2	.6859	.6859	1.2574	.3439	.1943	.2263	.2427
3	.6859	.6859	1.2574	.3439	.1943	.2263	.2427
4	.6859	.7865	1.5089	.3982	.1943	.2641	.2801
5	.823	1.0562	1.6766	.5083	.3812	.3961	.3547
6	1.1401	1.4419	1.9448	.6687	.4531	.5847	.5601
7	1.358	1.9334	2.2131	.7377	.4641	.4904	.5228
8	1.6766	2.0056	2.1795	.6874		.4527	.4108
9	1.7269	2.0957	2.0119	.6874		.4715	.3174
10	1.2239	1.8143	1.9616	.7377		.8048	.2614
11	.3353	.2829	.2614	.8478	.9724	1.4586	.1802
12	.2374	.2452	.1867	.1063		1.6095	.1802
13		.2829	.2241	1.2483	1.0898	1.4922	
14	.2012	.2452	.2427	.4024	1.1233	1.4586	
15	.2543	.3018	.3174	1.1191	.9054	1.5089	
16	.2321	.3018		1.4074	1.0898	1.5257	.1475
17	.2652	.3395			.2263	.3361	.2321
18	.3201	.3584		.2294			.1677
19	.431	.4338			.3395		.3561
20	.4681	.5093		.3149	.3961		.3725
21	.3944	.4715	.3547	.2753	.3395		.2785
22	.3429	.4338	.2987	.285	.3018		.3185
23	.3086	.3772	.2987	.2543	.2829	.2427	.3521
24	.2801	.3086	.3772	.2614	.2155	.2263	.2427
Max	1.7269	2.0957	2.2131	1.4074	1.1233	1.6095	.5601
Min	.2012	.2452	.1867	.1063	.1875	.2263	.1475
Avg	.6389	.7535	1.0437	.5549	.4922	.7369	.2983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1492	.1886	.1867	.6706	.7011	
2	.168	.1311	.1886	.1867	.6783	.7011	
3	.168	.1372	.1886	.1867	.6783	.7011	
4	.168	.1402	.2263	.2241	.6783	1.2269	
5	.168	.2658	.3018	.2801	.9945	1.5089	
6	.1867	.3239	.4527	.3921	1.4746	2.0287	
7	.2241	.431	.415	.4108	2.2291	2.1963	
8	.168	.2949	.3772	.3547		2.1125	
9	.1307	.2515	.2641	.2801		.2641	
10			.2075	.2801		.2452	
11	.8288	2.3304	2.4646	.1823	.1886	.1867	1.0111
12	1.4074	2.4813	1.166	.2347		.2054	1.065
13		2.3807	2.2801	.1989	.1886	.2054	1.0898
14	1.3923	2.2801	2.4478	.1989	.1509	.168	.9282
15		2.1293	2.5484	.2347	.1509	.168	.9389
16	1.8067	2.3137	2.4143	.2543	.1509	.168	.9326
17	.7537	2.6322			.1886	.1867	.2058
18	1.6787	2.5987	.8145	.2229	.1698		.2829
19	.3315	.3584	.3547		.3018		.2818
20	.3441	.3772	.3174	.2774	.3395		.3086
21	.2683	.1886	.2801	.2743	.3018		.2915
22	.2035	.2641	.2427	.2058	.2452		.2429
23	.1886	.2075	.2427	.3429	.3856		.1658
24	.168	.1492	.2075	.1867	.547	.6135	
Max	1.8067	2.6322	2.5484	.4108	2.2291	2.1963	1.0898
Min	.1307	.1311	.1886	.1823	.1509	.168	.1658
Avg	.5201	.9920	.8083	.2544	.5356	.7549	.5958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.1886	.1132	.112	.1494	.132	.0373
2	.0373	.1886	.1132	.112	.1494	.132	.0373
3	.0373	.1867	.1132	.112	.1494	.132	.0373
4	.0373	.1848	.132	.112	.1494	.1509	.0373
5	.056	.1848	.1341	.1867	.1698	.1698	.0373
6	.0934	.2241	.2641	.2427	.1867	.2263	.0934
7	.0934	.2241	.2641	.2241	.1886	.2263	.0747
8	.0934	.1886	.1886	.2427		.2075	.0747
9	.112	.1886	.1509	.2427		.1886	.0747
10	.112	.1509	.2263	.2427		.2263	.168
11		.1886	.1867	.2263		.2054	.1886
12		.1509	.168	.1886		.1307	.1867
13	.1509	.1698	.1307	.2402	.1886	.2054	.1509
14	.1494	.1698	.1307	.1886	.1886	.168	.1509
15	.1509	.1494	.168		.1886	.168	.1509
16	.1509	.1698	.2241		.1509	.1867	.1494
17	.0943	.1698			.3018	.2241	
18	.1509	.1886		.168	.3018		.1509
19	.1509	.3395	.0934		.3018		.2263
20	.1867	.3018	.1867	.1886	.2829		.2241
21	.3206	.2263	.1867	.2263	.2263		.1132
22	.2452	.1509	.1867	.1494	.1509	.0373	.1509
23	.2241	.132	.1494	.1509	.132	.0373	.1658
24	.0373	.2263	.1132	.112	.1698	.132	.0373
Max	.3206	.3395	.2641	.2427	.3018	.2263	.2263
Min	.0373	.132	.0934	.112	.132	.0373	.0373
Avg	.1237	.1935	.1647	.1834	.1961	.1643	.1182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1509	.1509	.168	.1494	.1509	.1494
2	.2054	.1509	.1509	.168	.1494	.1509	.1494
3	.2054	.1494	.1509	.168	.1494	.1509	.1494
4	.2054	.1478	.1509	.168	.1494	.1698	.1494
5	.2054	.1478	.1509	.1867	.1509	.1698	.1494
6	.2241	.1494	.1509	.2054	.1698	.1698	.1494
7	.2427	.1886	.1509	.2054	.2263	.1509	.1867
8	.168	.2054	.1698	.1494		.1698	.1494
9	.168	.132	.1509	.168		.132	.1867
10	.1307	.1867	.1886	.168		.1886	.1867
11	.1509	.1886	.2054	.1663	.2829	.2427	.1698
12	.1509	.2075	.1867	.2452		.2241	.2075
13	.1311	.2452	.2054	.2427	.2829	.168	.2263
14	.1509	.2075	.2241	.1886	.2641	.2054	.2452
15	.1509	.1886	.2241	.2427	.3206	.1867	.2641
16	.1494	.2075	.1867	.2263	.2641	.168	.1886
17	.1509	.2263			.2075	.168	.2075
18	.1509	.2263	.2054	.2614	.2075		.2452
19	.168	.2452	.2241		.2263		.2075
20	.1886	.2641	.2241	.2263	.2641		.2452
21	.2241	.2075	.2054	.1867	.2452	.2054	.2054
22	.2263	.2075	.2241	.1886	.2263	.1867	.1886
23	.2263	.2075	.1867	.1509	.2075	.1494	.2075
24	.2241	.168	.1698	.168	.1494	.1698	.1494
Max	.2427	.2641	.2241	.2614	.3206	.2427	.2641
Min	.1307	.132	.1509	.1494	.1494	.132	.1494
Avg	.1835	.1919	.1842	.1931	.2147	.1751	.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.4904	.3018	.7545	.7316	
2		.6554	.4904	.3018	.7545	.7316	
3		.5801	.4904	.3018	.6706	.7316	
4		.583	.5658	.3018	.6706	1.0974	
5		.7545	.7095	.3772	1.0395	1.4022	
6		.8551	.9709	.5847	1.3245	1.7269	
7		.8356	.7842	.547	1.9281	2.0454	
8		.7956	.7468	.5658		1.8107	.4108
9		.6882		.4715		.3395	
10		.5365	.4715	.4904		.4527	
11		2.1628	2.2131	.3772	.3395	.4338	
12		2.3807	1.358	.415	.5093	.4338	.4096
13			2.7496		.3961	.4338	1.1437
14	1.7204	2.364	2.6658		.415		1.1065
15	2.0119	2.2634	2.3137		.415		.763
16	2.0153	2.3304	2.5987	.3772	.3961	.2263	.9116
17	1.8399	2.4813			.5658	.2075	
18	2.0957	2.4478	.8869	.4338	.4338		.3113
19	.6859	.4854	.5041		.4715		.3932
20	.7969	.7095	.4481	.4904	.5281		.4096
21	.7459	.6722	.4294	.4904	.4527	.2263	.2984
22	.6203	.6224	.2987	.3772	.3772	.1886	.1966
23	.5506	.5847	.2987	.5658	.679	.132	.1823
24		.5407	.5093	.2987	.5847	.6602	
Max	2.0957	2.4813	2.7496	.5847	1.9281	2.0454	1.1437
Min	.5506	.4854	.2987	.2987	.3395	.132	.1823
Avg	1.3083	1.1729	1.0452	.4247	.6527	.7375	.5447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.081	.1696	1.0174		.8573	
2	.1658	.081	.1696			.8859	
3	.1638	.081	.1696			.964	
4	.16	.081	.1966			1.0166	
5	.1619	.081	.2035				
6	.2195	.081	.2543	1.0174		1.0974	
7	.2429	.081	.3052	1.3565		1.8004	
8	.3239	.081	.2543	1.1869		1.8861	
9	.2458	.1943	.1696	.1696		.1619	
10	.1619	.2713	.1696	.1696			
11	1.2631	1.6956		.1696			
12	1.5384	1.3565		.2012			.724
13	1.4089	1.3565	1.5261			.1457	.8478
14	1.2631	1.1869	1.5261			.1943	.6783
15	1.2631	1.1869	1.3565	.1943		.1943	.905
16	1.3927	1.3565		.1943		.1943	.8573
17	1.5546	1.5261				.1619	.1829
18	1.3117	1.5261	1.0174			.1943	.1357
19	.2915	.1696	.2035				.1715
20	.2915	.2035	.2543		.2915		.1715
21	.2915	.2543	.2035				.1715
22	.2429	.2035	.1696		.1943		.1715
23	.1943	.2035	.1696				.1715
24	.1311		.1696	.1696		.7316	
Max	1.5546	1.6956	1.5261	1.3565	.2915	1.8861	.905
Min	.1311	.081	.1696	.1696	.1943	.1457	.1357
Avg	.6018	.5800	.4329	.5315	.2429	.6991	.4324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1012	.9717	1.1869			.8688	
2	.7811	1.1336	1.3565			.8916	
3	1.4746	1.2146	1.4413			1.0166	
4	1.6194	1.4251	1.7804			1.0517	
5	1.7814	1.6518	2.5434			1.0498	
6	1.9433	2.1862	2.5434			1.448	
7	1.9433	2.1862	3.2217			1.9281	
8	2.6397	2.8988	2.9673			2.0576	.5506
9	2.5101	1.7004	2.713			.9431	.7287
10	2.6235	2.3739	2.8826				.8059
11	1.6842	1.5261	1.8652	2.3739		2.5749	.8573
12	1.9433	1.6956	1.5261	2.4863		2.4939	.9431
13	1.9109	1.8652	1.6956			2.3482	.9326
14	1.9271	1.8652	1.6956			2.8016	.8478
15	1.9433	1.8652	1.6956	2.4863		2.332	1.0288
16	1.8623	1.95		2.1434		2.7206	1.0174
17	1.7166	2.0348				.2915	.1715
18	1.8623	1.8652				.1943	.1715
19	.3239	.3391					.3429
20	.3239	.4239			1.8861		.3429
21	.3401	.407					.3429
22	.3239	.3391			.3239		.3429
23	.3239	.3391					.3391
24	.2915	.2915	.3052			.8413	
Max	2.6397	2.8988	3.2217	2.4863	1.8861	2.8016	1.0288
Min	.2915	.2915	.3052	2.1434	.3239	.1943	.1715
Avg	1.4665	1.4396	1.9637	2.3725	1.105	1.5474	.6104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.9717	1.0174	.1696		.2195	
2	.6554	1.166	1.2717	.1696		.3292	
3	.8097	1.2146	1.1869			.2534	
4	.9717	1.2955	1.3565			.2896	
5	1.1336	1.3765	1.6956			.3189	
6	1.2308	2.1052	2.2043	.2543		.4733	
7	1.406	2.2672	2.8826	.4239		.4607	
8	1.4575	2.5911	2.713			.3887	
9	1.4575	1.8138	2.0348	.5087		.8573	
10	1.7814	2.0348	2.2043	1.1869			.0343
11	.2267	.1696	.1696	2.0348		2.7206	.0514
12	.2267	.1696	.1696	2.0576		2.5263	.0686
13	.2591	.1696	.1696			2.7206	.0857
14	.1619	.1696	.1696			2.2672	.1029
15	.1619	.1696	.1696	2.0576		2.2672	.0857
16	.2591	.2543		1.8861		2.4615	.1029
17	.1619	.2543				.2591	.1029
18	.1943	.2543				.2267	.1017
19	.2591	.3052	.2035				.2401
20	.3563	.4239	.3391		.9431		.2572
21	.2915	.4239	.3052				.2401
22	.2915	.4239	.2543		.1943		.2543
23	.2915	.3391	.2543				.2374
24	.1311	.2915	.3052	.2035		.2172	
Max	1.7814	2.5911	2.8826	2.0576	.9431	2.7206	.2572
Min	.1311	.1696	.1696	.1696	.1943	.2172	.0343
Avg	.6166	.8606	1.0037	.9957	.5687	1.0698	.1404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0324	.0509			.3292	
2		.0324	.0339			.3258	
3		.0324	.0339			.3086	
4		.0324	.0339			.362	
5		.0324	.0509			.362	
6		.081	.0509			.4525	
7		.0648	.0848			.5121	
8		.0648	.0678			.5144	.0162
9		.0486	.0509			.0648	.0648
10		.0509	.0509	.0509			.0686
11	.081	.3391	.3391	.0339		.0324	.1357
12	.2591	.4239	.4239	.0648		.0324	.1715
13	.3563	.5087	.4239			.0324	.1715
14	.3239	.4239	.3391			.0324	.1715
15	.2915	.4239	.3391	.0648		.0324	.1734
16	.3563	.5087		.0648		.0324	.1658
17	.421	.5087				.0324	.0343
18	.3563	.5087	.0848			.0324	.0343
19	.0486	.0509	.0509				.0514
20	.0648	.0678	.0678		.0648		.0514
21	.0648	.0678					.0514
22	.0486	.0678			.0671		.0514
23	.0324	.0509					.0343
24		.0324	.0509			.2454	
Max	.421	.5087	.4239	.0648	.0671	.5144	.1734
Min	.0324	.0324	.0339	.0339	.0648	.0324	.0162
Avg	.2080	.1856	.1383	.0558	.0660	.2076	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2652	.2452	.2263	.6554	.6979	.3018
2		.2652	.2829	.2263	.7373	.8299	.3315
3		.2486	.2829	.2263	.8356	.8676	.3647
4		.2486	.415	.2641	.9175	1.2071	.3647
5		.3647	.4715	.3395	1.0159	1.4335	.431
6		.4588	.5658	.5281	1.1012	1.5844	.4973
7		.4096	.5281	.4527		1.8296	.6133
8		.3315	.3395	.3206		1.6598	.5243
9		.3315	.3018	.2829		.2263	.4641
10		.2713	.2641	.3018		.2263	.3978
11		1.442	1.7541	.2035		.2641	.4641
12		1.6221	2.0182	.2012			.5243
13		1.5729	1.9427	.2012			.5243
14	1.0486		1.8296	.1989		.2263	.6554
15	1.1012	1.4746	1.9993	.2652		.2641	.5898
16	.9717	1.6057	1.905				.6554
17		1.6057				.2641	.1989
18			1.2826			.3018	.1989
19	.3932		.3584	.3315	.4338		.2622
20	.4096	.5281	.415	.3978	.4527		.3315
21	.3932	.4904	.3772	.2652	.3961	.2263	.2984
22	.3315	.3772	.3395	.3315	.3584	.1886	.2652
23	.3315	.3206	.2452	.8848	.547		.2652
24		.2984	.2452	.2263	.5898	.6413	.3018
Max	1.1012	1.6221	2.0182	.8848	1.1012	1.8296	.6554
Min	.3315	.2486	.2452	.1989	.3584	.1886	.1989
Avg	.6226	.6920	.8004	.3179	.6701	.7188	.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0377	.0377	.0373	.0373	.0381
2	.0373	.0373	.0377	.0377	.0373	.0373	.0381
3	.0373	.0373	.0377	.0377	.0373	.0373	.0381
4	.0373	.0373	.0377	.0377	.0373	.0373	.0381
5	.0373	.0373	.0377	.0377	.0373	.056	.0377
6	.056	.0554	.0566	.0566	.0373	.056	.0566
7	.0373	.037	.0373	.0566	.0554	.0373	.0566
8	.0373	.037	.0373	.0566	.037	.0373	.0373
9	.0373	.037	.037	.0377	.037	.0373	.0373
10	.0373	.0373	.0373	.0377	.0187	.037	.0373
11	.037	.037	.0373	.0373	.0373	.0366	.0373
12	.037	.0373		.0373	.0373	.0362	.0373
13	.037	.037		.0373	.0187	.0362	.0373
14	.037			.0373	.0373	.037	.0377
15	.037	.0373		.0377	.0373	.0373	.0189
16	.0366	.0373			.0373		.0189
17		.0373			.0373		.0189
18	.037		.0566		.0373		.0373
19	.0554		.0754	.0549	.056		.0373
20	.0554	.0724	.0754	.0732	.056		.0554
21	.037	.0747	.0566	.037	.056	.0377	.037
22	.0373	.0377	.0377	.037	.0373	.0377	.0373
23	.0373	.0377	.0373	.0373	.0373	.0377	.0189
24	.0373	.0373	.0377	.0377	.0373	.0373	.0381
Max	.056	.0747	.0754	.0732	.056	.056	.0566
Min	.0366	.037	.037	.037	.0187	.0362	.0189
Avg	.0396	.0416	.0449	.0427	.0388	.0391	.0368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1494	.1698	.168	.132	.1509	.132
2	.0747	.1494	.1698	.168	.132	.1509	.132
3	.0747	.1494	.1698	.1494	.132	.1509	.132
4	.0747	.1494	.1886	.1494	.132	.1509	.1509
5	.0934	.1494	.2263	.168	.1509	.1698	.1886
6		.2033	.2641	.2427	.168	.2075	.2075
7	.112	.1848	.1867	.2614	.2033	.2075	.2241
8	.1307	.2195	.2402	.1867	.2218	.2075	.2054
9	.1494	.2561	.2743	.2241		.2075	.2402
10	.112	.2587	.2987	.2241	.1307	.2402	.1848
11	.1109	.2033	.2054	.1848	.2427	.2353	.1848
12	.1478	.2402	.1867		.1867	.197	.1848
13		.2195	.2054	.2561	.2054	.2402	.1307
14	.056		.1867	.2218	.2427	.2218	.1867
15	.2896	.1991	.2012	.2033	.2054	.2241	.1867
16	.2715	.2195	.2241		.2241		.168
17	.3077	.2033			.2641	.2957	.1663
18	.3761				.2641	.2561	.2218
19	.3224		.168	.3258	.3018		.1663
20	.3224	.3696	.3734		.3206		.2012
21	.3077	.3326	.3361	.1848	.2641	.2054	.2012
22	.2561	.2427	.2427	.1663	.1698	.1698	.1478
23	.2033	.1867	.168	.1478	.1509	.1509	.1307
24	.0747	.1848	.1698	.168	.1307	.1509	.132
Max	.3761	.3696	.3734	.3258	.3206	.2957	.2402
Min	.056	.1494	.168	.1478	.1307	.1509	.1307
Avg	.1792	.2129	.2207	.2000	.1989	.1996	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.3963
10			.3506
11		1.4091	.506
12		.1097	
13		.1307	.7907
14		.1109	
16		.0924	
17		.0914	
18		.1478	
23		.0924	
24	1.4575		
Max	1.4575	1.4091	.7907
Min	1.4575	.0914	.3506
Avg	1.4575	.2731	.5109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
11		.5138
13		2.4383
14		.0366
15		.0366
16		.362
17		.5792
18		.2772
24	1.2003	
Max	1.2003	2.4383
Min	1.2003	.0366
Avg	1.2003	.6062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
11		.8951
12		1.0526
13		.9962
15		.8907
16		.9014
17		.0354
18		.0554
24	1.3717	
Max	1.3717	1.0526
Min	1.3717	.0354
Avg	1.3717	.6895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
11		.0648
12		.1457
13		.1296
14		.1134
15		.0972
16		.0972
17		.1134
18		.1457
19		.0324
20		.0324
21		.0324
22		.0324
23		.0324
24	1.3717	
Max	1.3717	.1457
Min	1.3717	.0324
Avg	1.3717	.0822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9488	1.2651	.2214	.1265	.2056	.6958
2		.9488	1.2651	.2214	.1265	.2056	.6958
3		1.0279	1.2651	.2214	.1265	.2056	.6958
4		1.1069	1.5023	.2214	.1265	.2353	.6958
5		1.2809	1.7394	.2372	.1581	.2353	.759
6			2.0241	.2846	.2214	.2896	.8223
7		2.0557	2.372	.2688	.253	.3077	.8697
8		2.0873	2.4194	.1898	.253	.2688	.7907
9	1.5813	1.7394	2.451	.6325	.6642	.6325	.1581
10	1.0595	1.4232	2.3403		.9804	2.1348	.1265
11	.1739		.2056	2.0557	1.2967	2.2455	.1107
12	.1898	.2372	.2372	2.0873	1.2018	2.4036	.0949
13	.1898	.2372	.2372	2.0873	1.2018	2.2455	.0949
14	.1898	.2056	.2214	2.0241	1.1702	2.2138	.1107
15	.2214	.2214	.2214	2.0557	1.5339	2.2455	.1107
16	.2372	.2214	2.5101	1.2651	1.5813	2.0557	
17	.2214	.2214			.2056	.2214	
18	.2214	.2214			.1898	.2056	
19	.3795	.3005			.1898		.1581
20		.3479	.2056		.253		.2214
21	.253	.3479	.2056		.253	.2214	.1898
22	.2214	.3005	.2214	.1265	.2056	.2214	.1898
23		.3005	.2214	.1265	.2056	.6325	.4428
24		.2056	.3005	.2214	.1265	.2056	.6958
Max	1.5813	2.0873	2.5101	2.0873	1.5813	2.4036	.8697
Min	.1739	.2056	.2056	.1265	.1265	.2056	.0949
Avg	.3953	.7267	1.1158	.8082	.5271	.9017	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2172	.2896	.0579	.0579	.0724	.1738
2	.362	.2896	.3163	.0434	.0579	.0724	.1738
3	.4054	.3185	.2896	.0434	.0579	.0724	.1738
4	.5213	.3475	.2896	.0434	.0579	.0724	.1738
5	.6371	.3765	.4344	.0579	.0579	.0724	.2606
6	.8398	.7385	.8688	.0724	.0724	.0869	.3185
7		.724	.7964	.0724	.0724	.0724	.333
8		.8688	.2896	.0724	.0724	.0724	.3765
9	.6805	.8688	.7529	.2172	.2172	.2027	.0869
10	.3765	.7964	.8688		.2896	.5502	.0579
11	.0579			.8688	.5792	.695	.0579
12	.0579	.0724		.9846		.7819	.0579
13	.0633	.0724		.9412		.8398	
14	.0579	.0724		.9267		.9556	
15		.0724		.9488	.5357	.695	
16		.0724			.5357	.7529	
17		.0724			.0579	.0724	
18		.0724			.0579	.0579	
19	.0724	.0869			.0579		.0579
20		.0869	.0579		.0869		.0579
21	.0579	.0869	.0579		.0869	.0579	.0579
22	.0579	.0869	.0579	.0579	.0869	.0579	.0579
23		.0724	.0579	.0579	.0724	.1014	.1448
24	.0579	.0579	.0724	.0579	.0579	.0724	.1738
Max	.8398	.8688	.8688	.9846	.5792	.9556	.3765
Min	.0579	.0579	.0579	.0434	.0579	.0579	.0579
Avg	.2854	.2839	.3667	.3250	.1538	.2949	.1553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.3077	.3887		.8745	1.4575	.2267
2	.2429	.3077	.3887		.9555	1.4575	.2267
3	.2429	.3077	.3887		1.004	1.4575	.2267
4	.2915	.3077	.3887		1.2955	1.7814	.2267
5	.4049	.3077	.4372		1.4899	1.9433	.2915
6	.4534	.4534	.4858		2.0891	2.2672	.3563
7			.4372		2.5911	2.7368	.3239
8		.3887	.2105		2.672	2.834	.2105
9	.3887	.3401	.2267			.2915	.6802
10	.1943	.2915	.2267			.2915	1.0526
11			2.332			.3563	1.6194
12	2.5911	2.672	2.4291		.2591	.3887	1.6194
13	2.3482	2.753	2.5101			.421	1.6356
14	2.4777	1.2955	2.6235		.2591	.421	1.4575
15		2.2672	2.5911	.1619	.3239	.421	1.4251
16		2.4291	2.5101	.1619	.3239	.3887	
17		2.2672			.0486	.4534	
18		2.5101			.0648	.2915	
19		.3401			.2105		.2591
20	.3563	.4372			.3077		.3077
21	.3801	.4372			.3077	.2267	.1943
22	.3239	.4049		.2896	.3077	.2267	.1781
23		.3887		.7449	.6478	.2429	.1296
24	.2267	.3077	.3887		.8097	1.4575	.2267
Max	2.5911	2.753	2.6235	.7449	2.672	2.834	1.6356
Min	.1943	.2915	.2105	.1619	.0486	.2267	.1296
Avg	.7444	.9783	1.1155	.3396	.8421	.9915	.6131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0905	.0905	.0716		.0905	.0716
2	.0716	.0905	.0905	.0716		.0905	.0716
3	.0716	.0905	.0905	.0716		.0905	.0716
4	.0895	.0905	.0905	.0716		.0905	.0716
5	.1612	.0905	.1086	.0895		.1086	.0895
6	.1254	.1448	.1629	.1433		.181	.1433
7		.1267	.1448	.1254		.0905	.1433
8	.0972	.1086	.1254	.1254		.0716	.1075
9	.0648	.1267	.0895	.0905		.0716	.1267
10	.0724	.1267	.0895		.0724	.0716	.1086
11	.0905		.0716	.0905	.0905	.0895	.0972
12	.1086	.1448	.0895	.0905	.1448	.1075	.1086
13	.1267	.1267	.0895	.0905	.1448	.0716	.0905
14	.0724	.0905	.0895	.0543	.0905	.0716	.0905
15		.1267	.1254	.0905	.1267	.0895	.0724
16		.1448	.0537		.0905	.0895	
17		.1448			.1267	.1075	
18		.1448			.1629	.0895	
19	.1448	.181			.1267		.1448
20	.1448	.1991	.0716		.181		.181
21		.1991	.0716		.181	.1075	.1448
22	.1086	.1629	.0895		.1267	.0895	.1086
23		.1267	.0895		.1086	.1433	.0905
24	.1075	.0905	.0905	.2267		.0905	.0716
Max	.1612	.1991	.1629	.2267	.181	.181	.181
Min	.0648	.0905	.0537	.0543	.0724	.0716	.0716
Avg	.1017	.1291	.0959	.1002	.1267	.0956	.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0181	.0362	.037	.0181	.0362	.0185
2	.0185	.0181	.0362	.037	.0181	.0362	.0185
3	.0185	.0181	.0362	.037	.0181	.0543	.037
4	.0185	.0181	.0543	.0554	.0181	.0543	.0554
5	.0185	.0181	.0724	.0739	.0181	.0543	.0554
6	.0185	.0181	.1086	.0554	.0362	.0543	.0739
7		.0543	.0905	.0554	.0362	.0724	.037
8	.0362	.0362	.0739	.0739	.0724	.0739	.0185
9		.0543	.0554	.0724	.0724	.037	.0543
10	.0362	.0543	.0554		.0724	.037	.0362
11	.0724		.037	.0543	.0362	.037	.0362
12	.0362	.0362	.0554	.0543	.0373	.0554	.0181
13	.0362	.0362	.037	.0362	.0362	.0739	.0181
14	.0181	.0181	.0739	.0362	.0362	.037	.0181
15		.0181	.0554	.0181	.0362	.0554	.0181
16		.0543	.0185		.0362	.0739	
17		.0724			.0543	.0554	
18		.1086			.0543	.037	
19	.0724	.1086			.0543		.0543
20		.1086	.0739		.0905		.0724
21		.0905	.0185		.0724	.037	.0543
22		.0724	.0185	.0181	.0543	.0185	.0362
23		.0362	.0554	.0362	.0543	.037	.0181
24	.0185	.0362	.0362	.0185	.0181	.0362	.0185
Max	.0724	.1086	.1086	.0739	.0905	.0739	.0739
Min	.0181	.0181	.0185	.0181	.0181	.0185	.0181
Avg	.0312	.0480	.0523	.0453	.0438	.0483	.0365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823	.703	.6687	.2743	.2915	
2		.823	.8059	.6687	.2743	.2915	
3		.8402	.9088	.6687	.3086	.3086	
4		.823	1.0288	.6859	.3429	.3086	
5		.823	1.2174	.7716	.3772	.3429	
6		1.1488	1.5604	1.0288	.463	.4287	
7		1.4575	1.6118	1.2003		.4115	.3086
8		1.4746	1.6289	1.0974		.3258	.3086
9		1.5089	1.6118	1.2346		.583	.3086
10	.2915	1.4575	1.4746	1.3546	.0343	.9088	.2915
11		.3601	.3601	1.3717	.0343	1.2517	.2401
12	.0171	.3944	.3429		.0514	1.3717	.2572
13	.2743	.463	.3601	1.3889	.0514		.2572
14	.2572	.463	.3944	1.2517	.0343	.703	.2743
15	.3086	.463	.3601	1.4575	.7888	.7373	
16	.3601	.4458		1.166	.9088	.8916	
17	.3086	.4458			.2743	.2401	
18		.3258		.2229	.2743	.2229	
19	.0171	.3944	.4287	.3258	.3429	.2743	
20	.0171	.3429	.4287	.4115	.3944		.3944
21	.4115	.4287	.4287	.3429	.3772		.3601
22	.4287	.3944	.4287	.3258	.3258		.3258
23	.3944	.3601	.3944	.3086	.3258		.4458
24		.3944	.2915	.4115	.2915	.2915	
Max	.4287	1.5089	1.6289	1.4575	.9088	1.3717	.4458
Min	.0171	.3258	.2915	.2229	.0343	.2229	.2401
Avg	.2572	.7023	.7986	.8347	.3119	.5361	.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2915	.2229	.884	.6001	.4458
2		.2401	.2915	.2229	.9145	.6516	.4458
3		.2401	.2915	.2229	.9755	.7202	.463
4		.2572	.3086	.2229	1.0669	.8059	.463
5		.2743	.3086	.2915	1.2193	.8916	.4801
6		.463	.5487	.4287	1.4022	.9945	.5658
7		.4458	.4973	.4115	1.3565	1.5604	.7373
8	.0343	.3601	.3944	.3048	1.2651	1.4918	.6001
9	.0514	.3086	.1715	.2896	.1524	.2572	.6173
10	.0514	.2743	.3086	.2743	.1886	.3429	.5639
11	1.0802	1.3375	1.7318	.2591	.2229	.3601	.7888
12	1.4746	1.6632	1.989		.2401	.3429	.7468
13	1.5604	1.989	2.1605	.2896	.2743	.3601	.7621
14	1.5604	2.0748	2.0062	.2896	.2058	.3086	.7316
15	1.5261	1.8861	1.989	.3201	.2058	.3258	
16	1.6461			.3201	.2229	.3601	
17	1.8176				.2229	.3944	
18	1.5432	1.4746		.2439	.2401	.3601	
19	.3601	.3944	.2915	.3048	.2572	.3258	
20	.3601	.4115	.2743	.3506	.3086		.2743
21	.3601	.3772	.2572	.2896	.3258		.2439
22	.2915	.3258	.2401	.2743	.2743	.4115	.2286
23	.2401	.2915	.2229	.3658	.2229	.3944	.2286
24		.2401	.2572	.2058	.8688	.5487	.4458
Max	1.8176	2.0748	2.1605	.4287	1.4022	1.5604	.7888
Min	.0343	.2401	.1715	.2058	.1524	.2572	.2286
Avg	.8724	.7077	.7063	.2912	.5632	.5822	.5175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.12	.1029	.1029	.1372	.1029	
2	.0857	.12	.1029	.1029	.1219	.1029	
3	.0857	.12	.1029	.1029	.1219	.1029	
4	.1029	.12	.12	.1029	.1372	.12	
5	.12	.1372	.12	.1543	.1524	.1372	
6	.1886	.2229	.2572	.1886	.1829	.1715	
7		.1886	.2058	.2229	.1677	.1715	
8	.12	.1543	.1715	.1715	.1524	.1543	
9	.1029	.1543	.2058	.1886	.1372	.1372	
10	.2229	.3086	.3086	.3086	.2572	.1715	
11	.2058	.2915	.2915	.2915	.1543	.1715	
12	.1715	.2915	.3258		.2229	.1715	
13	.1715	.1543	.1543	.2572	.2229	.12	
14	.1715	.2229	.2572	.2229	.2229	.12	
15	.2401	.1886	.2572	.12	.2058	.1372	
16	.2401	.2401		.2572	.2058		
17	.2915	.2572			.2401	.1715	
18	.3429	.1543		.2058	.2743	.1886	
19	.2229	.2572	.2401	.2572	.1886		
20	.2058	.2572	.2229	.2401	.2572		.2229
21	.2058	.2229	.2229	.1886	.2058		.2058
22	.1715	.1715	.1715	.1715	.1715		.1886
23	.12	.1543	.12	.1715	.12		.1715
24	.0857	.12	.12	.1029	.1543	.1029	
Max	.3429	.3086	.3258	.3086	.2743	.1886	.2229
Min	.0857	.12	.1029	.1029	.12	.1029	.1715
Avg	.1722	.1929	.1943	.1878	.1839	.1420	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1029	.1372	.12	.12	.12	.0686
2	.0686	.0857	.1372	.12	.12	.12	.0686
3	.0686	.0857	.1372	.12	.12	.12	.0686
4	.0857	.0857	.1372	.1372	.1372	.1372	.0686
5	.1029	.0857	.1372	.1715	.1372	.1372	.0857
6	.1029	.1029	.1715	.1029	.1543	.1372	.1029
7		.0857	.1372	.0686	.12	.12	.0686
8	.0686	.0686	.12	.0343	.1029	.0857	.0514
9	.0514	.0686	.0514	.0343	.1029	.0686	.0514
10	.0686	.0686	.0514	.0343	.0686	.0514	.0343
11	.0686	.0343	.0343	.0343	.0686	.0514	.0514
12	.0514	.0514	.0514	.0343	.0343	.0343	.0343
13	.0514	.0514	.0514	.0343	.0343	.0514	.0343
14	.0514	.0686	.0514	.0343	.0514	.0686	.0343
15	.0686	.0514	.0514	.0343	.0514	.0514	
16	.0686	.0686		.0343	.0514	.0514	
17	.0686	.0514			.0686	.0857	
18	.0514	.0686		.1372	.0857	.0857	
19	.12	.12	.0857	.1372	.0857	.1543	
20	.12	.1372	.1372	.1372	.1029		.1372
21	.1029	.1715	.1715	.1543	.12		.1372
22	.0686	.1372	.1543	.1372	.1029	.0686	.1372
23	.0857	.12	.0686	.1372	.1715	.0514	.1372
24	.0686	.1029	.0514	.12	.12	.12	.0686
Max	.12	.1715	.1715	.1715	.1715	.1543	.1372
Min	.0514	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0753	.0864	.1012	.0917	.0972	.0896	.0758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.12	.8078	.7202	
2	.1715	.1715	.1715	.12	.8383	.7545	
3	.1886	.1715	.1886	.1372	.9145	.7888	
4	.1886	.1886	.2058	.1372	.9907	.8573	
5	.2058	.2058	.2229	.1715	1.2193	.9774	
6	.3086	.3086	.3429	.2572	1.4327	1.1488	
7		.2572	.3086	.2401	1.7528	1.5089	
8	.2743	.2572	.2915	.1677		1.4746	.5144
9	.2229	.2915	.3086	.1829	.1524	.12	.6001
10	.2229	.2058	.2572	.2134	.1372	.1886	.5792
11	1.7147	1.3203	1.9376	.1067	.1372	.2229	.7773
12	1.9033	1.9547	2.1948	.1677	.1543	.2229	.6859
13	1.9719	2.1605	2.1776	.1829	.12	.2058	.7621
14	2.0748	2.1434	2.1776	.1677	.1372	.2229	.7621
15	2.0576	2.0748	2.1948	.1981	.1543	.2229	
16	2.0233	2.0919		.2286	.1886	.2743	
17	2.1091	2.0233			.0686	.2915	
18	2.0405	1.7833		.1829	.2058	.1886	
19	.2572	.2401	.1886	.2439	.1886	.1715	
20	.2401	.2743	.1886	.2286	.2058		.1829
21	.2401	.2915	.1715	.1981	.1715		.1829
22	.2058	.2401	.1543	.1829	.1715		.1677
23	.1886	.2058	.1372	.2591	.1372		.1524
24	.1715	.1715	.1886	.12	.7926	.6687	
Max	2.1091	2.1605	2.1948	.2591	1.7528	1.5089	.7773
Min	.1715	.1715	.1372	.1067	.0686	.12	.1524
Avg	.8327	.8002	.6753	.1832	.4817	.5616	.4879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.9431	1.0802	.6859	.061	.0686	.0686
2	.6859	.9602	1.1317	.6859	.061	.0686	.0686
3	.7716	.9945	1.1831	.703	.0762	.0686	.0686
4	.8573	1.046	1.2003	.7202	.0762	.0857	.0686
5	.9602	1.0974	1.2003	.7716	.0914	.0857	.0857
6	1.2689	1.3546	1.3717	.9774	.1372	.1029	.12
7		1.3032	1.5947	.9945	.1067	.1029	.0857
8	1.2174	1.5604	1.5432	.9755	.0914	.0686	.0514
9	1.2174	1.4746	1.5775	1.0822			.0514
10	1.2346	1.286	1.406	1.1431			.0305
11	.0686	.0514	.0686	.7926		1.0802	.0305
12	.0686	.0686	.0686	1.2803			.0457
13	.1029	.0514	.0686	1.3565	1.0974	1.3717	.0457
14	.0686	.0514	.0686	1.3413	1.166	1.3889	.0457
15	.0686	.0514	.0686	1.1888	1.406	1.3375	
16	.0686	.0514		1.1888	1.046	1.2346	
17	.0686	.0686			.0857	.0514	
18	.0686	.0686		.0762	.0857	.0514	
19	.12	.0686	.1029	.0914	.1029	.0686	
20	.12	.1029	.1029	.1067	.12		.1067
21	.12	.1029	.1029	.0914	.0857		.0914
22	.1029	.1029	.0857	.0762	.0857	.0514	.0914
23	.0857	.0857	.0686	.0762	.0686	.0514	.2591
24	.0514	.0857	.0686	.0686	.061	.0686	.0514
Max	1.2689	1.5604	1.5947	1.3565	1.406	1.3889	.2591
Min	.0514	.0514	.0686	.0686	.061	.0514	.0305
Avg	.4339	.5430	.6744	.7163	.3056	.3899	.0772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.5668	.9945			.1524	.1905
2	.5735	.5668	1.326			.1524	.1905
3	.5735	.5668	1.326			.1524	.1905
4	.7373	1.0202	1.4918			.1905	.2286
5	1.0322	1.2146	1.4918			.2477	.2477
6	1.5893	1.6194	2.0719			.4382	.3429
7	1.0595	2.3158	2.5692			.362	.3429
8	2.2138	2.4453	2.7349			.2477	.2286
9	2.2138	2.2377	2.5692			.4954	.2286
10	1.0437	2.2377	2.304			1.4899	.1143
11	.1143	.1143	.0953	2.0567		2.0081	.0953
12	.1334	.1524	.0953	2.4615	1.5384	2.1052	.0953
13	.0953	.0953	.1143	2.3805	1.7166	2.4291	.0953
14	.0953	.2286	.1143	2.1052	2.1052	2.4291	.0953
15	.0953	.1143	.1143	2.1862	1.8187	2.4291	.0953
16	.0953	.1334	.1143	2.1052	2.0481	2.4291	.1143
17	.0953	.2667			.2858	.2096	.1524
18	.1143	.1905			.2096	.2096	.1905
19	.2477	.2858			.3048		.1905
20	.3048	.2858			.3429		.1905
21	.3048	.2858			.2477	.2096	.1905
22	.3048	.1905			.1905	.2096	.1715
23	.1524	.1715			.1524	.1905	.5201
24	.1524	.1524	.1715			.1524	.1905
Max	2.2138	2.4453	2.7349	2.4615	2.1052	2.4291	.5201
Min	.0953	.0953	.0953	2.0567	.1524	.1524	.0953
Avg	.5798	.7274	1.1587	2.2159	.9134	.8609	.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2286			.5801	.2105
2	.1905	.2096	.2286			.663	.2105
3	.1905	.2096	.2286			.663	.2105
4	.2286	.3048	.2477			.7625	.2105
5	.2858	.3239	.2858			.8288	.3239
6	.3239	.2667	.381			1.1797	.3401
7	.2667	.2667	.381			1.5565	.3401
8	.2667	.2858	.2858			1.3108	.3077
9	.2667	.2858	.2477			.2477	.3563
10	.1334	.2858	.2286			.2477	.4858
11	.9878	.8907	.9998	.4001		.2858	.4858
12	.9878	.8097	.9686	.3429	.5079	.2858	.6478
13	.8097	.5668	.703	.3429		.3048	.6478
14	.8097	.7287		.2858	.381	.3048	.6478
15	.8745	.7287	.884	.2858	.3429	.3048	.6478
16	.5506	.8097	.9602	.2858	.2858	.3048	.5668
17	.8745	.9717			.3239	.2477	.2286
18	.8745	.8907			.3048	.2477	.1905
19	.2667	.2858			.362		.2858
20	.3429	.3429			.4001		.2858
21	.3429	.3429			.3429	.2477	.2858
22	.3239	.2858			.2858	.2477	.2858
23	.2286	.2858			.2515	.2105	.2477
24	.1905	.2286	.2286			.431	.2105
Max	.9878	.9717	.9998	.4001	.5079	1.5565	.6478
Min	.1334	.2096	.2286	.2858	.2515	.2105	.1905
Avg	.4503	.4515	.4680	.3239	.3444	.5210	.3608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.2286			.1715	.0762
2	.1715	.1905	.2286			.1715	.0762
3	.1715	.1905	.2286			.1715	.1905
4	.1524	.1905	.2286			.1905	.0762
5	.1715	.2096	.1905			.2286	.1334
6	.2286	.1334	.2477			.2477	.1334
7	.0953	.1334	.2286			.1524	.1334
8	.1143	.1334	.2096			.1715	.0953
9	.1143	.1143	.1524			.1905	.1334
10	.0762	.0953	.1334			.1905	.1524
11	.0762	.1334	.1715	.1905		.1905	.1715
12	.0762	.1905	.1524	.2096	.0953	.1334	.1524
13	.1524	.1143	.1334	.1905	.1524	.1334	.1524
14	.1524	.1334	.1143	.1905	.1905	.1334	.1524
15	.1143	.1715	.0762	.1524	.1715	.1334	.1905
16	.1143	.1715	.1143	.1524	.1143	.1334	.1334
17	.1715	.1524			.1905	.1143	.1715
18	.1334	.1715			.1143	.1715	.1905
19	.2096	.1905			.1715		.1905
20	.2096	.2286			.1715		.1905
21	.2096	.2286			.2286	.1715	.1905
22	.2096	.2096			.2286	.1715	.1905
23	.2286	.2477			.2096	.1334	.1715
24	.1715	.2286	.2286			.1715	.1143
Max	.2286	.2477	.2477	.2096	.2286	.2477	.1905
Min	.0762	.0953	.0762	.1524	.0953	.1143	.0762
Avg	.1540	.1731	.1804	.1810	.1699	.1672	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2286			.5801	
2	.2667	.2667	.2286			.5801	
3	.2667	.2667	.2286			.5801	
4	.2858	.381	.2858			.5801	
5	.3429	.4191	.381			.5967	
6	.4382	.4382	.4763			1.9006	
7	.4191	.381	.5335			2.1376	
8	.4191	.381	.4191			2.5049	.3978
9	.4191	.2858	.381			.4572	.3646
10	.2477	.2858	.2858			.4572	.663
11	.7209	.8288	.787	.4001		.4954	.8288
12	.7373	.663	.9259	.3429	.8097	.6097	1.1602
13	.6226	.5801	.6173	.3429	.381	.4954	1.1602
14	.6226	.7459	.7562	.2858	.4001	.4954	1.1602
15	.6554	.663	.7926	.2858	.362	.4954	1.1602
16	.4915	.8288	.6718	.2858	.3048	.4954	.8288
17	.4915	.8288			.2477	.381	.3048
18	.4915	.7459			.3239	.1905	.4954
19	.2858	.2858			.4001		.5716
20	.4001	.381			.4954		.4954
21	.4001	.381			.4001		.5716
22	.4191	.2858			.3239		.4954
23	.2667	.2477			.3521		.2477
24	.2667	.2667	.2286	1.3717		.5407	
Max	.7373	.8288	.9259	1.3717	.8097	2.5049	1.1602
Min	.2477	.2477	.2286	.2858	.2477	.1905	.2477
Avg	.4268	.4627	.4840	.4736	.4001	.7670	.6816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 201 / 11KV WALEKHINDI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 202 / 11KV BEVNOOR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 201 / 11 Kv Basargi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1848	.2402			.6944	
2	.1829	.1867	.2402			.7716	
3	.1829	.1867	.2772			.7621	
4	.2134	.1867	.2772			.7621	
5	.2743	.2715	.462			1.142	
6	.2591		.3696			1.3435	
7	.2743	.3403	.4066			1.768	
8		.3109	.3511			1.6821	
9						.2865	
10	.1829	.2195	.2218	.1848		.2507	.8238
11	1.3435	1.3352	1.5893	.2033		.2328	.7522
12	1.4723	1.6644	1.6448	1.0903		.2149	.7701
13	1.3757	1.5339	1.7187	.1663	.2229	.2149	.9492
14	1.3592	1.5893	1.7372	.1294	.1772	.2149	.7343
15	1.3426	1.6095	1.7556	.2218		.2328	.7701
16	1.3272	1.7187	1.7556	.2218	.2896	.2328	.7522
17	1.4175	1.6632			.3292	.2328	.2149
18	1.3272	1.5708			.2926	.1254	.2328
19	.2195	.2218			.2865		.2328
20	.3077	.1848			.362		.2507
21	.2743	.197			.2926		.1791
22	.2195	.197			.2715		.1254
23	.1991	.2149			.3858		.1254
24	.1677	.1848	.2149			.6097	
Max	1.4723	1.7187	1.7556	1.0903	.3858	1.768	.9492
Min	.1677	.1848	.2149	.1294	.1772	.1254	.1254
Avg	.6405	.7169	.8289	.3168	.2910	.6197	.4938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 202 / 11 Kv Basargi Gavtaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0739	.0747			.0566	.0747
2	.0732	.0747	.0747			.0566	.0747
3	.1097	.0747	.0747			.0566	.0747
4	.1463	.0747	.0934			.0566	.0747
5	.1829	.1494	.112			.168	.0934
6	.2195		.112			.2195	.1494
7	.1829	.2328	.1867			.1991	.2054
8	.0732	.181	.1307			.1433	.1494
9		.1448	.0934			.1267	.0934
10	.1075	.1086	.0934	.056		.1086	.112
11	.1086	.1086	.0934	.0934		.0724	.112
12	.1267	.0905	.0747	.0934		.0724	.0934
13	.1097	.0934	.0747	.056	.1629	.0724	.0934
14	.1097	.0934	.0747	.056	.1097	.0724	.0747
15	.0924	.0934	.0747	.0747		.1086	.056
16	.0924	.0934	.0934	.0934	.1109	.1086	.0747
17	.0924	.0934			.128	.1086	.112
18	.1478	.112			.1463	.1086	.1307
19	.1629	.2054			.1991		.1494
20	.2328	.112			.2378		.1867
21	.181	.1494			.1629	.0747	.1307
22	.128	.0943			.1097	.0747	.0747
23	.0924	.0943			.0924	.0724	.0747
24	.0732	.0924	.0754			.0747	.0724
Max	.2328	.2328	.1867	.0934	.2378	.2195	.2054
Min	.0732	.0739	.0747	.056	.0924	.0566	.056
Avg	.1269	.1148	.0945	.0747	.1460	.1006	.1057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 203 / 11 KV Sindur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.8002	1.1203			.2033	
2	1.1088	.9602	1.1203			.2054	
3	1.2012	.9488	1.2289			.2054	
4	1.4784	1.0279	1.4746			.2033	
5	1.7002	1.4815	1.4746			.4298	
6	1.7372		1.9662			.567	
7	2.0328	1.7223	2.3594			.4656	
8	2.1807	1.8964	2.1956			.4344	
9		1.8442	1.9826				
10	.9012	1.0517	1.8842	.2294		1.647	
11	.2149	.2012	.1966	2.1464		1.9728	.2172
12	.2534	.2012	.1966	.213		2.0814	.2172
13	.2012	.168	.1638	1.3927	2.077	2.1357	.2172
14	.2012	.2241	.1638	1.4419	1.9907	2.1719	.1991
15	.1991	.2241	.2458	1.9006		2.19	.1991
16	.1991	.2054	.2458	1.9006	1.9136	2.2081	.181
17	.2507	.2427			.2774	.2715	.1629
18	.2715	.2614			.3582		.2172
19	.3109	.3921			.3258		.2715
20	.362	.3734			.439		.3258
21	.2926	.3361			.3258		.2534
22	.2587	.2987			.2587		.1629
23	.2402	.2241			.2218		.6154
24	.1848	.2195	.2054			.2033	
Max	2.1807	1.8964	2.3594	2.1464	2.077	2.2081	.6154
Min	.1848	.168	.1638	.213	.2218	.2033	.1629
Avg	.7183	.6654	1.0720	1.3178	.8188	1.0351	.2492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 209 / 11 Kv JATH West

Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11KV K. MAHANKAL GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9955	1.1222	.9877	1.0059	.9877	.6036
2		.9593	1.1222	.9694	.9694	.9877	.5853
3		.905	1.086	.9145	.9145	.9694	.5487
4		.9593	1.086	.8779	.9511	1.0059	.6036
5		.9955	1.1222	.9511	.9877	1.0059	.6401
6	1.3213	1.0679	1.1222	1.0242	1.0242	1.0242	.6767
7	1.3394	1.1403	1.1765	1.134	1.0974	1.0608	.6767
8	1.2308	1.0317	1.1403	1.0608	.9694	1.0185	.5853
9	1.086	1.1765	1.2308	1.134	.9335	.8962	.6036
10	1.3394	1.1403	1.2851	1.2071	1.134	1.0974	.7682
11	1.3032	1.2308	1.3937	1.39	1.0242		.8596
12	1.4842	1.3032	1.448	1.4083	.9877		1.3169
13	1.3213	1.3756	1.3937	1.3717	1.0974	1.134	1.3352
14	1.4118	1.3394	1.3032	1.39	1.0608	1.0242	1.3535
15	.8145	1.3213	1.3575	1.3717	1.0425	.9877	1.3169
16	.8869	1.3032	1.3213	1.3535	1.1523	1.0608	1.3535
17	1.3937	1.3394	1.2851	1.3352	1.0242	1.6461	
18	1.3575	.9774		1.39	1.1157		1.5181
19	1.4842	1.5565		1.4632	1.3169		1.5546
20	1.5384	1.4299	1.4661	1.5181	1.39	1.3575	1.6095
21	1.448	1.3937	1.3032	1.39	1.3169	1.1706	1.4998
22	1.3213	1.3032	1.2127	1.2437	1.1888		1.3169
23	1.1765	1.2308	1.086	1.0974			1.1157
24	1.1584	1.0498	1.1584	.9955	1.0059	1.0059	.6401
Max	1.5384	1.5565	1.4661	1.5181	1.39	1.6461	1.6095
Min	.8145	.905	1.086	.8779	.9145	.8962	.5487
Avg	1.2851	1.1886	1.2374	1.2075	1.0744	1.0800	1.0036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2346	1.4582	.373	.0343	.1715	.1029
2		1.2717	1.5939	.3391	.0343	.1715	.0857
3		1.2887	1.6804	.373	.0171	.1715	.12
4		1.3565	1.7661	.407	.0343	.1543	.12
5		1.4582	1.8176	.4239	.0343	.2058	.1543
6	1.1145	1.6617	1.8652	.4578	.0514	.2401	.1715
7	2.0576	2.0178	2.2721	.5426	.0514	.2743	.2058
8	2.1605	2.323	2.34	.5765	.0171	.2572	.1543
9	2.0576	2.3061	2.1026	.6274	.1372	1.2003	.1715
10	2.0576	2.1365	2.2552	.5765	.5487	1.8176	.1696
11	.2058	.2543	.2035	.5426	1.1317	1.9204	.1696
12	.2401	.2204	.2374	.4409	1.1145	2.2119	.1357
13	.2058	.1865	.2374	.373	1.1145	1.749	.1187
14	.2058	.2035	.2035	.5765	1.2254	2.0576	.1357
15	.2229	.2204	.2543	.5596	1.166	2.0233	.1526
16	.2058	.2374	.2713	.5426	1.5775	2.0576	.1526
17	.2229	.2374	.2713		.1543	.1715	.1696
18	.2058	.1865			.2058		.1886
19	.2058	.3222			.2401		.2204
20	.2058	.3222	.0848	.0514	.2401	.1543	.2374
21	.2229	.3052	.0848	.0343	.2229	.1543	.2543
22	.2572	.2883	.1017	.0343	.2058	.12	.2374
23	.2572	.2543	.0848	.0343		.12	.8478
24	.1715	.2401	.2374	.0678	.0343	.1886	.1029
Max	2.1605	2.323	2.34	.6274	1.5775	2.2119	.8478
Min	.1715	.1865	.0848	.0343	.0171	.12	.0857
Avg	.6570	.8556	.9738	.3788	.4171	.7997	.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3944	.3944	.3772	1.0631	1.166	.823
2		.3772	.39	.3429	1.1145	1.1831	
3		.3601	.407	.3601	1.2003	1.1831	
4		.3772	.407	.3944	1.3546	1.5089	
5		.4287	.4239	.4287	1.5261	1.7147	
6		.463	.4801		1.9204	2.2291	
7		.4458	.463	.5304	2.4348	2.7435	
8		.463	.4458	.4801	2.2634	2.8807	1.1145
9		.4287	.4287	.463	.3944	.4287	.9774
10		.4115	.4115	.463	.3772	.4115	1.4403
11		2.2119	2.5034	.4458	.3772	.0857	1.4746
12		2.2634		.4458	.3944	.0857	1.5089
13		2.3663	2.5057	.4458	.4115	.3944	.8402
14	.0857	2.4348	2.3663	.463	.4115	.4287	1.2346
15	.1715	2.2634	2.4006	.4755	.4287	.4115	1.3375
16	.6516	1.9719	2.4863	.5316	.4287	.463	1.3032
17	1.6461	2.0748	2.572	.4801	.4458	.4287	.3601
18	2.0062	1.9033		.4801	.4287		.3944
19	.4287	.4115		.463	.3944		.4287
20	.4801	.4287	.4115	.4801	.4287	.4115	.4115
21	.463	.4287	.4115	.4115	.4287	.4115	.4115
22	.4458	.4115	.4115	.4287	.4287	.3944	.3944
23	.4115	.4115	.4115	1.0288		.8745	.4115
24		.4115	.3944	.3944	1.0117	1.166	.8573
Max	2.0062	2.4348	2.572	1.0288	2.4348	2.8807	1.5089
Min	.0857	.3601	.39	.3429	.3772	.0857	.3601
Avg	.6790	1.0060	1.0060	.4702	.8551	.9548	.8735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV RANJANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4575	1.4243	1.0174	.2204	.2155	
2		1.4752	1.56	.9835	.1865	.1989	
3		1.5261	1.6278	1.153	.1696	.1989	
4		1.56	1.7465	1.2548	.2035	.2486	
5		1.6448	1.8652	1.3565	.3052	.2984	
6		1.7635	2.0687	1.4752	.373	.3647	
7		1.9839	2.1874	1.8143	.3647	.3647	
8		1.8821	2.2552	1.6956	.2486	.2818	.0838
9		1.8652	2.2043	1.9161	1.0608	1.1437	.1006
10		1.3395	1.6956	.9326	1.7901	2.0885	.1006
11		.3052	.2374	2.0517	2.1879	2.3868	
12		.2713	.2374	1.8991	2.2045	2.4366	
13		.2374	.2713	1.8652	2.2045	2.1879	
14		.2543	.2374	1.7804	2.3205	2.3205	
15		.2713	.2883	1.8991	2.3868	2.4034	
16	.3429	.2883	.3052	2.0348	1.7736	2.4697	
17	.3772	.2883	.3391	.2713	.2818	.2984	
18	.3944	.2374		.3391	.1989		
19	.583	.3222		.4409	.3812		.463
20	.4801	.407	.2883	.4748	.3812	.2652	.4115
21	.4287	.373	.2713	.3222	.3315		.3429
22	.3772	.3391	.2543	.2543	.2652		.3429
23	.3429	.3052	.2035	.2374			.9602
24		.3086	.2883	.2035	.2204	.2321	
Max	.583	1.9839	2.2552	2.0517	2.3868	2.4697	.9602
Min	.3429	.2374	.2035	.2035	.1696	.1989	.0838
Avg	.4158	.8628	.9935	1.1530	.8722	1.0739	.3507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV LANGERPETH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.1715	.12	.7888	.8573	
2		.1372	.1543	.1029	.8573	.8573	
3		.1372	.1526	.12	.9431	.8573	
4		.1715	.1526	.1715	1.1145	.9431	
5		.2058	.2058	.1886	1.2003	1.0631	
6		.2572	.2743	.2229	1.2689	1.3717	
7		.1715	.2401	.2058	1.6975	1.8004	
8		.1715	.2229	.1886	1.0631	1.7661	
9		.1886	.2058	.1543	.1372	.1543	
10		.1886	.1543	.1372	.1029	.1715	
11	1.3546	1.5261	1.7661	.1029	.1372	.1029	1.2894
12	1.5604	1.6118		.0857	.12	.1372	1.3253
13	1.5947	1.6461	1.989	.1029	.12	.1029	1.2894
14	.1715	1.7147	2.0576	.1372	.1029	.1372	1.4685
15	1.3032	1.7833	2.1091	.1543	.0686	.1715	1.5402
16	1.5261	1.749	2.1091	.2058	.12	.1543	1.5402
17	1.8347	1.8519	1.8347	.1715	.1372	.1372	.1254
18	1.8861	1.166		.1372	.1543		.1433
19	.2229	.2058		.1372	.1886		.1612
20	.2401	.2229	.1372	.1543	.1715	.1372	.1433
21	.2058	.2058	.1543	.1372	.1715		.1612
22	.1715	.1886	.1372	.1543	.1715		.1612
23	.1543	.1886	.1543	.7716			.1254
24		.1543	.1715	.1372	.8059	.8402	
Max	1.8861	1.8519	2.1091	.7716	1.6975	1.8004	1.5402
Min	.1543	.1372	.1372	.0857	.0686	.1029	.1254
Avg	.9405	.6666	.6931	.1750	.5062	.6191	.7288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.FACTORY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5432	1.4243			.2229	
2		1.5775	1.5939			.2229	
3		1.6108	1.7804			.2058	
4		1.7295	1.8991			.2572	
5		1.8991	2.1365			.2915	
6		2.0687	2.34			.3601	
7		2.4247	2.9843			.3429	
8		2.7978	3.103			.3086	
9		2.6452	2.9843			1.0288	
10	1.5089	2.4247	2.7978			1.7147	
11	.3944	.373	.407		.4115	2.1948	.2035
12	.4287	.39	.4578		1.1488	2.2291	.1865
13	.4287	.3391	.4239	1.2209	1.166	2.1948	.2035
14	.3601	.373	.4748	1.4413	1.3717	1.8861	.1696
15	.3772	.39	.4917	1.3904	1.406	2.0576	.1526
16	.3086	.407	.5596	1.3735	1.2346	2.3148	.1526
17	.2743	.39		.2374	.3258	.3429	.1865
18	.3944	.4748		.3052	.2915		.1865
19	.4115	.5087		.3561	.3944		.2035
20	.4115	.5256		.3561	.4458		.2204
21	.3772	.4748			.3772		.2374
22	.3258	.407			.3086		.2374
23	.2401	.407					.6443
24		.2229	.407			.2401	
Max	1.5089	2.7978	3.103	1.4413	1.406	2.3148	.6443
Min	.2401	.2229	.407	.2374	.2915	.2058	.1526
Avg	.4458	1.1002	1.5450	.8351	.7402	1.0231	.2296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV EXPRESS MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.0716	.1612	.1433	.1075	.1254	.0716
2	.1433	.0716	.1254	.1254	.1075	.1254	.0537
3	.0895	.0537	.1254	.1254	.0895	.1075	.0358
4	.0895	.0537	.0716	.0895	.0895	.0895	.0358
5	.0895	.0358	.0537	.0895	.0895	.0716	.0358
6	.0716	.0179	.0537	.0716	.0895	.0895	.0537
7	.0537	.0537	.0895	.0537	.0895	.0895	.0537
8	.0537	.0716	.0895	.0537	.1075	.0895	.0716
9	.0537	.1075	.0895	.0537	.1075	.0537	.0895
10	.0716	.1254	.1227	.1254	.1433	.1075	.1075
11	.0895	.1433	.1433	.1612	.1612	.1433	.1612
12	.0895	.1433	.1612	.1433	.1612	.1791	.1791
13	.1075	.1612	.1433	.1612	.2149	.1612	.1791
14	.0895	.1433	.1075	.1433	.1791	.1612	.1612
15	.0716	.1612	.1075	.1433	.1433	.1433	.1254
16	.0716	.1433	.1254	.1075	.1254	.1254	.1075
17	.0358	.1433	.0895	.1075	.0895	.1254	.1075
18	.0179	.1075		.0895	.0716		.0895
19	.0179	.1433		.0895	.0716		.0716
20	.0537	.1612	.0895	.1075	.1075	.0537	.1612
21	.0716	.1791	.0716	.1075	.1075	.1075	.197
22	.0895	.197	.1612	.1433	.1254	.1075	.1791
23	.0895	.1791	.1433	.1612		.0895	.1433
24	.1612	.0895	.1612	.1791	.1254	.1254	.0716
Max	.1612	.197	.1612	.1791	.2149	.1791	.197
Min	.0179	.0179	.0537	.0537	.0716	.0537	.0358
Avg	.0798	.1149	.1130	.1157	.1176	.1123	.1060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV LANGERPETH GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.3224	.4119	.2507	.1254	.3224	.197
2	.0716		.3761	.2328	.1254	.3224	.1791
3	.0716	.2328	.3761	.2149	.1433	.3045	.2328
4	.0895	.2686	.3582	.2686	.1612	.3045	.3224
5	.0895	.394	.4119	.3224	.197	.3582	.3761
6	.1075	.4835	.4477	.3582	.2328	.4656	.4298
7	.1433	.5014	.4835	.4119	.4298	.4835	.4477
8	.394	.4656	.5014	.3582	.0716	.4656	.4119
9	.4119	.4656	.3761	.4119	.1433	.3582	.1433
10	.197	.4835	.4656	.4656	.197	.4656	.394
11	.4298	.4656	.3761	.394	.3045	.4477	.3582
12	.4477	.4477	.5194	.4298	.4835	.5373	.3224
13	.4119	.4298	.4298	.4119	.394	.394	.2507
14	.3582	.4119	.3761	.394	.3582	.4298	.2507
15	.3224	.394	.394	.3582	.2328	.394	.2328
16	.1791	.394	.3224	.3403	.3761	.3761	.2328
17	.394	.4119	.5194	.394	.3582	.3582	.2507
18	.5373	.394		.4477	.4835		.2865
19	.6089	.4656		.4835	.591		.3582
20	.6089	.5194	.4477	.4656	.591	.3761	.3403
21	.5731	.5014	.4656	.4477	.5194	.394	.3582
22	.5194	.5014	.3582	.3761	.4656	.3403	.3761
23	.4477	.4656	.3403	.1433		.2328	.2328
24	.0716	.3761	.4119	.2865	.1433	.3403	.2149
Max	.6089	.5194	.5194	.4835	.591	.5373	.4477
Min	.0716	.2328	.3224	.1433	.0716	.2328	.1433
Avg	.3149	.4259	.4168	.3612	.3099	.3851	.3000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV SHIRDHON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2353	.2427		.2378	.4858	.1928
2	.1886	.2195	.2378	.0732	.3315		.1907
3	.1698	.2195	.2195	.0732		.4915	.1715
4	.1698	.2353	.2378	.0924		.5967	.1907
5	.2054	.2378	.2561	.0934		.6299	.1907
6	.2801	.3326	.3292	.0747		.6882	.1928
7	.3142	.4435	.3881	.0754		.8162	.4694
8	.3658	.3605	.4066	.0716		.8065	.5117
9		.3605				.1357	.4401
10	.2454	.463		.0739		.1629	.3591
11	1.8404		2.7046	.037			.4214
12	2.2085	1.7718	.3077			.1067	.3429
13	2.226	1.5592	2.4741	.037	.0848		.4512
14	2.0908	1.7551	2.9473	.037	.0838		.4988
15		2.6642	2.5415	.0362	.0848	.2713	.5117
16		2.4188	2.93		.0848	.4075	.602
17		2.3137	2.5312	.0362	.0838		.1886
18		2.7694		.0905	.0848		.1829
19	.3077	.2926		.3258	.0857		.2218
20	.3121	.3361		.2012	.0924		.2054
21	.3189	.2801		.2149	.1494		.2012
22	.253	.2614		.1227	.2012	.2149	.1663
23	.2372	.2614		.3521	.4111		.1478
24	.1867	.2187	.2614			.4481	.1753
Max	2.226	2.7694	2.9473	.3521	.4111	.8162	.602
Min	.1698	.2187	.2195	.0362	.0838	.1067	.1478
Avg	.6373	.87	1.1885	.1115	.1551	.4473	.3011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV BORGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.1698		.1698	.1698	.132
2	.132	.132	.1698	.132	.1698	.1698	
3	.132	.1132	.1698	.1132	.1509	.1509	.1132
4	.132	.1132	.1509	.132	.1509	.1509	.1132
5	.1509	.132	.1509		.1509	.1698	.132
6	.1905	.1509	.1698	.1509	.1905	.1698	.132
7	.1509	.1663	.1867	.1509	.1886	.1886	.1698
8	.1334	.1698	.1867	.1829	.1698	.1646	.1509
9	.168	.1494		.1578	.1663		.112
10	.1463	.1829		.2103	.1341	.1463	.1595
11	.1417	.168	.1448	.2195	.1463	.1848	.1629
12	.1433	.168	.1829	.1886	.128	.1698	.132
13	.1254	.1509	.1478		.1307		.1132
14	.128	.1698	.1463	.1509	.1307	.1509	.132
15	.112	.2263	.1463	.1509	.1509	.1867	.1307
16	.132	.1698	.1663	.1698	.1509	.2195	.1494
17	.1509	.1509	.1698	.168	.168	.1629	.1132
18	.1848	.181		.2033	.1829		.1791
19	.2054	.1886		.2033	.1991		.168
20	.2452	.2641		.2263	.2452		.2075
21	.1886	.2452		.2263	.2075		.2263
22	.1698	.2263		.2263	.1698	.1886	.1886
23	.1509	.2075		.1886	.1509		.1478
24	.1509	.1509	.1886		.1509	.1509	.1509
Max	.2452	.2641	.1886	.2263	.2452	.2195	.2263
Min	.112	.1132	.1448	.1132	.128	.1463	.112
Avg	.1548	.1712	.1655	.1776	.1647	.1703	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2075	.2263		.9393	.9488	.6554
2	.1886	.1886	.2075	.2987	.9069	1.012	.664
3	.1886	.1886	.2075	.2195	.9175	1.0562	.664
4	.2075	.2075	.2075	.2195	.9831	1.0883	.6802
5	.2263	.2263	.2263	.2195	1.1142	1.166	.7287
6	.2614	.2641	.3018	.2587	1.2597	1.2944	.7773
7	.2987	.3395	.3547		1.3413	1.5384	.8162
8	.3547	.3361	.3206	.2534		1.8023	.8124
9	.3547	.3696				.2353	.7499
10	.1991	.3326				.2715	.679
11	2.3644	2.2245	2.6707			.2587	.7499
12	2.8182	2.6871	.3658			.2195	.8025
13	2.8018	2.5911	3.0148	.2218	.1991		.884
14	2.5911	2.5888	2.8675	.2218	.2172	.2801	.7407
15	2.3205	2.7183	2.7932	.2195	.2195	.2641	.8124
16	2.7349	2.6871	3.0996	.2561	.2378	.2587	.8124
17	2.8018	3.0498	3.0639	.2172	.2378	.2218	.1753
18	2.6558	2.9165		.1991	.2561		.1949
19	.3326	.2772		.2172	.2772		.2033
20	.3547	.3734		.2075	.2987		.2241
21	.2801	.2987		.2012	.2829		.2263
22	.2614	.2801		.2054	.2427	.3511	.2075
23	.2427	.2427		.6722	.9175		.1509
24	.2075	.2241	.2263		.6535	.9061	.639
Max	2.8182	3.0498	3.0996	.6722	1.3413	1.8023	.884
Min	.1886	.1886	.2075	.1991	.1991	.2195	.1509
Avg	1.0523	1.0758	1.2596	.2534	.6054	.7319	.5854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV SHIVGANGA GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.1494		.1227	.1132	.1307
2	.0943	.1132	.1494		.1227	.1132	.1294
3	.0943	.1132	.1494		.1075	.0943	.1109
4	.1132	.0943	.1509		.1254	.1132	.1097
5	.132	.1132	.1509		.1267	.1132	.1097
6	.1698	.132	.1698		.1463	.132	.112
7	.128	.1509	.1867		.1132	.132	.1132
8	.1267	.132	.1132		.1132	.1132	.1509
9	.112	.1509			.132		.112
10	.1509	.2241			.1509	.181	.181
11	.132	.2263	.2263	.2012	.1698		.1698
12	.1509	.2641	.1886	.181	.1698		.2075
13	.1698	.1509	.1829		.1698	.1132	.1509
14	.1698	.1886	.1829	.1463	.1886	.132	.1886
15	.1698	.2402	.132	.1494	.2075	.1509	.2263
16	.1509	.2075	.1509	.1698	.1886	.1886	.2075
17	.1509	.2263	.1478	.1698	.1886	.1867	.1886
18	.1132	.1509		.1698	.1509		.1307
19	.2263	.1509			.132		.1494
20	.1886	.1698		.181	.1509		.1478
21	.1509	.1646		.1629	.1509		.1307
22		.1646		.1254	.1494	.1494	.1267
23	.1494	.168		.1086	.128		.1267
24	.1132	.1294	.1494		.1086	.132	.1494
Max	.2263	.2641	.2263	.2012	.2075	.1886	.2263
Min	.0943	.0943	.1132	.1086	.1075	.0943	.1097
Avg	.1422	.1649	.1613	.1605	.1464	.1349	.1483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV SHIRDHON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2075	.2452		.2075	.1886	.2012
2	.2263	.1886	.2452	.2012	.2263	.1886	.1829
3	.2241	.1698	.2641	.2012	.2054	.2075	.1663
4	.2427	.1698	.2452	.2012	.2054	.2075	.1663
5	.2402	.1886	.2641	.1867	.2241	.2263	.1848
6	.2743	.2075	.2641	.1867	.2614	.2241	.1848
7	.2507	.2353	.2743	.1494	.2241	.2614	.1791
8	.2149	.2254	.2378	.1214	.2012	.2378	.2149
9	.1865	.2058		.1402	.208		.2126
10	.1865	.2103		.1478	.2229	.208	.1595
11	.2229		.1753	.1478	.2254		.1772
12	.2328	.2401	.208		.208		.2572
13	.2378	.2865	.2103	.2507	.2126		.2058
14	.2172	.2865	.2126	.2686	.1949	.2035	.2401
15	.2378	.2774	.2149	.2686	.2103	.2126	.2279
16	.2353	.2743	.2172	.2865	.2103	.1949	
17	.2507	.2507	.2481	.2865	.2454	.208	.1928
18	.2401	.2481		.2865	.2835		.2534
19	.2743	.2896		.3439	.3045		.2561
20	.3547	.4108		.3658	.3584		.3511
21	.3326	.3475		.3142	.3395		.3174
22	.3174	.3206		.2452	.3018	.2149	.2829
23	.2801	.3018		.2075	.2452		.2075
24	.2829	.2427	.2452		.1886	.2075	.2218
Max	.3547	.4108	.2743	.3658	.3584	.2614	.3511
Min	.1865	.1698	.1753	.1214	.1886	.1886	.1595
Avg	.2511	.2515	.2357	.2289	.2381	.2127	.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV ALKUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.8063	.7373		.2126	.1949	.1307
2	.7045	.8764	.7802		.197	.1772	.1294
3	.6882	.9214	.7802		.197	.1753	.1715
4	.7537	.8413	.7975		.2149	.156	.1734
5	.9393	.9709	.8669		.2481	.1715	.1907
6	1.1043	1.0288	1.0402		.2835	.208	.208
7	1.3123	1.0923	1.4243		.2686	.208	.2835
8	1.4243	1.153	1.4419		.2353	.1629	.1829
9	1.4255	1.2346			.4382	.4801	.1867
10	.9717	1.2209		.3506	.4801	.6706	.132
11	.197	.2454	.2303	.4207	.5201		.1509
12	.2149	.2279		.5548	.5959		.1509
13	.2328	.2328	.2303	.6068	.6344	.8288	.1509
14	.2149	.2454	.2254	.6173	.6588	.9724	.1509
15	.2149	.2254	.1753	.6104	.7282	.8124	.1109
16	.2507	.2454	.2254	.6104	.7087	.9414	.1463
17	.2835	.2804	.2279	.1753	.1097	.2534	.1509
18	.3224	.2835		.1753	.1463		.1294
19	.2865	.298			.2149		.1494
20	.3155	.3155		.2353	.2481		.2172
21	.2658	.2774		.2353	.2303		.197
22	.2254	.2774		.2328	.2103	.208	.394
23	.2103	.2601		.2195	.2103		.1402
24	.197	.208	.2572		.2195	.1928	.1494
Max	1.4255	1.2346	1.4419	.6173	.7282	.9724	.394
Min	.197	.208	.1753	.1753	.1097	.156	.1109
Avg	.5622	.5737	.6294	.3880	.3421	.4008	.1740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.2263	.9619	.2058	.9259	1.0185	.6173
2	.823	.2829	.9054	.2058	.9259	1.3014	.6173
3	.7202	.3395	.7356	.4115	.823	1.0751	.5658
4	.7716	.3395	.7922	.5144	.823	1.0185	.5144
5	.7202	.3961	.9054	.6173	.7716	1.0185	.463
6	.6687	.4527	.9054	.8745	.7716	.9619	.4115
7	.5144	.4527	.5093	.6687	.7716	.9054	.5144
8	.3086	.2263	.3961	.6687	.8745	.679	.3086
9	.3395	.2829		.6173	.8745		.9619
10	.3961	.6224		.2058	.5093	.463	.679
11	.5093	.3961	.2572	.2058	.8488	.3601	.2263
12	.3395	.3395	.2058	.2572		.2572	.7356
13	.3961	.0114	.3601	.2572	.7356		.3395
14	.4527	.3961	.2572	.2572	.9619	.5658	.0114
15	.2829	.3395	.3601	.3681	.6224	.6173	.0114
16	.2829	.7922	.6173	.5144	.7922	1.0288	.1143
17	.2263	1.0185	.6687	.7716	1.1883	1.0288	.7922
18	.1698	.9619		1.0802	1.0751		.9619
19	.1698	1.2449		1.0288	.7356	.7202	.9619
20	.1698	1.1317		.9259	.7356	.823	.9054
21	.1698	1.0751		.9774	.7922		.7356
22	.1698	1.0751		1.1317	1.2449	.823	.9054
23	.2263	1.0185		.7202	.7356		.679
24	.9259	.2263	1.2449	.3086	.7716	.8488	.5658
Max	.9259	1.2449	1.2449	1.1317	1.2449	1.3014	.9619
Min	.1698	.0114	.2058	.2058	.5093	.2572	.0114
Avg	.4407	.5687	.6302	.5748	.8396	.8165	.5666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11KV DUDHEBHAVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1865				
2		.1696				
3		.1677				
4		.1696				
5		.1865				
7		.3018				
8		.4191				
9	1.8442	.9221				
10	1.7604		1.4575		.7377	.1886
11	.2035		.1372		.8817	.1715
12	.1865		.12		.9556	.1578
13	.2035		.0857		1.0174	.1753
14	.2035		.2058		1.0174	.1578
15			.1886		1.073	.1753
16	.1341		.1928		1.073	.1578
17	.1844		.1715		.2035	.1753
18	.1844		.1886		.218	.2454
19	.3052		.2058		.2543	.2279
20	.2713		.2058		.2374	.2454
21	.2743		.1715		.2374	.2454
22	.2058		.1578		.2012	.2103
23	.2035		.1543		.1865	.5434
24		.2035		.1543		
Max	1.8442	.9221	1.4575	.1543	1.073	.5434
Min	.1341	.1677	.0857	.1543	.1865	.1578
Avg	.4403	.3029	.2602	.1543	.5924	.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV NAGAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5087			.2058	
2		.6443			.2058	
3		.6371			.2229	
4		.8139			.2401	
5		1.0059			.2743	
6		1.5089			.3086	
7		1.5424				
8		1.6108				
9	1.1869	1.4243				
10	1.1191	1.1736	1.3889		.4694	.2279
11		.1865	.1886		.5426	.2103
12	.2058	.2012	.2058		.6783	.1928
13	.2374	.1865	.2058		.7712	.1052
14	.2374	.2012	.2058		.8139	.1227
15	.2543	.1865	.2401		.8048	.1463
16	.2543	.1844	.2572		.8478	.1402
17	.2204	.1696	.2743		.1696	.1578
18	.2713	.1844	.2743		.2374	.1646
19	.2713	.1677			.2543	.2454
20	.2543	.1844	.2058		.2543	.2629
21	.2543	.1696	.2058		.2374	.2454
22	.218	.1677	.1886		.1886	.2172
23	.2035				.1734	.3681
24		.2012		.1753	.2035	
Max	1.1869	1.6108	1.3889	.1753	.8478	.3681
Min	.2035	.1677	.1886	.1753	.1696	.1052
Avg	.3706	.5766	.3201	.1753	.3859	.2005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV CHOROCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1696				
2		.1715				
3		.1715				
4		.1865				
5		.2035				
6		.2035				
7		.2035				
8		.1865				
9		.1341				
10			.1715		.1696	.5959
11	.3018				.1357	.5258
12	.5596				.1006	.4733
13	.4748				.1006	.4908
14	.503				.1017	.4382
15	.4694		1.1145		.1006	.4382
16	.4527		1.2269		.1017	.4557
17	.4527		1.1488			.2103
18	.373		1.0517			.1928
19	.2035		.1886		.2035	.1578
20	.2204		.1715		.2204	.1578
21	.2204		.1753		.2035	.1402
22	.1886		.12		.2012	.1402
23	.1865				.3052	.1417
24		.1865		.1267		
Max	.5596	.2035	1.2269	.1267	.3052	.5959
Min	.1865	.1341	.12	.1267	.1006	.1402
Avg	.3543	.1817	.5965	.1267	.1620	.3256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV DHALEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5935	
2					.6859	
3					.8573	
4					.9602	
5					1.0288	
6					1.0631	
7		.2713				
8		.2713				
9	.1696	.2374				
10	.1357	.2012	.1715		.1696	.8238
11	.8478	.7042	1.2003		.1357	.8764
12	.9054	.5087	1.2174		.1187	.8589
13	1.0059	.6783	1.2269		.12	.8764
14	1.1022	.8478	1.4198		.12	1.0692
15	1.1869	.7969	1.3889		.1526	1.1218
16	1.2071		1.4373		.1526	1.1393
17	1.2407	1.1904	1.3546		.1696	1.1393
18	1.2548	1.0174	.2058		.1865	.1402
19	.2713	.1844	.1928		.1844	.2629
20	.2543	.1865	.2058		.2204	.2629
21	.2401	.2012	.2229		.2204	.2454
22	.1543	.1865	.2401		.2012	.2103
23	.1526	.1677	.1372		.3391	.1753
24		.1526		.1387	.2743	
Max	1.2548	1.1904	1.4373	.1387	1.0631	1.1393
Min	.1357	.1526	.1372	.1387	.1187	.1402
Avg	.6752	.4590	.7587	.1387	.3788	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV CHOROCHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1387			.1543	
2		.1402			.1715	
3		.1402			.1715	
4		.1387			.2229	
5		.156			.2229	
6		.1886			.2035	
7		.208				
8		.208				
9	.1907	.156				
10	.1715	.1543	.1715		.1734	.1646
11	.1907	.156	.1543		.156	.1753
12	.1907	.1372			.1543	.1578
13	.1928	.1387			.156	.1646
14	.1928	.1372			.156	.1578
15	.1907	.1214	.1886		.1578	.1578
16	.2058	.1543	.2058		.1578	.1578
17	.2229	.1387	.2058		.1578	.181
18	.208	.12				.1753
19	.208	.1214			.2774	.2629
20	.2254	.1372	.2058		.2601	.2715
21	.2279	.1214	.1928		.2427	.2454
22	.1907	.1372	.1753		.1886	.1928
23	.1734	.1214	.1578		.1734	.1578
24		.156		.1402	.1543	
Max	.2279	.208	.2058	.1402	.2774	.2715
Min	.1715	.12	.1543	.1402	.1543	.1578
Avg	.1988	.1470	.1842	.1402	.1856	.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV DUDHEBHAVI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0867				
2		.0867				
3		.0857				
4		.1029				
5		.1214				
6		.156				
7		.1387				
8		.104				
9	.2427	.1214				
10	.2454	.156	.1886		.1734	.1928
11		.1543	.1372		.156	.1829
12	.1387	.1907	.1372		.1907	.1753
13	.208	.1715	.1753		.1907	.181
14	.2279	.1734	.1886		.1052	.1928
15	.2254	.1886	.1886		.1387	.1928
16	.2572	.156	.2058		.1387	.2103
17	.2743	.1543	.1886		.2427	.2279
18	.208	.156	.1886		.2601	.2454
19	.208	.1734	.2058		.2601	.2629
20	.1907	.208	.2058		.2572	.2629
21	.1715	.1886	.1715		.208	.2229
22	.1214	.1734	.1543		.1214	.1928
23	.1214	.1543	.1543		.1214	.1715
24		.104		.1448		
Max	.2743	.208	.2058	.1448	.2601	.2629
Min	.1214	.0857	.1372	.1448	.1052	.1715
Avg	.2029	.1461	.1779	.1448	.1832	.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV SHELKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6405		1.0526		.2263		.0377
2	.6405		1.1336		.2263		.0189
3	.703		1.1822	.3725	.2452		.0189
4	.8619		1.2289	.4534	.2641		.0189
5	1.0608		1.3599	.6001	.3395		.0381
6	1.1603		1.5424	.7545	.5281		.0381
7	1.8399		1.9113	.7293	.4904		.0377
8		2.0885	1.9725	.779	.3206		.0377
9	1.757	.1989	1.6741	.7611		.6316	.0377
10	1.4419	1.5546	1.6385	.6562	.2515	.8848	.0377
11	.2743	.2801	.3109		.8356	1.0814	.0189
12		.3142	.3511	.7773		1.1305	.0189
13	.2561	.2328	.3174	.7373		1.1961	.0189
14	.2614	.2149	.2987	.6401	.7449	1.1305	.3547
15		.2686	.2987	.5761		1.442	.2957
16	.2561	.2926	.3109	.5668		1.1043	.2715
17	.2835	.3109	.3109	.2743		.2229	.2957
18	.2926	.3696		.2957	.1829	.2686	.2987
19	.3292	.3734		.3361			.3361
20	.3921	.4481		.3734	.3547		.4338
21	.3961	.4108		.3206			.3395
22	.3174	.3547		.2829			.2801
23		.2987		.2427		.0377	.5079
24	.2402		.2801		.2263		.0377
Max	1.8399	2.0885	1.9725	.779	.8356	1.442	.5079
Min	.2402	.1989	.2801	.2427	.1829	.0377	.0189
Avg	.6702	.5007	.9542	.5265	.3740	.8300	.1596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.112		.1966		.0648
2			.112		.1966		.0648
3			.112		.1966		.0648
4			.1494		.2155		.0648
5			.1886		.2374		.1187
6	.2427		.2263		.4287		.1526
7	.2427		.2075		.4334		.1406
8		.168	.1494	.0754			.16
9	.0934	.1448	.112	.0754		.0716	.1524
10	.1063	.1494	.1086			.0739	.1389
11	.9878	1.0442	1.065			.0732	.3906
12	1.1873	1.1633	1.2643			.0693	.4744
13	.9962	1.1174	1.2003			.0693	.4744
14	.1086	1.1498	1.1174			.0716	.4902
15		1.2308	1.166			.0543	.3725
16	1.0364	1.2955	1.4091			.0693	.4586
17	1.3763	1.3603	1.4255	.1109		.0886	.1063
18	1.0957	1.1363			.2012	.1086	.1132
19	.168	.1478		.1509		.1254	.1307
20	.1867	.168		.1509	.132		.132
21	.1886	.168		.1132			.1097
22	.1663	.1494		.1132			.0924
23		.1307		.1781		.0972	.0934
24			.112		.1966		.0648
Max	1.3763	1.3603	1.4255	.1781	.4334	.1254	.4902
Min	.0934	.1307	.1086	.0754	.132	.0543	.0648
Avg	.5455	.6702	.5687	.121	.2435	.0810	.1927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV RAIWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.0747		.1875		.0937
2	.0905		.0747		.1875		.0937
3	.0905		.0747	.0747	.1898		.0937
4	.0905		.112	.112	.2056		.125
5	.1509		.1698	.1494	.2881		.2035
6	.1886		.2263	.2241	.5079		.2713
7	.1698		.1867	.168			.2968
8		.1478	.1509	.128			.3311
9	.1132	.1478	.1307	.1109	.0377	.0886	.2896
10	.0732	.1097	.128	.1086	.0377	.0747	.2503
11	.5218	.6539	.5624		.0377	.0739	.2347
12	.4843	.68	.7343	.112		.0739	.2107
13	.4218	.6718	.7186	.0739		.0739	.2201
14	.1463	.6405	.578	.0924	.0377	.0739	.2378
15		.6718	.6249	.0924		.0739	.208
16	.6325	.6944	.8065	.1307		.1132	.2824
17	.6081	.7099	.8381	.1097		.0678	.0701
18	.6249	.5639			.1844	.0876	.0905
19	.1448	.1086		.132		.0924	.0914
20	.1307	.1478		.1509	.1698		.1307
21	.1109	.1307		.1132		.0747	.112
22	.112	.0934		.0943		.0754	.056
23		.0747		.1739		.1296	.056
24			.0747		.1898		.1094
Max	.6325	.7099	.8381	.2241	.5079	.1296	.3311
Min	.0732	.0747	.0747	.0739	.0377	.0678	.056
Avg	.2498	.3904	.3481	.1237	.1739	.0838	.1733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV SHELKEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075		.2075		.1886		.1509
2	.1886		.2075		.1886		.1509
3	.1886		.2075	.1886	.1886		.1509
4	.2452		.2452	.2263	.2075		.2263
5	.3395		.3018	.2829	.2452		.3206
6	.4338		.3772	.3584	.3584		.4338
7	.3361		.3018	.3361	.3018		
8		.2926	.2801	.2561	.2641		.2452
9	.2801	.2534	.2561	.2353	.2075	.2378	.1867
10	.2534	.2561	.2481	.2328	.1867	.2195	.1509
11	.2378	.2328	.2534		.1509	.2054	.1698
12		.2561	.2241	.2263		.2054	
13	.2241	.2241	.2241	.2614		.2263	.2033
14	.128	.2263	.2452	.2452	.2241	.2075	.2241
15		.2263	.2452	.2241		.2075	.2263
16	.2241	.2561	.2614	.2075		.2218	.2241
17	.1829	.2561	.2614	.2561		.2561	.2218
18	.2561	.2835		.2926	.2195	.2534	.2614
19	.3109	.3475		.3547		.3361	.3018
20	.3921	.3734		.3584	.415	.2075	.3584
21	.3772	.3361		.2829		.2641	.3206
22	.3018	.3018		.2641		.2075	.2477
23		.2452		.1886		.1698	.1886
24	.2452		.2263		.1886		.1698
Max	.4338	.3734	.3772	.3584	.415	.3361	.4338
Min	.128	.2241	.2075	.1886	.1509	.1698	.1509
Avg	.2677	.2730	.2541	.2639	.2357	.2284	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294		.1109		.1132		.0189
2	.1109		.1109		.1132		.0189
3	.1109		.1109		.1132		.0189
4	.1494		.1494		.132		.0189
5	.1867		.2241		.1698		.0377
6	.2427		.2801		.2263		.0377
7	.1294		.168		.1886		.0377
8		.1829	.1867				.0377
9	.168	.1829	.1494	.2054		.1494	.0377
10	.1494	.1494	.1494	.2054		.128	.0377
11	.1463	.1307	.0914		.1463	.1829	.1509
12	.128	.1307	.1478			.1494	.1886
13	.1463	.1294	.1478	.0377		.1294	.168
14	.1463	.0924	.1494	.1132		.1494	.1132
15		.1109	.1494	.1663		.168	.1886
16	.1307	.1494	.168			.1494	.132
17	.0905	.1494	.168	.2427		.1494	.1494
18	.128	.1867			.1848	.1494	.1307
19	.1646	.2054		.2241		.1867	.2054
20	.2378	.2241		.2452	.2743		.2452
21	.2195	.2054		.1886			.2075
22	.1494	.1867		.1698			.1509
23		.1294		.1132		.0566	.1132
24	.1294		.1294		.0943		.0377
Max	.2427	.2241	.2801	.2452	.2743	.1867	.2452
Min	.0905	.0924	.0914	.0377	.0943	.0566	.0189
Avg	.1521	.1591	.1551	.1738	.1596	.1457	.1035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV RAIWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655		.0678		.0724		.0189
2	.0492		.0678		.0724		.0189
3	.0492		.0678	.0373	.0724		.0189
4	.0566		.0724	.0373	.0732		.0566
5	.0754		.0905	.0943	.0924		.0566
6	.0754		.0924	.1132	.112		.0754
7	.0739		.1132	.1086	.0943		.1132
8		.1463	.0895	.1063			.1109
9	.1075	.124	.1097	.1063	.0754	.0747	.1187
10	.1029	.1097	.1029	.0914	.0549	.0537	.0709
11	.128	.128	.0848		.0732	.0709	.0686
12	.1267	.1214	.1029	.1052		.0709	.0663
13	.1097	.1372	.1029	.104		.0701	.0838
14	.0914	.1214	.12	.0867	.0914	.0532	.1187
15		.1214	.12	.0693		.0724	.1174
16	.0914	.116	.1372	.0709		.0876	.1147
17	.112	.116	.1372	.0895		.0829	.116
18	.1417	.1029			.0905	.0886	.1214
19	.1086	.1372		.1109		.0566	.0924
20	.1254	.1417		.128	.112		.1109
21	.128	.1214		.1097		.0377	.0754
22	.1463	.1214		.0914		.0377	.0381
23		.0995		.0724		.0377	.0189
24	.0709		.0848		.0724		.0189
Max	.1463	.1463	.1372	.128	.112	.0886	.1214
Min	.0492	.0995	.0678	.0373	.0549	.0377	.0189
Avg	.0969	.1228	.0980	.0912	.0828	.0639	.0759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV JAKHAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838		.1341		.0943		.0377
2	.0838		.1341		.0943		.0377
3	.0838		.1677	.0671	.0943		.0377
4	.1174		.218	.0838	.0943		.0566
5	.1509		.2652	.1006	.1132		.0934
6	.1844		.3149	.1174	.1698		.112
7	.3768		.431	.1509	.1132		.112
8		.2321	.4807	.1341	.1132		.112
9	.4096	.3932	.3978	.1341	.1475	.1357	.0943
10	.2155	.3113	.2984	.1509	.1326	.1696	.0566
11	.0934	.1307				.2458	.0566
12		.0754	.132	.1802		.2622	.0572
13	.1307	.0943	.1132	.2155		.2622	.0381
14	.0934	.0754	.1132	.1475	.1802	.2155	.0572
15		.0754	.1132	.1475		.2155	.0572
16	.0934	.0943	.1494	.2155		.2949	.0566
17	.0934	.0943	.1494			.0566	.0754
18	.0934	.1307			.1307	.0754	.0943
19	.0747	.1494		.1132		.0754	.0943
20	.056	.168		.0762	.0934	.0754	.0943
21	.0566	.168		.1509		.0754	.0754
22	.056	.1494		.1132		.0754	.0762
23		.1132		.1132		.0566	.0655
24	.0566		.0754		.0943		.0566
Max	.4096	.3932	.4807	.2155	.1802	.2949	.112
Min	.056	.0754	.0754	.0671	.0934	.0566	.0377
Avg	.1302	.1534	.2169	.1340	.1190	.1528	.0710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
9	1.8298	
24		.3696
Max	1.8298	.3696
Min	1.8298	.3696
Avg	1.8298	.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV KOKLE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.3841	
10	.1829		
24			.3142
Max	.1829	.3841	.3142
Min	.1829	.3841	.3142
Avg	.1829	.3841	.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.3841	
10	.4294		
24			.3696
Max	.4294	.3841	.3696
Min	.4294	.3841	.3696
Avg	.4294	.3841	.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.1307	
10	.1294	.128	
24			.1294
Max	.1294	.1307	.1294
Min	.1294	.128	.1294
Avg	.1294	.1294	.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
10	.0934	.0747	
24			.1109
Max	.0934	.0747	.1109
Min	.0934	.0747	.1109
Avg	.0934	.0747	.1109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.0549	
10	.056		
24			.0924
Max	.056	.0549	.0924
Min	.056	.0549	.0924
Avg	.056	.0549	.0924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV SHINDEWADI (H) AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.9221
Max	.9221
Min	.9221
Avg	.9221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV KUKTOLI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV KONGNOLI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.8478
Max	.8478
Min	.8478
Avg	.8478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV KAROLI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.823
Max	.823
Min	.823
Avg	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 205 / 11 KV SARATI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV DESHING GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3109	.3292		.2926	.2926	.3109
2	.3109	.3109	.3658		.2926	.2926	.3109
3	.3109	.3109	.3658		.2926	.2926	.3109
4	.3109	.3109	.3841		.2926	.2926	.3292
5	.3292	.3292	.4024		.2926	.2926	.3292
6	.4024	.3658	.4024		.3475	.3658	.3292
7	.3658	.3658	.3109		.3841	.4024	.3292
8	.3109	.3658	.3292		.3658	.3658	.3292
9	.3109	.2561	.3292			.3018	.2743
10	.2926	.2743	.3841			.2926	.3292
11		.2926	.3475			.3292	.3658
12		.3475	.3475			.3292	.3658
13		.3658	.3475		.439	.3292	.1829
14	.0914	.3658	.3841		.439		.1829
15	.1097	.3658	.3841		.439		.3475
16	.2926	.3475	.3658		.4207	.3475	.3475
17		.3658	.3841		.4207	.3292	.3658
18	.4024	.4572	.3658		.439		.3658
19	.4572	.5121			.439	.4755	.4207
20	.567	.4755			.5121	.4755	.4207
21	.4572	.4938			.439	.4938	.4024
22	.3658	.439	.3841		.3475	.3292	.3658
23	.3292	.3658	.3109		.3292	.3292	.2926
24	.3109	.3109	.3292	.2926	.2926	.2926	.2926
Max	.567	.5121	.4024	.2926	.5121	.4938	.4207
Min	.0914	.2561	.3109	.2926	.2926	.2926	.1829
Avg	.3319	.3627	.3597	.2926	.3759	.3453	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8886	1.0898	1.1736		.1174	.1341	.1844
2	.8886	1.0898	1.2574		.1174	.1341	.1844
3	.8886	1.0898	1.3748		.1174	.1341	.2012
4	.8886	1.0898	1.5089		.1174	.1341	.2012
5	1.0059	1.5089	1.5424		.1341	.1677	.1677
6	1.5089	1.7101	1.5927		.1677	.2012	.1677
7	2.1795	1.7939	2.5149		.218	.2347	.2012
8	2.0454	2.1795	2.7161		.2347	.2347	.2347
9	2.0454	2.0957	2.6825			1.2574	.2347
10	2.0287	1.6766	2.5149			1.6766	.2012
11		.1677	.285			2.0454	.2012
12		.285	.3018			2.079	.1677
13		.2347	.3018		1.7604	2.1125	.1509
14	.2012	.2683	.2515		1.8442	2.1795	.1509
15	.2012	.2515	.2515		1.8778	2.3137	.1174
16	.2347	.2515	.2683		1.9113	2.3472	.1844
17	.3353	.2347	.2515		.2012	.2347	.1844
18	.3856	.3521	.2683		.2515		.1844
19	.2683	.3018			.2683	.2012	.2012
20	.2515	.2683			.2683	.1844	.2012
21	.2347	.2347			.2515	.1844	.1677
22	.2012	.2012	.1174		.2012	.1341	.1677
23	.1677	.2012	.128		.1509	.1677	1.0059
24	.1341	.1677	.2012	.1174	.1174	.1341	.1677
Max	2.1795	2.1795	2.7161	.1174	1.9113	2.3472	1.0059
Min	.1341	.1677	.1174	.1174	.1174	.1341	.1174
Avg	.8087	.7810	1.0240	.1174	.5164	.8099	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	1.0562	1.0059	.1006	.1174	.1844
2	.2347	1.0562	1.0898	.1006	.1174	.1844
3	.2347	1.0562		.1006	.1174	.2012
4	.2347	1.073		.1006	.1174	.1844
5	.2683	1.3077	1.4419	.1006	.1174	.1677
6	.3521	1.6766		.1006	.1174	.1174
7	.3018	1.7269		.1341	.1174	.1341
8	.3856	1.8442		.1341	.1341	.1677
9	.4024	1.9448			.5868	.1677
10	.3856	1.8442			.8383	.0838
11		.1509	.1844			.1006
12		.2012	.218			.1006
13		.1677	.218	.6706		
14		.1509	.2012	.7042	.8383	
15		.1677	.2012	.7042	.9389	.1341
16		.1677	.2012	.8048	1.0395	.1509
17		.1844	.2012	.1006	.1677	.1341
18	.2515	.2515	.2012	.1006		.1341
19	.2515	.1677		.1174	.1844	.1341
20	.2347	.1844		.1174	.1677	.1341
21	.218	.2012		.1174	.1677	.1174
22	.2012	.218		.1174	.1677	.1174
23	.1677	.2012		.1174	.1677	.4694
24	.1174	.1677	.2012	.1006	.1174	.1677
Max	.4024	1.9448	1.4419	.8048	1.0395	.4694
Min	.1174	.1509	.1844	.1006	.1174	.0838
Avg	.2633	.7153	.4471	.2322	.3169	.1585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0671			.4359	.6706	.3688
2	.0671	.0671	.1006		.4359	.6706	.3856
3	.0671	.0671	.1174		.4359	.6706	.4024
4	.0671	.0671	.1174		.4359	.6706	.4191
5	.0671	.0671	.1174		.4527	.7545	.4527
6	.1006	.1006	.1341		.57	1.0898	.4694
7	.1006	.1006	.1006		.9054	1.2742	.7712
8	.0838	.1006	.1006		1.0898	1.3077	.8383
9	.0838	.1006	.1174			.0671	.8048
10	.0671	.1006	.1509			.0671	.7712
11		1.073	1.6263			.1006	.7545
12		1.5089				.1006	.7545
13		1.5424	1.7101		.0671	.1006	.7545
14	1.4754	1.6095	1.6933		.0671	.1006	.8383
15	1.5089	1.643	1.6933		.0671	.1006	.9556
16	1.5424	1.6933	1.6766		.0671	.1174	.9389
17	1.5424	1.7772	1.576		.0671	.1006	.0503
18	1.5424	1.5089	1.1736		.0671		.0503
19	.1006	.1006			.0838	.1174	.0838
20	.1006	.1006			.0838	.1006	.0838
21	.0671	.1174			.0671	.1341	.0838
22	.0671	.1174	.0671		.0671	.1341	.0838
23	.0671	.1006	.0671		.6371	.3353	.0671
24	.0671	.0503	.1006	.0671	.4694	.6706	.3353
Max	1.5424	1.7772	1.7101	.0671	1.0898	1.3077	.9556
Min	.0671	.0503	.0671	.0671	.0671	.0671	.0503
Avg	.4215	.5742	.6548	.0671	.3286	.4111	.4799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0503		.0335	
2		.0503	.0168	.0335	
3	.0671	.0503	.0168	.0335	
4	.0671	.0503	.0168	.0335	
5	.0671	.0335	.0168	.0335	
6	.0671	.0503	.0335	.0335	
7	.0503	.0671	.0503	.0335	
8	.0671	.0671	.0503	.0335	
9	.0671	.0671		.0335	
10	.0671	.0671		.0168	
11	.0671	.0671		.0168	.0671
12	.0671	.0671		.0168	.0503
13	.0671	.0671		.0168	.0503
14	.0671	.0671	.0335	.0335	.0503
15	.0671	.0671	.0335	.0503	.0503
16	.0671			.0671	.0335
24	.0671				
Max	.0671	.0671	.0503	.0671	.0671
Min	.0503	.0335	.0168	.0168	.0335
Avg	.0661	.0593	.0298	.0325	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1097	.1097		.0549	.7316	.4207
2	.1174	.1097	.128		.0549	.7316	.4755
3	.1174	.0183	.128		.0549	.7316	.4755
4	.128	.1097	.1463		.0549	.7316	.4938
5	.128	.128	.1463		.0914	.7316	.5121
6	.1646	.1463	.1463		.1097	.823	.5121
7	.1646	.1646	.128		.6401	.8962	.5487
8	.1646	.1463	.128		.6401	.9511	.5853
9	.1509	.1097	.1097			.0732	.567
10	.1341	.128	.1097			.0732	.567
11		1.6461	1.5546			.0732	.5853
12		1.6095				.0732	.5853
13		1.5546	1.6278			.0732	.6036
14	1.6461	1.6461	1.5729		.0549	.0732	.6036
15	1.6461	1.6827	1.5729		.0549	.0732	.6036
16	1.6278	1.6461	1.5364		.0732	.0732	.6401
17	1.6278	1.5364	1.4632		.0732	.0732	.0549
18	1.6095	1.6461	1.39		.0732		.0549
19	.128	.1097			.0732	.0914	.0732
20	.1463	.1097			.0732	.0914	.0732
21	.128	.128			.0732	.0914	.0671
22	.1097	.128	.2561		.0732	.0914	.0671
23	.1097	.1097	.2926		.6401	.3658	.0549
24	.128	.1097	.1097	.2561	.0549	.7316	.4024
Max	1.6461	1.6827	1.6278	.2561	.6401	.9511	.6401
Min	.1097	.0183	.1097	.2561	.0549	.0732	.0549
Avg	.4907	.6180	.6328	.2561	.1588	.3674	.4011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 201 / 11 KV VITTHALWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1372	.1254	.1227	.1307		.1075
2	.1478	.1227	.1254	.1063	.132	.1227	.0895
3	.1478	.1227	.1254	.1063	.1307	.1227	.0905
4	.1478	.1227	.1433	.1063	.132	.1402	.1267
5	.1478	.1433	.1612	.1254	.1494	.1578	.1267
6	.1698	.1612	.1791	.1433	.1867	.1753	.128
7	.1949		.1791	.1433	.132	.1402	.1463
8	.1715	.2012	.181	.1433	.1086	.1402	.128
9	.1543	.1448	.1267	.1448	.1075	.1227	.1086
10	.2058	.1629	.1267	.124	.0724	.0876	.1187
11	.1928	.1267	.1448	.1543	.0876	.1052	.1063
12	.1753	.1629		.1402	.1052	.12	.1214
13	.1578	.1629	.181	.1595	.1227	.1214	.1526
14	.1629	.1629	.1612	.1433	.1227	.1267	.1254
15	.181	.1629	.1612	.156	.1227		.1063
16	.181	.1629	.1254	.1715	.1402	.1214	.1595
17	.2012	.181	.1612	.1715	.1402	.1478	.156
18	.1402	.181	.2149	.1907	.1578	.1629	.1753
19	.2454	.1829	.2149	.2149	.1753	.181	.2103
20	.2279	.2012	.1753	.2507	.2279		.2149
21	.2229	.1991	.1402	.1867	.2103	.1433	.1867
22	.2058	.181	.1402	.168	.1928	.1254	.1307
23	.1543	.181	.1227	.1494	.1578	.1075	.1132
24	.168	.1372	.1629	.1227	.132	.1402	.1075
Max	.2454	.2012	.2149	.2507	.2279	.181	.2149
Min	.1402	.1227	.1227	.1063	.0724	.0876	.0895
Avg	.1772	.1611	.1556	.1519	.1407	.1339	.1349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 202 / 11 KV KEREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.6859	.7545	.583	.4527	.4481	.3856
2	.6979	.7888	.9114	.7888	.4527	.4481	.3856
3	.6979	.9945	1.262	1.0166	.4527	.4481	.3772
4	.7922	1.1145	1.4899	1.0745	.4715	.4854	
5	1.0974	1.4373	1.7013	1.2894	.4904	.4854	.3944
6	1.4632	1.7177	1.7551	1.3969	.5847	.5228	.3944
7	1.9909		1.8446	1.5223		.4668	.4115
8	2.0058	1.8275	1.9313	1.5074	.4527	.4294	.4031
9	1.8267	1.5775	.6733	.7545	.724	.5636	.4031
10	1.5746	1.4198	1.3146	1.2936	.7922	.779	.415
11	.4163	.4607	.4207	1.1389	.8288	1.1271	.415
12	.4344	.4298		1.2012	.7956	1.3032	.415
13	.4287	.4525	.4287	1.3491	.779	1.2851	.415
14	.4287	.4755	.4458	1.5729	.8785	1.1403	.415
15	.4287	.4755	.4458	1.5565	.9614	1.2752	.415
16	.4557	.4938	.4694	1.5043	.8951	1.4327	.3961
17	.4938	.4755	.4694	.3961	.3921	.3841	.3961
18	.3982	.5121	.3772	.3174	.4294	.394	.3961
19	.5014	.5194	.4908	.4904	.4481	.4119	.4338
20	.5194	.5373	.5258	.4904	.4854		.4527
21	.5258	.5731	.463	.4904	.4668	.4163	.4715
22	.4908	.543	.4287	.4904	.4668	.4163	.4527
23	.4733	.5068	.4287	.4715	.4668	.4163	.547
24	.4527	.4835	.4706	.4115	.4715	.4668	.4163
Max	2.0058	1.8275	1.9313	1.5729	.9614	1.4327	.547
Min	.3982	.4298	.3772	.3174	.3921	.3841	.3772
Avg	.8039	.8044	.8479	.9628	.5930	.6759	.4177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 203 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2427	.2829	.2614	1.278	1.0442	.9717
2		.2427	.2452	.2427	1.3108	1.2597	1.0364
3		.2075	.2452	.2427	1.3435	1.3757	1.1336
4		.2075	.3174	.2452	1.3603	1.6244	1.2289
5		.2829	.3547	.3206	1.3927	1.8067	1.3108
6		.3206	.4108	.415	2.0222	2.4531	1.3435
7			.4668	.5093		2.8012	1.4091
8		.3547	.3734	.3772		2.4531	1.3279
9		.2865	.2054	.3018		.2427	1.3603
10	.0503	.2658	.2427	.1753		.2054	1.4251
11	1.0526	2.3011	1.9433	.1867	.1307	.2241	1.4737
12	1.4737	2.2624		2.0119	.112	.2353	1.5524
13	1.668	2.2081	2.17	.2378	.0934	.2378	1.4883
14	1.8138	2.2081	2.2348	.2507	.112	.2452	1.3123
15	1.9433		2.2672	.2561	.112	.2402	1.4083
16	1.9595	2.5057	2.332	.2896	.2054	.3045	1.4883
17	2.1052	2.6155	2.4615	.2743	.2427		.208
18	1.9433	2.2672		.3077	.2987	.2561	.2402
19	.3734	.4294	.3584	.3881	.3734	.3174	.2772
20	.3547	.4108	.3961	.3734	.4294		
21	.3584	.3921	.3395	.3734	.3734		.1663
22	.3018	.2987	.2829	.3174	.3361		.1478
23	.2641	.2801	.2641	.9012	.7127	.7712	.1109
24		.2641	.2801	.2641	1.0526	.9779	.9393
Max	2.1052	2.6155	2.4615	2.0119	2.0222	2.8012	1.5524
Min	.0503	.2075	.2054	.1753	.0934	.2054	.1109
Avg	1.1187	.9479	.8397	.3968	.6646	.9538	1.0157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7291	.7716	.7202	.57	.2477	.2477	.1905
2	.7461	.763	.7682	.57	.2477	.2477	.1905
3		.763	.7362	.5765	2.05	.2477	.1905
4		.8383	.7362	.5596	2.0881	.2477	.2096
5	.9724	.9221	.9555	.5868	.3239	.2858	.2667
6	1.094	1.4083	1.5912	.6718	.4191	.3429	.3429
7	1.6575	2.0348	2.3537	.852		.4001	.1524
8	1.6842	2.1548	2.42	.9175	.3239	.362	.7763
9	1.8067	2.1548	2.4034	1.1984	.5316	.6154	.2286
10	1.6549	1.8947	2.2447	1.0814	.9393	1.4091	.3429
11		.2667	.2858	1.0814	1.3765	1.8399	.3429
12		.2667	.2858	1.1105	1.5384	1.8233	.2667
13		.2858	.2858	1.085	1.4413	1.7695	.1715
14		.2667	.3048	.8745	1.1012	1.8351	.1715
15		.2858	.2858	1.0814	.7499	1.9006	.1715
16		.3048	.3048	1.1142	1.2334	2.2377	.2477
17	.1905	.3429	.3048	.2286	.2096	.2667	.2667
18	.362	.1905	.3048	.2858	.2667	.1905	.2667
19	.362	.362		.3239	.3239	.3048	.3429
20	.362	.381	.2667	.362	.362	.3239	.381
21	.2858	.381	.2477	.3239	.3048	.2858	.3048
22	.2858	.3429	.2286	.3048	.2667	.2477	.2667
23	.2667	.3048	.2096	.2667	.2477	.1905	.5243
24	.2477	.2477	.2667	1.5242	.2477	.2477	.1905
Max	1.8067	2.1548	2.42	1.5242	2.0881	2.2377	.7763
Min	.1905	.1905	.2096	.2286	.2096	.1905	.1524
Avg	.7942	.7473	.8048	.7313	.7322	.7446	.2836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.2667	.2096	.8951	1.0059	
2	.2096	.1905	.2477	.2096	.8951	1.0059	
3	.2286	.2096	.2477	.2096	.9175	.9892	
4	.2286	.2096	.2477	.2096	1.0159	.9892	
5	.2477	.2286	.2667	.2096	1.1012	1.2431	.6952
6	.2858	.2858	.3048	.2286	1.4413	1.5074	
7		.2667	.3239	.1905	2.0809	1.8461	
8	.2858	.2477	.2858	.2096	2.0729	1.9595	
9	.3048	.2477	.2477	.1905	.2096	.1524	
10		.2286	.2286	.1905	.2477	.2286	
11		1.4403	1.9989	.2096	.2667	.2858	
12		2.1714		.1905	.1905	.2858	1.4419
13	1.3592	2.1548	1.9595	.2096	.2858	.2858	1.749
14	1.9113	2.2542	1.9845	.1905	.2858	.2858	1.7814
15	1.7939	2.1382	2.1052		.1905	.3048	1.3599
16	2.1382	2.2211	2.1538		.2667	.3048	1.7695
17	1.5947	1.6575	2.0165	.1905	.2858	.3429	.1905
18	1.5769	1.749	1.1498	.2286	.2858	.2858	.2477
19	.2858	.1905		.2667	.2858	.2477	.2477
20	.2858	.3048	.2096	.3048	.3239	.2286	.3048
21	.2667	.3048	.2286	.2858	.3048	.2286	.2858
22	.2667	.3048	.2477	.2477	.2858	.2286	.2477
23	.2286	.2858	.2477	.7865	.8745	.6687	.2096
24	.2096	.2286	.2667	.2286	.8785	1.0343	.6952
Max	2.1382	2.2542	2.1538	.7865	2.0809	1.9595	1.7814
Min	.2096	.1905	.2096	.1905	.1905	.1524	.1905
Avg	.6959	.8213	.7834	.2453	.6620	.6644	.8019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.5935	.6371	.503
2	.1334	.1524	.1524	.1524	.57	.6371	
3	.1334	.1524	.1524	.1524	.6036	.6371	
4	.1524	.1524	.1524	.1524	.663	.6464	
5	.1524	.1524	.1905	.1715	.7459	.7865	
6	.1905	.2286	.2096	.1905	.9779	1.0978	
7	.2286	.2286	.2286	.2477	1.3763	1.4413	
8	.2096	.1905	.1905	.2096	1.6518	1.7166	
9	.2096	.1905	.2096	.1905	.1334	.1905	.7537
10	.2096	.1905	.1905	.1905	.1524	.1715	.9831
11		1.2003	1.8461	.1905	.1715	.2096	1.2308
12		1.5565		.1905	.1905	.2096	1.3435
13	1.2407	1.1012	1.8842	.2096	.1905	.2096	1.3108
14	1.4582	1.7204	1.8351	.1905	.1715	.2096	1.1271
15	1.576	1.8023	1.9595	.2096	.1143	.2096	1.6766
16	1.7436	1.7695	2.0243	.2096	.1905	.1905	1.757
17	1.2209	1.8679	1.9364	.2667	.1715	.2286	.1905
18	1.2346	1.6518	1.3117	.2477	.1905	.2096	.1905
19	.2286	.2096		.2477	.2096	.2477	.1715
20	.2286	.2477	.2286	.2667	.2477	.1905	.2477
21	.1905	.2477	.2286	.2286	.2286	.1905	.2477
22	.1905	.2096	.2096	.1905	.2096	.1905	.2096
23	.1524	.1905	.1905	.5765	.57	.4748	.1905
24	.1524	.1524	.1524	.1524	.5765	.6371	.503
Max	1.7436	1.8679	2.0243	.5765	1.6518	1.7166	1.757
Min	.1334	.1524	.1524	.1524	.1143	.1715	.1715
Avg	.5177	.6549	.7107	.2161	.4542	.4821	.7433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.3239	.2096	.381	.2858	.3048
2	.0572	.1905	.1905	.1905	.2858	.2286	.2858
3	.0572	.1905	.1905	.0762	.2858	.1905	.2286
4	.0572	.1905	.1715	.0762	.1905	.1143	.1524
5	.0762	.1905	.0762	.0572	.1334	.0953	.1143
6	.0762	.1524	.2096	.0762	.1334	.0762	.0762
7	.0762	.0381	.1715	.0953	.0762	.0762	.0762
8	.0762	.1143	.1905	.0572	.0762	.0762	.0953
9	.2477	.1143	.1334	.1143	.0762	.2858	.2477
10	.1905	.3239	.3239	.1334	.4191	.1524	.0762
11		.1524	.4572	.0572	.2096	.3239	.362
12		.1524	.3239	.3429	.6097	.3239	.2858
13	.0762	.362	.2286	.2096	.3239	.2286	.1334
14	.2286	.2286	.0762	.3239	.362	.0381	.1143
15	.381	.4382	.1905	.2858	.0762	.3048	.3239
16	.3429	.4382	.2096	.1715	.5525	.2858	.2667
17	.3239	.2667	.1143	.1334	.2858	.0762	.3048
18	.3239	.2286	.0762	.1334	.1524	.0762	.1905
19	.3429	.381		.1334	.0572	.2286	.2286
20	.3429	.381	.0762	.3048	.2477	.0762	.2667
21	.0762	.4001	.0762	.3429	.1905	.0762	.2477
22	.0762	.0762	.0762	.1715	.0381	.0762	.1715
23	.0762	.1524	.1905	.381	.362	.2286	.2858
24	.2858	.0762	.2286	.2477	.5335	.3048	.1905
Max	.381	.4382	.4572	.381	.6097	.3239	.362
Min	.0572	.0381	.0762	.0572	.0381	.0381	.0762
Avg	.1801	.2262	.1872	.1802	.2524	.1762	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.7087	.4915	.39	.1143	.1334	.1143
2	.3155	.7011	.4915	.39	.1143	.1334	.1143
3	.3506	.7011	.4588	.407	.1334	.1334	.1143
4	.3944	.6935	.4424	.4024	.1334	.1334	.1524
5	.4287	.763	.5609	.4359	.1524	.1524	.1905
6	.056	.8478	1.0185	.5304	.1905	.1905	.2477
7	1.0059	1.283	1.3121	.7537	.1715	.2096	.1715
8	1.1065	1.262	1.6632	.8583	.1715	.1715	.1334
9	.9945	1.262	1.7187	.8907	.4207	.5182	.1524
10	1.0395	1.2071	1.3603	1.0442	.8063	1.0814	.1143
11		.0953	.1334	1.0111	.9503	1.4575	.1334
12		.1334	.1715	1.0059	1.2125	1.6289	.1715
13	.1334	.1143	.1715	.9503	1.065	1.5927	.1524
14	.1334	.1524	.1524	.8848	1.1174	1.5203	.1524
15	.1143	.1524	.1715	.8848	.7748	1.7737	.1524
16	.1143	.1715	.1715	.7775	1.3283	1.7737	.1524
17	.2096	.2096	.1715	.0762	.2096	.1905	.1524
18	.2096	.2096	.1905	.1334	.1905	.1524	.1905
19	.2286	.2286			.1524	.1524	.1715
20	.2286	.2286	.1715	.1715	.1905	.1524	.1905
21	.1905	.2286	.1715	.1524	.1905	.1334	.1715
22	.1143	.2096	.1715	.1334	.1715	.1334	.1715
23	.1143	.1905	.1715	.1143	.1334	.1143	.4973
24	.1334	.1143	.1715	.1524	.1143	.1334	.1143
Max	1.1065	1.283	1.7187	1.0442	1.3283	1.7737	.4973
Min	.056	.0953	.1334	.0762	.1143	.1143	.1143
Avg	.3607	.4945	.5091	.5457	.4254	.5736	.1700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1715	.1334	.1715	.1905	.1524
2	.1524	.1905	.1715	.1334	.1715	.1905	.1524
3	.1524	.1905	.1715	.1334	.1905	.1905	.1524
4	.1905	.1905	.1715	.1334	.2477	.1905	.1524
5	.7171	.2286	.2286	.1524	.2477	.2286	.1905
6	.2858	.3239	.3048	.1905	.2686	.2858	.2667
7	.2126	.3048	.3429	.2477	.3582	.3429	.2286
8	.2534	.3239	.2858	.2286	.3366	.3048	.1524
9	.2534	.3429	.2667	.2286	.1715	.362	.1715
10	.2477	.362	.3239	.2286	.3641	.3814	.2477
11		.2858	.2286	.1715	.3155	.3641	.2477
12		.3429	.3048	.3239	.333	.333	.3048
13	.1143	.2286	.2858	.2858	.2172	.3224	.2096
14	.2286	.2286	.3048	.2858	.2477	.1928	.2477
15	.1715	.2804	.2858	.2477	.1715	.362	.2667
16	.1715	.3155	.2858		.2835	.3077	.2286
17	.2858	.2454	.3048		.2896	.3258	.2096
18	.2858	.3077	.3048	.2858	.3239	.2715	.2096
19	.2667	.3439			.362	.3429	.2477
20	.2667	.381	.2477	.3239	.3429	.2858	.2858
21	.2286	.2858	.2858	.3239	.3048	.2477	.2667
22	.2286	.2286	.2286	.2477	.2858	.2096	.2096
23	.1905	.2096	.1905	.1905	.2096	.1524	.2096
24	.1524	.1905	.1905	.1334	.1715	.1905	.1524
Max	.7171	.381	.3429	.3239	.3641	.3814	.3048
Min	.1143	.1905	.1715	.1334	.1715	.1524	.1524
Avg	.2368	.2718	.2560	.2205	.2661	.2740	.2151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.0913
Max	1.0913
Min	1.0913
Avg	1.0913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.2667
Max	.2667
Min	.2667
Avg	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.1886	.1715	.1905	.2075	.1715
2	.1886	.1886	.1886	.1715	.1905	.2075	.1715
3	.1509	.1886	.1886	.1715	.1905	.2075	.1715
4	.1524	.1886	.1886	.1524	.1715	.2075	.1715
5	.1524	.1886	.1886	.1524	.1905	.2075	.1715
6	.1524	.2218	.1524	.1524		.1905	.1524
7	.1509	.1509	.1509	.132	.1524	.132	
8	.1698	.1698	.1143		.1886	.132	.1509
9	.1867	.1867	.168	.2075	.1463	.1848	
10	.1753	.2149	.1791	.2195	.2172	.2012	.1791
11		.2103	.2195	.2126	.1848	.2012	.1663
12		.2195	.1658	.197		.1991	.1829
13	.1715	.168	.2218	.2033	.1494	.1663	.2033
14	.2075	.1509	.2218	.1509	.1132	.168	.1509
15	.1886	.1867	.2033	.1478	.1494	.1698	.1509
16	.1698	.1698	.1848	.1294	.1132	.1509	.132
17		.1509	.1829	.1433	.1294	.1097	.1509
18	.2241	.1478	.1494	.1646	.1629	.1494	.1578
19	.2241	.2172		.2218	.2195	.1494	.2054
20	.2614	.2926		.3734	.2926	.2715	
21	.2957	.2896	.2829	.2896	.2743	.2561	.2686
22	.2641	.2561	.3018	.2926	.2378	.2427	.2218
23	.2641	.2195	.2641	.2427	.2452	.1886	.1886
24	.1886	.2263	.1886	.1886	.2075	.2075	.1886
Max	.2957	.2926	.3018	.3734	.2926	.2715	.2686
Min	.1509	.1478	.1143	.1294	.1132	.1097	.132
Avg	.1965	.2013	.1952	.1951	.1871	.1878	.1766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1886	.1867	1.8023	1.6575	1.4419
2		.1509	.1886	.1886	1.8023	1.6766	1.4746
3		.1509	.1886	.1698		1.6194	1.4918
4		.1509	.1886	.1698		1.6575	1.5249
5		.1509	.1886	.1886	1.9227	1.9006	1.7695
6		.168	.2075	.2075	2.3205	2.2377	1.8187
7		.2241	.2075	.2263	2.652	2.4863	
8		.1886	.2033	.2427	2.8502	2.7664	2.0891
9	.168	.2075	.2195	.2241	.1187	.1097	
10	.1509	.1478	.2172	.2218	.1417	.1509	2.42
11		2.6155	3.0681	.2614	.112	.1494	2.4646
12		2.7831		.2427		.1478	1.989
13	2.3137	2.5652	2.6825	.2218	.1848	.1698	2.2708
14	2.6825	2.8502	2.6825	.2402	.1509	.1886	2.2466
15	2.6825	2.5819	2.7496		.1578	.1886	2.3472
16	2.6825	2.7831	2.7161	.2587	.1663	.2075	2.4478
17	2.6825	2.8502	2.8502	.2279	.1781	.2601	.1296
18	2.3205	2.6825	2.1795	.2896	.1989	.2801	.1463
19	.2149	.2614		.2715	.2896		.2218
20	.2507	.2427		.2378	.2957	.1829	
21	.2328	.2195	.2241	.2402	.2957	.181	.2427
22	.2241	.2561	.2241	.2241	.2378	.1791	.2218
23	.2241	.2012	.2054	1.3927	1.5927	1.1683	.2263
24		.1867	.2033	.2054	1.6712	1.6766	1.2955
Max	2.6825	2.8502	3.0681	1.3927	2.8502	2.7664	2.4646
Min	.1509	.1478	.1886	.1698	.112	.1097	.1296
Avg	1.2946	1.0321	1.0373	.2756	.9115	.9236	1.4419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762	.0762	.8322	1.0174	.7377
2		.0762	.0572	.0762	.8322	1.0288	.7293
3		.0762	.0572	.0762	.8322	.9945	.7459
4		.0762	.0572	.0762	.9282	.9945	.7459
5		.0762	.0572	.0762	.9602	1.1768	.852
6		.0953	.0572	.0762	1.1203	1.2616	.9339
7		.0953	.0762	.0762	1.2803	1.326	
8		.0762	.0762	.0762	1.3923	1.5424	1.1797
9	.0572	.0762	.0572	.0762	.0953	.0953	
10	.0572	.0762	.0572	.0953	.0572	.0762	1.2929
11		1.2742	1.2631	.0953	.0572	.0762	1.4089
12		1.358		.0953		.0953	1.1934
13	1.0774	1.4586	1.2289	.0953	.0572	.1143	1.2323
14		1.4419	1.3763	.0953	.0572	.0953	1.1934
15	1.1934	1.4083	1.3279	.0953	.0572	.0953	1.2266
16	1.1736	1.2574	1.3117	.0953	.0953	.0953	1.2597
17		1.3245	1.1336	.0953	.0572	.0953	.0762
18	1.2763	1.3077	1.1305	.0953	.0762	.0953	.0762
19	.0953	.0762		.0953	.1143	.0953	.0953
20	.0953	.0953		.0762	.1143	.0953	
21	.1143	.0953	.0762	.0762	.1143	.0953	.0953
22	.1143	.0762	.0953	.0762	.0953	.0953	.0762
23	.0953	.0762	.0953	.7293	.8453	.6706	.0762
24		.0762	.0762	.0762	.8619	1.0059	.7545
Max	1.2763	1.4586	1.3763	.7293	1.3923	1.5424	1.4089
Min	.0572	.0762	.0572	.0762	.0572	.0762	.0762
Avg	.4863	.5053	.464	.1114	.4754	.5139	.7610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3916	1.4706	1.174	.2452	.2477	.1905
2		1.5497	1.5623	1.2498	.2452	.2477	.1715
3		1.5497	1.5813	1.2803	.2452	.2477	.1715
4		1.5813	1.5813	1.3413	.2452	.2477	.1715
5		1.6129	1.5623	1.3889	.2263	.2452	.1715
6		1.9524	2.3594	1.531	.2263	.3018	.1886
7		2.7854	3.315	2.1605	.2263	.3206	
8		2.8018	2.9007	2.4006	.2241	.2801	.2772
9	2.9007	3.1276	3.0664	2.4291	1.6244	1.8084	
10	2.332	2.0005	2.6558	2.4129	2.5911	2.7183	.2652
11	2.332	.2241	.1886	2.3266	3.1659	2.7199	.2957
12		.2614	.2427	2.1628		2.7044	.2241
13	.2241	.2641	.1886	2.4453	3.0148	2.6216	.2452
14	.2452	.2263	.2263	2.3685	2.7035	2.6379	.2743
15	.2641	.2263		2.4086	2.6216	2.5911	.2743
16	.2641	.2427		2.4086	2.8837	2.5263	.2743
17		.2263		.1698	.2172	.3258	.2957
18	.3174	.3018	.2801	.2229	.2378	.3077	.2715
19	.3142	.3734		.2587	.2957	.2896	.2957
20	.3142	.415		.2829	.3206	.2772	
21	.3142	.415	.2987	.2486	.3206	.2587	.2987
22	.2957	.3584	.3018	.2641	.3018	.2587	.2801
23	.2772	.3018	.2829	.2263	.2858	.2402	1.3283
24		.2641	.2829	.7621	.2452	.2477	.2241
Max	2.9007	3.1276	3.315	2.4453	3.1659	2.7199	1.3283
Min	.2241	.2241	.1886	.1698	.2172	.2402	.1715
Avg	.7996	1.0189	1.2815	1.4135	.9875	1.028	.2947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.3413	1.2071	.9231	.3018	.4338	.4001
2	.4481	1.3923	1.2574	.9503	.3018	.4338	.381
3	.4481	1.4918	1.2574	.9995	.3018	.4338	.362
4	.4481	1.4918	1.2574	1.0159	.3395	.4338	.362
5	.4481	1.8778	1.7101	1.2266	.415	.4715	.3395
6	.4481	1.9113	2.3137	1.4586		.4715	.3772
7	.547	2.3807	2.4813	1.576	.3018	.415	
8	2.2801	2.5194	2.42	1.7772	.3018	.415	
9	2.5526	2.1795	2.146	1.8564	.7537	2.4874	
10	2.4531	2.1548	1.8778	1.7238	1.7436	3.8226	.2987
11		.2543	.4572	1.8107	2.1125	4.6944	.2614
12		.2641		1.5249			.2641
13	.2241	.2263	.2241	1.7101	1.1065	4.4262	
14	.3772	.3361	.2801	1.073	1.7635	4.359	.1867
15	.3696	.2641		1.5089	1.576	4.292	.3734
16	.3696	.3018		1.6095	1.8778	4.158	.4108
17		.3206		.181	.1791	.2353	.3696
18	.4854		.2987	.2614	.3734	.4904	.4108
19	.5014	.3961		.2987	.4477	.547	.5281
20	1.6834	.679		.4066	.5658	.5658	
21	.5373	.6722	.6036	.3898	.5093	.5281	.4904
22	.5014	.6036	.5658	.415	.5093	.4527	.4527
23	.4656	.5487	.547	.3018	.4338	.415	.9496
24	.4527	.4904	.4904	.5281	.3018	.4338	.4001
Max	2.5526	2.5194	2.4813	1.8564	2.1125	4.6944	.9496
Min	.2241	.2263	.2241	.181	.1791	.2353	.1867
Avg	.8177	1.0477	1.1886	1.0636	.7508	1.5398	.4010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.415	.4024	.3511	.3841	.3511	
2	.3881	.415	.3881	.3511	.3841	.3395	.3841
3	.3881	.415	.3881	.3511	.3841	.3395	
4	.3881	.415		.3511	.3658	.3961	.4024
5	.4251	.415	.4066	.3696	.3841	.3961	.4163
6	.4668	.4435	.4706	.4481	.439	.4251	.4298
7	.5041	.5175	.4784	.4294	.4706	.499	.4525
8	.4755	.4706	.4031	.439	.4119	.4251	.3721
9	.3721	.4887	.4801	.4119	.4207	.5068	.3506
10	.4854	.443	.4854	.4382	.4733		.3721
11		.4508	.4784	.4607	.4607		.3544
12			.4607	.5375	.4607		.3506
13	.5201		.4382	.4908	.4681		.4031
14	.5548		.4733	.4835	.4508		.4252
15	.4854		.4607	.4908	.4334		.3544
16	.4458		.4961	.5083	.4508		.4382
17			.4835	.4458	.4681		.4252
18	.4334		.4835	.4607	.4854		.4887
19	.5375			.4835	.5493		.5249
20	.6154			.5611	.5792		.5487
21	.499		.4755	.4938	.5359		.5121
22	.462		.4938	.4805	.462		.4207
23	.4251		.3881	.4251	.3881		.3841
24	.4251	.415	.4207	.3696	.4024	.3511	.362
Max	.6154	.5175	.4961	.5611	.5792	.5068	.5487
Min	.3721	.415	.3881	.3511	.3658	.3395	.3506
Avg	.4630	.4420	.4503	.4430	.4464	.4029	.4169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2829	.2829	.2263	1.1603	1.3927	
2	.2263	.2829	.2829	.2263	1.2597	1.4586	
3	.2263	.2641	.2641	.2263	1.2125	1.4922	
4	.2263	.2641	.2641	.2263	1.1603	1.5424	
5	.2263	.2641	.2829	.2452	1.3094	1.5402	
6	.2829	.3206	.2829	.2452	1.7404	1.8461	
7	.2641	.3018	.2926	.2452	1.6907		
8	.2829	.2829	.2829	.2075	2.2708		
9	.2075	.2452	.2263		.2829		
10	.2075	.2641	.2263	.1886	.2075		
11		2.1464	2.556	.1886	.2452		2.7846
12				.2263	.2452		2.4697
13	2.0719		2.3758	.1886	.2263		2.5396
14			2.343	.2075	.1886		2.5194
15			2.4863	.1886	.1698		2.5692
16	2.5724		2.8673		.1886		2.6189
17			2.4863		.1698		.2641
18	2.2834		1.9989		.2075		.2263
19	.2829				.2641		.2452
20	.3206			.3206	.3018		.2829
21	.3206		.2075	.2829	.3018		.2829
22	.3018		.2263	.2641	.3018		.2641
23	.2829		.2075	.8356	1.1305		.2452
24	.2075	.2829	.3018	.1886	1.0978	1.3927	
Max	2.5724	2.1464	2.8673	.8356	2.2708	1.8461	2.7846
Min	.2075	.2452	.2075	.1886	.1698	1.3927	.2263
Avg	.5800	.4335	.9878	.2594	.7222	1.5236	1.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	.2829	1.4091	1.1012	.2075	.2075	.1886
2	1.1336	.8048	1.4419	1.2146	.2075	.2075	.1698
3	1.2146	1.0395		1.2146	.2075	.2075	.1698
4	1.2955	1.5083		1.166	.2075	.2075	.1698
5	1.5729	1.5238	1.5238	1.3279	.2075	.2075	.1698
6	2.13	1.8842	2.0645	1.5729	.2452	.2263	.1886
7	2.4531	2.2939	2.4086	1.8842	.2075	.2263	.2263
8	2.5194	1.9393		2.0719	.2452	.2075	.2075
9	2.4863	2.2611	2.3967	2.0388	1.1012	1.17	.2263
10	2.2874	2.1538	2.2186	2.0056	1.9826		.2075
11		.1698	.2452	1.989	2.3482		.2263
12				1.7532	2.343		.1698
13	.2075		.2641	1.8299	2.0153		.1886
14	.2452		.2452	1.8461	1.9989		.2075
15	.2263			1.8461	1.3413		
16	.2263			1.8299	1.4582		
17	.2263			.1132			.2263
18	.2263				.1509		.2263
19	.3018				.2263		.2452
20	.3395			.2641	.2452		.2829
21	.3584		.2641	.2641	.2829		.2829
22	.3395		.2641	.2641	.2829		.2829
23	.3018		.2263	.2452	.2263		1.1336
24	.2263	.2829	.2829	.2263	.2075	.2075	.1886
Max	2.5194	2.2939	2.4086	2.0719	2.3482	1.17	1.1336
Min	.2075	.1698	.2263	.1132	.1509	.2075	.1698
Avg	.9714	1.3454	1.0897	1.2759	.7803	.3075	.2539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	.6706	.8356	.4534	.0943	.1132	.0943
2	.7287	.6706	.8684	.4858	.0943	.1132	.0943
3	.7287	.7042	.8848	.4858	.3018	.1132	.0943
4	.6478	.7293	.9012	.4858	.0943	.0943	.0943
5	.583	.7682	.9175	.5344	.1132	.1132	.0943
6	.8097	.9667	1.065	.6478	.1132	.132	.0943
7	.9831	1.2597	1.2125	.6882	.132	.132	.1132
8	1.1603	1.3108	1.3763	.6882	.0943	.1132	.0943
9	1.1768	1.2597	1.2452	.7209	.4001	.5201	.0943
10	1.1437	1.1961	1.1984	.6796	.5571		.1132
11		.1307	.132	.7373	.7209		.0943
12			.132	.7274	.8583		.1132
13	.1132			.6405	.9012		.1132
14	.1509		.1509	.6718	.9231		.0943
15	.1509			.6562	.6554		.0943
16	.132			.7011	.9231		
17				.0754	.0754		.0943
18	.1509			.0943	.1132		.1132
19	.1509			.132	.132		.132
20	.1698			.132	.1509		.1509
21	.1698		.1509	.132	.1509		.1509
22	.1698		.1509	.1132	.1509		.132
23	.1509		.132	.1132	.132		.5668
24	.132	.132	.132	.1132	.0943	.1132	.0943
Max	1.1768	1.3108	1.3763	.7373	.9231	.5201	.5668
Min	.1132	.1307	.132	.0754	.0754	.0943	.0943
Avg	.4897	.8166	.6756	.4546	.3323	.1558	.1272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1698	.132	1.1469	1.3094	.9175
2	.1698	.1886	.1698	.132	1.1797	1.3094	.9175
3	.1509	.1886	.1698	.132	1.1797	1.326	.9831
4	.1509	.1886	.1698	.132	1.1961	1.3435	.9995
5	.1509	.2075	.1698	.132	1.3094	1.3599	1.0486
6	.1698	.2452	.2075		1.5565	1.0159	1.3117
7	.2263	.2263	.2378	.1886	2.2542	1.8461	1.7328
8	.2452	.2641	.2452	.2263	2.0885	2.3482	1.8785
9	.2263	.2641	.2452	.2075	.2075	.132	2.1862
10	.1886	.2452	.2452	.1509	.1509		2.2119
11		2.2283	2.3758	.1509	.1698		2.304
12				.1698	.1886		1.9498
13	1.7204		2.4577	.1886	.1698		2.2874
14	2.1216		2.6852	.1886	.1509		2.0222
15	2.1464		2.9504	.1886	.1509		1.8842
16	2.0553		2.7854	.2075	.1698		2.2045
17			2.5692	.1698	.1886		.132
18	2.0972		2.1956	.132	.2263		.1698
19	.2641			.1886	.2263		.2075
20	.2829			.1886	.2452		.2452
21	.2641		.2075	.1698	.2452		.2452
22	.2452		.1886	.1509	.2263		.1886
23	.2075		.132	1.0159	1.1603		.1509
24	.132	.1886	.1698	.7621	1.0814	1.2763	.0934
Max	2.1464	2.2283	2.9504	1.0159	2.2542	2.3482	2.304
Min	.132	.1886	.132	.132	.1509	.132	.0934
Avg	.6374	.3853	.9880	.2307	.7029	1.3267	1.178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 201 / Salgare Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 202 / Chabukswarwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 203 / Janraowadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.6289
Max	1.6289
Min	1.6289
Avg	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
23	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.4096	.443	.4096	.0762	.0762	.0762
2	.7773	.4372	.5373	.4858	.0762	.0762	.0762
3	.8642	.4534	.5973	.547	.0762	.0572	.0953
4	1.065	.6226	.7442	.6371	.0762	.0762	.1143
5	1.1984	.7362	.815	.7459	.0762	.0762	.1143
6	1.3108	.9922	.1361	.8192	.1524	.1334	.1715
7	1.6194	1.0526	1.382	1.2431	.1524	.1715	.2286
8	1.3763	1.065	1.4175	1.1469	.1334	.1715	.1715
9	1.3765	1.004	1.2178	1.1603	.1638	.197	.1905
10	1.3763	.9012	.9955	1.0978	.1829	.3704	.1715
11	.1334	.0953	.0953	1.1203	.2401	.4111	.1334
12	.1524	.1524	.1143	1.1069	.3353	.4586	.1524
13	.2096	.1334	.1334	1.1203	.3506	.8029	.1334
14	.1905	.1524	.1524	.7907	.3321	.7773	.1334
15	.1905	.1143	.1143	1.0279	.3841		.1334
16	.1715	.0953	.1334	.8002	.506	.7432	.0953
17	.2096	.1524	.1143		.0953	.1143	.1143
18	.2096	.1334	.1334	.1715	.1143	.2477	.1334
19	.1334	.1905	.1524	.0762	.1143	.0953	.1524
20	.1905	.1715	.2096	.1334	.0953	.0953	.1905
21	.1715	.1715	.1715	.1334	.1143	.1143	.1715
22	.1715	.1715	.1524	.0953	.0953	.1143	.1334
23	.1334	.1334	.1143	.0953	.1143	.0762	.2883
24	.1715	.1143	.1334	.1143	.0953	.0953	.0762
Max	1.6194	1.065	1.4175	1.2431	.506	.8029	.2883
Min	.1334	.0953	.0953	.0762	.0762	.0572	.0762
Avg	.5885	.4023	.4254	.6556	.1730	.2414	.1438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1715	.2286	.2096	.6089	.443	.3601
2	.1143	.1524	.2096	.1905	.6135	.4656	.3772
3	.1334	.1524	.2096	.2096	.6268	.5068	.4334
4	.1524	.1715	.2286	.2096	.6379	.5373	.4854
5	.2096	.2096	.2667	.2286	.7087	.5792	.5316
6	.2858	.2477	.3048	.3048	.8954	1.2536	.7712
7	.2667	.3048	.3239	.362	1.0631	1.4883	1.1022
8	.2477	.2667	.381	.3048		1.1462	.8078
9	.2096	.2667	.2667	.2667	.2286	.3048	1.0974
10	.1715	.1905	.1334	.3239	.1715	.2286	1.142
11	1.4899	1.7737	2.1195	.2858	.1715	.1905	1.3496
12		1.825	2.392	.2858	.1524	.0953	
13		1.4148	2.6863	.2858	.1715	.1334	1.2536
14		2.2857	2.4806	.2858	.1715	.1524	1.3289
15		2.1357	2.3838	.2667	.1715	.1334	1.3611
16	2.516	2.3388	2.5431	.2667	.1524	.1715	1.4506
17	2.7168	2.5072	2.6578		.1905	.1905	.2286
18	2.6223	2.392	2.364	.2096	.1905	.1905	.1905
19	.2096	.2286	.2477	.2858	.2286	.2667	.2477
20	.3048	.3048	.3048	.3048	.2286	.2286	.3048
21	.2667	.3048	.2667	.2667	.2286	.1905	.2477
22	.2096	.2667	.2286		.1524	.1715	.2096
23	.1524	.2286	.2096	.5201	.3721	.3366	.1905
24	.1334	.1334	.2096	.2096	.6024	.4119	.3681
Max	2.7168	2.5072	2.6863	.5201	1.0631	1.4883	1.4506
Min	.1143	.1334	.1334	.1905	.1524	.0953	.1905
Avg	.6273	.8447	.9853	.2765	.3800	.4090	.6887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	1.0808	1.3112	1.4175	.1905	.1334	.2286
2	1.701	1.3432	1.4327	1.5223	.1905	.1334	.2286
3	1.8755	1.6476	1.6301	1.7372	.2096	.1524	.2667
4	2.0908	2.0376	1.7896	1.8781	.2096	.1715	.2858
5	2.3819	2.3663	2.2386	2.0908	.2477	.2286	.3239
6	2.8349	2.6932	3.155	2.4177	.2477	.2667	.4191
7	3.1699	2.8654	3.2247	2.955	.2477	.3048	.4382
8	3.0121	2.6932	2.8654	2.8921	.2477	.2477	.2667
9	2.955	2.6863	2.5692	2.8296	.6268	.5548	.2477
10	2.3211	2.4806	2.4356	2.7463	.6154	.7011	.2286
11	.2858	.2286	.2667	2.6818	.7343	1.258	.1334
12	.3239	.2286	.2858	2.7221	.8869	1.2403	.1334
13	.2858	.1905	.2858	2.5692	1.1641	1.6476	
14	.1905	.2477	.2858	2.6863	1.1765	1.5769	.1715
15	.2667	.2667	.2858	2.3034	1.1888	1.6057	.2096
16	.2667	.2667	.2858	.7343	.8505	1.6712	.2477
17	.2286	.3048	.2858		.2096	.2096	.2858
18	.362	.2858	.3239	.2096	.2286	.1905	.2477
19	.2858	.3048	.381	.2286	.2477	.2858	.3239
20	.4001	.2286	.381	.3048	.2286	.3048	.362
21	.362	.3429	.362	.2858	.1905	.2667	.3239
22	.2477	.2477	.2858		.1334	.2477	.2667
23	.1905	.2286	.2477	.2096	.1334	.2286	.5973
24	.2286	.1905	.2286	.2477	.2096	.1334	.2286
Max	3.1699	2.8654	3.2247	2.955	1.1888	1.6712	.5973
Min	.1905	.1905	.2286	.2096	.1334	.1334	.1334
Avg	1.1579	1.0607	1.1185	1.7123	.4423	.5734	.2811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0762	.0572	.0572	.0572
6	.0953	.0572	.0762	.1143	.1143	.0572	.0953
7	.0572	.0572	.0762	.0953	.0953	.0762	.1143
8	.0572	.0572	.0572	.0572	.0572	.0762	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572		.0572	.0572	.0572	.0572	.0572
11	.0572	.0572	.0572	.0572	.0572	.0572	.0572
12	.0572	.0572	.0572	.0572	.0572	.0572	.0572
13	.0572	.0572	.0572	.0572	.0572	.0572	.0572
14	.0572	.0572	.0572	.0572	.0572	.0572	.0572
15	.0572	.0572	.0572	.0572	.0572	.0572	.0572
16	.0572	.0572	.0572	.0572	.0572	.0762	.0572
17	.0762	.0572	.0762		.0762	.0762	.0762
18	.0953	.1143	.1143	.0762	.1143	.0953	.0953
19	.1524	.1524	.1334	.0953	.1524	.0953	.1143
20	.1334	.1334	.1334	.1334	.1143	.0953	.1524
21	.0953	.0953	.0953	.0953	.0762	.0762	.0953
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23		.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.1524	.1524	.1334	.1334	.1524	.0953	.1524
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0704	.0688	.0699	.0696	.0715	.0659	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.1143	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.1143	.0953	.0953	.1143	.1143	.0953	.0953
4	.1334	.1143	.1334	.1334	.1334	.1334	.1334
5	.1715	.1334	.1524	.1715	.1715	.1524	.1524
6	.2096	.1715	.1715	.2096	.2096	.1524	.2286
7	.1715	.1715	.1715	.1905	.1715	.1715	.1905
8	.1334	.1715	.1143	.1334	.1524	.1524	.1143
9	.0953	.1334	.1334	.1143	.1143	.0762	.0762
10	.1143	.1143	.0953	.1143	.1143	.1334	.0953
11	.1334	.1143	.1524	.1524	.0953	.1143	.0953
12	.1334	.1334	.1143	.1334	.0953	.1143	.1143
13	.1334	.1334	.1334	.1143	.1143	.1334	.0953
14	.0953	.1143	.1334	.0953	.1334	.1334	.0953
15	.1334	.1143	.1143	.1334	.1334	.1334	.1334
16	.1334	.1143	.1334	.1143	.1334	.1143	.1143
17	.1905	.1143	.1715		.1334	.1905	.1524
18	.2096	.1334	.1905	.1524	.1905	.1524	.1143
19	.2477	.1715	.2667	.2096	.2477	.1905	.1715
20	.2477	.2286	.2477	.2096	.2286	.2096	.2096
21	.2096	.1905	.2096	.1715	.1905	.1715	.1715
22	.1524	.0953	.1334		.1524	.1143	.1334
23	.1143	.1143	.0953	.1334	.1143	.0953	.0953
24	.0953	.1143	.0953	.0953	.1143	.1143	.0953
Max	.2477	.2286	.2667	.2096	.2477	.2096	.2286
Min	.0953	.0953	.0953	.0953	.0953	.0762	.0762
Avg	.1485	.1326	.1437	.1403	.1437	.1358	.1278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	1.4746		
2		1.5746		
3		1.8233		
4		2.2939		
5		2.3758		
6		2.7349		
7		2.8178	.2343	
8	1.9925	2.7846	.2401	
9			2.5926	.3978
10	.5376		2.7854	.4588
11	.4923		2.8178	.4641
12	.3765		2.7035	.5304
13	.3475		2.7035	.4641
14	.3765		2.652	.431
15	.3292		2.652	.3932
16	.3475			.3647
17	.1623		.1326	.3978
18	.1989		.3018	.3978
19	.3978		.3772	.4588
20	.4807		.3467	.4641
21	.4641		.3467	.5571
22	.4641		.4207	.4973
23	.4862		.3506	1.3108
24		.4656	.2086	
Max	1.9925	2.8178	2.8178	1.3108
Min	.1623	.4656	.1326	.3647
Avg	.5007	2.0383	1.2862	.5059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926	.3077		.4066	.3077
2			.3475		.4163	.3475
3		.2926	.3582		.3658	.3696
4		.3326	.3801		.3921	.3841
5		.3696	.3898		.3258	.362
6		.4066	.4344		.3696	.4024
7		.4066	.4298		.3801	.3982
8	.3681	.4066	.4066		.3403	.3439
9	.2804	.3734	.3696	.2303	.3544	.3696
10	.2614	.298	.3326	.2328	.2947	.3361
11	.2614	.3292	.2987	.2658	.3189	.2987
12	.2915	.3366	.2987	.3582	.2303	.3326
13	.2926	.3582	.3292	.2915	.3366	.3326
14	.3086	.333	.3658	.2949	.3189	.2957
15	.2804	.3439	.3734	.2374	.3045	.3326
16	.2804	.3841		.2804	.3121	.3326
17	.3366	.3506	.3361	.2883	.3185	.3696
18	.2957	.407	.3772	.3361		.4066
19	.4435		.4066	.4252	.3201	.4435
20	.4435		.4435	.3841	.3224	.4066
21	.3547		.3696	.3544	.3012	.3475
22	.3292		.3326	.2772	.3292	.3292
23	.3292		.3326		.2772	.2957
24		.3326	.2865		.3658	.3292
Max	.4435	.407	.4435	.4252	.4163	.4435
Min	.2614	.2926	.2865	.2303	.2303	.2957
Avg	.3223	.3530	.3612	.3040	.3348	.3531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8288	1.0242		1.7604	1.3603
2		.7537	1.0903		1.8842	1.4403
3		.7293	1.1203		2.0243	1.5074
4		.8951	1.1458		2.2775	1.5546
5		.8951	1.2323		2.4143	1.6004
6		.8848	1.2567		2.536	1.7328
7		.8122	1.2567		2.9492	2.6686
8	1.0164	.9945	1.2567		3.0346	2.5029
9	1.1088	1.0719	1.2567		.6401	2.652
10	.7392	1.0456	1.2567	.5041	.5601	2.672
11	2.5873	2.3967	1.1458	.4877	.5228	2.5911
12	2.2119	2.6052	1.1458	.5359		2.5396
13	2.4697	2.7515	1.0164		.7577	2.4905
14	2.5526	2.9508	1.134	.4805	.7865	2.6216
15	2.6686	2.967	1.1458	.6535	.8402	2.7526
16	2.7846	2.9473		.9055	.9425	2.652
17	3.1687	3.1017	.7762	.924	.8402	2.652
18	2.652	2.9165	.7468	.9425	.8589	.6802
19	.6962		.6722	.961	.9335	.9831
20	.663		.6838	.6653	.5228	.9945
21	.6554		.7207	.7392	.6348	.7865
22	.6299		.7392	.8402	.4481	.9614
23	.6226		1.1088	1.1797	1.0722	.6962
24		.5571	1.9958		1.4752	1.2125
Max	3.1687	3.1017	1.9958	1.1797	3.0346	2.7526
Min	.6226	.5571	.6722	.4805	.4481	.6802
Avg	1.7017	1.6897	1.0838	.7553	1.3355	1.8460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1105	1.2125		2.2672	2.0485
2		.9945	1.2631		2.5857	2.2939
3		1.0277	1.3413		2.7692	2.6073
4		.9831	1.3592		2.8807	2.8647
5		1.0526	1.4091		3.0121	3.1417
6		1.4918	1.4413		3.0967	3.2007
7		1.2125	1.1934		3.3316	3.2606
8	1.2955	1.1603	1.2431		3.3916	3.3916
9	.7209	.9175	1.1934		.8583	3.4808
10	.2321	.8097	1.1934	.5601	.6562	3.4408
11	2.8178	2.5263	1.1271	.6062	.6478	3.2322
12	2.6246	2.9165	1.1271	.8421	.4572	3.1402
13	2.734	3.1824	1.1012	.8192	.6325	3.2322
14	2.8622	3.3196	1.1603	.8962	.7449	3.1131
15	3.1626	3.6134	1.0159	.8065		3.2322
16	3.4974	3.6885		.5792	.8482	3.0664
17	3.6134	3.722	.6962	.8333	.6882	3.1824
18	2.8841	3.7957	.6962	.9339	.8097	1.1142
19	1.0442		.9012	.7748	.7865	1.1105
20	1.065		.9116	.6401	.7935	1.0774
21	1.1603		.852	.759	.8002	.9945
22	1.065		.8619	.8962	.7287	1.0277
23	1.0774		.9945	1.6598	1.704	.9831
24		1.0608	2.3644		1.8023	1.8023
Max	3.6134	3.7957	2.3644	1.6598	3.3916	3.4808
Min	.2321	.8097	.6962	.5601	.4572	.9831
Avg	1.9910	2.0308	1.1591	.8290	1.5780	2.5016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914	.0549		.0572	.1109
2		.0924	.0543		.0724	.128
3		.0739	.0739		.0846	.0934
4		.0739	.0914		.1	.128
5		.1109	.128		.0753	.112
6		.1463	.1448		.132	.1294
7		.1294	.1075			.1097
8		.1294	.1075		.132	.1267
9		.0983	.0895		.112	.1086
10	.0724	.0848	.0895	.0895	.1134	.1097
11	.052	.0671	.0716	.0857	.0791	.128
12	.052	.0549	.056	.0995	.096	.0924
13	.052	.0739	.0924	.08	.08	.0747
14	.0876		.0924	.081	.0983	.0924
15	.1052	.1086	.112	.0655	.112	.0924
16	.1227	.0895		.04	.081	.1109
17	.0876	.12	.0895	.096	.08	.0924
18	.0876	.1492	.1075	.0934	.1406	.0914
19	.0876		.0886	.0987	.1014	.1097
20	.1433		.0914	.1286	.1143	.1294
21	.1254		.1294	.1014	.128	.0924
22	.0914		.0924	.0846	.0924	.0934
23	.0924		.0924	.0572	.0747	.0934
24		.0914	.0739		.0724	.0934
Max	.1433	.1492	.1448	.1286	.1406	.1294
Min	.052	.0549	.0543	.04	.0572	.0747
Avg	.0899	.0992	.0926	.0858	.0969	.1059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881		.8669	.6859	.1829	.1791	.1646
2	.3841		.9536	.7888	.1829	.181	.1646
3	.4001		.9536	.8413	.1829	.181	.1646
4	.4481		1.0402	.9156	.1829	.2172	.1829
5	.5121		1.0402	1.1736	.2378	.2658	.2378
6	1.2955		2.1948	1.893	.3658	.2629	.3658
7	1.5384		2.4025	1.8861	.3658	.3506	.4024
8	1.4403		1.8747	1.7772	.3292	.2629	.2195
9	1.3279		1.2955	1.1271	.3277	.5121	.1646
10	1.3279	1.4575	1.3603	1.2929	.4801	1.5261	.2561
11		.2195	.2561		.4801	.7459	.2743
12	.1097	.2195	.2743	1.1336		.9717	.2896
13	.1663	.2195	.2957	1.2289		1.1336	.2743
14	.1478	.2195	.2926	1.278	.7373	1.2146	.2614
15	.1294	.2195	.3292		.7459	1.2146	.2743
16	.1848	.2195	.3361		.6554	1.1336	.3361
17	.2587	.2149	.3258		.1638	.3292	.2587
18	.2926	.2149	.2561				.2957
19		.3582	.2926		.181		.2896
20	.3326	.3898	.4066		.2172		.2772
21	.2743	.2629	.3658	.2561	.2149		.2195
22	.2561	.1753	.362	.2195	.2126	.2195	.2195
23		.1734		.1829	.3189	.1646	.4359
24	.1463		.1734	.2896	.1829	.1791	.1646
Max	1.5384	1.4575	2.4025	1.893	.7459	1.5261	.4359
Min	.1097	.1734	.1734	.1829	.1638	.1646	.1646
Avg	.5362	.3260	.7804	.9982	.3309	.5623	.2581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0274	.0549	.0305	.1189	.125	.0892
2		.0282	.0549	.0312	.1189	.1296	.104
3		.0282	.0564	.0316	.1189	.1296	.104
4		.0423	.0714	.0324	.1189	.1296	.1219
5		.0446	.0714	.0486	.1562	.1619	.1524
6		.064	.0762	.0648	.2267	.3163	.2469
7		.0663	.0914	.0469	.3567	.3906	.3125
8		.048	.0914	.0474	.2378	.381	.2896
9		.032	.1027	.0282	.0463	.044	.1189
10		.0297	.0446	.0324	.0469	.0469	.1806
11		.2972	.3048	.029	.0457	.048	.2229
12		.2972	.463	.0274	.0429	.0282	.2641
13		.2858		.0297	.0358	.0305	.3048
14		.2858	.4572	.0309	.052	.0309	.3479
15	.1448	.282	.4344		.0457	.0309	.3086
16		.282	.3338		.0457	.0312	.2743
17		.2972	.4877		.0469	.0457	.0305
18		.2972	.2317	.0316	.0469		.0316
19		.0714	.048	.0486	.0474	.0486	.0633
20	.0486	.0857	.0625		.048	.0486	.048
21	.0474	.0846	.0474	.0469	.0486	.0492	.0474
22	.0312	.0846	.0312	.0474	.0486	.0328	.048
23		.08		.1265	.061	.0655	.0316
24		.0305	.0533	.0301	.1128	.125	.0846
Max	.1448	.2972	.4877	.1265	.3567	.3906	.3479
Min	.0312	.0274	.0312	.0274	.0358	.0282	.0305
Avg	.068	.1322	.1668	.0421	.0948	.1074	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1646	.2347	.04		
2	.1646	.2256	.2347	.1097		
3	.1646	.2256	.2896	.1669		
4	.192	.2256	.2896	.1669		
5	.192	.2896	.362	.2		
6	.5647	.5053	.5001	.381		
7	.3963	.5792	.5716	.6241		
8	.4161	.5213	.5716	.5716		
9	.423	.5068	.4572	.4512		
10	.3948	.4512	.4344	.3292	.423	
11	.0423	.0446	.0633	.3292	.3525	
12	.0423	.0446	.0617	.3018	.2172	
13	.0579	.0457	.061	.2896	.2896	
14	.0412	.0457	.0572	.2606	.3102	
15	.0423	.0463	.0549		.3102	
16	.0457	.0463	.0533		.3102	
17	.0457	.0469	.0753		.0423	.1265
18	.0457	.0625	.0633		.061	.1296
19		.0819	.096			.125
20	.116	.0983	.0949			.1265
21	.0819	.0781	.0312			.0949
22	.0486	.061	.0594			.0903
23		.0293				.1021
24	.0274	.0297	.0293	.04		
Max	.5647	.5792	.5716	.6241	.423	.1296
Min	.0274	.0293	.0293	.04	.0423	.0903
Avg	.1674	.1857	.2064	.2841	.2574	.1136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0924	.0724	.0914	.1109	.0732	.0924
2	.0554	.0934	.0724	.0924	.1109	.0732	.0924
3	.0554	.0924	.0732	.0934	.1109	.0732	.0924
4	.0739	.0924	.0914	.112	.1109	.1097	.1109
5	.0739	.1109	.1097	.1463	.112	.1629	.1294
6	.0924	.1848	.1829	.2641	.128	.1629	.2587
7	.056	.2033	.1829	.2801	.1478	.1646	.2743
8	.0739	.2402	.1463	.2241	.1478	.128	.2218
9	.0739	.2218	.128	.1829	.1294	.1097	.1848
10		.1848		.1463	.1294	.1097	.181
11		.1663	.0914	.128	.1109	.0732	.1097
12		.1663	.0914	.1097	.0914	.1294	.1086
13	.0739	.1478		.1294	.0732	.1109	.1063
14	.0554		.1097	.1294	.0732	.0924	.104
15	.0537	.1463	.1086		.0732	.1109	.1052
16		.1463	.1372		.1097	.1294	.1372
17		.1463	.1715		.1097	.1478	.1543
18		.1463	.1791	.2149	.1267	.2218	.2126
19		.1829	.2033	.1829	.1629	.2402	.2195
20	.2957	.2715	.2402		.181	.2241	.2587
21	.2218	.2172	.2033	.2218	.1086	.1848	.1829
22	.1848	.181	.1463	.1494	.0905	.1478	.1509
23		.1086		.112	.0724	.1097	.1132
24	.0554	.1109	.0724	.1086	.112	.0732	.0924
Max	.2957	.2715	.2402	.2801	.181	.2402	.2743
Min	.0537	.0924	.0724	.0914	.0724	.0732	.0924
Avg	.0969	.1589	.1340	.1560	.1139	.1318	.1539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0943	.0934		.0189	.0183
2		.0914	.0943	.0934		.0189	.0183
3		.0914	.0943	.0914		.0189	.0183
4		.0914	.0943	.0943		.0189	.0183
5		.1097	.1132	.0934		.0189	.0185
6		.1097	.1132	.1132		.0377	.0366
7		.1463	.1509	.1886		.0377	.0366
8	.1478	.0924	.1509	.1698		.0377	.0366
9	.1294		.1509	.1886			.0366
10	.1294	.1478	.1646	.1509		.0351	.0366
11		.1663	.1463	.1494	.0743	.0297	.0358
12	.1097	.112	.1463	.1494		.0716	.0354
13	.2033	.112	.1267	.1478		.0732	.0366
14	.1663	.112	.1307	.1478	.1132	.0739	.0362
15	.1294	.0754	.1494		.0943	.0554	.0549
16	.1478	.0754	.1886		.132	.037	.0532
17	.1848	.0943	.132		.132		.0343
18	.1663	.1132	.1109			.037	.0177
19		.1509	.1478		.0566		.0362
20	.1848	.1886	.1463		.0566		.0183
21	.1646	.1509	.112		.0566		.0185
22	.128	.1132	.1132		.0377	.0183	.0177
23		.0943			.0377	.0183	.0183
24		.0914	.0943	.0943		.0189	.0183
Max	.2033	.1886	.1886	.1886	.132	.0739	.0549
Min	.1097	.0754	.0943	.0914	.0377	.0183	.0177
Avg	.1532	.115	.1289	.1310	.0791	.0356	.0294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 207 / 11 KV JADAR BOBALAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.0486	.1463		.3277	.3239
2		.1109	.0486	.1478		.3277	.3239
3		.1109	.0486	.168		.3277	.3239
4		.1109	.0486	.1867		.4858	.3563
5		.1109	.0648	.1867		.5668	.4049
6		.1478	.081	.2641		1.0526	.6478
7		.1478	.1134	.3018		1.1336	.7287
8		.1109	.0972	.1886		1.1336	.5121
9		.1109	.081	.2241		.1457	.5761
10		.0739		.1848	.2218		.543
11		.1943	.7099	.1294	.1943	.1943	.743
12			.6401	.1109	.0648	.2195	.7628
13			.5792	.1109	.0648	.2012	.7727
14			.643	.1109	.1134	.1829	.7819
15			.7145		.1296	.2218	.8173
16		.1619	.6763		.1296	.2402	.8322
17			.543		.1457	.2587	.1753
18		.1943	.4534		.1457	.2587	.3658
19		.1134	.1848		.1619		.3982
20	.0739	.1134	.1829		.1619		.3658
21	.0924	.0972	.1829	.3258	.1619	.2218	.3326
22	.0924	.0972	.1848		.1619	.1663	.2561
23		.0648			.1457	.2591	.2195
24		.0739	.0486	1.3717		.2429	.3239
Max	.0924	.1943	.7145	1.3717	.2218	1.1336	.8322
Min	.0739	.0648	.0486	.1109	.0648	.1457	.1753
Avg	.0862	.1187	.2898	.2599	.1431	.3890	.4953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.9831	.8192	.9831	.1638	.1638	.1696
2	.6554	1.4746	1.1469	1.1469	.1638	.1638	.1638
3	.8192	1.6385	1.6385	1.3108	.1638		.1638
4	1.3108	1.8023	1.6385	1.3108	.1638	.1638	.1638
5	1.8023	1.9662	1.8023	1.4746	.2458	.1638	.1638
6	2.13	1.9662	2.13	1.6385	.3277	.2458	.2458
7	2.2939	2.13	2.4577	1.9662	.3277	.2458	.2458
8	2.13	2.13	2.3758	1.9662	.2458	.2458	.1638
9	2.13	1.9662	2.13	1.9662	.4915	.9012	.1638
10	1.9662	1.9662	2.0481	1.8023	1.6385	1.5565	.1638
11	.1638	.1638	.2458		1.6385	1.5565	.1638
12	.1638	.1638	.1638			1.6385	.1638
13	.1638	.1638	.2458	1.6975	1.8842	1.9662	.0819
14	.1638	.1638	.2458	2.0748	1.8023	1.9662	.0819
15	.1638	.2458	.2458	1.8023	1.8023	2.0481	.1638
16	.1524	.1638	.2458		1.8023	1.9662	.1638
17	.1638	.1638	.2458	.3277	.1638	.1638	.1638
18	.2458	.2458	.2458	.1638	.1638		.1638
19		.2458	.2458	.1638	.1638		.1638
20	.2458	.2458	.2458	.2458	.1638	.1638	.1638
21	.1638	.1638	.2458	.2458	.1638	.1638	.1638
22	.1638	.1638	.2458	.2458	.1638	.1638	.1638
23	.1638	.1638	.1638	.1638	.1638	.1638	.6554
24	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Max	2.2939	2.13	2.4577	2.0748	1.8842	2.0481	.6554
Min	.1524	.1638	.1638	.1638	.1638	.1638	.0819
Avg	.7902	.8602	.8909	1.0886	.6162	.7607	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0819	.0819	.0819	.4915	.6554	.2458
2	.0819	.0819	.0819	.0819	.4915	.6554	.2458
3	.0819	.0819	.0819	.0819	.4915	.6554	.2458
4	.0819	.0819	.0819	.0848	.4915	.6554	.2458
5	.0819	.0848	.0819	.0848	.9831	.8192	.2458
6	.1638	.1696	.0819	.1696	1.3108	.9831	.3277
7	.1638	.1696	.1638	.1696	1.3108	1.1469	.4915
8	.1638	.1696	.1638	.0848	1.3108	.9831	.4915
9	.1638	.1638	.0819	.0819	.0819	.1638	.4915
10	.1638	.0819	.0819	.0819	.0819	.0819	.4915
11	.6554		.6554		.0819	.0819	.6554
12	.6554		.8192			.0819	.6554
13	.6554	.6554	.9831	.0819	.0943	.0819	.6554
14	.9831	.9831	1.0174	.0819	.0819	.0791	.6554
15	.3277	1.3108	1.0174	.0819	.0819	.0819	.6554
16		1.3108	1.0174		.0943	.0819	.4915
17		1.3108	.8478	.0819	.0819	.0819	.0819
18		1.3108	.6783	.0819	.0819		.0819
19		.1638	.1696	.0819	.1638		.1638
20	.1638	.1638	.1638	.0819	.1638	.1638	.1638
21	.1638	.1638	.1638	.0819	.1638	.1638	.1638
22	.1638	.0819	.1638	.0819	.1638	.1638	.0819
23	.0819	.0819	.0819	.0819	.3277	.2458	.0819
24	.0819	.0819	.0819	.0819	.4915	.4915	.2458
Max	.9831	1.3108	1.0174	.1696	1.3108	1.1469	.6554
Min	.0819	.0819	.0819	.0819	.0819	.0791	.0819
Avg	.2580	.3994	.3685	.0907	.3964	.3909	.3482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0943	.0566	.0566	.0566	.0566
5	.0566	.0943	.0943	.0566	.0754	.0566	.0566
6	.0566	.1132	.0943	.0566	.0754	.0754	.0566
7	.0566	.1132	.0943	.0566	.0943	.0754	.0754
8	.0566	.0943	.0943	.0566	.0754	.0754	.0754
9	.0566	.0943	.0943	.0566	.0566	.0754	.0754
10	.0566	.0943	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566		.0566	.0566	.0566
12	.0566	.0566	.0566			.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0754	.0566	.0566	.0566	.0566	.0566
15	.0566	.0754	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566		.0566	.0566	.0566
17	.0943	.0566	.0566	.0566	.0566	.0566	.0566
18	.0943	.0943	.0566	.0943	.0566		.0566
19		.0943	.0566	.0943	.1132		.0943
20	.0943	.0943	.0943	.1132	.1132	.1132	.0943
21	.0943	.0943	.0943	.0943	.1132	.1132	.0943
22	.0943	.0943	.0943	.0754	.1132	.1132	.0943
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.1132	.0943	.1132	.1132	.1132	.0943
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0648	.0770	.0707	.0656	.0705	.0677	.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0848	.0848	.0848		.8478	.2543
2		.0848	.0848	.0848		.8478	.2543
3		.0848	.0848	.0848		.8478	.2543
4		.0848	.1696	.0848		.8478	.2543
5		.0848	.1696	.0848		.8478	.3391
6		.1696	.1696	.1696		1.0174	.5087
7		.1696	.1696	.1696		1.2717	.5935
8		.1696	.1696	.0848		1.2717	.5935
9		.1696	.0848	.0848		.1696	.5935
10		.0848	.0848	.0848		.0848	.5935
11		1.1022	1.1869			.0848	.6783
12	.3391	1.3565	1.6956			.0848	.763
13	.5087	1.6108	1.6956	.0848	.0848	.0848	.6783
14	.8478	1.5261	1.5261	.0848	.0848	.0848	.6783
15	.8478	1.4413	1.5261	.0848	.0848	.0848	.6783
16		1.3565	1.5261		.0848	.0848	.6783
17	.8478	1.5261	1.0174		.0848	.0848	.0848
18		1.5261	.9326	.0848	.0848		.0848
19		.1696	.1696	.0848	.1696		.1696
20	.1696	.1696	.1696	.1696	.1696	.1696	.1696
21	.1696	.1696	.1696	.1696	.1696	.1696	.1696
22	.1696	.1696	.1696		.1696	.1696	.0848
23	.0848	.0848	.0848		.5087	.2543	.0848
24		.0848	.0848	.0848		.6783	.2543
Max	.8478	1.6108	1.6956	.1696	.5087	1.2717	.763
Min	.0848	.0848	.0848	.0848	.0848	.0848	.0848
Avg	.4428	.5617	.5511	.1036	.1542	.4586	.3957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0754	.0754
7	.0566	.0943	.0943	.0566	.0754	.0754	.0754
8	.0566	.0943	.0943	.0566	.0566	.0754	.0754
9	.0566	.0566	.0566	.0566	.0566	.0754	.0754
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566		.0566		.0566	.0566	.0566
12	.0566	.0566	.0566			.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.0566	.0566	.0566	.0566	.0566
15	.0566	.0566	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566		.0566	.0566	.0566
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0566	.0943	.0566	.0943	.0566		.0566
19		.0943	.0566	.0943	.1132		.0943
20	.0943	.0943	.0943	.0943	.1132	.1132	
21	.0943	.0943	.0943	.0754	.1132	.1132	.0943
22	.0943	.0566	.0943	.0566	.1132	.1132	.0943
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.1132	.1132	.0943
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0615	.0664	.0645	.0629	.0673	.0677	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0943	.0754	.0754	.0754	.0754	.0754
5	.0754	.0943	.0754	.0754	.0754	.0754	.0754
6	.0754	.0943	.0754	.0754	.0943	.0943	.0943
7	.0754	.1132	.0754	.0754	.0943	.0943	.0943
8	.0754	.0943	.0754	.0754	.0943	.0943	.0943
9	.0754	.0943	.0943	.0754	.0754	.0943	.0943
10	.0754	.0754	.0943	.0754	.0754	.0754	.0754
11	.0754	.0754	.0754		.0754	.0754	.0754
12	.0754	.0754	.0754			.0754	.0754
13	.0754	.0754	.0754	.0754	.0754	.0754	.0943
14	.0754	.0754	.0754	.0754	.0754	.0754	.0943
15	.0754	.0754	.0754	.0754	.0754	.0754	.0943
16	.0754	.0754	.0754		.0754	.0754	.0943
17	.1132	.0943	.0754		.0754	.0754	.0943
18	.1132	.0943	.0754	.132	.0754		.0943
19		.1132	.0943	.132	.1509		.1509
20	.1509	.132	.1509	.1509	.1509	.1509	.1509
21	.1509	.132	.1509	.1509	.1509	.1509	.1509
22	.1509	.132	.1509	.1132	.1509	.1509	.0943
23	.0943	.0754	.0754	.0943	.0754	.0754	.0754
24	.0754	.0943	.0754	.0754		.0754	.0754
Max	.1509	.132	.1509	.1509	.1509	.1509	.1509
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.0894	.0919	.0872	.0914	.0917	.0891	.0935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0174	1.0174	1.3565	.3391	.2543	
2		1.1869	1.5261	1.3565	.3391	.2543	
3		1.5261	2.0348	1.3565	.3391	.2543	
4		1.5261	2.2043	1.3565	.3391	.2543	
5		2.0348	2.2043	1.5261	.4239	.2543	
6		2.2043	2.3739	2.0348	.4239	.3391	
7		2.4587	2.7978	2.5434	.4239	.5935	
8	1.1869	2.4587	2.9673	2.5434	.4239	.5087	
9	1.5261	2.3739	2.5434	2.5434	.6783	.5935	
10	1.1869	.3391	2.2891	2.3739	2.0348	2.5434	.0848
11	.3391	.3391	.4239	2.3739	2.1195	2.5434	.0848
12	.3391	.4239	.3391	2.3739		2.5434	.0848
13	.3391	.5087	.3391	2.3739	2.3739	2.5434	.0848
14	.3391	.4239	.4239	2.2043	2.3739	2.713	.0848
15	.3391	.4239	.4239	2.3739	2.3739	2.713	.2543
16	.3391	.4239	.4239		2.2891	2.2043	.3391
17	.4239	.4239	.5087	.3391	.3391	.3391	.3391
18	.5087	.5087	.5087	.4239	.3391		.3391
19		.5087	.4239	.4239	.5935		.3391
20	.4239	.4239	.4239	.4239	.5935		.3391
21	.3391	.4239	.4239	.4239	.5935		.3391
22	.3391	.4239	.4239	.4239	.5935		.3391
23	.3391	.3391	.3391	.4239	.3391		.5087
24	.3391	.3391	.3391	.3391	.3391	.3391	
Max	1.5261	2.4587	2.9673	2.5434	2.3739	2.713	.5087
Min	.3391	.3391	.3391	.3391	.3391	.2543	.0848
Avg	.5405	.9609	1.1551	1.4745	.9142	1.2105	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1696	.1696	.1696	1.0174	.8478	.3391
2	.1696	.1696	.1696	.1696	1.0174	.8478	.3391
3	.1696	.1696	.1696	.1696	1.0174	.8478	.3391
4	.1696	.1696	.1696	.1696	1.0174	1.3565	.3391
5	.1696	.1696	.1696	.1696	1.8652	1.5261	.3391
6	.2543	.1696	.1696	.1696	2.2043	1.6956	.5087
7	.2543	.1696	.2543	.1696	2.2043	2.1195	.6783
8	.2543	.1696	.1696	.1696	2.2043	1.95	.6783
9	.2543	.2543	.2543	.1696	.1696	.1696	.6783
10	.1696	.1696	.2543	.1696	.1696	.1696	.6783
11	2.0748	1.8652	2.0348		.1696	.1696	.6783
12	1.6956	2.0348	2.1195			.1696	.9326
13		2.0348	2.0348	.1696	.1696	.1696	1.0174
14	.6783	1.8652	1.8652	.1696	.1696	.1696	1.0174
15	1.8652	1.95	2.0348	.1696	.1696	.1696	1.0174
16	1.8652	1.95	2.0348		.1696	.1696	1.0174
17	2.3739	1.95	1.5261	.1696	.1696	.1696	.1696
18	2.2043	1.8652	1.3565	.1696	.1638		.1696
19		.2543	.1696	.1696	.1696		.1696
20	.2543	.2543	.1696	.1696	.1696	.1696	.1696
21	.2543	.2543	.1696	.1696	.1696	.1696	.1696
22	.1696	.2543	.1696	.1696	.1696	.1696	.1696
23	.1696	.1696	.1696	.1696	.3391	.3391	.1696
24	.1696	.1696	.1696	.1696	.6783	.6783	.3391
Max	2.3739	2.0348	2.1195	.1696	2.2043	2.1195	1.0174
Min	.1696	.1696	.1696	.1696	.1638	.1696	.1696
Avg	.7186	.7772	.7489	.1696	.6854	.6474	.5052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.2374	.2915	.2241	.7969	.6783	.7377
2	.3185	.2035	.2713	.2241	.8383	.7545	.7293
3	.3185	.2229	.2713	.2427	.8718	.8718	.8383
4	.3391	.2427	.3052	.3086	.9389	.9156	.8718
5	.3391	.2743	.3429	.3353	1.0608	.9389	.9614
6	.4527	.3353	.407	.4694	1.3923	1.5249	1.1934
7	.285	.3688	.4694	.503	1.7901	2.0553	1.6766
8	.3353	.3052	.4359	.4748	1.4419	2.146	1.7238
9	.3391	.3222	.4024	.407	.1696	.2035	1.6575
10	.3185	.2713	.373	.4024	.218	.218	1.5729
11	1.8564	1.3923	2.146	.3688		.2683	1.6385
12	1.5424	1.5424	2.1879	.3521			1.1934
13	2.0553	1.9448	2.1879	.3856		.2374	1.5249
14	2.0972	1.8778	1.8564	.2035		.2374	1.6575
15	2.0972	1.989	2.1628	.285	.1526	.2683	1.6575
16	2.1628	1.989	2.2283	.2683	.1865	.2683	1.6575
17		1.7238	2.2283		.2402	.3734	.2987
18	1.7238	2.0119	2.1216	.2195	.2218	.2241	
19	.2241	.3326	.3361	.2587	.3361	.2218	.2614
20	.3696	.3841	.462	.2957	.3696	.2587	.3696
21	.3658	.3326	.2587	.2614	.3326	.2614	.3326
22	.3326	.3326	.2614	.2241	.2987	.2241	.3326
23	.3326	.2957	.2614	.5959	.5258	.5365	.3121
24	.3174	.2614	.2957	.2587	.6783	.6859	.6706
Max	2.1628	2.0119	2.2283	.5959	1.7901	2.146	1.7238
Min	.2241	.2035	.2587	.2035	.1526	.2035	.2614
Avg	.8186	.7997	.9402	.3291	.6430	.6249	1.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	.8215	.7291	.9221	.2629	.3429	.2883
2	1.2574	.8478	.8718	.9945	.2601	.3391	.2915
3	1.4251	.8383	.9835	1.0395	.2774	.3391	.3121
4	1.4586	.9892	1.1065	1.2742	.298	.3561	.3391
5	1.6741	1.0774	1.3592	1.5415	.3121	.3856	.3944
6	2.3868	1.1934	1.6741	1.8351	.4287	.6539	.5087
7	2.3922	1.6712	1.8187	2.2775	.5087	.6539	.6036
8	2.556	1.8515	1.7368	2.1464	.3391	.5765	.5868
9	2.5194	1.704	1.7901	2.2186	.788	.8383	.57
10	1.7436	1.6741	1.9227	2.2119	1.0227	1.5261	.5256
11	.3561	.3052	.3561	2.2447	1.442	1.6741	.5533
12	.4527	.1844	.4578	2.0481	1.8233		.5197
13	.4917	.285	.503	2.0553	1.8067	2.0645	.4748
14	.4578	.3018	.373	2.1382	1.8442	2.1216	.4409
15	.503	.3185	.4359	2.2045	1.8233	2.0553	.4359
16	.5868	.3561	.4694	2.0119	1.7404	2.2447	.4748
17		.2883	.5533		.2218	.2987	.5415
18	.5533	.4191	.6274	.2561	.3174	.4805	.5415
19	.4435	.4805	.7842		.4294	.4805	.6283
20	.6348	.462	.8131	.3142	.4805	.4294	.5975
21	.5729	.4207	.7095	.3142	.4435	.3881	.499
22	.4805	.3841	.5228	.2957	.3881	.3734	.4481
23		.2402	.4805	.2629	.3696	.3086	.7373
24	.4854		.2427	.4854	.2629	.333	.3052
Max	2.556	1.8515	1.9227	2.2775	1.8442	2.2447	.7373
Min	.3561	.1844	.2427	.2561	.2218	.2987	.2883
Avg	1.1152	.7441	.8884	1.4133	.7455	.8376	.4841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0739	.0747	.0924	.0934	.0934	.0747
2	.0754	.0747	.0754	.0747	.0943	.0754	.0739
3	.0754	.0924	.0754	.0747	.0943	.0754	.0934
4	.0754	.112	.0943	.0924	.0943	.0943	.112
5	.0934	.1307	.112	.112	.112	.112	.1478
6	.1494	.1663	.1307	.1663	.1494	.168	.1829
7	.1478	.1478	.1663	.1478	.1848	.1663	.1307
8	.1294	.112	.1478	.112	.1848	.1478	.1478
9	.1109	.1109	.1109	.112	.1478	.1109	.1307
10	.0934	.0934	.0934	.1109	.112	.112	.1294
11	.0934	.0739	.0924	.0747		.0924	.1109
12	.1109	.0934	.0934	.0924			.0934
13	.1109	.0924	.0924	.0924		.0924	.0934
14	.0934	.0739	.0739	.1097		.0924	.1109
15	.0924	.0924	.0747	.0914	.0934	.1097	.1109
16	.0934	.0924	.0924	.0914	.1109	.0924	.112
17		.0747	.1109	.0924	.1109	.1109	.0924
18	.1294	.112	.1294	.1294	.1294	.1494	
19	.1478	.1294	.1307	.1478	.1494	.1663	.1663
20	.2012	.1848	.1829	.1848	.1867	.1478	.2033
21	.1646	.1867	.1463	.1663	.1494	.1294	.1294
22	.1294	.1494	.1109	.1109	.1307	.112	.0934
23	.112	.112	.0934	.112	.0934	.0924	.0747
24	.0934	.0934	.0747	.0924	.0934	.0934	.0934
Max	.2012	.1867	.1829	.1848	.1867	.168	.2033
Min	.0747	.0739	.0739	.0747	.0934	.0754	.0739
Avg	.1129	.1115	.1075	.1118	.1257	.1146	.1177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0373	.0554	.0373	.056	.037
2		.0554	.0373	.056	.0373	.056	.0373
3		.056	.037	.056	.0377	.056	.0554
4		.056	.0554	.0739	.0566	.0554	.0554
5		.0739	.056	.0739	.0934	.0739	.0747
6		.1097	.0934	.0924	.1307	.1109	.1109
7		.0914	.0924	.112	.112	.112	.1109
8	.0554	.0924	.0554	.0739	.0924	.0747	.0554
9			.0554	.056	.0739	.0554	.056
10	.0554		.0373		.037	.037	.0373
11	.037		.056	.0187	.0373	.0185	.037
12	.0187			.0373	.0373		.0187
13	.0373		.0373	.0373	.037	.0187	.0187
14	.037		.037	.037	.0185	.037	.0185
15	.037		.037	.037	.0183	.0187	.0373
16	.0554	.0554	.0554	.0549	.0183	.037	.0185
17		.0554	.056		.0366	.0373	.0373
18	.0554	.0739	.056		.0366	.0554	.0739
19	.056	.0739	.0747			.0739	.0554
20	.1109	.0747	.0914	.0924	.0924	.1109	
21	.0924	.0747			.0924	.0934	
22	.0747	.0739		.0554	.0747	.0554	
23		.037	.0554	.056	.0747	.0373	
24			.0373	.037	.056		.0554
Max	.1109	.1097	.0934	.112	.1307	.112	.1109
Min	.0187	.037	.037	.0187	.0183	.0185	.0185
Avg	.0556	.0682	.0548	.0586	.0582	.0582	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.0349	1.3056	1.073	.1526	.2713	.3052
2	1.4586	1.0682	1.4413	1.2431	.1357	.2713	.285
3	1.5089	1.5261	1.543	1.3077	.1526	.2713	.2883
4	1.5415	1.5261	1.5592	1.442	.1357	.2713	.3018
5	1.5581		1.643	1.5083	.1341	.285	.3018
6	1.8023		1.6078	1.6712	.2012	.3561	.3561
7	1.3927		1.8351	1.9334	.2683	.4578	.6036
8	1.917		1.704	1.6907	.2713	.1526	.2035
9	1.6078		2.0153	1.6385	.7042		.3561
10	1.6741		1.7238		.9892	1.3077	.4527
11	.6036		.5935	1.6409	1.2929	1.5083	.5365
12	.7377			1.6575	1.5249		.1526
13	.7209		.5868	1.5912	1.3435	1.7238	.4578
14	.5765		.5365	1.6095	1.5893	1.7072	.4694
15	.6203	.503	.5935	1.4918	1.6078	1.8351	.5197
16	.6539	.6706	.503	1.5746	1.5249	1.7901	.4578
17		.5426	.7712		.2614	.2427	.4481
18	.57	.7377	.788	.128	.1663	.2987	.4805
19	.2801	.8596	.8686		.1848	.2772	.5729
20	.5975	.8413	.6722	.2218	.3142	.2987	.1494
21	.5544	.8596	.5359		.3326	.3696	.2614
22	.4854	.7947	.5175	.1663	.3292	.3696	.168
23		.7392	.5041	.1772	.3292	.3391	.6706
24	.4435	.1494	.6838	.4668	.1715	.2743	.3391
Max	1.917	1.5261	2.0153	1.9334	1.6078	1.8351	.6706
Min	.2801	.1494	.503	.128	.1341	.1526	.1494
Avg	1.0233	.8466	1.0666	1.2117	.5882	.6672	.3807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.1734	.2254	.2229	.3185	.0509	.5087
2	.218	.1715	.2229	.2254	.3353	.0509	.5365
3	.2347	.2058	.2229	.2401	.3856	.0671	.5426
4	.2515	.218	.2374	.2572	.4144	.0838	.6443
5	.2713	.2713	.2683	.3052	.4475	.1006	.7042
6	.3353	.3391	.2515	.3052	.5898	.2515	.8619
7	.2515	.3772		.3856	.8684	.3222	1.2597
8	.2713	.2683	.2486	.3521	.852	.7377	.6874
9	.2883	.2683	.2683	.3353	.1341	.1677	1.1271
10	.3018	.2374	.2347	.3561	.1802	.2321	1.2266
11	1.6078		1.4089	.3856	.1658	.1989	1.3426
12	1.9006	.5197	1.7368	.3688	.1492		.6203
13	1.9498	1.1768	1.8023	.3353	.1341	.1865	1.2431
14	1.9498	1.4586	1.5581	.3353	.1341	.2543	1.2763
15	1.873	1.442	1.6876	.3391	.1509	.218	1.278
16	1.917	1.4255	1.6575	.3052	.1696	.2515	1.2944
17		1.3108	1.8351		.2033		.1494
18	1.8023	1.4089	1.8023	.1663			.2218
19	.2614	.1989	.2614	.1848		.2241	.2241
20	.3881	.2772	.3696	.2218	.0373	.2772	.2218
21	.3696	.3142	.3326	.1867	.0187	.2402	.2054
22	.3142	.2801	.2614	.168	.0185	.2054	.168
23		.2801	.2402	.2915	.0187	.2774	.156
24	.2587	.1867	.2614	.2427	.2883	.0343	.4115
Max	1.9498	1.4586	1.8351	.3856	.8684	.7377	1.3426
Min	.218	.1715	.2229	.1663	.0185	.0343	.1494
Avg	.7835	.5569	.7563	.2833	.2734	.2111	.7047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 208 / 11 KV DHULKARWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3916		1.4582		.298	.3988	.3222
2	1.4586		1.6278		.2835	.3944	.3222
3	1.5249		1.7101		.2804	.407	.3353
4	1.6575		1.6766		.298	.407	.39
5	1.7901		1.7404		.3121	.4191	.4239
6	1.9006		1.6712		.5658	.6036	.5197
7	1.4918		2.0317		.5256	.6539	.663
8	1.9334		1.5238		.5596	.3561	.3353
9	1.5581		1.873		.8718		.6133
10	1.5581		1.7901		.8048	1.3413	.6962
11	.5533		.6371	1.5581	1.6078	2.0287	.6706
12	.7377			2.0719	1.9062		.1865
13	.7712		.6539	1.9616	1.8067	1.9498	.5801
14	.6783		.5935	2.2634	1.9826	2.0972	.6539
15	.6952		.7545	1.9559	1.9662	1.989	.7545
16	.7042	.7122	.2035	1.8564	1.8067	2.0317	.6203
17		.763	.8785		.2218	.3174	.7577
18	.8122	.8718	.788		.2957	.5175	.8316
19	.4294	.8962	.9055		.3174	.4854	.7316
20	.7577	.5853	.8131		.5359	.4435	.2218
21	.6767	.7577			.499	.4435	.3361
22	.5544	.7023		.3174	.462	.4108	.2241
23		.6468		.3155	.462	.3467	.7712
24	.5415		.6099		.2947	.4161	.3429
Max	1.9334	.8962	2.0317	2.2634	1.9826	2.0972	.8316
Min	.4294	.5853	.2035	.3155	.2218	.3174	.1865
Avg	1.0989	.7419	1.1970	1.5375	.7902	.8390	.5127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914	.0934	.0953	.0876	.0886
2		.0943	.0895	.0914	.0857	.0838
3		.0934	.0914	.0934	.1097	.0848
4		.0924	.0876	.0886	.1063	.0914
5		.0876	.0895	.0857	.12	.0876
6		.0857	.0943	.0914	.1334	.0953
7		.0934	.0924	.0934	.0943	.1143
8		.1372	.1097	.0914	.0943	.1132
9		.1463	.0905	.0924	.0914	.0895
10		.112		.0886	.0886	.0914
11		.096	.181	.0886	.0857	.0905
12		.0838	.1791	.12	.0914	.0914
13			.0934	.0838	.0934	.0914
14		.0819	.0857	.0857	.0857	.0895
15		.0772	.0934	.0905	.0886	.0905
16		.0791		.0886	.0914	.0905
17		.0838		.0876	.0914	.0914
18		.0848		.0914	.0886	.1294
19		.0857		.0895		.1646
20	.1867	.0934	.0886	.0876	.0886	.1097
21	.1772	.0895	.0867	.0895	.0867	.0924
22	.0895	.0934	.0943	.0876	.0857	.0914
23	.0876	.0914	.0953	.0857	.0876	.0876
24		.0934	.0934	.0953	.0914	.0953
Max	.1867	.1463	.181	.12	.1334	.1646
Min	.0876	.0772	.0857	.0838	.0857	.0838
Avg	.1353	.0942	.1015	.0910	.0942	.0977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0934		.1029
2		.0953	.0867		.1063
3		.0953	.0781		.1097
4		.0934	.0772		.104
5		.0943	.0762		.1402
6		.0943	.0983	.1638	.1357
7		.0934	.1341	.144	.1492
8		.0943	.0838	.1355	.1526
9		.0934	.0857	.0914	.1562
10		.0943	.0876	.0943	.1326
11		.0943	.0886	.0876	.1296
12		.0943	.0943	.0876	.1357
13		.0743	.0943	.0943	.1492
14		.0914	.1086	.0914	.1619
15		.1067	.0914	.0934	.16
16			.0934	.0943	.1739
17			.0934	.0914	.0857
18			.0857		.0943
19			.0926		.0943
20		.112	.08		.0876
21	.1886	.0914	.0772	.0934	.0876
22	.0953	.0953	.0983	.0895	
23	.0886	.0953	.0876	.0876	.0857
24		.0953	.0953	.0953	.0876
Max	.1886	.112	.1341	.1638	.1739
Min	.0886	.0743	.0762	.0876	.0857
Avg	.1242	.0947	.0909	.1022	.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1753	.0857	.0762	.0876
2		.2195	.0876	.0772	.1097
3		.2835	.0838	.0819	.1387
4		.3361	.0762	.0781	.1494
5		.3429	.0819	.0819	.1402
6		.301	.08	.0848	.1494
7		.3201	.0819	.0876	.1132
8		.3593	.0934	.0857	.0934
9		.3763	.2572		.0953
10		.3121	.1739	.2347	.0934
11		.3121	.1718	.1829	.0924
12		.301	.1677	.2804	.0934
13		.2972	.1783		.0924
14		.2972			.0914
15		.2896		.3125	.0895
16				.5864	.0905
17				.1372	.0934
18					.0924
19					.0914
20		.0914	.0857		.0857
21		.0857		.0914	.0914
22	.0924	.112	.0934	.0886	.0762
23		.0943	.0914	.0857	.0819
24		.1494	.0867	.0934	.0943
Max	.0924	.3763	.2572	.5864	.1494
Min	.0924	.0857	.0762	.0762	.0762
Avg	.0924	.2528	.1163	.1526	.1011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0934		.0867	.0895
2		.0886	.0914		.0857	.0934
3		.0914	.0934		.0914	.0857
4		.0895	.0895		.0886	.0886
5		.0934	.1753		.0857	.1753
6		.0876	.2715		.1867	.1829
7		.0943	.1715		.2254	.1296
8		.0943	.1677		.2743	.144
9		.0943	.1492		.1907	.1075
10			.1543		.1677	.1097
11			.1734		.0914	.1109
12			.1734		.0876	.0972
13			.1715		.1417	.1029
14			.0886		.0857	.1254
15			.0857		.0857	.181
16				.1372	.0857	.2195
17				.1595		.1865
18				***		.2058
19				.2454		.2353
20						.1543
21			.0857	.2303	.1417	.1478
22	.0895	.1097	.0934	.1433	.0791	.0876
23	.0857	.0857	.0934	.1543	.0819	.0934
24		.0886	.1109		.128	.0943
Max	.0895	.1097	.2715	123.8656	.2743	.2353
Min	.0857	.0857	.0857	.1372	.0791	.0857
Avg	.0876	.0919	.1333	17.8479	.1246	.1353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.1562	.0876
2		.208	.2294	.0867
3		.2401	.2713	.0934
4		.2835	.3086	.0886
5		.3361	.3658	.0857
6		.3467	.6962	.0781
7			.6093	.2743
8		.1562	.2743	.2652
9		.2012	.1174	.2846
10				.3077
11			.112	.3201
12			.0857	.2787
13		.1543	.1509	.2949
14		.1307	.1417	.2429
15			.0857	.1966
16				.1254
17		.125	.0857	.1715
18				.1928
19		.1578		
20		.1829		
21	.0876	.208	.0857	
22	.0943	.125	.0876	
23	.0943	.1265	.0914	
24		.1075	.1475	.0914
Max	.0943	.3467	.6962	.3201
Min	.0876	.1075	.0857	.0781
Avg	.0921	.1925	.2159	.1877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 207 / 11 KV YELAVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1063	.1753	.1829
2		.1387	.1734	.2103
3		.1595	.1829	.1734
4		.2774	.1791	.2686
5		.2241	.1372	.1928
6		.1753	.2987	.2957
7		.1772	.2172	.2195
8		.1829	.2012	.3696
9		.1898	.2683	.1387
10		.218	.4475	.1372
11		.2932	.5312	.1387
12		.427	.6554	.1387
13		.6093	.9555	.1372
14		.9442	1.0288	.1402
15		.7748	.9709	.1214
16		.828	.8855	.1433
17		.125	.7716	.1578
18		.128	.8539	.1829
19		.1991		.2172
20		.2401		.1715
21	.1029	.1991	.1928	.2126
22	.1086	.1463	.1595	.1734
23	.0914	.1029	.1372	.0914
24		.1372	.1448	.1463
Max	.1086	.9442	1.0288	.3696
Min	.0914	.1029	.1372	.0914
Avg	.1010	.2918	.4349	.1817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.5801	.7373
2	.1905		.663	.8192
3	.2096		.7459	.9116
4	.1905		.7459	.9945
5	.2286			1.1603
6	.2858			1.2929
7	.3429			1.4586
8	.381		.1715	1.3927
9	.4954		.2858	.1334
10	.381		.0381	.1524
11	1.2431			.1524
12	1.2929			.1334
13	1.3426			.1143
14	1.3592			.1334
15	1.326		.1905	.1905
16	1.3757		.2667	.1905
17	.7459		.2477	.1905
18	.9448		.2667	.1509
19	.1905		.2858	.1886
20	.3048		.3048	.1886
21	.2858		.2667	.1886
22	.2667		.2477	.2077
23	.2477		.3201	.4715
24	.1905	.2286	.663	.6478
Max	1.3757	.2286	.7459	1.4586
Min	.1905	.2286	.0381	.1143
Avg	.5854	.2286	.37	.5084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1905		.663
2	.2286		.7459
3	.2858		.663
4	.3429		.7459
5	.381		.9116
6	.4954		.9116
7	.5144		.9831
8	.3429		1.0774
9	.4954		.1905
10	.381		.1905
11	1.757		.1905
12	1.8233		.1905
13	1.9559		.2096
14	1.989		.2286
15	1.9393		
16	1.989		.2286
17	2.1216		.2667
18	1.7072		.2858
19	.2858		.3429
20	.4191		.381
21	.4382		.381
22	.4191		.3429
23	.381		.4144
24	.2286	.3429	.663
Max	2.1216	.3429	1.0774
Min	.1905	.3429	.1905
Avg	.8797	.3429	.4873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.4144		.0762
2	.5304		.0572
3	.4973		.0762
4	.5801		.0762
5	.663		.0953
6	.5735		.0953
7	.7459		.1334
8	.7956		.1143
9	.8288		.0953
10	.7956		.2858
11	.0762		.2858
12	.0762		.2858
13	.0762		.2785
14	.0953		.2652
15	.0953		.2984
16	.0762		.3315
17	.0953		.0953
18	.1143		.1143
19	.1143		.1334
20	.1143		.1524
21	.1143		.1334
22	.0953		.1143
23	.0762		.0953
24	.0762	.0762	.0572
Max	.8288	.0762	.3315
Min	.0762	.0762	.0572
Avg	.3217	.0762	.1561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.9945		
2	1.0774		
3	1.1603		
4	1.326		
5	1.4586		
6	1.4752		
7	1.5415		
8	1.4918		
9	1.3757		
10	1.326		
11	.0762		.1658
12	.0953		
13	.1143		
14	.1334		.7293
15	.1334		.6796
16	.1334		.6962
17	.1524		.1143
18	.1715		.1334
19	.1715		.1524
20	.1715		.1905
21	.1905		.2286
22	.1715		.2096
23	.1334		.1905
24	.1143	.1334	
Max	1.5415	.1334	.7293
Min	.0762	.1334	.1143
Avg	.6329	.1334	.3173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 201 / 11 KV HALLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5261
Max	1.5261
Min	1.5261
Avg	1.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 202 / 11 KV LAMAN TANDA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5775
Max	1.5775
Min	1.5775
Avg	1.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0469	.0739	.0716	1.3279	1.5074	1.0883
2	.0537	.0625	.0739	.0716	1.3279	1.5074	1.0883
3	.0537	.0625	.0739	.0716	1.3279	1.5074	1.0883
4	.0537	.0625	.0739	.0716	1.3279	1.5424	1.0883
5	.0537	.0625	.0739	.0716	1.3279	1.5424	1.1043
6	.0716	.0625	.0739	.0895	1.3765	1.6126	1.2003
7	.0537	.0625	.052	.0895	1.2793	1.6301	1.2492
8	.0537	.0469	.0537	.0716	.0526	.0526	.0497
9	.0537	.0469	.0543		.0526	.0526	1.4232
10	.0537	.0469	.0526		.0526	.0492	1.5364
11	1.8244	1.781	2.0405	.0867	.0351	.0526	1.5684
12	1.8818	1.9997		.052	.0526	.0701	1.6712
13	1.7553	1.9528	2.1538	.052	.0526	.0701	1.4746
14	1.6446	1.906	2.1376	.0693	.0526	.0701	1.4723
15	1.692	1.8591	2.1376	.0724	.0701	.0526	1.4563
16	1.6446	1.8122	1.9433		.0701	.0526	1.4883
17	1.7078	1.8122	1.8461	.0701	.0701	.0526	.064
18	1.5779	1.7497	1.5546	.0701	.0701	.0526	.048
19	.0469	.0526	.0648	.0701	.0701	.0739	.0716
20	.0625	.0886	.0895	.0876	.0701	.0732	.0716
21	.0625	.0709	.0895	.0876	.0655	.0732	.0716
22	.0625	.0716	.0895	1.3441	1.4723	1.1363	.0537
23	.0625	.0716	.0716	1.3441	1.4723	1.1523	.0537
24	.0537	.0469	.0724	.0716	1.3603	1.5074	1.1043
Max	1.8818	1.9997	2.1538	1.3441	1.4723	1.6301	1.6712
Min	.0469	.0469	.052	.052	.0351	.0492	.048
Avg	.6097	.6599	.6499	.1946	.6015	.6456	.8994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.5658	.6602	.567	.5601	.6348	.5658
2	.5914	.5144	.6413	.5487	.5975	.5601	.5658
3	.5544	.5144	.6471	.5304	.5601	.5601	.5281
4	.5544	.5144	.6413	.5121	.5601	.5601	.5281
5	.5729	.5487	.6413	.5487	.5601	.5601	.5281
6	.6099	.5487	.5847	.5487	.5601	.5788	.547
7	.6099	.5144	.5729	.5487	.5975	.5975	.5601
8	.5359	.463	.5121	.5121	.5041	.5415	.5304
9	.499	.4801	.5249	.439	.5228	.5601	.4557
10	.4805	.4973	.5138	.5487	.5041	.5973	.3429
11	.4784	.5144	.5959	.5973	.5788	.7095	.583
12	.5784	.6516	.631	.591	.5975	.7282	.6516
13	.5784	.6344	.6836	.6447	.5788	.7282	.6878
14	.6154	.6516	.7186	.6268	.6161	.7095	.6344
15	.5973	.6516	.7011	.6767	.5975	.7095	.583
16	.5973	.6516	.631	.6984	.6348	.7095	.583
17	.567	.6859	.6219	.691	.5975	.5601	.6344
18	.5658	.6859	.6584	.7701	.6161	.5788	.6001
19	.6516	.7619	.7499	.7682	.7655	.7522	.7202
20	.7888	.9328	.8048	.8596	.8775	.8501	.7888
21	.7373	.9145	.7865	.7865	.7209	.8029	.7716
22	.6859	.8686	.7499	.7842	.7842	.7733	.7202
23	.6344	.7545	.6401	.6908	.6908	.6224	.6516
24	.6653	.5658	.6602	.5853	.6161	.6348	.5658
Max	.7888	.9328	.8048	.8596	.8775	.8501	.7888
Min	.4784	.463	.5121	.439	.5041	.5415	.3429
Avg	.5991	.6286	.6489	.6281	.6166	.6508	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4586	1.2616	1.4754	1.0227			
2	1.4586	1.278	1.4754	1.0227			
3	1.4586	1.3108	1.4754	1.0059			
4	1.4586	1.3108	1.4754	1.0059			
5	1.4586	1.3435	1.4754	1.0059			
6	1.4586	1.4582	1.4754	1.0059			
7	1.4754	1.491	1.3592	1.1065			
8	1.5089	1.5402	1.5592				
9	1.5257	1.6221	1.6095	1.1065	1.2929	1.3757	
10				1.291	1.5249	1.5257	
11				1.2717	1.5746	1.5746	
12				1.2597	1.6078	1.5581	
13				1.3923	1.6078	1.5912	
14				1.3426	1.5746	1.6244	
15				1.326	1.5083	1.5415	
16				1.3108	1.4752	1.4752	
22							1.0395
23							1.0562
24	1.4419	1.2616	1.4089	.9724			
Max	1.5257	1.6221	1.6095	1.3923	1.6078	1.6244	1.0562
Min	1.4419	1.2616	1.3592	.9724	1.2929	1.3757	1.0395
Avg	1.4704	1.3878	1.4789	1.1530	1.5208	1.5333	1.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0762	.0943	.0747	.5792	.7133	.442
2	.0747	.0762	.0943	.0747	.5792	.7133	.442
3	.0747	.0762	.0943	.0747	.5792	.7316	.442
4	.0747	.0762	.0943	.0747	.6097	.7316	.442
5	.0747	.0762	.0943	.0747	.6401	.823	.4572
6	.112	.1067	.1132	.0747	.7926	.9694	.5401
7	.0934	.1067	.0914	.0934	.7621	1.0242	.6944
8	.0934	.0914	.0914	.0747	.1097	.1097	.0886
9	.0934	.1067	.1294	.0747	.1097	.1097	.8078
10	.1307	.0914	.1063	.0934	.0914		.9722
11	1.1126	1.0212	1.1574	.112	.0914	.1097	.9877
12	1.1111	1.1126		.1097	.0914	.1097	1.2452
13	1.1111	1.0974	1.0185	.1097	.0914	.1097	.9831
14	.9297	1.0227	.9414	.1097	.0732	.0732	.9259
15	.8688	.8535	.9259	.1097	.0914	.0732	.9722
16	.9297	.9686	1.0031	.1063	.1097	.0914	.9722
17	.9783	1.0467	1.0494	.1063	.1097	.0732	.0772
18	.8253	.953	.9722	.128	.0914	.0732	.0772
19	.0914	.1063	.0772	.0914	.0914	.0924	.1174
20	.1067	.1307	.0747	.1097	.1463	.112	.1174
21	.061	.1494	.112	.1097	.1494	.1307	.1174
22	.0914	.1227	.0934	.6554	.7499	.5401	.1006
23	.0914	.112	.0747	.6097	.7316	.4784	.1006
24	.0747	.0762	.112	.0747	.6097	.7133	.442
Max	1.1126	1.1126	1.1574	.6554	.7926	1.0242	1.2452
Min	.061	.0762	.0747	.0747	.0732	.0732	.0772
Avg	.3867	.4024	.3746	.1386	.3367	.3785	.5235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8244	1.656	1.6324	1.4083	.0724	.0633	.0724
2	1.6804	1.6872	1.6324	1.3443	.0543	.0633	.0724
3	1.6964	1.6872	1.6324	1.3123	.0543	.0633	.0724
4	1.6964	1.7185	1.6324	1.2803	.0543	.0633	.0724
5	1.7284	1.7185	1.6324	1.2803	.0543	.0633	.0724
6	1.7444	1.7966	1.8564	1.3123	.0724	.0633	.0724
7	2.0965	2.1559	1.9608	1.4883	.0724	.0633	.0724
8	2.1445	2.1872	2.1925	.08	.0724	.0633	.0678
9	2.1125	2.1559	2.0805	1.4243	1.7553	1.9766	.0876
10	.064	.0625	.048	1.5364	2.0083	1.9989	.0648
11	.064	.0469	.048	1.7976	2.1348	2.0873	.0648
12	.0617	.0625	.08	1.8343	1.9292	2.0715	.0655
13	.0617	.0625	.064	1.7869	1.8818	2.0083	.0655
14	.0648	.0625	.08	1.7236	1.8185	2.0083	.081
15	.0648	.0625	.064	1.6446	1.8679	1.8185	.0648
16	.064	.0469	.08	1.5546	1.8185	1.7236	
17	.0469	.0625		.08	.0633	.0709	.0972
18	.0469	.0781		.0686	.0633	.0709	.0648
19	.0469	.0663		.0686	.0633	.0716	.0716
20	.0625	.0686	.0953	.0857	.0633	.0716	.0895
21	.0625	.0686		.0857	.0655	.0724	.0895
22	.0625	.0848	.08	.0724	.0633	.0724	1.4685
23	.0625	.0848	.064	.0724	.0633	.0724	1.5223
24	1.7444	1.656	1.5497	1.4403	.0724	.0633	.0724
Max	2.1445	2.1872	2.1925	1.8343	2.1348	2.0873	1.5223
Min	.0469	.0469	.048	.0686	.0543	.0633	.0648
Avg	.8043	.8058	.9253	1.0326	.6766	.6985	.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV MALIWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0181	.0362	.0343	.0181	.0351	.0362
2	.0362	.0181	.0362	.0343	.0362	.0351	.0362
3	.0362	.0181	.0362	.0343	.0362	.0351	.0362
4	.0362	.0181	.0362	.0343	.0362	.0351	.0362
5	.0362	.0181	.0362	.0343	.0362	.0351	.0362
6	.0362	.0362	.0362	.0857	.0362	.0351	.0362
7	.0362	.0181	.0362	.0343	.0362	.0351	.0362
8	.0362	.0362	.0362	.0171	.0362	.0175	.0362
9	.0362	.0362	.0362	.0343	.0181	.0175	.0362
10	.0362	.0181	.0343	.0343	.0362	.0362	.0362
11	.0181	.0362	.0343	.0189	.0351	.0351	.0362
12	.0181	.0362	.0343	.0189	.0351	.0351	.0347
13	.0362	.0362	.0343	.0189	.0351	.0351	.0347
14	.0362	.0362	.0343	.0377	.0351	.0351	.0362
15	.0362	.0543	.0171	.037	.0351	.7095	.0362
16	.0362	1.8122	.0171	.0181	.0351	.7095	.0181
17	.0362	.0362	.0343	.0362	.0351	.0351	.0181
18	.0362	.0362	.0171	.0181	.0351	.0351	.0362
19	.0362	.0362	.0343	.0362	.0175	.0362	.0362
20	.0362	.0362	.0343	.0362	.0351	.0362	.0362
21	.0362	.0362	.0343	.0362	.0362	.0362	.0362
22	.0362	.0362	.0343	.0362	.0351	.0362	.0362
23	.0362	.0362	.0343	.0362	.0351	.0362	.0362
24	.0362	.0362	.0362	.0343	.0362	.0351	.0362
Max	.0362	1.8122	.0362	.0857	.0362	.7095	.0362
Min	.0181	.0181	.0171	.0171	.0175	.0175	.0181
Avg	.0347	.1057	.0329	.0332	.0334	.0901	.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	.0514	.0526	.0175	.0532	.052	.0532
2	.052	.0514	.0526	.0175	.0532	.052	.0532
3	.052	.0514	.0526	.0175	.0532	.052	.0532
4	.052	.0514	.0526	.0175	.0532	.052	.0532
5	.052	.0514	.0526	.0175	.0532	.052	.0532
6	.052	.0514	.0532	.0175	.0532	.052	.0532
7	.052	.0514	.0693	.0175	.0532	.052	.0686
8	.052	.0514	.0693	.0175	.052	.052	.0686
9	.0693	.0857	.0701	.0175	.052	.052	.0686
10	.0693	.0514	.0693	.0701	.0693	.052	.0686
11	.0686	.0686	.0693	.0709	.0693	.0693	.0686
12	.0686	.0686	.0701	.0709	.0693	.0693	.052
13	.0686	.0686	.0701	.0514	.0693	.0693	.052
14	.0693	.0686	.1006	.0514	.0693	.0693	.052
15	.0686	.0686	.1006	.0497	.0693	.0693	.052
16	.0686	.0686	.1006	.048	.0693	.0693	.0693
17	.0693	.0686	.1006	.048	.0693	.0693	.052
18	.0686	.0686	.0526	.0492	.0693	.0693	.052
19	.0686	.052	.0526	.0328	.052	.0532	.0693
20	.0514	.0526	.0175	.0328	.052	.0532	.0693
21	.0514	.0526	.0175	.0164	.0492	.0532	.0693
22	.0686	.052	.0175	.0532	.052	.0532	.0693
23	.0514	.0526		.0532	.052	.0526	.0693
24	.052	.0686	.0526	.0175	.0532	.052	.0526
Max	.0693	.0857	.1006	.0709	.0693	.0693	.0693
Min	.0514	.0514	.0175	.0164	.0492	.052	.052
Avg	.0603	.0595	.0616	.0364	.0588	.0580	.0601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	1.2003	1.1869	.013
2	.0191	.0191	.0191	.0191	1.1145	1.1869	.0131
3	.0191	.0191	.0191	.0191	1.0288	1.1869	.0131
4	.0191	.0191	.0191	.0191	1.0288	1.1869	.0137
5	.0191	.0191	.0191	.0191	1.0174	1.1869	.0137
6	.0191	.0191	.0191	.0191	1.0343	1.1869	.0139
7	.0191	.0191	.0191	.0191	.9389	1.2887	.0141
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9		.0191	.0191	.0191	.0191	.0191	.0191
10		.0191	.0191	.0191	.0191	.0191	.0141
11		2.3579	2.774	.0191	.0191	.0191	.0141
12		2.3663		.0191	.0191	.0191	1.3226
13		1.7126	2.0748	.0191	.0191	.0191	1.6108
14		2.4348	2.4348	.0191	.0191	.0191	1.1869
15	2.4272	2.7161	2.452	.0191	.0191	.0191	1.2717
16	2.4272	2.2192	2.4006	.0191	.0191	.0191	1.3077
17	2.0805	2.0805	2.6406	.0191	.0191		1.3565
18	2.0458	2.1498	2.3663	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191		.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	1.0059	.8288		.0191
23	.0191	.0191	.0191	1.2689	1.1401	.013	.0191
24	.0191	.0191	.0191	.0191	1.286	1.1869	.013
Max	2.4272	2.7161	2.774	1.2689	1.286	1.2887	1.6108
Min	.0191	.0191	.0191	.0191	.0191	.013	.013
Avg	.5138	.7643	.7923	.1123	.4536	.4481	.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3226	1.3565	1.4746	1.0631	.0191	.0191	.0191
2	1.2717	1.3565	1.4746	1.0288	.0191	.0191	.0191
3	1.2548	1.3565	1.4746	.9945	.0191	.0191	.0191
4	1.2548	1.3565	1.4746	.9945	.0191	.0191	.0191
5	1.2548	1.3565	1.5432	.9724	.0191	.0191	.0191
6	1.2548	1.4582	1.6118	.9779	.0191	.0762	.0191
7	1.2407	1.4752	1.6461	1.0395	.0191	.0191	.0191
8		1.56	1.6289	.0191	.0191	.0191	.0191
9		1.56	1.5947	1.1065	1.2548	1.4243	.0191
10		.0191	.0191	1.2717	1.4243	1.56	.0191
11		.0191	.0191	1.4582	1.4243	1.56	.0191
12	.0191	.0191	.0191	1.4922	1.3735	1.5261	.0191
13		.0191	.0191	1.4922	1.4243	1.4752	.0191
14		.0191	.0191	1.2717	1.4243	1.5432	.0191
15	.0191	.0191	.0191	1.3226	1.4243	1.5089	.0191
16	.0191		.0191	1.3226	1.3904	1.4419	.0191
17	.0191	.0191	.0191	.0191	.0191		.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	1.0395
23	.0191	.0191	.0191	.0191	.0191	.0191	1.073
24	1.3375	1.2742	1.4746	1.4574	.0191	.0191	.0191
Max	1.3375	1.56	1.6461	1.4922	1.4243	1.56	1.073
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5768	.6243	.6527	.8091	.4769	.5384	.1055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3361	.3292	.2614	.2829	.2614	.2075
2	.2801	.3361	.3292	.2587	.2614	.2614	.2075
3	.2801	.3361	.3292	.2402	.2614	.2614	.2075
4	.2801	.3361	.3292	.2402	.2587	.2614	.2075
5	.2715	.362	.362	.2561	.2957	.2743	.2427
6	.3109	.443	.4075	.2743	.3439	.3224	.2926
7	.2743	.3582	.3366	.2957	.3045	.3189	.2772
8	.3403	.4557	.3944	.2865	.333	.3467	
9		.4748		.2835	.3086	.3294	.2804
10	.0191	.4862	.4191	.2126	.3121	.3429	.3086
11		.5144	.4755	.2835	.3121	.3601	.3429
12		.5144	.4973	.3086	.3641	.3429	.3561
13		.3467	.5144	.3189	.3506	.3467	.373
14		.5201	.5426	.3012	.3189	.3189	.3258
15	.4252	.5281	.5426	.3292	.3224	.3366	.333
16	.4508	.4557	.5365	.3361	.3403	.4031	.3366
17	.4508	.4908	.5144	.3292	.3121		.3155
18	.4115	.4508	.5144	.3292	.2481	.3294	.3467
19	.4334	.4801	.4409	.3292	.2686	.2865	.3506
20	.4161	.5083		.3109	.3109	.2401	.2561
21	.394	.5138		.3142	.2957	.2614	.2614
22	.3801	.4477	.3881	.2641	.2957	.2801	.2987
23	.3772		.2987	.2829	.2641	.2241	.2801
24	.2987	.3547	.3841	.2801	.2829	.2614	.2075
Max	.4508	.5281	.5426	.3361	.3641	.4031	.373
Min	.0191	.3361	.2987	.2126	.2481	.2241	.2075
Avg	.3355	.4370	.4231	.2886	.3020	.3031	.2876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1578	.1829	.1433	.7865	.8907	.6009
2	.1227	.1578	.1829	.1267	.8288	.8907	.6009
3	.1227	.1578	.1829	.1267	.8288	.8907	.6009
4	.1227	.1526	.1829	.1267	.8288	.8907	.6009
5	.1227	.1753	.2195	.1463	.8551	.8907	.6009
6	.1578	.1928	.1848	.2054	.9556	1.1336	.6154
7	.1629	.1848	.1848	.2075	1.0364	1.247	.7125
8	.181	.1612	.1829	.1886	.1494	.1509	.1494
9		.1417	.1829	.1509	.1509	.1494	.8421
10		.132	.1509	.1509	.1509	.1478	1.0722
11		1.9227	2.649	.0754	.1509	.1478	1.3927
12		2.3205		.0724	.1132	.1478	1.7166
13		2.3371	2.5873	.0724	.1132	.1494	1.8842
14		2.3868	2.5987	.1448	.1132	.1494	1.7976
15		2.4034	2.5987	.1448	.1132	.1494	1.5497
16	1.6385	2.4531	2.5526	.1433	.1132	.1494	1.2018
17	1.6575	2.5194	2.6825	.1433	.1132		.132
18	1.6194	2.079	2.42	.1433	.1132	.1509	.132
19	.1595	.1494	.1698	.1629	.1478	.1886	.1698
20	.1791	.1829	.1848	.1829	.1791	.2075	.1848
21	.181	.1829	.1829	.1848	.1772	.1509	.1829
22	.181	.1829	.1829	.7865	.8356	.7209	.1829
23	.1772		.1646	.7865	.8745	.6009	.1848
24	.1402	.1578	.1829	.2641	.7865	.9069	.7442
Max	1.6575	2.5194	2.6825	.7865	1.0364	1.247	1.8842
Min	.1227	.132	.1509	.0724	.1132	.1478	.132
Avg	.4157	.9083	.9128	.2034	.4381	.4827	.7438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.2263	.2452	.1886	.2829	.2263
2	.2829	.2641	.2263	.2263	.1886	.2829	.2263
3	.2829	.2641	.2263	.2263	.1886	.2829	.2263
4	.2829	.2641	.2263	.2263	.1886	.2829	.2263
5	.2829	.2641	.2641	.2641	.1886	.2829	.2641
6	.3018	.3018	.2641	.2641	.2263	.3018	.3018
7	.2829	.3018	.3018	.2263	.2452	.3395	.3018
8	.2641	.3395	.3018	.2263	.2263	.3018	.2829
9		.2829	.3018	.2641	.2075	.2641	.3018
10		.2641	.2641	.2263	.1698	.2641	.2829
11		.2641	.3018	.2263	.1509	.2452	.2641
12		.2829	.3018	.2263	.1509	.2452	.2641
13		.3018	.3206	.2263	.1509	.2641	.2829
14		.3018	.3206	.2263	.1886	.2641	.3018
15	.3018	.3018	.3018	.1886	.1886	.2641	.2641
16	.2263	.2641	.3018	.1698	.2263	.2452	.2452
17	.2641	.2829	.3206	.2075	.6602		.2263
18	.2641	.3018	.3018	.2075	.2829	.2452	.2829
19	.3018	.3018	.3018	.2075	.3772	.3395	.2641
20	.3772	.3395		.2263	.3395	.3018	.3395
21	.3395	.3395	.3018	.2641	.3206	.3018	.3018
22	.3018	.2641	.3018	.3206	.3018	.3018	.2829
23	.3018		.3018	.2263	.3018	.2641	.2829
24	.3018	.2641	.2263		.2075	.2829	.2263
Max	.3772	.3395	.3206	.3206	.6602	.3395	.3395
Min	.2263	.2641	.2263	.1698	.1509	.2452	.2263
Avg	.2924	.2879	.2829	.2312	.2444	.2805	.2696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2641	.2829	.2641	.2641	.2641	.2263
2	.2829	.2641	.2829	.2641	.2641	.2641	.2263
3	.2829	.2641	.2829	.2641	.2641	.2641	.2263
4	.2829	.2829	.2829	.2641	.2641	.2641	.2263
5	.3018	.3018	.3206	.2829	.2829	.2641	.2829
6	.3395	.3206	.3174	.2829	.3206	.3174	.2987
7	.2829	.3018	.2614	.2641		.2427	.2801
8	.2427	.2263	.2614	.2452		.2427	.2427
9	.1867	.2054	.2241	.2427	.2987	.2241	.2241
10		.2054	.2241	.1867	.2614	.2427	.2241
11		.2054	.2054	.1867	.2614	.2614	
12		.2241	.168	.2241	.2241	.2614	
13		.2241	.168	.2241	.2241	.2614	.2241
14		.2427	.1867	.2241	.2241	.2614	.2801
15		.2427	.168	.2241	.2614	.2427	.2801
16	.2987	.2427	.168	.2054	.2241	.2427	.2614
17	.2801	.2427	.168	.2054	.2427	.1867	.2801
18	.2801	.2801	.1867	.2054	.2801	.2241	.2427
19	.3772	.3734	.3584	.2987	.3547	.2987	.2987
20	.415	.4294	.3206		.4294	.3361	.415
21	.4338	.4108	.3584		.3734	.3174	.3961
22	.3772	.3961	.3395		.3547	.2801	.3395
23	.1132	.3206	.2829	.3206	.2987	.2614	.2829
24	.2829	.2829	.2829	.3403	.2829	.2829	.2263
Max	.4338	.4294	.3584	.3403	.4294	.3361	.415
Min	.1132	.2054	.168	.1867	.2241	.1867	.2241
Avg	.2969	.2814	.2543	.2486	.2844	.2629	.2720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2263	.2263	.3018	.3018	.2641	.1886
2	.3018	.2641	.2263	.3018	.3018	.2641	.1886
3	.3018	.2641	.2263	.2829	.3018	.2641	.1886
4	.3018	.2641	.2263	.2829	.2829	.2641	.1886
5	.3018	.3018	.2241	.3018	.2641	.2829	.2263
6	.3206	.3395	.2241	.3395	.2075	.3174	.2987
7	.3018	.2263	.2241	.1886		.2241	.2987
8	.3174	.2452	.2241	.2075		.2241	.168
9	.3361	.4108	.4108	.2054	.2427	.2614	.2427
10		.3734	.6722	.3547	.2427	.3361	.3174
11		.6584	.2427	.5304	.5228	.2801	.3361
12		.5304	.1867	.5121	.5041	.2987	.4108
13		.499	.3361	.6036		.2427	.6535
14		.2801	.3174	.2957		.4207	.3361
15		.2801	.4108	.4207	.2241	.2614	.5041
16	.4108	.3734	.5788	.4207	.7468	.3174	.4481
17	.3734	.3921	.4108	.3547	.5601	.3921	.6908
18	.4108	.3174	.4854	.2241	.4854	.3734	.4108
19	.2641	.2427		.2263	.2427	.2614	.2427
20	.2829	.2987	.2641		.2801	.2614	.2452
21	.2829	.2987	.2829		.2801	.2427	.2263
22	.3395	.2801	.3018		.2801		.3395
23	.3772	.2801	.3018	.2452	.2801	.2054	.3018
24	.3206	.3584	.2263	.3395	.3206	.2641	.2054
Max	.4108	.6584	.6722	.6036	.7468	.4207	.6908
Min	.2641	.2263	.1867	.1886	.2075	.2054	.168
Avg	.3248	.3336	.3144	.3305	.3436	.2836	.3191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV PATGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1509	.0943	.0754	.2105	.3887	.1619
2	.0754	.1132	.0943	.0754	.2105	.3887	.1619
3	.0754	.0943	.0943	.0754	.2105	.3887	.1619
4	.0754	.0943	.0943	.0943	.2105	.3887	.1619
5	.0943	.0943	.1307	.1132	.2915	.3887	.1943
6	.1132	.132	.1307	.1132	.5506	.6316	.2401
7		.1132	.112	.0943		.8421	.3239
8	.1494	.1132	.1307	.0754		.0747	.0934
9	.1307	.1132	.1494	.0934	.112	.0934	.4049
10		.1307	.168	.0934	.0934	.0934	.502
11		1.004	1.2308	.0934	.0934	.112	.6478
12		1.0526		.0747	.112	.0934	.6802
13		.9878		.0934	.0934	.0747	.6802
14		.9555	.8907	.0747	.0934	.0747	.6316
15		.9717	.8745	.0747	.0934	.0747	.6478
16	1.0159	1.166	1.085	.0934	.112	.0747	.6316
17	1.166	1.1498	1.2955	.112	.0747	.0747	.0747
18	1.0526	1.2308	1.2146	.0934	.0934	.0747	.0934
19	.1886	.1494	.1132	.1307	.112	.0934	.0934
20	.1886	.1307	.1132		.112	.0934	.0943
21	.1886	.1307	.1132		.0934	.0747	.0943
22	.1509	.112	.1132		.421	.1943	.0943
23	.132	.0943	.0943	.2591	.4049	.1781	.0943
24	.0754	.1509	.0943	.0943	.2267	.3887	.1619
Max	1.166	1.2308	1.2955	.2591	.5506	.8421	.6802
Min	.0754	.0943	.0943	.0747	.0747	.0747	.0747
Avg	.2910	.4348	.3832	.0999	.1830	.2231	.2969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.1132	.0943	.2915	.4534	
2	.0943	.132	.1132	.0943	.2753	.4372	
3	.0943	.132	.1132	.0943	.2753	.4372	
4	.1132	.132	.1132	.1132	.2915	.4372	
5	.132	.1509	.1307	.1132	.3239	.4372	
6	.1698	.1886	.168	.1132	.6154	.6802	
7	.1698	.1698	.1494	.132		.8907	
8	.2054	.2075	.2054	.1132		.168	
9	.1867	.1867	.2241	.132	.5506	.1867	
10		.1867	.3174		.2241	.1867	
11		1.004	1.1012		.168	.1494	
12		1.085			.2054	.1494	
13		.9717			.1867	.1307	.5344
14		.9393	.8583		.1494	.1494	.6478
15		.9878	.8583		.1307	.1307	.8097
16	.9831	1.1174	1.1174		.168	.1307	.8097
17	1.0688	1.166	1.2308		.168	.1867	.1307
18	1.1336	1.1336	1.1498		.168	.1494	.1307
19	.2452	.2054	.1132		.1867	.112	.1307
20	.2075	.1867	.1132		.168	.1307	.132
21	.1886	.168	.1132		.168		.132
22	.1509	.1494	.1132		.4858		.1132
23	.132	.132	.0943	.3563	.4696		.1132
24	.0943	.1132	.1132	.0943	.2753	.4534	
Max	1.1336	1.166	1.2308	.3563	.6154	.8907	.8097
Min	.0943	.1132	.0943	.0943	.1307	.112	.1132
Avg	.3035	.4574	.3920	.1318	.2702	.2946	.3349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.1886	.1886	.2915	.4858	.2429
2	.1886	.2263	.1886	.1886	.2915	.4696	.2429
3	.1886	.2263	.1886	.1886	.2915	.4696	.2429
4	.1886	.2452	.1886	.1886	.2915	.4696	.2401
5	.2263	.2641	.2801	.2263	.3239	.4696	.3201
6	.2829	.3206	.3361	.3018	.8097	.9717	.4001
7	.3018	.3395	.3174	.2829		1.1174	.4161
8	.2427	.3584	.2801	.2075		.2241	.1494
9	.2241	.2801	.2427	.168	.2987	.2054	.3563
10		.2614	.2614		.1307	.168	.4372
11		1.0526	1.0364		.2054	.2054	.4696
12		1.0688			.1867	.168	.5182
13		.9231			.2241	.1867	.4049
14		.8583	.8097		.2241	.168	.3239
15		.8583	.7611		.2241	.1867	.3401
16	1.0978	1.0202	1.0364		.2241	.1867	.421
17	1.166	1.1984	1.1822		.1867	.2241	.1494
18	.3725	1.1174	1.1336		.2614	.1867	.1307
19	.3961	.3174	.2263		.3174	.168	.1867
20	.3395	.3174	.1886		.3174	.1867	.1886
21	.3018	.3174	.2075		.2987	.2054	.1886
22	.2829	.2801	.2263		.5992	.2429	.1886
23	.2452	.2263	.1886	.3563	.5668	.2429	.1698
24	.1886	.2075	.2075	.2077	.2591	.5182	.2429
Max	1.166	1.1984	1.1822	.3563	.8097	1.1174	.5182
Min	.1886	.2075	.1886	.168	.1307	.168	.1307
Avg	.3568	.5213	.4398	.2277	.3102	.3386	.2905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0202	1.1336	1.2146	.2915	.0943	.0943	.0943
2	1.0202	1.1336	1.2146	.2915	.0943	.0943	.0943
3	1.0202	1.1336	1.2146	.2915	.0943	.0943	.0943
4	1.0526	1.1984	1.2955	.1296	.0943	.0943	.0943
5	1.1012	1.3927	1.5223	.2429	.132	.1132	.0943
6	1.5223	1.6356	1.6356	.2591	.1509	.112	.1307
7	2.3158	2.1538	2.2186	.2753		.112	.1494
8	2.4615	2.5425	2.3158	.0377		.1307	.1307
9	2.3805	2.4291	2.3158	.1781	1.085	1.3279	.112
10		.0747	.056	.6478	1.3117	1.7328	.1307
11		.0373	.0373	.7449	1.4563	1.8947	.168
12		.0373	.168	.8097	.0857	1.8947	.1494
13		.0373	.1494	1.0526	1.4575	1.6356	.112
14		.0373	.1307	1.0364	1.4575	1.7328	.0934
15		.0373	.112	1.166		1.9433	.0934
16	.2241	.0373	.1494	1.0364	.9922	2.0567	.112
17	.2427	.0373	.2427	.168	.1307	.0373	.1494
18	.2054	.0373	.2427	.112	.1307	.0747	.1307
19	.2452	.0373		.1494	.1494	.112	.1867
20	.2075	.2427			.1307	.1307	.1509
21	.2075	.2241	.0566		.1494	.112	.2641
22	.1886	.1867	.0566		.112	.112	.8745
23	.1509	.1867	.0566	.1132	.112	.0934	.8421
24	1.0202	1.085	1.2146	.2753	.0943	.0943	.0934
Max	2.4615	2.5425	2.3158	1.166	1.4575	2.0567	.8745
Min	.1509	.0373	.0373	.0377	.0857	.0373	.0934
Avg	.9215	.7120	.8009	.4433	.4531	.6596	.1894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5601	.5175	.1867		.2241	.1867
2	.5601	.5975	.5228	.168		.1867	.1886
3	.6036	.5975	.5487	.168		.1867	.1886
4	.6283	.6348	.5487	.168			.1867
5	.7095	.7095	.7095	.1867			.1867
6	.8316	.8589	.924	.2241			.2241
7	1.0974	1.2323	1.2437	.2241		.0187	.2241
8	1.2136	1.2696	1.3817	.1867		.112	.2241
9	1.2449	1.2696	1.3676	.168		.2218	.1715
10		.1829	.168	.2587		.5228	.168
11		.2241	.1867	.2987		.4904	.1494
12		.2218		.3361		.4854	.1494
13		.2195	.168	.7682		.5281	.168
14		.2241	.168	.8402		.4481	.1494
15	.2614	.2241	.1867	.7392	.2427	.6036	.168
16	.2614	.2402	.1867	.4572	.2614	.6722	.1867
17	.2614	.2378	.2241	.1867	.5228	.0373	.1867
18	.2241	.2402	.2241	.1848	.5601	.0377	.1886
19	.2427	.2241	.2614	.2378	.2614	.0373	.1509
20	.2614	.2772	.168		.2427	.2263	.2241
21	.2614	.2926	.168		.2427	.2241	.2263
22	.2241	.2987	.1867		.2427	.2263	.4481
23	.2241	.2402	.1867		.2241	.2241	.4527
24	.5601	.5228	.5228	.1867		.2241	.1867
Max	1.2449	1.2696	1.3817	.8402	.5601	.6722	.4527
Min	.2241	.1829	.168	.168	.2241	.0187	.1494
Avg	.5382	.4833	.4683	.3087	.3112	.2828	.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5228	.5228	.5788	.3658	.5601	.5281
2	.5281		.5121	.5601	.3734	.5601	.4854
3	.4854	.5041	.5228	.5601	.3696	.5788	.4904
4	.4435	.5041	.5175	.5788	.3658	.5601	.4481
5	.4108	.5228	.5601	.5788	.3734	.5788	.4904
6	.3772	.5041	.567	.5601	.3881	.6161	.5281
7	.3921	.4854	.5041	.4481		.5228	.4715
8	.3961	.4481	.5175	.4294		.5914	.4854
9	.4108	.5415	.6099	.4481	.3547	.5853	.5281
10		.8962	.7655	.8871		.8215	.7095
11		.8596	.8589	.9145		.8865	.8215
12		.8589	.9335	.9335		.9149	.8962
13		.8316	.7842	.9145		.8865	.9709
14		.9709	.7842	.9149	.5601	.8402	.9149
15	.4481	.9511	.8029	.9055	.7468	1.0185	.8962
16	.4294	1.0164	.8402	.9694	.9896	1.1016	.8962
17	.4481	1.0082	.8962	.8402	1.0269	1.0456	.8775
18	.4854	.9877	.8215	.6838	.9149	.7922	.7842
19	.4668	.8962	.7095	.6036	.8402	.7095	.7167
20	.4854	.6468	.5228		.7095	.5601	.6348
21	.4854	.4854	.5228		.6535	.5093	.5658
22	.4854	.4938	.5975		.5788	.4668	.7095
23	.5041	.5228	.6348	.3292	.5788	.4904	.679
24	.5853	.5041	.5175	.5788	.3696	.5415	.5228
Max	.5853	1.0164	.9335	.9694	1.0269	1.1016	.9709
Min	.3772	.4481	.5041	.3292	.3547	.4668	.4481
Avg	.4646	.6940	.6594	.6770	.5866	.6974	.6688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2427	.2561	.2241	.2427	.2241	.2241
2	.2241	.2427	.2614	.2241	.2378	.2241	.2263
3	.2218	.2241	.2587	.2241	.2402	.2241	.2241
4	.2241	.2241	.2614	.2054	.2427	.2241	.2241
5		.2241	.2561	.2054	.2561	.2241	.2241
6	.2402	.2427	.2218	.2054	.2614	.2241	.2263
7	.2241	.2801	.2614	.2427		.2241	.2241
8	.2452	.2614	.2378	.2054		.2378	.2075
9	.2054	.2241	.2614	.2054	.2801	.2402	.2427
10		.2987	.2801	.2587		.2801	.2427
11		.2957	.2801	.2614		.2641	.2427
12		.3109	.2987	.2378		.2427	.2241
13		.3174	.2987	.2801		.2452	.2241
14		.2957	.2987	.2743	.3921	.2427	.2241
15	.3174	.2987	.2987	.2772	.2614	.2452	.2241
16	.3174	.2743	.2987	.2614	.2614	.2614	.2427
17		.2801	.3174	.2987	.2427	.2641	.3174
18	.4108	.2957	.2801	.3326	.2987	.2614	.3206
19	.3921	.3109	.3547	.3292	.2987	.2829	.2987
20	.3361	.4075	.2614		.3921	.2829	.3018
21	.3174	.3921	.2614		.3361	.2614	.2987
22	.2987	.3696	.2614		.2801	.2402	.2829
23	.2801	.2926	.2614	.2614	.2614	.2241	.2427
24	.2241	.2614	.2614	.2614	.2378	.2241	.2263
Max	.4108	.4075	.3547	.3326	.3921	.2829	.3206
Min	.2054	.2241	.2218	.2054	.2378	.2241	.2075
Avg	.2768	.2861	.2745	.2512	.2791	.2446	.2474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.4108	.924	.5228	.1307	.8962	.5975
2	1.0082	.3734	.9145	.5228	.128	.8962	.6036
3	.9709	.3361	.8962	.4854	.1294	.9335	.5601
4	.9431	.2987	.8779	.4854	.1307	.9335	.5601
5	.8871	.2614	.8589	.4481	.128	.9335	.6036
6	.8589	.2054	.7762	.4481	.1294	.9522	.6348
7	.7095	.1867	.7095	.3361		.7468	.6413
8	.5658	.1494	.5544	.2987		.7316	.5601
9	.3326	.4294	.8413	.6722	.4481	.7468	.7468
10		.8048	.9335	1.1088	.8589	1.1694	.7842
11		.8029	1.0829	1.2136		1.1949	.8589
12		.7762	1.1949	1.2437		1.2449	.8029
13		.5853	.7842	1.2323		1.0829	.7468
14		.9145	.8775	1.1458	.8215	.9431	1.1389
15	.112	.9335	.9709	.9877	1.1949	.9335	.9335
16	.1307	.8871	.9522	.9896	1.1203	.9054	.8402
17	.2614	.7842	.9335	1.0082	.9522	.8589	.8215
18	.2614	.7316	.9335	.9979	.8589	.8299	.8299
19	.3921	.7023	.7095	.823	.6908	.7842	.8215
20	.3361	.8779	.2054		.6348	.7842	.8299
21	.2987	.7468	.2054		.7468	.7545	.8589
22	.3361	.8501	.3921		.8402	.7095	.7167
23	.3734	.9145	.5975	.1109	.9709	.7095	.9054
24	1.0456	.4108	.9335	.5415	.1307	.8962	.6413
Max	1.0456	.9335	1.1949	1.2437	1.1949	1.2449	1.1389
Min	.112	.1494	.2054	.1109	.128	.7095	.5601
Avg	.5716	.5989	.7941	.7439	.5813	.8988	.7516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	.8962	1.3169	1.1949	.7095	.8962	1.1203
2	1.1317	.8589	1.2803	1.1949	.695	.8775	1.0829
3	1.0456	.8589	1.307	1.2136	.7392	.8775	1.0829
4	.9709	.8215	1.307	1.2136	.7468	.9149	1.0562
5	.9054	.7842	1.2936	1.2136	.9877	.9709	1.0562
6	.8215	.7468	1.2936	1.2696	1.1088	.9896	1.1203
7	.8501	.8029	1.2803	1.1576		.9335	1.094
8	.9335	.6908	1.1949	1.1389		1.1458	1.2323
9	.4527	1.0269	1.2197	1.307	.2241	1.0974	1.1949
10		1.0349	1.3817	1.2936	.3174	.5415	1.1203
11		1.0242	1.307	1.307	.5415	1.1203	1.0456
12		1.0829	1.2323	1.1706	.7655	1.1694	1.0456
13		1.0974	1.1949	1.1949	.9522	1.1949	1.0456
14		1.1203	1.2323	1.1458	.1867	1.2826	1.2696
15	.1867	1.0974	.4108	1.0242	.6722	1.1576	1.2696
16	.1867	1.1203	1.2696	1.0719	.9149	1.094	1.2696
17	.1867	1.0974	1.3817	1.1827	1.1576	1.1203	1.2696
18	.2241	1.1576	1.3817	1.1706	1.0082	.4527	1.2826
19	.2987	1.1827	1.1949	1.2696	.8589	1.1203	1.2696
20	.3547	1.1576	.4481		.8589	1.1694	1.0185
21	.4854	1.3306	.4481		.8962	1.1576	.8215
22	.5601	1.3443	.6348		.9335	1.1317	.9808
23	.6908	1.3169	1.2323	.1848	.8215	1.0456	.9431
24	1.2449	.8962	1.3443	1.1576	.2012	.8402	1.1317
Max	1.2449	1.3443	1.3817	1.307	1.1576	1.2826	1.2826
Min	.1867	.6908	.4108	.1848	.1867	.4527	.8215
Avg	.6678	1.0228	1.1495	1.1465	.7408	1.0126	1.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1307	.1867	.1494	.168	.168	.168
2	.2075	.1307	.1463	.1494	.1494	.168	.1509
3	.1867	.112	.1463	.1494	.1478	.1494	.1494
4	.1698	.112	.1494	.1494	.128	.1494	.132
5	.1294	.0934	.1494	.1494	.1307	.1494	.1307
6	.112	.0934	.1478	.1867	.1294	.112	.1307
7	.1109	.112	.2743	.112		.112	.132
8	.0943	.0747	.1294	.112		.1478	.1307
9	.0924	.1307	.2614	.168	.1307	.1494	.1307
10		.1478	.2241	.1478	.168	.1509	.1494
11		.1494	.2241	.1829	.1867	.1494	.168
12		.1463	.2054	.1867		.1509	.168
13		.1109	.1307	.1848	.1494	.1494	.168
14		.1494	.1494	.1829	.168	.1509	.168
15	.112	.1478	.2054	.1867	.2054	.1494	.168
16	.1307	.128	.2054	.1478	.1494	.1698	.168
17	.112	.1307	.1867	.1494	.168		.1494
18	.0934	.1848	.2054	.1463	.1307		.1509
19	.1307	.1829	.1494	.1848	.1494	.1307	.1494
20	.1307	.1646	.168		.168	.2452	.132
21	.1867	.2241	.2054		.1867	.2427	.112
22	.1867	.2033	.2054		.2241	.2075	.2075
23	.168	.1829	.2054	.1494	.168	.168	.2263
24	.1886	.1307	.1867	.1494	.1646	.168	.1698
Max	.2075	.2241	.2743	.1867	.2241	.2452	.2263
Min	.0924	.0747	.1294	.112	.128	.112	.112
Avg	.1445	.1406	.1853	.1583	.1605	.1608	.1546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 201 / 11 KV malgaon Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.567	.5975	.4251	.462	.5175	.4805
2	.5359	.5544	.5788	.4066	.462	.5175	.4668
3	.5175	.5415	.5601	.3921	.462	.5175	.4481
4	.5228	.5359	.5359	.3734	.462	.5544	.4481
5	.5658	.5601	.5729	.3734	.462	.5544	.5041
6	.6287	.6348	.6099	.3734	1.1088	.5914	.6099
7	.5975	.6348	.5729	.4108	.5544	.5544	.5304
8	.5788	.6161	.5544	.462	.5544	.5914	.4938
9	.5601	.5415	.5121	.462	.439	.5487	.6401
10	.6099	.4435	.4755	.5544	.4755	.5359	.5304
11	.5853	.5729	.5304	.5914	.6219	.5175	.5544
12		.6653	.5487	.5914	.5853	.5121	.5175
13	.439	.6283	.6099	.6468	.567	.4755	.499
14	.462	.6283	.6653	.6468	.4938	.4706	.5175
15	.4572	.6036	.7392	.6468	.7316	.5121	.5359
16	.4755	.6584	.7865	.7023	.567	.5487	.5788
17	.5304	.7865	.7682	.7392	.6036	.5853	.7655
18		.6767	.8131	.7762	.6219	.6653	.6908
19	.7023	.7865	.7207	.7947	.7023	.823	.6838
20	.7762	.9511		.8316	.8131	.7865	.8131
21	.7316	.8316		.8316	.7207	.6219	.7316
22	.695	.7392	.5359	.6468	.6653	.567	.6401
23	.6584	.6468	.4755	.5914	.6099	.5544	.5853
24	.6036	.5914	.5975	.439	.5544	.5359	.5175
Max	.7762	.9511	.8131	.8316	1.1088	.823	.8131
Min	.439	.4435	.4755	.3734	.439	.4706	.4481
Avg	.5818	.6415	.6073	.5712	.5958	.5691	.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 202 / 11 KV Cannal AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191		.2667	.1905	.4858	.4744	.4858
2	.381	.2858	.2667	.1905	.4858	.4801	.4694
3	.3429	.2667	.2858	.1715	.4858	.4801	.4694
4	.3429	.2667	.3048	.1715	.4687	.5668	.4475
5	.3429	.3048	.3048	.1715	.5668		.4843
6	.362	.362	.381	.1905	.7287	.9393	.5761
7	.381	.362	.3048	.2286	.8907	1.0082	.7499
8	.381	.3239	.3239	.1905	.1905	.2667	.2096
9	.3429	.381	.3239	.1905	.2858		.6483
10	.3239	.381	.3048	.1524	.2858		.8124
11	1.3916	1.5497	1.6404	.1524	.2858		.9555
12		1.7652		.1905	.2858		.9555
13	.6405	1.5935	1.4998	.1905	.2477		.759
14	.9282	1.5684	1.6975	.1905	.2286		.8162
15	1.3592	1.5699	1.7654	.1905	.2477		.9061
16	1.5623	1.7078	1.7833	.2477	.2667	.2096	.9442
17	1.6484	1.6404	1.5935	.2477	.2477	.2477	.2667
18	1.5023	1.6356	1.5813	.2667	.3048	.2858	.2858
19	.3048	.381	.3048	.2858	.2858	.3239	.2858
20	.381	.4191		.2858	.3429	.3048	.3048
21	.3429	.362	.2477	.2667	.3239	.2858	.2477
22	.3429	.3429	.2477	.4372	.6562	.4915	.2477
23	.3048	.2858	.2096	.5668	.6167	.5182	.2096
24	.4763	.3048	.2667	.2096	.5668	.5218	.5601
Max	1.6484	1.7652	1.7833	.5668	.8907	1.0082	.9555
Min	.3048	.2667	.2096	.1524	.1905	.2096	.2096
Avg	.6437	.7852	.7230	.2324	.4076	.4628	.5457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 203 / 11KV RAMNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.4807	.4096	.3688	.0953	.1334	.1143
2	.6613	.5365	.4641	.39	.0953	.1334	.0953
3	.6539	.5487	.4534	.39	.0953	.1334	.0953
4	.6718	.5658	.4858	.463	.0953	.1334	.0953
5	.7865	.7701	.8619	.4641	.0953	.1715	.1334
6	1.1843	.8421	.9922	.5571	.1143	.2096	.1715
7		1.2793	.4641	.6226	.1334	.1905	.1524
8	1.2967	1.3279	1.2176		.1524	.1715	.1524
9	1.2967	1.3599	1.2498	.7287		.8642	
10	.1524	.1334	.1524	.7287	.6481	.9172	
11	.1524	.1715	.1715	.7773	.7968	.9374	
12		.1905		.7773	.7655	.9217	
13	.1334	.1715	.1715	.7773	.7343	.8951	
14	.1524	.1715	.3429	.8097	.6481	.8749	
15	.1524	.1715	.1905	.7773	.6944	.8383	.1715
16	.1524	.1905	.2096	.7773	.7407	.8796	.2286
17	.1715	.1905	.2286	.1334	.1524	.1334	.1143
18	.1905	.2286	.2477	.1143	.1524	.1524	.1524
19	.2286	.2286	.2667	.1524	.2096	.1715	.1905
20	.2096	.2477	.2667	.1524	.1905	.1524	.1905
21	.2096	.2477	.1715	.1524	.1905	.1524	
22	.1905	.2477	.1334	.1334	.1715	.1334	.5182
23	.1715	.2096	.1334	.1143	.1524	.1143	.4428
24	.3086	.3353	.4096	.285	.0953	.1334	.1143
Max	1.2967	1.3599	1.2498	.8097	.7968	.9374	.5182
Min	.1334	.1334	.1334	.1143	.0953	.1143	.0953
Avg	.4445	.4520	.4215	.4629	.3139	.3978	.1843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1307	.1132	.2743	.3163	.0754
2		.1132	.132	.1097	.2743	.3201	.0732
3		.1132	.1494	.1109	.3201	.3479	.1109
4		.1132	.1698	.132	.3795	.3521	.1132
5		.132	.1886	.1307	.3963	.4111	.112
6		.1886	.2075	.132	.4458	.6882	.132
7		.2263	.2263	.1509		.68	.132
8	.056	.2075	.2263	.112		.1494	.1109
9		.2075	.2075	.0934		.0924	.2006
10		.1867	.2241	.0943	.4458	.0924	.25
11		1.085	.8097	.0934	.1097	.1097	.2812
12		1.085		.0747	.0934	.1109	.253
13		1.0202	.5624	.0934	.1097	.0914	.253
14		.7907	.7522	.0747	.112	.0739	.2881
15		.8642	.7522	.0924	.112	.1109	.3277
16		1.1174	1.1012	.1097	.0934	.1109	.3239
17		.9282	1.2163	.112	.112	.1109	.0895
18		.8381	1.1336	.132	.0934	.0747	.1132
19		.1494		.1478	.112	.1109	.1307
20	.0943	.2263			.1494	.1132	.132
21		.1886	.1509		.1307	.1698	.1509
22	.1698	.1698	.132		.3077		.1494
23	.1132	.1509	.1132		.2372	.0754	.1294
24		.1132	.1509	.1132	.1509	.3005	.0754
Max	.1698	1.1174	1.2163	.1509	.4458	.6882	.3277
Min	.056	.1132	.1132	.0747	.0934	.0739	.0732
Avg	.1083	.4304	.4160	.1111	.2124	.2180	.1670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.168	.1509	.1463	.1698	.1132
2	.132	.1509	.168	.1494	.1494	.1509	.1463
3		.1509	.1494	.128	.132	.1698	.1478
4	.1463	.1509	.1886	.1294	.1307	.1886	.1886
5	.1478	.1509		.132	.132	.1867	.1867
6	.168	.1698	.2427	.132	.132	.1509	.2075
7	.1698	.2561	.2614	.1509		.132	.2054
8	.2149	.1646	.1448	.1132		.2622	.1132
9		.407	.1698	.104		.2915	.2427
10		.4748	.2126	.1734	.132	.431	.3547
11		.2303	.3222	.3155	.4801	.2883	.415
12		.3772	.431	.2987	.2279	.3149	.3467
13		.2629	.39	.3206	.3294	.3391	.2804
14		.2454	.2743	.2801	.3521	.2835	.3361
15		.3506	.3601	.2801	.3856	.2241	.3696
16		.4161	.3353	.3292	.3641	.4144	.4294
17		.3772	.3506	.2987	.2652	.2947	.2896
18		.4024	.2743	.2452	.2126	.112	.2378
19	.3109	.2012	.2012	.2054	.1991	.1463	.1848
20	.2801	.2263	.132		.2218	.1698	.1867
21	.2641	.2263	.1698		.1886	.1698	.1663
22	.2075	.1886	.1509		.1509	.1509	.1494
23	.1698	.1698	.1509		.1509	.132	.1294
24	.1509	.1509	.132	.1494	.1543	.1698	.1132
Max	.3109	.4748	.431	.3292	.4801	.431	.4294
Min	.132	.1509	.132	.104	.1307	.112	.1132
Avg	.1919	.2522	.2339	.2043	.2208	.2226	.2309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2201	.2462	.2743	.1829	.1254	.1448	.0924
2	.2934	.2462		.1852	.1097	.1463	.0914
3	.3715	.2462	.2408	.1829	.112	.1267	.0739
4	.4512	.2462	.301	.208	.132	.1267	.0716
5	.4868	.2934	.442	.1957	.1494	.1478	.0732
6	.543	.4816	.4161	.1932	.1509	.1109	.0701
7	.5502	.7011	.535	.2317	.1509	.128	.0709
8	.6015	.6748	.7282	.0886	.1509	.124	.0709
9		.6171	.6622	.1947	.1509	.2743	.0701
10		.1063	.124	.2572	.1509	.3715	.0876
11		.1417	.1829	.3102	.2751	.5498	.1052
12		.1448	.1629	.3144	.2317	.4923	.1029
13		.1433	.1448	.282	.2435	.4451	.0876
14		.124	.0876	.2782	.3155	.3755	.0924
15		.1448	.1227	.3243	.3155	.443	.1029
16		.1267	.1387	.3477	.2364	.4729	.1006
17		.181	.1734	.1463	.0886	.1075	.132
18		.2353	.2149	.1463	.1063	.0857	.1063
19	.2402	.1949	.1402	.1478	.124	.0914	.104
20	.1829	.2195	.0732		.128	.1132	.128
21	.1646	.1829	.1132		.128	.1109	.1294
22	.1448	.128	.112		.1294	.1097	.2469
23	.1254	.1097	.0943		.1134	.0914	.2439
24	.2469	.2641	.2591	.1829		.1267	.0924
Max	.6015	.7011	.7282	.3477	.3155	.5498	.2469
Min	.1254	.1063	.0732	.0886	.0886	.0857	.0701
Avg	.3302	.2583	.2497	.2200	.1660	.2215	.1061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.1132	.0943	.0373	.0934	.0739	.0943
2	.0924	.0934	.0934	.0366	.0943	.0747	.0943
3	.0905	.0943	.0943	.0366	.0934	.0732	.0905
4	.1086	.0943	.0934	.0373	.1132	.0732	.0914
5	.1097	.0934	.0943	.0373	.1132	.0924	.0924
6	.0914	.0943	.112	.0373	.1509	.1109	.112
7	.0914	.1132	.1132	.0373	.1509	.0934	.112
8	.0924	.112	.1307	.0187	.1307	.0754	.112
9	.1294	.0754	.132	.0187	.1132	.0543	.0934
10	.112	.0934	.1132	.0187	.112	.0543	.0934
11	.0924	.0934	.1132	.0189	.1132	.0549	.0924
12	.0924		.132	.0377	.1132	.0543	.1097
13	.1307		.132	.0373	.112	.0554	.1109
14	.1307	.1132	.1307	.0187	.1132	.0554	.128
15	.1307	.112	.112	.0377	.1109	.1109	.1494
16	.1294		.132	.0377	.1109	.1307	.1509
17	.1294	.1509	.132	.0377	.1307		
18	.1478	.1494	.1307		.168	.1494	.1494
19	.1494		.1494		.2033	.1494	.1663
20	.168				.1848	.168	.1663
21	.1698				.1646	.1494	.128
22	.1494		.056	.0934	.0924	.1307	.1097
23	.132			.1132	.0924	.0934	.1109
24	.0934	.112	.1132	.0373	.112	.0924	.0934
Max	.1698	.1509	.1494	.1132	.2033	.168	.1663
Min	.0905	.0754	.056	.0187	.0924	.0543	.0905
Avg	.1190	.1067	.1145	.0393	.1245	.0943	.1153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.132	.1307	.0747	.6722	.8745	.7682
2	.0934	.112		.0747	.7362	.8642	.7682
3	.0934	.1132	.132	.0739	.7682	.8583	.8421
4	.0934	.112	.112	.0739	.8223	.8482	.8421
5	.112	.1132	.1132	.0924	.8539	.8749	.8421
6	.1109	.132	.112	.0934	.9602	1.2163	.8802
7	.1109	.1307	.1307	.1132	1.2483	1.2483	1.0722
8	.132	.132	.132	.1132	.112	.1086	.1307
9	.1509	.112	.1494	.0943	.1132	.132	1.1043
10	.1509	.1132	.1698	.1132	.1132	.1132	1.4723
11	1.3123	1.3927	1.7764	.112	.1132	.132	1.5181
12	1.3443	1.5684		.168	.1132	.132	1.5524
13	1.4251	1.2803	1.5844	.1509	.1132	.112	1.6194
14	1.3603	1.4089	1.8461	.1307	.1097	.112	1.6549
15	1.4403	1.5384	1.7976	.1307	.0924	.0934	1.6032
16	1.4899	1.4723	1.7284	.112	.0934	.1132	1.4737
17	1.3923	1.4723	.8002	.1132	.0934	.1132	.1307
18	1.3763	1.5223	1.2955	.112	.112	.1132	.1307
19	.132		.0934		.128	.132	.1509
20	.1307				.1109	.1509	.132
21	.132			.1132	.0895	.132	.1307
22	.1307			.5441	.7907	.7522	.1334
23	.132		.0934	.6081	.8421	.7522	.1132
24	.0934	.1307	.132	.0747	.6167	.8802	.7682
Max	1.4899	1.5684	1.8461	.6081	1.2483	1.2483	1.6549
Min	.0934	.112	.0934	.0739	.0895	.0934	.1132
Avg	.5430	.6836	.6489	.1494	.4091	.4525	.8264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1307	.132	.0934	.9172	1.0402	.933
2	.1132	.132	.112	.0934	.9602	1.0279	.933
3	.1132	.112	.1132	.0934	.9804	1.0242	.9762
4	.0943	.1132	.112	.0943	1.0402	1.0437	.9762
5	.0943	.132	.112	.1132	1.1069	1.1523	.9762
6	.1132	.1494	.132	.1132	1.2018	1.4243	1.0242
7	.1132	.1509	.1509	.1132	1.4232	1.5893	1.1843
8	.132	.168	.1509	.1132	.1494	.1132	.0934
9	.132	.168	.1494	.1132	.1509	.1267	1.1363
10	.1307	.132	.168	.132	.1509	.132	1.3923
11	1.6248	1.5684	1.8244	.1307	.1509	.1132	1.4251
12	1.531	1.7078		.132	.168	.1086	1.4575
13	1.6288	1.7711	1.7764	.132	.168	.1109	1.5238
14	1.5935	1.7604	1.8623	.112	.1698	.0943	1.5074
15	1.6762	1.8027	1.8299	.1132	.1307	.112	1.0322
16	1.8027	1.7394	1.8404	.132	.1294	.132	1.1043
17	1.8278	1.8884	2.0348	.1307	.1294		
18	1.7553		1.6194	.132	.1886	.1494	.1494
19	.168		.1494		.1886	.1494	.1478
20	.1886				.1663	.1494	.1509
21	.1867		.1494	.112	.168	.1494	.1509
22	.1509			.8065	1.1523	1.1203	.1307
23	.1494		.0934	.8642	1.1683	.9602	.1109
24	.0934	.132	.1307	.0934	.8855	1.1702	.9488
Max	1.8278	1.8884	2.0348	.8642	1.4232	1.5893	1.5238
Min	.0934	.112	.0934	.0934	.1294	.0943	.0934
Avg	.6461	.7644	.6973	.1801	.5435	.5736	.8463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 248019 / 220KV Narwad Substation

Feeder No / Name : 804 / 220KV Mhaishal

Feeder KV- 220 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.064	.08	.3086	.3121	.427	
2		.064	.064	.3048	.3041	.4218	
3	.0625	.0819	.0648	.301	.3807		
4	.0791	.1134	.0819	.3121	.4694		
5	.096	.1147	.112	.3041	.5944	.5864	
6	.1526	.128	.1475	.3963	.7225	.6401	
7	.176	.1457	.176	.5624	.5556	.8128	
8	.1389	.1265	.144		.125	.1372	
9	.1406	.1054	.128		.0937	.144	
10	.104	.0974	.1174			.1581	
11	.953	1.0031	1.0311		.0949	.0324	.1265
12	.9414	.884	.9488		.0772	.0229	.1806
13	.7225	.7775	.7282		.0753	.0038	.1467
14	.6015	.6836	.6203		.0926	.0038	.5053
15	.5213	.5937	.6287		.2772	.0038	.5647
16	.6539	.6895	.8802			1.5432	.5792
17	.7335	.9031	.9145			.125	.0714
18	.8069	.8688	.8025		.5041	.0191	.0926
19	.1265	.1423			.1054	.0152	.1107
20	.1457	.128			.1219	.0019	.128
21	.128	.1107	.0753		.108	.0019	.0937
22	.0949	.0949	.0762		.4115	.0019	.0791
23	.0781	.096	.3241			.0019	.08
24	.0617	.0791	.0972	.3241	.3144	.4321	
Max	.953	1.0031	1.0311	.5624	.7225	1.5432	.5792
Min	.061	.064	.064	.301	.0753	.0019	.0714
Avg	.3295	.3373	.3747	.3517	.287	.2517	.2122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.4268	.4607	.1867	.1886	.1698	.132
2	.3239	.4268	.4572	.1886	.1886	.1509	.132
3	.3201	.3864	.4687	.1848	.1886	.1509	.1886
4	.426	.4344	.5487	.1848	.2263	.1698	.2075
5	.5182	.5944	.6405	.1829	.2641	.1783	.2263
6	.7773	.7529	.7811	.2534	.3018	.2614	.2427
7	.8322	.9957	1.0494	.2561	.3174	.2587	.2054
8	.8097	1.1138	1.0536		.2218	.2218	.2054
9	1.0883	1.1004	1.2037		.4254	.7682	.1494
10	.1227	.1753	.1829			.8322	.2012
11	.1494	.1848	.2587		.6173	.8962	.2103
12	.1294	.1294	.2195		.6401	.8223	.2149
13	.1448	.1663	.2172		.7125		.1097
14	.1478		.1829		.6882	.7116	.1448
15	.1494	.1848	.2218		.5281		.1463
16	.1867	.2033	.2195				.1463
17	.1848	.181	.2172			.168	.1448
18	.2033	.2772	.2896		.168		.1829
19	.3547	.3361			.2054	.1494	
20	.3361	.2987			.2263		.2195
21	.2801	.2829	.1867		.2263		.2172
22	.2614	.2641	.1886		.1886	.1494	.5121
23	.2263	.2263	.1886			.1506	.5068
24	.3315	.4641	.4915	.1867	.1886	.1886	.1316
Max	1.0883	1.1138	1.2037	.2561	.7125	.8962	.5121
Min	.1227	.1294	.1829	.1829	.168	.1494	.1097
Avg	.3597	.4176	.4422	.203	.3356	.3555	.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	1.186	1.0648	.2622	.2402	.3018	.4801
2	.7459	1.2003	1.078	.2591	.2402	.2829	.5601
3	.7287	1.2125	1.1043	.2652	.3326	.2829	.7202
4	.4641	1.2809	1.4251	.3315	.4854	.3772	.8002
5	.4694	1.8884	1.6324	.4024	.5601	.4668	.8642
6	1.2548	2.1376	1.8515	.4696	.6908	.7842	.9614
7	1.5581	2.4453	2.0645	.4096	.4481	.5914	1.2125
8	1.491	2.3922	2.3594		.3801	.4066	.3734
9		1.7553	1.9757		.8179	1.6324	.2614
10	.1677	.1966	.1823			1.6644	.2218
11	.2012	.2743	.285		1.085	1.7553	.1677
12	.1829	.2865	.0663		1.1142	1.3757	.1802
13	.197	.2103	.1966		1.3279		.1781
14		.2303	.2105		1.4089	1.4089	.0486
15		.2328	.1966		1.2631		.048
16		.3045	.2458				
17		.4024	.4534			.4024	.3315
18	.2507	.5359	.4588		.4481		.3353
19	.695	.462			.4854	.4108	.4096
20	.6908	.5228			.4904	.3929	.3978
21	.5601	.5788	.3439		.415	.3929	.3688
22	.4294	.4294	.3292		.3961	.0329	.8907
23	.3547	.3174	.2652			.4191	.8097
24	.7287	1.2955	1.2125	.2652	.2402	.3206	.4527
Max	1.5581	2.4453	2.3594	.4696	1.4089	1.7553	1.2125
Min	.1677	.1966	.0663	.2591	.2402	.0329	.048
Avg	.6267	.9074	.8637	.3331	.6435	.6851	.4815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.4161	.3814	.0648	.081	.16
2	.3401	.3765	.3864	.064	.0819	.1677
3	.3361	.3765	.4268	.081	.0819	.176
4	.4161	.4755	.5601	.0983	.1147	.1781
5	.5376	.695	.5937	.1296	.1638	.176
6	.8745	.823	.7842	.1802	.2267	.1802
7	1.1227	1.0059	1.2323		.2105	.1698
8	1.0623	1.0936	1.2163		.1423	.0469
9	.8905	1.0494	.8482	.253	.5937	.0469
10	.0772	.1457	.1265		.6249	.048
11	.0983	.2105	.1457	.4012	.6562	.0762
12	.1311	.1781	.1457	.6009	.5182	.0463
13	.0474	.16	.128			.0457
14		.1457	.1107	.4999	.5468	.0594
15			.16	.463		.0926
16		.144				.1094
17		.2429			.1423	.125
18		.2241	.2267	.1235		.1423
19	.2915	.2429		.1718	.1296	.192
20	.3077	.208		.2241	.1265	.1781
21	.2429	.1943		.16		.1619
22	.1781	.1781		.144	.2267	.3521
23	.1619	.1457			.2103	.3239
24	.3361	.3953	.3521	.08	.0972	.1638
Max	1.1227	1.0936	1.2323	.6009	.6562	.3521
Min	.0474	.144	.1107	.064	.081	.0457
Avg	.4101	.3968	.4603	.2200	.2619	.1424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4108	.3772	.3696	.3772	.3584	.3395
2	.3734	.415	.3772	.3734	.3772	.3395	.3398
3	.3734	.3961	.415	.3696	.3772	.3395	.3772
4	.4066	.3961	.4527	.3841	.4338	.3772	.5281
5	.4572	.4294	.4904	.4024	.4904	.415	.5093
6	.5611	.4668	.5658	.4344	.547	.5228	.547
7	.567	.5228	.5175	.4938	.5658	.5415	.5014
8	.4525	.4251	.4251		.439	.462	.4163
9	.4024	.3982	.4024		.3841	.3881	.3582
10	.3582	.4031	.3801			.3948	.3544
11	.3292	.394			.4024	.394	.3224
12	.4066	.4163	.3982		.3841	.3982	.3292
13		.4207	.4477		.3841	.3982	.362
14		.4572	.4525		.3841	.3684	.3982
15		.439	.4572		.3841		.3801
16		.4207	.4207				.4024
17		.4344	.4163			.4251	.4066
18		.4784	.4525		.5041		.4854
19	.724	.5853			.6036	.5281	.567
20	.7865	.6468			.6979	.5068	.5611
21	.6838	.6099	.6401		.5847	.5228	.5121
22	.5788	.5415	.5068		.5093	.4677	.4344
23	.4854	.4527	.3658			.4116	.3658
24	.4207	.4481	.3961	.3658	.3961	.3772	.3772
Max	.7865	.6468	.6401	.4938	.6979	.5415	.567
Min	.3292	.394	.3658	.3658	.3772	.3395	.3224
Avg	.4854	.4587	.4456	.3991	.4613	.4256	.4240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0114	.0152	.0297	.0633	.0149	.0152
2	.0286	.0122	.0663	.0286		.0149	.0152
3	.0293	.0149	.064	.0293	.08	.0156	.0152
4	.0293	.0152	.081	.0602	.0781	.0156	.0152
5	.0305	.0149	.08	.0594	.0791	.064	.0152
6	.0301	.0145		.0602	.0648	.064	.0152
7	.0297	.0137	.0983	.0594	.0328	.064	.0015
8	.0301	.0156	.0671		.0625	.064	.064
9	.0301	.0158	.064		.0972	.032	.0328
10	.029	.0149	.0617			.032	.0309
11	.0158	.0324	.0602		.0937	.0316	.0312
12	.0158	.0305	.0594		.0625	.0633	.0301
13	.0105	.0141	.0602		.064		.0297
14		.0139	.0594		.064	.0305	.0301
15		.0141	.0602		.064		.0301
16		.0152	.0602				.0301
17		.0151	.0594				.0594
18	.0158	.0154	.0602		.064		.0602
19	.0088	.0149			.048	.0152	
20	.0128	.0145			.0158	.0152	.0301
21	.012	.0145	.0617		.0312	.0152	.0305
22	.0111	.0145	.0602		.0297	.0152	.0309
23	.0109	.0156	.0594			.0152	.0152
24	.0301	.0124	.0164	.0602	.064	.0297	.0152
Max	.0305	.0324	.0983	.0602	.0972	.064	.064
Min	.0088	.0114	.0152	.0286	.0158	.0149	.0015
Avg	.022	.0158	.0607	.0484	.0610	.0322	.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3174	.3174	.426	.7842	.9122	.2452
2	.2957	.2801	.3174	.421	.7773	.9231	.2452
3	.2896	.2801	.3361	.4161	.8855	.9231	.2829
4	.3582	.3361	.3772	.5506	1.406	1.004	.3206
5	.4024	.3734	.4527	.7209	1.6004	1.3123	.3772
6	.5014	.4481	.5658	.9717	1.749	1.6004	.3921
7	.5487	.5601	.5847	1.1797	1.2963	1.9044	.3881
8	.4706	.5228	.5601		.3326	.4108	.3361
9	.4706	.4294	.4294		.2686	.3174	.9995
10		.3801	.4435			.2801	1.1336
11	1.6842	1.9271	2.1548		.2587	.2987	1.1797
12	1.5524	1.9271	2.0317		.2772	.2614	1.1271
13	1.5497	1.7553					1.0814
14	1.4548		1.6194		.3511	.2561	.9717
15	1.3599	1.5813	1.6385				1.0159
16	1.4548	1.4685	1.7901				1.166
17	1.5844	1.7553	1.9989			.0152	.2561
18	.9877	1.6049	1.1934		.3547		.2896
19	.4481	.4572			.4294	.1829	.4024
20	.4481	.4435			.4527	.2987	.4024
21	.3961	.4251			.415		.3658
22	.3734	.3734	.2957		1.1363	.2614	.3326
23	.3547	.3174	.431			.2452	.3361
24	.2896	.3174	.3174		.7748	.9282	.2452
Max	1.6842	1.9271	2.1548	1.1797	1.749	1.9044	1.1797
Min	.2896	.2801	.2957	.4161	.2587	.0152	.2452
Avg	.7638	.7948	.8928	.6694	.7528	.6492	.5789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3441	1.0648	.9145	1.0082	.2804	.3189	.2561
2	1.3443	1.1984	.9061	.9488	.2947	.3258	.2561
3	1.2793	1.2186	.9374	.9339	.2686	.3224	.2561
4	1.2483	1.3272	1.2498	.9282	.2804	.2103	.2743
5	1.439	1.4548	1.4232	1.0623	.3439	.3898	.3658
6	1.668	1.9845	1.6156	1.1203	.4075	.567	.5138
7	2.3045	2.1559	2.1247	1.3927	.5083	.5373	.4938
8	2.3967	2.1914	2.3015	.4477	.4508	.567	.4066
9	2.2405	2.3205	2.3434	1.3426	.8065	1.4403	.4024
10	.3224	.4298	.439		1.0722	1.7078	.3547
11	.3506	.4207	.4207	1.3757	1.1203	1.8023	.3045
12	.3641	.4024	.4607	1.5223	1.166	1.7071	.2743
13	.362	.415	.5068	1.406	1.2955	1.8515	.3439
14	.3721	.4024	.4755	1.4243	1.326	1.8515	.3544
15	.4119	.4207	.4119	1.5402	1.3279	1.9498	.3761
16	.443	.4755	.4784	1.4969	1.5684	2.0972	.3366
17	.543	.6036	.5552	.5258	.3982	.3605	.3403
18	.6135	.8029		.5068	.4252		.4119
19	.5548	.823		.4477	.5068		.4344
20	.591	.724		.4607	.5258	.2801	.439
21	.6024	.7095	.4075	.4207	.4607	.2926	.4525
22	.5609	.5487	.4024	.3814	.4477	.3584	1.1142
23	.4961	.4961	.3582	.3582	.3898	.2926	.9922
24	1.0242	1.0402	1.0174	.852	.3258	.362	.2743
Max	2.3967	2.3205	2.3434	1.5402	1.5684	2.0972	1.1142
Min	.3224	.4024	.3582	.3582	.2686	.2103	.2561
Avg	.9532	.9846	.9405	.9523	.6666	.8906	.4178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2103	.2012	.1791	.4801	.5182	.3277
2	.2328	.2534	.2012	.1629	.6226	.506	.3353
3	.2195	.208	.2012	.1595	.6802	.5121	.3906
4	.2218	.2629	.2241	.1829	.7842	.5506	.421
5	.3077	.3366	.3361	.2328	.8951	.7449	.4902
6	.4298	.439	.4024	.3045	1.2967	.9945	.6062
7	.5249	.4854	.4572	.3258	.3761	1.2955	.7373
8	.5373	.4344	.4163	.2865	.3898	.2481	.2481
9	.4607	.4477	.4024	.2507	.4163	.2103	.7209
10	.3403	.4252	.4024		.4161	.2481	.7701
11	.8749	1.5061	1.2163		.2896	.2561	.5121
12	1.1043	1.4899	.2534	.3294	.2454	.2614	.5898
13	.9878	1.1469	.9393	.3077	.2481	.2926	.6882
14	.9282	1.1069	.9762	.2658	.2507	.2926	.6401
15	.9374	1.0227	.9962	.2534	.2835	.2926	.5851
16	.9646	1.0322	1.1523	.2865	.2804	.2801	.6722
17	1.0623	1.1469	1.0437	.2629	.2715	.2743	.1949
18	1.166	1.1904	.9762	.2865	.2835		.2328
19	.3521	.3174		.3439	.3155		.2658
20	.3121	.2926		.4252	.3582	.3292	.2926
21	.3544	.2926	.2507	.6081	.2835	.3841	.3045
22	.2896	.2743	.2743	.583	.663	.4024	.2715
23	.2507	.2561	.2149	.5247	.583	.3605	.2126
24	.2534	.2303	.2195	.2126	.427	.5376	.3201
Max	1.166	1.5061	1.2163	.6081	1.2967	1.2955	.7701
Min	.2195	.208	.2012	.1595	.2454	.2103	.1949
Avg	.5563	.6170	.5344	.3079	.4642	.4451	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2254	.2378	.1595	.6562	.4858	.2713
2	.2126	.1991	.2218	.1578	.7209	.4744	.2622
3	.197	.1791	.2195	.1433	.7099	.4801	.2622
4	.2012	.1928	.2172	.156	.8322	.5506	.2622
5	.2353	.2126	.3258	.1753	.8855	.6401	.2984
6	.3658	.2534	.3658	.2303	1.0526	.7956	.2968
7	.4572	.3294	.4024	.2686	.2629	1.0883	.3437
8	.543	.3721		.2835	.208	.2481	.2054
9	.4656	.4344	.4755	.2865	.1791	.2507	.7499
10	.4163	.3681	.4755		.1578	.2454	.4877
11	1.1797	1.4746	1.7204	.2103	.1753	.2561	.5441
12	1.3117	1.5074	.2328	.2328		.2427	.5441
13	1.2803	1.4232	1.4083	.2254		.2378	.5693
14	1.2334	1.5089	1.5074	.2481	.181	.2561	.6081
15	1.3117	1.4582	1.4883	.2715	.2126	.2195	.6316
16	1.2967	1.4022	1.5655	.2454	.2126	.2561	.6642
17	1.2809	1.2498	1.4723	.2865		.2772	.1417
18	1.1574	1.1736	1.2018	.3395	.2149		.197
19	.333	.3544		.3544	.2481		.2126
20	.3224	.3292		.3982	.2896	.3292	.2328
21	.2947	.3109	.2328	.6882	.2454	.3475	.2149
22	.2658	.2926	.2149	.6882	.5281	.3391	.1829
23	.2353	.2743	.1991	.6173	.5182	.2812	.1433
24	.2743	.2454	.2534	.1791	.5937	.4744	.2688
Max	1.3117	1.5089	1.7204	.6882	1.0526	1.0883	.7499
Min	.197	.1791	.1991	.1433	.1578	.2195	.1417
Avg	.6304	.6571	.6875	.2976	.4326	.3989	.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1829	.1867	.1698	.1848	.1867
2	.1663	.2012	.1829	.1698	.1629	.1494	.1829
3	.1698	.1867	.1829	.1663	.1848	.1509	.181
4	.1478	.1991	.2012	.1509	.1646	.1478	.1829
5	.1886	.2378	.2012	.1886	.1867	.1867	.1991
6	.2218		.2195	.2241	.2075	.1848	.2195
7	.2772	.2587	.2926	.2075	.1829	.1867	.2012
8	.2427	.2353	.3734	.2033	.1629	.1848	.2241
9	.462	.2195	.3696	.2241	.1663	.3772	.2195
10	.3921	.2641	.3658		.1867	.4108	.2378
11	.4344	.2926	.3439	.415	.2587	.4108	.2987
12	.4904	.2743	.3045	.5068	.2987	.4024	.4338
13	.3658	.2561	.4066	.439	.1867	.4024	.2427
14	.2614	.2614	.4294	.3696	.2218	.4024	.3326
15	.3326	.2561	.4527	.3841	.3395	.2926	.3961
16	.3982	.2561	.462	.4108	.4481	.3734	.3761
17	.3841	.2926	.3584	.3584	.4108	.3696	.3761
18	.3772	.3292	.2507	.2896	.3772		.3012
19	.3547	.4572		.3326	.4481		.4119
20	.3258	.4572		.3206	.4805	.2614	.3475
21	.3395	.3658	.3142	.2926	.4108	.2427	.2772
22	.2715	.2987	.2987	.2614	.3772	.2241	.2614
23	.2561	.2587	.2641	.2172	.2641	.2195	.2452
24	.2263	.2241	.2075	.2033	.1829	.1867	.2195
Max	.4904	.4572	.462	.5068	.4805	.4108	.4338
Min	.1478	.1867	.1829	.1509	.1629	.1478	.181
Avg	.3030	.2727	.3029	.2836	.2700	.2705	.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0175			.0373
2	.0358	.0732	.052	.0354	.0526	.056
3	.0366	.0905	.0532	.0549	.0532	.0709
4	.0532	.0905	.0716	.0724	.0709	.0732
5	.0543	.0914	.0701	.0886	.0716	.0732
6		.0914	.0709	.0895	.0709	.0732
7	.0895	.0924	.0895	.0905	.0716	.0732
8	.0914	.0934	.0709	.0905	.0693	.0732
9	.0905	.0914	.0895	.0886	.0701	.0732
10	.0895	.0914		.0895	.0362	.0747
11	.0914	.0537	.0354	.0876	.0914	.0532
12	.0914	.0358	.0351	.0886	.0934	.0716
13	.0943	.0354		.0886	.0914	.0724
14	.0914	.0351	.0366	.0876	.0914	.0709
15	.0914	.0377		.0905	.0914	.0709
16	.0943	.0358	.0351	.0709	.0914	.0716
Max	.0943	.0934	.0895	.0905	.0934	.0747
Min	.0358	.0351	.0175	.0354	.0362	.0373
Avg	.0782	.0673	.0560	.0809	.0745	.0680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2033	.1829	.1109	.1867	.1494	
2	.1698	.1829	.1829	.1132	.1829	.1463	
3	.1494	.1698	.1829	.112	.2075	.1494	
4	.1478	.168	.1949	.1294	.2172	.1478	
5	.2075	.181	.2195	.1294	.2033	.1886	
6	.2452	.2012	.2561	.1478	.2241	.2218	
7	.2075	.2075	.2195	.128	.2195	.1867	.1097
8	.3584	.1848	.2328	.1433		.1753	.0732
9	.3841	.1629	.2378	.1646		.3961	.112
10	.3584	.1463	.2378			.3734	.3475
11	.362	.1646	.2614	.1886	.1772	.3292	
12	.3696	.1646	.4338	.1991		.2926	
13	.2614	.168	.4805	.2402		.2614	
14	.1646	.168	.4755	.2561	.4108	.2561	.2507
15	.2987	.1646	.4477	.4108	.2987	.439	.2926
16	.3772	.1829	.6348	.4904	.3772	.4668	
17	.2715	.1463	.5175	.3982	.3326	.4066	.0709
18	.1848	.1097	.3961	.3696	.2427		
19	.2263	.1463		.2896	.2987		.2772
20	.2012	.1646		.2427	.3018		.3547
21	.2033	.1829		.1991	.2614		.439
22	.1886	.2241		.1886	.2241		.3206
23	.2241	.1829	.1109	.1663	.1829		.2054
24	.2054	.1991	.1829	.112	.2012	.1848	
Max	.3841	.2241	.6348	.4904	.4108	.4668	.439
Min	.1478	.1097	.1109	.1109	.1772	.1463	.0709
Avg	.2480	.1740	.3044	.2143	.2500	.2651	.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV WAIFALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.1143	.0762	.1524	.1143	.0953
2	.1334	.1143	.1143	.0762	.1524	.1143	.0953
3	.1334	.1143	.1143	.0762	.1524	.1143	.0953
4	.1334	.1143	.1143	.0762	.1524	.1143	.0953
5	.1334	.1143	.1524	.0762	.1715	.1524	.1334
6	.1715	.1143	.2286	.1143	.1905	.2286	.1715
7	.1905	.1715	.1905	.0953	.1524	.2096	.1524
8	.1715	.1334	.1334	.0953	.1334	.1334	.1334
9	.1334	.0953	.1334		.0762	.1524	.0953
10	.1334	.1143	.1334		.1143	.1334	.1334
11	.1334	.1143	.1143		.1524	.1334	.1143
12	.1524	.0953			.1143	.1334	.0953
13	.1524	.0953		.1334	.0953	.1334	.0762
14	.1524	.0953		.1334	.0953	.1334	.0762
15	.1524	.0953		.1524	.0953	.1334	.0953
16	.1143	.1143		.1905			.1143
17	.1143	.1334		.1905	.1334	.0953	.1524
18	.1715	.1524		.1715	.1524	.1334	.1715
19	.1905	.1905		.2096	.1524	.1334	.1715
20		.2096		.1524	.2096	.1334	.1905
21	.1524	.2096		.1524	.1334	.1334	.1524
22	.1524	.1905		.1524	.1334	.1334	.1143
23	.1334	.1524		.1524	.1143	.1143	.0953
24	.1334	.1143	.1143	.0762	.1524	.1143	.0953
Max	.1905	.2096	.2286	.2096	.2096	.2286	.1905
Min	.1143	.0953	.1143	.0762	.0762	.0953	.0762
Avg	.1466	.1318	.1381	.1277	.1383	.1359	.1215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.8316	.5373		.1715	.1715	
2	.6468	.8316	.5373		.1715	.1715	.0762
3	.6468	.823	.5373		.1715	.1715	.0762
4	.6468	.8145	.5373		.1715	.1715	.0762
5	.724	.8145	.6859		.1715	.2477	.0762
6	1.2536	1.1222	1.2548		.2667	.381	.1524
7	1.56	1.448	1.3748		.1905	.4001	.1905
8	1.3672	1.5023	1.3413		.1905	.2858	.1524
9	1.262	1.39	1.326		.4294	.567	.0953
10	.1905	.1905	.1905		.4108	.6401	.1143
11	.1524	.1524	.1715		.2801	.6068	.0953
12	.1334	.1334			.2957	.5487	.0762
13	.1334	.1334			.3658	.439	.1143
14	.1524	.1524		.2286	.4755	.4572	.1334
15	.1524	.1524		.4854	.4755	.5121	.1334
16	.1905	.1524			.3658		.1334
17	.1905	.1715		.1905	.1905		.1334
18	.2477	.1905			.2286	.1143	.1905
19	.2477	.2286		.1334	.2286	.1143	.2477
20	.2858	.2477		.1715	.2667	.1143	.2858
21	.3239	.2477		.1715	.1905	.1143	.1905
22	.362	.2477		.1715	.1905	.1143	.1715
23	.4763	.1905		.1715	.1715	.0953	.1715
24	.6468	.7392	.5373		.1715	.1715	.0762
Max	1.56	1.5023	1.3748	.4854	.4755	.6401	.2858
Min	.1334	.1334	.1715	.1334	.1715	.0953	.0762
Avg	.5267	.5378	.7526	.2155	.2601	.3004	.1375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.3048	.2667		.3734	.4938	.1143
2	.4382	.3048	.2667		.3734	.4938	.1143
3	.2477	.3048	.2667		.4668	.4938	.1143
4	.2477	.3048	.2667		.5359	.4938	.1143
5	.3048	.3429	.381		.8962	.7421	.1905
6	.4572	.4001	.4715		1.1222	1.2894	.3239
7	.5335	.4763	.4527		.2096	1.4148	.3048
8	.4763	.381	.415		.2096	.2858	.2477
9	.362	.3429	.381	.0953	.1715	.2096	.4191
10	.3048	.2858	.362	.1334	.1715	.2286	.8962
11	1.989	1.6385	2.3148	.1334	.1524	.2286	
12	1.9669	1.5746			.1524	.2286	.9511
13	1.8519	1.8564		.1334	.1524	.2096	.8413
14	1.7147	1.8442		.1334	.1524	.2096	.7682
15	1.7833	1.8442		.1334	.1715	.2286	.8048
16	2.0687	2.0553		.1143	.1715		.8048
17	2.0348	2.0719		.1715	.1143		.2096
18	2.0576	2.0957			.2096		.2096
19	.4382	.4191		.2096	.2858		.2477
20	.4763	.4191		.2096	.3239	.1143	.3048
21	.381	.4191		.2096	.2858		.2667
22	.381	.381			.5853		.2477
23	.381	.3429			.5304		.1905
24	.2477	.2667	.2667		.3734	.4938	.1143
Max	2.0687	2.0957	2.3148	.2096	1.1222	1.4148	.9511
Min	.2477	.2667	.2667	.0953	.1143	.1143	.1143
Avg	.8913	.8615	.5093	.1524	.3413	.4623	.3826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS
 fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0076	.0095	.0229	.0191	.0171	.0019
2	.0019	.0038	.0095	.021	.0191	.0229	.0019
3	.0076	.0076	.0095	.0191	.0191	.0191	.0019
4	.0095	.0076	.0095	.0248	.0191	.0133	.0019
5	.0076	.0076	.0095	.0229	.0286	.0381	.0019
6	.0057	.0076	.0191	.0286	.0191	.04	.0229
7	.0076	.0133	.0171	.0229	.0286	.0171	.0191
8	.0229	.0057	.0133		.04	.0076	.0133
9	.0019	.0114	.0133	.0248	.0305	.0019	.0191
10		.0076		.0057	.0286	.0191	.0095
11			.0019	.0057	.0191		.0057
12	.0171			.0057	.0286		.0019
13	.0038	.0076		.0057	.021		.0019
14	.0019	.0076		.0057	.0229		.0019
15	.0019	.0171		.0057	.0019		.0019
16	.0038	.0171		.0248	.0171		.0019
17	.0095	.0191		.0019	.04		.0019
18	.0191	.0191		.0152	.0191		.0057
19	.0191			.0305	.0305		.0095
20		.0095		.0305	.0114		.0171
21		.0095		.0305	.021		.0152
22		.0095		.0191	.0191		.0133
23		.0095		.0191	.0171		.0152
24	.0095	.0076	.0095	.0305	.0191	.0133	.0019
Max	.0229	.0191	.0191	.0305	.04	.04	.0229
Min	.0019	.0038	.0019	.0019	.0019	.0019	.0019
Avg	.0085	.0101	.0111	.0184	.0225	.0190	.0079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374	.5535	.6316	.2452	.2641	.3961	
2	.4374	.578	.6722	.2452	.2452	.3361	
3	.4999	.578	.6882	.2452	.2452	.3696	
4	.6325	.5937	.6882	.2641	.2829	.4294	
5	.8539	.6093	.7202	.3018	.3395	.4108	
6	.9488	.8124	.9122	.3961	.4527	.4108	
7	1.142	1.186	1.1498	.4527	.3395	.4854	
8	1.1728	1.2176	1.2176	.5041	.3395	.5228	
9	1.1561	1.1717	1.2003	.8223	.5247	1.0242	
10	.2172	.2743	.2772		.6472	1.1385	
11	.2218	.4066	.4108	.9962	.8436	1.2492	.1294
12	.2054	.4108	.3326	1.0437	.8951	1.2163	.5851
13	.1848	.3547	.3361	.953	.8436	1.0311	.2686
14	.1848	.3174	.2987	.8855	.8697	1.0082	.3361
15	.2402	.3174	.3174	.9061	.8179	.9442	.3547
16	.3361	.3921	.3174	.8951	.9297	1.0623	.3921
17	.3921	.5601	.3174	.4854	.362	.463	.3174
18	.5975	.5975	.3326	.5601	.4481	.4668	.3734
19	.5228	.6535		.4481	.3696		.4108
20	.4108	.5041	.2427	.2829	.3734		.3395
21	.415	.4527	.2614	.3018	.3395		.3395
22	.3734	.415	.3018	.3018	.3734		.5218
23	.3584	.3772	.2641	.3018		.3921	.506
24	.4218	.4902	.5992	.2452	.2641	.3772	
Max	1.1728	1.2176	1.2176	1.0437	.9297	1.2492	.5851
Min	.1848	.2743	.2427	.2452	.2452	.3361	.1294
Avg	.5151	.5760	.5430	.5254	.4961	.6867	.3750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3765	.4934	.5216	.1478	.168	.2218	
2	.3765	.5498	.5921	.1478	.1509	.2402	
3	.4054	.5563	.6062	.1478	.1509	.2614	
4	.5213	.5563	.6144	.1478	.1698	.2641	
5	.6081	.5921	.6287	.1848	.2263	.2829	
6	.7628	.8688	.8431	.2801	.2829	.2829	
7	1.0856	1.0856	1.0425	.2614	.3361	.3109	
8	1.0433	1.1431	1.1004	.2378	.2353	.3109	.0914
9	.9305	1.086	.9701	.4934	.4033	.6687	.1463
10	.128	.1509	.2378		.4172	.9095	.1097
11	.1463	.1772	.2054	.6573	.4054	.9095	
12	.1448	.197	.208	.7385	.6602	.8002	.1772
13	.128	.1629	.1991	.7002	.7133	.724	.1017
14	.1463	.1791	.2012	.6661	.7526	.8002	.1227
15	.1478	.1612	.1829	.7095	.5357	.8768	.4607
16	.1646	.1448	.2353	.7674	.7682	.9587	.1433
17	.2218	.2378	.2534	.2353	.0914	.2012	.2172
18	.2772	.2195	.2926	.3258	.2534	.2743	.2561
19	.2987	.3142		.2743	.2587		.2378
20	.2829	.3174	.181	.2427	.2402		.2614
21	.2829	.3018	.1848	.2241	.2241		.2241
22	.2641	.2829	.168	.2054	.2075		.5719
23	.1886	.2218	.1478	.1867		.2241	.5268
24	.362	.4371	.4793	.1478	.168	.2427	
Max	1.0856	1.1431	1.1004	.7674	.7682	.9587	.5719
Min	.128	.1448	.1478	.1478	.0914	.2012	.0914
Avg	.3873	.4349	.4389	.3535	.3400	.4883	.2432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 207 / 11 KV Sawarde Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.168	.1886	.1698	.1698	.2402	.1867
2	.1509	.1886	.1886	.1698	.1509	.2195	.1867
3	.1509	.1886	.1698	.1698	.1509	.2033	.1478
4	.1698	.1886	.1886	.1698	.1698	.2241	.1509
5	.1867	.1698	.1886	.1886	.1886	.1886	.1524
6	.2054	.2452	.2263	.2263	.2263	.1886	.1886
7	.2012	.2452	.2054	.168	.1848	.1478	.1494
8	.1612	.1829	.1578	.1448	.1463	.1372	.128
9	.1433	.1417	.156	.1372	.1448	.1448	.124
10	.1372	.1509	.1543		.1254	.1267	.1543
11	.1387	.1372	.1448	.1949		.0876	.1543
12	.1387	.1187	.1696	.1612	.1086	.1433	.124
13	.1595	.1372	.1991	.1791	.1086	.1448	.1387
14	.1646	.1543	.1991	.1772	.1646	.1646	.1402
15	.1663	.156	.1991	.1791	.1463	.1663	.1448
16	.1478	.1372	.1595	.1791	.1433	.1734	.1448
17	.1448	.124	.1715	.1753	.1402	.1753	.1387
18	.1829	.1254	.1677	.1907	.1214	.1886	.1734
19	.2772	.2353		.2481	.1928		.2279
20	.3174	.3109	.2378	.2507	.2534		.2715
21	.2614	.3326	.2587	.2561	.2587	.1829	.2772
22	.2263	.2614	.2402	.2241	.2241		.2054
23	.2075	.2241	.2054	.1698		.2402	.1698
24	.1886	.1867	.2054	.1698	.1698	.2614	.2033
Max	.3174	.3326	.2587	.2561	.2587	.2614	.2772
Min	.1372	.1187	.1448	.1372	.1086	.0876	.124
Avg	.1833	.1879	.1905	.1869	.1677	.1785	.1701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0762	.1132	.1052	.2915	.3201	.0572
2	.1132	.0762		.1063	.2915	.3005	.0572
3	.132	.0762	.1132	.1254	.3563	.2846	.0572
4	.1698	.1334	.1509	.1448	.4801	.3163	.0572
5	.2452	.2075	.2075	.1612	.6401	.4961	.0762
6	.3206	.3018	.2452	.2103	.8802	.8482	.1886
7	.2641	.2427	.2075	.2572		.9755	.1509
8	.2263	.2054	.1886	.1132	.132	.1886	.0943
9	.1867	.1698	.2263	.0943	.0943	.1698	.2721
10	.2054	.1509	.1698	.0943	.0724	.1886	.3201
11	.9804	.9722	.9297	.0754	.0549	.1698	.3041
12	.8951	.9145	.9259	.1307	.112	.168	.5182
13	.8025	.8128	.5944	.1307	.1478	.1698	.4843
14	.7562	.7375	.5401	.0914	.1097	.1698	.2778
15	.6327	.7468	.4001		.0358	.1698	.3125
16	.7186	.8025	.6874		.0366		.3681
17	.8749	.9842	.8002		.1463	.1698	.0739
18	.8278	.8855		.2241	.1848	.1886	.0934
19	.2402	.2054		.2241	.2218		.1109
20	.2641	.1886		.2075	.2075	.1509	.1494
21	.2452	.1698	.0754	.1698	.1886	.0762	.1867
22	.1886	.1509	.0189	.3887	.4858	.0572	.1698
23	.132	.132	.0189	.3239	.3887	.0572	.1509
24	.132	.0953	.1132	.0895	.2915	.3361	.0572
Max	.9804	.9842	.9297	.3887	.8802	.9755	.5182
Min	.1132	.0762	.0189	.0754	.0358	.0572	.0572
Avg	.4028	.3933	.3363	.1651	.2544	.2714	.1912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3048	.2829	.2641	.2829	.2829	.2286
2	.3018	.3048	.2829	.2263	.2641	.2641	.2286
3	.3395	.3048	.2829	.2263	.2641	.2641	.2286
4	.3961	.362	.3395	.2829	.3206	.3395	.2858
5	.4527	.4527	.4338	.3584	.3961	.4338	.3395
6	.547	.547	.5658	.415	.5281	.5093	.4904
7	.415	.4108	.3881	.3361		.3734	.4527
8	.3361	.3142	.3582	.2801	.2054	.2772	.3326
9	.2896	.2587	.2896	.2378	.1698	.1698	.2715
10	.2507	.2328	.2686	.2402	.1848	.1848	.168
11	.2715	.2218	.2402		.2715	.1848	.2353
12	.2402	.2218	.2743	.2957	.2507	.2033	.2279
13	.2772	.2378	.2772	.2772	.2715	.2033	.2149
14	.2801	.2587	.2926	.2772	.2561	.2054	.1991
15	.2587	.2587	.2865	.2926	.2402	.2054	.2402
16	.2614	.2772	.2772	.2926	.2218		.2801
17	.2743	.2926	.2561	.2534	.2172	.3361	.2772
18	.3045	.2926		.3761	.2865	.3547	.2926
19	.3982	.439		.4668	.4344		.3511
20	.5359	.5729		.499	.5041	.4338	.4338
21	.4668	.4854	.4294	.4294	.415	.3584	.3961
22	.4338	.415	.3961	.3772	.3772	.3018	.3584
23	.3584	.3395	.3395	.3206	.3206	.2829	.3018
24	.3206	.3239	.3018	.3018	.3018	.3018	.2477
Max	.547	.5729	.5658	.499	.5281	.5093	.4904
Min	.2402	.2218	.2402	.2263	.1698	.1698	.168
Avg	.3463	.3387	.3268	.3186	.3037	.2941	.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.8951	1.0402	.1132	.1509	.1132	.5636
2	.7209	.9054	1.0242	.0943	.1509	.1132	.5533
3	.7682	.9724	1.0242	.1132	.1494	.1132	.5533
4	.8848	1.1065	1.1012	.1698	.1829	.1509	.5636
5	.9762	1.3426	1.2944	.2452	.2328	.2075	.5967
6	1.0814	1.6244	1.6385	.3206	.3121	.2641	.7042
7	1.5203	2.1792	2.3537	.2926		.2641	.9054
8	1.7368	2.1464	2.6189	.2614	.2241	.2427	.1698
9	1.6518	2.1464	2.4366	1.491	1.0562	1.5384	.1509
10	.0934	.1463	.132	1.749	1.1683	1.8515	.168
11	.168	.2263	.2241	1.8351	1.3603	1.8679	.1494
12	.168	.2075	.2614	2.0809	1.4251	1.7532	.1646
13	.1494	.2641	.2587	2.1051	1.5061	1.7004	.1294
14	.168	.2829	.2614	1.9498	1.3923	1.5565	.0934
15	.1886	.3018	.2402	1.8785	1.2793	1.7736	.0924
16	.2075	.2801	.2801	1.8023	.2126		.1663
17	.2427	.2614	.2641	.1867	.1867	.1867	.1494
18	.2829	.2641		.1867	.2263	.2427	.132
19	.3206	.2614		.2801	.2033		.1867
20	.2829	.3018		.2263	.2263	.2263	.1867
21	.2829	.2614	.1867	.2075	.1886	.1886	.1698
22	.2263	.2263	.1867	.1886	.1886	.6226	.6882
23	.1886	.1886	.1698	.1698	.1509	.5898	.7202
24	.9012	.8619	.9878	.1132	.1509	.132	.5967
Max	1.7368	2.1792	2.6189	2.1051	1.5061	1.8679	.9054
Min	.0934	.1463	.132	.0943	.1494	.1132	.0924
Avg	.5938	.7356	.8564	.7525	.5359	.7136	.3564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.2429	.3041	.3269	
2	.1132	.0943	.0934	.2429	.2846	.3269	
3	.1132	.0943	.0934	.2526	.2812	.3269	
4	.132	.1132	.0943	.2526	.2778	.3311	
5	.1509	.132	.1132	.3048	.3658	.3506	
6	.2263	.2452	.1698	.3906	.6405	.6249	
7	.2427	.2241	.2614	.4321	.6895	.8173	
8	.2054	.1663	.1867	.1478	.1509	.1478	
9	.1663	.1494	.1478	.0709	.0934	.1294	
10	.1463	.128	.1294		.0732		
11	.945	.9934	1.0686	.0716	.0554		
12	1.0669	1.0364	1.1363	.0724	.0537		
13	1.0105	1.0212	.9242	.0724	.0537	.0886	
14	.9783	.8802	.8543	.0724	.0549	.0934	.7377
15	.9389	.8688	.8916			.0934	.6859
16	1.0364	.8833	.9846	.1417	.0924	.0876	.6093
17	1.0848	1.0562	.9511	.1646	.0886	.0739	.1254
18	.9682	1.0517	.8949	.128	.0724	.1063	.1417
19	.1463	.1867		.1307	.1463		.1254
20	.2075	.1509		.2033	.1698		.168
21	.1698	.1867	.1294	.2033	.1509		.1307
22	.1698	.1698	.1109	.3549	.3963		.112
23	.132	.1698	.1109	.3353	.3963		.112
24	.132	.1132	.1132	.0924	.3437	.3763	
Max	1.0848	1.0562	1.1363	.4321	.6895	.8173	.7377
Min	.1132	.0943	.0934	.0709	.0537	.0739	.112
Avg	.4415	.4262	.4351	.1991	.2276	.2688	.2948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.5287	.4744	.0187	.1086	.0914	
2	.4401	.4934	.4801	.0187	.0886	.0724	
3	.423	.4793	.4374	.0187	.0895	.0724	
4	.4729	.4729	.4744	.0187	.1075	.0732	
5	.6001	.4868	.5312	.0189	.1075	.0914	
6	.7529	.6716	.7011	.0189	.1254	.1494	
7	.9829	.8716	.8993	.0187	.12	.1433	
8	.9556	.9267	.9482	.0187	.12	.1372	
9	.8859	.8741	.8802	.0705	.2743	.5144	
10	.0857	.0781	.0983		.3286	.6015	
11	.0895	.1063	.1478		.4988	.6661	
12	.0876	.1086	.1402	.0974	.6015	.6573	
13	.1052	.104	.1052	.0974	.543	.6485	
14	.1075	.1052	.124	.0857	.5647	.6226	.124
15	.128	.1433	.1267	.0823	.5007	.6081	.1097
16		.1433	.1829	.0934	.5639	.5721	.1029
17	.1463	.1463	.1478		.1006	.064	.0838
18	.181	.2033	.1848	.3961	.0693	.0781	.0867
19	.1991	.1829		.1402	.1417		.0876
20	.1646	.1848		.1214	.1448		.1086
21	.1663	.1772		.1227	.128		.1097
22	.1463	.1663	.0177	.1052	.1109		.2462
23	.128	.1478	.0177	.1063	.1109		.2462
24	.4548	.5498	.5376	.0189	.1075	.1109	
Max	.9829	.9267	.9482	.3961	.6015	.6661	.2462
Min	.0857	.0781	.0177	.0187	.0693	.064	.0838
Avg	.3550	.3480	.3646	.0804	.2357	.3144	.1305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.124	.1334	.0995	.112	.0905	
2	.1143	.1052	.1143	.1006	.0934	.0895	
3	.0953	.1052	.0953	.1086	.0943	.0895	
4	.0953	.1052	.1143	.1086	.0943	.0895	
5	.0953	.124	.1143	.1267	.1132	.0924	
6	.1143	.1448	.1334	.1254	.132	.1307	
7	.132	.1307	.1334	.2096	.1334	.1494	
8	.112	.0934	.1905	.2054	.0934	.0934	
9	.112	.2641	.2658	.1772	.1109	.1886	
10	.0867	.2801	.2658		.132	.2033	
11	.0995	.2614	.3258	.0716	.2286	.1848	
12	.1017	.2829	.2896	.2641	.168	.2667	
13	.0995	.1715	.1886	.1781	.0934	.1132	
14	.1017	.1715	.1886	.2328	.0747	.2075	.3772
15	.104	.2858	.2801	.3048	.112	.2858	.2667
16	.1029	.2286	.2033	.2667	.1509	.1715	.3018
17	.104	.3206	.1905	.2829	.2096	.1715	.3174
18	.1063	.2772	.3224	.3048	.3018	.2641	
19	.1294	.2641		.1509	.1698		.2286
20	.168	.2641		.132	.1886		.2286
21	.1463	.2452	.1463	.132	.1886		.2096
22	.1478	.1524	.124	.112	.1132		.1132
23	.1254	.1143	.12	.1132	.112		.1132
24	.1227	.124	.1334	.1006	.1132	.1109	
Max	.168	.3206	.3258	.3048	.3018	.2858	.3772
Min	.0867	.0934	.0953	.0716	.0747	.0895	.1132
Avg	.1137	.1933	.1851	.1699	.1389	.1575	.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.1698		.1478	.1867	.112
2	.1698	.1509	.1698		.1478	.1867	.112
3	.1698	.1509	.1698		.1478	.1867	.112
4	.1698	.1698	.1698		.1478	.1867	.112
5	.2452	.2075	.2075		.1848	.2427	.168
6	.2829	.2829	.3361		.2587	.3326	.2218
7	.2534	.2378	.2801		.3077	.3258	.2743
8	.2353	.1848	.2033			.2254	.2561
9	.1928	.1663	.2172			.2454	
10		.1097	.1886			.2401	.1848
11		.1132	.168			.2254	.168
12	.1132	.132	.2033			.2507	.2149
13	.1132	.1848	.2033		.1949	.2481	.2012
14	.1132	.168	.1848		.2629		.1478
15	.1509	.168	.1848	.2507	.2427	.1494	.1698
16	.1509	.1663	.1663	.2658			.1867
17		.1646	.1132	.3086		.1829	.2218
18	.2328	.2328	.1629		.2947		.2561
19	.2481	.2534		.1463	.3506	.2507	.2957
20	.3292	.3696		.2507	.3582	.2715	.3292
21	.3142	.3326		.2195	.3403	.1494	.2587
22	.2801	.2801		.2353	.2743	.1494	.2241
23	.2241	.2427		.1829	.2402	.1494	.1848
24	.1698	.1886	.2075		.1829	.2033	.112
Max	.3292	.3696	.3361	.3086	.3582	.3326	.3292
Min	.1132	.1097	.1132	.1463	.1478	.1494	.112
Avg	.2061	.2003	.1951	.2325	.2402	.2185	.1967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5937	.5851		.0943	.0943	.1829
2	.4967	.5937	.6009		.0943	.0943	.1829
3	.4967	.578	.6009		.0943	.0943	.1806
4	.4967	.5937	.6405		.0943	.0943	.1806
5	.587	.6249	.6718		.1132	.132	.2241
6	.7432	.8749	.9061		.1886	.2075	.3277
7	1.0494	1.25	1.2809		.168	.1867	.3163
8	1.1111	1.3435	1.2346		.3374	.104	.112
9	1.0669	1.1888	1.1126		.3521	.4268	.0739
10	.0724	.0709	.1006		.362	.5268	.0747
11	.0747	.0924	.0739		.3864	.5792	.0754
12	.0924	.1294	.0905		.503	.8179	.0554
13	.0924	.1086	.104		.4755	.7375	.0747
14	.0914	.0914	.0701		.5117		.0566
15	.0732	.0716	.0701	.7253	.4012	.7562	.0747
16	.0739	.0693	.0701				.0747
17		.1097	.1086	.0895		.0914	.0924
18	.1494	.1478	.1109		.1063	.0914	.1109
19	.1109	.1307		.1294	.168	.1132	.1478
20	.1698	.2075		.132	.1867	.132	.1663
21	.1698	.1886		.2561	.1646	.0943	.1307
22	.132	.1698		.112	.1294	.2134	.3077
23	.1132	.132		.0934	.1097	.1829	.3681
24	.4801	.5937	.5601		.0943	.0934	.1829
Max	1.1111	1.3435	1.2809	.7253	.5117	.8179	.3681
Min	.0724	.0693	.0701	.0895	.0943	.0914	.0554
Avg	.3675	.4148	.4733	.2197	.2334	.2665	.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0747	.0747		.1718	.0537
2	.0739	.0747	.0747		.1718	.0537
3	.0739	.0739	.0747		.2056	.0537
4	.0739	.0739	.0739		.2056	.0537
5	.1109	.1132	.1848		.2241	
6	.1698	.1886	.2263		.3315	
7	.168	.1867	.2054		.4321	
8	.1494	.1663	.168		.1254	
9	.1097	.1086	.1646		.0709	
10	.0857	.12	.1433		.0532	
11	.7907	.8951	.9374		.052	
12	.7253	.8951	.9145		.0671	.4588
13	.7621	.8383	.7375		.0514	
14	.7773	.823	.7676			
15	.8179	.8535	.6622			.6241
16	.7099	.9145	.6859			.6001
17		.9145	.8333			.0747
18	.743	.8078	.7468			.0924
19	.1086	.124		.4111	.1267	.1494
20	.112	.1478		.1307	.1086	.1646
21	.1086	.1294		.1109	.0905	.0924
22	.1109	.0924		.1875	.0537	.0934
23	.0924	.0739		.1543	.0532	.0739
24	.0747	.0747	.0754		.1543	.0537
Max	.8179	.9145	.9374	.4111	.4321	.6241
Min	.0739	.0739	.0739	.1109	.0514	.0537
Avg	.3053	.3652	.4079	.1989	.1447	.1795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.3048	.2241	.2218	.2658	.2561	
2	.2614	.2858	.2218	.2172	.2454	.2614	.2218
3	.2452	.2858	.1848	.2126	.2534	.2587	.2195
4	.2452	.2667	.1829	.2103	.2926	.2534	.2241
5	.2801	.3048	.2218	.2195	.2865	.2587	.2402
6	.2957	.3048	.3109	.2896	.2947	.3174	.2772
7	.3109	.362	.2402	.2715	.3292	.3174	.3109
8	.2667	.2743	.2561	.2378	.2103	.2033	.2241
9	.2096	.2149	.2218	.2195	.2195	.1829	.1646
10	.1905		.2126	.2303	.1829	.1848	.1848
11	.1772	.1886	.2353	.2279	.1848	.1848	.1753
12	.2012	.2263	.2195	.2149	.1829	.2172	.2126
13	.2033	.197	.2378	.2126	.2033	.2561	.2103
14	.197		.2561	.2378	.1848	.2195	.1991
15	.1753		.2218	.2103	.2033	.2378	.1949
16	.1715		.2218	.197	.2149	.2172	.2149
17	.1949	.2172	.2012	.2378	.2263		.2402
18	.2012	.2241	.2534		.2614	.4436	.2353
19	.2427	.3077	.2926		.2957	.2241	.2587
20	.3511	.3696			.3475	.2957	.3547
21	.4001	.3801	.3174		.3361	.2987	.3174
22	.3429	.3475	.3109	.2896	.3077	.2587	.3142
23	.3048	.2987	.2587	.2926	.3142	.2427	.2715
24	.2587	.3048	.2587	.2378	.2686	.2715	.2263
Max	.4001	.3801	.3174	.2926	.3475	.4436	.3547
Min	.1715	.1886	.1829	.197	.1829	.1829	.1646
Avg	.2494	.2833	.2418	.2344	.2547	.2549	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.9717	.7373	.4001	.1524	.1478	.1663
2	.7116	.9962	.6562	.3906	.1524	.1494	.168
3	.7343	1.0517	.6401	.4049	.1715	.1494	.1646
4	.7811	1.1405	.6325	.3953	.1715	.1478	.1663
5	.8796	1.3094	.7287	.4801	.2096	.2241	.1867
6	.9907	1.2967	.9998	.4999	.2096	.2263	.2561
7	1.46	1.4083	1.4575	.6249	.2477	.2896	.2587
8	1.7764	1.4842	1.6385		.1905	.2378	.168
9	1.4083	1.5278	1.2498		1.0155	1.1561	.1848
10	.1524		.2172	.8124	1.1092	1.2967	.1905
11	.1715	.1698	.1991	.8785	1.0202	1.3125	.1715
12	.2286	.1698	.1848	.933	1.012	1.3125	.1715
13	.2286	.1132	.2033	1.0202	.9998	1.2809	.1905
14	.2096	.1698	.1848	1.2654	.9722	1.1736	.2096
15	.2096	.1886	.2033	1.21		1.1069	.2096
16	.2477	.2075	.1848	1.1227		1.2809	.2096
17		.2587	.2402	.2477	.132		.2286
18		.2054	.2614	.2286	.1463	.1478	.2286
19	.2667	.2012	.2012	.2858	.2054	.181	.2477
20	.3048	.2402			.2075	.2012	.2286
21	.2858	.2829			.2054	.2033	.2096
22	.2858	.2402	.1848	.2477	.1867	.2054	.2096
23	.2667	.2241	.168	.1524	.1829	.1867	.6167
24	.6722	.8785	.7522	.4268	.1524	.1629	.1698
Max	1.7764	1.5278	1.6385	1.2654	1.1092	1.3125	.6167
Min	.1524	.1132	.168	.1524	.132	.1478	.1646
Avg	.5906	.6407	.5421	.6014	.4115	.5557	.2171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1629	.1307	.1294	1.012	.7202	.0554
2	.132	.1848	.1294	.1307	1.0517	.6642	.056
3	.132	.1886	.1267	.1307	1.2146	.6173	.0543
4	.132	.1829	.1307	.1307	1.4586	.6325	.0554
5	.1698	.2149	.168	.132	1.4723	.6882	.056
6	.2641	.2303	.2614	.2378	1.5893	1.2029	.0914
7	.2957	.2801	.2587	.2402	1.5623	1.4327	.1086
8	.3109	.2772	.2427	.2427	.2054	.1829	.056
9	.2561	.2772	.2587	.2402	.1463	.2241	.5601
10	1.1561			.2402	.1646	.1867	.506
11	1.2191	1.5497	1.5684	.2195	.1829	.1867	
12	1.0974	1.4217		.2241	.1663	.1494	
13	1.1589	1.3748		.2054	.1663	.1494	
14		1.2498		.2033	.1663	.1494	
15	1.2334	1.2041	1.0402	.2218	.1478	.1494	.7773
16	1.1584	1.189	1.5278	.2195	.1663	.168	1.0494
17	1.2346	1.2193	1.5971	.2172	.1829		.1417
18	1.174	1.2498	1.6004	.2481	.1991		.1402
19	.1991	.2402	.128	.2427	.2427		.1109
20	.2033	.2241			.2427		.1494
21	.2241	.2012	.1663		.2033		.1698
22	.1698	.1867	.168	.6636	.7926	.0554	.1698
23	.1698	.1663	.1663	.7133	.8592	.0554	.1509
24	.1509	.1646	.1463	.1478	.9555	.7811	.056
Max	1.2346	1.5497	1.6004	.7133	1.5893	1.4327	1.0494
Min	.132	.1629	.1267	.1294	.1463	.0554	.0543
Avg	.5380	.5931	.5166	.2446	.6063	.4419	.2257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3658	.362	.3772	.3658	.3696
2	.3475	.362	.362	.3511	.3584	.362	.3658
3	.3292	.298	.362	.3475	.3584	.3696	.3696
4	.3292	.3109	.3696	.3547	.3361	.3582	.3734
5	.3658	.3224	.3658	.3696	.3361	.362	.3696
6	.4024	.3292	.4207	.4024	.3734	.4066	.4024
7	.3292	.3547	.3326	.3696	.3921	.3658	.3109
8	.3292	.3109	.3734	.3475	.3258	.3142	.3326
9	.2926	.2865	.3475	.3696	.3077	.3109	.3174
10	.3077			.3544	.3142	.2926	.2926
11	.3174	.2561	.3475	.3511	.3326	.3109	.3155
12	.3511	.3109	.3841	.3658	.2561	.3109	.3189
13	.3366	.3475	.3658	.3439	.2743	.3109	.3045
14	.3395	.3475	.3658	.3189	.2378	.3109	.2926
15	.3155	.3475	.3658	.3326	.2743	.3109	.3018
16	.2743	.3658	.3292	.3475	.3658	.3155	.3292
17	.3077	.3475	.2743	.2534	.3475	.298	.333
18	.3582	.3921	.4024	.298	.3658	.3109	.4252
19	.3982	.4706	.4887	.4207	.4525	.4481	.4572
20	.4294	.543			.499	.4435	.5041
21	.5658	.5304	.439		.4755	.4163	.4715
22	.5093	.462	.4668	.4382	.462	.3841	.415
23	.4527	.4294	.4251	.4715	.4481	.3734	.3772
24	.3658	.3881	.4066	.3841	.415	.4066	.3734
Max	.5658	.543	.4887	.4715	.499	.4481	.5041
Min	.2743	.2561	.2743	.2534	.2378	.2926	.2926
Avg	.3633	.3686	.3800	.3616	.3619	.3524	.3635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7287	.5735	.4801	.0701	.0566	.056
2	.7287	.7522	.4999	.4588	.0686	.0566	.0554
3	.7287	.7716	.4801	.4534	.0532	.056	.0543
4	.7432	.7773	.4744	.4428	.052	.0566	.0554
5	.7968	.828	.5182	.4801	.0537	.0754	.056
6	.8592	.9069	.7907	.4999	.0876	.0943	.0566
7	1.0987	.8579	1.0311	.6081	.0857	.0924	.0934
8	1.1288	.8977	1.2003	.0934	.1029	.1097	.0747
9	1.1439	.9808	1.1431	.7682	.6015	.8535	.0566
10	.0995			.8381	.6748	.9145	.061
11	.0972	.0739	.0754	.9442	.8069	1.0031	.0556
12	.096	.0724	.0876	.873	.9031	.9808	.0638
13	.1006	.0724	.0724	.7819	.9031	.9511	.0667
14	.0995	.0724	.0724	.8471	.7526	1.134	.0556
15	.1029	.0905	.0732	.7859	.7526	.8688	.0579
16	.1227	.0857	.0895	.727	.7977	1.0004	.0417
17	.1214	.0886	.0732	.1029	.0678	.0943	.0829
18	.6882	.1097	.112	.1052	.0747		.0848
19	.12	.1086	.1109	.1086	.0732		.0838
20	.1402	.112			.0747	.0566	.0857
21	.1417	.1132	.056		.0739	.0554	.0876
22	.1075	.1097	.0554	.0739	.056	.056	.442
23	.0876	.0924	.056	.0686	.0554	.0566	.4633
24	.6882	.6249	.6081	.4877	.0701	.056	.0566
Max	1.1439	.9808	1.2003	.9442	.9031	1.134	.4633
Min	.0876	.0724	.0554	.0686	.052	.0554	.0417
Avg	.4484	.4055	.3752	.5013	.3047	.3945	.0978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17			.7907	
23			.1509	
24	.8173	.9602		.1478
Max	.8173	.9602	.7907	.1478
Min	.8173	.9602	.1509	.1478
Avg	.8173	.9602	.4708	.1478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			.1509		
23			.5376		
24	.1478	.1294	.1698	.5535	.7499
Max	.1478	.1294	.5376	.5535	.7499
Min	.1478	.1294	.1509	.5535	.7499
Avg	.1478	.1294	.2861	.5535	.7499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			.2254		
23			.3174		
24	.2835	.3174	.3142	.2801	.3361
Max	.2835	.3174	.3174	.2801	.3361
Min	.2835	.3174	.2254	.2801	.3361
Avg	.2835	.3174	.2857	.2801	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
16	.0943	
24	.132	.0934
Max	.132	.0934
Min	.0943	.0934
Avg	.1132	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			1.2483		
23		.1886	.2641		
24	.743	.8583	.1886	.2402	.2054
Max	.743	.8583	1.2483	.2402	.2054
Min	.743	.1886	.1886	.2402	.2054
Avg	.743	.5235	.567	.2402	.2054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			.0125		
23			.0566		
24	.2229	.2972	.301	.0554	.0373
Max	.2229	.2972	.301	.0554	.0373
Min	.2229	.2972	.0125	.0554	.0373
Avg	.2229	.2972	.1234	.0554	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		.2427	.1886	.9393	1.2452	.6882
2	.168		.2195	.1698	.8802	1.2266	.6483
3	.1698		.2012	.1698	.8907	1.1336	.6325
4	.1829		.2033	.1886		1.1469	.6093
5	.1848		.2427	.1886	1.004	1.1984	.6093
6	.2452		.3018	.2263	1.085	1.2955	.6325
7	.2641		.3361	.2402	1.2803	1.5238	.6401
8	.2801		.3772	.2587	.1829	.2241	
9	.3206	.3772	.415	.2587	.2218	.2641	.1581
10	.2829	.1307		.2641	.2829	.2926	.6405
11	2.3205	2.0481		.2829	.2641	.2195	.6944
12	2.4813	2.4981	2.6155	.3584	.2987	.2218	.8583
13	2.6155	2.6993	2.7526	.3772	.2587	.2241	
14	2.5149	2.5819	2.934		.2427	.2587	.9503
15	2.5484	2.5149		.168	.2241	.2012	.8642
16		2.1714		.2054		.2926	1.0242
17	2.42	2.3868	2.3472	.3734		.3142	.1867
18	.8381	2.1628	2.8182	.3734		.3174	.1734
19	.2829	.3696			.2829		.2241
20	.2829	.3584	.1886	.2241	.2561	.1867	.2241
21	.2641	.3361	.1886	.168	.2427	.1886	.1867
22	.2263	.3206	.1886	1.1142	1.247	.7682	.2263
23	.2075	.2801	.1886	1.0486	1.278	.7042	.2075
24	.2075		.2452	.1886	.9878	1.2308	.6722
Max	2.6155	2.6993	2.934	1.1142	1.2803	1.5238	1.0242
Min	.168	.1307	.1886	.168	.1829	.1867	.1581
Avg	.8477	1.4157	.8951	.3198	.6175	.6382	.5341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075		.1886	.2075	.1715	.1886	.1698
2	.1886		.1646	.1886	.1698	.1715	.1509
3	.1698		.1663	.2075	.1509	.1509	.1509
4	.168		.1509	.2075	.1494	.1494	.1698
5	.2075		.1867	.2075	.2075	.168	.1698
6	.2614		.2452	.2263	.2452	.2263	.2075
7	.2452		.1867	.2218	.2427	.2054	.2402
8	.1663		.1646	.1629	.1829	.1663	
9	.1463	.1478	.1663	.1646	.1646	.1463	.168
10	.1791	.1612	.1791	.1612	.1772	.1629	.1791
11	.1829	.1433	.1791	.1433	.1433	.1629	.1595
12	.1663	.1829	.2149		.1629	.2172	.181
13	.2033	.1848	.2054	.2195	.1097	.2172	.1991
14	.1867	.2033	.2241	.1848	.1307	.2033	.1829
15	.1867	.2033	.2054	.1848	.1494	.2012	.1829
16	.1867	.1848	.1698	.1848	.128	.1478	.1663
17	.1646	.1867	.1698	.1646	.1629	.1612	.1629
18	.181	.2054	.1791	.2149	.1829	.1991	.2172
19	.2353	.2641			.2561		.2561
20	.2801	.2743	.2402		.2743	.2195	.2772
21	.2641	.2829	.2587	.2614	.2641	.2218	.2772
22	.2829	.2614	.2452	.2427	.2427	.2075	.2452
23	.2452	.2427	.2075	.2075	.2263	.1698	.2263
24	.2169		.2075	.2075	.1905	.1886	.1698
Max	.2829	.2829	.2587	.2614	.2743	.2263	.2772
Min	.1463	.1433	.1509	.1433	.1097	.1463	.1509
Avg	.2051	.2086	.1959	.1986	.1869	.1849	.1961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395		.3429	.3239	.3239	.3206	.2858
2	.2987		.3206	.3048	.2829	.2987	.2858
3	.2743		.2743	.3048	.2829	.2715	.2858
4	.2743		.2743	.3018	.2987	.2561	.3048
5	.3511		.3174	.3018	.3361	.2987	.3048
6	.415		.381	.3429	.4527	.3841	.3584
7	.4481		.3961	.3206	.4108	.3696	.3174
8	.4108		.2987	.3439	.3547	.3547	
9	.3658	.362	.3174	.2195	.2865	.2772	.2957
10	.2743	.2926	.2801	.2058	.2715	.3077	.3439
11	.2926	.2801	.2987	.2303	.2896	.3109	.2641
12	.2801	.2987	.2987	.2481	.3109	.3109	.3841
13	.3361	.2241	.2801	.2241	.3045	.3109	.3881
14	.2801	.2641	.3511	.2054	.2686	.3018	.3547
15	.2987	.3326	.3142	.2715	.2865	.3018	.4207
16	.3361	.3511	.2743	.3045	.2801	.3142	.4024
17	.3772	.3361	.2926	.4119	.3258	.2587	.333
18	.3988	.2926	.2987	.4706	.362	.2987	.3511
19	.4706	.462			.4344		.5228
20	.5359	.5228	.3547	.4481	.4755	.3772	.4854
21	.4854	.4854	.3734	.4715	.4207	.3734	.4854
22	.4527	.4338	.3734	.4527	.3841	.3511	.4338
23	.3961	.3961	.3429	.3772	.3511	.3018	.3772
24	.362		.362	.3239	.3429	.3174	.2858
Max	.5359	.5228	.3961	.4715	.4755	.3841	.5228
Min	.2743	.2241	.2743	.2054	.2686	.2561	.2641
Avg	.3648	.3556	.3225	.3222	.3391	.3160	.3596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3599		1.4582	.9995	.1886	.2263	.1886
2	1.3435		1.4091	.9831	.1715	.2054	.2054
3	1.326		1.4089	.9667	.1715	.2012	.2075
4	1.2929		1.3927	.9503	.1494	.1829	.2241
5	1.3763		1.5565	.9503	.1886	.2241	.2427
6	1.5912		1.7238	1.0159	.2263	.2641	.2987
7	1.8233		1.917	1.0978	.2054		.2801
8	2.0222		2.0481	.2241	.2054	.2241	
9	2.1216	2.0388	1.9334	1.0322	.9069	1.6221	.1848
10	.2427	.1991	.168	1.0883	.8745	1.6385	.1848
11	.2641	.2172	.2641	1.2289	.8907	1.6712	.1698
12	.2772	.2829	.2743	1.3435	1.1012	1.6712	.1663
13	.1848	.2801	.3142	1.4582	.9442	1.6549	.2054
14	.2054	.2987	.3511	1.3435	1.1305	1.8067	.1848
15	.168	.3395	.3475	1.3117	1.4419	1.7695	.168
16	.2241	.3547	.4251		1.4723	1.7859	.1867
17	.2641	.3292	.4294	.2012	.1448	.2241	.2012
18	.3696	.2241	.3921	.2241	.2012	.2427	.2241
19	.2801	.3547			.2452		.2241
20	.3584	.3772	.2241		.2378	.2614	.2614
21	.3395	.3584	.2241		.2263	.2427	.2427
22	.3395	.3395	.2054	.2054	.2263	.2241	.9339
23	.3018	.3018	.2054	.1886	.2263	.2075	.8848
24	1.3426		1.3927	1.0159	.1886	.2263	.1886
Max	2.1216	2.0388	2.0481	1.4582	1.4723	1.8067	.9339
Min	.168	.1991	.168	.1886	.1448	.1829	.1663
Avg	.8091	.4197	.8724	.8915	.4986	.7626	.2721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867		.2452	.1698	1.4403	1.6385	.8322
2	.1698		.2427	.1698	1.5223	1.5684	.8002
3	.168		.2195	.1698	1.5402	1.5364	.7773
4	.1494		.2218	.1886	1.6057	1.5546	.7522
5	.2033		.2587	.1886	1.6842	1.7695	.7773
6	.2561		.3174	.2263	1.8461	1.9006	.9878
7	.2587		.2987	.2402	2.2085	2.1714	1.1336
8	.2402		.2987	.2218	.2561	.2378	
9	.2241	.3361	.2427	.2378	.2378	.2452	
10	.2012	.2561	.2033	.2149	.1612	.2614	
11	2.5724	1.8842	2.7686	.2172	.1663	.2801	
12	2.7035	2.9165	2.8509	.2587	.2033	.2801	
13	2.8182	2.9001	2.769	.3326	.2587	.2614	
14		2.9329	2.2611	.3429	.2772	.2801	
15	2.3644	2.982	1.4548	.3429	.2195	.2614	
16	2.4615	2.672	2.8938	.3601	.1991	.2743	
17	2.6686	2.6216	2.7357	.3353	.181	.2353	
18	2.4326	2.1792	2.2348	.4115	.2195	.2353	
19	.2561	.2926			.2614		
20	.2772	.3174	.2427	.3429	.2614	.2012	
21	.2829	.2987	.2241	.333	.2402	.2218	
22	.2801	.2561	.1867	1.4251	1.8187	.8907	
23	.2614	.2587	.2054	1.4575	1.7736	.8745	
24	.2075		.2641	.1698	1.3763	1.6194	.8259
Max	2.8182	2.982	2.8938	1.4575	2.2085	2.1714	1.1336
Min	.1494	.2561	.1867	.1698	.1612	.2012	.7522
Avg	.9410	1.5403	1.0278	.3634	.8316	.8174	.8608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112		.128	.1132	.1143	.1132	.0754
2	.1097		.1109	.1132	.0953	.0934	.0754
3	.0914		.0924	.0943	.0934	.0914	.0754
4	.0924		.0934	.1132	.1132	.0732	.0754
5	.112		.1307	.1132	.132	.0934	.0754
6	.1509		.1478	.1478	.132	.1294	.1307
7	.1494		.1494	.128	.1254	.112	.1433
8	.1267		.1147	.1254	.1433	.0905	
9	.1063	.1478	.1134	.1063	.1109	.0943	.0838
10	.12	.0693		.1075	.0905	.0566	.1029
11	.12	.0867		.1075	.0732	.0701	.1029
12	.1097	.0867	.1254	.0895	.0895	.0886	.1075
13	.1097	.112	.1075	.1086	.0747	.0895	
14	.0895	.0905	.1097		.0914	.0886	.1063
15	.1075	.0895		.0857	.1097	.1086	.1086
16	.112	.1075		.1254	.1063	.0377	.1132
17	.0995	.1097	.1294	.1063	.1052	.0914	.1109
18	.1107	.112		.1075	.1097	.1109	.12
19	.1619	.2195			.1433		.1494
20	.2303	.2279	.1132	.1612	.1829	.128	.1715
21	.2263	.1928	.1494	.168	.1848	.1494	.1663
22	.1886	.1629	.1307	.1509	.1867	.112	.1509
23	.1646	.1448	.112	.132	.1132	.0943	.132
24	.132		.128	.1132	.1132	.1132	.0754
Max	.2303	.2279	.1494	.168	.1867	.1494	.1715
Min	.0895	.0693	.0924	.0857	.0732	.0377	.0754
Avg	.1305	.1306	.1214	.1190	.1181	.0969	.1115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989		1.8187	.5601	.168	.1698	.1132
2	1.9989		1.8233	.5441	.168	.1494	.1132
3	1.989		1.7532	.5281	.1509	.1463	.1132
4	1.9393		1.7368	.5121	.1509	.128	.1132
5	2.0481		1.7966	.5121	.1715	.1478	.132
6	2.3472		2.3472	.5281	.1715	.1905	.1698
7	2.9673		2.4577	.5668	.1698	.2263	.132
8	3.0498		2.8675	.0747	.1886	.2263	
9	2.8178	2.8012	2.6355	.5921	1.6575	2.1548	.132
10	.1698	.1494	.2054	.5693	1.9227	2.3304	.1307
11	.2241	.1867	.1886	.6316	1.9951	2.5652	.1307
12	.2427	.2427	.2614	.7125	1.989	2.5819	.1132
13	.2641	.2452	.2614	1.2431	1.8842	2.4813	
14	.2829	.2641	.2801	2.1216	1.9559	2.3807	
15	.2452	.2263	.2987	2.3975	1.989	2.5149	
16	.2641	.2241	.2801	2.2211	1.8515	2.2542	
17	.3206	.2452	.3361	.2263	.1494	.0934	
18	.2801	.2614	.3174	.2427	.1886	.168	
19	.2829	.2641			.2054		
20	.2829	.2614	.1509		.2195	.1132	
21	.2641	.2641		.2172	.2075	.112	
22	.2614	.2427	.0762	.2172	.2096	.0934	
23	.2263	.2427	.0762	.2241	.1886	.1132	
24	1.9227		1.8023	.5441	.2033	.1715	.1132
Max	3.0498	2.8012	2.8675	2.3975	1.9951	2.5819	.1698
Min	.1698	.1494	.0762	.0747	.1494	.0934	.1132
Avg	1.1117	.4081	1.0805	.7267	.7565	.9353	.1255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1509	.0566	.7773	1.1961	.132
2	.1494		.1307	.0566	.7287	1.1603	.1334
3	.128		.128	.0566	.8356	1.1469	.1307
4	.128		.1463	.0566	.9503	1.1142	.1494
5	.168		.168	.0566	1.0486	1.2146	.1509
6	.2075		.1886	.0943	1.1961	1.3441	.1698
7	.2427		.2075	.1097	1.5061	1.4899	.1886
8	.2402		.2241	.1294	.168	.1698	.1478
9	.2801	.2263	.2241		.1494	.2054	
10	.181		.1829	.2054	.0739	.2054	
11	1.8564	1.6244	1.9662	.1886	.1097	.2218	
12	1.9725	2.0885	1.9725	.2263	.128	.1991	
13	2.0222	2.2542	1.6741	.1949	.1478	.181	
14	1.989	2.0719	1.0883	.2126	.1646	.1629	
15	1.9334		2.1956	.197	.1463	.1949	
16	1.9334		2.42	.181	.1698	.2172	
17	1.7166	2.0553	2.1464	.1097	.208	.2218	
18	1.5708	1.8067	1.8842	.2054	.2195	.2033	
19	.2012	.1829			.2241		
20	.2452	.1867	.0943	.1848	.2378	.1886	
21	.2829	.1886	.0754	.1698	.2195	.1886	
22	.2075	.1867	.0754	.8907	1.2452	.6718	
23	.1886	.1698	.0754	.8097	1.2289	.6226	
24	.1698		.1509	.0566	.7682	1.1822	.1509
Max	2.0222	2.2542	2.42	.8907	1.5061	1.4899	.1886
Min	.128	.1698	.0754	.0566	.0739	.1629	.1307
Avg	.7577	1.0868	.7639	.2022	.5271	.5958	.1504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2058	.1715	.1715	.1715	.1715	.1372
2	.1372	.1715	.1715	.1715	.1715	.1715	.1372
3	.1372	.2058	.1715	.1715	.1715	.1715	.1372
4	.1372	.2058	.2058	.2058	.2058	.2058	.1715
5	.1715	.2058	.2401	.2401	.2401	.2229	.2401
6	.2229	.2401	.2401	.2401	.2401	.2401	.2401
7	.2058	.2401	.2401	.2401	.2058	.2058	.2058
8	.2058	.1715	.2058	.2058	.1715	.1886	.1372
9	.1372	.2058	.1715	.2058	.1715	.2058	.1715
10	.1715	.1715	.1715	.1715	.1372	.1715	.1372
11	.1372	.1715	.1715	.1715	.2058	.1715	.2058
12	.1372	.2401	.1715	.2058	.1715	.1715	.2058
13	.1715	.2401	.1715	.1715	.1715	.1715	.2058
14	.1715	.1715	.2058	.1715	.2058	.2058	.1715
15	.1715	.2401	.2401	.2058	.2058	.2058	.1715
16	.1372	.2058	.2401	.2058	.2058	.1715	.1886
17	.1715	.2058	.2058	.2058	.2058	.1715	.1543
18	.1372		.2058	.2058		.2058	.2058
19	.4436	.2058	.2743		.2743	.2401	.2401
20	.4938	.2401	.2743		.3086	.2401	.2401
21	.2401	.2743	.2743	.2401	.2915	.2058	.2229
22	.2401	.2743	.2401	.1715	.2572	.1715	.2229
23	.2058	.2743	.2401	.2401	.2401	.1715	.1886
24	.2229	.2058	.2058	.2058	.2058	.1715	.1372
Max	.4938	.2743	.2743	.2401	.3086	.2401	.2401
Min	.1372	.1715	.1715	.1715	.1372	.1715	.1372
Avg	.1977	.2162	.2129	.2011	.2103	.1929	.1865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2058	.1715	.1715	.1715	
2	.1715	.2058	.1715	.1715	.1715	.1715	
3		.2058	.1715	.1715	.2058	.2058	
4	.2058	.2058	.1715	.2058	.2058	.2058	
5	.2743	.2401	.2229	.2401	.2401	.2401	
6	.3086	.2915	.2743	.2743	.3086	.2915	
7	.2401	.2572	.2058	.2401	.2743	.2401	
8	.2058	.2058	.2058	.2058	.2058	.1715	
9	.1715	.1715	.2058	.1715	.1715	.1715	
10		.1543	.1715	.1715	.1715	.1372	.1715
11	.1715	.1715	.1715	.1372	.1715	.1715	.1715
12	.1372	.1715	.1715	.1372	.1715	.1715	
13	.1372	.1715	.1715	.1372	.1715	.1715	.1715
14	.1143	.1715	.1715	.1372	.1715	.1715	.1715
15	.1715	.1715	.1715	.1715	.1715	.1715	.1715
16	.1715	.1715	.1715	.1715	.1715	.2058	.1715
17	.1715	.6516	.2058	.1715	.1715	.2058	.1715
18	.2058	.1715	.2058	.2058	.1715	.2058	.2058
19	.2572	.2401	.2743		.2572	.2401	.2401
20	.2572	.2743	.2743		.2572	.2401	.2401
21	.2743	.2743	.2743	.2401	.2401	.2401	.2401
22	.2572	.2572	.2401	.2743	.2229		.2058
23	.2229	.2572	.2401	.2401	.2229		.1886
24	.2058	.2058	.2229	.2058	.2058	.2058	
Max	.3086	.6516	.2743	.2743	.3086	.2915	.2401
Min	.1143	.1543	.1715	.1372	.1715	.1372	.1715
Avg	.2047	.2294	.2072	.1933	.2044	.2003	.1939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6173	.583	.6173	.583	.5487	.5144
2	.583	.583	.583	.583	.583	.5487	.4801
3	.583	.583	.583	.583	.583	.5487	.4801
4	.583	.583	.6173	.583	.583	.5487	.5487
5	.6516	.6516	.6516	.6516	.6516	.6173	.6173
6	.703	.7202	.6516	.7202	.7202	.6173	.6859
7	.6516	.7202	.6173	.7202	.7202	.6859	.6516
8	.583	.583	.5658	.583	.583	.5144	.5144
9	.5316	.5144	.5144	.4801	.4801	.4801	.4801
10	.4801	.4801	.5487	.4801	.4801	.4801	.4115
11	.5144	.5658	.5144	.4801	.4115	.5144	.4287
12		.5658	.5144	.5144	.4458	.5487	.4458
13		.583		.5487	.4801	.5487	.4801
14		.6173	.703	.583	.5144	.5487	.5144
15	.6173	.6173	.6859	.6516	.5487	.583	.5316
16	.6173		.6001	.6173	.5144	.6173	.5487
17	.5487		.583	.6173	.6001	.583	.5487
18	.6001	.6516	.583	.583	.6173	.5487	.6173
19	.7202	.6859	.7716		.6859	.6173	.6859
20	.7888	.7545	.7545		.7716	.6859	.6859
21	.7888	.823	.7202	.6516	.7202	.6516	.7202
22	.7202	.7202	.703	.6859	.7202	.6173	.703
23	.6516	.7202	.703	.6516	.6516	.583	.6173
24	.6173	.6173	.6516	.6344	.6173	.5487	.5144
Max	.7888	.823	.7716	.7202	.7716	.6859	.7202
Min	.4801	.4801	.5144	.4801	.4115	.4801	.4115
Avg	.6263	.6344	.6262	.6009	.5944	.5744	.5594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3086	.3086	.3429	.3086	.2743
2	.3086	.3429	.3086	.3086	.3429	.3086	.2743
3	.3086	.3429	.3086	.3086	.3086	.3086	.3086
4	.3429	.3429	.3429	.3772	.3086	.3086	.3772
5	.4115	.4115	.3944	.4287	.3429	.3944	.4458
6	.4115	.4115	.4287	.3772	.4115	.4458	.4458
7	.3429	.3601	.4287	.2915	.3772	.3772	.3772
8	.3086	.3429	.3429	.2401	.3429	.3429	.3086
9	.2743	.3086	.2915	.2229	.3086	.2915	.3086
10	.2915	.3429	.3086	.2229	.2743	.2915	.2401
11	.2401	.3086	.3086		.2743	.2743	.2915
12	.1715	.3086	.3086	.2743	.2743	.2401	.2743
13	.2058	.3086	.3429	.3772	.2572	.2743	
14	.3429	.3258	.3429	.3772	.2915	.3086	.2401
15	.2915		.3429	.3429	.2915	.3086	.2401
16	.1715	.3258	.3086	.2743	.1886	.2743	.2915
17		.3429	.3086	.3086	.2401	.2743	.2572
18		.3429	.3086	.3429	.2743	.2743	.3086
19	.4458	.4115	.3772		.3601	.3429	.3429
20	.4973	.4458	.4115		.463	.3429	.3772
21	.4458	.4458	.4458	.4115	.4287	.3086	.3772
22	.4458	.4458	.4287	.4458	.4287	.3086	.3772
23	.4115	.3601	.3601	.3772	.3772	.3086	.3429
24	.3086	.3429	.3086	.3258	.3429	.3086	.2743
Max	.4973	.4458	.4458	.4458	.463	.4458	.4458
Min	.1715	.3086	.2915	.2229	.1886	.2401	.2401
Avg	.3312	.3593	.3486	.3307	.3272	.3136	.3198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.5144	.5487	.2743
2	.0343	.0343	.0343	.0343	.5144	.5487	.2401
3	.0343	.0343		.0343	.5144	.5487	.2401
4	.0343	.0343		.0343	.5144	.5487	.2743
5	.0343	.0343	.0343	.0343	.5144	.5487	.2743
6	.0343	.0343	.0343	.0343	.5487	.6859	.2743
7	.0343	.0343	.0343	.0343	.6516	.7202	
8	.0343		.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343		.0343	.0343	.583
10	.0343	.0343	.0343	.0343	.0343	.0343	.6173
11	1.406	1.3375	1.4746	.0343	.0343	.0343	.7888
12	1.3717	1.3717		.0343	.0343	.0343	.7545
13	1.3717	1.3717		.0343	.0343	.0343	.7202
14	1.3375	1.3717	1.3032	.0343	.0343	.0343	.7888
15	1.3375	1.3032	1.2689	.0343	.0343	.0343	.7888
16	1.2689	1.2003	1.2689	.0343		.0343	.7545
17	1.166	1.166	1.166	.0343		.0343	.0343
18	1.0974	1.0631	1.1317	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343		.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.4458	.583	.3086	.0343
23	.0343	.0343	.0343	.4801	.583	.3086	.0343
24	.0343	.0343	.0343	.0343	.4801	.583	.2743
Max	1.406	1.3717	1.4746	.4801	.6516	.7202	.7888
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4544	.4652	.4047	.0751	.265	.2429	.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343		.9431	.583
2	.0343	.0343	.0343	.0343		.9431	.583
3	.0343	.0343	.0343	.0343		.8916	.583
4	.0343	.0343	.0343	.0343		.8916	.583
5	.0343	.0343	.0343	.0343		.8916	.6173
6	.0343	.0343	.0343	.0343		1.1145	.5487
7	.0343	.0343	.0343	.0343		1.286	.6173
8	.0343	.0343	.0343	.0343		.0343	.0343
9	.0343	.0343	.0343	.0343		.0343	
10		.0343	.0343	.0343	.0343	.0343	.9259
11	3.2579	3.5665	3.7723		.0343	.0343	1.1145
12	3.1722	3.6866	3.7723		.0343	.0343	
13	3.1207	3.5837	3.7723		.0343	.0343	1.3717
14	3.1722	3.7037	3.8066		.0343	.0343	1.3717
15	3.0864	3.6866	3.8066		.0343	.0343	1.2346
16	3.0864	3.5665	3.7723		.0343	.0343	1.2346
17	3.0864	3.5151	3.738		.0343	.0343	.0343
18	3.0864	3.4465	3.7037		.0343	.0343	.0343
19	.0343	.0343	.0343		.0343	.0343	.0343
20	.3429	.0343	.0343		.0343	.0343	.0343
21	.0343		.0343		.0343	.0343	.0343
22	.0343	.0343	.0343		1.1145	.6173	.0343
23	.0343	.0343	.0343		1.0288	.583	.0343
24	.0343	.0343	.0343	.0343		.9431	.583
Max	3.2579	3.7037	3.8066	.0343	1.1145	1.286	1.3717
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.1257	1.2726	1.2789	.0343	.1825	.3994	.5557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2119	2.2634	2.2634	1.989	.0343	.0343	.0343
2	2.1948	2.2634	2.3663	1.989	.0343	.0343	.0343
3	2.1948	2.2634	2.4006	1.989	.0343	.0343	.0343
4	2.2634	2.2634	2.4006	1.989	.0343	.0343	.0343
5	2.2977	2.2634	2.4691	1.7147	.0343	.0343	.0343
6	2.1948	2.4006	2.5377	1.8176	.0343	.0343	.0343
7	2.4006	2.6063	2.572	2.1262	.0343	.0343	.0343
8	2.6063	2.8121	2.6063	.0343	.0343	.0343	.0343
9	2.2634	2.7435	2.4691	2.572	2.4691		.0343
10	.0343	.0343	.0343	2.6063	2.6063		.0343
11	.0343	.0343	.0343	2.8807	2.6749		.0343
12	.0686	.0343	.0343	3.0864	2.6749	2.4691	.0343
13	.0686	.0343	.0343	2.9492	2.6063	2.6749	.0343
14	.0686	.0343	.0343	3.2236	2.6749	2.7435	.0343
15	.0686	.0343	.0343	3.2922	2.6063	2.6749	.0343
16	.0686	.0343	.0343	2.9492	2.6063	2.6063	.0343
17	.0686	.0343	.0343	.0343	.0686	.0343	.0343
18		.0343	.0343	.0343	.0686	.0343	.0343
19	.0686	.0343	.0343		.0686	.0343	.0343
20		.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343		.0343	1.7147
23	.0343	.0343	.0343	.0343	.0343	.0343	1.5775
24	1.9204	2.2634	1.749	2.0576	.0343	.0343	.0343
Max	2.6063	2.8121	2.6063	3.2922	2.6749	2.7435	1.7147
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.0545	1.0260	1.0131	1.7926	.9364	.6532	.1686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5377	2.2634	2.2634	2.0919	.1372	.1372	.1372
2	2.6063	2.2634	2.332	2.0919	.1372	.1372	.1372
3	2.6063	2.2634	2.332	2.0919	.1372	.1372	.1372
4	2.6749	2.2634	2.5377	2.1434	.1372	.1372	.1372
5	2.6749	2.2634	2.6406	2.1262	.1715	.1372	.1372
6	2.7435	2.6749	2.6749	2.2634	.2058	.2058	.1372
7	3.0521	2.8121	2.915	2.6749	.1372	.1372	.1715
8	3.2922	3.0178	3.0864	.1372	.1372	.1372	.1372
9	3.0864	2.8807	3.155	3.0864	1.3032	1.2346	.0686
10	.1372	.2058	.1372	3.4979	1.3717	1.5775	.1372
11	.1372	.2058	.1372	3.3608	1.4403	1.7147	.1372
12	.2401		.1372	3.2922	1.2346	1.8519	.1372
13	.1372		.1372	3.0864	1.2346	1.7833	.1372
14	.1372		.1372	3.155	1.166	1.6461	.1372
15	.1372		.1372	3.2236	.9602	1.6118	.1372
16	.1372	.1372	.1372	3.2236	.9602	1.5775	.1372
17		.0343	.1372	.1372	.1372		.1372
18		.0343	.1372	.1372	.0686	.1372	.1372
19	.2058	.2058	.1372		.1372	.1372	.1372
20	.1372	.2058	.1372			.1372	.1372
21	.1372	.1372	.1372	.1715	.1372	.1372	.1372
22	.2058	.2058	.1372	.1715	.1372	.1372	.4801
23	.1372	.2058	.1372	.1372	.1372	.1372	.4801
24	2.0748	2.332	1.6804	2.0576	.1372	.1372	.1372
Max	3.2922	3.0178	3.155	3.4979	1.4403	1.8519	.4801
Min	.1372	.0343	.1372	.1372	.0686	.1372	.0686
Avg	1.3289	1.3306	1.1474	2.0163	.5114	.6576	.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2075	.2075	.132	.4218	.3953	.253
2	.1698	.1886	.1886	.132	.4428	.3749	.2721
3	.1886	.2075	.1886	.1509	.427	.3795	.2721
4	.1698	.2263	.2075	.1509	.4531	.4001	.2915
5	.2263	.2263	.2263	.1698	.4744	.4161	.2915
6	.2641	.2641	.2829	.2263	.5668	.6226	.4024
7	.3395	.2829	.2829	.2263	.5898	.6964	.4372
8	.3395	.2829	.2926	.3206	.2263	.2218	.1494
9	.2452	.2402	.3018	.3018	.168	.1867	.4586
10	.2427	.2195	.2987	.2829		.1867	.5761
11	1.1043	1.3108		.2641		.1663	.5376
12		1.4419		.2452		.1646	.5218
13		1.4575	1.4746	.2829	.2033	.168	.6325
14		1.3927	1.3435	.2263	.168	.1663	.5735
15		1.2803	1.2944	.2075	.1494	.168	.6081
16		1.2483	1.2803	.2263	.1494	.1509	.6241
17	1.0978	1.2308	1.3763	.2263	.1663	.168	.1494
18	1.1203	1.1069	1.2003	.2263	.1294	.1886	.1294
19	.2614	.2218			.1663		.1307
20	.2829	.2452	.168		.1886	.132	.1698
21	.2829	.2452	.1698	.1698	.1886	.132	.1698
22	.2829	.2452	.1509		.5281	.2721	.1698
23	.2452	.2263	.1509	.4428	.4321	.2561	.1509
24	.1698	.2263	.2075	.132	.4428	.4111	.2561
Max	1.1203	1.4575	1.4746	.4428	.5898	.6964	.6325
Min	.1509	.1886	.1509	.132	.1294	.132	.1294
Avg	.3781	.5927	.5378	.2259	.3182	.2793	.3428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029	2.6217	2.6029		1.1789	.7773
2	2.584	2.6029	2.584		1.1616	.8025
3	2.584	2.6783	2.584		1.1317	.8333
4	2.6029	2.7349	2.6217		1.1145	.8592
5	2.6029	2.8669	2.6029		1.1488	1.004
6	2.6972	2.9424	2.6972		.9061	1.6118
7	2.8292	3.0178	2.9235		2.2634	1.8839
8	3.1687	3.0744	3.0367	.3134	2.4897	2.2218
9	3.1121	3.2065	3.2065	.5275	2.5463	1.848
10	2.9613	2.9235	3.2065		2.9047	2.4897
11	3.2065	2.6029	3.3385		2.8669	1.8296
12	2.6029	2.8292	3.131		2.8292	2.3954
13	3.2442	3.3762	3.0367	1.3203	2.7538	2.4143
14	3.1876	3.3008	3.131		2.7161	2.4709
15	3.131	3.1121	3.0744	1.7375	2.3011	2.1879
16	2.3011	2.3577	2.8292	1.262	2.1472	2.0182
Max	3.2442	3.3762	3.3385	1.7375	2.9047	2.4897
Min	2.3011	2.3577	2.584	.3134	.9061	.7773
Avg	2.8387	2.8905	2.9129	1.0321	2.0288	1.7280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5658	.5601	.5415
2	.547	.5415	.5228	.5281
3	.547	.5601	.5415	.547
4	.6036	.5788	.5601	.5658
5	.679	.6161	.6161	.6224
6	.7282	.7842	.7468	.7468
7	.6535	.6653	.6468	.6535
8	.5014	.5121	.543	.4887
9	.439	.443	.4656	.4477
10	.4161	.2035	.4298	.4075
11	.4075	.1772	.4298	.4075
12	.3898	.1595	.4733	.3898
13	.443	.1949	.5068	.4344
14	.4656		.4887	.3841
15	.3982	.2126	.5068	.4525
16	.1433	.4207	.5014	.4252
17	.1928	.4382	.1595	.394
18	.1928	.4681	.1734	.4557
19	.2149	.6089	.6626	
20	.823	.8779	.8413	
21	.8131	.8131	.7392	
22	.7392	.7392	.6722	
23	.6283	.6722	.5975	
24	.5281	.5544	.5975	.547
Max	.823	.8779	.8413	.7468
Min	.1433	.1595	.1595	.3841
Avg	.5017	.5134	.5409	.4968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.2858	.3048	.3395	.2743	.3125	.257
2	.3353	.3353	.2932	.3125	.2572	.301	.3125
3	.2896	.3121	.301	.3601	.2538	.2896	.2932
4	.2534	.2858	.3269	.333	.2267	.2675	.3239
5	.2743	.3479	.2961	.3161	.2235	.3005	.3353
6	.3001	.2774	.2785	.2543	.2401	.2187	.1886
7	.3658	.3761	.3582	.2915	.4715	.2143	.3121
8	.415	.4294	.4024	.3189	.547	.1486	.2947
9	.4854	.5281	.4854	.415	.6602	.1947	.4024
10	.4435	.4715	.6979	.5093	.6413	.2372	.5788
11	.4163	.4527	.7545	.3109	.6224	.2713	.6413
12	.5041	.547	.5093	.439	.6602	.3206	.6413
13	.4854	.5281	.5847	.6224	.4338	.3174	.3258
14	.5093	.547	.8865	.407		.3189	.6283
15	.3982	.5281	.8488	.5175	.7167	.3658	.6979
16	.2812	.5281	.5281	.6979	.8299	.3961	.7545
17	.3681	.547	.547	.4715	.8299	.3584	.7167
18	.3641	.3467	.4854	.4715	.4527	.3547	.3801
19	.4481	.3801	.4715		.4527		.4338
20	.3549	.3549	.4527		.4481	.2896	.4527
21	.4706	.4344	.5228	.4251	.4668	.2751	.4904
22	.3944	.4715	.3086	.3772	.4904	.2881	.4096
23	.3161	.4298	.3479	.3227	.3647	.3048	.462
24	.39	.2761	.3563	.3812	.3041	.3241	.3163
Max	.5093	.547	.8865	.6979	.8299	.3961	.7545
Min	.2534	.2761	.2785	.2543	.2235	.1486	.1886
Avg	.3843	.4175	.4729	.4043	.4725	.2900	.4437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.5844	1.8296	1.6409	1.7541	1.7353	1.7353
2	1.6598	1.6032	1.8861	1.6032	1.7918	1.7918	1.6598
3	1.6787	1.6221	1.7541	1.5466	1.8107	1.7541	1.6975
4	1.6975	1.5844	1.6598	1.5089	1.8107	1.7918	1.6032
5	1.6975	1.6221	1.5089	1.4523	1.8296	1.773	1.5089
6	1.7353	1.8107	1.6598	1.8861	1.8484	1.7918	1.7353
7	1.8673	1.8107	1.6975	1.9239	1.9616	1.8861	1.7164
8	1.8861	1.8296	1.8484	1.5844	1.9616	1.9993	1.8861
9	1.7353	1.3203	1.5089	1.3203	1.5089	1.3769	1.9805
10	1.6787	1.2449	1.3392	1.3392	1.358	1.5844	1.6598
11	1.7353	1.5089	1.5089	1.3392	1.5089	1.5089	1.8673
12	1.8484	1.7164	2.0748	1.5089	1.6598	1.6032	1.6598
13	1.8484	2.1313	2.0748	2.1313	.0467	2.2068	2.32
14	1.8296	2.0748	2.2257	1.9805		2.0748	2.2257
15	1.9239	2.037	2.0748	2.0559	1.358	1.8861	2.0936
16	1.7918	1.8673	1.8861		2.1125	2.1691	2.1502
17	1.9616	1.7541	2.0748	1.905	1.8484	2.0748	2.1125
18	1.3203	1.7353	1.8861	1.5089	1.6032	1.5089	1.9805
19	1.2637	1.2449	1.5466	1.1317	1.358	1.3957	1.3203
20	1.226	.9997	1.358		1.2637	.9431	1.1317
21	1.1128	1.0751	1.3014	1.0374	1.226	1.2637	1.0185
22	1.3014	1.0374	1.5089	1.7353	1.5844	1.1694	1.1883
23	1.7918	1.905	1.8861	1.7164	1.7918	1.7353	1.8484
24	1.6598	1.6221	1.773	1.6032	1.7353	1.6975	1.773
Max	1.9616	2.1313	2.2257	2.1313	2.1125	2.2068	2.32
Min	1.1128	.9997	1.3014	1.0374	.0467	.9431	1.0185
Avg	1.6614	1.6142	1.7447	1.6118	1.5970	1.6967	1.7447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0286	.0429	.0421	.04	.506	.5344	.2743
2	.0293	.0514	.0427	.0297	.5535	.5121	.286
3	.032	.0457	.0412	.0347	.5401	.506	.286
4	.0324	.0427	.0434	.04	.5693	.5218	.2972
5	.0381	.0434	.0419	.0457	.6093	.5247	.3521
6	.0412	.0619	.0545	.0461	.7907	.9282	.4572
7	.0869	.0594	.0619	.056	.7907	1.004	.6249
8	.0714	.0833	.0732	.0583	.1029	.0732	.052
9	.0754	.0686	.0857	.0613	.0667	.048	.5087
10	.0754	.0995	.08	.0754		.0587	.6203
11	1.8515	1.8138	1.9271	.0648		.0503	.7202
12	1.873	1.9433		.0772		.0461	
13	1.8233	1.326	1.8564	.0572		.0503	.6802
14	1.7101	1.7695	1.9595	.061	.0629	.0004	.8215
15	1.5912	1.704	1.9524	.0551	.0503	.0011	.8215
16	1.6078	1.7695	2.1548	.0572	.0482	.0008	.8048
17	1.6385	1.9006	2.1862	.0486	.08	.072	.0381
18	1.5083	1.5912	2.0481	.0648	.0657	.0545	.0732
19	.0688	.056			.0629		.0453
20	.052	.0377	.0457		.0549	.032	.0324
21	.0419	.0503	.06	.0514	.0457	.0248	.0291
22	.0434	.0461	.0335		.5992	.301	.0227
23	.0412	.0434	.0372	.4843	.5535	.301	.0267
24	.0314	.0579	.0389	.032	.4961	.5506	.2812
Max	1.873	1.9433	2.1862	.4843	.7907	1.004	.8215
Min	.0286	.0377	.0335	.0297	.0457	.0004	.0227
Avg	.5997	.6128	.6757	.0734	.3324	.2694	.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1463	.1646			.1629	.1829
2		.1463	.1448			.1463	.1463
3		.1463	.1433			.1448	.1463
4		.1663	.1448			.1294	.1463
5		.2195	.1612			.1646	.1829
6		.2561	.2012			.2149	.1829
7		.1097	.1991		.1267	.181	.2195
8	.1097	.1463	.1433		.128	.1433	.1463
9	.1267	.128	.1448		.1267	.1448	.1463
10	.1097	.1463	.1463		.0549	.1463	.1463
11	.128	.1448	.1448		.0905	.1463	.1463
12	.1097	.1646			.0905	.1463	.1463
13	.1463	.1612	.1463		.0905	.1463	.1463
14	.1463	.1433			.1097	.1463	.1463
15	.1463	.1448	.1646		.0905	.1463	.1463
16	.128	.1433	.1646		.0895	.1463	.1463
17		.1448	.1463		.1086	.1463	.1463
18		.1463	.128		.0895	.2561	
19	.1646	.1991	.1463		.1991	.1829	.2195
20	.2561	.2328			.2378	.2195	.2561
21	.2561	.2328	.2561		.2149	.2195	.2195
22	.2378	.1991	.2427		.2172	.1829	.1829
23	.2195	.1629	.2195	.1463	.1829	.1829	.1463
24	.2561	.1646	.1629	.1646	.1463	.1612	.1829
Max	.2561	.2561	.2561	.1646	.2378	.2561	.2561
Min	.1097	.1097	.128	.1463	.0549	.1294	.1463
Avg	.1694	.1665	.1674	.1555	.1330	.1670	.1686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1463	.1629			.1612	.1463
2		.1463	.1433			.1463	.1463
3		.1478	.1463			.1448	.1463
4		.1663	.1448			.1267	.1463
5		.1829	.181			.1612	.1463
6		.2195	.2149			.1991	.1463
7		.1646	.2172		.181	.2172	.1829
8	.2561	.1463	.181		.2195	.1791	.1829
9	.1267	.128	.1433		.128	.1448	.1463
10	.128	.1463	.1433		.1097	.1463	.1463
11	.128	.1629	.1629		.0905	.1463	.1463
12	.128	.1463			.0914	.1463	.1463
13	.1463	.1612	.1463		.1086	.1463	.1463
14	.1463	.1629	.1478		.1097	.1463	.1463
15	.1463	.1433	.1463		.0895	.1463	.1463
16	.1109	.1448	.1463		.0905	.1463	.1463
17		.1448	.1463		.0895	.1463	.1463
18		.1463	.1097		.1086	.1829	.1829
19	.1646	.2172	.128		.2172	.1829	.2195
20	.2561	.2534			.2328	.2195	.2561
21	.2561	.2378	.2561		.2195	.2195	.2195
22	.2195	.2195	.2378		.1991	.1829	.1829
23	.2195	.181	.2218	.2195	.1629	.1463	.1463
24	.2561	.1829	.1646	.128	.1448	.1629	.1463
Max	.2561	.2534	.2561	.2195	.2328	.2195	.2561
Min	.1109	.128	.1097	.128	.0895	.1267	.1463
Avg	.1792	.1708	.1678	.1738	.1440	.1645	.1631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2195	.1829			.6859	
2		.2195	.181			.6952	
3		.2195	.197			.6783	
4		.2195	.1791			.6687	
5		.2195	.2012			.6687	
6		.2378	.2172			.7291	
7		.2378	.2378			.7716	
8	.2743	.2561	.2353			.0905	.1433
9	.2896	.2743	.2507		.1086	.0914	.6859
10	.2561	.2926	.2561		.0362	.0732	.7545
11		2.9005	2.4615		.0716	.0914	.6001
12	2.8978	2.8509			.0732	.0914	.6173
13	2.5968	2.8509	2.3998		.0724	.0914	.6859
14	2.7286	2.8178			.0549	.0914	.5487
15	2.8296	2.915	2.3998		.0537	.0914	.5316
16	2.7109	2.9334			.0724	.0732	.7202
17		2.8292	2.0458		.0895	.0895	.1433
18		2.713	2.0458		.1086	.1075	.1433
19	.2378	.2149	.2195		.1646	.1433	.1433
20	.2195	.2353			.1629	.1433	.1791
21	.2195	.2353	.1829		.1463		.1791
22	.2195	.2172	.1463		.7545		.0716
23	.2195	.1829	.1267		.7291		.0716
24	.2561	.2195	.181	.1097		.7202	
Max	2.8978	2.9334	2.4615	.1097	.7545	.7716	.7545
Min	.2195	.1829	.1267	.1097	.0362	.0732	.0716
Avg	1.1397	1.1047	.7174	.1097	.1799	.3279	.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS
Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
1	.5121	.5201
2	.5121	.5487
3	.5487	.5144
4	.5487	.5087
5	.5487	.5548
6	.5487	.5487
7	.5487	.5548
8	.5121	.5144
9	.5121	.3391
10	.5121	.4908
11	.5144	.3772
12	.5144	
13	.4748	.4854
14	.4748	.4801
15	.4801	.4508
16	.4748	.5144
Max	.5487	.5548
Min	.4748	.3391
Avg	.5148	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0185				.8676
2			1.0185				.8488
3			.9997				.8488
4			.9808				.811
5			.9896			.9054	.7733
6	1.0164		1.0082	.9795		.9149	.8215
7	.9511	.9328	.9055		.905	.823	.8501
8	.9145	.9055		.9313	.9313	.8417	.8413
9	.8326	.8775		.8682	.8859	.8059	
10		.9114			.9391	.9671	
11		.9671			.9671	.9391	.9774
12	.961	1.086		1.1104		.9114	.9745
13		1.1041			.9774	.9036	
14		1.0242				.9694	1.0208
15		1.1222		1.134	1.0242	.9694	1.0136
16		1.2308				1.1283	1.0679
17		1.2178			1.2309	.9745	
18		1.1222				1.0341	1.1403
19	1.1157	1.267			1.2048		1.086
20		1.3306			1.2986	1.1088	1.2071
21		1.2382			1.2012		1.1888
22		1.2136				1.1576	1.1949
23		1.1694		1.1203	1.1016	1.0374	1.0751
24	1.1317	1.094	1.094	1.1317	1.0829	1.0269	.9242
Max	1.1317	1.3306	1.094	1.134	1.2986	1.1576	1.2071
Min	.8326	.8775	.9055	.8682	.8859	.8059	.7733
Avg	.989	1.1008	1.0019	1.0393	1.0577	.9677	.9767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9774				.8495
2			.9671				.8322
3			.9391				.8059
4			.9391				.823
5			1.0082			.9214	.8495
6	1.0349		1.1016	1.0719		.8859	.9593
7	.9979	.9795	.9795		.961	.8962	.8779
8	.8596	.8596			.8413	.7964	.7701
9	.8048	.7947		.8131	.7964	.7964	
10		.8215			.7964	.8413	
11		.9896			.8686	.8871	.8501
12	.961	1.0082		1.1317		.9709	.9709
13		1.0456			.9896	.9522	
14		1.0642				.9425	.961
15		1.0456		1.1203	.9511	.8779	.9709
16		1.0642				.961	1.0456
17		1.0751			1.1694	.9055	
18		1.094				1.0185	1.0751
19	1.1694	1.2449			1.2637		1.1506
20		1.3769			1.2637	1.1763	1.2826
21		1.3014			1.2136	1.0534	1.1506
22		1.2323				1.0136	1.1458
23		1.1273		1.0791	1.0974	.9671	1.0387
24	1.0679	1.0317	1.0498	1.0498	1.0608	1.0029	.8669
Max	1.1694	1.3769	1.1016	1.1317	1.2637	1.1763	1.2826
Min	.8048	.7947	.9391	.8131	.7964	.7964	.7701
Avg	.9851	1.0642	.9952	1.0443	1.021	.9403	.9638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743				
2			.2743				.2926
3			.2772				.2772
4			.2772				.3292
5			.3109			.3475	.3109
6			.3475	.3696		.3658	.3511
7	.5083	.394	.4163		.4119	.4163	.394
8	.6626	.4163		.4119	.394	.4119	.4119
9	.6447	.3801		.3761	.4119	.2427	
10		.3582			.1254	.2957	
11		.3142			.3292	.2743	.3658
12	.543	.2772		.2772		.2743	.128
13		.2743			.1478	.2743	
14		.2743				.362	.2926
15		.2743		.3109	.3292	.3801	.128
16		.3077				.3801	.3109
17		.3801			.1227	.3982	
18		.362				.3801	.3658
19	.4835	.3292			.3258		.3292
20		.3109			.3258	.3292	.2801
21		.2587			.2801	.3292	.2801
22		.2587				.2587	.2801
23		.2263		.2614	.124	.2957	.2614
24	.5611	.2614	.1467	.2957	.2957	.2926	.2957
Max	.6626	.4163	.4163	.4119	.4119	.4163	.4119
Min	.4835	.2263	.1467	.2614	.1227	.2427	.128
Avg	.5672	.3143	.2906	.3290	.2787	.3320	.2992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.064				.0354
2			.0579				.0354
3			.0579				.0747
4			.0594				.0747
5			.061			.0633	.1132
6	.0213		.061	.0914		.064	.0663
7	.0206	.0282	.0579		.0602	.0709	.0747
8	.0236	.0282		.1097	.0633	.0663	.0686
9	.0343	.0305		.0949	.1494	.1029	.1052
10		.1097			.1905	.1867	
11		.1132			.2614	.1494	.1886
12	.1075	.1867		.2263		.181	.2587
13		.1509			.1132	.1886	
14		.0572				.0724	.1509
15		.1109		.0671	.1132	.0754	.1524
16		.1052				.0754	.1524
17		.1509			.1132	.1509	
18		.1132					.0754
19	.064	.0754			.1075		.0972
20		.1097			.1086	.0732	.104
21		.0617			.1524	.0716	.1052
22		.0617				.0732	.0297
23		.0655		.061	.064	.0358	.0297
24	.0221	.0655	.064	.0934	.0602	.064	.0358
Max	.1075	.1867	.064	.2263	.2614	.1886	.2587
Min	.0206	.0282	.0579	.061	.0602	.0358	.0297
Avg	.0419	.0902	.0604	.1063	.1198	.0981	.0966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV Bendri - Nimani

GAOTHAN FEEDER

GAONTHA Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0377
2			.0377				.0377
3			.0377				.0377
4			.0377				.0377
5			.0377			.0377	.0373
6	.0381		.0377	.0373		.0381	.0377
7	.0373	.0366	.0377		.0381	.0377	.0377
8	.0377	.0354		.0381	.0381	.0377	.0377
9		.0373		.0377	.0377	.4298	.0377
10		.0362			.0377	.4298	
11		.0373			.0381	.5258	.037
12	.0381	.0373		.0377		.0377	.0377
13		.0362				.0377	
14		.0377				.0377	.0381
15		.0377		.0381	.0381	.0377	.0381
16		.0377				.0377	.0377
17		.0377			.037	.0373	
18		.037					.0377
19	.0747	.037			.0747		.0754
20		.0377			.0754	.0377	.0754
21		.0373			.0762	.0377	.0754
22		.0377				.0377	.0762
23		.0377		.0373	.0762	.0377	.0762
24	.0381	.0381	.0377	.0373	.037	.0377	.0377
Max	.0747	.0381	.0377	.0381	.0762	.5258	.0762
Min	.0373	.0354	.0377	.0373	.037	.0373	.037
Avg	.044	.0372	.0377	.0376	.0504	.1084	.0467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1905	.1524	.7773	.7811	.0895
2	.1524	.1524	.1905	.1524	.7682	.8002	.0876
3	.1524	.1524	.1715	.1524	.7499	.7682	.0886
4	.1524	.1715	.1715	.1715	.7682	.7116	.0886
5	.1715	.1905	.2096	.1715	.8097		.0895
6	.2286	.2286	.2667	.1905	.8962	.8697	.1052
7	.1715	.2667	.2477	.2096	1.0526	1.1523	.0876
8	.2096	.2477	.2477	.2096		.2096	
9	.2096	.2286	.2286	.1905		.2096	.0876
10	.2286	.2477	.2667	.1905	.1905	.1905	
11	1.6716	2.234	2.1445	.1715	.1905	.1905	1.078
12	1.8818	2.2531	2.2771	.1905	.2096	.1905	1.166
13	1.8501	2.1296	1.668	.2096	.2096	.2096	1.1843
14	1.6604	1.906	2.0325	.1905	.1905		1.1717
15	1.6446	1.8122	1.9766	.2096	.1905	.1715	1.1633
16	1.6324	1.7747	1.8343	.2477	.1715	.1905	1.0722
17	1.7869	1.6512	1.9134	.2286	.2096	.1905	
18	1.6518	1.6404	1.7764	.1905	.2096	.1905	.1905
19	.2096	.2286	.2096	.1715	.2096	.1715	.1905
20	.2477	.2667	.1905	.1524	.2096	.1715	.1905
21	.2477	.2667	.2096	.1715	.2096	.1715	.1715
22	.2286	.2477	.1905	.8322	.9145		.1524
23	.2286	.2096	.1715	.8259	.8381		.1334
24	.1715	.1905	.2096	.1524	.7682	.8065	.0886
Max	1.8818	2.2531	2.2771	.8322	1.0526	1.1523	1.1843
Min	.1524	.1524	.1715	.1524	.1715	.1715	.0876
Avg	.7059	.7854	.7915	.2390	.4883	.4174	.4132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	.8642	.8173	.6009	.0762	.0762	.0572
2	.6706	.9374	.8322	.6722	.0762	.0762	.0572
3	.6401	.9804	.8173	.6964	.0762	.0762	.0572
4	.6478	.9962	.8619	.68	.0762	.0953	.0572
5	.8749	1.0242	.9482	.7202	.0953	.1143	.0762
6	1.2146	1.1523	1.0385	.8962	.1524	.1143	.1143
7	1.1142	1.3441	1.1574	.7432	.1334	.1524	.1143
8	1.4083	1.439	1.3757	.1143	.0953	.1524	
9	1.4251	1.3763	1.3592	1.0936	1.1043	1.3283	.0953
10	.0953	.0953	.0953	1.2651		1.5364	
11	.0953	.0953	.0953	1.3117	1.2963	1.4548	.0762
12	.1143	.0953	.0953	1.4413	1.2967	1.4373	.0953
13	.1143	.1143	.0953	1.3592	1.2811	1.3599	.0953
14	.1143	.0953	.1143	1.2803	1.2498	1.3125	.0953
15	.1143	.1524	.1143	1.2955	1.3435	1.1717	.0953
16	.1143	.1524	.1524	1.1584	1.3757	1.1574	.1524
17	.1143	.1524	.1524	.1715	.0953	.1143	
18	.1524	.1524	.1715	.1715	.1143	.1143	.1524
19	.1524	.1715		.1334	.1334	.0762	.1524
20	.1524	.1905	.1143	.0953	.1334	.0572	.1524
21	.1524	.1715	.1334	.0953	.1143	.0572	.1334
22	.1143	.1524	.1143	.0953	.1143	.0572	.8907
23	.1143	.1524	.0953	.0953	.0953	.0572	.8802
24	.7773	.7655	.6944	.5761	.0762	.0953	.0572
Max	1.4251	1.439	1.3757	1.4413	1.3757	1.5364	.8907
Min	.0953	.0953	.0953	.0953	.0762	.0572	.0572
Avg	.4670	.5343	.4976	.6984	.4611	.5102	.1742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.415	.4108	.3734	.381	.3772	.2641
2	.3961	.3921	.3961	.3772	.381	.3584	.2452
3	.3961	.3961	.3772	.3961	.381	.3361	.2452
4	.3961	.4066	.3772	.4108	.381	.3395	.2641
5	.4527	.4066	.4338	.4108	.4001	.3658	.3018
6	.5359	.4854	.547	.4668	.5041	.462	.4527
7	.5487	.5658	.5601	.499	.499	.4938	.4435
8	.4207		.4755	.4755	.3841	.4572	.3841
9	.4344	.4572	.4656	.4344	.3982	.4163	.4207
10	.3761	.4572		.4163		.3761	
11	.4024	.4119	.4075	.3982		.3366	.1448
12	.4163	.4031	.4298	.394		.3582	.1753
13	.4163	.4115	.4252	.394	.3189	.394	.197
14	.394	.4334	.3982	.3982	.3511	.3898	.3841
15	.3982	.4115	.3841	.4024	.3403	.394	.3982
16	.3982	.3988	.3439	.4119	.3547	.3506	.4119
17	.4163	.3681	.3224	.3982	.3658	.3544	
18		.4024	.3258	.4477	.3982	.394	.3982
19	.5544	.4938			.4525	.3658	.4835
20	.6722	.6283	.5121	.4954		.3841	.543
21	.5975	.5914	.5068	.5144	.5359	.3696	.5487
22	.5281	.5601	.4805	.4763	.5041	.3547	.4572
23	.4755	.4854	.4294	.4001	.4668	.3174	.3921
24	.4338	.4527	.4481	.3961	.381	.415	.2829
Max	.6722	.6283	.5601	.5144	.5359	.4938	.5487
Min	.3761	.3681	.3224	.3734	.3189	.3174	.1448
Avg	.4546	.4537	.4299	.4255	.4089	.3817	.3563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	1.2967	1.3125	1.0279	.0953	.1143	.1143
2	.9717	1.3125	1.2967	1.0437	.0953	.1143	.0953
3	.9488	1.2967	1.2803	1.0242	.0953	.1143	.0953
4	.9717	1.2483	1.2809	.9488	.0953	.1334	.0953
5	1.1523	1.2967	1.3283	1.0202	.1143	.1524	.1143
6	1.3748	1.3916	1.4083	1.1385	.1715	.1524	.1524
7	1.8107	1.6324	1.7236	1.2483	.1524	.1905	.1524
8	1.749	1.8818	1.8027	.1334	.1524	.1524	.1334
9	1.9006	1.9364	1.7764	1.2967	1.1523	1.406	.1334
10	.1143	.1524	.1334	1.3599	1.2967	1.5655	
11	.1143	.1905	.1715	1.2498	1.2811	1.5497	.0381
12	.1334	.1905	.2096	1.4251	1.2809	1.5813	.0381
13	.1524	.1715	.1905	1.4419	1.2967	1.531	.0381
14	.1524	.1715	.1715	1.4754	1.3443	1.5655	.1524
15	.1715	.1905	.1715	1.3279	1.4548	1.4706	.1524
16	.1715	.1905	.2096	1.4723	1.5181	1.6288	.1334
17	.1905	.1905	.0762	.1524	.1524	.1524	
18	.2286	.1905		.1334	.1524	.1524	.1334
19	.2286	.2286			.1334	.1524	.1334
20	.2286	.2477	.1905	.0953	.1524	.1524	.1524
21	.2286	.2477	.1905	.0953	.1524	.1334	.1524
22	.2096	.2096	.1715	.0953	.1524	.1334	.9602
23	.1905	.1905	.1334	.0953	.1334	.1334	.9717
24	1.0623	1.2651	1.25	1.0279	.0953	.1334	.1143
Max	1.9006	1.9364	1.8027	1.4754	1.5181	1.6288	.9717
Min	.1143	.1524	.0762	.0953	.0953	.1143	.0381
Avg	.6450	.7217	.7491	.8839	.5300	.6069	.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 205 / 11 KV Nimani Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2641	.2772	.2263	.2353	.2075
2	.2427	.2033	.2641	.2353	.2263	.2012	.1886
3	.2427	.2033	.2452	.2561	.2263	.2012	.1886
4	.2427	.2195	.2641	.2561	.2263	.2218	.2263
5	.2801	.2195	.3018	.2715	.2452	.2534	.2829
6	.3921	.3077	.3772	.2896	.3206	.2896	.3772
7	.2957	.3801	.3174	.3511	.3395	.3258	.3734
8	.2715	.2561	.2743	.2534	.2587	.2743	.2378
9	.2195	.2353	.2328	.2172	.2172	.1595	.2012
10	.2172	.1991	.1753	.197	.1433	.1629	
11	.2172	.1791	.1949	.1753	.1433	.1991	.1629
12	.2195	.2126	.2303	.1991	.1463	.2149	.1402
13	.2126	.2103	.2534	.197	.1448	.2149	.1433
14	.2126	.2229	.2534	.2172	.1646		.1448
15	.2172	.2629	.2534	.2172		.2303	.1829
16	.2172	.2303	.2328	.2507	.0362	.2279	.2149
17	.2195	.2103	.2561	.2172	.2172	.2328	
18	.2378	.2328	.2534	.2534	.2172	.2507	.197
19	.3292	.2926	.2926		.2534	.2926	.2172
20	.4066	.3326	.3841	.3292	.362	.3292	.4024
21	.4066	.3881	.3696	.439	.3658	.2957	.3658
22	.3658	.3734	.3258	.2987	.3326	.2614	.3292
23	.3258	.3174	.3109	.2263	.2926	.2427	.2772
24	.2801	.2772	.2829	.2743	.2263	.2012	.2263
Max	.4066	.3881	.3841	.439	.3658	.3292	.4024
Min	.2126	.1791	.1753	.1753	.0362	.1595	.1402
Avg	.2714	.2587	.2754	.2565	.2318	.2399	.2403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0867	.0943	.0634	.0629	.061	
2	.061	.0867	.0943	.0533	.0629	.0381	
3	.0579	.08	.0734	.0503	.0629	.0457	
4	.0533	.08	.0734	.0503	.0734	.0686	
5	.0503	.0867	.0943		.0734	.0503	
6	.0532	.0867	.0943		.0838	.0617	
7	.0566	.0671	.0838		.0838	.1017	
8	.0703	.112	.0734		.0629	.1109	
9	.0772	.1132	.0734		.0734	.1294	
10	.108	.1715	.0943		.0838	.1698	
11	.1219	.181	.132		.1509	.1524	.2054
12	.1581	.2353		.1267	.2033	.2033	.2353
13	.1526	.2353	.1698	.1991	.2054	.2012	.2427
14	.1734	.2534	.1698	.2353	.2427	.1848	.2328
15	.1406	.2534	.2427	.181	.1698	.1715	.2012
16	.1067	.2534	.2218	.2172	.1698	.1334	.1509
17		.181	.1663	.2353	.1509	.132	.1509
18		.1267	.1307	.2172	.1294	.1097	.132
19	.1067	.1086	.1294	.2172	.132	.132	.132
20	.0867	.1448	.112		.1307	.0895	.132
21	.0747	.1991	.1109		.1494		.1524
22	.08	.1629	.1097		.132		.1307
23	.088	.1629	.064		.0634		.132
24	.1029	.088	.1629	.0634	.1086	.0566	
Max	.1734	.2534	.2427	.2353	.2427	.2033	.2427
Min	.0503	.0671	.064	.0503	.0629	.0381	.1307
Avg	.0930	.1482	.1205	.1469	.1192	.1145	.1716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9568	.9282	.9717	.6009	.1296	.1402	.0351
2	.945	.9717	.9717	.5624	.1134	.1029	.0354
3	.945	.9717	.9717	.5624	.1134	.1109	.0354
4	.9145	1.0202	.9717	.5864	.1134	.1063	.0358
5	.9722	1.0562	.9717		.1134	.1448	.0549
6	1.2029	1.1043	1.247		.1619	.2054	.0549
7	1.3426	1.2811	1.4575		.1457	.1829	.0709
8	1.4198	1.3599	1.4899		.1781	.181	.0324
9	1.358	1.3757	1.3765		1.2308	1.2334	.0335
10	.1734	.1029	.0972		1.4089	1.4899	.0362
11	.1463	.1086	.1848		1.5384	1.6324	.0509
12	.1463	.181		.543	1.4548	1.5844	.1267
13	.1629	.1991	.1629	1.9909	1.4243	1.5181	.1612
14	.1463	.1991	.1612	2.0814	1.4091	1.3283	.1612
15	.1463		.1578	1.9909	1.2492	1.2803	.1595
16	.1448	.1991	.156	1.8642	1.1873	1.2346	.1772
17		.1991	.1595	1.3756	.1417	.1629	.1387
18		.2353	.1629	.2172	.1214	.0693	.1187
19	.1463	.2353	.1663	.181	.1772	.0328	.1928
20	.1829	.2172	.1463		.1663	.0526	.181
21	.1478	.1991	.128	.1991	.168	.0354	.1646
22	.1478	.1991	.1294	.1448	.1663	.0347	.9231
23	.1478	.181	.128	.1448	.1478	.0347	.9602
24	.759	.9282	.8145	.6167	.1448	.1448	.0347
Max	1.4198	1.3757	1.4899	2.0814	1.5384	1.6324	.9602
Min	.1448	.1029	.0972	.1448	.1134	.0328	.0324
Avg	.5752	.5849	.5732	.8539	.5502	.5435	.1656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5912				.1326
2			1.8233				.1326
3			1.7901				.1311
4			1.8233				
5			1.9227			.2155	.1311
6	1.7269		1.989	.8192		.2486	.1326
7	2.2969	2.1125	2.4531	1.1934	.2622	.2652	.1326
8	2.2634	2.4813		1.3108	.2622	.3149	.1326
9	2.5149	2.42		1.2125	1.4586	2.0885	.1658
10		.1638			1.8945	2.652	
11					2.2298	1.5912	.1492
12	.2591			2.0454			.2486
13					2.0287	2.5526	
14		.2622				1.5581	.3315
15		.2949		2.2801	1.9113	1.5912	.2321
16		.3277			1.9616		.2155
17		.3315			.2155		
18		.3315				.2294	.3149
19	.3441	.3978			.3315	.1311	
20		.3932			.3315	.1638	.2818
21		.3605			.2486	.1638	.2818
22		.3605				.1658	1.7101
23		.2984		.2241	.2515	.1326	1.861
24	1.3748	1.5083	1.4918	1.1797	.208	.2486	.1326
Max	2.5149	2.4813	2.4531	2.2801	2.2298	2.652	1.861
Min	.2591	.1638	1.4918	.2241	.208	.1311	.1311
Avg	1.5400	.8029	1.8606	1.2832	.9711	.8419	.3605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0476				.0594
2			.0457				.0625
3			.0438				.0686
4			.0457				.0686
5			.0438			1.4586	.0343
6	.0419		.0587	.056		1.8896	.0686
7	.057	.0503	.064		2.1216	2.0388	.0594
8	.0692	.0754		.0732	.0497	.0594	.0274
9	.0648	.0846		.0774	.0648	.0594	1.6907
10		.0724			.0838	.0526	
11		2.4985			.0591	.0945	1.989
12	2.1548	2.4985		.0713		.0754	2.1714
13		2.5526			.0572	.0854	
14		1.9227				.0732	1.989
15		2.0553		.0705	.0594	.0572	1.989
16		2.1216			.0629	.104	1.9725
17		2.3205			.0966	.0854	
18		2.1879				.096	.0823
19	.1389	.0869			.0907	.0629	.0823
20		.0774			.0667	.0533	.0572
21		.072			.0613	.0476	.0572
22		.064				.0617	.044
23		.0663		1.3108	1.4255	.0305	.0457
24	.0446	.0457	.0438	.0438	1.3603	1.4586	.0297
Max	2.1548	2.5526	.064	1.3108	2.1216	2.0388	2.1714
Min	.0419	.0457	.0438	.0438	.0497	.0305	.0274
Avg	.3673	1.0474	.0491	.2433	.4043	.3972	.6023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1702				.0732
2			1.2018				.0732
3			1.2018				.0732
4			1.2334				.0724
5			1.2803			.1143	.0739
6	1.3123		1.3763	.6325		.1132	.1086
7	1.4864	1.7394	1.6004	.7773	.112	.1109	.0701
8	1.5684	1.8976		.8962	.0747	.1402	.0693
9	1.5043	1.7394		.9602	1.2651	1.6324	.0678
10		.1052			1.4723	1.8138	
11		.112			1.5364	1.8564	.1029
12	.0732	.112		1.7604		1.8122	.1029
13		.1109				1.781	
14		.112				1.8564	.1387
15		.1109		1.7604	1.5546	1.8244	.1402
16		.1086			1.4998	1.7284	.1052
17		.0732			.1417	.0972	
18		.1109				.096	.1006
19	.1478	.1417			.1448	.0709	.1433
20		.1478			.1494	.0724	.1448
21		.1494			.1494	.1086	.1448
22		.1848				.0732	.9686
23		.112		.1109	.1132	.0732	.9686
24	1.1984	1.1069	1.166	1.012	.0732		.0724
Max	1.5684	1.8976	1.6004	1.7604	1.5546	1.8564	.9686
Min	.0732	.0732	1.166	.1109	.0732	.0709	.0678
Avg	1.0415	.4542	1.2788	.9887	.6374	.8092	.1817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.3951				2.4897
2			3.3951				2.4897
3			3.3951				2.4897
4			3.3951				2.4897
5			3.3951			3.0864	2.4897
6	3.3951		3.3951	3.3608		3.0864	2.9424
7	3.2819	3.0556	3.1687	3.0556	3.1687	2.8578	2.9424
8	3.0556	2.8292		2.9127	2.9424	2.8292	2.8292
9	2.8006	2.7161		2.8292	2.8292	2.6029	2.7161
10		2.8006			2.8292	2.9424	
11		3.0247			3.2487	3.1367	3.4728
12	3.2819	3.3608		3.8809		3.4374	3.3608
13		3.5848			3.0556	3.4728	
14		3.6969				3.3951	3.2487
15		3.9209		3.8089	3.5848	3.3951	3.4728
16		4.145				3.5848	3.4728
17		3.9209			3.9209	3.3608	
18		3.5848				3.2487	3.3951
19	3.5082	3.9209			3.8089		3.3951
20		4.3004			3.9609	3.3951	3.6214
21		3.9609			3.9609	2.1502	3.5082
22		3.7346				3.2819	3.5437
23		3.6214		3.658	3.5437	3.2819	3.315
24	3.7723	3.315	3.6214	3.5848	3.658	3.4294	3.0556
Max	3.7723	4.3004	3.6214	3.8809	3.9609	3.5848	3.6214
Min	2.8006	2.7161	3.1687	2.8292	2.8292	2.1502	2.4897
Avg	3.2994	3.5274	3.3951	3.3864	3.4240	3.1566	3.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.3146
Max	1.3146
Min	1.3146
Avg	1.3146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV KASABE DIGRAJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.4706	.679	.6984	.5658	.5093	.3801
2	.6224	.4706	.679	.6984	.5658	.5093	.3801
3	.6224	.4706	.679	.6984	.5658	.5093	.3801
4	.679	.4706	.679	.6984	.6413	.5281	.3801
5	.7167	.4706	.6979	.6984	.6413	.547	.4298
6	.547	.4525	.679	.6447	.6413	.679	.4119
7	.7167	.4525	.6413	.591	.6036	.6036	.4163
8	.5281	.4344	.6413	.4163	.6036	.6602	.5373
9	.3961	.4525	.6413	.3841	.5281	.6602	.5784
10	.4887	.7922	.5415	.3696	.7059	.4527	.4835
11	.6268		.6908	.4251	.6516	.7095	.5658
12	.691	.7922		.4251	.4706	.7095	.5847
13	.6024	.6602	.6535	.5914	.4525	.7282	.5093
14	.691	.6413	.6908	.7023	.7011	.6161	.3584
15	.6024	.679	.8029	.7207	.5609	.6535	.679
16	.4835	.6036	.8029	.5544	.5959	.6722	.5847
17		.7922	.4668	.7392	.4607	.5041	.4338
18		.6602	.5792	.7095	.6348	.439	.4294
19	.5792		.7362	.6161	.4527	.6984	.6908
20	.6089	.8299	.7537	.7468	.5847	.7265	.7468
21	.591	.8488	.7265	.5041	.5847	.7362	.8402
22	.591	.811	.7265	.8402	.5658	.4477	.7468
23	.5373	.811	.6984	.679	.6413	.4163	.679
24	.6602	.4887	.7545	.7343	.7733	.5281	.3801
Max	.7167	.8488	.8029	.8402	.7733	.7362	.8402
Min	.3961	.4344	.4668	.3696	.4525	.4163	.3584
Avg	.6002	.6161	.6800	.6202	.5914	.5935	.5253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1109	.132	.0747	.2652	.2374	.2012
2	.0943	.1109	.132	.0747	.2652	.2374	.2012
3	.0943	.1109	.132	.0747	.2652	.2374	.2012
4	.0943	.1109	.132	.0747	.2652	.2374	.2012
5	.0943	.1109	.132	.0747	.2652	.2374	.2012
6	.0943	.1109	.132	.0747	.2652	.2374	.2378
7	.0943	.1109	.132	.0934	.2652	.2543	.2561
8	.0943	.0924	.132	.0934	.0566	.0754	.056
9	.0943	.0924	.0943	.0747	.0566	.0754	.2881
10		.0943	.0943	.0566	.056	.0566	.3561
11	.9012		1.0802	.0754	.056	.0566	.3561
12	.9393	.9431		.0754	.056	.0566	.3561
13	.9122	1.0117	1.0288	.0754	.056	.0754	.373
14	.9442	1.0117	1.0631	.0566	.056	.0754	.373
15	.9646	.9774	1.0802	.0566	.056	.0754	.3561
16	.9282	.8916	1.046	.0754	.056	.0754	.3391
17		.8916	1.0631	.0566	.056	.0566	.0566
18		.9774	.9555	.0566	.0566	.0747	.0566
19	.0747	.0943	.1307	.0566	.0566	.056	.0566
20	.1109	.1698	.1307	.0566	.0754	.0747	.0754
21	.1109	.1698	.0747	.0566	.0754	.0747	.0566
22	.1294	.1698	.0747	.2774	.2543	.1844	.0566
23	.1109	.1698	.0747	.2486	.2543	.2054	.0566
24	.0943	.1294	.1509	.2462	.2652	.2374	.2054
Max	.9646	1.0117	1.0802	.2774	.2652	.2543	.373
Min	.0747	.0924	.0747	.0566	.056	.056	.056
Avg	.3366	.3766	.3999	.0932	.1440	.1360	.2072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1991	.1886	.197	.1698	.1886	.1829
2	.1886	.1991	.1886	.197	.1698	.1886	.1829
3	.1886	.1991	.1886	.197	.1698	.3395	.1829
4	.2075	.1991	.1886	.197	.1698	.1886	.1829
5	.2075	.2353	.1886	.3045	.1698	.1886	.1991
6	.2801	.3077	.2829	.3045	.2614	.3018	.2896
7	.2427	.2896	.2641	.2328	.2427	.2829	.2715
8	.2054	.2534	.2452	.2328	.2241	.2452	.2378
9	.2054	.2353	.2641	.2172	.2054	.1886	.2378
10		.2772	.2987	.2829	.2801	.2427	.3018
11	.2378		.2801	.2641	.2054	.2241	.2075
12	.2012	.2427		.2452	.2054	.2241	.1886
13	.2172	.2801	.2987	.2587	.0934	.2054	.2263
14	.2353	.2427	.2614	.2507	.056	.2054	.2263
15	.1991	.2829	.2427	.2241	.2715	.2241	.2075
16	.181	.2241	.2427	.2241	.1991	.2241	.2263
17		.2427	.2614	.2427	.2353	.2241	.1886
18		.2801	.2715	.2614	.0747	.2378	.2241
19	.2896	.2987	.2561	.2987	.0754	.2743	.2427
20	.3258	.3206		.3174	.3395	.2926	.2801
21	.3077	.3395	.2896	.2427	.3395	.2561	.2801
22	.2896	.3206	.3045	.2427	.2641	.2561	.2801
23	.2715	.2829	.2686	.2427	.2641	.2378	.2614
24	.2075	.1991	.2075	.197	.1698	.2641	.1829
Max	.3258	.3395	.3045	.3174	.3395	.3395	.3018
Min	.181	.1991	.1886	.197	.056	.1886	.1829
Avg	.2323	.2588	.2492	.2448	.2023	.2377	.2288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0754	.0747	.7125	.8381	.1781
2	.0754	.0747	.0754	.0747	.7045	.8223	.1781
3	.0754	.0747	.0754	.0747	.7045	.8223	.1781
4	.0754	.0747	.0754	.0747	.7045	.8223	.1781
5	.0754	.0747	.0754	.0934	.7045	.8223	.1781
6	.0754	.0747	.0754	.0747	.7701	.8124	.1619
7	.1132	.0934		.0934	.8029	.8592	.1781
8	.1132	.112	.0943	.112	.0754	.0943	.056
9	.1132	.112	.0754	.1307	.0754	.1132	.4321
10	.112	.0943	.1132	.0943	.0934	.1132	.5441
11	1.7736		2.1874	.1132	.0934	.0943	1.1822
12	1.8842	2.0687		.1132	.112	.0754	1.3603
13	1.8785	2.1365	2.1195	.1132	.0934	.0754	1.247
14	1.7976	2.1195	2.0178	.1132	.0747	.0754	.9069
15	1.7328	2.0517	2.0687	.112	.0747	.0566	1.2146
16	1.6518	1.9161	2.0348	.1307	.0747	.0943	1.1984
17	1.6518	1.8991	1.8821	.112	.112	.0754	.0943
18		1.8482	1.757	.0943	.0754	.0934	.0754
19	.112		.0934	.0754	.0754	.0747	.0754
20		.0943	.0934	.0754	.0943	.056	.0754
21	.0924	.0943	.0934	.0754	.0943	.056	.0754
22	.0924	.0943	.0747	.8124	.9835		.0754
23	.0924	.0754	.0747	.7611	.9069	.1781	.0754
24	.0754	.0934	.0754	.0747	.7125	.8482	.1781
Max	1.8842	2.1365	2.1874	.8124	.9835	.8592	1.3603
Min	.0754	.0747	.0747	.0747	.0747	.056	.056
Avg	.6245	.6978	.6958	.1531	.3719	.3466	.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV VASANT LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1802	.3018	.1254	.0754	.0566	.0514
2	.1802	.3018	.1254	.0754	.0566	.0514
3	.1966	.3018	.1433	.0754	.0566	.0514
4	.213	.3018	.1433	.0754	.0566	.0514
5	.2294	.3018	.1612	.0754	.0566	.0514
6		.3395	.2149	.0754	.1698	.0514
7	.2622	.3395	.2149	.0943	.1509	.1509
8	.2949	.3395	.2149	.2075	.2075	.1677
9	.3239	.3772	.2149	.2075	.3961	.1619
10		.3772	.2829	.197	.3018	.1619
11		.3772	.3018	.197	.2829	.2452
12	.3547		.2829	.197	.2829	.2263
13	.3584	.3772	.3018	.197	.2829	.2263
14	.3584	.3772	.3206	.197	.2641	.132
15	.3547	.3584	.3206	.1791	.2641	.2263
16	.3174	.2829	.3206	.1791	.2641	.2263
Max	.3584	.3772	.3206	.2075	.3961	.2452
Min	.1802	.2829	.1254	.0754	.0566	.0514
Avg	.2788	.3370	.2306	.1441	.1969	.1396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0187	.0162	.016
2					.0187	.0162	.016
3					.0187	.0162	.016
4					.0187	.0162	.016
5					.0187	.0162	.016
6					.0187	.0162	.016
7					.0187	.0162	.16
9							.0164
10							.0164
11	.0324	.0324	.0373				.0164
12	.0324	.0324					.0164
13	.0324	.0324	.0373				.0164
14	.0324	.0324	.0373				.0164
15	.0324	.0324	.0373				.0164
16	.0324	.0324	.0373				.0164
17		.0324	.0373				
18			.0373				
22				.0373	.0162	.016	
23				.0187	.0162	.016	
24					.0187	.016	
Max	.0324	.0324	.0373	.0373	.0187	.0162	.16
Min	.0324	.0324	.0373	.0187	.0162	.016	.016
Avg	.0324	.0324	.0373	.028	.0182	.0161	.0258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 KV PWV BRAMHNAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.0716	.0358	.056	.0373	.0366	.0002
2	.1417	.0716	.0358	.0549	.0373	.0366	.0002
3	.1417	.0543	.0543	.056	.0373	.0366	.056
4	.1448	.0543	.0543	.056	.0373	.0366	.056
5	.1448	.0914	.0543	.056	.0934	.0366	.056
6	.1448	.1097	.0537	.056	.0934	.0905	.0754
7	.1448	.1097	.0716	.056	.0934	.0895	.0754
8	.1463	.1097	.0895		.0934	.0905	.0943
9	.1463	.1227	.0886		.0934	.0905	.0943
10	.1578	.128	.0895	.0747	.0895	.0905	.0943
11	.0526	.1254	.1075	.0934	.0895	.0905	.0943
12	.0537	.0895		.0934	.0895	.0905	.0566
13	.0537	.0895	.0905	.0934	.0895	.1086	.0377
14	.0537	.0895	.0905	.0934	.0895	.1086	.0377
15	.0537	.0537	.0905	.0934	.0537	.0716	.0377
16	.0537	.0537	.0905	.0934	.0537	.0716	.0377
17		.0537	.0724	.0747	.0537	.0724	.0377
18		.0549	.0724	.0747		.0724	.0377
19	.0189	.0537	.0549	.0747	.0366	.0724	.0377
20	.0189	.0537	.0549		.0366	.0724	
21	.0189	.0537	.0549	.0373	.0366	.0019	.0377
22	.0189	.0537	.0549	.0373	.0366	.0002	.0377
23	.0754	.0537	.0549	.0373	.0362	.0002	.0377
24	.0732	.0358		1.3716	.0373	.0002	
Max	.1578	.128	.1075	1.3716	.0934	.1086	.0943
Min	.0189	.0358	.0358	.0373	.0362	.0002	.0002
Avg	.0909	.0766	.0689	.1302	.0628	.0612	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV EXPRESS LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3511	.1867	.3361	.2241	.1097
2	.3142	.3511	.1867	.3361	.2241	.1097
3	.3142	.3734	.1867	.3361	.2241	.1097
4	.3361	.3734	.181	.3361	.2241	.1097
5	.3361	.3734	.1867	.3361	.2241	.1097
6	.3361	.3734	.1867	.3361	.2241	.1097
7	.3361	.3734	.1734	.3361	.2241	.3361
8	.3361	.3734		.3361	.3361	.3174
9	.3547	.3734		.3361	.3361	.3174
10	.3547	.3734	.3361	.3361	.3361	.3734
11	.3547	.3734	.3361	.3361	.3361	.3734
12	.1029		.3361	.3361	.3361	.3734
13	.3547	.3361	.3361	.3361	.1867	.3734
14	.3547	.3361	.3361	.3361	.3361	.3734
15	.3547	.3361	.3361	.3361	.3361	.3734
16	.3547	.3361	.3361	.3361	.3361	.3734
Max	.3547	.3734	.3361	.3361	.3361	.3734
Min	.1029	.3361	.1734	.3361	.1867	.1097
Avg	.3256	.3605	.2600	.3361	.2778	.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV YESHWANT EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4352	1.7718	1.6827	1.2403		.9568
2	1.4352	1.7718	1.6827	1.2403		.9568
3	1.4352	1.7718	1.701	1.2403		.9568
4	1.4352	1.7718	1.701	1.2894		1.0631
5	1.4529	1.7718	1.701	1.2894		1.0631
6	1.5947	1.8427	1.6827	1.2757		1.4175
7	1.5947	1.8427	1.701	1.4529	1.4175	1.4175
8	1.7718	1.7896		1.4529	1.5947	1.5238
9	1.7718	1.7896		1.5238	1.701	1.5415
10	1.7718	1.8073	1.0745	1.6301	1.701	.8859
11	1.7718	1.8073	1.7909	1.5592	1.701	1.5947
12	1.7718		.7164	1.4529	1.701	1.5947
13	1.7718	1.8099	1.7909	1.4529	1.701	1.6301
14	1.7718	1.8099	1.7909	1.5238	1.701	1.4883
15	1.7718	1.8099	1.7909	1.5238	1.701	1.4883
16	1.6301	1.8099	1.7909		1.2403	.4607
24			.6858			
Max	1.7718	1.8427	1.7909	1.6301	1.701	1.6301
Min	1.4352	1.7718	.6858	1.2403	1.2403	.4607
Avg	1.6367	1.7985	1.5522	1.4098	1.6160	1.2525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.0191	.0339		.0061	.0059
2	.3353	.0191	.0339		.0042	.0059
3	.3353	.0191	.0335		.0042	.0059
4	.3353	.0191	.0339		.0042	.0059
5	.3521		.0339		.0061	.0059
6	.3521		.0343		.0061	.0059
7	.3521	.0983	.3292		.0061	
8	.5316	.1475	.3292	.0187	.0061	.0061
9	.2572	.1475	.3292	.0187	.0061	.0156
10	.2743	.1492	.0914	.1715	.0061	.0156
11	.2774	.1526			.0061	.0156
12	.1029		.2561	.0061	.0061	.0164
13	.0857	.2401	.3292	.0061	.0061	.0156
14	.0857	.2401	.3292	.0061	.0061	.0156
15	.0857	.2427	.3292	.0061	.0061	.0156
16	.0857	.2427	.3292		.0061	.0156
Max	.5316	.2427	.3292	.1715	.0061	.0164
Min	.0857	.0191	.0335	.0061	.0042	.0059
Avg	.2615	.1336	.1904	.0333	.0057	.0111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV HARIPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1603	1.0159	1.0277	.9389	.0189	.0189	.0189
2	1.1603	1.0277	1.0159	.9116	.0189	.0189	.0189
3	1.1603	1.0277	1.0159	.9116	.0189	.0189	.0189
4	1.1603	.9995	1.0159	.8907	.0189	.0189	.0189
5	1.1603	1.0277		.8802	.0189	.0189	1.5278
6	1.1934	1.0608	1.1271	.8642	.0189	.0189	.0189
7	1.2929	1.0814	1.2763	.852	.0189	.0189	.0189
8	1.2944	1.1797	1.2431	.0189	.0189	.0189	.0189
9	1.3108	1.2125	1.2431	.7773	.5571	.6299	.0189
10	.0189	.0189	.0189	.8162	.6299	.6874	.0189
11	.0189	.0189	.0189	.8453	.663	.6882	.0189
12	.0189	.0189		.8453	.6554	.6802	.0189
13	.0189	.0189	.0189	.8453	.5735	.6401	.0189
14	.0189	.0189	.0189	.8383	.5801	.6554	.0189
15	.0189	.0189	.0189	.8288	.5636	.6226	.0189
16	.0189	.0189	.0189	.8002	.5535	.6009	.0189
17	.0189	.0189	.0189	.0189	.0189	.0189	.0189
18	.0189	.0189	.0189	.0189	.0189	.0189	.0189
19	.0189	.0189	.0189	.0189	.0189	.0189	.0189
20	.0189	.0189			.0189	.0189	.0189
21	.0377	.0189	.0377		.0189	.0189	.0189
22	.0189	.0189	.0189		.0189	.0189	.3125
23	.0189	.0189	.0189	.0189	.0189	.0189	.2968
24	1.1271	.9995	.9995	.9389	.0189	.0189	.0189
Max	1.3108	1.2125	1.2763	.9389	.663	.6882	1.5278
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.5126	.4540	.4862	.6609	.2116	.2295	.1056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 KV DUDHGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4902	.5281	.6299	.5304	.0189	.0187	.0189
2	.5182	.5281	.6299	.5243	.0189	.0187	.0187
3	.5121	.5281	.6299	.506	.0189	.0187	.0189
4	.4902	.5281	.6299	.547	.0189	.0187	.0185
5	.5506	.5281	.6299	.5407	.0189	.0187	.0187
6	.5376		.663	.5571	.0189	.0187	.0189
7	.5921		.5636	.5636	.0187	.0187	.0183
8	.6325		.5506	.0179	.0185	.0187	.0187
9	.7045	.0648	.5571	.6562	.6154	.6154	.0179
10		.0189	.0166	.6478	.6802	.583	.0187
11	.0187	.0189	.0183	.7042	.7125	.6478	.0187
12	.0187	.0185	.0179	.6882	.7287	.6958	.0187
13	.0187	.0185	.0181	.6882	.7125	.6802	.0187
14	.0187	.0187	.0181	.6962	.664	.663	.0187
15	.0187	.0187	.0177	.6554	.5992	.639	.0187
16	.0187	.0185	.0173	.663	.5668	.5921	.0187
17		.0187	.0177	.0185	.0187	.0173	.0175
18		.0185	.0181	.0187	.0187	.0183	.0171
19	.0187	.0185	.0183	.0187	.0187	.0187	.0171
20	.0187	.0189	.0189	.0189	.0187	.0185	.0171
21	.0187	.0189	.0187	.0189	.0187	.0187	.0171
22	.0187	.0189	.0189	.0189	.0187	.0187	.4428
23	.0187	.0189	.0189	.0187	.0187	.0189	.4321
24	.4961	.4961	.5967	.4915	.0189	.0187	.0187
Max	.7045	.5281	.663	.7042	.7287	.6958	.4428
Min	.0187	.0185	.0166	.0179	.0185	.0173	.0171
Avg	.2728	.1649	.2639	.4087	.2325	.2256	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV KAVATHE PIRAN

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3734	.3772	.3511	.3361	.3734	.3018
2	.3361	.3734	.3772	.3361	.3361	.3734	.3018
3	.3511	.3734	.3772	.3361	.3361	.3734	.3361
4	.3395	.3734	.3772	.3326	.3361	.3734	.3961
5	.4338	.3734	.415	.3361	.3395	.3734	.3696
6	.4715	.4108	.3395	.3696	.415	.4108	.415
7	.4108	.3921	.4108	.4108	.4108	.4108	.3961
8	.3511	.3734	.3395	.3361	.3734	.3547	.3696
9	.3658	.3174	.2987	.2987	.3395	.3174	.3109
10		.3395	.2987	.3395	.3174	.2507	.2743
11	.3511	.2896	.3258	.2987	.2987	.3224	.2772
12	.3326	.3395	.3439	.2987	.2614	.2896	.2926
13	.3142	.3395	.3475	.3395	.2614	.3511	.2957
14	.3174	.3326	.3547	.3395	.2614	.3658	.2926
15	.3174	.3326	.3547	.3772	.2614	.3361	.2957
16	.3174	.3361	.3734	.415	.3174	.3511	.2926
17		.2987	.3511	.2614		.3258	.3142
18		.2957	.3361	.3395	.3361	.3045	.3292
19	.5601	.4108	.3921	.415	.4108	.3841	.3475
20	.5228	.4854	.4294	.415	.5228	.4435	.4435
21	.5228	.4904	.4481	.4481	.4854	.4668	.4938
22	.4668	.4527	.4481	.4108	.4668	.4108	.4207
23	.4108	.4108	.3921	.3772	.4108	.3395	.3696
24	.3961	.3734	.3772	.3511	.3361	.3734	.3174
Max	.5601	.4904	.4481	.4481	.5228	.4668	.4938
Min	.3142	.2896	.2987	.2614	.2614	.2507	.2743
Avg	.3927	.3703	.3702	.3556	.3552	.3615	.3439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV KAVATHE PIRAN AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0004	1.0227	.9945	1.0117	.0095	.0076	.0133
2	1.0227	1.0227	1.0288	1.0513	.0091	.0076	.0133
3	.9945	1.0227	1.0288	1.0852	.0093	.0076	.0133
4	1.0343	1.0227	1.0288	1.0974	.0091	.0076	.0135
5	1.1317	1.0227	1.0631	1.1317	.0095	.0076	.013
6	1.153	.8215	1.0974	1.1191	.0111	.0076	.0131
7	1.1401	.8551	1.1191	1.1317	.0114	.0076	.013
8	1.17	.8551	1.1191	.0086	.0107	.0076	.0131
9	1.2003	.9724	1.1317	1.2003	1.0852	1.2548	.0128
10		.0095	.009	1.2689	1.2209	1.5261	.013
11	.0076	.0091	.0084	1.153	1.2209	1.3032	.013
12	.0076	.0095	.0084		1.2378	1.2717	.013
13	.0076	.0095	.0084	1.2887	1.2209	1.286	.013
14	.0076	.0091	.0084	1.2887	1.2039	1.2656	.013
15	.0076	.009	.0086	1.2689	1.17	1.2346	.013
16	.0076	.0091	.0084	1.1317	1.153	1.1869	.013
17		.009	.0086	.0099	.0076	.0086	.013
18		.0091	.0086	.0095	.0076	.0095	.013
19	.0076	.0093	.0088	.0095	.0076	.009	.013
20	.0076	.0099	.0088	.0097	.0076	.0091	.013
21	.0076	.0095	.0086	.0095	.0076	.009	.013
22	.0076	.0099	.0086	.0097	.0076	.0135	.823
23	.0076	.0097	.0086	.0091	.0076	.0137	.823
24	1.0513	1.0227	1.0174	1.0117	.0095	.0076	.0135
Max	1.2003	1.0227	1.1317	1.2887	1.2378	1.5261	.823
Min	.0076	.009	.0084	.0086	.0076	.0076	.0128
Avg	.5229	.4071	.4479	.7528	.4023	.4362	.0806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV SAMDOLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2801	.3018	.2054	.3018	.2614	.2452
2	.2587	.2801	.3018	.2054	.3018	.2614	.2263
3	.2772	.2801	.3018	.2054	.3018	.2614	.2614
4	.2614	.2801	.3018	.2054	.3018	.2614	.2195
5	.2801	.2801	.3018	.2241	.3018	.2614	.2402
6	.2427	.2987	.3018	.2427	.2614	.2614	.2614
7	.2218	.2427	.2614	.2427	.2614	.2427	.2452
8	.2054	.2054	.2241	.2241	.2241	.2241	.2218
9	.1886	.2241	.1867	.1991	.2614	.2241	.2054
10		.2263	.2614	.2195	.2241	.2241	.2263
11	.2241	.2614	.2772	.2614	.2427	.2507	.2241
12	.2427	.2641	.2614	.2614	.2427	.2427	.2241
13	.2427	.2641	.2987	.2987	.2241	.2303	.2427
14	.2427	.3018	.3361	.3018	.2054	.2715	.2427
15	.2427	.2987	.3174	.2987	.1867	.2587	.2241
16	.2427	.2987	.2987	.2987	.2614	.2126	.2054
17		.2987	.2987	.2614	.2614	.2641	.2054
18		.2534	.2957	.3395	.2614	.2033	.2241
19	.3734	.2987	.3361	.3395	.2987	.2743	.2452
20	.3547	.415	.3584	.3772	.3734	.3511	.3361
21	.3361	.415	.3547	.3734	.3547	.3142	.3361
22	.3174	.3772	.3395	.3395	.3361	.2801	.3018
23	.2987	.3395	.3018	.3018	.2987	.2641	.2641
24	.2801	.2801	.2987	.2801	.3018	.2614	.2587
Max	.3734	.415	.3584	.3772	.3734	.3511	.3361
Min	.1886	.2054	.1867	.1991	.1867	.2033	.2054
Avg	.2673	.2902	.2966	.2711	.2746	.2568	.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV SAMDOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.0187	.0189	.0189	.216	.4458	.2134
2	.0175	.0187	.0189	.0189	.216	.4458	.2321
3	.0171	.0187	.0189	.0189	.216	.4458	.213
4	.0173	.0187	.0189	.0189	.216	.4458	.2267
5	.0179	.0187	.0189	.0189	.216	.4458	.213
6	.0175	.0187	.0187	.0189	.1829	.4801	.2267
7	.0175	.0187	.0187	.0189	.25	.5144	.2713
8	.0177	.0187	.0187	.0189	.0183	.0187	.0173
9	.0173	.0187	.0187	.0189	.0181	.0187	.5083
10		.0187	.0187	.0189	.0183	.0162	.5316
11	1.4403	1.8625	1.9387	.0189	.0183	.0173	.543
12	1.5432	1.949	1.8656	.0189	.0183	.0177	.5194
13	1.5604	1.9342	1.8473	.0189	.0183	.0179	.5068
14	1.5604	1.8823	1.829	.0189	.0183	.0181	.5121
15	1.5604	1.7718	1.8296	.0189	.0183	.0177	.5175
16	1.5604	1.7013	1.7924	.0187	.0183	.0175	.5121
17		1.6651	1.6461	.0187	.0183	.0177	.016
18		1.576	1.5729	.0187	.0183	.0173	.0158
19	.0189	.0187	.0189	.0183	.0183	.0177	.0171
20	.0187	.0187	.0189	.0183	.0183	.0181	.0187
21	.0187	.0187	.0189	.0183	.0183	.0185	.0187
22	.0187	.0189	.0189	.2896	.4458	.2103	.0187
23	.0187	.0189	.0189	.2134	.4458	.2347	.0187
24	.0181	.0187	.0189	.0189	.2134	.4458	.2458
Max	1.5604	1.949	1.9387	.2896	.4458	.5144	.543
Min	.0171	.0187	.0187	.0183	.0181	.0162	.0158
Avg	.4521	.6101	.6093	.0382	.1197	.1818	.2556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV SHAURYA INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.0183	.112	.056	.0747	.0934	.0934
2	.132	.0183	.112	.056	.0747	.0934	.112
3	.1494	.0183	.1307	.056	.0747	.0934	.0943
4	.1509	.0183	.1307	.056	.0747	.0934	.112
5	.0943	.0183	.1494	.0373	.0747	.0934	.0754
6	.1307	.0183		.0373	.0747	.112	.1334
7	.037	.0183	.0747	.0373	.056	.0747	.0732
8	.0183	.0187	.0187	.0187	.0187	.0187	.052
9	.0175	.0187	.0747	.112	.1494	.1494	.1698
10		.112	.1494	.0934	.112	.132	.1307
11	.0183	.112	.1867	.1494	.0934	.1509	.1307
12	.0183	.0934	.1307	.1307	.056	.0724	.112
13	.0183	.0934	.1307	.112	.112	.1509	.112
14	.0183	.1494	.112	.112	.112	.1109	.112
15	.0183	.0747	.112	.112	.112	.1307	.112
16	.0183	.0934	.112	.112	.1307	.1334	.112
17		.0934	.0934	.0373	.1307	.1478	.112
18		.0934	.0747	.0934	.1307	.1509	.112
19	.0183	.0934	.0187	.0747	.1307	.1109	.112
20	.0183	.0187	.0187	.0747	.0934	.0934	.112
21	.0183	.0934	.0187	.0934	.0373	.1017	.112
22	.0187	.0934	.0187	.0934	.056	.0886	.0747
23	.0187	.0934	.0934	.112	.0934	.0549	.112
24	.0934	.0183	.1307	.0934	.0934	.0934	.0739
Max	.1509	.1494	.1867	.1494	.1494	.1509	.1698
Min	.0175	.0183	.0187	.0187	.0187	.0187	.052
Avg	.0560	.0621	.0958	.0817	.0903	.1060	.1066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 KV WARANA KATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6964	.0166	.6802	.547			
2	.6882	.7459	.6802	.5407			
3	.7127	.7459	.6802	.5407			
4	.7125	.7459	.6802	.5636			
5	.7293	.7701	.6802	.5571			
6	.7611	.7701	.7209	.5801			
7	.8162	.7865	.7537	.5735			
8	.8583	.7865	.7449				
9	.8718	.8029	.7293	.7625	.7865	.7287	
10				.7865	.7865	.7865	
11				.7865	.8288	.8848	
12				.8192	.8453	.8421	
13				.8288	.8288	.8684	
14				.8192	.7956	.8453	
15				.7865	.7373	.8288	
16				.8192	.7373	.7537	
22							.4915
23							.4915
24	.6802	.6796	.7449	.5243			
Max	.8718	.8029	.7537	.8288	.8453	.8848	.4915
Min	.6802	.0166	.6802	.5243	.7373	.7287	.4915
Avg	.7527	.685	.7095	.6772	.7933	.8173	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV BUDHGAON GAONTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.663	.6859		.7202	
2	.6859	.663	.6935		.7282	
3	.7011	1.1105	.6859		.7545	
4	.7087	.663	.7108		.7202	
5	.7011	.5801	.6859		.6935	
6	.7087				.6859	
7	.7011	.5801			.6859	
8	.5201				.6859	
9	.4973		.8402	.4641	.6859	.7202
10		.7127	.8402	.4641	.703	.7373
11		.7459	.7888	.6962	.7716	.823
12		.6962	.703	.5636	.9774	
13	.5316	.663	.8573	.4973	.6001	
14		.663	.7202	.5304	.6516	
15		.7459	.7716	.6464	.7373	
16		.7459	.8573		.7545	.7202
17		.7293	.823	.7459	.7716	
18		.4475		.6962		
19		.8619				
20		.9282				
21		.8453				
22		.8619				
23		.8288				
24	.7716	.7459	.6562		.6859	
Max	.7716	1.1105	.8573	.7459	.9774	.823
Min	.4973	.4475	.6562	.4641	.6001	.7202
Avg	.6557	.7372	.7547	.5894	.7230	.7502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV KALERAN (KAVALPUR) SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12		.1086		.2286	
2	.1214		.1086		.2315	
3	.12		.0905		.2743	
4	.12		.1029		.2778	
5	.1214		.1029		.3048	
6	.12					
7	.12				.3048	
8	.104				.0457	
9	.1029		.0867	.0457	.0457	.0914
10		.0995	.1214	.0514	.0457	.1067
11		.9448	1.1963	.0305	.0457	.0171
12		.9614	1.1317	.061	.061	.0914
13	.8916	.8785	.9774	.061	.061	.1524
14		.8785	.9602	.0457		
15		.9116	.9774	.0457	.061	
16		.9116	1.046		.061	.1372
17		.9448	1.1145	.0457	.0457	
18		.8619		.0457		
19		.0497				
20		.116				
21		.116				
22		.0995				
23		.0995				
24	.12		.1029		.2286	
Max	.8916	.9614	1.1963	.061	.3048	.1524
Min	.1029	.0497	.0867	.0305	.0457	.0171
Avg	.1874	.5624	.5485	.0480	.1452	.0994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV BISUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2241	.208		.2058	
2	.208	.2241	.2229		.2058	
3	.2229	.2241	.2229		.208	
4	.2229	.2241	.2254		.2058	
5	.2401	.1989	.2229		.1886	
6	.2279	.2241			.1715	
7	.1734	.2241			.1886	
8					.1543	
9	.1543		.1543	.1372	.1543	.12
10		.1372	.1715	.1372	.1543	.12
11		.1478	.1715	.12	.1543	.1029
12		.1543	.1715	.1372	.1543	.12
13	.1543	.1715	.1715	.1372	.1543	.12
14		.1886	.1886	.1543	.1715	
15		.1715	.1715	.1372	.1543	
16		.1715	.1715		.1715	.1543
17		.1543	.1886	.1543	.1543	
18		.1372		.0171		
19		.1886				
20		.3086				
21		.2572				
22		.2572				
23		.2572				
24	.2229	.2241	.2058		.2058	
Max	.2401	.3086	.2254	.1543	.208	.1543
Min	.1543	.1372	.1543	.0171	.1543	.1029
Avg	.2033	.2032	.1912	.1257	.1754	.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV BUDHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1658	.2572		.0514	
2	.3429	.1658	.2601		.052	
3	.3906	.1658	.2743		.0514	
4	.3858	.3315	.2601		.0526	
5	.4268		.2572			
6	.4268	.3315				
7	.4268	.4144			.0514	
8	.4687				.1543	
9	.4572		.0686	.0497	.1543	.0686
10		.0332	.0514	.0497	.2229	.0343
11		.0497		.0497	.2572	.0514
12		.0497	.0514	.0497	.2915	
13	.0457	.0497	.0686	.0497	.3258	
14		.0663	.0686	.0457	.3258	
15		.0497	.0514	.0305	.2572	
16		.0497	.0343		.2572	.0686
17		.0497	.0514	.0457	.0343	
18		.0663		.0457		
19		.0663				
21		.0663				
22		.0663				
23		.0663				
24	.0514	.0663	.2486		.0514	
Max	.4687	.4144	.2743	.0497	.3258	.0686
Min	.0457	.0332	.0343	.0305	.0343	.0343
Avg	.3389	.1185	.1431	.0462	.1619	.0557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV EXPRESS COLLEGE

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.052		.0366	
2	.1387		.0343		.0549	
3	.12		.0351		.0543	
4	.1372		.0343		.0532	
5	.1372		.0351		.0549	
6	.1372				.0354	
7	.1543				.0373	
8					.052	
9	.1734		.0686	.0514	.052	.0514
10		.0686	.0686	.0514	.0693	.0514
11		.0686	.0686	.0857	.052	.0857
12		.0686	.0686	.0686	.052	.0686
13	.0857	.0514	.0686	.0514	.052	.0686
14		.0686	.0686	.0514	.052	
15		.0686	.0686	.0514	.052	
16		.0686	.0686		.052	.0686
17		.0514	.0343	.0514	.0515	
18		.0514		.0514		
19		.0514				
20		.0514				
21		.0343				
22		.0343				
23		.0343				
24	.1543		.0514		.0343	
Max	.1734	.0686	.0686	.0857	.0693	.0857
Min	.0857	.0343	.0343	.0514	.0343	.0514
Avg	.1375	.0551	.0550	.0571	.0499	.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV JYPTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1029		.104	
2	.0747	.104		.0857	
3	.0747	.1029		.0867	
4	.1494	.1029		.1029	
5	.1494	.1029		.1029	
7	.1494			.1029	
8				.1029	
9		.1029	.0343	.1029	.0343
10	.2743	.1029	.0343	.0686	.0171
11	.2743	.1372	.0171	.0343	.0171
12	.1029		.0171	.1372	.0343
13	.1029	.1029		.1029	.0171
14	.1543	.1029	.0171	.1372	
15	.1372	.0857	.0171	.1372	
16	.0343	.0857		.0343	.0686
Max	.2743	.1372	.0343	.1372	.0686
Min	.0343	.0857	.0171	.0343	.0171
Avg	.1348	.1030	.0228	.0962	.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV BISUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514		.0373		.1543	
2	.0693		.052			
3	.0693		.0514			
4	.0867		.052			
5	.0867		.0514		.1829	
6	.0514				.2315	
7		.0934			.2286	
8					.0457	
9	.0693		.0686	.0497	.0457	
10		.0663	.0514	.0457	.0457	.1886
11		.9282	.2058		.0457	.2229
12		1.0774	.9431		.0305	.2229
13	.8745	.9945	.9431		.0305	.1715
14		.8619	1.0288		.0305	
15		.8288	.9945		.0305	
16		.8619	.9431		.0305	.2401
17		.8619	.9774	.0497	.0457	
18		.6962		.0497		
19		.0497				
20		.0497				
21		.0497				
22		.0497				
23		.0332				
24	.0343	.0663	.0332		.1219	
Max	.8745	1.0774	1.0288	.0497	.2315	.2401
Min	.0343	.0332	.0332	.0457	.0305	.1715
Avg	.1548	.4731	.4289	.0487	.0867	.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 KV DUDHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4108	.4294	.4108	.3734	.3921	.3547
2	.3921	.4108	.4294	.4108	.3734	.3734	.3547
3	.3921	.4108	.4294	.4108	.3734	.3734	.3547
4	.3921	.4108	.4294	.4108	.3734	.3734	.3547
5	.3921	.4481	.4294	.4108	.3921	.3921	.3921
6	.4481	.4481	.4108	.4294	.4108	.3734	.3734
7	.4108	.4108	.4294		.4481	.4294	.3921
8	.3547	.3547	.4108	.3547	.4108	.4481	.4294
9	.3174	.3734	.3734	.3361	.4108	.4108	.3734
10	.3734	.3734	.3734	.3547	.4108	.4668	.3921
11	.3734	.4481	.4108	.3547	.4668	.4668	.4481
12	.4108	.4294	.4108	.4294	.4481	.4481	.4481
13	.4108	.4294	.4108	.4668	.4481	.4854	.4668
14	.4294		.4294	.4668	.4481	.4763	.4481
15	.4108		.4481	.4668	.4481	.4854	.4668
16	.3921		.4481	.3734	.4481	.5228	.4668
17		.5228	.4481	.4481	.4481	.4854	.4668
18		.5041	.3921	.4108	.4481	.4294	.4668
19	.3547	.6161	.4668	.5041	.5601	.5601	.5041
20	.6161	.6535	.5041		.6161	.5041	.5601
21	.5601	.6161	.4481	.5415	.5228	.5228	.5415
22	.5415	.5788	.4481	.5228	.5601	.4481	.5041
23	.5041	.4854	.4481	.4294	.4481	.3921	.4294
24	.4108	.4294	.4481	.4108	.3921	.3921	.3547
Max	.6161	.6535	.5041	.5415	.6161	.5601	.5601
Min	.3174	.3547	.3734	.3361	.3734	.3734	.3547
Avg	.4218	.4650	.4294	.4252	.4450	.4438	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 KV SAWALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.2824	.4961	.3077
2	.0191	.0191	.0191	.0191	.2824	.4961	.3077
3	.0191	.0191	.0191	.0191	.2824	.4961	.3077
4	.0191	.0191	.0191	.0191	.2824	.4801	.3077
5	.0191	.0191	.0191	.0191	.2824	.4961	.3563
6	.0381	.0381	.0381	.0191	.3418	.5121	.3887
7	.0953	.0381	.0381		.3567	.5441	.502
8	.0381	.0381	.0381	.0381	.0191	.0191	.0381
9	.0191	.0381	.0191	.0191	.0191	.0191	.6958
10	.0191	.0381	.0191	.0191	.0191	.0191	.7432
11	1.3117	1.2651	1.3748	.0191	.0191	.0191	.8697
12	1.3279	1.2955	1.3904	.0191	.0381	.0191	.9014
13	1.2955	1.4089	1.2811	.0191	.0191	.0191	1.3441
14	1.3117	1.4089	1.1717	.0191	.0191	.0191	.8697
15	1.2146	1.3117	1.1561	.0191	.0381	.0191	.8065
16	1.1822	1.2955	1.2029	.0191	.0191	.0191	.759
17		1.3279	1.1498	.0191	.0191	.0191	.0381
18		1.3441	1.1498	.0191	.0191	.0191	
19	.0191	.0191	.0191	.0381	.0191	.0381	.0381
20	.0381	.0191	.0381	.0381	.0191	.0381	.0381
21	.0381	.0381	.0381	.0191	.0191	.0381	.0381
22	.0191	.0191	.0381	.3121	.4641	.3239	.0191
23	.0191	.0191	.0381	.2972	.4961	.3077	.0191
24	.0191	.0191	.0191	.0191	.2824	.4961	.3077
Max	1.3279	1.4089	1.3904	.3121	.4961	.5441	1.3441
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3682	.4616	.4298	.0464	.1524	.2072	.4349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 KV DHARAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0202	1.1271	1.094	.7125			
2	1.0202	1.1271	1.0774	.7125			
3	1.0202	1.1271	1.0608	.7125			
4	1.0202	1.1271	1.0608	.8097			
5	1.0526	1.1271	1.0774	.8745			
6	1.0688	1.1603	1.094	.8745			
7	1.1336	1.1768	1.0774				
8	1.166	1.2266	1.0442				
9	1.2289	1.1336	1.1105	1.1437	1.2763	1.3592	
10				1.2763	1.3117	1.3757	
11				1.3757	1.2955	1.3757	
12				1.4089	1.2631	1.2929	
13				1.3757	1.2955	1.2763	
14				1.3426	1.2955	1.2597	
15				1.3592	1.2955	1.1603	
16				1.326	1.2955	1.1271	
22							1.0277
23							1.0111
24	.9878	1.094	1.094	.7287			
Max	1.2289	1.2266	1.1105	1.4089	1.3117	1.3757	1.0277
Min	.9878	1.094	1.0442	.7125	1.2631	1.1271	1.0111
Avg	1.0719	1.1427	1.0791	1.0689	1.2911	1.2784	1.0194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 KV BAGANI ROAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0572	.6133	.583	.3077
2	.0381	.0381	.0572	.0572	.5138	.5668	.3077
3	.0381	.0381	.0572	.0572	.5138	.5668	.3077
4	.0381	.0381	.0572	.0572	.5138	.5668	.3077
5	.0381	.0381	.0572	.0572	.5138	.583	.3239
6	.0572	.0381	.0572	.0572	.5801	.583	.421
7	.0381	.0572	.0572		.6133	.6154	.4858
8	.0381	.0572	.0572	.0762	.0381	.0572	.0381
9	.0381	.0381	.0572	.0381	.0191	.0381	.6722
10	.0381	.0381	.0572	.0381	.0381	.0381	.6401
11	.7907	.9555	.9231	.0572	.0381		.7042
12	.8065	.9069	.9069	.0381	.0191	.0381	.7842
13	.8065	.9012	.8745	.0381		.0381	.7522
14	.8539	.8907	.9393	.0381	.0191	.0381	.7682
15	.8065	.8745	.8745	.0381	.0191	.0381	.7362
16	.7748	.8259	.8097	.0381	.0191	.0381	.6562
17		.7842	.8192	.0381	.0381	.0381	.0381
18		.7522	.502	.0381	.0381	.0381	.0381
19	.0381	.0572	.0762	.0572	.0572	.0572	.0381
20	.0572	.0762	.0572	.0381	.0572	.0572	.0572
21	.0572	.0572	.0381	.0381	.0572	.0381	.0572
22	.0572	.0762	.0381	.5596	.6154	.3401	.0381
23	.0572	.0572	.0381	.5304	.5992	.3077	.0381
24	.0381	.0381	.0572	.0762	.5304	.583	.3077
Max	.8539	.9555	.9393	.5596	.6154	.6154	.7842
Min	.0381	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.252	.3197	.3136	.0921	.2637	.2543	.3677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.7842	.7468	.5975	.5601	.2987
2	.8589	.7842	.7468	.5975	.5601	.2987
3	.8589	.7842	.7468	.5975	.5788	.2987
4	.8589	.7842	.7468	.5975	.5788	.2987
5	.8589	.8215	.7468	.6348	.5788	.2987
6	.8589	.8962	.7095	.6348	.6161	.5601
7	.8589	.9335		.6908	.6722	.6161
8	.8775	.8589	.7468	.7095	.6859	.6161
9	.9149	.9149	.7468	.7282	.7282	.6535
10	.9149	.9149	.7468	.7282	.7468	.6535
11	.9335	.9335	.7468	.7095	.7468	.6908
12	.9335	.8775	.7468	.7095	.7095	.6722
13	.9522	.8215	.7655	.7095	.7282	.7095
14	.9335	.8215	.7282	.7095	.7282	.7095
15	.9335	.8215	.7282	.6908	.7468	.7095
16	.9522	.4481	.7842	.7095	.7468	.7095
Max	.9522	.9335	.7842	.7282	.7468	.7095
Min	.8589	.4481	.7095	.5975	.5601	.2987
Avg	.8974	.8250	.7456	.6722	.6695	.5496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV NANDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.9808	1.0751	1.0374	1.0185	1.0242	.7922
2	.9145	.9619	1.0751	.9997	.9997	1.0164	.7922
3	.8779	.9619	1.0562	.9997	.9997	.8962	.7733
4	.8596	.9619	1.1128	.9997	.9979	.905	.7922
5	.8962	.9808	1.2136	1.0425	1.1576	.905	.8589
6	.9328	1.0242	1.1883	1.1088	1.1088	.9412	
7	.9694	1.0791	1.134	1.0903	1.1157	.9774	.9709
8	.8779	.9955	.9313	.9511	.8954	.9694	.0732
9	.8596	.905	.985	.6697	.8859	.8962	.823
10		.9709	1.0029	.9231	.8859	.9877	.9391
11	.8775	.8962	.9922	.9694	.7682	.9694	.8682
12	.8596	.9922	1.0985	1.1157	.9694	.9593	.8596
13	.9145	1.0029	1.1568	.0732	.8413	.9412	.8326
14	.8962	.9745	1.1043	.9328	.8779	.9134	.8326
15	.8779	1.0317	.9709	1.0059	.8779	.9036	.8413
16	.8779	1.0029	.9568	.9593	.8779	.9214	.5138
17	.7522	.8859	.9412	.905	.823	.9593	.7712
18	.823	.9114	.9231	.9709		.8688	.8328
19	1.0534	1.0745	1.1706				.9955
20	1.2752	1.2936			1.2254	1.1827	1.1458
21	1.2323	1.3256	1.2936	1.2437	1.1706	1.1203	1.0903
22	1.2136	1.2696	1.2752	1.2136	1.1888	.9979	1.0751
23	1.1694	1.1763	1.1576	1.1273	1.0974	.9149	.9997
24	1.0242	1.0562	1.094	1.0751	1.0751	1.0608	.8676
Max	1.2752	1.3256	1.2936	1.2437	1.2254	1.1827	1.1458
Min	.7522	.8859	.9231	.0732	.7682	.8688	.0732
Avg	.9575	1.0298	1.0830	.9734	.9935	.9666	.8409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0602	.0537	.0554	.0549	.2623	.2591	.1656
2	.0602	.0532	.0554	.0549	.2559	.2559	.1505
3	.061	.0709	.056	.0554	.2526	.2258	.1524
4	.061	.0709	.0747	.0554	.2559	.2439	.1524
5	.061	.0716	.0739	.0554	.2526	.2623	.2286
6	.061	.0724	.0739	.0549	.2591	.2591	.1635
7	.061	.0724	.1294	.0554	.2526	.2743	.1806
8	.0452	.0895	.1097	.0554		.0305	.0354
9	.0301	.0895	.0914	.0549	.0305	.0301	.2134
10		.0716	.0724	.0732	.0305	.2709	.2408
11	.571	.6859	.7011	.0732	.0301	.0301	.2439
12	.5182	.7407	.6554	.0732	.0301	.0509	.2439
13	.5053	.7316	.6944	.0732	.0301	.0514	
14	.4904	.6923	.6944	.0549	.0301	.0351	.2286
15	.5182	.6773	.6706	.0549	.1806	.0354	.2315
16	.5401	.6554	.6622	.0549	.0301	.0354	.2134
17	.571	.6554	.6472	.0549	.0301	.0532	.0339
18	.5639	.6249	.6401	.0503		.0358	.052
19	.052	.0848	.1402	.0497	1.0317	.0358	.0514
20	.0532	.0886	.0532		.0301	.0358	.0537
21	.0532	.1097	.0537	.0509	.0301	.0362	.0362
22	.0532	.0934	.0543	.2494	.2107	.1806	.0366
23	.0537	.0934	.0543	.2526	.2258	.1829	.037
24	.0602	.0537	.0747	.0549	.2559	.2439	.1829
Max	.571	.7407	.7011	.2526	1.0317	.2743	.2439
Min	.0301	.0532	.0532	.0497	.0301	.0301	.0339
Avg	.2219	.2793	.2745	.0746	.1817	.1314	.1447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV MALBHAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3353	.2932	.2469	.0739	.0554	.0754
2	.3668	.3395	.2968	.2469	.0739	.0537	.0754
3	.3227	.3395	.2968	.25	.0732	.0554	.0754
4	.2934	.3549	.2932	.25	.0732	.0554	.0754
5	.3081	.3658	.3048	.2656	.0732	.0554	
6	.3521	.381	.3125	.2623	.0724	.0739	.0754
7	.3814	.4365	.3506	.2778	.0724	.0924	.0739
8	.4108	.3864	.3913	.128	.0716	.1097	.0924
9	.3961	.4012	.3906	.4115	.176	.2559	.1294
10		.181	.1829	.4115	.176	.2709	.1086
11	.2149	.2561	.1829	.4268	.1656	.2709	.1075
12	.2033	.2561	.1463	.4115	.1806	.2675	.1063
13	.2054	.2218	.1629	.4115	.1806	.2709	.0716
14	.1867	.2218	.1629	.3353	.1957	.2591	.0701
15	.168	.2012	.1463		.1806	.2439	.0876
16	.1478	.2012	.1463	.3048	.1806	.2286	.104
17	.1433	.2012	.1463	.181	.052	.0914	.124
18	.1991	.1848	.1463	.1109		.0739	.0895
19	.1448	.1307	.1463		.0867	.0554	.0895
20	.1463	.112	.112		.0867	.0739	.0709
21	.128	.112	.1109	.0924	.0867	.0739	.0716
22	.1294	.1132	.1109	.1109	.4251	.0747	.2035
23	.1294	.1494	.0926	.1109	.0924	.0754	.1875
24	.4251	.3506	.3125	.2778	.1097	.0739	.0754
Max	.4251	.4365	.3913	.4268	.4251	.2709	.2035
Min	.128	.112	.0926	.0924	.052	.0537	.0701
Avg	.2502	.2597	.2183	.2631	.1286	.1338	.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.462	.4572	.4854	.462	.4481	.4527
2	.4435	.439	.439	.4668	.4435	.4435	.3881
3	.439	.4344	.439	.4435	.439	.4656	.3658
4	.439	.4854	.4854	.4435	.439	.4706	.3734
5	.4854	.5175	.5228	.4572	.4854	.4854	.462
6	.5228	.5415	.5415	.4668	.5041	.5601	.5228
7	.499	.499	.5359	.4805	.4805	.5121	.4435
8	.4835	.4706	.4938	.4163	.4066	.3658	.4066
9	.4525	.4508	.4656	.4031	.3841	.4024	.4075
10	.4252	.4161	.4607	.5895	.3506	.4119	.3721
11		.4334	1.262	.3988		.4382	.3988
12		.4334	.5258	.3814		.4207	.3772
13		.4961	.4835	.4477		.4119	.3506
14		.4706	.4887	.4656	.5973	.439	.3601
15		.4835	.4706	.4382	.4887		.3814
16		.4656	.4784	.3467		.4572	.4207
17			.5373	.3721		.4706	.4458
18	.6379		.5596	.4557		.5014	.4961
19	.6089	.8149	.6068			.5194	.4908
20	1.1523	.7602				.5194	.6241
21	.6653	.6584	.5959		.6154	.5373	.6068
22	.6468	.5609	.543		.5729	.5068	.5487
23	.6036	.5788	.5611		.5415	.4706	.5175
24	.5228	.5175	.5175	.4854	.4557	.4668	.4938
Max	1.1523	.8149	1.262	.5895	.6154	.5601	.6241
Min	.4252	.4161	.439	.3467	.3506	.3658	.3506
Avg	.5582	.5177	.5422	.4444	.4791	.4663	.4461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 KV TUKAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0914	.0924	.0924	.3048	.2201	.1467
2	.0914	.0914	.0924	.0934	.3048	.2317	.1429
3	.0934	.0924	.0914	.0754	.3086	.2494	.1738
4	.0934	.0924	.0895	.0739	.3437	.2317	.1932
5	.1109	.1109	.1097	.0739	.3658	.2743	.1806
6	.1294	.1463	.1097	.0914	.4115	.301	.2286
7	.1307		.1294	.1086	.4268	.4489	.2675
8	.1097	.1417	.1097	.128	.0926	.0895	.0895
9	.1086	.1075	.0905	.1063	.0926	.0686	.2378
10	.1086	.0983	.1086	.1052	.0716	.0686	
11	.7783	1.0185	.9217	.0693	.0905	.0867	.2824
12		.9568	1.0669	.1227		.104	.2743
13		1.0212	1.034	.1075	.0867	.0867	.2286
14		.9031	1.1222	.1063	.0895	.0709	.2439
15		.7628	1.0185	.0876	.0905	.0876	.2629
16		.7859	.9659	.1075	.0905	.1063	.2439
17		.9907	.8802	.0876	.1075	.104	.0617
18		.9602	.8322	.0867	.0905	.1254	.0772
19	.1417	.1267	.1075	.104	.0914	.1227	.0819
20	.1433	.1478			.1109	.1254	.0819
21	.1267	.1463	.1075		.0934	.2591	.1006
22	.1294	.1478	.1097		.2824	.2229	.1097
23	.128	.1294	.0934		.2591	.2107	.0924
24	.1097		.1294	.1109	.3048	.2462	.1635
Max	.7783	1.0212	1.1222	.128	.4268	.4489	.2824
Min	.0914	.0914	.0895	.0693	.0716	.0686	.0617
Avg	.1544	.4123	.4092	.0969	.1961	.1726	.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.381	.4572	.3704	.0739	.1294	.1267
2	.6859		.4572	.4115	.0732	.128	.1086
3	.6687	.4572	.5401	.4572	.0732	.1402	.1109
4	.743	.463	.6173		.0924	.1294	.1494
5	.9259	.5487	.6859		.0934	.1494	.1267
6	.9907	.6097	.7621		.0924	.168	.1494
7	1.0669	.884	.8383		.1097	.2012	.1663
8	1.153	1.0974	1.0212		.1109	.2054	.1463
9		1.1126	.884		.1187	.4607	.1086
10	.1267	.144	.1663		.1204	.5201	.0857
11	.1734	.2033	.2054	.4725	.1174	.5428	.0857
12	.1734	.2218	.2195	.5944		.5357	.0857
13	.1629	.2033	.2241	.463	.0753	.4311	.0867
14	.1867	.197	.2033	.463	.1143	.4115	.0876
15	.2054	.1848	.2241	.5093	.1189	.3715	.1052
16	.2241	.2402	.2195	.5468		.4115	.0857
17	.2241	.2378	.2353	.1543		.128	.104
18	.1829	.2561	.2587	.156		.1254	.1214
19	.2033	.2743	.2187	.156			.1227
20	.2054	.2772				.1227	.132
21	.2218	.2561	.208		.2054	.1402	.124
22	.2402	.2614	.192		.1478	.1254	.1067
23	.2195	.2427	.2056		.1478	.1254	.1543
24	.5552	.3277	.3963	.3395		.1478	.1075
Max	1.153	1.1126	1.0212	.5944	.2054	.5428	.1663
Min	.1267	.144	.1663	.1543	.0732	.1227	.0857
Avg	.4419	.3948	.4104	.3918	.1109	.2544	.1162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 400 / STATION TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	04-JUN-18
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7602	.8048		.695	.7602	.6584
2	.7316	.724	.7682	.6335	.6653	.724	.6584
3	.6401	.6878	.7762	.5853	.6283	.6878	.6219
4	.5914	.6697	.7762	.5121	.5975	.6516	.6154
5	.5914	.6878	.7682	.5175	.5975	.6154	.6219
6	.6283	.6697	.7316	.5914	.5975	.5792	.6584
7	.6653	.7059	.7392	.6584	.7316	.6154	.6584
8	.7316	.6878	.7316	.724	.695	.6516	.695
9	.7316	.724	.7316	.7602	.724	.695	.6697
10	.8954	.815		.8326	.788	.7316	.7602
11	.8688	.9955		.9955	.9511	.8326	.9593
12	.905	.9412	1.1584	1.0136	.9774	.8596	.9955
13	.9412	.9955	1.1222	1.0136	.9412	.8059	.8869
14	.9412	.9955	1.0974	1.0136	.924	.8059	.8688
15	.9412	1.0136	1.0974	1.086	.924	.8413	.9231
16	.9877	.9774	1.0974	1.0498	.9511		.9231
17		1.0059	1.0974	1.0277	.9593	.8326	.9671
18	1.0317	1.0242	1.086	1.0029	.8688	.8688	.9955
19	1.1584	1.1694	1.2308	1.2178	1.1222	1.0242	1.0631
20	1.1765	1.2403	1.1462	1.0745	1.1222	.9774	1.0631
21	.8507	1.134	.9745		1.0136	.905	.9671
22	.9955	1.0029	.9412	.8505	.9231	.8326	.905
23	.9231	.8413	.8779	.8413	.8869	.7602	.7964
24	.823	.8145	.8413	.7762	.7316	.7964	.6516
Max	1.1765	1.2403	1.2308	1.2178	1.1222	1.0242	1.0631
Min	.5914	.6697	.7316	.5121	.5975	.5792	.6154
Avg	.8486	.8868	.9362	.8535	.8340	.7763	.8160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.6335	.7682	.6535	.5601	.6154	.6154
2	.7392	.6154	.7682	.5914	.5601	.5973	.6154
3	.7392	.5973	.7316	.5544	.5281	.5792	.5853
4	.6535	.5792	.7392	.5601	.4904	.543	.5853
5	.5601	.5792	.7023	.5228	.4854	.543	.5175
6	.5601	.5792	.6653	.5228	.5281	.5249	.5175
7	.5601	.5249	.6653	.5228	.5228	.4887	.4854
8	.5601	.5249	.6584	.5853	.4805	.4706	.5175
9	.5853	.7164	.6516	.6697	.5487	.499	.5249
10	.6447	.8596		.7421	.5792	.5853	.5611
11	.7316	.905		.8145	.8326	.6878	
12	.8688	.9955	.9774	.7602	.8048	.7164	.8326
13	.9412	.8507	.9145		.8779	.6805	.8145
14	.905	.8145	.8779	.9412	.924	.7164	.8145
15	.905	.9145	.9145	.7602	.924	.7865	.7602
16	.8501	.8779	.9511	.8869	.8688		.8507
17		.823	.823	.7964	.7421	.7316	.724
18	.7682	.7964	.8779	.7164	.7059	.5853	.7682
19	.8688	.8954	1.0719	.9412	.8688		.8328
20	.8869	1.0631	1.0164	.8413	.8869		.8954
21	.7964	.9313	.7316		.7783	.8131	.7316
22	.7421	.8688	.8048	.7316	.6516	.724	.6838
23	.724	.8048	.7682	.6653	.6697	.6516	.7095
24	.8871	.6697	.8131	.7392	.5975	.6335	.6219
Max	.9412	1.0631	1.0719	.9412	.924	.8131	.8954
Min	.5601	.5249	.6516	.5228	.4805	.4706	.4854
Avg	.7526	.7675	.8133	.7054	.6840	.6273	.6767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.724	.7545	.7922	.7167	.6697	.7545
2	.6535	.6878	.7468	.7468	.679	.6516	.7545
3	.5601	.6697	.7095	.6535	.6348	.6154	.7167
4	.5601	.6516	.679	.5601	.5975	.5973	.679
5	.5228	.6335	.679	.5228	.6036	.5792	.6348
6	.5658	.6154	.6478	.5281	.6036	.5611	.6478
7	.6602	.6154	.6097	.6036	.679	.5611	.5716
8	.6602	.7059	.6478	.6224	.679	.4706	.6097
9	.7621	.7167	.6859	.724	.679	.6413	.6535
10	.924	.8962		.7964	.7922	.7842	.7964
11	1.1949	1.1694		1.1222	1.094	.9431	1.086
12	1.2323	1.2323	1.2437	1.2308	1.2071	.9709	1.1317
13	1.2323	1.2382	1.2197		1.1949	1.0349	1.0679
14	1.1576	1.1458	1.2071	1.2308	1.1317	1.0269	1.0498
15	1.2323	1.251	1.2449	1.3213	1.1317	1.0562	1.1946
16	1.2826	1.2696	1.2826	1.3213	1.1576		1.1765
17		1.1949	1.2696	1.3306	1.1222	1.0829	1.1088
18	1.2308	1.2696	1.307	1.307	1.1389		1.1949
19	1.1946	1.2696	1.307	1.3306	1.1584		1.1949
20	1.3032	1.4045	1.1949	1.2071	1.2308		1.2136
21	1.1584	1.2197	1.0829		1.1041	1.2323	1.1203
22	.8688	.9335	.9335	.8299	.8688	.9054	.8676
23	.8688	.9335	.8962	.8299	.8326	.8589	.7545
24	.811	.7421	.7922	.8488	.7545	.695	.7842
Max	1.3032	1.4045	1.307	1.3306	1.2308	1.2323	1.2136
Min	.5228	.6154	.6097	.5228	.5975	.4706	.5716
Avg	.9300	.9662	.9610	.9300	.9080	.7969	.9068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7316	.6733	.6173	.5668	.6268	.5609
2	.6878	.7133	.6661	.6024	.5506	.6089	.5487
3	.6379	.6984	.6173	.6024	.57	.6024	.5487
4	.6379	.6201	.5967	.5784	.583	.5847	.5365
5	.6201	.6024	.5636	.5784	.5658	.5784	.4973
6	.5487	.5658	.506	.5609	.5784	.5721	.4858
7	.5144	.5548	.5144	.4908	.5083	.5087	.4475
8	.5083	.5316	.4694	.5068	.4475	.4908	.4359
9	.5792	.5258	.6335	.543	.4588	.5487	.5194
10	.5853	.6468		.6584	.5658	.5973	.6468
11		.7282		.7842	.2075	.695	.7164
12		.8029	.7545	.724	.695	.7468	.6878
13		.7733	.7545	.6379	.6468	.6722	.6401
14		.7356	.7392	.7392	.7468	.6908	.7023
15		.7392	.7602	.8131	.7842	.7356	.8059
16		.7655	.7392	.6984	.7356	.6838	.8501
17	.5365	.6535	.6878	.6805	.6602	.6036	.6878
18	.695	.6535	.5609	.7059	.591	.6036	.695
19	.6838	.6908	.6878	.7316	.5611	.6099	.6401
20	.8402	.7282		.7682	.6154	.5853	.6154
21	.7655	.7947	.5792		.695	.6219	.7316
22	.8402	.8316	.7499	.6805	.7316		.7783
23	.8589	.823	.7316	.7011	.6697	.6697	.7783
24	.7602	.7762	.7602	.6344	.6443	.6268	.6335
Max	.8589	.8316	.7602	.8131	.7842	.7468	.8501
Min	.5083	.5258	.4694	.4908	.2075	.4908	.4359
Avg	.6680	.6953	.6545	.6538	.5991	.6202	.6329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 203 / 11 KV Timber Area

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4715	.4904	.4904	.415	.4338	.415
2	.4904	.4527	.4527	.4527	.415	.3961	.3961
3	.4715		.4527	.415	.3961	.3961	.3961
4		.415	.415	.415	.3961	.3772	.3772
5	.4338	.415	.415	.415	.3772	.3395	.3772
6	.3772	.3772	.3961	.3772	.3772	.3395	.3395
7	.3395	.3109	.3326	.3206	.3772	.3206	.3361
8	.3395	.3174	.3584	.3395	.3361	.2743	.3326
9	.3584	.3584	.3772	.3961	.3961	.3772	.3772
10	.3395	.4527		.3961	.415	.3772	.3961
11		.547		.5093	.4527	.415	.3961
12		.5093	.5788	.4715	.3772	.3961	.4715
13		.4338	.4715	.3982	.415	.3772	.3696
14		.4527	.4338	.4119	.3961	.415	.3734
15	.4715	.5281	.5658	.4904	.5093	.4904	.4527
16	.4527	.4715	.5093	.5093	.4715	.3961	.4338
17	.3584	.4527	.5093	.5093	.4715	.415	.4527
18	.3395	.4715	.5093	.5093	.415	.4108	.5281
19	.415	.5093	.4904	.5788	.4904	.4251	.5093
20	.4715	.5658		.6036	.4715	.4527	.5281
21	.4715	.5658	.4527		.4338	.4338	.4527
22	.4904	.547		.5228	.4715	.4338	.4904
23	.5093	.5658	.547	.5093	.4904	.4338	.4904
24	.5281	.4904	.5093	.5093	.4338	.4527	.415
Max	.5281	.5658	.5788	.6036	.5093	.4904	.5281
Min	.3395	.3109	.3326	.3206	.3361	.2743	.3326
Avg	.4288	.4644	.4634	.4587	.4250	.3991	.4211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.5847	.679	.6979	.6602	.679	
2	.7545	.5847	.6036	.679	.6036	.679	
3	.7922	.5847	.6036	.679	.5658	.6602	
4	.6036	.5847	.6036	.6413	.547	.6413	
5	.679	.5847	.5658	.6413	.547	.6224	
6	.6602	.6036	.5658	.5847	.547	.6036	
7	.6036	.6036	.6036		.547	.5847	
8	.547	.5847	.8488		.5658	.5658	
9		.7167	1.0374		.6602	.679	.7545
10		.8676	1.0374		.7733	.7922	.8676
11		.9808	1.0185		.7922		.811
12		.9808			.8299	.9431	.7733
13		.9431	1.0185		.8488	.9054	.8488
14		.9054	1.0562		.8865	.8676	.9431
15		1.094	1.1128		.9431	.8865	1.0374
16	.6224	1.1128	.9808		.9619	.9431	.9997
17	.6413	1.094	1.0185		.8676		.9054
18	.6584	1.094	1.0562		.9055		.8299
19	.7499	1.0562	1.0164		.9425		.8775
20	.7682	.9808			.961		.8029
21	.7316	.9431	.7167		.9055		.7356
22	.7207	.8676	.7356		.8775		.7167
23	.6838	.8299	.7733		.8488		.7167
24	.8299	.6602	.7545	.7167	.6602	.6979	
Max	.8299	1.1128	1.1128	.7167	.9619	.9431	1.0374
Min	.547	.5847	.5658	.5847	.547	.5658	.7167
Avg	.6975	.8268	.8367	.6628	.7603	.7344	.8413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.226	1.2449	1.1694	1.2071	1.2071	
2	1.1694	1.2071	1.2449	1.1694	1.2071	1.1883	
3	1.1694	1.2071	1.2449	1.1694	1.226	1.1694	
4	1.1694	1.1883	1.2449	1.1694	1.226	1.1694	
5	1.1883	1.1883	1.226	1.1694	1.226	1.1883	
6	1.1883	1.1883	1.226	1.1694	1.226	1.1883	
7	1.2071	1.2071	1.226		1.2449	1.2071	
8	1.2071	1.2071	1.2637		1.2449	1.2449	
9		1.2449	1.2826		1.2449	1.226	1.1883
10		1.2826	1.2826		1.2449	1.2449	1.1883
11		1.3392	1.2826		1.2637	1.226	1.2071
12		1.226			1.2826	1.2449	1.226
13		1.2637	1.2826		1.2637	1.226	1.226
14		1.2826	1.3014		1.2449	1.2449	
15		1.2449	1.3014		1.2449	1.2449	1.2826
16	1.2637	1.3014	1.2449		1.226	1.2637	
17	1.2826	1.2826	1.2826		1.3014		1.2449
18	1.2449	1.2826	1.3014		1.2449		1.2826
19	1.2071	1.2449	1.1883		1.2071		1.2449
20	1.1883	1.2449			1.226		1.1883
21	1.2071	1.2449	1.1883		1.1883		1.1506
22	1.1883	1.2637	1.1694		1.1694		1.1883
23	1.2071	1.2449	1.1506		1.2449		1.2071
24	1.1694	1.2449	1.2449	1.1694	1.2071	1.226	
Max	1.2826	1.3392	1.3014	1.1694	1.3014	1.2637	1.2826
Min	1.1694	1.1883	1.1506	1.1694	1.1694	1.1694	1.1506
Avg	1.2016	1.2441	1.2466	1.1694	1.2339	1.2182	1.2173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.5658	.6602	.679	.6602	.6979	
2	.679	.5658	.6602	.679	.6602	.6979	
3	.679	.5658	.6602	.679	.6602	.679	
4	.679	.5658	.679	.679	.6602	.679	
5	.679	.5847	.679	.679	6.5072	.679	
6	.679	.6036	.679	.6602	.6413	.6602	
7		.6036	.679		.679	.6602	
8		.6224	.9431		.7733	.811	
9		.6979	1.1694		.9619	.9619	1.0562
10		.7733	.9431		1.1317	1.1317	1.1128
11		.8865	.9054		1.0751	.9619	.9242
12		.8676	1.0751		1.0185	.8299	.7356
13		.9431	1.0751		1.0562	.9619	.7545
14		1.0374			1.0751	1.1317	.9431
15		1.2071	.8676		1.0562	1.1128	1.1694
16	.3584	1.2071	.8488		1.0751	1.094	1.1128
17	.3584	1.1317	.811		1.0751		1.0562
18	.3206	1.1317	.7922		.9619		.9997
19	.2829	1.0374	.7733		.7922		.7167
20	.5093	.9054			.7356		.679
21	.5658	.7545	.547		.6979		.6413
22	.5658	.6979	.5847		.679		.6224
23	.547	.6979	.6413		.6413		.6224
24	.679	.547	.6979	.679	.6602	.679	
Max	.679	1.2071	1.1694	.679	6.5072	1.1317	1.1694
Min	.2829	.547	.547	.6602	.6413	.6602	.6224
Avg	.5507	.8000	.7896	.6763	1.0806	.8488	.8764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 207 / 11KV SPARE 1 FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.1132	.132	.0943	.0943	
2	.1132	.1132	.1132	.132	.0943	.0943	
3	.1132	.1132	.1132	.132	.0943	.0943	
4	.132	.1132	.132	.132	.0943	.0943	
5	.132	.1132	.132	.132	.0943	.0943	
6	.132	.1132	.132	.132		.1132	
7	.132	.132	.132		.1132	.132	
8	.132	.1132	.1132		.132	.132	
9		.1132	.1132		.132	.1132	.132
10		.1132	.1132		.1132	.1132	.132
11		.1132	.1132		.0943	.0943	.1307
12		.1509			.0943	.0943	.132
13		.1698	.1132		.1132	.1132	.1698
14		.1509	.1646		.1132	.1132	.2263
15		.3018	.3206		.0943	.0943	.3395
16	.0943	.3206	.3395		.0754	.0943	.2829
17	.1132	.2641	.3206		.1509		.2641
18	.1132	.1886	.3395		.1509		.2641
19	.1132	.1698	.3395		.1132		.1509
20	.132	.132			.132		.132
21	.132	.1509	.1132		.132		.1132
22	.1132	.132	.1132		.1132		.0943
23	.1132	.132	.132		.132		.1132
24	.1132	.0943		.1132	.0943	.1132	
Max	.132	.3206	.3395	.132	.1509	.132	.3395
Min	.0943	.0943	.1132	.1132	.0754	.0943	.0943
Avg	.1198	.1517	.1722	.1293	.1115	.1054	.1785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.132		.1698	
2	.132	.132	.132		.1852	
3	.132	.132	.132		.1852	
4	.132	.132	.132		.1852	
5	.132	.132	.132		.216	
6	.132	.1509	.132		.2469	
7	.132	.132	.1509		.2623	
8	.4915	.463	.4588	.1147	.2315	
9		.5093	.5735	.1147	.216	.1219
10		.5247	.6882		.132	.0754
11		.571	.6226	.0754	.1132	.1638
12		.5401		.1698	.0943	.1966
13		.5247	.6882	.1509		.1966
14		.5093	.5407	.132		.1802
15		.4938	.5898	.1509	.1132	.1311
16	.0943	.1132	.132	.132	.0943	
17	.1132		.132	.1509		.1311
18	.1132		.1509	.1509		.1147
19	.1132		.1509	.1509		.0943
20	.0943			.1886		.1132
21	.1509			.1698		.1509
22	.1509			.1698		.132
23	.1509			.1698		.132
24	.132	.132	.132		.1543	
Max	.4915	.571	.6882	.1886	.2623	.1966
Min	.0943	.1132	.132	.0754	.0943	.0754
Avg	.1487	.3132	.3054	.1461	.1733	.1381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.4897	2.3011	2.32	
2				2.452	2.3011	2.32	
3				2.3388	2.32	2.32	
4				2.2634	2.32	2.3388	
5				2.3765	2.3388	2.452	
6				2.4331	2.3388	2.5086	
7		1.7353		2.452	2.3577	2.452	
8		1.905		2.3388	2.1691		
9	1.5089	2.452		2.5274			
10	1.3957	2.7161		2.9424		2.6749	
11	1.2826	3.1687		3.4139			3.263
12	1.3014	2.9047	3.3951	3.0367		3.263	2.9235
13	1.2449	2.8292	2.9613	2.7538			3.0178
14		3.1687		2.7726			
15		3.5082	3.4139	3.0556			3.3573
16		3.263	3.1876	3.1121		2.7915	3.2253
17				3.0744	2.9235		3.0178
18	1.2637		2.9424		2.6783		2.3388
19	1.3957		2.3954	2.4897	2.584		2.5652
20			2.2634		2.4897		2.452
21					2.4709		2.32
22				.2075	2.4331		2.3765
23	1.358		2.4709	2.1125	2.452		2.32
24			2.1691	2.4709	2.3011	2.3388	
Max	1.5089	3.5082	3.4139	3.4139	2.9235	3.263	3.3573
Min	1.2449	1.7353	2.1691	.2075	2.1691	2.32	2.32
Avg	1.3439	2.7651	2.7999	2.5292	2.4237	2.5254	2.7648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4335	1.5278	1.5278	
2				1.3957	1.5466	1.5089	
3				1.358	1.5655	1.4901	
4				1.3203	1.5844	1.4901	
5				1.358	1.6032	1.5466	
6				1.4335	1.6032	1.6787	
7		1.2637		1.5278		1.5466	
8		1.3014		1.5844	1.6221	1.773	
9	1.1317	1.5466		1.9239			
10	1.1506	1.773		2.3011		2.3011	
11	1.1317	2.2068		2.5086			2.4331
12	1.0562	2.1502	2.2257	2.3011		2.2634	2.1125
13	.9619	2.037	2.0182	1.8484			1.9427
14		2.1691		1.8296			
15		2.5086	2.3388	1.9616			2.5086
16		2.2634	2.2068	2.3011		2.3954	2.5086
17				2.3388	2.2822		2.2634
18	.9619		2.037		2.2068		2.1313
19	1.1694		1.8107	1.8861	1.9239		1.9805
20			1.3957		1.8107		1.7164
21			1.3014		1.6975		1.6598
22				1.0562	1.6598		1.6975
23	1.1883		1.6787	1.3769	1.6221		1.7353
24			1.5089	1.4901	1.5278	1.5466	
Max	1.1883	2.5086	2.3388	2.5086	2.2822	2.3954	2.5086
Min	.9619	1.2637	1.3014	1.0562	1.5278	1.4901	1.6598
Avg	1.0940	1.9220	1.8522	1.7397	1.7189	1.7557	2.0575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2826	.9431	1.4335	
2				1.358	1.0185	1.3957	
3				1.3203	1.094	1.3957	
4				1.2449	1.1694	1.3957	
5				1.3203	1.2449	1.4146	
6				1.4712	1.3392	1.4523	
7		1.4146		1.4523		1.3957	
8		.3584		.8676	1.4335	1.3769	
9	.9431	1.358		1.1694			
10	.3395	1.6787		1.6221			
11	.3018	1.0562		1.7541			.9808
12	.3018	1.358	1.6598	1.0751		1.7918	1.773
13	.2641	1.1317	.6413	1.5466			1.5844
14		1.3957		1.6598			
15		1.6409	1.5466	1.6409			1.6975
16		1.6409	1.5844	1.6787		1.0374	1.6975
17				1.6409	1.5089		1.7353
18	.2452		1.094		1.4901		1.6598
19	.2641		1.5844	1.5655	1.4712		1.6221
20			1.358		.8676		1.5278
21			1.3957		1.4146		1.0562
22				1.4523	1.4335		1.3203
23	1.3203		1.4146	.8676	1.4712		1.4901
24			1.5089	.547	.8676	1.5466	
Max	1.3203	1.6787	1.6598	1.7541	1.5089	1.7918	1.773
Min	.2452	.3584	.6413	.547	.8676	1.0374	.9808
Avg	.4975	1.3033	1.3788	1.3589	1.2512	1.4214	1.5121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2071	1.0374	1.0374	
2				1.1694	1.0374	1.0185	
3				1.1317	1.0562	1.0185	
4				1.0562	1.0751	1.0562	
5				1.1128	1.094	1.094	
6				1.1694	1.1317	1.1694	
7		.6413		1.2826		1.3014	
8		.7922		1.1128	1.1317		
9	.6224	1.0185		1.4335			
10	.5658	1.3014		1.7164		1.6409	
11	.5658	1.2637		1.8484			1.6221
12	.6036	1.2449	1.4146	1.8861		1.7353	1.9427
13	.5847	1.1694	1.358	1.6787			1.5466
14		1.2826		1.6032			
15		1.4901	1.6598	1.8107			2.1879
16		1.3203	1.5278	2.0182		1.9805	1.6975
17				1.773	1.6409		1.5466
18	.547		1.4901		1.5089		1.3014
19	.5847		1.3203	1.4712	1.3957		1.094
20			1.094		1.094		1.0562
21			.9431		1.0185		1.094
22				1.094	.9431		1.1128
23	.5847		1.2071	1.0185	1.0185		1.1317
24			.5847	1.1128	.9997	1.0562	
Max	.6224	1.4901	1.6598	2.0182	1.6409	1.9805	2.1879
Min	.547	.6413	.5847	1.0185	.9431	1.0185	1.0562
Avg	.5823	1.1524	1.2600	1.4146	1.1455	1.2826	1.4445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.773	1.358	1.5089	
2				1.751	1.358	1.4901	
3				1.6787	1.3392	1.4901	
4				1.5844	1.3392	1.4712	
5				1.6975	1.3203	1.5466	
6				1.6032	1.3203	1.6409	
7		.7545		1.6598	1.4523	1.1694	
8		1.1694		1.7541	1.773		
9	.547	1.358		1.6032			
10	.5093	1.8107		1.8107		1.094	
11	.547	1.6598		2.2634			1.9616
12	.5658	1.8107	1.6975	1.7541		1.9427	1.6409
13	.5658	1.9993	2.0936	1.905			2.0748
14		1.8673		2.3388			
15		1.9993	1.8296	2.2634			2.037
16		2.0936	1.6409	2.1879		1.7164	1.7918
17				.9997	1.5466		1.6975
18	.6036		1.0562		1.7353		1.6409
19	.5847		1.5844	1.9239	2.037		1.3957
20			1.4712		.811		1.5466
21			1.0374		1.8484		1.6598
22				1.4712	1.6598		1.6975
23	.6413		.9997	.7356	1.5655		1.5089
24			1.3769	1.6221	1.358	1.5278	
Max	.6413	2.0936	2.0936	2.3388	2.037	1.9427	2.0748
Min	.5093	.7545	.9997	.7356	.811	1.094	1.3957
Avg	.5706	1.6523	1.4787	1.7324	1.4889	1.5089	1.7211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2449	1.1128	1.1128	
2				1.2071	1.1128	1.094	
3				1.1317	1.1128	1.094	
4				1.0562	1.094	1.094	
5				1.094	1.094	1.1317	
6				1.1128	1.094	1.2071	
7		1.0185		1.2637		1.3392	
8		1.1506		1.3769	1.2071	1.3392	
9	.8676	1.4335		1.9993			
10	.8865	1.8673		2.4143			
11	1.0185	1.9616		2.3577			1.9239
12	.9808	1.905	1.9616	2.3577			1.9427
13	1.0374	1.6409	1.7918	1.9427			1.6975
14		1.7353		2.0182			
15		2.0182	2.1313	1.9993			2.0936
16		1.9616	2.0936	1.9805		1.9427	1.8673
17				1.9427	1.9993		1.773
18	.8676		1.7164		1.7353		1.6975
19	.9054		1.6598	1.6032	1.4335		1.4146
20			1.3957		1.1506		1.2826
21			1.2826		1.2637		1.1506
22				1.0562	1.094		1.2071
23	1.0562			1.1128	1.1317		1.2449
24			1.2826	1.358	1.1128	1.1128	
Max	1.0562	2.0182	2.1313	2.4143	1.9993	1.9427	2.0936
Min	.8676	1.0185	1.2826	1.0562	1.094	1.094	1.1506
Avg	.9525	1.6693	1.7017	1.6014	1.2499	1.2468	1.6079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4712	1.094	1.358	
2				1.4335	1.1317	1.3392	
3				1.3957	1.1694	1.3392	
4				1.358	1.226	1.3392	
5				1.3957	1.2826	1.3203	
6				1.4335	1.3203	1.2071	
7		.8865		.9808		1.3392	
8		.8488		1.3769	1.3203	1.3392	
9	.7545	1.358		1.5844			
10	.7167	1.8484		1.8484		2.0936	
11	.7545	1.7918		2.1125			1.7541
12	.7167	1.6787	2.037	1.9239		2.0748	1.7353
13	.6602	1.5278	1.7541	1.5278			1.5278
14		1.7353		1.6975			
15		1.8861	2.3011	1.8107			1.6787
16		1.6221	1.8861	1.8861		1.905	1.6975
17				1.7353	1.8673		1.5466
18	.7356		1.8861		1.7353		1.3203
19	.7356		1.4901	1.7164	1.6409		1.6221
20			1.358		1.4712		1.5466
21			1.4146		1.358		1.2637
22				1.1128	1.4335		1.4335
23	.7545		1.4901	1.3957	1.5466		1.5466
24			1.5655	1.5089	1.0562	1.3769	
Max	.7545	1.8861	2.3011	2.1125	1.8673	2.0936	1.7541
Min	.6602	.8488	1.358	.9808	1.0562	1.2071	1.2637
Avg	.7285	1.5184	1.7183	1.5574	1.3769	1.5026	1.5561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.1509	.1886	
2				.1886	.1509	.1886	
3				.1698	.1509	.1886	
4				.1698	.1698	.2075	
5				.1886	.1698	.2075	
6				.2263	.1698	.2075	
7		.2075		.2075		.2075	
8		.2075		.1886	.1698	.1886	
9	.2075	.2263		.2263			
10	.2075	.3018		.2641		.2263	
11		.3018		.3018			.2075
12		.3018	.3206	.3206		.2641	.2452
13		.3018	.3018	.2829			.2452
14		.2641		.2829			
15		.3018	.2829	.3206			.2452
16		.2829	.3018	.2641		.3018	.2263
17				.2829	.2641		.2263
18	.1886		.2829		.2452		.2263
19	.2075		.2452	.2263	.2452		.2075
20			.2263		.2452		.2075
21			.1886		.2452		.2075
22				.1509	.2263		.2075
23	.2075		.1886	.1509	.2075		.1886
24			.2075	.1886	.1509	.2075	
Max	.2075	.3018	.3206	.3206	.2641	.3018	.2452
Min	.1886	.2075	.1886	.1509	.1509	.1886	.1886
Avg	.2037	.2697	.2546	.2281	.1974	.2153	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1132	.2263	.1698	
2				.1698	.2263	.1698	
3				.1415	.2263	.1698	
4				.1698	.2263	.1698	
5				.1698	.2263	.1698	
6				.1132	.2263	.1698	
7		.2263		.2263		.1698	
8		.2263		.1698	.2263	.464	
9	.1811	.1698		.1698			
10	.215	.1301		.1698		1.2449	
11	.1698	.1924		.1867			.2037
12	.2263	.2263	.2263	.1301		1.1317	.696
13	.2263	1.4203	.2773	1.1996			1.0808
14		1.2675		1.1713			
15		.1698	.2263	1.2845			1.3354
16		1.2788	1.3524	1.3297			.1811
17				.1075	.2263		1.2449
18	.2263		.1132		.1301		1.2109
19	.2263		.1698	.0905	.5545		.1867
20			.1698		.1132		.2263
21			.1867		.1867		.1245
22					.1811		.4753
23	.2263		.1924	.2263	.1698		.1132
24			.2263	.1245	.2263	.1698	
Max	.2263	1.4203	1.3524	1.3297	.5545	1.2449	1.3354
Min	.1698	.1301	.1132	.0905	.1132	.1698	.1132
Avg	.2122	.5308	.3141	.3732	.2248	.3817	.5899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 407 / 33KV SUYESH DUCTILE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0412	1.5051	1.2675	
2				.9393	1.2901	1.2562	
3				.8205	1.0525	1.2449	
4				.9506	1.0751	1.2505	
5				1.1543	.9733	1.2505	
6				1.6183	1.143	.2377	
7		.0905		1.5278			
8		.1019		.8657	.4979	.2263	
9	.7243	.3508		.8035			
10	.2263	.8374		.696		.1471	
11	.1415	.2263		.2377			.2603
12	.1132	.9167	.1754	.9054		.2037	.249
13	.1132	.2263	1.6409	.3508			.8714
14		.3056		.2263			
15		.2546	.9846	1.6975			1.7428
16		.4527	1.573	1.7541		.1698	.9733
17				.928	.5658		.928
18	.1471		1.6183		.5772		.3961
19	.1245		.8488	1.6975	.7582		.3508
20			1.0412		.9506		.4753
21			.249		.7356		1.0185
22				.249	1.1996		.8092
23	.2263		.2377	1.6296	1.358		.447
24			.1132	.9054	1.6975	1.3354	
Max	.7243	.9167	1.6409	1.7541	1.6975	1.3354	1.7428
Min	.1132	.0905	.1132	.2263	.4979	.1471	.249
Avg	.2271	.3763	.8482	.9999	1.0253	.7809	.7101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 201 / 11 KV Mahavir
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.2829
Max	.2829
Min	.2829
Avg	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 204 / 11 KV Galaxy

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.2075
Max	.2075
Min	.2075
Avg	.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 205 / 11 KV Bamnoli

Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	.0924
Max	.0924
Min	.0924
Avg	.0924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
23	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.2804		.8916	.8718	.9602	
2	.7011	.2743		.8322	.8478	.9015	
3	.6661	.2378		.7621	.8573	.8817	
4	.6733	.2477		.7449	.8573	.8048	
5	.788	.2526		.6097	.9114	.8916	
6	.9313	.2526		.5792	.9114	.852	
7	.7545	.2934		.487	.8855	.7682	
8	.3948	.3772	.6249	.8855	.7926	.7133	
9	.128	.6443	1.1218	1.1096	1.1919	1.1919	1.0974
10	.2557	1.0242	.961	1.448		1.5203	1.3756
11		1.1203	.9412	1.4937		1.2308	1.4937
12	.1238	.7125	1.2696	1.4937		.9412	1.643
13	.221	.7545	1.2178	1.4632		1.2696	1.3032
14	.2096	.7796	1.3169	1.448		1.3169	1.3756
15	.2012	.9335	1.4784	1.086	1.5684	1.3443	1.5089
16	.1738	.9511	1.086		1.3169	1.4784	1.6598
17	.064		1.3306	1.3306	1.182	1.3032	
18	.0693		1.3169		.7796	1.0136	
19	.144		1.2437		1.3169	1.134	
20	.2614		.9175		1.1462	1.2178	
21	.1387		.3978		1.1706	1.1218	
22	.2667		.9175	.9069	.9389		
23	.3018		.9602	.9945	.9724		.6584
24	.6935	.3018	.3018	.9389	.8619	.9175	
Max	.9313	1.1203	1.4784	1.4937	1.5684	1.5203	1.6598
Min	.064	.2378	.3018	.487	.7796	.7133	.6584
Avg	.3850	.5552	1.0237	1.0266	1.0200	1.0807	1.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4999	.2103		.3841	.3948	.4694	
2	.423	.2149		.3734	.3734	.5213	
3	.3734	.2149		.4115	.3109	.535	
4	.3628	.2103		.3715	.3109	.4572	
5	.3628	.2058		.3307	.3521	.4999	
6	.3521	.2401		.3201	.3201	.4572	
7	.2972	.2347		.3094	.3041	.3658	
8	.2675	.5365	.4694	.4329	.3467	.439	
9	.3521	.6935	.8048	.6859	.8596	.7011	.8596
10	.3628	.9774	1.2826	.9955		1.0185	1.1317
11	.5144	1.2071	1.2826	1.0562		.9709	1.0562
12	.4512	1.1317	1.1317	1.0242		.9709	1.2071
13	.3658	.9979	.9214	1.0349		.823	.9214
14	.4146		.9877	1.0242		1.2567	1.2826
15	.421	1.1203	1.2449	1.2071	1.1088	1.0456	1.1949
16	.4268	1.2071	1.0562		1.0562	1.094	1.0456
17	.2667		.961	1.0974	.961	.8871	
18	.2058		.8413		.8417	.8048	
19	.2286		.7628		.6706	.6401	
20	.2149		.506		.5624	.6401	
21	.2103		.4108		.4694	.5365	
22	.2031		.3948	.4001	.5135		
23	.2103		.3841	.3681	.4938		.3307
24	.5243	.2103	.2103	.4108	.3628	.4877	
Max	.5243	1.2071	1.2826	1.2071	1.1088	1.2567	1.2826
Min	.2031	.2058	.2103	.3094	.3041	.3658	.3307
Avg	.3463	.6008	.8031	.6441	.5586	.7101	1.0033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.2197		1.1458	1.0534	1.1643	
2	1.1088	1.1088		1.1088	1.0349	1.1643	
3	.9979	1.0349		1.1088	1.0349	1.1088	
4	1.0534	1.0349		1.0719	.9979	1.0534	
5	.9979	1.0349		1.0349	.9795	1.0164	
6	1.0349	1.0349		1.0349	.961	.9425	
7	.9979	1.0349		.9979	.924	.9055	
8	.961	.961	.8871	.8686	.8501	.7947	
9	.8131	.8871	.9055	.7947	.8501	.8686	.7577
10	.7762	.924	.9979	.8501		.8871	.8501
11	.6653	.924	.9979	.8501		.961	.7762
12	.6653	.961	1.0349	.924		.9979	.8131
13		.961	.9979	.924		.8501	.7762
14	.924	.9979	.9979	.924		.961	
15	.961	1.0349	1.0719	.9979	.7392	.961	.9055
16	.7762	.9979	.9979		.9425	.924	.8501
17	.037		.9795	.924	.924	.9425	
18	1.0164		.9979		.8871	.9055	
19	1.4045		1.1643		1.1088	1.2382	
20	1.4969		1.2012		1.3676	1.3306	
21	1.4415		1.2752		1.3676	1.2752	
22	1.4415		1.3491	1.2936	1.4045		
23	1.386		1.2752	1.1827	1.3306		1.2382
24	1.2936	1.3306	1.3306	1.1827	1.0903	1.2012	
Max	1.4969	1.3306	1.3491	1.2936	1.4045	1.3306	1.2382
Min	.037	.8871	.8871	.7947	.7392	.7947	.7577
Avg	1.0204	1.0284	1.0860	1.0115	1.0446	1.0206	.8709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0057	.0076		.0057	.0061	.0244	
2	.0076	.0091		.0076	.0076		
3	.0076	.0122		.0091	.003	.0229	
4	.0095	.0152		.0091	.0152	.0152	
5	.0095	.0183		.0152	.0152	.0183	
6	.0095	.0244		.0152	.0183	.0229	
7	.0076	.0267		.0183	.0244	.0244	
8	.0038	.0671	.2972	.1753	.1585	.0213	
9	.0038	.0793	1.5089	1.4022	.2629	.0244	.0351
10	.0038	.1036	.3521	.2934		.0274	.0305
11	.0038	1.4937	1.5844	1.1317		.0457	.0442
12	.0038	.3338	1.0631	1.5364		.0457	.0412
13	.0038	1.4937	1.5684	1.643		.0488	.0305
14	.0038	1.358	1.3443	1.7741		.0183	.0351
15	.0038		1.0242	2.1125	1.848	.0503	.0381
16	.0038	1.6598	.8215		1.5364	.0442	.029
17	.0038		1.8107	1.5524	1.643	.0488	
18	.0038		1.2567		.0709	.029	
19	.0057		1.8671		.0305	.032	
20	.0057				.0244	.032	
21	.0057		.0213		.0244	.0305	
22	.0076		.0152	.0091	.0259		
23	.0095		.0057	.0061	.0244		.0259
24	.0057	.0095	.0095	.0038	.003	.0259	
Max	.0095	1.6598	1.8671	2.1125	1.848	.0503	.0442
Min	.0038	.0076	.0057	.0038	.003	.0152	.0259
Avg	.0058	.4195	.9094	.6169	.3022	.0311	.0344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7372	1.7926	1.8446	1.7013	1.5223	1.6289	1.4632
2	1.7013	1.6632	1.7718	1.647	1.4883	1.6448	1.3717
3	1.6832	1.6263	1.7375	1.5927	1.4864	1.5223	1.2803
4	1.6651	1.5203	1.6655	1.5565	1.5023	1.4842	1.2567
5	1.6289	1.5023	1.6478	1.5565	1.4706	1.4937	1.2567
6	1.6289	1.5203	1.7013	1.5746	1.4864	1.4415	1.3306
7	1.5581	1.5384	1.6655	1.4864	1.3998	1.39	1.3306
8	1.5927	1.6289	1.7193	1.3611	1.379	1.4118	1.2567
9	1.6297	1.6478	1.5769	1.3611	1.2357	1.3575	1.3306
10	1.6655	1.7541	1.7926		1.2934	1.379	1.386
11	1.0277	1.6832	1.5154	1.4784	1.258	1.5203	1.386
12		1.7364	1.5384	1.4969	1.2934	1.1458	1.386
13		1.7187	1.4299	1.5154	1.2757	1.5339	1.3676
14		1.6655	1.8461	1.4998	1.3112	1.4632	1.4415
15	1.2934	1.7187	1.8656	1.6448	1.3289	1.4784	1.4415
16	1.1999	1.6832		1.4998	1.3289	1.46	1.2752
17	1.8054	1.6655	2.0144	1.5546	1.3535	1.4784	1.3672
18	1.8665	1.7364	1.8427	1.5939	1.3394	1.4118	1.4148
19	2.1538	2.0953	2.1262	1.8446	1.7193	1.7924	1.7541
20	2.1992	2.1794		1.97	2.0271	1.8296	1.9004
21	2.1399	2.1312	2.009	1.8427	1.8473	1.7926	1.893
22	2.0883	2.1439	1.9728	1.8446	1.8665	1.6263	1.8446
23	1.9404	2.1132	1.8625	1.7551	1.7737	1.6078	1.6834
24	1.7909	1.8111	2.0058	1.8642	1.5947	1.6827	1.4784
Max	2.1992	2.1794	2.1262	1.97	2.0271	1.8296	1.9004
Min	1.0277	1.5023	1.4299	1.3611	1.2357	1.1458	1.2567
Avg	1.7141	1.7615	1.7796	1.6192	1.4826	1.5240	1.4540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.197	.2075	.1791	.181	.1646
2	.1867	.1848	.1949	.1886	.1772	.1848	.1646
3	.1886	.1629	.197	.1886	.1791	.1612	.1646
4	.1886	.1629	.197	.1886	.181	.1629	.1848
5	.1886	.181	.1991	.2075	.181	.1867	.2218
6	.2075	.1991	.2715	.2263	.2507	.1848	.2218
7	.2241	.2033	.2328	.2641	.2715	.2012	
8	.2402		.2353	.2829	.2149	.2534	.2402
9	.3511	.2481	.2715	.2987	.2149	.2353	.2957
10	.3224	.3658	.3142	.3696	.3142	.197	.3326
11	.2328	.3395	.3439	.3696	.2772	.2926	.3142
12		.3018	.3326	.3142	.2926	.2012	.2587
13		.3206	.2534	.3258	.2743	.1848	.2402
14		.2241	.2715	.2353	.2743	.2012	.2378
15	.2658	.2926	.2561	.2195	.2743	.1848	.2587
16	.2149	.2561	.2402	.2218	.2218	.2033	.2402
17	.2149	.2218	.2218	.2402	.2195	.1848	.1772
18	.1663	.2149	.2218	.2149	.181	.1629	.2149
19	.2033	.2172	.2378	.2507	.197	.1829	.2172
20	.2218	.2328		.2534	.1991	.2218	.2303
21	.2126	.2353	.2641	.2353	.2195	.2033	.2328
22	.2033	.2481	.2452	.2172	.2218	.1848	.2328
23	.1848	.2328	.2263	.0838	.1991	.1663	.2328
24	.1848	.1848	.2353	.2075	.1991	.1829	.1663
Max	.3511	.3658	.3439	.3696	.3142	.2926	.3326
Min	.1663	.1629	.1949	.0838	.1772	.1612	.1646
Avg	.2185	.2354	.2461	.2422	.2256	.1961	.2280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	1.0642	1.0679		.9145	.9511	.8871
2	.9896	1.0269	1.0242	.3142	.8688	.8326	.823
3	.0175	.9335	.9313	.3174	.8413	.8316	.7947
4	.9335	.8962	.9511	.3361	.8413	.8215	.7682
5	.9335	.8775	.9412	.3361	.8326	.7947	.7316
6	.9522	.8402	.9231	.3326	.8688	.724	.7316
7	.8686	.8589	.8779	.3395	.7865	.6805	.7392
8	.8316	.8775		.3584	.788	.7059	.7762
9	.9425	.9979	.9694	.3734	.905	.7392	.961
10	1.0317	1.0719	1.0534	.4525	.9709	.8029	1.1949
11	1.1041	1.0719	1.1458	.5175	1.0349	.8402	1.1389
12	1.1041	1.0269	1.1088	.1867	1.0719	.8775	.8589
13	1.1157	1.1458	1.1088	.5415	1.0425	.8962	.9149
14	1.086	1.0269	1.1643	.5729	1.0425	.8775	.8501
15	1.1157	1.0903	1.1643	.5914	1.0534	.8589	.8402
16	1.1706	1.1458	1.1458	.5359	1.0719	.8962	1.1016
17	1.0679	1.0719	1.0534	1.3491	1.0425	.8402	1.1157
18		1.0242	1.0608	1.1222	.8869	.8501	.8688
19		1.2803	1.2936	1.3535	1.0029	1.1088	1.1462
20		1.262		1.267	1.0136	1.1458	1.1584
21		1.267	1.2752	1.1222	1.0534	1.1088	1.1403
22		1.3352	1.2197	1.1706	1.0903	1.0164	1.0608
23		1.2803	1.1088	1.0791	1.0425	.924	1.0425
24	1.1016	1.0829	1.1403	1.0082	.9774	.985	.9055
Max	1.1706	1.3352	1.2936	1.3535	1.0903	1.1458	1.1949
Min	.0175	.8402	.8779	.1867	.7865	.6805	.7316
Avg	.9663	1.0648	1.0786	.6773	.9602	.8796	.9396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	1.0082	.8869	.823	.7421	.8048	.7023
2	.8596	.9335	.8328	.7682	.7164	.7421	.5914
3	.823	.9335	.8145	.7499	.6878	.7392	.567
4	.7865	.8962	.823	.695	.6805	.7282	.5487
5	.7682	.8775	.8059	.695	.724	.7023	.567
6	.7682	.7392	.7421	.7133	.6878	.6697	.5853
7	.7316	.7207	.724	.7133	.6626	.6805	.5914
8	.7133	.7282		.6767	.6516	.6697	.6099
9	.6878	.6626	.5973	.6767	.6036	.5729	.5914
10	.6516	.6626	.5544	.6335	.6401	.5788	.5788
11	.3429	.6447		.6653	.6154	.6348	.5415
12	.6805	.6516	.6335	.6722	.6697	.6468	.6348
13	.7059	.6767	.7207	.6535	.5973	.5975	.6099
14	.6984	.6697	.7207	.7095	.6154	.5601	.6535
15	.6984	.695	.7392	.7095	.6335	.6535	.6468
16	.6878	.695	.7392	.7095	.5792	.6722	.6283
17	.6335	.6697	.7207	.6838	.6219	.6535	.5611
18	.7023	.7059	.724	.7343	.7421	.6468	.6733
19		.905	.9511	.9412	.8596	.9055	.8145
20		.9955		.9134	.8688	.8962	.8954
21		.9492	.9412	.905	.8871	.8871	.8775
22		1.0242	.9328	.905	.9425	.8316	.9134
23		1.0136	.9328	.8688	.9145	.7762	.8869
24	.9328	1.0719	.9412	.8779	.8048	.8238	.7207
Max	.9328	1.0719	.9511	.9412	.9425	.9055	.9134
Min	.3429	.6447	.5544	.6335	.5792	.5601	.5415
Avg	.7247	.8137	.7847	.7539	.7145	.7114	.6663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.751	6.7507	6.4883	2.9492	4.7239	6.7873	5.1532
2	5.8002	6.9102	6.7627	2.9001	4.8731	6.7084	5.156
3	5.8002	7.0696	6.6072	2.8509	4.6205	6.7696	5.0926
4	5.8985	8.5048	6.8816	2.2119	4.4256	6.9502	6.0471
5	6.6358	8.9301	7.029	1.6118	4.3747	7.2257	6.4849
6	7.8155	9.1958	8.502	1.5775	6.4129	9.7022	6.5729
7	10.2881	11.4283	10.5424	2.9835	7.7246	11.7421	
8	11.0082	11.0082	11.1254	2.8807	6.8816	11.7284	7.867
9	8.1276	11.8827	10.7648	3.5608	3.2047	6.9307	9.249
10	8.4036	10.6996	11.4283	3.8803	4.6273	9.0798	9.5148
11	5.407	11.4632	13.1985	4.5182	1.8747	10.8528	9.5148
12	10.8402	12.4309		4.465	8.4362	11.0563	8.7174
13	10.691	12.252		4.6799	8.8477	10.2589	7.0988
14	10.2732	12.6543	8.3453	4.3056	9.7737	10.3652	6.6975
15	10.0274	9.6228	10.4716	4.1461	9.2581	10.5304	7.0696
16	10.6396	9.4136	11.7261	4.1993	9.1564	11.5112	8.3814
17	10.3715	10.7796	5.156	2.6578	1.9753	2.9864	6.9616
18	10.2589	12.1411	5.4561	2.6292	2.4977	2.4446	2.3137
19	3.0167	3.0687	1.773	2.9647	2.955	2.4451	2.7046
20	3.1893	3.4705		2.7263	3.1493	2.6578	2.9321
21	3.0298	3.2768	2.0513	2.4177	3.0727	2.7109	2.8607
22	2.8395	3.1024	2.2177	2.5206	1.8296	2.4714	2.6235
23	2.5514	2.6818	2.0851	4.7737	5.3212	5.3155	5.8002
24	2.1719		2.7046	1.885	4.7188	6.9685	5.2092
Max	11.0082	12.6543	13.1985	4.7737	9.7737	11.7421	9.5148
Min	2.1719	2.6818	1.773	1.5775	1.8296	2.4446	2.3137
Avg	7.1182	8.6408	7.2056	3.1790	5.1973	7.3416	6.0879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 202 / 11 KV GMIE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
23	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
23	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 204 / 11KV WATER FILTER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 206 / 11KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.773	2.1719		1.9814	
2			2.0748	2.0957		1.6221	
3			2.1125	2.0957		2.0748	
4			1.9616	1.9052		1.773	
5			2.1502	1.9052		1.6975	
6			2.21	1.7909		1.0669	
7			1.0185	1.6385		1.6194	
8			1.4901	1.6004		1.4901	
9			1.6221	1.6385		1.0456	
10	.9619	1.7164		2.2481	2.21	1.4712	1.4901
11		2.3388	1.6598	1.905	1.9052	1.9243	1.5844
12	.8417	2.2862	1.6975	2.2291	1.6385	2.2068	1.6032
13	.7975	2.2822	1.3392	2.1529	1.5623	2.1691	1.4335
14	.8775	2.3577	1.094	1.0185		2.0911	1.5089
15	.8669	2.3388	1.9616	1.8861	1.9052	2.0748	1.5466
16	.9795	2.1879	2.2291	2.1125	2.21	2.2445	1.6598
17	1.0136	2.2822	1.0185		2.1719	1.6787	.9619
18		1.6766	2.2481		1.6004		1.5655
19		2.191	2.1719		2.2068		1.0669
20		1.6385			2.1338		1.467
21		1.7337	1.4335		1.4523		1.6221
22		1.5466	1.8861		2.1719		1.5051
23		1.6409	2.1879		1.5089		1.5432
24			1.6575	2.1719		2.191	
Max	1.0136	2.3577	2.2481	2.2481	2.21	2.2445	1.6598
Min	.7975	1.5466	1.0185	1.0185	1.4523	1.0456	.9619
Avg	.9055	2.0155	1.7726	1.9157	1.8982	1.8012	1.4684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.358	1.448		1.0349	
2			1.4335	1.4098		.8775	
3			1.226	1.4098		.7865	
4			1.3392	1.3717		.9134	
5			1.358	1.3717		.8413	
6			1.4335	1.0974		.8596	
7			.8779	.8326		.3567	
8			1.0185	1.0082		1.0562	
9			1.8861	1.9052		1.1812	
10	1.3203	1.9243		1.2574	1.2574	1.3392	1.0562
11		1.4146	1.5844	1.3336	1.2955	1.2071	1.5089
12	.9492	1.2449	1.6194	1.448	1.3336	1.9239	1.2637
13	.4534	1.0185	1.5278	1.8861	1.6004	1.226	1.1088
14	.3155	1.2449		2.0748	1.829	1.8107	1.1317
15	.5201	1.4523	1.5844	1.8861	1.7909	1.358	1.226
16	.8871	.547	2.0386	1.7918	1.7909	1.3392	1.6787
17	1.4146	1.226	1.0288		1.8671	1.3957	1.7164
18		1.3527	1.4098		1.9805		.8316
19		.9709	1.1317		.6161		1.9052
20		1.1317			1.1883		1.5813
21		1.5623	1.2449		.7619		1.4146
22		1.0185	1.1317		1.0269		1.5813
23		1.5432	.9709		1.0456		.9335
24			1.6194	1.448		.9979	
Max	1.4146	1.9243	2.0386	2.0748	1.9805	1.9239	1.9052
Min	.3155	.547	.8779	.8326	.6161	.3567	.8316
Avg	.8372	1.2608	1.3725	1.4694	1.3846	1.1392	1.3527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2947	.3734		.3326	
2			.3224	.3511		.2896	
3			.3155	.3511		.3326	
4			.2915	.3292		.3361	
5			.2947	.3292		.2896	
6			.3086	.3439		.2801	
7			.3109	.362		.2865	
8			.3658	.3982		.4163	
9			.567	.5335		.5093	
10	.1448	.6602		.6161	.6036	.679	.5658
11		.6224	.6224	.547	.5716	.7545	.5847
12	.1353	.5847	.547	.5847	.6097	.6036	.6668
13	.0781	.415	.679		.5716	.415	.5093
14	.0389	.6413	.7095			.6224	.7167
15	.0629	.7356	.679	.7167	.5335	.5658	.7167
16	.1236	.5281	.5658		.5716	.5093	.547
17	.0892	.4527	.4572		.6097	.4904	.4715
18		.3395	.5335		.3547		.4001
19		.3395	.4191		.3174		.362
20		.2835			.2561		.2896
21		.2865	.2926		.3018		.3395
22		.2172	.3292		.3326		.2915
23		.3018	.362		.3547		.3734
24			.3224	.3734		.4954	
Max	.1448	.7356	.7095	.7167	.6097	.7545	.7167
Min	.0389	.2172	.2915	.3292	.2561	.2801	.2896
Avg	.0961	.4577	.4359	.4435	.4607	.4560	.4882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3176	1.2346		2.1125	
2			1.2269	1.3756		2.0182	
3			1.4506	1.3756		2.5274	
4			1.2894	1.4632		2.0748	
5			1.4449	1.4632		2.3388	
6			1.448	1.6632		2.5652	
7			1.4632	1.7924		2.8387	
8			2.4143	1.8298		2.4709	
9			2.9235	1.531		1.773	
10	1.2826	2.2257	2.584	2.7915	1.9814	1.9616	2.0936
11		2.9235	2.4331	2.3388	2.4768	2.0957	2.7726
12	.7625	2.9047	2.5911	3.0178	2.7816	2.8292	3.3573
13	.7716	3.131	2.3765	3.0933	2.6673	1.9993	2.1879
14	.8322	2.8481	2.1313	3.0178	2.5911	3.2819	2.3954
15	.5201	2.9424	3.2065	3.2065	2.4768	2.1125	3.131
16	.9774	2.3011	2.9912	3.4328	2.3243	3.5837	2.0936
17	1.0277	2.6029	2.1338	2.6406	2.21	2.2445	3.0556
18		2.3577	2.4387		2.0165		2.1125
19		2.4897	2.4768		2.3388		2.5652
20		2.0165			2.0748		2.5086
21		1.2403	1.0631		2.0936		2.5463
22		.9995	1.9022		2.6783		1.3937
23		1.1305	2.3011		1.922		2.2068
24			1.4022	1.2346		1.922	
Max	1.2826	3.131	3.2065	3.4328	2.7816	3.5837	3.3573
Min	.5201	.9995	1.0631	1.2346	1.922	1.773	1.3937
Avg	.8820	2.2938	2.0439	2.1390	2.3310	2.3750	2.4586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9979	1.1203		.9619	
2			.9511	1.0719		.8962	
3			1.0829	1.0719		.8402	
4			.9694	1.0242		.9055	
5			1.0349	1.0242		.8954	
6			1.1643	.9979		.9114	
7			.9412	.9979		.8131	
8			1.1389	1.0456		1.0349	
9			1.4901			1.2637	
10	.3961	1.094	1.6787	1.0185	1.6004	1.3769	1.2071
11		1.6956	2.5463	1.2071	1.829	1.358	1.3957
12	.4119	1.7353	1.4712	1.3957	1.9052	1.9427	1.7918
13	.1677	1.7337	1.2955	1.905	1.829	1.7918	1.4901
14	.0718	1.8484	2.0748	1.4712	1.7909	1.6598	1.5278
15	.1429	2.0748	1.9805	1.5089		1.6975	2.0936
16	.1334	1.8861	2.1502	1.6787	1.7147	1.773	1.9239
17	.1658	2.0182	2.3011	1.905	2.0957	2.037	1.7541
18		1.4098	1.8671		1.226		1.1128
19		1.3908	1.4098		1.3014		1.2637
20		1.3014			1.0562		1.251
21		1.2323	1.2071		1.0829		.9511
22		.8869	1.2449		1.2071		1.2012
23		1.1203	1.3203		1.0642		.9877
24			.9511	1.1203		.8589	
Max	.4119	2.0748	2.5463	1.905	2.0957	2.037	2.0936
Min	.0718	.8869	.9412	.9979	1.0562	.8131	.9511
Avg	.2128	1.5305	1.4465	1.2685	1.5156	1.2788	1.4251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4435	.7095		.5281	
2			.3761	.6653		.679	
3			.4024	.6653		.5975	
4			.3294	.6219		.6413	
5			.3681	.6219		.5788	
6			.2778	.543		.6908	
7			.4784	.3658		.6602	
8			.4999	.5121		.4066	
9			.4557	.8299		.7733	
10	.3395	.7922	.9242	.6287	.8676	.9242	1.0374
11		.6036	.9054	.8299	.7621	.7842	.9808
12	.2267	.5658	.8299	.9431	.6859	.7167	.9619
13	.2561	.8299	.6413	.6979	.7621	.9242	.8865
14	.3077	.5975	.5415	.4715	.8383	.8865	.9431
15	.2774	.547	.7545	.5847	.7621		.9335
16	.3189	.5093	.9054		.6859	.6413	.9619
17	.2686	.5093	.724	.9431	.8764	.8676	1.0669
18		.547	.6413		.5716		.547
19		.6535	.6413		.6287		.6413
20		.4344			.6602		.4668
21		.6535	.4344		.724		.6602
22		.6602	.5601		.6859		.6413
23		.4163	.6413		.3961		.4435
24			.5975	.7095		.4954	
Max	.3395	.8299	.9242	.9431	.8764	.9242	1.0669
Min	.2267	.4163	.2778	.3658	.3961	.4066	.4435
Avg	.2850	.5943	.5815	.6672	.7076	.6939	.7980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1317	1.1812		.7842	
2			1.0185	1.1431		.9242	
3			1.0751	1.1431		.6653	
4			.9619	1.0562		.8775	
5			.8962	1.0562		.9522	
6			1.0456	.924		1.0164	
7			.4973	.583		.5548	
8			.4424	.583		.5144	
9			.6767	.8676		1.3392	
10	.3772	.8501	.9145	.8962	1.0669	.9808	.8865
11		.9431	1.0185	1.2071	1.2193	1.1317	1.358
12	.4161	1.1694	1.3957	1.3957	1.448	.9997	.8676
13	.1257	1.5466	1.3203	1.0185	1.5242	1.3203	.9431
14	.096	1.3203	1.3957	1.3957	1.5623	1.5466	.9054
15	.0629	1.0562	1.1506	1.3203	1.3336	1.1317	1.0562
16	.064	1.2449	1.3957	1.2637	1.2574	1.2449	.9054
17	.3932	1.1694	.4338	1.1694		1.5089	.7922
18		1.2637	.9808		.5914		.7282
19		.6584	.5609		.9431		1.2449
20		.6268			.4207		1.1317
21		1.094	.5281		.5426		.3487
22		.9997	.679		.8215		.5375
23		1.2637	.7922		.9808		.6068
24			1.1694	1.1812		.6908	
Max	.4161	1.5466	1.3957	1.3957	1.5623	1.5466	1.358
Min	.0629	.6268	.4338	.583	.4207	.5144	.3487
Avg	.2193	1.0862	.9339	1.0770	1.0548	1.0102	.8794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.1687	2.8578		1.6409	
2			2.7726	2.9721		2.6029	
3			3.2253	2.9721		2.7726	
4			2.9424	2.8578		2.8858	
5			3.3722	2.8578		2.6595	
6			2.9721	2.7435		2.8006	
7			2.8006	2.7435		3.0556	
8			2.6863	2.4897		1.5844	
9			1.5278	2.7161		1.829	
10	.4801	.5201	2.7161	2.3765	3.2253	3.2819	2.7161
11		1.8673	3.1121	2.7161	3.1687	1.9433	1.5278
12	.1166	1.9239	1.3443	3.0556	3.2819	.7207	2.6595
13	.0117	2.8006	2.8858	2.7726	3.2819	1.5123	2.9424
14	.056	.5201	1.9433	1.5278	3.2253	.2195	1.6409
15	.0082	1.4003	3.0556	2.6595	3.0864	2.6863	1.6409
16	.1263	2.7161	3.2253	2.7726	2.8578	3.1121	3.2253
17	.1263	.4087	2.7161	2.7161	3.0556	2.1502	1.9239
18		.3395	2.7435		1.5278		1.9239
19		2.8292	1.6975		3.2819		2.037
20		.3138	1.5844		3.1687		1.7718
21		1.9433	3.2007		2.1148		1.6004
22		3.2819	3.0864		3.3385		3.2253
23		2.915	2.9721		3.2819		2.0576
24			3.2253	2.8578		3.1121	
Max	.4801	3.2819	3.3722	3.0556	3.3385	3.2819	3.2253
Min	.0082	.3138	1.3443	1.5278	1.5278	.2195	1.5278
Avg	.1322	1.6986	2.7074	2.7036	2.9926	2.2539	2.2066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 201 / 11 KV Shivaji Road Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 202 / 11 KV Filter House Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 203 / 11 KV Darga Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 204 / 11 KV Laxmi Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 205 / 11 KV Shivneri Chowk

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
4	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.7842	.7922	.7356	.7922	.7545	.6908
2	.5281	.811	.7545	.7545	.7922	.7733	.7167
3	.5281	.7842	.6413	.7733	.7922	.7922	.7207
4	.6097	.811	.6478	.7545	.7545	.7922	.7545
5	.6097	.811	.6478	.6097	.7922	.6097	.7545
6	.6097	.7842	.6478	.7356	.7922	.6097	.7282
7	.7356	.811	.7733	.7545	.7922	.7922	.7392
8	.7356	.8299	.7733	.7356	.7733	.811	.7468
9	.7356	.6668	.6413	.6097	.7733	.811	.6097
10	.7733	.7356			.7545	.7922	.811
11	.7733	.7545	.2957	.8299	.7545	.7922	.811
12	.7545	.7545	.7282	.811	.7545	.7468	.811
13	.7545	.7545	.7468	.811	.7545	.7733	.7922
14	.6287	.7545	.7282	.8215	.7545	.7922	.7922
15	.6478	.7356	.7356	.7922	.7545	.7922	.7922
16	.7733	.7545	.7167	.7922	.7545	.7733	.7922
17	.7733	.7356	.7356	.7922	.7545	.7922	.7922
18	.7655	.7545	.7545	.811	.7356	.5415	.811
19	.7922	.7545	.7733	.811	.7545	.7842	.6668
20	.6478	.7356		.6668	.6097		.6668
21	.6478	.6036	.6097	.439	.6602	.6036	.6668
22	.6859	.6348	.7356	.6478	.6668	.6036	.8589
23	.811	.7922	.7356	.7922	.811	.6036	.7922
24	.5281	.811	.7922	.7356	.7922	.811	.7356
Max	.811	.8299	.7922	.8299	.811	.811	.8589
Min	.5281	.6036	.2957	.439	.6097	.5415	.6097
Avg	.6824	.7566	.7003	.7398	.7550	.7369	.7522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	1.0498	1.1222	.9922	1.0029	.9922	.8596
2	1.1203	1.0029	1.0498	.9922	.905	.9816	.8505
3	1.0642	.9774	.9145	.9671	.8316	.9465	.8507
4	.9896	.9313	.9145	.9774	.8131	.9671	.8059
5	.9149	.8869	.8413	.8954	.8048	.9313	
6	.8779	.8954	.8413	.905	.8316	.9412	.7522
7	.905	.8688	.8596	.8505	.8871	.8326	.7164
8	.8775	.8238	.924	.8589	.8507	.7442	.7421
9	.9231	.8413	.924	.8589	.8505	.7973	.8063
10	1.0692	.9991		.9991	.9671	.8859	.8238
11	1.2894	1.2489	1.7353	1.2536	.9214	1.1871	1.0099
12		1.3032	1.5769	1.3289	1.2715	1.1999	1.1041
13		1.3611	1.4842	1.3289	1.2715	1.182	1.086
14	1.6297	1.3394	1.4266	1.3213	1.2803	1.1946	1.0277
15	1.4815	1.3394	1.3717	1.3575	1.2986	1.1888	1.0498
16	1.4842	1.3535	1.4148	1.3352	1.3253	1.2127	1.0387
17	1.4118	1.4083	1.4661	1.39	1.3535	1.2489	1.0566
18	1.448	1.3643	1.5181	1.4706	1.3112	1.3535	1.0985
19	1.7375	1.6476	1.7896	1.701	1.6126		1.283
20	1.6301	1.7878		1.6124	1.7002		1.3696
21	1.3643	1.4148	1.406	1.5261	1.3112	1.2715	1.2094
22	1.2094	1.1999	1.262	1.2445	1.1871	1.1765	1.2226
23	1.1641	1.2197	1.1999	1.1043	1.1163	1.0608	1.0745
24	1.1157	1.0745	1.1222	1.0387	1.0029	1.0277	.8859
Max	1.7375	1.7878	1.7896	1.701	1.7002	1.3535	1.3696
Min	.8775	.8238	.8413	.8505	.8048	.7442	.7164
Avg	1.2192	1.1808	1.2348	1.1796	1.1128	1.0602	.9880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9055	1.0349	.823	.7733	.7545	.6602
2	.8962	.8962	1.0164	.8048	.7545	.7468	.6348
3	.8316	.8686	.961	.8131	.6908	.7023	.6036
4	.7762	.8871	.961	.8501	.6838	.7023	.6224
5	.7762	.9055	.9997	.8688	.7207	.6722	.6348
6	.8488	.8962	.9997	.8048	.7356	.6979	.5975
7	.8501	.8686	.9795	.8402	.7577	.679	.5729
8	.8326	.8869	1.0534	.7682	.7023	.6908	.6161
9	.8869	1.0099	1.0498	.7783	.6335	.6468	.5853
10	.8505	1.0517		.815	.6584	.6335	.5973
11	.9134	1.1163	1.1163	.8682	.6219	.7421	.5731
12	.8954	1.0229	1.0745	.8131	.6219	.724	.6089
13		1.0631	1.1041	.8507	.6653	.724	.567
14		1.0631	1.4266	.8869	.6908	.7167	.6535
15		1.1041	.9593	.8686	.7207	.7468	.6908
16	.9593	1.086	.9671	.8059	.7316	.7316	.6535
17	.7964	1.0317	.8954	.7701	.7392	.695	.6219
18	.8962	1.0745	1.0277	.8507	.567	.6838	.6653
19	1.0608	1.2269	1.2403	.9511	.8145		.7783
20	1.086	1.3253		.9145	.8686		.8871
21	1.1765	1.2308	1.0608	.9328	.8299	.8501	.8775
22	1.0974	1.1946	1.0164	.9522	.9242	.8589	.9054
23	1.0242	1.0631	.9522	.823	.8676	.7577	.8299
24	.8962	.924	1.0349	.8402	.7733	.7733	.6979
Max	1.1765	1.3253	1.4266	.9522	.9242	.8589	.9054
Min	.7762	.8686	.8954	.7682	.567	.6335	.567
Avg	.9165	1.0293	1.0423	.8456	.7311	.7241	.6723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2883	1.2003	1.086	1.1088	1.1088	1.0974	1.0288
2	1.1203	1.1431	1.086	1.0974	1.1088	1.0974	.9717
3	.9979	1.2003	.9671	1.0425	1.0642	1.0317	.9717
4	.9425	1.1431	.9671	1.0317	1.0642	1.0425	.9145
5	.9522	1.0288	.9671	.8688	1.0642	1.0317	.9145
6	.9522	.9717	.9877	.8871	1.0642	.9774	.8573
7	.8779	.9717	.8596	.7682	.8871	.9979	.8573
8	.8145	.9145	.8505	.8145	.823	.8779	.8002
9	.9231	.8145	1.086	.8688	.8688	1.0288	.8596
10	.8596	1.0517		.9882	1.0317	1.086	1.0099
11		1.1568	1.3717	1.2489	1.086	1.1431	1.1694
12		1.1694	1.3717	1.1946	1.086	1.1431	1.1043
13		1.1163	1.3146	1.086	1.0974	1.086	1.0631
14	.4344	1.0631	1.2574	1.2071	1.1643	1.1431	1.0745
15	.4938	1.2357	1.3146	1.3169	1.3169	1.2574	1.2489
16	.4887	1.182	1.3146	1.1403	1.1403	1.086	1.2489
17	1.0288	1.0631	1.1523	1.1403	1.1403	1.1431	1.1283
18	1.0288	.9991	1.1163		1.086	1.0288	1.1283
19	1.2003	1.0923	1.1443	1.182	1.0099		.9991
20	1.2003	1.1963	.0309	1.086	1.0745		1.0517
21	1.2574	1.2226	1.0208	.1052	1.1163	1.086	1.0631
22	1.3146	1.262	.7602	1.1523	1.2071	1.1431	1.1946
23	1.3717	1.3432	1.1643	1.1643	1.1643	1.2003	1.1946
24	1.2883	1.3146	1.2489		1.1088	1.1643	1.086
Max	1.3717	1.3432	1.3717	1.3169	1.3169	1.2574	1.2489
Min	.4344	.8145	.0309	.1052	.823	.8779	.8002
Avg	.9922	1.1190	1.0626	1.0227	1.0785	1.0860	1.0392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
 NO- Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3429	.3258	.3326	.1052	.3841	.3429
2	.3361	.3429	.3258	.3292	.1109	.439	.4001
3	.2772	.3429	.3224	.3292	.112	.4344	.3429
4	.2772	.3429	.3224	.2172	.112	.3292	.2858
5	.3361	.3429	.3224	.2172	.112	.3258	.2858
6	.3361	.2858	.3292	.3326	.056	.4344	.2286
7	.3292	.2858	.1075	.3292	.3881	.3881	.2286
8	.3258	.3429	.2658	.3258	.439	.3841	.4572
9	.3258	.2715	.1143	.3258	.2172	.4001	.3761
10	.3224	.2629		.3121	.4344	.2286	.2126
11	.3224	.3155	.2858	.1629	.3258	.4572	.4784
12	.3292	.3189	.3429	.4344	.2172	.2858	.4733
13	.1646	.2658	.3429	.2715	.439	.2286	.4252
14	.3801	.2658	.3429	.439	.2218	.4572	.4298
15	.3841	.2686	.3429	.2743	.2195	.5144	.4344
16	.3258	.2686	.3429	.4344	.3801	.2858	.4344
17	.1143	.2658	.1646	.4344	.3801	.5144	.2686
18	.3429	.3155	.2126	.4298	.4887	.1143	.4298
19	.3429	.3121	.3121	.2686	.2658		.1052
20	.1715	.3121	.0463	.1086	.4835		.1052
21	.1715	.3189	.0537	.0526	.4784	.4001	.1063
22	.1715	.3155	.3258	.1097	.2743	.4572	.4887
23	.4001	.3224	.3292	.1109	.2772	.2286	.4344
24	.3361	.3429	.3258	.3326	.1109	.4435	.4572
Max	.4001	.3429	.3429	.439	.4887	.5144	.4887
Min	.1143	.2629	.0463	.0526	.056	.1143	.1052
Avg	.2983	.3072	.2698	.2881	.2770	.3698	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.086	1.0242	.9145	.9717	.8869	.8676
2	1.1431	1.0479	.9877	.8954	.9526	.8779	.8299
3	1.0669	1.0098	.9877	.8573	.9145	.8779	.8299
4	.9717	.9907	.9511	.9526	.8954	.8326	.7922
5	.9145	.8383	.9511	.8764		.7682	.7922
6	.8573	.8383	.8048	.8002	.8192	.7133	.7545
7	.8192	.8192	.7499	.7811	.8002	.6878	.7167
8	.8002	.7811	.7682	.7621	.8002	.6697	.7167
9	.7811	.8192		.8002	.7811	.7922	.7356
10	.8326	.8383		.8145	.7621	.7167	.7733
11	.9593	.9335		.8869	.8048	.7545	.8954
12	.8962	.9717	1.2384	.924	.7964	.7167	.8954
13	.7865	1.0098	1.086	.9694	.9412	.7922	.8383
14	.8413	1.0288	1.0669	.9145	.9412	.7922	.9335
15	.8145	1.0479	1.0479	.9328	.8145	.7922	.9335
16	.9955	1.0098	1.1431		.7964	.8215	.8954
17	.9412		1.105	1.0608	.8145	.7922	.9335
18		1.0479	1.086		.7783	.8299	.9907
19	1.2193	1.086	1.3336		1.0425	1.094	1.105
20	1.2955	1.3352	1.3908		1.2071	1.094	1.2574
21	1.2574	1.2803	1.1812		1.1888	1.094	1.1812
22	1.2003	1.166	1.086		1.134	1.0185	1.105
23	1.2003	1.2254			1.0974	.9431	1.0479
24	1.2765	1.1431	1.1222	.9526	.9907	1.0317	.9054
Max	1.2955	1.3352	1.3908	1.0608	1.2071	1.094	1.2574
Min	.7811	.7811	.7499	.7621	.7621	.6697	.7167
Avg	1.0039	1.0154	1.0556	.8880	.9150	.8496	.9053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.105	1.0242	1.1241	.8764	.924	.8299
2	1.0098	1.0479	.9877	1.086	.8192	.8871	.7922
3	.9907	.9907	.961	1.0669	.9145	.8871	.7922
4	.9526	.9335	.961	1.0288	.8954	.8589	.7545
5	.8954	.9145	.924	.9526	.9526	.8501	.7545
6	.8573	.8954	.8316	.8764	.9145	.7947	.7545
7	.8383	.8764	.7762	.8383	.8573	.7207	.7167
8	.8002	.8954	.7947	.8573	.8192	.7392	.7167
9	.7811	.8573		.8764	.8383	.7133	.7167
10	.7577	.8383		.8962	.8764	.7922	.811
11	.4435	.8002		.9055	.8131	.7922	.8002
12	.4435	.8383	1.1241	.924	.8871	.8299	.8573
13	.4572	.8573	1.0098	.9795	.823	.8676	.8573
14	.462	.8764	.9717	.8871	.8316	.8676	.8192
15	.9877	.8573	.9717	.961	.8501	.8402	.8383
16	.924	.9526	1.0098	1.0164	.8779	.8589	.8192
17	.3841	.9145	1.0098	.9328	.823	.7922	.7811
18		.9526	.8573		.7577	.8676	.8573
19	1.1812	1.0164	1.1812		.9795	1.0374	.9907
20	1.2574	1.2012			1.0903	1.0185	1.1241
21	1.3146	1.1643	1.2003		1.0719	1.0185	1.105
22	1.2384	1.2197	1.2765		1.0608	.9808	1.0479
23	1.2193	1.2012			1.0608	.7545	.9907
24	1.1431	1.1431	1.1157	1.1431	.8573	.9979	.8676
Max	1.3146	1.2197	1.2765	1.1431	1.0903	1.0374	1.1241
Min	.3841	.8002	.7762	.8383	.7577	.7133	.7167
Avg	.8880	.9729	.9994	.9640	.8978	.8621	.8498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8573	.8402	.8192	.7621	.8029	.679
2	.8192	.8383	.8215	.8002	.743	.7842	.679
3	.8002	.8002	.8215	.8192	.7621	.7842	.6413
4	.7811	.7621	.8029	.8573	.7621	.7468	.6413
5	.743	.743	.7842	.8764	.7811	.7468	.6036
6	.743	.724	.8215	.8954	.7811	.7095	.6413
7	.724	.7049	.7842	.7621	.8002	.7282	.679
8	.7049	.6859	.8402	.724	.7811	.6348	.7167
9	.724	.7811		.8002	.8573	.5975	.7922
10	.7842	.8383		.6535	.7049	.7733	.6722
11	.6161	.7049		.6722	.8215	.7167	.7811
12	.5975	.6478	.5906	.7095	.7468	.7167	.724
13		.7621	.8954	.8775	.7842	.6036	.743
14	.6161	.7811	.9335	.8589	.7842	.679	.7621
15	.6348	.8002	.8764	.8402	.7468	.7167	
16	.8589	.8002	.8383	.8402	.8029	.6413	.7811
17	.9149	.6668	.8954	.8962	.7842	.7167	.8002
18		.8764	.8002		.8215	.7167	.8383
19	.7049	.8402	.9907		.9335	.8299	.8764
20	.9717	.9149	.9526		.9522	.679	.9145
21	.9145	.9335	.724		.8775	.7545	.8383
22	.8192	.8402	.9717		.6908	.7922	.8002
23	.9145	.8029			.6908	.6036	.7621
24	.8573	.8764	.9522	.8573	.7811	.8402	.7167
Max	.9717	.9335	.9907	.8962	.9522	.8402	.9145
Min	.5975	.6478	.5906	.6535	.6908	.5975	.6036
Avg	.7765	.7909	.8469	.8089	.7897	.7215	.7428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811		.7392	.8002	.7811	.7392	.6602
2	.7621	.743	.695	.7811	.7621	.7023	.6413
3	.743	.724	.695	.7811	.743	.7023	.6413
4	.7049		.6767	.7621	.724	.6722	.6036
5	.6859	.7049	.6838	.724	.7049	.6468	.6036
6	.6478	.7049	.695	.6859	.6859	.6348	.5658
7	.6287	.6478	.6535	.6287	.6668	.6036	.5281
8	.6097	.6097	.6036	.5716	.6287	.5359	.5281
9	.6097	.5716		.5716	.5906	.5359	.4904
10	.5304	.5335		.5729	.5525	.5658	.4904
11	.5359	.5335		.5304	.5359	.5601	.4763
12	.5175	.5144	.6287	.5544	.5304	.5415	.4763
13	.5359	.5335	.6097	.5729	.4938	.5228	.5144
14	.5487	.5335	.6287	.6099	.5487	.5228	.5144
15	.5729	.5335	.6097	.6468	.5175	.5658	.5144
16	.5487	.5716	.6287	.6219	.5487	.5601	.5144
17	.5175	.5716	.6097	.5914	.5121	.5281	.5144
18		.6097	.5716		.5359	.6036	.5525
19	.6859	.6838	.8002		.7392	.7545	.6859
20	.8954	.9145	.8573		.8501	.7922	.8764
21	.9145	.9425	.743		.8501	.7545	.8573
22	.9145	.9328	.8764		.8686	.7545	.8192
23	.8573	.9055			.8596	.7167	.7621
24	.8002	.8002	.8131	.8002	.8002	.7762	.679
Max	.9145	.9425	.8764	.8002	.8686	.7922	.8764
Min	.5175	.5144	.5716	.5304	.4938	.5228	.4763
Avg	.6760	.6736	.6909	.6560	.6679	.6372	.6046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.9145	.8589	.9335	.8002	.7842	.679
2	.8764	.8573	.8215	.9145	.7621	.7468	.6602
3	.8383	.8383	.7842	.8383	.743	.7468	.6413
4	.7811	.8192	.7842	.8002	.7049	.7095	.6224
5	.743	.7811	.7842	.7811	.6859	.6722	.6036
6	.7049	.724	.7095	.743	.6668	.6348	.5658
7	.6859		.6535	.724	.7049	.6161	.6036
8	.8002	.743	.6908	.7621	.7621	.6348	.6602
9	.8573	.9145		.8002	.7811	.7468	.8299
10	1.0082	1.086		1.1203	.381	.9619	.9431
11	1.1949	1.2003		1.307	1.1576	.9054	1.1431
12	1.2136	1.2574	1.4289	1.3256	1.1949	.9808	1.1431
13	1.2323	1.2384	1.467	1.3256	1.2696	1.0082	1.105
14	1.307	1.2193	1.3527	1.3443	1.2136	1.0185	1.105
15	1.3817	1.2193	1.3146	1.3817	1.2323	1.0185	1.1241
16	1.3256	1.3336	1.3527	1.3817	1.2696	.9709	1.1431
17	1.0829	1.2955	1.4098	1.3256	1.2136	.8676	1.1431
18		1.2955	1.2955		1.1576	.8488	1.086
19	1.4289	1.307	1.4861		1.2752	1.094	1.1812
20	1.4289	1.4377	1.5242		1.363	1.0562	1.2003
21	1.2003	1.4003	1.2193		1.1949	.9808	1.1241
22	1.105	1.1576	1.105		1.0456	.9054	1.0288
23	1.0479	1.1016			.9709	.7545	.9526
24	.9145	.9526	.9709	.9717	.8192	.8402	.7167
Max	1.4289	1.4377	1.5242	1.3817	1.363	1.094	1.2003
Min	.6859	.724	.6535	.724	.381	.6161	.5658
Avg	1.0458	1.0910	1.1007	1.0434	.9737	.8543	.9169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2007	2.8578	2.9081	3.0864	2.8578	2.4434	2.6595
2	3.0864	2.7435	2.8532	2.915	2.6863	2.2805	2.5463
3	2.9721	2.6863	2.7149	2.7435	2.5149	2.3045	2.4331
4	2.8578	2.6292	2.4977	2.6292	2.4577	2.3045	2.32
5	2.7435	2.572	2.4434	2.4577	2.3434	2.1948	2.1502
6	2.572	2.4006	2.3348	2.4006	2.4006	2.1176	2.1502
7	2.4006	2.4577	2.3891	2.4577	2.5149	2.009	2.2634
8	2.5149	2.5149	2.3891	2.5149		2.2497	2.2634
9	2.572	2.6292		2.572		2.2262	2.3765
10	2.7692	3.4294		3.0407	2.915	2.7161	2.7161
11	3.6214	3.7723		3.5837	3.4751	3.1687	1.6004
12	3.7466	4.0009	4.6296	3.6923	3.8552	3.2253	3.658
13	3.8009	4.0009	4.1152	1.9204	3.8009	3.3951	3.7723
14	3.6923	4.0581	4.0581	3.9506	3.786	3.3608	3.7151
15	3.638	4.0581	4.2867	4.0181	3.7466	3.3608	3.7151
16	3.8009	3.9438	4.1152	4.1701	3.7311	3.3608	3.7723
17		3.8866	4.1152	3.9638	3.6923		3.7151
18		4.1152	4.1724		3.5294	2.1502	3.7151
19	4.0009	4.0181			3.9095	1.8107	4.0581
20	4.2295	4.7782			4.225	1.6975	4.2867
21	4.401	4.2353			3.8009	3.7346	3.8295
22	3.3722	3.5294			3.2579	3.1687	
23	3.2007	3.3665			3.0407	2.9424	3.2007
24	3.315	2.9721	3.0178	3.2007	2.915	2.6606	2.7726
Max	4.401	4.7782	4.6296	4.1701	4.225	3.7346	4.2867
Min	2.4006	2.4006	2.3348	1.9204	2.3434	1.6975	1.6004
Avg	3.2958	3.4023	3.3150	3.0732	3.2480	2.6471	3.0300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2584	5.487	5.4893	5.144	5.144	5.1532	4.4136
2	5.2012	5.2584	5.3772	5.0869	4.9726	4.9291	4.257
3	5.144	5.144	5.3212	5.0297		4.9291	4.2438
4	5.0297	5.0869	5.1532	4.9726	4.6296	4.8171	4.1872
5	4.8583	4.9726	5.0926	4.8011	4.4582	4.7611	4.2438
6	4.6868	4.9154	4.9291	4.5153	4.5725	4.537	4.1872
7	4.5153	4.6868	4.5931	4.5725	4.6868	4.313	4.1307
8	4.6296	4.7439	4.8731	4.5725		4.369	4.0741
9	4.7439	5.0297		4.7439		3.5288	4.0741
10	4.5931	5.2012		4.8171	5.0297	4.6399	4.369
11	4.5931	5.8871		5.6573	5.2652	5.2058	5.2012
12	3.3608	6.1728	6.8587	5.8253	5.2652	5.4321	5.3727
13	2.4086	5.9442	6.4586	5.7133	5.3212	4.9794	5.2012
14	4.0175	5.8299	5.9442	5.9934	5.5453	5.0926	5.2012
15	4.313	6.1157	6.0014	6.0494	5.6013	5.3189	5.2584
16	5.2092	6.1157	6.23	5.9934	5.6013	5.0412	5.3155
17	5.7133	6.0014	5.8299	5.7693	5.8814	5.3189	5.144
18		5.9442	5.8299		5.3772	4.481	5.5441
19	5.8299	6.1614			5.6013	5.7716	5.3727
20	6.6301	6.8336			5.9934	4.9794	5.487
21	6.8016	6.5535			6.0494	5.4321	5.0869
22	5.8299	6.2174			5.7133	5.2058	4.9154
23	6.23	6.1614			5.6013	4.6399	4.8011
24	5.3155	5.7156	5.8253	5.2584	5.2584	5.3212	4.5268
Max	6.8016	6.8336	6.8587	6.0494	6.0494	5.7716	5.5441
Min	2.4086	4.6868	4.5931	4.5153	4.4582	3.5288	4.0741
Avg	4.9962	5.6742	5.6129	5.2509	5.3128	4.9249	4.7754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.9431	1.0374			.9997	.7373
2	1.0374	.8916	.9997			.9431	.6859
3	1.0185	.8916	.9997			.9431	.6516
4	1.0185	.8916	.9997			.9431	.6516
5	1.0374	.8916	.9997		.823	.9431	.6687
6	.9808	.8916	.9619		.823	.9808	.7545
7	.9619	.8745	.9431		.8916	.9054	.7716
8	.9054	.823	.9054		.8573	.8865	.7888
9	.9808	.9431	.9242		.9054	1.0631	.9431
10	1.094	.9997			1.0562	.8573	1.0185
11	1.1506	1.1883			1.1128	.9259	1.0562
12	1.2637	1.2637	1.4335			.9602	1.1694
13	1.2449	1.3014	1.358		1.1694	.9602	1.1317
14	1.2449	1.2826	1.3769		1.2071	.9602	1.094
15	1.2449	1.3203	1.4146		1.226	.9602	1.1694
16	1.1883	1.3203	1.4146		1.2449	.9774	1.2071
17		1.2637	1.3203		1.2071	.9259	1.1694
18	1.0631	1.1883	1.3014		1.1694	.9602	1.2071
19	1.2174	1.4335	1.4712		1.358	1.1488	1.3392
20	1.3032	1.5089			1.3392	1.1488	1.3769
21	1.2003	1.4146	1.4146		1.2826	1.0802	1.3014
22	1.2003	1.358	1.3203		1.2637	1.0288	1.2637
23	1.1488	1.2826	1.2826		1.1694	.9774	1.1694
24	1.1883	1.0117	1.1317	1.1128		1.0374	.8573
Max	1.3032	1.5089	1.4712	1.1128	1.358	1.1488	1.3769
Min	.9054	.823	.9054	1.1128	.823	.8573	.6516
Avg	1.1212	1.1325	1.1910	1.1128	1.1170	.9799	1.0077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0857	.0943		.0686	.0943	.0686
2	.0943	.0857	.0943		.0686	.0943	.0686
3	.0943	.0857	.0943		.0686	.0943	.0686
4	.0943	.0857	.0943		.0686	.0943	.0686
5	.0943	.0857	.0943		.0686	.0943	.0686
6	.0943	.0857	.0943		.0686	.0754	.0686
7	.0754	.0686	.0754		.0686	.0754	.0686
8	.0754	.0686	.1132		.0686	.0754	.0686
9	.0943	.1132	.1509		.0754	.1029	.0943
10	.1132	.1698			.1509	.1372	.132
11	.1132	.1698			.1698	.12	.1509
12	.1509	.1886	.2452		.1886	.1372	.1698
13	.1132	.1698	.1886		.1698	.12	.1509
14	.1132	.1509	.2075		.1509	.12	.1509
15	.132	.1886	.1886		.1698	.1543	.1509
16	.1132	.1698	.1886		.2075	.1372	.2075
17	.1029	.1886	.1886		.1698	.1543	.1886
18		.1509	.1698	.1543	.132	.1029	.1509
19	.1029	.1509	.1132	.1372	.1132	.1029	.132
20	.1372	.1509			.132	.1029	.1509
21	.1372	.132	.1132	.1029	.1132	.1029	.132
22	.12	.132	.132	.1029	.1132	.1029	.132
23	.12	.132	.1132	.1029	.1132	.1029	.1132
24	.0943	.0857	.1132	.1132	.0857	.1132	.0686
Max	.1509	.1886	.2452	.1543	.2075	.1543	.2075
Min	.0754	.0686	.0754	.1029	.0686	.0754	.0686
Avg	.1076	.1290	.1365	.1189	.1168	.1088	.1177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9609	3.8066	4.1872	3.9043	3.2407	3.678	2.9321
2	3.7912	3.7037	4.0741	3.7912	3.2407	3.5648	2.7263
3	3.7912	3.7037	4.0741	3.7912	3.2407	3.5648	2.7263
4	3.8477	3.7037	4.0741	3.7912	3.2407	3.5648	2.7263
5	3.9609	3.6008	3.9609	3.8477	3.2407	3.5648	2.8292
6	3.6214	3.5494	3.9043	3.4517	3.1379	3.5082	3.035
7	3.7346	3.4465	3.7912	3.3385	3.3951	3.3951	3.0864
8	3.7346	3.4465	3.8477	1.8673	3.2922	3.4517	3.0864
9	3.9043	3.9043	4.0175		3.2819	3.3951	3.3385
10	4.0175	4.3004		3.3385	4.0175	3.4465	3.5648
11	3.5082	4.7531		4.4702	3.8477	3.9095	4.0741
12	2.0936	4.7531	5.3755	4.7531	4.0175	4.0124	4.0175
13	1.1317	4.7531	4.9794	4.357	4.2438	3.6523	3.9609
14	2.8858	4.6965	4.5833	4.6965	4.1307	3.9609	4.0175
15	3.0556	4.8097	4.8097	4.6965	4.4136	3.8066	4.2438
16	4.1872	4.7531	4.7531	4.6399	4.1872	3.8066	4.0741
17	3.7551	4.5268	4.5833	4.1152	4.357	4.0638	3.9609
18	4.1667	4.5833	4.6399	4.4753	4.1307	3.3951	4.3004
19	4.784	5.3189	5.2058	4.784	4.5268	4.321	3.9043
20	4.7325	5.6019	.2263	4.7325	4.9228	3.6008	4.1872
21	4.321	4.9228	4.3004	3.2407	4.5268	4.8354	4.0175
22	4.2181	4.7531	4.2438	3.7551	4.357	3.858	4.6399
23	4.4239	4.8663	4.5268	3.7551	4.357	3.3951	4.0741
24	4.1872	4.1152	4.5268	4.1872	3.3436	3.9609	3.4979
Max	4.784	5.6019	5.3755	4.784	4.9228	4.8354	4.6399
Min	1.1317	3.4465	.2263	1.8673	3.1379	3.3951	2.7263
Avg	3.7423	4.3489	4.2130	3.9904	3.8621	3.7380	3.6259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.7207	.695	.7095	.6099	.6653	.6348
2	.7095	.7207	.7023	.7023	.6161	.6099	
3	.7095	.6653	.7023	.7023	.5601	.6099	.6099
4	.6722	.6653	.6722	.679	.5601	.6099	.6161
5		.6653	.6722	.6653	.5658	.6099	.6099
6	.679	.6653	.679	.6722	.6413	.6401	.6099
7	.6413	.7023	.6979	.6348	.5847	.6283	.5975
8	.5847	.5914	.8402	.5975	.4904	.5359	.5228
9	.5544	.5544	.5601	.5601	.499	.499	.5304
10	.5611	.543	.5544	.5228	.4435	.5175	.4938
11	.112	.5487	.5359	.4481	.4805	.5175	.439
12	.112	.5487	.5975	.4854	.4108	.5228	.4435
13	.1698	.5487	.5914	.4854	.4854	.5601	.499
14	.1698	.5914	.6348	.5359	.5415	.5228	.499
15	.1509	.6099	.6348	.5544	.5175	.5601	.5228
16	.1494	.5914	.5914	.5729	.5175	.5914	.5415
17	.112	.5914	.5853	.4805	.5175	.5359	.499
18	.7947	.5914	.543	.462	.4755		.6036
19	.7964	.7316	.631	.7133	.6584	.7059	.6036
20	.8596	.7964	.7602		.7964	.7316	.8048
21	.8775	.8413	.6878	.7682	.7964	.7682	.8048
22	.8688	.8507	.7392	.7865	.7964	.6219	.823
23	.8326	.8507	.7947	.7316	.7964	.7392	.7468
24	.7392	.7682	.7499	.7655	.6838	.7316	.6348
Max	.8775	.8507	.8402	.7865	.7964	.7682	.823
Min	.112	.543	.5359	.4481	.4108	.499	.439
Avg	.5460	.6648	.6605	.6189	.5852	.6102	.5952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4435	.4938	.5041	.462	.4481	.4108
2	.4294	.4435	.462	.4668	.4668	.4108	.3881
3	.4294	.4435	.4066	.4294	.4668	.4108	.3881
4	.4294	.4066	.4108	.4294	.4294	.4108	.3841
5	.4338	.4066	.4108	.4294	.4338	.4108	.3881
6	.4338	.3881	.415	.4294	.4338	.3921	.3921
7	.4338	.4251	.4715	.415	.415	.4108	.415
8	.4338	.4066	.4294	.4108	.4904	.3921	.3961
9	.4294	.4251	.4294	.4108	.3921	.3921	.3921
10	.4435	.4251	.4108	.3921	.3734	.3921	.3547
11	.4435	.4066	.4108	.3921	.3734	.4294	.3734
12			.462	.3921	.3881	.462	.3511
13			.4435	.3921	.4066	.4854	.3696
14		.4207	.462	.4854	.4294	.3361	.3921
15	.5415	.4805	.5228	.3921	.4108	.4294	.3734
16	.4854	.4066	.4668	.3921	.3921	.3921	.4108
17	.4481	.4108	.4435	.3921	.3881	.3881	.3921
18	.4668	.4572	.4668	.3921	.3881		.462
19	.5359	.567	.5792	.567	.5304	.5792	.499
20	.6219	.6154	.543		.6219	.5853	.5914
21	.6036	.6335	.5973		.5304	.5914	.5914
22	.6036	.6335	.6219		.5487	.5304	.6099
23	.5853	.6219	.5788	.6468	.567	.4805	.5729
24	.4805	.4938	.5304	.5228	.5175	.4805	.4294
Max	.6219	.6335	.6219	.6468	.6219	.5914	.6099
Min	.4294	.3881	.4066	.3921	.3734	.3361	.3511
Avg	.4845	.4710	.4779	.4421	.4523	.4452	.4303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6401		.6653	.5975	.5544	
2	.6161	.6219		.6722	.5601	.5544	
3	.6161	.6219		.6099	.5601	.5544	
4	.6161	.6283		.6099	.5281	.5544	
5	.6161	.6283		.6099	.5281	.5544	
6	.6602	.6283	.6602	.6099	.547	.5544	
7	.7356	.7207	.8402		.6602	.6283	
8	.6908	.6838	.7655	.7095	.7356	.6099	
9	.823	.961	1.0534	.7865	.8962	.6099	
10	.8507	1.0498	1.0719	.8413	.9522	.499	
11	.9328	1.086		.8413	.924		
12	.9511		1.1458	1.0242	.9795		.0381
13	.9877		1.0829	.2801	.9979		.0381
14	.9425	.9774	1.1016	.8686	.9511		.0572
15	1.1827	1.0317	1.2012	.8871	.9877		.0572
16	1.0719	1.0164	1.0903	1.0059	1.0164		.0572
17	.924	.7392	.9979	.8779	.8871		.0572
18	.7947	.7392	.9145	.8779	.8413		.0373
19	.7023	.8048	.8507	.7392	.7682	.0166	.0373
20	.7682	.8779	.7392		.7865		
21	.7499	.7682	.7316	.6653	.695		
22	.7499	.6584	.695	.6838	.6584		
23	.7133	.7316	.6722	.5359	.6036		
24	.6653	.6401	.7499	.6653	.6348	.5853	
Max	1.1827	1.086	1.2012	1.0242	1.0164	.6283	.0572
Min	.6099	.6219	.6602	.2801	.5281	.0166	.0373
Avg	.7905	.7843	.9091	.7303	.7624	.5230	.0475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 201 / 11 KV Doordarshan
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.905	.9511	.905	.7796	.8413	.823
2	.8326	.8326	.8871	.8507	.7164	.8048	.7682
3	.8048	.7964	.8501	.7602	.6447	.7499	.7682
4	.7682	.7602	.8501	.7682	.6447	.6767	.7682
5	.7682	.724	.8029	.7682	.6447	.6767	.7682
6	.7682	.724	.7468	.7316	.6805	.7316	.7095
7	.7316	.7783	.695	.7682	.7682	.7783	.7392
8	.724	.695	.6878	.6878	.6584	.7343	.6767
9	.6878	.6584	.7865	.7059	.6878	.724	.6767
10	.7964	.6878	.7783	.788	.6767	.6878	.6767
11	.7964	.6878	.7602	.6878	.695	.6878	.6697
12	.905	.6878	.724	.7059	.6516	.6516	.7164
13	.6878	.6516	.724	.7059	.724	.6878	.6733
14	.6516	.6878	.7602	.724	.6335	.6584	.6201
15	.7392	.6878	.7964	.7343	.7059	.6584	.6447
16	.7762	.724	.7964	.7343	.7282	.695	.5792
17	.7392	.724	.7602	.7164	.7059	.6154	.7964
18	.695	.7421	.7164	.7522	.6626	.6733	
19	.8328	.9412	.9134	.8505	.8505	.8059	.8326
20	.905	.9593	.9492	.7442	.8859	.8596	.8596
21	.9412	.9774	.9671	.7442	.8326	.8775	.8238
22	.9412	1.0974	.9313	.9214	.9511	.8775	.8238
23	1.0136	1.1157	.985	.8859	.9145	.8413	.8238
24	.9774	.9412	1.0242	.9412	.815	.8779	.823
Max	1.0136	1.1157	1.0242	.9412	.9511	.8779	.8596
Min	.6516	.6516	.6878	.6878	.6335	.6154	.5792
Avg	.8079	.7995	.8268	.7743	.7358	.7447	.7418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 202 / 11 KV WALCHAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)
1		.3921
2		.3361
3		.3361
4		.2801
5		.2801
6		.5041
7		.6653
8		.6161
9		.7655
10		.8589
11		.8131
12	.0566	.9511
13	.056	.8048
14	.0747	.7316
15	.2957	.8413
16	.5121	.9145
17	.6154	.7499
18	.5975	
19	.6584	.8048
20	.5914	.695
21	.5914	.724
22		.6878
23	.1509	.6516
24		.3361
Max	.6584	.9511
Min	.056	.2801
Avg	.3818	.6409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8823	1.8107	1.7558	1.7187	2.2497	1.5364	1.4266
2	1.7918	1.701	1.6461	1.6632	2.0851	1.4266	1.3717
3	1.701	1.6461	1.5364	1.5364	2.0851	1.4266	1.3352
4	1.5364	1.5912	1.5364	1.5364	2.0851	1.3717	1.262
5	1.5364	1.5912	1.5524	1.5364	2.0851	1.3717	1.262
6	1.5364	1.5364	1.4969	1.4815	1.9753	1.3717	1.262
7	1.4815	1.5364	1.4969	1.4815	2.0513	1.3575	1.3306
8	1.4661	1.4661	1.4815	1.4118	1.9753	1.3575	1.3169
9	1.5203	1.5203	1.4969	1.5203	1.9004	1.2489	1.3352
10	1.701	1.5746	1.6461	1.6461	1.9404	1.2489	1.5729
11	1.7558	1.6832	1.8107	1.7741	2.1068	1.4842	1.6263
12	1.7558	1.6832	1.9204	1.8296	2.0851	1.448	1.6827
13	1.8107	1.6289	1.8656	1.9404	2.0302	1.5203	1.5384
14	1.8107	1.7918	1.9204	1.9404		1.5524	1.7194
15	1.885	1.8461	2.009	1.9753	1.9753	1.4998	1.6644
16	1.9204	1.7918	2.009	1.9753	1.8656	1.5364	1.6644
17	1.8656	1.7918	1.9547	1.9753	1.8461	1.5927	1.6644
18	1.8107	1.7558	1.9004	2.1399	1.7558	1.5927	1.8656
19	2.1176	2.1399	2.2805	2.3045	1.9547	1.9004	2.0119
20	2.1719	2.2262	2.1176	2.0851	2.0633	1.8099	2.1216
21	2.009	2.1176	1.9004		1.9204	1.647	1.8823
22	2.009	2.1399	1.9753	2.6886	1.9204	1.5746	1.7918
23	2.0633	2.0851	1.9753	2.6337	1.8107	1.5546	1.7375
24	1.9185	1.9753	1.9204	1.8296	2.4143	1.6461	1.4815
Max	2.1719	2.2262	2.2805	2.6886	2.4143	1.9004	2.1216
Min	1.4661	1.4661	1.4815	1.4118	1.7558	1.2489	1.262
Avg	1.7941	1.7763	1.8002	1.8532	2.0079	1.5032	1.5803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 206 / 11 KV DATTANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788	.7522	.7964	.7316	.6805	.6878	.6516
2	.7522	.7164	.7059	.6767	.6516	.6154	.5973
3	.724	.6805	.6878	.6584	.5792	.6154	.5973
4	.6878	.6447	.695	.6516	.5792	.5792	.5973
5	.6516	.6089	.695	.6516	.5792	.5792	.5973
6	.6516	.6447	.695	.6335	.5792	.5792	.567
7	.6516	.6447	.724	.5973	.5792	.5731	.5792
8	.6089	.591	.6154	.5552	.5792	.6024	.5249
9	.5373	.6089	.5853	.5373	.5731		.5249
10	.2835	.5316	.5792	.4961	.5249	.567	.4706
11	.2804	.567	.543	.5493	.5068	.5316	.4656
12	.2804	.567	.5792	.5316	.4835	.4961	.4607
13	.5959	.567	.5792	.543	.4656	.5316	.4908
14	.5609	.6024	.6154	.5792	.5014	.5316	.4961
15	.5853	.6024	.6878	.6024	.5373	.4961	.5316
16	.5487	.6024	.6516	.6024	.5373	.5316	.4961
17	.5487	.6024	.6154	.567	.5373	.5258	.5068
18	.5068	.6024	.6089	.6024	.4656	.5434	
19	.6447	.6733	.7442	.7164	.6241	.6836	.6878
20	.7164	.815	.724		.6935	.691	.724
21	.7522	.8505	.6836	.8596	.7265	.6733	.724
22	.8238	.8688	.7964	.8238	.7964	.6733	.724
23	.8775	.905	.8507	.788	.8326	.6878	.724
24	.8417	.8059	.8326	.8048	.7522	.7602	.6516
Max	.8775	.905	.8507	.8596	.8326	.7602	.724
Min	.2804	.5316	.543	.4961	.4656	.4961	.4607
Avg	.6208	.6690	.6788	.6417	.5986	.5981	.5822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.6461	1.5203	2.1948	.2172	.2195	
2	2.1216	1.6827	1.7924	2.3529	.1829	.2195	
3	2.1948	1.829	2.2177	2.4691	.181	.2195	
4	2.4874	2.1948	2.5972	2.5339	.2195	.2561	
5	2.7069	2.5606	2.8959	2.652	.2587	.3258	
6	3.2922	3.2922	3.1459	2.5339	.2926	.3982	
7	3.658	3.5117	3.2217	.3439	.3258	.394	
8	3.5117	3.2922	3.0361	2.5606		1.6827	
9	2.9264	3.5117	3.0407	2.7149	1.7918	2.6337	.1629
10	.3582	.2534	.3258	1.9547	2.5606	2.9199	.1646
11	.3982	.2926	.3258	2.1033	2.9995	3.1093	.181
12	.4024	.2172	.3258	2.3167	2.9995	3.2579	.2926
13	.3658	.2534	.3475	2.4143	2.9264	3.1459	.2896
14	.362	.2926	.3439	2.4434	1.9753	2.8959	.3109
15	.362		.333	2.4874	2.1948	2.7069	.3077
16	.3258		.3475	.2172	.2865	.2534	.2896
17	.3258		.3439	.2561	.2865	.2195	.2926
18	.3258	.2172	.3109	.2561	.3224	.2172	.3077
19	.3224	.2926	.3258	.2715	.394	.2195	.3109
20	.4298	.2896		.2743	.4656	.2534	.3077
21	.4656	.2561	.3475	.2534	.4344		2.0119
22	.394	.2561	.3258	.2561	.3658	.2172	2.1719
23	.362	.2172	.3258	.2172	.2926	.2195	2.3777
24	1.829	1.6095	1.3169	3.6008	.2195	.2561	
Max	3.658	3.5117	3.2217	3.6008	2.9995	3.2579	2.3777
Min	.3224	.2172	.3109	.2172	.181	.2172	.1629
Avg	1.3308	1.3318	1.2658	1.6533	.9649	1.1409	.6520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3169	1.2936	1.2437	1.1888	1.0974	1.0242
2	1.2071	1.2803	1.2437	1.2489	1.1584	1.0974	1.0136
3	1.1706	1.2437	1.2803	1.262	1.1946	1.0974	1.0425
4	1.2071	1.2437	1.3394	1.2308	1.2308	1.134	1.0498
5	1.2308	1.267	1.3169	1.1888	1.2437	1.1222	1.0974
6	1.3394	1.3032	1.3032	1.1584	1.267	1.1584	1.0974
7	1.3756	1.3611	1.3535	1.1403	1.2437	1.2178	1.1222
8	1.3611	1.4327	1.3676	1.1523	1.3032	1.2308	1.0974
9	1.4327	1.4327	1.5364	1.2489	1.3756	1.2894	1.0692
10	1.6476	1.448	1.4661	1.4632	1.5203	1.3575	1.1706
11	1.6118	1.5364	1.4632	1.4842	1.4327	1.4118	1.1218
12	1.576	1.5927	1.448	1.5364	1.3611	1.4632	1.1888
13	1.4327	1.6461	1.4632	1.5524	1.3253	1.4118	1.1765
14	1.3611	1.6651	1.4118	1.4632	1.3611	1.3717	1.1946
15		1.6461	1.4661	1.2308	1.3253	1.3032	1.1946
16		1.6289	1.4815	1.3169	1.4327	1.2803	1.2308
17		1.6827	1.4842	1.3756	1.5043	1.3169	1.262
18		1.4784	1.448	1.4998	1.576	1.267	1.267
19		1.6095	1.4449	1.448		1.2437	1.3169
20	1.7909	1.6289		1.5364	1.6118	1.3032	1.3032
21	1.7193		1.4299	1.4632	1.448	1.2803	1.3352
22	1.576	1.5927	1.4632	1.3032	1.3169	1.1222	1.3213
23	1.5927	1.4998	1.4937	1.2803	1.2803	1.0974	1.2986
24	1.3169	1.4632	1.3169	1.3717	1.2308	1.1706	1.0498
Max	1.7909	1.6827	1.5364	1.5524	1.6118	1.4632	1.3352
Min	1.1706	1.2437	1.2437	1.1403	1.1584	1.0974	1.0136
Avg	1.4331	1.4783	1.4050	1.3416	1.3449	1.2436	1.1686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0732	.1097	.1097	.1448	.1463	.1086
2	.0732	.0732	.1086	.1086	.1463	.1463	.1097
3	.0732	.0732	.0732	.1097	.1629	.1463	.1294
4	.0732	.0732	.0724	.1086	.1829	.1829	.128
5	.1086	.0914	.0732	.128	.2172	.2172	.1448
6	.1086	.0905	.1097	.1267	.2195	.2896	.1463
7	.0905	.0905	.0924	.1267	.0724	.0716	.1086
8	.0732	.0724	.0732	.1463	.0366	.0543	.1829
9	.0549	.0724	.0724	.1448	.0362	.0724	.1829
10	.0537	.0914	.0914	.0366	.0549	.0732	.181
11	.2172	.2715	.1753	.0366	.0543	.0543	.181
12	.2926	.2743	.4024	.0543	.0362	.0549	.2195
13	.2926	.3258	.439	.0366	.0362	.0543	.2896
14	.2926	.3658	.4344	.0362	.0362	.0362	.3109
15	.2896	.3801	.4344	.0366	.0362	.0549	.362
16	.2172	.3658	.4525	.0543	.0358	.0543	.1267
17	.2534	.3258	.4572	.0549	.0537	.0549	.128
18	.2534	.4024	.4572	.0366	.0537	.0724	.1267
19	.0716	.0724	.1267	.0543	.0716	.0914	.1097
20	.0895	.0724	.1097	.0732	.1075	.0905	.1086
21	.0895	.0943	.1097	.1463	.1829		.1086
22	.0716	.0905	.1086	.1478	.1829		.1097
23	.0724	.1097	.1086	.1646	.1463	.1463	.1086
24	.0732	.0732	.0924	.1097	.1086	.1463	.1448
Max	.2926	.4024	.4572	.1646	.2195	.2896	.362
Min	.0537	.0724	.0724	.0362	.0358	.0362	.1086
Avg	.1399	.1677	.1993	.0912	.1007	.1050	.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1463	.181	.1086	.1448	.1097	.1848
2	.1463	.1463	.1463	.1097	.1097	.1097	.1829
3	.1463	.1463	.1478	.1267	.1109	.1097	.181
4	.1829	.1463	.1829	.128	.1463	.1463	.1991
5	.181	.181	.2172	.1448	.181	.1448	.2012
6	.2172	.181	.2195	.1448	.2172	.1448	.1991
7	.181	.181	.181	.1448	.2012	.1791	.1829
8	.1791	.1448	.1463	.1463	.1991	.181	.1448
9	.1075	.1448	.181	.1448	.1829	.1433	.1629
10	.1791	.1463	.1646	.1227	.1448	.1448	.1646
11	.1791	.1448	.1629	.1267	.1448	.1097	.1629
12	.1791	.1097	.1063	.1463	.1433	.1267	.1829
13	.1433	.1267	.1646	.1448	.1433	.1646	.181
14	.1075	.1086	.1629	.128	.1433	.2033	.2012
15	.1075	.1097	.1629	.1448	.1433	.2561	.1991
16	.1433	.1448	.1646	.1097	.1791	.2534	.181
17	.1433	.1097	.1629	.1086	.1791	.2172	.1829
18	.1433	.1267		.1463	.2149	.2195	.181
19	.2149	.1829	.1448	.1829	.2149	.2218	.2012
20	.2149	.1629		.2172	.2149		.1991
21	.2149	.1829	.1267	.181	.181	.2896	.1829
22	.1791	.181	.128	.1646	.1829	.2561	.1629
23	.181	.1829	.1267	.1448	.1463	.2534	.1646
24	.1829	.1463	.181	.1086	.1463	.1463	.2195
Max	.2172	.1829	.2195	.2172	.2172	.2896	.2195
Min	.1075	.1086	.1063	.1086	.1097	.1097	.1448
Avg	.1667	.1493	.1619	.1406	.1673	.1796	.1836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.2172	.2561	.181	.2561	
2	.2195	.1829	.2534	.2534	.1829	.2561	
3	.2195	.1829	.2561	.2561	.2172	.2561	
4	.2561	.1829	.2957	.2715	.2561	.2926	
5	.2534	.2172	.3292	.2743	.181	.2896	
6	.362	.362	.3258	.2896	.3292	.362	
7	.362	.3224	.3292	.2715	.362	.3582	
8	.3582	.2865	.362	.2743	.2926	.362	
9	.3582	.2865	.3658	.2715	.2896	.3224	.181
10	.3224	.2896	.3439	.2507	.2561	.3292	.1829
11	.2865	.3292	.3292	.2195	.2896	.2896	.181
12	.2865	.2896	.3258	.2715	.2865	.2896	.1646
13	.2865	.2561	.2896	.2561	.2865	.2561	.1629
14	.2865	.2896	.2896	.2534	.2149	.2534	.1646
15			.3109	.2926	.2149	.2195	.1629
16			.3077	.2896	.2507	.2172	.1448
17	.2149		.3258	.2561	.2507	.2561	.1463
18	.2149	.2195	.2896	.2195	.2865	.2172	.1629
19	.2149	.2534	.2926	.2743	.3582	.2561	.1646
20	.2865	.2561		.3258	.4298	.2534	.1629
21	.2865	.2896	.2896	.2896	.3982		.1629
22	.2865	.2561	.2715	.2561	.3658	.2172	.1646
23	.2896	.2172	.2715	.2534	.3292	.2172	.1629
24	.2561	.2561	.2195	.2534	.2195	.2926	
Max	.362	.362	.3658	.3258	.4298	.362	.1829
Min	.2149	.1829	.2172	.2195	.181	.2172	.1448
Avg	.2785	.2593	.2996	.2658	.2804	.2748	.1648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1463	.2195	.1463	.695	.8779	.439
2	.1829	.1463	.2534	.1448	.724	.9511	.4706
3	.1829	.1463	.2561	.1463	.823	1.0974	.5121
4	.2195	.1829	.2772	.1267	.905	1.2071	.543
5	.2172	.2195	.2743	.128	1.0974	1.3032	.6036
6	.2534	.2172	.2715	.1267	1.1827	1.5565	.6468
7	.2534	.2534	.2561	1.4299	.3658	.2507	.1829
8	.1829	.2534	.2218	.1463	.3658	.2172	.6516
9	.1829	.2561	.1829	.1448	.1829	.2172	.6335
10	.2149	.2534		.1829	.1448	.1829	.6401
11	2.1719	.9877	1.0974	.181	.1448	.2033	.6335
12	2.4143	1.1222	2.268		.1448	.1829	1.0974
13	2.3777	1.5546	2.9264	.2172	.1448	.181	1.267
14		1.8099	2.8959	.2195	.1448	.2195	1.6461
15		1.9204	3.0769	.2218	.1448	.2172	1.6289
16	1.448	1.9909	2.9264	.1829	.1433	.2195	.181
17	1.5203	1.9753	2.8959	.181	.1791	.181	.1829
18	1.6651	1.6461	2.9264		.1791	.1829	.181
19		.2172	.181	.2353	.2149	.181	.1646
20	.2865	.2561		.2865	.2507	.2195	.1629
21	.2865	.2896	.1829	.5792	.8779		.1463
22	.2149	.2507	.181	.724	1.0608		.1448
23	.2172	.2172	.181	.695	.8413	.5068	.1463
24	.2195	.1829	.2172	.1629	.6516	.8413	.4344
Max	2.4143	1.9909	3.0769	1.4299	1.1827	1.5565	1.6461
Min	.1829	.1463	.181	.1267	.1433	.181	.1448
Avg	.7093	.6873	1.0986	.3004	.4837	.5090	.5558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.963	2.963	2.7435	2.8532	2.8532	3.0727	2.6337
2	2.963	3.0727	2.8829	2.8235	2.7149	3.1276	2.7149
3	2.963	3.0727	2.963	2.8532	2.6337	3.1276	2.6337
4	3.0727	2.963	2.9864	2.8778	2.3285	3.1824	2.5503
5	3.0407	2.9321	2.9081	2.963	2.1948	3.2579	2.4143
6	2.8235	2.7149	2.8235	2.9321	2.0633	3.3122	2.3348
7	3.095	3.095	2.8532	2.8778	2.5789	3.2773	2.6337
8	2.552	2.7149	2.7149	2.9081	2.7149	2.7149	2.6063
9	2.963	2.6063	2.4691	2.8778	2.1399	2.7149	2.9081
10	2.9012	2.8532	2.4434	3.3122	2.7149	2.7435	2.9321
11	2.9321	2.9321	2.524	3.1824	2.963	2.8235	3.0178
12	2.9321	2.8532	3.095	3.0407	2.963	2.963	2.9321
13	2.963	2.7149	2.4143	2.8532	2.963	2.9864	2.963
14	2.963	2.6063	2.3348	2.7435	2.963	2.963	3.1047
15	2.8532	2.8532	2.8235	2.6063	2.963	2.9864	2.963
16	2.9321	2.9321	2.963	2.524	2.7938	2.9864	2.9321
17	2.552	2.8532	2.9864	2.3891	2.9012	3.1276	2.8778
18	3.3122	2.9864	2.8532	2.2497	2.9012	3.2036	2.8532
19	2.6863	2.963	2.8532	2.7149	2.6863	3.2373	2.7692
20	2.9012	2.8235		2.963	2.9012	2.6063	2.7984
21	2.9012	2.963	2.9081	2.8235	2.6063	2.6337	2.7984
22	3.0087	2.8235	2.7692	2.7149	2.963	2.7149	2.7692
23	2.8235	2.7435	2.8235	3.0727	2.963	2.7435	2.8532
24	2.8532	2.7435	2.8235	2.8778	3.0407	3.0727	2.6063
Max	3.3122	3.095	3.095	3.3122	3.0407	3.3122	3.1047
Min	2.552	2.6063	2.3348	2.2497	2.0633	2.6063	2.3348
Avg	2.9146	2.8658	2.7809	2.8348	2.7295	2.9825	2.7750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.2075
Max	.2075
Min	.2075
Avg	.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.4748
Max	.4748
Min	.4748
Avg	.4748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDIFeeder No / Name : 204 / 11 KV Nelkaranji Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0934
Max	.0934
Min	.0934
Avg	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
14	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,
KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.4915
Max	.4915
Min	.4915
Avg	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3858	.3048	.3241	.3269	.1254	.1791	
2	.4096	.3395	.3048	.3658	.1063	.1629	
3	.4527	.3858	.3048	.3658	.1075	.1463	
4	.3906	.4725	.3749	.4938	.1075	.1478	
5	.5668	.7468	.4687	.6173	.124	.1829	
6	.9374	.9414	.9922	1.078	.1227	.2303	
7	1.3599	1.2186	1.2651	.2743	.1227		
8	1.3599	1.1574	1.3108	.3858	.3353	.3582	
9	1.2037	1.2651	1.142	.9374	.4458	.4999	
10	.1715	.2481	.156	1.0936	.6097	.787	
11	.1772	.2534	.1753	.9488	.7907	.9105	
12	.1791	.2195	.1949	.8488	.884	.9686	
13	.1417	.2743	.2172	.9602	.9686	.9998	
14	.1791	.2743	.2149	.9259	.7773	.9105	
15	.1433	.2126	.1949	.9374	.7926	.8642	.2195
16	.1734	.1989	.1949	.1791	.1907	.2229	.2303
17	.1928	.1791	.1433		.2126	.1753	.2172
18	.1595	.2214	.1448	.1402	.2534		.2561
19	.2534	.2926	.2926	.1417	.2926		.2835
20	.2378	.3142	.2534	.1417	.2835		.2896
21	.2172	.2987	.2149	.1254	.2172		.2561
22	.1991	.2402	.2149	.1254	.2378		.2218
23	.181	.1867	.1886	.1254	.2218		.2195
24	.3437	.2591	.2656	.2709	.1267	.1772	
Max	1.3599	1.2651	1.3108	1.0936	.9686	.9998	.2896
Min	.1417	.1791	.1433	.1254	.1063	.1463	.2172
Avg	.4173	.4377	.3981	.5135	.3524	.4661	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0876	.1075	.0886	.1267	.1097	
2	.0905	.0886	.0914	.0886	.1075	.0924	
3	.0914	.0876	.0914	.0701	.1063	.0886	
4	.0886	.0701	.1109	.0709	.1075	.0905	
5	.1086	.0867	.1478	.1075	.1267	.128	
6	.1829	.1387	.1848	.1448	.1433	.1867	
7	.1949	.1543	.1629	.1646	.1448		
8	.1829	.1402	.104	.1254	.1254	.1478	
9	.1357	.1267	.1052	.1417	.0995	.128	
10	.116	.1417	.124	.124	.0995	.1294	
11	.12	.128	.1402	.1417	.0886	.1387	
12	.12	.1463	.1387	.1227	.116	.1372	
13	.1341	.1294	.1372	.1417	.0995	.1214	
14	.104	.1646	.1372	.124	.1006	.1227	
15	.1029	.168	.1214	.1227	.1029	.1227	.1595
16	.1052	.128	.1387	.1402	.104	.1227	.1646
17	.1063	.1341	.0876		.124	.0995	.1629
18	.1227	.1524	.1063	.1433	.1448		.1463
19	.1629	.1578	.1753	.1433	.1646		.1595
20	.1829	.1791	.1595	.1417	.1848		.181
21	.1791	.1629	.1433	.124	.1867		.1734
22	.1612	.1254	.1267		.1595		.1629
23	.1417	.1086	.1086	.124	.1387		.128
24	.1086	.1052	.1075	.0895	.1254	.124	
Max	.1949	.1791	.1848	.1646	.1867	.1867	.181
Min	.0886	.0701	.0876	.0701	.0886	.0886	.128
Avg	.1306	.1297	.1274	.1220	.1261	.1229	.1598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.0995	.1524	.8383	1.1736	
2	.0914	.1334	.0848	.1524	.7545	1.0936	
3	.0905	.1334	.0838	.1334	.7545	1.1385	
4	.0914	.1143	.1006	.1334	.7545	1.186	
5	.0924	.1334	.1187	.1524	.9945	1.4413	
6	.128	.1524	.1326	.1715	1.326	1.6975	
7	.181	.1524	.1886	.1715	.1387		
8	.1829	.1524	.1417	.1524	.1433	.1829	
9	.1612	.1463	.1524	.1524	.1448	.1524	
10	.168	.1677	.1524	.1524	.124	.1524	
11	1.4255	.7373	1.9826	.1334	.1509	.1715	
12		1.2146	2.2377	.1524	.1052	.1715	
13		1.4232	2.343	.1334	.0983	.1524	
14		1.7185	2.4366	.1524	.1254	.1524	
15	.8886	1.8351	2.1714	.1524	.1448	.1524	
16	1.2431	1.7966	1.9826	.1334	.1017	.1143	
17	1.1633	2.1293	.5138		.1463	.1254	.1715
18	1.4586	1.7368	1.278	.1334	.1848		.1524
19	.1715	.1543	.1905	.1334	.1829		.1372
20	.1905	.2033	.1905	.1334	.2035		.1543
21	.1715	.1715	.1715	.6706	.7545		.1463
22	.1524	.1357	.1715	.7545	1.1022		.1646
23	.1524	.1187	.1524	.7545	1.0936		.1463
24	.1524	.1524	.116	.1524	.8383	1.1574	
Max	1.4586	2.1293	2.4366	.7545	1.326	1.6975	.1715
Min	.0905	.1143	.0838	.1334	.0983	.1143	.1372
Avg	.4052	.6236	.7164	.2223	.4669	.6127	.1532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1433	.112		1.0936	.2865
2	.1463	.1463	.112		1.1203	.2926
3	.1433	.1448	.1132		1.1797	.2865
4	.128	.1612	.132		1.2483	.2561
5	.1629	.1829	.1698		1.4746	.2957
6	.2172	.2614	.2263		2.1548	.2743
7	.1734	.2561	.2172		.2622	.1791
8	.1402	.2149			.1658	.6958
9	.1387	.1341				
10	.1189					.643
11	1.3717					.743
12	2.2531					.9259
13	2.372					.9907
14	2.5587					.9717
15	2.652					.8488
16	2.7035					.1296
17	2.6558					.1219
18	2.5606					.1677
19	.2012			.208		.2058
20	.2294			.2507		.1949
21	.2743			1.0608		.1829
22	.2103			.9998		.1478
23	.156			1.0364		.1294
24	.1387	.1402	.112		1.0802	.2774
Max	2.7035	.2614	.2263	1.0608	2.1548	.9907
Min	.1189	.1341	.112	.208	.1658	.1219
Avg	.9104	.1785	.1493	.7111	1.0866	.4020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4321			.181	.1478
2	.4167			.1791	.1463
3	.4424			.1629	.1433
4	.6478			.1829	.1595
5	.9282			.2263	.1734
6	1.5912			.3395	.2402
7	1.8656	1.5581		.3142	.2195
8	1.7901	1.7833		.431	.1991
9	1.704	1.6385			
10	.1619				.2012
11	.1715				.1844
12	.1886				.2012
13	.2035				.1829
14	.208				.2195
15	.2279				.2772
16	.2149				.2614
17	.2103				.2427
18	.2267				
19	.2743		.2743		
20	.298		.2947		.1715
21	.3658		.3506		.3391
22	.2865		.2402		.2915
23	.2033		.2218		.2915
24	.4167			.1829	.1433
Max	1.8656	1.7833	.3506	.431	.3391
Min	.1619	1.5581	.2218	.1629	.1433
Avg	.5615	1.6600	.2763	.2444	.2113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4801	.3658		.1612	.0693
2	.4687	.4744	.3658		.1595	.0732
3	.4801	.4801			.1791	.0739
4	.5864	.583	.4287		.2218	.0934
5	.8848	.7865	.5144		.2263	.0693
6	1.3927	1.0608	.6859		.2926	.112
7	1.6194	1.6095	.2378		.2804	.0914
8	1.704	1.4575			.6401	.0732
9	1.6385	1.3443				
10	.1423					.1362
11	.1475					.1269
12	.16					
13	.1943					
14	.2294					
15	.2374					
16	.2401					
17	.2515					.1989
18	.1638					.2012
19	.2058			.2149		.2279
20	.1578			.1646		.1715
21	.2149			.2218		.4049
22	.1829			.1848		.439
23	.1791			.1829		.3563
24	.4687	.4572	.3658		.1629	.0716
Max	1.704	1.6095	.6859	.2218	.6401	.439
Min	.1423	.4572	.2378	.1646	.1595	.0693
Avg	.5172	.8733	.4235	.1938	.2582	.1661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3734	.1494		.3258	.2641
2	.362	.3658	.1494		.3224	.2614
3	.3582	.362	.1463		.3109	.2561
4	.3814	.4024	.1646		.2896	.2686
5	.4066	.4108	.1867		.3475	.2774
6	.5228	.5281	.2075		.4854	.3772
7	.4298	.3982	.2033		.4572	.3658
8	.3326	.3582			.2957	.3361
9	.2926	.2743				
10	.2587					.2279
11	.2561					.2835
12	.2172					.3109
13	.2149					.2561
14	.2254					.2534
15	.2561					.2481
16	.2378					.2195
17	.2195					.3155
18	.3582					.443
19	.5373			.5373		.4938
20	.5853			.567		.5304
21	.6241			.6584		.4481
22	.4298			.4108		.3326
23	.3734			.3696		.3018
24	.3734	.3734	.1494		.3292	.2561
Max	.6241	.5281	.2075	.6584	.4854	.5304
Min	.2149	.2743	.1463	.3696	.2896	.2195
Avg	.3591	.3847	.1696	.5086	.3515	.3186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.12	.0869		.1128	.1014
2	.1235	.1235	.0869		.1128	.104
3	.1269	.1303	.0983		.1	.1067
4	.1448	.1486	.1014		.1014	.128
5	.1572	.1656	.1337		.1189	.1526
6	.208	.2134	.1829		.1448	.1852
7	.1646	.1738	.1715		.1646	.1875
8	.1143	.1463			.1052	.1551
9	.12	.109				
10	.0909					.0762
11	.0943					.0909
12	.1067					.0914
13	.1105					
14	.1257					
15	.1216					
16	.1296					
17	.1029					.1417
18	.1715					.1486
19	.1486			.1372		.1486
20	.1829			.1772		.1383
21	.192			.1707		.1425
22	.1707			.1296		.1383
23	.1238			.1334		.1238
24	.1217	.1183	.0869		.1097	.0987
Max	.208	.2134	.1829	.1772	.1646	.1875
Min	.0909	.109	.0869	.1296	.1	.0762
Avg	.1371	.1449	.1186	.1496	.1189	.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0838	.0732		.7682	.3155
2	.0732	.0848	.0732		.759	.3224
3	.0724	.0838	.0732		.7811	.3292
4	.0886	.0655	.0924		.8333	.3077
5	.0716	.0829	.112		.9282	.2865
6	.1006	.116	.1097		1.0526	.298
7	.1029	.1214	.12		.1478	.104
8	.0876	.1029			.0848	.3391
9	.0914	.1006				
10	.1097					
11	1.0974					
12	1.1462					
13	1.1789					
14	1.2346					
15	1.1904					
16	1.1961					
17	1.2574					
18	1.1736					
19	.12			.12		
20	.1433			.1387		
21	.1646			.7164		
22				.7377		
23	.0914			.7537		
24	.0732	.0848	.0732		.7773	.3121
Max	1.2574	.1214	.12	.7537	1.0526	.3391
Min	.0716	.0655	.0732	.12	.0848	.104
Avg	.4755	.0927	.0909	.4933	.6814	.2905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.815	1.0341	1.0745	.8905	.0953	.0762	.0953
2	.7975	1.0402	1.0517	.9259	.0953	.0953	.0953
3	.823	1.0631	1.0402	.9259	.1143	.0953	.0953
4	.8413	1.1163	1.1163	.9374	.1143	.1334	.0762
5	.8589	1.1831	1.2403	1.0753	.1334	.1143	.0762
6	.3224	1.5604	1.3496	1.2342	.0953	.1143	.0953
7		1.8959	1.576	.1334	.1143	.1143	.1143
8	.3189	1.6655	1.647	1.0155	1.226	1.1393	.1334
9	.5973	1.701	1.701	1.2498	1.5546	1.5223	.0953
10	.0762	.1524	.1143	1.3763	1.643	1.7164	.0953
11	.0762	.1334		1.5775	1.3375	1.5769	.0953
12		.1334		1.5223	1.4373	1.4918	.0953
13		.1334		1.4377	1.3432	1.5074	.1143
14	.0953	.1334	.1143	1.3146	1.475	1.595	.1143
15	.1334	.1143	.1143	1.1789	1.262	1.7013	.1143
16	.1143	.1143	.1143	.1334	.1143	.0953	.1143
17	.1334	.1143	.1334	.1143	.1334	.1143	.1143
18	.1334	.1334	.1334	.1143	.1334		.1143
19	.1524	.1334	.1524	.0953	.0953	.0953	.1524
20	.1715	.1715	.1524	.0762	.0762	.0953	.1905
21	.1715	.1715	.1334	.0953	.1143	.0762	.6485
22	.1334	.1715	.1334	.0953	.1143	.0762	.6878
23	.1334	.1143	.1143	.0762	.0762	.0762	.7701
24	.7373	.9945	.9922	.7202	.0762	.0762	.0762
Max	.8589	1.8959	1.701	1.5775	1.643	1.7164	.7701
Min	.0762	.1143	.1143	.0762	.0762	.0762	.0762
Avg	.3636	.6324	.6761	.7632	.5406	.5956	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1143	.1143	1.1104	1.2357	.6081
2	.1143	.1334	.1143	.0953	1.0692	1.1568	.6796
3	.1143	.1143	.1143	.0953	1.0749	1.363	.6226
4	.1143	.1143	.1143	.0953	1.3443	1.2757	.6401
5	.1334	.1143	.1143	.1143	1.2936	1.2136	.7537
6	.1334	.1334	.1334	.1334	1.379	1.358	.78
7	.1524	.1334	.1715	.1715	.0953	.0953	.1334
8	.1524	.1524	.1715	.1715	.1143	.1143	.6062
9	.1334	.1334	.1334	.1334	.1143	.0953	.7907
10	.1334	.1334	.1143	.1334	.1334	.1334	.78
11	1.3575	1.5249	1.543	.1524	.0953		.8495
12	1.4899	1.6817	1.8427	.1143	.0953	.1334	.7802
13	1.6095	1.7511	1.7878	.1334	.1524	.1524	.7373
14	1.4352	1.7896	1.543	.1143	.1143	.1524	.7362
15	1.3535	1.6301	1.4918	.1143	.0953	.1715	.7545
16	1.3611	1.5775	1.4548	.1524	.1143	.1334	.1334
17	1.439	1.4864	1.0454	.1334	.1334	.1143	.1143
18	1.3253	1.3998	1.1393	.1143	.1524	.1143	.0953
19	.1143	.1334	.1334	.1143	.1143	.1334	.1334
20	.1524	.1715	.1905	.0953	.1143	.1715	.1334
21	.1334	.1715	.1905	.9816	1.0387	.7888	.1143
22	.1334	.1715	.1715	1.1104	1.2254	.7888	.1143
23	.1334		.1524	1.2071	1.2696	.6154	.1143
24		.1334	.1334	.1334	1.1831	1.2449	.5624
Max	1.6095	1.7896	1.8427	1.2071	1.379	1.363	.8495
Min	.1143	.1143	.1143	.0953	.0953	.0953	.0953
Avg	.5797	.6486	.5881	.2470	.5678	.5546	.4903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5493	.6588	.7762	.7127	.1143	.0953	.0953
2	.5731	.7343	.7762	.7209	.0762	.1334	.0953
3	.5658	.7202	.7783	.7293	.0762	.0762	.0953
4	.5721	.7619	.8779	.7045	.1143	.0762	.0762
5	.6024	.815	1.0269	.8848	.1334	.0953	.0953
6	.7716	1.1218	1.1273	1.073	.0953	.0953	.1143
7	1.1218	1.3611	1.3169	.1143	.1334	.1334	.1334
8	.8326	1.1218	1.4415	.8048	.929	.8495	.1334
9	1.0387	1.267	1.4632	1.1191	1.2357	1.3535	.0953
10	.1143	.1334	.0953	1.1768	1.3443	1.2437	.0953
11	.1143	.1143	.0953	1.3146	1.1744	1.0454	.1143
12	.0953	.1143	.0953	1.2715	1.2894	1.0229	.0953
13	.0953	.1143	.0762	1.1763	1.1789	1.0277	.0953
14	.1143	.1143	.0953	1.0867	1.1317	1.046	.1143
15	.1143	.0762		1.0566	1.0867	1.2795	.0953
16	.0953	.0762	.0953	.1143	.0953	.0953	.0953
17	.1143	.0762	.1143	.1334	.1143	.0953	.0953
18	.1143	.0953	.0953	.1143	.1143	.1143	.1143
19	.0953	.1143	.1143	.0953	.1334	.1334	.1334
20	.1334	.1334	.0953	.0953	.0953	.1334	.1524
21	.1334	.1334	.1143	.0762	.0762	.1143	.4163
22	.1143	.1334	.1143	.0762	.0953	.1143	.4557
23	.1143	.0762	.1143	.0762	.1143	.1143	.5121
24	.4908	.6516	.7282	.4862	.0953	.1143	.0953
Max	1.1218	1.3611	1.4632	1.3146	1.3443	1.3535	.5121
Min	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.3617	.4466	.5055	.6339	.4603	.4418	.1506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.128	.1109	.0934	.0934	.1075	
2	.1075	.104	.1097	.0934	.0895	.1063	
3	.104	.1097	.0924	.0924	.1097	.0914	
4	.1006	.0895	.1109	.1097	.1109	.0747	
5	.1063	.0857	.128	.1294	.1097	.1075	
6	.1387	.1227	.1478	.168	.104	.124	
7	.2195	.1991	.1463	.1663	.132	.1227	.0914
8	.1663	.1646	.124	.128	.0914	.1029	.1052
9	.1267	.1294	.1052	.1063	.1433	.1267	.1294
10	.1214	.1052	.1006	.116	.12	.3681	.1075
11	.0914	.0867	.0876	.1214	.112	.0924	.1097
12	.1075	.1227	.0886	.1109	.1052	.104	.0867
13	.1029	.1052	.0895	.1075	.1433	.1147	.1109
14	.1227	.1063	.0886	.1307	.1417	.1267	.1052
15	.1097	.0895	.0716	.1387	.1494	.0937	.0829
16	.1063	.0905	.0886	.1307	.1227	.1086	.1086
17	.1086	.1075	.104	.1433	.1463	.0867	.104
18	.1109	.0838	.116	.156	.1578	.0914	.1254
19	.1214	.1254	.1578	.1612	.1612	.1494	.1867
20	.2241	.2012	.1829	.1478	.1494	.197	.1267
21	.2149	.1991	.2054	.128	.128	.1478	.1109
22	.1848	.1848	.1663	.1267	.1029	.1214	.1387
23	.1629	.1294	.1463	.1029	.1052		.1254
24	.128	.124	.112	.112	.1052	.0934	
Max	.2241	.2012	.2054	.168	.1612	.3681	.1867
Min	.0914	.0838	.0716	.0924	.0895	.0747	.0829
Avg	.1337	.1248	.1200	.1259	.1223	.1243	.1150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6278	2.2923	1.8755	1.7465	.2715	.197	
2	1.7635	2.3211	1.8309	1.8519	.2507	.1791	
3	1.8778	2.3579	1.949	2.0332	.2658	.156	
4	2.2382	2.524	2.2085	2.0062	.2401	.1829	
5	2.5034	2.8654	2.6006	2.1325	.208	.1791	
6	3.155	3.0653	3.4294	2.5265	.2454	.156	
7	3.5947	3.2251	3.3532	.2896	.2058	.2012	
8	3.219	2.3663	3.1824	1.9136	1.6461	1.9547	
9	3.12	3.0653	3.0498	2.5431	2.0972	2.8807	
10	.1949	.2303	.1928		2.4531	3.2602	
11	.1677	.1734	.1715		2.6216	3.2779	.1341
12	.1658	.1715	.1677		2.5484	3.3653	.1357
13	.1696	.1696	.1865		2.7846	3.3311	.1372
14	.2058	.1509	.1907		2.7199	3.0298	.1402
15	.2058	.1492	.1886			3.4728	.2126
16	.218	.1492	.1753		.1715	.1791	.2149
17	.2321	.1509	.1989			.2103	.1402
18	.2401	.2035	.2267		.1829	.2454	.1417
19	.2427	.2427	.2804		.1612	.2865	.2149
20	.2686	.333	.1949			.3045	.2149
21	.2804	.2835	.1772		.181		1.3032
22	.2658	.1791	.1791		.1715	.1715	1.4022
23	.2507	.1629	.1753				1.3032
24	1.5203	1.6832	1.8404	1.335	.2561	.1791	
Max	3.5947	3.2251	3.4294	2.5431	2.7846	3.4728	1.4022
Min	.1658	.1492	.1677	.2896	.1612	.156	.1341
Avg	1.1553	1.1882	1.1677	1.8378	.9841	1.2455	.4381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1433	.128	.1526	1.2125	1.8176	
2	.1372	.1417	.1294	.1372	1.326		
3	.1372	.156	.1294	.1402	1.278	1.8298	
4	.1715	.1928	.1463	.1543	1.3717	1.6766	
5	.1715	.1791	.181	.1734	3.0476	1.8482	
6	.2058	.1949	.2126	.2035	1.7901	2.0576	
7	.2035	.2103	.1715	.1991	.1372	.156	
8	.1341	.1578	.1526	.1417	.1696	.1829	.8745
9	.1696	.1595	.1341	.1612		.1791	
10	.1949	.1595	.1928		.1387	.1402	1.2309
11	1.9951	2.0576	2.572		.1646	.124	1.3032
12	2.3205	2.364	2.5652		.1433	.1402	1.3592
13	2.3061	2.0119	2.4863		.1646	.1433	1.3717
14	2.0748		2.3752		.1254	.1595	1.4022
15	2.1262	1.9393	2.3663		.12	.1595	1.382
16	2.0287	2.0481	2.4539		.1715	.197	.2172
17	2.0553	2.1382	1.9725		.1646	.1578	.1402
18		2.0119	1.8623		.2149	.1753	.1433
19	.2254	.1715	.2103		.1886	.1791	.181
20	.2686	.208	.2481		.3429	.197	.2149
21	.2454	.2103	.2126				.2149
22	.2658	.1772	.1791		1.3923	.8059	.1791
23	.2328	.1612	.1227			.7442	.1402
24	.1448	.1772	.1463	.1387	1.0608	.1715	
Max	2.3205	2.364	2.572	.2035	3.0476	2.0576	1.4022
Min	.1341	.1417	.1227	.1372	.12	.124	.1402
Avg	.7805	.7553	.8896	.1602	.7012	.6019	.6903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1097	.2743	.1063	.2427	.2774	
2	.1402	.1086	.2587	.1254	.1715	.2401	
3	.1402	.124	.2402	.1097	.1677	.2622	
4	.1543	.1254	.1829	.1433	.1658	.1658	
5	.1543	.1646	.181	.2172	.2294	.1475	
6	.1715	.1629	.2149	.3012	.2401	.12	
7	.213	.1791	.2804	.3881	.2622	.2401	
8	.3018	.2328	.1886	.3439	.2035	.1715	.1417
9	.3561	.1991	.1526	.3475	.2401	.1802	.1402
10	.3801	.197	.1791		.2715	.1433	.1075
11	.2804	.1753	.1949		.2401	.181	.12
12	.1907	.12	.1578		.1387	.1463	.1017
13	.2481	.1017	.1417		.1886	.1646	.1029
14	.2865	.0503	.1629		.1715	.1629	.1052
15	.2481	.0829	.1612		.1372	.1991	.1063
16	.181	.116	.1463		.1475	.2012	.1086
17	.1734	.1844	.156		.2294	.2507	.2454
18		.2035	.1187			.2865	.2658
19	.1991	.3601			.3277	.3292	.3077
20	.2195	.3814			.3258	.3292	.197
21	.197	.3506	.1848				.1791
22	.181	.2303	.168			.1052	.2686
23	.1829	.3045	.1463				.1402
24	.1086	.1448	.3077	.1448	.2743	.2401	
Max	.3801	.3814	.3077	.3881	.3277	.3292	.3077
Min	.1086	.0503	.1187	.1063	.1372	.1052	.1017
Avg	.2108	.1837	.1909	.2227	.2188	.2066	.1649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2195	.2012	.1417	.2427	.208	
2	.1753	.1448	.1848	.1433	.2572	.3258	
3	.1753	.1595	.1663	.1646	.2572	.3403	
4	.1715	.1612	.1646	.197	.2534		
5	.1715	.2378	.197	.2353	.3467	.2149	
6	.2058	.2715	.2303	.2835	.2561	.1734	
7	.2374	.2865	.2947	.3142	.2149	.1734	
8	.3018	.2507	.2915	.2534	.2254	.2103	.1772
9	.3391	.2172	.2204	.2561	.208	.1928	.2103
10	.2172	.1772	.2328		.2229	.2149	.1791
11	.2103	.1907	.2481		.2103	.2172	.1715
12	.2427	.1715	.2454		.2427	.1829	.1696
13	.2126	.1357	.2303		.2103	.1829	.1715
14	.2149	.1174	.2715		.2012	.2172	.1753
15	.2561	.1326	.2149		.2012	.2534	.2126
16	.2172	.1492	.2195		.208	.2561	.181
17	.208	.1844	.2427				.2103
18		.1526	.2035		.2774	.2103	.2481
19	.2715	.2915	.2507		.2915	.2561	.3258
20	.3292	.3641	.2587		.2401	.2926	.3224
21	.2507	.4031	.2218		.208		.2865
22	.2896	.3366	.2241		.2294		.2507
23	.2561	.2686	.1829			.2353	.2103
24	.181	.2534	.2172	.181	.2572	.2401	
Max	.3391	.4031	.2947	.3142	.3467	.3403	.3258
Min	.1715	.1174	.1646	.1417	.2012	.1734	.1696
Avg	.2309	.2199	.2256	.2170	.2392	.2299	.2189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	.5636
24	.7316
Max	.7316
Min	.5636
Avg	.6476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.4582
Max	1.4582
Min	1.4582
Avg	1.4582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.2929
Max	1.2929
Min	1.2929
Avg	1.2929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.6962
Max	.6962
Min	.6962
Avg	.6962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.9774
24	1.5432
Max	1.5432
Min	.9774
Avg	1.2603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 406 / 110 KV SADGURU SUGAR
FACTORY C Feeder KV- 132 /
OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1612	.1372	.12	.6554	.4915	
2	.1227	.1612	.1402	.1227	.639	.4915	
3	.1387	.1612	.1372	.1063	.639	.4915	
4	.1227	.1612	.1402	.1063	.639	.5243	
5	.1417	.1791	.1715	.1075		.5967	
6	.1715	.197	.1865	.1227		1.0774	
7	.1696	.2303	.2401	.1772		.1886	
8	.1696	.2481	.1865	.1753	.017	.1578	
9	.12	.1578	.1696	.1417	.017	.1753	
10	.12	.1696	.1372	.1402	.0848	.1715	
11	1.5746	1.6108	.1658	.104	.0848	.1677	
12		1.6956	1.576	.1543	.0678	.1341	
13		1.0288	1.3413	.1543	.0848		1.1797
14		1.0898	1.3077	.1543	.1357		1.0608
15	1.5893	1.2039	1.3735	.1357	.78		.9556
16	1.5893	1.2717	1.6409	.1357	.1886	.1715	.1696
17	1.7204	1.5939	1.1065	.12	.2058	.1372	.1715
18	1.5729	1.6956	1.1603	.1734	.2058		.2279
19	.1907	.1865		.1753	.2058		.1886
20	.2454	.2204	.1886	.2103	.2058	.1715	.2378
21	.2279	.2229	.1928	.6706	.7956	.1372	.2149
22	.2103	.2229	.1417	.7209	.852	.3429	.1629
23	.1772		.1236	.5898	.8192		.1612
24	.1417	.1595	.1578	.1214	.6554	.4588	
Max	1.7204	1.6956	1.6409	.7209	.852	1.0774	1.1797
Min	.12	.1578	.1236	.104	.017	.1341	.1612
Avg	.5075	.6100	.5271	.2058	.3799	.3382	.4300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5596	.503	.4748	.3521	.1063	.0857	.1017
2	.5533	.503	.4694	.2984	.1063	.0857	.1029
3	.5636	.5197	.5087	.3856	.1063	.0857	.1052
4	.5304	.5197	.5144	.3315	.1063	.0857	.1029
5	.57	.547	.5426	.3227	.124	.0857	.1029
6	.6962	.6299	.6443	.442	.1595		.12
7	.9054	.9503	.8648	.1543	.124	.1372	.1402
8	1.0111	.9831	.9326	.6104	.4475	.6226	.1227
9	1.0395	.9503	.8987	.6203		.7209	.12
10	.1187	.1357	.1174	.5636		.78	.1214
11		.1017	.0663	.547			
12		.1017	.1341	.5735		.78	.12
13		.1017	.1341	.5407	.7209		
14		.1187	.1227	.6226	.5898		.0857
15	.1187	.1187	.104	.6554	.6882		.1052
16	.1017	.1187	.0857	.1017	.12	.0686	.1063
17	.1029	.1017	.1214	.1372	.1372	.0678	.1227
18	.1372	.1017	.1029	.1372	.1543		.156
19	.1387	.1526		.12	.12		.1612
20	.1734	.1696	.1214	.1387	.1372	.1357	.1595
21	.1402	.1696	.12	.1402	.12	.1357	.4191
22	.1227	.1372	.1214	.1227	.1029	.1187	.3749
23	.1227		.1097	.1063	.0857		.3725
24	.4607	.503	.4748	.3944	.1063	.0857	.1187
Max	1.0395	.9831	.9326	.6554	.7209	.78	.4191
Min	.1017	.1017	.0663	.1017	.0857	.0678	.0857
Avg	.4083	.3582	.3385	.3508	.2181	.2551	.1564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.6371	.6443	.4917	.0709	.0857	.0848
2	.788	.6371	.6371	.4694	.0709	.0857	.0848
3	.8139	.6539	.6783	.547	.0709	.0857	.0848
4	.8029	.6706	.763	.583	.0709	.0857	.0848
5	.7127	.7293	.8383	.503	.0709	.0857	.0838
6	.8886	.5636	1.0343	.6706	.1063	.12	.1006
7	1.1271	1.3272	1.4074	.1017	.1227	.1372	.1187
8	1.4586	1.3108	1.5257		.5801	.6882	.1006
9	1.1603	1.2125	1.4413	.788	.5735	.9503	.1017
10	.1017	.1341	.1227	.9116	.7045	1.0288	.1187
11	.0848		.0838	.8288	.8848	1.3565	
12		.1187	.1052	.8848	.7865	1.3565	.0914
13		.1187	.1029	.8848	.5898		.0819
14		.1187	.1063	.852	.8848		.1223
15	.1017	.1187	.1219	.8848	.8848		.12
16	.1526	.1174	.1029	.0848	.1029	.1017	.12
17	.1372	.1017	.1067	.1029	.1029	.0848	.0867
18	.12	.1017	.1017	.0857	.1029		.0903
19	.1715	.1187		.0867	.12	.1187	.1387
20	.156	.1341	.104	.1052	.12	.1006	.12
21	.156	.1341		.0876	.1029	.1006	.5801
22	.1227	.1187	.12	.0886	.1029	.0848	.4778
23	.1227		.0867	.0709	.0857		.6539
24	.6203	.6371	.6443	.4973	.0709	.0857	.0848
Max	1.4586	1.3272	1.5257	.9116	.8848	1.3565	.6539
Min	.0848	.1017	.0838	.0709	.0709	.0848	.0819
Avg	.5045	.4461	.4945	.4613	.3076	.3549	.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3641	.3582	.3185	.3086		.2743	.2229
2	.3429	.3224	.3222	.3086		.2743	.2279
3	.3506	.3224	.3086	.3294		.2743	.2401
4	.3641	.3224	.3429	.3429		.3086	.2572
5	.3681	.3582	.3772	.3881		.3258	.3086
6	.4287	.4298	.4239	.4252		.3772	.3391
7	.4508	.443	.4359	.4508		.3944	.39
8	.3772	.3898	.39			.3772	.3391
9	.3772	.3681	.373	.3601		.3772	.3391
10	.3429	.3052	.3429	.3429		.3772	.285
11	.3772	.2035	.3467	.3814		.3391	
12		.2374	.3601	.3988	.3506	.3391	.39
13		.373	.3772	.3772	.3155		.3429
14		.3688	.407	.3601	.2804		.2572
15	.4115	.373	.39	.3561	.3155		.2947
16	.4334	.373	.373	.373	.2103	.2883	.298
17	.4334	.39	.3688	.3814	.3155	.2883	.3544
18	.3467	.39	.3561	.4207	1.6126		.3761
19	.4733	.4578			.4115		.4973
20	.5434	.5087	.3772		.4801	.3052	.4287
21	.4908	.4409	.4334		.4115	.2883	.3641
22	.4607	.4748	.3944		.3772	.2713	.3117
23	.4075		.3429		.3086		.2947
24	.3429	.3544	.3391	.3121		.2915	.2204
Max	.5434	.5087	.4359	.4508	1.6126	.3944	.4973
Min	.3429	.2035	.3086	.3086	.2103	.2713	.2204
Avg	.4042	.3724	.3696	.3676	.4491	.3206	.3208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1612	.1402	.1402	.1612	.1543	.0857
2	.1402	.1612	.1402	.1254	.1433	.1372	.0876
3	.1595	.1612	.1372	.1417	.1433	.1372	.0701
4	.1445	.1612	.1372	.1433	.1433	.1372	.0686
5	.1595	.1791	.1578	.1417	.1433	.1543	.0857
6	.1753	.197	.1886		.1772	.1886	.1017
7	.1772	.1772	.2058	.1543	.1595	.1715	.1543
8	.1928	.1595	.1886	.1372	.1578	.2058	.1029
9	.1595	.1734	.1696	.1715	.1227	.2103	.1029
10	.2103	.1677	.2058	.1387	.2103	.1753	.1715
11	.2279	.1509	.1907	.208	.2103	.1696	
12		.1696	.2058	.2058	.2279	.1357	.206
13		.1696	.2058	.1886	.2103		
14		.1696	.1715	.1372	.2103		.1543
15	.2103	.1696	.1734	.1357	.1578		.156
16	.1734	.1677	.1715	.1543	.1753	.1017	.1372
17	.1907	.1677		.1734	.1578	.1017	.1402
18	.1928	.1696	.1907	.2103	.1753		.1578
19	.2454	.1696		.1928	.2629		.2279
20	.298	.2347	.2058	.2303	.2279	.1357	.2715
21	.2481	.2204	.2353	.2126	.2229	.1341	.193
22	.2126	.2058	.1949	.1949	.2058	.1017	.1829
23	.1949		.1829	.1791	.1753		.1715
24	.1578	.1595	.1402	.1612	.1612	.1543	.0857
Max	.298	.2347	.2353	.2303	.2629	.2103	.2715
Min	.1402	.1509	.1372	.1254	.1227	.1017	.0686
Avg	.1919	.1749	.1791	.1686	.1810	.1503	.1416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-JUN-18
HR	Load (MW)
6	1.4419
Max	1.4419
Min	1.4419
Avg	1.4419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0537	.0509	.0532	.0537	.0686	.0339
2	.0526	.0537	.0335	.0351	.0537	.0514	.0335
3	.052	.0537		.052	.0537	.0514	.0339
4	.0701	.0537	.0335	.0526	.0537	.0514	.0335
5	.0532	.0716	.0503	.0709	.0532	.0686	.0509
6	.0876	.0895	.0848	.0876	.0532	.1029	.0509
7	.0886	.1063	.1017		.0886	.12	.0503
8	.0857	.1063	.0848	.0701	.0876	.1029	.0678
9	.0701	.0876	.0678	.0686	.1052	.1052	.0678
10	.0526	.0848	.052	.0686	.1052	.0848	.0686
11	.0867	.0509	.0526	.0693	.0701	.0678	
12		.0678	.052	.0693	.0701	.0671	
13		.0671	.0514	.0867	.0701		.052
14		.0509	.0532	.0686	.0701		.0509
15	.0857	.0509	.052	.0686	.0701		.0514
16	.0857	.0678	.0686	.0686	.0701	.0509	.0693
17	.104	.0678	.0686	.0867	.0701	.0509	.0686
18	.0867	.0678	.0686	.0867	.0701		.0724
19	.1227	.0848		.1227	.0701	.0848	.0886
20	.1402	.1017	.104	.1052	.1052	.0848	.1227
21	.124	.1187	.124	.1052	.12	.0678	.1063
22	.1063	.1029	.0876	.0886	.12	.0335	.0701
23	.0886		.0693	.0709	.0857		.0351
24	.0525	.0709	.0678	.0514	.0532	.0857	.0335
Max	.1402	.1187	.124	.1227	.12	.12	.1227
Min	.052	.0509	.0335	.0351	.0532	.0335	.0335
Avg	.0833	.0753	.0672	.0742	.0760	.0737	.0596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2328	.2328		.3647	.4096	.2753
2	.2195	.2328	.2279		.3647	.4096	.2622
3	.2172	.2353	.2229		.3647	.4096	.2591
4	.2353	.2328	.2374		.4096	.4096	.2753
5	.2743	.2804	.2683		.5087	.4641	.2949
6	.3841	.3391	.3353		.8288	1.0117	.4973
7	.394	.333	.298			.3045	.2987
8	.3366	.3224	.2804		.2286	.2303	.502
9	.3224	.2715	.2401		.2033	.2481	1.3444
10	.2987	.3292	.2715		.1402	.2481	.6325
11	1.1336	1.3565	.1928		.1715	.2328	.6483
12	1.2431	1.4419	.2401		.1646	.2353	.6874
13	1.1401	1.4575	.2155	1.3435	.181	.2686	.6636
14	.7969	1.3496	.2543	1.4752	.181	.1991	.6249
15	1.0631	1.3056	.2543	.3155	.181	.197	.5864
16	1.1869	1.166	.3506	.2572	.1829		.1417
17	1.2517	1.4074	.3429	.2774	.2195	.2402	.3582
18	1.2971	.7956	.3239	.2658	.2012	.2614	.2218
19	.3582	.3045		.362	.2987	.2987	.3174
20	.3801	.362		.362	.3772	.2614	.2957
21	.3403	.3258		.4733	.6173		.2561
22	.3077	.2926		.4748	.57	.2949	.2012
23	.2507	.2328		.3932	.5365	.2915	.1629
24	.2378	.2353	.2279		.3647	.4424	.2721
Max	1.2971	1.4575	.3506	1.4752	.8288	1.0117	1.3444
Min	.2172	.2328	.1928	.2572	.1402	.197	.1417
Avg	.5794	.6184	.2640	.5454	.3331	.3349	.4200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3812	.6299	.4694		.2667	.2303	.197
2	.3932	.5735	.4641		.2667	.2303	.181
3	.3932	.5735	.4807		.2667	.2303	.1991
4	.4096	.6133	.5197		.2667	.2303	.1949
5	.4807	.6464	.57		.2667	.2303	.2149
6	.8848	.9724	.8551		.3841	.3439	.3258
7	1.247	1.3375	1.2174			.2896	.3734
8	1.1203	1.3847	1.3565		.407	.6802	.2957
9	1.0753	1.3203	1.0898		.426	.7522	.5068
10	.2987	.3403	.2883		.5197	.6964	.2507
11	.2926	.298	.5967			.7125	.2507
12	.2534	.3155	.7701		.5898	.8002	.2481
13	.2686	.3086	.6371		.8162	.7522	.2804
14	.298	.2883	.7969	.4475	.664	.8421	.2601
15	.2915	.2915	.7956		.7202	1.0082	
16	.3052	.2883	1.0898	1.0513	.2915		
17	.333	1.4074	.9339	.8848	.3506	.3511	
18	.394	.3772	.9496	.4239	.3544	.3696	.4572
19	.4344	.4298		.4656	.3841	.3361	.4294
20	.4656	.4904		.4706	.4294	.3361	.4108
21	.4572	.4344		.4382	.4108		.5601
22	.3801	.3841		.362	.3258	.2427	.4858
23	.2865	.2896		.3048	.2686	.2195	.3521
24	.3647	.6036	.4287		.2858	.2303	.1991
Max	1.247	1.4074	1.3565	1.0513	.8162	1.0082	.5601
Min	.2534	.2883	.2883	.3048	.2667	.2195	.181
Avg	.4795	.6083	.7531	.5387	.4073	.4597	.3178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0358	.0543		.0347	.0354	.0354
2	.0354	.0358	.0537		.0347	.0354	.0358
3	.0358	.0362	.0537		.0347	.0354	.0351
4	.0354	.0358	.0543		.0347	.0354	.0351
5	.0354	.0532	.0537		.0351	.0354	.0354
6	.0351	.0716	.0701		.0514	.0543	.0354
7	.0876	.0905	.0537			.0549	.0537
8	.0857	.0934	.0905		.0366	.0716	.0709
9	.0867	.0943	.0895		.0177	.0876	.0351
10	.0857	.0747	.1086		.0347	.0876	.0693
11	.0857	.0716	.0509			.0701	.0876
12	.1052	.0716	.0876		.0857	.0867	.0686
13	.0358	.0716	.0686	.0693	.1006	.0876	.0848
14	.0543	.0543	.0332	.0678	.0857	.0857	.0678
15	.0716	.0701	.0693	.0732	.0686	.0514	
16	.0701	.0895	.0838	.0526	.0686		
17	.0537	.0724	.0678	.052	.0701	.0526	
18	.0724	.0716	.0829	.0503	.0716	.0354	.0716
19	.0732	.0914		.0701	.112	.0532	.0716
20	.0934	.112		.0701	.0934	.0537	.0895
21	.0953	.1334		.0686	.0934		.0886
22	.0953	.0762		.0686	.0914	.0532	.0709
23	.0747			.0503	.0724	.0532	.0351
24	.0354	.0543	.0549		.0347	.0354	.0351
Max	.1052	.1334	.1086	.0732	.112	.0876	.0895
Min	.0351	.0358	.0332	.0503	.0177	.0354	.0351
Avg	.0656	.0722	.0674	.0630	.0619	.0569	.0577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5556	.5247	.4062	.3479	.0709	.0716	.0469
2	.5864	.5247	.4111	.3437	.0709	.0716	.0469
3	.6173	.5556	.4111	.3521	.0701	.0709	.0625
4	.6173	.5864	.4062	.3479	.0701	.0709	.0625
5	.6327	.6173	.4586	.3593	.0701	.0709	.0625
6	.6481	.6173	.6093	.4111	.0701	.0701	.0625
7	.8642	.7407	.8223	.0848	.0693	.0709	.0781
8	.9568	.8333	.9061	.5851	.4167	.4428	.0937
9	.8642	.8179	.8697	.5624	.3086	.4475	.0781
10	.0617	.0617	.0848	.5693	.3241	.5851	.0625
11		.0693	.0514	.5401	.5247	.6249	
12		.0509	.0509	.6173	.571	.6718	.0625
13		.0686	.0686	.6327	.6327	.6562	.0625
14		.0678	.0678	.6327	.5401	.6249	.0625
15	.0617	.0514	.0686	.6173	.5401	.703	
16		.0509	.0857	.061	.0693	.0625	.081
17	.0617	.0686	.0848	.0867	.0693	.0625	.0781
18	.0926	.0848	.0857		.0693		.0781
19	.0772	.0857		.0693	.0709	.0625	.0781
20	.0772	.1017	.0678	.081	.0732	.0625	.0781
21	.0772	.1029	.0686	.0655	.0724	.0625	.3281
22	.0617	.1017	.0678	.0701	.0732	.0625	.3125
23	.0617	.0848	.0689	.0701	.0732	.0625	.3125
24	.5624	.5247	.4111	.373	.0701	.0732	.0625
Max	.9568	.8333	.9061	.6327	.6327	.703	.3281
Min	.0617	.0509	.0509	.061	.0693	.0625	.0469
Avg	.3967	.3081	.2884	.3426	.2079	.2506	.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1097	.1254	.1075	.112	.1097	.0732
2	.0914	.0914	.1267	.1063	.1109	.1097	.0732
3	.1097	.0914	.1254	.1075	.1109	.1097	.0914
4	.1463	.1097	.124	.1086	.1109	.1097	.128
5	.1646	.1463	.1433	.1075	.1294	.128	.1463
6	.1829	.1646	.181	.1448	.1478	.1663	.1829
7	.2012	.1829	.2012	.1433	.1646	.1433	.1646
8	.2195	.1829	.181	.1448	.1629	.1772	.1646
9	.1463	.1646	.1612	.1254	.1267	.1595	.128
10	.1463	.128	.1267	.1267	.0895	.124	.128
11	.1463	.0701	.1433	.1267	.0886	.128	
12	.1097	.0716	.1086	.124	.0914	.128	.128
13	.1097	.1086	.1075	.1267	.1075	.128	.128
14	.1097	.1075	.1086	.1267	.1075	.1097	.128
15	.128	.0543	.1075	.1267	.1086	.1463	
16	.128	.0537	.1075	.1433		.1463	.128
17	.128	.1086	.1267	.1227	.124	.1463	.1463
18	.1463	.1433	.128		.1612		.1463
19	.1829	.1629		.1448	.1791	.1463	.1829
20	.2012	.1991	.181	.168	.2195	.1829	.1829
21	.2012	.197	.1612	.1698	.1829	.1463	.1463
22	.1646	.1629	.1448	.168	.1646	.128	.128
23	.1463	.1448	.1254	.1307	.128	.1097	.1097
24	.1097	.128	.1254	.1086	.1307	.1097	.0914
Max	.2195	.1991	.2012	.1698	.2195	.1829	.1829
Min	.0914	.0537	.1075	.1063	.0886	.1097	.0732
Avg	.1463	.1285	.1379	.1308	.1330	.1345	.133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0564	.0587	.0743	.1029	.3475	.3384	.044
2	.0541	.0572	.0734	.0787	.3475	.3246	.0429
3	.0541	.0564	.0724	.08	.3429	.3155	.044
4	.0549	.0572	.0724	.0947	.3475	.3201	.0286
5	.0705	.0762	.0714	.096	.3658	.3246	.029
6	.0857	.0781	.0914	.0991	.3749	.3246	.0625
7	.0914	.088	.1	.1048	.096	.0806	.0309
8	.0657	.0772	.0857	.0895	.0707	.06	.0663
9	.088	.0617	.0937	.096	.0653	.056	.0463
10	.0766	.0617	.0762	.0914	.0697	.0594	.044
11	2.0119	2.5149	2.3868	.0977	.0594	.0625	.0617
12	2.2874	2.6852	2.5857	.0874	.06	.0579	.061
13		2.4863	2.6852	.0977	.064	.0716	.0457
14		2.6155	2.4577	.0943	.0549	.0707	.0648
15		2.4863	.8928	.1052	.0629	.064	
16		2.4863	2.4577	.0876	.0737	.0857	
17	1.9662	2.3594	2.4577	.0953	.0754	.0772	
18	2.2874	2.6155	2.6155	.0754	.0857	.0655	.1029
19	.088	.0892	.1048		.0983		.0857
20	.0791	.0926	.101		.1029	.0869	.0943
21	.0772	.0903	.0953				.0874
22	.0762	.0892	.0926		.1337		.0707
23	.0753	.0903	.0914	.3521	.3475	.0791	.0734
24	.0587	.0602	.0753	.1768	.3567	.3429	.0446
Max	2.2874	2.6852	2.6852	.3521	.3749	.3429	.1029
Min	.0541	.0564	.0714	.0754	.0549	.056	.0286
Avg	.4852	.8931	.8296	.1101	.1740	.1556	.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.4527	.4527	.3772	.415	.3395
2	.4904	.4527	.4527	.3772	.3395	.3772	.3018
3	.4527	.415	.3772	.3772	.3018	.3772	
4	.4527	.415	.3772	.3734	.3018	.3772	.3018
5	.4527	.4527	.3772	.4527	.3395	.3772	.3018
6	.4481	.4481	.4481	.5228	.3395	.3772	.3018
7	.5121	.5014	.439	.5914	.3772	.4527	.3395
8	.4656	.5068	.5121	.5175	.3772	.4904	.3018
9	.4961	.5316	.5853	.5731	.4435	.5792	.4435
10	.5365	.5548	.5895	.5731	.4435	.5544	.3734
11	.4961	.5792		.6024	.5014	.5792	
12	.5121	.5228	.5601	.439	.3772	.4481	
13	.3582	.5068	.5175	.5175	.4344	.4481	.4854
14	.3018	.5731	.6516	.5175	.4706	.5487	.4435
15	.5281	.5792	.5731	.631	.5544	.5544	.5792
16	.5281	.6447	.567	.631	.4961	.5792	.6024
17	.4481	.567	.5373	.5121	.5228	.5068	.4755
18	.4161	.5731	.5175	.567	.4961	.5121	.5014
19	.5014	.6024	.5731	.4755	.567		.5121
20	.5544	.7468	.6584		.6154	.6283	.5975
21	.5228	.5975	.5281		.5175	.4904	.5281
22	.5175	.5658	.5228		.4904	.415	.5281
23	.4527	.5281	.5228	.4527	.5281	.3772	.5281
24	.5281	.4527	.5281	.4527	.415	.4527	.3395
Max	.5544	.7468	.6584	.631	.6154	.6283	.6024
Min	.3018	.415	.3772	.3734	.3018	.3772	.3018
Avg	.4776	.5321	.5160	.5052	.4428	.4747	.4346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0892	.0743	.0949	.0926	.1296	.2012	.0975
2	.0857	.0753	.0937	.0949	.1334	.2073	.0991
3	.0846	.0743	.0926	.0937	.1334	.2073	.0975
4	.0846	.0724	.0937	.096	.1097	.2134	.0827
5	.1	.0753	.1107	.1094	.1128	.2134	.092
6	.1204	.0926	.1372	.1147	.1158	.2705	.1027
7	.1219	.1174	.1524	.1054	.0579	.0667	.0579
8	.1014	.1189	.1054	.125	.0587	.0734	.1276
9	.1143	.1158	.0926	.16	.0617	.0394	.0869
10		.1113	.1052	.0695	.0762	.0533	
11		2.3868	.4329	.1027	.0417	.0533	
12		2.3868	2.0729	.1	.0417	.0834	
13		2.5194	2.2283	.108	.0541	.0581	.0602
14	2.3868	2.652	1.4998	.1067		.0914	.0587
15	2.3868	2.652	1.6446	.1128	.1174	.08	.1217
16	2.5194		2.2283	.1128	.088	.0754	.0389
17	2.0729	.5716	2.5194	.1143	.0903		.0373
18	2.1765	.4694	2.3594	.1337	.1067	.048	.0373
19	.0869	.0834	.0987		.0648		.0526
20	.1219	.0772	.1054		.0695		.0657
21	.1143	.0914	.104			.1052	.0676
22	.1027	.1067	.1054		.2103	.1006	.0695
23	.104	.0937	.108	.1315	.2042	.0975	.0695
24	.0903	.0724	.0937	.0937	.1067	.1981	.0975
Max	2.5194	2.652	2.5194	.16	.2103	.2705	.1276
Min	.0846	.0724	.0926	.0695	.0417	.0394	.0373
Avg	.6532	.6561	.6950	.1089	.0993	.1208	.0772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6413	.6036	.6722	.415	.5658	.4527
2	.679	.6413	.6036	.6036	.415		.4527
3	.6413	.6036	.5658	.6036	.415	.415	.415
4	.6413	.6036	.5658	.6722	.415	.415	.4527
5	.679	.6722	.6036	.7545	.4527	.415	.4904
6	.7468	.7545	.7167	.8215	.4527	.4527	.679
7	.7392	.7392	.6348	.7392	.4527	.4527	.6722
8	.6584	.6653	.5853	.6653	.4108	.4527	.679
9	.6379	.7316	.7164	.7087	.4706	.543	.7545
10	.4252	.7087	.8322	.8063	.5373	.5731	.6722
11	.4481	.7964	.8322	.7796	.4805	.788	.7011
12	.439	.6878	.7316	.724	.4481	.7392	.6516
13	.5068	.788	.8131	.6653	.4481	.7468	.6283
14	.6653	.7964	.8505	.679	.4755	.7316	.7164
15	.7392	.7316	.7164	.7712	.5121	.8048	
16	.5853	.7712	.7796	.7712	.362	.724	
17	.5731	.7164	.7164	.6878	.5228	.5175	.7545
18	.5548	.6516	.6516	.6733	.5068	.6447	.7377
19	.6878	.724	.724		.5175		.724
20	.8215	.8215	.8215		.5281	.7023	.8048
21	.8299	.7545	.8215		.5281	.679	.7468
22	.7545	.7545	.8215		.679	.6036	.7095
23	.679	.679	.7468	.4904	.679	.5281	.7167
24	.7167	.6413	.6036	.7095	.4527	.6036	.4527
Max	.8299	.8215	.8505	.8215	.679	.8048	.8048
Min	.4252	.6036	.5658	.4904	.362	.415	.415
Avg	.6470	.7115	.7108	.6999	.4824	.5954	.6393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 401 / 33 KV KBL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2801
Max	.2801
Min	.2801
Avg	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV DUDHONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1109	.0701	.5937		.1875	.0739
2	.0905	.0914	.0716	.5693		.176	.0747
3	.0914	.0905	.0732	.5937		.1966	.0747
4	.1109	.1086	.1052	.6173		.1943	.0739
5	.112	.1109	.1029	.6481		.192	.0934
6	.1109	.1494	.1029	.8223		.3125	.1478
7	.1086	.1478	.1109	.1052		.1109	.1294
8	.1132	.1448	.1075	.1052		.0686	.2214
9	.112	.1097	.1063	.1075		.1086	.1875
10		.0995	.1052	.104		.0972	.1677
11		1.4251	1.2483	.1052			.1524
12		1.5223	1.3763	.1052		.0876	.1543
13		1.2651	1.3283	.1063	.0983		.1875
14		1.3603	1.2811	.0895	.1029	.0848	.1524
15	1.2029	1.4083	1.2651		.0701	.0867	.1326
16	1.1873	1.406	1.2483	.0678	.0655	.0924	
17	1.3763	1.3763	1.1843	.1052	.0663		.0617
18	1.2963	1.2631	1.1523	.104	.0747		.0686
19	.1387	.1029	.096		.1086		.0686
20	.1478	.1086	.1097		.1075		.0739
21	.1294	.1097	.1097		.1943	.0924	.0747
22	.1109	.1097	.0914		.1898	.0924	.0747
23	.1109	.1086	.0905		.1829	.0747	.0747
24	.1086	.1109	.0732	.5247		.1806	.0747
Max	1.3763	1.5223	1.3763	.8223	.1943	.3125	.2214
Min	.0905	.0905	.0701	.0678	.0655	.0686	.0617
Avg	.3553	.5350	.4838	.3041	.1146	.1353	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV NAGRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.3887	.3932	.08	.0848	.0648	.0732
2	.3932	.3932	.421	.081	.0857	.0671	.0762
3	.3887	.3725	.4481	.0819	.0686	.0995	.0572
4	.426	.3361	.4641	.0983	.0693	.1029	.0583
5	.421	.3932	.503	.1006	.0693	.1029	.0793
6	.4641	.3795	.5365	.1063	.0886	.1052	.0869
7	.57	.5243	.6371	.0819	.08	.104	.1017
8	.5898	.4999	.6554	.4161	.3647	.2469	.0819
9	.5571	.5967	.6516	.6036	.3239	.3239	.0686
10		.0625	.0791	.6299	.3239	.3795	.0474
11		.061	.0848	.6706	.2915	.3978	
12		.061	.0838	.7042	.2881	.3932	.0625
13		.061	.0655	.6299	.2591	.2984	.064
14		.0937	.081	.6203	.2743		.061
15	.0655	.0926	.0686		.2622	.3605	.0819
16	.0633	.061	.0693	.0518	.0709	.0556	.0819
17	.0648	.0625	.0848	.0625	.0671		.061
18	.0772	.0633	.0838	.0549	.0686		.0497
19	.0829	.0983	.104		.0972		.0762
20	.0983	.0972	.0995		.0983		.0781
21	.0995	.1029	.0781	.081	.1052	.1219	.1296
22	.081	.0914	.081	.064	.1052	.1143	.0772
23	.0949	.0686	.0772	.0819	.0983	.0716	.1134
24	.3605	.3768	.3521	.0781	.0937	.0648	.0716
Max	.5898	.5967	.6554	.7042	.3647	.3978	.1296
Min	.0633	.061	.0655	.0518	.0671	.0556	.0474
Avg	.2765	.2224	.2584	.2561	.1558	.1829	.0756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV TAKARI EXPS

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.543	.6154	.5731	.3506	.631	.4656
2	.5792	.5373	.5731	.5316	.3506	.6089	.4252
3	.5316	.5014	.6219	.5258	.3294	.6173	.4298
4	.5316	.5373	.5609	.5258	.3429	.5959	.4344
5	.543	.5792	.6024	.567	.3467	.583	.4706
6	.5731	.5853	.5792	.6154	.3961	.6241	.4607
7	.6154	.543	.724	.6089	.3189	.6859	.4706
8	.7392	.5792	.7602	.6878	.2743	.6935	.5068
9	.6878	.5792	.7682	.6584	.2774	.5201	.543
10		.6805	.6447	.6878	.3467	.5087	.7316
11		.7682	.6584	.6653	.4435	.5609	.6584
12		.5853	.6154	.5975	.3772	.5609	.6154
13		.7316	.6584	.5281	.5792	.5548	.6805
14		.724	.6516	.4904	.6219	.5548	.6805
15	.543	.7682	.6154		.5914	.6024	.6024
16	.543	.3772	.6584	.5487	.4755	.5258	.7522
17	.5373	.5731	.6089	.5729	.439		.7087
18	.4706	.6154	.567	.5975	.3856	.4252	.6447
19	.5373	.5731	.567		.4656		.7602
20	.5316	.5959	.5959		.5895		.6379
21	.5316	.6661	.5609	.3018	.5959	.362	.5959
22	.5316	.6584	.5258	.2469	.5895	.4298	.6447
23	.5014	.6584	.5316	.3326	.6173	.4607	.6024
24	.6024	.543	.6379	.567	.3658	.6516	.4607
Max	.7392	.7682	.7682	.6878	.6219	.6935	.7602
Min	.4706	.3772	.5258	.2469	.2743	.362	.4252
Avg	.5634	.6043	.6209	.5443	.4363	.5599	.5826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV NAGRALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8589	.8779	.8299	.3584	.8326	.7095
2	.8215	.8215	.8326	.7762	.3584	.8048	.7095
3	.8676	.7922	.788	.8215	.3772	.8048	.7167
4		.7922	.8589	.8676	.3772	.8326	.7922
5	.9808	.9335	.9431	.9431	.3772	.9431	.9054
6	1.1317	1.1128	1.1317	1.1317	.3961	1.094	1.0562
7	.924	.961	.924	.8779	.3696	.905	1.0082
8	.7602	.8145	.7602	.7522	.3258	.7602	.8962
9	.6805	.7087	.724	.724	.1772	.8059	.543
10		.724	.7011	.7087	.181	.6836	.4835
11		.7164	.7164	.7087	.1372	.8238	.5138
12		.7522	.7522	.7164	.5373	.7164	.8869
13		.7602	.7522	.7602	.543	.7087	.8328
14		.7522	.7964	.7421	.2149	.7164	.7421
15	.8954	.7682	.788		.5792	.7164	.695
16	.7343	.7602	.7602	.7164	.5014	.7522	
17	.788	.7164	.7164	.7087	.724		.7545
18	.7202	.7164	.6379	.703	.7602		.7628
19	.8417	.8688	.8505		1.0974		.905
20	.9979	1.0974	1.0608		.9979		.961
21	1.0349	1.1088	1.1088	.3696	.9709	1.0349	.9522
22	.9694	1.1203	1.0829	.3696	1.0829	.9335	.9335
23	.9335	.9709	.9709	.3511	.8688	.7545	.7733
24	.9054	.8775	.9335	.9484	.3584	.8688	.7356
Max	1.1317	1.1203	1.1317	1.1317	1.0974	1.094	1.0562
Min	.6805	.7087	.6379	.3511	.1372	.6836	.4835
Avg	.8808	.8544	.8529	.7394	.5280	.8246	.7943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / SATTESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.4481	.6161	.415	.4481
2	.2987	.4527	.6036	.4527	.4715
3	.3395	.5093	.6161	.4527	.4854
4	.3584	.5228	.6036	.4715	.4668
5	.4527	.5601	.6036	.4904	.4904
6	.4715	.5601	.6036	.5093	.4854
7	.4527	.5601	.5788	.4904	.5975
8	.4715	.5281	.5847	.6036	.6161
9	.4527	.5601	.6036	.6348	.5975
10	.5281	.5041	.6036	.6348	.6161
11	.5601	.5281	.6036	.6348	.6036
12	.5601	.4338	.6036	.6036	.6036
13	.5658	.5601	.6036	.6036	.6224
14	.5228	.5975	.5847	.5975	.3174
15	.5281	.5975		.6036	.5788
16	.5281	.6036	.5788	.5601	.5847
18		.6036			
Max	.5658	.6036	.6161	.6348	.6224
Min	.2987	.4338	.5788	.415	.3174
Avg	.4618	.5370	.5994	.5474	.5366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.4146	1.4937	1.4335	1.1643	1.307	1.0185
2	1.3769	1.3769	1.4335	1.4146	1.1389	1.2567	.9808
3	1.3957	1.3769	1.4335	1.3769	1.1203	1.307	.9431
4	1.4335	1.4335	1.4712	1.4146	1.1128	1.386	.9619
5	1.5089	1.4901	1.5089	1.5278	1.1694	1.5466	1.1128
6	1.6244	1.6617	1.7177	1.6244	1.1694	1.6448	1.4335
7	1.6632	1.6632	1.7002	1.6263	1.2136	1.5524	1.4937
8	1.4998	1.4661	1.4299		1.0719	1.3717	1.2197
9	1.4661	1.4506	1.3756	1.4506	.9694	1.2357	1.1403
10	1.4327	1.4685	1.6124	1.5546	.9328	1.4083	1.2851
11	1.39	1.5223	1.6832	1.5565	1.0136	1.267	1.448
12		1.5203	1.6476	1.5384	1.0136	1.1041	1.448
13		1.2986	1.6644	1.6461	1.0136	1.4118	1.4661
14	1.5927	1.5364	1.7193	1.5746	1.2536	1.3394	1.3169
15	1.5364	1.6095	1.701	1.6827		1.3352	1.3535
16	1.5565	1.5565	1.7375	1.7013	1.2715	1.3717	1.4632
17	1.6289	1.7013	1.6651	1.6832	1.3032		1.5364
18	.5847	1.7375	1.6108	1.7556	1.5043	1.4661	1.4327
19	1.7918	1.957	1.8642		.547		1.5364
20	2.0328	2.2177	2.0538		1.7924	1.2445	1.9044
21	1.9044	2.0165	1.7924		1.7556	1.3443	1.7364
22	1.7924	1.7924	1.7737	.547	1.6804	1.363	1.643
23	1.6617	1.7177	1.6244		1.6448	1.2071	1.4335
24	1.4523	1.475	1.5684	1.4712		1.3817	1.0374
Max	2.0328	2.2177	2.0538	1.7556	1.7924	1.6448	1.9044
Min	.5847	1.2986	1.3756	.547	.547	1.1041	.9431
Avg	1.5337	1.6025	1.6368	1.5042	1.2207	1.3569	1.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5658	.5847	.547	.5847	.5281	.6036
2	.5658	.5658	.5847	.547	.5658	.5658	.6036
3	.5847	.5658	.5658	.5658	.5658	.547	.5847
4	.5658	.5847	.5658	.547	.5847	.5281	.6224
5	.5847	.5847	.5658	.5658	.5658	.5658	.6224
6	.6224	.5847	.5658	.5658	.5847	.5658	.6413
7	.5658	.5658	.5281	.5847	.5658	.5658	.6413
8	.5658	.6224	.5847	.6224	.547	.6602	.6602
9	.5847	.9335	.8779	.8682	.7888	1.094	.7316
10	.5658	.9997	1.226	1.1317	1.0164	1.1128	1.1203
11	.5658	1.0374	1.3203	1.0751	1.307	1.1317	1.4523
12	.5658	1.094	1.4299	1.0185	.9709	1.1506	1.2012
13		1.0374	1.7164	.8865	1.3256	1.6409	1.1128
14	.6036	1.0242	1.9239	1.4712	1.4146	1.8296	1.4523
15	.5658	1.4901	1.8861	1.4712		1.8296	1.3392
16	.547	1.4146	1.5844		1.2071	1.3769	1.5089
17	.5093	1.2071	1.7541	1.2826	.9619		1.1883
18	.5281	.7733	.7922	.8299	.6036	.811	.6602
19	.5658	.679	.7733		.5847		.679
20	.5847	.6036	.6224		.5658	.6036	.6413
21	.5847	.5847	.5658		.5847	.6413	.6036
22	.5847	.5847	.5658		.5658	.6602	.5847
23	.5658	.5847	.547		.5281	.6602	.547
24	.6224	.5658	.5847	.5281	.5658	.5281	.6224
Max	.6224	1.4901	1.9239	1.4712	1.4146	1.8296	1.5089
Min	.5093	.5658	.5281	.5281	.5281	.5281	.547
Avg	.5740	.8022	.9465	.8394	.7633	.8908	.8510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3395	.3772	.2641		.502	.3688
2	.2829	.3395	.3584	.2641		.4915	.3647
3	.2641	.3395	.3584	.2829		.5506	.3481
4	.2829	.3584	.3584	.2641		.6401	.3521
5	.3772	.3961	.3584	.3018		.7209	.3647
6	.415	.3961	.3961	.3395		.759	.4752
7	.4066	.3921	.4338	.3547		.2614	.2054
8	.4066	.4108	.4481	.3696		.2829	.4641
9	.3881	.3921	.4066	.4066		.2641	.4902
10	.3696	.4066	.4251	.3841		.2641	.578
11	2.3158	2.1862	2.556	.3772		.2614	
12	2.3845	2.2024	2.6086	.3696		.2614	
13		2.2245	2.5425	.3696		.2427	
14	1.9524	2.3967	2.2565	.3772	.056	.2402	
15	2.0805	2.251	2.1285	.3961		.2587	.8124
16	2.0325	2.2565	2.2725	.3961	.3547	.2587	.2772
17	1.7438	2.2405	2.0241	.4251	.3326		.2402
18	1.7924	2.0005	1.9364	.4024	.2402	.2033	.2263
19	.3326	.4066	.3511		.2561		.3018
20	.3734	.4668			.2829	.2452	.2829
21	.3961	.4108	.2987		.6401	.3441	.2829
22	.3772	.4108	.3206		.6081	.4359	.3018
23	.3772	.3921	.3018		.502	.4191	.2829
24	.3018	.3395	.3734	.2829		.4961	.3856
Max	2.3845	2.3967	2.6086	.4251	.6401	.759	.8124
Min	.2641	.3395	.2987	.2641	.056	.2033	.2054
Avg	.8668	.9982	1.0387	.3488	.3636	.3820	.3703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2075	.1886	.132	.132	.1698
2	.1698	.1886	.2075	.1698	.132	.132	.1509
3	.1698	.1698	.1886	.1698	.1132	.1132	.1509
4	.1886	.1698	.1886	.1698	.1132	.1132	.1509
5	.1698	.1698	.1698	.1698	.1132	.1132	.1698
6	.1698	.1698	.1698	.1886	.1132	.1132	.1698
7	.1698	.1698	.1886	.2075	.1132	.1132	.1698
8	.1698	.3772	.3772	.3772	.2829	.3395	.3018
9	.1886	.4338	.4338	.4527	.3961	.415	.3772
10	.1698	.415	.4527	.4527	.415	.5281	.4715
11	.1698	.4338	.5281	.4527	.415	.5281	
12	.1698	.4527	.4338	.3584	.3584	.3018	.2641
13		.415	.4338	.3961	.0377		.3961
14	.1698	.4338	.4715	.4904	.4527	.4904	.5281
15	.1698	.4527	.4527	.4527		.3961	.3772
16	.1698	.4527	.4527		.415	.4527	.4338
17	.1886	.4527	.3961	.415	.3395		.3961
18	.1698	.4527	.3961	.3584	.3395	.3018	.3395
19	.1886	.3018	.3018		.2263		.3018
20	.1886	.2641	.2641		.1886	.1698	.2263
21	.1886	.2263	.2075	.1509	.1509	.2263	.132
22	.2075	.2452	.1886		.1509	.2075	.1509
23	.2075	.2452	.1886	.1132	.1132	.1886	.132
24	.1886	.2075	.2263	.2263	.1132	.132	.1698
Max	.2075	.4527	.5281	.4904	.4527	.5281	.5281
Min	.1698	.1698	.1698	.1132	.0377	.1132	.132
Avg	.1796	.3120	.3136	.2980	.2272	.2623	.2665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1612	.1991	.1629	.1254	.1254	.112
2	.1463	.1254	.1629	.1463	.1254	.1267	.0934
3	.1463	.1254	.1448	.1463	.1086	.128	.0943
4	.1448	.1448	.1448	.1448	.1097	.1433	.0943
5	.1448	.1448	.1791	.1448	.128	.1629	.0943
6	.1629	.1629	.197	.1612	.1478	.1646	.1294
7	.2126	.1907	.2126	.1907	.181	.1772	.1646
8	.1715	.1907	.1715	.1677	.1734	.1595	.1448
9	.1696	.1357	.1543	.1509	.1402	.1696	.156
10	.1844	.1457	.176	.1492	.156	.1578	.1417
11	.1341	.1457	.1638	.1696	.1492	.1543	.1372
12	.1457	.1372	.1619	.1492	.1492	.1677	.1509
13		.1543	.1734	.1526	.1341	.1402	.124
14	.156	.1433	.156	.156	.1372	.1402	.124
15	.1578	.1387	.1433	.1543		.1595	.1578
16	.1372	.1372	.1526	.1677	.1387	.1595	.1543
17	.116	.1326	.1372	.1823	.1526		.1658
18	.1174	.1844	.1526	.1658	.1341	.1387	.1475
19	.156	.1734	.2012		.1715		.1734
20	.1991	.197	.1991		.1629	.1715	.1448
21	.1991	.197	.181		.1663	.1646	.1478
22	.181	.1791	.1829		.1829	.1307	.168
23	.181	.1791	.181		.1478	.1307	.1494
24	.1629	.1612	.197	.1629		.1294	.112
Max	.2126	.197	.2126	.1907	.1829	.1772	.1734
Min	.116	.1254	.1372	.1448	.1086	.1254	.0934
Avg	.1604	.1578	.1719	.1592	.1465	.1501	.1367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.679	.5658	.2829	.5658	.5658
2	.547		.6413	.5658	.2829	.547	.5658
3	.547	.5658	.6413	.5847	.3018	.5847	.5658
4	.5658	.5658	.5658	.547	.3018	.5658	.5847
5	.5658	.5281	.6602	.5658	.3206	.5281	.5847
6	.5847	.2641	.6602	.5847	.3018	.5658	.6036
7	.6036	.2641	.6602	.5847	.3395	.5658	.5847
8	.6036	.3018	.6413	.5847	.2641	.5281	.5847
9	.5658	.5281	.5658	.547	.2829	.5281	.7733
10	.4715	1.5466	.6602	.547	.4338	.5093	.8488
11	.5658	1.3769	.7356	.5847	.5658	.9054	1.094
12	.547	1.0185	.6224	.5281	.3772	1.0374	1.2637
13	.5658	.8865	.7095	.8299		1.094	.7356
14	.5847	.7922	1.2826	.547	.547	.6602	.9808
15	.5847	.811	1.2826	.8676		1.3203	1.6975
16	.6036	.7922	1.1523	.5093	1.0751	1.2449	1.5466
17	.6036	.679	1.1317	.3961	1.094		1.2826
18	.5847	.7356	1.0751	.3018	1.0562	.547	.7356
19	.5847	.7167	.6036		.547		.5847
20	.6036	.679	.5847		.6413	.5281	.4904
21	.6036	.6602	.547	.2829	.5847	.5658	.4904
22	.5847	.679	.5658	.3018	.6224	.5847	.5093
23	.5847	.679	.5658	.3206	.6224	.5847	.5658
24	.5847	.5847	.679	.547	.3018	.5658	.5847
Max	.6036	1.5466	1.2826	.8676	1.094	1.3203	1.6975
Min	.4715	.2641	.547	.2829	.2641	.5093	.4904
Avg	.5753	.7052	.7464	.5315	.5067	.6876	.7843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0492	.0343	.6718		
2	.0343	.0492	.0343	.6718		
3	.0343	.0492	.0343	.6718		
4	.0343	.0492	.0343	.6718		
5	.0343	.0492	.0514	.6718		
6	.0514	.0492	.0514	.8356		
7	.0514	.0328	.0514	.9995		
8	.0514	.0492	.0514	.0343		
9	.0514	.0328	.0514	.0335		
10	.0503	.0503	.0335	.064		
11	1.358	1.1822	1.3748	.048		
12	1.5257	1.247	1.358	.048		
13	1.5089	1.2955	1.4419	.048	.0343	
14	1.3889	1.3927	1.4419	.048	.0343	
15	1.4232	1.3435	1.3763	.032	.0343	.0503
16	1.2452	1.2452	1.2452	.048	.0343	
17	1.2125	1.2289	1.3108	.0469	.0343	
18	1.0486	1.0978	1.278	.0335	.0514	
19	.048	.0514	.0343			
20	.048	.0514	.0343			.0492
21	.048	.0514	.0343			.0492
22	.048	.0514	.0343	.0335		.2785
23	.048	.0514	.0343			.0492
24	.0343	.0492	.0514	.7575		
Max	1.5257	1.3927	1.4419	.9995	.0514	.2785
Min	.0343	.0328	.0335	.032	.0343	.0492
Avg	.4755	.4500	.4782	.3235	.0372	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV M WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6876	1.6876	1.6385	.0857		.0686
2	1.6876	1.6549	1.6385	.0857		.0686
3	1.7204	1.6221	1.6712	.0857		.0686
4	1.7532	1.6057	1.704	.1029		.0686
5	1.8023	1.5565	1.7204	.1029		.0686
6	1.9826	1.6221	1.7532	.1029		.0686
7	1.9989	1.9334	1.7695	.0983		.1029
8	2.0972	2.0317	2.0317	1.9989		1.1142
9	2.0972	1.9334	2.0153	2.1628		1.1305
10	.0838	.1029	.0838	2.2283		1.3108
11	.0671	.0972	.1006	2.2119		1.3108
12	.1006	.0972	.0838	2.3045		
13	.0983	.0972	.0819	2.3045		
14	.0819	.0983	.0819	2.1765	1.0814	
15	.0819	.0983	.0819	2.1285		1.278
16	.1006	.1311	.0983	.096	.0983	.0857
17	.1006	.1147	.1029		.0819	.0686
18	.1174	.12	.1029	.1006	.9831	.0686
19	.1174	.12	.12		.0857	
20	.0819	.12	.12		.0686	
21	.0983	.12	.12		.0686	
22	.1006	.12	.12		.0686	
23	.0838	.1029	.0857		.0686	
24	1.6712	1.6385	1.6549	.0857		.0686
Max	2.0972	2.0317	2.0317	2.3045	1.0814	1.3108
Min	.0671	.0972	.0819	.0857	.0686	.0686
Avg	.8255	.7844	.7909	1.0257	.2894	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0867	.0686	.0686		.0343	
2	.0343	.0867	.0343	.0686		.0343	
3	.0686	.104	.0514	.0686		.0343	
4	.0343	.104	.0857	.0686		.0343	
5	.0686	.104	.1029	.0686		.0343	
6	.0857	.0693	.0686	.0686		.0343	
7	.0857	.0867	.0857	.0857		.0686	
8	.0686	.0867	.0857	.0686	.0686	.0686	
9	.0343	.0347	.0343	.0514	.0343	.0686	
10	.0701	.0351	.0526	.0164	.0335	.0343	
11	.0175	.0171	.0701	.0328	.0168	.0343	
12		.0514	.0526	.0328	.0168	.0343	
13		.0686	.0686	.0164	.0168	.0343	
14		.0838	.0686	.0328	.0335	.0343	
15		.1006	.1029	.032	.0335	.0343	
16		.1006	.1029	.064	.0335	.0343	
17		.0838	.0686	.048	.0168	.0343	
18	.0343	.0686	.0686	.0328	.0168	.0343	
19	.0343	.0343	.0343	.0328	.0686		.0503
20	.0686	.0857	.0343				.0671
21	.0686	.0686	.0686		.0686		.0867
22	.0857	.0857	.0686		.0343		.0867
23	.1029	.1029	.0686		.0343		.0867
24	.0857	.104	.1029	.0686		.0343	
Max	.1029	.104	.1029	.0857	.0686	.0686	.0867
Min	.0175	.0171	.0343	.0164	.0168	.0343	.0503
Avg	.0611	.0772	.0688	.0513	.0351	.0397	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV M WADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5121	.5121		.4755	.1463
2	.5121	.5304	.4755	.5121		.4755	.1097
3	.5121	.5304	.4755	.5121		.4755	.1097
4	.5487	.5304	.5121	.5121		.4755	.128
5	.5853	.567	.5487	.5487		.5121	.1829
6	.6219	.7316	.5853	.5853		.5487	.2195
7	.6584	.695	.6219	.6584		.6219	.2561
8	.5487	.6219	.5487	.5487		.5487	.1829
9	.4755	.5121	.5121	.5249		.5121	.1829
10	.5228	.4344	.5068	.4755		.439	.2054
11	.5228	.4163	.4706	.4938	.4525	.4024	.3361
12	.4108	.4344	.5415	.5121	.6335		.3734
13	.3439	.4163	.5788	.5304		.439	
14	.4525	.4854	.5788	.5304		.5121	.6535
15	.4525	.5228	.4938	.543	.5973	.5121	.5487
16	.3982	.4854	.5487	.5249	.5249	.5487	.5487
17	.4706	.4525	.567	.5792	.5249	.5121	.567
18	.4706	.5121	.567	.5487	.6335	.5487	.5487
19	.6335	.6584	.5853		.695		.567
20	.8145	.8048	.8048		.7316		.724
21	.7421	.7316	.7316		.6584		.6878
22	.724	.695	.695		.5487		.5792
23	.5973	.5853	.5853		.5121		.4887
24	.5487	.5487	.5487	.5121		.4755	.1463
Max	.8145	.8048	.8048	.6584	.7316	.6219	.724
Min	.3439	.4163	.4706	.4755	.4525	.4024	.1097
Avg	.5465	.5605	.5665	.5350	.5920	.5020	.3692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3603	1.6385	1.6518	.0857		.0857	
2	1.3927	1.6057	1.7004	.0857		.0857	
3	1.4413	1.5565	1.7166	.0857		.0857	
4	1.587	1.5565	1.8138	.0857		.0857	
5	1.7328	1.5402	1.9271	.0857		.0857	
6	1.8461	1.7204	2.0729	.1029		.0857	
7	1.9271	2.1136	2.1376	.1029		.0857	
8	2.0243	2.1956	2.0729	1.6385		1.5089	
9	1.9433	2.1956	2.0405	2.0481		1.704	
10	.0838	.081	.0655	2.2939	.1562		
11	.0671	.0648	.0819	2.6216	.3906	1.7204	
12	.0819	.081	.0819	2.6871	1.1248		
13	.0819	.0648	.0983	2.6379	1.2342	1.7695	
14	.0819	.0983	.0983	2.3922		1.7695	
15	.0838	.0983	.0972	2.343		1.6057	
16	.0819	.0983	.0972	.096		.0686	
17	.096	.081	.0983	.08	.1094	.0686	.0343
18	.08	.0857	.1029	.0819	.0781	.1029	.6554
19	.096	.1029	.1029		.0857		.0983
20	.1147	.12			.0857		.0983
21	.1147	.12			.0857		.5079
22	.1006	.1029			.0857		.5079
23	.1006	.0857			.0857		.5079
24	1.2955	1.5729	1.6194	.0655		.0857	
Max	2.0243	2.1956	2.1376	2.6871	1.2342	1.7695	.6554
Min	.0671	.0648	.0655	.0655	.0781	.0686	.0343
Avg	.7423	.7908	.9839	1.0326	.3202	.6473	.3443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0671	.0857	.8848		.0343
2	.0686	.0671	.0857	.8848		.0343
3	.0686	.0671	.0857	.8848		.0343
4	.0686	.0671	.0857	.8848		.0343
5	.0857	.0671	.1029	.8848		.0686
6	.0857	.1006	.1029	.9831		.0686
7	.1029	.1174	.12	1.2452		.0686
8	.1029	.1006	.12	.1029		.1715
9	.1029	.1006	.1029	.0838		.3932
10	.1006	.0983	.1147	.0983		.6001
11	1.5089	1.5223	1.3927	.1147		.9602
12	1.6057	1.4737	1.5729	.1311		.9945
13	1.5729	1.3441	1.587	.1475		.823
14	1.3763	1.5565	1.587	.1311		.8048
15	1.3916	1.5729	1.4737	.1147		.5533
16	1.3272	1.4746	1.4419	.1134		.0686
17	1.2963	1.2631	1.3108	.1296		
18	1.1523	1.2793	1.3108	.1311		
19	.096	.12	.1029			.048
20	.1134	.12	.12			.048
21	.081	.1029	.1029		.0686	.048
22	.1147	.1029	.1029		.0343	.048
23	.0983	.0857	.0857		.0343	.048
24	.0686	.0671	.0857	.8848		.0343
Max	1.6057	1.5729	1.587	1.2452	.0686	.9945
Min	.0686	.0671	.0857	.0838	.0343	.0343
Avg	.5274	.5391	.5535	.4650	.0457	.2721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1341	.1372	1.1961		.0686
2	.1372	.1341	.1372	1.1961		.0686
3	.1372	.1341	.1372	1.1961		.0686
4	.1715	.1341	.1543	1.1961		.0686
5	.1715	.1341	.1715	1.3108		.0857
6	.2058	.1677	.2058	1.4419		.0857
7	.2401	.1509	.1886	1.5729		.1029
8	.2058	.1844	.2058	.1029		.3647
9	.1715	.1509	.1715	.0671		.3481
10	.1341	.1543	.1341	.1296		.3681
11	1.7436	1.7147	1.8442	.1619		.333
12	1.8945	1.989		.1457		.2454
13	1.8187	1.8778	1.8842	.1619	.1372	.2572
14	1.8515	1.7772	1.8842	.1619		.2572
15	1.7368	1.6263	1.704	.1619		.2743
16	1.6933		1.7368	.1943	.1372	.0686
17	1.5592	1.5592	1.6057	.2241	.12	
18	1.5424	1.5089	1.6095	.1966	.5801	
19	.1509	.1543				
20	.1475	.2058	.1543			.1311
21	.1638	.2058	.1543		.0686	.0983
22	.1311	.2058	.1372		.0686	.0983
23	.1311	.1715	.1372		.0686	.0983
24	.1372	.1341	.1715	1.1961		.0686
Max	1.8945	1.989	1.8842	1.5729	.5801	.3681
Min	.1311	.1341	.1341	.0671	.0686	.0686
Avg	.6839	.6352	.6667	.6323	.1686	.1695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV WINE PARK 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1014	.2263	.1494			.213
2	.2263	.112	.2263				.213
3	.2263	.109	.2263				.213
4	.2263	.0941	.2263				.213
5	.2263	.1189	.2263				.213
6	.2263	.2241	.2263				.213
7	.2263	.5258	.6036				.2622
8	.2263	.3045	.6036				.7316
9	.2263	.9242		1.0562			1.0562
10	.2263			1.3203			
11	.2263			.9619			
12	.2263			.3018			
13	.2263			1.2826			
14	.2263			1.4335			
15	.2263			1.6221			
16	.2263			1.2449			
17	.2263			.7023			
18	.2263	.2263					
19	.0964	.6036					
20	.1457	.3961					
21	.1227	.3206					
22	.1372	.2641					
23	.1372	.2452		.2263	.3018		.2829
24	.3018	.1143	.2263	.2263	.2263	.3018	.109
Max	.3018	.9242	.6036	1.6221	.3018	.3018	1.0562
Min	.0964	.0941	.2263	.1494	.2263	.3018	.109
Avg	.2089	.2928	.3101	.8773	.2641	.3018	.3382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV ANDHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.6194	1.7695				
2	1.4746	1.6194	1.7859				.064
3	1.4746	1.6221	1.7859				
4	1.3889	1.6712	1.7444				
5		1.7695	1.7764				
6		1.9006	1.9364				
7		2.2775	2.332				
8		2.4741	2.4741				.3018
9		2.5069		.7545			.3018
10				.2818			
11				2.3758			
12				2.6379			
13				2.8509			
14				2.8509			
15				2.9007			
16				.4338			
17	.4588			.5281			
18	.5243						
19	.5847	.6036					
20	.6036	.6036					
21	.5281	.6036					
22	.4904	.6036					
23	.4527	.5281		.3018	.3018		.7926
24	1.5074	1.6549	1.7695	.2835	.3018	.3018	
Max	1.5074	2.5069	2.4741	2.9007	.3018	.3018	.7926
Min	.4527	.5281	1.7444	.2818	.3018	.3018	.064
Avg	.9136	1.4705	1.9305	1.4727	.3018	.3018	.3651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11KV ANDHALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3584	.4527	.2987			.2378
2		.3584	.4527				.2378
3		.3584	.415				.2561
4		.3772	.415				.2743
5		.3772	.415				.2829
6		.3018	.5281				.3395
7		.2957	.4527				.4527
8		.2715	.415				.3772
9		.4527		.3018			.3772
10	.2987			.2427			
11	.2801			.298			
12	.2801			.2947			
13	.2427			.298			
14	.2427			.2947			
15	.2427			.3121			
16	.2241			.3086			
17	.2241			.2915			
18	.2614	.5281					
19	.3734	.5281					
20	.4527	.5658					
21	.415	.5658					
22	.415	.5658					
23	.3772	.5281		.2835	.3258		.3734
24	.4287	.3584	.4287		.2835	.3292	.2378
Max	.4527	.5658	.5281	.3121	.3258	.3292	.4527
Min	.2241	.2715	.415	.2427	.2835	.3292	.2378
Avg	.3172	.4245	.4417	.2931	.3047	.3292	.3133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.16	.144				.144
2		.16	.128				.144
3		.16	.128				.144
4		.176	.128				.1406
5		.192	.128				.1406
6		.208	.16				.1581
7		.208	.176				.1718
8		.16	.192				.3041
9		.144		.8002			.3681
10	.144			.096			
11	1.3123			.096			
12	1.3443			.128			
13	1.2803			.096			
14	1.2483			.112			
15	1.1363			.128			
16	1.1523						
17	1.1363			.176			
18	.9762	1.2643			.192		
19	.176	.176					
20	.208	.192					
21	.192	.208					
22	.192	.2241					
23	.176	.176		.2561	.2881		.144
24	.16	.16	.144	.3841	.2721	.2401	.144
Max	1.3443	1.2643	.192	.8002	.2881	.2401	.3681
Min	.144	.144	.128	.096	.192	.2401	.1406
Avg	.7223	.2480	.1476	.2272	.2507	.2401	.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.096	.096				.048
2		.096	.096				.048
3		.096	.096				.048
4		.112	.112				.048
5		.128	.112				.048
6		.144	.112				
7		.128	.112				
8		.128	.112				
9		.144		1.1363			
10	.128			.08			
11	1.7604			.064			
12	1.8084			.048			
13	1.7604			.0486			
14	1.6964			.064			
15	1.6164			.08			
16	1.5844			.096			
17	1.5844			.128			
18	1.4883	1.6804					
19	.096	.112					
20	.112	.112					
21	.112	.112					
22	.096	.112					
23	.096	.096		.6562	.7522		.064
24	.112	.096	.096	.8802	.6562	.7202	.048
Max	1.8084	1.6804	.112	1.1363	.7522	.7202	.064
Min	.096	.096	.096	.048	.6562	.7202	.048
Avg	.9367	.2120	.1049	.2983	.7042	.7202	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8402	
2	.8402	.8402	
3	.8402	.8402	
4	.8402	.8402	
5	.8402	.8402	
6	.8402	.8402	
7	.8402	.8299	
8	.8402		
9	.8589	.8402	.8589
10			.8215
11			.8215
12			.8215
13			.8215
14			.8215
15			.8402
16			.8215
24			.0914
Max	.8589	.8402	.8589
Min	.8402	.8299	.0914
Avg	.8423	.8389	.7466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 207 / 11 KV Kranti LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1734	.1734		.0002
2	.208	.1907		.0002
3	.208	.1907		.0002
4	.208	.1907		.0002
5	.208	.1907		.0002
6	.208	.1907		.0002
7	.1907	.1886		.0002
8	.208	.2058		.0002
9	.1372	.208	.208	.0002
10			.2058	
11			.1612	
12			.1417	
13			.1928	
14			.1928	
15			.1928	
16			.1907	
Max	.208	.208	.208	.0002
Min	.1372	.1734	.1417	.0002
Avg	.1944	.1921	.1857	.0002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5844	1.8107				1.7924
2		1.5844	1.6975				1.7924
3		1.5844	1.6975				1.7924
4		1.5684	1.6975				1.6804
5		1.5844	1.8107				1.6804
6		1.5844	1.8107				1.6804
7		1.5844	1.8107				1.6804
8		1.6975	1.6975				1.7924
9		1.5844		1.5844			1.4563
10	1.5684			1.2449			
11	1.5684			1.358			
12	1.5684			1.2449			
13	1.4563			1.5844			
14	1.4563			1.4712			
15	1.5684			1.4712			
16	1.6804			1.5844			
17	1.5684			1.6975			
18	1.5684	1.7924					
19	1.5844	1.7924					
20	1.6975	1.7924					
21	1.5844	1.7924					
22	1.5844	1.7924					
23	1.5844	1.6804		1.5123	1.5123		1.5123
24	1.5684	1.5844	1.8107	1.5844	1.4563	1.5684	1.7924
Max	1.6975	1.7924	1.8107	1.6975	1.5123	1.5684	1.7924
Min	1.4563	1.5684	1.6975	1.2449	1.4563	1.5684	1.4563
Avg	1.5738	1.6615	1.7604	1.4852	1.4843	1.5684	1.6957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.0274	.029	.759		.5792	
2	.0274	.0274	.029	.7682		.4877	
3	.0274	.0286	.029	.7682		.4877	
4	.0263	.0297	.029	.7682		.4877	
5	.0263	.0297	.029	.8002		.503	
6	.0263	.0274	.029	.8482		.5792	
7	.0267	.0251	.029	.0267		.0274	
8	.0267	.0267	.0282	.0267		.0293	
9	.0305	.0267	.0267	.0267		.0305	
10	.0305	.0274	.0259	.04		.0305	
11		1.5432	1.4074	.0297		.0305	
12	1.387	1.5432	1.5655	.0274		.0305	
13	1.3413	1.358	1.5655	.0267		.0305	
14	1.3717	1.2346	1.5339	.0274		.0305	
15	1.2651	1.1883	1.4373	.0274		.0305	
16	1.1888	1.1728	1.326	.0274			
17	1.0974	1.1728		.0274			
18	.9297	.8333	1.0802				.0274
19	.0274	.029	.0267		.0171		.0274
20	.029	.029	.0274		.0372		.0274
21	.0297	.029	.0267		.7164		.0274
22	.0297	.029	.0267		.7164		.4321
23	.0297	.029	.0267		.7164		.029
24	.0267	.0297	.029	.759		.6859	
Max	1.387	1.5432	1.5655	.8482	.7164	.6859	.4321
Min	.0263	.0251	.0259	.0267	.0171	.0274	.0274
Avg	.3925	.4374	.4506	.3214	.4407	.2550	.0951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5658	.5121	.5068		.5658	
2	.5068	.5658	.4755	.5068		.5658	
3	.5068	.5658	.4755	.5068		.5658	
4	.5068	.5847	.4755	.5068		.5658	
5	.543	.6036	.5121	.543		.679	
6	.5973	.6535	.6036	.5792		.7468	
7	.5973	.6219	.543	.543		.7865	
8		.4656	.5121	.5068		.6401	
9	.4706	.4344	.4656	.5068		.5853	
10	.4344	.3982	.4656	.4344		.543	
11		.3982	.4706	.439		.4858	
12	.3982	.4344	.5194	.4207		.5121	
13	.4344	.4706	.5249	.4252		.5068	
14	.4344	.4706	.5249	.4252		.5068	
15	.4706	.4706	.5249	.4252		.5121	
16	.4706	.4887	.5068	.4252			
17	.4382	.4733		.443			
18	.4252	.5068	.5068				.5792
19	.5853	.543	.6516		.2629		.6154
20	.7392	.7059	.6878		.3721		.724
21	.6722	.6516	.6516		.6401		.6516
22	.6224	.6584	.6154		.6283		.5611
23	.5658	.6036	.5228		.5975		.5068
24	.543	.5281	.5121	.5068		.5658	
Max	.7392	.7059	.6878	.5792	.6401	.7865	.724
Min	.3982	.3982	.4656	.4207	.2629	.4858	.5068
Avg	.5213	.5360	.5331	.4806	.5002	.5833	.6064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9172	1.0402	.9998	.0526		
2	.9172	1.0082	.9998	.0526		
3	.9172	.9722	.9998	.0526		
4	.9488	1.0082	.9998	.0533		
5	1.1069	1.0082	.9998	.0533		
6	1.1069	1.0883	1.0155	.0533		
7	1.1385	1.2176	1.2811	.0533		
8	1.2176	1.1702	1.1717	.9488		
9	1.2308	1.1702	1.1385	1.1385		
10	.0648	.0762	.0549	1.2809		
11		.0594	.0579	1.2809	1.0364	
12	.0648	.0594	.0389	1.2967		
13	.0648	.0579	.0638	1.2967	1.1984	
14	.0648	.0579	.0714	1.2967	1.247	
15	.0648	.0579	.0667	1.2967	1.3117	
16	.0648	.0705	.0743	.0633		
17	.0533	.0705		.0469		
18	.0695	.0705	.0724			.0309
19	.0404	.0564	.0705			.029
20	.0533	.0564	.0564			.0549
21	.0434	.0564	.0549			.3681
22	.0457	.0564	.0549			.3841
23	.0495	.0564	.0549			.3841
24		1.0562	1.0311	.0533		
Max	1.2308	1.2176	1.2811	1.2967	1.3117	.3841
Min	.0404	.0564	.0389	.0469	1.0364	.029
Avg	.4657	.4834	.4969	.5761	1.1984	.2085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 201 / 11 KV DEORASHTRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 202 / 11KV KUNDAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 204 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 205 / 11 KV TAKARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 401 / 33 KV KIRLOSKAR WADI NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 403 / 33 KV PALUS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 404 / 33 KV MOHITE VADGAON
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 405 / 33 KV EBARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
23	.2743
24	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 406 / 33 KV SANDGEWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 407 / 33KV KRANTI CO-GENERATION NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 408 / KRANTI CO-GEN-II NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / 11 KV KADEPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.2195	.1463	.502	.6554
2	.1463	.2195	.1463	.4961	.6554
3	.1463	.1463	.1463	.4961	.6554
4	.1463	.2195	.1463	.5182	.6554
5	.1463	.2195	.1463	.6554	.6554
6	.1463	.2195	.1463	.7042	.6554
7	.1463	.2218	.1463	.0716	.1463
8	.1463		.1463	.1075	.1463
9	.1463	.2012	.1463	.1086	.1463
10	.1357	.2195	.1433	.1372	.1463
11	2.3205	2.0972	2.9172	.1387	.2195
12	2.556	2.4249	2.652	.1417	.2926
13	2.7183	2.4577		.2172	.2926
14	2.6216	2.6216		.2172	1.8351
15	2.4531		2.6852	.2926	.2926
16	2.2939		2.6852	.2804	.2957
17	2.1628	2.4249	2.4863	.2058	.2195
18	1.6644	2.4249	1.6876	.2058	
19	.1387	.1463	.1097		
20	.2058	.1463	.0716		
21	.2195	.1463	.0724		
22	.2172	.1463	.0724		
23	.2172	.1463	.0724		
24	.1463	.2195	.1463	.4961	
Max	2.7183	2.6216	2.9172	.7042	1.8351
Min	.1357	.1463	.0716	.0716	.1463
Avg	.8912	.8233	.7781	.3154	.4685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.2193	1.4746			.0366
2	1.3108	1.2803	1.4746			.0366
3	1.3108	1.2803	1.5074			.0366
4	1.3435	1.4083	1.5074			.0366
5	1.3763	1.4723	1.5074			.0366
6	1.4746	1.7604	1.6385			.0732
7	1.6385	1.9845	1.6385			.0732
8	1.9662	1.9845	2.0317			.0732
9	1.9006	1.9845	1.9662			2.0317
10	.1174	.1463	.1677			2.0317
11	.1402	.1463	.1772	1.704		2.0317
12	.1372	.1463	.197	1.7695		1.8343
13	.1357	.1463	.2149	2.4249		1.7078
14		.1463	.2149	2.2024	1.4419	
15	.1372	.1463	.2149	2.332	1.704	2.6216
16	.1372	.1463	.2058		.0732	.0693
17	.1341	.1463	.2103	.1463	.0732	.1341
18	.1219	.1463	.1753	.1219	.0732	
19	.1189	.1463	.1052		.0732	
20	.1189	.1463			.0732	
21	.1219	.1463			.0732	
22	.1143	.1463			.1463	
23	.1158	.1463			.1463	
24	1.4632	1.1888	1.6461			.1463
Max	1.9662	1.9845	2.0317	2.4249	1.704	2.6216
Min	.1143	.1463	.1052	.1219	.0732	.0366
Avg	.7281	.7338	.9138	1.5287	.3878	.7654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1646	.1646	.1829	.1646	.1646	
2	.1829	.1646	.1646	.181	.1646	.1646	
3	.1829	.1646	.1646	.1791	.1463	.1646	
4	.1829	.1646	.1646	.1791	.1646	.1829	
5	.2195	.1829	.1646	.2058	.1646	.1829	
6	.2561	.1829	.2195	.2401	.1646	.2378	
7	.2561	.2012	.2195	.2229	.2241	.2195	
8	.2195	.1829	.2195	.2058	.168	.1646	
9	.1646	.1463	.1829	.2103	.168	.1463	
10	.1174	.1463	.1509	.1715	.168	.1463	
11	.12	.1097	.1433	.1494	.1867	.1417	
12	.12	.1097		.1029	.168	.1543	
13	.1357	.1097	.0905	.1254	.1494	.156	
14	.1372	.128	.0895	.12	.168	.1402	
15	.1372	.128	.1433	.12	.1494	.1578	
16	.1372	.128	.2172	.1402	.1494	.1387	
17	.1187	.128	.2149	.1677	.1867	.1526	
18	.12	.1646	.2149	.12	.2427		
19	.1595	.1829	.2328		.2427		
20	.2172	.2561	.2353		.2614		
21	.2195	.2378	.2328	.1463	.2241		
22	.2012	.2012	.2149	.1646	.2012		
23	.1829	.1829	.2012	.1646	.1829		.1097
24	.1829	.1829	.1646	.1848	.1646	.1646	
Max	.2561	.2561	.2353	.2401	.2614	.2378	.1097
Min	.1174	.1097	.0895	.1029	.1463	.1387	.1097
Avg	.1731	.1646	.1831	.1675	.1823	.1656	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1829	.2012	.1848		.1829	
2	.2195	.1646	.2012	.1848		.1772	
3	.2378	.1646	.2012	.1848		.1829	
4	.2561	.1646	.2012	.1848		.2195	
5	.2743	.1829	.2378	.2195		.2378	
6	.3292	.2012	.2743	.2452		.2561	
7	.2561	.2614	.2561	.2987	.3772	.2378	
8	.2378	.2378	.2195	.1848	.2829	.2378	
9	.3109	.2195	.2195		.2614	.2561	
10	.2926	.4207	.1844	.1543	.2427		
11	.2195	.2378	.2172	.1848	.2987	.2715	
12		.2195	.1433	.1865	.2987	.2534	
13	.1991	.2195	.1448	.1646	.2987	.1829	
14	.1886	.1829	.1448	.2195	.1829	.1886	
15	.2218	.1635	.1612	.2378	.2378	.2507	
16	.2195	.2195	.2328	.2865	.2561	.2896	
17	.2279	.2195	.2328	.2926	.3109	.208	
18	.2658	.2561	.2353	.2743	.2378		
19	.2195	.2743	.2328		.2378		
20	.2378	.3292	.2328		.2561		
21	.2378	.2561	.2481		.2195		
22	.2195	.2378			.2195		
23	.2195	.2378			.1829		.2378
24	.2195	.2012	.2195	.1829		.1829	
Max	.3292	.4207	.2743	.2987	.3772	.2896	.2378
Min	.1886	.1635	.1433	.1543	.1829	.1772	.2378
Avg	.2404	.2273	.2110	.2151	.2589	.2245	.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.2195	.1463	1.757		1.9662
2	.1463	.2195	.1463	1.757		1.9662
3	.1463	.2195	.1463	1.757		1.9662
4	.1463	.2195	.1829	1.8023		1.9662
5	.1646	.2195	.1829	1.989		1.9662
6	.1829	.2195	.1829	2.2131		1.9662
7	.1829	.2218	.1829	.208		.1463
8	.2195	.2195	.2012	.1402	.0716	.1463
9	.2195	.2058	.1463	.1402	.0732	.1463
10	.2103	.2058	.2427	.208		.1463
11	2.6216	2.3777	3.1687	.2103		.1867
12	2.7846	2.2558	3.0178	.2195		.1848
13	2.7526	2.4387	2.9172	.2058		.1848
14	2.9492	2.8045	3.1855	.2058		.1829
15	3.0148	2.6216		.2218		.1848
16	2.8837	2.6216	2.7349	.2218	.0549	.1848
17	2.4905	2.4387	2.5526	.2195	.1463	.1448
18	2.2939	2.1338	2.3922	.2172	.1463	
19	.2035	.1829	.1086		.1463	
20	.2058	.2012	.0905		.1463	
21	.2195	.1829	.1086		.1463	
22	.2195	.1463	.0724		1.9662	
23	.2195	.1463	.0724		1.9662	
24	.1463	.2195	.1463	1.7368		2.13
Max	3.0148	2.8045	3.1855	2.2131	1.9662	2.13
Min	.1463	.1463	.0724	.1402	.0549	.1448
Avg	1.0321	.9559	.9708	.8121	.4864	.8759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / 11 KV KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2641	.2987	.2743	.3206	.2987	
2	.2987	.2641	.2987	.2772	.3206	.2987	
3	.2987	.2641	.2987	.2743	.3206	.2987	
4	.2987	.2641	.2987	.362	.3395	.3361	
5	.3361	.2641	.3734	.4435	.3772	.3734	
6	.4668	.3395	.4668	.4904	.547	.4108	
7	.3734	.3961	.3734	.3734	.5847	.3734	
8	.3174	.3772	.3734	.3696	.4904	.3547	
9	.2614	.3395	.3547	.3658	.4715	.3547	
10	.2829	.3395	.3077	.3961	.3174	.2801	
11	.2587	.3018	.3045	.415	.2987	.3772	
12	.2772	.3206		.4527	.4481	.3206	
13	.2772	.3395	.3142	.3772	.4481	.3018	
14	.2772	.3547	.3395	.415	.4294	.415	
15	.2641	.3174	.2957	.415	.4294	.3772	
16	.2829	.3174	.3439	.3772	.3734	.3961	
17	.2957	.3174	.3439	.3772	.4481	.415	
18	.2587	.3361	.1753	.3961	.4481		
19	.2957	.3921	.3584		.4294		
20	.3584	.3734	.3547		.3361		
21	.3734	.3734	.3696	.3395	.3361		
22	.3395	.3361	.3696	.3206	.3361		
23	.3395	.3174	.2926	.3206	.3174		.4481
24	.2987	.3018	.2987	.2772	.3206	.2926	
Max	.4668	.3961	.4668	.4904	.5847	.415	.4481
Min	.2587	.2641	.1753	.2743	.2987	.2801	.4481
Avg	.3096	.3255	.3306	.3686	.3954	.3486	.4481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / 33 KV SAGARESHWAR SAHAKARI NON SHEDDABLE EHV INDUSTRIAL FEEDERS

SOO Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5463	1.1946	2.3765	2.5463	1.8673	2.6029	
2	2.5463	1.1946	2.3765	2.4897	1.8673	2.5463	
3	2.5463	1.1946	2.3765	2.4897	1.8673	2.4691	
4	2.5463	1.1946	2.3765	2.4897	1.8673	2.5463	
5	2.5463	1.1946	2.3765	2.4897	1.8673	2.5463	
6	2.4897	1.1946	2.3765	2.4897	.9231	2.5463	
7	2.3765	1.1946	2.3765	2.2068	1.9805	2.5463	
8	2.32	2.1502	2.4897	2.2634	2.1502	2.6029	
9	1.358	2.32	2.4897	2.4331	2.0936	2.5463	
10	1.1403	2.2634	2.2068	2.4331	2.0936	2.2068	
11	1.1043	2.3765	2.5463	2.4897	2.2634	2.3765	
12	1.3032	2.4897	2.5463	2.4331	2.3765	2.3765	
13	1.3032	2.4897	2.4331	2.3765	2.3765	2.4897	
14	1.3032	2.7161	2.6595	2.4331	2.3765	2.3765	
15	1.3169	2.5463	2.5463	1.6975	2.4331	2.5463	
16	1.2489	2.6029	2.5463	2.4897	2.3765	2.6029	
17	1.2489	2.6595	2.4897	2.2634	2.3765	2.2634	
18	1.2489	2.7161	2.4331	2.0936	2.3765		
19	1.1946	2.4897	2.3765		2.3765		
20	1.1946	2.4897	2.6029		2.2634		
21	1.1403	2.5463	2.037	.9328	2.3765		
22	1.1043	2.4331	2.037	.9231	2.524		
23	1.1946	2.3765	2.2634	1.8673	2.6029	2.3765	2.3765
24	2.5463	1.1946	2.3765	2.5463	1.8673	2.6029	
Max	2.5463	2.7161	2.6595	2.5463	2.6029	2.6029	2.3765
Min	1.1043	1.1946	2.037	.9231	.9231	2.2068	2.3765
Avg	1.7028	2.0509	2.4048	2.2217	2.1477	2.4827	2.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / 11 KV KADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	.9808	.961	.9808	.8676	.8488	.9313
2	.9145	.9431	.9335	.9431	.8131	.811	.905
3	.905	.9054	.9431	.9054	.7762	.811	.8779
4	.9511	.9054	.9979	.8962	.7842	.811	.8871
5	1.0349	.9431	1.0974	.9335	.8299	.8488	.9511
6	1.1883	1.1317	1.2696	1.2696	1.1576	1.1317	1.1088
7	1.182	1.2803	1.2803	1.3817	1.3014	1.2136	1.1088
8	1.1203	1.2012	1.2197	1.2437	1.2323	1.1458	1.0242
9	.9979	1.1088	1.1706	1.134	1.134	1.0974	.9145
10	.9774	.905	1.0387	1.086	1.0608	.9511	.8048
11	.9412	.9511	1.0791	1.0425	.9412	.9145	.8688
12	.9955	.961	1.1706		1.1523	.961	.905
13	.9511	.9877	1.1523		.9745		.9774
14		.961	1.134		1.0059		1.0498
15	1.0059	.9877	1.134		1.0425		1.0608
16	.9795	1.0903	1.1523		1.0974		1.0242
17	.9955	.9979	1.1222		1.0317		1.0608
18	.985	.9877	1.0745		.9955		1.086
19	1.086	1.0974	1.267		1.086		1.1222
20	1.4003	1.1827	1.4118		1.2936		1.2986
21	1.2696	1.1203	1.2696		1.2136		1.2197
22	1.1576	1.0242	1.1389		1.1203		1.1088
23		.9979	1.094		1.0374		.9335
24	.9979	.9997	.9335	1.0185	.9522	.9054	1.7372
Max	1.4003	1.2803	1.4118	1.3817	1.3014	1.2136	1.7372
Min	.905	.905	.9335	.8962	.7762	.811	.8048
Avg	1.0453	1.0271	1.1269	1.0696	1.0376	.9578	1.0403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / 11 KV MIDC NO.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3253	1.3112	1.39	1.4266	1.3253	1.3253	1.3169
2	1.3112	1.3112	1.3756	1.4449	1.3169	1.3253	1.3306
3	1.262	1.3611	1.3306	1.4449	1.2757	1.2757	1.2803
4	1.2536	1.3611	1.3817	1.4118	1.3073	1.2757	1.2536
5	1.3169	1.3611	1.3676	1.4118	1.3253	1.2757	1.166
6	1.2894		1.39	1.3937	1.3611	1.3112	1.1919
7	1.0974	1.3756	1.3535	1.4449	1.3073	1.2757	1.2536
8	1.0349	1.3611	1.4045	1.3394	1.2094	1.262	1.2803
9	.9808	1.448	1.4937	1.4266	1.2894	1.3611	1.1919
10	.5578	1.39	1.4045	1.3611	1.3535		1.1789
11	.5251	1.3535	1.4784	1.4815	1.3611		1.3112
12	.4954	1.3611	1.46		1.3756		1.3253
13	.4481	1.39	1.4784		1.3756		1.3611
14	.4527	1.39	1.4969		1.3112		1.3535
15		1.4118	1.46		1.39		1.39
16		1.4327	1.4784		1.39		1.3394
17		1.4632	1.4449		1.3394		1.3394
18	.3368	1.448	1.4266		1.2894		1.3575
19	.4733	1.4632	1.4415		1.2894		1.3394
20	.4938	1.4415	1.4415		1.2403		1.39
21	1.3611	1.4335	1.46		1.3756		1.4083
22	1.2757	1.419	1.4632		1.3112		1.3756
23	1.2483	1.3957	1.4449		1.2269		1.3575
24	1.39	1.3466	1.3676	1.4266	1.1568	1.2403	1.2803
Max	1.39	1.4632	1.4969	1.4815	1.39	1.3611	1.4083
Min	.3368	1.3112	1.3306	1.3394	1.1568	1.2403	1.166
Avg	.9490	1.3926	1.4264	1.4178	1.3127	1.2928	1.3072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / 11 KV SHALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.3599	1.3763	.1294	.132	.128	.5571
2		1.3435	1.2811	.1294	.1294	.128	.5182
3	.7926	1.3435	1.3108	.1478	.128	.128	.5121
4	.9831	1.4232	1.4918	.1478	.1132	.1294	.5571
5	1.1603	1.4548	1.704	.1663	.128	.1478	.663
6	1.587	1.6194	1.9662	.1848	.168	.168	.6962
7	1.7368	1.8747	2.1765	.2241	.1848	.1829	.1097
8	1.989	2.2119	2.1628	1.6804	1.6004	1.1012	.1294
9	2.0645	2.2447	2.17	1.9109	1.4899	1.5203	.1254
10	.12	.1214	.128	2.0485	1.3283		.124
11	.1448	.1463	.128	2.4249	1.3603		.0709
12	.1254	.1433	.1086		1.2651		.0886
13	.1417	.1448	.1267		1.0936		.0886
14	.1433	.128	.1448		1.0155		.1063
15	.1433	.1478	.1448		1.0279		.1075
16	.1478	.1463	.1433		.1341		.1214
17	.1433	.1629	.1612		.156		.104
18	.1387	.2012	.1595		.1372		.0876
19	.1433	.2195	.1433		.1578		.0876
20	.1848	.2218	.1433		.1646		.0876
21	.1848	.1829	.1646		.1463		.571
22	.112	.181	.1646		.1478		.5182
23	.1494	.1646	.1478		.1478		.4967
24	1.0402	1.4232	1.3443	.1294	.128	.1294	.5636
Max	2.0645	2.2447	2.1765	2.4249	1.6004	1.5203	.6962
Min	.112	.1214	.1086	.1294	.1132	.128	.0709
Avg	.6233	.7754	.7913	.7770	.5202	.3763	.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / 11 KV KADEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1867	.1848	1.0936		.6401	
2	.1294	.1848	.1829	1.1069		.6401	
3	.128	.1829	.1629	1.1702		.6401	
4	.1448	.1829	.1848	1.2483		.6401	
5	.1829	.1829	.2241	1.5524		.6706	
6	.2378	.2218	.2218	1.5684		.8749	
7	.2195	.2614	.2195	.2481		.181	
8	.1086	.2614	.181	.2378		.2195	.6882
9	.2195		.2149	.2195		.1448	.8322
10	.1478	.2149	.2218	.1578			.7865
11	2.0729	2.6216	2.6993	.2328			.8436
12	2.3266	2.672	2.8841				.8749
13	2.2672	2.5194	2.8178				.8951
14	2.1628	2.5232	2.5232		.1029		.884
15	2.1628	2.4863	2.2283				.8488
16	2.13	2.3685	2.1628				.1174
17	1.9845	2.1445	2.0485		.1214		.1174
18	1.7604	2.0972	1.9524				.1187
19	.2172	.1097	.2172		.2149		.1187
20	.2218	.1848	.2172		.1791		.12
21	.2241	.2195	.1829		.7407		.124
22	.2195	.2172	.1646		.7499		.1052
23	.181	.1829	.1646		.6944		.0867
24	.1848	.1867	.1848	1.1248		.6401	
Max	2.3266	2.672	2.8841	1.5684	.7499	.8749	.8951
Min	.1086	.1097	.1629	.1578	.1029	.1448	.0867
Avg	.8242	.9745	.9353	.8301	.4005	.5291	.4726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 205 / 11 KV MIDC NO.2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	04-JUN-18
HR	Load (MW)
15	1.643
16	1.8107
17	1.4327
18	1.1888
19	1.0985
20	1.2536
21	1.3535
22	1.3535
23	1.39
Max	1.8107
Min	1.0985
Avg	1.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / 11 KV SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3734	.4024	.3734		.3734	.3658
2	.3696	.3734	.362	.3734		.3734	.362
3	.3734	.3734	.3658	.3734		.3734	.3224
4	.4481	.3734	.394	.4854		.3734	.3292
5	.4527	.4108	.439	.5415		.3734	1.4415
6	.5175	.5228	.5121	.5415		.5975	.362
7	.4435	.5175	.5487	.5487		.5544	.4024
8	.4108	.439	.4805	.4344		.439	.3326
9	.3658	.4508	.439	.394		.4344	.2957
10	.439	.4115	.4435	.2427	.3224		.2218
11	.4359	.3856	.3898	.4755	.4298		.2865
12	.4748	.3429	.4508		.3814		.3224
13	.3467	.3582	.4508				.3403
14	.3582	.3658	.4382				.3582
15	.4115	.3982	.4382				.3224
16	.3429	.439	.4115				.3544
17	.431	.4344	.407		.4908		.3721
18	.5144	.439	.4144		.4557		.394
19	.4854	.5121	.4477		.5316		.4119
20	.5853	.5731	.5792		.6154		.5487
21	.5601	.543	.5487		.5914		.4805
22	.5228	.5121	.5121		.5175		.4481
23	.4435	.4805	.4481		.4481		.3734
24	.439	.3734	.4481	.3734		.4108	.4066
Max	.5853	.5731	.5792	.5487	.6154	.5975	1.4415
Min	.3429	.3429	.362	.2427	.3224	.3734	.2218
Avg	.4408	.4335	.4488	.4298	.4784	.4303	.4106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1523	1.6057	1.5364	.1509		.0377	
2	1.1469	1.5402	1.5402	.132		.0373	
3	1.1934	1.4899	1.4918	.132		.0373	
4	1.3108	1.4575	1.5565	.132		.0373	
5	1.6004	1.4575	1.7604	.1509		.0373	
6	1.873	1.8564	2.2211	.1698		.0754	
7	2.0805	1.8343	2.4577	.1886		.132	
8	2.0081	2.0719	2.332	1.8842			.0732
9	2.0645	2.1051	2.2085	2.0056	.6249	1.6385	.0554
10	.1097	.1086	.1294	2.0972	1.4083		
11	.1494	.128	.1132	2.7515	1.4899		
12	.1307	.1478	.132		1.3441		.056
13	.1494	.1463	.1509		1.3441		.0747
14	.1698	.1463	.168		1.3765		.056
15	.1886	.1663	.1867		1.2955		.0747
16	.2263	.1646	.1867		.0754		.0543
17	.1646	.1663			.1132		
18	.1848	.1829	.1698		.1132		.0732
19	.1463	.1829	.1509		.112		.0732
20	.1494	.2218	.1509		.0943		.0732
21	.1478	.2195	.1698		.0754		.2846
22	.132	.181	.1698		.0754		.0686
23	.1294	.1646	.1509		.0754		.2372
24	1.0936	1.6385	1.5729	.1509		.0566	
Max	2.0805	2.1051	2.4577	2.7515	1.4899	1.6385	.2846
Min	.1097	.1086	.1132	.132	.0754	.0373	.0543
Avg	.7376	.8077	.9003	.8288	.6412	.2322	.0965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 208 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	.8238	1.4712	1.6598	1.2071	1.4003	1.5893
2	1.6827	.8688	1.3306	1.6221	1.4712	1.386	1.6461
3	1.6632	.8688	1.307	1.6057	1.4335	1.4415	1.6118
4	1.5729	.905	1.086	1.4937	1.4335	1.4632	1.5364
5	1.5524	.905	.9877	1.3169	1.5466	1.4632	1.5893
6	1.5844	.9896	1.0029	.9259	1.5466	1.1517	1.5364
7	1.2936	1.0269	1.0974	1.4415	1.6598	1.4003	1.4632
8	1.1203	.9412	1.1827	1.0745	1.6598	1.4415	1.4415
9	.8488	1.4937	1.7364	1.2012	1.773	1.6032	1.386
10	.7209	1.5466	2.1285	1.3817	1.6598		1.4415
11	.8238	1.5844	1.5497	1.773	2.1691		1.2803
12	.583	1.531	2.1502		1.9805		1.5524
13	.2896	1.4969	2.1125		2.0748		1.4937
14	.3125	1.6057	2.0748		2.452		1.7551
15		1.6221	2.1691		2.452		
16		1.7177	2.1125		1.9805		
17		1.7924	2.037		1.9239		
18	.2606	1.8861	1.9427		2.0748		
19	.2812	1.6975	1.6975		2.2634		
20	.3498	1.7372	1.7353		1.8861		
21	.8596	1.7924	1.6975		1.4937		
22	1.1694	1.6804	1.6598		1.9239		
23	.7011	1.5844	1.6787		1.6632		
24	1.5729	.8238	1.4784	1.6409	1.0242	1.587	1.5844
Max	1.6827	1.8861	2.1691	1.773	2.452	1.6032	1.7551
Min	.2606	.8238	.9877	.9259	1.0242	1.1517	1.2803
Avg	.9939	1.3717	1.6428	1.4281	1.7814	1.4338	1.5272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELWADE S/STN

Feeder No / Name : 201 / 11 KV TONDOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3696		.4024	2.8292	1.8564	2.3205
7	.4572	.5014	.439	.2987	.2865	.285
8	.3696	.5228	.4066	.3018	.2241	.3292
9	.3734	.3961	.3881	.2987	.2241	.3772
10	.3142	.439	.3734	.3326	.2772	.2801
11	1.989	3.1642	3.3951	.3189	2.2634	.3696
12	2.4143	3.0148	3.5475	.3403	1.8785	.3772
13	2.9504	3.0148	3.7723	.3439	1.8564	.3734
14	3.1161	3.2769	4.0143	.2896		.4066
15		3.0476	3.7723	.2926		.4715
16		3.1131		.3292		.415
17		3.0967	3.3608	.3696		
18		2.6379		.3734		
19		.4207	.2829			
24	2.3472		.2957	1.9605		
Max	3.1161	3.2769	4.0143	2.8292	2.2634	2.3205
Min	.3142	.3961	.2829	.2896	.2241	.2801
Avg	1.4701	2.0497	1.8808	.6199	1.1083	.5459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELWADE S/STN

Feeder No / Name : 202 / 11 KV RAIGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	3.1855		3.0312	.3856	.2241	.3018
7	3.2693	2.7469	3.2769	.4477	.2926	.2926
8	3.0178	3.0498	2.6216	1.8442	2.4143	
9	3.1017	2.9172	2.4741	2.5987	2.8487	
10	.2987	.4024	.2172	3.12		
11	.3018	.3881	.2926	2.9165	2.0348	2.6825
12	.2926	.3881	.2743	2.9843	1.8785	3.1017
13	.3018	.3658	.362	3.0521	1.8564	3.437
14	.2865	.4251	.3761	2.8487		3.2693
15			.3982	2.4417		3.2217
16			.4706	.3658		
17		.4024	.4755	.4435		
18		.4251				
19		.439	.3506			
24	3.1855		2.7854	.3155		
Max	3.2693	3.0498	3.2769	3.12	2.8487	3.437
Min	.2865	.3658	.2172	.3155	.2241	.2926
Avg	1.7241	1.0864	1.2433	1.8280	1.6499	2.3295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 203 / 11 KV SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9431		.8686	.9335	.8962	.7922
7	.9431	.9054	.8871	.8488	.8589	.8131
8	.7468	.7545	.7316	.8402	.8131	.6722
9	.9431	.8501	.7762	.7545	.695	.6722
10	.7964	.8316	.823	.7316	.2801	.6602
11	.7468	.7762	.8316	.8048	.7701	.6535
12	.7922	.7392	.7316	.8326	.823	.7545
13	.7964	.695	.6468	.724	.9054	.6535
14	.7922	.8131	.6401	.7164		.6535
15		.7947	.8316	.7316		.7392
16		.7682	.8402	.695		.7468
17		.8316	.8488	.6805		.7545
18		.8413		.7087		
19		.8501	.7468			
24	.7468		.695	.7545		
Max	.9431	.9054	.8871	.9335	.9054	.8131
Min	.7468	.695	.6401	.6805	.2801	.6535
Avg	.8247	.8039	.7785	.7683	.7552	.7138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4525		.4424	2.8045	2.5484	2.9569
7	.5487	.5041	.4424	.3582	.3018	.3206
8	.5544	.415	.3932	.362	.2515	.362
9	.4668	.4108	.3768	.3292	.218	.362
10	.3109		.3353	.3018	.2587	.4207
11	3.0556	2.5724	2.7978	.2683	.3206	.362
12	2.9264	2.7362	2.8166	.285	.3018	.4024
13	2.9569	2.9001	2.5434	.3185	.2896	.362
14	2.9874	2.7362	2.6825	.3185		.3658
15		2.7362	2.5434	.3185		
16		2.7199	2.431	.3391		
17		2.7199		.3052		
18		2.4413	2.0119	.2012		
19		.2949	.2543			
24	.3734		.2949	2.0957		
Max	3.0556	2.9001	2.8166	2.8045	2.5484	2.9569
Min	.3109	.2949	.2543	.2012	.218	.3206
Avg	1.4633	1.9323	1.4547	.6147	.5613	.6572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.4937		1.3599	.2075		.132
7	1.7918	1.8821	1.6385	.2054		.181
8	1.8671	1.8945	1.5729	1.226		1.0898
9	1.8861	1.7804	1.4582	1.587		1.4089
10	.1254	.1147	.0829	1.6057		1.5089
11	.1132	.1475	.1341	1.6385	.5256	1.5089
12	.1867	.1475	.1341	1.8351	.5967	1.5261
13	.2033	.1802	.1187	1.7695	.7865	1.5089
14	.1886	.1638	.1341	1.7695		1.4413
15		.1638	.1526	1.6876		1.4413
16		.1311	.2012	.1311		.1677
17			.2012	.1638		
18		.1802	.2075	.1475		
19		.1966	.2054			
24	1.1763		1.278	.1509		
Max	1.8861	1.8945	1.6385	1.8351	.7865	1.5261
Min	.1132	.1147	.0829	.1311	.5256	.132
Avg	.9032	.5819	.5920	1.0089	.6363	1.0832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.7655		.3881	.2054	.2075	.679
7	.7545	.6722	.5853	.1886	.2075	.3403
8	.6908	.4715	.5914	.6348	.3018	.3881
9	.7545	.4668	.6283	.6099	.3018	.1867
10	.7023	.6283	.6401	.6979	.2801	.1886
11	.7733	.6283	.8048	.6979	.2829	.1867
12	.7392	.4435	.5175	.4715	.2829	.1698
13	.679	.4207	.4024	.6602	.2801	.1867
14	.6722	.4066	.6154	.679		.1867
15		.6653	.695	.6602		.1991
16			.1663	.1886		.2012
Max	.7733	.6722	.8048	.6979	.3018	.679
Min	.6722	.4066	.1663	.1886	.2075	.1698
Avg	.7257	.5337	.5486	.5176	.2681	.2648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1629	.1097	1.1069		.7701	
2	.1267	.1629	.0914	1.078		.7537	
3	1.5927	.1448	.0905	1.0467		.7701	
4	.1646	.1629	.128	1.0155		.8029	
5	.1829	.181	.1646	1.0494		.8356	
6	.2012	.2172	.2195	1.1728		.9175	
7	.2195	.2534	.2378	.2155		.197	
8	.2353	.2353	.2353	.1989		.197	
9	.1829	.2172	.2012	.1658		.1791	
10	.2012	.181	.1991	.1509		.1612	
11	1.5043	1.5729	1.7029	.1663		.1543	
12	1.5684	1.668	1.7654	.1829		.1753	
13	1.6004	1.6549	1.6604	.2195		.1753	.5312
14	1.6004	1.668	1.7711			.1791	.4428
15	1.6164	1.7004	1.8244	.2195		.1612	.4481
16	1.6164	1.7204	1.7124	.2012	.1829		.4481
17	1.5844	1.7328	1.6842	.2172	.2012	.12	.1372
18	1.5043	1.6549	1.4737	.2353	.1463		.1372
19	.2172	.1991	.1928	.2561	.1829		.1543
20	.1991	.2012	.1928		.1646		.1543
21	.2172	.2012	.1734		.8002		.12
22	.2172	.181	.156		.7682		.12
23	.181	.1463	.1387	.1663	.7537		.1543
24	.1478	.1629	.1267	1.1069		.7537	
Max	1.6164	1.7328	1.8244	1.1728	.8002	.9175	.5312
Min	.1267	.1448	.0905	.1509	.1463	.12	.12
Avg	.7087	.6826	.6772	.5086	.4	.4296	.2589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6737	.9465	.9457	.2054		.12	
2	.7068	.9202	.9054	.2054		.1029	
3	.6737	.9334	.9191	.1907		.12	
4	.7183	.9202	.9446	.1882		.12	
5	.815	1.1831	.9846	.2462		.1372	
6	.9869	1.3277	1.1437	.3185		.1543	
7	1.4335	1.5512	1.4403	.3475		.1543	
8	1.579	1.4723	1.3336	1.1469		.3841	
9	1.6072	1.3014	1.488	1.347		.5121	
10	.2606	.2235	.2606	1.3603		.5121	
11	.3258	.2667	.3521	1.467	1.467	.4321	
12	.3601	.257	.3521	1.4952			
13	.3944	.2881	.3567	1.4815			
14	.3944	.2896	.3567	1.5015		1.439	
15	.3772	.2858	.3418	1.467		1.5154	.2824
16	.3944	.2896	.39	.2469			.2675
17	.4287	.3001	.3763	.2743			.1932
18	.4458		.2896	.2921	.1372		.2229
19	.3772	.3185	.3506	.3185			.208
20	.3601	.3001	.3506				.1932
21	.3258	.2896	.2709		.1543		.4252
22	.3086	.2572	.2378		.1543		.5075
23	.2743	.2317	.2054		.1543		.5005
24	.8128	.9334	.9318	.2054		.12	
Max	1.6072	1.5512	1.488	1.5015	1.467	1.5154	.5075
Min	.2606	.2235	.2054	.1882	.1372	.1029	.1932
Avg	.6264	.6560	.647	.7153	.4134	.4160	.3112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.664	.6964	.7045	.104		.0905	
2	.6478	.7125	.7209	.1029		.0905	
3	.664	.6882	.6802	.1029		.0724	
4	.6882	.6722	.6802	.1017		.0905	
5	.6964	.7449	.7045	.1357		.0905	
6	.7287	.8421	.7449	.1677		.1267	
7	.8684	.9231	.9175	.1677		.1448	
8	.9231	.9393	.9231	.7773		.664	
9	.9175	.9717	.9339	.7773		.6154	
10	.1134	.1448	.0905	.8488		.6478	
11	.1612	.1646	.2715	.8905		.7202	
12	.181	.181	.1991			.6401	
13	.181	.1829	.2012	1.004		.6405	
14	.181	.181	.2012	.9717		.6249	
15	.181	.1991		.9667		.6173	
16	.2172	.2012	.2012	.1311	.1267		
17	.1991	.1991	.1646	.1267	.1629		
18	.181	.1629		.1267	.1448		
19	.1991	.1448		.1267	.1086		.1029
20	.1991	.1448			.1267		.1187
21	.181	.1433			.1086		.2688
22	.1629	.124			.0905		.2343
23	.1448	.1052			.0905		.2031
24	.6882	.6964	.7373	.104		.0905	
Max	.9231	.9717	.9339	1.004	.1629	.7202	.2688
Min	.1134	.1052	.0905	.1017	.0905	.0724	.1029
Avg	.4154	.4236	.5339	.4071	.1199	.3729	.1856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.12		1.012		.5401	
2	.0819	.12		.9804		.5247	
3	.0983	.12		.9374		.5093	
4	.0983	.1029		.9061		.5556	
5	.0819	.12		.8951		.5864	
6	.0972	.12		1.034		.5864	
7	.1147	.12		.1174		.0857	
8	.081	.1372		.116		.0686	
9	.0983	.1372	.1147	.1326		.0686	
10	.0972	.12	.116	.1341		.0686	
11	1.3435	1.4737	1.2651	.1147		.081	
12	1.3748	1.5604	1.439	.1457		.08	
13	1.3748	1.406	1.5023	.1311		.112	
14	1.3904		1.4883	.1147		.096	
15	1.3592		1.4403	.1296		.096	
16	1.1561		1.4737	.1475			
17	1.2186		1.4899	.1457	.1543		
18	1.2342	1.3889	1.4413	.1619	.1372		
19	.12	.1387	.1387	.1619	.1372		
20	.1543	.1715	.1387		.1372		.1543
21	.1543	.1387	.12		.571		.12
22	.156	.1387	.12		.5247		.1029
23	.12	.1029	.1029		.5247		.0857
24	.0972	.12		1.0279		.5093	
Max	1.3904	1.5604	1.5023	1.034	.571	.5864	.1543
Min	.081	.1029	.1029	.1147	.1372	.0686	.0857
Avg	.5083	.3928	.8261	.4273	.3123	.2855	.1157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	1.0595	1.1544	.1734		.1357	
2	.7907	1.0753	1.1523	.1715		.1526	
3	.7748	1.0595	1.1203	.1715		.1526	
4	.7811	1.0911		.1696		.1696	
5	.8697	1.186	1.1544	.2204		.1865	
6	1.0279	1.2967	1.3283	.788		.2035	
7	1.2323	1.4864	1.3763	.2683		.2204	
8	1.3123	1.5813	1.6032	1.2041		.9217	
9	1.1012	1.5181	1.7204	1.4022		1.1248	
10	.1802	.2058	.2515	1.2651		1.078	
11	.1865	.208	.2743	1.5278		1.2492	
12	.2035	.2601	.2947	1.6872		1.2483	
13	.2035	.2279	.3012	1.6716		1.2963	
14	.2035	.2279	.3045	1.6358		1.2803	
15	.2035	.2481	.2896	1.5813		1.2176	
16	.2204	.2507	.3258	.1875			
17	.2374	.2686	.3292	.2056			
18	.2543	.2507	.3077	.2401	.2204		.1696
19	.2543		.2715	.2591	.1865		.1526
20	.2543		.2686		.1865		.1357
21	.2543		.2481		.1696		.4999
22	.2204		.2454		.1526		.4531
23	.2035		.2103		.1526		.4062
24	.7865	1.0437	1.1702	.1907		.1357	
Max	1.3123	1.5813	1.7204	1.6872	.2204	1.2963	.4999
Min	.1802	.2058	.2103	.1696	.1526	.1357	.1357
Avg	.5236	.7655	.6827	.7510	.1780	.6733	.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.3224	.3012	.3012		.3403	
2	.3155	.3224	.3012	.3012		.3403	
3	.333	.3045	.2804	.2804		.3224	
4	.3544	.3403	.3189	.2804		.3403	
5	.394	.3898	.3403	.3467		.394	
6	.4607	.4428	.4784	.4854		.5014	
7	.4656	.4656	.5014	.4801		.5194	
8	.3366	.394	.394	.4115		.4119	
9	.3582	.3761	.3366	.2915		.394	
10	.394	.394	.3761	.3429		.3403	
11	.3403	.3045	.3761	.3582		.3403	
12	.3582	.3403	.3982	.3761		.3761	.2572
13	.3403	.2686	.3658	.3721		.3439	
14	.3403	.2715	.3658	.3366		.3403	.3601
15	.3582	.2686	.3475	.3582		.3761	.3944
16	.3403	.2865	.3696	.3189			.3944
17	.4119	.2865	.4251	.3403	.4961		.3944
18	.3582	.3403	.439	.3582	.4784		.3772
19	.4119	.394	.4572	.3582	.4784		.4287
20	.4784	.5316	.4572		.4784		.4409
21	.4252	.4607	.3582		.3761		.407
22	.3898	.4477	.2481		.3761		.3391
23	.3544	.3761	.2126		.3582		.2883
24	.3582	.3224	.3224	.2126		.3582	
Max	.4784	.5316	.5014	.4854	.4961	.5194	.4409
Min	.3155	.2686	.2126	.2126	.3582	.3224	.2572
Avg	.3756	.3605	.3655	.3455	.4345	.3775	.3711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.5914	.499	.3658	.3921	.4481	.0739
2	.4108	.5544	.4854	.3881	.3772	.4294	.0747
3	.4108	.5544	.5544	.4207	.3734	.3921	.0934
4	.4435	.5544	.5228	.462	.3961	.3921	.0924
5	.4854	.5544	.6283	.4938	.4668	.3921	.1109
6	.5228	.5544	.6908	.5853	.5658	.5601	.1307
7	.5601	.6468	.6535	.5914	.6161	.6348	.1294
8	.4805	.5601	.5729	.2561	.5415	.5359	.3292
9	.4481	.5788	.6161	.2957	.5415	.4805	.2772
10	.5175	.7207	.6099	.2561	.5093	.4251	.2614
11	.4435	.6908	.5729	.3734	.5853	.4251	.2957
12	.5487	.3881	.499	.5041	.5175	.4251	.4854
13	.4207	.5175	.4572	.6224	.5175	.4108	.4527
14	.4207	.5601	.499	.5975	.5359	.4066	.4668
15	.439	.6468	.5544	.6224	.4066	.4481	.4338
16	.567	.6283	.5121	.6161	.5359	.4805	.4668
17	.5487	.6535	.5304	.5658	.5175	.4481	.4527
18	.6584	.6722		.5975	.499		.4668
19	.6653	.7577	.5359		.6161		.5847
20	.7577	.7762	.5544		.6908		.5788
21	.7023	.8215	.5853	.5658	.6161		.4668
22	.6468	.8029			.5144	.1294	.4481
23	.5729	.7392		.415	.5601	.1267	.3547
24	.4481	.6099	.5359	.3881	.3921	.5228	.112
Max	.7577	.8215	.6908	.6224	.6908	.6348	.5847
Min	.4108	.3881	.4572	.2561	.3734	.1267	.0739
Avg	.5227	.6306	.5557	.4754	.5119	.4257	.3183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1267	.128	.463	.4588	.9412	
2	.1307	.1267	.1267	.463	.4534	.905	
3	.1294	.1267	.128	.4748	.4481	.905	
4	.1494	.1448	.1478	.4578	.4588	.905	
5	.1478	.1448	.168	.4748	.4321	.905	
6	.1848	.1448	.1867	.463	.4424	1.0679	
7	.1848	.1629	.2012	.0848	.0943	.1991	
8	.2241	.2172	.2402	.0905	.0747	.1991	
9	.2402	.181	.2378	.0732	.0747	.2012	
10	.2054	.1646	.2353	.0924	.1509	.1829	
11	1.8267	2.0995	1.9685	.1494	.128	.1791	
12	1.8959	2.3529	2.0809	.168	.1294	.181	
13	2.0774	2.3228	2.1464	.1698	.1294	.181	.4218
14	2.0633	2.2986	2.1136	.1867	.1109	.1448	
15	2.009	2.2805	2.0719	.1867	.1478	.1267	.7209
16	2.0452	2.2177	1.9227	.1698	.1663	.1433	.1867
17	1.9366	2.0538	1.8679	.1867	.1663	.1448	.2241
18	1.7375	1.8473		.2075	.2402		.2075
19	.1463	.1991	.0554		.1848		.2241
20	.1646	.2033	.0924		.2218		.2075
21	.1463	.2054	.0934	.4752	1.0349		.2075
22	.1463	.1848	.0554	.4752	1.0534		.2054
23	.1267	.1848		.4641	1.0269		.2054
24	.1478	.1267	.1267	.4908	.4641	.961	
Max	2.0774	2.3529	2.1464	.4908	1.0534	1.0679	.7209
Min	.1267	.1267	.0554	.0732	.0747	.1267	.1867
Avg	.7582	.8382	.7452	.2940	.3455	.4707	.2811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.1948	2.2624			.1829	
2	2.3926	2.1948	2.2539			.1829	
3	2.4539	2.2862	2.5415			.1829	
4	2.5968	2.2862	2.8959			.2195	
5	2.6863	2.3777	2.955			.2195	
6	3.1024	2.5972	2.915			.3109	
7	3.035	3.1093	2.9504			.2743	
8	3.1034	3.4751	3.2074	1.7295		2.1491	
9	3.035	3.1855	2.8121	1.9227	2.3525	2.7938	.168
10	.3121	.181	.1991	2.2775	2.2809	2.774	.1663
11	.3109	.3174	.2149	2.556	2.8395	2.8807	.1663
12	.3292	.2957	.2715	2.5606	2.8235	2.7149	.168
13	.3109	.2987	.3077	2.5888	2.7149	2.5882	.168
14	.3292	.3174	.3077	2.6073	2.7149	2.6749	.1886
15	.3292	.3174	.3224	2.6871	2.6787	2.3148	.168
16	.3292	.3511	.3475	.2987	.2218	.2012	
17	.3109	.3361	.3189	.2641	.2957	.2743	
18	.2743	.3696		.2614	.2195		.2427
19	.2926	.3547			.2195		.2263
20	.3658	.3511			.2926		.2054
21	.3658	.3361			.2926		.8962
22	.2743	.3142			.2378		.9995
23	.2012	.2957		.2614	.1829		.9217
24	2.5953	2.1948	2.0687			.1829	
Max	3.1034	3.4751	3.2074	2.6871	2.8395	2.8807	.9995
Min	.2012	.181	.1991	.2614	.1829	.1829	.1663
Avg	1.3224	1.2641	1.6196	1.6679	1.3578	1.2845	.3604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4251	1.6289	.1646	.112	.1326	
2	1.3565	1.4251	1.7337	.1478	.1132	.1326	
3	1.4089	1.5089	1.9281	.1663	.112	.1326	
4	1.5432	1.5089	2.0576	.1848	.1307	.1341	
5	2.2119	1.5927	2.1795	.1646	.1494	.1341	
6	2.2291	1.8275	2.3739	.2012	.1494	.1658	
7	2.3148	2.4478	2.6505	.2218	.1509	.1326	
8	2.3232	2.431	2.5339	1.3226	.9389	1.6078	.1307
9		2.3137	2.3834	1.6712	1.6385	2.1216	.1109
10	.1307	.0995	.1646	1.9227	1.7124	2.1714	.0732
11	.1109	.1526	.1829	2.0972	1.7772	2.1365	.0724
12	.1109	.1372	.2218	2.0645	2.0553	2.2291	.0747
13	.1326	.1387	.2218		1.9559	2.2977	.0943
14	.1341	.1629	.2402	1.9685	1.9227	2.2885	.168
15	.1341	.1629	.2054	2.0405	1.8067	2.4691	.132
16	.1509	.1629	.1848	.1494	.1509	.181	.1307
17	.1341	.1612	.1848	.168	.1174	.1646	.132
18	.1341	.1612		.1698	.1174		.1494
19	.1492	.181			.1509		
20	.2012	.2012	.1848		.1677		.168
21	.1844	.1991	.2195	.1494	.1677		.6554
22	.1844	.2033		.132	.1509		.7209
23	.1509	.1848		.112	.1509		.6882
24	1.4632	1.2071	1.6448	.1663	.1132	.1174	.1646
Max	2.3232	2.4478	2.6505	2.0972	2.0553	2.4691	.7209
Min	.1109	.0995	.1646	.112	.112	.1174	.0724
Avg	.7941	.8332	1.1562	.7326	.6672	1.0416	.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4458	.4887	.0373	.0377	.0332	.0183
2	.4481	.4973	.5121	.0373	.0377	.0332	.0183
3	.4805	.4973	.4801	.056	.0377	.0332	.0185
4	.5228	.4973	.5258	.0373	.0377	.0332	.0185
5	.5359	.4973	.5959	.0373	.056	.0332	.0187
6	.5788	.5658	.6241	.056	.0566	.0332	.037
7	.6161	.7202	.7316	.056	.0747	.0497	.0373
8	.6653	.7545	.7343	.2486		.2818	.037
9	.7207	.7888	.7421	.2486		.3315	.0183
10	.0747	.0686	.0905	.2458	.2785	.3812	.0181
11	.1029	.0549	.0914	.2949	.3149	.4409	.0181
12	.0857	.0914	.0914	.3921	.3481	.463	.0373
13	.0857	.0857	.0924	.2294	.3481	.4973	.0377
14	.0857	.0905	.0914	.4096	.3481	.5201	.0187
15	.0857	.0924	.0914	.3725	.3812	.4801	.0187
16	.0857	.0924	.0914	.0566	.0332	.0366	.0377
17	.0857	.1307	.0924	.0747	.0332	.0366	.0373
18	.0686	.128		.0754	.0497		.0377
19	.0514	.0724			.0332		.0373
20	.0514	.0739			.0497		.0566
21	.0686	.0554		.0373	.0497	.0362	.0934
22	.0686	.0549		.0566	.0332	.0362	.112
23	.0686	.0543		.0373	.0332	.0181	.112
24	.3696	.4115	.4706	.037	.0377	.0332	.0183
Max	.7207	.7888	.7421	.4096	.3812	.5201	.112
Min	.0514	.0543	.0905	.037	.0332	.0181	.0181
Avg	.2674	.2842	.3688	.1424	.1232	.1829	.0380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0838	.0739	1.2689	.9503	1.2597	.0366
2	.0934	.0838	.0747	1.2717	.9231	1.2431	.037
3	.0739	.0838	.0732	1.2548	.9503	1.2266	.0366
4	.0924	.0838	.0739	1.3032	.9945	1.2266	.037
5	.0924	.0838	.0934	1.286	.9831	1.2266	.0373
6	.0934	.0838	.1109	1.4413	.9762	1.3094	.0554
7	.0934	.1006	.0914	.0905	.0373	.0332	.056
8	.1097	.1006	.0905	.1097	.0754	.0332	1.1273
9	.1086	.1006	.1267	.0924	.056	.0503	1.0164
10	.0924		.128	.0934	.056	.0663	.8871
11	2.2916	2.2018	2.1548	.0943	.0335	.0848	.924
12	2.1091	1.9806	2.2377	.0754	.0335	.0857	.852
13	2.1434	2.3348	2.3594	.0934	.0335	.1052	.7811
14	2.0919	2.371	2.3205	.0943	.0503	.0724	.7865
15	2.0919	2.0919	2.1548	.0934	.0503	.0914	.7773
16	1.9376	2.1719	2.1051	.0754	.0663	.1448	.0373
17	2.0576	1.97	1.8351	.0934	.0663	.1086	.0373
18	1.8347	1.9105	1.8351	.0943	.0663		.0377
19	.0838	.0914			.0497		.0187
20	.0838	.112			.0497		.0377
21	.0838	.112		.9878	1.2597		.0187
22	.0829	.1086		.9374	1.326	.0503	.0189
23	.0829	.0914		.9667	1.326	.0362	.0187
24	.0924	.0838	.0914	1.286	.9282	1.2597	.0366
Max	2.2916	2.371	2.3594	1.4413	1.326	1.3094	1.1273
Min	.0739	.0838	.0732	.0754	.0335	.0332	.0187
Avg	.7496	.8016	.9490	.5956	.4726	.4857	.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	1.3413	1.6164	.0511		.0564	
2	1.3763	1.3413	1.6518	.0695			
3	1.4419	1.4922	1.6518	.0695		.0572	
4	1.4419	1.4083	1.6356	.0695		.0572	
5	1.4746	1.4083	1.6164	.0714		.0579	
6	1.5729	1.5524	1.7814	.0983		.0587	
7	1.7004	1.8884	1.8884	.0987		.08	
8	1.9784	1.9364	1.9845	1.4685		1.3435	
9	1.9433	1.9919	1.9685	1.5043		1.5524	
10	.0774	.0974	.0857	1.5181		1.6164	
11	.0734	.0905	.0705	1.5339		1.8187	
12	.076	.1075	.0907	1.5813			
13	.064	.0895	.0697	1.5684			
14	.0834	.1086	.0823	1.5746			
15	.0949	.0867	.1054	1.6164			
16	.0937	.08	.104	.08			
17	.112	.0903	.084		.0974		
18	.0914	.0791	.0789		1.2498		
19	.0937	.08	.0526		.0753		
20	.096	.0633	.0579		.0648		.0743
21	.096	.0633	.0753		.0533		.57
22	.0695	.0625	.0648		.0533		.663
23	.0838	.0633	.0695		.0541		.663
24	1.3443	1.3226	1.6004	.0511		.0549	
Max	1.9784	1.9919	1.9845	1.6164	1.2498	1.8187	.663
Min	.064	.0625	.0526	.0511	.0533	.0549	.0743
Avg	.7023	.7019	.7703	.7662	.2354	.6139	.4926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1663	.1646	1.2003		1.1561
2	.1311	.1663	.1629	1.1544		1.1111
3	.1311	.1663	.1463	1.1069		1.1111
4	.1638	.1663	.1463	1.1069		1.1111
5	.16	.1663	.1463	1.1227		1.1111
6	.1638	.1663	.1463	1.1683		1.2803
7	.1829	.1478	.1629	.104		.1254
8	.1457	.1848	.1629	.0772		
9	.1463	.1267	.1433	.081		.1029
10	.1578	.1772	.1928	.081		.1017
11	2.1792	2.5194	2.5692	.0671		.1075
12	2.4086	2.6023	2.6543	.0819		
13	2.3482	2.5194	2.7362	.081		
14	2.3594	2.4697	2.7362	.08		
15	2.2775	2.42	2.6852	.081		
16	2.2939	2.4086	2.6073	.096		
17	2.2552	2.2348	2.3967	.096	1.1544	
18	2.0165	2.1628	1.9524		.0838	
19	.128	.1402	.1494		.0848	
20	.1646	.1848	.1357		.0848	
21	.1646	.1629	.1417		1.142	
22	.1646	.1448	.112		1.2037	
23	.1646	.1463	.124		1.2186	
24	.1433	.1646	.1463	.124		1.1873
Max	2.4086	2.6023	2.7362	1.2003	1.2186	1.2803
Min	.128	.1267	.112	.0671	.0838	.1017
Avg	.8576	.9131	.9467	.4394	.7103	.7732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4668	.4805	.4481		.5228	
2	.4572	.4668	.4854	.4294		.4854	
3	.4207	.4668	.4854	.4481		.4854	
4	.4207	.5359	.5041	.4481		.4854	
5	.695	.5359	.5228	.4481		.499	
6	.6447	.7167	.6838	.6161		.6767	
7	.6584	.6447	.6335	.6653		.6767	
8	.5788	.591	.5895	.5788		.6379	
9	.5493	.5611	.5784	.6161		.5028	
10	.4748	.5847		.5731		.583	
11	.5434	.6024	.4835	.5434		.5201	
12	.5609	.5373	.5375	.6001			
13	.5973	.5731		.5258			
14	.567	.543	.6762	.5729			
15	.543	.5973	.7011	.6447			
16	.4656	.567	.6588	.6241			
17	.4904	.6201	.6268	.5415	.8063		
18	.4715	.5959	.57		.8059		
19	.5847	.695	.5853		.8413		
20	.7133	.8507	.6979		.8775		.7316
21	.7167	.724	.6979		.7682		.7316
22	.6036	.6584	.6224		.6653		.6602
23	.5544	.5853	.5544		.5914		.4527
24	.4668	.5041	.5359	.5281		.5544	
Max	.7167	.8507	.7011	.6653	.8775	.6767	.7316
Min	.4207	.4668	.4805	.4294	.5914	.4854	.4527
Avg	.5515	.5927	.5869	.5473	.7651	.5525	.6440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 400 / STATION TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.8488
Max	.8488
Min	.8488
Avg	.8488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 401 / 33 KV SHIRSGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.1687
Max	3.1687
Min	3.1687
Avg	3.1687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 406 / 33 KV ACORN-I (Wind Mill) NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
12	.2829
24	.2572
Max	.2829
Min	.2572
Avg	.2701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 407 / 33 KV WANGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.6008
Max	3.6008
Min	3.6008
Avg	3.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 410 / 33 KV SHIVANI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.3148
Max	2.3148
Min	2.3148
Avg	2.3148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 411 / 33 KV BHIKWADI (KH.)

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3004
Max	4.3004
Min	4.3004
Avg	4.3004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 601 / SONHIRA S.S.K.LTD

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	6.3375
Max	6.3375
Min	6.3375
Avg	6.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	.1109	.104	.1075	.1086	.1075	.1075
2	1.6975	.0739	.104	.1075	.1086	.1075	.1075
3	1.6975	.0732	.0867	.1063	.1097	.0895	.1086
4		.0732	.0867	.1063	.1097	.0895	.1086
5	1.6598	.0732	.104	.1063	.1086	.0895	.1063
6	1.6221	.0724	.104	.1063	.1063	.0867	.0709
7	1.5466	.0724	.1029	.1029	.1052	.0857	.104
8	1.5089	.1017	.1017	.104	.1063	.0838	.1029
9	1.5089	.0995	.1017	.1029	.1063	.1017	.1029
10	1.6804	.096	.0937	.0995	.1187	.1006	.1006
11	1.773	.1006	.1052	.0995	.1029	.0983	
12		.0983	.1052	.1029	.1029	.096	.1017
13		.0995	.1052	.1029	.1029	.1029	.1029
14		.0876	.1052	.1086	.1006	.1017	.1052
15	2.0911	.1006	.1063	.1052	.1006	.1006	.1052
16	1.97	.116	.1017	.1017	.1174	.1296	.1052
17	.1029	.0995	.1006	.1372	.1174	.0995	
18	.104	.104	.1017		.0983		.1006
19	.1029	.1214	.1052	.112	.104		.104
20	.1433	.1387	.1063	.1463	.1387	.1075	.104
21	.1448	.1254	.1097	.1109	.1227	.1075	.1063
22	.1109	.1086	.1448	.1109	.1086	.1063	.1075
23	.1109	.1254	.1063	.1086	.1075		.1063
24	1.8298	.1097	.1075	.1075	.1075	.1075	
Max	2.0911	.1387	.1448	.1463	.1387	.1296	.1086
Min	.1029	.0724	.0867	.0995	.0983	.0838	.0709
Avg	1.1570	.0992	.1042	.1089	.1092	.1	.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4754	.9431	1.4217	1.5089	1.2597	1.5604	
2	1.3413	.9054	1.3523	1.4754	1.3108	1.4563	
3	1.3032	.8676	1.283	1.4403	1.2887	1.3523	
4	1.2269	.8676	1.1789	1.406	1.1568	1.2136	
5	1.2178	.9054	1.2136	1.3717	1.1789	1.2136	
6	1.0608	.8962	1.2689	1.3717	1.166	1.2407	
7	.9979	.8962	1.3592	1.5074	1.1934	1.3592	
8	.8676	1.2548	1.4899	1.5402	1.326	1.4746	
9	.724	1.5364	1.7078	1.7814	1.5546	1.6667	
10	.7468	1.7593	1.8362	1.9685	1.3676	1.8435	
11		1.9204	1.9204	1.9608	1.326	1.9753	
12		1.3077	1.278	1.4922	1.2498	1.3108	
13		1.283	1.4091	1.4255	1.5623	1.4083	1.5043
14		1.6644	1.9334	1.9204	1.8519	1.821	1.7375
15	.7468	1.7604	2.0405	1.9292	1.8519	1.8122	1.8823
16	.6447	1.6194	1.7166	1.7924	1.5546	1.5432	1.6289
17	.6173	1.6964	1.7985	1.8027	1.7497	1.7593	
18	.6173	1.5249	1.6762		1.6057		1.5181
19	.7712	1.6324		.8962	1.6964		1.6057
20	.9431	1.6575	1.6575	1.531	1.4575		1.4083
21	.8962	1.086	1.2403	.9145	.8322		1.0608
22	.9431	1.5223	1.6575	1.3923	1.5402		1.5074
23	.9431	1.6385	1.704	1.3763	1.5524		1.5402
24	1.4746	.9431	1.595	1.4403	1.2887	1.6297	
Max	1.4754	1.9204	2.0405	1.9685	1.8519	1.9753	1.8823
Min	.6173	.8676	1.1789	.8962	.8322	1.2136	1.0608
Avg	.9780	1.3370	1.5538	1.5324	1.4134	1.5356	1.5394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1218	1.0349	1.0387	1.0985	.5548	.8669	.7522
2	1.0867	1.0349	.9671	1.0631	.5258	.8669	.7316
3	1.0631	.9979	.8954	1.0387	.5316	.8322	.6584
4	1.0387	.9877	.8596	.9671	.5014	.7628	.6584
5	1.0029	1.0242	.8954	1.0029	.5316	.7628	.724
6	1.0029	1.0608	.9313	1.0745	.5316	.7888	.724
7	1.0745	1.1104		1.0288	.4908	.8669	.8413
8	1.0056	1.2689	1.1789	1.2407	.6104	.8573	.8478
9	1.0402	1.3077	1.4091	1.3413	.6226	.9282	.8848
10	1.1065	1.3763	1.4723	1.3435	.6081	.9393	.9069
11	1.0749	1.4091	1.643	1.3927	1.0486	1.0437	
12		1.3923	1.2742	1.1336	1.0608	.8124	.7712
13		1.1401	1.1401	.2774	1.073		.9496
14		1.3077	1.3748	1.2742	.9282	1.0486	.8916
15	1.0867	1.326	1.4922	1.3592	.9717	1.0608	.9259
16	1.1218	1.3923	1.4091	1.3763	1.0242	1.0623	.8916
17	1.1096	1.3603	1.406	1.4403	.9282	1.0688	
18	1.0402	1.2597	1.3123		.8322		.9259
19	1.0517	1.3592			.9724		.8478
20	1.1462	1.406	1.1443	.4656	.9724	.7442	.9362
21	1.0498	1.1789	1.0166	.4908	.8322	.7522	.8764
22	1.0498	1.2483	1.2048	.5258	.9362	.8596	.9568
23	1.0608	1.283	1.1919	.5895	.964	.8063	.9816
24	1.1919	1.0608	1.1443	1.1568	.5548	.9015	
Max	1.1919	1.4091	1.643	1.4403	1.073	1.0688	.9816
Min	1.0029	.9877	.8596	.2774	.4908	.7442	.6584
Avg	1.0727	1.2220	1.2001	1.0310	.7753	.8873	.8421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0498	.8962	.9877	.924	.905	1.4327	.5487
2	1.0136	.8501	.9877	.8871	1.1946	1.3969	.5601
3	.9877	.8501	.9145	.8501	1.0974	1.3253	.5544
4	.924	.8048	.8779	.8131	.961	1.2178	.5121
5	.8676	.8413	.9145	.8871	1.0608	1.2178	.6733
6	.7922	.8688	.9511	.961	1.1706	1.2536	.8413
7	.9054	.9214	.9774	1.0387	1.267	1.2894	1.0513
8	.7842	.9568	1.1789	1.1096	1.4022	1.3523	1.1919
9	.7095	1.1789	1.2407	1.3032	1.4217	1.3904	1.2003
10	.961	1.1843	1.3108	1.2597	1.4918	1.5089	1.3592
11	.8669	1.2929	1.4582	1.3413	1.2887	1.5249	
12		.9259	.9496	1.0166	1.283	1.2209	
13		.8859	.9835	.9313	1.283	1.2136	1.2407
14		1.0174	1.2887	1.2346	1.6244	1.4419	1.5089
15	.1311	1.2407	1.3375	1.326	1.6095	1.5089	1.5775
16		1.1736	1.2887	1.2887	1.5249	1.4419	1.3375
17	.0995	1.2597	1.2308	1.2929	1.5424	1.5074	
18	.7865	1.0749	1.1191		1.3592		1.2407
19	.9568	1.2071		.5014	1.5604		1.3176
20	1.0242	1.3466	1.0387		1.491		1.5074
21	.9877	.961	.961	.9145	1.1576		1.1458
22	.9145	1.0745	1.0608	1.086	1.3253		1.3611
23	.8871	1.2048	1.1694	1.0631	1.4373		1.3672
24	1.0745	.8962	1.0387	.9774	.9671	1.5043	
Max	1.0745	1.3466	1.4582	1.3413	1.6244	1.5249	1.5775
Min	.0995	.8048	.8779	.5014	.905	1.2136	.5121
Avg	.8362	1.0381	1.0985	1.0458	1.3094	1.3749	1.1049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 402 / 33kv NEW VITA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
11	2.0348
Max	2.0348
Min	2.0348
Avg	2.0348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.0972	4.9383	4.8354	3.4328	.8688	3.7609	1.2071
2	4.9931	4.9954	4.8354	3.3288	.9134	3.7609	1.2071
3	4.8891	4.9954	5.0503	3.2247	.9231	3.7609	1.3717
4	5.0972	5.9099	5.1578	3.6408	.9877	3.7609	1.4661
5	5.5133	6.4152	5.2652	3.9529	1.0974	3.6534	1.9004
6	5.9294	6.6873	5.9099	4.473	1.1643	3.4385	2.3102
7	6.9696	7.4269	7.4417	2.0805	1.0745	1.6632	1.5912
8	6.9696	8.239	7.2817	4.161	2.8487	4.8354	2.7566
9	7.0576	6.7616	6.2414	5.0972	3.0247	5.3727	2.8292
10	1.5581	1.5432	2.3926	5.5927	3.4385	7.3377	3.3573
11	4.9411	5.2012	5.8253	6.9159	3.7071	7.0576	
12	4.6091	1.6118	1.9765	7.2588	3.7609	6.7215	
13	4.6639	5.3727	4.8891	7.2588	5.9099	6.7656	
14	4.8234	4.2981	1.3523	7.2428	3.7609	6.4015	2.6749
15	1.4563	4.161	5.2012	7.356	4.8354	6.1728	2.572
16	4.481	4.161	4.369	1.7375	2.1491	2.1033	1.3375
17	4.6491	4.6811	1.6644	1.8461	2.7721	1.3226	
18	4.5462	4.6296	4.369		1.6632		.9259
19	1.5203	2.6006	2.7778	.5144	2.2177		1.2346
20	1.9044	2.6006	2.0805	.4298	2.2177	.1086	1.749
21	2.0165	2.572	1.8724	1.2226	4.4353	.439	2.6749
22	1.9044	1.5604	1.7684	.9231	4.4353	1.0425	2.7778
23	1.6804	1.5604	1.5604	.9774	3.7146	1.086	2.572
24	4.9931	4.8731	4.8354	3.3288	1.0208	3.7609	
Max	7.0576	8.239	7.4417	7.356	5.9099	7.3377	3.3573
Min	1.4563	1.5432	1.3523	.4298	.8688	.1086	.9259
Avg	4.2610	4.4915	4.1230	3.7390	2.6225	3.8330	2.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2172	.1943	.0743	1.5043		
2	.2103	.2149	.1943	.0724	1.4723		
3	.2241	.1829	.1898	.0724	1.4403		
4	.2172	.1848	.1898	.0714	1.3927		
5	.2172	.1848	.1875	.0714	1.3603		
6	.2353	.2561	.1989	.0724	1.3603		
7	.3292	.2896	.2012	.1094	.2263		.0347
8	.3439	.3224	.2401	.096	.1886		.2469
9	.3658	.3224	.2561	.1017	.1886	.2507	.2258
10	.3403	.3224	.2254	.0943	.156	.2353	.6562
11	.8002	2.7183	2.5069	.0943	.1734	.2561	1.004
12	.852	2.8675	2.6379	.0943	.1907	.2743	1.1498
13	2.5232	2.9172	2.7349	.1886	.1928	.2378	1.0936
14	2.4905	2.9005	2.6852	.2263	.2149	.2378	1.0936
15	2.5888	2.5029	2.6379	.2263	.1791	.197	1.1873
16	2.6216	2.3371	2.6543	.3206	.1989	.2481	.168
17	2.6543	2.3371	2.6852	.2987	.2058	.208	.168
18	2.3922	2.2611	2.5526	.2987	.2427	.1734	.1867
19	.2804	.1989	.2753		.1928		.1867
20	.2865	.2321	.1296		.2103	.1526	.1509
21	.2926	.2229	.0903	1.7004	1.3763		.1509
22	.2561	.213	.0926	1.6194	1.3923		.1509
23	.2561	.2105	.088	1.5708	1.3443		.1509
24	.2103	.2353	.1966	.0743	1.5203		
Max	2.6543	2.9172	2.7349	1.7004	1.5203	.2743	1.1873
Min	.2103	.1829	.088	.0714	.156	.1526	.0347
Avg	.8833	1.0272	1.0019	.3431	.7052	.2246	.4709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9334	1.8023	1.5844	1.2483	.1109	.112	
2	1.8623	1.8187	1.5203	1.2483	.1109	.112	
3	1.8842	1.7652	1.4403	1.1717		.0934	
4	1.7814	1.7166	1.3603	1.1717	.1109	.0943	
5	1.7814	1.8785	1.3603	1.1873	.1109	.1132	
6	1.9662	2.0809	1.5074	1.2029	.1109	.1307	
7	2.5857	2.2611	2.0972	.1097	.1132	.112	
8	2.7526	2.4905	2.2939	1.4723		1.6194	
9	2.6871	2.5232	2.13	1.9006		1.9524	
10	.0995	.116	.0926	1.989	1.5546	2.1548	.0747
11	.1357	.1097	.0709	2.2708	1.5546	2.42	.0747
12	.1052	.128	.1006	2.3205	1.5708	2.2211	.0747
13	.1052	.1075	.1075	2.42	1.6712	2.1956	.0739
14	.1075	.0732	.1075	2.2939	1.704	2.304	.0739
15	.1097	.1109	.1075	2.1628	1.6712	2.42	.0747
16	.1097	.1267	.1086	.0747	.1075	.08	.0754
17	.1463	.1267	.1086	.0747	.1075	.0848	.0754
18	.1402	.1254	.0716	.1109	.1075	.0848	.1132
19	.1734	.1254	.1254		.1075		.1109
20	.1753	.1433	.1433		.1097		.1109
21	.1791	.1307	.1448	.1109	.112		.8097
22	.1433	.1494	.1448	.112	.1307		.8745
23	.1052	.112	.1433	.112	.112		.8259
24	1.9662	1.668	1.668	1.2803	.1109	.112	
Max	2.7526	2.5232	2.2939	2.42	1.704	2.42	.8745
Min	.0995	.0732	.0709	.0747	.1075	.08	.0739
Avg	.9598	.9037	.7725	1.1839	.5428	.9693	.2459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0317	1.9826	2.0222	1.587	.1867	.1658	
2	1.9662	1.9662	1.9989	1.587	.1867	.1658	
3	1.9662	1.9334	1.9989	1.5364	.1867	.1677	
4	1.9006	1.9559	1.9989	1.5364	.1867	.1677	
5	1.9006	2.0222	2.0885	1.5364	.2241	.1989	
6	2.0972	2.2542	2.3205	1.5364	.2241	.2321	
7	2.5857	2.5526	2.7161	.2195	.2561	.2347	
8	2.3205	2.556	2.5194	2.0972			
9	2.2283	2.5724	2.5857	2.3472	1.8138	.4527	
10	.2321	.2774	.362	2.5149	1.6244	.4527	
11	.2347	.2926	.407	2.5819	1.5912	.5344	
12	.2321	.4435	.39	2.652	1.5746	.5344	
13		.4805	.4435	2.7681	1.5912	2.5149	
14		.4251	.4066	2.7496	1.5912	2.652	
15	.3353	.3881	.4024	2.6155	1.5581	2.4531	
16	.3978	.462	.4024	.2896	.2294	.3052	
17	.4359	.499	.3429	.3734		.2896	.2126
18	.4973	.5121	.2984	.4108		.2926	.2126
19	.2267	.3658	.2926		.2347		.2149
20		.4435	.2195		.1989		.1791
21		.4481	.2195	.1829	.1966		
22		.4108	.2218	.1829	.1966		.4816
23		.3734	.2218	.1867	.2321		.431
24	2.0317	1.9393	2.0222	1.6194	.1867	.1658	
Max	2.5857	2.5724	2.7161	2.7681	1.8138	2.652	.4816
Min	.2267	.2774	.2195	.1829	.1867	.1658	.1791
Avg	1.3123	1.1482	1.1209	1.5051	.6796	.6656	.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1494	.1509	.1478	.1509	.1307
2	.1494	.1307	.1494	.1509	.1478	.1143	.1307
3	.1109	.1132	.1494	.1509	.1478	.1143	.1307
4	.1109	.1132	.1494	.1509	.1402	.1143	.1307
5	.1109	.1143	.1509	.1509	.1402	.1509	.1433
6	.1478	.1524	.1698	.1509	.1402	.1886	.1663
7	.132	.1905	.1509	.1524	.1509	.1886	.1478
8	.1509	.1509	.1334	.1524	.1509	.1524	.1463
9	.1143	.1132	.1509	.1524	.0754	.1334	.0934
10	.1143	.1143	.1132	.1509	.1886	.1143	.1075
11	.1075	.0943	.1132	.1509	.1509	.0943	.112
12	.1075	.1132	.1143	.1132	.132	.0943	.112
13	.1075	.1132	.1143	.1132	.1494	.0747	.1029
14	.1075	.1715	.1143	.1132	.1867	.0747	.1029
15	.1075	.1132	.1143	.1132	.1494	.0934	.0747
16	.1463	.1132	.1143	.1132	.1307	.0943	.0754
17	.1509	.1132	.1524	.1132	.1494	.0943	.0754
18	.1132	.1132	.1143	.1132	.1509	.0953	.0754
19	.1509	.1524	.1509		.1886		.1478
20	.1494	.168	.1509		.2096	.1509	.1478
21	.168	.1886	.1886	.1494	.1867	.1886	.1509
22	.1494	.1886	.1886	.1052	.1886	.1698	.1509
23	.1494	.1509	.1494	.1052	.1886	.1509	.1402
24	.1494	.1294	.1494	.1509	.1478	.1509	.132
Max	.168	.1905	.1886	.1524	.2096	.1886	.1663
Min	.1075	.0943	.1132	.1052	.0754	.0747	.0747
Avg	.1315	.1353	.1415	.1349	.1558	.1282	.1220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.439	.4207	.3696	.3326	.3658	.2427
2	.439	.439	.4207	.3696	.3326	.3696	.2427
3	.4435	.4024	.4207	.3696	.3326	.3696	.2427
4	.4435	.4024	.4435	.3696	.3326	.4024	.2427
5	.4435	.4706	.4805	.3696	.3734	.4656	.3174
6	.6653	.5552	.6468	.5914	.4481	.6447	.5041
7	.7316	.6268	.6697	.5487	.5914	.6089	.5175
8	.4961	.5373	.5083	.5014	.2195	.2534	.4163
9	.4161	.4298	.4733	.4298	.2172	.181	.3155
10	.4477	.2107	.4578	.3582	.3982	.1267	.2652
11	.4656	.4287	.4161	.3467	.3982	.3506	.2321
12	.4656	.4161	.407	.3467	.394	.4252	.1638
13	.5194	.4161	.4161	.3467	.3582	.4075	.1696
14	.4656	.4075	.4161	.4161	.3582	.4252	.1696
15	.3582	.4075	.4207	.4557	.3582	.3761	.3898
16	.3224	.4239	.4207	.373	.3761	.3688	.3898
17	.394	.39	.4359	.3772	.4298	.3688	.3647
18	.5373	.4287	.4854	.4115	.4298	.4239	.3647
19	.6089	.5316	.5609		.4656		.4435
20		.6201	.4908		.4656	.3898	.4854
21		.5853	.4755	.439	.4656	.2126	.4805
22		.5175	.4805	.4066	.4344	.156	.4435
23		.4435	.4251	.3696	.3982	.2279	.4066
24	.4755	.4755	.4207	.3696	.3326	.3658	.2303
Max	.7316	.6268	.6697	.5914	.5914	.6447	.5175
Min	.3224	.2107	.407	.3467	.2172	.1267	.1638
Avg	.4807	.4586	.4672	.4062	.3851	.3603	.3350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 206 / 11 KV Umar Kanchan AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1463	.2195	.1612	1.2018	1.4575	
2	.2218	.1086	.2058	.1612	1.1702	1.4089	
3	.2218	.1086	.2204	.1612	1.1385	1.4091	
4	.2218	.1086	.1957	.1612	1.1203	1.4091	
5	.2218	.1463	.2267	.1612	1.2483	1.5223	
6	.2218	.1829	.1578	.1791	1.2803	1.8138	
7	.2172	.2195	.2538	.1829	.181	.2172	
8	.2172	.2195	.2172	.2012	.181	.1475	
9	.2172	.2195	.1578	.2035	.1753	.1433	.3593
10	.2035	.2126	.1791	.2241	.1629	.1448	.3795
11	2.6216	2.6686	2.9172	.2241	.1463	.1448	.3932
12	2.6543	2.9835	2.8837	.2195	.1463	.1448	.4096
13	2.6543	3.1493	2.8837	.2195	.1463	.1463	.3704
14	2.6379	3.1161	2.8837	.2172	.1267	.1463	.3704
15	2.6216	2.9835	2.8837	.2534	.1267	.1848	.3658
16	2.5888	2.7846	2.8837	.2195	.1791	.1991	.0377
17	2.6216	2.8509	2.9172	.2103	.1791	.181	.0377
18	2.3805	2.8344	2.7846	.2195	.1448	.1433	.0366
19	.1387	.2164	.208	.2195	.1448		.037
20		.2256	.208		.128		.1848
21		.2606	.1829	1.6409	1.4403		.1478
22		.2561	.1629	1.4403	1.5043		.1478
23		.2538	.1629	1.3603	1.5061		.1494
24	.1848	.1463	.2172	.1612	1.2334	1.4737	
Max	2.6543	3.1493	2.9172	1.6409	1.5061	1.8138	.4096
Min	.1387	.1086	.1578	.1612	.1267	.1433	.0366
Avg	1.1645	1.1001	1.0922	.3653	.6255	.6546	.2285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.2321	.2155	.1943		.1989	.2321
2	.1311	.2294		.1943		.1989	.2155
3	.1311	.2294	.2155	.1943		.2012	.2321
4	.1326	.2321	.2155	.2267		.2012	.2155
5	.1326	.2321	.213	.2267		.2012	.2321
6	.2321	.2294	.0347	.2267		.2321	.0373
7	.2321	.2294	.2321	.2294		.2321	.2347
8	.2321	.2294	.2321	.2294		.2347	.2347
9	.2321	.2294	.2321	.2347		.2321	.2321
10		.2241	.2267	.1989		.2347	.2321
11		.2321	.2321	.1989		.2321	.2294
12		.2321	.2241	.2321	.1134	.2321	.1638
13		.2321	.2294	.2321	.2321	.2321	.2321
14		.218	.2294	.2321	.2321	.2321	.2321
15		.2155	.2267	.2321	.2321	.2347	.2321
16	.2321	.2155	.2321	.2321	.2321	.2294	.2321
17	.2294	.2321	.2321	.2321	.1147	.2321	.2321
18	.2321	.2321	.2347	.2321	.1147	.0354	.2321
19	.2267	.2347	.2321		.2294		.2321
20		.2321	.2321		.2294	.0354	.2321
21		.2347	.2267		.2294	.2155	.2321
22		.0343	.2267		.2294	.2321	.2321
23		.2321	.1966		.2321	.2321	.2321
24	.2294	.2321	.2294	.1943		.2012	.2321
Max	.2321	.2347	.2347	.2347	.2321	.2347	.2347
Min	.1311	.0343	.0347	.1943	.1134	.0354	.0373
Avg	.1955	.2211	.2175	.2196	.2017	.2062	.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0486	1.326			.0533	
2	.9602	1.1797	1.3426			.0533	
3	.9488	1.2597	1.3426			.0549	
4	1.012	1.2452	1.3916			.0556	
5	1.0753	1.3108	1.4586			.0556	
6	1.1385	1.5249	1.643			.0564	
7	1.3763	1.5912	1.7604	.0533		.0533	
8	1.5729	1.5074	1.8107	.8192		1.3923	
9	1.5729	1.4419	1.6741	1.0395		1.5089	
10	.048	.0671	.0949	1.1191		1.6095	
11	.0518	.1326	.1052	1.8778		1.6263	
12	.0533	.1619	.116	2.0119		1.6095	
13		.064	.104	1.6446		1.6766	
14	.1265	.064	.1402	2.0348		1.5746	
15	.1296	.156	.1387	2.0348	1.3108	1.5592	
16	.1311	.1543	.1326	.0648	.0617	.0572	
17	.1311	.1509		.0648	.0655	.0594	
18	.1296	.1355			.0617		
19	.1372	.0995	.0556				
20	.1372	.1372					.0564
21	.1387	.1372			.0541		.4755
22	.1402	.1174			.0526		.4161
23	.1357	.1372			.0541		.4161
24	.9602	1.0486	1.326			.0541	
Max	1.5729	1.5912	1.8107	2.0348	1.3108	1.6766	.4755
Min	.048	.064	.0556	.0533	.0526	.0533	.0564
Avg	.5681	.6197	.8868	1.1604	.2372	.7283	.3410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 202 / 11KV PRABHAT STEEL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0229	.012	.0061	.0061	.0137	
2	.0274	.0229	.0103	.0046	.0061	.0107	
3	.0183	.0244	.0086	.0061	.0122	.0137	
4	.0152	.0244	.0086	.0061	.0152	.0198	
5	.0122	.0259	.0069	.0046	.0183	.0244	
6	.0168	.0244	.0069	.0061	.0213	.0396	
7	.0137	.0259	.0305	.0061	.0213	.1494	
8	.0046	.0244	.0274	.2195	.0076	.1886	
9	.003	.0213	.2033	.04	.0152	.1715	
10	.0076	.0091	.547	.0507	.0122	.1048	
11	.0076	.0251	.2218	.8962	.0122	.2743	
12	.0076	.0229	.2957	.0869		.3584	
13	.0061	.0168	.2614	.4481	.0762	.4904	
14	.0061	.0413	.2241	.4527	.0686	.2054	
15	.0061	.0423	.2241	.0137	.0594	.3018	.0091
16	.0061	.4854	.6626	.0732	.096	.6036	.0076
17	.0076	.2075		.0869	.3018	.3018	.0061
18	.0048	.415	.2957		.3018		.003
19	.0244	.8299	.2957		.3018		.0107
20	.029	.7545	.0061	.0061	.1097		.0076
21	.0305	.3395	.0061	.0061	.1886		.0076
22	.0305	.0152	.0061	.0061	.0122		.0107
23	.0244	.0351	.0061	.0061	.0107		.0076
24	.0259	.0244	.0137	.0061	.0061	.0122	
Max	.0305	.8299	.6626	.8962	.3018	.6036	.0107
Min	.003	.0091	.0061	.0046	.0061	.0107	.003
Avg	.0153	.1450	.1470	.1108	.0731	.1825	.0078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 203 / 11 KV YETGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.1867	1.7804	.064	2.1026	.0747
2	.2263	.2641	.1867	1.8143	.064		.0747
3	.2263	.2641	.168	1.8652	.064	2.1704	
4	.2263	.3018	.1698	1.9033	.0648	2.1704	
5	.2263	.3018	.2075	2.0405	.0648	2.2043	
6	.2263	.3395	.2614	2.4006	.0648	2.34	.1307
7	.3048	.3395	.3206	.1905		.2286	.1494
8	.381	.3429	.2829	.1698		.2286	1.1736
9	.2987	.3048	.2641	.1886		.2263	.9503
10	.2286	.2263	.2829	.2263		.2263	1.2071
11	3.4294	3.4591	3.219	.2263		.2075	
12	3.2247			.2263		.2075	
13	3.2236	3.3404	2.9508	.2286	1.8313	.2075	
14	3.2236	3.3573	3.3573	.2263	.2286	.1698	1.166
15		3.1369	3.2556	.2286	.2286	.2263	1.1797
16	2.8826	3.2895	3.0182	.2263	.2263		.0747
17	2.8826	3.2726		.3018	.2263		.0747
18	2.7808	2.8826	1.6907		.1886		.0762
19	.2481	.2452	.2263		.1886		.0762
20	.2401	.2452	.1494		.1886		.1524
21	.2641	.2075	.1494		1.6956		
22	.2641	.2263	.1294		1.7635		.0754
23		.2075	.1294	.0648	1.8652	.0914	.0754
24	.2263	.2263	.2054	1.7126	.0655	2.0348	.0934
Max	3.4294	3.4591	3.3573	2.4006	1.8652	2.34	1.2071
Min	.2263	.2075	.1294	.0648	.064	.0914	.0747
Avg	1.1573	1.1742	.9460	.8432	.5046	.9401	.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.3077	1.5261	.2218	.2829	.2987	
2	1.1401	1.6278	1.5261	.2218	.2801	.2987	
3	1.1401	1.8652	1.5261	.2218	.2801	.2987	
4	1.2071	1.9448	1.6108	.2587	.2829	.3395	
5	1.3413	2.1795	1.7635	.2957	.3048	.3395	
6	1.6575	2.6113	2.0348	.4251	.3048	.3772	.9665
7	2.0348	2.713	2.9334	.4435	.3772	.3772	.2641
8	2.146	2.5774	2.713	1.4582	1.6956	2.0008	.2241
9	2.079	2.5095	2.4587	1.8442	2.2043	2.5434	.2012
10	.3734	.3772	.2957	1.9595	2.4006	2.5774	.168
11	.4527	.3018	.1663	2.0348		2.4926	
12	.5281	.3206	.1663		2.3739	2.5265	
13	.4715	.3395	.3326	1.8107	2.1026	2.5095	
14	.4191	.3772	.2772	2.1704	1.8991	2.5265	.1478
15		.4527	.2957	2.3739	1.8313	2.5434	.1448
16	.5281	.4904		.3018	.2641	.2829	.2195
17	.4904	.4527		.3772	.3018	.2957	.1494
18	.4572	.3429	.2957		.3018		.2218
19	.4904	.6036	.4435	.2987	.3734		.2241
20	.5281	.5731	.2957	.3582	.3734		.2263
21	.4954	.4344	.2957	.362	.3361		.6783
22	.4572	.3961	.2957	.2896	.3018		.6104
23	.415	.3584	.2957	.3018	.3018		.6104
24	1.2071	1.2407	1.4922	.2772	.2829	.2987	
Max	2.146	2.713	2.9334	2.3739	2.4006	2.5774	.9665
Min	.3734	.3018	.1663	.2218	.2641	.2829	.1448
Avg	.9246	1.0999	1.0473	.8321	.8460	1.2737	.3371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 206 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3429	.4066	.2987	.3326	.3544	.168
2	.3696	.3429	.3734	.2987	.3361	.3224	.1494
3	.3361	.3052	.3734	.2987	.3361	.3121	.1494
4	.3696	.3052	.3921	.3174	.3734	.3224	.1036
5	.4481	.3429	.4481	.3921	.4108	.3658	.2054
6	.5601	.4207	.5175	.5415	.5228	.4805	.2957
7	.5415	.5083	.5792	.5175	.5175	.4607	.4066
8	.4656	.4961	.5138	.4525	.3801	.4382	.3403
9	.4382	.4458		.3856	.2534	.3641	.3189
10	.3601	.4801	.4115		.3658	.3294	
11	.3856	.4024	.4475	.2835	.3292	.3944	
12	.3898	.3601	.3988	.3544	.2743	.3121	
13	.3681	.3647	.4557	.3222	.2401	.2896	
14	.3681	.4161	.394	.3366	.3018	.3206	.3224
15	.4119	.4239	.4435	.4607	.3321	.3403	.362
16	.4344			.4252	.3361	.3601	.3814
17	.4973			.4075	.3481	.333	.3812
18	.3768		.6348		.3521		.3772
19	.4458	.567	.5914	.4163	.5487		.4298
20	.5014	.6516	.5258	.4805	.5731		.4572
21	.4908	.5792	.4733	.4066	.5014	.4252	.4066
22	.4908	.5544	.462	.3734	.4525		.3696
23	.4252	.462	.3881	.3547	.4298	.1867	.3206
24	.4108	.3772	.4435	.3547	.3326	.3814	.1867
Max	.5601	.6516	.6348	.5415	.5731	.4805	.4572
Min	.3361	.3052	.3734	.2835	.2401	.1867	.1036
Avg	.4273	.4357	.4607	.3854	.3825	.3547	.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 201 / 11 KV LENGARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0623	.9842	.9998	.0312	.0351	.061	
2	1.1822	1.0311	1.0936	.0332	.0354	.061	
3	1.2717	1.0753	1.0936	.0339	.0358	.048	
4	1.1822	1.0802	1.2186	.0351	.0362	.048	
5	1.3927	1.1728	1.3599	.0537	.0532	.0781	
6	1.6057	1.1888	1.5935	.0709	.0526	.0937	
7	1.6575	1.5154	1.656	.0753		.081	
8	1.8785	1.6872	1.6766	.7926	.4999	.7225	
9	1.8442	1.7976	1.7985	.7716	.7811	.8535	
10	.1372	.0766	.0572	.7819	.9374	.9031	
11	.0743	.0937	.0663	.9659	.7529	1.0852	
12	.0762	.0914	.0332	1.0822	.8398	1.0517	.0486
13	.0857	.0762	.0335	1.1431	.9122	1.0185	.0486
14	.0714	.0762	.0983	1.2041		.9755	.0324
15	.0695	.0762	.0823	1.2191		1.142	.0324
16	.0667	.0781		.0903	.0812	.1128	.0446
17	.0657	.0781		.0903	.0781	.1113	.0446
18	.104	.0781	.0914		.0772		.0434
19	.0857	.0781			.0937		.0579
20	.0838	.08	.0869	.1029	.0972		.0579
21	.0857	.08	.0705	.0343	.0686		.2
22	.0714	.0762	.0667	.0343	.0686		.2143
23	.0734	.0762	.0564	.0343	.0695		.2143
24	.9842	.9031	.9804	.0309	.0351	.0705	
Max	1.8785	1.7976	1.7985	1.2191	.9374	1.142	.2143
Min	.0657	.0762	.0332	.0309	.0351	.048	.0324
Avg	.6338	.5646	.6768	.3960	.2686	.4732	.0866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 202 / 11 KV VEJEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.128	.1143	.9282	.663	.8951	
2	.1029	.128	.0953	.8987	.6706	.8951	
3	.1227	.1307	.0943	.8842	.6706	.9496	
4	.1254	.132	.132	.8842	.6706	1.0029	
5	.128	.1494	.168	.8916	.6706	1.0387	
6	.128	.1494	.2054	.9156	.6706	.9717	
7	.1448	.1526	.2054	.0924	.12	.1478	
8	.1463	.181	.2054	.0914	.0747	.1526	
9	.1463	.1753	.1867	.0914	.0943	.112	.6036
10	.1463	.1865	.1867	.0716	.0943	.1109	.4475
11	1.5769	1.9669	2.7808	.0895	.0838	.1307	.4475
12	2.0576	2.1704	3.0521	.0895	.0829	.1494	.4475
13	2.2043	2.2721	3.0521	.0895	.1341	.0943	.5636
14	2.0919	2.6113	2.7263	.1097	.1067	.0905	.4973
15	2.1776	2.6791	2.8292	.1086	.124	.1886	.4641
16	2.2291	2.6749		.0905	.116	.1543	.1791
17	2.3312	2.6406		.1097	.1134	.1402	.1791
18	2.0062	2.6406			.116		.1578
19	.1677	.2452	.0914	.1463	.1267		.1578
20	.1578	.1886	.112	.1463	.1294		.1433
21	.1578	.1509	.1097	.6796	.8619		.128
22	.1029	.132	.0934	.6464	.8002		.128
23	.12	.132	.0943	.6464	.8259		.1097
24	.1187	.1227	.1143	.9054	.6299	.8583	
Max	2.3312	2.6791	3.0521	.9282	.8619	1.0387	.6036
Min	.1017	.1227	.0914	.0716	.0747	.0905	.1097
Avg	.7830	.9225	.7928	.4177	.3604	.4490	.3103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 203 / 11 KV SALSHINGE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9172	1.0364	.9831	.1526	.1402	.1658	
2		1.0814	1.0486	.1402	.124	.1526	
3	1.0526	1.1568	1.1603	.1417	.1417	.1526	
4	1.1043	1.2071	1.1934	.1448		.1402	
5	1.1961	1.1873	1.3435	.1629		.1991	
6	1.3108	1.2651	1.5074	.1791		.2058	
7	1.4413	1.4842	1.5893	.2035	.2303	.2427	
8	1.4582	1.6057	1.704		.9568	1.0562	
9	1.4255	1.4899	1.7695	.3001	1.0631	1.1984	
10	.213	.1646	.1593	1.2163	1.0631	1.2793	
11	.1406	.1692	.1753	1.6876	1.0155	1.3763	
12	.1677	.1829	.1753	1.5074	***	1.3435	
13	.1943	.2241	.1772	1.5249	1.0311	1.2452	
14	.1562	.2241	.2058	1.5415	1.0623	1.1336	.1696
15	.1619	.1966	.1907	1.5223	1.1336	1.2616	.1865
16	.2058	.2103		.1852	.1467	.1783	.1865
17	.2204	.2126		.1852	.1718	.2439	.1865
18	.213	.2126	.1808		.192		.1844
19	.2683	.2454	.2105	.2401	.1966		.1823
20	.2058	.2454	.208	.2374	.213		.1823
21	.2279	.2454	.2105	.2204	.2103		.3395
22	.1886	.2204	.1981	.1372	.1781		.5247
23	.1943	.2035	.1718	.1402	.1875		.5247
24	.9922	.9488	.9503	.1802	.1402	.1781	
Max	1.4582	1.6057	1.7695	1.6876	109.0011	1.3763	.5247
Min	.1406	.1646	.1593	.1372	.124	.1402	.1696
Avg	.5937	.6425	.7051	.5432	5.6476	.6530	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 204 / 11 KV LENGARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2987	.3361	.2241	.3361	.2534	.3048
2	.3584	.3048	.3142	.2054	.3361	.2353	.2858
3	.3395	.3429	.3142	.2054	.3361	.2427	.2858
4	.3395	.381	.3403	.2614	.3547	.2033	.2858
5	.3395	.3856	.3582	.2587	.3547	.2402	.3206
6	.3395	.4525	.3582	.3326	.333	.3292	.3881
7	.3772	.2915	.3761	.3045	.3544	.2804	.4207
8	.3961	.3121	.3506	.298	.2481	.3012	.3403
9	.3641	.2915	.3506	.2454	.3189	.2481	.3681
10	.3772	.3113	.3429	.3561	.3189	.2915	.3086
11	.3641	.3258	.362	.2713	.2031	.3429	.3086
12	.3429	.3086	.3475	.2743	.2429	.2915	.3155
13	.3467	.3155	.3258	.3086	.2561	.3761	.298
14	.3258	.298	.3439	.3045	.2454	.2865	.2896
15	.3506	.3077	.333	.3045	.2686	.3012	.2896
16	.2915	.2865		.3045	.2481	.2601	.3292
17	.3086	.2835		.3224	.2267	.2427	.3292
18	.3018	.2835	.2713		.2486		.3658
19	.3224	.4066	.3045	.3582	.3239		.439
20	.4163	.4435	.3142	.4119	.3982	.3366	.4755
21	.462	.499	.3361	.3734	.3544	.3326	.4481
22	.3174	.4108	.2801	.3921	.2865	.2957	.3734
23	.3511	.3547	.2614	.4108	.3045	.2957	.2987
24	.3772	.3326	.3361	.2427	.3734	.2686	.2987
Max	.462	.499	.3761	.4119	.3982	.3761	.4755
Min	.2915	.2835	.2614	.2054	.2031	.2033	.2858
Avg	.3528	.3428	.3299	.3031	.3030	.2843	.3403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.2096	.2587	.1949	.1949	.2172	.2096
2	.2715	.2096	.2587	.1829	.2126	.2033	.1905
3	.2715	.1905	.2772	.1829	.2303	.2033	.1905
4	.2743	.1905	.2772	.2012	.2126	.181	.1905
5	.2743	.2218	.2743	.1991	.197	.197	.1905
6	.2743	.2241	.2743	.2328	.1753	.2427	.2054
7	.2743	.2172	.2743	.2801	.1753	.2218	.2218
8	.2715	.2218	.2561	.2241	.2103	.2033	.2033
9	.2658	.1991	.2561	.2241	.1949	.197	.2054
10	.2658	.2058	.2378	.2012	.2303	.2126	.2054
11	.2303	.2454	.2743	.2534	.1677	.1715	.2054
12	.2058	.2454	.3086	.2715	.1696	.1734	.2054
13	.2126	.2629	.3125	.2715	.1991	.2481	.197
14	.2328	.2629	.1989	.2926	.1753	.1928	.197
15	.2507	.2629	.2401	.3174	.2012	.2481	.197
16	.2279	.2686		.2614	.2507	.1907	.197
17	.2507	.2686		.2715	.2126	.2303	.2279
18	.2103	.2686	.2303		.2303		.2629
19	.2865	.298		.2401	.2715		.3155
20	.2829	.3155	.2926	.3258	.3142	.2454	.3506
21	.3018	.3155	.2926	.1886	.2829	.1867	.3224
22	.2614	.3142	.3292	.2229	.2353	.2075	.2865
23	.2772	.2957	.2614	.1928	.2614	.2286	.2507
24	.2686	.2241	.2587	.2195	.1928	.2427	.2096
Max	.3018	.3155	.3292	.3258	.3142	.2481	.3506
Min	.2058	.1905	.1989	.1829	.1677	.1715	.1905
Avg	.2588	.2474	.2688	.2371	.2166	.2111	.2266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2641	.2987	.2054	.2126	.2033	
2	.2829	.2667	.2801	.2054	.2126	.2033	
3	.2829	.2477	.2743	.1867	.2279	.1867	
4	.2829	.2858	.2743	.1867	.2328	.1867	
5	.3018	.2957	.2926	.2054	.2303	.2427	
6	.3018	.3012	.2926	.2587	.2481	.2587	
7	.3206	.3224	.2926	.2915	.2481	.2195	
8	.3961	.3258	.2926	.2915	.3721	.373	
9	.3921	.2818	.3109	.1509	.4525	.2155	.3734
10	.3734	.3437	.3109	.1753	.3982	.2374	.2987
11	.2347	.3841	.4572	.2629	.2254	.2774	.2987
12	.213	.4161	.4207	.3544	.2427	.3506	.2987
13	.2347	.3932	.4066	.3544	.2294	.3467	.3326
14	.4049	.3441	.2987	.3761	.2753	.1907	.3696
15	.4321	.3277	.4805	.3721	.3018	.333	.3696
16	.3768	.3121		.2658	.373	.3681	.3696
17	.4588	.2601		.2658	.2279	.1663	.3292
18	.2241	.2254	.1791	.2658	.1715		.3292
19	.3052	.3109	.2835	.3366	.3045		.3658
20	.333	.3658	.3403	.3544	.3439	.2241	.3658
21	.362	.3841	.3258	.3012	.3326	.2427	.3292
22	.2629	.3403	.3109	.2658	.2149		.2743
23	.2896	.3045	.2614	.2303	.2402		.2378
24	.2829	.2743	.2987	.2402	.2126	.2241	
Max	.4588	.4161	.4805	.3761	.4525	.373	.3734
Min	.213	.2254	.1791	.1509	.1715	.1663	.2378
Avg	.3180	.3157	.3174	.2668	.2721	.2525	.3295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 207 / 11KV KANDESARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0572	.0377		.3953	.3858	
2	.0724	.0381	.0377		.4161	.3429	
3	.0732	.0381	.0377		.4096	.3525	
4	.0732	.0572	.0566			.3715	
5	.0732	.0572	.0537			.4001	
6	.0732	.0762	.0537			.4344	
7	.0732	.0953	.0537			.0934	
8	.0724	.0953	.0754			.0943	
9	.1086	.0953	.0754			.0747	
10	.1086	.0934	.0754		.0486	.0739	
11	.679	.788	.7274		.0754	.0754	
12	.6447	.8417	.6718	.1187	.0747	.0762	
13	.7002	.8596	.6249	.1029	.0754	.0953	
14	.6516	.7922	.6923	.1029	.0934	.0762	
15	.6984	.679	.7562	.104	.0934	.0747	
16	.7188	.6371		.0867	.0747	.0762	
17	.7482	.6036		.0693	.0934	.0953	.0754
18	.7095	.6173			.0943		.0754
19	.0754	.0566			.0934		.0566
20	.0747	.0566		.1029	.0924		.0566
21	.0754	.0566		.4572	.4064		.0566
22	.0739	.0754		.4557	.3525		.0377
23	.0554	.0754		.4607	.3948		.0377
24	.0724	.0566	.0377		.3953	.3715	
Max	.7482	.8596	.7562	.4607	.4161	.4344	.0754
Min	.0554	.0381	.0377	.0693	.0486	.0739	.0377
Avg	.2824	.2875	.2542	.2061	.2044	.1980	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4115	.6001	.5144	.5487	.5487	
2	.4458	.4115	.6001	.4801	.5144	.5487	
3	.4458	.4458	.5658	.4973	.5144	.5144	
4	.4115	.4458	.5487	.463	.4801	.5144	
5	.3944	.4458	.5144	.463	.4973	.4973	
6	.3772	.4458	.5144	.4973	.4973	.4973	
7	.3772	.4115	.4801	.5316	.5144	.5487	
8	.2401	.4115	.5487	.583	.5487	.583	
9	.1543	.6173	.6516	.5487	.6173	.6344	
10	.1543	.6173	.6173	.5658	.6173	.6344	
11	.1886	.583	.6173	.6344	.583	.6001	
12	.1543	.6173	.6344	.6516	.6001	.5658	
13	.1715	.6516	.6516	.6173	.6001	.5868	.1886
14	.1715	.703	.703	.6687	.6001	.5868	.1715
15	.1715	.7202	.7545	.7202	.6001	.6706	.4801
16	.2401	.703	.7545	.6859	.6516	.6706	.4801
17	.2401	.7202	.7716	.6859	.6516	.6371	.4801
18	.1715	.6173	.6687	.703	.5487	.5868	.0762
19	.1715	.6001	.6344		.5487		.0762
20	.3086	.583	.6001	.5316	.5144		.0762
21	.3086	.6001	.6001	.5658	.5316		.0762
22	.3086	.6173	.6173	.5658	.6173		.0762
23	.3086	.6001	.6516	.6001	.6173		.0762
24	.4801	.3086	.6173	.5144	.5316	.6001	
Max	.4801	.7202	.7716	.7202	.6516	.6706	.4801
Min	.1543	.3086	.4801	.463	.4801	.4973	.0762
Avg	.2865	.5537	.6216	.5778	.5644	.5803	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 202 / 11 KV PARE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1086	.2218	.6249	.7811	1.3123	
2	.1086	.0895	.2012	.5937	.7274	1.2803	
3	.1086	.1052	.1886	.5937	.6958	1.1843	
4	.1448	.104	.2033	.6173	.7907	1.1523	
5	.1448	.1063	.2241	.6642	.8642	1.1523	
6	.181	.1052	.1867	.68	.9014	1.1203	
7	.181	.1075	.2614	.181	.2103	.181	
8	.181	.1097	.2614	.2507	.1791	.181	
9	.181	.1029	.2427	.1715	.181	.181	
10	.181	.1075	.2614	.1715	.1433	.1448	
11	1.4089	1.6842	1.9334		.1791	.1402	
12	2.1052	1.9271	2.1628		.1791	.2172	
13	2.0805	1.9334	2.4531	.2587	.1791	.2241	
14	1.9662	1.9433	2.3537	.2587	.1433	.2402	.7373
15	2.0805	1.9498	2.1956	.2561	.1433	.2218	.9945
16	1.8233	1.8785	2.13	.2772	.181	.2402	.1017
17		1.9595		.2561	.2172	.2263	.1029
18	1.4575	1.7368	1.5684	.2561	.181	.1772	.0701
19	.1612	.2218			.181		.1075
20	.1097	.2241		.0812	.181		.0686
21	.1402	.2241		.6481	.9602		.0686
22	.1433	.2614	.1433	.6562	1.2803		.0701
23	.1417	.2402	.1433	.7499	1.3123		.0701
24	.1448	.1086	.2452	.6173	.7811	1.3603	
Max	2.1052	1.9595	2.4531	.7499	1.3123	1.3603	.9945
Min	.1086	.0895	.1433	.0812	.1433	.1402	.0686
Avg	.6661	.7225	.8791	.4221	.4822	.5756	.2391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3272	1.4083	1.5402	.0709	.0693	.0701	
2	1.4419	1.3603	1.5424	.0724	.0709	.0701	
3	1.4746	1.3108	1.5424	.0724	.0709	.0701	
4	1.4575	1.2498	1.4403	.1086	.1063	.0701	
5	1.4899	1.4918	1.4922	.1063	.1052	.0701	
6	1.5708	1.4403	1.6617	.1063	.1075	.0701	
7	1.8351	1.7004	1.7604	.1254	.1075	.0701	
8	1.9559	1.7204	1.9227	1.4586	1.4083	1.2631	
9	1.989	1.6404		1.6766	1.5089	1.3279	
10	.0686	.0686	.1387	1.9113	1.5424	1.7404	
11	.0716	.104	.1433	2.0119	1.5424	.7611	
12	.0732	.1075	.1448	1.8107	1.8442	2.0178	
13	.0686	.128	.1463	1.8275	1.8442	2.1091	.0724
14	.1075	.1227	.1463	1.8442	1.8107	2.0687	.0724
15	.0732	.1254	.1463	1.9113	1.576	2.0687	.0732
16	.1052	.124	.1448	.0772	.1052	.0895	.0716
17	.0686	.0924	.1772	.1029	.1052	.0876	.0724
18	.0716	.1109	.1402	.1052	.1052	.0819	.0732
19	.0701	.1307			.1052		.0716
20	.0732	.124	.0716	.0812	.1052		.0701
21	.0747	.1227	.1075	.0886	.0701		.5468
22	.0709	.1214	.1075	.104	.0701		.6154
23	.0724	.1254	.0895	.1029	.0701		.4801
24	1.2944	1.3108	1.491	.0886	.1029	.0701	
Max	1.989	1.7204	1.9227	2.0119	1.8442	2.1091	.6154
Min	.0686	.0686	.0716	.0709	.0693	.0701	.0701
Avg	.7044	.6767	.7317	.6898	.6064	.7461	.2017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0377				
2	.0762						
3	.0762		.0377				
4	.0762		.0377				
5	.0762		.0377				
6	.0762						
7	.0762		.0377				
10		.0754	.0754	.0754	.0754	.0754	
11		.1132	.1132	.0943	.0754	.0953	
12		.0943	.1132	.1132	.0754	.0953	
13		.0754	.0754		.0754	.1143	
14		.0754	.0754	.0754	.0754	.1334	
15		.0943	.1132	.1132	.0754	.0762	
16		.0754	.1132		.0754	.1143	
17		.0754	.0566		.0754	.1143	.0762
18		.0377				.0953	
19		.0754					
20		.0377					
21		.0377					
22		.0377					
23		.0377					
24	.0762		.0377				
Max	.0762	.1132	.1132	.1132	.0754	.1334	.0762
Min	.0762	.0377	.0377	.0754	.0754	.0754	.0762
Avg	.0762	.0673	.0687	.0943	.0754	.1015	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3772	.4001	.3772		.3961	.3772
2	.4191	.3772	.381	.381		.3961	.3547
3	.4191	.3772	.381	.362		.3961	.3547
4	.4001	.3772	.381	.381		.3961	.3511
5	.3772	.3772	.381	.381		.3961	.3511
6	.3772	.3772	.381	.3734		.3961	.3511
7	.3772	.3772	.381	.381		.3961	.415
8	.2515	.3772	.4191	.4191		.3772	.415
9	.2263	.4338	.4572	.4527		.3961	.4191
10	.2075	.4527	.4572	.4527		.415	.415
11	.1437	.415	.4572	.4572	.3961	.4338	
12	.1437	.381	.4382	.3961	.3921	.4572	
13	.1437	.4001	.4572	.4108	.3961	.4572	
14	.0914	.4191	.4572	.4338	.3961	.4572	.4572
15	.0895	.4191	.4382	.4572	.3961	.4572	.4191
16	.0895	.4191	.4001	.415	.3772	.4572	.4001
17	.0964	.4191	.4527	.415	.3772	.4338	.4191
18	.1006	.381	.4715		.415	.4338	.4191
19	.1216	.3772	.4382		.415	.4338	.4191
20	.3361	.3734	.4191		.3961	.4338	.4382
21	.415	.3734	.3772		.3961	.3772	.4191
22	.3772	.4001	.3734		.3961	.3772	.4191
23	.3772	.4001	.3772		.3961	.3772	.415
24	.4191	.3772	.4001	.3734		.3961	.3772
Max	.4191	.4527	.4715	.4572	.415	.4572	.4572
Min	.0895	.3734	.3734	.362	.3772	.3772	.3511
Avg	.2675	.3941	.4157	.4066	.3958	.4143	.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5243	.583	.0823	.0914	.0747	.1417
2	.5182	.5304	.583	.0857	.0914	.0732	.1417
3	.506	.5304	.583	.0834	.0924	.0732	.1417
4	.506	.6554	.6783	.0947	.0924	.0732	.1595
5	.5921	.8048	.8139	.1158	.1109	.0914	.2126
6	.8097	1.0059	.9496	.1269	.1294	.128	.2658
7	.9831	1.1022	1.1022	.1252	.1294	.1307	.1109
8	1.1469	1.0883	1.1233	.4531	.3315	.2984	.1109
9	1.0814	1.1469	1.1065	.691	.2683	.3521	
10	.1307	.1052	.1086	.7682	.2743	.3647	.0724
11	.1867	.1402	.0697	.9831	.3222	.3856	
12	.1417	.156	.0732	.8745	.2984	.3391	
13	.168	.156	.0812	1.065	.298	.4115	
14	.1595	.1753	.0914	1.1271	.298	.4572	
15	.1595	.1949	.0914	1.065	.2774	.4115	
16	.1595	.1949	.1	.0732		.0762	
17	.1772	.1949	.1014	.1646	.112	.0762	.0724
18	.2172	.1829	.0947		.112	.0762	.0676
19	.1791	.1848	.1128	.128	.1254	.0762	.0686
20	.1791	.1463	.12	.128	.1254	.0762	.0734
21	.1791	.1402	.1257	.1294	.1097	.0762	.1524
22	.1791	.1402	.1147	.1109	.1097	.0762	.1677
23	.1612	.1402	.1334	.1097	.0914	.1402	.1677
24	.4915	.4641	.5658	.1113	.0914	.0934	.1595
Max	1.1469	1.1469	1.1233	1.1271	.3315	.4572	.2658
Min	.1307	.1052	.0697	.0732	.0914	.0732	.0676
Avg	.3958	.4210	.3961	.3781	.1731	.1846	.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4801		.5121	.1663	.4458	.4854
2	.499	.4801	.5175	.5373	.1646	.4458	.4481
3	.4887	.4801	.5175	.5487	.1629	.4458	.4481
4	.4784	.4801	.5121	.6468	.1629	.4801	.4481
5	.5792	.567	.6219	.6516	.2033	.5144	.5228
6	.6135	.7442	.6878	.6805	.2587	.5487	.6535
7	.6733	.7442	.724	.7282	.2172	.583	.7095
8	.5895	.6687	.7011	.6001	.1753	.5316	.6653
9	.5935	.6687	.703	.6464	.1341	.5365	.5847
10	.5365	.6036	.7042	.5898		.5256	.5609
11	.57	.5868	.6661	.5256	.2317	.5087	
12	.583	.5868	.6001	.4807	.2103	.5258	
13	.5197	.5658	.631	.5201	.5548	.5138	
14	.6001	.5731	.5967	.6173	.5548	.4961	.4588
15	.6001	.6379	.5937	.6874	.5959	.4835	.3795
16	.6001	.6661	.6802	.5426	.6135	.4801	.3201
17	.5316	.6935	.6241	.5144	.631	.4862	.5434
18	.6173	.7362	.5316		.631	.4862	
19	.7087	.7888	.6173		.6836	.4862	.6584
20	.7087	.788	.6401	.2012	.7343	.4862	.7164
21	.7796	.7392	.6036	.2402	.6485	.4755	.6661
22	.7362	.6653	.5914	.2033	.583	.462	.5853
23	.5365	.6036	.5658	.1663	.5316	.4854	.4755
24	.5121	.5144	.5914	.5228	.1663		.4854
Max	.7796	.7888	.724	.7282	.7343	.583	.7164
Min	.4784	.4801	.5121	.1663	.1341	.4458	.3201
Avg	.5903	.6276	.6184	.5165	.3920	.4971	.5408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4382	.4298	.415	.4382	.3761	.1715
2	.2286	.4382	.4251	.4191	.4382	.3841	.1715
3	.2286	.4191	.4066	.4191	.4191	.3582	.1715
4	.2286	.4191	.4066	.4001	.4191	.3582	.1905
5	.2286	.415	.4525	.4024	.4294	.3506	.1905
6	.2667	.4481	.5014	.3982	.4435	.3772	.2096
7	.3048	.5415	.4835	.4715	.4755	.4715	.2286
8	.2477	.5121	.5373	.4715	.394	.4001	.2477
9	.1524	.4119	.5068	.439		.4001	.2096
10	.4024		.439	.4656	.4706	.462	.4706
11	.4706	.2772	.394	.4163	.4481	.4435	.4298
12	.4477	.2772	.4207	.4607	.4715	.4251	.4344
13	.543	.5068	.4207	.4477	.4904	.4251	.3898
14	.5121	.5068	.394	.3439	.4763	.3921	.394
15	.4706	.4706		.4119	.4763	.3921	.3982
16	.5194	.4572	.3658	.3109	.4572	.4108	.4024
17	.4887	.4572	.5304	.3439	.4382	.4108	.3582
18	.4755	.4706	.5121		.4191		.4163
19	.5373	.5068			.4763		.4572
20	.7023	.6485	.6478	.567	.6478		.591
21	.6468	.5792	.6287	.5914	.6036	.2286	.5359
22	.5601	.5249	.5525	.5228	.4557	.2096	.5041
23	.5281	.5068	.4763	.4527	.4207	.1905	.4572
24		.4572	.439	.4108	.4572	.3681	.1905
Max	.7023	.6485	.6478	.5914	.6478	.4715	.591
Min	.1524	.2772	.3658	.3109	.394	.1905	.1715
Avg	.4095	.4648	.4714	.4355	.4637	.3731	.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.4687	.4111	.5693	
2	.0572	.0572	.0572	.4744	.4062	.5218	
3	.0381	.0572	.0381	.4744	.3906	.4801	
4	.0381	.0572	.0381	.4744	.3953	.4801	
5	.0572	.0572	.0381	.5312	.4531	.463	
6	.0572	.0572	.0381	.5487	.5624	.6097	
7	.0762	.0762	.0572	.8488	.0762	.0572	
8	.0953	.0762	.0381	.9755	.0762		
9	.0762	.0762	.0572	1.0059	.0762	.0572	
10	.1334		.0572	.0572	.0762	.0572	
11	1.2346	1.2334	1.1584	.0762	.0953	.0572	.4012
12	1.4373	1.2967	1.1584	.0762	.0953	.0572	.3506
13	1.4548	1.2967	1.2346	.0762	.0953	.0953	.4531
14	1.3592	1.2651	1.25	.0762	.0953	.0762	.3395
15	1.3757	1.2811	1.2654	.0762	.0953	.0762	.3593
16	1.3435	1.2018	1.2346	.1143	.0953	.1143	.0762
17	1.1248	1.1702	1.1873	.1143	.0953	.1143	.0762
18	.8642	1.0688	.9998		.0762	.1143	.0572
19	.0762	.0762			.0953		.0572
20	.0762	.0762	.0572	.0572	.0953		.0572
21	.0762	.1143	.0572	.4218	.5312		.0572
22	.0762	.0762	.0572	.4012	.5624		.0572
23	.0572	.0572	.0572	.4218	.5624		.0572
24	.0572	.0572	.0572	.4687	.4167	.5693	
Max	1.4548	1.2967	1.2654	1.0059	.5624	.6097	.4531
Min	.0381	.0572	.0381	.0572	.0762	.0572	.0572
Avg	.4708	.4714	.4457	.3745	.2471	.2539	.1846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1524		.4001	.3953	
2	.1524	.1334	.1524		.3704	.3953	
3	.1524	.1334	.1334		.3795	.3841	
4	.1524	.1334	.1334		.3749	.3841	
5	.1715	.1334	.1334		.427	.3906	
6	.1905	.1524	.1524		.5247	.5556	
7	.2096	.1715	.1905		.2477	.1905	
8	.2096	.1905	.1715		.2096		
9	.1524	.1715	.1715	.7407	.1905		
10	.1715	.1524	.1715	.7655	.1334	.1905	
11	.7116	.8002	.884	.2096	.1334	.1905	
12	.759	.8482	.9602	.1905	.1334	.1905	
13	.7655	.9442	.9877		.1334	.1715	
14	.7499	.9602	.8642			.1524	
15	.7907	.8162	.9061	.1905	.1334	.1524	
16	.8592	.8482	.8951	.1905	.1334	.1524	
17	.8697	.9488	.6874	.2286	.1334	.1524	
18	.8436	.8962			.1715	.1905	.381
19	.2096	.2096			.1905		.3239
20	.2667	.2477		.2477	.2096		.2858
21	.2477	.2286		.4902	.4999		.2477
22	.2096	.2477		.4531	.4999		.2286
23	.1715	.1905		.427	.4428		.1524
24	.1715	.1715	.1715		.4062	.3953	
Max	.8697	.9602	.9877	.7655	.5247	.5556	.381
Min	.1524	.1334	.1334	.1905	.1334	.1524	.1524
Avg	.3900	.4118	.4399	.3758	.2817	.2726	.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.6371	.7888	.6135	.5201	.4748	
2	.583	.6371	.7716	.5959	.5028	.4527	
3	.5596	.6133	.7716	.6024	.5028	.4409	
4	.5533	.6133	.7802	.5721	.4854	.4508	
5	.5935	.6133	.7716	.5721	.4854	.4458	
6	.6371	.6203	.7969	.6588	.4854	.4409	
7	.6962	.8551	.8619	.6796	.4694	.4973	
8	.8356	.9054	.9116	.8215	.503	.5243	
9	.8356	.9945	.9145	.7956	.5304	.5407	.3506
10	.8259	.8785	1.0343	.8383	.6104	.5304	.4096
11		.8886	.8886	.9614	.6036	.7042	
12	.9175	1.0277		.9339	.6952		.4239
13		1.0442		.9054	.6001	.6796	.4527
14	.788	1.0174	.9221	.7716	.6344	.6539	.4161
15		.9667	1.0174	.8383	.6516	.663	.3814
16	.8785	.9614	.9831	.8684	.5571	.664	.3582
17	.9282	1.0562	1.0322	.8848	.6133	.7042	.3315
18	.9614	1.073	.9282		.5992		.3149
19	.8785	.9945	.6613		.5407		.3185
20	.8648	.9556	.6706	.5533	.5138		.3353
21	.7969	.8785	.5935	.5658	.5087	.3222	.3601
22	.78	.8453	.6001	.5487	.5596	.3258	.3772
23	.6706	.8048	.6173	.5375	.5487	.333	.2743
24	.6516	.6371	.8059	.6068	.5201	.5144	.3155
Max	.9614	1.073	1.0343	.9614	.6952	.7042	.4527
Min	.5533	.6133	.5935	.5375	.4694	.3222	.2743
Avg	.7546	.8550	.8238	.7148	.5517	.5181	.3613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 203 / 11 K V NEWARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0754	.0572		.0663	.108	
2	.0762	.0754	.0572		.0671	.0903	
3	.0572	.0754	.0572		.0671	.0914	
4	.0572	.0566	.0572		.0671	.0926	
5	.0762	.0566	.0572			.0914	
6	.0762		.0572			.0937	
7	.0953	.0943	.0572			.0377	
8	.0762	.0754	.0572			.0377	
9	.0566	.0754	.0572			.0189	
10	.0754	.0754	.0572			.0189	
11		.2429	.2372	.0762		.0189	
12	.2056	.2652	.2134	.0762		.0189	
13		.3315					.064
14	.2315	.3041	.2743		.0762	.0566	.0686
15		.2915	.2915		.0754	.0762	.0474
16	.1898		.3292		.0754	.0762	.0754
17	.1875		.253		.0943	.0762	.0566
18	.1898	.1875	.2103		.0754		.0566
19	.0754	.0754	.0953		.0762		.0754
20	.0943	.0754	.0953	.0943	.0943		1.9791
21	.0943	.0762	.1143	.0781	.096		.0943
22	.0943	.0762	.0953	.0663	.1265		.0754
23		.0572	.0762	.0663	.1094		.0754
24	.0754	.0754	.0572		.0663	.0762	
Max	.2315	.3315	.3292	.0943	.1265	.108	1.9791
Min	.0566	.0566	.0572	.0663	.0663	.0189	.0474
Avg	.1080	.1294	.1267	.0762	.0822	.0635	.2426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2743	.2772	.2957		.3292	
2	.2715	.2587	.2957			.3258	
3	.2896	.2587	.3142	.3109		.3366	
4	.3077	.2587	.3475	.3475		.3582	
5	.3142	.2926	.3696	.3658		.3801	
6	.3292	.3258	.4066	.3982		.4207	
7	.3475	.3582	.394	.4344		.3982	
8	.3224	.3366	.3761	.3403		.3258	
9	.333	.3898	.4161	.3641		.3506	
10	.3294	.3258	.373	.3506		.3856	
11	.2835	.3121	.3294	.3294		.2601	
12	.3155	.3467	.3467	.3155		.2915	
13	.3155	.333		.3189		.3258	
14	.3189	.3045	.333	.3155		.298	
15	.3189	.2865	.3429	.3189		.2865	.1267
16	.3155	.2804	.3353	.3189	.4031		.1612
17	.3155	.2804	.3429	.3366	.4557	.2947	.2058
18	.3189	.2804	.3294		.4908	.2947	
19	.3982	.3721					
20	.4755	.439					.4163
21	.4435	.4024					.3982
22	.3696	.3881	.3881		.3881		.3142
23	.3142	.3174	.3142		.3326		.2772
24	.2957	.2772	.2772	.2957		.3142	
Max	.4755	.439	.4161	.4344	.4908	.4207	.4163
Min	.2715	.2587	.2772	.2957	.3326	.2601	.1267
Avg	.3307	.3208	.3455	.3386	.4141	.3320	.2714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1612	.2012	.1417		.4999	
2	.1612	.1433	.1991	.1402		.6009	
3	.1772	.1448	.1991	.1578		.6241	
4	.1753	.1448	.1991	.1578		.6554	
5	.156	.1629	.2149	.1595		.664	
6	.1696	.1791	.2328	.1772			
7	.1715	.197	.2507	.1753		.1341	
8	.1928	.1949	.2427	.1578		.1663	
9	.1696	.1753	.2427	.1907		.1886	
10	.1658	.1865	.2058	.2126		.1791	
11	1.3443	1.3441	1.6164	.2126		.1791	
12	1.6004	1.6484		.2328		.1753	
13	1.6164	1.5813	1.6288	.1629		.1907	
14	1.6004	1.5844	1.4864	.1629		.1907	
15	1.587	1.5023	1.5154	.1646		.1928	.4365
16	1.5546	1.5339	1.5278	.1463	.1638		.1406
17	1.5043	1.4232	1.3889	.1463	.7407	.1907	.1128
18	1.5927	1.3125	1.2346		.1543	.1886	.1402
19	.1802	.2204					.443
20	.1989	.2561					.1402
21	.2172	.2587					.1417
22	.2012	.2614	.1646		.4904		.124
23	.1791	.2218	.1463		.5335		.1063
24	.1612	.1612	.2012	.1417		.5093	
Max	1.6164	1.6484	1.6288	.2328	.7407	.664	.443
Min	.156	.1433	.1463	.1402	.1543	.1341	.1063
Avg	.6349	.6250	.6549	.1689	.4165	.3253	.1984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1069	1.3927	1.3441	.4515		.1772	
2	1.1405	1.3763	1.4232	.4572		.1646	
3	1.186	1.3763	1.4548	.4877		.1829	
4	1.2018	1.3763	1.5203	.4816		.1991	
5	1.2186	1.3927	1.5364	.5418		.2195	
6	1.2346	1.4899	1.5684	.587		.2033	
7	1.3123	1.6484	1.692	.6321		.2195	
8	1.406	1.6484	1.8343	.6097		1.1574	
9	1.406	1.7284	1.8185	.6401		1.5023	
10	.1372	.197		.6481		1.5971	
11	.1578	.1326		.6562		1.5043	
12	.1928	.1578	.0905	.6405		1.5813	
13	.2126	.1734	.2543	.6405		1.6872	
14	.2279	.2481	.2896	.6249		1.7236	
15	.2481	.2454	.3224	.6249		1.7236	.218
16	.2481	.2481	.3366	.2303	.2686		.2229
17	.2303	.2835	.3544	.2686	.2481	.1457	.1524
18	.2279	.3224			.2126	.176	.1791
19	.2303	.3012					.2328
20	.2279	.2865					.1791
21	.2149	.2686					.6636
22	.181	.2279	.1075		.2534		.571
23	.1629	.1907	.1063		.1991		.6173
24	1.0185	1.1012	1.2651	.4515		.181	
Max	1.406	1.7284	1.8343	.6562	.2686	1.7236	.6636
Min	.1372	.1326	.0905	.2303	.1991	.1457	.1524
Avg	.6305	.7422	.9622	.5375	.2364	.7970	.3374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 248001 / 220/33 VITA EHV KARVE S/STN

Feeder No / Name : 208 / EHV CONSUMER TEMBHU SHEDDABLE EHV(AGRICULTURE)

Feeder KV- 220 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	13.565
Max	13.565
Min	13.565
Avg	13.565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 248001 / 220/33 VITA EHV KARVE S/STN

Feeder No / Name : 401 / 33KV VITA INCOMING

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	7.0199
Max	7.0199
Min	7.0199
Avg	7.0199