

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.503	.4287	.4191	.4287	.4191	.5144
2		.4191	.4287	.4191	.4287	.503	.5144
3		.4191	.5144	.4191	.5144	.503	.6001
4		.8383	.6859	.6859	.6859	.8383	.8573
5		.9221	.8573	.9221	.8573	.9221	.9431
6		1.0059	1.0288	1.0059	1.0288	1.0059	1.1145
9	.8383		.9431	.9221		.9221	.9431
10	.6097	.6859	.381	.6859	.7621	.6859	.4572
11	.381	.5335	.3048	.3048	.3048	.381	.381
12		.381	.3048	.3048	.3048	.3048	
13	.3048	.3048		.3048		.381	.3048
14			.3048				.3048
15		.3048	.3048	.3048	.3048		.3048
16	.381	.3048	.3048	.381	.3048	.3048	.3048
17	.3048	.3048	.3048	.381	.381	.381	.381
18	.7545	.8573	.7621	.8573	.7545	.8573	.7545
19	.9221	.9431	.8383	.8573	.9221	1.0288	.8907
20	.8383	.8916	.9221	.8573	.9221	.9431	.9221
21	.8383	.8573	.9221	.8573	.9221	.9431	.8907
22	.8097	.3048	.8383	.8573	.8383	.8573	.9221
23	.503	.3048	.5335	.6859	.6706	.8573	.7587
24	.4572	.503	.4287	.503	.5144	.4191	.6859
Max	.9221	1.0059	1.0288	1.0059	1.0288	1.0288	1.1145
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.6110	.5795	.5877	.6160	.6237	.6729	.6548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 202 / 11KV AKLUJ URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6706	.8573	.6706	.8573	.6706	.8573
2		.6706	.7716	.6706	.7716	.6859	.6859
3		.6706	.7716	.6706	.7716	.7545	.6859
4		.8383	.8573	.8383	.8573	.8383	.7716
5		.9221	.9431	.9221	.9431	.9221	.9431
6		1.0059	.9774	1.0059	1.0288	.9717	1.1145
7		1.0059					
9			1.2003	1.2574	1.1145	1.2574	1.2003
10	.9145	.9907	.9145	1.0669	.9907	.9145	.9145
11	.7621	.9145	.9145	.9145	.9145	.8383	
12		.9145	.8383	.8383	.7621	.8383	.9145
13	.8383	.8383		.3048		.8383	.8383
14			.8383				.8383
15		.7621	.7621	.7621	.7621		.7621
16	.7621	.8383	.7621	.7621	.7621	.7621	.9145
17	.8383	.7621	.9145	.8383	.8383	.381	.9145
18	.8383	1.0288	.9145	1.0288	1.0059	1.0288	1.0059
19	1.1736	1.2003	1.2574	1.2003	1.2574	1.2003	1.2146
20	1.0898	1.2003	1.1736	1.2003	1.1736	1.2003	1.2574
21	1.0898	1.1145	1.1843	1.2003	1.1736	1.2003	1.1736
22	1.0059	.9774	1.0898	1.1145	1.0059	1.1145	1.0526
23	.9221	.8573	.9221	.9431	.9221	.9431	.8907
24	.7621	.7545	.8573	.8383	.8916	.6706	.8573
Max	1.1736	1.2003	1.2574	1.2574	1.2574	1.2574	1.2574
Min	.7621	.6706	.7621	.3048	.7621	.381	.6859
Avg	.9164	.9018	.9391	.9071	.9402	.9015	.9432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 203 / 11KV DIVISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.4287	.4191	.4287	.4191	.4287
2		.4191	.4287	.4191	.4287	.4191	.4287
3		.4191	.4287	.4191	.4287	.4191	.5144
4		.4191	.4287	.4191	.5144	.4191	.6859
5		.4191	.4287	.4191	.6001	.4191	.6001
6		.503	.4287	.503	.6859	.4858	.6859
9			.8573	.8383	.8573	.8383	.8573
10	.6097	.6859	.6097	.7621	.6859	.6859	.7621
11	.5335	.4572	.6097	.6097	.5335	.6097	.7621
12			.7621	.4572	.7621	.6097	.6859
13	.6859	.7621		.3048		.6859	.3963
14			.6859				.6859
15		.5335	.7621	.3048	.7621		.6859
16	.6097	.5335	.381	.381	.7621	.6097	.4572
17	.6859	.4572	.7621	.381	.7621	.4572	.4572
18	.8383	.8916	.7621	.8573	.8383	.5144	.8478
19	.9145	1.1145	.9145	.8573	1.0059	.8573	1.0898
20	.9221	.9431	.9221	.8573	.9221	.8573	.9717
21	.7545	.8573	.8383	.8573	.9431	.8573	.8097
22	.5868	.5144	.6706	.8573	.5868	.6859	
23	.4191	.4287	.4191	.5144	.503	.4287	.4049
24	.381	.4191	.4287	.4191	.4287	.4191	.4287
Max	.9221	1.1145	.9221	.8573	1.0059	.8573	1.0898
Min	.381	.4191	.381	.3048	.4287	.4191	.3963
Avg	.6618	.5893	.6170	.5646	.6720	.5849	.6498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 204 / 11KV BAGEWADI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 205 / 11KV ANANDNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 206 / 11 KV MIDC

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 207 / DR INAMDAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0335	.0377	.0386	.0309	.0386	.036
2		.0319	.036	.0386	.0291	.0302	.0343
3		.0285	.0343	.0335	.0291	.0302	.0326
4		.0251	.0326	.0302	.0274	.0335	.0309
5		.0244	.0343	.0335	.0309	.0369	.0274
6		.0302	.0343	.0335	.036	.0324	.024
7			.036	.0335		.0386	
8			.0309	.0302	.0514	.0369	.0429
9			.0377	.0302	.0703	.0319	.036
10	.0412	.0381	.0381	.0259	.0564	.0564	.0594
11	.0457	.0472	.0564	.029	.0457	.0564	.0564
12		.0594	.0594	.0594	.0564	.0564	.0594
13	.0488	.0564		.0533		.0594	.0442
14			.0457				.0747
15		.0579	.0564	.0533	.0625		.061
16	.0457	.0533	.0457	.0533	.061	.0594	.0579
17	.0503	.0381	.0564	.0457	.0579	.0564	.0564
18	.0553	.0549	.0457	.0514	.0838	.0617	.0664
19	.0436	.0514	.0469	.048	.0687	.06	
20	.052	.0634	.0405	.036	.0469	.0549	.0664
21	.0402	.0446	.0402	.036	.0386	.0583	.0488
22	.0469	.0446	.0469	.0394	.0437	.0394	.0405
23	.0469	.0446	.0402	.0429	.0453	.036	.034
24	.0366	.0335	.0394	.0419	.0309	.0419	.036
Max	.0553	.0634	.0594	.0594	.0838	.0617	.0747
Min	.0366	.0244	.0309	.0259	.0274	.0302	.024
Avg	.0461	.0431	.0422	.0399	.0478	.0457	.0466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 201 / 11 KV WAGHOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.3932	.253	.2818	.4268	.2591	2.7349
2	.3481	.3932	.253	.2818	.4268	.2591	2.6092
3	.3481	.3932	.253	.2984	.4268	.2561	2.5617
4	.3647	.3932	.3163	.2984	.4572	.2846	2.6882
5	.3978	.3658	.3163	.3315	.4572	.3163	2.6882
6	2.372	2.2862	2.8902	.3647			2.6882
7	2.6882	2.7435	3.2026				3.0045
10				3.1626	2.6092	2.4996	
11					2.8464	2.7808	
12					3.1626	2.734	
13						2.734	
14						2.8121	
16						2.734	
17				2.4387			
18	.3932	.3163	.3315	.3658	.1619	.1989	
19	.3932	.3163	.4144	.4268	.2915	.1326	.3048
20	.3932	.253	.4144	.4268	.3239	.1326	.2812
21	.3932	.2214	.3647	.4268	.1619	.1326	.2187
22	.3932	.253	.3315	.4268	.2915	2.8464	2.734
23	.3932	.253	.3315	.4268	.2591	2.7673	2.8121
24	2.2862	.3932	.253	.2984	.4268	.2591	2.6882
Max	2.6882	2.7435	3.2026	3.1626	3.1626	2.8464	3.0045
Min	.3481	.2214	.253	.2818	.1619	.1326	.2187
Avg	.8235	.6410	.7090	.6837	.8486	1.3411	2.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 202 / 11KV SANGAM-Lawang-
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 203 / 11 KV LAWANG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5243	.3887	.4973	2.8121	3.3198	.5304
2	.4973	.5243	.3887	.4973	2.8121	3.2388	.5304
3	.5304	.5243	.3887	.4641	2.8121	3.2388	
4	.5304	.5243	.4161	.4641	2.8121	3.2007	.5636
5	.5636	.5243	.4161	.4641	2.8121	3.2007	.5967
6	.5801			2.372	2.6558	3.0407	
7				2.451	2.8902	3.0407	
10	2.8807	2.8464	3.1131				3.1131
11	3.2007	3.1626	3.195				3.2769
12	.128		.2294				
13	.128						
14	.2241		.1966				
15	.2241						
16	.2881						
17		.1492	.2622				
18	.3932			.3932	.2591	.2984	
19	.5571	.4858	.3647	.4534	.3239	.4144	.426
20	.5571	.421	.3647	.5243	.2915	.4973	.4858
21	.5571	.4049	.3647	.4915	.2915	.5304	.5182
22	.5243	.3887	.3647	2.7854	3.0407	.5304	.5182
23	.5243	.3887	.4641	2.9492	3.2007	.5304	.4858
24	2.2862	.5243	.421	.4973	2.9492	3.2388	.5304
Max	3.2007	3.1626	3.195	2.9492	3.2007	3.3198	3.2769
Min	.128	.1492	.1966	.3932	.2591	.2984	.426
Avg	.7836	.8138	.7087	1.0932	2.1402	2.0229	.9646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 204 / GAOTHAN (LAWANG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 205 / J K SANGAM

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 206 / Vajrai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1492	.0648	.1107	.116	.1296	3.4947	.116
2	.1492	.0648	.1107	.1326	.1296	3.4315	.116
3	.1492	.0648	.1107	.1326	.1457	3.4315	.1326
4	.1658	.0648	.1423	.1492	.1619	3.305	.1492
5	.1823	.0648	.1562	.1658	.1619	3.2417	.1823
6	.1823			3.5738		3.0519	
7						3.1152	
10	3.558	1.2334	3.2712				3.255
11		1.4232	3.4008				3.5789
12	3.3208		.1134				
13	3.3208						
14	1.3916		1.2631				
15	1.3757						
16	1.4074						
17	1.4737	3.2575	.1781				
18	.0648	.253	.1326	.1457	.1423	.1326	
19	.081	.1898	.1823	.2105	.1739	.1658	.2267
20	.0972	.1739		.1943	.1898	.1658	.2267
21	.0972	.1739		.1781	.1739	.1658	.1943
22	.0648	.1423	.116	.1296	3.1943	.116	.1619
23	.0655	.1265	.116	.1296	3.4473	.116	.1457
24	.1492	.0648	.1107	.116	.1296	3.5421	.116
Max	3.558	3.2575	3.4008	3.5738	3.4473	3.5421	3.5789
Min	.0648	.0648	.1107	.116	.1296	.116	.116
Avg	.8723	.4908	.6343	.4134	.6817	1.9625	.6616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 207 / 11 KV CANAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.583	.5316	.547	.5487	.5316	2.7526
2	.5304	.5658	.5316	.547	.5487	.5316	2.7526
3	.547	.583	.5487	.547	.5487	.5316	2.7206
4	.5636	.6001	.5487	.5801	.5658	.5596	2.7206
5	.5801	.6173	.5935	.6133	.583	.5935	2.7526
6	2.4985	2.7092	1.9161	.5801			2.5606
7	2.7989	2.9835	2.0008				
10				1.4922	1.8976	3.0007	
11					1.8976	3.4294	
12					1.8976	3.2579	
13					1.7711	3.2579	
14						3.2236	
16						3.3436	
17				1.8004		3.3093	
18	.5658	.5596	.5304	.5316	.5316	.4973	
19	.583	.6173	.5801	.6173	.5535	.547	.583
20	.583	.583	.547	.6173	.6173	.5636	.583
21	.6173	.583	.547	.6001	.5535	.5636	.583
22	.6173	.5487	.5304	.5426	.5658	2.8464	3.1722
23	.5935	.5316	.547	.5487	.5658	2.8147	3.2579
24	.5304	.583	.5316	.547	.5487	.5487	2.8006
Max	2.7989	2.9835	2.0008	1.8004	1.8976	3.4294	3.2579
Min	.5304	.5316	.5304	.5316	.5316	.4973	.583
Avg	.8671	.9034	.7489	.7141	.8872	1.7869	2.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 202 / VIZORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	1.3717	1.7236	1.8004	.1311	.2134	.1509
2	1.4175	1.4575	1.6766	1.8004	.1147	.2134	.1311
3	1.6448	1.5432	1.7185	1.7318	.144	.2591	.1865
4	1.5699	1.7318	1.7341	1.7661	.1739	.2896	.1581
5	1.6461	1.9204	1.7869	1.8347	.1581	.3201	.192
6	1.6918	1.9719	1.8185	1.9033	.2006	.3506	.1696
7	1.7375	2.0405	1.9006	1.7071	.1943	.381	.1802
10					2.0405	2.0405	1.8362
11			.061		1.829	1.7528	1.6796
12			.0762		2.0153	1.5306	1.6217
13					1.7985	1.5638	
14					1.6941	1.4575	
15	.0819	.0686		.0857	1.6137	1.4299	
16	.0983	.1052		.1638	1.6766	1.5278	
17	.1187	.104	.0762	.1402	1.5586	1.5655	
18	.1829	.1865	.1372	.1147	.1219	.081	
19	.2286	.3222	.2439	.0819	.2591	.1174	.2896
20	.2591	.2949	.2439	.1006	.2591	.1311	.2896
21	.2915	.3052	.2591	.1357	.2743	.1475	.3048
22	.2591	1.5089	1.7833	.1638	.2591	.1265	.3048
23	1.2498	1.5394	1.8004	.128	.2286	.1107	.2896
24	1.2803	1.406	1.7004	1.8347	.1638	.1981	.1296
Max	1.7375	2.0405	1.9006	1.9033	2.0405	2.0405	1.8362
Min	.0819	.0686	.061	.0819	.1147	.081	.1296
Avg	.8891	1.0516	1.1024	.9113	.7686	.7185	.4946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 204 / KHUDUS-I

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.0086
Max	.0086
Min	.0086
Avg	.0086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 205 / EXPRESS FEEDER WATER NON SHEDDABLE WATER SUPPLY AND
 SUPPLY Feeder KV- 11 / UTILITY
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.3258	.3052	.2058	.4096	.2915	.2785
2	.3561	.3258	.3584	.2401	.3441	.3258	
3	.3391	.3601	.3052	.2572	.427	.3601	.3277
4	.39	.4287	.3584	.2915	.5243	.3944	.3605
5	.407	.4973	.3772	.3601	.5079	.4287	.4409
6	.4239	.5316	.3772	.4458	.5571	.4801	.3932
7	.4409	.5487	.3772	.4973	.4588	.5144	.3005
8	.5087	.5144	.3391	.4973	.5243	.4973	.3441
9	.5087	.5658	.3052	.5144	.4687	.4458	.2949
10	.5426	.3277	.3772	.5407	.4999	.4973	.2591
11	.5243	.2881	.3086	.442	.2896	.2932	.216
12	.4481	.3441	.2401	.3658	.4268	.3887	.1829
13	.5243	.3841	.2229	.4321	.4115	.1646	.1619
14	.5898	.4588	.2058	.4268	.4012	.1718	.1718
15	.4752	.4024	.2915	.4012	.4012	.176	.1966
16	.5121	.3441	.3772	.5182	.4374	.104	.2241
17	.5601	.3113	.3429	.4784	.3506	.3549	.2315
18	.4877	.3222	.3429	.3932	.3944	.3277	.2915
19	.5144	.3391	.3258	.3401	.2229	.3768	.0857
20	.463	.3441	.2743	.421	.3429	.3361	.1029
21	.4287	.3222	.2229	.4915	.3944	.3113	.1372
22	.4458	.2713	.2401	.3932	.3429	.213	.12
23	.3048	.2713	.2401	.3441	.3258	.253	.12
24	.373	.3429	.3052	.2229	.3725	.3086	.2401
Max	.5898	.5658	.3772	.5407	.5571	.5144	.4409
Min	.3048	.2713	.2058	.2058	.2229	.104	.0857
Avg	.4552	.3822	.3092	.3967	.4098	.3340	.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 201 / JAMBUDBET

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 202 / BABHULGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.2103	.2204	1.262	1.2548	1.2717	1.3395
2	.2713	.2103	.2374	1.3146	1.3565	1.2717	1.3904
3	.2713	.2303	.2713	1.3146	1.3904	1.2887	1.4413
4	.3052	.2629	.3052	1.3146	1.4922	1.2887	1.5261
5	.3052	.2804	.3391	1.4723	1.4922	1.3226	1.5769
6	.3052	.298	.373	1.5775	1.5261	1.3226	1.6108
7				1.4899		1.3565	1.5261
10	1.6617	1.8652	1.5775				
11	1.8652	1.6617	1.595				
12	1.8652	1.7804	1.7177				
13	1.95	1.6108	1.7337	.2035		.1865	
14	1.95	1.56	1.7177	.2103	.1696	.1865	
15	1.8652	1.5261	1.647	.2454	.1357	.1696	
16	1.8023	1.4922	1.5604	.2035	.1357	.1865	
17	1.7204	1.4074	1.5604	.2035	.1696	.1865	
18	.2561		.208	.2204	.2374	.1865	
19	.2743	.2543	.2427	.3222	.2374	.2713	.2454
20	.2743	.2713	.3121	.2374	.2374	.2543	.2804
21	.2561	.2713	.3121	.2543	.2035	.2374	.2629
22	.2279	.3052	1.1393	1.2887	1.1869	1.2039	1.2269
23	.2279	.2713	1.1919	1.2548	1.2378	1.2717	1.3146
24	.2713	.2103	.2543	1.2269	1.1869	1.2717	1.3056
Max	1.95	1.8652	1.7337	1.5775	1.5261	1.3565	1.6108
Min	.2279	.2103	.208	.2035	.1357	.1696	.2454
Avg	.8665	.7990	.8817	.8219	.8029	.7755	1.1575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 203 / SANGAM

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.9831
Max	.9831
Min	.9831
Avg	.9831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 201 / 11KV YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2439		.2286	.2743
2		.2572	.2286		.2286	.2572
3		.2572	.2134		.2286	.2743
4		.2743	.2134		.2286	.2915
5		.3086	.2286		.2439	.3086
6		.3429	.2439		.3048	.3258
7		.3429	.2591			.3429
8			.2743			
9			.2896		.3048	
10				.3086	.3353	.4801
11				.3429		.3772
12				.3429		.4458
13				.3086		.4801
14				.3429		.4801
15				.3429		.463
16				.3601		.463
17						.4115
18	.3429	.3658			.3944	
19	.3601	.381		.3353	.4115	.3201
20	.3772	.3658		.3201	.4115	.3048
21	.3772	.3506		.3048	.3944	.3048
22	.3429	.3048		.2896	.3772	.2743
23	.3086	.2743		.2743	.3429	.2591
24		.2743	.2591		.2439	.3086
Max	.3772	.381	.2896	.3601	.4115	.4801
Min	.3086	.2401	.2134	.2743	.2286	.2572
Avg	.3515	.3100	.2454	.3228	.3119	.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 202 / 11KV GRAMIN

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3048		2.753	2.4006
2		.3601	.3048		2.753	2.4863
3		.3772	.3048		2.7854	2.6578
4		.3944	.3353		2.915	2.8292
5		.4115	.3658		3.0769	2.915
6					3.2388	3.0007
7					3.1579	3.0864
13				.2743		
14				.3086		
15				.3086		
16				.3258		
18	.3429	.3506			.3429	
19	.3772	.381		.381	.3429	.3963
20	.3944	.4115		.3963	.3258	.3963
21	.3944	.4115		.381	.3258	.3963
22	.3772	.3963		2.5149	1.9719	2.2672
23	.3601	.3353		2.5911	2.1434	2.3482
24		.3429	.3048		2.753	2.3148
Max	.3944	.4115	.3658	2.5911	3.2388	3.0864
Min	.3429	.3353	.3048	.2743	.3258	.3963
Avg	.3744	.3763	.3201	.8313	2.0633	2.1150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 203 / 11 KV CHOUDESHWARWADI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861		.1524	.1715
2		1.9719		.1524	.1715
3		2.1434		.1524	.1715
4		2.2291		.1524	.1715
5		2.3148		.1677	.1715
6		2.4863			
7		2.7435			
10			2.6578		2.672
11			2.7435		2.5101
12			2.8292		2.2672
13			2.8292		
14			2.7435		
15			2.6578		
16			2.6578		
18	.1715	.1829		.1715	
19	.1715	.1829	.1829	.1715	.1829
20	.1715	.1981	.1829	.1715	.1829
21	.1715	.1981	.1829	.1715	.1829
22	.1715	1.8623	.1677	.1715	.1829
23	1.6289	2.0243	.1677	.1715	.1677
24		1.7147		.1524	.1715
Max	1.6289	2.7435	2.8292	.1715	2.672
Min	.1715	.1829	.1677	.1524	.1677
Avg	.4144	1.5813	1.6669	.1632	.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 205 / GIRZANI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 206 / 11 kV MAHARSHINAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.7621		.7621	.8573
2		.7716	.7621		.7621	.7716
3		.8573	.7621		.7621	.7716
4		.9431	.7621		.8383	.8573
5		.9431	.9145		.9145	.9431
6		1.0288	.9907		.9145	.9431
7		1.0288	.9907			1.0288
8			1.0669			
9			1.0669		.9907	
10				1.0288	.9907	.9431
11				1.0288		1.0288
12				1.0288		1.1145
13				1.0288		.9431
14				.9431		
15				1.0288		.9431
16				.9431		1.0288
17						.9431
18	1.1145	1.1431			1.0288	
19	1.1145	1.1431		1.0669	1.1145	.9907
20	1.1145	1.0669		1.0669	1.1145	.9907
21		.9907		1.0364	1.0288	.9907
22	1.0288	.9145		.9907	.9431	.9145
23	.9431	.884		.7621	.9431	.8383
24		.8573	.7621		.7621	.8573
Max	1.1145	1.1431	1.0669	1.0669	1.1145	1.1145
Min	.9431	.7716	.7621	.7621	.7621	.7716
Avg	1.0631	.9593	.8840	.9961	.9247	.9350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 207 / Deshmukh Mala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.8097		.1219	.1372
2		1.0288			.1219	.1372
3		1.1145	.8745		.1219	.1543
4		1.1145	.8745		.1372	.1543
5		1.2003	1.0526		.1524	.1715
6		1.286	1.2146			
7		1.3717	1.3765			
10				1.3717	1.3279	1.4251
11				1.4575		1.2793
12				1.4575		1.2631
13				1.5432		
14				1.4575		
15				1.4575		
16				1.4575		
18	.1372	.1677			.12	
19	.1543	.1829		.1829	.1543	.1829
20	.1543	.1829		.1677	.1543	.1677
21	.1543	.1829		.1524	.1543	.1677
22	.1543	.7287		.1372	.1372	.1524
23	.6859	.8097		.1219	.1372	.1372
24		.7716	.8097		.1219	.12
Max	.6859	1.3717	1.3765	1.5432	1.3279	1.4251
Min	.1372	.1677	.8097	.1219	.12	.12
Avg	.2401	.7857	1.0017	.9137	.2279	.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 201 / 11 KV CHAKORE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5394	2.0881	1.9509	1.7985	.4572	.4572	.4725
2	1.5546	.0017	1.9814	1.7833	.4572	.442	.4725
3	1.6004	2.1795	2.0729	1.7833	.4572	.4572	.4877
4	1.6766	2.2405	2.1948	1.9052	.4725	.4877	.5182
5	1.7833	2.271	2.2558	2.1033	.5335	.5182	.5335
6	1.8595	2.3015	2.3167	2.271	.5944	.5182	.6097
7	2.1338	2.3472	2.4082	2.3472	.5335	.5487	.5487
10					2.3167	2.3624	2.4539
11					2.4844	2.4996	2.3624
12					2.5758	2.5758	
13		.2439	.2286	.3048	2.915	2.3929	
14	.3201	.2896	.2591	.3353	2.5606	2.3167	
15	.3353	.2743	.2743	.3353	2.4691	2.271	
16		.2591	.3048	.3658	2.3624	2.21	
17		.3658	.3353	.3658	2.21	2.1338	
18	.4268	.3963	.381	.381	.3658	.3353	.3048
19	.4725	.5182	.503	.5182	.5182	.4725	.4572
20	.4877	.4877	.4572	.4877	.4572	.4572	.4268
21	.442	.4877	.4268	.4572	.442	.4268	.4572
22	1.89	1.829	1.7528	.4725	.4572	.4725	.4877
23	1.9509	1.89	1.7833	.4572	.4572	.4572	.4572
24	1.448	2.0271	1.9204	1.7985	.4572	.4725	.4572
Max	2.1338	2.3472	2.4082	2.3472	2.915	2.5758	2.4539
Min	.3201	.0017	.2286	.3048	.3658	.3353	.3048
Avg	1.2451	1.1841	1.2530	1.0669	1.2070	1.1493	.7192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 202 / 11 KV KONDBAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5182	.5487	.4725	1.7528	1.9052	1.9814
2	.4572	.4877	.5487	.4877	1.7528	1.9052	1.9966
3	.4572	.5487	.5182	.503	1.7985	1.9357	1.9966
4	.4877	.5792	.5487	.4877	1.89	1.9662	2.0881
5	.5182	.5487	.5792	.5335	1.9966	2.1338	2.3167
6	.5487	.6097	.5792	.5487	2.1338	2.5606	2.5911
7	.6097	.6401	.6706	.5182	2.4082	2.652	2.5453
10	2.713	3.0788	3.094	2.4387			
11	2.7587		2.9874	2.5301			
12	2.7892	3.0636	2.9569	2.3472			
13		3.0331	2.9264	2.2558	.1981	.2286	
14	2.8045	.7468		2.0729	.2134	.2286	
15	2.9264	.7773	2.1948	2.1338	.2286	.2591	
16	2.9874	2.9874	2.3167	2.2862	.2743	.2743	
17	3.0331	2.9264	2.332	2.1948	.2896	.2896	
18	.4877	.4268	.3506	.3506	.3658	.3963	.4268
19	.5182	.5487	.4725	.442	.4268	.442	.4572
20	.4725	.4877	.442	.4115	.4115	.4268	.4572
21	.4572	.4572	.4115	.3963	.4115	.4115	.4725
22	.4877	.4877	.4572	1.7223	1.9204	2.0119	2.1338
23	.4572	.5487	.4572	1.7528	1.9357	2.0729	1.9509
24	.4725	.4725	.5182	.4725	1.768	1.9204	2.0576
Max	3.0331	3.0788	3.094	2.5301	2.4082	2.652	2.5911
Min	.4572	.4268	.3506	.3506	.1981	.2286	.4268
Avg	1.2810	1.1417	1.2338	1.2436	1.1672	1.2642	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 203 / 11 KV VATHPHALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 204 / vaibhav agrotech ht
consumer Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0017	.0017	.0017	.0017	.0017	.0017	.0017
2	.0017	.0017	.0017	.0017	.0017	.0017	.0017
3	.0017	.0017	.0017	.0017	.0017	.0017	.0017
4	.0017	.0017	.0017	.0017	.0017	.0017	.0017
5	.0017	.0017	.0017	.0017	.0017	.0017	.0017
6	.0017	.0017	.0017	.0017	.0017	.0017	.0017
7	.0017	.0017	.0017	.0017	.0017	.0017	
8	.0017	.0017	.0017	.0017	.0017	.0017	.0017
9	.0017	.0017	.0017	.0017	.0017	.0017	.0017
10	.0017		.0017	.0017	.0017	.0017	.0017
11	.0017		.0017	.0017	.0017	.0017	.0017
12	.0017	.0015	.0017	.0017	.0017	.0017	.0017
13		.0017	.0017	.0017	.0015	.0017	.0017
14	.0017	.0017	.0017	.0017	.0017	.0017	.0017
15	.0017	.0017	.0017	.0017	.0017	.0017	.0017
16	.0017	.0017	.0017	.0017	.0017	.0017	.0017
17	.0017	.0017	.0017	.0017	.0017	.0017	.0017
18	.0017	.0017	.0017	.0017	.0017	.0017	.0017
19	.0017	.0017	.0017	.0017	.0017	.0017	.0017
20	.0017	.0017	.0017	.0017	.0017	.0017	.0017
21	.0017	.0017	.0017	.0017	.0017	.0017	.0017
22	.0017	.0017	.0017	.0017	.0017	.0017	.0017
23	.0017	.0017	.0017	.0017	.0017	.0017	.0017
24	.0017	.0017	.0017	.0017	.0017	.0017	.0017
Max	.0017	.0017	.0017	.0017	.0017	.0017	.0017
Min	.0017	.0015	.0017	.0017	.0015	.0017	.0017
Avg	.0017	.0017	.0017	.0017	.0017	.0017	.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 201 / 11KV KHANDALI NAGTHANA SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2229	.2915	.2572	.2743	.2572	.4801
2	.2743	.2401	.3086	.2743	.2915	.2743	.4973
3	.2915	.2401	.3086	.2743	.3086	.2743	.5487
4	.2743	.2572	.2915	.3086	.3429	.3086	.6859
5	.3258	.2743	.3429	.3772	.4287	.3429	.7545
6	.4115	.3086	.4115	.4115	.4458	.4115	.7716
10	1.1694	1.1517	1.0802	1.0974	1.0985	.9922	1.3643
11	1.1517	1.1694	1.0802	1.046	1.1163	1.0631	1.1694
12			1.0288	.8402	1.0277	.9745	1.0277
13	.9745	1.0808	.9602	.8916	1.0631	.9214	
14	1.0985	1.0099	.9602	.9431	.6201	.9745	
15	1.0985	1.1163	.9774	.9259	1.0631	1.0099	
16	1.0277	1.1517	1.0117	.9774	1.0277	1.0631	
17	1.046	1.1163	.8402	.9431	.9568	.9745	
18	.2401	.3086	.2229	.3086	.2126		
19	.2058	.3258	.3086	.3429	.2835	.463	.4973
20	.2058	.3086	.3429	.3086	.2743	.4801	.5144
21	.1886	.2915	.3086	.2915	.2743	.5487	.5144
22	.2401	.2572	.2743	.2572	.2572	.5487	.4287
23	.2229	.2401	.2572	.2743	.2572	.5144	.4287
24	.2572	.2229	.2572	.2572	.2743	.2572	.463
Max	1.1694	1.1694	1.0802	1.0974	1.1163	1.0631	1.3643
Min	.1886	.2229	.2229	.2572	.2126	.2572	.4287
Avg	.5498	.5647	.5650	.5528	.5666	.6327	.6764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 202 / 11KV DATTANAGAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7528
Max	1.7528
Min	1.7528
Avg	1.7528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 203 / 11KV BHOSALE WASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2743	.2915	.2743	2.0062	2.0729	2.4348
2	.2401	.2591	.3086	.2743	2.0062	2.0729	2.4863
3	.2572	.2743	.2915	.2896	2.0576	2.0576	2.452
4	.2915	.2896	.3258	.2896	2.0748	2.0729	2.4863
5	.3086	.3048	.3429	.3048	2.1262	2.0729	2.572
6	.3429	.3353	.3772	.3506	2.1434	2.1033	2.6235
7					2.2805	2.3167	2.7092
10	2.4166	2.3845	2.4863	2.3472			
11	2.6566	2.6086	2.3472	2.3167			
12			1.7985	2.2862			
13	2.3205	2.5606	1.8442	2.2862	.16	.16	
14	2.5926	2.4806	1.7985	2.2558	.192	.192	
15	2.4486	2.5126	1.829	2.2558	.192	.176	
16	2.5446			2.5377	.192	.2401	
17	2.5149		2.0424	2.6235	.2241	.2401	
18	.2134	.3086	.2286	.2915	.2561	.2915	
19	.3048	.3429	.2743	.2572	.3201	.2743	.3963
20	.2896	.3086	.2896	.2915	.3048	.3086	.381
21	.2896	.2915	.2896	.3086	.3048	.3258	.3353
22	.2896	.2915	.2896	2.0405	2.0424	2.4006	2.1643
23	.2896	.2572	.2743	2.0576	2.0881	2.4348	2.1795
24	.2915	.2743	.2915	.2743		2.0881	2.452
Max	2.6566	2.6086	2.4863	2.6235	2.2805	2.4348	2.7092
Min	.2134	.2572	.2286	.2572	.16	.16	.3353
Avg	1.058	.9088	.9011	1.2483	1.1651	1.2580	1.9748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 201 / BABULGOAN FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3795	.3121		1.1888	1.2193	1.2193	1.3108
2	.3795	.3269		1.2037	1.2037	1.2346	1.2955
3	.3953	.3201		1.2483	1.2334	1.2193	1.2955
4	.4111	.2972		1.1888	1.2631	1.2654	1.2483
5	.4744	.2972		1.1888	1.2631	1.3735	1.2803
6	.506	.3048		1.2037	1.2929	1.3565	1.2955
7					1.3375	1.3413	1.3108
10	1.4266	1.382					
11	1.4022	1.4415					
12	1.3969	1.4937		.1932			
13		1.3717		.1932	.1337	.1898	
14		1.3672		.208	.1635	.1898	
15	1.4712	1.3969		.1189	.1486	.1423	
16	1.1888	1.4632		.1486	.1783	.1265	
17	1.2346			.1783	.1635	.2372	
18	.2675			.208	.2378	.3163	
19	.4161		.2972	.3715	.2972	.3953	.3637
20	.3418		.3567	.3269	.3121	.3479	.4111
21	.3121		.3418	.3567	.3418	.3637	.3795
22	.3567		1.1591	1.2483	1.278	1.2967	1.358
23	.3161		1.1294	1.278	1.2037	1.2803	1.3435
24	.3637	.2972		1.0402	1.3375	1.2803	1.2955
Max	1.4712	1.4937	1.1591	1.278	1.3375	1.3735	1.358
Min	.2675	.2972	.2972	.1189	.1337	.1265	.3637
Avg	.6863	.8623	.6568	.6890	.7689	.7987	1.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 202 / WAFEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	1.2193			.2526	.2675	.2824
2	.4144	1.387			.2526	.2709	.2675
3	.4191	1.3226			.2675	.2559	.2229
4	.3704	1.2483			.2824	.2972	.208
5	.3906	1.3565			.2378	.286	.2526
6	.3963	1.3226			.2378	.3121	.286
7	.4973	1.3565			.2378		
10					1.6461	1.8814	2.2119
11					1.7985	2.0119	2.2466
12				1.5158	1.7985	1.8595	
13				1.7387	1.6766	2.0525	
14		.1337		1.813	1.776	1.9997	
15	.208	.1524		1.9022	1.7985	2.0809	
16	.1783	.1783		1.7981	1.89	1.7497	
17	.2229			1.5752	1.9907	1.6129	
18	.2258		.2229	.3121	.2378	.2372	
19	.2675		.2824	.2972	.2675	.3005	.3163
20	.2675		.2972		.2824	.2846	.2846
21	.2824		.3418	.3269	.2972	.2846	.3005
22	1.174		.2675	.2972	.2972	.2846	.3163
23	1.2193		.2526	.2824	.2675	.2378	.3005
24	.3932	1.2037		.208	.2972	.2526	.2972
Max	1.2193	1.387	.3418	1.9022	1.9907	2.0809	2.2466
Min	.1783	.1337	.2229	.208	.2378	.2372	.208
Avg	.4303	.9892	.2774	1.0056	.8223	.8962	.5567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 202 / 11KV VELAPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.448
Max	1.448
Min	1.448
Avg	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 203 / SANGAM

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.3765
Max	1.3765
Min	1.3765
Avg	1.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 204 / YASHWANTNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.8595
Max	1.8595
Min	1.8595
Avg	1.8595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 205 / 11KV GANESH NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18
HR	Load (MW)
24	.8192
Max	.8192
Min	.8192
Avg	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 206 / 11 Kv Harinagar (M S

GAOTHAN FEEDER

Karkhana Feeder KV- 11 /

OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.448
Max	1.448
Min	1.448
Avg	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 207 / MAHALUNG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.5148
Max	2.5148
Min	2.5148
Avg	2.5148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 208 / GAOTHAN (MALINAGAR)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9907
Max	.9907
Min	.9907
Avg	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 704 / 132 KV SMS SL Cogen

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 201 / 11KV JAMBHUD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8804	1.97	2.1033	2.1033	2.1491	.2686	.2534
2	1.8804	2.1691	2.1491	2.1491	2.0595	.2686	.2534
3	1.8804	1.97	2.1491	2.1491	2.1491	.3582	.2896
4	1.8804	1.97	2.1491	2.1849	2.1491	.3582	.2896
5	1.9342	2.0595	2.1491	2.1849	2.0595	.3582	.362
6	1.97	2.1491	2.1491	2.2148	2.0595	.3582	.362
7	2.2923	2.3282	2.4177	2.4806	2.2386	.3582	.2715
8	2.3282	.2865		.2534	.2172	.3582	.3258
9	2.3663	.2896	.2686		.2896	.362	.2896
10	.2172	.362	.2149		.2534	2.3282	2.5072
11	.2896	.2172	.2149		.2715	2.4177	2.6863
12	.2896	.2534	.2149		.2534	2.7221	2.7759
13	.2172	.2715	.2507		.2172	2.758	2.6863
14	.362	.2715			.2715	2.7221	2.6505
15	.2896	.2715	.2149		.362	2.758	2.4539
16	.2896	.362	.2149		.362	2.6147	2.4188
17	.3582	.362	.2172	.2241	.3582	2.4539	2.5968
18	.3224	.362	.2896	.2896	.3582	.2534	.2172
19	.3582	.2715	.2896	.362	.3582	.2896	.2534
20	.3582	.2715	.2715	.362	.3582	.3258	.2715
21	.3224	.2172	.2715	.3258	.3582	.2534	.2715
22	1.97	2.1033	2.1491	2.1491	.2686	.2172	.2715
23	1.97	2.1719	2.1033	2.0595	.2686	.2172	.2172
24	.1829	2.0595	2.1719	2.1033	2.1491	.2686	.2172
Max	2.3663	2.3282	2.4177	2.4806	2.2386	2.758	2.7759
Min	.1829	.2172	.2149	.2241	.2172	.2172	.2172
Avg	1.0921	1.0425	1.1193	1.4747	.9100	1.0687	1.0497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 202 / 11KV KONDARPATTA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.587	1.587
2						1.6194	1.6194
3						1.6194	1.6194
4						1.6194	1.6194
5						1.7004	1.6194
6						1.7004	1.7004
7						1.9433	1.8623
10	1.8623	2.0243	1.5384		2.1052		
11	2.0243	2.1538	1.9109		2.1376		
12	1.9433	2.2348	1.9433		2.1862		
13	2.1052	2.1862	1.9757		2.1052		
14	1.9433	2.1052			2.0243		
15	1.9433	2.1052	1.668		1.9433		
16	2.1052	2.1052	1.7814		2.0243		
17	2.0243	1.9433	1.6194	2.0153	1.6194		
22					1.4899	1.5546	1.6194
23					1.5384	1.587	1.587
24	.1829					1.5384	1.587
Max	2.1052	2.2348	1.9757	2.0153	2.1862	1.9433	1.8623
Min	.1829	1.9433	1.5384	2.0153	1.4899	1.5384	1.587
Avg	1.7927	2.1073	1.7767	2.0153	1.9174	1.6469	1.6421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 203 / NEWARE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.5384	1.6194	1.6194	1.5708		
2	1.3927	1.4575	1.6194	1.6518	1.5384		
3	1.3927	1.4575	1.6194	1.6518	1.5384		
4	1.3927	1.5384	1.6194	1.6518	1.4899		
5	1.4255	1.6194	1.6194	1.7004	1.4575		
6	1.6057	1.7004	1.7004	1.7328	1.4575		
7	1.6549	1.7004	1.7814	1.8623	1.7004		
8	1.8842						
9	1.8623						
10						2.0243	1.8623
11						2.1862	1.9433
12						2.1052	1.9433
13						2.1052	1.8623
14						1.9919	1.9433
15						2.0729	1.9109
16						1.9433	1.9757
17						1.9109	
22	1.5384	1.6194	1.6194	1.8023			
23	1.6194	1.6194	1.6194	1.8023			
24	.1829	1.5384	1.6194	1.6194	1.6194		
Max	1.8842	1.7004	1.7814	1.8623	1.7004	2.1862	1.9757
Min	.1829	1.4575	1.6194	1.6194	1.4575	1.9109	1.8623
Avg	1.4453	1.5789	1.6437	1.7094	1.5465	2.0425	1.9202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 204 / 11KV NADURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.6194	1.6518
2						1.6194	1.6518
3						1.6194	1.6194
4						1.6194	1.6194
5						***	1.6518
6						1.7004	1.7004
7						1.7004	1.7004
10	1.5384	1.7814	1.9433		1.8623		
11	1.6194	1.8623	1.9433		1.9109		
12	1.7004	1.9433	2.0243		1.9433		
13	1.7814	2.1052	2.0243		1.9757		
14	1.7814	2.0243			1.9433		
15	1.8623	2.0243	1.7814		1.9433		
16	1.7814	2.1052	1.8623		1.9433		
17	1.8623	1.9433	1.4575	1.9433	1.9109		
22					1.6194	1.6194	1.5565
23					1.6194	1.6518	1.6057
24	.3506					1.6194	1.6518
Max	1.8623	2.1052	2.0243	1.9433	1.9757	25.9107	1.7004
Min	.3506	1.7814	1.4575	1.9433	1.6194	1.6194	1.5565
Avg	1.5864	1.9737	1.8623	1.9433	1.8672	4.0680	1.6409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 205 / NEWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7545	.6535	.6535	.7167	.7167	.6908
2	.8402	.8488	.7468	.6908	.7545	.7545	.7095
3	.9335	.8676	.8402	.7468	.7922	.8488	.7468
4	1.0082	.9808	.9335	.8962	.9054	1.0374	.8402
5	1.0829	1.0374	1.0269	.9979	.9619	1.0374	.9709
6	1.1576	1.094	1.1203	1.0829	1.1317	1.1317	
7	.8402		.8402	.8402	.8488	.8488	
8	.7095	.7167	.6535	.6908	.7167	.6602	.7095
9	.5601	.5658	.4715		.5041	.4715	.6413
10	.5228	.4715	.4715		.4668	.4338	.4715
11	.4854	.3772	.415		.3734	.415	.3772
12	.5228	.3772	.3772		.3734	.3395	.3772
13	.4854	.3772	.3772		.3361	.3395	.3772
14	.4668	.3772			.3258	.2829	.3772
15	.4668	.3772	.3772		.3734	.3395	.3772
16	.4668	.4715	.3772		.3734	.3772	.4715
17	.4904	.4668	.3734	.4854	.4715	.4108	.4715
18	.6036		.5601	.5415	.5658	.4668	.5658
19	.6979	.7468	.8962	.7842	.7922	.8215	.7922
20	.7545	.7468	.8402	.8962	.8488	.8775	.8488
21	.6979	.7468	.7468	.7282	.7167	.8215	.7545
22	.679	.6535	.6535	.6908	.6602	.6535	.6602
23	.6602	.6535	.6535	.6908	.6602	.6535	.6602
24	.1829	.6602	.6535	.6908	.679	.6602	.6535
Max	1.1576	1.094	1.1203	1.0829	1.1317	1.1317	.9709
Min	.1829	.3772	.3734	.4854	.3258	.2829	.3772
Avg	.6693	.6531	.6547	.7567	.6395	.6417	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 201 / 11KV SHRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.3048	.3048	.3048	.3048	.3048	.3048
2	.1524	.3048	.3048	.3048	.3048	.3048	.3048
3	.1524	.3048	.3048	.3048	.3048	.3048	.3048
4	.1524	.3048	.3048	.3048	.3048	.3048	.3048
5	.1524	.3048	.3048	.3048	.3048	.3048	.3048
6	.1524	.3048	.3048	.3048	.3048	.3048	.3048
7	.1524	.3048	.3048	.3048	.3048	.3048	.2286
8	.1524	.3048	.3048	.1524	.1524	.3048	.1524
9	.0762	.1524	.3048	.1524	.1524	.1524	1.7528
10	1.2955	3.0484	1.5241	2.7434	3.3532	2.7434	3.3532
11	1.6004	3.5056	3.0484	3.3532	1.9052	3.0484	3.658
12	1.829	3.8104	3.3532	3.658	3.8104	3.0484	.1524
13	1.829	3.8104	3.3532	3.8104	3.7494	3.2008	.1524
14	1.9052	3.9628	3.3532	3.9628	3.658	3.2008	.1524
15	1.9052	3.9628	2.8959	3.9628	3.5056	3.3532	.1524
16	1.9052	3.9628	3.2008	3.658	3.5056	3.2008	.1524
17	1.9052	3.9628	3.3532	3.3532	3.3532	1.5242	.1524
18	.0762	.3048	.1524	.3048	.3048	.0762	.1524
19	.1524	.3048	.3048	.3048	.3048	.1524	.3048
20	.1524	.3048	.3048	.3048	.3048	.1524	.3048
21	.1524	.3048	.3048	.3048	.3048	.3048	.3048
22	.1524	.1524	.3048	.3048	.3048	.3048	2.4386
23	.1524	.3048	.3048	.3048	.3048	.3048	2.591
24	.1829	.3048	.3048	.3048	.3048	.3048	.3048
Max	1.9052	3.9628	3.3532	3.9628	3.8104	3.3532	3.658
Min	.0762	.1524	.1524	.1524	.1524	.0762	.1524
Avg	.6871	1.4416	1.2003	1.3781	1.3089	1.1463	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 202 / 11 KV NARALACHIWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9145	.9907	.7621	.9145	.9145	.6859
2		.9145	.9755	.7621	.9145	.9145	.7621
3	.9145	.9907	1.0364	.9145	.9907	.884	.7621
4	.9145	.9907	1.0364	.9145	.9907	.884	.9145
5	1.0669	1.0364	1.0669	1.0669	1.0669	.9297	.9145
6	1.1584	1.0364	1.0669	1.0669	.9907	1.0517	1.0669
7	.1219	.1219	.9145	1.1431	.9907	1.1736	1.1431
8	.1219		.1219	.0914	.1219	.1219	.0762
9	.0914	.0762	.1067	.0914	.0762	.0762	.0762
10	.0914	.0762	.0762	.0762	.061	.0762	.061
11	.0914	.061	.0762		.061	.061	.061
12	.0914	.061	.0762	.0762	.0457	.061	.0762
13	.0914	.061	.061		.061	.0762	.0762
14	.0914	.061	.061	.0762	.061	.0762	.0914
15	.0914	.0762	.061	.0762	.0762	.0762	.0914
16	.0914	.0762	.0762	.0762	.0762	.0762	.1067
17	.1219	.1524	.0762	.0914	.0762	.0762	.1219
18	.1219	.1524	.1524	.1524	.1067	.0914	.1219
19	.1524	.1524	.1524	.1524	.1219	.1524	.1219
20	.1524	.1677	.1524	.1524	.1219	.1524	.1219
21	.1524	.1677	.1524	.1524	.1219	.1524	.1219
22	.7621	.8383	.6859	.7621	.7621	.6859	.1219
23	.8383	.9907	.7621	.8383	.884	.7621	.1219
24	.7621	.8993	.9907	.7621	.8383	.8993	.7621
Max	1.1584	1.0364	1.0669	1.1431	1.0669	1.1736	1.1431
Min	.0914	.061	.061	.0762	.0457	.061	.061
Avg	.3883	.4380	.4553	.4662	.4388	.4344	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 203 / 11KV NIMGAON VILLAGE
AG/SDT Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.7621	.6097	.5335	.7621	.5335
2	.6859	.7621	.7621	.6097	.6097	.7621	.6097
3	.6859	.7621	.7621	.6097	.6097	.6859	.6097
4	.6859	.8383	.8383	.7621	.6859	.6859	.6097
5	.7621	.8383	.8383	.7621	.7621	.6859	.6097
6	.8383	.9145	.8383	.7621	.7621	.8383	.7621
7	.8383	.9145	.8383	.8383	.7621	.8383	.7621
8	.9145	.1524	.0762	.0762	.0762	.0762	.0762
9	.0762	.0762	.0762	.0762	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11		.0762	.0762	.0762	.0762	.0762	.0762
12	.0762	.0762	.0762	.0762	.0762		.0762
13	.0762	.0762	.0762	.0762	.0762	.061	.0762
14	.0762	.0762	.0762	.0762	.0762	.061	.0762
15	.0762	.0762	.0762	.0762	.0762	.061	.0762
16	.0762	.0762	.0762	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	.0762
18	.0762	.0762	.1067	.1524	.1524	.0914	.0762
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.6097	.6097	.4572	.4572	.6097	.6097	.1524
23	.6859	.6859	.6097	.4572	.6859	.6859	.1524
24	.6097	.6859	.6859	.7621	.5335	.6859	.6097
Max	.9145	.9145	.8383	.8383	.7621	.8383	.7621
Min	.0762	.0762	.0762	.0762	.0762	.061	.0762
Avg	.3976	.3810	.3633	.3334	.3302	.3665	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 204 / NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0762	.0762	.0914	.0762	.061	.0762
2	.0762	.0762	.0762	.0914	.0914	.061	.0762
3	.0914	.1067	.0762	.0914	.0914	.0914	.0762
4	.1067	.1067	.0914	.1067	.0914	.0914	.0914
5	.1067	.1219	.1219	.1067	.1067	.1067	.1067
6	.1219	.1372	.1524	.1219	.1219	.1219	.0914
7	.1219	.1372	.1067	.1372	.1219	.1219	.1067
8	.0914	.0914	.1067	.0914	.0914	.0914	.0914
9	.0762	.0914	.0762	.0914	.0762	.061	.0914
10	.0762	.0762	.0762	.0762	.061	.061	.061
11	.061	.061	.0762	.061	.061	.061	.061
12	.061	.061	.061	.061	.0457	.061	.061
13	.061	.0457	.0762	.061	.0457	.0762	.061
14	.061	.0457	.061	.0457	.061	.0762	.0457
15	.061	.0457	.0457	.0457	.061	.0762	.0457
16	.061	.0457	.0457	.0457	.0762	.0762	.0457
17	.061	.061	.061	.0762	.0762	.0914	.0762
18	.0762	.0914	.0762	.0914	.0914	.1067	.0914
19	.1067	.0914	.0914	.0914	.1067	.1067	.1067
20	.1067	.1067	.1067	.0762	.1067	.0914	.1219
21	.1067	.1067	.1067	.0914	.0914	.0914	.1219
22	.0914	.1219	.0914	.0914	.0914	.0914	.1067
23	.0914	.1219	.0914	.0762	.0762	.0762	.0762
24	.061	.061	.0914	.0914	.0762	.061	.061
Max	.1219	.1372	.1524	.1372	.1219	.1219	.1219
Min	.061	.0457	.0457	.0457	.0457	.061	.0457
Avg	.0832	.0870	.0851	.0838	.0832	.0838	.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 205 / naganemala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.0914	.1524	.1524	.1219
2	.1524	.1524	.1524	.0914	.1524	.1524	.1219
3	.1524	.1524	.1524	.0914	.1524		.1219
4	.1524	.1524	.1677	.1219	.1524	.1524	.1524
5	.1524	.1524	.1829	.1219	.1524	.1524	.1524
6	.1524	.1677	.2134	.1524	.1524	.1829	.1524
7	.1524	.1677	.1524	.1524	.1524	.1677	.1524
8	.0762	.0914	.0914	.0914	.0762	.1219	.0914
9	.061	.0762	.061	.0762	.0762	.0762	.0762
10	.7621	.7621	.6859	.7621	.8078	.6859	.6097
11	.823	.884	.7621	.7621	.8078	.7621	.8383
12	.8383	.9297	.8383	.6859	.7926	.7621	.061
13	.8383	.8688	.8383	.6859	.7621	.8383	.061
14	.884	.9145	.9145	.6401	.7621	.7621	.0457
15	.9145	.945	.9145	.7621	.7316	.7621	.0457
16	.9145	.945	.9145	.7621	.7164	.9145	.0457
17	.8993	.9297	.9297	.8383	.6859	.9145	.0762
18	.1219	.1219	.0914	.1524	.1219	.0914	.1372
19	.1524	.1524	.1524	1.3108	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1372	.1524	.1372
22	.1524	.1524	.1524	.1524	.1372	.1067	.5792
23	.1524	.1524	.1524	.1524	.1524	.1067	.6097
24	.1524	.1524	.1524	.1219	.1524	.1524	.0914
Max	.9145	.945	.9297	1.3108	.8078	.9145	.8383
Min	.061	.0762	.061	.0762	.0762	.0762	.0457
Avg	.3798	.3950	.3804	.3785	.3455	.3684	.1994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 206 / jay khanderaya
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8383	.9145	.6859	.9145	.6706	.6097
2		.8383	.9145	.6097	.9145	.6706	.6097
3	.8383	.9145	.9297	.6859	.8383	.7316	.6859
4	.9145	.9145	.9602	.7621	.8383	.7316	.7621
5	.9755	.9755	1.0364	.7621	.8535	.7621	.7621
6	1.0364	.9602	1.0364	.9145	.9145	.8078	.9145
7	1.0669	.9602	1.1279	.9145	.9907	.8078	.9145
8	.1067	.1067	.0914	.0914	.0914	.1219	.0762
9	.0762	.061	.061	.0914	.061	.0914	.0762
10	.0762	.061	.061	.0762	.0457	.061	.061
11	.061	.0457	.061	.0762	.0457	.0762	.061
12	.0457	.0457	.061	.0762	.0457	.0762	.061
13	.0457	.0457	.061	.0457	.061	.061	.0457
14		.0457	.061	.0762	.061	.061	.061
15		.0457	.061	.0762	.0762	.0762	.061
16	.0457	.0457	.0762	.0762	.0762	.0762	.061
17	.061	.0457	.061	.0914	.0762	.0762	.061
18	.1067	.1067	.0914	.0914	.1067	.0762	.0762
19	.1219	.1219	.0914	.0914	.1219	.1524	.0914
20	.1219	.1219	.1067	.0914	.1219	.1524	.0914
21	.1219	.1219	.1219	.0914	.1219	.1524	.0914
22	.6859	.7316	.6859	.7621	.6097	.6097	.0914
23	.7621	.8078	.7621	.8383	.7011	.6097	.0914
24	.5792	.7621	.884	.7621	.8383	.6097	.6097
Max	1.0669	.9755	1.1279	.9145	.9907	.8078	.9145
Min	.0457	.0457	.061	.0457	.0457	.061	.0457
Avg	.4064	.4052	.4299	.3683	.3969	.3467	.2928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 207 / MAULI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9145	.9907	.6859	.8383	.8383	.9145
2	.9145	.9907	.9907	.7621	.8383	.9145	.9145
3	.9145	.9907	.9907	.7621	.8383	.9145	.9145
4	.9145	.9145	.9907	.9145	.9145	.9145	1.0669
5	.9907	.9145	1.0669		.9145	.9145	1.2193
6	.9907	1.0669	1.1431	1.0669	1.0669	.9907	1.2193
7	1.0669	1.0669	1.1431	1.2193	1.0669	.9907	.0762
8	.0762	.1524	.0762	.0762	.0762	.0762	.0762
9	.0762	.0762	.0762	.0762	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11	.0762	.0762	.0762	.0762	.0762	.0762	.0762
12	.0762	.0762	.0762	.0762	.0762	.0762	.0762
13	.0762	.0762	.0762	.0762	.0762	.0762	.0762
14	.0762	.0762	.0762	.0762	.0762	.0762	.0762
15	.0762	.0762	.0762	.0762	.0762	.0762	.0762
16	.0762		.0762	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	.0762
18	.0762	.0762	.0762	.1524	.1524	.0762	.0762
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.8383	.7621	.6097	.6097	.7621	.7621	.1524
23	.9145	.9145	.7621	.6097	.8383	.9145	.1524
24	.4428	.9145	.9145	.7621	.6859	.8383	1.0669
Max	1.0669	1.0669	1.1431	1.2193	1.0669	.9907	1.2193
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.4217	.4672	.4541	.3810	.4223	.4287	.3747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 208 / KESHAVNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1219	.1219	.0914	.1067	.1219	.0762
2	.1219	.1219	.1219	.0914	.1067	.1219	.0762
3	.1219	.1219	.1219	.0914	.1067	.1219	.0762
4	.1219	.1219	.1219	.0762	.1067	.1219	.0914
5	.1219	.1219	.1372	.0914	.1067	.1219	.1067
6	.1219	.1372	.1677	.1067	.1067	.1524	.1219
7	.1219	.1372	.1372	.1219	.1067	.1524	.1524
8	.0762	.1067	.0762	.0914	.1067	.1219	.1067
9	.061	.0914	.061	.0914	.0914	.0762	.0914
10	.4725	.4572	.381	.381	.4572	.381	.4572
11	.5335	.5335	.4572	.4572	.503	.4572	.5335
12	.5639	.5792	.5335	.5335	.503	.5335	.0762
13	.5792	.5944	.5335	.5335	.503	.5335	.061
14	.5792	.5792	.4572	.5335	.4572	.4572	.061
15	.5944	.5792	.4572	.5335	.4572	.4572	.061
16	.5335	.5792	.4572	.4572	.3963	.4572	.061
17	.503	.5487	.5182	.5335	.4092	.4572	.0762
18	.0762	.0914	.0914	.0914	.1067	.0914	.1067
19	.1219	.1219	.1524	.0914	.1219	.1067	.1219
20	.1219	.1219	.1524	.1067	.1219	.1067	.1219
21	.1219	.1219	.1524	.1067	.1219	.0914	.1219
22	.1219	.1219	.0914	.1067	.1219	.0914	.442
23	.1219	.1219	.0914	.1067	.1219		.4268
24	.1219	.1219	.1219	.0914	.1067	.1219	.0914
Max	.5944	.5944	.5335	.5335	.503	.5335	.5335
Min	.061	.0914	.061	.0762	.0914	.0762	.061
Avg	.2566	.2648	.2381	.2299	.2273	.2372	.1550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 209 / BALIRAJA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0762	.0914	.0762	.061	.0762
2	.061	.061	.0762	.0914	.0762	.061	.0762
3	.061	.061	.0762	.0762	.0762	.061	.0762
4	.061	.061	.0762	.0762	.0762	.061	.0914
5	.061	.0914	.0914	.0762	.0762	.0762	.1067
6	.0762	.0914	.1067	.0914	.0762	.0914	.1067
7	.0762	.0914	.0762	.0762	.0762	.0914	.1067
8	.061	.061	.0457	.0762	.0457	.061	.0914
9	.061	.0305	.0457	.0762	.0457	.0457	.0914
10	.6859	.823	.7621	.7621	.7621	.7621	.7621
11	.823	.884	.9145	.7621	.8688	.9145	.8383
12	.884	.9297	.9907	.8383	.884	.9907	.061
13	.9145	.9907	.9145	.8383	.8383	.9907	.061
14	.9297	.9755	.9145	.8383	.8383	.9145	.0457
15		.9755	.9145	.8383	.7621	.9145	.0457
16	.8383	.9297	.9145	.8383	.7621	.9145	.0457
17	.7316	.9145	.9297	.8383	.7621	.9145	.0762
18	.061	.0762		.0914	.061	.0762	.061
19	.061	.0762	.0914	.0914	.0762	.1067	.0457
20	.061	.0914	.0914	.0762	.0762	.1067	.061
21	.061	.1067	.1067	.0762	.0762	.0914	.061
22	.061	.1067	.0914	.0762	.0762	.0914	.5792
23	.061	.0914	.0914	.0762	.061	.0914	.6097
24	.061	.061	.0762	.0914	.0762	.061	.0914
Max	.9297	.9907	.9907	.8383	.884	.9907	.8383
Min	.061	.0305	.0457	.0762	.0457	.0457	.0457
Avg	.2962	.3601	.3684	.3277	.3169	.3563	.1778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 201 / BACHERI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516	.583	.5144			
2		.6173		.5144			
3		.6001		.5487			
4		.6516		.583			
5		.6859		.6516			
6		.7202		.703			
7		.703		.6001			
8		.583		.5487			
9		.4458		.4287			
10		2.915		2.8635			
11		3.0864		2.915			
12				2.915			
23	.5487	.6344	.583	.6001	.6859	.5658	2.1948
24	.6344	.6344	.6001	.5487	.583	.6516	.5658
Max	.6344	3.0864	.6001	2.915	.6859	.6516	2.1948
Min	.5487	.4458	.583	.4287	.583	.5658	.5658
Avg	.5916	.9945	.5887	1.0668	.6345	.6087	1.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 202 / PILIV SECTION GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801					
2		.4287					
3		.463					
4		.5487					
5		.583					
6		.6001					
7		.6516					
8		.583					
9		.4287					
10		.4287					
11		.4287					
12		.3944					
13		.3601					
14		.3601					
23	.4287	.583	.5487	.463	.6173	.5144	.6001
24	.4287	.4115	.4973	.463	.463	.6516	.4458
Max	.4287	.6516	.5487	.463	.6173	.6516	.6001
Min	.4287	.3601	.4973	.463	.463	.5144	.4458
Avg	.4287	.4833	.523	.463	.5402	.583	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 203 / CHANDAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715					
2		.1715					
3		.2058					
4		.2229					
5		.2058					
6		.2058					
7		.2401					
8		.2058					
9		.12					
10		1.3889					
11		1.6289					
12		1.749					
23	.1715	.1886	.1886	.1886	.1715	.1886	1.0288
24	.1886	.1715	.1886	.1715	.1886	.1886	.1886
Max	.1886	1.749	.1886	.1886	.1886	.1886	1.0288
Min	.1715	.12	.1886	.1715	.1715	.1886	.1886
Avg	.1801	.4912	.1886	.1801	.1801	.1886	.6087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 204 / KUSMODE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.452					
2		2.3663					
3		2.4863					
4		2.9664					
5		3.0864					
6		3.3436					
7		3.4294					
9		.2572					
10		.3086					
12		.3086					
13		.3086					
14		.3086					
23	2.572	2.8292	2.915	2.7435	2.7435	2.7435	.2572
24	2.0576	2.4006	2.8292	2.4863	2.572	2.7778	2.332
Max	2.572	3.4294	2.915	2.7435	2.7435	2.7778	2.332
Min	2.0576	.2572	2.8292	2.4863	2.572	2.7435	.2572
Avg	2.3148	1.9180	2.8721	2.6149	2.6578	2.7607	1.2946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 205 / SULEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431		1.0288			
2		1.0288		1.0288			
3		1.1145		1.0631			
4		1.166		1.1145			
5		1.2517		1.166			
6		1.3375		1.2003			
7		1.2003		1.3546			
8		.0857		.0857			
9		.0857		.0686			
10		.0857		.0686			
23	.8573	1.0288	1.0117	1.2346	1.0288	.9088	.1372
24	.7716	.7716	1.0288	.9774	1.2517	1.166	.9602
Max	.8573	1.3375	1.0288	1.3546	1.2517	1.166	.9602
Min	.7716	.0857	1.0117	.0686	1.0288	.9088	.1372
Avg	.8145	.8416	1.0203	.8659	1.1403	1.0374	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 207 / Sheri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431		.7716			
2		1.166		.823			
3		1.2517		.8573			
4		1.4232		1.0288			
5		1.3717		1.286			
6		1.4575		1.3717			
7		1.6632		1.5775			
8		.12		.12			
9		.0857		.0857			
10		.1029		.1372			
23	.6516	1.1145	.8573	.823	.7716	.8573	.1029
24	.8573	.6859	1.1145	.7373	.823	.8573	.7545
Max	.8573	1.6632	1.1145	1.5775	.823	.8573	.7545
Min	.6516	.0857	.8573	.0857	.7716	.8573	.1029
Avg	.7545	.9488	.9859	.8016	.7973	.8573	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 208 / PILIV (URBAN) GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086		.3429			
2		.3258		.3429			
3		.3429		.3601			
4		.4115		.3944			
5		.4801		.4287			
6		.5144		.5144			
7		.3258		.4801			
9		.2743		.3772			
10		.3944		.3429			
11				.3429			
12				.3429			
23	.3086	.3772	.4115	.3772	.4115	.3944	.3772
24	.3258	.2401	.3429	.3601	.3601	.4287	.3429
Max	.3258	.5144	.4115	.5144	.4115	.4287	.3772
Min	.3086	.2401	.3429	.3429	.3601	.3944	.3429
Avg	.3172	.3632	.3772	.3851	.3858	.4116	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 201 / 11KV KALAMWADI.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.448	1.5242	1.5242	.1829	.1981	.1524
2	1.0669	1.6766	1.6004	1.6766	.1981	.2134	.1677
3	1.1431	1.7528	1.6766	1.7528	.2134	.2134	.1829
4	1.2193	1.9052	1.9052	1.829	.2439	.2439	.2134
5	1.448	2.0576	1.9814	1.9052	.2439	.2591	.2439
6	1.6004	2.1338	2.0576	1.9814	.2591	.2743	.2743
7	1.9814	2.1338	2.21	2.2862	.2591		
8	2.21	2.2862	2.3624	2.4387			
9		2.2862			2.5149	2.2862	2.4387
10					2.4387	2.1338	
11					2.2862	2.0576	
12					2.1338	1.9814	
13					1.9814	1.9052	
14					1.829	1.829	
15					1.7528	1.7528	
16					1.6766		
19	.2134	.2439	.2286	.2134	.2439	.2286	.2591
20	.1981	.2286	.1981	.1981	.2286	.2134	.2591
21	.1981	.2134	.1829	.1981	.2134	.1981	.2439
22	.1677	.2134	.1677	.1829	.1829	.1829	.2286
23	.1524	.1981	.1524	.1829	.1981	.1677	.2286
24	.4725	.1372	.1829	.1372	.1677	.1981	.1524
Max	2.21	2.2862	2.3624	2.4387	2.5149	2.2862	2.4387
Min	.1524	.1372	.1524	.1372	.1677	.1677	.1524
Avg	.9439	1.2610	1.1736	1.1791	.9261	.8704	.3881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 202 / 11KV TANDULWADI FEEDER. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1677	.2439	.1524	.2134	.2286	.2134
2	.2134	.1677	.2743	.1677	.2439	.2743	.2286
3	.2286	.1829	.2896	.1829	.2743	.3048	.2439
4	.2286	.2134	.3506	.1981	.2896	.3506	.2591
5	.2743	.2591	.381	.2134	.3048	.381	.2743
6	.3201	.2896	.4115	.2286	.3201	.4115	.2896
8				1.5242			
9	2.2862	1.6766	1.6766	1.3717			
10	2.21	1.6766	1.6004	1.2955			
11	2.0576		1.5242	1.2193			
12	1.829	1.6766	1.448	1.1431			
13	1.6766	1.6004	1.2955	1.0669			
14	1.448	1.5242	1.2193	1.0669			
15	1.3717	1.3717	1.1431	1.0669			
16	1.3717	1.2193	1.0669	1.1431			
17					1.6766	1.9814	
18					2.0576	1.9052	
19	.2286	.3506	.2134	.2134	1.829	1.829	1.6004
20	.2439	.3353	.2439	.2439	1.6766	1.7528	1.6766
21	.2286	.3048	.2286	.2591	1.5242	1.6766	1.6004
22	.1981	.2896	.2134	.2286	1.2193	1.6004	1.5242
23	.1677	.2591	.1981	.1981	.9907	1.5242	1.3717
24	.1829	.1524	.2134	.1829	.1829	.7621	1.3717
Max	2.2862	1.6766	1.6766	1.5242	2.0576	1.9814	1.6766
Min	.1677	.1524	.1981	.1524	.1829	.2286	.2134
Avg	.8497	.7220	.7118	.6365	.9145	1.0702	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 203 / SALMUKH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.5944	.7011	.5639	.8383	.6401	.5639
2	.6097	.6706	.7621	.6249	.9297	.7621	.6554
3	.6554	.7773	.8078	.6554	.9602	.884	.8688
4	.7316	.823	.9297	.7164	1.0517	1.0517	1.0212
5	.8688	.8993	1.0059	1.2193	1.1126	1.1888	1.2346
6	.9145	1.0059	1.0669	1.1888	1.1888	1.2193	1.0669
8	.6859	.7164	.7164	.7468	1.0364	.8383	.7773
9	.6554	.5182	.5944	.8078	.7316	.6554	.503
10	.6097	.5487	.5335	.884	.7164	.6249	.4572
11	.4877	.6097	.4572	.4725	.6859	.6401	.4115
12	.503	.5792	.503	.4572		.5944	.381
13	.5335	.381	.5335	.442	.6097	.5639	.3506
14	.5487	.4115	.5944	.4115	.5639	.5944	.3658
15	.5639	.4268	.6249	.3963	.4877	.4725	.3506
16	.4725	.4572	.6401	.442	.381		.3963
17	.7621		.6554	.4572	.4268	.5944	.4115
18	.7773	.8535	.6859	.5182	.6554	.6554	.7773
19	.8078	.8383	.7164	.7621	.7316	.7164	.8688
20	.8535	.8078	.7773	.8383	.6859	.8688	.9297
21	.9145	.7621	.7316	.9145	.6554	.8078	.9907
22	.8383	.7164	.6554	.9602	.6097	.6097	.8993
23	.7468	.6706	.5639	.8535	.5792	.5639	.8383
24	.1829	.5487	.6097	.503	.6859	.5335	.503
Max	.9145	1.0059	1.0669	1.2193	1.1888	1.2193	1.2346
Min	.1829	.381	.4572	.3963	.381	.4725	.3506
Avg	.6647	.6644	.6898	.6885	.7420	.7309	.6792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 204 / Shendechinch

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2134	.1372	.1524	1.1431	1.3717	1.1431
2	.1524	.2286	.1372	.1677	1.0669	1.448	1.2193
3	.1981	.2439	.1524	.1829	.9907	1.6766	1.2955
4	.2134	.2743	.1829	.1981	1.0669	1.7528	1.3717
5	.2439	.3048	.1981	.2134	1.1431	1.7528	1.448
6	.2896	.3353	.2286	.2286	1.2193	1.829	1.5242
7					1.2955	1.9052	1.7528
8					1.448	.4572	1.9052
17	2.5911	2.4387		2.21			
18	2.5911	2.2862	1.6766	2.0576			
19	2.3624	2.1338	1.6004	1.6004	.2591	.2439	.3506
20	2.21	1.829	1.448	1.5242	.2439	.2286	.3048
21	2.0576	1.6004	1.3717	1.448	.2591	.2134	.2743
22	1.7528	1.5242	1.2955	1.3717	.2439	.1981	.2439
23	1.6766	1.448	1.2193	1.2955	.2439	.1829	.2134
24	.1829	1.448	1.3717	1.1431	1.2193	.2286	.1677
Max	2.5911	2.4387	1.6766	2.21	1.448	1.9052	1.9052
Min	.1372	.2134	.1372	.1524	.2439	.1829	.1677
Avg	1.1899	1.1649	.8477	.9853	.8459	.9635	.9439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 205 / FALAWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372	.1524	.1372	1.2193	1.1431	1.2193
2	.1677	.1524	.1524	.1524	1.0669	1.2193	1.3717
3	.1829	.1677	.1829	.1677	1.1431	1.3717	1.448
4	.1981	.1677	.1981	.1829	1.0669	1.448	1.5242
5	.2134	.1829	.2134	.1981	1.0669	1.5242	1.6004
6	.2286	.1981	.2134	.2134	.9907	1.5242	1.6766
7					1.448	.8383	1.829
8					1.6766	2.0576	1.9814
16		2.8197					
17	2.8197	2.3624	2.1338	2.4387			
18	2.5149	2.1338	1.9814	2.3624			
19	2.4387	1.829	1.829	1.7528	.1981	.2134	
20	2.2862	1.6766	1.7528	1.6766	.1829	.1981	.2134
21	2.21	1.5242	1.6766	1.6004	.1677	.1829	.1981
22	1.9052	1.448	1.6004	1.5242	.1524	.1677	.1677
23	1.6004	1.2955	1.5242	1.3717	.1372	.1524	.1524
24	.3201	1.448	1.2955	1.448	1.2955	.1372	.1372
Max	2.8197	2.8197	2.1338	2.4387	1.6766	2.0576	1.9814
Min	.1524	.1372	.1524	.1372	.1372	.1372	.1372
Avg	1.2313	1.1695	1.0647	1.0876	.8437	.8699	1.0400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 207 / maloli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1524	.1677	.1372	.1524	.1219
2	.1524	.1372	.1677	.1829	.1372	.1524	.1372
3	.2134	.1372	.1981	.1981	.1981	.1829	.1677
4	.2134	.1829	.2134	.2134	.2286	.1981	.1981
5	.2286	.1829	.2286	.2286	.2439	.2134	.2286
6	.2439		.2439	.2439	.2591	.2286	.2591
9		2.7435	2.7435	2.8959			
10		2.9721	2.6673	2.7435			
11	3.1245	2.9721	2.5911	2.5149			
12	3.0483	2.8959	2.5149	2.3624			
13	2.9721	2.8959	2.4387	2.21			
14	2.8959	2.7435	2.3624	2.1338			
15	2.8197	2.5911	2.2862	2.1338			
16	2.5149	2.4387	2.21	2.21			
17					3.0483	2.8197	
18					2.7435	2.7435	
19	.1981	.2286	.2134	.1981	2.6673	2.6673	2.6673
20	.2134	.2134	.1981	.2134	2.5911	2.5911	2.5911
21	.1981	.1981	.1829	.1981	2.4387	2.5149	2.4387
22	.1677	.1829	.1677	.1829	2.2862	2.4387	2.3624
23	.1524	.1524	.1524	.1524	2.1338	2.2862	2.2862
24	.3506	.1219	.1372	.1524	.1219	1.9814	2.1338
Max	3.1245	2.9721	2.7435	2.8959	3.0483	2.8197	2.6673
Min	.1372	.1219	.1372	.1524	.1219	.1524	.1219
Avg	1.1025	1.2699	1.1035	1.0768	1.3739	1.5122	1.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 201 / BUNDLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	.362	.2286	.3429	1.7604	2.1052	1.9433
2	1.829	.362	.2286	.3429	1.6766	2.1052	1.9433
3	1.9814	.362	.2286	.3429	1.829	2.0243	1.9433
4	1.9814	.362	.2286	.3429	1.829	2.1052	2.1052
5	2.1338	.3048	.3048	.3429	1.9814	2.2672	2.2672
6	2.21	.543	.3048	.5144	2.21	2.4291	2.4291
7	2.6673				2.2862	2.9959	2.5911
10		2.4387	2.5149	2.4806			
11		2.4387	2.4387	2.4006			
12		2.4387	2.4387	2.2862			
13		2.2862	2.2862	2.1338			
14		2.2862	2.2862	1.9814			
15		2.2862	2.2862	1.9814			
16		2.4387	2.2862	1.9814			
17		2.4387	2.1338	2.0576			
19	.4287	.362	.381	.4287	.4287	.3429	.381
20	.4287	.362	.381	.4287	.3429	.3429	.3048
21	.3429	.362	.3048	.3429	.3429	.3429	.3048
22	.3429	.2715	.3048	1.7604	2.0576	2.0576	1.5242
23	.3429	.2715	.3048	1.6766	2.0576	1.9433	1.9052
24	1.7528	.3048	.2286	.3429	1.6766	2.1052	1.9433
Max	2.6673	2.4387	2.5149	2.4806	2.2862	2.9959	2.5911
Min	.3429	.2715	.2286	.3429	.3429	.3429	.3048
Avg	1.3996	1.1641	1.1050	1.2256	1.5753	1.7821	1.6604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 202 / VELAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6478	.4572	.5335	.6859	.5335	.5144
2	.6001	.8573	.4572	.6097	.6097	.6097	.6001
3	.6859	.8573	.4572	.6859	.7716	.6859	.6859
4	.7716	.8573	.7621	.8383	.8573	.8383	.8573
5	.9431	.9431	.9145	.9907	1.0288	.9145	1.0288
6	1.286	1.286	1.1431	1.1431	1.286	1.0669	1.3717
7	1.3717	1.3717	1.2193	1.2193	1.4575	1.2193	1.286
8	1.2003	1.1145	1.1431	1.0669	1.286	.9907	1.2003
9	1.0288	1.0288	1.1145	.9907	1.0288	.9145	1.0288
10	.9431	.9431	.9431	.8383	.8573		.8573
11	.8573	.8573	.8573	.7621	.8573		.8573
12	.8573	.8573	.8573	.7621	.8573	.7621	.8573
13	.8573	.8573	.8573	.6859	.9431	.6097	.8573
14	.9431	.8573	.6859	.6859	.8573	.6859	.6859
15	.8573	.6859	.6859	.6097	.8573	.7621	.8573
16	.9431	.6859	.6859	.6859	.8573	.7621	.7621
17	.9431	.8573	.8573	.7621	.9431	.7621	.7621
18	1.1145	1.0288	1.0288	1.1765	1.1145	.9145	
19	1.2003	1.2003	1.2003	1.3575	1.2003	1.0669	1.1431
20	1.1145	1.1145	1.1145	1.1765	1.2003	.9907	1.0669
21	.9431	.9145	1.0288	.905	1.0288	.9145	.9145
22	.8573	.7621	.6859	.905	.8573	.7621	.9145
23	.7716	.6097	.6859	.8145	.7716	.6097	.8383
24	.5335	.6859	.4572	.6001	.6859	.5335	.5144
Max	1.3717	1.3717	1.2193	1.3575	1.4575	1.2193	1.3717
Min	.5335	.6097	.4572	.5335	.6097	.5335	.5144
Avg	.926	.9117	.8458	.8669	.9542	.8141	.8896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 203 / 11 KV NEVARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.9433	1.9814		.1715	.1524	.0762
2	.1715	1.8623	2.0576	2.0576	.1715	.1524	.0762
3	.1715	1.9433	2.0576	2.1338	.1715	.1524	.1524
4	.1715	1.9433	2.0576	2.1338	.1715	.1524	.1524
5	.1715	2.1052	2.1338	2.21	.1715	.1524	.2286
6	.1715	2.2672	2.1338	2.4387	.1715		.3048
7		2.4291	2.21	2.4387			
10	2.2862				2.3624	2.3624	2.3482
11	2.5911				2.4387	2.5149	
12	2.5149				2.3624	2.5149	
13	2.5149				2.4387	2.2862	
14	2.2862				2.4387	2.1338	
15	2.2862				2.4387	2.2862	
16	2.3624				2.3624	2.3624	
17	1.5242				2.4387	2.2862	
19	.2572	.1715	.2572	.1524	.2572	.1524	.1524
20	.2572	.1715	.2572	.1524	.2572	.1524	.1524
21	.2572	.1524	.2572	.1524	.2572	.1524	.1524
22	1.829	1.9814	2.4387		.1715	.1524	.1524
23	1.9052	1.9814	2.2862		.1715	.0762	.1524
24	.1524	1.829	1.9814	2.0576	.1715	.1524	.0762
Max	2.5911	2.4291	2.4387	2.4387	2.4387	2.5149	2.3482
Min	.1524	.1524	.2572	.1524	.1715	.0762	.0762
Avg	1.2027	1.5985	1.7007	1.5927	1.0798	1.0709	.3213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 204 / 11KV NIMGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.1715	.1524	.1524	1.3717	1.6004	1.9433
2	1.2193	.1715	.1524	.1524	1.5242	1.5242	1.9433
3	1.3717	.1715	.1524	.1524	1.5242	1.6766	2.1052
4	1.5242	.1715	.1524	.1524	1.6766	1.829	2.1052
5	1.6766	.1715	.2286	.1524	1.7528	1.9814	2.2672
6	1.829	.1715	.2286	.1524	1.829	2.2862	2.4291
7	2.2862				2.4387	2.7435	2.915
10		2.5101	2.3482	2.2862			
11		2.4291	2.4291	2.1338			
12		2.4291	2.4291	1.9814			
13		2.4291	2.2672	1.9052			
14		2.2672	2.2672	1.829			
15		2.2672	2.1052	1.829			
16		2.4291	2.1052	1.829			
17		2.4291	1.9433	1.9814			
19	.2572	.1715	.2572	.181	.2572		.1524
20	.2572	.1715	.2572	.181	.2572	.1524	.1524
21	.2572	.1524	.2572	.1524	.2572	.1524	.1524
22	.2572	.1524	.1715	1.448	1.5242	1.829	1.448
23	.1715	.1524	.1715	1.448	1.5242	1.829	1.5242
24	1.2193	.1715	.1524	.1715	1.2193	1.6004	1.829
Max	2.2862	2.5101	2.4291	2.2862	2.4387	2.7435	2.915
Min	.1715	.1524	.1524	.1524	.2572	.1524	.1524
Avg	1.0420	1.0595	1.0114	1.0136	1.3197	1.6004	1.6128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 205 / TANDULWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.1715	.1524	.1524	.9145	1.0669	1.4575
2	.9907	.1715	.1524	.1524	.9145	1.0669	1.4575
3	.9907	.1715	.1524	.1524	1.0669	1.1431	1.4575
4	1.0669	.1715	.1524	.1524	1.2193	1.3717	1.4575
5	1.0669	.1715	.2286	.1524	1.3717	1.5242	1.6194
6	1.1431	.1715	.2286	.1524	1.5242	2.0576	1.7814
7	1.9814				1.829		2.1052
10		2.3148	2.0243	1.829			
11		2.1052	1.9433	1.6766			
12		2.1052	1.9433	1.5242			
13		1.6194	1.6194				
14		1.6194	1.4575	1.2193			
15		1.6194	1.4575	1.2193			
16		1.7814	1.4575	1.3717			
17		1.7814	1.4575	1.448			
19	.2572	.2572	.2572	.1524	.2572	.2286	.1524
20	.2572	.2572	.3086	.1524	.2572	.2286	.1524
21	.2572	.2286	.1715	.1524	.1715	.2286	.1524
22	.1715	.1524	.1715		1.1431	1.2955	1.0669
23	.1715	.1524	.1715		1.2193	1.2955	1.2955
24	.9907	.1715	.1524	.1715	.9145	1.0669	1.3765
Max	1.9814	2.3148	2.0243	1.829	1.829	2.0576	2.1052
Min	.1715	.1524	.1524	.1524	.1715	.2286	.1524
Avg	.7951	.8597	.7830	.6960	.9848	1.0478	1.1948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 206 / BHAKAREWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.2955	1.5242	1.3717	.1715	.1524	.1715
2	.1715	1.2003	1.5242	1.3717	.1715	.1524	.1715
3	.1715	1.286	1.5242	1.5242	.1715	.1524	.2572
4	.1715	1.3717	1.6766	1.6004	.1715	.1524	.2572
5	.1715	1.5432	1.6766	1.6766	.1715	.1524	.3429
6	.1715	1.9719	1.6766	1.9052	.1715	.1524	.3429
7		1.9433	1.9052	1.829			
10	1.6766				2.0576	2.0576	2.0243
11	2.21				1.9814	1.9814	
12	1.9052				2.0576	1.9814	
13	1.829				1.829	1.7528	
14	1.6766				1.7528	1.6004	
15	1.6766				1.6766	1.6004	
16	1.829				1.6766	1.6766	
17	1.6004				1.6766	1.6766	
19	.2572	.2572	.2572		.2572	.2286	.1524
20	.2572	.2572	.2572		.2572	.2286	.1524
21	.2572	.2286	.1715		.1715	.2286	.1524
22	1.1431	1.3717	1.448		.1715	.2286	.1524
23	1.2193	1.3717	1.3717		.1715	.1524	.1524
24	.1524	1.2955	1.448	1.3717	.1715	.1524	.1715
Max	2.21	1.9719	1.9052	1.9052	2.0576	2.0576	2.0243
Min	.1524	.2286	.1715	1.3717	.1715	.1524	.1524
Avg	.9359	1.1841	1.2662	1.5813	.8469	.8230	.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 207 / UGHDEWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	1.0288	1.2193	1.0669		.0857	.0857
2	.0857	1.1145	1.2193	1.0669	.0857	.0857	.0857
3	.0857	1.1145	1.2193	1.0669	.0857	.0857	.0857
4	.0857	1.2003	1.2193	1.0669	.0857	.0857	.0857
5	.0857	1.2003	1.2193	1.1431	.0857	.0857	.1715
6	.0857	1.286	1.2193	1.1431	.0857	.0857	.1715
7		1.3717	1.1431	1.2193			
10	1.2955				1.2193	1.2146	
11	1.5242				1.2803	1.2955	
12	1.448				1.3603	1.2146	
13	1.448				1.1431	1.1336	
14	1.2955				1.1431	.9717	1.2955
15	1.2193				1.1431	1.1336	
16	1.2193				1.2193	1.2146	
17	1.2193				1.1431	1.0526	
19	.0857	.1715	.0762	.0857	.0857	.1715	.0762
20	.0857	.1715	.0762	.0857	.0857	.1715	.0762
21	.0857	.0857	.0762	.0857	.0857	.0857	.0762
22	.9907	1.2955	1.2193	.0857	.0857	.0857	.0762
23	.9907	1.2955	1.1431	.0857	.0857	.0857	.0762
24	.0857	.9907	1.2193	1.1431	.0857	.0857	.0857
Max	1.5242	1.3717	1.2193	1.2193	1.3603	1.2955	1.2955
Min	.0857	.0857	.0762	.0857	.0857	.0857	.0762
Avg	.6754	.9482	.9438	.7188	.5576	.5215	.1883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 208 / NAGTHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	2.0576	1.9814	1.9052	.1715	.1715	.1715
2	.1715	1.9719	1.9814	1.829	.1715	.1715	.1715
3	.1715	2.0576	1.9814	1.829	.1715	.1715	.2572
4	.1715	2.0576	2.0576	1.9052	.1715	.1715	.2572
5	.1715	2.2291	2.0576	1.9814	.1715	.1715	.3429
6	.1715	2.3148	2.0576	2.1338	.1715	.2572	.3429
7		.7716	2.1338	2.2862			
10	2.3624				2.21	2.3482	2.1052
11	2.4387				2.3624	2.4291	
12	2.3624				2.3624	2.4291	
13	2.3624				2.1338	2.2672	
14	2.21				2.1338	2.1862	
15	2.1338			.1715	2.0576	2.2672	
16	2.1338			.1715	2.21	2.3482	
17	2.1338			.1715	1.6004	2.2672	
18				.1715			
19	.2572	.3429	.2286	.1715	.2572	.3429	.1524
20	.2572	.3429	.2286	.1715	.2572	.3429	.1524
21	.2572	.3429	.2286	.1715	.2572	.2572	.1524
22	1.829	2.0243	1.7528	.1715	.1715	.2572	.1524
23	1.829	2.0243	1.9052	.1715	.1715	.1715	.1524
24	.3506	2.0576	1.9814	1.9052	.1715	.1715	.1715
Max	2.4387	2.3148	2.1338	2.2862	2.3624	2.4291	2.1052
Min	.1715	.3429	.2286	.1715	.1715	.1715	.1524
Avg	1.1973	1.5842	1.5828	1.0187	.9693	1.0600	.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 201 / SHRIPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3429	.2572	.3506	.3658		.2572
2	.3506	.3429	.3429	.3506	.3658		.3429
3	.3506	.3429	.4287	.3506	.3658		.4287
4	.3506	.4287	.4287	.3506	.3658		.4287
5	.5258	.4287	.5144	.5258	.4477		.5144
6	.5258	.5144	.6001	.5258	.5487		.5144
7	.5258	.5144	.6001	.5258	.5487		.6001
8	.4382	.4287	.4801	.5258	.4572		.3429
9	.3506	.4287	.3429	.4382	.3658		.3429
10	.2572	.3506	.3429	.2572	.3506	.362	.362
11	.2572	.3506	.2572	.2572	.2629	.2715	.2715
12	.2572	.2629	.2572	.2572	.2629	.2743	.2715
13	.1715	.2629	.1715	.1715	.2629	.2743	.2715
14	.1715	.2629	.1715	.1715	.2629	.2715	.1829
15	.1715	.2629	.1715	.1715	.2629	.2743	.2743
16	.1715		.2572	.181	.2629	.2743	.2715
17	.1715	.1715	.2629	.2715		.2572	.2629
18	.4287	.1715	.3506	.181		.2572	.4382
19	.5144	.3429	.5258	.543		.5144	.5258
20	.5144	.5144	.5258	.5487		.4287	.6135
21	.4287	.5144	.4382	.4525		.3429	.4382
22	.4287	.3429	.3506	.362		.2572	.3506
23	.3429	.2572	.3506	.362		.2572	.2629
24	.5335	.3429	.2572	.3506	.362		.2572
Max	.5335	.5144	.6001	.5487	.5487	.5144	.6135
Min	.1715	.1715	.1715	.1715	.2629	.2572	.1829
Avg	.3579	.3558	.3619	.3534	.3601	.3084	.3678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 202 / MAHALUNG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1715	.1715	1.9662	2.1348		1.829
2	.1753	.1715	.1715	1.9662	2.1348		1.829
3	.1753	.1715	.1715	1.9662	2.1605		1.829
4	.2629	.1715	.1715	1.9662	2.1605		1.829
5	.2629	.1715	.1715	2.13	2.2405		1.829
6	.2629	.1715	.2572	2.2119	2.2405		1.9052
7				2.4577	2.4006		2.0576
8							.1715
9							.1715
10	1.9814	2.3758	1.9814				.1753
11	2.3624	2.6216	2.3624			.0876	.1753
12	2.5149	2.9492	2.4387			.1753	.181
13		2.4577	2.4387			.1753	
14	2.2862	2.3758				.1753	.1753
15	2.3624	2.3758	2.3624			.1753	.1753
16	2.3624		2.5149			.1753	.1753
17	2.572	2.1338	2.13			.1715	.0876
18						.1715	.1753
19	.1715	.1715	.1753	.1753		.1715	.1753
20	.1715	.1715	.1753	.1753		.1715	.1753
21	.1715	.1715	.1753	.1753		.1715	.1753
22	.1715	.1715	2.0481	2.0805		1.829	.1753
23	.1715	.1715	2.0481	2.0805		1.829	.1753
24	.3582	.1715	.1715	1.9662	2.1605		1.829
Max	2.572	2.9492	2.5149	2.4577	2.4006	1.829	2.0576
Min	.1715	.1715	.1715	.1753	2.1348	.0876	.0876
Avg	.9985	1.0183	1.1651	1.6398	2.2041	.4215	.7599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 203 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.7716	.6859	.0876	.0876		.0857
2	.7373	.7716	.6859	.0876	.0876		.0857
3	.7373	.6859	.6859	.0876	.0876		.0857
4	.7373	.8573	.6859	.0876	.0876		.0857
5	.7373	.8573	.6859	.0876	.0876		.0857
6	.8192	.8573	.7621	.0876	.0876		.0857
7	.9831	1.0288	.9145				.0857
8	1.2289						.0857
9	1.2289						.0857
10				1.2193	1.3108	1.186	1.0402
11				1.2193	1.2289		1.0279
12				1.2193	1.2289	1.2003	1.1203
13				1.2193	1.2289	1.186	1.1203
14				1.2193	1.2289	1.2003	.9602
15				1.1431	1.2289	1.2003	.9602
16				1.2003	1.2289	1.2003	1.1069
17				1.186		1.1431	1.1469
18						.0857	
19	.0857	.0857	.0876	.0876		.0857	.0876
20	.0857	.0857	.0876	.0905		.0857	.0876
21	.0857	.0857	.0876	.0876		.0857	.0876
22	.6859	.6859	.0876	.0876		.0857	.7011
23	.6859	.6859	.0876	.0876		.0857	.8192
24	.9202	.7716	.6859	.0876	.0876		.0857
Max	1.2289	1.0288	.9145	1.2193	1.3108	1.2003	1.1469
Min	.0857	.0857	.0876	.0876	.0876	.0857	.0857
Avg	.6997	.6331	.4792	.534	.6641	.6793	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 204 / CHAUKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.0857	.0857	1.3927	1.6804		1.5242
2	.1753	.0857	.0857	1.3927	1.6804		1.5242
3	.1753	.0857	.1029	1.3927	1.6804		1.5242
4	.1753	.0857	.1372	1.4746	1.6804		1.5242
5	.1753	.1715	.1715	1.6385	1.7394		1.5242
6	.1753	.1715	.1715	1.8023	1.8842		1.5242
7				1.8842	1.8185		1.6766
8							.0857
9							.0857
10	1.9052	1.8842	1.7528				.0876
11	2.0576	2.13	1.9052			.0876	.0876
12	2.0576	2.13	1.9814			.0876	.1578
13	1.9814	2.13	1.9814			.0876	.1227
14	1.9814	1.9662				.1227	.1052
15	1.9814	1.9662	1.9052				.1052
16	1.9814	1.8023	1.9814			.0876	.1227
17	2.1338	1.829	1.8842			.0857	.0876
18						.0857	.0876
19	.0857	.0857	.0876	.0876		.0857	.1753
20	.0857	.0857	.0876	.0876		.0857	.0876
21	.0857	.0857	.0876	.0876		.0857	.1753
22	.0857	.0857	1.7204	1.5813		1.6004	.0876
23	.0857	.0857	1.6385	1.6604		1.6004	.0876
24	.3582	.0857	.0857	1.3927	1.6804		1.6004
Max	2.1338	2.13	1.9814	1.8842	1.8842	1.6004	1.6766
Min	.0857	.0857	.0857	.0876	1.6804	.0857	.0857
Avg	.8959	.8519	.9397	1.2211	1.7305	.3419	.5905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 205 / MALEWADI AG/SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.6004	1.9052	.0876	.0876		.0857
2	1.6385	1.7147	1.9052	.0876	.0876		.0857
3	1.6385	1.7147	1.9052	.0876	.0876		.1029
4	1.6385	1.5242	1.9052	.1753	.0876		.1372
5	1.8023	1.8861	1.9814	.1753	.1052		.1715
6	2.0481	1.829	1.9814	.1753	.1227		.1715
7	2.13	1.9052	2.3624				.1372
8	2.3758						.0857
9	2.2119						.0857
10				2.2862	2.5396	2.2929	2.4006
11				2.5149	2.7854	2.5606	2.2138
12				2.2862	2.7854	2.5606	
13				2.3624	2.5396	3.2617	2.0805
14				2.2862	2.4577	2.3205	2.0719
15				2.2862	2.4577	2.2929	2.0557
16				2.4006	2.6216	2.451	2.0805
17				2.3205		2.0576	2.2119
18						.0857	
19	.0857	.0857	.1753	.1227		.0857	.0876
20	.0857	.0857	.0876	.1052		.0857	.0876
21	.0857	.0857	.0876	.0876		.0857	.0876
22	1.7147	1.9814	.0876	.0876		.0857	1.9662
23	1.6004	1.9052	.0876	.0876		.0857	1.9662
24	1.8214	1.8004	1.9052	.0876	.0876		.0857
Max	2.3758	1.9814	2.3624	2.5149	2.7854	3.2617	2.4006
Min	.0857	.0857	.0876	.0876	.0876	.0857	.0857
Avg	1.5010	1.3937	1.2598	1.0055	1.3466	1.4509	.9300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 206 / Borgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8573	.8573	.8764	.905	.8573	.8573
2	.8764	.8573	1.1145	.964	.924	.8573	1.1145
3	1.0517	.9431	1.286	1.2269	1.0974	.8573	1.286
4	1.4022	1.1145	1.3717	1.4022	1.267	1.2003	1.286
5	1.5775	1.3717	1.4575	1.5775	1.4784	1.3717	1.4575
6	1.5775	1.4575	1.5432	1.5775	1.6461	1.5432	1.6289
7	1.4022	1.3717	1.4575	1.4899	1.4632	1.4575	1.3717
8	1.3146	1.2003	1.2003	1.3146	1.1888	1.286	1.1145
9	1.0517	.9431	1.0288	1.0517	.9145	1.0288	.9431
10	.9431	.8764	.8573	1.0288	.8764	.8145	.823
11	.8573	.8764	.8573	.7716	.7888	.8316	.7392
12	.8573	.8764	.8573	.7716	.7888	.823	
13	.7716	.7888	.6859	.6859	.6135		.6401
14	.6859	.7011	.6001	.6001	.6135	.6401	.6401
15	.7716	.7011	.6859	.6859	.6135	.6335	.6401
16	.7716	.7011	.6859	.7316	.6135	.6401	.7316
17	.7716	.7716	.7888	.7392	.6859	.6859	.7011
18	.8573	.8573	.7011	.9145	.8573	.7716	.964
19	1.0288	1.1145	1.3146	1.2803	1.286	1.2003	1.3146
20	1.2003	1.2003	1.2269	1.2536	1.286	1.2003	1.3146
21	1.0288	1.1145	1.1393	1.1888	1.2003	1.1145	1.1393
22	.9431	.9431	1.0517	1.0059	1.0288	1.0288	1.1393
23	.8573	.9431	.8764	.9145	.9431	.9431	.8764
24	.8764	.8573	.8573	.8764	.9145	.8573	.8573
Max	1.5775	1.4575	1.5432	1.5775	1.6461	1.5432	1.6289
Min	.6859	.7011	.6001	.6001	.6135	.6335	.6401
Avg	1.0147	.9766	1.0209	1.0387	.9998	.9845	1.0252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 207 / Mundafane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9831	1.0279	1.1145	.8383
2				.9831	1.0402	1.1145	.8383
3				.9831	1.0402	1.1145	.8383
4				.9831	1.0279	1.2003	.8383
5				1.065	1.1203	1.2003	.8383
6				1.1469	1.1203	1.2003	.9145
7				1.1469	1.1203	1.2003	.9145
10	.9907	1.1469	.9907				
11	1.1431	1.2289	1.2003				
12	1.0669	1.3108	1.2003				
13	1.0669	1.2289	1.1145				
14	1.1431	1.1469	.9431				
15	1.1431	1.1469	.8573				
16	1.1431	1.1469	1.2003				
17	1.286	1.1431	1.1469				
22			.9831	1.0402	1.0288	.9145	
23			.9831	1.0402	1.1145	.9907	
24				.9831	1.0402	1.1145	.9145
Max	1.286	1.3108	1.2003	1.1469	1.1203	1.2003	.9145
Min	.9907	1.1431	.8573	.9831	1.0279	.9145	.8383
Avg	1.1229	1.1874	1.0620	1.0355	1.0681	1.1164	.8669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 201 / 11 KV TAMKHEDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 202 / 11 KV TONDLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 203 / 11 KV KHALAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 204 / 11 KV SHERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	2.21	2.3167	2.3777	.1372	.1219	.1067
2	1.9662	2.2862	2.3167	2.332	.1372	.1219	.0914
3	2.0119	2.2862	2.3777	2.2862	.1372	.1219	.0914
4	2.0729	2.3624	2.4082	2.2558	.1372	.1524	.1219
5	2.1033	2.3624	2.4387	2.2862	.1524	.1524	.1524
6	2.1338		2.4387	2.3167	.1524	.1219	.1829
7	2.5301	2.5911	2.3167	2.6216	.1829	.2134	.1829
8	.1524	.2286	.1524	.1829	.1981	.2134	.1829
9	.1524	.1524	.1524	.1524	.1524	.1524	.1524
10	.1372	.1524	.1524	.1524	1.829	2.5606	2.4387
11	.1524	.1219	.1219	.1524	2.5911	2.8045	2.652
12	.1524	.1219	.1219	.0914	2.652	2.652	2.5911
13	.0762	.0914	.1219	.1067	2.7435	2.6216	2.4387
14	.1524	.1219	.1219	.1067	2.8349	2.4539	2.3624
15	.1524	.1219	.1219	.1219	2.5301	2.3777	2.3624
16	.1524	.1219	.1219	.1219	2.6825	2.6216	2.2862
17	.2286	.1219	.1524	.1219	2.5911	2.4691	2.2862
18	.2286	.1829	.1219	.1829	.1524	.1372	.1524
19	.2286	.1829	.1524	.1829	.1524	.1524	.1524
20	.1524	.1219	.1524	.1829	.1524	.1524	.1524
21	.1524	.1219	.1524	.1677	.1524	.1524	.1524
22	2.1338	2.2862	2.2558	.1524	.1219	.1219	1.7528
23	2.21	2.2862	2.3167	.1372	.1219	.1219	1.7528
24	1.8595	2.21	2.2862	2.3624	.1372	.1219	.1219
Max	2.5301	2.5911	2.4387	2.6216	2.8349	2.8045	2.652
Min	.0762	.0914	.1219	.0914	.1219	.1219	.0914
Avg	.9672	.9933	1.0580	.8815	.9513	.9539	1.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 201 / HANUMAN MANDIR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
18		.1638
19		.3605
20		.3605
21		.3277
22		.2949
23		.2949
24	.1829	
Max	.1829	.3605
Min	.1829	.1638
Avg	.1829	.3004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 202 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9659		.1372	
2	1.0402		.1337	
3	1.1145		.1486	
4	1.1888		.1486	
5	1.2631		.1337	
6	1.4118		.1189	
7	1.4861		.1337	
8	1.5306		.1486	
9				.1189
10				1.6347
11				1.6347
12				1.709
13				1.8576
14				1.8576
15				1.8576
16				1.9319
17		.104		
19		.1486		
20		.1783		
21		.1783		
22		.1189		
23		.1189		
24	.1829		.1189	
Max	1.5306	.1783	.1486	1.9319
Min	.1829	.104	.1189	.1189
Avg	1.1315	.1412	.1358	1.5753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 203 / MIRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326		1.6941	
2	.1		1.7238	
3	.1		1.7238	
4	.0857		1.7238	
5	.0869		1.7535	
6	.0869		1.7535	
7	.0705		1.7833	
8	.0762		.1486	
9				.104
10				.1486
11				.1337
12				.1189
13				.1932
14				.1932
15				.208
16				.1783
17		1.8724		
19		.1189		
20		.1189		
21		.1486		
22		1.6941		
23		1.6941		
24	.5609		1.6941	
Max	.5609	1.8724	1.7833	.208
Min	.0705	.1189	.1486	.104
Avg	.1444	.9412	1.5554	.1597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 204 / 11KV ANUSEWASTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0949		1.8976	
2	.0949		1.9766	
3	.1107		1.9766	
4	.1107		2.0241	
5	.0949		2.0241	
6	.0949		2.0557	
7	.0791		2.0873	
8	.0791		.1265	
9				.1107
10				.1423
11				.1265
12				.1107
13				.1107
14				.0949
15				.0949
16				.0949
17		2.2455		
19		.125		
20		.1265		
21		.1107		
22		1.866		
23		1.866		
24	.1829		1.866	
Max	.1829	2.2455	2.0873	.1423
Min	.0791	.1107	.1265	.0949
Avg	.1047	1.0566	1.7816	.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 205 / 11KV THITWASTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1	1.0155	
2	1.0936	
3	1.0936	
4	1.1717	
5	1.2498	
6	1.3748	
7	1.4998	
8	1.6404	
10		1.8122
11		1.8591
12		1.8747
13		1.8435
14		1.8122
15		1.781
23	1.0936	
24	.3506	
Max	1.6404	1.8747
Min	.3506	1.781
Avg	1.1583	1.8305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 201 / MALKHAMBI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.2193	1.2193	1.4575	.0857	.0857	.0857
2	1.0669	1.2193	1.2955	1.2955	.0857	.0857	.0857
3	1.2003	1.2955	1.2955	1.3717	.0857	.0857	.0857
4	1.286	1.2955	1.2193	1.3717	.0857	.0857	.0857
5	1.3717	1.2955	1.2955	1.448	.0857	.0857	.0857
6	1.5432	1.2955	1.3717	1.448	.0857	.0857	.0857
7	1.7147	1.5242	1.448	1.6004	.0857	.0857	.0857
8	1.8004	.1715	.0857	.0857	.0857	.0857	.0857
9	1.5242	.1715	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	1.6004	1.448	1.6766
11	.0857	.0857	.0857		1.8442	1.7528	1.7528
12	.0857	.0857	.0857		1.6766	1.829	1.7528
13	.0857	.0857	.0857		1.8442	1.7528	
14	.0857	.0857	.0857	.0857	1.6004	1.829	1.5242
15	.0857	.0857	.0857	.0857	1.8004	1.9052	1.7528
16	.0857	.0857	.0857		1.6766	1.829	1.829
17		.0857	.0857	.0857	1.6766	1.829	1.448
18	.0857	.0857	.0857	.0857	.0857	.0857	.0857
19	.0857	.0857	.0857	.0857	.0857	.0857	.0857
20	.0857	.0857	.0857	.0857	.0857	.0857	.0857
21	.1715	.0857	.0857	.0857	.0857	.0857	.0857
22	1.1431	1.2955	1.2955	.0857	.0857	.0857	.1715
23	1.1431	1.2193	1.3717	.0857	.0857	.0857	.1715
24	1.286	1.2193	1.2193	1.2955	.0857	.0857	.0857
Max	1.8004	1.5242	1.448	1.6004	1.8442	1.9052	1.829
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.7563	.5938	.5930	.6158	.6288	.6478	.5773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 202 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.1715	.0857
2	.0762	.0857	.0857	.0857	.0857	.1715	.0857
3	.0762	.0857	.0857	.0857	.0857	.1715	.0857
4	.0762	.1715	.0857	.1372	.0857	.1715	.1715
5	.1524		.1372	.1715	.1715	.2572	.1715
6	.2286	.1715	.1715	.2572	.2401	.2572	.2572
7	.1524	.1715	.2401	.2572	.2401	.2572	.2572
8	.1524	.0857	.1715	.2572		.1715	.1715
9	.1715	.0857	.0857	.0857	.1372	.0857	.0857
10	.0857	.0857	.0857	.0857	.0857	.0857	.0857
11	.0857	.0857	.0857	.0857	.0857	.0857	.0857
12	.0857	.0857	.0857	.0686	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	
14	.0857	.0857	.0857	.0857	.0857	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857	.0857	.0857	.0857	.0857
18	.0857	.1715	.0857	.0857	.1715	.1715	.1715
19	.1715	.2572	.1715	.1715	.1715	.1715	.1715
20	.1715	.1715	.1715	.2058	.1715	.1715	.1715
21	.1715	.0857	.1715	.1372	.1715	.0857	.1715
22	.0857	.12	.0857	.0857	.1715	.0857	.0857
23	.0857	.0857	.0857	.0857	.1715	.0857	.0857
24	.0762	.0857	.0857	.0857	.0857	.1715	.0857
Max	.2286	.2572	.2401	.2572	.2401	.2572	.2572
Min	.0762	.0857	.0857	.0686	.0857	.0857	.0857
Avg	.1127	.1133	.1122	.1229	.1275	.1393	.1267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 203 / MALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6001	.4287	.5144	1.9814	2.5911	2.3624
2	.4572	.7716	.4287	.4287	2.1338	2.5911	2.4387
3	.4572	.7716	.5144	.5144	2.1338	2.7435	2.4387
4	.4572	.7716	.5144	.6001	2.2862	2.7435	2.5149
5	.5335	.8573	.4801	.6859	2.4387	2.8959	2.5911
6	.6001	.8573	.6001	.7716	2.4387	2.8959	2.5911
7					2.6673	3.1017	2.934
8					.6001	.6001	.6859
9					.5144	.5144	.6001
10	.4287	2.4387	2.5149	2.2862	.4287	.3429	.3429
11	2.7435	2.4387	2.6673	2.4387	.4287	.3429	.4287
12	2.7435	2.4387	2.6673	2.5911	.3429	.3429	.4287
13	2.5911	2.5149	2.5911	2.5911	.3429	.4287	
14	2.5911	2.5911	2.4387	2.4387		.4287	.4287
15	2.8502	2.5149	2.5149	2.5149		.3429	.4287
16	2.5149	2.3624	2.4387	2.5911		.3429	.4287
17	2.5149	2.4387	2.3624	2.4387		.3429	.4287
18	2.5149	.6859	.5144	.5144	.6001	.4287	.6001
19	.6859	.6859	.6001	.6001	.6001	.5144	.6859
20	.6859	.6859	.6859	.6859	.6859	.6001	.6859
21	.6859	.6859	.7716	.6859	.6859	.6859	.6859
22	.6001	.5144	.6001	2.2291	2.3624	2.2862	2.2862
23	.6001	.5144	.6001	1.9814	2.4387	2.2862	2.5149
24	.5335	.6001	.4801	.5144	1.9814	2.4387	2.2862
Max	2.8502	2.5911	2.6673	2.5911	2.6673	3.1017	2.934
Min	.4287	.5144	.4287	.4287	.3429	.3429	.3429
Avg	1.3451	1.3686	1.3054	1.4579	1.4046	1.3680	1.3834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 204 / KAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0857	.0857	.0857	1.2955	1.6766	1.6004
2	.0762	.0857	.0857	.0857	1.3717	1.8442	1.6766
3	.0762	.0857	.0857	.0857	1.5242	1.7528	1.7528
4	.0762	.0857	.0857	.0857	1.5242	1.7528	1.829
5	.0762	.0857	.0857	.0857	1.6766	1.7528	1.9052
6	.0762	.0857	.0857	.0857	1.7528	1.829	1.9052
7	.1524	.0857	.0857	.0857	1.9052	1.829	1.9814
8	.1334	.0857	.0857	.0857	.0857	.0857	.0857
9	.0857	.0857	.0857	.0857	.0857	.0857	.0857
10	.0857	1.829	1.829	1.829	.0857	.0857	.0762
11	2.1338	1.829	1.829	1.9814		.0857	.0762
12	2.1338	1.829	1.9052	1.9814	.0857	.0857	.0667
13	1.9814	1.7528	1.7528	1.9814	.0857	.0857	
14	2.1795	1.829		1.829	.0857	.0857	.0762
15	1.9814	1.7528	1.829	1.829	.0857	.0857	.0762
16	1.9814	1.829	1.9052	1.7528	.0857	.0857	.0762
17	1.829	1.9052	1.7528	1.829	.0857	.0857	.0762
18	1.829	.0857	.0857	.0857	.0857	.0857	.0667
19	.1715	.0857	.0857	.0857	.0857	.0857	.1334
20	.1715	.0857	.0857	.0857	.0857	.0857	.1334
21	.1715	.0857	.0857	.0857	.0857	.0857	.0667
22	.0857	.0857	.0857	1.2955	1.6004	1.448	1.9719
23	.0857	.0857	.0857	1.829	1.6004	1.5242	1.6766
24	.0762	.0857	.0857	.0857	1.2955	1.6766	1.6004
Max	2.1795	1.9052	1.9052	1.9814	1.9052	1.8442	1.9814
Min	.0762	.0857	.0857	.0857	.0857	.0857	.0667
Avg	.7386	.6636	.6163	.8057	.7244	.7619	.8259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 205 / VITTHALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.6766	1.829	1.9814	.6001	.5144	.3429
2	1.8861	1.9052	1.829	1.9814	.6001	.5144	.3429
3	1.6766	1.9052	1.7528	2.0576	.5144	.6001	.4287
4	1.8861	2.0576	1.7528	2.1338	.5144	.6001	.5144
5	1.7528	2.0576	1.9052	2.1338	.6001	.6859	.5144
6	2.0576	2.1338	1.9814	2.1338	.6859	.6859	.6001
7	2.1338	2.21	2.1338	2.2862	.6859	.6001	.7716
8	2.572	.3429	.4287	.4287	.6859	.5144	.6859
9	2.21	.2572		.3429	.4287	.5144	.6001
10					2.1338	2.3624	2.6578
11					2.5149	2.5149	2.7435
12					2.3624	2.5149	2.7435
13					2.3624	2.5911	
14					2.4387	2.4387	2.7435
15					2.4387	2.4387	2.5149
16					2.4387	2.5149	2.5149
17					2.4387	2.5911	2.8807
18	.5144	.2572	.6859	.5144	.3429	.6001	.4572
19	.6001	.2572	.7716	.6001	.5144	.6001	.5335
20	.6001	.3429	.6001	.6859	.5144	.6001	.5335
21	.5144	.3429	.5144	.7373	.6001	.5144	.5335
22	1.6004	1.829	1.9052	.6859	.6001	.4287	.4572
23	1.6766	1.829	2.0576	.6859	.5144	.3429	.4668
24	1.8004	1.6766	1.829	1.9814	.6859	.5144	.3429
Max	2.572	2.21	2.1338	2.2862	2.5149	2.5911	2.8807
Min	.5144	.2572	.4287	.3429	.3429	.3429	.3429
Avg	1.5801	1.3176	1.4651	1.3357	1.1757	1.1999	1.1706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 201 / KOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.1943	.197	.1943	.181	.1989
2	.197	.1943	.2126	.1781	.1791	.1989
3	.197	.2267	.2149	.1943	.197	.2155
4	.2149	.2915	.2507	.1943	.2149	.2321
5	.2328	.2915	.3224		.2507	.2652
6	.3189	.3239	.3721	.2915	.2865	.2984
7	.2835	.2429	.3012	.2915	.3189	.3315
9	.2149	.1943	.2126	.2105	.2126	.2321
10	.2481	.1943	.2534	.2105	.1949	.1989
11	.2126	.1943	.2149	.1457	.197	.1658
12	.2303	.1457	.1949	.1457	.1791	.1658
13	.2126	.1943	.1949	.1457	.1612	.1658
14	.1949	.1943	.1772	.1619	.1612	.1492
15	.1949	.1619	.1753	.1619	.1433	.0995
16	.1949	.1781	.1402	.1619	.1949	
17	.2126	.1943	.1772	.1781	.1772	.116
18	.1791	.1943	.2172	.1781	.2172	.1989
19	.2172	.1781	.2715	.3077	.3258	.2486
20	.2353	.3077	.3045	.2753	.3292	.2984
21	.2534	.2683	.2715	.2267	.3109	.2652
22	.2507	.2267	.2896	.1943	.2715	.2321
23	.2481	.2105	.2328	.1943	.2353	.2155
24	.5809	.2105	.2149	.1943	.1991	.1989
Max	.5809	.3239	.3721	.3077	.3292	.3315
Min	.1791	.1457	.1402	.1457	.1433	.0995
Avg	.2407	.2179	.2354	.2017	.2234	.2132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 202 / Kolegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1943	.1829	.1619	.1791
2	.1772	.1943	.1991	.1619	.181
3	.197	.2105	.2172	.1619	.197
4	.2303	.2267	.2353	.1781	.2149
5	.2481	.3239	.2865	.2267	.2481
6	.3189	.3239	.3224	.2753	.3012
7	.3544	.3401	.4075	.3401	.3544
8	.2658	.3239	.2896	.2105	.2865
9	.2534	.2591	.1629		.1991
10	2.0557	2.3967	2.077		2.1418
11	2.3028		1.8814		2.1712
12	1.9444	2.332	1.8595		1.9867
13	2.1872	2.672	1.8138	2.1214	1.9265
14	2.2138	2.5101	1.8814	2.0891	1.8061
15	2.2184	2.2834	1.8724	2.17	1.7985
16	2.1914	2.2672	1.9467		1.7833
17	1.8976	2.1862	1.9265		1.768
18	.2865	.1781	.1629	.1781	.1791
19	.3077	.2753	.2378		.2715
20	.3077	.2429	.2378	.2267	.2926
21	.3045	.2105	.2402	.1943	.2772
22	.2658		.2172	.1781	.1829
23	.2481	.1943	.2172	.1781	.1829
24	.6668	.1943	.1991	.1781	.181
Max	2.3028	2.672	2.077	2.17	2.1712
Min	.1772	.1781	.1629	.1619	.1791
Avg	.9009	.9245	.7948	.5430	.7963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 203 / Phalawni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3603	1.5384	1.7158	1.587	1.6347
2		1.587	1.6406	1.587	1.6941
3	1.5524	1.7814	1.6255	1.7004	1.7457
4	1.7711	2.1862	1.7017	1.9919	1.8778
5	2.1715		2.0245	2.3644	2.1858
6	2.3929	2.4291	2.3022	2.7044	2.3746
7	2.5966	2.5101	2.8235	3.0607	2.5629
8	.4607	2.8826	.3224		.3224
9	.2686	.2267	.1991	.1781	.2172
10	.2149	.1943	.1991	.1781	.197
11	.1595	.1619	.1791		.1991
12	.1772	.1619	.1791	.1619	.181
13	.1772	.1943	.1791		.1791
14	.1772	.2105	.181	.1134	.1791
15	.1772	.1943	.1791		.1433
16	.1791	.1943	.2149	.1296	.1433
17	.1949	.2267	.2328		.2126
18	.2715	.2429		.2267	.2534
19	.3801	.3239	.3801		.3292
20	.362	.3077	.3658	.3563	.3658
21	.3439	.2915	.3511	.3077	.3258
22	1.4232	1.749	1.7071	1.8461	1.6204
23	1.5023	1.8299	1.7309	1.8461	1.6556
24	1.6286	1.5384	1.8364	1.7814	1.709
Max	2.5966	2.8826	2.8235	3.0607	2.5629
Min	.1595	.1619	.1791	.1134	.1433
Avg	.8671	.9984	.9683	1.2290	.9295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 201 / DOMBALWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5546	1.5546	1.8623	1.3279	1.8138	1.7166
2	1.3279	1.5546	1.5223	1.8623	1.3279	1.2631	1.7166
3	1.3279	1.5546	1.587	2.0081	1.3279	1.3279	1.7166
4	1.5223	1.6194	1.6518	2.0081	1.3765	1.3927	1.8138
5	1.5384	1.7004	1.7166	2.0891	1.5384	1.4575	1.8138
6	1.587	1.9433	1.7814	2.1538	1.7328	1.5223	1.5223
7	2.332	2.1862	1.8461	2.1376	1.9433	1.9433	2.0891
8		.2347	.2012	.2683			
9		.1844	.1677	.2683			
10	.1677	.1341	.1341	.1509			
11	.1341	.1341	.1341	.1006			
12	.1341	.1006	.1174	.0838			
13	.1509	.1006	.1174	.0838			
14	.1509	.1006	.1341	.0671			
15	.1509	.1341	.1174	.1006			
16	.1509	.1006	.1174	.0335			
17	.1174	.1006	.1677	.0838			
18	.1509	.1341	.3353	.1341			
19	.2347	.2012	.3185	.2515	.3018	.3521	.3353
20	.2515	.2012	.3185	.2515	.3018	.3521	.3353
21	.2515	.2012	.3185	.2515	.3018	.3521	.3018
22	1.749	1.5546	1.7814	1.4899	1.6842	1.6194	.3018
23	1.7328	1.5546	1.8138	1.4575	1.6518	1.6194	.3018
24	1.2955	1.6194	1.5546	1.8138	1.3279	1.7166	1.668
Max	2.332	2.1862	1.8461	2.1538	1.9433	1.9433	2.0891
Min	.1174	.1006	.1174	.0335	.3018	.3521	.3018
Avg	.7837	.7877	.8129	.8755	1.2418	1.2871	1.2025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 202 / AMBEMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4024	.3688	.3353	.3856	.3688	.3353
2	.3353	.4024	.3688	.3353	.3856	.3688	.3353
3	.3353	.4024	.3856	.3353	.3856	.3521	.3353
4	.3353	.4024	.3856	.3353	.4024	.3521	.3353
5	.3688	.4024	.4024	.3521	.4191	.3353	.3353
6		.4191	.4024	.3856	.4359	.3353	.3353
7		.0671	.0671		.0671		.0503
8			.0838				
9			.1006				
10	1.668	1.749	1.4899	1.7004	1.6194	1.7976	2.3158
11	1.8623	1.8138	2.1052	1.8461	1.7976	1.9433	.0838
12	1.8623	1.8138	2.1214	1.7814	1.6518	1.9433	.1006
13	1.8138	1.6032	2.0405	1.5384	1.5384	1.9433	.1006
14	1.8138	1.5546	1.9109	1.4575	1.4737	1.8461	.0838
15	1.749	1.5708	1.8299	1.3603	1.4737	1.7976	.0671
16	1.7004	1.4089	1.8299	1.4251	1.4899	1.6518	.0503
17	1.6194	1.3765	.1677	1.3748	1.4899	1.6194	.0838
18	.0671		.3688	.0671	.1006	.1006	.0671
19	.3521	.3018	.3353	.3185	.2683	.3521	.3353
20	.3521	.3185	.3353	.3688	.3521	.3521	.3688
21	.3521	.3185	.3353	.3688	.3353	.3521	.3688
22	.3521	.3018	.3353	.3688	.3185	.3353	1.7814
23	.4024	.3688	.3353	.3856	.3185	.3353	1.7328
24	.3353	.4024	.3353	.3353	.3856	.3185	.3353
Max	1.8623	1.8138	2.1214	1.8461	1.7976	1.9433	2.3158
Min	.0671	.0671	.0671	.0671	.0671	.1006	.0503
Avg	.9006	.8286	.7684	.7988	.7770	.8953	.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 203 / KHUDUS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6842	.5506	2.0891	1.7814	1.587	1.5708	1.8461
2	1.6842	.5506	1.6194	1.7814	1.587	1.6194	1.8461
3	1.7814	.5506	1.7166	1.8461	1.587	1.668	1.8785
4	1.9595	.583	1.7976	1.8461	1.587	1.7166	1.8785
5	2.0405	.6154	1.8947	1.8623	1.6194	1.8138	1.9433
6	2.1052	.6478	1.9757	1.9109	1.6518	1.9109	2.0405
7	2.5101	.7449	2.0405	2.17	1.9433	2.1376	2.2996
19	.1509	.2683	.3353	.3018	.3018	.3353	.3018
20	.1677	.3185	.3353	.3353	.3018	.3353	.3018
21	.1844	.3353	.3353	.3353	.3185	.3353	.3018
22	.583	2.1862	1.7814	1.6194	1.8785	1.8785	.3018
23	.6154	2.1376	1.8299	1.6518	1.9271	1.8785	.3018
24	1.6842	.583	2.1862	1.7814	1.6194	1.6194	1.8461
Max	2.5101	2.1862	2.1862	2.17	1.9433	2.1376	2.2996
Min	.1509	.2683	.3353	.3018	.3018	.3353	.3018
Avg	1.3193	.7748	1.5336	1.4787	1.3777	1.4476	1.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 204 / ZANJEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1677	.1677	.1677	.1677	.1844	.1677
2	.1677	.1677	.1677	.1677	.1677	.1844	.1677
3	.1677	.1677	.1677	.1677	.1677	.2012	.1677
4	.1677	.1677	.1677	.1677	.1677	.2012	.1677
5	.1844	.1844	.1677	.1677	.1677	.1677	.1844
6	.218	.1844	.1677	.1677	.1677	.1677	.1844
10	.9878	.9069	.9393	.8907	.8583	.9069	1.166
11	1.0526	.9231	1.0364	1.004	.8907	.9069	
12	1.0364	.9069	1.085	.9717	.8907	.9069	
13	1.0364		1.0364	.8421	.8745	.8583	
14	.9717		.8907	.8097	.8421	.7611	
15	.8907	.8907	.8421	.7449	.7611	.7125	
16	.8745	.9393	.8259	.7287	.7611	.7773	
17	.7773	.9069		.7773	.6316	.7773	
19	.1341	.1341	.1677	.1341	.1174	.1677	.1509
20	.1677	.1509	.1677	.1677	.1509	.1677	.1509
21	.1677	.1341	.1677	.1677	.1509	.1677	.1509
22	.1677	.1509	.1677	.1677	.1509	.1677	.9717
23	.1677	.1677	.1677	.1677	.1509	.1677	1.0364
24	.1677	.1677	.1677	.1677	.1677	.1509	.1677
Max	1.0526	.9393	1.085	1.004	.8907	.9069	1.166
Min	.1341	.1341	.1677	.1341	.1174	.1509	.1509
Avg	.4837	.4122	.4562	.4374	.4203	.4352	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 205 / 11 KV Ranvijay Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.1341	.1341	.1006	.1677	.1341	.1006
2	.1006	.1341	.1341	.1006	.1677	.1341	.1006
3	.1006	.1341	.1509	.1006	.1677	.1341	.1006
4	.1174	.1509	.1509	.1006	.1677	.1341	.1006
5	.1174	.1677	.1677	.1174	.1677	.1341	.1174
6	.1174	.1677	.1677	.1174	.1677	.1341	.1174
7	.1174	.1677	.1677	.1677	.1677	.1341	.1341
8	.1006	.1677	.1677	.1677	.1677	.1174	.1341
9	.1006	.1341	.1677	.1677	.1677	.1174	.1006
10	.0335	.1341	.1341	.1677	.1341	.1174	.1341
11	.0671	.1341	.1341	.1006	.1341	.1174	.1341
12	.0503	.1341	.1341	.1006	.1341	.1174	.1341
13	.0503	.1341	.1341	.1006	.1341	.1174	.1006
14	.0503	.1341	.1341	.1006	.1341	.1174	.1006
15	.0503	.1341	.1341	.1006	.1341	.1174	.0335
24	.1006	.1006	.1174	.1006	.1677	.1341	.1006
Max	.1174	.1677	.1677	.1677	.1677	.1341	.1341
Min	.0335	.1006	.1174	.1006	.1341	.1174	.0335
Avg	.0859	.1415	.1457	.1195	.1551	.1258	.1090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 201 / GARWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.583	.3963	.4115	.4458	.6516
2	.5487	.4287	.6001	.4572	.4268	.4801	.6516
3	.6001	.5144	.6173	.5792	.442	.5316	.6687
4	.6173	.5144	.6344	.6401	.4572	.6001	.6859
10	1.8861	1.8861	1.7071	1.9052	1.8861	1.6804	1.8747
11	1.9719	2.0062	1.7985	2.0576		1.8861	
12	2.0576	2.1776	2.0576	1.9052		2.1434	
13	2.1434	2.4006	2.0119	1.9052		2.2291	
14	2.2291	1.0288	1.9052	1.829	2.2291	2.2634	
15	2.3148		1.829	1.7528	1.9719	2.3148	
16	2.3148	1.8861	1.7985	1.7071	2.0576	2.1434	
17	2.2291	1.1145	1.7528	1.6004	2.0576	1.8861	
18	.5144	.4458	.3353	.3048	.3429	.4287	.3572
19	.5144	.4973	.5335	.5335	.3601	.5144	.5716
20	.4287	.5144	.5182	.5182	.3429	.5658	.6001
21	.4287	.5658	.4877	.5182	.4801	.6173	.5792
22	.5144	.5487	.4572	.4572	.4973	.6516	1.1145
23	.4287	.5487	.4268	.4268	.4973	.6516	1.1145
24	.1829	.5144	.5658	.4115	.4115	.4287	.6859
Max	2.3148	2.4006	2.0576	2.0576	2.2291	2.3148	1.8747
Min	.1829	.4287	.3353	.3048	.3429	.4287	.3572
Avg	1.1810	1.0012	1.0853	1.0477	.9295	1.1822	.7963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 202 / CHANDAPURI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.286	1.5604	1.4632	1.4784	1.7833	1.6118
2	1.4575	1.5089	1.5089	1.4784	1.4937	1.7147	1.6289
3	1.4746	1.6632	1.4746	1.4937	1.2193	1.6804	1.5947
4	1.5089	1.7147	1.5432	1.4937	1.2955	1.6289	1.5775
5	1.8004	1.749	1.6804	1.6004	1.5242	1.6804	1.6804
6	1.989	1.6461	1.8519	1.7528	1.7071	1.7147	1.8861
7	2.0748	1.6461	1.9204	1.829	1.829	1.749	1.9204
18	.4458	.2058	.1829	.1524	.2572	.2058	.16
19	.463	.2401	.2134	.2286	.2401	.2401	.2
20	.463	.2401	.2286	.2286	.2572	.2572	.2229
21	.4115	.2572	.2286	.2286	.2743	.2743	.2143
22	.9431	1.6289	1.3717	1.4632	1.5432	1.5432	.2378
23	1.0288	1.6461	1.448	1.448	1.8004	1.6289	.2378
24	.1829	1.1145	1.6118	1.4632	1.448	1.7661	1.6461
Max	2.0748	1.749	1.9204	1.829	1.829	1.7833	1.9204
Min	.1829	.2058	.1829	.1524	.2401	.2058	.16
Avg	1.1154	1.1819	1.2018	1.1660	1.1691	1.2762	1.0585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 201 / DASUR PATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0857	.0762	.0762		1.2955	1.2193
2	.0914	.0857	.0762	.0762		1.3413	1.2498
3	.1067	.1029	.1067	.0762		1.2193	1.2498
4	.1219	.1372	.1219	.1219		1.2955	1.2803
5	.1524	.1372	.1372	.1219		1.2955	1.2803
6	.1677	.1715	.1524	.1524		1.4754	1.326
7	.1829	.1715	.1677	.1677		1.4022	1.448
8	.1715	.1543	.1067	.1219		.1219	.1219
9	.1029	.1029	.0914	.1219	.12	.1067	.0914
10	1.5089	1.448	1.4937	1.448	1.3108	.1219	.0762
11	1.326	1.5851	1.5546	1.4632	.0762	.0914	.0457
12	1.5242	1.5089	1.5851	1.4632	.0762	.061	.0457
13	1.6613	1.5089	1.5394	1.4632	.0762	.0762	
14	1.6004	1.4937	1.5546	1.4937	.0762	.0762	.0457
15	1.5546	1.4784	1.5699	1.2955	.0762	.0762	.0457
16	1.5546	1.448	1.5851	1.4937	.0762	.0762	
17	1.5546	1.5089	1.4937	1.4327	.0762	.0762	
18	.0857	.0914	.0914	.1372	.1067	.0914	.0914
19	.1372	.1524	.1715	.1543	.1372	.1219	.1219
20	.1372	.1219	.1715	.1543	.1067	.1067	.1219
21	.1029	.1067	.1372	.1372	.1219	.1067	.1219
22	.0686	.0914	.1067	1.1584	1.5424	1.2193	.1067
23	.0857	.0914	.0914		1.3717	1.2193	.0914
24	.3506	.0857	.0762	.0914		1.3717	1.2193
Max	1.6613	1.5851	1.5851	1.4937	1.5424	1.4754	1.448
Min	.0686	.0857	.0762	.0762	.0762	.061	.0457
Avg	.6017	.5779	.5941	.6271	.3567	.6019	.5429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 202 / 11 KV NANAWARE WASTI

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.6859	.7621	.8535	.2058	.2134	.1981
2	.5792	.6859	.7621	.823	.2058	.1981	.2134
3	.5792	.7621	.7926	.823	.2058	.1829	.2439
4	.6097	.8916	.823	.8535	.2572	.2286	.2591
5	.6859	.7926	.823	.8535	.3086	.2743	.2743
6	.7773	.823	.8688	.8688	.8573	.3048	.3201
7	.9145	.823	1.0059	.9907	.3601	.3353	.3506
8	.1886	.2439	.2286	.2743		.2591	.2743
9	.2058	.2401	.2286	.2134		.2134	.1981
10	.1715	.1981	.2134	.1715	.9907		.945
11	.1715	.1829	.1981	.1715	1.0669		.9907
12	.1715	.1677	.2286	.1715	1.1279	.6554	.9907
13	.1715	.1829	.2134	.1372	1.0669	.945	1.0059
14	.2401	.1829	.2286	.1372	1.0974	.9602	.9907
15		.1981	.2286	.1029	.9145	.9602	.9907
16		.2134	.2134	.1715	.945	.9755	.9145
17	.3086	.2286	.2134	.2058	.9602	.9755	.9145
18	.2401	.2286	.2743	.2915	.2134	.1524	.1981
19	.3429	.2286	.3429	.3429	.2896	.2286	.2743
20	.3086	.2286	.2743	.3086	.2439	.1981	.2439
21	.2058	.1981	.2229	.2572	.2286	.1829	.2286
22	.6249	.7164	.7926	.1981	.1981	.1981	.6859
23	.6401	.7316	.7926	.1829	.1981	.1981	.7621
24	.1829	.6859	.7316	.8535	.2058	.2134	.1981
Max	.9145	.8916	1.0059	.9907	1.1279	.9755	1.0059
Min	.1715	.1677	.1981	.1029	.1981	.1524	.1981
Avg	.4038	.4384	.4776	.4274	.5522	.4115	.5277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 203 / 11 KV BHIMA NADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.884	.6859	.7926
2					.9145	.6859	.7926
3					.9145	.6097	.7926
4					1.0631	.6097	.8078
5					.945	.8383	.823
6					.9755	.9602	.8383
7					.9755	.9907	.8078
10	.6706	.8993	.9297	.9907			
11	.6859	.9907	.9907	1.1145			
12	.7621	1.0059	1.0059	1.1317			
13	.8383	1.0212	.9755	.9907			
14	.8383	1.0212	1.0212	.9907			
15		1.0364	1.0212	.9145			
16	.7621	1.0669	.9602	1.0059			
17	.823	1.0669	1.0059	.9755			
22				.7621	.8383	.7164	
23				.8383	.8383	.7621	
24	.1829				.9431	.7621	.7926
Max	.8383	1.0669	1.0212	1.1317	1.0631	.9907	.8383
Min	.1829	.8993	.9297	.7621	.8383	.6097	.7926
Avg	.6954	1.0136	.9888	.9715	.9292	.7621	.8059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 277023 / 132/33KV VELAPUR EHV S/S

Feeder No / Name : 403 / 33 kV Vizori

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.0517
Max	1.0517
Min	1.0517
Avg	1.0517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 277101 / 132/11 KV SHRIPUR

Feeder No / Name : 701 / 132 KV Pandurang Sahakari NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Sakh Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	2.1948
Max	2.1948
Min	2.1948
Avg	2.1948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 277101 / 132/11 KV SHRIPUR

Feeder No / Name : 702 / 132 KV Pandurang Sahakari NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Sakh Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	3.8409
Max	3.8409
Min	3.8409
Avg	3.8409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 201 / 11KV JADHAVWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2439		.2652	.2896	.2439	.2622
2	.2439	.2439		.2652	.2896	.2439	.2622
3	1.3413	1.3413		1.4918	.945	1.3717	1.4746
4	1.3717	1.3717		1.5746	.9907	1.448	1.5565
5	1.4022	1.4022		1.6244	1.0212	1.6766	1.8023
6	1.8595	1.768		1.8233	1.0364	1.7528	1.6712
7	2.0271	2.271		2.2377	1.5851	2.1491	2.13
8	2.332	2.4691		2.4291	1.6766	2.332	2.1365
9	2.3266	.3201	2.2939	2.2996		2.0576	2.0348
10	1.4255	.2439	2.1136	1.2498		1.9509	1.8652
19	.3077	.2591	.3113	.2743	.3563	.3113	
20	.3077	.2896	.3149	.3201	.3401	.3113	.2753
21	.3239	.2896	.3315	.3048	.2896	.3113	.2753
22	.2915	.3048	.3149	.3048	.2896	.2949	.2753
23	.2915	.2743	.2984	.3048	.2915	.2949	.2753
24	.2286	.2743		.2984	.2896	.2743	.2622
Max	2.332	2.4691	2.2939	2.4291	1.6766	2.332	2.1365
Min	.2286	.2439	.2984	.2652	.2896	.2439	.2622
Avg	1.0203	.8354	.8541	1.0667	.6922	1.0640	1.1039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 202 / 11KV CHAUR WASTI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	1.3413		1.4746	1.0974	2.652	
2	1.2498	1.2498		1.4419	1.0364	2.6188	1.3094
3	.3963	.3963		.426	.3658	.8619	.431
4	.3963	.3963		.426	.3658	.895	.4475
5	.4268	.4268		.4588	.4115	.9613	.4807
6	.4572	.442		.5407	.503	1.0608	.6962
7	.4572	.4572		.5407	.4268	.9282	.7293
9						.4534	
19	2.0317	1.89	2.1956	1.9509	1.9814	2.7362	
20	1.8023	1.8947	1.8947	1.8747	2.0405	2.2377	.8421
21	1.5729	1.7814	1.7814	1.8138	1.7985	2.304	.8421
22	1.5565	1.587	1.587	1.2498	1.4251	1.4586	.8097
23	1.5238	1.5546	1.5546	1.2193	1.3927	1.4255	.7773
24	3.0007	1.3717		1.5238	1.1584	2.7673	1.3757
Max	3.0007	1.8947	2.1956	1.9509	2.0405	2.7673	1.3757
Min	.3963	.3963	1.5546	.426	.3658	.4534	.431
Avg	1.2471	1.1376	1.8027	1.1493	1.0772	1.6686	.7946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 203 / 11KV SIDACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1219		.1619	.2105	.1619	.1658
2	.1219	.1219		.1619	.2105	.1619	.1658
3	1.3413	1.3413		1.6356	1.4899	1.6356	1.6741
4	1.3717	1.3717		1.7814	1.587	1.7814	1.8233
5	1.4327	1.4327		2.1052	1.7328	1.9109	1.9559
6	1.4937	1.4937		2.2348	1.9052	1.9757	1.7404
7	1.5242	1.6156		1.9757	2.0119	2.2348	2.0719
8	1.6156	1.6918		1.9919	2.1538	2.0567	1.9814
9	1.7004	1.587	2.1862	1.7328	2.1052	1.9433	1.9814
10	1.6842	1.4022	1.9433	1.5384	1.9919	1.8299	1.9662
19	.1475	.1943	.1802	.1943	.1829	.1638	
20	.1475	.1981	.1966	.2105	.2105	.1989	.1966
21	.1802	.2134	.1966	.1943		.1989	.1829
22	.1802	.1829	.213	.1781		.1989	.1829
23	.1802	.1829	.1966	.1943		.1989	.1829
24	.1	.1067		.1943	.2105	.1781	.1823
Max	1.7004	1.6918	2.1862	2.2348	2.1538	2.2348	2.0719
Min	.1	.1067	.1802	.1619	.1829	.1619	.1658
Avg	.8345	.8286	.7304	1.0303	1.2310	1.0519	1.0969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 204 / 11KV DEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677			.1638	.1524	.1638	.1619
2	.1829			.1638	.1524	.1638	.1619
3	.1829			.1802	.1524	.1966	.1943
4	.1829			.1802		.2294	.2267
5	.1829			.1966		.2622	.2591
6	.1981			.2458		.2622	.2591
7	.2134			.2458	.2439	.213	.2753
11	1.8515	1.2193	1.3763	1.326	1.3603	1.4746	
12	1.9919	1.2803	1.4251	1.3413	1.3441	1.4575	
13	1.7652	1.4419	1.4754	1.3108	1.2498	1.4413	
14	1.587	1.5089	1.4419	1.326	1.3279	1.3441	
15	1.4899	1.5927	1.4251	1.3565	1.2955	1.3765	
16	1.6032	1.4937	1.4922	1.2955	1.3279	1.3765	
17	1.5565	1.448	1.5565	1.2803	1.2955	1.3279	
18	1.5893	1.387		1.1736	1.2041	1.3441	
19		.1677	.213	.1829	.1829	.1943	
20		.1677	.2155	.1829	.1943	.1943	1.3413
21		.1677	.2155	.1829	.1524	.1943	1.3108
22		.1524	.1823	.1829	.1372	.1619	1.2346
23		.1524	.1823	.1829	.1372	.1457	1.166
24	.1677			.1802	.1619	.1475	.1457
Max	1.9919	1.5927	1.5565	1.3565	1.3603	1.4746	1.3413
Min	.1677	.1524	.1823	.1638	.1372	.1457	.1457
Avg	.9321	.9369	.9334	.6134	.6707	.6510	.5614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 205 / 11KV MALSHIRAS URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9156	1.0174		1.0288	1.153	1.1191	1.1317
2	.8478	.9665		.9774	1.1022	.9831	1.0288
3	.823	.9755		1.1145	1.0364	1.0814	1.1317
4	.945	1.153		1.2346	1.2548	1.278	1.3375
5	1.2209	1.2209		1.3375	1.2498	1.3108	1.4746
6	1.3226	1.2955		1.4403	1.4175	1.4091	1.5775
7	1.4074	1.2955		1.4746	1.3717	1.3763	1.4918
8	1.3056	1.2193		1.3375	1.3395	1.1469	1.3108
9	1.2346	1.3226	1.286	1.2689	1.2146	1.065	1.3108
10	1.1831	1.2039	1.1488	1.0974	1.1336	1.0322	1.0814
11	1.0974	1.153	1.0802	1.0631	.9393	1.0159	.9175
12	1.0974	.9665	.9665	.9945	.9069	1.0288	.8848
13	1.0117	.9496	.9326	.9602	.8907	.9774	
14	.9602	.9156	.8987	.9431	.8817	.8573	.7545
15	.9259	.9326	.8648	.9259	.8573		.8383
16	.9602	.9496	.9496	.9088	.823	.9431	.9069
17	.9774	.9665	1.0288	.9602	.9945	.9774	
18	1.046	1.0174	1.1145	1.0288	1.0631	1.0288	1.1431
19	1.286	1.3904	1.4575	1.3032	1.2517	1.3375	
20	1.286		1.4746	1.406	1.3889	1.3203	1.4899
21	1.3032		1.3375	1.4232	1.3735	1.3546	1.4089
22	1.2689		1.286	1.3889	1.3565	1.3717	1.4413
23	1.2003		1.2003	1.2346		1.3375	1.1584
24	1.1022	1.0513		1.1317	1.1869	1.2209	1.2346
Max	1.4074	1.3904	1.4746	1.4746	1.4175	1.4091	1.5775
Min	.823	.9156	.8648	.9088	.823	.8573	.7545
Avg	1.1137	1.0981	1.1351	1.1660	1.1386	1.1554	1.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 206 / 11KV Medad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8138	1.7071		1.9433	2.0081	2.0729	2.0972
2	1.7652	1.6613		1.7814	1.8947	1.7814	1.8023
3	.421	.3963		.4372	.421	.4372	.4424
4	.3963	.3963		.4372	.421	.4372	.4424
5	.3963	.3963		.421	.4534	.4534	.4588
6	.4268	.4877		.4696	.4877	.4696	.5407
7	.442	.442		.4372	.4534	.4049	.5079
16						.1296	
19	3.1741	2.5606	2.915	2.713	2.5301	3.1131	
20	2.5101	2.6216	2.5911	2.774	2.6073	2.7199	.4372
21	2.6052	2.4939	2.3967	2.4996	2.3472	2.4905	.3963
22	2.1052	2.3167	2.3644	2.21	2.1033	2.2611	.3658
23	2.0729	1.0669	2.3158	2.0729	2.1862	2.2119	.3658
24	1.7147	1.829		2.2996	2.1052	2.1052	2.13
Max	3.1741	2.6216	2.915	2.774	2.6073	3.1131	2.13
Min	.3963	.3963	2.3158	.421	.421	.1296	.3658
Avg	1.5264	1.4135	2.5166	1.5766	1.5399	1.5063	.8322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 207 / 11KV TARANGFAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3887		.3932	.4858	.3932	.3932
2	.381	.3887		.3932	.4858	.3932	.3932
3	1.6766	1.004		1.6057	1.9595	1.6221	1.6221
4	1.7985	1.2955		2.1628	2.0243	2.13	2.13
5	2.0271	1.829		2.4577	2.1376	2.1792	2.1792
6	2.1033	2.332		2.7854	2.0576	2.4086	2.1136
7	2.1948	2.7692			2.4387	2.6052	2.5724
8	.1677	2.6073		2.5232	2.6063	2.4577	2.4086
9	.1781	2.3266	1.9662	2.6543	2.2939	2.13	2.0645
10	.2105	2.0576	1.8187	1.5074	1.7004	1.7532	1.4255
11					1.7004		
15					1.7204		
19	.4424	.4725	.5735	.3932	.4588	.4424	
20	.4424	.4115	.4915	.4588	.4424	.426	.3963
21	.4424	.3963	.4752	.4588	.3963	.4096	
22	.426		.426	.4752	.3963	.4096	.381
23	.426		.426	.4752	.381	.4096	.381
24	.3963	.4049		.426	.4915	.4096	.4096
Max	2.1948	2.7692	1.9662	2.7854	2.6063	2.6052	2.5724
Min	.1677	.3887	.426	.3932	.381	.3932	.381
Avg	.8559	1.3346	.8824	1.2780	1.3432	1.2862	1.3479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 208 / 11 KV TARANGFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3353		.3978	.3887	.3658	.3887
2	.3658	.3353		.4475	.3887	.4115	.4372
3	.3963	.3353		.4475	.3887	.4268	.4534
4	.4268	.3963		.4641	.3963	.4572	.4858
5	.4268	.4572		.4973	.4534	.4877	.5182
6	.4268	.4725		.4807	.4572	.503	.5182
7		.442		.4475	.4268	.4572	.4696
8	.3353	.3353		.4049	.3658	.4877	.4578
9	.3113	.2743	.3563	.3239	.3048	.3048	.3391
10	.2622	.2134	.2267	.2591	.2753	.2896	.2374
11	.2458	.2267	.1943	.2267		.2439	.2204
12	.2949	.2105	.1696	.1943		.2267	.1865
13	.0983	.1943	.1696	.1781		.1781	.2012
14	.0983	.1781	.2204	.1781	.1781	.1781	.2035
15	.1966	.1781	.2374	.1943	.1781	.2105	.2347
16	.2458	.1943	.2204	.2591	.1943	.2429	.2515
17	.2429	.2105	.2267	.2915	.1981	.2591	.2743
18	.2429	.2267	.2429		.2374	.2915	.3048
19	.3563	.3239	.4049	.2267	.4534	.3887	
20	.3563	.4588	.4534	.4534	.4858	.4534	.4572
21	.4696	.442	.4696	.426	.442	.4534	.4268
22	.3887		.4858	.4049	.381	.4049	.4115
23	.3563		.4534	.421	.4268	.4534	.4115
24	.3201	.3353		.3978	.3658	.3658	.3887
Max	.4696	.4725	.4858	.4973	.4858	.503	.5182
Min	.0983	.1781	.1696	.1781	.1781	.1781	.1865
Avg	.3143	.3080	.3021	.3488	.3517	.3559	.3599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 209 / 11KV KALE-PANDARE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2439		.2622	.2743	.2622	.2267
2	.2439	.2622		.2622	.2743	.2622	.2267
3	.2743	.2743		.2915	.2743	.2785	.2753
4	.2743	.2743		.2915	.3048	.2949	.2915
5	.3048	.3048		.3239	.3201	.3113	.3077
6	.3201	.3353		.3563	.3506	.4096	.3887
7	.3353	.3201		.3401	.3048	.3932	.3563
11	2.4615	2.6216	2.6558	2.4691	2.1948	2.343	
12	2.6216	2.5453	2.4806	2.4387	2.21	2.2672	
13	2.5069	2.7035	2.3365	2.4939	2.1491	2.251	
14	2.4249	2.4387	2.3685	2.4291	2.1338	1.8023	
15	2.1628	2.5101	2.3845	2.3967	2.2611	1.6032	
16		2.5232	2.3685	2.3805	2.2447	2.2377	
17	2.1792	2.332	2.3967	2.3482	2.2283	1.9062	
18	2.2024	2.2862	2.4129	2.2186	2.1862	1.5565	
19	.2622	.2591	.3441	.2591	.4372	.2984	
20	.2622	.2591	.3401	.3077	.3401	.2753	2.0119
21	.2949	.2286	.2915	.3077	.3201	.2753	1.9509
22	.2622	.2286	.2429	.2753	.3048	.2591	1.829
23		.2286	.2429	.2753	.2896	.2591	1.7985
24	.2743	.2743		.2458	.2743	.3113	.2429
Max	2.6216	2.7035	2.6558	2.4939	2.2611	2.343	2.0119
Min	.2439	.2286	.2429	.2458	.2743	.2591	.2267
Avg	1.0480	1.1168	1.6050	1.0940	1.0323	.9456	.8255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 210 / COURT-(GOVT) EXPRESS NON SHEDDABLE WATER SUPPLY AND
 FEEDER Feeder KV- 11 / UTILITY
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1219		.12	.1296	.1219	.116
2	.1219	.1219		.1372	.1311	.1219	.1372
3	.1219	.1219		.1372	.1219	.1219	.0995
4	.1219	.1219		.1372	.1219	.1219	.1326
5	.1219	.1219		.1372	.1296	.1219	.1326
6		.1219		.12	.1219	.1219	.1372
7	.1219	.1219		.116	.1296	.1219	.1372
8	.1219	.1219		.1326	.1219	.1219	.1219
9	.0972	.1219	.0819	.1219	.1219	.1219	.1219
10	.081	.1219	.0819	.1219		.1326	.1219
11	.0983	.1372	.0983	.1219	.1219	.1326	.1357
12	.0983	.1372	.1357	.1296	.1219	.1326	.1357
13	.0972	.1372	.1357	.1296	.1219	.1326	.1357
14	.0972	.1372	.1357	.1296	.1219	.1326	.1311
15	.0983	.1372	.1357	.1311	.1311	.1326	.1357
16	.0819	.1372	.1357	.1219	.1296	.116	.1357
17	.0972	.1372	.1372	.1219	.1296	.1326	.1296
18	.0983	.1372	.1372		.1296	.1326	.1296
19	.0972	.1372	.1372	.1219	.1296	.1326	.1296
20	.0972	.1372	.1372	.1219	.1296	.1372	.1296
21	.0972	.1219	.1029	.1219	.1219	.1372	.1296
22	.0972	.1219	.1029	.1219	.1219	.1372	.1296
23	.0972	.1219	.116	.1219	.1219	.1372	.1296
24	.1219	.1219		.1029	.1219	.1219	.1372
Max	.1219	.1372	.1372	.1372	.1311	.1372	.1372
Min	.081	.1219	.0819	.1029	.1219	.116	.0995
Avg	.1046	.1283	.1207	.1252	.1254	.1282	.1297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 201 / 11KV KANHER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.1781	.1638	.1677	.1943	.1638	.1829
2	.1829	.1781	.1475	.1677	.1781	.1638	.1829
3	.1829	.1943	.1311	.1524	.1781	.1802	.1829
4	.1829	.2105	.1475	.1524	.1781	.1802	.1829
5	.1829	.2267	.1638	.1829	.1943	.1966	.1981
6	.1829	.2267	.1802	.1829	.1943	.213	.1981
7	.1677	.2267	.1802	.1829	.1943	.213	.2187
8	.1875	.1781	.1966	.1829	.1781	.1966	.1981
9	1.2346	1.2308	1.3117	1.1584	1.2146		.1981
10	1.4899	1.3927	1.3108	1.3117	1.3117	1.4937	.213
11	1.4899	1.3927	1.2654	1.3765		1.5242	
12	1.4575	1.3279	1.0822	1.2146		1.4784	
13	1.3927	1.2631	1.0517	1.2308	.8745	1.4784	
14	1.3441	1.247	1.0212	1.1822	1.2631	1.4784	
15	1.3117	1.166	1.0467	1.166	1.2308	1.4937	
16	1.2793	1.1174	.9907	1.0526	1.1174	1.5089	
17	.1619	.1147	.1219	.0972	.1311	.1219	
18	.1781	.1638	.1219	.1296	.1475	.1524	2.0081
19	.1781	.1966	.1524	.1619	.1638	.1829	2.0081
20	.1781	.1638	.1524	.1619	.1638	.1829	1.9109
21	.1781	.1311	.1562	.1781	.1638	.1875	1.6518
22	.1781	.1475	.1524	.1781	.1802	.1829	1.6032
23	.1781	.1638	.1677	.1781	.1802	.1677	1.5546
24	.1981	.1781	.1638	.1829	.1943	.1638	.1829
Max	1.4899	1.3927	1.3117	1.3765	1.3117	1.5242	2.0081
Min	.1619	.1147	.1219	.0972	.1311	.1219	.1829
Avg	.5786	.5423	.4825	.5139	.4467	.5785	.7574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 202 / 11KV ISLAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1094	.0972	.0983	.1094	.0972	.0983	.1562
2	.1094	.1134	.0983	.1094	.0972	.1147	.1562
3	.1094	.1296	.1147	.1094	.1134	.1147	.1562
4	.125	.1457	.1311	.125	.1296	.1311	.1562
5	.1562	.1619	.1475	.1562	.1457	.1638	.2343
6	.2031	.1619	.1638	.1562	.1619	.1802	.25
7	.1875	.1781	.1475	.1718	.1619	.2294	.2656
8	.1875	.1457	.1475		.1457	.2294	.2343
9	.1562	.1296	.0983	.0972	.1296		.2031
10	1.0526	.9878	1.3279	1.3117	1.2793	1.8947	2.1376
11	1.587	1.0688	1.4251	1.3441		2.1376	
12	1.7004	1.2631	1.5546	1.3117		1.9271	
13	1.6842	1.2793	1.3603	1.2631	1.1498	1.9919	
14	1.587	1.166	1.166	1.166	1.587	2.0405	
15	1.3441	1.1336	1.1336	.9878	1.4575	1.8299	
16	1.1984	1.1174	.8421	.9878	1.3765	1.7328	
17	1.0202	1.0526	.9231	1.004	1.3117	1.6194	
18	.0972	.0983	.0781	.0972	.0983	.1406	.1966
19	.1296	.1147		.1134	.1147	.2031	.2458
20	.1296	.1475	.1406	.1134	.1311	.1875	.2294
21	.1296	.0983	.125	.1134	.1147	.1562	.1966
22	.1296	.0983	.1094	.1134	.0983	.1718	1.7814
23	.1134	.0983	.1094	.1134	.0983	.1718	1.7814
24	.1094	.0972	.0983	.1094	.0972	.0983	.1718
Max	1.7004	1.2793	1.5546	1.3441	1.587	2.1376	2.1376
Min	.0972	.0972	.0781	.0972	.0972	.0983	.1562
Avg	.5565	.4618	.5018	.4863	.4589	.7637	.5031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 203 / 11KV MANAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2753	.2294	.2286	.2915	.2294	.2812
2	.2812	.2753	.2294	.2286	.2915	.2458	.2896
3	.2812	.2753	.2622	.2286	.3077	.2458	.3125
4	.2812	.2915	.2622	.2286	.3239	.2785	.3048
5	.3125	.2915	.2785	.2439	.3239	.2949	.3125
6	.3125	.3077	.2785	.2439	.3401	.2949	.3281
7	.2968	.3077	.2785		.3077	.2949	.3281
8	.2343	.2753	.2622	.2439	.2591	.2949	.2286
9	.2031	.1943	.213	.2187	.2267		.2031
10	.1943	.1966	.2031	.2429	.213	.1981	.213
11	.1943	.213	.1562	.2267		.1677	
12	.2429		.1718	.2105		.1875	
13	.2267	.2294	.1718	.2267	.1966	.1718	
14	.2267	.1966	.1718	.2267	.1802	.1677	
15	.2267	.1802	.1562	.2429	.2622	.1524	
16	.2267	.1802	.2134	.2429	.2785	.2031	
17	1.9919	2.5749	2.3903	2.5425	2.6397	.1219	
18	2.2834	2.3967	2.3434	2.3967	2.3967	2.4082	.2785
19		1.6032		2.0891	2.1052	2.0309	.2622
20	1.5708	1.9595	1.656	1.7814	1.9109	1.6248	.2949
21	1.5546	1.7814	1.3748	1.6194	1.4575	1.2967	.2949
22	1.4575	1.6032	1.1717	1.4251	1.3927	1.1431	.2949
23	1.3927	1.4413	1.0623	1.2955	1.2308	1.0669	.2785
24	1.2029	1.1822	1.1822	.9907	1.1822	1.0688	1.0212
Max	2.2834	2.5749	2.3903	2.5425	2.6397	2.4082	1.0212
Min	.1943	.1802	.1562	.2105	.1802	.1219	.2031
Avg	.6726	.7927	.6400	.7663	.8236	.6169	.3251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 204 / ISLAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1041	1.0526	1.086	1.0517	1.0688	1.086	1.1946
2	1.1222	1.1174	1.086	1.0517	1.1012	1.1041	1.1946
3	1.004	1.1174	1.1222		1.1822	1.1584	1.267
4	1.267	1.2955	1.1584	1.1393	1.3117	1.2489	1.267
5	1.3717	1.3603	1.3756		1.4251	1.3756	1.448
6	1.5432	1.3927	1.4299		1.5223	1.4661	1.5775
7	1.4118	1.2631	1.4661	1.4022	1.2631	1.4118	1.4198
9	1.0317	.8583	.9774	.964	.8907		.9955
10	.7935	.8326	.8145	.7449	.6335	.7783	.7602
11	.6316	.724	.5973	.664		.6154	.6878
12	.6802		.5249	.5344		.6335	.6154
13	.7125	.6878	.5249	.4858	.5973	.5792	.5973
14	.7125	.6697	.543	.502	.6697	.5973	.543
15	.7611	.6878	.5792	.5182	.6878	.5792	.4887
16	.7935	.7059	.5973	.5344	.6335	.6154	.5249
17	.7935	.724	.5792	.5506	.6697	.724	.7059
18	.7125	.7783	.7421	.6964	.7421	.8145	.9412
19	.9555	1.1946		1.1498	1.267	1.1946	1.267
20	1.0364	1.1584	1.267	1.1336	1.2489	1.3213	1.2489
21	1.0526	1.1222	1.1222	1.1012	1.1765	1.2851	1.1403
22	1.0364	1.1041	1.1041	1.0364	1.1584	1.2308	1.1222
23	1.0364	1.086	1.1041	1.0526	1.1222	1.1946	1.1222
24	1.1041	1.004	1.086	1.0288	1.0688	1.1222	1.1946
Max	1.5432	1.3927	1.4661	1.4022	1.5223	1.4661	1.5775
Min	.6316	.6697	.5249	.4858	.5973	.5792	.4887
Avg	.9856	.9971	.9494	.8671	1.0210	1.0062	1.0141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 205 / GORADWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.4737	1.4413	1.387	1.4413	1.4575	1.406
2	1.406	1.6194	1.4575	1.448	1.5384	1.5384	1.4842
3	1.4842	1.6194	1.4575	1.448	1.587	1.5384	1.5623
4	1.4842	1.8138	1.5546	1.4842	1.587	1.6194	1.7185
5	1.5623	1.8299	1.6356	1.5623	1.6194	1.6356	1.8747
6	1.7185	1.8785	1.7814	1.7185	1.7166	1.7814	2.0309
7	2.1559	1.9433	2.0729	1.8747	1.749	2.0081	2.4371
8	1.9997	1.9595	1.6194	1.5546	1.6518	1.5708	2.2028
9	.2343	.3239	.2294	.2343	.2591		.3048
10	.2591	.2622	.1718	.2267	.1966	.2343	.3277
11	.2267	.1802	.1562	.2267		.2187	
12	.2915	.1638	.1562	.1943		.2343	
13	.2591	.1802	.1562	.2105	.1966	.25	
14	.2591	.1802	.1562	.1619	.2294	.2812	
15	.2591	.1802	.1562	.1781	.2294	.2656	
16	.3077	.1802	.1718	.2267	.2458	.2812	
17	.3077	.1966	.1875	.2105	.2622	.2812	
18	.3077	.2622	.2187	.2753	.2949	.2968	.3441
19	.3725	.2949	.3125	.3887	.3113	.3906	.5571
20	.3887	.3113	.3353	.3887	.3277	.381	.5571
21	.3887	.2949	.3437		.3113	.3906	.5079
22	.3887	.3277	.3125	.3401	.3277	.4218	.4915
23	.3725	.3277	.2968	.3401	.3441	.4374	.5079
24	.4062	.3401	.3441	.2896	.3563	.3441	.442
Max	2.1559	1.9595	2.0729	1.8747	1.749	2.0081	2.4371
Min	.2267	.1638	.1562	.1619	.1966	.2187	.3048
Avg	.7603	.7560	.6969	.7117	.7629	.7765	1.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 206 / SARGARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6964	.8097	1.004	1.1336	.9555	1.1012	1.2955
2	.7287	1.0526	1.0364	1.1336	.9555	1.1336	1.4575
3	.7287	1.1174	1.0364	1.1336	1.1012	1.1336	1.4575
4	.8097	1.1498	1.1174	1.2146	1.2146	1.2308	1.4575
5	.8907	1.3603	1.2308	1.2955	1.2631	1.2955	1.6194
6	1.004	1.3927	1.4413	1.3765	1.3117	1.4413	1.7004
7	1.3441	1.6356	1.6356	1.4575	1.5384	1.6356	1.8623
8	.4374	.2915	.3113	.25	.2591	.2622	.3125
9	.2343	.2429	.213	.1875	.2105		.25
10	.1781	.213	.1718	.2105	.1638	.1562	.1966
11	.1457	.1802	.1718	.2105		.1562	
12	.1619	.2294	.1406	.1619		.1562	
13	.1619	.1638	.1562	.1638	.1638	.1562	
14	.1781	.1475	.1562	.1619	.1475	.1406	
15	.1943	.1311	.1562	.1619	.1966	.1406	
16	.1943	.1475	.1406	.1781	.213	.1562	
17	.2105	.1475	.1562	.1943	.2294	.1562	
18	.2105	.1966	.1718	.1943	.2294	.1875	.2294
19	.2267	.2458	.2031	.2915	.2458	.2031	.2949
20	.2429	.2622	.2343	.2915	.2458	.2343	.2785
21	.2429	.2458	.2343	.2753	.2294	.2343	.2458
22	.5668	.6154	.9878	.9878	.9717	.9717	.2622
23	.7935	.7773	1.0364	.9717	.9878	1.0526	.2785
24	.5344	.7935	1.004		.8745	1.0688	1.2146
Max	1.3441	1.6356	1.6356	1.4575	1.5384	1.6356	1.8623
Min	.1457	.1311	.1406	.1619	.1475	.1406	.1966
Avg	.4632	.5645	.5895	.5929	.6231	.6263	.8478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 201 / DESHMUKH PATTAG AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.3717	1.4746	1.4419	1.5242	1.6804	1.5851
2	1.0395	1.4327	1.4746	1.4419	1.5851	1.7318	1.6461
3	1.0898	1.5546	1.5261	1.4922	1.6461	1.7833	1.7071
4	1.1736	1.768	1.5604	1.5257	1.7375	1.9033	1.768
5	1.2574	1.89	1.7833	1.7436	1.8595	2.0233	1.829
6	1.3413	2.0119	2.0233	1.9281	1.9509	2.1434	1.9204
7	2.0119	2.1338	2.3663	2.0957	1.9814	2.3148	1.9814
8	2.2634	.2134	.2743	.2683	.2439	.3086	.2439
9	2.2634						
19	.1829	.2401	.2347	.2743	.2743	.2134	.2515
20	.1981	.2401	.2347	.2591	.3086	.2439	.2683
21	.1981	.2401	.2347	.2439	.2743	.2439	.2683
22	1.2193	1.286	1.3413	1.2955	1.166	1.448	
23	1.2498	1.406	1.3748	1.3413	1.6289	1.4937	.2683
24	.8573	1.3108	1.4251		1.4022	1.6461	.2683
Max	2.2634	2.1338	2.3663	2.0957	1.9814	2.3148	1.9814
Min	.1829	.2134	.2347	.2439	.2439	.2134	.2439
Avg	1.1568	1.2214	1.2377	1.1809	1.2559	1.3699	1.0774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 202 / 11KV UMBARE DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3201	.3772	.3688	.3201	.3429	.3201
2	.3353	.3201	.3601	.3688	.3201	.3601	.3201
3	.3353	.3201	.3601	.3688	.3353	.3601	.3201
4	.3353	.3048	.3429	.3353	.3353	.3772	.3201
5	.3353	.3048	.3429	.3353	.3658	.3772	.3201
6	.3353	.3353	.3429	.3353	.3963	.3772	.3353
7	.3018	.3658	.3429	.3315	.3658	.3944	.3658
8	.2984	.3201	.3086	.2984	.3048	.3429	.3048
10		2.1338	2.6825	2.3472	1.829	2.7092	2.2862
11		3.0521	2.8502	2.4387	2.572	2.6673	
12		3.0864	2.934	2.8197	2.6578	2.5911	
13	2.5911	3.0521	2.6825	2.5911	2.7435	2.4387	
14	2.6368	2.9835	2.3472	2.4387	2.7778		
15	2.5911	2.9321	2.2634	2.2862	1.7147	2.4387	
16	2.5606	2.7435	2.1795	2.2253	2.572	2.21	
17	2.5149	2.1434	2.0957	1.9814	2.1434	2.0576	
19	.2439	.3086	.3018	.2743	.2915	.2896	.3353
20	.2743	.3429	.3353	.2896	.3086	.3201	.3481
21	.3048	.3772	.3647	.3048	.3086	.3201	.3481
22	.3353	.3772	.3688	.3201	.3258	.3048	1.6575
23	.3353	.3772	.3647	.3201	.3429	.3048	1.7101
24		.3353	.3688		.3201	.3429	1.9281
Max	2.6368	3.0864	2.934	2.8197	2.7778	2.7092	2.2862
Min	.2439	.3048	.3018	.2743	.2915	.2896	.3048
Avg	.9445	1.2198	1.1326	1.1133	1.0751	1.0441	.7480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 203 / KHANDOBA WASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.1981	.2058	.1943	.1677	.2058	.1524
2	.1966	.1981	.2058	.1943	.1677	.1886	.1524
3	.213	.1981	.2229	.2105	.1677	.1886	.1677
4	.213	.1829	.2229	.2105	.1524	.2058	.1677
5	.2294	.1829	.2401	.2429	.1524	.2229	.1677
6	.2294	.1829	.2401	.2915	.2591	.2229	.1981
7	.2458	.2134	.2572	.2949	.2286	.2572	.2286
8	.1966	.2134	.2058	.2105	.1981	.2229	.1981
10	1.3435	1.5851	1.7814	1.2597	1.4022	1.8861	1.5851
11	1.829	1.9719	1.7166	1.5546	1.749		
12	1.7375	2.0748	1.8785	1.7375	1.2003		
13	1.9052	2.0576	1.7328	1.6461	1.2346		
14	1.829	2.0233	1.749	1.5242			
15	1.7375	1.9547	1.8679	1.4022		1.8595	
16	1.5851	1.8519	1.7814	1.2803	1.4575	1.7375	
17	1.4175	1.989	1.6194	1.1888	1.7833	1.6613	
19	.2134	.1372	.2294	.1981	.2229		.2321
20	.2439	.1886	.1966	.1829	.2572	.1981	.1638
21	.2439	.1715	.1802	.1524	.2058	.1524	.1658
22	.2134	.1886	.213	.1524	.2058	.1524	1.1498
23	.2134	.2058	.1966	.1524	.2058	.1524	1.166
24	.1524	.2134	.1966		.1677	.2058	1.21
Max	1.9052	2.0748	1.8785	1.7375	1.7833	1.8861	1.5851
Min	.1524	.1372	.1802	.1524	.1524	.1524	.1524
Avg	.7448	.8265	.7791	.6800	.5793	.5718	.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 204 / 11KV KACHAREWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.1158	.2915	.2818	.1189	.2915	.1341
2	.2652	.1174	.2915	.2818	.1219	.2915	.1372
3	.2818	.1219	.2915	.2818	.125	.3086	.1387
4	.2984	.125	.3086	.2984	.128	.3086	.1417
5	.2984	.128	.3429	.3315	.1326	.3258	.1448
6	.3647	.1478	.3601	.3315	.1417	.3772	.1494
7	.3315	.1463	.3772	.3481	.1463	.3772	.1463
8	.3315	.1326	.2915	.2818	.1448	.3429	.1387
9	.3018	.1235	.2401	.2683	.1326	.2743	.1326
10	.2515	.1158	.1989	.1823	.125	.2058	.0991
11	.0975	.1886	.1492		.1372	.0914	.2012
12	.0914	.1543	.1326		.1372	.0869	.1844
13	.0869	.1543	.116		.1372	.0793	.1509
14	.0808	.1543	.116	.061			.1341
15	.0762	.1372	.0995	.0564		.0655	.1174
16	.0716	.1543	.1326	.0549	.12	.0716	.1174
17	.0686	.1886	.1326		.1715	.0808	.1341
18	.0716	.2229	.1509	.0716	.2058	.093	
19	.0884	.3258	.3149	.1021	.3258		.2818
20	.0945	.3086	.2984	.1067	.2915	.1235	.285
21	.1021	.2743	.2652	.1097	.2572	.1265	.2652
22	.1067	.2915	.2652	.1143	.2572	.1296	.2818
23	.1097	.2915	.2622	.1158	.2743	.1311	.2785
24		.1128	.2818		.1174	.2743	.2652
Max	.3647	.3258	.3772	.3481	.3258	.3772	.285
Min	.0686	.1128	.0995	.0549	.1174	.0655	.0991
Avg	.1798	.1764	.2380	.1937	.1704	.2026	.1765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 205 / KAMALMALA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.768	2.1948	2.0729	2.0424	2.3663	1.9509
2	1.4575	1.9052	2.2462	2.1052	2.1033	2.4006	2.0729
3	1.5384	2.0424	2.3148	2.0729	2.1491	2.4348	2.2558
4	1.5384	2.1338	2.3834	2.1052	2.1948	2.4177	2.3472
5	1.6194	2.2558	2.4863	2.1214	2.2253	2.5034	2.4387
6	1.8842	2.3777	2.5034	2.1052	2.2862	2.5549	2.5606
7	2.17	2.5301	2.5377	2.4291	2.3472	2.6235	2.6216
8	2.7206	.3201	.3601	.2949	.2286	.3086	.2743
9	2.13						
19	.3048	.3944	.3563	.3048	.3429	.3201	.3239
20	.3353	.3601	.3401	.2896	.3601	.3506	.3401
21	.3658		.3239	.2743	.3086	.3201	.3605
22	1.3565	1.9547	1.9757	1.9052	1.9719	1.7985	.2949
23	1.4632	2.1262	2.0081	1.9509	2.2634	1.829	.3077
24	1.186	1.6156	2.0243		1.9814	2.3148	.2915
Max	2.7206	2.5301	2.5377	2.4291	2.3472	2.6235	2.6216
Min	.3048	.3201	.3239	.2743	.2286	.3086	.2743
Avg	1.4352	1.6757	1.7182	1.5409	1.6289	1.7531	1.3172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 206 / TIRWANDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.2591	.3429	.3277	.3048	.3429	.2896
2	.3441	.2591	.3429	.3277	.2896	.3429	.2743
3	.3647	.2591	.3429	.3277	.2896	.3429	.2743
4	.3605	.2591	.3601	.3441	.2896	.3429	.2743
5	.3932	.2591	.3772	.3768	.2896	.3429	.3048
6		.3048	.3772	.426	.3658	.3601	.3201
7	.3647	.3658	.4115	.3812	.3201	.3601	.3658
8	.2785	.2896	.3258	.2785	.2743	.3086	.2743
10	1.0059	.9297	1.2289	1.065	.823	1.166	1.1279
11	1.2193	1.2003	1.1797	1.0364	1.0117	1.0364	
12	1.1736	1.2174	1.278	1.0669	1.0974	.945	
13	1.2651	1.1831	1.3108	1.0974	1.1145	.884	
14	1.2193	1.166	1.1469		1.0974		
15	1.1584	1.0802	1.0774	1.0059	.823	.5487	
16	1.0669	.9945	1.0486	.9145	1.0802		
17	.9145	.9945	.9995	.7621		.7621	
19	.2896	.2743	.2949	.2743	.2915	.2286	.2949
20	.2896	.2743	.2652	.2591	.3258	.2591	.3149
21	.3048	.2915	.2785	.2439	.2915	.2591	.2949
22	.2743	.3086	.3113	.2896	.3086	.2896	.6882
23	.2743	.3429	.3277	.2896	.3429	.2896	.7045
24		.2743	.3277		.3048	.3429	.7701
Max	1.2651	1.2174	1.3108	1.0974	1.1145	1.166	1.1279
Min	.2743	.2591	.2652	.2439	.2743	.2286	.2743
Avg	.6445	.5812	.6343	.5547	.5398	.4877	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 201 / 11KV LAXMINAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	1.5998	1.2689	1.1431	1.2346	1.1431	1.9978
2	.8688	1.6531	1.2689	1.1431	1.3413	1.1431	1.8347
3	.8688	1.7242	1.2689	1.1431	1.3717	1.1584	1.8347
4	.8993	1.7776	1.3032	1.1736	1.448	1.1888	1.8519
5	.945	1.9553	1.3889	1.2041	1.5242	1.326	1.8861
6	1.0974	2.0086	1.5604	1.4022	1.6004	1.5089	1.8861
7	1.5242	2.0442	1.869	1.6461	1.6461	1.6613	2.2291
8	.3506	.3733	.3086	.2896	.3048	.3201	.3772
9	.2844		.2286	.2666	.2439	.2743	.2844
10	.2311	.1886	.1829	.2311	.1829	.2401	.2311
11	.1778	.1867	.1524	.1955	.1524	.1715	
12	.1422	.1543	.1219	.1778	.1524	.1715	
13	.16	.1543	.1219	.1422	.1219	.1372	
14	.1778	.1543	.1067	.1422	.1219	.1543	
15	.1955	.1867	.1067	.16	.1219	.1715	
16	.2133	.1715	.1219	.16	.1372	.1715	
17	.2311	.1715	.1524	.1422	.1372	.1886	
18	.2489	.1886	.1981	.1778	.2134	.2401	.2844
19	.2844	.2401	.3201	.2133	.2896	.3601	.32
20	.32	.3258	.3048	.2666	.2896	.3601	.3555
21	.3555	.3086	.2743	.3377	.2896	1.8176	.3911
22	1.2621	1.2174	1.0822	1.2443	1.1584	1.6975	.4088
23	1.3332	1.2689	1.1584	1.2976	1.1431	1.8176	.3911
24	.3353	1.4043	1.2689	1.1584	1.1431	1.1431	1.8347
Max	1.5242	2.0442	1.869	1.6461	1.6461	1.8176	2.2291
Min	.1422	.1543	.1067	.1422	.1219	.1372	.2311
Avg	.5567	.8460	.6725	.6441	.6821	.7736	1.0823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 202 / 11KV GIRVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4286	.4973	.5316	.5031	.12	.5658
2	.5144	.4286	.4973	.5316	.4845	.12	.5658
3	.5144	.4472	.4973	.5316	.5031	.12	.5658
4	.5316	.4658	.4973	.5487	.5404	.12	.583
5	.5487	.4845	.5788	.583	.5963	.12	.6001
6	.583	.5031	.5487	.6516	.6149	.1543	.6344
7	.5658	.5217	.4801	.6001	.6521		.6344
8	.4973	.4845	.4458	.4801	.5031	.12	.4973
9	.4099	.3429	.3772	.3913	.3429	.0857	.4845
10	1.7147	1.5947	1.3546	1.5279	1.4918	1.8004	
11	1.9378	1.8519		1.5838	1.4403	2.0748	
12	2.031	1.8347	1.5604	1.677	1.6461	2.1091	
13	2.031	1.8347	1.5947	1.8074	1.6804	1.6975	
14	2.0496	1.7318	1.5775	1.5838		1.8176	
15	2.0869	1.6461	1.5775	1.472	1.8861	1.9204	
16	2.0869	1.5947	1.5432	1.2111	1.869	1.7147	
17	2.1055	1.5089	1.6118	1.118		1.9033	
18	.3354	.3258	.3086	.4286	.3258	.463	.4845
19	.4099	.3772	.463	.4845		.6001	.559
20	.4658	.4801	.463	.5404		.6001	.6521
21	.5031	.4973	.4801	.5963	.12	.5487	.6335
22	.4954	.4973	.5144	.4904	.12	.5658	2.1055
23	.4444	.4973	.5316	.5404	.12	.5658	2.1428
24	.5316	.4472	.4973	.5316	.5404	.12	.5658
Max	2.1055	1.8519	1.6118	1.8074	1.8861	2.1091	2.1428
Min	.3354	.3258	.3086	.3913	.12	.0857	.4845
Avg	.9962	.8678	.8042	.8518	.7990	.8461	.7671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 203 / 11KV MANDAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.801	.8916	.9088	.801	.8916	.9088
2	.8745	.7846	.8916	.9088	.7683	.9088	.9896
3	.8916	.7683	.8916	.9259	.7519	.9088	.9088
4	.9259	.8173	1.0117	.9431	.801	.9431	1.0082
5	1.0117	.9645	1.0117	.9945	.9318	1.0631	1.0974
6	1.1488	1.1116	1.166	1.2174	1.177	1.166	1.2003
7	1.166	1.0952	1.166	1.2003	1.1116	1.1145	1.1488
8	1.0117	1.0135	.9945	1.1488	1.0298	1.1317	.9774
9	.8664	.9259	.9774	.9154	.9431	.9431	.8664
10	.801	.8745	.7716	.8173	.8573	.8573	.801
11	.7356	.8573	.703	.7519	.703	.7202	.7356
12	.6866	.8059	.6859	.6866	.7202		.7029
13	.7029	.6687	.6687	.5885	.6344	1.2003	.6702
14	.8198	.6344	.6001	.6048	.6001	.6173	.6375
15	.7519	.6173	.583	.6375	.583	.5487	.6212
16	.7683	.6001	.583	.6539	.583	.6001	.6212
17	.7846	.7202	.7373	.6702	.6687	.6344	.6048
18	.8173	.8402	.823	.8173	.8916	.7888	.7356
19	.8991	.9431	1.046	.8991	1.1317	1.1145	.9318
20	.9645	1.046	1.0288	1.0462	1.1488	1.166	1.1116
21	.9481	.9774	.9945	1.0135	1.0631	1.0974	1.0625
22	.8991	.9774	.9774	.9481	.9602	1.1203	1.0135
23	.8827	.8916	.9259	.8991	.9259	1.0642	.9808
24	.8916	.8173	.8916	.9088	.8173	.8916	.9896
Max	1.166	1.1116	1.166	1.2174	1.177	1.2003	1.2003
Min	.6866	.6001	.583	.5885	.583	.5487	.6048
Avg	.8795	.8564	.8759	.8794	.8585	.9344	.8886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 204 / 11KV AHILYANAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7337	2.2672	1.869	2.0919	2.191	2.3815	2.1091
2	1.7718	2.3815	1.869	2.3243	2.3815	2.3815	2.1091
3	1.7909	2.4577	1.9033	2.3243	2.5149	2.3815	2.1091
4	1.848	2.572	1.9376	2.3434	2.6673	2.4196	2.1434
5	2.0767	2.6673	2.0576	2.3815	2.8197	2.4768	2.2291
6	2.3434	2.8959	2.2977	2.7244	2.9531	2.8387	2.4006
7	2.915	2.9912	2.4691	2.915	3.0293	3.2579	3.0434
8	.6668	.5335	.5041	.4954	.4763	.5335	.4801
9	.6287	.3944	.3772	.381	.4001	.4294	.5335
10	.2667	.3086	.362	.362	.4001	.3258	.4001
11	.3239	.2743	.2667	.3429	.3429	.3086	
12	.2667	.2801	.2667	.3239	.3048	.2915	
13	.2858	.2572	.3048	.3048	.3048	.3086	
14	.3239	.2572	.3048	.3239	.3429	.2915	
15	.362	.2401	.2858	.3239	.3048	.2915	
16	.381	.2401	.3048	.3048	.3048	.3174	
17	.4001	.2401	.3429	.2858	.2858	.3086	
18	.4382	.2915	.2858	.362	.3239	.3429	.4191
19	.4763	.3772	.4954	.381	.5144	.5144	.4763
20	.4954	.4801	.5335	.4382	.5144	.5316	.5144
21	.5144	.463	.5335	.5335	.5335	.5316	.5716
22	2.0386	1.8176	2.2862	2.0386	2.1529	1.989	.6287
23	2.0957	2.0351	2.3053	2.0957	2.3815	2.1091	.6097
24	.5716	2.1148	2.0351	2.3243	2.1529	2.4006	2.1091
Max	2.915	2.9912	2.4691	2.915	3.0293	3.2579	3.0434
Min	.2667	.2401	.2667	.2858	.2858	.2915	.4001
Avg	1.0423	1.2016	1.0916	1.1969	1.2749	1.2485	1.3463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 205 / 11KV PURANDAWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2058	.1905	.2096	.1524	.2058
2	.1905	.1905	.2058	.1905	.2096	.1524	.2058
3	.1905	.2286	.2058	.2096	.2286	.1715	.2058
4	.2286	.2477	.2229	.2286	.2477	.1905	.2614
5	.2858	.2858	.2915	.2667	.2858	.2096	.2743
6	.3239	.3239	.3547	.381	.3239	.2667	.3258
7	.381	.362	.3429	.4001	.362	.3048	.3601
8	.3048		.2915	.3429	.3239	.2477	.3258
9	.2477	.2401	.2858	.3239	.2477	.2054	.3048
10	1.8099	1.5604	1.9433	1.7147	2.0576	1.7924	1.1431
11	2.0386	1.6461	2.1529	1.7528	2.191	1.5947	
12	1.8099	2.0233	2.0195	1.9052	2.0957	1.5261	
13	1.8099	1.989	1.9814	2.0957	2.0576	1.6244	
14	1.7909	1.9204	2.0767	2.0386	1.9433	1.5604	
15	1.7718	2.0538	1.8099	2.0576	1.9243	1.6118	
16	1.8099	2.0351	1.9624	2.0195	2.1148	1.6975	
17	1.848	1.9547	2.0957	2.0005	1.7909	1.7147	
18	.1524	.2058	.2096	.1905	.1905	.2401	.2477
19	.1715	.2229	.3048	.2096	.3048	.3174	.2667
20	.1715	.2401	.2667	.2286	.2286	.3086	.2858
21	.2096	.2401	.2667	.2667	.1715	.2801	.2858
22	.1905	.2058	.2286	.2477	.1715	.2058	1.5623
23	.1715	.2058	.2096	.2477	.1524	.2058	1.6194
24	.2096	.1715	.2058	.2096	.2286	.1524	.2058
Max	2.0386	2.0538	2.1529	2.0957	2.191	1.7924	1.6194
Min	.1524	.1715	.2058	.1905	.1524	.1524	.2058
Avg	.7629	.8150	.8392	.8216	.8359	.6972	.4757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 201 / 11KV DAHIGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3739	1.1145	1.4575	1.4251		.4801	.5365
2	2.3872	1.1145	1.4575	1.4251		.4801	.5365
3	2.572	1.2574	1.5432	1.4413		.4801	.5935
4	2.713	1.3413	1.6289	1.5089		.4801	.6001
5	2.8826	1.4251	1.8004	1.6108		.4801	.5935
6	3.0521	1.6956	2.0576	1.7604		.5144	.5365
7	3.3913	2.2291	2.0233	2.3472			
8	.8002	.4239	.4801	.4748		.503	.4801
9	.746	.4115	.3258	.4115		.2683	.3429
10		.3429	.2572	.2572		2.0957	1.8861
11			.1677	.2572	2.3834	2.2131	2.0576
12	.2229		.1677	.2229	2.4006	2.2634	1.9204
13	.2572		.1677		2.4006	2.2891	1.6289
14	.2572		.1677		2.4177	2.0348	1.6289
15		.2572	.1844	.2572	2.0233	1.8861	1.4918
16		.2915	.218		1.8861	1.8861	1.3375
17	.3544	.3086	.3429		1.8004	1.5089	1.286
18	.4694	.4115	.3856		.4458	.3429	.3429
19	.4694	.4801	.5487		.5487	.4694	.4287
20	.503	.5487	.6001		.583	.4458	.4973
21	.5087	.5144	.6001		.5487	.5487	.5144
22	1.2574	1.4575	1.4918		.4801	.503	1.1317
23	1.2717	1.5432	1.5089		.4801	.5487	1.2003
24	2.229	1.2574	1.5432	1.5089		.4801	.5365
Max	3.3913	2.2291	2.0576	2.3472	2.4177	2.2891	2.0576
Min	.2229	.2572	.1677	.2229	.4458	.2683	.3429
Avg	1.4359	.9213	.8803	1.0649	1.4153	1.0088	.9612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 202 / 11KV KALAMBOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3642	.6203	.6859	.6706	3.0007	2.3148	
2	1.3642	.6203	.703	.6706	3.0007	2.3148	.0136
3	1.3642	.5647	.7202	.6706	2.915	2.4006	2.0957
4	1.3565	.6241	.7373	.7373	3.0521	2.4863	2.0243
5	1.3642	.7545	.7888	.7545	3.0007	2.572	2.0957
6	1.5261	.8383	.823	.8718	3.0007	2.7435	2.2043
7	1.6028				3.4294	3.0864	2.6825
8	1.3565	.5868		.7545	.6516	.3353	.6001
9	4.5357	2.4006	2.4006	2.3148	.6001	.4694	.4748
10	2.5149	2.4006	3.0864	2.915	.463	.3688	.4287
11	2.7978	3.0864	2.5434	3.1722	.4287	.3018	.3429
12	2.713	2.915	2.8502	3.1722	.5144	.4024	.4287
13		2.8292	3.1855	3.0007	.5144	.3688	.4287
14	3.1722	2.7949	2.5263	2.6578	.5144	.407	
15	3.2217	2.7435	2.7978	2.572	.5144	.4024	.3944
16	3.1855	2.7435	2.8502		.5144	.3772	.4287
17	2.6749	3.0007	2.7435		.5487	.4287	.5144
18	2.8826	2.5892	2.713		.7888	.4801	.5144
19	.5053	.5658	.6516	.6859	.823	.6706	.6001
20	.6706		.7202	.6859	.7545	.5944	.6001
21	.6706	.7202	.7716	.6859	.7202	.6371	.6516
22	.6371	.7202	.7373	3.0007	2.0576	2.1795	.6516
23	.6274	.6859	.7042	3.1207	2.1434	2.2634	.6687
24	1.3642	.6203	.6859	.6874	3.0864	2.2291	2.2634
Max	4.5357	3.0864	3.1855	3.1722	3.4294	3.0864	2.6825
Min	.5053	.5647	.6516	.6706	.4287	.3018	.0136
Avg	1.8901	1.6102	1.6557	1.6901	1.5432	1.2848	.9594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 203 / 11KV SHINDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3521	.3772	.3688	2.572	2.4863	2.5149
2	.4115	.3121	.4115	.3688	2.6578	2.572	2.3739
3	.4115	.3269	.4115	.3856	2.7435	2.6578	2.3472
4	.4115	.3521	.4458	.4024	2.8292	2.7435	2.3472
5	.4115	.4012	.4801	.4191	2.915	3.0007	2.3472
6	.5144	.4458	.5487	.5365	2.915	3.4294	2.6825
7	.5487				3.1893	3.738	2.934
8	.6173			.4191	.463	.3688	.4801
9	.3429			.3086	.3772	.3521	.3391
10	2.8826	2.7435		3.1722	.2572	.208	.2915
11	2.8235	3.1722	3.4294	3.4465	.2572	.2012	.2229
12	2.8826	3.3779	3.5608	3.5322	.2572	.1677	.2401
13	3.6008	3.5322	3.476	3.2236	.2229	.1677	.2401
14	3.4294	3.4294	3.437	3.1722	.2229	.1677	.2229
15	3.476	3.3436	3.437	3.0864	.2401		.2058
16	3.2217	3.2579	3.1855		.2401		.1715
17	3.0521	3.2236	3.2579		.2743	.2012	.2915
18	.2683	.3944	.2883		.3086	.2515	.4287
19	.4024	.4287	.4287	.4458	.3772	.5087	.4458
20	.4239	.4458	.463	.4458	.3772	.5087	.463
21	.4239	.463	.463	.463	.3772	.4239	.463
22	.3688	.4801	.4115	2.4006	2.2291	2.3472	.4287
23	.3521	.4458	.3688	2.4863	2.4006	2.6282	.4287
24	1.8442	.3521	.3772	.3688	2.5377	2.4006	2.5987
Max	3.6008	3.5322	3.5608	3.5322	3.1893	3.738	2.934
Min	.2683	.3121	.2883	.3086	.2229	.1677	.1715
Avg	1.3972	1.4895	1.4629	1.4726	1.3017	1.4332	1.0629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 204 / 11KV SHERIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5175	.9221	1.2003	1.1736	.3601	.3772	.3772
2	1.7051	.9221	1.286	1.1736	.3772	.3772	.3688
3	1.6956	.9221	1.3717	1.1736	.4287	.3772	.39
4	2.5577	1.0059	1.3717	1.1003	.4287	.3772	.4191
5	2.5577	1.1736	1.5432	1.3413	.4801	.4115	.5087
6	2.7282	1.5089	1.8519	1.6766	.5144	.4801	.5087
7	2.8826	2.0119	1.9719	1.9281	.4458		
8	.682	.4191	.4287	.3567	.3944	.4359	.4801
9	.6104	.4115	.3772	.3429	.3772	.4191	
10	.2543	.3429	.2743	.2915	3.7722	1.8442	2.1434
11	.2347		.1677	.2058	2.0747	2.0119	2.1434
12				.1715	3.6008	2.0687	
13					3.4294	2.0957	1.8861
14					3.0864	1.6766	1.8861
15				.2229	3.0864	1.6956	1.8004
16	.218	.2743	.1677		3.0864	1.6956	1.749
17	.2229	.3258	.2572		2.7434	1.4575	1.4575
18	.3391	.4481	.3688		.4115	.3688	.3601
19	.4287	.5228	.4801	.4458	.4801	.5426	.4115
20	.463	.4801	.5144	.4458	.4801	.5144	.4287
21	.3715	.4801	.4801	.4801	.4458	.4748	.4287
22	.9724	1.1145	1.2346	.4973	.4115	.4458	1.3375
23	.9724	1.166	1.2346	.3772	.3772	.407	1.3032
24	2.0119	.9724	1.2003	1.1736	.3601	.3772	.3688
Max	2.8826	2.0119	1.9719	1.9281	3.7722	2.0957	2.1434
Min	.218	.2743	.1677	.1715	.3601	.3688	.3601
Avg	1.1713	.8118	.8891	.7673	1.3189	.9101	.9884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 205 / 11KV DAHIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7051	.8383	1.0269	.9221	1.1203	1.0288	.9431
2	1.6956	.8383	1.0269	.9221	1.1203	1.0288	.9326
3	1.7051	.9221	1.0269	.9431	1.1203	1.0288	.9431
4	2.0576	1.0059	1.2136	1.0174	1.2136	1.0288	1.0288
5	2.0462	1.2003	1.4003	1.2003	1.307	1.0288	1.1869
6	2.3739	1.2574	1.4003	1.3717	1.4563	1.2003	1.3565
7	2.713	1.1869	1.307	1.3289		1.3717	
8	2.0462	.9659		1.1393	1.0269	1.0059	1.0288
9	1.7042	.9774	1.0269	.9431	.5601	.8383	.8573
10	.6706	.9088	.8402	.7716	.4287	.7716	.8573
11	.5944	.8775	.5868	.8402	.6001	.6706	.8402
12	.0686	.8402	.3391	.7468	.5144	.5868	.6535
13	.6859	.7468	.3391	.6535	.5144	.503	.6535
14	.6001	.4108	.5144	.6535	.4287	.5087	.4668
15	.5087	.4108	.503	.7468	.5144	.5087	.5601
16	.5258	.6535	.5144		.5144	.5087	.5601
17	.6001	.6535	.6001		.6859	.6859	.5601
18	.7545	.7468	.763		1.0288	.7716	.9335
19	1.0288	1.2136	1.0288	1.2136	1.286	1.1145	1.2136
20	1.1022	1.2136	1.1145	1.307	1.286	1.1401	1.307
21	1.1022	1.2136	1.1145	1.307	1.2003	1.1401	1.2136
22	1.0174	1.2136	1.0631	1.2136	1.0288	1.073	1.2136
23	.9326	1.1203	.9431	1.1203	1.0288	1.0059	1.1203
24	1.7051	.8383	1.0269	.9221	1.1203	1.0288	1.0288
Max	2.713	1.2574	1.4003	1.3717	1.4563	1.3717	1.3565
Min	.0686	.4108	.3391	.6535	.4287	.503	.4668
Avg	1.2477	.9273	.9009	1.0135	.9176	.8991	.9330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 206 / 11KV EXPRESS SHIVPRASAD NON SHEDDABLE EXPRESS HV FEEDERS
 MILK Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1017	.0747	.1174	.0747	.1029	.1017
2	.1372	.0838	.0747	.1174	.0747	.1029	.1017
3	.1372	.0848	.0934	.1174	.0747	.1029	.1006
4	.1372	.0838	.0934	.104	.0934	.1029	.1017
5	.1372	.0848	.112	.1189	.0934	.1029	.1017
6	.1372	.0892	.168	.1027	.1307	.1029	.1017
7	.1372	.1006	.1494	.1006	.1307	.1372	.1029
8	.1372	.1006	.1494	.1187	.1494	.1677	.0857
9	.1372	.1372	.1494	.12	.1307	.1844	.12
10	.104	.1372	.1307	.12	.12	.218	.1372
11	.3018	.2614	.3018	.1494	.1886	.2515	.1307
12	.2743	.2054	.2515	.2054	.1886	.2572	.1494
13	.2572	.1494	.2012	.1307	.12	.2012	.1494
14	.2572	.1494	.2012	.1307	.12	.1341	.1494
15	.1677	.112	.1187	.1494	.1029	.1357	.1307
16	.1189	.1494	.1187		.1029	.1357	.112
17	.1696	.1307	.12		.1029	.1174	.1307
18	.1696	.112	.1174		.1029	.1006	.1494
19	.1677	.1494	.12	.168	.1543	.2035	.168
20	.1865	.1494	.12	.168	.1543	.1715	.1867
21	.1844	.1494	.12	.168	.1029	.1341	.1867
22	.2229	.1494	.2058	.168	.1029	.1372	.2241
23	.1341	.1494	.1357	.0747	.1029	.1357	.1307
24	.1715	.1341	.0747	.1341	.0747	.1029	.12
Max	.3018	.2614	.3018	.2054	.1886	.2572	.2241
Min	.104	.0838	.0747	.0747	.0747	.1006	.0857
Avg	.1710	.1314	.1417	.1325	.1164	.1476	.1322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 207 / 11 KV PIRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.5426	.7716	.6706	.2401	.2401	.2347
2	1.0231	.5365	.8573	.6706	.2401	.2401	.2374
3	1.5261	.5365	.9431	.6706	.2572	.2401	.2347
4	1.4403	.5868	1.0288	.7545	.2743	.2401	.2515
5	1.6956	.6706	1.0288	.8383	.2915	.2401	.2883
6	1.5908	.8718	1.3032	1.0059	.3258	.2401	.3052
7	1.8313	1.1145	1.286	1.2717		.2572	.3018
8	.463	.2374	.2229	.2515	.2401	.218	.2572
9	.407	.2058	.1715	.1715	.2401	.1844	.3086
10	.1677	.1715	.1372	.1372	1.0288	.9221	.9431
11	.1509		.1006	.1029	1.1145	1.0395	1.0288
12	.1187			.0857	1.0288	.9431	.8745
13					1.0288	.9326	.7202
14					.8916	.8383	.6859
15	.1017			.1029	.8573	.8139	.6173
16	.104	.1372	.0983		.8573	.7545	.6344
17	.1696	.1372	.1543		.8059	.6706	.6344
18	.1486	.1372	.2012		.2915	.1715	.2058
19	.2515	.2401	.3086	.2058	.2915	.2713	.2058
20	.2572	.2401	.2915	.2058	.3086	.2515	.2401
21	.2543	.2401	.2743	.2058	.2915	.2572	.2401
22	.5533	.6173	.6859	.2743	.2743	.2543	.4801
23	.5533	.6859	.6706	.2743	.2401	.2374	.5144
24	1.0231	.5533	.6859	.6706	.2401	.2401	.2347
Max	1.8313	1.1145	1.3032	1.2717	1.1145	1.0395	1.0288
Min	.1017	.1372	.0983	.0857	.2401	.1715	.2058
Avg	.6723	.4454	.5611	.4511	.5069	.4458	.4450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 201 / 11KV DHARMपुरI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5034	1.6632	3.395	1.7147	.5658	.6687	.6344
2	2.6064	1.7147	3.7038	1.8004	.6001	.6859	.6344
3	2.7434	1.8004	4.0466	1.8004	.6001	.703	.6344
4	2.8806	1.869	4.3896	1.9033	.6001	.7202	.6859
5	3.0178	1.9719	4.7326	2.2291	.6516	.7373	.7202
6	3.8066	2.1434	5.0754	2.332	.7202	.7373	.7545
7	4.5954	2.7435	5.4184	2.5206	.7888	.7545	.7716
8	.583	.6516	.5487	.6001	.6859	.6859	.6859
9	.5144	.5316	.5144	.6001	.5658	.6173	.6001
10	.4973		.463		2.0405		2.3148
11	.463	.3601	.3944	.4115	2.2977	2.4691	2.3491
12	.5316	.3944	.3772	.3772	2.3834	2.332	2.2291
13	.463	.4458	.4115	.3772	2.2119	2.2462	2.2291
14	.5316	.4458	.3944	.3944	2.1262	2.0062	2.0576
15	.5144	.4287	.3429	.3921	1.9719	1.7147	1.9719
16	.5144	.4973	.3601	.3601	1.9719	2.0576	1.8004
17	.5144	.8916	.4458		2.0748	1.9376	1.6975
18	.3429	.8916	.5144		.4458	.6859	.3429
19	.6859	1.3718	.5658	.6001	.6516	.6859	.4458
20	.6687	1.3203	.6859	.6516	.6344	.6859	.5487
21	.6173	2.2291	.6859	.6344	.6173	.6859	.6516
22	1.5432	3.1379	1.5089	.6173	.6173	.6516	1.5089
23	1.6632	3.1208	1.7147	.6001	.6344	.6344	1.3889
24	2.4577	1.6632	3.0864	1.7147	.5658	.6516	.6344
Max	4.5954	3.1379	5.4184	2.5206	2.3834	2.4691	2.3491
Min	.3429	.3601	.3429	.3601	.4458	.6173	.3429
Avg	1.4692	1.4038	1.8240	1.0777	1.1260	1.1198	1.1788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 202 / 11KV NATEPUTE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8176	.8573	1.749	.823	.8573	1.166	.8916
2	1.7832	.8573	1.9204	.8573	.8573	1.2003	.8916
3	1.7832	.9259	2.092	.8573	.8573	1.2346	.8916
4	1.749	1.0631	2.2634	1.0631	.9774	1.2689	1.046
5	1.7146	1.1145	2.4348	1.2003	1.0631	1.3032	
6	2.229	1.2003	2.6406	1.2689	1.3375	1.3375	1.2517
7	2.7434	1.3032	2.812	1.3203	1.3717	1.3717	1.4403
8	1.2346	1.2346	1.166	1.2003	1.2003	1.2346	1.2003
9	1.0974	1.1317	1.0631	1.166	1.0974	1.0631	1.0802
10	1.046	1.0974	1.0631		1.0802	1.1488	.9945
11	1.046	1.0631	.9602	1.1949	1.1317	1.1145	1.0117
12	.9945	1.046	.9774	1.1203	1.0631	1.0802	1.0631
13	.9945	.9945	1.0802	1.046	1.0802	1.0117	1.0288
14	.9602	.8916	.9945	1.046	.9945	.9431	1.0288
15	.8916	.8916	1.0117	1.0288	1.0288	1.0802	.9945
16	.9774	.8402		1.1576	1.0117	.9945	.9945
17	.9945	1.9547	1.0117	1.0288	.9602	.9945	.9602
18	.9774	1.9204	1.0288	1.0288	.9602	1.0288	1.2003
19	1.2003	2.4006	1.2346	1.2689	1.3375	1.2517	1.1831
20	1.1317	2.229	1.0974	1.2346	1.2346	1.2003	1.166
21	1.0631	2.0576	1.0288	1.1145	1.1317	1.1831	1.1317
22	.9431	1.989	1.0288	1.0288	1.0974	1.1488	1.1317
23	.8916	1.7832	.9259	.9431	1.1145	.9431	.9945
24	1.8518	.8573	1.5776	.823	.8573	1.1317	.8916
Max	2.7434	2.4006	2.812	1.3203	1.3717	1.3717	1.4403
Min	.8916	.8402	.9259	.823	.8573	.9431	.8916
Avg	1.3382	1.3210	1.4418	1.0792	1.0710	1.1431	1.0638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 203 / 11KV MANDAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4404	1.0288	2.4006	1.2003	.3772	.4115	.3944
2	1.509	1.0288	2.6064	1.2003	.3772	.4287	.3944
3	1.5776	1.166	2.812	1.2003	.4115	.4287	.3944
4	1.646	1.2346	3.0178	1.3032	.4115	.4458	.4287
5	1.7146	1.3717	3.2236	1.6289	.4801	.463	.4287
6	2.2634	1.4918	3.4294	1.749	.5487	.4801	.4801
7	2.812	1.8861	3.6352	1.8347	.5144	.4801	.5144
8	.5144	.463	.4801	.4115	.4287	.4458	.4801
9	.3772	.3601	.3086	.3258	.3429	.3772	.4458
10	.2743	.2915	.2743		1.5261	1.6975	1.6632
11	.2401	.2401	.2229	.2614	1.7318	1.2003	1.6632
12	.2229	.2401	.2058	.2058		1.8347	1.4403
13	.2401	.2229	.2229	.1715	1.5604	1.6975	1.4746
14	.2401	.2058	.1886	.1867	1.5775	1.5261	1.1831
15		.2058	.1886	.2054	1.4403	1.406	1.2517
16	.3086	.2401	.2058	.2427	1.3203	1.4575	1.1488
17	.3258	.5486	.2058	.2229	1.3375	1.3889	1.0288
18	.3429	.6858	.3429	.2401	.2401	.3429	.2743
19	.3944	.823	.3772	.3086	.4458	.3772	.3086
20	.3944	.7888	.3944	.4287	.4287	.3772	.3601
21	.3944	.823	.4115		.4115	.3944	.4115
22	.9431	2.4006	1.0631	.3772	.3772	.3944	.9259
23	.9945	2.2976	1.1317	.3944	.3772		.9088
24	1.3718	1.0288	2.1948	1.1317	.3772	.3944	.3944
Max	2.812	2.4006	3.6352	1.8347	1.7318	1.8347	1.6632
Min	.2229	.2058	.1886	.1715	.2401	.3429	.2743
Avg	.8931	.8781	1.231	.6923	.7410	.8022	.7666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 204 / 11KV LONAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	1.286	2.7778	1.4232	1.2003	1.8347	1.749
2	2.3662	1.286	2.9492	1.4575	1.2003	1.9376	1.8861
3	2.4692	1.3717	3.1208	1.5432	1.2003	2.0405	2.0405
4	2.572	1.5604	3.2922	1.5432	1.3375	2.1434	2.2291
5	2.675	1.6461	3.4636	1.9719	1.6289	2.2462	***
6	3.2578	1.7833	3.6694	2.2291	1.989	2.3491	2.572
7	3.8408	2.0576	3.8408	2.3663	1.8347	2.452	2.6578
8	.7545	.8573	.8573	.6859	.6859	.6859	.7373
9	.6516	.7373	.583	.6859	.6859	.583	.703
10	1.2689	1.6118	1.5604		1.989	1.8347	1.989
11	1.3375		1.7833	1.9044	2.0919	1.9033	2.0748
12	1.7833	2.0405	1.869	1.6118	2.0576		1.8519
13	1.7833	1.9033	1.7833	1.5775	1.989	1.6632	1.5604
14	2.0062	1.5947	1.7318	1.4918		1.6118	1.3717
15		1.7661	1.6118	1.6991		1.406	1.4232
16	1.6118	1.5604	1.5089	1.4918	1.3717	1.4918	1.0117
17	1.4918	2.9492	1.4746	1.3203	1.6632	1.5775	1.2003
18	.5316	1.0288	.6859	.4973	.4801	.823	.4458
19	.7545	1.646	.7888	.8745	.8573	.7716	.583
20	.8059	1.6118	.8059	.8573	.8745	.6859	.7202
21	.7888	1.5776	.823	.823	.8916	.6516	.8573
22	1.2003	1.2003	1.3717	1.1317	1.5775	1.7661	1.3032
23	1.2689	2.5034	1.406	1.166	1.6632	1.7661	1.286
24	2.4215	1.286	2.6064	1.4232	1.166	1.749	1.749
Max	3.8408	2.9492	3.8408	2.3663	2.0919	2.452	79.9212
Min	.5316	.7373	.583	.4973	.4801	.583	.4458
Avg	1.7350	1.6029	1.9319	1.3816	1.3834	1.5641	4.7468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 205 / 11KV PHADATARI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.2572	.583	.2743	.2915	.3601	.3086
2	.7544	.2572	.6172	.2743	.2915	.3772	.3086
3	.7544	.3086	.6516	.3086	.3086	.3772	.3086
4	.7888	.3429	.6858	.3429	.3086	.3944	.3429
5	.823	.4287	.7202	.3429	.3429	.3944	.3429
6	.7888	.4801	.7888	.3944	.4115	.4115	.3944
7	.823	.4115	.823	.4287	.3601	.4115	.4287
8	.3429	.3429	.2743	.3429	.2572	.3086	.3429
9	.2743		.2401	.2572	.1543	.2401	.2401
10	.2058		.2058		.1029	.1886	.2058
11	.1715		.1543	.2054	.0686	.1886	.1543
12	.1372	.2058	.12	.1715	.12	.1543	.12
13	.1715	.1715	.1372	.1715	.1029		.1029
14	.1372	.1715	.1372	.1886	.0857	.1372	.1029
15	.1715	.1886	.1372	.1886	.12	.1543	.12
16	.1715	.2058	.1372	.1715	.1029	.1543	.12
17	.1715	.3772	.1372		.1029	.12	.1372
18	.2058	.4116	.2401	.2058	.2058	.2229	.1372
19	.3258	.6858	.3086	.3086	.3429	.3258	.2058
20	.3772	.6516	.3772	.3944	.3258	.3429	.2743
21	.3429	.6172	.3086	.3429	.3086	.3772	.3429
22	.3086	.6172	.2915	.3429	.3086	.3258	.3086
23	.2743	.583	.2915	.3086	.3258	.3086	.2915
24	.6858	.2572	.5486	.2743	.2915	.3429	.3086
Max	.823	.6858	.823	.4287	.4115	.4115	.4287
Min	.1372	.1715	.12	.1715	.0686	.12	.1029
Avg	.4137	.3797	.3715	.2837	.2350	.2878	.2479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDHIRAS S/STN

Feeder No / Name : 201 / 11KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9448	1.6617	.5788	1.5927	.4862	.5765	.57
2	2.0119	1.6766	1.5927	1.6766	.4694	.6348	.5533
3	2.0243	1.6956	1.8671	1.8652	.4748	.6268	.5365
4	2.146	1.7804	2.1434	2.0119	.503	.6468	.5533
5	2.1795	2.0348	2.3148	2.3472	.5407	.6535	.57
6	2.2634	2.4813	2.572	2.6825	.5365	.6908	.5868
7	2.2801	2.753	2.8292	2.8664	.5407	.6908	.583
8	2.4143	2.672	2.713	2.8826	.421		
9				2.8502	2.7368	2.713	2.7664
10	.3185	.2591	.3258	.3018	3.0769	3.4541	2.2969
11	.2915	.3086	.3185	.2753	2.915	3.0178	2.3482
12	.2915	.3086	.2915	.2591	2.915	2.934	2.4291
13		.3077	.2543	.2753	2.753	2.8502	2.4291
14		.2683	.2683	.2591	2.915	2.6825	2.4291
15	.2753		.2915		2.915	2.5149	2.4615
16	.3239	.2915	.3185		3.0007	2.431	2.5749
17	.3563	.3258	.3521		.2883	.2683	.2753
18	.3563	.3814	.4359		.4801	.3353	.3725
19	.4858	.4481	.4694	.4858	.5316	.4024	.4858
20	.4534	.4191	.4858	.4534	.5533	.503	.4858
21	.4694	.4973	.503	.4915	.57	.503	.4534
22	.5365	.5415	.5197	.5243	.5765	.503	.4858
23	.5087	.5601	.5533	.5197	.5426	.4858	.4858
24	1.9281	.5087	.5256	.5596	.503	.5975	.4862
Max	2.4143	2.753	2.8292	2.8826	3.0769	3.4541	2.7664
Min	.2753	.2591	.2543	.2591	.2883	.2683	.2753
Avg	1.1362	1.0082	.9793	1.2590	1.3019	1.3355	1.1834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 203 / 11KV PALASMANDAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4748	.4191	.4049	.8383	.905	.8583
2	.421	.4694	.426	.3887	.8048	.905	1.0059
3	.4527	.4527	.4694	.3856	.8048	.985	1.0526
4	.4862	.4748	.4801	.4024	.7545	.9745	1.1736
5	.503	.4862	.5228	.4359	.7287	1.1393	1.3413
6	.5197	.4973	.4287	.4862	1.0395	1.2407	1.4251
7	.5365	.4858	.4115	.5365	1.1469	1.5061	1.4251
8					1.1012	1.2136	1.0059
9	2.431	2.3807	2.9874	2.431	.2915		
10	2.7664	2.5911	2.915	2.5987	.2591	.3052	.3018
11	2.834	2.7664	2.6825	2.5101	.2429	.285	.2915
12	2.753	3.1741	2.5101	2.5101	.2429	.2683	.3239
13		2.9235	2.431	2.3805	.2429	.285	.3239
14		2.5149	2.3482	2.2996	.2572	.3018	.3239
15	2.5911	2.431	2.3739		.2401	.285	.3239
16	2.5425	2.572	2.2634		.2713	.2683	.2915
17	1.2955	1.4937	1.3413		2.3472	2.8502	2.7854
18	1.2146	1.2717	1.3413		2.6282	2.753	2.915
19	1.2793	1.4003	1.1736	1.1336	3.1741	2.5911	2.6882
20	1.0898	1.1869	1.0898	1.1336	2.7978	2.5149	
21	.9717	1.1869	1.0898	1.065	2.4587	2.5149	2.2672
22	1.0059	1.1145	1.0082	.9831	2.3739	2.3472	2.1052
23	.9835	1.0288	1.0059	.9717	2.1795	2.1795	2.1052
24	.4024	.7287	1.0288	.9717	.8383	2.1672	2.0119
Max	2.834	3.1741	2.9874	2.5987	3.1741	2.8502	2.915
Min	.4024	.4527	.4115	.3856	.2401	.2683	.2915
Avg	1.3095	1.4829	1.4238	1.2647	1.1693	1.3385	1.2885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 204 / 11KV FONDSHIRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.6874	.6952	.7712	.7712	.7095	.6539
2	.7712	.6962	.8059	.7773	.7865	.7468	.7042
3	.8048	.7545	.8478	.8383	.8097	.8775	.7712
4	.8097	.8383	.9431	.8886	.8745	.9522	.8383
5	.9221	.9054	1.0269	.9221	.9717	1.0082	.9221
6	1.0059	.9779	1.0117	.9326	.8029	1.0208	.9393
7	1.0059	.9995	1.0829	.9054	.6964	.9313	1.0059
8	.8383	.8907	.8573	.8383	.5992	.8139	.8718
9	.7209	.7537	.6613	.7042	.502	.6613	.6203
10	.788	.6964	.5765	.6371	.4534	.4748	.5868
11	.5506	.6443	.5182	.6154	.5079	.4858	.421
12	.5506	.4458	.503	.3887	.5182	.5365	.4372
13		.5415	.4694	.421	.4049	.4359	.3887
14		.4287	.4359	.3725	.3353	.3521	.3887
15	.5182	.3856	.4049		.3258	.4359	.3725
16	.5344	.2883	.3887		.4801	.4372	
17	.5344	.5415	.4862		.5228	.4191	.4534
18	.5344	.6104	.5868		.6535	.5365	.6154
19	.7343	.8402	.7712	.8907	.8962	.8048	.9231
20	.9221	.8907	.9556	.9393	.9389	.9389	
21	.7611	.8478	.9221	.8029	.9536	.9221	.8259
22	.7712	.7888	.9054	.7449	.8764	.7621	.8097
23	.763	.7888	.8383	.7712	.8505	.7209	.8097
24	.6706	.6613	.6344	.7209	.7287	.7619	.6478
Max	1.0059	.9995	1.0829	.9393	.9717	1.0208	1.0059
Min	.5182	.2883	.3887	.3725	.3258	.3521	.3725
Avg	.7371	.7043	.7220	.7441	.6775	.6978	.6821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 205 / 11KV TAMSHIDWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.4458	.4748	.4534	.4359	.4359	.4191
2	.3222	.4527	.4801	.4372		.4917	.4024
3	.3688	.4694	.4973	.2774		.5256	.3856
4	.4024	.4862	.4973	.3887		.5256	.4359
5	.4534	.503	.5068	.4359	.3768	.5087	.4527
6	.4862	.5243	.4917	.4534	.5571	.503	.4527
7	.4862	.4588	.4801	.4694	.4858	.5601	.4527
8					.3401		
9	3.0849	2.753	2.9504	2.8669	.2915		
10	2.915	2.8016	2.915	2.753	.2591	.3222	.2515
11	2.753	2.8487	2.7664	2.5911	.2105	.2591	.2105
12	2.753	2.7978	2.4387	2.4615	.1781	.218	.2267
13		2.8121	2.649	2.3805	.1943	.2347	.1943
14		2.8121	2.5987	2.1538	.2058	.2515	.1943
15	2.4777	2.7778	2.5149		.2328	.2267	.1943
16	2.5587	2.6621	2.4813		.2204	.218	1.1012
17		.2035	.218		2.696	2.9005	2.915
18	.2105	.3086	.2347		2.8995	2.7664	.3725
19	.3563	.4481	.2515	.4372	2.6791	2.431	2.3482
20	.3605	.407	.3856	.3887	2.8487	2.2298	
21	.3856	.4287	.3887	.3768	2.5604	2.0119	2.1538
22	.4024	.4239	.4359	.426	2.5095	1.8442	1.8299
23	.4024	.4115	.4372	.4191	2.2592	1.7772	1.749
24	.3018	.407	.4458	.4527	.4359	1.8652	1.7604
Max	3.0849	2.8487	2.9504	2.8669	2.8995	2.9005	2.915
Min	.2105	.2035	.218	.2774	.1781	.218	.1943
Avg	1.0886	1.2454	1.1974	1.0854	1.0894	1.0503	.8811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103] BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 206 / 11KV KADAMWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
10	.4191		.2515
11		.2105	
Max	.4191	.2105	.2515
Min	.4191	.2105	.2515
Avg	.4191	.2105	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 207 / 11KV CHAVANWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	1.7269	1.7635	1.7604	1.073	1.0679	1.0059
2	2.0119	1.7604	2.0008	1.8442	1.0562	1.0682	1.0898
3	3.8561	1.8442	2.1605	2.0119	1.0322	1.1403	1.1736
4	2.2891	1.9062	2.5206	2.3472	1.0898	1.1022	1.1736
5	2.3472	2.0957	2.5034	2.431	1.0814	1.2357	1.2574
6	2.431	2.4249	2.692	2.7664	1.2574	1.4582	1.4251
7	2.4478	2.672	2.915	2.9675	1.4251	1.8111	1.4922
8	2.5095	2.3482	2.2043	2.4453	1.2146	1.2209	1.1904
9				2.5604	2.4615	2.3739	2.5316
10	.4191	.3563	.407	.3563	2.8018	2.73	2.3807
11	.3239	.3772	.3688	.3239	2.7206	2.6073	
12	.3401	.373	.3353	.3401	2.7206	2.6073	2.2996
13		.39	.2915	.3563	2.2348	2.5987	2.1538
14		.39	.2683	.3563	2.3739	2.2801	2.1052
15	.3401	.3772	.2347		2.3807	2.1862	2.0081
16	.3725	.3521	.0671		2.2805	2.2298	2.0809
17	1.6057	1.5947	1.6766		.2374	.3018	.2591
18	1.6194	1.5089	1.5927		.407	.3688	.3563
19	1.491	1.3889	1.5089	1.6278	.5087	.6036	.5182
20	1.2071	1.475	1.3413	1.5384	.5533	.6706	
21	1.2239	1.475	1.2631	1.3599	.5935	.6874	.5668
22	1.1401	1.2517	1.1736	1.2289	.5935	.7209	.6478
23	1.1065	1.1869	1.0059	1.1336	.6722	.7209	.6802
24	1.8652	1.0682	1.2003	.9724	1.0898	.6443	.6706
Max	3.8561	2.672	2.915	2.9675	2.8018	2.73	2.5316
Min	.3239	.3521	.0671	.3239	.2374	.3018	.2591
Avg	1.5615	1.3193	1.3694	1.5364	1.4108	1.4348	1.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 208 / 11 KV ISHWAR PIND AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.8309	.9522	.9892	.2012	.2347	.2347
2	1.0395	.8718	.9054	1.0059	.1966	.2801	.218
3	1.073	.9221	1.0117	1.1736	.218	.2743	.2012
4	1.0688	.9724	1.1317	1.3413	.2267	.2715	.1781
5	1.1568	1.0898	1.1869	1.4251	.2683	.3077	.2347
6	1.1336	1.1961	1.3817	1.4575	.2753	.3361	.2429
7	1.0669	1.3765	1.4403	1.4575	.2915	.3547	.2683
8	1.0852	1.2793	1.2574	1.2239	.2105		
9				1.2239	1.4251	1.2209	1.6263
10	.1341	.1781	.1543	.1341	1.4413	1.2887	1.643
11	2.753	.1526	.1357	.1134	1.3279	1.3413	1.6518
12	.1296	.1494	.1174	.0972	1.3441	1.358	1.4251
13		.1494	.1006	.1147		1.2574	1.3441
14		.1187	.1174	.1147	1.2407	1.0898	1.2955
15	.1311	.1063	.1174		1.2003	1.1736	1.2146
16	.1296	.1029	.1174		1.2717	1.2742	1.1012
17	.1296	.1187	.1341		.1017	.1509	.1457
18	.1619	.1677	.1509		.1865	.1677	.2105
19	.3725	.1886	.1844	.2429	.2614	.2105	.2753
20	.2012	.2035	.2105	.2591	.2347	.2515	
21	.218	.2572	.2105	.213	.2515	.2515	.2429
22	.2012	.2801	.218	.213	.2713	.2515	.2429
23	.2012	.2614	.2012	.2012	.2743	.2347	.2267
24	.9717	.2035	.2229	.2204	.2012	.2614	.2347
Max	2.753	1.3765	1.4403	1.4575	1.4413	1.358	1.6518
Min	.1296	.1029	.1006	.0972	.1017	.1509	.1457
Avg	.6840	.4860	.5070	.6611	.5618	.6019	.6572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 209 / 11 KV MARKADWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.2012	.1696	.1677	.1844	.168	.1357
2	.1174	.1943	.1715	.1677	.1677	.1526	.1134
3	.1341	.1844	.1543	.1677	.1638	.181	.1006
4	.1341	.1658	.1543	.1509	.1802	.2035	.1174
5	.1509	.1638	.1696	.1457	.1966	.2012	.1357
6	.1677	.1802	.1357	.1509	.1802	.181	.1509
7	.1619	.1296	.168	.1526		.1492	.1526
8					.1147		
9	.7712	.7935	.7461	.7042	.0937		
10	.9221	.8745	.823	.8718	.0972	.1017	.0838
11	.8421	1.0269	.8097	.8097	.0648	.0838	.0648
12	1.004	1.1016	.9054	.7773	.0486	.0671	.0819
13		.1494	.8745	.8097	1.3441	.1006	.1134
14		.12	.8383	.7935	.0686	.1174	.081
15	.7865	.1029	.7287		.0686	.1006	.0648
16	.7449	.7122	.7209		.0678	.0671	.0648
17	.0819	.0747	.0671		.8478	1.0562	.8745
18	.0972	.0693	.1006		.9156	1.0059	.8907
19	.1296	.112	.1341	.1296	.9665	.9221	.7449
20	.1341	.1696	.1296	.1296	.8383	.8048	
21	.1457	.2058	.1341	.1311	.8048	.7042	.5182
22	.1844	.2058	.1509	.1638	.6874	.6036	.4858
23	.1844	.1696	.1677	.1966	.6104	.5533	.4372
24	.1341	.1865	.1696	.1677	.1844	.5426	.5197
Max	1.004	1.1016	.9054	.8718	1.3441	1.0562	.8907
Min	.0819	.0693	.0671	.1296	.0486	.0671	.0648
Avg	.3395	.3171	.3749	.3573	.3868	.3667	.2825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 201 / 11KV KOTHALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3258		.3601	1.0822		2.1605
2	.2915	.3258	.3944	.3772	1.0974		
3	.3258	.3429		.3944	1.0974		2.1605
4	.3601	.3772		.4115	1.1584		2.1605
5	.3429	.4115		.4287			2.1605
6	.3429	.463	.4801	.4458	1.4327		2.1605
7					1.6918		2.2805
8					.2896		.2915
9					.2591		.2572
10	1.6975	2.2977	1.89	2.1262	.2572		.2229
11	2.4691	2.2634	2.1795	2.2634	.2401		.2229
12	2.6235	2.2291	1.9662	2.2291	.2401		.2401
13	2.4863	2.1948	1.9966	2.1434	.2401		.2743
14	2.2977	2.1948	1.829	2.0576	.2401		.2743
15	2.2462	2.0919	1.6766	1.7375			.2915
16	2.1948	2.0576	1.6766	1.7071	.2229	.2743	.2572
17		1.869	1.8861	1.6004	.2058	.3258	.2743
18		.2572	.2401	.2134	.2401	.3601	.3353
19		.2915	.3601	.3201	.3258	.3944	.3353
20		.3258	.3429	.3048	.3258	.3601	.2896
21		.3601	.3258	.2743	1.749	.3429	.2896
22		.3601	.3258	1.2193	1.8519	2.1605	.2743
23		.3772	.3429	1.1431	1.8004	2.1605	.2743
24	1.2574	.3258		.3601	1.0822		2.1605
Max	2.6235	2.2977	2.1795	2.2634	1.8519	2.1605	2.2805
Min	.2572	.2572	.2401	.2134	.2058	.2743	.2229
Avg	1.3709	1.0353	1.1195	1.0532	.7786	.7973	.8543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 202 / 11KV GURSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.5604	1.4746	.2896		.3086
2	1.166	1.2003	1.5775	1.4746	.2896		.3086
3	1.2689	1.2689	1.5947	1.4918	.3048		.3429
4	1.3375	1.3375	1.6118	1.5089	.3201		.3601
5	1.3717	1.406	1.6289	1.5089	.3201		.3944
6	1.406	1.6804	1.6461	1.5261	.3506		.4115
7	1.4403	1.7147	1.749	1.6461			
8	1.6461	.3086	.2591	.2572			
9	.2743	.2401	.2134	.2743			
10	.2572	.2058	.1677	.2401	1.5432		
11		.2058	.1677	.2058	1.5775		
12	.2058	.2058	.1524	.2058	1.6118		
13	.2058	.2058	.1524	.1886	1.6461		
14	.1886	.2229	.1524	.1886	1.5775		
15	.1886	.2229	.1677		1.5432		
16	.1886	.2401	.1524	1.9204	1.5432	1.4918	
17	.2058	.2058	.1715	.1677	1.3717	1.3889	1.1431
18	.2401	.2058	.2058	.2134		.2401	.2439
19	.2572	.2401	.2058	.3201	.3086	.3601	.3201
20	.2572	.2915	.2743	.3048	.3429	.3601	.3048
21	.2743	.3086	.3086	.3048	.3601	.2743	.3048
22	.9431	1.5089	1.3375	.3048	.3086	.2743	.945
23	1.0288	1.5261	1.3717	.2896	.3086	.2743	1.0517
24		1.0802	1.5432	1.4575	.2896		.2915
Max	1.6461	1.7147	1.749	1.9204	1.6461	1.4918	1.1431
Min	.1886	.2058	.1524	.1677	.2896	.2401	.2439
Avg	.7038	.7152	.7655	.7598	.8104	.5830	.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 203 / 11KV SHINDEWADI FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0069		.0069		.0061		.0069
2	.0069		.0069		.0061		.0069
3	.0069	.0069	.0069		.0061		.0069
4	.0069	.0069	.0069		.0061		.0069
5	.0069	.0069	.0069		.0061		.0069
6	.0069	.0069	.0069		.0061		.0069
7	.0069	.0069	.0069		.0061		.0069
8	.0069		.0069		.0183		.0069
9	.0069	.0069	.0122		.0183		.0069
10	.0069	.0069	.0183		.0206		
11	.0069	.0069	.0183		.0206		
12	.0069	.0069	.0183		.0206		
13	.0069	.0069	.0183		.0154		
14	.0069	.0069	.0183		.0154		
15	.0069	.0069	.0183		.0206		
16	.0069	.0069	.0183	.0069	.0206	.0206	
17	.0069	.0069	.0206	.0061	.0206	.0206	.0183
18	.0069	.0069	.0206	.0061	.0206	.0206	.0183
19	.0069	.0069	.0206	.0183	.0206	.0069	.0183
20	.0069	.0069	.0069	.0183	.0206	.0069	.0183
21	.0069	.0069	.0069	.0183	.0206	.0069	.0183
22	.0069	.0069	.0069	.0061	.0206	.0069	.0061
23	.0069	.0069	.0069	.0061	.0206	.0069	.0061
24		.0069	.0069		.0061		.0069
Max	.0069	.0069	.0206	.0183	.0206	.0206	.0183
Min	.0069	.0069	.0069	.0061	.0061	.0069	.0061
Avg	.0069	.0069	.0122	.0108	.0151	.0120	.0102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 204 / 11KV DHARMPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.7716	.5487	.5182		.583
2	.5658	.6001	.7888	.5658	.5182		.6859
3	.583	.6173	.823	.6001	.5487		.6859
4	.7202	.6516	.8402	.6859	.6554		.7202
5	.823	.7202	.8745	.7545	.7316		.7545
6	.9774	.9088	.9088	.9259	.8078		.8402
7	.8573	.7373	.6859	.6344	.7316		.7373
8	.6516	.6344	.442	.6859	.5487		.5316
9	.5144	.4287	.442	.4973	.442		.4458
10		.4287	.3506	.4287	.4115		
11		.4287	.2896	.3601	.3772		
12	.4801	.4115	.3048	.3429	.3086		
13	.4287	.3772	.2743	.3258	.2743		
14	.3944	.3258	.2743	.3086	.2743		
15	.3944	.3429	.2591	.2915	.2743		
16	.3944	.3601	.3048	.3086	.2915	.3086	
17	.3944	.3944	.3772	.3201	.3258	.3601	.3353
18	.6001	.4458	.4801	.381	.4801	.4973	.4268
19	.6516	.5316	.7373	.7011		.703	.6554
20	.6859	.6173	.7202	.6554		.7716	.6859
21	.6859	.6687	.703	.6249		.703	.5944
22	.6859	.6516	.6001	.5944		.6344	.5487
23	.6516	.6859	.5487	.5487		.6001	.5182
24	.5487	.583	.7545	.5144	.5182		.5487
Max	.9774	.9088	.9088	.9259	.8078	.7716	.8402
Min	.3944	.3258	.2591	.2915	.2743	.3086	.3353
Avg	.6017	.5473	.5648	.5252	.4757	.5723	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 205 / 11 KV MASUGADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2743	.2229	.6554		1.166
2	.2572	.2743	.2743	.2401	.6706		1.2346
3	.2572	.3086	.2915	.2572	.6859		1.286
4	.3086	.3258	.3086	.2915	.7164		1.3375
5	.3429	.3258	.3429	.3258	.7621		1.406
6	.3601	.3258	.3772	.3429	.9602		1.4575
7					1.4937		1.7147
8					.2591		.2229
9	1.3889				.2439		.2058
10		2.0233	1.7528	.1886			
11		2.1776	1.7833	1.9204			
12	1.9033	2.0576	1.768	1.8004			
13	1.8519	1.8861	1.6309	1.7147			
14	1.7833	1.749	1.5394	1.6632			
15	1.7318	1.7318	1.4784	1.5432			
16	1.6118	1.7318	1.5242	.0069		.1543	
17	.2229	1.749	1.6118	1.0822	.2058	.1543	.1829
18	.1886	.1715	.1886	.2286	.2229	.3086	.2286
19	.2743	.2229	.2401	.2591	.2401	.2915	.2896
20	.2915	.2743	.2572	.2896	.2401	.2915	.2743
21	.2915	.2915	.2572	.2743	.2572	.2401	.2743
22	.2058	.2743	.2401	.6249	.9945	1.0631	.2439
23	.2058	.2743	.2229	.6249	1.0288	1.0974	.2134
24	1.1736	.2401	.2743	.2229	.6249		1.1317
Max	1.9033	2.1776	1.7833	1.9204	1.4937	1.0974	1.7147
Min	.1886	.1715	.1886	.0069	.2058	.1543	.1829
Avg	.7446	.8900	.7923	.6726	.6036	.4501	.7570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 206 / 11 KV KARUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.3032	1.2346	1.406	.2896		1.166
2	.9945	1.3717	1.2517	1.4403	.3048		.3601
3	1.0631	1.4403	1.2689	1.4746	.3201		.3772
4	1.0974	1.5089	1.286	1.5089	.3353		.3944
5	1.2003	1.5432	1.3203	1.5089	.3658		.4115
6	.8573	1.5604	1.3546	1.5432	.3963		.4287
7		1.7318	1.7147	1.6804			
8	.3944	.4287	.2134	.2743			
9	.3944	.2743	.2134	.2572			
10	.2401	.2401	.1981	.2401	1.286		
11	.2229	.2229	.1372	.1715	1.3717		
12	.1886	.2058	.1524	.1715	1.5089		
13	.2058	.1886	.1677	.1886	1.6804		
14	.2229	.1886	.1829	.1886	1.6461		
15	.2058	.2058	.1829	.1886	1.6118		
16	.1886	.2229	.1981	.1886	1.5775	1.3375	
17	.1886	.2572	.2572	.1677	1.6289	1.2517	1.1279
18	.2401	.2915	.2401	.1677	.1886	.3086	.2743
19	.2743	.3086	.3772	.3353		.4115	.381
20	.3086	.3258	.3601	.3201		.3772	.3506
21	.3429	.3429	.3258	.3506		.3772	.3201
22	1.1317	1.1831	1.286	.3201		.3258	1.1279
23	1.2003	1.1831	1.3375	.3048		.3258	1.0517
24	.8573	1.2346	1.2174	1.3717	.2896		.3429
Max	1.2003	1.7318	1.7147	1.6804	1.6804	1.3375	1.166
Min	.1886	.1886	.1372	.1677	.1886	.3086	.2743
Avg	.5629	.7402	.6866	.6571	.9251	.5894	.5796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 207 / 11 KV MOROCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.8573	.8059	.823	.2134		.3086
2	.7202	.9431	.8059	.8573	.2134		.3086
3	.7888	1.0288	.823	.8745	.2286		.3086
4	.823	1.0288	.8402	.8745	.2439		.3258
5	.823	1.0631	.8916	.8916	.2591		.3258
6	.823	1.0631	.9088	.9088	.2743		.3258
7	.9774	1.0974	1.1145	.9774			
8	.2572	.2743	.2286	.2401			
9	.1886	.2058	.1524	.1715			
10		.1715	.1219	.1372	.8573		
11		.1372	.0914	.1029	1.1145		
12	.1372	.1372	.0914	.1029	.9945		
13	.1372	.12	.0762	.0857	1.1831		
14	.1372	.12	.0914	.0857	1.0117		
15	.1543	.12	.1067	.1029	1.0117		
16	.1543	.12	.0914	.1029	.9945	1.0631	
17	.1715	.12	.1543	.0914	.9431	.9259	.6859
18	.1715	.12	.1543	.1372	.1543	.2401	.1829
19	.2401	.1886	.2743	.2134		.2915	.2591
20	.2572	.2229	.2572	.2439		.3086	.2743
21	.2572	.2401	.2572	.2439		.2915	.2439
22	.7373	.7202	.7545	.2134		.2743	.6249
23	.823	.7202	.7716	.2134		.2743	.6097
24	1.0898	.823	.7716	.8059	.2134		.2915
Max	1.0898	1.0974	1.1145	.9774	1.1831	1.0631	.6859
Min	.1372	.12	.0762	.0857	.1543	.2401	.1829
Avg	.4782	.4851	.4432	.3959	.6194	.4587	.3625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 201 / 11 KV Barshi feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 202 / 11 KV Kategaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 204 / 11KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.503	.57	.0168		
2	.4694	.5868	.6036	.0168		
3	.4694	.5868	.6371	.0168		
4	.503	.6706	.6371	.0168		
5	.5365	.7545	.7377	.0168		
6	.6874	.8383	.788	.0168		
7	.7377	.8718	.8383	.0168		
8		.8383	.7545			
10					.7545	
11					.8718	
12					.9389	
13					.9389	
14					.8718	
15					.8383	
16					.7712	
19						.0168
20						.0168
21						.0168
22						.0168
23						.0168
24	.4191	.503	.5365	.0168		
Max	.7377	.8718	.8383	.0168	.9389	.0168
Min	.4191	.503	.5365	.0168	.7545	.0168
Avg	.5344	.6837	.6781	.0168	.8551	.0168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 205 / BABHULGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168	.0168		
2	.0168	.0168	.0168	.0168		
3	.0168	.0168	.0168	.0168		
4	.0168	.0168	.0168	1.4083		
5	.0168	.0168	.0168	1.8442		
6	.0168	.0168	.0168	2.0119		
7	.0168	.0168	.0168	2.2131		
8				2.1795		
9					2.2801	2.3807
19						.0168
20						.0168
21						.0168
22						.0168
23						.0168
24	.0168	.0168	.0168	.0168		
Max	.0168	.0168	.0168	2.2131	2.2801	2.3807
Min	.0168	.0168	.0168	.0168	2.2801	.0168
Avg	.0168	.0168	.0168	1.0805	2.2801	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 206 / 11 KV KALAMBWADI FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.5868	.503		
2	.3856	.6036	.5365		
3	.4191	.6036	.5533		
4	.4359	.6371	.5868		
5	.4862	.6371	.6203		
6	.5533	.6706	.6371		
7	.7712	.8718	.6371		
8		.7545	.6036		
10				.4527	
11				.5365	.0134
12				.6371	
13				.6371	
14				.6706	
15				.6706	
16				.7712	
24	1.6194	.5868	.503		
Max	1.6194	.8718	.6371	.7712	.0134
Min	.3856	.5868	.503	.4527	.0134
Avg	.6320	.6613	.5756	.6251	.0134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 201 / CHIKHARDE FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
9	.4458
24	1.5947
Max	1.5947
Min	.4458
Avg	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 202 / NARI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
9	.7545
24	1.5432
Max	1.5432
Min	.7545
Avg	1.1489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 203 / YELAMB FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
9	.6859
24	2.2672
Max	2.2672
Min	.6859
Avg	1.4766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 204 / forest Feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.9717
Max	.9717
Min	.9717
Avg	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 205 / Indapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
9	1.869
24	.4801
Max	1.869
Min	.4801
Avg	1.1746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 206 / Sawargaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
9	.2401
24	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 207 / MAHAGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.6194
Max	1.6194
Min	1.6194
Avg	1.6194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 201 / 11 KV PANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0943	.0838
2	.0762		.0943	.0838
3	.0762		.0943	.0838
4	.0762		.0943	.0084
5	.0762		.0943	.0838
6	.0762		.0943	.0838
7	.0762		.0943	.0838
8	.0762		.0943	.0838
9	1.5242		1.5261	.0838
10	1.0479	1.4251	1.7604	.0762
11	1.6004	1.6766	1.5089	
12	1.6004	1.7604	1.6766	
13	1.7528	1.5089	1.7604	
14	1.829	1.643	1.8442	
15	1.7528	1.6598	1.7604	
16	1.6766	1.6766	1.8442	
17	.0762	.0943	.0838	1.829
18	.0762	.0943	.0838	1.9052
19	.0762	.0762	.0838	1.448
20	.0762	.0838	.0838	1.2955
21	.0305	.0838	.0838	1.2193
22	.0762	.0943	.0838	.8383
23	.0762	.0943	.0838	1.0669
24	.0762	.0943	.0943	.0838
Max	1.829	1.7604	1.8442	1.9052
Min	.0305	.0762	.0838	.0084
Avg	.5816	.8044	.6299	.5801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 202 / 11 KV SAKAT AG FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762		.0943	.1677
2	.0943	.0762		.0943	.1677
3	.0943	.0762		.0943	.1677
4	.0943	.0762		.0943	.1677
5	.0943	.0762		.1509	.2515
6	.0943	.0762		.0943	.2515
7	.0943	.0762		.0943	.503
8	.0943	.0762		.0943	.503
9	.4191	.0762		.0943	
10	.503	.0762	.0914	.0838	
11	.6706				
12	.8383				
13	.8383				
14	.8048				
15	.6706				.0762
16	.6706				.0762
17	.0943	.7621	.8383	.8383	.0762
18	.0943	.7621	.9221	.8383	.0762
19	.0857	.7621	.8718	.8383	.0762
20	.0943	.5335	.8383	.6706	.0762
21	.0943	.2382	.7287	.6706	.0762
22	.0943	.3048	.7042	.503	.0762
23	.0943	.3048	.7545	.2515	.0762
24	.0943	.0762		.6706	.1677
Max	.8383	.7621	.9221	.8383	.503
Min	.0857	.0762	.0914	.0838	.0762
Avg	.2881	.2503	.7187	.3484	.1685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 203 / 11 KV KALEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1431		.6706	.0838
2		1.2193		.9892	.0838
3		1.2193		1.1736	.0838
4		1.3717		1.3748	.0838
5		1.3717		1.5089	.0838
6		1.5242		1.5424	.0838
7		2.2862		1.5089	.0838
8		2.0576		1.5424	.0838
9					2.0119
15		.0762	.0943	.0838	
16		.0762	.0943	.0838	2.1338
17			.0943	.0838	
18		.0762	.0943	.0838	.0762
19		.0762	.0943	.0838	.0762
20	1.6766	.0762	.0943	.0838	.0762
21	1.5927	.0762	.0943	.0838	.0762
22	1.5089	.0762	.0943	.0838	.0762
23	1.3413	.0762	.0943	.0838	.0762
24	2.915	.0762		.0857	.0838
Max	2.915	2.2862	.0943	1.5424	2.1338
Min	1.3413	.0762	.0943	.0838	.0762
Avg	1.8069	.7576	.0943	.6195	.3151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 204 / 11 KV OLD GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2452	.1886	.2229	.1715	.1886	.1886
2	.1715	.1886	.1886	.2229	.1715	.1886	.1886
3	.1715	.1886	.2829	.2572	.2572	.2263	.1886
4	.3429	.2829	.3772	.3429	.3429	.2641	.5658
5	.6001	.3772	.5658	.4287	.4287	.4904	.6602
6	.6859	.5658	.7167	.6859	.6859	.6036	.6602
7	.7716	.7545	.7545	.7716	.6859	.5658	.6602
8	.6344	.6602	.6516	.7202	.6344	.5847	.5658
9	.6602	.4715	.5144	.5144	.5658	.4715	.4715
10	.4715	.4715	.3429	.4287	.4715	.2829	.3429
11	.5281	.2829	.2572	.2572	.2263	.1886	.2572
12	.3772	.1886	.2572	.1715	.1886	.1886	.1715
13	.2263	.1886	.2058	.1715	.1886	.1886	.1715
14	.1886	.1886	.1715	.1715	.1698	.1886	.1715
15	.1886	.1886	.12	.1715	.1886	.1886	.1715
16	.1886	.1886	.1715	.1715	.1886	.1886	.1715
17	.2829	.1886	.1715		.1886	.1886	.1715
18	.4715	.2829	.3429	.3429	.2829	.2829	.1715
19	.5658	.6602	.6001	.6001	.3772	.4715	.5144
20	.5658	.6602	.6001	.5144	.5658	.5658	.6001
21	.4715	.4715	.5144	.4287	.3772	.4715	.4287
22	.3772	.2829	.3429	.3429	.2829	.2829	.3429
23	.2829	.1886	.3086	.2572	.2641	.1886	.2572
24	.1715	.2263	.1886	.2572	.1715	.1886	.1886
Max	.7716	.7545	.7545	.7716	.6859	.6036	.6602
Min	.1715	.1886	.12	.1715	.1698	.1886	.1715
Avg	.3987	.3497	.3681	.3675	.3365	.3183	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 205 / 11 KV NEW PANGAON GAOTHAN SEPARATED GAOTHAN FEEDERS
FEED Feeder KV- 11 / OUTGOING

DATE	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.2075	.1886
2	.1524		.1886	.1715
3	.1715		.1698	.1715
4	.2286		.2829	.2572
5	.3048		.3772	.3429
8	.3429		.2829	.3429
9	.3429		.2829	.3429
10	.2572	.2829	.2829	.2572
11	.1715	.2263	.1886	.2058
12	.1715	.1886	.1886	.1715
13	.1715	.1886	.1886	.1715
14	.1715	.1886	.1886	.1715
15	.1715	.1886	.1886	.1715
16	.1715	.1886	.1886	.1715
17	.1715	.1886	.1886	.1715
18	.2229	.1886	.1886	.1715
19	.4287	.2452	.2829	.3429
20	.3429	.3206	.3772	.4287
21	.2572	.3772	.3772	.3429
22	.2229	.2829	.2829	.2572
23	.1715	.2452	.1886	.1715
24	.2058		.2263	.1886
Max	.4287	.3772	.3772	.4287
Min	.1524	.1886	.1698	.1715
Avg	.2284	.2358	.2418	.2369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 201 / BARSHI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 202 / KARI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 203 / UKKADGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 204 / UKKADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 205 / BARSHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4049
Max	.4049
Min	.4049
Avg	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 206 / Shirale Ag Fdr
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 207 / Pangri Gaothan Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 201 / JAMGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.2226
Max	3.2226
Min	3.2226
Avg	3.2226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 202 / BHATAMBARE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 203 / HALDUGE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 204 / Jamgaon GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 205 / Bhatambre Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.7287
Max	.7287
Min	.7287
Avg	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 206 / Malegaon AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 207 / Upale(D) Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 208 / 11 kv Zaregaon Ag Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.2955
Max	1.2955
Min	1.2955
Avg	1.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 201 / 11 KV Raleras SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0762	.0457	.0762	.061	.0457	1.1431
2	.061	.0762	.0305	.0762	.0457	.0457	1.1431
3	.0457	.0762	.1067	.0762	.0457	.0457	1.0669
4	.061	.0762	.0457	.0762	.0457	.0457	1.0669
5	.0762	.0914	.061	.0914	.0457	.0457	1.0669
6	.061	.0914	.061	.0914	.0762	.0457	1.1431
7	.0762	.0914	.061	.0914	.0762	.0457	1.2498
8	.0762	.0762	.061	.0914	.0762	.0762	1.3717
9	.061	.0762	.0457	.0914	.0762	.0762	1.2955
10	1.3717	1.5851	1.5242	1.5394	1.6156	.0914	.061
11	1.6766	1.6766	1.6766	2.0271	2.2862	2.1338	.0457
12	2.0576	2.0119	1.829	2.0119	2.4387	2.3624	
13	2.1338	2.21	2.21	2.0119		2.2862	
14	2.21	2.1948	2.1338	1.9814	2.2862	2.1643	
15	2.4387	2.21	2.1338	2.0881	2.21	1.9814	
16	2.5149	2.2862		2.1338	1.9052	2.0576	
17	2.2862	2.0424	2.1338	2.21	1.9814	2.0881	
18	.0762	.0762	.0762	.1372	.1372	.0762	.061
19	.0762	.0914	.0762	.1524	.1067	.0762	.061
20	.0914	.1219		.1677	.1067	.061	.0762
21	.0914	.1524	.0914	.1677	.0762	.061	.061
22	.0914	.1372	.0914	.1067	.061	.0457	.061
23	.0762	.1219	.0762	.1067	.061	.0305	.061
24	2.5053	.0457	.0762	.061	.0457	.0305	1.0364
Max	2.5149	2.2862	2.21	2.21	2.4387	2.3624	1.3717
Min	.0457	.0457	.0305	.061	.0457	.0305	.0457
Avg	.8449	.7373	.6658	.7360	.6898	.6674	.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 202 / 11 KV PANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 203 / 11 KV GOUDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 204 / 11 KV VAIRAG Urban Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859			.6401	.7621	.7621
2					.6401	.7621	.7621
3		.6097		.6097	.6554	.7621	.7621
4					.6554	.7621	.8383
5					.7164	.9145	.9145
6					.7468	.9145	.9907
7		.8383	.8383	.8383	.8078	.884	.9145
8		.8383		.7621	.8383	.8383	.8383
9	.7621	.7621		.7621	.7621		.8383
10	.6859			.7316	.7621	.8383	.6859
11	.7621			.7164	.8383	.7621	.6097
12			.6859	.6859	.7621	.7621	.6097
13				.6859		.8383	.6097
14	.7621			.6859		.8383	.6097
15				.6859		.8383	.6097
16	.7621			.7316		.7621	.6859
17				.7621		.8383	.7011
18				.8535		.9145	.7621
19				.8535		.9907	.8383
20	.9145			.8383		.9907	.9145
21				.8383		.9145	.8383
22	.7621		.9145	.8383		.8383	.8383
23	.7621		.7621	.7773		.7621	.8383
24	.6859	.7621	.6859	.7316	.7316	.7621	.6097
Max	.9145	.8383	.9145	.8535	.8383	.9907	.9907
Min	.6859	.6097	.6859	.6097	.6401	.7621	.6097
Avg	.7621	.7494	.7773	.7573	.7351	.8370	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 205 / 11 KV IRLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7621	.8535	.6859	.9602	.7316	.0305
2	.8078	.7621	.945	.7621	.9907	.7621	.0305
3	1.0364	.9145	.9755	.7621	.9907	.7621	.0305
4	1.0974	.9145	.9907	.9145	1.0974	.8383	.0305
5	1.1888	.9145	1.0059	.9145	1.2193	.9145	.0305
6	1.2955	1.2193	1.2803	1.2193	1.5242	1.448	.0457
7	1.4784	1.5242	1.6461	1.5242	1.6309	1.6766	.0305
8	1.4632	1.6004	1.6766	1.5242	1.6613	1.6766	.0305
9	1.4937	1.6004	1.5089	1.5242	1.6613	1.5546	.0305
10	.0305	.0305	.0762	.0457	.0305	.0305	.945
11	.0305	.0305	.0457	.0457	.0305	.0305	1.4327
12	.0305	.0305	.0457	.0457	.0457	.0305	
13	.0305	.0305	.0457	.0457	.0457	.0305	
14	.0305	.0305	.0457	.0457	.0305	.0305	
15	.0305	.0305	.0457	.0457	.0305	.0305	
16	.0305	.0305	.0457	.0457	.0305	.0305	
17	.0305	.0305	.0457	.0457	.0457	.0305	
18	.0305	.0305	.0457	.0457	.0762	.0305	.0305
19	.0457	.0305	.0457	.0457	.0762	.0305	.0305
20	.0457	.0457	.0457	.0457	.0457	.0305	.0457
21	.0457	.061	.0457	.0457	.0457	.0305	.0457
22	.0457	.0457	.0457	.0457	.0305	.0305	.0457
23	.0457	.0305	.0457	.0457	.0305	.0305	.0305
24	2.8769	.6706	.6097	.884	.4572	.0305	
Max	2.8769	1.6004	1.6766	1.5242	1.6613	1.6766	1.4327
Min	.0305	.0305	.0457	.0457	.0305	.0305	.0305
Avg	.5771	.4738	.5068	.4731	.5328	.4509	.1704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 207 / Dahitane Ag Fdr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 201 / 11 KV JAVALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 202 / 11 KV SAROLE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.749	1.8861	1.8861	1.8861	1.8176	1.8004
2	1.8004	1.8004	1.8519	1.8861	1.8861	1.8176	1.8004
3	1.8004	1.8004	1.8519	1.8861	1.8861	1.8176	1.8004
4	1.8519	1.8004	1.8861	1.8861	1.8861	1.8176	1.8519
5	1.9719	1.8861	1.8004	1.9204	1.8861	1.8519	1.8519
6	1.8861	1.8861	1.7147	1.8861	1.8004	1.8004	1.8519
7	1.8861	1.749	1.7147	1.9204	1.7147	1.7833	1.8519
23	1.8004						
24	1.8176	1.7318	1.8861	1.8861	1.8861	1.8176	1.8004
Max	1.9719	1.8861	1.8861	1.9204	1.8861	1.8519	1.8519
Min	1.8004	1.7318	1.7147	1.8861	1.7147	1.7833	1.8004
Avg	1.8461	1.8004	1.8240	1.8947	1.8540	1.8155	1.8262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 203 / 11 KV AMBEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 204 / Rui SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9717
Max	.9717
Min	.9717
Avg	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 205 / Kasari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.753
Max	2.753
Min	2.753
Avg	2.753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 201 / 11 KV MALWANDI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762		.0914	.0914		
2	.0838	.0762		.0914	.1219		
3		.1219		.0762	.0762	.1174	
4	.0838	.0762	.1006	.1219	.0914		
5		.0914		.1219	.1219		
6	.1677	.1524		.1524	.0762	.1341	
7		.1219		.1524	.1219		
8	.1341	.1219	.1341	.1524	.1524	.1677	1.3413
9	.0572	.0762		.2743	.1219		1.2193
10	1.2193	.6859		.9145	.7621	.9145	.0686
11	1.6156	1.2803		1.2193	.6859		
12	1.7528	1.2955		1.1888	.7621		
13	1.6766	1.2955	1.3413	1.2803	1.6766	1.8442	
14	1.5242	1.3108		1.1584	1.5242		
15	1.5242	1.2193		1.2193	1.3108		
16	1.4022	1.387	1.1736	1.448	1.3108	1.8442	
17	1.3717			1.3717	1.2955		
18	.0686	1.6004		.0762	.1372		
19	.08	.0762		.1372	.1524		.1143
20	.08	.1524		.1524	.1372		.1143
21	.0686	.1219	.1341	.1372	.1372		.1143
22	.0686	.1067		.0914	.1219		.1143
23	.0686	.1067	.1174	.0914	.1219		.1143
24	2.2672	.0914	.1174	.1067	.0914	.1341	1.0059
Max	2.2672	1.6004	1.3413	1.448	1.6766	1.8442	1.3413
Min	.0572	.0762	.1006	.0762	.0762	.1174	.0686
Avg	.7657	.5063	.4455	.4928	.4668	.7366	.4674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 202 / 11 KV GULPOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572		.6097	.5487		
2	.8383	.5487	.6706	.7621	.6097		
3		.6097		.9145	.6097	.8383	
4	1.0059	.6097	.6706	.9145	.6859		.0838
5		.7621		1.0669	.8383		
6	1.1736	.9145		1.2193	.9145	1.1736	
7		1.2193	1.0059	1.3717	1.3717		
8	1.5927	1.2193		1.6004	1.5242	1.6766	.1341
9	1.3717	.9907	.8383	1.3717	1.3717		.0914
10	.0572	.0762		.0914	.0762	.1006	1.0669
11	.0572	.0762	.0838				
12	.0572	.061		.0762	.0762		
13	.0572	.0305	.0838	.0762	.0762	.0838	
14	.0572	.0305		.0762	.061		
15	.0572	.0457		.0762	.061		
16	.0572	.0457	.0503	.0762	.061	.0838	
17	.0686			.0762	.0762		
18	.0686			.0914	.0762		
19	.0914			.1067	.1219		.0686
20	.0914			.1067	.1219		.0914
21	.08		.1174	.0914	.1219		.0914
22	.08			.0914	.1219		.08
23	.0686		.1006	.0914	.1067		.0686
24	2.2672	.4572	.5868	.503	.4572	.5868	.0838
Max	2.2672	1.2193	1.0059	1.6004	1.5242	1.6766	1.0669
Min	.0572	.0305	.0503	.0762	.061	.0838	.0686
Avg	.4599	.4797	.4208	.4983	.4387	.6491	.186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 203 / 11 KV SURDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762		.1067	.0762		
2	.1174	.0914	.1341	.061	.0762		
3		.0914			.0914	.1174	
4	.1677	.1219		.1067			.1174
5		.1372		.1067	.1524		
6	.3353	.1829	.2515	.2743	.1829	.2012	
7		.2591		.2743	.2439		
8	.2683	.2439		.2286	.2286		.2515
9	.1486	.1829		.1829	.1524		.1143
10	.1029	.1219	.1341	.0914	.0914	.1341	.7621
11	.08	.0914		.1372	.0914		
12	.0686	.0762		.0914	.0914		
13	.0686	.061	.0838	.061	.0914	.0838	
14	.0686	.061		.061	.0762		
15	.0686	.1067		.1219	.0762		
16		.1067	.1174	.1219	.0762	.1174	
17	.0686			1.9814	1.6461		
18	2.1643			1.9357	1.9814		
19	2.0881			1.5242	1.5242		.16
20	1.7071			1.1279	1.1431		.16
21	1.4632		1.3413	1.0364	1.1584		.16
22	1.3717				1.0669		.1372
23	1.2193		1.1736	.9602	.9297		.1372
24	1.2574	1.0364	.8551	1.0059	.945	.9724	.8383
Max	2.1643	1.0364	1.3413	1.9814	1.9814	.9724	.8383
Min	.0686	.061	.0838	.061	.0762	.0838	.1143
Avg	.6755	.1793	.5114	.5272	.5301	.2711	.2838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 205 / 11 kV Yawali Ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		.0457	.0457		
2	.0503	.0305	.0503	.0457	.0457		
3		.0305		.0457	.0762	.0335	
4	.0503	.0457	.0503	.061	.061		1.5089
5		.061		.0762	.0762		
6	.0671	.0762		.0762	.0914	.0335	
7		.0762		.0762	.0762		
8	.0671		.0671	.0762	.061		2.1795
9	1.9814	2.1033		2.1338	1.8595	1.9784	1.3717
10	2.1643	2.21		2.1338	1.5546	2.0957	.0229
11	2.3167	2.2862	2.431	2.1338	1.829		
12	2.5149	2.2558		2.1338	1.9509		
13	2.3167	2.7435	2.3472	2.0729	1.9966		
14	2.4387	2.2862		1.9814	1.7528	2.0957	
15	2.3777	2.2862		1.7528	1.829		
16	2.332	2.332	2.3472	2.1033	1.8138	2.1795	
17	.0457			.061	.1067		
18	.0343			.0762	.0762		
19	.0457			.0762	.061		.0457
20	.0457			.0762	.0762		.0457
21	.0457		.0671	.061	.061		.0457
22	.0457			.061	.061		.0457
23	.0343		.0503	.0762	.061		.0457
24	.0671	.0457	.0503	.0503	.0457	.0457	1.1736
Max	2.5149	2.7435	2.431	2.1338	1.9966	2.1795	2.1795
Min	.0343	.0305	.0503	.0457	.0457	.0335	.0229
Avg	.9521	1.1822	.8290	.7286	.6529	1.2089	.6485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 206 / 11 kV Turk-Pimpri AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4877		.6097	.5487	.7545	
2	.503	.5182	.6371	.6097	.5487		
3		.6097		.7621	.823		
4	.6706	.6097	.6706	.7621	.6859	.9221	.0838
5		.6859		.9145	.6859		
6	.8383	.884	.9221	1.0669	.6859	.9221	
7		1.0212		1.0669	.7621		
8	1.0059	.9145	1.0059	1.2193	.9145	1.0059	.1341
9	.0686	.0914		.0762	.0914		.08
10	.0572	.0914		.0762	.0914	.0838	.7316
11	.0457	1.2955	.0838	.061	.0914		
12	.0457	.0762		.061	.0762		
13	.0457	.0762		.1219	.1219	.0671	
14	.0457	.0762		.0762	.0762		
15	.0572	.0762		.0762	.061		
16	.0572	.0762	.0503	.0762	.0762	.0671	
17	.0686			.0762	.0762		
18	.0686			.1067	.0762		
19	.0914			.0122	.1219		.0914
20	.0914			.1219	.1372		.0914
21	.08		.1174	.1219	.1524		.0914
22	.0686			.1219	.1219		.0914
23	.0686		.1006	.1067	.0762		.0686
24	2.2672	.0914	.0914	.0838	.0762	.1174	.0838
Max	2.2672	1.2955	1.0059	1.2193	.9145	1.0059	.7316
Min	.0457	.0762	.0503	.0122	.061	.0671	.0686
Avg	.3123	.4519	.4088	.3495	.2991	.4925	.1548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 201 / 11 KV SOUNDARE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0457	.0514	.0686	.0457		.8916
2	.0686	.0457	.0514	.0686	.0457		.8745
3	.0686	.0457	.0514	.0514	.0457		.9088
4	.0686	.0457	.0514	.0514	.061		.9088
5	.0686	.061		.0343	.0457		.9431
6	.0686	.061	.0514	.0343	.061		.9945
7	.0686	.061	.0343	.0686	.0762		1.3032
8	.1029	.061	.0857	.0857	.0762		1.2517
9	.061	.0457	.0514	.0514	.0514		.1029
10	.0457	.0514	.0686	.0457	.0514		.1219
11	.0457	.0686	.0857	.0457	.0514		.1829
12	.0457	.0514	.0514	.0457	.0514	.0514	
13	.0457	.0686	.0514	.0457	.0514		
14	.0457	.0686	.0514		.0514	.0514	
15	.0457	.0686	.0514	.0457	.0514	.0514	
16	.0457	.0686	.0514	.0762	.0514	.0857	
17	1.5242	1.6632	1.6118	1.4632		1.9376	
18	1.5242	1.6632	1.6118	1.4784		1.8347	.0457
19	1.448	1.3889	1.2003	1.1431		1.5604	.0914
20	1.0974		1.0117	.9755		1.1831	.0762
21	.9755	1.0802	.9774	.9602		1.1317	.061
22	.945	1.046	.9431	.945		1.0802	.0457
23	.945	.9431	.9088	.9145		1.0288	.061
24	.9602	.823	.9431	.8916	.8688		.9431
Max	1.5242	1.6632	1.6118	1.4784	.8688	1.9376	1.3032
Min	.0457	.0457	.0343	.0343	.0457	.0514	.0457
Avg	.4326	.4142	.4369	.4170	.1022	.9088	.5449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 202 / 11 KV KORFALE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 203 / 11 KV KASARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6401	.9259	.9602	.7011	.8059	.0686
2	.7202	.6401	.9259	1.0288	.7773	.8059	.0686
3	.7202	.6401	.9259	1.0288	.884	.8059	.0686
4	.7202	.6401	.9259	1.1145	.884	.8573	.0514
5	.9088	.6401	.9259	1.1831	.8993	1.1831	.0686
6	.7773	.8993	1.166	1.2517	1.1888	1.4575	.0514
7	1.4232	1.2346	1.5604	1.5432	1.3717	1.5432	.0514
8	1.5432	1.2498	1.5947	1.4327	1.3717	1.5775	.0686
9	.0457	.0305	.0514	.0457		.0514	
10	.0457	.0343	.0686			.0514	
11	.0305		.0686	.0305		.0343	1.2803
12	.0305		.0514	.0305		.0514	
13	.0457	.0514	.0514	.0457			
14	.0457	.0686	.0514	.0457			
15	.0457	.0514		.0457			
16	.0762	.0686	.0514	.0457		.0857	1.4632
17		.0686	.0514	.0457		.0514	.0305
18		.0514	.0686	.0457		.0686	.0305
19		.0686	.0686	.0457		.0686	.0305
20		.0514	.0686	.0457	.0514	.0686	.0457
21		.0514	.0686	.0457	.0514	.0686	.061
22		.0686	.0514	.0457	.0514	.0686	.061
23		.0514	.0514	.0457	.0514	.0686	.061
24	.0514		.0514	.0514	.0457	.0514	.0686
Max	1.5432	1.2498	1.5947	1.5432	1.3717	1.5775	1.4632
Min	.0305	.0305	.0514	.0305	.0457	.0343	.0305
Avg	.4677	.3476	.4272	.4436	.6407	.4679	.2016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 204 / KASARWADI GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3258	.1715	.1715	.3258	.2572	.2401
2	.1715	.3258	.1715	.1715	.3429	.2572	.2401
3	.1715	.3258	.1715	.1715	.3601	.2572	.2401
4	.1715	.3258	.1715	.2572	.3601	.2572	.2743
5	.2572	.3258	.3429	.3601	.4458	.3429	.3429
6	.4287	.6001	.6001	.6001	.6344	.4287	.3944
7	.6516	.6344	.6001	.6344	.6344	.6001	.6001
8	.4287	.4973	.4287	.463	.4973	.4973	.5658
9	.4287	.4801	.2572	.3944	.4287	.4458	.463
10	.2572	.3772	.1715	.3429	.2915	.1543	.2572
11	.2915	.1715		.2229	.2401	.1372	.2915
12	.2915	.1143	.1715	.2229	.1715	.1715	
13	.2401	.1715	.1715	.2229		.1715	
14	.2058	.1715	.1715	.2058	.1715	.1715	.1886
15	.1715	.1715	.1715	.2058	.1715	.1715	.2572
16	.2915	.1715	.1715	.1886	.2058	.1715	.2572
17	.3429	.1715	.2058	.2743	.2401	.2229	.2572
18	.3944	.1715	.2572	.2743	.3258	.2915	.3429
19	.5144	.4287	.3429	.3429	.3258	.463	.5144
20	.4973	.4287	.4287	.4801	.4801	.5316	.5316
21	.463	.2572	.3429	.4973	.4287	.463	.5316
22	.463	.2058	.2572	.4973	.3772	.3429	.4801
23	.4458	.1715	.2058	.3601	.3429	.2743	.4287
24	.1715	.3429	.1715	.1715	.3086	.2915	.2401
Max	.6516	.6344	.6001	.6344	.6344	.6001	.6001
Min	.1715	.1143	.1715	.1715	.1715	.1372	.1886
Avg	.3301	.3070	.2677	.3222	.3526	.3072	.3609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 205 / 11 KV Maruti Technofab NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1715	.0857	.2229	.2401	.1886	.2229
2	.1543	.1715	.0857	.2401	.2401	.1886	.2229
3	.1543	.1715		.2229	.2401	.1886	.2058
4	.1715	.1715	.0857	.2401	.2401	.2058	.2058
5	.1715	.1715	.0572	.2743	.2229	.1886	.2058
6	.1715	.1715	.0686	.2743	.2229	.2058	.2229
7	.1886	.1543	.0686	.2572	.2229	.1886	.2401
8	.1715	.0686	.0857	.2401	.2401	.2058	.0857
9	.2058	.0686	.1372	.2743	.1372	.1715	.0686
10	.2058	.0686	.1372	.2915	.2229	.1886	.0857
11	.2401	.0857	.1372	.3086	.2058	.2229	.0514
12	.2572	.0686	.1715	.2915	.2229	.2229	
13	.2229	.0857	.2058	.2915	.2572	.2572	
14	.2058	.0857	.2229	.2743	.2743	.2572	.0686
15	.2058	.0686	.2572	.2572	.2743	.2572	.0686
16	.12	.0857	.3086	.2401	.2572	.2572	.0686
17	.1886	.0686	.2915	.2229	.1886	.2743	.0857
18	.1886	.0686	.3258	.2229	.1886	.1543	.0857
19	.1715	.0857	.2572	.2401	.2229	.2401	.1029
20	.1715	.0857	.1886	.2572	.2915	.2401	.12
21	.1715	.0857	.2229	.2401	.1715	.1543	.1372
22	.1715	.0857	.2058	.2229	.1715	.2401	.2058
23	.1715	.0857	.2229	.2229	.1715	.2401	.2058
24	.2401	.1715	.0857	.2229	.2401	.1715	.2229
Max	.2572	.1715	.3258	.3086	.2915	.2743	.2401
Min	.12	.0686	.0572	.2229	.1372	.1543	.0514
Avg	.1865	.1086	.1702	.2522	.2236	.2129	.1450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 201 / Industrial Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.4481	.3048	.4486	.362	.4001	.2286
2	.2286	.3772	.2667	.4162	.381	.3429	.2286
3	.1905	.3018	.2667	.362	.3429	.3429	.2286
4	.1905	.2587	.2667	.3239	.3429	.3429	.2286
5	.2286	.3429	.2858	.3048	.3239	.3429	.2477
6	.2667	.362	.3048	.362	.3048	.3429	.2477
7	.2858	.5144	.4001	.4191	.381	.4572	.3239
8	.3395	.4066	.4472	.4321	.3772	.4382	
9	.2858	.3048	.4644	.4504	.5041	.4527	
10	.563	.5573	.4435	.5067	.695	.4715	
11	.7499	.6632	.5914	.5975	.7316	.5975	
12	.7828	.7444	.7499	.8215	.7865	.7023	
13	.7322	.714	.6878	.7468	.7682	.5544	
14	.6647	.483	.6089	.5601	.695	.4108	
15	.5436	.6943	.5401	.5442	.6516	.4481	
16	.6251	.5883	.6805	.6005	.8775	.6161	
17	.7023	.5544	.6048	.5601	.7522	.5205	
18	.563	.4668	.5143	.5067	.6878	.4554	
19	.5201	.415	.4854	.4338	.6584	.3239	
20	.5415	.3772	.4486	.3961	.6435	.3985	
21	.5415	.3429	.462	.3961	.5533	.3048	
22	.5448	.3048	.5196	.4382	.499	.2286	
23	.4692	.2858	.4133	.4191	.4854	.2667	
24	2.5339	.4504	.3429	.482	.381	.4382	.2286
Max	2.5339	.7444	.7499	.8215	.8775	.7023	.3239
Min	.1905	.2587	.2667	.3048	.3048	.2286	.2286
Avg	.5559	.4566	.4625	.4804	.5494	.425	.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 202 / Gaothan Fdr

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4108	.4129	.4137	.4294	.4495
2	.3961	.4294	.4129	.4145	.4294	.4504
3	.4338	.4481	.4108	.4531	.4504	.4884
4	.5658	.5041	.4854	.5098	.5255	.5636
5	.7733	.5788	.5788	.6783	.6283	.7341
6	.9431	.8445	.8775	.9421	.924	.944
7	.8299	.882	.8962	.7341	.8871	.8471
8	.7882	.8632	.7506	.6542	.7207	
9	.5556	.5963	.6535	.5601	.5914	
10	.4385	.4582	.499	.4668	.5201	
11	.3841	.4011	.4435	.3361	.4066	
12	.3721	.3457	.3658	.3361	.3326	
13	.3793	.3601	.3258	.3361	.3142	
14	.3769	.3224	.3077	.3361	.3326	
15	.4119	.2999	.2896	.3547	.2987	
16	.4294	.3196	.3258	.3547	.3361	
17	.4294	.3801	.3494	.3734	.3919	
18	.4207	.4572	.4243	.4108	.452	
19	.6161	.924	1.0858	.7468	.7362	
20	.7095	.8402	.7362	.7842	.7802	
21	.5818	.6602	.6136		.7052	
22	.499	.5658	.5578	.5847	.5969	
23	.4481	.4715	.4508	.5281	.5046	
24	1.0816	.4108	.4108	.4329	.4294	.4495
Max	1.0816	.924	1.0858	.9421	.924	.944
Min	.3721	.2999	.2896	.3361	.2987	.4495
Avg	.5533	.5323	.5277	.5105	.5301	.6158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 203 / Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
8		1.2059
9		.5121
24	2.915	
Max	2.915	1.2059
Min	2.915	.5121
Avg	2.915	.859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 204 / Shelgaon(m)Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.064	.064	.0624	1.0155	.9922	.9328
2	.0312	.048	.048	.0468	.9374	1.0082	.9627
3	.0312	.048	.048	.0468	.9374	1.0082	1.0093
4	.0312	.048	.048	.0468	1.0155		1.0559
5					1.0936	1.0986	1.1335
6					1.2186	1.3283	1.3819
7					1.4842	1.8418	1.7235
8					1.531	1.2483	1.5838
17	2.2565	.9602	1.9817	2.4006			
18	2.2245	2.0805	1.8724	2.2138			
19	1.7284	1.9204	1.5604	1.8976	.064	.0622	.0625
20	1.5043	1.6156	1.3419	1.5813	.064	.0622	.0469
21	1.3443	1.5023	1.2795	1.3441	.048	.0622	.032
22	1.3603	1.4232	1.2795	1.2811	.048	.0466	.0312
23	1.4083	1.3757	1.2327	1.2498	.048	.0466	.0312
24	1.2967	1.3603	1.3443	1.1859	1.1717	.048	.0466
Max	2.2565	2.0805	1.9817	2.4006	1.531	1.8418	1.7235
Min	.0312	.048	.048	.0468	.048	.0466	.0312
Avg	1.1040	1.0372	1.0084	1.1131	.7626	.6810	.7167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 205 / DEVGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8802	.5121	.5655
2					.8802	.7682	.6947
3					.8002	.7682	.7593
4					.7682	.7682	.8401
5					.7202	.8724	1.1309
6					.6401	1.0082	1.1956
7	1.4575	1.3123	1.3603	1.3425			
8	1.9109	1.6324	1.4563	1.5043			
9	2.068	1.702	1.2803	1.4883			
10	1.9387	1.7469	1.0402	1.4883			
11	1.858	.8735	1.1203	1.4243			
12	1.761	1.2617	1.2003	1.3603			
13	1.294	1.3749	1.3603	1.2003	1.2963	1.6004	
14	1.3587	1.3264	1.3123	1.2483	1.5061	1.5203	
15	1.3911	1.3264	1.1523	1.2483	1.5384	1.4723	
16	1.3117	1.3927	1.2003	1.2803	1.5203	1.4403	1.3923
17	1.2963	1.2955	1.3425	1.1203	1.2803	1.4217	1.2803
18	1.2963	1.1984	1.0514	1.0402		1.2925	1.3603
19	1.2963	1.7814	1.4881	1.1203	.9602	1.1956	1.1523
20	1.2803	1.5384	1.3587	1.0402	.8322	.9855	1.0883
21	1.2803	1.2955	1.2617		.8322	.8401	.9602
22	1.1843	1.166	1.1484	1.1523	.8162	.7755	.8802
23	1.0402	.9717	.9705	1.0402	.8162	.7109	.8002
24	1.004	.9282	.9282	.8573	.9602	.7042	.6624
Max	2.068	1.7814	1.4881	1.5043	1.5384	1.6004	1.3923
Min	1.004	.8735	.9282	.8573	.6401	.5121	.5655
Avg	1.4460	1.3402	1.2240	1.2327	1.0028	1.0365	.9842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 201 / Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.1886		.2241	.1715	.2263
2	.2263	.2263	.2058		.2241	.2058	.2263
3	.2263	.2263	.2058		.2614	.2401	.2641
4	.3018	.2829	.2058		.3361	.3086	.3395
5	.415	.3584	.4115		.4481	.4115	.4527
6	.5281	.6036	.4973		.5975	.5487	.5658
7	.5658	.5658	.4801		.6161	.4801	.5658
8	.5281	.5175	.4108	.5281	.4481	.4115	.4527
9	.3772				.3429	.3395	.3018
10	.2926	.3429	.2641	.2587	.2229	.2987	.2353
11	.2172	.2401	.2263	.181	.1029	.2241	.181
12		.1715	.1132	.1448	.1372	.1886	.1448
13	.181		.1132	.1448	.1372	.0151	
14	.181	.1886				.0075	.1448
15	.181				.1372	.1132	.1448
16	.1991	.2058	.1132	.1991	.1543	.1509	.1448
17	.2534	.2058		.2353	.1715	.1509	.181
18	.3258	.2401	.4527		.1715	.1886	.1991
19	.439	.4115	.415	.4525	.3429	.415	.3696
20		.3772			.4115		.4066
21		.3429			.3429	.3772	.3326
22		.2572		.3292	.2743	.2641	.2987
23	.2587	.2229	.2263	.2195	.2058	.2263	.2241
24	.5668	.2218	.2058	.2263	.2241	.2058	.2263
Max	.5668	.6036	.4973	.5281	.6161	.5487	.5658
Min	.181	.1715	.1132	.1448	.1029	.0075	.1448
Avg	.3245	.3064	.2786	.2654	.2841	.2584	.2882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 202 / Shripat-Pimpri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2801			1.7814	1.0402	1.1888
2	.2614	.2801			1.7814	.9602	1.406
3	.2614	.2801			1.9109	1.3717	1.7604
4	.2614	.2801			1.9757	1.6766	1.9204
5	.2614	.3174			2.17	1.9204	2.1862
6	.2614	.3361			2.5263	2.2558	2.2672
7					2.9797	2.7435	3.0769
8					2.7854	2.8045	2.9473
9					1.5089	3.0148	2.6882
10	2.2672	1.5546		2.1052			
11	2.7206	2.6825		2.332			
12		2.8349		3.2388			
13	3.2388	2.8045		2.9473			
14	3.3036	2.9264					
15	3.2712						
16	2.9797						
17	2.3644	1.829		2.915			
19	.4108	.3772		.3734	.3429	.3734	.3547
20		.3086			.3429	.3734	.3734
21					.3086	.3734	.2987
22				.2614	.2743	.2614	.2534
23	.2987		.2241	.2614	.2743	.2241	.2614
24	2.2672	.2801		.2241	1.3765	.8802	1.0536
Max	3.3036	2.9264	.2241	3.2388	2.9797	3.0148	3.0769
Min	.2614	.2801	.2241	.2241	.2743	.2241	.2534
Avg	1.5432	1.1581	.2241	1.6287	1.4893	1.3516	1.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 203 / Shendri Feeder AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	.663	.7468		.1829	.1181	.1654
2	1.3375	.663	.5944		.1829	.1181	.1654
3	1.3203	.7087	.9202		.1829	.1383	.1867
4	1.3203	.9259	1.1469		.1829	.1467	.1867
5	1.5242	1.4022	1.1736		.1981	.1943	.1867
6	1.829	1.8595	1.2803			.2134	.1867
7	2.2862	2.3777	2.1338				
8		2.2558		2.1338			
9		1.7604		1.8671			
10					.9869	1.0288	1.2269
11					2.1948	.2743	
12					2.5606	2.7435	
13					2.6216	1.6004	
14					2.5301	1.6004	
15					2.3167	2.4387	
16					2.4996	2.4387	
17					2.3777	2.4082	
19	.1867	.2		.2143	.16	.2286	.2134
20		.1715			.1734	.2286	.2134
21		.1734			.1734	.2	.2134
22		.1467		.16	.1257	.2	.1734
23	.1372	.1257	.1867	.16	.1143	.2	.1619
24	4.1105	.663	.6687	.6687	.16	.1257	.16
Max	4.1105	2.3777	2.1338	2.1338	2.6216	2.7435	1.2269
Min	.1372	.1257	.1867	.16	.1143	.1181	.16
Avg	1.5389	.9398	.9835	.8673	1.0487	.8322	.2646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 201 / 11 KV Gaudgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4115	.463	.463	.4801	.4268	.4801
2	.4268	.4115	.463	.463	.4801	.4268	.4801
3	.4572	.4115	.463	.463	.5487	.4268	.5144
4	.5792	.4572	.4973	.5144	.6173	.4268	.6859
5	.823	.7164	.823	.6516	.8916	.6097	.9431
6	.9145	.8078	.9945	.9945	1.0288	.9145	.9431
7	1.0212	.8993		.9945		.8993	1.0631
8	1.0517	.8078		.8059		.7621	.823
9	1.0517	.7202	.8059	.6516	.7011	.6859	.6097
10	1.0517	.6001	.6859	.7545	.7316		.4572
11	1.0059	1.0288	.8916	.9259	.7621	.8573	
12	.9755	1.0631	.8573	.9259	.8383	.9945	
13	.945	1.0631	.9431	.9602	.8993	.9945	
14	.3353	1.0631	.9431	.8916	.9145	.9431	
15	.3353	1.0631	.9431	.8573	.9145	.9431	
16	.3353	1.0631	.9945	.9431	.9145	.9431	
17	.3353	1.0288	.9945	.9602	.8383	.9431	
18	.4572	.4287	.5658	.4458	.6097	.6859	.5792
19	.7621	.8916	.8059	.8573	.884	.9945	
20	.7316	.9945	.7716	.8573	.8688	.9945	.8993
21	.6706	.9602	.6859	.7202	.6401	.8916	.6859
22	.503	.8573	.5487	.583	.5944	.7545	.6097
23	.4268	.5487		.5487	.4877	.6516	.503
24	.4268	.4115	.463	.463	.4801	.4268	.4801
Max	1.0517	1.0631	.9945	.9945	1.0288	.9945	1.0631
Min	.3353	.4115	.463	.4458	.4801	.4268	.4572
Avg	.6687	.7795	.7430	.7373	.7330	.7651	.6723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 202 / 11 KV Raulgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2743	.2915	.2915	.3086	.2743	.3429
2	.3353	.2743	.2915	.2915	.3086	.2743	.3429
3	.381	.2743	.2915	.3086	.3429	.2743	.3429
4	.4572	.3353	.4287	.3429	.4115	.2743	.3772
5	.5944	.5335	.823	.3944	.583	.381	.7202
6	.5944	.6249	.823	.7716	.7888	.7164	.7716
7	.5639	.7164	.8059	.8059	.7545	.6859	.8059
8	.5639	.5792	.5487	.6344	.6516	.5639	.6859
9	.3353	.7202	.4287	.4801	.3963	.5487	.4572
10	.2896	.7202	1.286	1.0288	1.3413	1.2003	.3658
11	.2896	1.8861	1.4575	1.4746	1.2803	1.8861	
12	.2134	1.9204	1.8004	1.6461	1.448	2.0576	
13	.2134	1.9204	1.8861	1.7833	1.5242	2.0576	
14	2.1338	1.9204	1.8861	1.8176	1.5851	2.0576	
15	2.1338	2.0919	1.8861	1.7147	1.5851	2.0576	
16	2.1338	1.8861	1.8861	1.7147	1.5242	2.0576	
17	2.1338	1.8519	1.7147	1.9204	1.448	2.0576	
18	2.1338	.2915	.6173	.2058	.442	.3772	.2439
19	1.5242	.5487	.6516	.583	.5792	.7202	.6097
20	1.2193	.823	.6001	.6859	.5487	.6859	.6097
21	1.1584	.7888	.4287	.4801	.4572	.5487	.4268
22	.3658	.6173	.4287	.3772	.3658	.4287	.3506
23	.2896	.4115	.3772	.3429	.3048	.3429	.3048
24	.3658	.2743	.2915	.2915	.3086	.2743	.3429
Max	2.1338	2.0919	1.8861	1.9204	1.5851	2.0576	.8059
Min	.2134	.2743	.2915	.2058	.3048	.2743	.2439
Avg	.8650	.9285	.9138	.8495	.8037	.9501	.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 203 / 11 KV Bhalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.3565	1.2003	1.3717	1.4403	1.829	1.6289
2	1.5242	1.3565	1.2003	1.3717	1.4403	1.829	1.6289
3	1.5242	1.3565	1.3717	1.3717	1.4746	1.829	1.6289
4	1.5242	1.4937	1.3717	1.3717	1.8176	1.829	1.7147
5	1.5242	1.6766	1.3717	1.5432	1.8861	2.0119	1.8861
6	.5335	1.829		1.7147	2.0576	2.1338	1.9719
7	.5335	1.89	2.0233		2.4006	2.2558	2.2805
8	.503	1.7528	2.1434	2.1434	2.572	2.4082	2.2805
9	.3048	1.9719	2.1434	2.1262	2.2862	2.572	1.9814
10	.1981	.3086	.2915	.3086	.2134		1.9814
11	.1981	.2572	.2058		.1829	.2572	
12	.2134	.2229	.2058	.2401	.1829	.3086	
13	.2134	.2058	.2058	.2401	.1829	.3086	
14	.1829	.2058	.1715	.2058	.1829	.2743	
15	.1829	.2058	.1715	.1715	.1829	.2572	
16	.1829	.2058	.1715	.2058	.1829	.2058	
17	.1829	.2572	.2229	.2058	.2286	.2058	
18	.2743	.2572	.5144	.2401	.3353	.2401	.2591
19	.4572	.6516	.6516	.5487	.4877	.6516	.5639
20	.4572	.6859	.6516	.4115	.4572	.6516	.5639
21	.3658	.6859	.463	.4458	.4115	.6001	.381
22	.3048	.5144	.4287	.3429	.3048	.463	.3048
23	.2591	.2572	.4287	.3086	.2743	.3086	.2439
24	1.6004	1.3565	1.2003	1.3717	1.406	1.5546	1.6289
Max	1.6004	1.9719	2.1434	2.1434	2.572	2.572	2.2805
Min	.1829	.2058	.1715	.1715	.1829	.2058	.2439
Avg	.6186	.8734	.8178	.8301	.9413	1.0863	1.3487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 201 / 11 Kv pathari Gaothan

GAOTHAN FEEDER

feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.12	.1029	.1372	.1029	.12	.1543
2	.12	.12	.1029	.12	.1029	.12	.1543
3	.12	.1715	.1372	.12	.1372	.1543	.1543
4	.1715	.2401	.1715	.12	.1372	.1886	.1886
5	.2743	.2915	.3086	.1715	.3429	.2915	.2743
6	.3601	.3944	.3772	.3086	.3772	.4287	.3601
7	.3772	.4115	.4115	.3944	.4115	.3429	.4287
8	.3258	.3429	.3086	.3601	.3086	.2572	.3772
9	.2915	.2401	.2058	.2401		.1715	.2743
10	.1886	.2058	.1029	.1372	.1372	.1029	.1886
11	.1372	.1715	.0686		.0857	.0857	.1029
12	.12		.0686	.1029	.1029	.0857	
13	.1029	.1029	.0857	.1029	.1029	.1029	.1029
14	.1029	.0686	.1029	.1029	.1029	.1029	.1029
15	.1372	.0686	.1029	.1029	.0857	.12	.1029
16	.1372	.0686	.1029	.1029	.1029	.1029	.1029
17	.12	.1029	.1029	.0857	.1029	.12	.1029
18	.1372	.2058	.1372	.1372	.12	.1543	.1372
19	.2572	.3086	.3086	.2058	.2572	.3086	.2743
20	.2229	.3429	.2915	.2743	.3086	.3086	.3429
21	.2058	.2743	.2229	.2058	.2401	.2401	.2743
22	.1543	.1715	.1715	.1715	.2058	.2229	.2058
23	.1372	.1372	.1372	.1372	.1543	.1715	.1715
24	.1372	.12	.1029	.1372	.1029	.1372	.1715
Max	.3772	.4115	.4115	.3944	.4115	.4287	.4287
Min	.1029	.0686	.0686	.0857	.0857	.0857	.1029
Avg	.1858	.2035	.1765	.1730	.1797	.1850	.2065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 202 / 11 Kv Dhanore Ag feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9945	1.166	1.0974
2					.9602	1.1145	1.0974
3					1.0288	1.1488	1.1317
4					1.2346	1.2003	1.166
5					1.2689	1.3032	1.3546
6					1.3375	1.3717	1.5604
7						1.5432	1.6118
8						1.5432	1.4918
9						1.4232	1.4575
10	1.6289	1.406	1.3032				
11	1.989	1.5775	1.6118	1.5432			
12	2.1091		1.8004	1.6804			
13	2.0919	.3429	1.8861	1.749			
14	2.0576	1.3717	1.8176	1.7147			
15	2.0062	1.7147	1.8004	1.749			
16		1.8519	1.7147	1.6118			
17		1.7833	1.6975	1.5432			
24					1.0288	1.0974	1.0631
Max	2.1091	1.8519	1.8861	1.749	1.3375	1.5432	1.6118
Min	1.6289	.3429	1.3032	1.5432	.9602	1.0974	1.0631
Avg	1.9805	1.4354	1.7040	1.6559	1.1219	1.2912	1.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 203 / 11 KV Pimpalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.7545	.7202	.7888		
2	.9259	.7545	.7202	.7716		
3	.9259	.7202	.7545	.823		
4	.9431	.7545	.7888	.8745		
5	.9945	.7888	.8573	.8745		
6	1.0117	.9259	.9259	.9088		
7	1.0631	1.0974	.9602	.9088		
8	.9431	.9602	.9602	.9259		
9	.8916	.9259	.9259	.9088		
10				.8573	.7545	.7545
11					1.0117	1.0802
12					1.1488	1.1145
13					1.1317	1.1145
14					1.1317	1.1488
15					1.0631	1.0974
16					1.166	1.1145
17					1.0631	1.0631
24	.9602	.7373	.6859	.7202		
Max	1.0631	1.0974	.9602	.9259	1.166	1.1488
Min	.8916	.7202	.6859	.7202	.7545	.7545
Avg	.9619	.8419	.8299	.8511	1.0588	1.0609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 201 / 11 KV DAM FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.5944	.6706	.884	.8383
2	.884	.945	.7621	.7621	.8688	.8383
3	.884	.945	.7621	.884	.8383	.8383
4	.884	.884	.7164		.8688	.8383
5	.9145	.9145	.945		.8688	.884
6	.9145	.9145	.9755	.945	.9145	.9145
7	.9145	.9145	.9907	.442	.9297	.945
8	.945		.945		.9145	1.0364
9	.9145	1.0059	.9145		.945	1.0364
23					.7621	
24	.945	.4572	.4268	.6097	.8688	.7621
Max	.945	1.0059	.9907	.945	.945	1.0364
Min	.884	.4572	.4268	.442	.7621	.7621
Avg	.9115	.8772	.8033	.7189	.8785	.8932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 202 / 11 KV TANDULWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.061	.061	.0457	.061	.061	.2439
2	.061	.061	.0457	.0914	.061	.061	.2134
3	.061	.061	.0457		.061	.0762	.381
4	.0762		.061		.0914	.0762	.3963
5	.0914	.1219	.1067	.1067	.1067	.0914	.4115
6	.1219		.1524		.1524	.1372	.4115
7	.1524		.1677		.1677	.1677	.381
8	.1677	.1219		.1372	.1372	.1524	
9	.1219		.0914		.1067	.0914	
10	.442		.3963		.3506	.3506	
11	.6554		.5335	.5487		.4572	
12	.6097		.3201		.5792	.4877	
13	.6097		.5335		.5792	.5335	
14	.6097		.5944	.5639	.5487	.5792	
15	.6401	.5639	.5792		.5182	.6097	
16	.6706		.4877		.5487	.6097	
17	.6097		.4877	.5639	.5487	.6097	
18	.0914	.061	.0762		.061	.061	.1067
19	.1219		.1219		.1067	.0914	.1372
20	.1219		.0914	.1219	.1372	.1219	.1219
21	.0914	.1219	.1067		.1219	.0914	.1067
22	.0914		.1372	.1067	.1067	.0762	.1067
23	.0762	.0762	.0914	.0762	.0914	.0762	.0762
24	.0762	.061	.061	.0762	.0762	.0762	.0762
Max	.6706	.5639	.5944	.5639	.5792	.6097	.4115
Min	.061	.061	.0457	.0457	.061	.061	.0762
Avg	.2686	.1311	.2326	.2217	.2313	.2394	.2264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274235 / 33/11 KV RATANJAN SUB

STATION

Feeder No / Name : 201 / 11 KV GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2229	.2229	.2058	.2229	.2401	.2058
2	.2572	.2058	.2229	.2229	.2572	.2401	.2058
3	.3086	.2572	.2401	.2229	.2572	.2572	.2229
4	.3601	.3086	.2743	.2401	.3086	.2915	.2572
5	.4287	.3601	.3258	.4115	.3429	.3601	.2915
6	.463	.4458	.3944	.4458	.3772	.3772	.3944
7	.4115	.4287	.4115	.4115	.4115	.4115	.4115
8	.3772	.3772	.3601	.3772	.3086	.3429	.3772
9	.2743	.2915	.2915	.3429	.2401	.2401	.2915
10	.2572	.2915	.2401	.2401	.1715	.2229	.1886
11	.2229	.1886	.1886	.2229	.1372	.1886	.1372
12	.1886		.1543	.1543	.0686	.1543	.1372
13	.1715	.1715	.12	.1372	.1372	.1372	.1543
14	.1543	.1715	.1543	.1715	.1372	.1543	.1372
15	.2058		.1886	.1715	.1715	.1372	.12
16	.1886	.1715	.1715	.1543	.1715	.12	.1372
17	.2229	.1886	.1886	.1543	.1715	.12	.1372
18	.2229	.2572	.2058	.1543	.2058	.12	.1886
19	.3258	.3601	.3601	.3086	.3258	.3429	.3086
20	.3601	.3772	.3772	.3772	.3772	.3601	.3772
21	.3086	.3258	.3258	.3258	.3258	.3258	.3601
22	.2401	.2743	.2572	.2572	.2401	.3086	.3086
23	.2229	.2058	.2401	.2229	.2229	.2572	.2572
24	.1715	.2058	.2229	.2229	.2229	.2058	.2229
Max	.463	.4458	.4115	.4458	.4115	.4115	.4115
Min	.1543	.1715	.12	.1372	.0686	.12	.12
Avg	.2729	.2767	.2558	.2565	.2422	.2465	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274236 / 33/11 KV DHAMANGAON SUB

STATIO

Feeder No / Name : 201 / 11 KV RALERAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2896	.2715	.2715	.2534	.3258
2	.2896		.2715			
3	.2899	.362		.2926		.3982
4	.3261				.362	
5	.3982	.4525	.3658			
6	.5068	.4525		.5792	.4525	.6355
7	.6516	.5068	.5068	.4706		.6335
8	.5792	.5792	.439	.4887	.543	.6878
9	.5792		.5121		.5068	
10	.4716	.4572	.6878	.724	.5068	.6878
11	1.5604	1.3717	1.0974	1.0288	1.286	1.3032
12	1.9547	1.4403	1.2517		1.1145	1.3717
13	1.8861	1.4575	1.3203	1.2003	1.4746	1.2003
14	1.8004	1.4575	1.3717	1.286	1.3375	1.4403
15	1.6289	1.3375	1.3717	1.2346	1.3375	1.2003
16		1.4403	1.4575	1.3032	1.286	1.2003
17	1.4575	1.406	1.4403	1.2003	1.3375	1.2346
18	.4525	1.286		.4801	.3258	.2534
19		.5068				
20	.362		.5121			.5068
21		.362		.362	.4024	
22			.2561	.2926	.3982	.362
23	.2929	.2926	.2534	.2929	.362	.2896
24	.3364	.2534	.3077	.2534	.2534	.362
Max	1.9547	1.4575	1.4575	1.3032	1.4746	1.4403
Min	.2896	.2534	.2534	.2534	.2534	.2534
Avg	.8057	.8269	.7608	.6918	.7522	.7830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
stati

Feeder No / Name : 201 / 11KV TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.9193	.8825	.9717	.8779	.8326	.9009
2	.7865	.9009	.9009	.8573	.823	.7602	.9193
3	.7316	.8825	.9193	.8192	.7865	.7602	.8825
4	.7316	.8457	.9009	.8383	.7865	.905	.9193
5	.823	.9009	.9193	.9526	.823	.9231	.9744
6	.9694	.956	.9928	1.0479	.9511	.9412	.9376
7	1.0608	1.0296	1.048	1.0669	1.0059	.905	.9744
8	.9145	1.0112	1.0663	1.1431	.9145	.905	.9928
9	.9193	.9928	.9744	1.0479	.8413	.7964	1.0112
10	1.1031	1.0663	1.1431	.8413	1.086	.956	1.0479
11	1.1767	1.1031	1.2384	.9145	1.1946	1.048	1.1431
12	1.1399	1.1215	1.1431	1.0059	1.1946	1.0296	
13	1.1031	1.1767	1.086	.9877	1.2127	.9928	1.1431
14	1.1399	1.195	1.0479	.9145	1.0498	.956	1.2384
15	1.195	1.1767	1.2384	.9511	1.086	.9928	1.2003
16	1.2134	1.195	1.2574	1.0059	1.267	.9744	1.2574
17	1.2502	1.2318	1.2765	.9694	1.1222	1.0663	1.2955
18	1.1583	1.3421	1.3336	1.0059	1.267	1.1399	1.6194
19	1.5076	1.5995	1.5242	1.3169	1.6108	1.2502	1.7147
20	1.3789	1.434	1.7147	1.2803	1.4842	1.3053	1.7147
21	1.2686	1.287	1.5813	1.1523	1.3756	1.2502	1.5242
22	1.0296	1.1767	1.4289	1.0974	1.1946	1.2134	1.2384
23	.956	1.0112	1.3336	.9694	1.0317	1.0663	1.1431
24	.8779	.9009	.9193	1.0479	.9145	.905	.9376
Max	1.5076	1.5995	1.7147	1.3169	1.6108	1.3053	1.7147
Min	.7316	.8457	.8825	.8192	.7865	.7602	.8825
Avg	1.0524	1.1024	1.1613	1.0086	1.0792	.9948	1.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 202 / 11 KV INDUSTRIAL ESTATE SHEDDABLE FEEDER HAVING WEEKLY
NO.02 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.4158	.3591	.4191	.3961	.3258	.2457
2	.2075	.4347	.3969	.4763	.3772	.3258	.2835
3	.1886	.3969	.4158	.4572	.3395	.2896	.2646
4	.1698	.378	.4158	.4191	.3206	.2743	.2457
5	.2075	.4158	.4536	.381	.2829	.2715	.2268
6	.3206	.4725	.4725	.4191	.3206	.2715	.2646
7	.415	.5292	.5103	.4954	.415	.2534	.3213
8	.4715	.5103	.5292	.5716	.4715	.2353	.3591
9	.6237	.6804	.5859	.6668	.6979	.2172	.4158
10	.7182	.7371	.7621	.7545	.7059	.2079	.381
11	.7938	.7749	.7621	.8488	.7783	.2079	.381
12	.7938	.7938	.8002	.7545	.8326	.2268	
13	.756	.756	.8383	.6602	.6516	.2268	.2858
14	.7371	.6993	.8573	.6224	.5792	.2079	.2477
15	.6993	.567	.6668	.6979	.5792	.2268	.2286
16	.6615	.6237	.6859	.7545	.7602	.2457	.2286
17	.7182	.6615	.7049	.6602	.8507	.2268	.3048
18	.6237	.7182	.7049	.6602	.7964	.2646	.3429
19	.6048	.5292	.6668	.6224	.724	.2835	.2858
20	.5292	.5103	.5144	.6602	.6697	.2646	.2858
21	.4914	.4725	.4763	.547	.6516	.3213	.2858
22	.4725	.4536	.4763	.5093	.4525	.3024	.2858
23	.4725	.4158	.381	.4715	.4344	.2835	.2858
24	.2452	.4347	.378	.381	.4338	.3982	.2646
Max	.7938	.7938	.8573	.8488	.8507	.3982	.4158
Min	.1698	.378	.3591	.381	.2829	.2079	.2268
Avg	.5054	.5576	.5756	.5796	.5634	.2650	.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 203 / 11 KV BHAGAWANT FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2951	.2951	.2477	.2172	.3258	.2213
2	.2012	.2582	.2582	.2858	.1829	.2896	.2029
3	.1829	.2766	.2766	.2667	.1829	.2715	.2213
4	.1829	.2398	.2398	.2477	.2378	.2715	.1844
5	.2561	.2582	.2951	.3429	.3109	.3077	.2398
6	.3475	.3135	.332	.381	.3658	.3439	.2582
7	.4024	.332	.3504		.3475	.3258	.2951
8	.3841	.3504	.3504		.2743	.3439	.2951
9	.2951	.3135	.3135		.3109	.2353	.166
10	.2582	.2951	.2858	.3109	.1991	.2582	.2858
11	.2766	.2766	.2477	.2743	.1629	.2766	.1905
12	.2766	.2398	.2286	.2926	.2534	.2766	
13	.2951	.2582	.2286	.2743	.2353	.2951	.2286
14	.2766	.2582	.2286	.3109	.2353	.2766	.2477
15	.2951	.2582	.1905	.2926	.2353	.2951	.2477
16	.2582	.2951	.2667	.2743	.2534	.3135	.2096
17	.2951	.3135	.2858	.2378	.2715	.332	.2667
18	.2582	.3504	.381	.3658	.2172	.2951	.381
19	.3873	.4242	.4191	.4207	.2534	.2766	.4763
20	.4057	.4057	.4572	.3658	.2715	.2582	.381
21	.3873	.3688	.381	.3292		.2398	
22	.332	.3688	.381	.2926	.2896	.2582	.2858
23	.3135	.3135	.381	.2743	.3801	.2582	.2667
24	.2743	.2951	.2951	.2858	.2378	.362	.2398
Max	.4057	.4242	.4572	.4207	.3801	.362	.4763
Min	.1829	.2398	.1905	.2378	.1629	.2353	.166
Avg	.2950	.3066	.3070	.3035	.2577	.2911	.2632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 203 / 11KV CANCER FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.1203	.9526	1.1203	.9335	1.3203	1.3336
2	1.1203	1.1203	.9526	1.1203	.9335	1.3203	1.3336
3	1.1317	1.1203	.9526	1.1203	.9335	1.1203	1.3336
4	1.1317	1.1203	.9526	1.1203	.9335	1.1203	1.3336
5	1.3203	1.1203	.9526	1.1203	.9335	1.1317	1.3336
6	1.3203	1.1203	.9526	1.1203	.9335	1.1317	1.3336
7	1.1317	1.1203	.9526	1.1203	.9335	1.1203	1.1431
8	1.1317		.9526	1.2696	.9335	.924	1.1431
9	1.1317		.924	.7621		.924	1.1431
10	1.1317	1.3336	1.2936	.9335	1.1203	.724	1.1431
11	1.1203	1.3336	1.307	.9335	1.5089	.9526	1.1203
12	1.1088	1.3336	1.1203	.9335	1.307	1.1431	1.1203
13	.924	1.1431	.9145	.9335	1.1317	.9526	.5487
14	.924	1.1431	1.1203	.9145	1.1317	1.1431	.7392
15	.9335	.9526	1.1203	1.1203	1.3203	1.1431	.9335
16	.9145	.9526	1.307	1.307	1.1317	1.1431	.9431
17	.9335	.9526	1.307		1.1317	1.1431	.7316
18	.9335	.9526	1.307		1.1317	1.1431	.7316
19	.7621	.9526	1.2696		1.1317	1.1431	.9145
20	.9335	.7621	1.1203		1.1317	1.1431	.7392
21	1.1203	.9526	1.1203		1.5089	1.3336	1.1203
22	1.1203	.9526	1.1203	.9145	1.5089	1.5242	1.3203
23	1.1203	.9526	1.307	1.1203	1.3203	1.3336	1.3203
24	1.3203	1.1203	1.1431	1.1203	1.1203	1.3203	1.3336
Max	1.3203	1.3336	1.307	1.307	1.5089	1.5242	1.3336
Min	.7621	.7621	.9145	.7621	.9335	.724	.5487
Avg	1.0850	1.0742	1.1009	1.0581	1.1350	1.1416	1.0913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 204 / 11KV I.T.I. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.5601	.5716	.7468	.4572	.5258	.5716
2	.3429	.5601	.5716	.7468	.5601	.3429	.5716
3	.3467	.5601	.5716	.7468	.5601	.3429	.5716
4	.5258	.5601	.5716	.7468	.5601	.5201	.5716
5	.5316	.4572	.5716	.6097	.4572	.5258	.5716
6	.7164	.5601	.7621	.6859	.7468	.7087	.5716
7	.7164	.5601	.7621	.7468	.7468	.7164	.7621
8	.7164		.7621	.7468	.9335	.7087	.7621
9	.7164		.7164	.7468		.5258	.7621
10	.7087	.7621	.5316	.7468	.5373	.5258	.7621
11	.5316	.7621	.4572	.7468	.5316	.5716	.5258
12	.5316	.7621	.5601	.6554	.5316	.7621	.5258
13	.5258	.7621	.5601	.5601	.7087	.5716	.7087
14	.5601	.7621	.5601		.7164	.7621	.5201
15	.7316	.5716	.5601	.6097	.7164	.5716	.5258
16	.7468	.7621	.5601		.7087	.5716	.5258
17	.7316	.7621	.5601		.7087	.5716	.7011
18	.5601	.7621	.5601		.7087	.7621	.5201
19	.5144	.9526	.5601		.905	.7621	.7087
20	.5601	.7621	.5601		.905	.7621	.7164
21	.5601	.7621	.5601	.5601	.7164	.7621	.7164
22	.4572	.7621	.5601	.5601	.7164	.7621	.7087
23	.5601	.5716	.7468	.5601	.7087	.5716	.5316
24	.5258	.4572	.5716	.7468	.5601	.5316	.5716
Max	.7468	.9526	.7621	.7468	.9335	.7621	.7621
Min	.3429	.4572	.4572	.5601	.4572	.3429	.5201
Avg	.5735	.6706	.5970	.6816	.6696	.6141	.6244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 206 / 11KV MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.4937	1.5242	1.643		1.6804	3.0484
2	1.2803	1.4937	1.3336	1.4937		1.4784	2.6672
3	1.2803	1.2193	1.3336	1.4937		1.2803	2.6672
4	1.4784	1.307	1.3336	1.4937		1.4784	2.6672
5	1.6632	1.307	1.5242	1.4937		1.4784	1.3336
6	1.6804	1.4937	1.7147	1.3717		1.6632	1.5242
7	1.6632	1.8671	2.0957	1.8671		2.0538	1.9052
8	1.6632		2.0957	2.0538		1.8671	1.7147
9	1.4784		1.4632	1.8671		1.2803	1.3336
10	1.6632	1.9052	2.0538	1.8671	1.4784	1.6632	1.5242
11	1.8671	2.0957	2.0538	1.8671	2.0538	1.9052	1.4632
12	2.0538	2.2862	2.2405	1.6766	2.2405	2.0957	1.6632
13	1.6804	2.2862	1.829	1.8671	2.2405	1.9052	1.8671
14	1.6804	1.9052	2.0538	1.8671	2.0538	1.7147	
15	2.0538	2.2862	1.7147	2.2405	2.0538	1.5242	1.2803
16	1.829	2.4768	2.2405	2.2405	2.4272	1.7147	1.2803
17	1.829	2.4768	1.829		2.4272	1.7147	1.4784
18		2.2862	2.0538		2.2405	1.7147	1.4632
19	1.829	2.0957	1.8671		2.0538	1.9052	1.8671
20	1.6766	1.7147	1.8671		1.848	1.7147	1.6632
21	1.4937	1.9052	1.4937		1.6632	1.7147	1.6804
22	1.3717	1.9052	1.4937	1.6804	1.848	1.7147	1.8671
23	1.3717	1.7147	1.4937	1.6804	1.848	1.5242	1.8671
24	.1524	1.4632	1.7147	1.4937		1.6632	3.0484
Max	2.0538	2.4768	2.2405	2.2405	2.4272	2.0957	3.0484
Min	.1524	1.2193	1.3336	1.3717	1.4784	1.2803	1.2803
Avg	1.5747	1.8629	1.7674	1.7504	2.0341	1.6854	1.8641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 207 / 11KV JAIN MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4937	1.3336	1.4937		1.4632	1.5242
2	1.267	1.4937	1.3336			1.267	1.3336
3	1.2536	1.4937	1.3336			1.2536	1.3336
4	1.4632	1.2193	1.3336	1.4937		1.448	1.3336
5	1.6632	1.5432	1.5242	1.2003		1.6632	1.5242
6		1.8671	1.9052	1.4937		1.6632	1.9052
7	1.8671	1.8671	1.9052	1.8671		2.0538	2.0957
8	2.0538		1.9052	1.8442		1.848	1.9052
9	1.6632		1.4632	1.8861		1.6461	1.7147
10	1.4632	1.5242		1.3717	1.448	1.4632	1.5242
11	1.448	1.5242	1.4937	1.3717	1.267	1.3336	1.267
12	1.2536	1.5242	1.307	1.4937	1.2536	1.5242	1.2536
13	1.2536	1.5242	1.307	1.4937	1.2536	1.5242	1.267
14	1.307	1.5242	1.307	1.4937	1.2536	1.5242	1.267
15	1.307	1.3336	1.307	1.4937	1.2536	1.3336	1.267
16	1.307	1.5242	1.307	1.3717	1.448	1.3336	1.2536
17	1.307	1.5242	1.4937		1.448	1.5242	1.448
18	1.3717	1.7147	1.6804		1.4632	1.7147	1.448
19	2.2405	2.0957	2.0538		2.0328	2.0957	2.2405
20		2.0957	2.0119	2.0538	2.2405	2.0957	2.2405
21	1.8671	1.9052	1.5242	1.829	2.0328	2.0957	2.2405
22	1.6804	1.9052	1.8671	1.6804	2.0538	2.0957	2.0328
23	1.4937	1.7147	1.4937	1.3717	1.848	1.7147	1.6461
24	1.448	1.2193	1.5242	1.2193		1.448	1.7147
Max	2.2405	2.0957	2.0538	2.0538	2.2405	2.0957	2.2405
Min	1.2536	1.2193	1.307	1.2003	1.2536	1.2536	1.2536
Avg	1.5118	1.6196	1.5528	1.5538	1.5926	1.6303	1.6159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 208 / 11KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4937	1.3336	1.4937		1.4632	1.3336
2	1.267	1.4937	1.3336	1.4937		1.267	1.3336
3	1.267	1.4937	1.3336	1.307		1.267	1.3336
4	1.2803	1.2003	1.3336	1.307		1.267	1.3336
5	1.4784	1.4937	1.3336	1.307		1.2803	1.5242
6	1.4784		1.5242	1.307		1.4632	1.7147
7	1.6632	1.6804	1.7147	1.4937		1.6632	1.9052
8	1.8671		1.7147	1.8298		1.6461	1.7147
9	1.4784		1.4632	1.6804		1.4632	1.7147
10	1.4632	1.5242	1.448	1.4937	1.4632	1.4632	1.7147
11	1.6632	1.5242	1.643	1.4937	1.6461	1.5242	1.4632
12	1.6632	1.7147	1.6804	1.4937	1.448	1.7147	1.6632
13	1.6461	1.7147	1.4937	1.4937	1.6461	1.5242	1.6632
14	1.6804	1.7147	1.6804	1.4937	1.6461	1.5242	1.6461
15	1.6461	1.5242	1.6804			1.5242	1.448
16	1.6804	1.5242	1.6804	1.307	2.0328	1.5242	1.2803
17		1.5242	1.8671		1.848	1.5242	1.6461
18	1.6804	1.5242	1.8671		1.848	1.7147	1.6461
19	1.8671	2.0957	2.2405		2.4272	1.9052	2.2405
20	1.8671	2.0957	2.2405		2.2405	1.9052	2.2405
21	2.0538	1.9052	1.8671	1.8671	2.0538	1.9052	2.0538
22	1.8671	1.7147	1.8671	1.8671	1.848	1.7147	1.848
23	1.8671	1.5242	1.4937	1.6804	1.448	1.5242	1.6461
24		1.4937	1.3336	1.4937		1.448	1.5242
Max	2.0538	2.0957	2.2405	1.8671	2.4272	1.9052	2.2405
Min	1.267	1.2003	1.3336	1.307	1.448	1.267	1.2803
Avg	1.6230	1.6178	1.6320	1.5212	1.8151	1.5509	1.6513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 213 / 11KV BARSHI TEXTILE MILL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRE Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.024	.9335	.9526	.9335		.9335	.0953
2	.0217	.9335	.9526	.9335		.9335	.0953
3	.0229	.9335	.9526	.9335		.9335	.0953
4	.0206	.9335	.9526	.0168		.9335	.0953
5	.0253	.9335	.9526	.9335		.9335	.0953
6	.0293	.9335	.9526	1.0829		.924	.0953
7	.2477	.9335	.9526	1.0829		.3772	.5716
8	.6478		.9526	.9335		.3715	.9526
9	.9335		.9335	.9335		.3086	.9526
10	.7316	.9526	.9335	.9335	.9335	.3544	.9526
11	.7392	.9526	.9335	.9335	.9335	.5716	.9335
12	.9335	.9526	.9335	.9145	.9335	.5716	.9335
13	.9335		.9335	.9145	.9335	.381	.9335
14	.9335	.9526		.9335	.9335	.381	.9335
15	.9335	.9526		.9335	.9335	.5716	.9335
16	.9335	.9526	.9335	.9335	.9335	.1905	.9335
17	.9335	.9526	.9335		.9335	.0953	.9335
18	.9335	.9526	.8573		.9335	.0953	.9335
19	.9335	.9526	.8573		.9335	.0953	.9335
20	.9335	.9526	.9335		.9335	.0953	.9335
21	.8573	.9526	.7621	.7621	.9335	.0953	.9335
22		.9526	.9335	.9335	.9335	.0953	.924
23	.8573	.9526	.9335	.9335	.9335	.0953	.9335
24	.0293	.9335	.9526	.9335		.9335	.0953
Max	.9335	.9526	.9526	1.0829	.9335	.9335	.9526
Min	.0206	.9335	.7621	.0168	.9335	.0953	.0953
Avg	.5908	.9453	.9266	.8921	.9335	.4696	.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 400 / Stn. T/F

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0486
Max	.0486
Min	.0486
Avg	.0486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 403 / Agalgaon

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2489	1.4786	1.308	1.5432	1.4661	1.3717	1.3649
2	1.1403	1.4218	1.4786	1.5432	1.3717	1.3169	1.308
3	1.086	1.4786	1.3649	1.4861	1.262	1.3169	1.4218
4	1.0317	1.3649	1.4218	1.4289	1.3032	1.3717	1.308
5	1.2489	1.5355	1.5924	1.6004	1.3575	1.4266	1.3649
6	1.5746	1.6492	1.7061	1.829	1.5746	1.4266	1.4786
7	1.7918	1.763	1.763	1.8861	1.7375	1.3717	1.5355
8		1.8198	1.8767	1.8861	1.6289	1.3717	1.5355
9	1.8767	1.8767	1.7061	1.9433	1.8107	1.1523	1.5924
10	1.8198	1.9905	2.1148	1.8107	1.9204	1.308	1.6004
11	2.1611	2.1042	2.2291	1.9204	2.0851	1.4786	1.6004
12	2.1611	2.1611	2.1148	1.9204	2.3045	1.4786	
13	2.0473	2.0473	2.1148	1.8656	2.1399	1.4786	1.5432
14	1.9905	1.9905	2.0576	1.8107	1.9753	1.3649	1.6575
15	1.8767	1.9905	2.0576	1.8656	2.1399	1.4786	1.7147
16	2.0473	2.1042	2.1719	1.9753	2.2497	1.5355	1.7147
17	2.2179	2.1042	2.1719	1.9753	2.1399	1.4218	1.829
18	2.0473	2.1611	2.4006	1.8107	2.2497	1.5355	2.2862
19	2.4454	2.4454	2.4577	2.3045	2.524	1.763	2.4006
20	2.1611	2.3317	2.6292	2.2497	2.3594	1.8198	2.2862
21	1.9905	2.0473	2.3434	1.9547	1.9204	1.763	2.2862
22	1.763	1.8767	2.2862	1.8656	1.8107	1.6492	1.7147
23	1.5924	1.6492	2.0005	1.701	1.7558	1.4786	1.6004
24	1.3575	1.4786	1.4218	1.6575	1.5364	1.5364	1.3649
Max	2.4454	2.4454	2.6292	2.3045	2.524	1.8198	2.4006
Min	1.0317	1.3649	1.308	1.4289	1.262	1.1523	1.308
Avg	1.7686	1.8696	1.9496	1.8264	1.8593	1.4673	1.6743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 407 / 33KV Atlanta Feeder (T/F

1) Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7721	9.5222	2.9721	10.0823		3.3608	3.4294
2	2.7721	9.5222	2.9721	8.2305		2.8006	3.315
3	2.7435		2.9721	10.0823		2.7721	3.315
4	3.2922	9.5222	2.9721	10.0823		3.2922	3.315
5	3.3265	9.8766	3.0293	9.5222		3.3265	3.4294
6	3.8809	8.6877	3.8866	10.0823		3.3265	3.8866
7	3.8809	10.6424	3.8866	11.2026		3.9209	4.0009
8	3.8809		3.8866	11.7627		3.3608	3.8295
9	3.2922		3.2922			3.3608	3.5437
10	3.2922	3.5437	1.6289		3.2922	2.8006	3.4294
11	3.2922	3.5437	3.2922		3.2922	2.9721	
12	3.2579	3.5437	7.316		3.2236	3.5437	2.7721
13	2.7149	3.4294	9.4102		3.2579	3.0293	2.7721
14	8.4019	3.5437	8.9621		3.2922	3.4294	2.7721
15	8.9621	2.9721	8.9621	8.5505	3.2922	2.9721	2.8006
16	8.9621	3.315	9.5222	8.9621	3.2922	3.1436	2.8006
17		3.315		10.0823	3.2579	3.1436	2.7721
18		3.4294			3.2922	3.7151	2.7149
19	11.2026	4.1152	11.2026		3.8409	4.0009	3.9209
20	10.2881	3.6008	9.145		4.3896	4.0009	3.8809
21	10.6424	3.5437	10.6424	10.6424	4.4353	4.1152	3.9209
22	10.0823	3.5437	15.6836	10.0823	4.481	4.2867	3.9209
23	9.5222	3.315	11.2026	10.0823	3.9209	3.5437	3.3608
24	3.3608	7.7732	3.1436	10.0823		3.3951	3.5437
Max	11.2026	10.6424	15.6836	11.7627	4.481	4.2867	4.0009
Min	2.7149	2.9721	1.6289	8.2305	3.2236	2.7721	2.7149
Avg	5.6283	5.4429	6.3629	9.9688	3.6115	3.4006	3.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 408 / 33KV Atlanta Feeder (T/F
2) Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9609	14.0032	5.144	14.5633		5.0926	3.8866
2	3.3951	14.0032		14.5633		4.481	3.5437
3	3.3608	14.0032	4.6868	14.5633		4.481	3.5437
4	3.3608	12.883	4.6868	14.0032		4.9897	3.4294
5	3.9609	12.883	4.8583	14.0032		5.0412	3.4294
6	3.9609	14.0032	5.3155	14.5633		5.0926	3.8866
7	4.5268	14.9177	6.2872	15.6836		5.6584	4.9154
8	5.0926		5.7156	16.8039		5.0926	4.9154
9	4.5268		4.9897	16.2437		4.5268	4.8583
10	5.0412	5.487	5.6013	16.8039	4.9897	5.0412	4.8583
11	4.9383	5.8299	16.8039	15.9122	6.0357	5.2584	4.481
12	5.5441	6.2872	18.4843	16.2437	5.9728	5.7156	5.0412
13	5.0412	6.0014	18.4843	15.3635	6.0357	5.0297	5.0412
14	15.6836	5.7156	19.0444		5.5441	4.6868	3.3608
15	13.7174	6.0014	18.4843		3.9209	4.8583	4.481
16	16.4609	6.2872	18.4843		6.5844	4.5725	4.481
17	16.2437	6.2872	19.0444		6.5158	4.1724	5.0412
18	16.8039	5.8299	18.4843		6.0357	4.4582	4.9897
19	16.8039	6.2872	18.4843		6.653	4.8583	5.6013
20	15.4321	5.7156		17.364	17.9241	4.8583	5.6013
21	16.2437	5.7156	15.6836	16.2437	5.6013	4.6868	5.6013
22	15.1235	5.7156	15.6836	16.2437	5.6013	4.5725	5.6013
23	15.1235	5.2584	15.1235	14.5633	5.6584	4.1152	5.6584
24	3.9609	14.0032	5.3155	14.5633		5.0926	4.1152
Max	16.8039	14.9177	19.0444	17.364	17.9241	5.7156	5.6584
Min	3.3608	5.2584	4.6868	14.0032	3.9209	4.1152	3.3608
Avg	9.0961	8.7781	12.0405	15.4607	6.6481	4.8514	4.5984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 201 / 11 KV JEUR URBAN GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4575	.4382	.5201	.5201	.5201	.5258	.4334
Max	1.4575	.4382	.5201	.5201	.5201	.5258	.4334
Min	1.4575	.4382	.5201	.5201	.5201	.5258	.4334
Avg	1.4575	.4382	.5201	.5201	.5201	.5258	.4334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 203 / 11 KV DAHIGAON-SHETFAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.6578	2.6873	2.774	2.6873	1.9071	2.4272	.1753
Max	2.6578	2.6873	2.774	2.6873	1.9071	2.4272	.1753
Min	2.6578	2.6873	2.774	2.6873	1.9071	2.4272	.1753
Avg	2.6578	2.6873	2.774	2.6873	1.9071	2.4272	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 204 / 11 KV DAHIGAON W/S NON SHEDDABLE WATER SUPPLY AND
EXPRESS Feeder KV- 11 / UTILITY
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0876	.1734	.2629	.3506	.2629	.3544	.4382
Max	.0876	.1734	.2629	.3506	.2629	.3544	.4382
Min	.0876	.1734	.2629	.3506	.2629	.3544	.4382
Avg	.0876	.1734	.2629	.3506	.2629	.3544	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 205 / 11 KV PANGARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.6083	.1658	.1658	.1658	.1658	.1696	1.1022
Max	2.6083	.1658	.1658	.1658	.1658	.1696	1.1022
Min	2.6083	.1658	.1658	.1658	.1658	.1696	1.1022
Avg	2.6083	.1658	.1658	.1658	.1658	.1696	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 206 / 11 KV WANGI NO-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.2234	.1353	.1334	.1372	.1429	.1429	2.1434
Max	2.2234	.1353	.1334	.1372	.1429	.1429	2.1434
Min	2.2234	.1353	.1334	.1372	.1429	.1429	2.1434
Avg	2.2234	.1353	.1334	.1372	.1429	.1429	2.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
J

Feeder No / Name : 207 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 201 / 11 KV KANDAR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3353						
7	.3353						
8	.3658	.2743	.3353	.2743	.2743	.3048	.3048
9	.381	.3048	.3048	.3048	.2743	.3048	.2743
10	.3048	.3048	.3048	.2743	.3048	.2743	.3048
11		.3048	.2743	.3048	.3048	.3048	.2743
12		.3048	.3353	.3048	.3048	.3048	
13		.3048	.3048	.3048	.3048	.3048	
14		.3048	.381	.2743	.3048	.3048	
Max	.381	.3048	.381	.3048	.3048	.3048	.3048
Min	.3048	.2743	.2743	.2743	.2743	.2743	.2743
Avg	.3444	.3004	.3200	.2917	.2961	.3004	.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 202 / 11 KV BARSHI W/S EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18
HR	Load (MW)
6	.4572
7	.4572
8	.4572
9	.4572
10	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 203 / 11 KV BITERGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.8959
Max	2.8959
Min	2.8959
Avg	2.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 204 / 11 KV KAVITGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2134						
7	.1829						
8	.1829	.1829	.1829	.1829	.1829	.1829	.1829
9	.1829	.1829	.1829	.1829	.1829	.1829	.1829
10	.1829	.1829	.1524	.1829	1.829	.1829	.1829
11	1.5242	1.829	1.829	1.829	1.829	.2439	
12	1.6004	1.7528	1.829	1.829	1.829	1.829	
13	1.6004	1.829	1.829	1.829	1.829	1.9052	
14	1.6004	1.7528	1.829		1.9052	1.9052	
24	3.0483						
Max	3.0483	1.829	1.829	1.829	1.9052	1.9052	.1829
Min	.1829	.1829	.1524	.1829	.1829	.1829	.1829
Avg	1.0319	1.1018	1.1192	1.0060	1.3696	.9189	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 205 / 11 KV WADSHIWANE-SATOLI SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 206 / 11 KV KANDAR VILLAGE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1829						
7	.1829						
8	.1829	.1829	.1829	.1829	.1829	.1829	.1524
9	.1829	.1829	.1829	.1829	.1829	.1829	.1829
10		.1829	.1829	.1829	.2134	.2134	.1829
11		.1829	1.829	1.9814	1.829	2.0576	
12		.1829	1.9052	2.0576	1.9052	2.0576	
13		1.829	1.9814	1.9052	1.9052	2.0576	
14		1.9814	1.9052	1.9052	1.9814	2.0576	
Max	.1829	1.9814	1.9814	2.0576	1.9814	2.0576	.1829
Min	.1829	.1829	.1829	.1829	.1829	.1829	.1524
Avg	.1829	.6750	1.1671	1.1997	1.1714	1.2585	.1727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 207 / 11 KV HARITKRANTI AG

PURELY LIS FEEDERS

EXPRESS F Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1219						
8	.1219	.1219	.1219	.1219	.0762	.1219	.1524
9	.1219	.1219	.1219	.1219	.1219	.1219	.1524
10	.1219	.1219	.1524	.1219	.1219	.1219	.1219
11		.1219	.1219	.1219	.1219	.1219	
12		.1219	.1219	.1219	.1219	.1219	
13		.1219	.1524	.1219	.1524	.1219	
14		.1219	.1524	.1219	.1219	.1219	
Max	.1219	.1219	.1524	.1219	.1524	.1219	.1524
Min	.1219	.1219	.1219	.1219	.0762	.1219	.1219
Avg	.1219	.1219	.1350	.1219	.1197	.1219	.1422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 208 / 11 KV KANDAR BACKWATER AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1829						
7	.2134						
8	.2134	.1829	.1829	.1829	.1829	.1829	.1829
9	.2134	.1829	.2134	.1829	.2134	.2134	.1829
10		.1829	.1829	.2134	.2134	.1829	.1524
11		1.829	1.829	1.9814	1.829	1.829	
12		1.8861	1.829	1.9052	1.9052	1.9052	
13		1.829	1.829	2.0576	1.9814	1.829	
14		1.829	1.9052	1.9814	1.9814	1.9509	
Max	.2134	1.8861	1.9052	2.0576	1.9814	1.9509	.1829
Min	.1829	.1829	.1829	.1829	.1829	.1829	.1524
Avg	.2058	1.1317	1.1388	1.2150	1.1867	1.1562	.1727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KA

Feeder No / Name : 201 / 11 KV KEM GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395			.3206	
2	.3395			.3206	
3	.3772			.3772	
4	.3772			.4715	
5	.5658			.5658	
6	.4715			.5658	
7	.4715			.4715	
9		.4715			.3772
10		.4715			.4715
11		.3772			.415
12		.415			.4715
13		.415			.4715
14		.3772			.3772
15		.3772			.3772
16		.3772			.4338
17			.4715		.3772
18			.3772		.4338
19			.4904		.4715
20			.4904		.415
21			.362		.3772
22			.362		.3772
23			.3772		.3772
24	.3395			.3206	
Max	.5658	.4715	.4904	.5658	.4715
Min	.3395	.3772	.362	.3206	.3772
Avg	.4102	.4102	.4187	.4267	.4149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 202 / 11 KV WADSHIVANE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287			.4973	
2	.4287			.4973	
3	.463			.5144	
4	.4801			.5144	
5	.5144			.5144	
6	.5144			.4801	
7	.5144			.4287	
8	.5144			.6001	
9		.5144			.5144
10					.4287
11		2.572			2.1862
12		2.6397			2.834
13		2.8317			2.753
14		2.7044			2.672
15		2.5101			2.713
16		2.3644			2.6621
17			2.4291		2.4291
18			2.2672		2.3805
19			.583		.5658
20			.6859		.5144
21			.5487		.5144
22			.5144		.5144
23			.4973		.5144
24	.4287			.4973	
Max	.5144	2.8317	2.4291	.6001	2.834
Min	.4287	.5144	.4973	.4287	.4287
Avg	.4763	2.3052	1.0751	.5049	1.6131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 203 / 11 KV MALAWADI AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0348			1.6194	
2	2.1862			1.9433	
3	2.4291			2.1862	
4	2.834			2.2672	
5	2.8826			2.2672	
6	2.9959			2.753	
7	2.834			2.915	
8	2.915			2.834	
9		.4287			.4287
10		.4287			.5144
11		.4287			.5144
12		.4287			.4287
13		.4287			.4287
14		.3944			.5144
15		.4287			.5144
16		.3772			.5144
17			.4287		.6001
18			.4287		.5144
19			.5144		.5426
20			.5487		.5144
21			.4458		.5144
22			.4458		.4287
23			1.6194		1.6194
24	1.6956			1.6194	
Max	2.9959	.4287	1.6194	2.915	1.6194
Min	1.6956	.3772	.4287	1.6194	.4287
Avg	2.5341	.4180	.6331	2.2672	.5728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 205 / 11 KV UPALWATE AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	
2				.3429	
3				1.0288	
4				1.2003	
5				1.3565	
6				1.7147	
7				1.9433	
8				1.9433	
9		2.0576			1.7147
10		2.0576			1.7147
11		.3429			.3429
12		.3429			.3429
13		.3429			.3429
14		.4287			.4287
15		.3391			.2572
16		.3429			.2572
17			.3429		.3429
18			.3429		.4287
19			.3429		.4287
20			.3429		.4458
21			.3429		.4458
22			.3429		.4801
23	2.4387		.3429		.3429
24	1.9814			.3429	
Max	2.4387	2.0576	.3429	1.9433	1.7147
Min	1.9814	.3391	.3429	.3429	.2572
Avg	2.2101	.7818	.3429	1.1351	.5544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE
(SOFeeder No / Name : 201 / 11 KV SALSE GAONTHAN
Feeder KV- 11 / OUTGOING

GAONTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE

(SO

Feeder No / Name : 202 / 11 KV SALASE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE

(SO

Feeder No / Name : 203 / 11KV ALSUNDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION
CHIKHALTHAFeeder No / Name : 201 / 11KV CHIKHALTHAN GAONTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 203 / 11 KV KEDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 204 / 11 KV KOTLING DEVASTHAN AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 205 / 11 KV SHETFAL(NAGOBACHE) SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 206 / 11 KV KUGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI
NO-1Feeder No / Name : 201 / 11 KV WANGI GAONTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 202 / 11 KV DHOKARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 203 / 11 KV WANGI 4 AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.8959
Max	2.8959
Min	2.8959
Avg	2.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 204 / 11 KV PANGARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 205 / 11 KV WANGI-3 AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 206 / 11 KV NAGANATH AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO
SFeeder No / Name : 202 / 11 KV SADE NEW AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO
S

Feeder No / Name : 204 / 11 KV SOUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO
SFeeder No / Name : 205 / 11 KV SADE OLD AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 201 / 11 KV UMRAD-KUMBHEJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14	.5144						
24	.9145	.5144	.4973	.5144	.5144	.4973	.5144
Max	.9145	.5144	.4973	.5144	.5144	.4973	.5144
Min	.5144	.5144	.4973	.5144	.5144	.4973	.5144
Avg	.7145	.5144	.4973	.5144	.5144	.4973	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 202 / 11 KV SOGAON-(E) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9814
Max	1.9814
Min	1.9814
Avg	1.9814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 203 / 11 KV BHAIKAVNATH AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1434
Max	2.1434
Min	2.1434
Avg	2.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 204 / 11 KV UMRAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4348
Max	2.4348
Min	2.4348
Avg	2.4348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 205 / 11 KV BHAIKAVNATH NEW AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	2.0576						
24	2.4387	.0503	.0503	.0503	.0503	.0503	.0503
Max	2.4387	.0503	.0503	.0503	.0503	.0503	.0503
Min	2.0576	.0503	.0503	.0503	.0503	.0503	.0503
Avg	2.2482	.0503	.0503	.0503	.0503	.0503	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 206 / 11 KV SOGAON NEW AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Max	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Min	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Avg	.0503	.0503	.0503	.0503	.0503	.0503	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 207 / 11 KV POPHALAJ-KUMBHEJ AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.4387	1.1736	1.1736	1.3413	1.3413	1.3413	1.1736
Max	2.4387	1.1736	1.1736	1.3413	1.3413	1.3413	1.1736
Min	2.4387	1.1736	1.1736	1.3413	1.3413	1.3413	1.1736
Avg	2.4387	1.1736	1.1736	1.3413	1.3413	1.3413	1.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION
KOLEGAONFeeder No / Name : 201 / 11 KV KOLEGAON GAONTHAN
Feeder KV- 11 / OUTGOING

GAONTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION

KOLEGAON

Feeder No / Name : 202 / 11 KV NIMGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION

KOLEGAON

Feeder No / Name : 203 / 11 KV KOLEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.8959
Max	2.8959
Min	2.8959
Avg	2.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 202 / 11 KV Dahigaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.0576	2.0576	2.2291	1.8861	2.0576	2.0576	.0857
Max	2.0576	2.0576	2.2291	1.8861	2.0576	2.0576	.0857
Min	2.0576	2.0576	2.2291	1.8861	2.0576	2.0576	.0857
Avg	2.0576	2.0576	2.2291	1.8861	2.0576	2.0576	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 203 / 11 KV SHETPHAL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	.0857	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 204 / 11 KV WANGI-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		.0857					
24	.0857		.0857	.0857	.0857	.0857	1.7147
Max	.0857	.0857	.0857	.0857	.0857	.0857	1.7147
Min	.0857	.0857	.0857	.0857	.0857	.0857	1.7147
Avg	.0857	.0857	.0857	.0857	.0857	.0857	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 202 / 11 KV YASHOBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.1612	.192	.1732	.1835	.2298	.1955	.2263
24	.1492	.1578	.192	2.0233	1.8176	1.7833	1.7318
Max	.1612	.192	.192	2.0233	1.8176	1.7833	1.7318
Min	.1492	.1578	.1732	.1835	.2298	.1955	.2263
Avg	.1552	.1749	.1826	1.1034	1.0237	.9894	.9791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 204 / 11 KV SANGAVI NO.2 AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.0394	.0412	.036	.0394	.0274	.0326	.0377
24	.036	.036	.0377	.0291	.0394	.0257	.0309
Max	.0394	.0412	.0377	.0394	.0394	.0326	.0377
Min	.036	.036	.036	.0291	.0274	.0257	.0309
Avg	.0377	.0386	.0369	.0343	.0334	.0292	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274237 / 33/11 KV SHETFAL

Feeder No / Name : 202 / 11 KV MURMAI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0848	.0838	.0829	.0829	.0819	.0829	.0829
Max	.0848	.0838	.0829	.0829	.0819	.0829	.0829
Min	.0848	.0838	.0829	.0829	.0819	.0829	.0829
Avg	.0848	.0838	.0829	.0829	.0819	.0829	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274237 / 33/11 KV SHETFAL

Feeder No / Name : 203 / 11 KV NAGANATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0829	.0838	.0829	.081	.0829	1.5927	1.8233
Max	.0829	.0838	.0829	.081	.0829	1.5927	1.8233
Min	.0829	.0838	.0829	.081	.0829	1.5927	1.8233
Avg	.0829	.0838	.0829	.081	.0829	1.5927	1.8233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274237 / 33/11 KV SHETFAL

Feeder No / Name : 204 / 11 KV KEDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4918	1.326	1.6108	1.5927	1.4746	.0829	.0838
Max	1.4918	1.326	1.6108	1.5927	1.4746	.0829	.0838
Min	1.4918	1.326	1.6108	1.5927	1.4746	.0829	.0838
Avg	1.4918	1.326	1.6108	1.5927	1.4746	.0829	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 202 / 11 KV Ghoti I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2071	.1882	.1882	.2252	.2259	.1877	.1882
2	.1877	.1877	.1882	.1877	.2815	.1877	.188
3	.2259	.1882	.1877	.1877	.2627	.1629	.1882
4	.3003	.1882	.2252	.1877	.3003	.1877	.1882
5	.3753	.1877	.2361	.1686	.3566	.2071	.2815
6	.4129	.3388	.3388	.2627	.4316	.3566	.4692
7	.4692	.4706	.4879	.3378	.4879	.4731	.4692
8	.3753	.3753	.4692	.4316	.4129	.319	.4692
9	.32	.3765		.3388	.2815	.3765	.3378
10	.3378	.3765		.2633	.2627	.4129	
11	1.2983	1.5059	1.689	1.7694	1.8391	1.8766	
12	1.882	1.5059	2.0455	2.1393	2.1559	1.8138	
13	2.2144	1.5059	2.1018	1.9142	2.2144	1.8195	
14	2.0455	1.5059	1.8884	1.9142	1.9497	1.8766	
15		1.8823	2.1018		1.9705	1.8766	
16		1.126	2.0643	2.0268	2.0248	1.8766	
17	2.1769	.9412	2.0643	2.0831	2.0455	2.0643	
18	2.0831	1.0541	2.0455	2.1206	1.9705	1.8766	1.807
19	.4129		.319	.3566	.3378	.3753	.3753
20	.3765	.3643	.3378	.3388	.2824	.3753	.3576
21	.3378	.3567	.3753	.32	.2824	.3753	.3576
22		.2815	.3334	.3566	.244	.2815	.3378
23	.2635	.2815	.3753	.2815	.2252	.2815	.32
24	2.4387		.2824	.3374	.2635	.1877	.2815
Max	2.4387	1.8823	2.1018	2.1393	2.2144	2.0643	1.807
Min	.1877	.1877	.1877	.1686	.2252	.1629	.188
Avg	.8924	.6904	.9248	.8065	.8796	.8262	.4135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 203 / 11 KV Ghoti II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751	.0753	.0674	.0753	.0751	.0751	.0938
2	.0751	.0753	.0751	.0753	.0751	.0751	.0938
3	.0941	.0753	.0938	.0751	.0938	.0728	.0938
4	.0941	.0761	.0938	.0751	.1126	.0751	.0938
5	.1501	.0753		.0751	.1501	.0751	.0938
6	.2259	.1882	.1501	.1129	.1877	.1126	.1689
7	.2815	.244	.244	.1882	.2627	.1686	.2539
8	.2627	.2259	.2627	.2361	.244	.1501	.2023
9	.2259	.1501	.1512	.1882	.1689	.0753	.1501
10	.118	.1126	.1126	.1314	.1126	.0751	
11	1.4682	1.1294	1.5576	1.5013	1.3141	1.5013	
12	1.7846	1.8823	1.807	1.764	1.3148	1.3489	
13	1.807	1.8766	1.8016	1.6327	1.5576	1.5013	
14	1.9012	1.8823	1.8148	1.6327	1.3828	1.5013	
15	1.703	1.5908	1.8391		1.4556	1.5013	
16	1.9012	1.8766	1.8579	1.8804	1.4691	1.5059	
17	1.9388	1.9161	1.9892	1.8391	1.2736	1.8766	
18	.2259	1.9765	1.9517	1.8203	1.3966	1.126	1.689
19	.1314	.1689	.1314	.1501	.127	.1877	.1314
20	.1318	.1692	.1126	.1501	.1314	.1501	.1126
21	.1129	.1314	.1126	.1314	.1274	.1501	.1126
22	.0941	.1314	.1129	.1126	.1126	.1129	.0941
23	.0751	.0751	.1126	.0938	.0938	.0938	.0815
24	2.4387	.0753	.0751	.0938	.0753	.0751	.0938
Max	2.4387	1.9765	1.9892	1.8804	1.5576	1.8766	1.689
Min	.0751	.0751	.0674	.0751	.0751	.0728	.0815
Avg	.7215	.6742	.7186	.6102	.5548	.5661	.2225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 204 / 11 KV Pathurdi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3388	.319	.2438	.2815	.3941	.32	.3753
2	.319	.32	.2815	.2815		.319	.3753
3	.7506	1.3136	1.126	1.5812	1.3136	1.3887	1.126
4	1.126	1.6941	1.689	1.9517	1.8766	2.0831	1.689
5	1.7265	1.9892	1.8785	2.5897	2.711	2.7023	1.8766
6	2.7106	3.0214	2.6273	2.6273	2.7146	3.3029	2.9111
7	3.1435	3.134	2.8235	3.209	3.0777	3.3029	3.5656
8	2.6135	2.5976	1.8766	3.0214	3.2653	3.4905	3.5764
9	2.5334	2.8149	2.2972	3.2653	3.3592		3.4259
10	2.5412	1.9662	2.4396	3.0589	3.209	1.126	
11		.5647	.2627	.3003	.2815	.0672	
12		.3753	.2627	.3003		.0751	
13				.2911		.2815	
14		.3753	.2627	.3003		.3003	
15		.3765	.2635			.3753	
16	.3765	.3753	.2627	.319		.2815	
17		.4504	.319	.3566	.3003	.3753	
18		.4518	.2432	.3937	.3378	.3753	.4329
19	.4129		.4129	.4504	.4129	.3753	.3882
20	.4129	.5647	.4692	.4692	.4692	.563	.5082
21	.3765	.4894	.5255	.4879	.4879	.563	.4384
22	.3378	.4692	.4504	.4692	.4129	.6568	.4894
23	.3378	.2824	.3241	.4504	.3753	.4215	.4706
24	.3204	.319	.2821	.2815	.4172	.32	.4706
Max	3.1435	3.134	2.8235	3.2653	3.3592	3.4905	3.5764
Min	.319	.2824	.2432	.2815	.2815	.0672	.3753
Avg	1.1987	1.1029	.9402	1.1625	1.4120	1.0029	1.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 400 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 402 / 33 KV JEUR

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 403 / 33 KV CHIKALTHAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.8583
Max	4.8583
Min	4.8583
Avg	4.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 404 / 33 KV WANGI

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.8299
Max	5.8299
Min	5.8299
Avg	5.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 405 / 33 KV KANDHAR

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.8299
Max	5.8299
Min	5.8299
Avg	5.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 407 / 33 KV UMRAD

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	8.2305
Max	8.2305
Min	8.2305
Avg	8.2305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 409 / 33KV DAHIGAON LIS

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 215 / DEVICHA MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.5144	.5144	.5144	.5144
2			.5144	.5144	.5144	.5144	.5144
3			.4287	.4287	.5144	.5144	.5144
4			.4287	.4287	.5144	.5144	.5144
5			.4287	.4287	.5144	.5487	.5487
6			.4287	.5144	.6001	.6001	.6001
7			.5144	.5144	.6001	.6001	.6001
8			.6001		.6001	1.0669	.6001
9				.4572			
10	.5716	.5716	.6668	.4572		.6668	.6668
11	.6668	.6668	.6668	.4572		.6668	.6668
12	.5716	.6668	.7621	.4572		.7621	.6668
13	.6668	.7621	.7621	.4572		.7621	.7621
14	.7621	.7621		.4572		.6668	.6668
15	.8573	.8573		.4572		.6668	.5716
16	.7621			.4572		.5716	.6668
17		.6668	.5716	.4572	.5144	.4572	.5144
18	.6668	.6668	.5716	.4572	.5144	.4572	.5144
19	.6668	.6668	.5716	.4572	.5487	.5144	.5144
20	.6668	.5716	.5716	.4572	.6001	.5144	.5144
21	.5716	.5716	.5716	.4572	.6001	.6001	.5144
22	.5716			.5144	.5144	.5144	
23	.5716	.5144	.5144	.5144	.5144	.5144	.5144
24	.4572		.5144	.5144	.5144	.5144	.5144
Max	.8573	.8573	.7621	.5144	.6001	1.0669	.7621
Min	.4572	.5144	.4287	.4287	.5144	.4572	.5144
Avg	.6451	.6621	.5580	.4709	.5433	.5966	.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 216 / Bhavani Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.4801	.5144	.5144	.5144
2			.5144	.4801	.5144	.5144	.5144
3			.5144	.4801	.5144	.5144	.5144
4			.5144	.4801	.5144	.5144	.5144
5			.5144	.5144	.5487		.5487
6			.4001	.6001	.6687	.6344	.6859
7			.7373	.703	.7913	.5487	.7373
8			.8059	.583	.7373	.7545	.8573
9				.6097			
10	.7621	.7621	.8954	.0762		.8383	.9526
11	.6668	.8192	.8954	.5335		.7621	.8573
12	.5716	.8573	.9526	.5335		.6668	.7621
13	.5716		1.0479	.5335		.7621	
14	.6668	.7621		.5335		.6668	
15	.7621	.8573		.5335		.5716	
16	.8573			.5335		.6668	
17	.7621	.7621	.743	.5335	.6344	.6001	
18	.6668	.8002	.6668	.6097	.6859	.6859	
19	.7621	.7621	.7621	.6097	.7202	.7716	
20	.7621	.7621	.7621	.6097	.8059	.7716	.8573
21	.7621	.7621	.6668	.5335	.7716	.7716	.7716
22	.6668			.6173	.6859	.6001	.7716
23		.6516		.6001	.6001	.5658	.8745
24	.4572		.5144	.4973	.5316	.5316	.5316
Max	.8573	.8573	1.0479	.703	.8059	.8383	.9526
Min	.4572	.6516	.4001	.0762	.5144	.5144	.5144
Avg	.6927	.7780	.6901	.5341	.6400	.6467	.7041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 217 / Karmala Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.6859	.6859	.7202	.7202
2			.6859	.6859	.6859	.6859	.6859
3			.6859	.6859	.6859	.6859	.6859
4			.6859	.6859	.6859	.6859	.6859
5			.7202	.7202	.7202	.7202	.7202
6			.7716	.7716	.8916	.8916	.9088
7			.9774	1.0117	1.046	.9774	1.0288
8			1.046	.9774	1.046	1.0802	1.0631
9				.6097			
10	.8573	.7621	1.1622	.6097		1.1431	1.1812
11	.7621	.9145	1.1431	.4572		1.1431	1.1431
12	.7621	1.0479	1.0479	.4572		1.0479	1.0479
13	.9526	.9526	.9526	.4572		1.0479	.9526
14	1.0479			.4572		.9526	.9526
15	.8573	.8573		.7621		.9526	.8573
16	.7621	.7621		.7621		.8383	.9526
17	.8573	.8192	.9145	.7621	.8402	.6859	.7373
18	.8573	.8573	.7621	.6859	.8573	.7716	.7716
19	.8573	.8573	.8573	.7621	.9431	.7716	.8573
20	.7621	.8573	.7621	.6859	1.0974	.8573	.8573
21	.7621	.7621	.7621		1.0288	.6001	.7716
22	.7621			.8573	.9945	.8573	
23		.823	.5658	.823	.8916	.8402	.8745
24	.6097		.7373	.7545	.7373	.7888	.7545
Max	1.0479	1.0479	1.1622	1.0117	1.0974	1.1431	1.1812
Min	.6097	.7621	.5658	.4572	.6859	.6001	.6859
Avg	.8192	.8561	.8382	.7012	.8649	.8585	.8732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 218 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6859		
2			.6859	.6859	.6859	.6859	.1715
3			.6859		.8573		
4			1.0288	1.0288	1.0288	.8573	.1715
5			1.3717		1.5432		
6			1.7147	1.5432	1.7147	1.5432	.1715
7			1.8861		1.8861	1.7147	
8			1.7147	1.7147	1.8004	1.7147	
9					1.5432	1.3717	
19					.1715		
20					.1715		
21					.1715		
22				.1715	.1715		.1715
23		.1715	.1715	.1715	.1715	.1715	.1715
24	.7202		.6859	.6001	.6859	.6859	.1715
Max	.7202	.1715	1.8861	1.7147	1.8861	1.7147	.1715
Min	.7202	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.7202	.1715	1.1050	.8451	.8859	1.0931	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 220 / 11KV VEET AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 221 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.1715	.1715	.1715	.0857
2			.1715	.1715	.1715	.1715	.0857
3			.1715	.1715	.1715	.1715	.0857
4			.1715	.1715	.1715	.1715	.0857
5			.1715	.1715	.1715	.1715	.0857
6			.1715	.1715	.1715	.1715	.0857
7			.1715	.1715	.1715	.1715	
8			.1715	.1715	.1715	.1715	
9					.1715	.1715	
19					.0857		
20					.0857		
21					.0857		
22				.0857	.0857		.0857
23		.0857	.0857	.0857	.0857	.0857	.0857
24	.7716		.1715	.1715	.1715	.0857	.0857
Max	.7716	.0857	.1715	.1715	.1715	.1715	.0857
Min	.7716	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.7716	.0857	.1629	.1559	.1429	.1559	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 222 / 11 KV SANGOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8861	2.0576	1.8861	1.8861	.1715
2			1.8861	2.2291	1.8861	1.8861	.1715
3			2.2291	2.2291	2.0576	2.0576	.1715
4			2.4006	2.3148	2.2291	2.0576	.1715
5			2.572	2.4006	2.4006	2.1434	.1715
6			2.6578	2.572	2.4863	2.3148	.1715
7			2.7435	2.7435	2.915	2.8292	
8			2.7435	2.915	2.915	2.8292	
9					2.572	2.7435	
19					.1715		
20					.1715		
21					.1715		
22				.1715	.1715		.1715
23		.1715	.1715	.1715	.1715	.1715	.1715
24	.7716		1.8004	1.8861	1.7147	1.8861	.1715
Max	.7716	.1715	2.7435	2.915	2.915	2.8292	.1715
Min	.7716	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.7716	.1715	2.1091	1.9719	1.5947	2.0732	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 223 / 11 KV KARMALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.5144	.5144	.5144	.5144
2			.5144	.5144	.5144	.5144	.5144
3			.5144	.5144	.5144	.5144	.5144
4			.5144	.6001	.5144	.5144	.5144
5			.6001	.6859	.6001	.6001	.6001
6			.6001	.6859	.7716	.6859	.7202
7			.6859	.7202	.8059	.7716	1.1145
8				.5144	.6859	.6859	.6859
9	1.1431	.7621	.5144		.5144		.6859
10		.6668	.5716			.5716	.7621
11	1.0479	.7621	.6668			.6668	.7621
12	.9526	.7621	.5716			.5716	.7621
13	1.0479	.8573	.6668			.8573	.8573
14	.8573					.7621	.7621
15	.7621					.8573	.9526
16	.9526						.9526
17		.9526	.7621	.7621	.6001	.6859	
18		1.1431	.8573		.6859	.7716	.6859
19		.9526	.8573	.8383	.7716	.7716	.8573
20		.9526	.9526	.7621	.9259	.8573	.7716
21		.8573	.8573	.7621	.8573	.8573	.8573
22				.7716	.7716	.8573	.7716
23		.5144	.6001	.6859	.6001	.6001	.6001
24	1.6861		.5144	.6001	.5487	.5144	.5487
Max	1.6861	1.1431	.9526	.8383	.9259	.8573	1.1145
Min	.7621	.5144	.5144	.5144	.5144	.5144	.5144
Avg	1.0562	.8348	.6493	.6621	.6586	.6820	.7290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 224 / 11 KV MIDC KARMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857	.0857	.0857	.0857	.0857
2			.0857	.0857	.0857	.0857	.0857
3			.0857	.0857	.0857	.0857	.0857
4			.0857	.0857	.0857	.0857	.0857
5			.0857	.0857	.0857	.0857	.0857
6			.0857	.0857	.0857	.0857	.0857
7			.0857	.0857	.0857	.0857	.0857
8			.0857	.0857	.0857	.0857	.0857
9	.1905	.1905	.0857	.0762	.0857	.5144	.0857
10	.0953	.0953	.0953	.0762		.0953	.0953
11	.0953	.0953	.0953			.0953	.0953
12	.0953	.0953	.0953			.0953	.0953
13		.0953	.0953			.0953	.0953
14	.0953					.0953	.0953
15	.0953			.0762		.0953	.0953
16	.0953			.0762		.0953	.0953
17	.0953	.0953	.0953		.0857	.0762	.0857
18	.0953	.0953	.0953		.0857	.0762	
19	.0953	.0953	.0953	.0762	.0857	.0762	.0857
20	.0953		.0953	.0762	.0857	.0762	.0857
21	.0953	.0953	.0953	.0762	.0857	.0762	.0857
22	.0953			.0857	.0857	.0762	.0857
23		.0857	.0857	.0857	.0857	.0953	.0857
24	.0762		.0857	.0857	.0857	.0857	.0857
Max	.1905	.1905	.0953	.0857	.0857	.5144	.0953
Min	.0762	.0857	.0857	.0762	.0857	.0762	.0857
Avg	.1007	.1039	.0900	.0820	.0857	.1044	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 229 / 11 WADGAON/BOSE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 230 / 11 KV MANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.5034	1.1145
2						2.7263	1.1871
3						2.8292	1.166
4						3.1722	1.286
5						3.3779	1.3717
6						3.4294	1.4575
7						3.5494	1.4918
8						3.4019	1.4575
9						.0177	.2915
10						.0177	
11						1.1517	
12						1.2403	
13						1.3289	
14						1.3289	
15						1.3289	
16						1.4575	
17						1.5089	
18						.3429	.2743
19						.3601	.5316
20						.6516	.583
21						.5144	.5487
22						.4287	.4458
23						.4287	.443
24	3.2065	2.4177	2.1948	2.2291	2.332	1.9719	1.0631
Max	3.2065	2.4177	2.1948	2.2291	2.332	3.5494	1.4918
Min	3.2065	2.4177	2.1948	2.2291	2.332	.0177	.2743
Avg	3.2065	2.4177	2.1948	2.2291	2.332	1.6279	.9196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 231 / 11 KV PUNWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 241 / 11KV GFSS Mangi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1772	.1063	.1063	.1063	.1063	.2126
2	.1772	.1772	.1063	.1063	.1063	.1063	.2126
3	.1772	.2303	.1417	.1063	.1063	.1417	.2658
4	.2126	.3012	.2126	.2126	.1772	.1417	.2658
5	.3189	.4252	.4252	.3721	.2126	.2126	.443
6	.443	.6556	.567	.5316	.443	.4252	.5316
7	.6201	.7442	.6201	.6379	.5316	.6379	.6379
8	.4607	.6379	.4252	.5316	.4252	.5316	.5316
9	.2481	.4784	.4252	.443	.3721	.2303	.443
10	.443		.2835	.443	.2658	.1417	
11	.2658	.2126	.2126	.2126	.2126	.1417	
12	.2126	.1949	.1772	.2126	.2126	.1417	
13	.2126	.1417	.1417	.2126	.2126	.1417	
14		.2126	.1772	.2126	.1417	.1417	
15		.2126	.2126	.1417	.1417	.1417	
16		.2126	.2658		.1595	.2126	
17		.2658	.2658	.2658	.1772	.2481	
18		.3544	.3544	.3544		.2481	.3012
19		.6379	.6379	.6379		.443	.443
20	.7442	.6379	.6379	.5316	.6379	.6024	.443
21	.6379	.443	.443		.5316	.4252	.443
22	.443	.3721	.3544		.3721	.3544	.3721
23	.3721	.3189	.2126		.2126	.2658	.2658
24	.2126	.2126	.2126	.2126	.2126	.1063	.2658
Max	.7442	.7442	.6379	.6379	.6379	.6379	.6379
Min	.1772	.1417	.1063	.1063	.1063	.1063	.2126
Avg	.3544	.3590	.3175	.3243	.2714	.2621	.3799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 232 / 11 KV MAJARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 233 / 11 KV UMRAD AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.9145	.9526	.8764	.9907
2		.9145	.9145		.8764	.9907
3					.9145	.9907
4					.9145	.9907
5					.9526	.9145
6	.9907	.9907	.9907	1.0288	1.0288	.9145
7					1.0669	.9145
8					.0381	.0381
9					.0381	.0381
10					1.0669	.9145
11					1.4098	1.1812
12	.0381	1.6385	1.4861	1.2955	1.448	
13	1.6766				1.448	
14					1.4098	
15					1.3717	
16					1.3717	
17					.0381	
18	.0381	.0762	.0762	.0381		
20				.0381		
23	.0381	.9907	.0381	.0381		
24	.7716	.9907	.9907	.9526	.8764	.9526
Max	1.6766	1.6385	1.4861	1.2955	1.448	1.1812
Min	.0381	.0762	.0381	.0381	.0381	.0381
Avg	.6382	.9308	.7730	.6205	.9526	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 234 / 11 KV SANT DYNESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 235 / 11KV MANJARGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.3429	.3048	.3048	.3048
2	.2667	.3048	.2667	.3048	.2667	.2667	.2667
3	.2667	.2667	.2667	.3048	.2667	.2667	.2667
4	.3048	.3048	.3048	.3048	.2667	.2667	.2667
5	.381		.381	.3429	.2667	.3048	.3048
6	.381	.381	.381	.381	.3048	.381	.381
7	.381	.381	.381	.381	.3429	.381	.381
8	.3048	.3429	.3048	.3429	.3429	.381	.381
9	.3429	.3429	.3048	.3429	.3048	.3429	.3048
10	.381	.381	.381	.381	.3429	.3429	.3429
11	.381	.3048	.381	.3429	.3429	.3429	.381
12	.3429	.3048	.381	.3429	.3429	.3048	
13	.3048	.3429	.381	.381	.3429	.3048	
14	.3048	.3429	.4191	.381	.3429	.3048	
15	.3429	.3429	.381	.3429	.3429	.2667	
16	.3048	.3429	.381	.3429	.3429	.3048	
17	.381	.3429	.3429	.3429	.381	.2667	
18	.3429	.2667	.3429	.381	.381	.3048	
19	.381	.3048	.3048	.381	.3429	.3048	.5335
20	.3429	.3048	.381	.3429	.3048	.3048	.5335
21	.3429	.3429	.381	.3429	.3048	.3429	.4572
22	.3048	.3429	.3429	.3048	.3048	.381	.4191
23	.3048	.3429	.3048	.3048	.3048	.3048	.381
24	.3048	.2667	.3429	.3048	.3048	.3048	.3048
Max	.381	.381	.4191	.381	.381	.381	.5335
Min	.2667	.2667	.2667	.3048	.2667	.2667	.2667
Avg	.3318	.3247	.3461	.3445	.3207	.3159	.3653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 236 / 11kv Sogaon link line ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.2862
2					2.2862
3					1.9052
4					2.0957
5					2.2862
6					2.2862
7					2.2862
10		2.2862	2.21	1.9814	
11		2.3243	2.21	2.2862	
12		2.3624		2.2862	
13		2.4006	1.9814	1.9052	
14		2.4006	1.9814	2.0957	
15	2.5149	2.4006	2.2862	2.2862	
16	2.4387	2.3243	2.2862	2.2862	
24					1.9814
Max	2.5149	2.4006	2.2862	2.2862	2.2862
Min	2.4387	2.2862	1.9814	1.9052	1.9052
Avg	2.4768	2.357	2.1592	2.1610	2.1767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 235 / 11 KV KETTUR/PAREWADI POOL SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0305	.0305	.0305	.0305	.0305	.0305	.0305
8	.0305	.0305	.0305	.0305	.0305	.0305	
12	1.5546	1.6461		1.6766	1.7375	1.6461	
14				1.6766			
16	1.6004	1.6004		1.6156	1.6766	1.7833	
17					1.6766		
20		.0305		.0305	.0305		.0305
21					.0305		
24	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Max	1.6004	1.6461	.0305	1.6766	1.7375	1.7833	.0305
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.6493	.5614	.0305	.7273	.6554	.7042	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 237 / 11 KV RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 238 / 11 KV GFSS PAREWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6097	.5487	.5792	.7011	.6706	.6401	.5944
8	.6401	.5792	.7316	.6859	.6401	.7011	.6859
12	.4725	.4877		.4268	.4268	.4572	.4572
16	.5487	.4572		.4572	.3963	.503	.4268
17					.4877		
20	.4877	.7011		.7011	.6554		.6249
21					.6097		
22					.6554		
24	.4268	.4572	.4572	.4877	.4572	.4877	.4572
Max	.6401	.7011	.7316	.7011	.6706	.7011	.6859
Min	.4268	.4572	.4572	.4268	.3963	.4572	.4268
Avg	.5309	.5385	.5893	.5766	.5555	.5578	.5411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 239 / 11 KV WASHIMBE /PAREWADI SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 240 / 11KV POMALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.713	2.5911	2.713	2.7892	2.9264	2.7435	2.8959
8		2.4691	2.8959		3.1855	2.9264	3.0788
12				2.8959			
13				2.8959			
14							3.0788
24	2.713						
Max	2.713	2.5911	2.8959	2.8959	3.1855	2.9264	3.0788
Min	2.713	2.4691	2.713	2.7892	2.9264	2.7435	2.8959
Avg	2.713	2.5301	2.8045	2.8603	3.0560	2.8350	3.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 244 / 11 KV KORTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.2803	1.3717	1.2955	1.448	1.1736	1.4251
8	1.6004	1.7071	1.2193	1.933	1.6766	1.781
12	.1372	.1524	.1372	.1296	.1219	.1875
16	.1677	.1619	.1372	.1372	.1619	.1296
20	.2134	.1981	.2134	.2439	.2347	.2267
23	.1524	.1406	.1981	.1524	.1524	.1524
24	.4534	.7449	.5792	.9602	.6249	.6802
Max	1.6004	1.7071	1.2955	1.933	1.6766	1.781
Min	.1372	.1406	.1372	.1296	.1219	.1296
Avg	.5721	.6395	.5400	.7149	.5923	.6546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 245 / 11 KV VEET AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2591	.3887	.3048	.2743	.3239	.3239
8	.4268	.4858	.3048	.4268	.3353	.4534
12	2.4387	1.5061	2.6397	1.2308	2.2558	1.1984
16	2.2558	1.2631	2.2253	1.1012	2.1643	1.1012
20	.3353	.2915	.3658	.3239	.3963	.2915
23	.2743	.2591	.2743	.2591	.2439	.2591
24	.2656	.2591	.2591	.2267	.2429	.2591
Max	2.4387	1.5061	2.6397	1.2308	2.2558	1.1984
Min	.2591	.2591	.2591	.2267	.2429	.2591
Avg	.8937	.6362	.9105	.5490	.8518	.5552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 246 / 11 KV GFSS VEET

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1619	.1696	.1619	.1543	.1943	.2267
8	.2915	.2915	.2267	.3086	.2374	.2915
12	.2374	.2267	.1619	.1457	.1219	.1619
16	.1943	.2035	.2543	.1619	.2035	
20	.1943	.3052	.2915	.2915	.3052	.2915
23	.1696	.1457	.1943	.1943	.2035	.2035
24	.1526	.1357	.1357	.1543	.1696	.1715
Max	.2915	.3052	.2915	.3086	.3052	.2915
Min	.1526	.1357	.1357	.1457	.1219	.1619
Avg	.2002	.2111	.2038	.2015	.2051	.2244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 253 / 11 KV JINTI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572		.4572	.4572	.4572
2	.4572	.5335	.4572	.4572	.4572	.4572	.5335
3	.5335	.5335	.5335	.4572	.5335	.381	.6097
4	.6859	.6097	.6859	.381	.6097	.6097	.6859
5	.7621	.7621	.8383	.6097	1.0669	.8383	.7621
6	1.0669	.9907	.9907	.8383	1.1431	.9907	
7	1.2193	1.1431	1.0669	.9907	1.2193	1.0669	
8	1.0669	1.0669	.9907	.9907	1.2193	1.0669	.7621
9	.7621	.7621		.6097	.7621	.8383	.5335
10		.6097					
11	.5335	.4572			.7621	.5335	
12		.4572	.5335			.4572	
13		.4572	.4572		.381	.4572	
14	.6097	.4572	.4572		.381	.3048	
15	.5335	2.2862	.381	.5335	.4572	.3048	
16	2.5911	2.2862	3.0483	2.2862	2.1338	3.5056	
17	3.5056	3.0483	3.2007	3.3532	3.5056	3.3532	
18	3.3532	3.4294	3.3532		3.2769	3.0483	
19	2.9721	3.3532	3.0483	2.8959		3.0483	1.0669
20	2.7435	3.2007	2.7435	2.7435	2.5911	2.7435	1.0669
21	2.4387	3.0483	2.2862	2.5911	2.5911	2.4387	.9145
22	2.2862	2.5911	2.1338	2.1338	2.21	2.2862	.6097
23	.4572	.4572	.6097	.6097	.6097	.5335	.4572
24	.5335	.4572	.4572	.5792	.5335	.5335	.4572
Max	3.5056	3.4294	3.3532	3.3532	3.5056	3.5056	1.0669
Min	.4572	.4572	.381	.381	.381	.3048	.4572
Avg	1.4080	1.3940	1.3681	1.3565	1.2810	1.3154	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 254 / 11 KV KATRAJ AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1524
2	.1524	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.1524	.1524	.1524	.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1524	.1524	.1524
6	.1524	.1524	.1524	.1524	.1524	.1524	.1524
7	.1524	.1524	.8383	.1524	.1524	.1524	.1524
8	.7621	.9145		.7621	.8383	.8383	.1524
9	.8383	.9145	.9145	.9145	.9145	.9907	.1524
10	.9145	.9907	.9907	.9145	.9145	.9907	.1524
11	.9145	.9907	.9907	.9907	.9907	.9907	
12	.9145	.9907	.9907	.9907	.9907	.9145	
13	.9145	.8383	.9907	.9907	.9145	.9145	
14	.9907	.8383	.9907	.9907	.9145	.9145	
15	.1524	.1524	.1524		.1524	.1524	
16	.1524	.1524	.1524	.1524	.1524	.1524	
17	.1524	.1524	.1524	.1524	.1524	.1524	
18	.1524	.1524	.1524	.1524	.1524	.1524	
19	.1524	.1524	.1524	.1524		.1524	.8383
20	.1524	.1524	.1524	.1524	.1524	.1524	.8383
21	.1524	.1524	.1524	.1524	.1524	.1524	.8383
22	.1524	.1524	.1524	.1524	.1524	.1524	.8383
23		.1524	.1524	.1524	.1524	.1524	.1524
24	.7716	.1524	.1524	.1524	.1524	.1524	.1524
Max	.9907	.9907	.9907	.9907	.9907	.9907	.8383
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.4046	.3779	.3976	.3910	.3877	.3810	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 256 / 11 KV TAKALI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0762	.0762	.0762	.0762	.0762	.0762
7	.0762	.0762	.0762	.0762	.0762	.0762	.0762
8	.5335	.5335	.0762	.0762	.0762	.381	.0762
9	.5335	.5335	.0762	.0762	.0762	.381	.0762
10	.5335	.6097	.0762	.0762	.0762	.381	.0762
11	.0762		.0762	.0762	.0762	.381	
12	.0762	.6097	.0762	.0762		.381	
13	.5335	.6097	.0762	.0762		.381	
14	.5335	.6097	.0762	.0762		.381	
15	.0762	.6097	.0762	.0762		.0762	
16	.0762	.0762	.0762	.0762		.0762	
17		.0762	.0762	.0762		.0762	
18	.0762		.0762	.0762		.0762	
19	.0762	.0762	.0762	.0762		.0762	
20	.0762	.0762	.0762	.0762		.0762	.5335
21	.0762	.0762	.0762	.0762	.0762	.0762	.5335
22	.0762		.0762	.0762	.0762	.0762	.5335
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	.5335	.6097	.0762	.0762	.0762	.381	.5335
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1756	.2468	.0762	.0762	.0762	.1651	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 257 / 11KV RAMWADI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762		.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0762	.0762	.0762	.0762	.0762	.0762
7	.0762	.0762	.0762	.0762	.0762	.0762	.0762
8	.0762	.0762	.0762	.0762	.0762	.0762	.0762
9	.0762	.0762	.0762	.0762	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762		.0762	.0762
11	.0762	.0762	.0762	.0762	.0762	.0762	
12	.0762	.0762	.0762	.0762	.0762	.0762	
13	.0762	.0762	.0762	.0762	.0762	.0762	
14	.0762	.0762	.0762	.0762	.0762	.0762	
15	.0762	.0762	.0762	.0762	.0762	.0762	
16	.9907	.9907	1.1431	.0762	1.1431	1.2955	
17		1.2193	1.2955	1.2193	1.3717	1.2955	
18		1.3717	1.2955	1.2193	1.448	1.2193	
19	1.0669	1.3717	1.2955	1.3717		1.2193	.0762
20	1.2193	1.2193	1.2193	1.3717	1.2193	1.2193	.0762
21	1.2193	1.0669	1.1431	1.2193	1.1431	1.2193	.0762
22	1.1431	.9145	1.1431	1.2193	1.1431		.0762
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.7716	.0762	.0762	.0762	.0762	.0762	.0762
Max	1.2193	1.3717	1.2955	1.3717	1.448	1.2955	.0762
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.3468	.3937	.4241	.3747	.3949	.3810	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 258 / 11KV NEMATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.9814	1.6766	1.5242	1.9814	1.6766	1.9814
2	1.9814	2.0576	1.9052	1.5242	1.9814	1.829	1.9814
3	1.9814	2.1338	1.9814	1.829	2.0576	1.9814	2.1338
4	2.1338	2.1338	1.9814	1.9814	2.0576	1.9814	2.1338
5	2.1338	2.1338	2.0576	1.9814	2.1338	1.9814	
6	2.2862	1.9814	2.1338	2.0576	2.1338	2.1338	2.4387
7	2.2862	2.1338	2.1338	2.1338	2.1338	2.1338	2.5911
8	.1524	.1524	.1524	.1524	.1524	.1524	2.5911
9	.1524	.1524	.1524	.1524	.1524	.1524	2.5911
10	.1524	.1524	.1524	.1524	.1524	.1524	1.0669
11	.1524	.1524	.1524	.1524	.1524	.1524	2.5911
12	.1524	.1524	.1524	.1524	.1524	.1524	
13	.1524	.1524	.1524	.1524	.1524	.1524	
14	.1524	.1524	.1524	.1524	.1524	.1524	
15	.1524	.1524	.1524	.1524	.1524	.1524	
16	.1524	.1524	.1524	.1524	.1524	.1524	
17	.1524	.1524	.1524	.1524	.1524	.1524	
18	.1524	.1524	.1524	.1524	.1524	.1524	
19	.1524	.1524	.1524	.1524		.1524	.1524
20		.1524	.1524	.1524		.1524	.1524
21		.1524	.1524	.1524	.1524	.1524	.1524
22		.1524	.1524	.1524	.1524	.1524	.1524
23		.1524	.1524	.1524	.1524	2.0576	.1524
24	1.829	1.9814	1.6766	1.5242	1.9814	1.5242	2.0576
Max	2.2862	2.1338	2.1338	2.1338	2.1338	2.1338	2.5911
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.9145	.7906	.7494	.7081	.8452	.8161	1.5575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEAGAON S/S

Feeder No / Name : 201 / 11 KV POTEAGAON/TARATGAON SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5242	1.829	1.7528	1.829	1.829	1.7528	.2439
23	.1524	.1829	.1524	.1524	.1524	.1677	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.5242	1.829	1.7528	1.829	1.829	1.7528	.2439
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.6097	.7214	.6859	.7113	.7113	.6910	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 202 / 11KV Borgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1524	.2286	.1524	.1524	.1524	1.7528
16	2.2862		2.2862	2.4387	1.9814	2.5911	
23	.1524	.1981	.1524	.1524	.1524	.1829	.1524
24	.1524	.1524	.1677	.1524	.1524	.1524	.1829
Max	2.2862	.1981	2.2862	2.4387	1.9814	2.5911	1.7528
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.6859	.1676	.7087	.7240	.6097	.7697	.6960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 203 / 11KV Ghargaon/ Padali AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1524	.1524	.1524	.1524	1.3717
16	1.3717	1.3108	1.2193	1.5242	1.2193	
23	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.3717	1.3108	1.2193	1.5242	1.2193	1.3717
Min	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.4572	.442	.4191	.4954	.4191	.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 242 / 11KV GFSS Potegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1981	.1829	.1677	.1981	.1829	.1981	.2439
16	.1219	.0914	.0914	.1372	.0914	.1524	
23	.1524	.1372	.1524	.1677	.1219	.1677	.1524
24	1.5432	.1524	.1219	.1219	.1677	.1219	.1524
Max	1.5432	.1829	.1677	.1981	.1829	.1981	.2439
Min	.1219	.0914	.0914	.1219	.0914	.1219	.1524
Avg	.5039	.1410	.1334	.1562	.1410	.1600	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 201 / 11KV WASHIMBE/BHAIRVNATH SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.3963
2		.3963
3		.3963
4		.3963
5		.3963
6		.3963
7		.4268
8		.4572
24	.7716	.1219
Max	.7716	.4572
Min	.7716	.1219
Avg	.7716	.3760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 202 / 11KV Goyegaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1524	.1524	.1524	.0762	.1219	.1219
2	.1524	.1524	.1524	.1524	.0914	.1219	.1219
3	.1677	.1524	.1829	.1372	.0914	.1219	.1219
4	.1829	.1829	.1829	.1372	.1219	.1372	.1219
5	.1829	.1829	.1829	.1524	.1372	.1372	.1219
6	.1829	.2134	.1981	.1524	.1524	.1524	.1524
7	.1829	.2134	.2134	.1524	.1524	.1524	.1524
8	.1829						
11	1.8595	1.8747	1.6309		1.4937	1.7528	
12	1.8442	1.9204	1.7071		1.5851	1.829	
13	1.829	1.8747	1.7375		1.6156	1.829	
14	1.8595	1.829	1.7528		1.6461	1.8442	
15	1.9357	1.7985	1.7223		1.6156	1.829	
16	1.9052	1.7375	1.6461		1.6156	1.7985	
17	1.829	1.7071	1.6156		1.5851	1.6461	
18							.1219
19							.1219
20	.1829	.0914	.1372		.061	.1524	.1219
21	.1829	.1524	.1372		.061	.1524	.1219
22	.1524	.1524	.1219		.0914	.1524	.1219
23	.1524	.1524	.1219		.0762	.1372	.1219
24	.9088	.1524	.1524	.1219	.1067	.1372	.1372
Max	1.9357	1.9204	1.7528	.1524	1.6461	1.8442	.1524
Min	.1372	.0914	.1219	.1219	.061	.1219	.1219
Avg	.8007	.7733	.7236	.1448	.6514	.7476	.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 203 / 11KV WASHIMBE /NANGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 204 / 11kv Jyotiba Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2193	1.406	1.5432	1.3717	1.4918	1.4575
2	1.3413	1.2193	1.406	1.4022	1.3717	1.5261	1.5089
3	1.3413	1.2498	1.4403	1.4175	1.3717	1.5432	1.5261
4	1.3413	1.2955	1.4575	1.6289	1.3717	1.5604	1.5432
5	1.4022		1.5432	1.6632	1.448	1.6289	1.5432
6	1.4022	1.3413	1.6632	1.6461	1.4937	1.6804	1.6289
7	1.448	1.3717	1.6461	1.6632	1.5242	1.7318	1.6461
8	1.4937	1.3717		1.6804	1.5242	1.5775	1.6118
17							1.4937
18	.0914	.1029	.12		.0762	.1029	
19	.1067	.1029	.12		.0762	.1029	
20	.1067	.1029	.1029		.0762		.061
21	.0914	.0686	.1029		.0762	.1029	.0914
22	.0914	.0686	.1029		.061	.1029	.0762
23	.0914	.0686	.1029		.061	.0857	.0762
24	.061	.0914	.061	.1029	.0762	.061	.0857
Max	1.4937	1.3717	1.6632	1.6804	1.5242	1.7318	1.6461
Min	.061	.0686	.061	.1029	.061	.061	.061
Avg	.7804	.6910	.8054	1.4164	.7987	.9499	1.0250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 205 / 11kv Washimbe gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1524	.1715	.1715	.1524	.1715	.2058
2	.1677	.1829	.1715	.1715	.1829	.1715	.1715
3	.1829	.192	.2058	.2058	.2134	.2058	.1715
4	.1829	.2134	.2401	.2058	.2134	.2572	.2401
5	.2134	.2439	.2743	.3086	.2743	.3086	.2915
6	.2439	.3048	.3429	.3429	.3048	.3772	.3258
7	.3048	.3353	.4287	.4115	.3506	.4287	.3944
8	.2743	.3048	.3429	.3429	.2743	.3086	.3429
9	.2134	.3086	.2743		.2134	.2229	
10	.2134	.2743	.2401		.1524	.2401	
11	.2134	.2134	.2058		.1524	.2058	
12	.1829	.2229	.1715		.1524	.1543	
13	.1829	.2058	.1372		.1524	.1372	
14	.1829	.1715	.1372		.1524	.1372	
15	.1524	.1715	.1372		.1372	.1543	
16	.1829	.2058	.1715		.1372	.2229	
17	.2134	.2401	.1886		.1524	.2743	
18	.1829	.3086	.2401		.1981	.3429	
19	.1829	.3258	.2915		.2591	.3258	
20	.1829	.3258	.3086		.2896		
21	.1829	.2572	.2572		.2439	.2572	
22	.1524	.2401	.2058		.2134	.2401	
23	.1524	.2058	.2058		.1981	.2229	
24	.1524	.1524	.1981	.1886	.1829	.2058	.2058
Max	.3048	.3353	.4287	.4115	.3506	.4287	.3944
Min	.1524	.1524	.1372	.1715	.1372	.1372	.1715
Avg	.1943	.2400	.2312	.2610	.2064	.2423	.2610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 206 / Kettur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0457	.0686	.0857	.061	.0686	.0686
2	.0914	.0457	.0686	.0857	.061	.0686	.0686
3	.0914	.0457	.061	.0686	.061	.061	.0686
4	.0762	.0457	.0857	.0686	.061	.0857	.0686
5	.0914	.0457	.0857	.0686	.061	.0857	.0857
6	.1067	.061	.0857	.0857	.0762	.0857	.0857
7	.1067	.061	.0686	.0857	.0762	.0686	.0857
8	.0914						
11	1.3413	1.5261	1.3717		1.5604	1.6118	
12	1.3413	1.4175	1.3717		1.6289	1.6804	
13	1.3717	1.5432	1.406		1.6804	1.6289	
14	1.3717	1.5261	1.406		1.6289	1.6632	
15	1.4022	1.5089	1.4232		1.5775	1.6289	
16	1.3717	1.4746	1.3889		1.5089	1.6118	
17	1.3413	1.4575	1.3717		1.4575	1.4918	
18							.061
19							.061
20	.061	.0686	.1029		.0686	.0857	.0762
21	.061	.061	.1029		.0857	.0686	.0762
22	.0457	.0686	.0857		.0686	.0686	.061
23	.0457	.0686	.0857		.0686	.0686	.061
24	.061	.0457	.0686	.0762	.0762	.0686	.061
Max	1.4022	1.5432	1.4232	.0857	1.6804	1.6804	.0857
Min	.0457	.0457	.061	.0686	.061	.061	.061
Avg	.5281	.5851	.5636	.0781	.6246	.6421	.0706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274195 / 33/11KV PANDE S/STN

Feeder No / Name : 201 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.823
Max	.823
Min	.823
Avg	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB
STATION

Feeder No / Name : 201 / JATEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1067
Max	.1067
Min	.1067
Avg	.1067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB
STATIONFeeder No / Name : 202 / WADGAON AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0914
Max	.0914
Min	.0914
Avg	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB
STATIONFeeder No / Name : 203 / KHADAKI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.0974
Max	1.0974
Min	1.0974
Avg	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274211 / HINGANI SUB STATION

Feeder No / Name : 201 / 11KV GULMOHARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1433
Max	.1433
Min	.1433
Avg	.1433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274211 / HINGANI SUB STATION

Feeder No / Name : 203 / 11 KV HINGANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0076
Max	.0076
Min	.0076
Avg	.0076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 201 / 11 KV RAJURI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3222	.3258	.3688	.3688	.3856	.3688	.703
4	.503	.4359	.4973	.4527	.5304	.4359	.9145
6	.6478	.5636	.6882	.547	.6325	.57	1.1888
8	.5668	.4475	.5304	.5304	.5801	.4191	1.2955
10	.3353	1.5394	.3429	.2401	.2658	.3086	.4359
11							.3856
12	1.8185	2.1696	2.572	1.5158		1.5546	
14	1.89	2.0271	2.472	1.5455	2.4577		
16	1.8185	1.9566	2.4006	1.387	2.372		
17	1.6716						
18		.2743	.3429	.4359	.2743	.3429	
20	.3812	.5636	.5243	.4694	.4359	.4641	.4694
22	.3978	.4694	.3601	.4024	.3353	.4359	.4527
24	.3222	.2804	.3688	.3086	.3812	.3521	.3688
Max	1.89	2.1696	2.572	1.5455	2.4577	1.5546	1.2955
Min	.3222	.2743	.3429	.2401	.2658	.3086	.3688
Avg	.8896	.9211	.9557	.6836	.7864	.5252	.6905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 202 / 11KV KORTI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1086	.0732	.1086	.1463	.1448	.0732	.1267
4	.1448	.1463	.1448	.1463	.181	.1086	.1629
6	.2534	.2126	.2126	.2229	.2454	.181	.2149
8	.2149	.2172	.2229	.2126	.1991	.2172	.2172
10	.181	.1463	.1448	.181	.1448	.181	.1829
11							.1463
12	.128	.1267	.1097	.1097	.0914	.1267	
14	.1448	.0905	.1086	.1097	.0914	.1086	
16	.1448	.1097	.128	.1097	.1086	.1086	
18	.1646	.1448	.1448	.1463	.1463	.1629	.2126
20	.1991	.2126	.181	.2172	.1629	.1928	.1448
22	.1267	.1629	.1448	.1448	.1448	.1646	.1629
24	.1097	.1097	.1086	.1086	.1086	.1097	.1097
Max	.2534	.2172	.2229	.2229	.2454	.2172	.2172
Min	.1086	.0732	.1086	.1086	.0914	.0732	.1097
Avg	.1600	.1460	.1466	.1546	.1474	.1446	.1681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 203 / 11 KV GOREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9145	.884	.5761	.7811	.7621	.6299	.2126
4	1.0669	1.1279	.7316	1.1431	.9602	.7468	.2454
6	1.2193	1.2803	.9145	1.4175	1.3672	1.1584	.2915
8	.2743	.7621	1.0974	1.3108	1.3108	1.0974	.3258
10	.2126	.2126	.181	.181	.181	.1991	.2103
11							1.2193
12	.181	.181	.1267	.1463	.1448	.181	
14	.181	.1991	.1448	.1097	.1086	.1629	
16	.1629	.1991	.1629	.1463	.1086	.1448	
18	.2172	.1646	.2172	.1463	.1448	.181	.1949
20	.2481	.2401		.2303	.2743	.2279	.2303
22	.1991	.1886	.2103	.181	.181	.2126	.1949
24	.7926	.5571	.4973	.5407	.181	.181	.1772
Max	1.2193	1.2803	1.0974	1.4175	1.3672	1.1584	1.2193
Min	.1629	.1646	.1267	.1097	.1086	.1448	.1772
Avg	.4725	.4997	.4418	.5278	.4770	.4269	.3302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 201 / 11KV KATRAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 202 / 11 KV TAKALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 203 / 11 KV KHATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11KV ZARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.3681			
6							.679
12		1.2197				1.0402	
13	1.3817		1.0719		.8869		
15				1.0456			
23	.4163	.3704	.4409	.4024	.3906	.4161	.4344
24	.3944	.4119	.3841	.4239	.3812	.4001	.4748
Max	1.3817	1.2197	1.0719	1.0456	.8869	1.0402	.679
Min	.3944	.3704	.3841	.3681	.3812	.4001	.4344
Avg	.7308	.6673	.6323	.56	.5529	.6188	.5294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / 11 KV KHADKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2218	3.0434		2.5463		2.8006	
8			2.846		2.999		
13				.1463			
16		.1886					
17						.1829	
18					.2587		
20							.4525
23	.2172	.2126	.2401	.2149	.2353	.2103	.2561
24	1.3394	1.5708	1.3256	1.4217	1.267	1.2567	.1619
Max	1.3394	3.0434	2.846	2.5463	2.999	2.8006	.4525
Min	.2172	.1886	.2401	.1463	.2353	.1829	.1619
Avg	.5928	1.2539	1.4706	1.0823	1.19	1.1126	.2902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11KV ZARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3258	.3511	.3018	.2601			.3189
9						.3921	
10					.4344		
12				.1463			
14							.1254
17						.1478	
18	.1578						
23		.1698	.1677	.1402	.168	.1526	.1772
24	.1715	.1387	.1448	.1677	.1372		.1372
Max	.3258	.3511	.3018	.2601	.4344	.3921	.3189
Min	.1578	.1387	.1448	.1402	.1372	.1478	.1254
Avg	.2184	.2199	.2048	.1786	.2465	.2308	.1897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 277019 / 132KV PAREWADI

Feeder No / Name : 401 / 33KV Jinti (MAKAI)
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
23	2.3148
24	2.3148
Max	2.3148
Min	2.3148
Avg	2.3148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 201 / RIDHORE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 202 / GFSS MAISGOAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 203 / MAHISGAON AG SEPERATED
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 403 / Vitthal Corporation
(Textile & Feeder KV- 33 /
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 201 / ROPALE AG FDR

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 202 / BITERGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 203 / NADI AG FDR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 204 / CANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 205 / 11 KV MUNGASHI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 206 / BARDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 201 / CHOBE PIMPARI BOGDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0495	.0533	.0667	.0533	.0667	.2534
2		.0495	.0533	.0667	.0533	.0533	.2267
3		.0495	.0533	.0667	.0533	.0533	.2134
4		.0372	.0533	.0667	.0533	.0533	.2134
5		.0495	.0533	.0667	.0667	.0533	.2667
6		.0495	.0533	.0667	.0667	.0533	.3201
7		.0495	.0533	.0667	.0667	.0533	.3467
8		.0619	.0533		.0667	.0667	.3467
9		.0541	.0667		.0667	.0667	
10		.2841	.2934		.3067	.3734	.3467
11	.0372	.4058	.3734		.3334	.3734	
12	.4706	.4464	.3734		.4534	.5201	
13	.483	.487	.3734	.4401	.4801	.4801	
14	.4582	.4734	.3734	.5335	.5068	.5201	
15	.4582	.4734	.3868	.5201	.4801	.4801	
16	.421	.4464	.3601	.5068	.5068		
17	.4087	.4193	.3467	.4934	.4934	.4668	
18	.0867	.1082	.3601	.0934	.0934	.08	.0667
19	.0743	.0812	.0533	.1067	.0934	.1067	.0934
20	.0867	.0676	.0667	.1067	.0934	.0934	.08
21	.0867	.0676	.0533	.1067	.08	.08	.1067
22	.0743	.0541	.0667	.08	.0667	.0667	.0667
23	.0619	.0533	.0667	.08	.08	.0667	.0667
24		.0495	.0667	.0667	.0667	.0934	.0533
Max	.483	.487	.3868	.5335	.5068	.5201	.3467
Min	.0372	.0372	.0533	.0667	.0533	.0533	.0533
Avg	.2467	.1820	.1711	.1895	.1950	.1879	.1917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 202 / 11KV Bogewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2803	1.1584	1.1584	1.1584	1.1126	.1524
2		1.3565	1.3108	1.3108	1.3108	1.326	.1677
3		1.3717	1.448	1.448	1.448	1.5394	.1981
4		1.6918	1.6461	1.6461	1.9547	1.6156	.2286
5		1.829	1.7833	1.7833	1.7833	1.7985	.2439
6		2.1186	1.9204	1.9204	1.9204	2.0729	.2743
7		2.2862	2.1795	2.1795	2.0729	2.3472	.3201
8		2.3765	2.2862		2.4082	2.2558	.2591
9		2.3303	2.271		2.1795	2.1338	
10		.1852			.1829	.2286	
11	1.8138	.1389	.1677		.1524	.1524	
12	.1829	.1543	.1524		.1219	.1677	
13	.1829	.1852	.1524	.1677	.1219	.1677	
14	.1981	.2006	.1524	.1829	.1372	.1677	
15	.1829	.1852	.1677	.1981	.1067	.1372	
16	.1677	.1852	.1829	.1981	.1372		
17	.1981	.1698	.1829	.2134	.1524	.1981	
18	.2134	.216	.1829	.2134	.2134	.1677	1.326
19	.2439	.2315	.2134	.3048	.2286	.2429	.2591
20	.2439	.2469	.2134	.3048	.2439	.2286	.2439
21	.2286	.1852	.2286	.2743	.1981	.2134	.2286
22	.2134	.2006	.2286	.2439	.1677	.1677	.2134
23	.1829	.1852	.1981	.2896	.1524	.1677	.1524
24		1.0059	.8383	.823	.884	.8993	.8993
Max	1.8138	2.3765	2.2862	2.1795	2.4082	2.3472	1.326
Min	.1677	.1389	.1524	.1677	.1067	.1372	.1524
Avg	.3271	.8465	.8376	.7821	.8099	.8482	.3445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 203 / GFSS chobepimpri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0181	.0181	.0181	.0181	.0181	.0181
2		.0181	.0181	.0181	.0181	.0181	.0181
3		.0181	.0181	.0181	.0181	.0181	.0181
4		.0181	.0181	.0181	.0181	.0181	.0181
5		.0181	.0181	.0181	.0181	.0181	.0181
6		.0181	.0181	.0181	.0181	.0181	.0181
7		.0181		.0181	.0181	.0181	.0181
8		.0181	.0181		.0181	.0181	.0181
9		.0127	.0127		.0181	.0181	
10		.0127	.0109		.0109	.0181	
11	.0181	.0127	.0109		.0109	.0181	
12	.0181	.0109	.0109		.0109	.0127	
13	.0127	.0127	.0109	.0181	.0109	.0127	
14	.0127	.0127	.0109	.0175	.0109	.0109	
15	.0109	.0127	.0109	.0181	.0109	.0109	
16	.0109	.0109	.0109	.0181	.0109		
17	.0109	.0109	.0109	.0127	.0109	.0109	
18		.0109	.0109	.0145	.0109	.0109	.0181
19	.0181	.0145	.0181	.0181	.0127	.0181	.0181
20	.0181	.0181	.0181	.0181	.0181	.0181	.0181
21	.0181	.0181	.0181	.0181	.0181	.0181	.0181
22	.0181	.0181	.0181	.0181	.0181	.0181	.0181
23	.0181	.0181	.0181	.0181	.0181	.0181	.0181
24		.0181	.0181	.0181	.0181	.0181	.0181
Max	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Min	.0109	.0109	.0109	.0127	.0109	.0109	.0181
Avg	.0154	.0154	.0150	.0176	.0152	.0164	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 201 / PADSALI AG.(Old Butashte) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2609	.2455	.2619	.2609	.2455
2	.2446	.2455	.2782	.2936	.2619
3	.7339	.9001	.0427	.6523	.9819
4	.8154	1.0147	.0629	.897	1.0474
5	.9785	1.3093	.5892	1.3862	1.2765
6	1.3862	1.5711	1.6693	1.8755	1.5384
7	1.5493	2.1112		2.1364	2.3076
8	2.3647	2.2912	2.2257	2.4137	2.4712
9	2.2995	2.0621	2.6185	2.6257	2.4712
10	1.9081	1.9802	2.3239	2.2506	.9492
11	.2772	.2455	.2782	.2283	.2619
12	.3262	.2782	.2455	.1794	.2128
13	.3262		.2128	.1794	.1964
14	.3262	.2455	.1964	.1631	.2128
15	.3099	.2291	.2128	.1794	
16	.3751		.2455	.1794	
17	.3588		.2291	.1957	
18	.3751		.3273	.2936	
19	.4403		.5401	.5545	
20	.4077		.4582	.5708	
21	.3262		.018	.3914	
22	.2936			.3262	
23	.2772			.2772	.2782
24	.2609	.2619	.2619	.2609	.2619
Max	2.3647	2.2912	2.6185	2.6257	2.4712
Min	.2446	.2291	.018	.1631	.1964
Avg	.7176	.9994	.6332	.7821	.9359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 202 / DHORE WASTI AG FEEDER(OLD SEPARATED AG FEEDERS HAVING SPECIAL
LAUL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1324	.2281	.2363	.1324
2	.1485	.149	.2932	.287	.149
3	.1815	.1656	.2443	.287	.1656
4	.231	.1821		.3207	.1821
5	.2475	.2483	.2932	.3376	.2649
6	.2805	.3477	.3747	.4558	.3808
7	.3135	.4305		.557	.447
8	.3465	.3973	.3747	.4051	.3973
9	.297	.298	.3095	.2701	.3477
10	.2145	.2152	.2118	.2194	.2649
11	1.5509	1.6722	1.5964	1.6205	1.5894
12	1.8974	1.5894	1.7918	1.5023	1.9371
13	2.1119	1.8708	1.7104	2.0762	1.8543
14	1.7819	1.8377		2.0594	1.6887
15	2.1944	1.7881	1.7918	2.0087	
16	1.8974		1.8733	1.9412	
17	1.9139		1.9059	2.0762	
18	1.6472		1.8081	1.9074	
19	.264		.2932	.287	
20	.2609		.3421	.3376	
21	.2145		.1792	.2532	
22	.1794			.1857	
23	.165			.1519	.1656
24	.132	.149	.1466	.1519	.149
Max	2.1944	1.8708	1.9059	2.0762	1.9371
Min	.132	.1324	.1466	.1519	.1324
Avg	.7751	.7171	.8299	.8306	.6322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 203 / GFSS Padsali

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1081	.2455	.09	.1262	.0901
2	.1081	.2455	.126	.1081	.0901
3	.0901	.9001	.144	.1128	.1081
4	.1262	1.0147	.144	.1442	.1081
5	.1622	1.3093	.18	.1802	.1622
6	.1802	1.5711	.2341	.2163	.2163
7	.1983	.1442		.2703	.1983
8	.2163	.1262	.2701	.1983	.2523
9	.2343	.1442	.216	.1983	.2163
10	.1622	.1262	.198	.1983	.1983
11	.1622	.1262	.144	.1442	
12	.1081	.0901	.162	.1442	.1442
13	.1442	.0901	.162	.1081	.1262
14	.1081	.1081	.144	.0901	.1081
15	.1081		.162	.0901	
16	.1262		.144	.1081	
17	.1622		.162	.1081	
18	.1262		.162	.1622	
19	.1622		.2341	.2163	
20	.1442		.2341	.2523	
21	.1442			.2163	
22	.1262			.1802	
23	.1081			.1262	.0901
24	.1262	.2619	.126	.1262	.1081
Max	.2343	1.5711	.2701	.2703	.2523
Min	.0901	.0901	.09	.0901	.0901
Avg	.1434	.4336	.1719	.1594	.1478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 204 / New BUTashte AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1128	.1283	.1289	
2	.1289	.1444	.1289	
3	.5641	.5621	.6447	
4	.6447	.6577	.8059	
5	.7253	.8342	1.0477	
6	.9671	1.0908	1.2894	
7	1.0477	1.6042	1.4506	
8	1.0477	1.6683	.8381	
9	1.4506	1.8769	1.6118	
10	1.4506	1.524	1.4829	
11	.2095	.2406	.1451	
12	.2095	.2406	.1128	
13	.1934	.2085	.1612	
14	.1612	.2406	.1128	
15	.1934	.2085	.1451	
16	.2418		.1451	
17	.2418		.1612	
18	.2418		.1612	
19	.2418		.2901	
20	.2095		.274	
21	.1934		.2095	
22	.1612		.1934	
23	.1451		.1773	.1604
24	.1128	.1444	.1289	
Max	1.4506	1.8769	1.6118	.1604
Min	.1128	.1283	.1128	.1604
Avg	.4540	.7109	.4936	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 205 / UJANI (M) AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.3304	.2891	.3315	.4091
2	.4475	.3304	.2891	.3149	.4091
3	.4973	.3634	.3212	.3481	.4255
4	.5304	.3964	.3533	.3812	.4582
5	.5801	.446	.4497	.4144	.5237
6	.663	.4955	.5461	.5304	.6055
7	.7459	.6772	.5461	.663	.6546
8	.7625	.6772	.6103	.5967	.6546
9	.663	.5616	.5782	.5304	.5401
10	.5801	.4625	.5139		3.0276
11	3.0167	2.3125	2.5697	.547	3.0276
12	3.0001	1.9987		2.3703	3.224
13	2.9007	3.0889	2.4734	3.0498	1.522
14	2.6852	2.9402	2.5697	3.0333	3.2404
15	3.2487	2.8576	2.65	3.0498	
16	3.0167		2.6822		
17			2.7303	2.3205	
18	3.0333		2.5697	3.1161	
19	.4475		.5782	.547	
20	.4641		.5139	.6299	
21	.4475		.5139	.547	
22	.3812		.4176	.4973	
23	.3634			.4475	.3634
24	.3978	.3469	.2891	.3319	.4255
Max	3.2487	3.0889	2.7303	3.1161	3.2404
Min	.3634	.3304	.2891	.3149	.3634
Avg	1.2734	1.1428	1.1389	1.1181	1.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 206 / NEW LAUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8317	1.9933	1.752	
2	1.6724	1.8498	1.6724	
3	.2548	.2551	.1752	
4	.2717	.2551	.2071	
5	.3504	.3189	.2867	
6	.3982	.3987	.4778	
7	.4778	.606	.6371	
8	.7327	.7176	.5734	
9	.6371	.6219	.5734	
10	.4778	.5581	.5415	
11	.4778	.4943	.3823	
12	.5415	.4943	.3185	
13	.5415	.59	.3982	
14	.5415	.4306	.4938	
15	.4778	.4624	.5097	
16	.5575		.4938	
17	.5575		.5575	
18	.5575		.4778	
19	2.2458		2.5484	
20	2.405		2.405	
21	2.3095		2.2458	
22	2.4847		2.1502	
23	2.3095		2.0546	2.0571
24	1.752	2.1528	1.752	
Max	2.4847	2.1528	2.5484	2.0571
Min	.2548	.2551	.1752	2.0571
Avg	1.0360	.7624	.9868	2.0571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALKHUNTE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.448	1.3352	1.3717	1.6289	1.4998	1.448
2	1.448	1.4842	1.4632	1.448	1.6461	1.5203	1.448
3	1.448	1.7194	1.6827	1.5384	1.6289	1.6651	1.5384
4	1.9909	1.9728	1.7737	1.6289	1.8099	2.1176	1.6289
5	2.7149	2.3348		2.1719	2.4691	2.3167	1.7194
6	3.0769	2.9321	2.8778	2.9864	2.7435	2.9447	1.8099
7	3.6199	3.6561	3.819		3.658	3.5848	1.9366
8	3.5294	3.6561	3.2579	3.0588	2.7149	3.1674	1.647
9							2.9502
17	2.1719	2.0995	2.0995	2.0814	2.3529		
18	2.3348	2.2081	2.1176	1.9909	2.1357		
19	2.0452	2.0995		2.0119	2.0995	2.1033	.6154
20	2.1719	1.9185	1.8642	2.0119	1.9004	2.0452	.5792
21	1.9366	1.7918	1.828	1.9004	1.7918	1.8461	.5611
22	1.7194	1.6289	1.7375	1.8099	1.7013	1.6832	.5068
23	1.6289	1.5927	1.6461	1.7194	1.6289	1.5746	.4755
24	1.6289	1.5565	1.4998	1.5729	1.6289	1.6095	1.4842
Max	3.6199	3.6561	3.819	3.0588	3.658	3.5848	2.9502
Min	1.448	1.448	1.3352	1.3717	1.6289	1.4998	.4755
Avg	2.1831	2.1312	2.0716	1.9535	2.0962	2.1199	1.3566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 202 / 11 KV AMBAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3772	.3772	.4115	.4287	.4115	1.1869
2	.4287	.3772	.4161	.4115	.4287	.4115	1.1022
3	.5144	.4115	.4801	.4578	.4287	.4287	1.1022
4	.6001	.463	.5487	.6001	.5144	.463	1.1869
5	.6001	.5487	.7202	.6516	.6001	.6783	1.3565
6	.6001	.8139	.823	.7545	.6068	.823	1.4413
7							1.7901
8							1.6598
9	1.0174	2.5095	2.7831	2.8502	2.7349	3.0514	
10	2.8826	3.1824	2.9843	3.0514	2.8826	3.0167	
11	3.1708	3.4808	2.9508		2.9843	2.9835	
12	3.4476	2.2131	2.7978		3.0178	3.2556	
13	3.3532	3.0167	2.7496	2.572	2.9005	3.1369	
14	3.2895	3.1855	2.6852	2.6578	2.6452	2.9508	
15		3.2156	2.6282	2.6282	2.7978	2.9843	
16	2.6825	2.5149	2.42	2.7435	2.713		
17	1.8442	2.0348	1.8896	1.8652	1.5432	1.757	
18	1.6907		1.757	1.8652	1.6461		
19	1.6575	1.8778		1.5261	1.5939	1.4752	2.8826
20	1.8233	1.8107	1.7436	1.5261	1.5432	1.56	2.7999
21	1.6575	1.6575	1.6263	1.4413	1.406	1.4918	2.7183
22	1.5746	1.576	1.56	1.2717	1.3032	1.4922	2.5987
23	1.5257	1.5261	1.4089	1.2136	1.2003	1.3413	2.3739
24	.6859	1.4413	1.3565	1.3565	.6001	1.1488	1.2071
Max	3.4476	3.4808	2.9843	3.0514	3.0178	3.2556	2.8826
Min	.4287	.3772	.3772	.4115	.4287	.4115	1.1022
Avg	1.6893	1.8207	1.7479	1.5928	1.6600	1.7431	1.8147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 203 / GFSS KURDU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3601	.3429	.3772	.3429	.3772	.3429
2	.3429	.3601	.3429	.3772	.3429	.3772	.3429
3	.3429	.3772	.4458	.4801	.3429	.3772	.3772
4	.4287	.4287	.4801	.5144	.4287	.4287	.463
5	.6001	.4973	.5144	.5487	.5487	.5487	.5144
6	.6859	.6001	.6001	.6344	.6001	.6344	.6344
8	.5144	.6173	.5144	.583	.5144	.4973	
9	.6001	.5658	.5144	.6001	.5487	.5658	.5487
10	.5658	.6001	.5316	.5487	.5487	.463	
11		.583	.4801		.463	.5487	
12	.5144	.4973	.4287		.4287	.463	
13	.463	.4801	.4115	.3429	.3944	.4287	
14	.4287	.4801	.3944	.3772	.3772	.3944	
15		.3772	.3772	.3772	.3429	.2915	
16	.4287	.3258	.3429	.3429	.3258	.3429	
17	.4115	.3772	.3258	.3429	.3429	.3429	
18	.4973	.3772		.4287	.4115		
19	.5487	.6001		.463	.6173	.6001	
20	.5144	.583	.6687	.6173	.6344	.6173	.6516
21	.5144	.5487	.6516	.6001	.5144	.5144	.6516
22	.5144	.3601	.6001	.5487	.463	.4801	.5316
23	.4287	.3601	.4287	.463	.4287	.4287	.463
24	.4115	.3601	.3258	.3772	.3772	.3772	.3429
Max	.6859	.6173	.6687	.6344	.6344	.6344	.6516
Min	.3429	.3258	.3258	.3429	.3258	.2915	.3429
Avg	.4826	.4659	.4630	.4736	.4495	.4591	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVLAS S/STN

Feeder No / Name : 202 / Dhavlas Bogda Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVALAS S/STN

Feeder No / Name : 203 / jhakale-Bhogewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 201 / MAHADEVWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1143	.1334	.2096	.1143	.4763
2		.1143	.0762	.1143	.1715	.1143	.5335
3		.1143	.0762	.1143	.1905	.1524	.5525
4		.1524	.0762	.1334	.2096	.1905	.6668
5		.1905	.1524	.2096	.2286	.2286	.6859
6		.2477	.2858	.2286	.2477	.2667	.724
7		.2858	.3048	.2477	.2286	.2858	.2858
8		.3048	.2477		.2667	.2477	.2667
9		.2286	.1905		.1143	.1905	.2096
10		.1905	.1143		.0762	.1905	
11	.1143	.1524	.0953		.0762	.1143	
12	.1143	.1524	.0953		.1143	.1143	
13	.1524	.1334	.0762	.1143	.1143	.1334	
14	.1524	.1334	.0762	.0762	.1524	.1143	
15		.6401	.6097	.0953	.7621	.743	
16	.5792	.6249	.6401	.7811	.8192		
17	.6706	.6401	.6554	.8192	.8573	.7811	
18	.7621	.6706	.6097	.724	.8764	.7621	.1905
19	.823	.7316	.5792	.7621	.8002	.8192	.2286
20	.8535	.7011	.5487	.5906	.8002	.8573	.2286
21	.8078	.6401	.5487	.6478	.7621	.5716	.1715
22	.7621	.6097	.5335	.5716	.724	.6287	.1143
23	.0914	.1143	.1524	.2858	.1143	.0762	.6097
24		.1143	.1143	.1334	.2667	.1143	.0953
Max	.8535	.7316	.6554	.8192	.8764	.8573	.724
Min	.0914	.1143	.0762	.0762	.0762	.0762	.0953
Avg	.4903	.3334	.2905	.3570	.3826	.3396	.3775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 202 / Barloni Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 203 / Bandhara Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0822	1.2498	1.2765	1.105	.8954	.0762
2		1.0974	1.1888	1.2003	1.1241	.9145	.0762
3		1.0974	1.0669	1.2003	1.0669	.9335	.0762
4		1.1279	1.0364	1.1431	1.0479	.8954	.0762
5		1.1279	1.0212	1.086	1.105	1.0479	.0762
6		1.1431	1.0212	1.086	1.1622	1.1431	.1143
7		.0762	.1334	.1143	.1143	.1334	1.4098
8		.1143	.1524		.1524	.1715	1.5432
9		.0762	.0953		.0762	.1143	1.5623
10		.0762			.0762	.0762	
11	.0762				.0762		
12	.0762				.0762	.0762	
13	.0762						
14	.0762						
15				.0762			
16	.0762			.0762			
17	.1143			.1143	.1143		
18	.1143			.0953	.1334		.0762
19	.0762	.1143	.0953		.1143	.1143	.0762
20	.0762	.0762	.0953	.0762	.0762	.1524	.1143
21	.0762	.0762	.1143	.0953	.0762	.0762	.0953
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	1.0059	1.4022	1.1736	.8002	.7621	1.1431	
24		1.0822	1.3717	1.2765		.9145	1.2384
Max	1.0059	1.4022	1.3717	1.2765	1.1622	1.1431	1.5623
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1600	.6154	.6595	.6121	.4492	.5222	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / GFSS Tandulwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0751	.0751	.129
2			.0751	.0751	.129
3			.0751	.0751	.129
4			.1501	.0751	.129
5			.2252	.1126	.1842
6			.2627	.1501	.2395
7			.1877		.2027
8			.2064		.1842
9		.1364	.1501		.1842
10		.1194	.1126	.1035	
11		1.6028	.1126	.069	
12		.0682	.1501	.069	
13		.0682	.1689		
14		.0682	.1689		
15		.0682	.1689		
16		.0682	.1501		
17		.1364	.1501		
18		.0758	.1314	.1724	
19		.1896	.1877	.1724	
20		.1896	.1877	.2069	
21		.1896	.1126	.2586	
22		.1517	.0751	.1724	
23		.1517	.0751	.1379	
24	1.5242		.1501	.0751	.1474
Max	1.5242	1.6028	.2627	.2586	.2395
Min	1.5242	.0682	.0751	.069	.129
Avg	1.5242	.2189	.1462	.1250	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / Ridhore Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		1.1936	1.1517	1.1488
11		1.2277	1.2703	1.196
12		1.2789	1.2872	1.2275
13		1.2618	1.3042	1.1803
14		1.2448	1.3042	1.1803
15		1.2618	1.2534	1.1803
16		1.2618	1.2703	1.1803
17		1.2618	1.2534	1.0544
24	1.5242			
Max	1.5242	1.2789	1.3042	1.2275
Min	1.5242	1.1936	1.1517	1.0544
Avg	1.5242	1.2490	1.2618	1.1685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / Tandulwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3323	1.1991	1.3717
2			1.3513	1.161	1.3717
3			1.3513	1.18	1.3908
4			1.1991	1.2371	1.4098
5			1.3894	1.2752	1.4289
6			1.4084	1.2942	
7			.8565		1.4289
8			.2094		1.448
9		.1523	.2094		.2096
10		.1523	.1903	.2284	
11		.1713	.1903	.2474	
12		.2094	.1903	.2284	
13		.1903	.2094	.2284	
14		.1903	.2284	.2284	
15		.1903	.2284	.2284	
16		.1903	.2284	.2284	
17		.1903	.2094	.2855	
18		.2855	.2284	.2855	
19		.1903	.2094	.2855	
20		.1903	.2094	.2855	
21		.2284	.1523	.2855	
22		.7613	1.18	1.3323	
23		1.3323	1.18	1.3894	
24	1.5242		1.3323	1.2181	1.3717
Max	1.5242	1.3323	1.4084	1.3894	1.448
Min	1.5242	.1523	.1523	.2284	.2096
Avg	1.5242	.3083	.6447	.6825	1.2701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 201 / 11 KV M.TEKADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 202 / 11 KV UJANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 203 / Kurduwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 204 / 11 KV TANDULWADI (OLD

SHEDDABLE RURAL

MODLIMB Feeder KV- 11 /

OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 205 / 11 KV AKULGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 206 / 11 KV MADHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 207 / 11 KV KURDUWADI W/W
EXPRESS Feeder KV- 11 /
OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 405 / Madha

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 406 / Mahisgaon (Karmala)

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 407 / Jeur

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 409 / Kurdu

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 410 / Vithal Corporation Sugar

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 702 / 132 kv indian suger

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	18.2899
Max	18.2899
Min	18.2899
Avg	18.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 201 / Nimgaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.0288	.9774	.8059	.6859	.9774	.1715
2	1.0631	1.0288	.9945	.823	.7716	.9774	.1715
3	1.1831	1.0288	.9431	.8402	.8573	.9602	.1886
4	1.2517	1.166	1.0288	.8573	1.0288	.9945	.1886
5	1.3203	1.166	1.0288	.9431	1.1317	1.0288	.1886
6	1.406	1.1831	1.1488	1.0288	1.1831	1.1145	.2058
7	1.4746	1.5947	1.5089	1.3717	1.3717	1.4575	.2229
8	1.4232	1.4746	1.5089	1.1145	1.5089	1.5261	.2058
9	1.2174	1.1317	1.4403	1.2174	1.5261	1.1488	.1715
10	.1543	.1715	.1715	.1715	.1886	.2058	1.046
11	.2058	.1543	.1543	.1715	.2058	.1543	1.3203
12	.2401		.1886	.2229	.2229	.1886	
13	.3086		.2058	.2401	.2229	.2229	
14	.2915		.2058	.2401	.2058	.2401	
15	.2743	.2572	.1715	.2401	.2058	.2572	
16	.2229	.2743	.2058	.2572	.2058	.2915	
17	.2915	.2743	.2058	.2743	.2229	.2743	
18	.3086	.2572	.2401	.3086	.2401		.1543
19	.2915	.2572	.2229	.3086	.2401	.2229	.1886
20	.2743	.2401	.2401	.3086	.2572	.2401	.2229
21	.2572	.2229	.2229	.3086	.2572	.2229	.3086
22	.2058	.2058	.1715	.2915	.1886	.2058	.2915
23	.1715	.1886	.1715	.1543	.1886	.1715	.2743
24	.8745	.8573	.6859	.7888	.3772	.9259	.1715
Max	1.4746	1.5947	1.5089	1.3717	1.5261	1.5261	1.3203
Min	.1543	.1543	.1543	.1543	.1886	.1543	.1543
Avg	.6537	.6744	.5851	.5537	.5623	.6091	.3163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 202 / MADHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3086	.3944	.4287	.4115	.3772	.4973
2	.4287	.3086	.3944	.4287	.3429	.3772	.5144
3	.4458	.3429	.3772	.4115	.3944	.3601	.5487
4	.463	.3944	.4287	.4458	.5144	.3772	.5487
5	.4801	.4287	.4287	.4801	.5487	.4287	.5658
6	.5316	.4458	.5487	.5144		.4801	.583
7	.583	.5316	.6173	.583	.6173	.583	.6344
8	.5658	.5144	.6173	.6001	.5144	.4801	.6001
9	.4458	.4973	.5487	.5144	.5144	.4458	.5316
10	.5316	.463	.5658	.5144	.5658	.4973	.5658
11	.5316	.5144	.5316	.5144	.5316	.5487	.5487
12	.5144		.5316	.5316	.5144	.5487	.5487
13	.5144		.4973	.5144	.5144	.5658	.5144
14	.4801		.5144	.5144	.5144	.5487	.5316
15	.4973	.583	.5487	.5316	.6001	.5658	.5487
16	.463	.583	.5487	.5144	.5316	.5658	.5487
17	.5144	.6173	.6001	.5487	.5658	.583	.5316
18	.5316	.6687	.6344	.6173	.5658	.6516	.5658
19	.5144	.8402	.7202	.583	.6859	.7888	.6001
20	.5487	.7545	.6859	.6001	.6173	.7202	.583
21	.4287	.6687	.6001	.583	.5658	.6687	.5658
22	.4115	.6001	.5658	.5144	.5316	.6001	.5144
23	.3944	.4801	.5144	.463	.4458	.5487	.0857
24	.3944	.3086	.463	.4458	.4287	.3944	.4801
Max	.583	.8402	.7202	.6173	.6859	.7888	.6344
Min	.3944	.3086	.3772	.4115	.3429	.3601	.0857
Avg	.4844	.5169	.5366	.5166	.5233	.5294	.5315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 203 / JADHAVWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2229	.2915	.2229	.2229	.8573
2	.2743	.2401	.2229	.3086	.2401	.2229	.9431
3	.2915	.2572	.2401	.3258	.2743	.2229	.9774
4	.3086	.3086	.2572	.3429	.3086	.2572	1.0288
5	.3258	.3429	.2915	.3601	.3944	.2743	1.1831
6	.3258	.3772	.4115	.3601	.7373	.4287	1.5432
7	.4458	.3944	.4801	.4287	.4458	.4458	2.1434
8	.4287	.3601	.3944	.3944	.4287	.4115	2.0748
9	.3258	.2915	.3258	.3086	.3429	.3944	1.9719
10	2.332	1.6804	1.4403	1.5604	1.0802	1.4575	.3086
11	2.8292	2.5892	2.2291	1.8861	1.6804	2.4691	.3086
12	2.8292	2.6235	2.5206	2.6406	1.9719	2.5206	.2915
13	2.8121	2.7435	2.452	2.6235	2.3148	2.5377	.3086
14	2.8464	2.5892		2.6235	2.4006	2.6235	.2915
15	2.7435	2.4348	1.9547	2.5892	2.4177	2.7435	.3086
16	2.5377	2.692	1.8347	2.6235	2.4691	2.6578	.2915
17		2.4006	2.2634	2.5892	2.5034	2.4006	.2915
18	.3429	.2572	.2572	.3086	.2401	.3601	.3086
19	.3944	.4115	.3772	.3429	.3429	.4287	.3429
20	.4115	.3772	.3944	.3944	.3944	.3944	.3944
21	.3429	.2915	.3258	.4115	.3429	.3429	.4115
22	.2743	.2401	.3086	.3429	.2915	.3601	.4287
23	.2401	.2401	.2743	.3086	.2743	.3772	.4115
24	2.6692	.2401	.2229	.2743	.2229	.2401	.8402
Max	2.8464	2.7435	2.5206	2.6406	2.5034	2.7435	2.1434
Min	.2401	.2401	.2229	.2743	.2229	.2229	.2915
Avg	1.1560	1.0260	.8566	1.0267	.9309	1.0331	.7609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 204 / chincholi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0514	.0343	.0343	.0343	.0343	.2572
2	.0343	.0514	.0343	.0343	.0343	.0343	.3429
3	.0343	.0514	.0343	.0343	.0514	.0343	.3772
4	.0514	.0686	.0514	.0514	.0686	.0343	.3944
5	.0857	.0857	.0514	.0686	.0857	.0514	.4287
6	.1029	.1029	.0857	.1029	.1029	.0857	.463
7	.1372	.1029	.1029	.1372	.12	.0857	.7716
8	.1029	.12	.12	.0857	.0857	.0857	.823
9	.1029	.0857	.0686		.0514	.1029	.8059
10	.7545	.5487	.3429		.3429	.3429	.0514
11	.9774	1.1317	.8745		.6859	.8573	.0514
12	1.0802	1.0802	.9088		.7716	.9431	.0343
13	1.0974	1.1317	.8916		.9088	.9602	.0343
14	1.1317	1.0802	.8745	.6859	.8573	.9945	.0343
15	1.0288	.9774	.6516	.6859	.8916	1.0117	.0343
16	.9774		.7888	1.0802	1.0117	.9945	.0229
17	.9259	.9259	.8745	1.0288	.8916	.8916	.0343
18	.0686	.0514	.0343	.1029	.0514	.1372	.0514
19	.1029	.0857	.0857	.1029	.0514	.0343	.0686
20	.1029	.0686	.0686	.12	.0514	.0857	.0857
21	.0857	.0514	.0686	.1029	.0343	.0514	.12
22	.0686	.0343	.0514	.0857	.0343	.0343	.1029
23	.0514	.0343	.0343	.0514	.0343	.0343	.3429
24	2.4291	.0514	.0343	.0343	.0343	.0343	.1543
Max	2.4291	1.1317	.9088	1.0802	1.0117	1.0117	.823
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0229
Avg	.4820	.3466	.2986	.2437	.3036	.3315	.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 201 / WAKAV

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.2517	1.3375	1.286	.7888	1.0117	.2572
2	1.4918	1.2517	1.3375	1.286	.7888	1.0117	.2572
3	1.4918	1.2517	1.3375	1.286	.7888	1.0117	.2572
4	1.4918	1.3032	1.3375	1.3717	.9945	1.0117	.3601
5	1.6461	1.3546	1.4575	1.4575	1.0974	1.0631	.4287
6	1.7318	1.5089	1.5947	1.6632	1.3032	1.5089	.5144
7	2.1776	1.9204	2.0233	1.9547	1.8176	1.8176	.6687
8	1.989	1.6118	1.4918	1.6804	1.7661	1.6975	.4801
9	.4458	.3429	.3944	.3772	.3429	.3772	1.6461
10	.3086			.3086	.2743	.3429	
11	.2229	.2572	.1715	.2058	.1715	.3429	
12	.2572	.2401	.1886	.2058	.1715	.2058	
13	.2743	.2229	.1886	.2058	.2058	.1715	
14	.2743	.2229	.1886	.2058	.2058	.1886	
15		.2229	.2229	.2058	.2058	.1886	
16	.2743	.2229	.2229	.2058	.2229	.1886	
17	.3429	.2058	2.2634	.2058	.2229	.1886	.2572
18	.4115	.2401	.2915	.2743	.3429	.3429	.2743
19	.4801	.5316	.5316	.4801	.5144	.5316	.4801
20	.4801	.5658	.5658	.4801	.4801	.4458	.4801
21	.3429	.4458	.4115	.4801	.3944	.4115	.463
22	.3429	.3772	.3429	.3429	.3772	.3429	.3429
23	.3429	.3772	.3086	.2743	.2743	.2572	.2743
24	2.4291	.2743	.2915	.2743	.2743	.2743	.2572
Max	2.4291	1.9204	2.2634	1.9547	1.8176	1.8176	1.6461
Min	.2229	.2058	.1715	.2058	.1715	.1715	.2572
Avg	.9018	.7045	.8044	.6966	.5844	.6223	.4529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 202 / MANEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 203 / ANGENGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.0288	1.8519	1.8004	1.3717	1.9033	.0857
2	1.4746	1.0288	1.8519	1.8004	1.3717	1.9033	.0857
3	1.4746	1.0288	1.8519	1.8004	1.3717	1.9033	.0857
4	1.4746	1.1145	1.8519	1.8004	1.4575	1.9033	.1372
5	2.0576	1.2003	1.9033	1.8861	1.5432	2.0576	.1715
6	2.4863	1.3717	2.2634	1.9547	1.8861	2.4006	.2743
7	3.1207	1.4575	3.0864	2.2462	2.2291	3.0864	.3086
8	2.915	1.4232	2.7435	2.1262	2.0576	2.7778	.1715
9	.1372	.1372	.1543	.1372	.1715	.0857	3.0178
10	.1029		.1029	.0686	.1715	.0686	
11	.1715	.0857	.1029	.1372	.1372	.0686	
12	.1372	.0857	.1029	.1372	.0686	.0857	
13	.1372	.0686	.1029	.1372	.0686	.0857	
14	.1372	.0686	.1029	.1372		.0857	
15	.1372	.0686	.1029	.1372	.0686	.0857	
16	.1372	.0686	.1029	.1372	.0686	.0857	
17	.1715	.0686	.0343	.1715	.0686	.0857	.1372
18	.1715	.0686	.0686	.1715	.0857	.1029	.1372
19	.1715	.1715	.2058	.1715	.1715	.1715	.2058
20	.1715	.2401	.2058	.1715	.2572	.1715	.2058
21	.1715	.1372	.1372	.1715	.1543	.1715	.2058
22	.1715	.1029	.1029	.1372	.1372	.1029	.1715
23	.1715	.1029	.1029	.1372	.1029	.0857	.1715
24	2.2672	.1715	.1029	.0686	.1372	.0857	.0857
Max	3.1207	1.4575	3.0864	2.2462	2.2291	3.0864	3.0178
Min	.1029	.0686	.0343	.0686	.0686	.0686	.0857
Avg	.8768	.4913	.8016	.7352	.6590	.8152	.3329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 204 / KHAIRAO

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2743	.2058	.2058	.2743	.2058	1.1145
2	.2058	.2743	.2058	.2058	.2743	.2058	1.1145
3	.2058	.2743	.2058	.2058	.2743	.2058	1.1145
4	.2058	.2743	.2058	.2058	.2743	.2058	1.1488
5	.2572	.2743	.2572	.2572	.2743	.2572	.2572
6	.3258	.2743	.3429	.3258	.2743	.3086	.2572
7	.2915	.2743	.2743	.3258	.2743	.3086	.3429
8	.2572	.2743	.2572	.2572	.2743	.2572	.2915
9	.2229	.2058	.2229	.1715	.2058	.1886	
10	.1715		.1029	.1029	.1543	.12	
11	.1715	.1715	.1029	.1029	.0857	.1029	
12	.1372	.12	.1029	.1029	.0857	.1029	
13	.1029	.0857	.12	.1029	.0572	.0857	
14	.12	.0857	.12	.1029	.1029	.1029	
15	.12	.1029	.0857	.1029	.1029	.1029	
16	.12	.1029	.0857	.1029	.1029	.1029	
17	3.035	2.6749	2.2634	2.7092	2.4006	2.3663	.1715
18	2.6578	2.9492	2.3491	2.7092	2.2805	2.1434	.1715
19	2.332	2.572	2.2291	2.0233	1.8861	1.749	.2743
20	2.4348	2.3148	2.0233	1.9204	1.7147	1.7833	.2743
21	2.4691	2.0576	1.8004	1.8176	1.6632	1.8176	.2229
22	2.3148	1.989	1.7833	1.8519	1.6118	1.5604	.2058
23	2.3148	1.8861	1.749	1.7661	1.5432	1.3717	.1715
24	2.4291	2.1776	1.8347	1.7147		1.4746	1.2003
Max	3.035	2.9492	2.3491	2.7092	2.4006	2.3663	1.2003
Min	.1029	.0857	.0857	.1029	.0572	.0857	.1715
Avg	.9628	.9430	.7888	.8081	.7040	.7137	.5208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 205 / KAPASEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.1029	.1029	.1715	.0514	.0857
2	.0857	.1715	.1029	.1029	.1715	.1029	.0857
3	.0857	.1715	.1029	.1029	.1715	.1029	.0857
4	.0857	.1715	.1029	.1029	.2058	.1715	.1029
5	.2058	.1715	.1715	.1715	.2058	.2572	.1372
6	.2401	.2572	.2401	.2572	.2743		.2058
7	.3086	.2572	.2915	.2915	.2572	.3086	.3086
8	.2572	.2572	.2743	.2401	.2401	.2401	.2743
9	1.9719	2.0576	1.6289	1.6975	1.8347	1.6289	
10	2.0576		1.8861	1.5775	1.8176	1.5432	
11	2.0576	1.9204	1.9719	1.6804	1.8861	1.749	
12	2.2291	1.9719	2.0405	1.5089	1.8347	1.9033	
13	2.3663	1.9719	1.8861	1.8861	1.8861	1.749	
14	2.2291	1.989	1.8861	1.8861	1.989	1.8861	
15	1.9719	1.8861	1.9547	1.9204	1.8519	1.8861	
16	1.9719	1.9204	1.9204	1.9204	1.7147	1.8861	
17	.1372	.0857	.0343	.1715	.0686	.0514	2.1262
18	.1715	.1029	.0514	.1715	.1029	.1029	.2058
19	.2058	.2743	.2058	.2229	.1715	.1543	.2229
20	.2058	.2229	.1886	.2229	.2572	.1372	.2743
21	.1715	.12	.1372	.2058	.1372	.1372	.2058
22	.1715	.12	.1029	.2058	.1029	.1029	.1715
23	.1715	.1029	.1029	.1715	.1029	.0857	.1715
24	1.6766	.1715	.1029	.1029	.1715	.1029	.0857
Max	2.3663	2.0576	2.0405	1.9204	1.989	1.9033	2.1262
Min	.0857	.0857	.0343	.1029	.0686	.0514	.0857
Avg	.8801	.7194	.7287	.7052	.7345	.7105	.2969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 206 / kumbhej

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715		.1715	.1715	.1029	.1715
2	.1372	.1715		.1715	.1715	.1029	.1715
3	.1372	.1715		.1715	.1715	.1029	.1715
4	.1372	.1715		.1715	.1715	.1029	.1715
5	.1543	.1715		.1715	.1715	.1029	.1715
6	.1715	.1715		.1715	.1715	.1543	.1715
7	.1715	.1715	.1715	.1715	.1715	.1715	.1715
8	.1372	.1715	.1372	.1715	.1715	.1372	.1715
9	1.0802	.9431	.8402	.8916	.6344	.823	
10	1.2346		.8402	.9259	.8059	.8059	
11	1.046	1.0117	.8402	.9259	.6173		
12	1.0974	1.0117	.8402	.8745	.6173	.6859	
13	1.166	.9259	.7716	.823	.6173	.6687	
14	1.1488	.9259	.7716	.823	.6173	.5658	
15	1.0974	.7888	.7716	.7202	.5658	.5658	
16	1.0974	.7888	.7716	.7202	.6173	.5658	
17	.1715	.0686	.2058	.1715		.1715	.7545
18	.1715	.0686	.2058	.1715		.1715	.1715
19	.1715	.1543	.1715	.1715	.1029	.1715	.1715
20	.1715	.1543	.1715	.1715	.1543	.1715	.1715
21	.1715	.1029	.1715	.1715	.1029	.1715	.1715
22	.1715	.0857	.1715	.1715	.1029	.1715	.1715
23	.1715	.0857	.1715	.1715	.1029	.1715	.1715
24	2.4291	.1715	.0857	.1715	.1715	.1029	.1715
Max	2.4291	1.0117	.8402	.9259	.8059	.823	.7545
Min	.1372	.0686	.0857	.1715	.1029	.1029	.1715
Avg	.5742	.3765	.4506	.3937	.3274	.3027	.2079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 201 / Uplai(BK)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.6001	1.286	1.0288	.8573	1.3717	.1715
2	1.6289	.6001	1.3717		.8573	1.3717	.1715
3	1.6289	.6859	1.5432	1.2003	.8573	1.5432	.1715
4	.6001	1.3717	1.5432		1.286	1.6289	.1715
5	.8573	2.0576	2.2291	1.8861	1.5432	2.0576	.1715
6	.9431	2.572	2.572	2.1434	2.4006	2.4006	.3429
7	.9431	2.6578	2.915		2.7435	3.0007	.4458
8	.9431	2.7435	3.0864		1.8347	3.0864	.4115
9	2.1434	2.1434	2.915		2.7435	2.7435	.3429
10	.1715	.2572	.2229	1.286	.2572	.2572	1.7147
11	.2229	.1715	.1715	.3429	.1715	.1886	2.6578
12	.1715	.1715	.1372	.1715	.1715	.1543	
13	.2058	.1715	.12	.1715	.1715	.1715	
14	.2058	.1715	.12	.1715	.1543	.1715	
15	.2572	.1715	.1715	.1715	.1372	.1715	
16	.2572	.1715	.1715	.1715	.1543	.1715	
17	.2572	.1715	.1715	.1372	.1715	.1715	
18	.3086	.1715	.2229	.2229	.1715	.2572	.2572
19	.3429	.2572	.3429	.3086		.2572	.3429
20	.3944	.3429	.3944	.3944	.3429	.2572	.4287
21	.3429	.3429	.3258	.3429	.3429	.2572	.3772
22	.3086	.3429	.2915	.2572	.3429	.1715	.3429
23	.2401	.2572	.2743	.2572	.2572	.1715	.2915
24	.7716	.6001	.9431	.9431	.3429	.8573	.1715
Max	2.1434	2.7435	3.0864	2.1434	2.7435	3.0864	2.6578
Min	.1715	.1715	.12	.1372	.1372	.1543	.1715
Avg	.6537	.8002	.9809	.6110	.7962	.9538	.4992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 202 / Rophale(KH)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715	.8573
2	.1715	.1715	.1715	.1715	.1715	.1715	.8573
3	.1715	.1715	.1715	.1715	.1715	.1715	.9431
4	.1715	.1715	.1715	.1715	.1715	.1715	1.0288
5	.1715	.1715	.1715	.1715	.1715	.1715	1.286
6	.2572	.1715	.1715	.2572	.1715	.2572	1.3717
7	.2572		.2572	.1715	.1715	.2572	1.8004
8	.2572	.2572	.2572		.2572	.1715	2.3148
9	.2572	.2572	.2572		.2572	.2572	2.1434
10	1.7147	1.286	.8573	.1715	.9431	2.0576	.1715
11	2.572	2.7435	2.572	1.3717	1.286	2.1434	
12	2.7435	2.4006	2.572	2.4863	1.286	2.3148	.1715
13	2.915	2.572	2.572	2.572	1.286	2.4863	.1715
14	2.572	2.2291	2.572	2.2291	1.286	2.4863	.1715
15	2.4863	2.8292	2.572	2.1434	1.286	2.4006	.1715
16	2.4863	2.572	2.4863	1.9719	2.572	2.4006	.1715
17	2.4006	2.4863	2.572	1.7147	2.4006	2.2291	.1715
18	.3429	.2572	.1715	1.8861	.1715	.2572	.1715
19	.3429	.2572	.2572	.1715	.2572	.2572	.1715
20	.3429	.2572	.2572	.1715	.2572	.2572	.1715
21	.1715	.2572	.2572	.1715	.2572	.1715	.1715
22	.1715	.2572	.1715	.1715	.2572	.1715	.1715
23	.1715	.2572	.1715	.1715	.2572	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.2572	.8573
Max	2.915	2.8292	2.572	2.572	2.572	2.4863	2.3148
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.9788	.9729	.9181	.8574	.6537	.9109	.6822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 203 / ANGENGAON(KH)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1338
Max	2.1338
Min	2.1338
Avg	2.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 204 / GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2572	.2572	.1715	.3429	.1715	.1715
2	.1715	.1715	.1715	.1715	.3429	.1715	.1715
3	.1715	.1715		.1715	.3429	.2572	.1715
4	.1715	.1715	.1715	.1715	.2572	.2572	.1715
5	.2572	.1715	.2572	.1715	.2572	.2572	.2572
6	.3429	.2572	.2572	.2572	.2572	.2572	.2572
7	.3429	.3429	.2572	.1715	.2572	.2572	.3429
8	.4287	.3429	.2572		.3429	.2572	.3429
9	.4287	.2572	.2572		.2572	.2572	.2572
10	.2572	.2572	.2572	.3429	.3429	.2572	.2572
11	.3429	.2572	.2572	.3429	.2572	.2572	.3429
12	.3429		.1715	.3429	.2572	.2572	.3429
13	.3429	.2572	.2572	.1715	.2572	.2572	.3429
14	.1715	.2572	.1715	.2572	.1715	.1715	.1715
15	.2572	.1715	.1715	.2572	.1715	.1715	.2572
16	.2572	.1715	.1715	.1715		.1715	.2572
17	.2572	.1715	.1715	.1715	.1715	.1715	.2572
18	.3429	.2572	.2572	.3429	.1715	.1715	.2572
19	.3429	.3429	.4287	.3429	.2572	.4287	.3429
20	.3429	.3429	.4287	.3429	.3429	.4287	.3429
21	.3429	.3429	.4287	.3429	.3429	.4287	.3429
22	.3429	.3429	.3429	.3429	.3429	.4287	.3429
23	.3429	.3429	.2572	.3429	.2572	.3429	.3429
24	.3429	.2572	.3429	.1715	.3429	.1715	.2572
Max	.4287	.3429	.4287	.3429	.3429	.4287	.3429
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.2965	.2572	.2609	.2533	.2758	.2608	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 205 / Kumbhej

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2572	.1715	.1715	.1715	.6859
2	.1715	.1715	.2572	.1715	.1715	.1715	.7716
3	.1715	.1715	.2572	.1715	.1715	.1715	.7716
4	.1715	.1715	.2572	.1715	.1715	.1715	1.2003
5	.1715	.1715	.2572	.1715	.1715	.2572	1.286
6	.2572	.1715	.2572	.1715	.1715	.2572	1.3717
7		.2572	.2572	.1715	.1715	.2572	1.5432
8		.2572			.2572	.2572	1.8004
9		.2572	.1715		.2572	.2572	1.7147
10	1.7147	1.2003	.8573	.2572	.8573	.8573	.1715
11	2.2291	1.286	1.9719	1.3717		.8573	
12	2.2291	1.3717	2.0576	2.3148	.8573	1.7147	.1715
13	2.2291	1.5432	2.1434	2.2291	1.0288	1.8004	.1715
14	2.2291	1.3717	2.2291	2.1434	1.0288	1.8004	.1715
15	2.2291	1.5432	2.2291	2.0576	1.0288	1.7147	.1715
16	2.3148	1.6289	2.2291	2.1434	.8573	1.8004	.1715
17	2.3148	1.3717	2.1434	2.2291	.9431	1.7147	.1715
18	.2572	.1715	.1715	1.8004	.1715	.1715	.1715
19	.2572	.2572	.2572	.2572	.2572	.2572	.1715
20	.2572	.2572	.2572	.2572	.2572	.2572	.1715
21	.1715	.2572	.2572	.2572	.2572	.1715	.1715
22	.2572	.2572	.1715	.2572	.2572	.1715	.1715
23	.2572	.2572	.1715	.2572	.2572	.1715	.1715
24	.1715	.2572	.2572	.1715	.1715	.2572	.6001
Max	2.3148	1.6289	2.2291	2.3148	1.0288	1.8004	1.8004
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.9635	.618	.8424	.8729	.4324	.6537	.6076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 206 / UPLAI(KH)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	.823	1.0288	.8573	.7716	1.4575	.2572
2	1.3717	.823	1.0288	.9431	.7716	1.5432	.2572
3	1.3717	.823	1.2003	.9431	.7716	1.5432	.2572
4	1.6289	1.0288	1.5432	1.0288	.8573	1.9719	.2572
5	.1715	1.3717	1.6289	1.5432	1.3717	1.9719	.2572
6	2.0576	1.8004	2.0576	1.8861	2.2291	2.0576	.4115
7	2.7949	2.3148	2.8292	.1543	2.7092	2.6063	.4287
8	2.452	2.6406	2.692		2.6063	2.7435	.3601
9	2.3663	1.9376	1.8861		2.572	2.6406	.2572
10	.1715	.2572	.3086	2.2291	.3429	.2572	1.5261
11	.1715	.2401	.2058	.1715	.2401	.2915	1.989
12	.1715	.1715	.2058	.1715	.2572	.2572	
13	.2229	.1715	.2058	.1715	.2572	.1715	
14	.2229	.2572	.1886	.1715	.1715	.1715	
15	.2401	.1886	.1886	.2058	.2058	.1715	
16	.2915	.1715	.1886	.2401	.2915	.1715	
17	.2915	.2572	.2743	.2401	.2572	.2572	
18	.3429	.2572	.2915	.3258	.2572	.3086	.3086
19	.3601	.3429	.3429	.3772	.4287	.3429	.3772
20	.3772	.3429	.3772	.4287	.3429		.463
21	.3086	.4287	.3601	.3944	.3429	.3429	.3944
22	.2572	.4287	.3258	.3429	.2915	.3258	.3429
23	.2572	.3429	.3086	.2915	.2572	.3086	.3086
24	.8573	.823	.9945	.7716	.7716	.6859	.2915
Max	2.7949	2.6406	2.8292	2.2291	2.7092	2.7435	1.989
Min	.1715	.1715	.1886	.1543	.1715	.1715	.2572
Avg	.8352	.7602	.8609	.6313	.8073	.9826	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 207 / vittalwadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0514	.0514	.5144
2	.0514	.0514	.0514	.0514	.0514	.0514	.6001
3	.0514	.0514	.0514	.0514	.0514	.0514	.6859
4	.0686	.0514	.0514	.0514	.0857	.0686	.7716
5	.1029	.0514	.0514	.0514	.0857	.0857	.8573
6	.0686	.0514	.0857	.1029	.0857	.0857	.9431
7	.0857	.0857	.1715	.1029	.1372	.12	1.1145
8	.0857	.1715	.1715		.1372	.1715	1.3375
9	.1029	.12	.12		.1372	.1715	1.2003
10	1.3717	.8573	.8059	.0514	.0686	.7716	.0686
11	1.6975	1.6804	1.7147	1.0288	1.3203	1.3717	.0686
12	1.6289	1.6975	1.7147	1.5775	1.3717	1.3546	.0686
13	1.5604	1.6289	1.7147	1.5432	1.4918	1.4232	.0514
14	1.4575	1.5432	1.6461	1.4746	1.5089	1.4575	.0514
15	1.3717	1.4403	1.5432	1.4403	1.286	1.4575	.0686
16	1.2003	1.5432	1.5261	1.406	1.3032	1.4575	.0857
17	1.1317	1.5947	1.3375	1.406	1.286	1.286	.0857
18	.0514	.0686	.0686	.9088	.0686	.1029	.0857
19	.0514	.0857	.0686	.0514	.12	.0686	.0514
20	.0514	.1715	.1029	.0514	.1715	.0686	.0514
21	.0514	.1715	.0686	.0514	.1715	.0686	.0514
22	.0514	.12	.0686	.0514	.12	.0514	.0686
23	.0514	.0857	.0686	.0514	.0857	.0514	.0686
24	.0514	.0514	.0686	.0514	.0514	.0686	.4287
Max	1.6975	1.6975	1.7147	1.5775	1.5089	1.4575	1.3375
Min	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.5187	.5594	.5551	.5276	.4687	.4965	.3908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 208 / londewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 201 / Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.787	.8025	.8124	.7407	.8535	.7811	.2263
2	.7499	.8124	.8322	.7499	.8642	.7842	.1867
3	.8539	.8381	.8745	.7811	.8592	.787	.1886
4	.8796	.8488	.8745	.7926	.9172	.7907	.3361
5	.9877	.9172	.8907	.8642	.9762	.787	.4338
6	1.0155	1.0279	1.0936	.9962	1.1385	.9717	.5228
7	1.0911	1.1544	1.2334		1.247	1.0467	.5847
8	1.0802	1.2803	1.2498	1.2323	1.2803	.9568	.4481
9	1.0648	1.142		1.2651	1.1702		.3921
10	.3142	.298	.2715	.2926	.2804	.3395	.7773
11	.3142	.3155	.2378	.2715	.2629	.3174	
12	.3109	.298	.2378	.2507	.2629	.3174	
13	.2686	.2804	.2402	.2507	.2534	.2987	
14	.2896	.2629	.2629	.2534	.2534	.3018	
15	.3045	.2629	.2686	.2715	.2629	.3206	
16	.3258	.3155	.2926	.2715	.2629	.3206	
17	.333	.298	.3258	.2896	.2926	.3547	
18	.362	.3681	.3326	.3258	.4344	.3921	
19	.4163	.333		.4525	.3012	.5093	
20	.5041	.3721	.5175	.5359	.3982		.5914
21	.4294	.4031	.4668	.462	.4252		.5359
22	.3547	.3681	.4294	.3921	.4031		.2614
23	.2987	.3506	.3361	.2987	.3801		.3921
24	.8162	.7773	.8025	.7621	.7842	.8097	.2987
Max	1.0911	1.2803	1.2498	1.2651	1.2803	1.0467	.7773
Min	.2686	.2629	.2378	.2507	.2534	.2987	.1867
Avg	.5897	.5886	.5856	.5566	.6068	.5888	.4117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 202 / kevad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.1886	.2172	.1886	.2075	.2378	.3149
2	.333	.1698	.2353	.1886	.2075	.2534	.2846
3	.3601	.1698	.2561	.2263	.1886	.2534	.3041
4	.3681	.2452	.2715	.3018	.2641	.3077	.3125
5	.4207	.3395	.3982	.415	.415	.3258	.3932
6	.4715	.2829	.4207	.5847	.6224	.3721	.5376
7	.5093	.6602	.4382		.6413	.439	.7042
8	.4527	.3018	.4908	.6036	.5093	.4784	.7907
9	.3961	.4527		.3772	.3584		.8436
10	.8642	.6401	.5921	.7926	.9122	.7682	
11	1.078		.9374	.8951	.9259	.8642	
12	1.2186	1.0155	.9374	1.0212	.9922	.9602	
13	1.1584	.9877	.9145	1.0364	.9998	1.0562	
14	1.1584	.9374	.884	1.0364	1.0185	1.0437	
15	1.1584	.9804	.8322	1.0212	.9998	1.0467	
16	1.0517	.9105	.8535	1.0212	.9998	1.0883	
17	.945	.9393	.8398	1.0364	1.086	1.0562	
18	.181	.1578	.2075	.1867	.181	.3921	
19	.2987	.1753		.3174	.3155	.4527	
20	.3772	.1772	.4338	.3772	.3109		.4338
21	.3206	.333	.3395	.2829	.298		.3772
22	.2641	.298	.3018	.2452	.2804		.2829
23	.2054	.2743	.2263	.2263	.2629		.2075
24	.333	.1886	.2103	.1886	.1886	.2534	.3201
Max	1.2186	1.0155	.9374	1.0364	1.086	1.0883	.8436
Min	.181	.1578	.2075	.1867	.181	.2378	.2075
Avg	.5942	.4707	.5108	.5465	.5494	.6131	.4362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 203 / Undergoan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2778	.176	.1943	.2321	.253	.3077	.2263
2	.2812	.1619	.1943	.2347	.2561	.2656	.1867
3	.2688	.1989	.2056	.2683	.2372	.2721	.1886
4	.3041	.2035	.2187	.3052	.2881	.2812	.2614
5	.2932	.2328	.2753	.3391	.3391	.3125	.3734
6	.3241	.2629	.2812	.3814	.373	.2968	.3961
7	.3437	.2629	.3041		.3601	.3401	.4481
8	.3086	.2713	.3086	.4115	.39	.3241	.3772
9	.3429	.2155		.3315	.3978		.2987
10	.1867	.2172	.1867	.1494	.2374	.2263	.2561
11	.2033	.1753	.1494	.1494	.2629	.1867	
12	.2218	.181	.1494	.1646	.2481	.1886	
13	.168	.2103	.1494	.1646	.2103	.112	
14	.1478	.2012	.1848	.168	.1829	.1132	
15	.1494	.2103	.1478	.1867	.2561	.1132	
16	.1494	.1753	.1463	.1494	.2658	.1132	
17		.1753	.1463	.1867	.2481	.1509	
18	.2195	.1753	.1478	.2195	.2534	.2561	
19	.2614	.2103		.3174	.2172	.3547	.4108
20	.3206	.2149	.3734	.3734	.2454		.3921
21	.3018	.2454	.3395	.3174	.2454		.3734
22	.2641	.2353	.2829	.2614	.2534		.2614
23	.2263	.2103	.2641	.2075	.2279		.2801
24	2.3434	.1865	.1943	.2294	.2652	.3041	.2263
Max	2.3434	.2713	.3734	.4115	.3978	.3547	.4481
Min	.1478	.1619	.1463	.1494	.1829	.112	.1867
Avg	.3438	.2087	.2202	.2499	.2714	.2378	.3098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 204 / Darfal Water Supply

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.029	.0151	.0145	.0151	.0151	.029	.0151
2	.029	.0151	.0151	.0151	.0151	.029	.0151
3	.029	.0151	.0145	.0151	.0151	.029	.0301
4	.029	.0151	.0145	.0151	.0151	.029	.0301
5	.0301	.0151	.0145	.0151	.0151	.029	.0301
6	.0602	.1656	.2107	.1505	.1355	.1448	.2258
7	.1505	.2408	.2258		.2408	.2027	.2709
8	.2258	.3161	.2709	.3311	.3612	.3161	.301
9	.4214	.4365		.3763	.3913		.3763
10	.3311	.4365	.3612	.4214	.362	.3913	
11	.3462	.4214	.3763	.3763	.362	.3913	
12	.3612	.4515	.4064	.301	.4064	.3763	
13	.3763	.4365	.3763	.286	.362	.4214	
14	.0151	.029	.0301	.0151	.029	.0301	
15	.0151	.029	.0151	.0151		.0301	
16	.0151	.029	.0151	.0151	.029	.0301	
17	.0301	.0301		.0151	.029	.0301	
18	.0301	.0579	.0151	.0151	.029	.0301	
19	.0301	.0452		.0301	.029	.0301	.0301
20	.0301	.0434	.0301	.0452	.029		.0301
21	.0151	.029	.0301	.0301	.029		.0301
22	.0151	.029	.0301	.0151	.029		.0151
23	.0151	.0301	.0301	.0151	.029		.0151
24	.029	.0151	.0145	.0151	.0151	.029	.0151
Max	.4214	.4515	.4064	.4214	.4064	.4214	.3763
Min	.0151	.0151	.0145	.0151	.0151	.029	.0151
Avg	.1108	.1395	.1196	.1106	.1293	.1368	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 201 / 11 KV JAMGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0526	.0514	.0543	.0526	.1029	.3048
2	.0526	.0526	.0514	.0543	.0526	.1029	.3048
3	.0526	.0526	.0686	.0543	.0701	.0857	.3506
4	.0876	.0701	.1029	.0543	.0876	.0857	.381
5	.1227	.0876	.1372	.1086	.1052	.1372	.381
6	.1578	.0876	.0154	.181	.1578	.1715	.3963
7	.1753	.1402	.1715	.1448	.1578	.1543	.5784
8	.1402	.1578	.1543	.1629	.1402	.0686	.3048
9	.1052	.1227	.1372	.1052	.0876	.0905	.4382
10	.5639	.6859	.5668	.2896	.4877	.4858	.0701
11	.7164	.7621	.7773	.5182	.7011	.6859	.0701
12	.8688	.884	.664	.6097	.6859	.6859	
13	.8413	.8383	.6478	.7537	.7545	.7287	
14	.8238	.7926	.7287	.6401	.7888	.7621	
15	.8238	.7926	.7287	.7186	.6097	.7621	
16	.8063	.8573	.7287	.6249	.5792	.7621	
17	.7712	.6859	.7287	.5944	.5335	.6478	
18	.061	.12	.0724	.0701	.0686	.1267	
19	.1052	.1372	.1448	.1227	.1372	.1267	.1578
20	.0876	.12	.1448	.1052	.1543	.1267	.1227
21	.0701	.1029	.0905	.1052	.1715	.0905	.1227
22	.0701	.0857	.0543	.1052	.12	.0905	.1052
23	.0701	.0686	.0543	.0876	.1372	.0905	.0701
24	.0526	.0701	.0514	.0543	.0701	.1029	.1219
Max	.8688	.884	.7773	.7537	.7888	.7621	.5784
Min	.0526	.0526	.0154	.0543	.0526	.0686	.0701
Avg	.3200	.3261	.2947	.2633	.2880	.3031	.2518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 202 / 11 KV ANJANGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.884	.9145	.9145	1.1043	.9145	.1753
2	1.0974	.884	.884	1.0669	1.1393	.9755	.1753
3	1.2269	.8993	.9907	1.2193	1.0212	1.0669	.2629
4	1.4899	.9755	1.1736	1.2955	1.1126	1.0974	.2629
5	1.6301	1.0212	1.3717	1.4175	1.4899	1.1431	.4207
6	1.6004	1.1584	1.4632	1.4937	1.6126	1.4327	.4207
7	1.7528	1.8747	2.0748	1.829	1.9631	1.6613	.4207
8	1.829	1.7071		2.1862	2.191	1.7528	.2629
9	1.6004	1.7071	1.8595	2.2786	1.6301	1.2803	.3506
10	.1829	.1524	.2715	.2804		.1829	.9145
11	.1524	.1715	.181			.1629	1.8054
12	.1578	.1372	.1448			.1448	
13	.1219	.12	.1448	.1753	.1543	.1448	
14	.1402	.12	.1448	.1928	.1372	.1448	
15	.1578	.1029	.1448	.1753	.1372	.1629	
16	.2279	.12	.1448	.1753	.1372	.1448	
17	.2629	.1543	.1629	.1928	.1715	.1629	
18	.298	.1543	.181	.2279	.2058	.181	
19	.3155	.2058	.3258	.3506	.3086	.2715	.3681
20	.2629	.3086	.3258	.3155	.3772	.362	.4382
21	.2454	.3258	.3258	.3155	.3944	.2715	.4031
22	.2279	.2058	.2715	.2103	.2572	.2896	.3506
23	.298	.1543	.2715	.1753	.1715	.181	.2454
24	.1677	.8535	.9145	.9717	.9145	.7926	.1753
Max	1.829	1.8747	2.0748	2.2786	2.191	1.7528	1.8054
Min	.1219	.1029	.1448	.1753	.1372	.1448	.1753
Avg	.6874	.5999	.6386	.7936	.7919	.6219	.4384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 203 / 11 KV WADACHIWADI(AU)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0526	.0686	.0724	.0701	.0686	.3963
2	.0701	.0526	.0686	.0543	.0876	.0686	.4908
3	.0701	.0701	.0686	.0543	.0876	.0857	.4268
4	.0701	.0876	.0857	.0543	.1227	.0857	.503
5	.0876	.1052	.0857	.1267	.1578	.12	.5487
6	.0876	.1052	.12	.1448		.12	.5335
7	.1402				.1578		.6859
8	.0701				.1052		.381
9	.0701	.1052	.1029	.1227	.0701	.1086	.5335
10	.8413	.8535	.5668	.4557	.3353	.4049	.061
11	.8688	.9145	.8097	.5792	.823	.8097	.0701
12	1.0669	.9755	.8907	.8688	.884	.8907	
13	1.1919	1.0059	.9717	.8535		.9717	
14	1.1744	.381	.9717	.8383	.7926	.9717	
15	1.1568	.9907	.9717	.8078	.7621	.9878	
16	1.1568	.945	.9717	.7926	.8383	.9717	
17	1.1218	.9145	.8907	.7621	.7773	.8907	
18	.0876	.1029	.0905	.0701	.061	.1448	
19	.1402	.0857	.1267	.1227	.1372	.1448	.1578
20	.1227	.1029	.1448	.0876	.1372	.1267	.1402
21	.1052	.1029	.0724	.1052	.1886	.1086	.1052
22	.0876	.0857	.0724	.0876	.1029	.0905	.0876
23	.0701	.0686	.0724	.0701	.12	.0724	.0701
24	.0876	.0701	.0686	.0724	.0701	.0857	.1067
Max	1.1919	1.0059	.9717	.8688	.884	.9878	.6859
Min	.0701	.0526	.0686	.0543	.061	.0686	.061
Avg	.4181	.3717	.3769	.3274	.3131	.3786	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 201 / 11 KV UPLAI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8916	1.0117	.9945	.8916	.8916	.2058
2	1.3203	1.1317	1.2003	1.1488	1.0974	.9945	.2058
3	1.4575	1.166	1.4575	1.2003	1.2003		.2401
4	1.5604	1.5089	1.4918	1.3203	1.3717	1.3032	.2401
5	1.5604	1.6804	1.749	1.5775	1.7147	1.7661	.3086
6	2.1948	2.1262	2.2291	1.8861	2.0576	2.0062	.3944
7	1.3203	2.7949	2.692		2.5892	2.8464	.4801
8	1.8347		2.8464	2.6063	2.692	2.332	.3429
9	1.7833	1.5432	2.2291	2.5549	2.5034	2.2805	.2743
10	.1886	.1886	.2401	.2058	.2058	.1886	1.6975
11		.1715	.1543		.1543	.1543	2.4006
12	.1715	.1543	.1715		.1372	.1543	
13	.1886	.1715	.1543	.1715	.1372	.1715	
14	.1715	.1715	.1543	.1543	.1372	.1715	
15	.1715	.1715	.1543	.1715	.1715	.1715	
16	.1543	.1543	.1715	.1715	.1543	.1715	
17	.1886	.1543	.1543	.1715	.12	.1715	
18	.2058	.1715	.1715	.2058	.1886	.1715	.2229
19	.3258	.3086	.3258	.3429	.3258	.3429	.3772
20	.3258	.3429	.3258	.3429	.3429	.3429	.3429
21	.2915	.3086	.2915	.2915	.2915	.2743	.3086
22	.2229	.8402	.2058	.2229	.2743	.2229	.2743
23	.2058	.2058	.1715	.2058	.2229	.2229	.2229
24	.8059	.8402	.7716	.7202	.8059	.7373	.2058
Max	2.1948	2.7949	2.8464	2.6063	2.692	2.8464	2.4006
Min	.1543	.1543	.1543	.1543	.12	.1543	.2058
Avg	.7612	.7477	.8552	.7937	.8245	.7865	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 202 / 11 KV ROPALE NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2572	.2401	.2229	.2401	.8402
2	.2401	.2401	.2572	.2401	.2401	.2401	.8573
3	.2743	.2401	.2915	.3086	.2401	.2743	.9431
4	.3086	.2915	.3258	.3086	.2915	.2915	1.0117
5	.3429	.3601	.3944	.4458	.3429	.3601	1.1831
6	.4458	.4801	.463	.4458	.463	.4115	1.5089
7	.5144	.4973	.5144		.4973	.4973	1.9376
8	.3944	.4115	.463	.4115	.3944	.463	1.9033
9	.3772	.3944	.3429	.3429	.3429	.3772	1.7147
10	2.0405	1.4746	.8573	1.2517	1.0288	1.1317	.2743
11	2.4006	2.6749	1.8861		1.989	1.8861	.2058
12	2.0919	1.0631	1.1488		2.1605	2.0576	.2058
13		2.5377	2.1776	2.4006	2.0576	1.5432	.1886
14	1.7661	2.1948	2.2634	2.572	2.2977	2.0748	.1886
15	2.2634	2.2119	2.2291	2.3491	2.1776	2.0748	.1715
16	2.6063	1.8519	1.9033	2.5377	2.1776	2.1948	.2229
17	2.572	1.3032	2.2291	2.3663	2.0405	2.1776	.1715
18	.3086	.2401	.2401	.2401	.1715	.2229	.2229
19	.4115	.3944	.4115	.3772	.3601	.3772	.463
20	.4115	.4115	.4115	.4458	.3601	.4115	.4115
21	.3429	.3601	.3429	.3429	.1372	.3429	.3429
22	.3258	.3258	.2743	.2915	.1543	.3258	.2401
23	.2743	.2915	.2401	.2743	.2401	.2915	.2229
24	.2743	.2401	.2572	.2401	.2229	.2401	.6859
Max	2.6063	2.6749	2.2634	2.572	2.2977	2.1948	1.9376
Min	.2401	.2401	.2401	.2401	.1372	.2229	.1715
Avg	.9229	.8638	.8409	.8777	.8588	.8545	.6716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 203 / 11 KV GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.12	.1029	.1029	.12	.12
2	.1029	.1029	.12	.1029	.1029	.12	.12
3	.1029	.1029	.1372	.1029	.1029	.12	.1029
4	.1372	.1543	.1543	.1372	.1372	.12	.1029
5	.1715	.1715	.1886	.1372	.1543	.2058	.1715
6	.2229	.2058	.2229	.2058	.2229	.2229	.2229
7	.2229	.2229	.2229		.2229	.1886	.1715
8	.2058	.1886	.1715	.1886	.1886	.1886	.2058
9	.1715	.1886	.1715	.1372	.1543	.1543	.1715
10	.1715	.1715	.1715	.1886	.1029	.1886	.1715
11	.1715	.1543	.1543		.1715	.1543	.1715
12	.1715	.1715	.1372		.1715	.1543	.1715
13	.1543	.1715	.1543	.1543	.1543	.12	.1715
14	.12	.1543	.1029	.12	.1543	.12	.12
15	.12	.12	.1029	.1372	.1372	.12	.1372
16	.1029	.1029	.12	.1372	.12	.12	.1372
17	.1543	.1543	.1543	.1543	.1372	.1543	.1372
18	.1715		.1543	.1715	.1372	.1543	.1543
19	.1715	.1715	.1715	.2058	.1715	.2058	.1543
20	.1715	.1886	.1715	.2058	.1886	.2058	.1886
21	.1715	.1715	.1886	.1715	.1715	.1886	.1715
22	.1543	.1543	.1543	.1543	.1543	.1715	1.869
23	.1372	.1372	.1372	.12	.12	.1372	.1372
24	.12	.12	.12	.1372	.12	.12	.1372
Max	.2229	.2229	.2229	.2058	.2229	.2229	1.869
Min	.1029	.1029	.1029	.1029	.1029	.12	.1029
Avg	.1550	.1558	.1543	.1511	.1500	.1565	.2258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 201 / 11 KV SAPATANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.7716	.9259	.8993	.8059	.9602	.2058
2	.7621	.8745	1.0631	1.0212	.9774	1.0288	.1715
3	.8688		1.3889	1.2651	1.1831	1.1145	.1715
4	1.2193	.9431	1.3717	1.4937	1.3375	1.6632	.2058
5	1.4784	1.6461	1.5604	1.5546	1.406	1.749	.2572
6	1.6766	1.7661	1.8176	1.6613	2.1262	2.0576	.3429
7	1.829	1.6804	2.3491		2.4863	2.4006	.4287
8	1.7833	1.8347	2.4177	2.0119	2.452	2.4348	.3601
9	1.6766	1.7661	2.3148	1.9509	1.749	2.4348	.2915
10	.1524	.1981	.1543	.2572	.1524	.1829	
11	.1524	.1829	.12		.1219	.1715	1.89
12			.1372		.1219	.1715	.1715
13	.1372	.1219	.12	.1715	.1219	.1886	.1715
14	.1524	.1372	.1372	.1715	.1219	.2229	.1715
15		.1524	.1715	.1886	.6516	.1886	.1372
16	.1524	.1372	.1715	.1715	.1219	.7621	.1372
17	.1524	.1677		.1524	.1219	.2058	.1543
18	.1829	.1524	.1715	.1524	.1829	.2229	.1372
19	.2286	.1829	.2401	.2439	.2439	.3429	.1886
20	.2439	.2439	.3086	.2896	.2286	.3086	.1886
21	.2134	.1981	.2572	.1524	.2134	.2915	.2229
22	.1829	.1829	.2229	.1372	.1829	.2743	.2058
23	.1524	.1524	.1886	.1372	.1524	.2572	.1886
24	.5639	.6173	.703	.7621	.7716	.8402	.2401
Max	1.829	1.8347	2.4177	2.0119	2.4863	2.4348	1.89
Min	.1372	.1219	.12	.1372	.1219	.1715	.1372
Avg	.6672	.6414	.7962	.7069	.7514	.8531	.2887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 202 / CHINCHOLI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0914	.0914	.1372	.1067	.0914	.6401
2	.1372	.1219	.0762	.1372	.0914	.0914	.6859
3	.12	.1372	.1372	.1372	.0914	.0914	.7011
4	.1543	.1829	.1829	.1543	.1372	.1067	.7621
5	.2058	.2134	.2134	.1543	.2134	.1219	1.0974
6	.2915	.2439	.2439	.1543	.2591	.2134	1.3717
7	.3429	.3048	.3048		.2896	.2743	1.768
8	.2915	.2743	.3048	.4287	.2743	.2896	1.5242
9	.2058	.2439	.2134	.3429	.2134	.2134	1.0974
10	1.4746	1.3032	.9145	.4268	.9602	1.2193	.1543
11	2.0576	2.0233	1.3717		1.4918	1.7528	.2401
12	2.2119	2.1605	1.5851			1.7528	
13	1.9719	2.2634	1.5851	1.5394	1.6118	1.5699	
14	2.1776	2.0233	1.5242	1.6918	1.6975	1.387	
15		1.9376	1.5546	1.6766	1.6804	1.6004	
16	2.0062	1.9719	1.5699	1.7223	1.4575	1.768	
17	2.1091	2.0919	1.6004	1.749	1.5089	1.7071	
18	.1829	.1219	.1543	.1372		.1372	.2401
19	.2134	.1677	.2229	.2134	.2134	.3086	.2743
20		.2591	.2743	.2591	.1829	.2915	.2572
21	.1829	.1829	.1715	.1372	.1829	.2743	.2572
22	.1524	.1524	.1715	.1067		.2229	.2229
23	.1219	.1372		.1067	.1219	.1715	.1886
24	.1543	.1219	.1067	.1715	.1372	.1067	.4572
Max	2.2119	2.2634	1.6004	1.749	1.6975	1.768	1.768
Min	.12	.0914	.0762	.1067	.0914	.0914	.1543
Avg	.7683	.7805	.6337	.5516	.6154	.6568	.6633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 203 / 11 KV SHINDEWADI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 201 / 11 KV NIMGAON NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.12	.0857	.0686	.0857	.0857	.3658
2	.1029	.12	.0857	.0686	.0857	.0857	.3658
3	.1029	.12	.0857	.0857	.0857	.0857	.4115
4	.1029	.12	.1029	.0857	.0857	.12	.4115
5	.12	.1372	.1029	.1029	.1029	.12	.503
6	.1372	.1543	.1029	.12	.1029	.12	.5487
7	.12	.1715	.1029	.1029	.1029	.12	.5944
8	.1029	.1029	.1029	.1029	.0686	.1029	.5182
9	.0857	.1029	.0857	.0857	.0686	.1029	.4572
10	.0857	.0857	.0857	.0857	.0857	.6097	.4268
11	.8993	.7164	.7164	.6097	.6097	.7468	.1029
12	.9145	.7621	.6859	.6859	.6859	.7316	.0857
13	.945	.7621	.8383	.7621	.7621	.8383	.0857
14	.945	.8383	.6401	.7621	.7621	.7773	.0857
15	.8383	.8383	.7468	.7773	.7621	.7316	.0686
16	.7011	.7621	.9755	.7773	.7773	.6706	.0686
17	.7621	.7621	.8688	.7926	.6859	.7316	.0686
18	.8535	.7621	.7926	.7926	.6859	.0686	.0686
19	.1029	.1372	.12	.0686	.12	.12	.0686
20	.1029	.1372	.12	.0686	.12	.1029	.0686
21	.1029	.0857	.1029	.0686	.12	.0857	.0686
22	.12	.0857	.1029	.0686	.0857	.0686	.0686
23	.12	.0857	.1029	.0686	.0857	.0686	.0686
24	.0857	.12	.0857	.0686	.0686	.0857	.442
Max	.945	.8383	.9755	.7926	.7773	.8383	.5944
Min	.0857	.0857	.0857	.0686	.0686	.0686	.0686
Avg	.3558	.3371	.3267	.3033	.3002	.3075	.2509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 202 / 11 KV SULTANPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4725	.4572	.3506	.381	.4572	.0857
2	.5487	.503	.4572	.3353	.4572	.4572	.0857
3	.5639	.5182	.4572	.381	.4877	.4572	.12
4	.5639	.5487	.5335	.3963	.503	.503	.1372
5	.5792	.5487	.5335	.4268	.503	.503	.1372
6	.5792	.5639	.5335	.4572	.5182	.503	.1543
7	.6706	.5639	.5335	.4877	.5182	.503	.1715
8	.7011	.5335	.5639	.5182	.4877	.442	.1372
9	.6097	.5335	.5792	.4877	.4877	.4725	.1029
10	.1029	.0686	.1029	.1029	.0686	.12	.3658
11	.1029	.12	.1029	.1029	.12	.1029	
12	.1029	.1543	.12	.1029	.12	.0857	
13	.12	.1543	.1372	.12	.12	.0857	
14	.12	.1543	.0686	.12	.12	.1029	
15	.1372	.1543	.0857	.12	.12	.1029	
16	.1372	.12	.1029	.12	.1029	.1029	
17	.1372	.12	.1029	.1372	.0857	.1029	
18	.1372	.12	.12	.1372	.0857	.12	.0857
19	.1372	.12	.1543	.1029	.12	.1543	.0857
20	.12	.12	.1372	.0857	.12	.1543	.0857
21	.1029	.12	.1372	.0857	.12	.1372	.0857
22	.1029	.12	.1029	.0857	.12	.12	.0857
23	.1029	.12	.0857	.0857	.12	.1029	.1029
24	2.4291	.4572	.4572	.381	.3429	.4572	.1029
Max	2.4291	.5639	.5792	.5182	.5182	.503	.3658
Min	.1029	.0686	.0686	.0857	.0686	.0857	.0857
Avg	.3934	.2920	.2778	.2388	.2596	.2646	.1254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 203 / 11 KV JANAI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 201 / WADOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 202 / TAKALI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 204 / NAGORLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 205 / BHIMANAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 206 / Alegaon 10 km

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 207 / Ranjani 6 km
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 208 / Adhegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	.6097
24	.1524
Max	.6097
Min	.1524
Avg	.3811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 209 / OSMANABAD WW
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 202 / Bemble AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 203 / Ghoti AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 204 / BHOSALE WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 205 / Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 206 / ChavanWadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 201 / WIRELESS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2652		.2134	.1829	.2321	.1829
2	.2134	.2652		.8078	.2134	.2321	.1829
3	.2439	.2652		.1981	.2134	.2321	.2134
4	.2743	.2652		.2286	.2439	.2321	
5	.3048	.2984		.3048	.2743	.2321	.2439
6	.3201	.3315		.3658	.3658	.2652	.2743
7	.3353	.3315		.3353	.3048	.2652	.3048
8	1.89	.3315		1.8442	1.829	.2652	.3048
9	2.7435	2.5149	2.4996	2.3205	2.2253	2.4996	.2984
10	3.0636	2.6825	2.5606	2.652	2.3167	2.5606	.2652
11	2.9264	2.5911	2.6216	2.4863	2.3015	2.6216	
12	2.9264	2.6216	2.4387	2.1879	2.4691	2.4996	
13	3.0483	2.6063	2.4234	2.1879	2.3777		
14		2.6368	2.4082	2.2377	2.1338		
15	2.3472	2.6216	2.4082	2.3205	2.1948	2.3167	
16	.1829	.1829	.1524	.1326	.1658		
17	.1989		.1829	.1219	.1658	.1829	2.8045
18	.1989		.1829	.2439	.2321	.1829	2.8654
19	.2321		.3048	.2439	.2652	.3048	2.7435
20	.2652		.2896	.2743		.2439	2.5301
21	.2652		.2439	.2439	.2652	.1829	2.3777
22	.2652		.2439	.2134	.2652	.1829	2.2862
23	.2652		.2286	.1829	.2652	.1829	2.1643
24	1.2194	.2652		.2134	.1829	.2652	.1829
Max	3.0636	2.6825	2.6216	2.652	2.4691	2.6216	2.8654
Min	.1829	.1829	.1524	.1219	.1658	.1829	.1829
Avg	1.0410	1.2398	1.2793	.9400	.9328	.7706	1.1897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 202 / PIMPALNER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3315		.2439	.2439	.3315	.2134
2	.3048	.3315		.2286	.2439	.3315	.2134
3	.3353	.3315		.2286	.2743	.3315	.2134
4	.3353	.3315		.3048	.2743	.3315	.2439
5	.3506	.3315		.3658	.3048	.3647	.2439
6	.3963	.3647		.4115	.3658	.3978	.2743
7	.3658	.3978		.3963	.3658	.3978	.3048
8	.3658	.3978		.3963	.3658	.3978	.3048
9	.3048	.2743	.3048	.3647	.2743	.2439	.3315
10	.2439	.2439	.2743	.3315	.2439	.2134	.3315
11		.1677	.1829	.2652	.2439	.1677	
12		.1829	.1524	.1989	.1524	.1524	
13		.1981	.1524	.1989	.1524		
14		.2134	.1677	.1989	.1524		
15	.2439	.1981	.1524	.1989	.1677	.1524	
16	1.829	1.7071	1.89	1.8564	.431		
17	2.9835		2.5301	2.7435	2.3205	2.5606	.1829
18	3.1824		2.652	2.5484	2.4863	2.4996	.2134
19	3.0664		2.4844	2.3472	2.652	2.3167	.3353
20	2.5857		2.332	2.1338	2.4863	2.1948	.3658
21	2.4863		2.21	2.1948	2.3205	2.0119	.3048
22	2.3205		2.1338	1.8595	2.3205	1.829	.2896
23	2.1548		1.8442	1.829	2.1548	1.7375	.2743
24	1.7071	1.989		.2439	.2439	2.0553	.2134
Max	3.1824	1.989	2.652	2.7435	2.652	2.5606	.3658
Min	.2439	.1677	.1524	.1989	.1524	.1524	.1829
Avg	1.2918	.4701	1.2976	.9204	.8851	1.0009	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 203 / NIMGAON (T)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.6575		1.326	1.5242	.1658	1.829
2	1.5242	1.6575		1.3565	1.5851	.1658	1.89
3	1.5851	1.8233		1.4022	1.8519	.1658	1.89
4	1.6461	1.989		1.5089	1.7071	.1658	1.89
5	1.6766	2.1548		1.6766	1.768	.1658	1.9204
6	2.0729	2.3205		1.9204	1.9509	.1658	1.9509
7	2.1948	2.4531		2.1643	2.1948	.1658	1.9509
8	.2439	2.4531		.2439	.1829	2.3205	2.1338
9	.3048	.1829	.1829	.2321	.1677	.1829	2.1548
10	.1219	.1524	.1524	.1326	.1372	.1524	1.989
11	.1219	.1067	.1219	.1326	.1219	.1219	
12	.1219	.1067	.1219	.1326	.1067	.1067	
13	.1219	.1067	.1219	.1326	.1067		
14	.1219	.1219	.1219	.1326	.1067		
15	.1219	.1067	.0914	.1326	.1067	.1067	
16	.1219	.1067	.1219	.1326	.1326		
17	.1658		.1219	.1219	.1326		.1524
18	.1989		.1372	.1524	.1989		.1524
19	.2321		.2134	.1829	.1989		
20	.2652		.1981	.1829	.1989		.2439
21	.2652		.1981	.1829	.1989		.1829
22	.2321		.1829	.1829	.1989		.1677
23	.1989		.1677	.1829	.1989		.1524
24	.6097	.1989		1.2955	1.3108	.1989	1.89
Max	2.1948	2.4531	.2134	2.1643	2.1948	2.3205	2.1548
Min	.1219	.1067	.0914	.1219	.1067	.1067	.1524
Avg	.6555	1.0411	.1504	.6351	.6828	.3108	1.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 204 / PIMPALNER GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3944		.463	.4458	.4458	.3772
2	.4801	.3944		.4458	.4115	.4458	
3	.5487	.3772		.4287	.4458	.463	.4458
4	.583	.4287		.4973	.4801	.5487	.4801
5	.6173	.463		.6001	.583	.6001	.5487
6	.6516	.5144		.703	.703	.6344	.5182
7	.6859	.5658		.6344	.6516	.6344	.6516
8	.6173	.5658		.6173	.5487	.6001	
9	.6001	.583	.5487	.5487	.5487	.5658	1.1145
10	.5316	.583	.4801	.463	.5144	.5144	.4973
11		.4973	.463	.4458	.4801	.4458	
12		.463	.4287	.4115	.4458	.4115	
13		.4287	.4287	.3772	.3944		
14	.5144	.4115	.4287	.3772	.3601		
15	.1372	.4458	.3772	.3429	.3429	.3429	
16	.463	.3944	.4115	.3601	.3944		
17	.463		.3944	.4287	.3944		.5316
18	.5144		.4458	.4458	.5144		.583
19	.5658		.583	.5658	.6344		.703
20	.6173		.6173	.6173	.6173		.6687
21	.5658		.5658	.5658	.583		.5658
22	.5487		.4973	.5144	.5487		.5144
23	.5144		.4801	.4801	.5144		.4458
24	.2286	.463		.4801	.463	.4801	.4115
Max	.6859	.583	.6173	.703	.703	.6344	1.1145
Min	.1372	.3772	.3772	.3429	.3429	.3429	.3772
Avg	.5188	.4690	.4767	.4923	.5008	.5095	.5661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 205 / Dahiwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.8861		1.7833	1.9033	1.7147	1.6918
2	1.8861	1.8861		1.8176	1.768	1.7147	1.989
3	1.9547	2.0576		1.869	2.0576		1.7985
4	1.989	2.2291		1.9204	1.8595	1.9719	1.829
5	2.0576	2.3148		1.9547	2.1262	2.0576	1.829
6	2.2634	2.4006		2.1262	2.0748	2.2291	2.0119
7	2.4863	2.4863		2.3834	2.5034	2.4006	2.0729
8	.1029	2.5377		.1029	.0514	2.4006	2.0576
9	.1029	.0514	.1029	.0829	.0305	.1029	2.3148
10	.0343	.0514	.1029	.0514	.0343	.0857	2.2377
11	.0343	.0514	.0857	.0514	.0305	.0686	
12	.0343	.0343	.0686	.0514	.0343	.0686	
13	.0305	.0343	.1029	.0343	.0343		
14	.0343	.0343	.1029	.0343	.0343		
15	.0343	.0343	.0686	.0343	.0343	.0686	
16	.0343	.0343	.1029	.0343	.0343		
17	.0343		.0343	.0343	.0343		.0686
18	.0343		.0343	.0343	.0514		.1029
19	.0514		.1372	.0343	.0514		.12
20	.0686		.1372	.0343	.0686		.1543
21	.0686		.1372	.0343	.0686		.1543
22	.0686		.1029	.0686	.0514		.1543
23	.0514		.0514	.0686	.0514		.1372
24	.6097	.0514		1.7661	1.7318	.0514	1.6613
Max	2.4863	2.5377	.1372	2.3834	2.5034	2.4006	2.3148
Min	.0305	.0343	.0343	.0343	.0305	.0514	.0686
Avg	.6633	1.0691	.0915	.6836	.6967	1.1488	1.2436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 206 / TAMBAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086		.2572	.3086	.2572	.2743
2	.3772	.3086		.2572	.3086	.2572	.2743
3	.3944	.3086		.2743	.3086	.2572	.2743
4	.4115	.3086		.2915	.3086	.2572	.3048
5	.4287	.3429		.3086	.2743	.2743	.3048
6	.3772	.3772		.3429	.3086	.3086	.3048
7	.3944	.3772		.3429	.3086	.3086	.3048
8	1.5242	.3944		2.0576	.2743	.2915	.3048
9	2.4348	3.2579	2.8635	.5144	2.5377	2.6578	.1715
10	2.4691	3.0521	2.7949	2.4006	1.8519	2.7092	.1715
11	2.5377	2.915	2.9492	2.3148	2.7435	2.7435	
12	2.8121	2.8978	2.8121	2.3148	2.4863	2.692	
13	2.8121	2.7949	2.7092	2.2291	2.4691		
14	2.7092	2.7435	2.7263	2.0576	2.4006		
15	2.4348	2.7435	2.2462	1.8861	2.2291	2.7092	
16	2.4691	1.2003	1.9719	1.7147	1.6289		
17	2.3148		2.3663	2.3663	1.8861		2.6578
18	2.2291		2.4863	2.4348			2.8292
19	2.1195		2.4863	2.4691	2.4863		2.692
20	2.0576		2.4006	2.5377	2.4863		2.5377
21	2.0576		2.2291	2.5034	2.4006		2.3834
22	1.8861		2.1434	2.3148	2.4006		2.332
23	1.8004		2.0576	1.9033	2.2291		2.3148
24	.6097	1.7147		.2572	.3086	2.1434	.2743
Max	2.8121	3.2579	2.9492	2.5377	2.7435	2.7435	2.8292
Min	.3429	.3086	1.9719	.2572	.2743	.2572	.1715
Avg	1.6668	1.5321	2.4829	1.5146	1.5193	1.2762	1.1506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 201 / AKOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 202 / MALEGAO AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 204 / UJANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 205 / SHEWARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 206 / Footjawalgaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 207 / GOATHAN TEMBHURNI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 208 / AKOLE BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6401
Max	.6401
Min	.6401
Avg	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 209 / SURLI BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 210 / SHEVARE PANIPURAWATHA
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 202 / BHEND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3856	.3944	.3932	.407	.4382
2	.373	.3856	.4115	.4096	.39	.4207
3	.4578	.3641	.4973	.3932	.4409	.4207
4	.4748	.4382	.5228	.4752	.5087	.5138
5	.5426	.4973	.583	.6062	.6104	.6135
6	.6274	.6135	.6001	.6554	.7122	.7343
7	2.8292	2.5549	2.332	2.4813	2.7435	
8	2.9321	2.3838		1.8442	2.9492	
9	1.8519	2.6993	2.5034	2.7328	2.7949	
10		2.4272	2.4006	2.6825	2.915	
11	2.332	2.524		2.5316	2.7606	
12	2.8978	2.4364		2.431	2.7263	
13	2.8121	2.4714	2.8635	2.5149	2.692	
14	2.4863	2.2885	2.9127	2.5652	2.6749	
19	.6783	.5316	.5935	.6718	.6274	2.8833
20	.6104	.5316	.5487	.6226	.6783	.5014
21	.5426	.5028	.5144	.5243	.5765	.5373
22	6.189	.5201	.4801	.4588	.5426	.5415
23	.407	.4382	.4409	.426	.5087	.5487
24	.6097	.39	.4287	.4287	.4239	.4801
Max	6.189	2.6993	2.9127	2.7328	2.9492	2.8833
Min	.3391	.3641	.3944	.3932	.39	.4207
Avg	1.5786	1.2692	1.1193	1.2924	1.4342	.7195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 203 / Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772		.3185	.3772	.3086
2	.3086	.3429		.3018		.3155
3	.3429	.3086			.3429	.2947
4	.4287	.3988			.3429	.3506
5	.4973	.4733			.3601	.4382
6	.5658	.5784			.3944	.4961
7	.5144	.5784		.3018	.4115	.4854
8	.4973	.5201		.1341	.5144	.4161
9	.5144	.5144	.4115	.2012	.4801	.3772
10	.5144	.463	.3429	.2515	.4458	.2915
11	.5487	.3641		.3018	.5316	
12	.5144	.3856			.3772	
13	.4801	.3155	.3258	.2683	.3258	
14	.4115	.298	.3429	.285	.2743	
15		.333	.4287	.2515	.2572	
16	.4115	.3012	.3772	.2347	.2401	
17	.4458	.2401	.3429	.285	.2229	
18	.4801	.3641	.3086	.3521	.3601	
19	.5487	.5434	.5144	.4024	.5144	.5316
20	.6173		.4973	.4024	.5144	.4733
21	.5144	.4557	.4801	.4024	.4801	.4961
22	.4801	.4607	.5087	.4191	.4801	.4458
23	.4115	.4031	.3772	.4024	.3601	.3681
24	.3772	.4458	.2572	.3429	.3944	.3561
Max	.6173	.5784	.5144	.4191	.5316	.5316
Min	.3086	.2401	.2572	.1341	.2229	.2915
Avg	.4682	.4115	.3940	.3084	.3914	.4028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 204 / AKOLE BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.2629	.2743	.213	.2204	.2915
2	.2713	.2658	.2572	.2294	.2035	.298
3	.2883	.2865	.2743	.2458	.2543	.2658
4	.3222	.3189	.3086	.3277	.3052	.2804
5	.3391	.4298	.4115	.3932	.3561	.3155
6	.3561	.4298	.3944	.3605	.373	.394
15		2.1971	2.1434	2.0119	2.0576	
16	.8745	2.3998	2.1262		2.1434	
17	.8402	2.4893	2.1434	1.9784	2.1605	
18	2.3663	2.3998	2.3525	2.079	2.0062	
19	2.2634	2.073	1.9719	1.9616	1.9376	.2865
20	2.1605	1.9845	1.6289	1.7436	1.7318	.2804
21	1.9719	1.7909	1.5432	1.643	1.7147	.2481
22	1.7318	1.647	1.5775	1.576	1.6118	.2454
23	.2883	.2915	.2743	.2294	.2883	1.7551
24	.6097	.4409	.2987	.2572	.2204	.2915
Max	2.3663	2.4893	2.3525	2.079	2.1605	1.7551
Min	.2713	.2629	.2572	.213	.2035	.2454
Avg	.9981	1.2317	1.1238	1.0166	1.0991	.4127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 205 / Palwan ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	2.8045	2.8464	2.649	2.5206	3.0674
2	1.8861	2.6993	2.8807	2.5987	2.4863	3.0148
3	2.0576	2.7168	2.9321	2.6658	2.8121	2.9797
4	2.5549	2.9767	3.0864	2.6155	2.8807	3.2236
5	2.7778	3.4675	3.2407	2.5149	3.4294	
6	3.2236	3.0298	3.2579	2.8502	2.6235	3.2057
7						3.3951
8						2.4006
9						2.4714
10						2.3663
11						1.7857
15		2.2436	2.4006	2.9172	2.8978	
16	2.7435	2.6755	2.3834	2.7496	3.1036	
17	2.572	2.6818	2.8807	2.649	2.8807	
18	2.3663	2.692	3.0693	2.5484	2.7263	
19	2.2634	2.6116	2.7435	2.5819	3.1036	1.0402
20	2.2291	2.3312	2.6235	2.4478	2.8978	1.0802
21	2.1948	2.1384	2.4348	2.2801	2.2805	.9465
22	2.1605	2.0858	2.2977	2.1125	2.0919	.8059
23	1.869	3.4355	3.2407	2.6825	3.1893	2.0332
24	.6097	2.8292	2.9835	2.713	2.572	3.0864
Max	3.2236	3.4675	3.2579	2.9172	3.4294	3.3951
Min	.6097	2.0858	2.2977	2.1125	2.0919	.8059
Avg	2.2229	2.7137	2.8314	2.5985	2.7810	2.3064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 201 / Gaonthan

Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 202 / Alegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 203 / Garakole

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 204 / TAKALI BANDHARA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 205 / CHANDAJ

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 206 / 11 KV RUI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 201 / ARAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 202 / JADHAVWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.2194
Max	1.2194
Min	1.2194
Avg	1.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 203 / TULSHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 201 / AKOLE(KH) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					2.1253	2.1807	1.9839
16	2.9014	2.7905	2.2253	2.8275	.1663		
24	.6097	.5914	.499	.3353	.1848	1.9035	1.749
Max	2.9014	2.7905	2.2253	2.8275	2.1253	2.1807	1.9839
Min	.6097	.5914	.499	.3353	.1663	1.9035	1.749
Avg	1.7556	1.6910	1.3622	1.5814	.8255	2.0421	1.8665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 202 / SHIRAL (T) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6766	1.6766	1.6613	1.5699	
16					1.9814
24	.6097	1.4784	1.4784	1.2955	
Max	1.6766	1.6766	1.6613	1.5699	1.9814
Min	.6097	1.4784	1.4784	1.2955	1.9814
Avg	1.1432	1.5775	1.5699	1.4327	1.9814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 203 / SURLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					1.5851	1.7375	1.9204
16	2.2253	2.0881	1.9966	1.8442	.0914		
24	.6097		.2439	.1829	.1372	1.4175	1.4575
Max	2.2253	2.0881	1.9966	1.8442	1.5851	1.7375	1.9204
Min	.6097	2.0881	.2439	.1829	.0914	1.4175	1.4575
Avg	1.4175	2.0881	1.1203	1.0136	.6046	1.5775	1.6890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 204 / SHIRAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3201	.3547	.3547	.3201	.3547	.3547	.373
16	.2427	.168	.1219	.1307			
24	.6097	.2241	.2427	.1829	.2054	.2054	.2103
Max	.6097	.3547	.3547	.3201	.3547	.3547	.373
Min	.2427	.168	.1219	.1307	.2054	.2054	.2103
Avg	.3908	.2489	.2398	.2112	.2801	.2801	.2917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 201 / KALWEL WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1981	.1524	.1739	.1677	.1715	.787
2	.1715	.1981	.1677	.1898	.1829	.0343	.787
3	.1715	.2134		.1898	.1829	.1886	.787
4	.1886	.2286	.1829	.2056	.1981	.2058	.8333
5	.2229	.2439	.2134	.2372	.2286	.2401	.9259
6	.2572	.2743	.2286	.2688	.2439	.2743	1.0031
7							1.4937
8							1.5242
9							1.4327
10	.9907	.945	1.2176	.9907	1.2003	.9877	
11	1.5394	1.4632	1.5655	1.2955	1.6289	1.4198	
12	1.6004	1.448	1.5813	1.326	1.7147	1.4352	
13	1.6309	1.4327	1.5813	1.326	1.7147	1.3889	
14	1.5699	1.4327	1.5181	1.3108	1.6289	1.3889	
15	1.5394	1.3413	1.5023	1.326	1.6289	1.3426	
16	1.5242	1.3108	1.3757	1.326	1.5432	1.358	
17	1.4937	1.1279	1.4706	1.3413	1.5432	1.1728	
19	.1829	.1524	.1581	.1677	.1715	.1543	.1372
20	.2134	.1524	.1581	.1677	.1886	.1543	.1524
21	.1981	.1524	.1581	.1677	.1886	.1389	.1524
22	.1981	.1372	.1581	.1677	.1715	.1389	.1524
23	.1981	.1524	.1581	.1677	.1715	.1389	.1524
24	.6097	.1981	.1524	.1739	.1677	.1715	.7407
Max	1.6309	1.4632	1.5813	1.3413	1.7147	1.4352	1.5242
Min	.1715	.1372	.1524	.1677	.1677	.0343	.1372
Avg	.7336	.6401	.7211	.6260	.7433	.6253	.7374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 202 / KADAM WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0305	.0309	.0305	.0305	.0343	.2439
2	.0343	.0305	.0309	.0305	.0305	.0343	.2439
3	.0343	.0305	.0309	.0305	.0305	.0343	.2743
4	.0343	.0305	.0309	.0305	.0305	.0343	.2743
5	.0514	.0457	.0309	.0457	.0457	.0514	.3048
6	.0514	.0457	.0309	.0457	.0457	.0514	.3201
7							.3963
8							.4268
9							.442
10	.4268	.3704	.3506	.3048	.3429	.3353	
11	.503	.4784	.4115	.381	.4287	.4268	
12	.5487	.4938	.4115	.381	.5144	.442	
13	.5487	.4475	.4115	.3963	.5144	.442	
14	.5335	.463	.3963	.3963	.5144	.4572	
15	.5335	.4475	.4268	.3963	.4801	.442	
16	.5335	.4475	.4572	.3963	.4801	.4268	
17	.4877	.4321	.4877	.4115	.5144	.381	
19	.0305	.0309	.0305	.0305	.0343	.0305	.0305
20	.0305	.0309	.0305	.0305	.0343	.0309	.0305
21	.0305	.0309	.0305	.0305	.0343	.0305	.0305
22	.0305	.0309	.0305	.0305	.0343	.0305	.0305
23	.0305	.0309	.0305	.0305	.0343	.0305	.0305
24	.6097	.0305	.0309	.0305	.0305	.0343	.2439
Max	.6097	.4938	.4877	.4115	.5144	.4572	.442
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.2559	.1989	.1861	.1730	.2102	.1890	.2215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 203 / PARITE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.1145	1.166	1.046	1.0212	1.0669	.2743
2	1.1145	1.1317	1.2346	1.2517	1.1126	1.0669	.2896
3	1.2003	1.286	1.2689	1.4746	1.3108	1.1431	.3048
4	1.3032	1.4403	1.7147	1.5604	1.387	1.2955	.3506
5	1.5432	1.5947			1.4327	1.5242	.3963
6	1.6289	1.8519	1.8861	1.6804	1.5089	1.6766	.4268
7	1.9719	2.0576	2.4006	2.0405	1.9509	2.0576	
8	2.1434	2.1091	2.3663	2.2634	1.9814	2.1338	
9	2.3148	1.9719	2.1262	1.989	1.89	2.1338	
10							1.4784
19	.3258	.3258	.2572	.3258	.2896	.2743	.3201
20	.3429	.3429	.2915	.3429	.3048	.2896	.3353
21	.3086	.3258	.2915	.3086	.3048	.2896	.3048
22	.3086	.3086	.2915	.2915	.3048	.2896	.3048
23	.3086	.3086	.3086	.2915	.3048	.2743	.3048
24	.6097	1.0974	1.166	.9602	.8688	.9145	.2743
Max	2.3148	2.1091	2.4006	2.2634	1.9814	2.1338	1.4784
Min	.3086	.3086	.2572	.2915	.2896	.2743	.2743
Avg	1.1026	1.1511	1.1978	1.1305	1.0649	1.0954	.4127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 201 / UPALWATE BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.061	.0686	.0358	.0162	.0152	.0358
2	.0648	.061	.0686	.0358	.0162	.0152	.0358
3	.0162	.061	.0686	.0358	.0324	.0152	.0358
4	.0162	.061	.0857	.0358	.0162	.0152	.0358
5	.0162	.061	.0857	.0358	.0162	.0152	.0358
6	.0162	.0762	.1029	.0358	.0162	.0305	.0358
7	.0324	.0762	.1029	.0358	.0162	.0305	.0358
8	.0648	.0762	.0857	.0358	.0162	1.3717	.0358
9	.9717		.5761	.421	.4534	.5121	.0343
10	1.5546	.6401	.4161	.3887	.3353	.4161	.0343
11	1.5242	.4572	.4481	.3772	.3048	.3841	
12	1.1279	.4115	.3521	.2915	.3048	.4001	
13	.7621	.2134	.3201	.3239	.2743	.3521	
14	.4572	.2439	.3041	.2591	.2743	.3521	
15	.4268	.2743	.3041	.1943	.3048	.3201	
16	.3658	.3048	.3201	.1943	.3048	.3201	
17	.061	.0686	.0358	.0324	.0152	.032	
18	.061	.0686	.0347	.0324	.0152	.0358	
19	.0762	.0857	.0358	.0324	.0305		.6401
20	.0762	.0857	.0358	.0162	.0305	.0358	.3963
21	.0762	.0857	.0358	.0162	.0305	.0358	.3506
22	.0762	.0857	.0362	.0162	.0305	.0358	.2134
23	.0762	.0686	.0358	.0162	.0305	.0358	.2134
24	.6097	.0762	.0686	.0358	.0162	.0305	.0358
Max	1.5546	.6401	.5761	.421	.4534	1.3717	.6401
Min	.0162	.061	.0347	.0162	.0152	.0152	.0343
Avg	.3561	.1610	.1678	.1223	.1209	.209	.1378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 202 / DAHIWALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1677	.1715	.2328	.2401	.1981	1.6644
2	.1029	.1677	.1715	.2328	.2058	.1981	1.6644
3	.1715	.1677	.1715	.2328	.1715	.1981	1.5684
4	.2401	.1677	.1886	.2507	.2401	.1981	1.5684
5	.1372	.1677	.1886	.2507	.2058	.1981	1.6644
6	.2058	.1829	.2058	.2507	.2058	.2134	2.0416
7	.1029	.1524	.1886	.2507	.1715	.2134	2.2725
8	.1029		.1715	.2149	.2058	.1981	2.3746
9	.0686	.1372	.1612	.1715	.1715	.1791	.1372
10	.0457	.1029	.1254	.1372	.0914	.1612	.1029
11	.0457	.0857	.1075	.0343	.0762	.1075	
12	.0457	.0686	.1075	.1372	.0914	.1075	
13	.0457	.0686	.1075	.0686	.0914	.1075	
14	.0457	.0686	.0895	.1372	.0914	.1075	
15	.0457	.0686	.0895	.1029	.0762	.1075	
16		.0686	.1075	.0343	.0762	.1075	
17	2.7435	2.5301	2.7846	2.9492	2.652	2.6246	
18	2.7435	2.8959	2.8807	3.3265	2.774	2.9287	
19	2.5606	2.6368	2.6246	3.0178	2.5606	2.8807	.1715
20	2.2558	2.4234	2.3365	2.8978	2.5301	2.4806	.2058
21	2.2862	2.2862	2.4006	2.7778	2.4387	2.2405	.2058
22	2.1338	2.0881	2.3205	2.4006	2.2862	1.9524	.2058
23	2.0576	1.9814	2.2085	2.3663	2.1643	1.8244	.2058
24	.4801	1.9814	1.829	2.2085	2.332	2.1033	1.7604
Max	2.7435	2.8959	2.8807	3.3265	2.774	2.9287	2.3746
Min	.0457	.0686	.0895	.0343	.0762	.1075	.1029
Avg	.8161	.8985	.9058	1.0285	.9229	.9015	1.1134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 203 / DAHIWALI BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.4022	1.3717	1.5043	1.6461	1.2498	.0716
2	1.9547	1.3717	1.3108	1.4403	1.6118	1.0974	.0716
3	1.8519	1.3717	1.2193	1.3443	1.5432	.9907	.0716
4	1.7147	1.3413	1.1431	1.3443	1.4746	.884	.0895
5	1.6461	1.3108	1.1584	1.2483	1.3717	.945	.0895
6	1.5432	1.3108	1.1888	1.2643	1.4746	1.0669	.1075
7	1.5775	1.3717	1.4784	1.3763	1.4403	1.2193	.0895
8	1.6461	1.3717	1.4327	1.3763	1.4746	1.3717	.0716
9	.0343	.0686	.0716	.0686	.0686	.0537	1.2193
10	.0305	.0514	.0537	.0686	.0457	.0358	1.2651
11	.0305	.0514	.0358	.0343	.0457	.0358	
12	.0457	.0343	.0358	.0686	.0457	.0358	
13	.0457	.0343	.0537	.0343	.0305	.0358	
14	.0305	.0343	.0537	.0343	.0305	.0358	
15	.0305	.0343	.0358	.0686	.0305	.0358	
16	.0305	.0343	.0358	.0343	.0305	.0358	
17		.0343	.0358	.0686	.0305	.0358	
18	.0305	.0343	.0358	.0343	.0305	.0537	
19	.0457	.0686	.0716	.0343	.0457	.0716	.0857
20	.061	.0686	.0716	.0686	.061	.0716	.0857
21	.061	.0686	.0716	.0686	.061	.0716	.0857
22	.061	.0686	.0716	.0343	.061	.0716	.0857
23	.061	.0686	.0716	.0686	.061	.0716	.0857
24	.0343	.061	.0686	.0716	.0343	.0457	.0716
Max	2.0576	1.4022	1.4784	1.5043	1.6461	1.3717	1.2651
Min	.0305	.0343	.0358	.0343	.0305	.0358	.0716
Avg	.6358	.4861	.4657	.4900	.5312	.4009	.2279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 201 / MIDC TEMBHURNI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.4801	.4801	.6687	.6687	.4287
2	.3601	.3601	.4458	.4801	.6173	.6173	.4287
3	.3601	.3601	.4458	.4458	.6173	.5144	.4287
4	.3944	.3944	.4287	.4458	.5144	.4801	.4287
5	.3944	.3944	.3944	.4287	.4801	.4458	.4287
6	.4287	.4287		.3944	.4458	.463	.3944
7	.463	.463		.4115	.4115	.5144	.3772
8	.4801	.5144		.4287	.5144	.583	.3086
9	.6173	.5658		.4973	.7716	.6344	.3772
10	.8402	.6001	.6001	.6516	.823	.8573	.3258
11	.9259	.6687	.6859	.7888	.9259	.9602	.3258
12	.9088	.7888	.7202	.8573	.9088	.8573	.4287
13	.9259	.7888	.7202	.8916		.8573	.3944
14	.8916	.6706	.7716	.6687	.8573	.823	.4115
15	.9259	.6344	.7716	.9088	.7888	.7888	.2572
16	.8402	.6173	.7888	.9431	.4287	.7888	
17	.7716	.5144	.8059	.9431	.6706	.7716	
18	.7373	.5144	.6173	.8402	.8573	.6859	
19		.5487	.583	.7888	.7373	.5144	.1715
20	.703	.5144	.583	.6859	.7373	.5144	.2401
21	.5658	.5144	.5144	.6344	.703	.5658	.2572
22	.4115	.4973	.5144	.6687	.6401	.5658	.2915
23	.4458	.4801	.5316	.6859	.6859	.5658	.3086
24	1.0212	.4115	.4801	.5144	.703	.703	.5658
Max	1.0212	.7888	.8059	.9431	.9259	.9602	.5658
Min	.3601	.3601	.3944	.3944	.4115	.4458	.1715
Avg	.6445	.5273	.5941	.6452	.6743	.6559	.3609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 202 / KANHERGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.2955	1.4022	1.4022	.2591	.2743	.3772
2	1.3565	1.3565	1.5394	1.6309	.2591	.2591	.3772
3	1.4632	1.4632	1.7833	1.7833	.2439	.2591	.3772
4	1.7375	1.7375	1.9814	1.9814	.2743	.2743	.3772
5	2.1186	2.1186	2.21	2.21	.2743	.2743	.3772
6	2.3929	2.7587	2.5758	2.5758	.2896	.3048	.3772
7	2.7587	2.6063	2.7949	2.6673			
8	2.4082	2.5911	2.7282	2.7435			
9	2.271	2.4844	2.4996	2.6368			
10					1.7528	1.8004	1.89
11					2.5758	2.915	2.8654
12					2.7892	3.0864	
13					2.6978	3.0864	
14	2.271				2.5606		
15					2.5301	3.0864	
16	2.271				2.5911	3.0864	
17					2.5149	2.915	
19	.1829	.1981	.2134	.2439	.2286	.3429	.2591
20	.2134	.1981	.2286	.2439	.3048	.3429	.2743
21	.2134	.1829	.2439	.2591	.3048	.3772	.3048
22	.1829	.1829	.2134	.3086	.3201	.3772	.3201
23	.1677	.2058	.1829	.2743	.3353	.3772	.3048
24	1.2955	1.2955	1.326	1.326	.2743	.3048	.3772
Max	2.7587	2.7587	2.7949	2.7435	2.7892	3.0864	2.8654
Min	.1677	.1829	.1829	.2439	.2286	.2591	.2591
Avg	1.4566	1.3783	1.4615	1.4858	1.1690	1.2497	.6328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 203 / VENEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4268	.4572	.4572	1.0669	1.0669	1.7147
2	.442	.442	.4572	.4572	1.0669	1.2651	1.7147
3	.4572	.4572	.4877	.4877	1.2651	1.4937	1.7147
4	.4572	.4572	.5182	.5182	1.3565	1.6766	1.7147
5	.4725	.4725	.5182	.5335	1.4937	1.7528	1.7147
6	.4877	.5944	.5487	.5487	1.7528	1.9357	2.2291
7					1.9357	1.9814	2.572
8					1.829	2.0729	2.4863
9					1.6766	2.4006	1.9814
10	2.271	1.6766	1.8138	1.4937			
11	2.6825	1.7833	2.1338	1.768			
12	2.5911	2.1186	2.4387	2.1033			
13	2.5149	2.2253	2.332	1.9052			
14	2.271	2.1643	1.5242	1.7375			
15	2.2862	2.1186	1.829	1.8138			
16	2.2558	2.0119	1.8747	1.8138			
17	2.2862	1.9204	1.8595	1.7833			
19	.3658	.4268	.381	.3963	.3963	.5144	.4268
20	.3963	.4268	.3963	.3963	.4115	.5144	.381
21	.381	.4572	.3963	.3963	.3963	.5144	.3963
22	.3963	.4572	.4115	.3963	.4115	.5144	.3963
23	.4115	.4572	.4115	.3963	.4268	.5144	.3963
24	1.0365	.4268	.4572	.4572	1.0364	1.0669	1.5432
Max	2.6825	2.2253	2.4387	2.1033	1.9357	2.4006	2.572
Min	.3658	.4268	.381	.3963	.3963	.5144	.381
Avg	1.2445	1.0761	1.0623	.9930	1.1015	1.2856	1.4255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION

Feeder No / Name : 201 / 11 KV BHEND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2743	.1829	.2743	.2743	.2439	.9755
2	.2591	.2743	.2134	.2896	.2743	.2439	1.0364
3	.2743	.2743	.3048	.3201	.3353	.2743	1.1584
4	.3048	.3353	.3658	.3353	.3353	.3048	1.2498
5	.3506	.3963	.4268	.3963	.3963	.3658	1.3717
6	.4268	.4268	.4572	.4572	.3963	.4268	1.5242
7							1.9814
8							2.3777
9							2.1948
10		1.1888	1.2193	1.3108	1.3108	1.3717	
11	2.1643	2.3167	2.2862	2.1643	1.4175	2.1643	
12	2.4387	2.4082	2.4996	2.4387		2.3472	
13	2.4387	2.4082	2.3777	2.4387	2.1338	2.1338	
14	2.5911	2.2253	2.2558	2.2862	2.1948	2.0424	
15	2.5911	1.8595	2.2862	2.2862	2.1491	1.9509	
16	2.6216	2.2862	2.4082	2.1948	1.4937	2.0729	
17	2.4387	2.3167	2.4691	1.8595	1.0669	2.1643	
19	.3048	.3658	.3353	.3048	.3353	.3658	.3658
20	.3048	.3353	.3353	.3048	.2743	.3353	.3353
21	.3048	.3048	.3201	.3048	.2591	.3048	.3048
22	.4115	.2743	.3048	.2743	.2439	.2743	.2439
23	.4458	.2134	.1981	.2743	.2134	.7011	.2439
24	.2439	.2743	.1829	.2439	.2743	.2286	.7926
Max	2.6216	2.4082	2.4996	2.4387	2.1948	2.3472	2.3777
Min	.2439	.2134	.1829	.2439	.2134	.2286	.2439
Avg	1.1136	1.0379	1.0715	1.0379	.8094	1.0158	1.0771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION

Feeder No / Name : 202 / 11KV HOLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 201 / MITKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6658	2.3903	2.6558	2.6086	.1492	.156	
2	2.5152	2.4215	2.6558	2.6726	.1492	.1387	
3	2.5459	2.4215	2.6558	2.6886	.1492	.1387	
4	2.5309	2.649	2.7206	2.6886	.1492	.156	
5	2.7161	2.652	2.769	2.7526	.1492	.156	
6	2.7161	2.652	2.769	2.8487	.1492	.156	
7	2.7496	2.6852	2.9656	2.9058	.144	.1734	
8	2.7161	2.7664	2.9656	2.8433	.144	.1886	
9	2.5987	2.8182	3.0476	2.9058	.1265	.1387	
10	.0914	.0914	.1214	.0587	2.7846		3.3029
11	.0914	.1189	.156	.1082	3.1245		
12		.1219	.1214	.1067	3.1504		
13		.1524	.1214	.1217	3.2007		
14	.1372	.1677	.1214	.1097	3.155		
15	.1372	.1524	.1387	.1372	3.1245		
16	.1372	.1524	.1214	.1204	3.216		
17	.1715	.1677	.1734	.1595	3.0178		
18	.1372	.0914	.1387	.1612	.1214		.1932
19	.1372	.1372	.1387	.2155	.2058		.1886
20	.1372	.1067	.1387	.1658	.2229		.1406
21	.1372	.1067	.1387	.1658	.2229		.2035
22	.1372	.3012	.1387	.1791	.156		.2279
23	.1715	.2947	.1214	.144	.156		.1404
24	2.6658		2.6558	2.6086	.144	.156	
Max	2.7496	2.8182	3.0476	2.9058	3.216	.1886	3.3029
Min	.0914	.0914	.1214	.0587	.1214	.1387	.1404
Avg	1.2747	1.1139	1.2396	1.2282	1.1380	.1558	.6282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 202 / MALEGAON CANAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2743	.2743	.3086	1.7284	2.0481	
2	.2957	.2743	.2743	.3086	1.7444	2.0809	
3	.3292	.2572	.3086	.3258	1.7444	2.0325	
4	.3696	.2572	.3544	.3429	1.7924	2.0805	
5	.3881	.2915		.3429	1.8084	2.2085	
6	.5359	.3429			2.2085	2.4166	
7					2.5446	2.6086	
8					2.3685	2.6886	
9					2.1822	2.5286	
10	3.3867	2.372	2.5926	2.2028	.1387		.2058
11	3.94	3.1459	2.9058	2.7965	.1214		
12		3.1131	2.8746	2.7892	.1387		
13		2.9473	2.7206	2.713	.1387		
14	3.4202	2.834	2.1956	2.5775	.1715		
15	3.504	2.7046	2.1464	2.3403	.1886		
16	3.1398	2.4036	2.1956	2.2613	.2229		
17	2.7435	2.3245	2.0972	2.2138	.2058		
18		.2629	.1907	.2033	.2229		.3045
19		.3012	.2572	.3315	.2572		
20		.3012	.3086				
21	.2401	.298					
22	.2572	.3012		.2987	.2229		.298
23	.2572	.2947		.2328	.2229		.2587
24	.2772	.2572	.3155	.2743	1.7284	1.8679	
Max	3.94	3.1459	2.9058	2.7965	2.5446	2.6886	.3045
Min	.2401	.2572	.1907	.2033	.1214	1.8679	.2058
Avg	1.4601	1.2171	1.3758	1.2702	1.0047	2.2561	.2668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 203 / HARINAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0171	.0185	.0181	.088	.1174	
2	.0189	.0171	.0183	.0181	.088	.1174	
3	.0189	.0171	.0185	.0181	.1027	.1174	
4	.0189	.0171	.0185	.0181	.132	.1677	
5	.0189	.0171	.0187	.0181	.1467	.2347	
6	.0189	.0171	.0185	.0181	.1614	.2683	
7	.0189	.0171	.0185	.0181	.1614	.3277	
8	.0189	.0171	.0187	.0181	.2054	.3932	
9	.0189	.0185	.0187	.0181	.1808		
10	.3048	.3353	.2622	.2258	.0181	.3277	.0171
11	.381	.381	.3605	.2934	.0181		
12		.3963	.3768	.2378	.0181		
13		.3506	.3277	.2347	.0181		
14	.503	.3353	.2785	.2526	.0181		
15	.4572	.3353	.2949	.2559	.0181		
16	.4115	.2972	.3277	.2258	.0181		
17	.3353	.2229	.2458	.2107	.0181		
18	.0152	.0185	.0181	.0185	.0181		.0189
19	.0171	.0185	.0181	.0187	.0181		.0189
20	.0171	.0185	.0181	.0179	.0181		.0189
21	.0171	.0183	.0181	.0179	.0181		.0189
22	.0171	.0185	.0181	.0187	.0181		.0189
23	.0171	.0187	.0181	.0187	.0181		.0187
24	.0189	.0171	.0185	.0181	.088	.0838	
Max	.503	.3963	.3768	.2934	.2054	.3932	.0189
Min	.0152	.0171	.0181	.0179	.0181	.0838	.0171
Avg	.1219	.1224	.1153	.0928	.0670	.2155	.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274248 / 33/11KV SOLANKARWADI

Feeder No / Name : 202 / SOLANKARWADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
23	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 401 / 33 KV Tembhurni

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
18		1.8519
23	1.829	
Max	1.829	1.8519
Min	1.829	1.8519
Avg	1.829	1.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 402 / 33 KV Bhend

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 403 / 33 KV Pimpalner

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 404 / 33 KV Bemble

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 405 / 33 KV Adhegaon

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 406 / 33 KV Kandhar (Surli)
Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 407 / 33 KV MIDC

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 408 / JINDAL EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1317	
2						1.1317	
3						1.1317	
4						1.1317	
5						1.1317	
6						1.1317	
7						1.1317	
8	.6173	.823	.2572	.3086	.3086	1.1317	1.1317
9						.7716	
10						.7716	
11						.7716	
12						.7716	
13						.7716	
14						.7716	
15						.7716	
16	.6687	.6173	.2572	.4115	.4115	.7716	.7716
17					.7716		.7716
18					.7716		.7716
19					.7716		.7716
20					.7716		.7716
21					.7716		.7716
22					.7716		.7716
23					.7716		.7716
24	.6687	1.0802	.4115	.463	.463	.7716	.7716
Max	.6687	1.0802	.4115	.463	.7716	1.1317	1.1317
Min	.6173	.6173	.2572	.3086	.3086	.7716	.7716
Avg	.6516	.8402	.3086	.3944	.6584	.9411	.8076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 409 / MILLENIUM EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3601	
2						.3601	
3						.3601	
4						.3601	
5						.3601	
6						.3601	
7						.3601	
8	1.2346	.7716	.7716	1.1831	1.1831	.3601	.3601
9						.5144	
10						.5144	
11						.5144	
12						.5144	
13						.5144	
14						.5144	
15						.5144	
16		.7202	.7202	1.2346	1.286	.5144	.5144
17					.3601		1.1317
18					.3601		1.1317
19					.3601		1.1317
20					.3601		1.1317
21					.3601		1.1317
22					.3601		1.1317
23					.3601		1.1317
24	1.1317	.6173	.823	1.0288	1.0288	.3601	.3601
Max	1.2346	.7716	.823	1.2346	1.286	.5144	1.1317
Min	1.1317	.6173	.7202	1.0288	.3601	.3601	.3601
Avg	1.1832	.7030	.7716	1.1488	.6019	.4327	.9157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 410 / STATION T/F

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 411 / Deveer Decor Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 801 / 220 KV EHV VSSSKL (CO GEN)

FE Feeder KV- 220 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 132/33 kV INDAPUR EHV

Feeder No / Name : 401 / 33kV SMC UJANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 132/33 kV INDAPUR EHV

Feeder No / Name : 402 / 132 KV EHV SEENA MADHA

(LIS AG Feeder KV- 132 /
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 132/33 kV INDAPUR EHV

Feeder No / Name : 403 / 132 KV SHIVRATNA (CO GEN)

ALEG Feeder KV- 132 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 132/33 kV INDAPUR EHV

Feeder No / Name : 404 / 132 KV EHV HYDRO

GENERATION (U Feeder KV- 132 /
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	3.658
Max	3.658
Min	3.658
Avg	3.658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 132/33 kV INDAPUR EHV

Feeder No / Name : 701 / 132 KV NTPC

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	7.316
Max	7.316
Min	7.316
Avg	7.316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHUPSANGI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 202 / 11KV ANDHALGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV LAXMI DAHIWADI

SEPARATED AG FEEDERS HAVING SPECIAL

FEEDER Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	2.5339
24	1.9433
Max	2.5339
Min	1.9433
Avg	2.2386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 204 / Gaothan Andhalgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4049
Max	.4049
Min	.4049
Avg	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 206 / 11 KV MAHAMADABAD(S)

SEPARATED AG FEEDERS HAVING SPECIAL

FEEDER Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 201 / 11KV UCHETHAN FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 202 / 11KV SARKOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	2.915
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 203 / 11KV BATHAN FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 204 / Bathan Gaothan

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
23	.2572
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 201 / 11 KV TAMDARDI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.6673
Max	2.6673
Min	2.6673
Avg	2.6673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 202 / 11 KV ARALI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 203 / 11 KV DONAJ FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 204 / 11 KV SIDDHAPUR FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 205 / 11 KV TANDUR FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 206 / 11 KV BORALE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 207 / Gaothan Borale

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 208 / 11 Kv Nandur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 209 / 11 Kv Mahasiddha Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 210 / Matoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 201 / 11KV HULJANTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3481	.0335	.0335	.0503	.2543	.2683	1.186
2	.3315	.0503	.0503	.0503	.2543	.2683	1.2651
3	.3481	.0503	.0503	.0503	.2543	.285	1.3441
4	.3978	.0671	.0503	.0671	.2713	.285	1.5813
5	.4144	.0168	.0671	.0838	.3052	.3185	1.7394
6	.4359	.0838	.0838	.1134	.3391	.3688	1.9292
7		.0671	.1174	.1006		.3688	1.8976
8		.0671		.0838			1.6129
9		.0671	.0671	.0671			2.1506
10	.3018	.0671	.0671	.0671	.3052	.2347	
11	2.2377	1.2651	1.2651	1.4586		.7907	
12	2.0056	1.9766	2.0873	2.0454	2.2382	1.6288	
13	2.1548	2.119	1.2651	2.0885	1.5939	1.5971	
14		2.0399	1.9766	2.1293	1.7804	1.4548	
15	1.9725	2.0557	1.9925	2.146	1.6956	1.5655	
16	2.1051	2.0715	1.1702	2.079	2.2552	1.6762	
17	2.0222	1.9608	.506	1.9784	2.1704	1.7078	
18	.7956	.8065	.933	.9282	.8648	.5535	
19	.5636	.8697	1.0911	.9054	1.0174	.9804	.4359
20	.5304	.7907	.7748	.8551	.8478	.9488	.4527
21	.5365	.8223	.7274	.8215	.8309	.3521	.4024
22	.4973	.8697	.8029	.7545	.7291	.3521	.3521
23	.4527	.8065	.7773	.6874	.6783	.3185	.3353
24	.3688	.0335	.0503	.0503	.2374	.2683	1.0911
Max	2.2377	2.119	2.0873	2.146	2.2552	1.7078	2.1506
Min	.3018	.0168	.0335	.0503	.2374	.2347	.3353
Avg	.9410	.7941	.6959	.8192	.9462	.7542	1.1850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 202 / 11 KV SODDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.7773	.7125	.8122	1.0395	.9374	.1658
2	.7127	.9069	.7935	.9614	1.1401	1.0623	.1658
3	.779	1.2308	.8583	1.0608	1.3077	1.1405	.1492
4	.8288	1.3279	1.1012	1.1603	1.576	1.2186	.1658
5	1.3094	1.4413	1.2955	1.4089	1.643	1.3279	.1658
6	1.6575	1.5546	1.7194	1.6244	1.6933	1.4373	.1989
7	2.0222	1.6842	1.6842	2.1051	1.6263	1.406	
8	2.1216	1.6194		2.0885	2.2298	1.9997	
9	2.1879	1.9433	1.668	1.8564	2.0287	1.6872	
10							.1492
11							1.0688
12							1.7328
18				.7127			
19		.2321	.2486	.2486	.218	.2105	.1823
20	.2321	.1989	.2652	.2486	.1844	.2267	.2486
21	.2155	.1823	.2155	.2486	.218	.2105	.1989
22	.1823	.1989	.1658	.2155	.1677	.1781	.1658
23	.1492	.1492	.1823	.2155	.1677	.1943	.1823
24	.6133	.6478	.6796	.7127	.8048		.1823
Max	2.1879	1.9433	1.7194	2.1051	2.2298	1.9997	1.7328
Min	.1492	.1492	.1658	.2155	.1677	.1781	.1492
Avg	.9768	.9397	.8278	.9800	1.0697	.9455	.3415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 203 / 11 KV MARAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.1638	.1638	.1638	.16	.1638	1.7394
2	.4915	.1638	.1638	.1638	.16	.1638	1.7394
3	.4915	.1638	.1638	.1638	.16	.1638	1.7394
4	.4915	.1638	.1638	.1638	.16	.1638	2.2138
5	.4915	.1638	.1638	.1638	.16	.1638	2.372
6	.4915	.1677	.1638	.1638	.16	.1638	2.372
7		.1677	.1638	.1638	.16	.1638	2.5301
8		.1677		.1638	.16	.1638	2.5301
9		.1677	.1638	.1638	.16		2.372
10	.3277	.1677			.16	.1638	
18	.9831	.8192	.7907	.9945	.9602	1.1069	
19	.9831	.9488	.7907	.9945	.8002	1.2651	.6554
20	.9831	.9488	.9488	.9945	.8002	.4915	.6554
21	.9831	.9488	.7907	.8288	.8002	.6554	.6554
22	.9831	.9488	.7907	.8288	.8002	.4915	.6554
23	.8192	.7907	.8097	.8288	.8002	.4915	.4915
24	3.5684	.1638	.1638	.1638	.16	.1638	1.5813
Max	3.5684	.9488	.9488	.9945	.9602	1.2651	2.5301
Min	.3277	.1638	.1638	.1638	.16	.1638	.4915
Avg	.8986	.4251	.4264	.4442	.3954	.3837	1.6202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 204 / Gaothan Huljanti

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4755	.543	.5258	.5258	.4938	.4344
2	.4207	.4755	.5068	.4733	.5847	.4755	.4525
3	.4557	.5853	.4525	.4557	.6201	.5121	.5068
4	.631	.6878	.5973	.6836	.6733	.5487	.6335
5	.7537	.8417	.724	.8962	.7973	.6878	.7602
6	1.0425	.9313	.8869	.9877	.9412	.9511	.9745
7	1.134	1.0099	1.086	1.0608	1.0679	1.0517	.9214
8	.9877	.9214		.9145	.8505	.8859	.815
9	1.0974	.8145	1.0631	.9511	.9313	1.1145	1.4175
10	1.2254	.6584			.8987	.9922	1.2048
11		.5487	.8505	.5853		.6335	1.3112
12	.7865	.4207	.3898	1.0242	.8478	.4161	1.2757
13	.7316	.3841	.8326	.4938	.6706	.4755	.6024
14		.4024	.6154	.7499	.9724	.4207	.3898
15	.7316	.4572	.362	1.0059	1.0174	.4755	.4075
16	1.134	.5304	.362	.7316	1.0059	.6036	.4344
17	1.0242	.421	.9774	.9877	.9724	.6036	.4706
18	1.0791	.4512	1.1694	1.0974	1.0059	.7133	1.382
19	.9328	.9922	1.0277	1.0242	.9313	.9955	1.0277
20	.9145	1.0692	1.1694	1.0608	1.086	1.0166	1.0631
21	.8048	.9114	1.0808	1.0974	.8817	.8328	.9922
22	.695	.6767	.8859	.8048	.7537	.7343	.7973
23	.6219	.7059	.7602	.695	.5959	.6036	.6878
24	.4733	.5121	.5973	.5959	.5959	.5121	.4706
Max	1.2254	1.0692	1.1694	1.0974	1.086	1.1145	1.4175
Min	.4207	.3841	.362	.4557	.5258	.4161	.3898
Avg	.8234	.6619	.77	.8219	.8360	.6979	.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 205 / 11 Kv Yedrav Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0467	1.2186	1.406	1.406	1.9134	1.9528	.1457
2	1.1717	1.5466	1.4217	1.4842	2.0873	2.1091	.1457
3	1.2811	2.1247	1.4706	1.5623	2.2613	2.1872	.1619
4	1.5623	2.1559	1.5623	1.8747	2.4669	2.3122	.1619
5	1.9216	2.1872	1.8747	2.4996	2.5143	2.4996	.1781
6	2.2184	2.6715	2.2455	2.1715	2.5775	2.609	.2105
7	2.359	2.6715	2.3903	2.4996	2.5775	2.3903	
8	2.4528	2.5309		1.9528	2.7357	2.5309	
9	2.3434	.5937	1.1069	2.359	2.5301	2.3434	
10							.1457
11			1.4373	.9061		.9374	1.3435
12	2.2028	2.3746	1.2342	1.906	1.866	2.0309	1.9292
13	2.2672		1.945	1.8903	1.9925	2.1247	
14		2.484	2.1091	1.9528	2.0241	2.2611	
15	2.1715	2.4215	1.9216	2.0309	1.8343	1.8435	
16	2.4059	2.3746	2.0399	1.9528	1.866	2.0934	
17	2.2184	2.1559	1.9766	1.7497		1.8435	
18						2.1357	
19	.703	.6874	.759	.5668		.2591	.2753
20	.664	.6405	.9646	.6964	.7748	.2267	.2429
21	.7125	.703	.9172	.8421	.7274	.2105	.2267
22	.6316	.7499	.9804	.8259	.7907	2.1052	.1943
23	.6154	.7343	.8907	.7449	.8381	.1781	.1781
24	.9686	1.0623	1.3592	1.3279	1.4706	1.5935	.1457
Max	2.4528	2.6715	2.3903	2.4996	2.7357	2.609	1.9292
Min	.6154	.5937	.759	.5668	.7274	.1781	.1457
Avg	1.5959	1.7044	1.5244	1.6001	1.8868	1.7729	.3790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 201 / 11 kv Hunnur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4696	.6802	.5668	.5506	.6316	.6478	.1296
2	.5182	.8745	.6802	.7059	.8583	.8907	.1296
3	.7287	.9878	.8583	.8259	.9717	.9555	.1457
4	.9393	1.004	1.1336	1.1498	1.0526	1.1174	.1457
5	1.1012	1.1498	1.3279	1.3441	1.3279	1.4089	.1781
6	1.4251	1.247	1.5708	1.5384	1.6356	1.7814	.1781
7	1.749	1.5546	1.9919	2.1862	1.7004	2.0891	.2591
8	1.8947	1.587	1.9757	2.2834	.7935	2.1862	.2105
9	1.9109	1.4251	2.1538	2.1538	1.8299	1.7976	.1619
10							.2591
11							.9231
12							2.0081
18							.7773
19	.1781	.3239	.2915	.2429	.2591	.2591	.2267
20	.2105	.3401	.3077	.2267	.3077	.2915	.2105
21	.2267	.2591	.2591	.2105	.2267	.2572	.1943
22	.2267	.2105	.2105	.1781	.1943	.1943	.1781
23	.1781	.1619	.2105	.1619	.1781	.1781	.1781
24	.3725		.4372	.3563	.4534	.4372	.1457
Max	1.9109	1.587	2.1538	2.2834	1.8299	2.1862	2.0081
Min	.1781	.1619	.2105	.1619	.1781	.1781	.1296
Avg	.8086	.8433	.9317	.9410	.8281	.9661	.3494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 202 / 11 kv Bhose Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 203 / 11 Kv Mahamdabad Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.061	.1219	.1372	.0914	.0914	.0152
2	.1219	.1067	.1524	.1677	.1219	.1372	.0152
3	.1524		.2134	.2286	.1829	.1981	.0152
4	.2134	.2229	.2743	.2896	.2134	.2591	.0152
5	.2743	.2743	.2896	.3353	.2896	.2896	.0152
6	.3353		.3201	.3963	.3658	.3963	.0152
7	.4268	.3963	.381	.4572	.4268	.4877	.0152
8	.442	.442	.5335	.3963	.1524	.3658	.0152
9	.381	.3658	.5182	.4115	.1524	.3658	.0152
10							.0152
11							.0762
12							.3506
18							.1524
19	.0152	.0305	.0305	.0457	.0305	.0152	.0152
20	.0152	.0305	.0305	.0457	.0305	.0171	.0152
21		.0152	.0305	.0305	.0305	.0171	.0152
22	.0152	.0152	.0305	.0305	.0305	.0171	.0152
23	.0152	.0152	.0305	.0305	.0305	.0152	.0152
24	.061	.0305	.0457	.061	.061	.0762	.0152
Max	.442	.442	.5335	.4572	.4268	.4877	.3506
Min	.0152	.0152	.0305	.0305	.0305	.0152	.0152
Avg	.1829	.1543	.2002	.2042	.1473	.1833	.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 204 / Gaothan Hunnur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 205 / MANEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.823	.5487	.5973	.5487	.5973	.1543
2	.6001	.9431	.6859	.7421	.7373	.7964	.1372
3	.823	1.166	.9602	.9955	.9259	1.0136	.1543
4	1.166	1.3889	1.2346	1.2851	1.1831	1.2127	.1543
5	1.2517	1.6118	1.4575	1.5565	1.4575	1.5746	.1715
6	1.406	1.9547	1.6461	1.7194	1.8347	1.7918	.2229
7	2.3148		2.3148	2.4796	2.3148	2.3348	.2401
8	2.332	2.1091	2.1605	2.6425	2.1434	2.6063	.2058
9	2.1434	1.8176	2.1948	2.4977	1.6975	1.7556	.1886
10							.4801
11							.823
12							2.0576
18							.9259
19	.2401	.2229	.2715	.2572	.2715	.2229	.2229
20	.2229	.2401	.2715	.2401	.2534	.2401	.2058
21	.2058	.2058	.2715	.2229	.2172	.2401	.1886
22	.1715	.2229	.2534	.2058	.1991	.2058	.1715
23	.1543	.1886	.2534	.1886	.1991	.1715	.1715
24	.3429	.5144	.4115	.4344	.4287	.4344	.1715
Max	2.332	2.1091	2.3148	2.6425	2.3148	2.6063	2.0576
Min	.1543	.1886	.2534	.1886	.1991	.1715	.1372
Avg	.9236	.9578	.9957	1.0710	.9608	1.0132	.3709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 206 / Lonar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1543	.1715	.0514	.2058	.2229	.6859
2	.2058	.1543	.1715	.0514	.2229	.2229	.8059
3	.2058	.1886	.1886	.0514	.2229	.2401	.9259
4	.2058	.1886	.2058	.0514	.2401	.2401	1.1831
5	.2229		.2058	.0514	.2401		1.5604
6	.2401	.2987	.2229	.0343	.2572	.2743	1.6975
7	.2058		.2229	.0343	.2401	.2743	1.989
8	.1886		.2058	.0343	.2058	.2401	2.1776
9	.1372	.2058	.1715	.0343	.1886	.1886	1.8176
10	2.0233	.2915			.2743	.2401	
11	2.0748	1.0288			1.4403	1.869	
12	2.0576	1.9376			2.3148	2.0748	
13	2.0233			2.2291	2.3148	2.4006	
14	2.0576	1.9719		2.2634	2.2634	2.2977	
15	2.1948	1.9033		2.332	2.2462	2.332	
16	1.8519	1.6804		2.1776		2.1948	
17	1.8519	2.1948			2.3663		
18	1.6632	1.8861			2.2634		
19	.2229	.2572	.0686	.2401	.2572	.2401	.2058
20	.2401	.2743	.0686	.2572	.2743	.2572	.2058
21	.2058	.2401	.0686	.2401		.2401	.1886
22	.1886	.2229	.0514	.2229	.2401	.2058	.1886
23	.1886	.2058	.0514	.2058		.2058	.1715
24	.1886	.1715	.1886	.0514	.2058	.2229	.5316
Max	2.1948	2.1948	.2229	2.332	2.3663	2.4006	2.1776
Min	.1372	.1543	.0514	.0343	.1886	.1886	.1715
Avg	.8681	.7728	.1509	.5586	.8802	.7945	.9557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 201 / 11 KV MANGALWEDHA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.6289
Max	1.6289
Min	1.6289
Avg	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 202 / 11 KV GFSS MGL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 203 / 11 KV BORALE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.7831
Max	2.7831
Min	2.7831
Avg	2.7831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 204 / 11 KV MALLEWADI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 205 / 11KV UCHETHAN FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1052
Max	2.1052
Min	2.1052
Avg	2.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 201 / 11KV JALIHAI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 202 / 11KV NANDESHWAR FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
24	2.915	2.915
Max	2.915	2.915
Min	2.915	2.915
Avg	2.915	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 203 / 11KV JITTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 205 / Gaothan Nimboni

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 206 / 11 KV Chikkalgi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 201 / SALGAR BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1052
Max	2.1052
Min	2.1052
Avg	2.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102] BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 202 / MAROLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102] BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 203 / LAWANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	03-MAR-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102] BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 204 / SALGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102] BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 205 / 11 kv jangalgi ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 201 / 11KV MARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7394	1.6762		1.5043			.3384
2	1.7394	1.7236		1.3763			.3144
3	1.7711	1.7711		1.2811			.2972
4	1.8785	1.8278		1.3435			.3658
5	1.9524	1.929		1.5181			.4481
6	2.2348	2.1376		1.9685			.583
7	2.7526	2.2725		2.3878			.8619
8	2.8346	2.5911					
9	2.2672		2.7854		2.8509		
10	.2187		.2561		.2332		
11	.598		.6226		.4172		
12	1.0212		.4694		.823		
13	1.0467		.5898		.8539		
14	1.0437		.8745		.8749		
15	.953		.9175		.8173		
16					.7331		
17		1.0814		.9686	.8322		2.652
18		.9393		.8619	.7282	.7865	2.652
19		.4344		.3506	.3605	.4024	.4161
20		.4298		.4161	.3887	.4656	.4694
21		.3292		.3201	.2743	.362	.3658
24	1.7078	1.6248		1.587			.3616
Max	2.8346	2.5911	2.7854	2.3878	2.8509	.7865	2.652
Min	.2187	.3292	.2561	.3201	.2332	.362	.2972
Avg	1.6099	1.4834	.9308	1.2218	.7836	.5041	.7789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 204 / 11 KV GFSS MARAPUR

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.181
Max	.181
Min	.181
Avg	.181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 205 / ITI COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7116	.7907		.7042		.5506	.1463
2	.759	.8223		.7202		.5506	.1463
3	.8002	.8223		.7682		.583	.1848
4	.9282	1.0155		.8223		.6226	.2427
5	1.0242	1.0936		.8642			.2801
6	1.1363	1.247		1.1012			.3395
7	1.4243	1.2651		1.3603			.3206
8	1.4548	1.3123					
9	1.012		.8684		1.3441		
17							1.5684
18							1.4864
19		.2743		.3142	.2402	.2353	.2378
20		.2172		.2561	.2378	.2378	.2195
21		.1791		.1791	.1646	.181	.1629
24	.6483	.7116		.7125		.5182	.1463
Max	1.4548	1.3123	.8684	1.3603	1.3441	.6226	1.5684
Min	.6483	.1791	.8684	.1791	.1646	.181	.1463
Avg	.9899	.8126	.8684	.7093	.4967	.4349	.4217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 206 / GUNJEGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.1791		.1829			1.1561
2	.2149	.181		.181			1.1561
3	.2149	.2172		.2353			1.1873
4	.2534	.2561		.2926			1.3123
5	.2926	.3077		.3511			1.4251
6	.3696	.3511		.4481			1.7238
7	.4435	.3841		.4251			2.1136
8	.3801	.3801					
9	.2658		.2743		.2149		
10	.2204		.2195				
11	2.0485		1.8785		1.5023		
12	2.6379		2.6216		2.0165		
13	2.5888		2.4291		2.1628		
14	2.556		2.251		2.2283		
15	2.5069		2.3266		2.0005		
16					2.0325		
17		2.17		1.8724	2.0485	2.1376	
18		2.1214		1.7869	2.0081	1.7695	
19		.3292		.3403	.362	.3658	.3658
20		.3292		.3224	.3582	.3658	.4207
21		.2507		.2835	.3012	.3045	.3224
24	.1772	.1791		.1829			1.1248
Max	2.6379	2.17	2.6216	1.8724	2.2283	2.1376	2.1136
Min	.1772	.1791	.2195	.181	.2149	.3045	.3224
Avg	.9616	.5454	1.7144	.5311	1.4363	.9886	1.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 201 / 11 Kv Machnur new
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.6401	.823	.7865	.7468	.7373	.0514
2	.7209	.6401	.7926	.7865	.823	.7045	.0514
3	.7209	.6401	.8078	.7537	.8059	.7209	.0514
4	.7701	.6401	.7926	.7373	.7716	.7209	.0514
5	.7373	.6097	.7773	.7373	.6706	.7537	.0514
6	.7701	.5792	.7468	.8029	.7888	.7209	.0514
7	.8684	.5792	.7926	.9012	.9088	.8029	.0514
8	.9012	.7773	.945		.8916	.9012	.0514
9	.9012	.7926	.9602	.852	.8535	.7865	.0514
10	.0549	.0514	.0514	.0514	.0514	.0514	.0514
11	.0549	.0514	.0514	.0514	.0514	.0514	.7773
12	.0549	.0514	.0514	.0514	.0514	.0514	.9145
13	.0549	.0514	.0514	.0514	.0514	.0514	.9755
14	.0549	.0514	.0514	.0514	.0514	.0514	.8535
15	.0549	.0549	.0514	.0514	.0514	.0514	
16	.0549	.0514	.0514	.0514	.0514	.0514	
17	.0514	.0514	.0549	.0514	.0549	.0514	
18	.0514	.0514	.0549	.0514	.0549		
19	.0514	.0514	.0549	.0514	.0549	.0514	.0549
20	.0514	.0514	.0549	.0514	.0549	.0514	.0549
21	.0514	.0514	.0549	.0514	.0549	.0514	.0549
22	.0514	.0514	.0549	.0514	.0549	.0514	.0549
23	.0514	.0514	.0549	.0514	.0549	.0514	.0549
24	.852	.6401	.8535	.8192	.7621	.7537	.0514
Max	.9012	.7926	.9602	.9012	.9088	.9012	.9755
Min	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.3662	.3026	.3765	.3433	.3653	.3596	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 202 / 11 Kv Bramhpuri Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 River Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0686	.0686	.0732	.0686	.0732	.3353
2	.0732	.0686	.0686	.0732	.0686	.0732	.3506
3	.0732	.0686	.0686	.0732	.0686	.0732	.3353
4	.0732	.0686	.0686	.0732	.0686	.0732	.3353
5	.0732	.0686	.0686	.0732	.0686	.0732	.3506
6	.0732	.0686	.0686	.0732	.0686	.0732	.3201
7	.0732	.0686	.0686	.0732	.0686	.0732	.3658
8	.0732	.0686	.0686		.0686	.0732	.3658
9	.0732	.0686	.0686	.0732	.0686	.0732	.3658
10	.0549	.0686	.0686	.0686	.0686	.0686	.061
11	.5571	.6097	.5182	.5182	.3353	.5182	.0686
12	.7373	.6706	.5182	.5182	.583	.5182	.0686
13	.6226	.6706	.503	.583	.583	.5182	.0686
14	.5898	.6706	.503	.3506	.4115	.5182	.0686
15	.5735	.5182	.503	.3506	.4115	.3658	
16	.5243	.5182	.503	.3506	.4115	.3658	
17	.4877	.5182	.5407	.3658	.3978	.3658	
18	.5182	.3353	.4096	.3658	.4144	.3506	.0732
19	.0686	.061	.0732	.0305	.0732	.0686	.0732
20	.0686	.0686	.0732	.0686	.0549	.0686	.0732
21	.0686	.0686	.0732	.0686	.0549	.0686	.0732
22	.0686	.0686	.0732	.0686	.0549	.0686	.0732
23	.0686	.0686	.0732	.0686	.0732	.0686	.0732
24	.0732	.0686	.0686	.0732	.0686	.0732	.3658
Max	.7373	.6706	.5407	.583	.583	.5182	.3658
Min	.0549	.061	.0686	.0305	.0549	.0686	.061
Avg	.2392	.2334	.2133	.1928	.1922	.1944	.2031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 203 / 11kv GFSS Bramhapuri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.2058	.1543	.181	.1715	.181	.1886
2	.1448	.2058	.1543	.181	.1543	.181	.1715
3	.1629	.2058	.1715	.181	.1543	.181	.1543
4	.181	.2058	.2058	.2172	.2058	.1991	.2058
5	.2896	.2743	.2743	.2715	.2743	.2534	.2572
6	.3801	.3086	.3258	.3258	.3601	.362	.3601
7	.3982	.3601	.3601	.3801	.3258	.362	.3772
8	.3077	.2743	.2915		.2572	.3077	.2915
9	.2715	.2572	.2401	.2715	.2401	.2896	.2401
10	.2534	.2572	.2134	.2572	.2401	.2229	.2572
11	.2172	.2229	.1886	.2058	.1886	.2058	.1886
12	.2172	.2229	.2058	.1829	.1886	.2229	.2058
13	.2353	.2058	.1886	.1829	.1886	.1829	.1886
14	.1991	.1886	.1715	.1219	.1543	.1543	.1715
15	.1991	.1715	.12	.1543	.1543	.1543	
16	.1991	.1715	.12	.1715	.1372	.1715	.1715
17	.2058	.1715	.1991	.1886	.1448	.1715	.2353
18	.1886	.2229	.2353	.2229	.181	.1543	.2172
19	.2401	.2743	.3077	.2572	.2896	.3086	.2896
20	.2572	.2915	.3077	.2743	.2896	.2743	.3258
21	.2572	.2401	.2715	.2401	.2715	.2572	.3439
22	.2401	.2401	.2353	.2229	.2534	.2401	.2896
23	.2401	.2058	.2172	.2058	.2353	.2058	.2534
24	.1991	.2058	.1886	.1991	.1886	.1991	.2058
Max	.3982	.3601	.3601	.3801	.3601	.362	.3772
Min	.1448	.1715	.12	.1219	.1372	.1543	.1543
Avg	.2353	.2329	.2228	.2216	.2187	.2268	.2430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 204 / 11 KV BRAHAMPURI BORE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0686	.0686	.0732	.0686	.0732	1.2346
2	.0732	.0686	.0686	.0732	.0686	.0732	1.2174
3	.0732	.0686	.0686	.0732	.0686	.0732	1.2003
4	.0732	.0686	.0686	.0732	.0686	.0732	1.1736
5	.0732	.0686	.0686	.0732	.0686	.0732	1.3717
6	.0732	.0686	.0686	.0732	.0686	.0732	1.2498
7	.0732	.0686	.0686	.0732	.0686	.0732	1.3565
8	.0732	.0686	.0686		.0686	.0732	1.4175
9	.0732	.0686	.0686	.0732	.0686	.0732	1.4632
10	.0732		.0686	.0686	.0686	.0686	.0686
11	1.1633	1.2003	1.0974	1.1126	1.2803	1.1126	.0686
12	1.491	1.5851	1.4784	1.5546	1.8347	1.6461	.0686
13	1.5238	1.6309	1.6004	1.7833	1.7223	1.7223	.0686
14	1.704	1.4175	1.5242	1.8004	1.8519	1.7528	.0686
15	1.6712	1.4937	1.4937	1.4784	1.5242	1.6461	.0686
16	1.6712	1.5242	1.5851	1.6918	1.5546	1.7528	.0686
17	1.5394	1.6613	1.8187	1.768	1.7695	1.7528	.0732
18	1.4937	1.6766	1.6712	1.6613	1.7532	1.6309	.0732
19	.0686	.0686	.0732	.0686	.0732	.0686	.0732
20	.0686	.0686	.0732	.0686	.0732	.0686	.0732
21	.0686	.0686	.0732	.0686	.0732	.0686	.0732
22	.0686	.0686	.0732	.0686	.0732	.0686	.0732
23	.0686	.0686	.0732	.0686	.0732	.0686	.0732
24	.0732	.0686	.0686	.0732	.0686	.0732	1.1126
Max	1.704	1.6766	1.8187	1.8004	1.8519	1.7528	1.4632
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.5586	.5747	.5579	.6053	.6005	.59	.5746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 205 / Machnur AG-2

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.884	.7926	1.065	.9907	1.1469	.0686
2	.9995	.884	.884	1.1142	.9755	1.1633	.0686
3	1.0159	.884	.9755	1.1305	1.0364	1.1305	.0686
4	1.0159	.945	.9602	1.1305	1.1126	1.1305	.0686
5	1.0322	.945	.9755	1.1633	1.1888	1.1633	.0686
6	1.0978	1.0364	1.0059	1.1633	1.2346	1.2125	.0686
7	1.2452	1.0669	1.3108	1.4091	1.2498	1.3272	.0686
8	1.4255	1.1584	1.3717		1.2803	1.3272	.0686
9	1.4746	1.1888	1.5432	1.3108	1.2955	1.3272	.0686
10	.0732	.0686	.0686	.0686	1.2955	.0686	.0686
11	.0732	.0686	.0686	.0686	.061	.061	.945
12	.0732	.0686	.0686	.0686	.0686	.0686	1.1736
13	.0732	.0686	.0686	.0686	.0686	.0686	1.1888
14	.0732	.0686	.0686	.0686	.0686	.0686	1.1888
15	.0732	.0686	.0686	.0686	.0686	.0686	
16	.0732	.0686	.0686	.0686	.061	.0686	
17	.0686	.0686	.0732	.0686	.0732	.0686	
18	.0686	.0686	.0732	.0686	.0732	.0686	
19	.0686	.0686	.0732	.0686	.0732	.0686	.0732
20	.0686	.0686	.0732	.0686	.0732	.0686	.0732
21	.0686	.0686	.0732	.0686	.0732	.0686	.0732
22	.0686	.0686	.0732	.0686	.0732	.0686	.0732
23	.0686	.0686	.0732	.0686	.0732	.0686	.0732
24	.9995	.884	.823	1.065	1.0212	1.1469	.0686
Max	1.4746	1.1888	1.5432	1.4091	1.2955	1.3272	1.1888
Min	.0686	.0686	.0686	.0686	.061	.061	.0686
Avg	.5117	.4515	.4848	.5005	.5662	.5428	.2808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 201 / 11 Kv Shirshi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 202 / 11 Kv Khadki Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 203 / 11 Kv Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102] BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi
SubstationFeeder No / Name : 204 / 11 KV GONEWADI AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 201 / 11 KV KHOMNAL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2012	.2058	.1524	.1524	.2058	.7926
2	.1372	.2012	.2058	.1677	.1372	.2058	.8535
3	.1677	.2035	.2229	.1677	.1524	.2229	.9907
4	.1981	.2347	.2401	.1829	.1829	.2401	1.1279
5	.2896	.2713	.2401	.2134	.2286	.3258	1.3717
6	.381		.2743	.2896	.3201	.3772	1.6156
7	.3658	.3688	.3772	.3201	.3658	.4287	2.0119
8	.2896	.3353	.3086		.2896	.3429	2.4863
9	.2715		.2743		.2134	.2743	2.572
10	.2353		.2401	.2401	.2134	.2229	.2058
11	1.5249		1.3032	1.2003	1.1271	1.643	.2058
12	2.7846	2.3739	2.5029	2.7515	2.2211	2.3537	.1715
13	2.536		2.1643	2.4034	2.4034	2.3205	.1715
14	2.4034		1.9966	2.2377	2.0553	2.2377	.1715
15	2.5029		2.1338	2.1382	2.0056	2.2874	.1372
16	2.6189	2.146	2.0881	2.3868	1.7939	2.5029	.1372
17			1.9814	1.9814	2.1262	2.4697	.1543
18	1.8652	2.2043	1.9052	1.89	2.0233	2.1948	.1886
19	.2713		.2591	.3048	.2915	.3201	.3429
20	.3052		.2743	.2439	.3086	.3048	.3601
21	.2683		.1829	.2134	.2743	.2286	.3429
22	.2347		.1829	.1829	.2401	.1981	.2743
23	.2012	.2012	.1524	.1677	.2401	.1829	.2401
24	.1372	.2012	.2012	.1524	.1524	.2058	.7316
Max	2.7846	2.3739	2.5029	2.7515	2.4034	2.5029	2.572
Min	.1372	.2012	.1524	.1524	.1372	.1829	.1372
Avg	.8751	.7452	.8299	.9086	.8133	.9290	.7357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 202 / 11 KV DONGARGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963		.4268	.4268	.442	.4458	.1829
2	.442		.5487	.4877	.5335	.4973	.1829
3	.4877		.695	.5792	.6401	.5144	.1981
4	.6097		.7529	.6859	.7621	.8916	.2286
5	.7468		.9846	.7926	.8535	1.166	.2743
6	.9145		1.1584	1.4632	1.0212	1.2689	.3658
7	1.4175		1.4769	1.768	1.5851	1.6804	.3963
8	1.4632	1.9448	1.5203	1.768	1.6309	1.9204	.3258
9	1.448		1.5203	1.7223	1.5089	1.4769	.2915
10	.2201		.1738	.2286	.2134	.2317	.2058
11	.1677		.1677	.1981	.1677	.2031	1.0631
12	.1829	.2347	.1219	.2134	.1524	.2187	1.4403
13	.1981		.1677	.2134	.1372	.2187	1.4403
14	.1829		.1524	.2286	.1524	.2031	1.4403
15	.2286		.1677	.2286	.1524	.1875	1.4746
16	.2439	.1677	.1524	.2286	.1829	.1718	1.5432
17			.1372	.1981	.2229	.1875	1.5775
18	.3391		.2743	.2286	.2743	.1677	1.5432
19	.3353			.3506	.3086	.3201	.2572
20	.3018		.2896	.3506	.3601	.3201	.3772
21	.2683		.2134	.2896	.3429	.2743	.3772
22	.2012		.1829	.2439	.2915	.2439	.3429
23	.2012	.1966	.1677	.2134	.2229	.1829	.3086
24	.3506	.503	.3932	.381	.381	.4458	.1829
Max	1.4632	1.9448	1.5203	1.768	1.6309	1.9204	1.5775
Min	.1677	.1677	.1219	.1981	.1372	.1677	.1829
Avg	.4934	.6094	.5150	.5620	.5225	.5599	.6675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 203 / 11 KV KHOMNAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0373	.0373	.0187	.0373	.0187
2	.0373		.0373	.0187	.0187	.0373	.0373
3	.0373		.0373	.0373	.0373	.0373	.0373
4	.056		.0373	.0373	.0373	.056	.056
5	.056		.056	.0747	.056	.0686	.0747
6	.112		.056	.112	.0934	.0934	.112
7	.1307		.0934	.112	.1307	.1307	.112
8	.0934	.0934	.0747	.0747	.0934	.0934	.0747
9	.056		.056	.0373	.0373	.0747	.056
10	.056		.0373	.0187	.0373	.056	.0373
11	.0373		.0373	.0189	.0373	.0373	.0373
12	.0187		.0189	.0189	.0189	.0189	.0187
13	.0373		.0187	.0189	.0189	.0189	.0187
14	.0373		.0187	.0189	.0377	.0189	.0187
15	.0373		.0187	.0189	.0189	.0189	.0187
16	.0373	.0362	.0373	.0377	.0377	.0189	.0373
17			.0373	.0373	.0343	.0377	.0373
18	.056		.0373	.0373	.056	.0187	.056
19	.056		.0747	.0747	.0747	.0747	.0747
20	.0747		.0934	.0747	.112	.0934	.0934
21	.0747		.056	.056	.0934	.0747	.0747
22	.056		.0373	.0373	.056	.0373	.056
23	.0373	.0373	.0373	.0373	.0373	.0373	.0373
24	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Max	.1307	.0934	.0934	.112	.1307	.1307	.112
Min	.0187	.0362	.0187	.0187	.0187	.0187	.0187
Avg	.0552	.0511	.0451	.0452	.0513	.0512	.0513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 201 / 11 KV MAULI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 202 / 11 KV NANDESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 203 / 11 KV NANDESHWAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4049
Max	.4049
Min	.4049
Avg	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 201 / DAMAJINAGAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1829	.2054	.1848	.2054	.2614	.2054
2	.1848	.2195	.1867	.1848	.2054	.2801	.2054
3	.2218	.2378	.2054	.2561	.2241	.3326	.2427
4	.2957	.2926	.2801	.3292	.2427	.3696	.2957
5	.3696	.3475	.3511	.3658	.3142	.3921	.3511
6	.4805	.4572	.4251	.4024	.4251	.4108	.4805
7	.5544	.4755	.462	.4706	.5487	.4527	.5175
8	.4066	.4024	.3547		.3881		.4066
9	.2957	.2926	.3174	.3658	.3547		.2587
10	.3326	.2614	.3174	.3326	.3696		.2614
11	.2587	.2801	.2587	.2218	.3326		.2427
12	.2614	.2427	.2241	.2587	.2054		.2614
13	.2614	.2427	.2218	.2772	.2452	.4481	.2054
14	.2218	.2241	.1848	.2957	.2054	.3326	.2241
15	.2218	.2587	.3326	.2957	.2241	.3142	.1886
16	.2957	.2772	.2957	.3326	.2614	.3326	.1886
17	.3292	.2402	.3292	.2772	.2427	.3326	.2641
18	.3841	.2587	.2241	.2587	.2427	.2957	.3361
19	.4207	.3511	.4108	.4251	.3696	.462	.4338
20	.439	.3881	.4805	.499	.3881	.5121	.4338
21	.3292	.3174	.3696	.4251	.3326	.4755	.3734
22	.2926	.2801	.3326	.4066	.3696	.4251	.3361
23		.2427	.2957	.3326	.4066	.3326	.3395
24	.2218	.1848	.2054	.2195	.2241	.2241	.2218
Max	.5544	.4755	.4805	.499	.5487	.5121	.5175
Min	.1848	.1829	.1848	.1848	.2054	.2241	.1886
Avg	.3166	.2899	.3030	.3225	.3053	.3677	.3031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 202 / Mangalwedha A.G. Feeder
(M.I.D Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	1.0059	1.0802	.9614	1.0749	1.1963	.1494
2	1.0631	1.0059	1.1145	.9614	1.0749	1.2346	.1494
3	1.0631	1.0774	1.1269	.9945	1.1269	1.3032	.1867
4	1.1233	1.2431	1.2209	1.094	1.1096	1.406	.2241
5	1.2929	1.3592	1.3226	1.1797	1.2346	1.5604	.2801
6	1.5074	1.6907	1.4413	1.4091	1.56	1.6956	.2957
7	1.7204	1.8515	1.8652	1.8461	1.8143	1.8482	.2957
8	1.9559	2.0809	1.8482		1.9839	1.8945	.2772
9	2.0957	1.9498	1.7465	1.8679	1.95	2.0957	.2218
10	.1478	.168	.168	.2218	.2054	.2218	.2614
11	.1848	.168	.1478	.0185	.168	.2033	1.2763
12	.1867	.168	.1478	.1663	.1867	.2033	1.9784
13	.2054		.1663	.1494	.168	.2218	1.989
14	.1848	.1867	.1829	.1494	.168	.2218	2.0119
15	.1848	.168	.1663	.168	.1867	.2218	1.9669
16	.1848	.168	.1848	.168	.1867	.2033	2.0119
17	.2033	.168	.1829	.1867	.1867	.2033	1.9227
18	.2033	.168	.2033	.1867	.2241	.2218	1.9334
19	.2033	.2427	.2772	.2241	.2801	.2378	.2587
20	.2033	.2614	.2772	.2587	.2957	.2378	.2402
21	.2012	.1867	.2033	.3511	.2033	.2012	.2402
22	.1646	.168	.1646	.3696	.2218	.1848	.2054
23		.1494	.1478	.1867	.3142	.1478	.2241
24	.9114	1.0174	1.0288	.9054	1.0229	1.0802	.1478
Max	2.0957	2.0809	1.8652	1.8679	1.9839	2.0957	2.0119
Min	.1478	.1494	.1478	.0185	.168	.1478	.1478
Avg	.7052	.7240	.6840	.6098	.7061	.7603	.7812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 203 / M.I.D.C. Express Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0185	.0187	.0187	.0187	.0187	.0189
2	.0185	.0185	.0187	.0187	.0187	.0187	.0189
3	.0185	.0185	.0187	.0187	.0187	.0189	.0189
4	.0185	.0185	.0187	.0187	.0187	.0187	.0189
5	.0185	.0185	.0187	.0187	.0187	.0189	.0187
6	.0185	.0185	.0187	.0187	.0185	.0187	.0187
7	.0187	.0185	.0187	.0185	.0185	.0187	.0187
8	.0187	.0185	.0187		.0187		.0187
9	.0187	.0185	.0187	.037	.0187	.0187	.0187
10	.0187	.0189	.0189	.0373	.0189	.0187	.0189
11	.0187	.0189	.0373	.0187	.0189	.0187	.0187
12	.0189	.0189	.0187	.0189	.0189	.0187	.0187
13	.0189	.0189	.0373	.0189	.0189	.0187	.0187
14	.0187	.0189	.0373	.0189	.0189	.0187	.0189
15	.0187	.0189	.0373	.0189	.0189	.0187	.0189
16	.0187	.0189	.056	.0189	.0189	.0187	.0189
17	.0187	.0189	.056	.0189	.0189	.0189	.0187
18	.0187	.0187	.0373	.0189	.0189	.0189	.0187
19	.0187	.0187	.0373	.0189	.0189	.0187	.0189
20	.0185	.0187	.0187	.0189	.0189	.0187	.0189
21	.0185	.0189	.0187	.0189	.0189	.0187	.0189
22	.0185	.0189	.0187	.0189	.0189	.0187	.0189
23		.0189	.0187	.0189	.0189		.0189
24	.0187		.0187	.0187	.0187	.0187	.0189
Max	.0189	.0189	.056	.0373	.0189	.0189	.0189
Min	.0185	.0185	.0187	.0185	.0185	.0187	.0187
Avg	.0186	.0187	.0265	.0204	.0188	.0187	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 201 / DARSHAN MANDAP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3429	.3772	.3429	.3429	.3395	.3258
2	.415	.3429	.415	.3429	.3086	.3395	.3086
3	.4527	.3086	.4338	.3429	.3086	.3772	.3086
4	.4904	.4115	.4527	.4115	.3258	.3772	.3258
5	.4904	.4458	.4904	.4115	.3601	.3772	.3772
6	.5093	.4458	.4904	.4458	.5144	.415	.4973
7	.4904	.4458	.5281	.4458	.463	.415	.4973
8	.463	.3601	.415	.4115	.4287	.4338	.4115
9	.3601	.4115	.4527	.4527	.4338	.3601	.3944
10	.4801	.4458	.5847	.5093	.4715	.3601	.4801
11	.5487	.5316	.6224	.4904	.4904	.4458	.5144
12	.583	.5144	.6602	.4904	.4715	.4115	.6516
13	.583	.4801	.6036	.5281	.6224	.463	.6173
14	.5487	.463	.5658	.4904	.7167	.4458	.6173
15	.583	.4801	.5281	.4715	.679	.4458	.6516
16	.6173	.547	.679	.4527	.679	.4115	.7167
17	.6173	.5847	.6859	.4115	.6036	.4458	.7167
18	.6173	.6224	.6859	.5144	.6413	.4973	.7733
19	.823	.8488	.8916	.6859	.9431	.583	.9619
20	.7202	.7922	.7716	.6859	.811	.6173	.8488
21	.5658	.7167	.6516	.6001	.6413	.5487	.7545
22	.5144	.6602	.463	.4973	.5093	.4458	.5093
23	.4115	.415	.4115	.4287	.415	.4115	.4527
24	.4527	.3429	.3772	.3429	.3601	.3772	.3601
Max	.823	.8488	.8916	.6859	.9431	.6173	.9619
Min	.3601	.3086	.3772	.3429	.3086	.3395	.3086
Avg	.5313	.4983	.5516	.4670	.5225	.4310	.5447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 202 / 11KV GANESHNAGAR SHEDDABLE URBAN
PANDHARPUR Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.583	.5658	.4001	.6516	.7545	.6516
2	.6036	.5144	.5658	.5487	.6001	.7545	.6516
3	.6413	.5144	.6036	.5487	.6001	.7922	.6516
4	.8299	.6173	.6036	.6001	.6001	.7922	.6516
5	.7545	.6516	.6602	.6516	.6173	.8488	.6859
6	.7733	.7202	.7545		.8059	.8676	.7373
7	.9431	.8745	.9242	.8573	.8916	.9242	.9945
8	.8402	.8745	.9619	.9259	.8745	.9242	.8573
9	.823	.7888	.811	.9054	.9054	.8059	.7716
10	.7545	.6859	.7922	.8676	.8676	.6859	.6859
11	.703	.7545	.7733	.811	.7922	.6859	.7202
12	.703	.7202	.7922		.7545	.7202	.7373
13	.7202	.703	.7545	.9054	.7356	.6859	.7373
14	.6516	.6859	.7167	.9997	.7167	.6859	.6859
15	.6516	.6859	.6413	.8676	.7167	.6516	.0686
16	.6516	.7733	.7545	.7733	.7167	.6173	.7922
17	.6516	.7733	.7202	.6859	.7733	.6173	.7167
18	.6516	.7733	.7202	.7373	.811	.6344	.7356
19	.8059	.9619	.8916	.9259	.9431	.8916	.9242
20	.8573	.9997	.8916	.8916	1.0185	.9259	
21	.823	1.0374	.8916	.8916	.9808	.9088	1.0185
22	.7545	.9619	.8573	.8745	.9431	.8745	.9242
23	.7202	.8488	.7716	.7716	.8676	.7545	.9054
24	.5658	.6173	.7922	.6001	.6859	.7922	.6859
Max	.9431	1.0374	.9619	.9997	1.0185	.9259	1.0185
Min	.5658	.5144	.5658	.4001	.6001	.6173	.0686
Avg	.7267	.7550	.7588	.7746	.7862	.7748	.7387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 203 / CABLE EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0377	.0343	.0343	.0377	.0343
2	.0377	.0343	1.1694	.0343	.0343	.0377	.0343
3	.0377	.0343	.0377	.0343	.0343	.0377	.0343
4	.0377	.0343	.0377		.0343	.0377	.0343
5	.0377	.0343	.0377		.0343	.0377	.0343
6	.0377	.0343	.0377	.0343	.0343	.0377	.0343
7	.0377	.0343	.0377	.0343	.0343	.0377	.0343
8	.0343	.0343	.0377	.0343	.0343	.0377	.0343
9	.0343	.0343	.0377	.0377	.0377	.0343	.0343
10	.0343	.0171	.0377	.0377	.0377	.0343	.0343
11	.0343	.0171	.0377	.0377	.0377	.0343	.0343
12	.0343	.0343	.0377	.0377	.0377	.0343	.0343
13	.0343	.0343	.0377	.0377	.0377	.0343	.0343
14	.0343	.0343	.0377	.0377	.0377	.0343	.0343
15	.0343	.0343	.0377	.0377	.0377	.0343	.0343
16	.0343	.0377	.0377	.0377	.0377	.0343	.0377
17	.0343	.0377	.0343	.0343	.0377	.0343	.0377
18	.0343	.0377	.0343	.0343	.0377	.0343	.0377
19	.0343	.0377	.0343	.0343	.0377	.0343	.0377
20	.0343	.0377	.0343	.0343	.0377	.0343	.0377
21	.0343	.4338	.0343	.0343	.0377	.0343	.0377
22	.0343	.0377	.0343	.0343	.0377	.0343	.0377
23	.0343	.0377	.0343	.0343	.0377	.0343	.0377
24	.0377		.0377	.0343	.0343	.0377	.0343
Max	.0377	.4338	1.1694	.0377	.0377	.0377	.0377
Min	.0343	.0171	.0343	.0343	.0343	.0343	.0343
Avg	.0354	.0512	.0839	.0355	.0364	.0356	.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 204 / 11 KV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.2401		.1886	.1886	.2263	.3086	.2229
12	.3601	.3429	.4904	.4715	.415	.3944	.2915
13	.3772	.2572	.4527	.0377	.4527	.4115	.3086
14	.3601	.2743	.4527	.4527	.415	.3772	.3086
15	.3601		.4527	.4338	.3772	.3772	.2286
16	.3772	.415	.3772	.415	.4338	.3772	.415
17	.3772	.415	.3429	.2401	.4527	.3429	.415
18	.3772	.415	.3429	.3429	.415	.2915	.3772
Max	.3772	.415	.4904	.4715	.4527	.4115	.415
Min	.2401	.2572	.1886	.0377	.2263	.2915	.2229
Avg	.3537	.3532	.3875	.3228	.3985	.3601	.3209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 205 / 11 KV SARGAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4458	.5281	.4115	.4287	.4527	.4115
2	.4904	.4115	.5281	.4115	.4115	.4527	.4115
3	.4904	.4458	.5658	.4115	.4115	.4904	.4115
4	.5281	.4458	.5658	.4458	.4115	.4904	.4287
5	.5658	.4801	.5658	.4801	.4458	.5281	.463
6	.6036	.5144	.6036	.4801	.5487	.5281	.5144
7	.6036	.5144	.6036	.5144	.583	.5658	.583
8	.5487	.5144	.5658	.5144	.583	.5658	.5487
9	.5487	.5144	.6036	.5281	.6036	.5487	.5144
10	.6001	.5144	.6602	.5658	.6224	.5144	.583
11	.6516	.5144	.7167	.6036	.5847	.5487	.6516
12	.6173	.5487	.7356	.5847	.5658		.5144
13	.6687	.5658	.6979	.5847	.7167	.583	.6859
14	.5487	.583	.6224	.5658	.7545	.5144	.6859
15	.583	.6687	.5847	.5658	.6979	.5144	.7545
16	.6001	.7356	.6979	.547	.7922	.5144	.7545
17	.583	.7167	.6516	.4801	.8676	.5144	.7167
18	.583		.6173	.5144	.7922	.5144	.7545
19	.6859	.7545	.7888	.6001	.8676	.583	.8299
20	.6516	.7167	.6173	.6516	.7922	.6173	.8299
21	.583	.679	.6173	.6344	.7167	.5658	.7167
22	.583	.679	.583	.6173	.6413	.5144	.6413
23	.583	.6036	.4801	.5487	.6036	.4973	.6413
24	.5281	.4801	.5658	.4458	.463	.5658	.4458
Max	.6859	.7545	.7888	.6516	.8676	.6173	.8299
Min	.4527	.4115	.4801	.4115	.4115	.4527	.4115
Avg	.5784	.5673	.6153	.5295	.6211	.5298	.6039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 206 / 11 KV AMBIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7202	.7922	.7545	.6859	.8299	.7545
2	.7167	.6859	.7922	.7373	.6859	.8299	.7545
3	.7167	.6859	.8676	.6859	.6859	.8676	.7545
4	.7545	.6516	.9054	.823	.7202	.8676	.7888
5	1.1317	.8916	.9431	.8916	.823	.9054	.8573
6	1.3392	1.166	1.226	1.046	1.166	.9431	1.1488
7	1.3014	1.0802	1.3203	1.166	1.2517	1.226	1.2517
8	.9945	.9431	1.0562	.9259	.9602	.9619	.9431
9	.8745	.823	.8676	.9242	.9431	.823	.8573
10	.823	.7202	.8865	.9997	.9054	.7716	.7888
11	.7716	.7888	.9431	1.0185	.9619	.7202	.7888
12	.7888	.8573	.8865	.9242	.9242	.7202	.8402
13	.823	.823	.8676	.8865	.9242	.7716	.8745
14	.8059	.8059	.811	.9054	.8676	.7373	.8916
15	.7888	.7888	.7733	.8488	.9242	.7545	.6516
16	.7716	.8865	.9242	.7922	.9619	.7716	.9431
17	.8402	.8676	.8745	.6687	.9997	.8059	.9997
18	.9259	1.0185	.9602	.7716	1.1128	.8402	1.1506
19	1.1488	1.226	1.1831	.9945	1.3392	1.1145	1.3769
20	1.1145	1.2449	1.1488	1.0117	1.2826	1.166	1.3392
21	.9602	1.1506	1.046	.9774	1.1317	1.0631	1.2071
22	.8402	1.0374	.9259	.9431	1.0562	.9602	1.0751
23	.8059	.9242	.8402	.8573	.9997	.8573	.9808
24	.8669	.7373	.7922	.7545	.7202	.9054	.7716
Max	1.3392	1.2449	1.3203	1.166	1.3392	1.226	1.3769
Min	.7167	.6516	.7733	.6687	.6859	.7202	.6516
Avg	.9025	.8969	.9431	.8879	.9597	.8839	.9496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 201 / 11 KV Manisha Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4805	.4458	.4458	.4801	.4973	.463
2	.4458	.4435	.4287	.4287	.463	.463	.4458
3	.4115	.5175	.4115	.4287	.4458	.4458	.4458
4	.4115	.5914	.4458	.4287	.4458	.4458	.4458
5	.5487	.5914	.4973	.4458	.5316	.4973	.5144
6	.583	.6283	.5658	.5658	.6344	.5487	.6001
7	.703	.6838	.6516	.6173	.7545	.6687	.703
8	.7373	.7762	.823	.703	.7373	.7545	.7545
9	.6859	.7207	.6859	.7373	.7023	.7392	.6859
10	.5144	.6173	.6283	.5914	.5175	.6099	.5914
11	.4973	.463	.5544	.5544	.4805	.5914	.5544
12	.463	.4115	.5359	.5175	.499	.5359	.5359
13	.4458	.4287	.5175	.499	.499	.4801	.499
14	.4287	.4287	.499	.5359	.4805	.4458	.5175
15	.463	.4287	.5544	.462	.499	.4973	.5359
16	.4458	.4973	.499	.499	.5175	.463	.5175
17	.4458	.4887	.5249	.5068	.5068	.5068	.4887
18	.4973	.543	.5611	.5249	.5792	.5611	.5611
19	.6173	.7059	.724	.6878	.7602	.7421	.8326
20	.6516	.7421	.7421	.724	.7602	.7602	.7964
21	.6344	.7059	.7421	.724	.724	.7059	.7964
22	.6653	.6878	.6697	.724	.6687	.7059	.7964
23	.5914	.5658	.5487	.6001	.6001	.6173	.7762
24	.6068	.499	.4801	.4973	.5144	.5316	.4801
Max	.7373	.7762	.823	.7373	.7602	.7602	.8326
Min	.4115	.4115	.4115	.4287	.4458	.4458	.4458
Avg	.5392	.5686	.5724	.5604	.5751	.5756	.5974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 202 / 11KV PANI PURWATHA EXP. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4066	.2743	.2229	.2401	.2229	.2229
2	.4458	.5729	.3258	.2229	.2401	.2229	.2229
3	.6001	.7762	.3258	.3086	.4458	.4801	.3772
4	.8745	.8871	.4115	.4287	.6516	.7716	.5487
5	.8059	1.0349	.5144	.6516	.7545	.8402	.6001
6	.583	.961	.6516	.6516	.9259	.9602	.6687
7	.583	.9979	.6516	.6516	.9431	.9602	.6344
8	.583	.9795	.6173	.6173	.9259	.6516	.6516
9	.5487	.961	.463	.583	.961	.6653	.6001
10	.5658	.8573	.6838	.6283	.9795	.6468	.6838
11	.5144	.8916	.5914	.6468	.9425	.5544	.6653
12	.5144	.8745	.5729	.6099	.961	.4251	.6283
13	.4973	.8573	.5914	.7762	.924	.5487	.5914
14	.463	.8745	.6099	.924	.9979	.5658	.5914
15	.2915	.8573	.6283	.8871	.924	.5144	.6099
16	.4115	.7202	.499	.6468	.7762	.6001	.462
17	.4115	.9149	.2987	.6535	.9709	.6348	.6908
18	.3772	.5041	.112	.4294	.4481	.4294	.3921
19	.3429	.4668	.2614	.2427	.2427	.3921	.4481
20	.3086	.2241	.5041	.2241	.2241	.2241	.2054
21	.2401	.2241	.3174	.2241	.2241	.2241	.2241
22	.2587	.2241	.2614	.3734	.3258	.2241	.2218
23	.4066	.3772	.3601	.3429	.3429	.3601	.5544
24	.5201	.499	.2401	.2229	.2401	.2401	.2401
Max	.8745	1.0349	.6838	.924	.9979	.9602	.6908
Min	.2401	.2241	.112	.2229	.2241	.2229	.2054
Avg	.4773	.7060	.4486	.5071	.6505	.5150	.4890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 203 / 11 KV ISBAWI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7392	.7202	.7888	.7888	.7888	.7888
2	.6859	.6283	.6687	.6859	.703	.7545	.8059
3		.961	.6687	.6516	.6516	.7202	.7545
4	.6516	1.0349	.7545	.6516	.6001	.703	.6859
5	.8916	1.1088	.8916	.703	.7888	.8059	.823
6	.9431	1.0719	.9774	.8916	.9602	.9088	.9431
7	.9945	1.1088	1.1831	1.046	1.1145	1.046	1.1317
8	1.0288	1.0534	1.1831	1.0631	1.0288	.9602	.9431
9	.9945	1.1273	1.046	1.0117	1.0719	.8871	.8573
10	.8059	.9945	.961	.8131	.924	.8686	.8316
11	.703	.8059	.8871	.7947	.8871	.8131	.8501
12	.7888	.8573	.8501	.8501	.8686	.8316	.8686
13	.7202	.8573	.8131	.7762	.7762	.823	.7762
14	.463	.823	.7947	.7577	.7947	.7545	.7577
15	.7888	.8402		.7392	.8131	.7716	.7947
16	.7888	.7888	.8131	.7762	.9055	.7202	.7392
17	.823	1.0164	.924	.9425	1.0903	.924	.8871
18	.8916	.9979	.961	.961	1.1458	.924	.9795
19	.8916	1.2012	1.1088	1.1643	1.386	1.0719	1.2752
20	.9431	1.2012	1.1273	1.1458	1.2752	1.0903	1.2382
21	.9259	1.1458	1.1827	1.1088	1.1827	1.1088	1.1458
22	1.0534	1.0164	1.0534	1.0903	1.0631	1.0534	1.1273
23	.8871	.8745	.8916	.8745	.9774	.9259	.8871
24	.7888	.8131	.7545	.7888	.8402	.823	.8059
Max	1.0534	1.2012	1.1831	1.1643	1.386	1.1088	1.2752
Min	.463	.6283	.6687	.6516	.6001	.703	.6859
Avg	.8321	.9611	.9224	.8782	.9432	.8783	.9041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 402 / 33KV Bandishegaon
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2984	8.4271	8.4362	8.642	8.4362	8.5905	8.3333
2	5.8642	9.6468	8.8477	8.8477	8.7963	9.105	8.642
3	6.4301	9.2587	9.0021	9.0535	9.0535	9.5165	8.8992
4	10.2881	10.4784	9.3622	9.3622	9.3107	10.0823	9.105
5	10.8539	13.4168	9.9794	10.2366	9.465	10.3395	9.3622
6	11.7799	14.5256	10.9568	11.2654	9.1564	9.105	9.7737
7	13.4774	14.8028	13.0659	13.1687	11.1111	10.391	10.0309
8	13.8375	14.3593	7.2017	13.0144	10.4424	12.8601	12.0885
9	12.8601	13.4722	10.0309	6.07	10.3675	8.3162	10.8539
10	1.9547	1.3889	1.7187	1.8296	1.6078	1.9959	1.8296
11	3.4979	3.4979	8.8706	8.9815	6.653	9.7022	3.1602
12	10.3395	7.1502	11.5318	10.9774	11.5872	11.4764	3.5482
13	10.2881	11.4198	10.0903	9.924	9.8131	10.8025	
14	10.5453	11.3169	6.9856	10.423	11.6981	10.8539	4.6571
15	8.7963	9.105	6.154	8.3162	9.8131	8.7963	7.7063
16	10.2881	9.5165	9.8686	9.8686	10.423	9.2078	1.4415
17	11.0597	11.9199	10.9774	11.3655	11.8644	11.31	1.386
18	5.0412	5.4887	7.2074	4.1581	5.2115	4.9897	1.6078
19	2.9835		2.9938	3.1047	3.4928	3.1602	3.2156
20	2.9321	3.4928	3.1602	3.3265	3.8255	3.6037	3.6037
21	2.9321	3.0493	2.9384	2.9384	3.3819	3.0493	3.271
22	2.7721	2.7166	2.6057	2.7721	2.8807	2.9938	2.9938
23	2.6057	2.4691	2.2634	2.4177	2.7778	2.6235	2.7166
24	11.1991	8.0944	8.2305	8.179	8.2305	8.2305	7.9733
Max	13.8375	14.8028	13.0659	13.1687	11.8644	12.8601	12.0885
Min	1.9547	1.3889	1.7187	1.8296	1.6078	1.9959	1.386
Avg	7.8302	8.6528	7.6033	7.8435	7.8916	7.9626	5.9217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 276001 / 110/11 KV PANDHARPUR

Feeder No / Name : 203 / 11 KV VITHAL MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 276001 / 110/11 KV PANDHARPUR

Feeder No / Name : 207 / 11 KV WATER WORKS

SHEDDABLE URBAN

PANDHARPUR Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8316
Max	.8316
Min	.8316
Avg	.8316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 201 / 11KV Bhalwani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2218	.1677	.2033	.1524	.2218	.1981
2	.2058	.2218	.1677	.2033	.1524	.2218	.1981
3	.2058	.2218	.1677	.2033	.1524	.2218	.1981
4	.2743	.2772	.1677	.2033	.1829	.2772	.1981
5	.3429	.2957	.1981	.2957	.2439	.2957	.2439
6	.3429	.3326	.2286	.3511	.3048	.3326	.3429
10	2.652	2.1879	2.2045	2.1548	2.1879	2.572	2.452
11	2.652	2.1714	2.2542	1.989	2.2045		
12	2.6023	1.8138	2.1879	2.0388	2.0719	2.0576	
13	2.4863		1.6575	1.8233	1.989	2.2977	
14	2.1548		1.5083	1.6575	1.8233	2.0576	
15	2.0885	1.5394	1.4586	1.6244	1.6575	1.7833	
16	2.1548	2.1186	1.7238	1.7071	1.8233	1.6156	
17	2.4863	1.7223	1.8399	1.6004	1.9062	1.5546	2.7018
18	.2402	.1524	.2033		.2155	.1524	.1848
19	.2772	.1829	.2587	.1524	.2772	.2134	.2772
20	.3326	.2134	.2957	.2134	.3142	.2439	.3511
21	.2587	.1829	.2587	.1829	.2957	.2134	.3142
22	.2402	.1829	.2218	.1829	.2772	.1981	.2587
23	.2218	.1829	.2033	.1829	.2402	.1981	.2402
24	.2058	.2218	.1677	.2033	.1524	.2218	.1981
Max	2.652	2.1879	2.2542	2.1548	2.2045	2.572	2.7018
Min	.2058	.1524	.1677	.1524	.1524	.1524	.1848
Avg	1.0777	.7602	.8353	.8587	.8869	.8475	.5572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 202 / 11KV Jainwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	1.2483	1.1126	1.335	1.326	1.1603	.9907
2	.4458	.462	.3658	.462	.3658	.499	.3658
3	.4458	.462	.3658	.462	.3658	.499	.3658
4	.463	.499	.4268	.4805	.3658	.499	.3658
5	.4801	.5175	.4268	.5914	.4268	.5175	.4268
6	.5144	.5544	.4572	.6283	.4877	.5544	.4877
7	.5144	.5544	.4877	.7207	.4877	.5544	.4877
8	.5144	.5544	.4572	.7392	.4572	.5544	.4877
9	.5144	.5175	.4572	.5914	.4572	.5544	.5144
16	.3696	.4268	.5175	.4115	.4251		
17	.3696	.4268	.5175	.3353	.4435	.3048	.3696
18	2.8178	2.4387	2.93	2.4387	2.8178	2.5911	2.8178
19	2.4863	2.2862	2.6873	2.1033	2.652	2.2862	2.4863
20	2.3205	2.1338		1.7833	2.0719	1.7833	1.9062
21	1.989	1.829	1.8378	1.5242	1.8233	1.448	1.4918
22	1.6575	1.5242	1.5604	1.448	1.4918	1.2346	1.1603
23	1.6575	1.5242	1.4737	1.3717	1.2431	1.0669	1.1603
24	.4458	1.5604	1.3717	1.387	1.3717	1.1603	1.0364
Max	2.8178	2.4387	2.93	2.4387	2.8178	2.5911	2.8178
Min	.3696	.4268	.3658	.3353	.3658	.3048	.3658
Avg	1.0251	1.0844	1.0266	1.0452	1.0600	1.0157	.9954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 203 / 11 KV KESKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.1294	.0914	.1109	.0914	.1294	.1067
2	1.0288	1.1603	.945	1.0608	.9145	.9945	.9907
3	1.0288	1.326	.945	1.0608	.9145	.9945	.9907
4	1.2003	1.6575	1.0364	1.1271		1.094	1.0669
5	1.2003	1.6575	1.2193	1.3592	1.3565	1.4918	1.2803
6	1.3203	1.6907	1.5851	1.6409	1.6004	1.6575	1.5089
7	1.8861	1.8233	1.7985	2.0553	1.9052	1.8233	1.89
8	1.9719		1.8595	1.9062	1.768	1.989	1.6461
9	1.7147	1.7238	1.6766	1.9062	1.1431	1.6907	1.7318
16	.0739	.0914	.1294	.1219	.1294	.061	
17	.0924	.1067	.1294	.1219	.1294	.0762	.1848
18	.1478	.0914	.1294	.1219	.1848	.0914	.1848
19	.1478	.1219	.1478	.1524	.2033	.1219	.2218
20	.1663	.1219	.1663	.1524	.1848	.1543	.2218
21	.1663	.1219	.1663	.1219	.1848	.1372	.1848
22	.1294	.1219	.1478	.1219	.1663	.1219	.1478
23	.1294	.0914	.1109	.1067	.1294	.1219	.1478
24	.181	.1294	.0914	.1109	.0914	.1294	.1219
Max	1.9719	1.8233	1.8595	2.0553	1.9052	1.989	1.89
Min	.0739	.0914	.0914	.1067	.0914	.061	.1067
Avg	.7564	.7157	.6875	.7422	.6528	.7156	.7428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 204 / 11 KV BHALWANIN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3067	.3102	.381	.3239	.3201	.3567	.3658
2	.3067	.3102	.3334	.3239	.3201	.3567	.3658
3	.3944	.306	.3467	.3239	.3467	.3864	.3201
4	.3601	.3841	.4534	.4016	.4268	.4755	.4268
5	.4268	.4268	.5601	.582	.5868	.6539	.6135
6	.723	.6478	.7621	.6563	.6059	.743	.6668
7	.6704	.6737	.5868	.6687	.5487	.7727	.5868
8	.5335	.5182	.4801	.4595	.4934	.5944	.5201
9	.3467	.4146	.3734	.4607	.3734	.4755	.3864
10	.3567	.3681	.2743	.4144	.3246	.3334	.2972
11	.3121	.2921	.2881	.3269	.2705	.2667	.2972
12	.3121	.2782	.2503	.2378	.2679	.2667	.2378
13	.2972	.2961	.2364	.2675	.2972	.2667	.2675
14	.2972	.282	.2397	.2972	.2675	.2401	.2378
15	.3269	.2397	.2397	.2824	.2957	.2401	.2526
16	.2972	.2401	.2606	.2801	.3696	.2401	.2526
17	.2972	.3467	.3246	.3658	.4435	.2667	.2972
18	.4904	.3734	.3201	.5487		.5182	.3269
19	.535	.4801	.5182	.5601	.639	.5601	.5053
20	.6687	.5868	.583	.6001	.6836	.5335	.639
21	.535	.5068	.4601	.5201	.5944	.3467	.5053
22	.4161	.4001	.4134	.4801	.5201	.3201	.4607
23	.3567	.3734	.3601	.4001	.3864	.3201	.3864
24	.3944	.3243	.3334	.3239	.3201	.3567	.3201
Max	.723	.6737	.7621	.6687	.6836	.7727	.6668
Min	.2972	.2397	.2364	.2378	.2675	.2401	.2378
Avg	.4151	.3908	.3908	.4211	.4218	.4121	.3973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 205 / 11 KV CHOUGHULEWADI SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1294	.1219	.1478	.1219	.1478	.1219
2	.12	.1294	.1219	.1478	.1219	.1478	.1219
3	.12	.1294	.1219	.1478	.1219	.1478	.1219
4	.1372	.1294	.1219	.1848	.1372	.1848	.1372
5	.1715	.2218	.1524	.2402	.1829	.2218	.1524
6	.1734	.2587	.2134	.2772	.2134	.2772	.1981
10	2.4863	2.3868	2.1548	2.3205	2.1382	2.4006	2.2291
11	2.5029	2.42	2.1548	2.3205	2.1051	2.0119	
12	2.3703	2.4034	2.1548	1.989	1.9725	1.829	
13	2.2377	2.1382	1.989	1.6575	1.8233	1.7223	
14	2.1548	2.0719	1.6575	1.6575	1.6575	1.5242	
15	2.0719	1.989	1.6575	1.6575	1.6575	1.4937	
16	2.1548	2.1714	1.8233	1.6766	1.6575	1.5394	
17	2.2211	1.8442	1.8233	1.7833	1.8233	1.7528	2.4697
18	.1326	.1219	.1294	.1219	.1478	.1219	.116
19	.1478	.1524	.1663	.1524	.1848	.1524	.1848
20	.1848	.1524	.2033	.1829	.1848	.1524	.2033
21	.1478	.1524	.1848	.1524	.1848	.1524	.1478
22	.1294	.1219	.1663	.1524	.1848	.1219	.1478
23	.1294	.1219	.1663	.1219	.1478	.1219	.1478
24	.12	.1294	.1219	.1478	.1219	.1478	.1219
Max	2.5029	2.42	2.1548	2.3205	2.1382	2.4006	2.4697
Min	.12	.1219	.1219	.1219	.1219	.1219	.116
Avg	.9540	.9226	.8289	.8209	.8043	.7796	.4414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 206 / 11 KV GARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	1.2193	1.2193	1.2431	1.2193	1.0669	1.0669
2	.1829	.1829	.1829	.2218	.2134	.1829	.2134
3	.2286	.1829	.1829	.2218	.2134	.1829	.2134
4	.3048	.2286	.1829	.2587	.2439	.2439	.2134
5	.3048	.2743	.2439	.3142	.2743	.2743	.2743
6	.4268	.3048	.3048	.3696	.3048	.3048	.3048
7	.3048	.3048	.2743	.3696	.3048	.3048	.3048
8	.2286	.3048	.2743	.3696	.3048	.3048	.3048
9	.1524	.1524	.3048	.1524	.2439	.2286	.2957
16	.1524	.1981	.2218			.1219	
17	.1524	.1981	.2218	.1524		.1524	.1109
18	1.2193	2.5911	2.7349	2.4387		2.4387	2.652
19		2.4387	2.4863	2.1338		2.2862	2.4863
20	1.5242	2.1338	2.2377	1.9814		1.829	1.4918
21	2.1338	1.9814	1.8233	1.6766		1.5242	1.326
22	1.9814	1.5242	1.5746	1.5242		1.3717	1.1603
23	1.5242	1.3717	1.4918	1.3717		1.3717	1.1603
24	.4715	1.2193	1.2193	1.326	1.2193	1.0669	1.2193
Max	2.1338	2.5911	2.7349	2.4387	1.2193	2.4387	2.652
Min	.1524	.1524	.1829	.1524	.2134	.1219	.1109
Avg	.6750	.9340	.9545	.9486	.4542	.8476	.8705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 207 / 11 KV SATPUTEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.1848	.1829	.1848	.1524	.1791	.1524
2	1.0288	1.4918	1.2803	1.3923	1.2498	1.3592	1.2193
3	1.0288	1.4918	1.2803	1.4255	1.2498	1.3592	1.2193
4	1.2003	1.6575	1.3717	1.4918	1.3413	1.4918	1.3413
5	1.3717	1.989	1.5242	1.7238	1.5242	1.6575	1.4327
6	1.5089	2.3205	1.8595	1.989	1.6766	1.8564	1.6156
7	2.5377	2.3205	2.1948	2.3537	2.0119	1.9559	2.1033
8	2.0576	2.4863	2.4387	2.6189	2.2862	2.0553	2.2862
9	1.7147	2.1879	2.1338	2.1216	1.9204	2.0553	2.0553
15		.1478					.0191
16	.1109	.1219	.1848	.1219	.1848	.0914	
17	.1109	.1219	.2033	.1524	.1848	.0914	.1109
18	.1294	.1829	.2033	.1524	.2218	.1219	.1848
19	.1478	.2134	.2218	.1829	.2218	.1524	.2587
20	.2587	.2286	.2402	.2286	.2957	.1829	.2957
21	.2587	.2134	.2218	.1829	.2587	.1524	.2587
22	.1848	.1829	.1848	.1524	.2218	.1524	.2218
23	.1848	.1829	.1848	.1524	.1848	.1524	.2218
24	.4525	.1848	.1829	.1848	.1524	.1848	.1524
Max	2.5377	2.4863	2.4387	2.6189	2.2862	2.0553	2.2862
Min	.1109	.1219	.1829	.1219	.1524	.0914	.0191
Avg	.8604	.9427	.8941	.9340	.8522	.8473	.8416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 201 / 11 KV SHELAVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3086	.381	.4287	.4287	.4801	.5144
2	.4191	.3086	.381	.4287	.4287	.5144	.5144
3	.4191	.3429	.381	.4287	.4287	.5144	.5144
4	.4382	.3429	.4191	.4287	.4287	.5144	.5144
5	.4572	.3772	.4382	.4458	.463	.5144	.5144
6	.4763	.3944	.4763	.463	.4801	.5144	.381
11		2.8978	2.5034	2.0576	2.7949	2.915	
12	3.2579	3.3379	3.3532	3.5151	3.6008	3.2579	
13	3.1703	3.5361	3.4751	3.1722	3.9781	3.618	
14	2.8959	3.4446	3.2465	3.1722	3.6008	3.7723	
15	3.6008	3.738	3.0483	3.5151	3.5151	3.4294	3.5246
16	3.6694	3.0483	3.2312	3.7723	3.6351	3.7723	
17	3.6866	3.7342	3.1855	4.0771	3.2007	3.6008	
18	3.6008	3.7342	2.8654	3.7151	3.2007	3.7723	
19		.2858					.3944
20	.2572	.4763	.4287	.4763	.4001	.4954	.4763
21	.3086	.4763	.4287	.4763	.5525	.5716	.5716
22	.3429	.4763	.4287	.4763	.5716	.5716	.5716
23	.3086	.4763	.4287	.4763	.5716	.5716	.5716
24	.4191	.2743	.4191	.4287	.4287	.3944	.5144
Max	3.6866	3.738	3.4751	4.0771	3.9781	3.7723	3.5246
Min	.2572	.2743	.381	.4287	.4001	.3944	.381
Avg	1.5637	1.6006	1.5536	1.6818	1.7215	1.7787	.7367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 202 / 11 KV UPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.5432	1.6194	1.7147	1.4575	1.8176	2.1605
2	1.9052	1.6289	1.7147	1.8861	1.5432	2.1091	2.1605
3	2.0005	1.7147	1.8099	1.8861	1.6289	2.1091	2.1605
4	2.0957	1.8004	1.9052	2.0576	1.7147	2.2291	2.2291
5	2.191	1.8861	2.0005	2.0576	1.8861	2.4006	2.2634
6	2.2862	1.8861	2.191	2.2291	.1715	2.6749	2.4387
7	2.7625	2.572	2.8578	2.4006	.1715	2.7778	2.4691
8	2.8578	2.4006	.1905	2.572	.1715	2.915	2.4387
9	2.4006	2.4006	.1905	2.4006	.1715	2.5034	2.1643
19	.1543	.381	.0381	.381	.2286	.4191	.3429
20	.1715	.381	.0381	.2858	.381	.381	.2858
21	.1886	.3429	.2058	.2858	.381	.2667	.2667
22	.1715	.2858	.2058	.2477	.2477	.2477	.2477
23	.1543	.2286	.1886	.1905	.2096	.2477	.2286
24	1.7147	1.4575	1.5242	1.5432	1.4575	1.749	1.749
Max	2.8578	2.572	2.8578	2.572	1.8861	2.915	2.4691
Min	.1543	.2286	.0381	.1905	.1715	.2477	.2286
Avg	1.5243	1.3940	1.1120	1.4759	.7881	1.6565	1.5737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 203 / 11 KV BHANDISHEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.2291	2.3815	2.0576	2.3339	1.8519	1.8861
2	2.6673	2.4006	2.4768	2.2291	2.1434	2.0576	1.8861
3	2.8578	2.572	2.6673	2.2291	2.2291	2.0576	1.8861
4	2.9531	2.8292	2.8578	2.3148	2.3148	2.0576	2.2634
5	3.0483	2.915	2.9531	2.4006	2.4863	2.6749	2.4387
6	3.3341	2.915	3.0483	2.7435	2.6578	2.9492	2.774
7	3.8104	3.2579	3.6199	3.2236	3.2579	3.0521	2.8197
8	3.7151	3.4294	3.5246	3.2579	3.0864	3.1893	2.9835
9	3.0864	3.1379	2.8197	2.8121	2.915	2.9835	2.7092
19	.2572	.3429	.3429	.4382	.3429	.4001	.3944
20	.3086	.381	.381	.4382	.4191	.4191	.4191
21	.3429	.3429	.2743	.381	.381	.3048	.3429
22	.3429	.2858	.2572	.2858	.2667	.2858	.3239
23	.2743	.2286	.2401	.2477	.2286	.2667	.3048
24	2.4768	2.0576	2.2862	2.0576	2.1434	1.7661	1.749
Max	3.8104	3.4294	3.6199	3.2579	3.2579	3.1893	2.9835
Min	.2572	.2286	.2401	.2477	.2286	.2667	.3048
Avg	2.1365	1.9550	2.0087	1.8078	1.8138	1.7544	1.6787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 204 / 11 KV WADIKUROLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.2286	.2401	.1715		
2	.1905	.1715	.2286	.2401	.1715		
3	.1905	.1715	.2286	.2401	.1715		
4	.2286	.1886	.2477	.2572	.2058		.2667
5	.2477	.2058	.2667	.2572	.2401	.2401	.2667
6	.2858	.2229	.2858	.2572	.2572	.2401	.2667
11		2.915	2.1605	2.4006	2.7778	2.7435	
12	3.0178	3.0483	3.0178	3.4294	3.4294	3.3093	
13	2.8197	3.1245	3.094	3.0864	3.6008	3.4465	
14	2.6368	3.094	3.4808	3.3436	3.4808	3.5151	
15	3.0864	3.4294		3.3951	3.3608	3.4294	3.5627
16	3.1722	3.1093	3.4294	3.3093	3.3093	3.2236	
17	3.0864	2.9874	3.2579	3.8295	2.9111	3.1722	
18	3.1722	2.9569	3.2922	3.7151	2.8654	3.2236	
19		.2858	.2096				.2229
20	.1543	.2858	.2477	.2667	.1143	.2477	.3048
21	.1543	.2667	.2229	.2667	.1143	.2858	.2858
22	.1715	.2477	.2229	.2477	.1143		.2667
23	.1715	.2286	.2401	.2286			.2477
24	.4715	.1543	.2286	.2401	.1715		
Max	3.1722	3.4294	3.4808	3.8295	3.6008	3.5151	3.5627
Min	.1543	.1543	.2096	.2286	.1143	.2401	.2229
Avg	1.3027	1.3633	1.2942	1.5395	1.5260	2.2564	.6323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 205 / 11 KV BHANDISHEGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7716	.6668	.5658	.5487	.5487	.6001
2	.5487	.6859	.6668	.5658	.5487	.5487	.6001
3	.6001	.6859	.7621	.583	.583	.583	.703
4	.6859	.7716	.8573	.6173	.6859	.7202	.823
5	.8916	.9431	.9526	.7373	.8573	.8402	.8916
6	1.2003	1.0288	1.1431	1.0288	1.1145	1.0802	1.046
7	1.0288	.8573	.9526	.8573	.8573	.9088	.8916
8	.8059	.7545	.8573	.7545	.7716	.8573	.7202
9	.7716	.6516	.6859	.7202	.6001	.703	.6001
10	.5487	.5144	.5144	.5316	.5144	.6516	.5716
11	.5487	.3963	.3944	.4115	.4115	.5144	
12	.5144	.3944	.3944	.3772	.4287	.3944	
13	.5316	.3944	.3772	.3772	.4115	.3772	
14	.5316	.4191	.3429	.3772	.3429	.3944	.5335
15	.5487	.3601	.4115	.3944	.4801	.4115	.5144
16	.6173	.4458	.3944	.463	.4287	.4115	.5335
17	.7373	.5144	.5316	.5335	.463	.3944	.5716
18	.6859	.6001	.6001	.6668	.5487	.6001	.5658
19	.8573	.9526	.7716	.8573	.8745	.823	.823
20	.9945	1.0479	.8916	.8954	.9088	.9259	
21	.9431	.9526	.7888	.8573	.823	.7888	.7716
22	.9088	.8573	.7545	.7621	.7373	.6687	.6859
23	.8573	.6859	.6859	.6287	.6173	.6001	.6516
24	.5487	.823	.6668	.583	.5487	.5487	.6001
Max	1.2003	1.0479	1.1431	1.0288	1.1145	1.0802	1.046
Min	.5144	.3601	.3429	.3772	.3429	.3772	.5144
Avg	.7273	.6879	.6694	.6311	.6294	.6373	.6849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 206 / 11 Kv Supali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8573	.9907	.8573	.7716	.8573	.8573
2	.8916	.9088	1.0098	.9088	.7716	.8573	.8573
3	.9259	.9431	1.0479	.9431	.8059	.8573	.8916
4	.9602	.9945	1.086	.9431	.8573	.8916	.8916
5	.9945	.9945	1.105	.9602	.8916	1.166	.8916
6	1.0288	.9945	1.1431	.9774	.9945	1.2346	1.2003
7	1.286	1.2346	1.4289	1.2003	1.2003	1.2003	1.2346
8	1.3717	1.2346	1.4289	1.2003	1.1145	1.3032	1.1145
9	1.3717	1.2517	1.0669	1.166	1.1145	1.1145	1.046
19	.0686	.0762	.0762	.0953	.0762	.0953	.1029
20	.0171	.0762	.0762	.0686	.0762	.0953	.0953
21	.0514	.0762	.0686	.0686	.1143	.0953	.0953
22	.0514	.0762	.0686	.0686	.0953	.0762	.0762
23	.0514	.0762	.0686	.0514	.0762	.0762	.0762
24	.4525	.7716	.9907	.8573	.7716	.823	.823
Max	1.3717	1.2517	1.4289	1.2003	1.2003	1.3032	1.2346
Min	.0171	.0762	.0686	.0514	.0762	.0762	.0762
Avg	.6943	.7044	.7771	.6911	.6488	.7162	.6836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 207 / TEJUS AGRO EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.3086	.4382			.3944	.3048
2	.1143	.3086	.4191			.4801	.3239
3	.1334	.3086	.4191			.4287	.3239
4	.1143	.3258	.4382			.4287	.3429
5	.1334	.3429	.4763			.4458	.381
6	.1143	.3429	.4763		.0514	.5144	.4001
7	.2096	.3086	.4191			.4973	.3429
8	.1334	.3258	.2286			.5316	.2477
9	.1524	.3772	.0572			.3429	.2667
10	.1143	.3944			.12	.3429	.0953
11	.1905	.2915			.1715	.3944	.1905
12	.3429	.4801			.2058	.4115	.2667
13	.4115	.5316			.12	.3601	.2477
14	.4572	.4801			.1543	.3601	.2667
15	.4115	.4801			.5144	.3429	.1905
16	.4801	.4572			.4458	.3944	.2477
17	.4458	.5487			.4801	.3772	.2667
18	.3429	.4115			.4801	.2743	.2743
19	.3429	.3239		.0572	.3944	.2915	.1715
20	.3429	.3239		.0514	.4572	.3944	.1905
21	.3258	.3429		.0514	.381	.4287	.1905
22	.3258	.3239			.381	.4382	.1524
23	.3258	.3048		.0514	.4191	.3239	.1715
24	.1905	.3258	.4191			.3601	.381
Max	.4801	.5487	.4763	.0572	.5144	.5316	.4001
Min	.1143	.2915	.0572	.0514	.0514	.2743	.0953
Avg	.2628	.3737	.3791	.0529	.3184	.3983	.2599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 201 / 11 KV KALERAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4344
Max	.4344
Min	.4344
Avg	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 202 / 11 KV AMBE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4715
Max	.4715
Min	.4715
Avg	.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 203 / 11 Kv Ranzani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4344
Max	.4344
Min	.4344
Avg	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 204 / 11 KV CHALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.3048	.5335	.4572	.4572	.381
2	.4572		.3048	.6097	.4572	.4572	.381
3	.4572	.4572	.3048	.5335	.6097	.6097	.6097
4	.6859	.6859	.3048	.6097	.6859	.6859	.6097
5	.7621	.6859	.3048	.8383	.9145	.9145	.9145
6	.9145	.9907	.7621	.7621	.9145	.9145	.9145
7	.7621	.9907	.7621	.6859	.9145	.9145	.9145
8	.6097	.9907	.4572	.6859	.9145	.9145	.7621
9	.6097	.4572	.4572	.5335	.4572	.6097	.6097
10	.4572	.6859	.4572	.4572	.4572	.4572	.4572
11	.4572	.3048	.3201	.3048	.381	.381	.3201
12	.3048	.3048	.3506	.3048	.381	.381	.381
13	.3048	.3048	.3353	.3048	.381		.381
14	.3048	.3048	.381	.3048	.381	.3048	.3048
15	.4572	.3048	.381	.3048	.3048	.3048	.381
16		.3048	.381	.381	.3048		.4572
17	.4572	.4572	.381	.381	.4572	.6097	.503
18	.6859	.4572	.6097	.381	.4572	.6097	.6097
19	.6859	.6097	.6859	.7621	.6859	.7621	.6097
20	.6859	.6097	.9145	.7621	.7621	.7621	.6859
21	.6859	.6097	.9907	.7621	.6097	.6097	.9907
22	.4572	.6097	.7621	.6097	.6097	.4572	1.0822
23	.4572	.4572	.381	.4572	.4572	.381	.3048
24	.4572	.4572	.3048	.381	.4572	.4572	.381
Max	.9145	.9907	.9907	.8383	.9145	.9145	1.0822
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.5467	.5473	.4833	.5271	.5588	.5889	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 205 / 11 Kv Chale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4525
Max	.4525
Min	.4525
Avg	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 206 / 11 KV DARLING

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.6097
2	.0762	.0762	.0762	.0762	.0762	.0762	.6097
3	.0762	.0762	.0762	.0762	.0762	.0762	.6097
4	.0762	.0762	.0762	.0762	.0762	.0762	.6097
6							1.0669
7							1.0669
8							1.0669
9							1.0669
11	1.0669	.9145	.7621	.9145	.7621	.7621	
12	1.3717	1.3717	1.0669	.9145	1.0669	1.0669	
13	1.3717	1.3717	1.0669	1.0669	1.0669	1.2193	
14	1.3717	1.2193	1.0669	1.0669	1.0669	1.0669	
16		1.2193	1.2193	1.0669	1.0669	1.0669	
17	1.2193	1.0669	1.2193	1.0669	1.0669		
18	.9145	1.0669	1.0669	1.0669	1.0669	1.0669	
19	.0762	.0762	.0762	.0762	.0762	.0762	.0762
20	.0762	.1219	.0762	.0762	.0762	.0762	.0762
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.4525	.0762	.0762	.0762	.0762	.0762	.6097
Max	1.3717	1.3717	1.2193	1.0669	1.0669	1.2193	1.0669
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.5284	.5316	.4841	.4662	.4662	.4382	.5498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 201 / 11 KV KHARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.4115	.9774	2.0891	2.0622	1.7814
2	.3772	.3086	.4115	.9774	2.1052	2.1872	1.7814
3	.3772	.3086	.4287	.9774	2.1214	2.2253	1.7814
4	.3772	.3429	.4287	1.1145	2.4291	2.4844	1.8623
5	.4115	.3772	.4287	1.3748	3.1417	2.9264	2.0405
6	.4458	.3944	.463	1.6872	3.4494	3.7494	2.2809
7				2.5606	3.5056	3.5056	3.1093
8				3.0178	2.5149	3.5056	3.2007
9				2.8826	.3429	2.9264	2.652
10	1.7004			.3258	2.332	.3601	
11	2.915	2.3482	1.829	.9717	3.5665		
12	3.1741	3.3198	2.9264	2.5101	3.597	3.658	
13	3.0121	3.0931	2.9264	3.1093	3.6732	3.658	
14	3.0769	3.1417	2.6825	3.2874	3.2769	3.658	
15	3.0769	3.4008	2.652	3.3198	2.9721	3.658	
16		2.915	2.652	3.6275	2.9264	3.658	
17	2.9797	3.255	2.7435	3.4008	2.8654	3.658	
18	2.915	2.332	2.5606	3.4979	1.4632		
19	.3086	.4973		1.4899	1.5708		.4115
20	.3429	.6001		1.8623	1.4899	.5487	.5144
21	.3772	.5316	.6173	1.7652	1.4251	.5487	.5487
22	.3772	.4458	1.0288	1.6518	1.2955	.5487	
23	.3429	.4115	.8573	1.4899	1.2955	.5144	.4801
24	.4115	.3086	.4115	.9259	2.0891	1.9372	1.3927
Max	3.1741	3.4008	2.9264	3.6275	3.6732	3.7494	3.2007
Min	.3086	.3086	.4115	.3258	.3429	.3601	.4115
Avg	1.3688	1.4320	1.4700	2.0335	2.3974	2.4752	1.7027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 202 / 11 KV BOHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4922	1.3927	1.6095	.5658	1.0526	1.2308	.3429
2	1.4754	1.5223	1.6095	.5658	1.0526	1.3603	.3429
3	1.4754	1.7166	1.6095	.5658	1.1336	1.4899	.3429
4	1.4754	1.8461	1.5546	.6859	1.3765	1.6194	.3601
5	1.5546	2.0729	1.9433	.9389	1.8461	1.9757	.4115
6	2.1872	2.4291	2.2253	1.3916	2.1862	2.3644	.4801
7	3.0788	3.1093	2.7892	1.8785	2.7692	3.0769	
8	3.0026	3.0121	2.2405	2.2862	2.9797	3.0769	
9	2.713	2.5911	2.7892	2.1376	2.0081	2.6235	
11							.9717
12							2.6558
19	.3944	.3772		.3772	.4287		.3944
20	.4287	.4287		.4458	.4458	.4458	.5487
21	.3772	.4115	.2058	.4115	.4287	.4458	.4973
22	.3772	.3772	.3944	.4115	.4115	.4115	.4973
23	.3772	.3601	.3772	.3429	.3772	.3772	.4115
24	1.3077	1.3279	1.3916	.4801	1.0526	1.166	.3601
Max	3.0788	3.1093	2.7892	2.2862	2.9797	3.0769	2.6558
Min	.3772	.3601	.2058	.3429	.3772	.3772	.3429
Avg	1.4478	1.5317	1.5954	.8990	1.3033	1.5474	.6155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 203 / 11 KV T SHETPHAL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.2743	.4287		.5487	.2743	.5144
2	.4115	.2743	.4287		.5487	.2743	.4801
3	.4115	.2743	.4287		.5487	.2743	.6516
4	.4115	.3429	.4287		.5487	.3429	.5144
5	.4115	.4115	.5144		.5487	.3429	.5658
6	.463	.4115	.5144		.5487	.4115	1.5089
7		.4115					2.6825
8							3.2007
9							3.1245
10	3.2388						
11	3.5627	3.3522	2.6825	.6859	2.2672	2.4387	
12	3.5627	3.6761		2.2348	3.4979	3.658	
13	3.7571	3.7085	3.5818	2.8826	3.6275	3.658	
14	3.8866	3.7409	3.2007	3.0445	3.6923	3.4294	
15	3.6275	2.8664	3.658	3.0607	3.2388	3.3836	
16	3.6923	3.7085	3.658				
17	3.6923	3.4332	3.658				
18	3.5627	3.336	3.5361				
19	.3429	.4973		.3429	.3429		.3772
20	.3429	.583		.583	.3429	.5658	.6173
21	.4115	.6173		.6173	.3429	.5658	.583
22	.4115	.6001		.583	.3429	.5487	.583
23	.3429	.4115		.5487	.3429	.5144	.6344
24	.4525	.2743	.3772		.5487	.2743	.4801
Max	3.8866	3.7409	3.658	3.0607	3.6923	3.658	3.2007
Min	.3429	.2743	.3772	.3429	.3429	.2743	.3772
Avg	1.7813	1.5812	1.9354	1.4583	1.2870	1.3098	1.1012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 204 / 11 KV KHARDI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2401	.3429	.3086	.2915	.2743	.3258
2	.2915	.2915	.3429	.3086	.2915	.2743	.3258
3	.2915	.3601	.3601	.3086	.3086	.3086	.3258
4	.3429	.4287	.3601	.3429	.4287	.3944	.4115
5	.4115	.5144	.6173	.4458	.5316	.4801	.5144
6	.6344	.583		.5658	.5316	.5487	.6687
7	.703	.6344	.6516	.6001	.6173	.6173	.6859
8	.4801	.4973	.5316	.463	.4801	.5144	.4801
9	.4115	.3086	.3944	.3944	.3772	.3944	.463
10	.3772	.3086	.3772	.3258	.3429	.3258	.3601
11	.3429	.2572	.3601	.2915	.2229	.2401	.3429
12	.3429	.2743		.3086	.3086	.3086	.3086
13	.3086	.2572	.3086	.3086	.2058	.2572	.3086
14	.3258	.2743	.2572	.2743	.2229	.2572	.2915
15	.3429		.2572	.3086	.2572	.3258	.3086
16	.3601	.2743	.2572	.3086	.2572	.3086	.2743
17	.3429	.3086	.3258	.3258	.3772		
18	.4458	.3772	.3429	.4287	.4287		
19	.5144	.6001		.5316	.583		.6687
20	.4287	.583		.5144	.5487	.6001	.5487
21	.3772	.463	.4458	.4287	.4973		.583
22	.3429	.3601	.3429	.4115	.4115	.4458	.463
23	.2915	.3429	.3258	.3086	.3601	.4115	.463
24	.2915	.2743	.3258	.3086	.2915		.3258
Max	.703	.6344	.6516	.6001	.6173	.6173	.6859
Min	.2915	.2401	.2572	.2743	.2058	.2401	.2743
Avg	.3872	.3832	.3764	.3801	.3822	.3835	.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 205 / 11KV Umbargaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4754	1.1012	1.6518	1.5089	1.3765	1.3603	.4458
2	1.4754	1.1012	1.6518	1.4754	1.3927	1.3603	.4458
3	1.4251	1.1984	1.6518	1.4754	1.6518	1.4575	.4458
4	1.4251	1.2955	1.7166	1.4575	1.6518	1.7166	.4458
5	1.5927	1.5546	1.7185	1.7814	1.8138	1.9757	.4458
6	2.2024	2.332	1.8747	2.21	2.2024	2.3482	.5487
7	2.6825	3.0769	3.1093	2.9264	3.2388	2.7206	
8	2.9264	.3429	3.1093	2.8045	3.1093	2.915	
9	2.5606	2.5911	3.0483	2.7206	2.8664	2.8502	
11							2.332
12							2.8349
19	.4801	.4458		.463	.5144		.4115
20	.5487	.5144		.5144	.5144	.4801	.5487
21	.5144	.463	.4458	.4801	.5144	.4801	.5144
22	.5144	.4458	.4458	.4458	.5316	.4801	.583
23	.4801	.4115	1.3748	.4458	.4801	.4801	.4287
24	.4525	1.0364	1.2742	1.4754	1.3279	1.2955	.463
Max	2.9264	3.0769	3.1093	2.9264	3.2388	2.915	2.8349
Min	.4525	.3429	.4458	.4458	.4801	.4801	.4115
Avg	1.3837	1.1940	1.7748	1.4790	1.5458	1.5657	.7781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 206 / 11KV Kasegaon (BEND WASTI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4458	.6344	.6516	.5487	.4458	2.1795
2	.5487	.4115	.6173	.6516	.5144	.4458	2.1795
3	.5487	.4458	.6344	.6173	.5144	.4801	2.1795
4	.5487	.4801	.6344	.6173	.5487	.5144	2.1795
5	.583	.5144	.6173	.6516	.5658	.5487	2.2801
6	.6173	.5487	.6173	.6859	.5487	.5487	.583
7							.583
10	2.915						
11	3.5627	2.4777	2.7435	2.5911	1.7814	2.4387	
12	3.6923	3.4332	3.1398	3.2388	3.6275	3.0483	
13	3.6923	3.1417	3.2007	3.2388	3.6599		
14	3.7894	3.3684	3.2007	3.0931	3.6923	3.5056	
15	3.7247	2.8664	3.1245	3.1093	3.6923	2.8045	
16	3.6599	3.0931	3.2769	2.7206	3.7247	3.0483	
17	3.6275	3.4979	3.2007	3.2065	3.4656	3.1245	
18	.9069	3.1417	3.1245	3.1093	3.3036	3.2007	
19	.4458	.4287		.4801	.4801		.4115
20	.5144	.6859		.6687	.5144	.5144	.703
21	.5144	.703	.5487	.6859	.5487	.6173	.7202
22	.4801	.6687	.6859	.6516	.5144	.6859	.7202
23	.4801	.6687	.6859	.6516	.4801	.6173	.6859
24	.4525	.4458	.6344	.6859	.6516	.4801	2.0119
Max	3.7894	3.4979	3.2769	3.2388	3.7247	3.5056	2.2801
Min	.4458	.4115	.5487	.4801	.4801	.4458	.4115
Avg	1.7097	1.5734	1.7401	1.6003	1.6689	1.5038	1.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 401 / Sitaram Mah SSK
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 201 / Tisangi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2715	.2715	.2715	.2801	.3734	1.8233
2	.362	.2715	.2715	.2715	.2801	.3734	1.8233
3	.362	.2715	.2715	.2715	.2801	.3734	1.8233
4	.4525	.2715	.2715	.2715	.2801	.3734	1.8233
5	.4525	.362	.2715	.2715	.3734	.3734	1.9062
6	.4525	.362	.362	.2715	.4668	.4668	2.0719
7	.4668	.362	.4525	.362	.4668		2.4863
8	.362	.2715	.362		.3734	.3734	2.9835
9	.2715	.362	.2715		.2801	.3734	2.7349
10	.2715	.2715	.2715		.2801	.3734	
11	2.652	2.0119	1.6575			2.4691	
12	3.1493	2.9835	2.652		2.4863	2.8959	
13	3.315	3.315	2.1548		3.0864	3.0007	
14		2.3205	1.6575		3.0864	2.8959	
15	2.9835	2.652	2.1548		3.1722	2.8959	
16	3.0664	2.8178	2.1548		3.2579	3.0807	
17	2.9835	2.8178	1.989			3.1674	
18	2.8178	2.7349	1.8233	.362	3.2579	2.8054	
19	.362	.362	.2715	.362	.3734	.4668	.4525
20	.362	.362	.362	.4525	.3734	.4668	.4525
21	.362	.362	.362	.4525	.3734	.3734	.4525
22	.362	.362	.4525	.362	.3734	.3734	.4525
23	.362	.362	.4525	.2715	.3734	.3734	.4525
24	.4287	.362	.362	.362	.2801	.3734	1.8233
Max	3.315	3.315	2.652	.4525	3.2579	3.1674	2.9835
Min	.2715	.2715	.2715	.2715	.2801	.3734	.4525
Avg	1.1748	1.1209	.8993	.3297	1.0843	1.2649	1.5708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 202 / 11 KV SONAKE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1886	.1867	.181	.1867	.1867	1.6461
2	.181	.1867	.1867	.181	.1867	.1867	1.6461
3	.181	.1867	.1867	.181	.1867	.1867	1.6461
4	.1867	.1867	.1867	.181	.1867	.1867	1.6461
5	.181	.1867	.0934	.181	.1867	.1867	1.6461
6	.181	.1867	.1867	.181	.1867	.1867	1.7375
7	.181	.1867	.2801	.181	.1867	.1867	2.4434
8	.181	.1867	.1867	.181	.1867	.1867	2.2624
9	.181	.1867	.1867	.181	.1867	.1867	2.4434
10	.181	.1867	.1867	.181	.1867	.1867	
11	1.8442	2.0119	1.9909	1.8442	1.8099	2.1719	
12	2.6825	2.7435	2.8959	2.6825	2.7149	2.8959	
13	2.652	2.8959	2.7149	2.7664	2.8959	2.8607	
14	2.7664	3.0769	2.8959	2.6825	3.0807	2.8292	
15	2.7349	2.7149	2.9874	2.652	2.8959	2.8959	
16	2.8178	2.8959	2.7149	2.652	2.8054	2.8054	
17	2.652	2.8054	2.8054	2.4034	2.7149	2.7149	
18	2.7149	2.7149	2.7149	2.3472	2.7149	2.5339	
19	.181	.1867	.1867	.181	.1867	.1867	.1867
20	.2715	.2801	.1867	.181	.2801	.1867	.1867
21	.362	.1867	.1867	.181	.2801	.1867	.1867
22	.3734	.1867	.1867	.181	.1867	.1867	.1867
23	.2801	.1867	.1867	.181	.2801	.1867	.1867
24	.1867	.1867	.1867	.181	.1867	.1867	1.5546
Max	2.8178	3.0769	2.9874	2.7664	3.0807	2.8959	2.4434
Min	.181	.1867	.0934	.181	.1867	.1867	.1867
Avg	1.0140	1.0392	1.0295	.9553	1.0375	1.0290	1.3070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 203 / 11 KV KORTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.9945	1.1736	1.0898	1.3717	.7392	.2715
2	1.0059	.9945	1.1603	1.2574	1.3717	1.0974	.2715
3	1.0898	.9945	1.1736	1.2574	1.5546	1.0974	.2715
4	1.2574	1.326	1.3413	1.5927	1.6461	1.0974	.2715
5	1.4089	1.4918	1.6575	1.5927	1.829	2.0119	.2715
6	1.9062	1.989	1.989	1.9281	2.0814	2.1719	.3734
7	2.652	2.652	2.3205	2.2634	2.5139		.362
8	2.652	2.4863	2.3205		2.6873	3.2579	.362
9	2.5692	2.3205	2.1548		2.3405	2.7435	.2715
10	.2715	.181	.181		.1867	.1867	.2715
11	.181	.181	.181		.1867	.1867	
12	.181	.181	.181		.1867	.1867	
13	.181	.181	.181			.1867	
14	.181	.181	.181			.1867	
15	.181	.181	.181		.1867	.1867	
16	.181	.181	.181		.1867	.1867	
17	.181	.181	.181			.1867	
18	.181	.181	.181	.362	.1867	.1867	
19	.362	.362	.2715	.362	.3734	.3734	.362
20	.3734	.362	.362	.4525	.3734	.4668	.4525
21	.362	.362	.362	.4525	.3734	.4668	.362
22	.362	.2715	.362	.4525	.3734	.4668	.362
23	.362	.2715	.362	.362	.3734	.3734	.362
24	.8383	1.0059	.7545	1.0059	1.1888	.5544	.2715
Max	2.652	2.652	2.3205	2.2634	2.6873	3.2579	.4525
Min	.181	.181	.181	.362	.1867	.1867	.2715
Avg	.8303	.8130	.8081	1.0308	1.0272	.8086	.3231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 204 / GADEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.0974	1.2803	1.326	1.7337	1.0974	.4668
2	1.6575	1.0974	1.6461	1.4089	1.7337	1.4632	.4668
3	1.6575	1.0974	1.8671	1.4918	1.9071	1.4632	.4668
4	1.8233	1.0974	1.829	1.7404	1.9938	1.4632	.4668
5	2.0719	1.6461	2.1948	1.9062	2.1672	1.6461	.5601
6	2.4863	2.7149	2.5606	1.9062	2.4272	1.9909	.6535
7	3.0664	2.9864	3.1093	2.4863	3.0007	2.9864	.5601
8	3.0664	2.8959	3.2579	2.652	3.1722	2.8959	.5601
9	3.0664	2.8959	3.2579	2.5692	2.915	2.5339	.4668
10	.2715	.2801	.1867	.181	.1867	.1867	.3734
11	.181	.1867	.1867	.2715	.1867	.1867	1.8099
12	.181	.1867	.1867	.2715	.1867	.1867	
13	.1867	.1867	.1867	.2715	.1867	.1867	
14	.181		.1867	.2715	.1867	.1867	
15	.181	.1867	.1867	.2715	.1867	.1867	
16	.181	.1867	.1867	.2715	.1867	.1867	
17	.181		.2801	.4525	.1867	.2801	
18	.181	.2801	.3734	.6335	.1867	.3734	
19	.181	.6535	.4668	.6335	.1867	.5601	.3734
20	.3734	.6535	.4668	.6335	.2801	.5601	.4668
21	.362	.5601	.3734	.543	.2801	.4668	.3734
22	.362	.4668	.4668	.4525	.2801	.4668	.4668
23	.2715	.3734	.3734	.362	.2801	.4668	.3734
24	.7545	1.0059	1.0974	1.3413	1.7194	.9145	.4668
Max	3.0664	2.9864	3.2579	2.652	3.1722	2.9864	1.8099
Min	.181	.1867	.1867	.181	.1867	.1867	.3734
Avg	1.0243	1.0334	1.092	1.0145	1.0732	.9557	.5513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 205 / Gaothan No.1 Takali-
Gadegaon Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0934	.0934	.0905	.0934	.0934	.0905
2	.0905	.0934	.0934	.0905	.0934	.0934	.0905
3		.0934	.0934	.0905	.0934	.0934	.0905
4	.0934	.0934	.0934	.0905	.0934	.0934	.0905
5	.0905	.1867	.1867	.0905	.1867	.1867	.181
6	.181	.1867	.1867	.181	.1867	.1867	.181
7	.2801	.1867	.2801	.181	.1867	.1867	.181
8	.181	.0934	.1867	.181	.1867	.0934	.181
9	.1867	.0934	.1867	.181	.1867	.0934	.181
10		.0934	.0934	.181	.0934	.1867	.181
11	.181	.0934	.0934	.0905	.0934	.1867	.0905
12	.181	.0934	.0934	.0905	.0934	.1867	.0905
13	.181	.0934	.0934	.0905	.0934	.1867	.0905
14	.181	.0934	.0934	.0905	.1867	.0934	.0905
15	.0905	.0934	.0934	.0905	.1867	.0934	.0905
16	.0905	.0934	.0934	.0905	.0934	.0934	.0905
17	.0905	.0934	.0934	.181	.0934	.1867	.0905
18	.0905	.1867	.1867	.181	.0934	.1867	.0905
19	.181	.2801	.1867	.2715	.0934	.1867	.181
20	.181	.2801	.1867	.2715	.1867	.2801	.181
21	.181	.1867	.1867	.181	.1867	.1867	.181
22	.1867	.1867	.1867	.181	.1867	.1867	.0905
23	.181	.0934	.0934	.0934	.1886	.1867	.0905
24	.0905	.0934	.0934	.0905	.0934	.1867	.0905
Max	.2801	.2801	.2801	.2715	.1886	.2801	.181
Min	.0905	.0934	.0934	.0905	.0934	.0934	.0905
Avg	.1491	.1323	.1362	.1396	.1362	.1556	.1244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 206 / 11KV Navale College
Express Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0934	.0934	.0905	.0934	.0934	.0934
2	.0905	.0934	.0934	.0905	.0934	.0934	.0934
3	.0905	.0934	.0934	.0905	.0934	.0934	.0934
4	.0905	.0934	.0934	.0905	.0934	.0934	.0934
5	.0905	.0934	.0934	.0905	.0934	.0934	.0934
6	.0905	.0934	.0934	.0905	.0934	.0934	.0934
7	.0905	.0934	.0934	.0905	.0934	.0934	.0934
8	.0905	.0934	.0934	.0905	.0934	.0934	.0934
9	.0905	.0934	.0934	.0905	.0934	.0934	.0934
10	.0905	.0934	.0934	.0905	.0934	.0934	.0934
11	.0905	.0934	.0934	.0905	.0934	.0934	.0934
12	.0905	.0934	.0934	.0905	.0934	.0934	.0934
13	.0905	.0934	.0934	.0905	.0934	.0934	.0934
14	.0905	.0934	.0934	.0905	.0934	.0934	.0934
15	.0905		.0934	.0905	.0934	.0934	.0934
16	.0905	.0934	.0934	.0905	.0934	.0934	.0934
17	.0905	.0934	.0934	.0905	.0934	.0934	.0934
18	.0905	.0934	.0934	.0905	.0934	.0934	.0934
19	.0905	.0934	.0934	.0905	.0934		.0934
20	.0934	.0934	.0934	.0905	.0934	.0934	.0934
21	.0905	.0934	.0934	.0905	.0934	.0934	.0934
22	.0905	.0934	.0934	.0905	.0934	.0934	.0934
23	.0905	.0934	.0934	.0905	.0934	.0934	.0934
24	.0905	.0934	.0934	.0905	.0934	.0934	.0934
Max	.0934	.0934	.0934	.0905	.0934	.0934	.0934
Min	.0905	.0934	.0934	.0905	.0934	.0934	.0934
Avg	.0906	.0934	.0934	.0905	.0934	.0934	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 207 / Gaothan No.2 Sonke-Tisangi
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.4525
Max	.4525
Min	.4525
Avg	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 201 / 11 KV ANAWALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		1.3717
2		1.3717
3		1.7147
4		1.7147
5		1.8861
6		2.0576
7		2.0576
8		2.0576
9		2.1434
10		.1715
11		.1715
12		.1715
13		.1715
14		.1715
15		.1715
16		.1715
17		.2743
18		.3429
19		.3944
20		.4115
21		.3772
22		.3429
23		.3086
24	.1886	1.0288
Max	.1886	2.1434
Min	.1886	.1715
Avg	.1886	.8773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 202 / 11 KV TAWASHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.2401
2		.2401
3		.2401
4		.3086
5		.3429
11		2.0576
12		3.6008
13		3.6008
14		3.5151
16		3.2579
17		3.2236
18		3.155
19		.2915
20		.3429
21		.3086
22		.2743
23		.2572
24	1.4632	.2401
Max	1.4632	3.6008
Min	1.4632	.2401
Avg	1.4632	1.4165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 203 / 11 KV ANAWALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.8573
2		.8573
3		.8573
4		.9431
5		1.0288
6		1.2003
7		1.0288
8		1.0288
9		.8573
10		.7716
11		.7716
12		.5144
14		.5144
15		.5144
16		.5144
17		.6859
18		.8573
19		1.0288
20		1.2346
21		1.1145
22		1.0288
23		.9431
24	.9431	.8573
Max	.9431	1.2346
Min	.9431	.5144
Avg	.9431	.8700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 204 / Shirgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4525
Max	.4525
Min	.4525
Avg	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 205 / VITHURAYA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.1715
2		.1715
3		.2401
4		.2401
5		.2229
11		1.2003
12		2.3148
13		2.4006
14		2.4863
16		2.2291
17		2.2634
18		2.2977
19		.1543
20		.1715
21		.1715
22		.1543
23		.1372
24	1.0374	.12
Max	1.0374	2.4863
Min	1.0374	.12
Avg	1.0374	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 206 / SIDDHANATH
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.2058
2		.2058
3		.2058
4		.2401
5		.2743
6		.3086
7		.3429
8		.3429
9		.3772
11		.8573
12		1.5432
13		1.3717
14		1.286
16		1.4575
17		1.2346
18		1.0631
19		.2058
20		.2401
21		.2401
22		.2195
23		.2058
24	.7545	.2058
Max	.7545	1.5432
Min	.7545	.2058
Avg	.7545	.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 207 / MAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		1.7337
2		1.7147
3		1.8861
4		2.0576
5		2.2291
6		2.2291
7		2.4006
8		2.572
9		2.572
10		.2572
11		.2572
12		.2572
13		.2572
14		.2572
15		.2572
16		.3429
17		.3429
18		.3429
19		.4458
20		.4115
21		.3429
22		.3086
23		.2915
24	.3772	1.2003
Max	.3772	2.572
Min	.3772	.2572
Avg	.3772	1.0403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 201 / WAKHARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.2195	.1029	.1029	.2058	.2058	1.7147
2	.1029	.1829	.1029	.1097	.2058	.2401	1.7147
3	.1029	.2195	.1029	.1029	.2401	.2401	1.8861
4	.1029	.1829	.1029	.1372	.2401	.2401	1.6766
5	.1029	.2561	.1372	.1715	.2401	.2743	1.7528
6	.1029	.2926	.1372	.1715	.3086	.3086	1.829
7	.1029	.2926	.1715	.1524	.2743	.3086	2.1338
8	.1715	.1829	.1715	.1715	.2401	.2743	2.1338
9	.2401	.2058	.1829	.2401	.2058	.1715	2.2253
10	.2058	.2058	.2195	.2401	.2058	.1715	.1715
11	2.1643	1.9204	1.9387	1.6766	1.7071	1.3413	.1372
12	2.774	2.5301	2.2862	2.0729	2.1338	1.9814	.1029
13	2.5301	2.652	2.5301	2.1338	2.4387	2.1338	
14	2.5606	2.4082	2.4387	2.2558	2.3777	2.1948	
15	2.5606	2.2862	2.2862	2.2253	2.3472	2.1948	
16	2.4387	2.0729	2.4996	2.3167	2.4082	2.1033	
17	2.9995	2.1338	2.4387	2.1033	2.1948	2.1338	
18	2.3167	2.1948	2.3472	2.0424	2.1643	2.332	
19	.2134	.2743	.2058	.2401	.2743	.1715	.1715
20	.2134	.2401	.1715	.2401	.2401	.1715	.1715
21	.2134	.2058	.1715	.2058	.2401	.1715	.1715
22	.2134	.2058	.1715	.2058	.2561	.1524	.1715
23	.2195	.1372	.1372	.2058	.0343	.1524	.2058
24	.1715	.2195	.1029	.1029	.2058	.2058	1.7147
Max	2.9995	2.652	2.5301	2.3167	2.4387	2.332	2.2253
Min	.1029	.1372	.1029	.1029	.0343	.1524	.1029
Avg	.9553	.9051	.8816	.8178	.8912	.8281	1.1158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 202 / KHED BHALWANI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0366	.0343	.0343	.0343	.0343	2.2291
2	.0343	.0366	.0343	.0343	.0343	.0343	2.2291
3	.0343	.0366	.0343	.0343	.0343	.0343	2.2291
4	.0343	.0366	.0343	.0343	.0343	.0343	2.4006
5	.0343	.0366	.0343	.0343	.0343	.0343	2.4863
6	.0343	.0366	.0343	.0343	.0343	.0343	2.572
7	.0343	.0366	.0343	.0343	.0343	.0343	2.4387
8	.0343	.0366	.0343	.0343	.0343	.0343	3.0483
9	.0343	.0343	.0366	.0343	.0343	.0343	3.1398
10	.0343	.0343	.0366	.0343	.0343	.0343	.0343
11	2.7435	2.9874		2.6216	2.9569	2.5606	.0343
12	3.5056	3.6275		3.2007	3.3532	3.3532	.0343
13	3.719	3.3227		3.3227	3.5361	3.4751	
14	3.597	3.4751		3.1093	3.5056	3.4751	
15	3.8714	3.4141	3.2007	3.2312	3.5665	3.4751	
16	3.3532	3.1703	3.3836	3.2312	3.8104	3.4751	
17	3.2922	3.2007	3.658	.2058	3.1093	3.2617	
18	3.3532	3.2007	3.0178	.1029	2.774	3.3532	
19	.0305	.0343	.0343	.0343	.0343	.0343	.0343
20	.0305	.0343	.0343	.0343	.0343	.0343	.0343
21	.0305	.0343	.0343	.0343	.0343	.0305	.0343
22	.0305		.0343	.0343	.0343	.0343	.0343
23	.0366		.0343	.0343	.0343	.0305	.0343
24	.0343	.0366	.0343	.0343	.0343	.0343	1.9662
Max	3.8714	3.6275	3.658	3.3227	3.8104	3.4751	3.1398
Min	.0305	.0343	.0343	.0343	.0343	.0305	.0343
Avg	1.1655	1.2227	.6907	.8156	1.1317	1.1238	1.3896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 203 / KOUTHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.829	1.829	1.6461	1.768	1.9509	.0343
2	1.829	1.829	1.829	1.6461	1.768	1.9814	.0305
3	1.829	1.829	1.829	1.6461	1.768	1.9814	.0305
4	1.9509	2.1338	1.9509	1.7071	1.768	2.0119	.0305
5	1.9509	2.4387	1.9509	1.9509	1.89	2.0119	.0305
6	2.1338	2.5911	2.0729	2.0119	2.3777	2.1948	.0305
7	2.4387	2.7435	2.6825	2.4996	2.7435	2.6216	.0305
8	2.6825	2.9264	2.7435	2.9264	2.8045	2.8045	.0343
9	2.6825	2.9874	3.2922	2.8045	2.8045	2.9264	.0343
10	.0343	.0343	.0305	.0343	.0305	.0343	.0343
11	.0343	.0343	.0305	.0343		.0343	.0343
12	.0343	.0343	.0305	.0343		.0343	2.8654
13	.0343	.0343	.0305	.0343		.0343	
14	.0343	.0343	.0305	.0343	.0343	.0343	
15	.0343	.0343	.0305	.0343	.0343		
16	.0343	.0343	.0343	.0343	.0343	.0343	
17	.0343	.0343	.0343	.0343	.0343	.0305	
18	.0305		.0343	.0343	.0343	.0343	
19	.0305	.0343	.0343	.0343	.0343	.0305	.0343
20	.0305	.0343		.0343	.0343	.0305	.0343
21	.0305	.0343		.0343	.0343	.0305	.0343
22	1.2498	.0343		.0343	.0343	.0305	.0343
23	.0305	.0343		.0343	.0343	.0305	.0343
24	.3048	1.7071	1.6461	1.5851	1.7071	1.89	.0305
Max	2.6825	2.9874	3.2922	2.9264	2.8045	2.9264	2.8654
Min	.0305	.0343	.0305	.0343	.0305	.0305	.0305
Avg	.8878	1.0200	1.1073	.871	1.0368	.9912	.1901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 204 / SHIRDHONE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.5851	2.1262	1.7071	1.6461	1.6766	
2	1.8519	1.5851	2.1262	1.7071	1.6461	1.6766	
3	1.7071	1.5851	2.1262	1.7071	1.6461	1.7071	
4	1.829	1.6766	1.9509	1.768	1.7071	1.7071	
5	1.7071	1.829	1.9509	1.768	1.7071	1.829	
6	1.829	1.9814	2.0119	1.829	1.829	1.89	
7	2.1338	2.1948	2.0729	2.1338	2.1338	2.1338	
8	2.2558	2.2558	2.1338	2.1948	2.1948	2.1948	
9	2.3167	2.3777	2.3777	2.3777	2.2558	2.1948	
12							2.1338
24	.4525	1.5851	1.768	1.5851	1.6461	1.6461	
Max	2.3167	2.3777	2.3777	2.3777	2.2558	2.1948	2.1338
Min	.4525	1.5851	1.768	1.5851	1.6461	1.6461	2.1338
Avg	1.7912	1.8656	2.0645	1.8778	1.8412	1.8656	2.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 205 / WAKHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3292	.3429	.3429		.2561	.3258
2	.2572	.3292	.3429	.3429		.2743	.3429
3	.2572	.3475	.3086	.3429		.2926	.3601
4	.2572	.3658	.3086	.3086		.3292	.3772
5	.3429	.3658	.3258	.3086		.3658	.4115
6	.4115	.4024	.4287	.4801		.4024	.4287
7	.3429	.3841	.3944	.3772		.3292	.4115
8	.3475	.3109	.3258	.3429	.2572	.2926	.3772
9	.3109	.2561	.2561	.3292	.2378	.2229	.3429
10	.2561	.2195	.2012	.2378	.1646	.1715	.1715
11	.2195		.1646	.1646	.128	.12	.1715
12	.1463	.1463	.1463		.1097	.1029	.1029
13	.1829	.1646	.1097	.128	.1097	.12	.1029
14	.1646	.1463	.1097	.128	.1097	.12	.1029
15	.1646	.1097	.1097	.1463	.0914		.1029
16	.1646	.1646	.1097	.1646	.128	.12	.1372
17	.1829	.1543	.1372	.1372	.1097	.12	.1715
18	.1829		.1715	.1715	.1829	.12	
19	.2926	.3258	.3258	.2915	.3109	.2058	.3086
20	.2926	.3429	.3258	.3258	.3292	.3772	.3086
21	.3109	.3429	.3086	.3086	.2743	.3429	.3086
22	.3658	.3429	.3258	.3258	.2561	.3429	.3086
23	.3658	.3429	.3429	.3258	.2561	.3086	.2058
24	.2743	.3292	.3429	.3429		.2561	.3258
Max	.4115	.4024	.4287	.4801	.3292	.4024	.4287
Min	.1463	.1097	.1097	.128	.0914	.1029	.1029
Avg	.2646	.2829	.2611	.2771	.1910	.2432	.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 206 / 11 KV Mauli Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3658	.4458	.3429	.3258	.3658	.3429
2	.2572	.3658	.3429	.3429	.3258	.3841	.3772
3	.2401	.439	.3429	.3429	.3429	.4024	.3944
4	.2572	.5121	.3429	.3086	.3429	.4024	.4287
5	.3429	.5487	.3429	.3086	.4115	.4024	.463
6	.4287	.5853	.463	.4115	.3772	.5121	.4973
7	.5658	.567	.6001	.5144	.3086	.6584	.463
8	.5121	.5487	.5144	.5658	.463	.5121	.4458
9	.3841	.4572	.4207	.4572	.4024	.4458	.3772
10		.4938	.4572	.5121	.4755	.4973	.4458
11	.4024	.4207	.4207	.4572	.5121	.5144	.3772
12	.4024	.3841	.4115	.4938	.4938	.4458	.4115
13	.3475	.4207	.439	.4938	.4572	.3772	.3944
14	.2926	.439	.439	.4024	.4755	.3772	.3601
15	.2926	.4572	.439	.4207	.5121	.4287	.3772
16	.2743	.4572	.5138	.4207	.5304	.4287	.3601
17	.3841	.4115	.4801	.3772	.5853	.4287	.3601
18	.3658	.4115	.463	.4287	.4572	.3429	.3601
19	.4755	.463	.5144	.4973	.5487	.3601	.4801
20	.3963	.4973	.5144	.5658	.5487	.3944	.4801
21	.0305	.4973	.5144	.5658	.6036	.4458	.4287
22	.439	.3944	.4973	.5144	.567	.4458	.4287
23	.4024		.4287	.3944	.5853	.3772	.3772
24	.2572	.3658	.3944	.3258	.3258	.3475	.3429
Max	.5658	.5853	.6001	.5658	.6036	.6584	.4973
Min	.0305	.3658	.3429	.3086	.3086	.3429	.3429
Avg	.3482	.4567	.4476	.4360	.4574	.4291	.4072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV SIDDHESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3086	
2				.3086	
3				.3086	
4				.3258	
5				.4458	
6				.583	
7				.6001	
9	.4458	.4801	.3601	.463	2.878
10	.3086	.2743	.2915	.2915	.2743
11	2.2365	1.8031	1.6817	1.5604	.2572
12	3.034	3.0514	3.3114	2.9127	.2401
13	3.1034	3.0167	3.2768	2.8607	.2058
14	2.8433	2.93		2.774	.2058
15	2.3405	2.826	2.6699	2.7046	.2229
16	2.8433	3.034	3.0687	2.7913	.2401
24	.4525			.3429	
Max	3.1034	3.0514	3.3114	2.9127	2.878
Min	.3086	.2743	.2915	.2915	.2058
Avg	1.9564	2.1770	2.0943	1.2239	.5655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV SATWAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372			.1715	
2	.1372			.1543	
3	.1372			.1543	
4	.1715			.1543	
5	.1886			.2058	
6				.2229	
7				.2229	
9	.1886	.2743	.2743	.2572	2.6179
10	.2743	.2572	.1886	.2915	.1715
11	1.543	1.7684	1.6297	1.5604	.1029
12	2.6699	3.0167	2.5206	2.0978	.2229
13	3.0514	3.0514	3.1207	2.3926	.2058
14	2.774	2.7913		2.5486	.2401
15	1.9591	2.6873	2.4619	2.6873	.2229
16	2.722	2.8607	2.5139	2.7913	.2058
24	.1372			.1715	
Max	3.0514	3.0514	3.1207	2.7913	2.6179
Min	.1372	.2572	.1886	.1543	.1029
Avg	1.1494	2.0884	1.8157	1.0053	.4987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV DESHMUKH NAGAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745			.8745	
2	.8745			.9088	
3	.9259			.9259	
4	1.0288			1.0288	
5	1.2174			1.1488	
6				1.3375	
7				2.0062	
9	2.0978	2.2365	2.1672	1.9418	.2572
10	.1715	.1543	.1886	.2058	.2743
11	.1886	.1372	.1543	.2058	1.3523
12	.1715	.1543	.1543	.1886	2.0978
13	.1886	.1372	.1543	.1886	2.0285
14	.1715	.1715		.1715	1.9938
15	.2058	.1715	.1372	.1715	1.9071
16	.1886	.2058	.1715	.1886	1.9591
24	.7716			.7545	
Max	2.0978	2.2365	2.1672	2.0062	2.0978
Min	.1715	.1372	.1372	.1715	.2572
Avg	.6483	.4210	.4468	.7655	1.4838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886			.1886	
2	.1886			.1886	
3	.1715			.1886	
4	.2058			.2401	
5	.2229			.3258	
6				.4115	
7				.3944	
9	.2743	.3086	.2743	.3086	.2743
10	.3601	.3258	.3258	.2743	.2743
11	.1715	.2572	.3086	.1886	.2058
12	.2401	.2915	.2401	.1886	.2572
13	.2058	.2229	.2229	.1543	.2229
14	.1543	.2058		.1372	.2915
15	.1543	.2058	.1886	.1372	.2229
16	.2572	.2058	.1543	.1715	.2572
24	.1715			.1715	
Max	.3601	.3258	.3258	.4115	.2915
Min	.1543	.2058	.1543	.1372	.2058
Avg	.2119	.2529	.2449	.2293	.2508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 206 / Dongare Shala
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346			1.0974	
2	1.2346			1.2174	
3	1.4746			1.2346	
4	1.4746			1.5089	
5	1.9033			1.8347	
6				2.2119	
7				3.3779	
9	2.8607	3.7102	3.5021	3.4501	.5316
10	.4287	.4287	.4801	.4115	.1715
11	.3601	.4801	.2058	.2058	1.5257
12	.2058	.4801	.3772	.5041	2.3752
13	.4115	.2401		.4115	3.1901
14	.3772	.3601		.3258	2.774
15	.2572	.3601	.2401	.4287	2.6526
16	.4973	.3944	.2572	.4973	2.93
24	1.046			.9259	
Max	2.8607	3.7102	3.5021	3.4501	3.1901
Min	.2058	.2401	.2058	.2058	.1715
Avg	.9833	.8067	.8438	1.2277	2.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 201 / 11 KV SARKOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	1.7661	1.7147	1.6632	1.7147	1.6975	1.7661
2	1.8004	1.7661	1.8004	1.6804	1.749	1.7661	1.8347
3	1.8347	1.8004	1.8519	1.6804	1.8004	1.8347	1.9204
4	1.869	1.7833	1.9204	1.8004	1.8519	1.869	1.9204
5	1.9204	1.7661	2.0405	1.9204	1.9719	1.9547	2.0576
6	2.0405	2.0233	2.1605	2.1262	2.0919	2.1776	2.2977
7	2.2119	2.1434	2.2634	2.2634	2.1776	2.2977	2.3491
8	2.4691	2.332	2.4863	2.4177	2.2634	2.4863	2.4863
9	2.7092	2.4863	2.5377	2.3663	2.3148	2.3834	2.4006
19	.2743	.2743	.4458	.4115	.3772	.4287	.3601
20	.3258	.3086	.4115	.4115	.463	.463	.4801
21	.3086	.3086	.3601	.3944	.4287	.4287	.4458
22	.2401	.2743	.3086	.3086	.3429	.3772	.4801
23	.2058	.2915	.3086	.3086	.2572	.3429	.4801
24	1.8004	1.749	1.7147	1.7318	1.5432	1.6804	1.7147
Max	2.7092	2.4863	2.5377	2.4177	2.3148	2.4863	2.4863
Min	.2058	.2743	.3086	.3086	.2572	.3429	.3601
Avg	1.4529	1.4049	1.4883	1.4323	1.4232	1.4792	1.5329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 202 / 11 KV OZEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1715	.1715	.1372	.1372	.1715
2	.1372	.1543	.1715	.1715	.1715	.1543	.1715
3	.1372	.1715	.1715	.1715	.1715	.1543	.1715
4	.1543	.1715	.1715	.1715	.1715	.1543	.1715
11	2.2634	1.9204	2.0576	2.0233	1.8861	1.8861	1.9376
12	2.7092	2.7435	2.2634	2.5377	2.5892	2.5034	2.1434
13	2.7092	2.4006	2.7263	2.5377	2.6406	2.6578	
14	2.7263	2.7435	2.5377	2.5549	2.572	2.7092	
15	2.4006	2.692	2.0919	2.5377	2.332	2.7435	
17	2.3663	2.4006	2.1776	2.572	2.572	2.6578	
18	2.4691	2.1776	2.6578	2.6063	2.5892	2.452	
19	.1372	.1543	.1715	.1372	.1715	.1715	.1715
20	.1372	.1715	.1886	.1886	.1543	.1715	.1886
21	.1372	.1715	.1886	.1715	.1715	.1715	.1886
22	.1543	.1715	.1715	.1543	.1715	.1715	.1715
23	.1543	.1715	.1886	.1372	.1543	.1715	.1715
24	.1372	.1543	.1715	.1715	.1372	.1372	.1715
Max	2.7263	2.7435	2.7263	2.6063	2.6406	2.7435	2.1434
Min	.1372	.1543	.1715	.1372	.1372	.1372	.1715
Avg	1.1216	1.1014	1.0752	1.1186	1.1055	1.1297	.4859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 203 / 11 KV KHATAKALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.2058	.2058	.2058	.2058
2	.1715	.1886	.1715	.2058	.2058	.2058	.2058
3	.2058	.1886	.1715	.2058	.2229	.2229	.2058
4	.2058	.1886	.1715	.2229	.2401	.2401	.2058
11	1.1317	1.2003	1.1831	1.166	1.1145	1.166	1.2346
12	1.2346	1.286	1.3375	1.286	1.3889	1.2517	1.3032
13	1.2689	1.3375	1.4232	1.3717	1.3889	1.3032	
14	1.2517	1.3032	1.406	1.3889	1.3717	1.3375	
15	1.3032	1.286	1.3032	1.3717	1.3546	1.3375	
17	1.3032	1.2003	1.1831	1.3546	1.3203	1.286	
18	1.3546	1.2517	1.2689	1.3717	1.3375	1.3717	
19	.1886	.1715	.2058	.2058	.2058	.2058	.1886
20	.1715	.1886	.2229	.2229	.2229	.2401	.2229
21	.1715	.1886	.2229	.2229	.2058	.2401	.2229
22	.1715	.1715	.2229	.2058	.2058	.2058	.2058
23	.1715	.1715	.2058	.2229	.1886	.2058	.1886
24	.4525	.6859	.1715	.2058	.2229	.1886	.2058
Max	1.3546	1.3375	1.4232	1.3889	1.3889	1.3717	1.3032
Min	.1715	.1715	.1715	.2058	.1886	.1886	.1886
Avg	.6429	.6576	.6496	.6728	.6708	.6597	.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 204 / 11 KV AMBIKA NAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.3546	1.2689	1.3375	1.3375	1.3717	1.4403
2	1.4232	1.4575	1.3375	1.3717	1.3717	1.4232	1.4918
3	1.4746	1.4746	1.5432	1.4575	1.4575	1.4918	1.5775
4	1.5775	1.5947	1.6289	1.6461	1.6118	1.5604	1.6289
5	1.7661	1.7147	1.749	1.7833	1.8004	1.6118	1.7147
6	2.0062	1.869	1.9719	2.0576	1.989	1.7661	1.9719
7	2.2805	2.0919	2.0576	2.2119	2.1434	2.1434	2.0576
8	2.4177	2.2634	2.2291	2.4177	2.2291	2.2805	2.1434
9	2.2291	2.0576	2.3148	2.452	2.4006	2.2462	2.0576
16		.1372	.1029	.1029	.1372	.1372	
17	.0857	.1372	.1715	.1715	.1372	.1372	
18	.1543	.1372	.2229	.2058	.1715	.1372	.1372
19	.1715	.1372	.2401	.2401	.1886	.1715	.2058
20	.1715	.1372	.2229	.2229	.1715	.2058	.2058
21	.1715	.1372	.2058	.2058	.1715	.2058	.2058
22	.1372	.1372	.1715	.1715	.1543	.2058	.2058
23	.1372	.1372	.1715	.1715	.1715	.2058	.2058
24	.4525	1.2517	1.2003	1.3203	1.3375	1.3375	1.406
Max	2.4177	2.2634	2.3148	2.452	2.4006	2.2805	2.1434
Min	.0857	.1372	.1029	.1029	.1372	.1372	.1372
Avg	1.0635	1.0126	1.0450	1.0860	1.0545	1.0355	1.1660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 205 / SHIVAJI NAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1715	.1715	.1543	.2058	.2058
2	.1372	.1543	.1543	.1715	.1715	.2229	.2058
3	.1543	.1715	.1543	.2058	.1715	.2401	.2058
4	.1715	.1715	.1543	.2229	.2058	.2229	.2058
11	1.0631	1.0288	1.166	1.0974	.8573	1.0288	1.0288
12	1.2003	1.2689	1.3375	1.286	1.2517	1.2517	1.0802
13	1.2003	1.3717	1.286	1.3032	1.3717	1.3375	
14	1.1831	1.406	1.3375	1.3203	1.3546	1.3717	
15	1.0974	1.4403	1.3032	1.3203	1.2689	1.3717	
17	1.1145	1.3717	1.3032	1.3032	1.1831	1.2003	
18	1.286	1.3717	1.2689	1.2003	1.2003	1.1145	
19	.2058	.2058	.2572	.2058	.3429	.2058	.1715
20	.1886	.2058	.2401	.2401	.2572	.2058	.2058
21	.1715	.2058	.2058	.2058	.2401	.2058	.2058
22	.1543	.1886	.1886	.1886	.2058	.2058	.2058
23	.1715	.1715	.1715	.1715	.2058	.2058	.2058
24	.1372	.1715	.1715	.1715	.1372	.2058	.2058
Max	1.286	1.4403	1.3375	1.3203	1.3717	1.3717	1.0802
Min	.1372	.1543	.1543	.1715	.1372	.2058	.1715
Avg	.5749	.6506	.6395	.6345	.6223	.6355	.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 206 / SARKOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.1886	.1715	.1715	.2058	.2058
2	.1715	.1715	.1715	.1715	.1715	.1715	.2058
3	.1886	.1715	.1715	.1715	.1715	.2058	.1715
4	.2572	.2229	.1715	.2058	.2058	.2572	.1715
5	.3086	.3258	.2058	.2743	.2572	.3086	.2401
6	.3772	.3429	.2743	.3944	.3601	.3772	.3086
7	.3258	.3429	.3429	.3429	.3429	.3772	.3772
9	.2058	.2058	.2572	.2229	.2229	.2572	.2058
10	.2058	.12	.2058	.1715	.2058	.2229	.1715
11	.2058	.1715	.1715	.1372	.2058	.1715	.1715
12	.1886	.1715	.1543		.1715	.1543	.1372
13	.1715		.1372	.1372	.1543	.1372	.1372
14	.1543	.1372	.12	.1372	.1372	.1372	.1372
15	.1372	.1543	.12	.1372	.1372	.1372	.1372
16	.1372	.1543	.1372	.1543	.1715	.3086	.1715
17	.1543	.1715	.1886	.1715	.2401	.2058	.2058
18	.2401	.2058	.2058	.2058	.2572	.2572	.2743
19	.3429	.3086	.3258	.3086	.4115	.3429	.3258
20	.3258	.3772	.2915	.3258	.3772	.3772	.3772
21	.3258	.3429	.2572	.2572	.3429	.3429	
22	.2915	.3086	.2572	.2229	.2915	.2572	
23	.2229	.2401	.2229	.2058	.2229	.2572	
24	.1715	.2058	.2058	.1715	.1715	.2058	.2058
Max	.3772	.3772	.3429	.3944	.4115	.3772	.3772
Min	.1372	.12	.12	.1372	.1372	.1372	.1372
Avg	.2296	.2299	.2080	.2136	.2348	.2468	.2169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 201 / 11 KV DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0857	.0905	.0905	.0905	.0857	.0905
2	.0905	.0857	.0905	.0905	.0905	.0857	.0905
3	.0905	.0857	.0905	.0905	.0905	.0857	.0905
4	.0905	.0857	.0905	.0905	.0905	.0857	.0905
5	.0905	.0857	.0905	.0905	.0905	.0857	.0905
6	.0905	.0857	.0905	.0905	.0905	.0857	.0905
7	.0905	.0857	.0905	.0905	.0905	.0857	.0905
8	.0905	.0857	.0905	.0905	.0905		
9	.0905	.0857	.0905	.0905	.0905		
10	.0905	.0857	.0905	.0905	.0905		.0905
11	1.1336	1.3717	1.1336	1.1336		1.3717	1.1336
12	1.2955	1.3717	1.448	1.2955	1.1336	1.3717	1.2955
13	1.2955	1.3717	1.2955	1.1336	1.1336	1.3717	
14	1.2955	1.3717	1.1336	1.1336	1.1336	1.3717	
15				.4858			
16	1.2955	1.3717	1.1336	.6478	1.1336	1.1336	
17	1.2955	1.3717	1.1336	1.2955	1.2955	1.2955	
18	1.1336	1.3717	1.1336	1.1336	1.2955	1.1336	
19	.0905	.0857	.0905	.0905	.0905	.0905	.0905
20	.0905	.0857	.0905	.0905	.0905	.0905	.0905
21	.0905	.0857	.0905		.0905	.0905	.0905
22		.0857	.0905	.0905	.0905		.0905
23	.0905	.0857	.0905	.0905	.0905	.0905	.0905
24	.4525	.0857	.0905	.0905	.0905	.0857	.0905
Max	1.2955	1.3717	1.448	1.2955	1.2955	1.3717	1.2955
Min	.0905	.0857	.0905	.0905	.0905	.0857	.0905
Avg	.4756	.4771	.4287	.4181	.3897	.5314	.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 202 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8947	2.4006	2.2672	2.2672	2.2672	2.4006	2.1052
2	1.9433	2.4006	2.2672	2.2672	2.2672	2.4006	2.1052
3	1.9433	2.572	2.2672	2.2672	2.2672	2.4006	2.1052
4	1.9433	2.572	2.4291	2.2672	2.4291	2.572	2.1052
5	2.1052	2.7435	2.4291	2.2672	2.4291	2.572	2.1052
6	2.2672	2.915	2.5911	2.4291	2.5911	2.7435	2.2672
7	2.9959	3.0864	2.915	2.5911	2.5911		
8	2.915	2.915	2.753	2.5911	2.5911	2.7435	2.4291
9	2.915	2.915	2.5911	2.5911	2.5911	2.7435	2.4291
10	.181	.1715	.181	.181	.181	.1715	.181
11	.181	.1715	.181	.181			.181
12	.181	.3429	.181	.181	.181	.3429	.181
13	.181	.3429	.181	.181	.181	.3429	
14	.181	.3429	.181	.181	.181	.3429	
15	.181	.3429	.181	.181	.181	.181	
16	.181	.3429	.181	.181	.181	.181	
17	.181	.3429	.181	.181	.181	.181	
18	.181	.3429	.181	.181	.181	.181	
19	.181	.3429	.181	.181	.181	.181	.181
20	.181	.3429	.181	.181	.181	.181	.181
21	.181	.3429	.181	.181	.181	.181	.181
22	.181	.1715	.181	.181	.181	.181	.181
23	.181	.1715	.181	.181	.181	.181	.181
24	1.8947	2.4006	2.2672	2.2672	2.2672	2.4006	2.1052
Max	2.9959	3.0864	2.915	2.5911	2.5911	2.7435	2.4291
Min	.181	.1715	.181	.181	.181	.1715	.181
Avg	1.0563	1.2932	1.1380	1.0975	1.1585	1.1730	1.2473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 203 / 11 KV CHANDRABHAGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0905	.0905	.0905	.0905
2		.0905	.0905	.0905	.0905
3		.0905	.0905	.0905	.0905
4		.0905	.0905	.0905	.0905
5		.0905	.0905	.0905	.0905
6		.0905	.0905	.0905	.0905
7		.0905	.0905	.0905	.0905
8		.1448	.0905	.0905	
9		.0905	.0905	.0905	
10		.0905	.0905	.0905	.0905
11		1.1336		1.2955	1.1336
12		1.2955	1.1336	1.2955	1.2955
13		1.1336	1.1336	1.2955	
14		1.1336	1.1336	1.2955	
15			1.1336	1.1336	
16		1.1336			
17		1.2955	1.2955	1.2955	
18		1.1336	1.2955	1.1336	
19		.0905	.0905	.0905	.0905
20		.0905	.0905	.0905	.0905
21		.0905	.0905	.0905	.0905
22		.0905	.0905	.0905	.0905
23		.0905	.0905		.0905
24	.4525	.0905	.0905	.0905	.0905
Max	.4525	1.2955	1.2955	1.2955	1.2955
Min	.4525	.0905	.0905	.0905	.0905
Avg	.4525	.4244	.3897	.4592	.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.5144	.4525	.4706	.543		.543
2	.3982	.5658	.4706	.4706	.543	.5792	.543
3	.4163		.4887	.5068	.5792	.5792	.6154
4	.4344	.6687	.5068	.543	.6154	.6878	.6516
5	.4706	.6859	.543	.6154	.6516	.8507	.724
6	.543	.7373	.5973	.7421	.6878	.8145	.8326
7	.5973	.703	.5792	.7602	.724	.8145	.7783
8	.6335	.703	.5792	.6878	.6878	.7059	.7059
9	.5792	.4801	.543	.5792	.5973	.5792	.6335
10		.463	.4344	.4525		.4801	.5068
11	.4525	.3429	.3801	.362	.362	.4287	.3982
12	.4344	.3086	.3439	.3439	.3982	.3982	.362
13	.4163	.3086	.3077	.3258	.3982	.3429	.3439
14	.4163	.3086	.3258	.3077	.362	.3429	.3258
15		.3429	.362		.362	.4525	.362
16		.4115	.3801	.362	.3982	.4525	.362
17	.5068	.4458	.4163	.3982	.4887	.4525	.362
18	.543	.5144	.4887	.5068	.543	.5068	.4706
19		.6001	.7421	.7602	.6878	.6878	.6516
20	.7602	.5487	.7059	.7602	.7602	.724	.724
21	.6335	.5144	.5973	.724	.6516	.6878	.6516
22	.6335	.4801	.5068	.5973	.6154	.6154	.5792
23	.5611	.4458	.5068	.5792	.5068	.5792	.5249
24	.3982	.4973	.4344	.4887	.543	.4458	.543
Max	.7602	.7373	.7421	.7602	.7602	.8507	.8326
Min	.3982	.3086	.3077	.3077	.362	.3429	.3258
Avg	.5113	.5040	.4872	.5367	.5524	.5743	.5498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 205 / NEW DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.004	.6687	.5668	.6478	.6478	.703	.6154
2	1.004	.6687	.6335	.6478	.6802	.7373	.6478
3	1.004	.7202	.6478	.6802	.7125	.7716	.6802
4	1.0526	.7202	.6478	.7125	.7773	.8059	.7125
5	1.1336	.7716	.8097	.7773	.9069	.823	.7449
6	1.2955	.9945	1.2955	.9069	1.1012		
7	1.5546	1.4403	1.5546	1.3765	1.3441	1.4232	1.2955
8	1.4899	1.5261	1.4899	1.4251	1.3279	1.4403	1.2631
9	1.166	1.2689	1.2955	1.2308	1.2308	1.3717	1.2146
10	.1448	.1715	.1267	.1448		.12	.1629
11	.1629	.1372	.1086	.1086	.1448	.12	.1448
12	.1629	.12	.1086	.0905	.1448		.0724
13	.1448	.1372	.1086	.0905	.0905	.1029	
14	.181	.0914	.1086	.0905	.0905		
15	.181	.12	.1086	.1086	.1086	.1086	
16	.1991	.12	.1267	.1086	.1086	.1086	
17	.2172	.1372	.1448	.1267	.1448	.1629	
18	.2172	.1524	.2172	.181	.2172	.181	
19	.2715	.1715	.2896	.2172	.2715	.2353	.2715
20	.2715	.1524	.3077	.2629	.3258	.2534	.3258
21	.2353	.1524	.2353	.2353	.2534	.2353	.2715
22	.2353	.1524	.1991	.1991	.2534	.2172	.2353
23	.2172	.1372	.181	.181	.2172	.181	.2172
24	.4572	.6344	.5668	.6154	.6316	.6516	.583
Max	1.5546	1.5261	1.5546	1.4251	1.3441	1.4403	1.2955
Min	.1448	.0914	.1086	.0905	.0905	.1029	.0724
Avg	.5835	.4736	.4950	.4652	.5101	.5121	.5564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 201 / UJANI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1094	.0309	.0305	.0312	.0154	.0156	.0305
2	.1094	.0309	.0305	.0312	.0309	.0156	.0305
3	.0937	.0309	.0305	.0312	.0309	.0156	.0305
4	.0937	.0309	.0305	.0312	.0309	.0156	.0305
5	.125	.0309	.0305	.0312	.0154	.0156	.0305
6	.1406	.0154	.0305	.0312	.0309	.0156	.0305
7	.1406	.0154	.0305	.0312	.0309	.0156	.0305
8	.125	.0309	.0305	.0312	.0309	.0156	.0312
9	.1094	.0156	.0305	.0312	.0156	.0156	.0312
10	.0937	.0156	.0781	.0156	.0156	.0156	.0312
11	.0937		.0781	.0156	.0156	.3125	.6249
12	1.0623	.6874	.9998	.6405	.7811	.6249	
13	.9686	.6554	.9374	.5468	.7499	.703	
14	.9061	.6562	.5468	.4687	.7343	.6562	
15	.8592	.578	.4531	.4531	.6562	.5624	
16	.5468	.381	.4687	.4999	.6249	.381	
17	.6173	.5487	.6249	.4999	.4843	.4725	
18	.0154	.0305	.0312	.0309	.0156	.0305	
19	.0154	.0305	.0312		.0156	.0305	.0309
20	.0309	.0305	.0312	.0154	.0156	.0305	.0309
21	.0309	.0305	.0312	.0154	.0156	.0305	.0309
22	.0309	.0305	.0312	.0154	.0156	.0305	.0309
23	.0309	.0305	.0156	.0309	.0156	.0305	.0309
24	.1094	.0309	.0305	.0156	.0154	.0156	.0305
Max	1.0623	.6874	.9998	.6405	.7811	.703	.6249
Min	.0154	.0154	.0156	.0154	.0154	.0156	.0305
Avg	.2691	.1725	.1943	.1541	.1834	.1695	.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 202 / RAMESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2187	.1543	.1829	.2031	.1543	.1562	.1372
2	.2187	.1543	.1829	.1875	.1543	.1406	.1219
3	.2031	.1698	.1677	.1875	.1698	.1406	.1219
4	.2031	.1698	.1677	.2187	.1698	.2031	.1372
5	.2343	.1852	.1981	.2187	.1852	.2343	.1677
6	.2812	.216	.2286	.2343	.216	.2656	.1981
7	.3281	.3086	.2743	.2656	.3086	.2812	.2286
8	.2656	.2623	.2896	.2656	.2623	.25	.2591
9	.1875	.2134	.2743	.2743	.1829	.2286	.2439
10	.1677	.1524	.1829	.1829	.1829	.1829	.1677
11	.1677	.1372	.2134	.1829	.1677	.6859	.7011
12	1.4175	1.3413	1.1584	1.2041	1.1888	1.2041	
13	1.4327	1.3108	1.1431	1.2498	1.0822	1.2346	
14	1.4632	1.3108	.884	1.2193	1.0669	1.2041	
15	1.3717	1.2041	1.0517	1.1584	1.0822	1.1584	
16	1.1279	1.0212	1.0936	1.1888	1.0059	1.1126	
17	1.1883	1.1584	1.2342	1.1888	.9907	1.1584	
18	.1389	.1372	.1562	1.2037	.125	.1524	
19	.1389	.2286	.2031	.1543	.1562	.1677	.1698
20	.1389	.2286	.2812	.1543	.1718	.1829	.1543
21	.1698	.1829	.2343	.1698	.1562	.1677	.1698
22	.1543	.1677	.2031	.1852	.1562	.1524	.1852
23	.1543	.1981	.2031	.1543	.1562	.1372	.216
24	.2187	.1698	.2134	.2031	.1698	.1562	.1372
Max	1.4632	1.3413	1.2342	1.2498	1.1888	1.2346	.7011
Min	.1389	.1372	.1562	.1543	.125	.1372	.1219
Avg	.4830	.4493	.4342	.4940	.4026	.4566	.2069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 203 / 11Kv palashi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0154	.0305	.0158	.0152	.0158	.0297
2	.0158	.0305	.0305	.0158	.0152	.0158	.0297
3	.0158	.0762	.0305	.0158	.0152	.0158	.0297
4	.0158	.0762	.0305	.0312	.0762	.0316	.0297
5	.0156	.0154	.0305	.0316		.0316	.0297
6	.0156	.0305	.0305	.0316	.0152	.0316	.0297
7	.0158	.0305	.0305	.0316	.0305	.0316	.0297
8	.0158	.0305	.0305	.0316	.0305	.0312	.0316
9	.0156	.0474	.0305	.0158	.0158	.0158	.0316
10	.0158	.0474	.0158	.0158	.0158	.0158	.0316
11	.0158	.0316	.0158	.0158	.0158	.1581	
12	.2372	.25	.2688	.2214	.3005	.3321	
13	.2688	.2846	.2372	.2372	.3479	.3479	
14	.2688	.3005	.2688	.253	.3321	.3163	
15	.253	.253	.3005	.253	.3479	.2688	
16	.2372	.1829	.3005	.2688	.3163	.2378	
17	.2591	.1981	.3005	.2688	.3163	.2526	
18	.0154	.0305	.0158	.0152	.0158	.0297	
19	.0152	.0305	.0316	.0154	.0158	.0297	.0154
20	.0154	.0305	.0316	.0154	.0158	.0297	.0309
21	.0154	.0305	.0158	.0152	.0158	.0297	.0305
22	.0154	.0305	.0158	.0152	.0158	.0297	.0152
23	.0154	.0305	.0158	.0152	.0158	.0297	.0152
24	.0158	.0152	.0305	.0181	.0152	.0158	.0297
Max	.2688	.3005	.3005	.2688	.3479	.3479	.0316
Min	.0152	.0152	.0158	.0152	.0152	.0158	.0152
Avg	.0752	.0875	.0891	.0777	.1007	.0977	.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 204 / Palashi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2865	.2172	.1991	.2686	.181	.2172
2	.1991	.3045	.2353	.181	.2507	.181	.2172
3	.1991	.3224	.2172	.2353	.2328	.2353	.2353
4	.2715	.3582	.3077	.3258	.3045	.2715	.2715
5	.4163	.4298	.3982	.362	.3582	.4163	.362
6	.5068	.4835	.4706	.4887	.4119	.4525	.5068
7	.4887	.5373	.543	.4887	.499	.5249	.543
8	.543	.4656	.4525	.4525	.4298	.5611	.3982
9	.362	.3982	.3258	.2715	.3982	.4163	.2353
10	.362	.3801	.3258	.3258	.362	.362	.2353
11	.3258	.362	.3258	.362	.362	.2715	.2896
12	.2896	.362	.2715	.3258	.2353	.2715	.2715
13	.3258	.3258	.2715	.3258	.2172	.2353	.2353
14	.362	.3258	.2896	.3439	.2172	.1991	.2172
15	.362	.362	.2896	.3258	.2715	.2353	.2172
16	.362	.2896	.2715	.2534	.2715	.3258	.2715
17	.3224	.2715	.2715	.2534	.3258	.2896	.2715
18	.2865	.3258	.2715	.2686	.5068	.362	.2686
19	.3045	.362	.5792	.2865	.543	.3258	.3224
20	.3224	.3982	.5068	.2686	.5249	.362	.3582
21	.3045	.362	.4525	.2507	.4163	.3258	.3045
22	.2686	.3077	.4163	.3045	.3258	.2715	.2686
23	.2507	.2353	.3258	.3224	.2715	.2353	.2686
24	.2353	.3045	.2172	.1991	.2686	.1991	.2172
Max	.543	.5373	.5792	.4887	.543	.5611	.543
Min	.1991	.2353	.2172	.181	.2172	.181	.2172
Avg	.3294	.3567	.3439	.3092	.3447	.3130	.2918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 201 / 11 KV LAXAMAN DAS
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5144	.8573	.6859
2	.7545	1.1203	.7545
3	1.0288	1.0631	1.0288
4	1.2689	1.0974	1.166
5	1.5432	1.3717	1.2003
6	1.8861	1.7147	1.3546
7	2.1262	2.3148	1.8861
8	2.0576	2.5549	2.1605
9	2.1434	2.4006	2.0576
10	.3258	.2572	2.0062
11	.4115	.2743	.2743
12	.4458	.3086	.2572
13	.4115	.3429	
14	.3601	.3086	
15	.3772	.2743	.2743
16	.4115	.3086	.3086
17	.3944	.3429	.3429
18	.3944	.4287	.3944
19	.4801	.3429	.4115
20	.4458	.3772	.4115
21	.4115	.3944	.3772
22	.3258	.3772	.3429
23	.2743	.3429	.3086
24	.3429	.823	.6516
Max	2.1434	2.5549	2.1605
Min	.2743	.2572	.2572
Avg	.7973	.8333	.8480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 202 / GADEGAON-WAKHARI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5601	.112	.1715
2	.4801	.1029	.1715
3	.4458	.0934	.1372
4	.3772	.0857	.1372
5	.3429	.12	.1029
6	.3086	.1543	.1372
7	.2241	.2054	.1715
8	.2614	.1886	.1886
9	.1715	.1543	.1715
10	.1543	.1029	.1372
11	.8573	.0857	
12	1.2689	.6348	
13	1.3032	.6859	
14	1.3546	.9945	
15	1.5089	1.2689	
16	1.3203	1.0288	
17	1.286	1.0802	
18	1.2003	1.1145	
19	.1543	.1715	
20	.1372	.2401	
21	.12	.1372	
22	.12	.1715	
23	.12	.1372	
24	.5487	.1029	.1372
Max	1.5089	1.2689	.1886
Min	.12	.0857	.1029
Avg	.6094	.3822	.1512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 203 / GADEGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	.6859	.4458
2	.6516	.4115
3	.6173	.4115
4	.5487	.4115
5	.6859	.4801
6	.7545	.6859
7	.9259	.8916
8	.7202	.823
9	.6859	.6516
10	.6859	.6859
11	.5144	.6516
12	.583	.6516
13	.5487	.6859
14	.5144	.7545
15	.5144	.583
16	.583	.6859
17	.583	.6516
18	.5487	.7202
19	.7888	.6859
20	.823	.6516
21	.7716	.7545
22	.6516	.6516
23	.5144	.6859
24	.6516	.5144
Max	.9259	.8916
Min	.5144	.4115
Avg	.6480	.6344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274246 / 33/11 KV AMBE

Feeder No / Name : 201 / 11 KV WAGHATE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4525
Max	.4525
Min	.4525
Avg	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 278032 / 220 KV BHALAWANI

Feeder No / Name : 801 / 220 KV CHANDRABHAGA S.S. NON SHEDDABLE EHV INDUSTRIAL FEEDERS
KARK Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 201 / 11 KV GURUSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0686	.0686	.0686	.0686	.0686	2.2291
2	.061	.0686	.0686		.0686	.0686	2.2291
3	.061	.0686	.0686	.0686	.0686	.0686	2.2291
4	.061	.0686	.0686	.0686	.0686	.0686	2.332
5	.061	.0686	.0686	.0686	.0686	.0686	2.332
6	.061	.0686	.0686	.0686	.0686	.0686	2.4691
7	.061						2.8807
8	.0686						2.8807
9	3.2579	3.155	3.155	3.4979	3.1893	2.9264	
10	3.5322	3.6351	3.2922	3.4979	3.1893	2.8045	
11			3.4294	3.3608	3.3951	2.6825	
12		3.7723	3.4637	3.2579	3.3265	2.8959	
13	3.0864	3.7723	3.7723	2.7435	3.2579	3.0483	
14	8.6591	3.6351	3.4979	2.6825	3.3436	3.0483	
15	3.5151		3.4979	2.6825	3.3265	3.4294	
16	3.155	2.6216	3.4979	3.0178	3.3265	3.1741	
17	.0686	.061	.0686	.0686	.0686	.0686	.0686
18			.0686	.0686	.0686	.0686	.0686
19	.0686		.0686	.0686	.0686	.0686	.0686
20	.0686		.0686	.0686	.0686	.0686	.0686
21	.0686	.061	.0686	.0686	.0686	.0686	.0686
22	.0686	.061	.0171	.0686	.0686	.0686	.0686
23	.0686	.061	.0686	.0686	.0686	.0686	.0686
24	.061	.0686	.0686	.0686	.0686	.0686	.0686
Max	8.6591	3.7723	3.7723	3.4979	3.3951	3.4294	2.8807
Min	.061	.061	.0171	.0686	.0686	.0686	.0686
Avg	1.2464	1.2539	1.2961	1.2206	1.2416	1.1350	1.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 202 / 11 KV HOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.8861	1.829	2.0576	2.0576	1.3717	.3429
2	1.6766	1.8861	1.829	2.2634	2.0576	1.3717	.3429
3	1.6766	1.8861	2.0576	2.2291	2.0576	1.5432	.3429
4	1.8595	2.0576	2.2634	2.4006	2.2634	2.0576	.3429
5	2.0119	2.332	2.2634	2.4006	2.2634	2.2291	.3429
6	2.1033	2.5377	2.4006	2.4006	2.2634	2.2291	.3429
7	2.3015		2.4006	2.4006	2.5377	2.1338	.3429
8	2.6235	2.5377	2.452	2.4006	2.5377	2.1338	.3429
9							2.1948
10							2.3929
17		.3048	.3429	.3429	.3429	.3429	.3429
18		.3048	.3429	.3429	.3429	.3429	.3429
19	.3429	.3048	.3429	.3429	.3772	.3429	.3429
20	.3429	.3048	.3429	.3429	.3429	.3429	.3429
21	.3429	.3048	.3429	.3429	.3429	.3429	.3429
22	.3429	.3048	.3429	.3429	.3429	.3429	.3429
23	.3429	.3048	.3429	.3429	.3429	.3429	.3429
24	.3201	.3429	.3048	.3429	.3429	.3429	.3429
Max	2.6235	2.5377	2.452	2.4006	2.5377	2.2291	2.3929
Min	.3201	.3048	.3048	.3429	.3429	.3429	.3429
Avg	1.2832	1.1733	1.2625	1.3310	1.3010	1.1133	.5597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 203 / 11 KV CHILAIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4115	.4801	.2743	.5487	.2743	1.5432
2	.5144	.4115	.4801	.2743	.5487	.2743	1.8861
3	.5144	.4115	.5144	.2743	.5487	.2743	1.8861
4	.5144	.5487	.5144	.2743	.5487	.2743	1.9204
5	.5144	.6859	.5144	.2743	.5487	.2743	2.0576
6	.5144	.6859	.5144	.2743	.5487	.2743	2.1948
7	.6001						2.8807
8	.5658						2.6063
9	2.4691		3.0178	3.0178	2.6406	3.1207	
10		2.8807	3.4294	3.155	2.9492	3.0864	
11	3.155	3.2922	3.155	2.8654	2.8807	3.2236	
12	3.155	3.6008	3.155	3.2236	2.8121	3.0864	
13	3.155	3.5665	2.7435	3.2236	2.7949	2.9664	
14	3.155	3.3951	3.155	3.1893	2.8121	2.915	
15	3.155	3.155	3.155	3.1893	2.9664	2.8292	
16	3.155	2.4691	2.332	2.692	2.9835	2.9664	
17		.1372	.2743	.2743	.2743	.2743	.2743
18		.5487	.2743	.2743	.2743	.4115	.2743
19	.4115	.6859	.2743	.5487	.2743	.5487	.2743
20	.5487	.5487	.2743	.5487	.2743	.5487	.2743
21	.5487	.5487	.2743	.5487	.2743	.5487	.2743
22	.5487	.4973	.2743	.5487	.2743	.5487	.2743
23	.5487	.4973	.2743	.5487	.2743	.5487	.2743
24	.5144	.4115	.4801	.2743	.5487	.2743	.5487
Max	3.155	3.6008	3.4294	3.2236	2.9835	3.2236	2.8807
Min	.4115	.1372	.2743	.2743	.2743	.2743	.2743
Avg	1.3701	1.3995	1.3437	1.3531	1.3000	1.3429	1.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 204 / 11 KV GURSALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.7202	.6516	.5144	.6859	.5144	.583
2	.6859	.7202	.6516	.5144	.6859	.5144	.583
3	.6859	.7202	.6859	.5144	.6859	.5144	.583
4	.823	.9945	.6859	.5487	1.0631	.6516	.7888
5	.9602	1.0974	.9602	.6516	1.2003	.6859	.823
6	1.0802	1.1317	1.0974	.7545	1.2346	1.0288	1.0288
7	1.0631		1.166	.9259	1.2003	1.0974	.9602
8	.9259	.9602	.9945	1.0288	.9259	.7545	.8573
9	.7545	.8573	.8573	.7202	.7716	.7373	.6516
10			.7888	.6516	.6516	.5487	.6516
11	.7202		.6173	.6859	.5487	.4973	
12	.7202	.7716	.583	.6859	.5144	.4801	.3772
13	.6516	.6173	.5144	.6516	.4973	.4287	
14	.583	.583	.5144	.5487	.4115		.3944
15	.6516		.5144	.5144	.4115	.4458	.3772
16	.7545	.7202	.4801	.5487	.4115	.463	.4458
17		.7545	.6516	.5487	.5487	.5144	.4458
18		1.0288	.9259	.6516	.6859	.7125	.4458
19	1.0288	1.166	1.2346	1.2003	.7545	.9945	.7545
20	1.0288	1.1317	1.0288	1.1317	.7202	.8916	.7545
21	.9602	.8573	.9259	.9602		.7888	.7202
22	.7888	.823	.6859	.7888	.6859	.6859	.6859
23	.7545	.7202	.5487	.6859	.5487	.6173	.6173
24	.6687	.7202	.6516	.5144	.6859	.5144	.6173
Max	1.0802	1.166	1.2346	1.2003	1.2346	1.0974	1.0288
Min	.583	.583	.4801	.5144	.4115	.4287	.3772
Avg	.8075	.8548	.7673	.7059	.7187	.6557	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 206 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435	2.7778	2.7778	2.7435	2.2291	.2058
2	2.7435	2.7435	2.7778	2.7778	2.7435	2.2291	.2058
3	2.7435	2.9492	3.0864	2.9492	3.0864	2.572	.2058
4	3.1722	3.1722	3.0864	2.9492	3.0864	3.3951	.2058
5	3.4294	3.5665	3.4294	3.0864	3.4294	3.3951	.2058
6	3.7037	3.8237	3.6008	3.6008	3.7551	3.9609	.3086
7	.1372	3.7037	3.7037	3.6008	3.7723	3.9438	.4115
8	.1372	3.8409	3.9438	3.9438	3.7723	3.9438	.4115
9							3.4294
10							3.5494
17	.1372	.1372	.1372	.1372	.1372	.2401	.1372
18		.2743	.1372	.1372	.1372	.2401	.1372
19	.1372	.2743	.1372	.2743	.0137	.2915	.1372
20	.1372	.2743	.1372	.2743	.1372	.3086	.1372
21	.1372	.1372	.1372	.1372	.1372	.2401	.1372
22	.1372	.1372	.1372	.1372	.1372	.2401	.1372
23	.1372	.1372	.1372	.1372	.1372	.2401	.1372
24	.5944	.1372	.1372	.1372	.1372	.1372	.2401
Max	3.7037	3.8409	3.9438	3.9438	3.7723	3.9609	3.5494
Min	.1372	.1372	.1372	.1372	.0137	.1372	.1372
Avg	1.3485	1.7533	1.7190	1.6911	1.7102	1.7254	.5744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 207 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17	.463		.5316	.3086	.3601	.3429	.4115
18			.3772	.4458	.4115	.4115	.4115
19	.4115		.3772	.4287	.4115	.4115	.463
20	.4115		.3772	.4115	.3429	.4115	.4115
21	.4115		.3772	.4115	.3429	.4115	.4115
22	.4115		.3772	.4115	.3429	.4115	.4115
23	.4115		.3772	.4115	.3429	.4115	.4115
24	.3772	.4115		.3429	.4115		.4115
Max	.463	.4115	.5316	.4458	.4115	.4115	.463
Min	.3772	.4115	.3772	.3086	.3429	.3429	.4115
Avg	.4140	.4115	.3993	.3965	.3708	.4017	.4179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 201 / 11 KV UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0526		.8642
2			1.2289		.9175
3			1.3565		1.17
4			1.4413		1.1523
5			1.4575		1.4089
6			1.4746		1.5061
7			1.5261		.9831
8			1.4575		1.668
9		1.1336		1.4575	
10		.0983			
12		.1143	.1029		
13		.1143			
14		.1143			
15		.1143			
16		.1143			
17		.1143			
18		.1143			
19		.1143		.2715	
20		.1143		.2715	
21		.1143		.2715	
22		.1143		.1867	
23		.1143		.181	
24	.6613		.9717		.1905
Max	.6613	1.1336	1.5261	1.4575	1.668
Min	.6613	.0983	.1029	.181	.1905
Avg	.6613	.1860	1.2070	.4400	1.0956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 202 / 11 KV SANGAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2267		.1905
2	.2286		.2507		.1905
3	.2477		.2267		
4	.2667		.2715		.1905
5	.2667		.2715		.1905
6	.2667		.2534		.1905
7	.2667		.2534		.1905
8			.2534		
9		.1905			
10		.1905		1.4752	
11				1.4413	
12		2.0317			
13		2.0481		1.2146	
14		2.13		1.2717	
15		2.13		1.3226	
16		2.0405		1.2631	
17		1.9433			
18		1.6549			
19		.362		.1886	
20		.2667		.2667	
21		.2667		.2667	
22		.2667		.181	
23		.2667		.1886	
24	.2667		.2294		.1905
Max	.2667	2.13	.2715	1.4752	.1905
Min	.2286	.1905	.2267	.181	.1905
Avg	.2548	1.1277	.2485	.8255	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 203 / 11 KV RANMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3735		1.4255		.9831
2	1.848		1.6108		1.0526
3	1.9624		1.4582		1.2146
4			1.8842		1.2955
5	2.3434		2.2043		1.4746
6	2.6292		2.3482		1.491
7	2.7244		2.4249		1.4243
8			2.3482		1.5083
9		2.2672		1.7814	
17		.3982			
18		.3887			
19		.426		.4572	
20		.4161		.5068	
21		.4409		.5068	
22		.426		.4525	
23		.4409		.4668	
24	.5944		1.3565		.4096
Max	2.7244	2.2672	2.4249	1.7814	1.5083
Min	.5944	.3887	1.3565	.4525	.4096
Avg	1.9250	.6505	1.8956	.6953	1.2060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 204 / 11 KV JADHAVWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.1905
2			.1905
3			.3429
4			.3429
5			.362
6			.362
7			.3239
8			.362
9		1.9433	
10		.16	
11		.1638	
12		.1791	
13		.0953	
14		.0905	
15		.0905	
16		.0905	
17		.0953	
18		.1905	
19		.1905	
20		.1905	
21		.1905	
22		.1905	
23		.1905	
24	.5944		.1905
Max	.5944	1.9433	.362
Min	.5944	.0905	.1905
Avg	.5944	.2701	.2964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 205 / 11 KV BARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9281		.3605
2			2.2043		.3841
3			2.34		.3932
4			2.4249		.4915
5			2.4939		.4858
6			2.5911		.373
7			2.7199		.3887
8			2.9165		.407
9		2.6558			
10		.1781			
11		.1638			
12		.1865			
13		.1865			
14		.1867			
15		.1619			
16		.2035			
17		.3258		3.0011	
18		.3224		2.5911	
19		.3224		2.4577	
20		.3224		2.2447	
21		.3155		1.8023	
22		.3258		1.8652	
23		.3155		1.8652	
24	.5944		.7122		1.8107
Max	.5944	2.6558	2.9165	3.0011	1.8107
Min	.5944	.1619	.7122	1.8023	.3605
Avg	.5944	.4115	2.2590	2.2610	.5661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 206 / 11 KV Karkamb Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5601		.3696
2			.543		.362
3			.5487		.543
4					.5487
5			.7316		.7392
6			.7468		.724
7			.724		.724
8			.724		.724
9				.5258	
10		.543		.5373	
11		.7087		.5201	
12		.7316		.5201	
13		.5487		.543	
14		.5601		.5258	
15		.543		.543	
16		.543		.543	
17		.5601		.5373	
18		.543		.7011	
19		.543		.6935	
20		.5601		.7164	
21		.543		.5258	
22		.5601		.3506	
23		.543	.6401	.362	
24	.4239		.543		.362
Max	.4239	.7316	.7468	.7164	.7392
Min	.4239	.543	.543	.3506	.362
Avg	.4239	.5736	.6401	.5430	.5663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 207 / 11 KV Diwan Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6004		.6859
2			1.6385		.8573
3			1.7147		1.3032
4			2.0957		1.6289
5			2.0957		1.7375
6			2.2862		2.0911
7			2.3624		2.3819
8			2.2862		2.6981
9		1.9052		1.9052	
16		.1905			
17		.0953			
18		.0953			
19		.1715		.3048	
20		.1715		.2715	
21		.1334		.2858	
22		.1334		.1905	
23		.1334		.1334	
24	.9892		1.1812		.1334
Max	.9892	1.9052	2.3624	1.9052	2.6981
Min	.9892	.0953	1.1812	.1334	.1334
Avg	.9892	.3366	1.9179	.5152	1.5019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 208 / 11 KV DESHMUKH PATT
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1905		.1905
2			.1905		.1905
3					.1905
4			.2667		.2858
5			.2667		.2858
6			.2667		.2858
7			.2667		.1905
8			.2667		
10		.3258		2.4768	
11		1.9662		2.4768	
12		2.1052			
13		2.1052		2.4387	
14		1.7166		2.3624	
15		1.7368		2.6101	
16		1.6964		2.572	
17		1.9044			
18		2.0178			
19		.2543		.2858	
20		.2543		.2858	
21		.1696		.1905	
22		.1848		.1905	
23		.1867	.1905	.1905	
24	.9665		.1905		.1905
Max	.9665	2.1052	.2667	2.6101	.2858
Min	.9665	.1696	.1905	.1905	.1905
Avg	.9665	1.1874	.2328	1.4618	.2262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 209 / 11 KV GULAME FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.3582
2			.3239
3			.4024
4			.3982
5			.4534
6			.543
7			.4915
9		1.7814	
10		1.9433	
11		1.9433	
12		1.9433	
13		1.8023	
14		1.7604	
15		1.8023	
16		1.7604	
19		.3582	
20		.3582	
21		.3277	
22		.362	
24	.6613		.3277
Max	.6613	1.9433	.543
Min	.6613	.3277	.3239
Avg	.6613	1.3452	.4123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 201 / 11 KV MENDHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6161	.7468	.5658	.5601	.6219	.2561
2	.5601	.5975	.6535	.5281	.5601	.6584	.2378
3	.5975	.5975	.6535	.5658	.5975	.695	.2195
4	.6348	.6908	.6535	.547	.6602	.7316	.3109
5	.6722	.7655	.7468	.5658	.7842	.7316	.4207
6	.7468	1.0082	.7468		.8775	1.0608	.6401
7	.9709	1.1203					1.0791
8	3.3846	3.4008	1.2955	3.5789	2.8016	3.255	.6401
9	3.5627	3.5627		3.7409	3.5303	3.3036	.695
10	3.5141	3.6437	3.336	3.4008	3.6923	3.1417	.5853
11	3.4332	3.0769	3.6761	3.6599	3.7247	3.3522	
12	3.3198		3.7894	3.6599	3.6923	3.2874	
13	3.1741	3.7571	3.7732	3.3198	3.4008	3.1903	
14	3.1093	3.6437	3.3522	3.1255	3.1579	2.9797	
15	3.0607	3.4979	3.3198	2.8826	3.0445	2.9312	.5121
16	.7733	.3772	.6722	.5975	.5228	.8413	
17	.811	.4715	.5415	.6908	.4668	1.0608	3.5141
18	.811	.4668	.6348	.7655	.5228	.6767	3.255
19	.8402	.7468	.7468	.8402	1.1203	.7499	2.5263
20	.9619	1.1203	.9335	.9335	1.0456	.7682	2.5911
21	1.0642	.7468	.6908	.9709	.9335	.7499	2.5587
22	.9335	.8402	.7282	.8589	.7095	.4024	2.5263
23	.8589	.7842	.7282	.7468	.6535	.2012	1.8947
24	.5975	.7842	.7468	.4715	.5975	.5853	.3109
Max	3.5627	3.7571	3.7894	3.7409	3.7247	3.3522	3.5141
Min	.5601	.3772	.5415	.4715	.4668	.2012	.2195
Avg	1.6246	1.5790	1.5075	1.6826	1.6372	1.5642	1.3039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 202 / 11 KV KHARATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2388		1.4575	1.7004	1.7328	1.5708	.0914
2	1.6194		1.6194	1.8138	1.7328	1.5708	.0914
3	1.749		1.7814	1.7652	1.8947	1.587	.0924
4	1.7652		1.9433	1.8299	1.9595	1.587	.0914
5	2.0405		2.0243	1.9757	2.1376	1.6194	.1097
6	2.2996		2.3805	2.1376	2.251	1.7166	.128
7	2.3805		2.17	2.0243	1.9433	2.1052	.1478
8	.2241				.1132	.1829	2.0243
9	.2241				.1132	.1463	2.1052
10	.1867				.1132	.1463	2.1052
11	.1867				.1132	.1463	
12	.1494	.0934			.1132	.128	
13	.1494	.0934		.0943	.1132	.128	
14	.0934	.0934		.0934	.132	.128	
15	.0934	.0934		.112	.132	.1097	1.6356
16	.0934	.0934	.1307	.112	.132	.1646	
17	.112	.0934	.1307	.1307	.132	.1829	
18	.112	.112	.1494	.1307		.1646	
19	.1307			.1307		.1463	.1829
20				.1132	.2263	.1463	.1829
21				.112	.2263	.1646	.1463
22				.0943	.1509	.128	.1463
23				.0943	.1509	.1097	.1097
24	1.5384		1.4575	1.7166	1.668	1.5546	.1097
Max	3.2388	.112	2.3805	2.1376	2.251	2.1052	2.1052
Min	.0934	.0934	.1307	.0934	.1132	.1097	.0914
Avg	.9193	.0961	1.3859	.8516	.7855	.6514	.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 203 / 11 KV PANDHAREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.12	.1886	.2241	.1307	.1463	2.1376
2	.1494	.132	.1886	.1867	.1307	.1463	2.1052
3	.1494	.1698	.2263	.2641	.168	.1829	2.0729
4	.1867	.2075	.2263	.2829	.2054	.2561	2.2672
5	.2241	.2452	.2829	.3395	.2452	.2926	2.1862
6	.2987	.3395	.3206	.3772	.3361	.3475	2.1052
7	.3734	.3584		.3584	.5041	.3658	2.0081
8	.3174	.2829			.2987	.3109	.1829
9	.2829				.168	.2743	.1463
10	.2263				.1307	.1829	.1463
11	.1698				.0934	.0914	
12	.1509				.0934	.0914	
13	.1509	.132		.1132	.0934	.0914	
14	.1509	.1509		.132	.0934	.0732	
15	.1698	.0943		.0754		.0732	.0914
16	2.0891	2.0891	1.6842	1.8947	1.9109	1.3765	
17	1.9271	2.17	1.9109	2.2834	1.9433	1.8138	
18	1.7328	1.9595	1.9757		2.2024	2.2672	
19	1.6518		2.0729	2.1376	2.1052	2.2834	.1829
20	1.5708	1.587	1.9595	2.0891	2.0405	2.2348	.2926
21	1.5061	1.7814	1.8623	1.9595	1.9109	2.1862	.2012
22	1.4413	1.6356	1.7814	1.8623	1.7652	2.1214	.1829
23	1.3927	1.5546	1.6842	1.6194	1.7976	2.1862	.1463
24	.1307	.132	.1886	.2054	.1307	.1463	2.2186
Max	2.0891	2.17	2.0729	2.2834	2.2024	2.2834	2.2672
Min	.1307	.0943	.1886	.0754	.0934	.0732	.0914
Avg	.6914	.7969	1.1035	.9114	.8043	.8143	1.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 204 / 11 KV Jadhavwadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.1372	.2641	.2829	.3018	.2926	1.9109
2	.2987	.1509	.2829	.2641	.3018	.2926	2.1862
3	.3361	.1698	.3018	.3018	.3395	.3292	2.2996
4	.3361	.1698	.3395	.3584	.3584	.3658	2.5425
5	.3734	.1886	.3395	.3772	.3961	.4024	2.672
6	.4108	.1886	.3772	.4338	.4715	.4755	2.7854
7	.4668	.2058	.4527	.4715	.415	.4024	2.8988
8	.4294	.1886	.415	.3772	.3772	.3658	3.0121
9	.3206	.1715	.3734	.3206	.3018	.2926	3.1255
10	.2829	.1886	.1867	.2263	.2641	.1829	.1646
11	2.5911	2.753	2.7206	2.2834	1.9109	1.668	
12	3.4332	2.834	2.7854	2.7692	3.1741	2.7206	
13	3.3198	3.0121	2.753	2.9959	3.0121	2.8016	
14	3.1255	2.3967	2.7854	3.0769	2.8502	2.753	
15	3.0283	2.5101	2.834	2.8178	2.9473	2.5911	.1463
16	3.6761	2.7692	2.753	2.9797	2.915	2.7692	.128
17	3.3198	2.9959	2.9473	3.1093	2.1376	2.8826	.1463
18	3.0769	2.834	3.0445	2.7206	2.5101	2.9312	.2378
19	.132	.3772	.1867	.2263	.3395	.2743	.4024
20	.132	.3772	.2241	.3361	.3961	.3109	.3658
21	.1509	.3395	.2427	.3961	.3395	.3475	.2926
22	.1509	.3206	.2801	.3584	.3395	.3658	.3292
23	.1509	.3395	.2987	.3206	.3206	.3292	.3109
24	.2987	.1509	.2641	.2829	.3206	.2926	1.4737
Max	3.6761	3.0121	3.0445	3.1093	3.1741	2.9312	3.1255
Min	.132	.1372	.1867	.2263	.2641	.1829	.128
Avg	1.2558	1.0737	1.1439	1.1703	1.1267	1.1016	1.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 205 / 11 KV Ropale Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4251	1.3765	1.3765	1.4251	1.3927	1.3279	.1829
2	1.4251	1.3765	1.4575	1.5708	1.4575	1.3279	.1646
3	1.4575	1.4899	1.4575	1.7004	1.5223	1.4575	.2012
4	1.4899	1.5708	1.6194	1.8299	1.587	1.587	.2195
5	1.587	1.668	1.7814	2.0243	1.7328	1.6194	.2378
6	1.9271	1.9757	1.8623	2.1376	1.9757	1.749	.2195
7	2.2996	2.2024	2.3158	2.251	2.2834	2.1052	.2195
8	2.1052	2.1214	2.4615	2.2834	2.3644	2.2834	.1829
9	2.2024	1.9919	2.2186	2.3644	2.5425	2.2186	.1646
10	.1698	.1132	.112	.112	.132	.128	
11	.1509	.1132	.0934	.112	.132	.1097	
12	.132	.1132	.0747	.112	.1132	.1097	
13	.132	.1132	.0747	.112	.132	.0914	
14	.1132	.1132	.056	.0934	.132	.0914	
15	.1132	.1132	.0934	.0934	.0566	.0914	2.3158
16	.1132	.1132	.1109	.112	.0934	.128	2.4777
17	.132	.1132	.1294	.112	.1132	.1463	2.5263
18	.132	.132	.1294	.1509	.1509	.1646	1.749
19	.132	.2263	.1494	.1509	.1886	.1646	.1848
20	.1509	.3772	.168	.168	.2452	.2195	.2012
21	.1698	.2263	.1867	.168	.1886	.2378	.128
22	.1698	.2263	.168	.1886	.1509	.2561	.128
23	.1509	.1886	.1494	.1886	.1509	.2561	.128
24	1.3927	1.3117	1.2955	1.3279	1.3603	1.2955	.2195
Max	2.2996	2.2024	2.4615	2.3644	2.5425	2.2834	2.5263
Min	.1132	.1132	.056	.0934	.0566	.0914	.128
Avg	.8031	.8070	.8142	.8662	.8416	.7986	.6237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 201 / 11 KV DEWADE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.046	1.0631	1.1831	1.0669	1.4918	.463
2	1.2193	1.1145	1.166	1.2689	1.0669	1.4575	.4801
3	1.3717	1.286	1.2003	1.3717	1.0669	1.7147	.4973
4	1.3717	1.286	1.3717	1.4403	1.0669	1.7147	.5144
5	1.4022	1.4575	1.5432	1.4575	1.3717	2.0748	.5658
6		1.6461	1.7147	1.4403	1.6766	2.0748	.6173
7	1.3717	1.8176	1.749	1.3717	1.9814	2.0748	.6344
8	1.6156	1.9033	1.7147	1.4918	1.9814	2.0748	
9	1.6766	1.6461	1.7833		1.9052	1.9719	
10	.3429	.2572	.1715	.3086	.2743	.3086	
11	.2915	.1886	.1715	.2572	.2572	.3601	
12	.1886	.3086	.1543	.2058			
13	.2229			.0857			
14	.2572						
15	.2572						
16	.2915						
17	.2743						
18	.2743						
19	.4801	.5487	.3772	.463	.4115	.4458	
20	.4801	.5144	.4287	.463	.4115	.4458	
21	.4801	.5144	.4115		.4287	.463	.5144
22	.4458	.4801	.3601	.5144	.463	.4801	.6001
23	.4458	.4458	.3772	.4458	.463	.463	.6173
24	.9297	.8573	.9945	1.0288	.9145		.4458
Max	1.6766	1.9033	1.7833	1.4918	1.9814	2.0748	.6344
Min	.1886	.1886	.1543	.0857	.2572	.3086	.4458
Avg	.7253	.9621	.9307	.8704	.9887	1.2260	.5409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 202 / 11 KV WATER SUPPLY FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.5944
Max	.5944
Min	.5944
Avg	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 203 / 11 KV PAT KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.0004
Max	1.0004
Min	1.0004
Avg	1.0004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 204 / 11 KV SHEVATE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0857	.0857	.1029	.0686	.4287
2	.1029	.0857	.0857	.0686	.1029	.0686	.4458
3	.1029	.0857	.0857	.0857	.1029	.0857	.4801
4	.1029	.1029	.0857		.1029	.1029	.5144
5	.1029	.12	.0857	.0857	.12	.1029	.5487
6	.1029	.12	.1029	.0857	.12	.12	.5658
7	.12	.12	.12	.0857	.1029	.12	.583
8	.12	.12	.1029	.0857	.1029	.12	
9	.12	.12	.0857		.0857	.0857	
10	.0857	.12	.5144	.0857	.0514	.0514	
11	.5639	.12	.5144	.0686	.4115	.4287	
12	.6249	.7716	.8916	.7716	.5335	.823	
13	.7011	.7888	.8745	.7716	.6249	.8916	
14	.6401	.8059	.8916	.7888	.6859	.9088	
15	.7468	.8573	.8402	.7716	.7316	.8745	
16	.8078	.8916	.8573	.823	.7011	.8573	
17	1.3717	.823	.8916	.8573	.6859	.8573	
18	.5792	.7716	.8916	.7202	.6859	.823	
19	.1029	.0857	.12	.0686	.0857	.0857	
20	.1029	.1029	.1029	.0857	.0857	.0857	
21	.1029	.1029	.0857		.0857	.0686	.0857
22	.12	.0857	.1029	.0857	.0686	.0686	.0857
23	.12	.0857	.1029	.0686	.0686	.0857	.0857
24	.1029	.12	.0857	.0686	.1029	.0686	.3601
Max	1.3717	.8916	.8916	.8573	.7316	.9088	.583
Min	.0857	.0686	.0857	.0686	.0514	.0514	.0857
Avg	.3229	.3115	.3586	.3152	.273	.3272	.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 205 / 11 KV OLD NANDURE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6613
Max	.6613
Min	.6613
Avg	.6613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 206 / 11 KV PAT.KUROLI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.884
Max	.884
Min	.884
Avg	.884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 207 / New Nandure

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.884
Max	.884
Min	.884
Avg	.884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 208 / taratgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.5944
Max	.5944
Min	.5944
Avg	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 209 / 11 Kv khed Bhose

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9496
Max	.9496
Min	.9496
Avg	.9496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 201 / 11 KV TUNGAT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6613
Max	.6613
Min	.6613
Avg	.6613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 202 / 11 KV SUSTE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.6706	.7926	.7621		.5792	.0343
2	.7011	.7011	.7926	.7926		.6097	.0343
3	.7316	.7316	.823	.7926	1.0974	.6706	.0343
4	.7621	.7621	.8535	.8688		.7316	.0343
5	.7926	.823		.884		.7926	.0343
6	.8535	.8535	1.2003	1.0059		.9145	.0343
7		1.0974	1.2803	1.1584	1.0974	1.2193	.0343
8		1.2498	1.2803	1.1888		1.2803	.0343
9		1.2803	1.2193		1.1584	1.2803	.0343
10		.0343	.0343		.0343		.0343
11	.0343	.0343	.0343		.0343	.0343	.6401
12	.0343	.0343	.0343	.0171	.0343	.0343	1.2803
13	.0343	.0343	.0343		.0343	.0343	
14	.0343	.0343	.0343		.0343	.0343	1.1279
15	.0343	.0343	.0343		.0343	.0343	1.2193
16	.0343	.0343	.0343	.0171	.0343		1.2498
17	.0343	.0343	.0343		.0343	.0343	1.1888
18	.0343	.0343	.0343		.0343	.0343	1.1279
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343		.0343	.0343	.0343
22	.0343	.0343	.0343		.0343	.0343	.0343
23	.0343	.0343	.0343	.0171	.0343	.0343	.0343
24	.6706	.6097	.7926	.7316	.5487	.5487	.0343
Max	.8535	1.2803	1.2803	1.1888	1.1584	1.2803	1.2803
Min	.0343	.0343	.0343	.0171	.0343	.0343	.0343
Avg	.2814	.3858	.4137	.6362	.2435	.4108	.3645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343		.0343	1.5546
2	.0343	.0343	.0343	.0343		.0343	1.5851
3	.0343	.0343	.0343	.0343		.0343	1.6461
4	.0343	.0343	.0343	.0343		.0343	1.6766
5	.0343	.0343	.0343	.0343		.0343	1.6766
6	.0343	.0343	.0343	.0343		.0857	1.7071
7		.0343	.0343	.0343	.0171	.0343	2.0424
8		.0343	.0343	.0343		.0343	2.1338
9		.0343	.0343	.0343	.0343	.0343	2.1948
10		.0343	.0343		.0343		.0343
11	1.5242	1.768	1.6461		1.829	1.9814	.0343
12	2.1338	2.3167		1.768	2.1643	2.6216	.0343
13	2.3167	2.3472	2.2558		2.2405	2.5606	
14	2.0576	2.3167			2.0729	2.6825	.0343
15	2.3777	2.4387			2.2253	2.3777	.0343
16	2.3167	2.1033		1.829	2.1338		.0343
17	2.3777	2.2862			2.2558	1.9509	.0343
18	2.1338	2.1643	2.1186		2.1338	2.4691	.0343
19	.0343	.0343	.0343	.0171	.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343		.0343	.0343	.0343
22	.0343	.0343	.0343		.0343	.0343	.0343
23	.0343	.0343	.0343	.0171	.0343	.0343	.0343
24	.0171	.0343	.0343	.0343	.0171	.0343	1.4937
Max	2.3777	2.4387	2.2558	1.829	2.2558	2.6825	2.1948
Min	.0171	.0343	.0343	.0171	.0171	.0343	.0343
Avg	.8816	.7621	.3458	.2839	1.0194	.7823	.7894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 204 / 11 KV NARANCHOLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.829	1.448	1.2498		1.2498	.0857
2	1.6461	2.0119	1.448	1.2651		1.3413	.0857
3	1.7985	2.1033	1.448	1.326		1.4175	.0857
4	1.9509	2.2253	1.6766	1.4632		1.5242	.1029
5	2.0424	2.2862	1.8138	1.7071		1.7528	.1372
6	2.1643	2.3777	2.2558	1.9814		1.89	.1543
7		2.774	3.0007	2.5758	2.332	2.4082	.1715
8		2.4387		2.1491	2.4234	2.4082	.1715
9		2.774		2.1643	2.3015	2.4387	
10		.1372			.1715		
11	.2058	.0686			.1543		1.2498
12	.1715	.1029	.12	.1372	.12		2.0881
13	.1543	.1372	.12		.1029	.0857	
14	.1372	.12	.1029		.0857	.0857	1.8442
15	.12	.1372	.1372		.0914	.0857	2.1033
16	.1372	.1029	.1029	.1372	.1029		2.2862
17	.12	.12			.168	.0857	1.9204
18	.1543	.1543	.1372		.1715	.1372	1.89
19	.1715	.2058	.1886	.2401	.1886	.1715	.1715
20	.1543	.1715	.2058		.1715	.1715	.1543
21	.1372	.1543	.1715		.1715	.1543	.1372
22	.12	.1372	.1543		.1543	.1543	.12
23	.1029	.1372	.1372	.2058	.12	.1372	.12
24	2.5301	1.5242	1.448	1.2193	1.448	1.2041	.1029
Max	2.5301	2.774	3.0007	2.5758	2.4234	2.4387	2.2862
Min	.1029	.0686	.1029	.1372	.0857	.0857	.0857
Avg	.7771	1.0096	.8482	1.2730	.5822	.9452	.7230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 205 / 11 KV TUNGAT GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.3429	.3601		.4115	.3601
2	.4115	.4458	.3429	.3601		.4458	.3772
3	.4287	.4801	.3772	.3772	.4287	.4801	.3601
4	.4801	.5144	.3944	.4115		.5144	.3944
5	.5144	.5487	.4801	.463		.5487	.4973
6	.6001	.6173	.6001	.5487		.583	.6001
7		.5487	.5658	.583	.6344	.6173	.6001
8		.5658	.5144	.4801	.4973	.5144	.5316
9		.3944	.4287	.3772	.3429	.3772	.4287
10		.3772	.3944		.4115		.3944
11	.4458	.3601	.3772		.3429	.3601	.3086
12	.3944	.3772	.2743	.2915	.3086	.3086	.3086
13	.3601	.3086	.2743		.2915	.2915	
14	.3258	.3086	.2572		.2743	.2915	.2572
15	.3258	.3086	.2572		.2401	.2572	.2915
16	.3772	.2401	.2743	.2915	.2572		.3429
17	.3601	.3258			.2743	.3086	.3601
18	.3772	.4115	.3772		.3772	.3944	.3601
19	.4973	.5658	.5658	.6344	.5144	.583	.5658
20	.4801		.5144		.5316	.583	.583
21	.4458	.4973	.4801		.5144	.4801	.4973
22	.4287	.4287	.463		.4458	.4458	.463
23	.3944	.0343	.4115	.3772	.4115	.4287	.4287
24	.4287	.3772	.3601	.3772	.3944	.3772	.3772
Max	.6001	.6173	.6001	.6344	.6344	.6173	.6001
Min	.3258	.0343	.2572	.2915	.2401	.2572	.2572
Avg	.4227	.4108	.4055	.4238	.3944	.4365	.4212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 201 / 11 KV KANHAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1696	.1696		2.5029
2			.1696	.1696		2.5692
3			.2035	.1865		2.652
4			.2035	.2035		2.7681
5			.2374	.2374		2.652
6			.2374	.2374		2.7681
7			.2374	.2713		2.9007
8			.2204	.2591		3.0001
9			.1187	.2267		3.0664
10	.1865		.1187			.116
11	2.0348		.1187		1.8233	.1658
12	3.3065		3.2386		3.63	
13	3.3404		3.2217		3.4642	
14	3.3573	3.7304	3.3913		3.5305	
15	3.3234	3.6456	3.5608		3.3648	
16	3.3065	3.6456	3.2217		3.4145	
17	3.2726	3.5608	3.086		3.315	
18	3.2217	3.2895	3.0352		2.652	.1492
19		.0339	.1357		.1658	.1658
20		.1187	.1696		.1989	.1989
21		.1187	.1696		.1492	.1492
22		.1187	.1696		.1823	.1989
23		.1187	.1696		.1326	.1658
24	.1823		.1696	.1696	.1715	2.4034
Max	3.3573	3.7304	3.5608	.2713	3.63	3.0664
Min	.1823	.0339	.1187	.1696	.1326	.116
Avg	2.5532	1.8381	1.0739	.2131	1.8710	1.5885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 202 / 11 KV KAROLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1029	.1147		1.5257
2		.08	.1029	.1147		1.6667
3		.0983	.1029	.0983		1.6194
4			.12	.0983		
5		.1097	.12	.1147		1.7337
6		.0972	.1372	.1147		
7		.1086	.1029	.1147		1.8233
8		.0869	.1029	.0983		1.6289
9		.0743	.1029	.0983		1.4403
10	.0827	.1217	.1029			.1355
11	1.0802	1.7147	1.1431		2.1776	.1
12	1.7802	2.3205	2.4539		2.2961	
13	1.8397	2.42	2.2138		2.191	
14	2.42	2.3205	2.2138		2.2018	
15	1.7461	2.1548	2.0557		2.0243	
16	1.8397	2.0719	2.0557		2.1136	
17	1.8261	2.0885	2.0557		2.0243	
18	2.0271	1.9725	2.0557		1.8976	.1075
19	.128	.1715	.1107		.1054	.0857
20	.1267	.1715	.1265		.08	.048
21	.112	.1524	.1265		.1158	.0663
22	.1107	.1017	.1265		.0934	.0857
23	.0983	.1029	.1524		.0834	.1147
24	.1715	.0762	.1029	.1311	.1372	1.307
Max	2.42	2.42	2.4539	.1311	2.2961	1.8233
Min	.0827	.0743	.1029	.0983	.08	.048
Avg	1.0259	.8143	.7538	.1098	1.2530	.8430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 203 / 11 KV UMBRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	1.0717	1.1431		
2		1.448	1.0717	1.1431		
3		1.0574	1.0717	1.1431		
4		1.1431	1.1431	1.2193		
5		1.2003	1.1431	1.2193		
6		1.2289	1.1431	1.2955		
7		1.286	1.2146			
8		1.4003	1.2146	1.2955		
9		1.5718	1.286	1.2955		
10	.0572	.0572	.0572			
11	.0572	.0572	.0572		.0572	
12	.0572	.0572	.0572		.0572	
13	.0572	.0572	.061		.0572	
14	.0572	.0572	.061		.0572	
15	.0572	.0572			.0572	
16	.0572	.0572	.0457		.0572	
17	.0572	.0572	.0457		.0572	
18	.0572	.0572	.0457		.0572	
19		.0556	.061		.0572	
20	.0572	.0572	.061		.0572	
21	.0572	.0572	.061		.0572	
22	.0572	.0572	.061		.0572	
23	.0572		.061		.0572	.0572
24	.7716	1.0002	1.0574	1.0669	1.2003	
Max	.7716	1.5718	1.286	1.2955	1.2003	.0572
Min	.0572	.0556	.0457	1.0669	.0572	.0572
Avg	.1082	.5699	.5284	1.2024	.1389	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 204 / 11 KV UMBRE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5068	.407	.415		.415
2		.4755	.407	.415		.3696
3		.5228		.4527		.362
4		.4534	.5087	.5658		.415
5		.5487	.6104	.6036		.4435
6		.5853	.5765	.679		.4706
7		.5853	.5426	.6036		.5121
8		.5544	.4409	.5068		.5281
9		.5175	.3391	.4706		.439
10	.4755	.4359	.4748			.4066
11	.4344	.4024	.4359		.3772	.4298
12	.4115	.3429	.2103		.3898	
13	.3658	.2058	.2058		.3429	
14	.3658	.2058	.2743		.2774	
15	.3361	.2058	.2743		.2454	
16	.3292	.2614	.3772		.2804	
17	.3932	.3734	.4115		.3429	
18	.439	.4108	.4115		.3898	.5281
19	.4588	.679	.583		.4024	.5658
20	.5487	.6413	.5601		.4298	.6036
21	.5853	.5658	.5601		.4435	.5658
22	.5487	.4904	.5228		.3982	.6036
23	.5175	.4527	.4481		.4481	.4755
24	.4024	.5121	.407	.415	.3772	.439
Max	.5853	.679	.6104	.679	.4481	.6036
Min	.3292	.2058	.2058	.415	.2454	.362
Avg	.4408	.4556	.4343	.5127	.3675	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 205 / 11KV Kanal Fata Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3777	2.0119	2.1195		.1581
2		2.1776	2.1795	2.1195		.1943
3		2.1628	2.3472	2.2043		.1492
4		2.1538	2.5149	2.3739		.1966
5		2.652	2.5149	2.3739		.1492
6		2.4577	2.5149	2.4756		.1696
7		2.9313	2.7161	2.5434		.213
8		2.7606	2.6825	2.6791		.216
9		2.6322	2.5774	2.713		.1823
10	.2033	.1677	.285			.1658
11	.1829	.1886	.2829		.0701	2.2672
12	.1187	.1698	.1989		.0905	
13	.0983	.1698	.2427			
14	.1017	.1677	.1867			
15	.1475	.1677	.1867			
16	.1357	.2012	.1867			
17		.2012	.1867		.1187	
18	.1829	.2012	.2241			2.7808
19	.2347	.3353	.2614		.2343	.2267
20	.2254	.3353	.2427		.2105	.2006
21	.2454	.3018	.2286		.216	.2058
22	.2543	.2683	.2241		.2486	.2629
23	.2534	.2347	.2241		.2743	.213
24	1.989	2.2148	2.0119	2.0348	2.0576	.1829
Max	1.989	2.9313	2.7161	2.713	2.0576	2.7808
Min	.0983	.1677	.1867	2.0348	.0701	.1492
Avg	.3124	1.1513	1.1347	2.3637	.3912	.4519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 206 / 11 KV SANGAVI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7611	.8907	.8097		.1296
2		.7773	.8907	.8907		.1619
3		.7611	.8907	.8907		.1457
4		.8583	.9717	.9717		.1134
5		.9555	1.0526	.9717		.1457
6		1.1336	1.1336	1.0688		.1781
7		1.247	1.2146	1.1336		.1457
8		1.2146	1.2146	1.4575		.1781
9		1.247	1.2146	1.4575		.1457
10	.0972	.1457	.0972			.1619
11	.1134	.1457	.0972		.1134	1.2793
12	.1619	.1781	.1296		.1457	
13	.1457	.1781	.1311		.1718	
14	.1781	.1619	.1296		.1457	
15	.1619	.1619	.1619		.1619	
16	.1781	.1619	.1943		.1781	
17	.1943	.1943	.1943		.1134	
18	.2105	.2105	.1781		.1296	1.5061
19	.1781	.2105	.1943		.0972	.1457
20	.1943	.2105	.1943		.1134	.1781
21	.1619	.2105	.1943		.1457	.1619
22	.1781	.1943	.1943		.1134	.1296
23	.1619	.1943	.1943		.1134	.1619
24	.9717	.6964	.8097	.8097	.8573	.1134
Max	.9717	1.247	1.2146	1.4575	.8573	1.5061
Min	.0972	.1457	.0972	.8097	.0972	.1134
Avg	.2191	.5088	.5237	1.0462	.1857	.2879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 207 / 11 KV JALOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6651	1.9909	1.9004		.1629
2		1.6832	1.9909	1.9004		.1991
3		1.7375	2.0814	1.9909		.1267
4		1.7556	2.0814	1.9909		.1629
5		1.8099	2.1719	1.9547		.181
6		1.8099	2.2624	1.9366		.1629
7		2.1538	2.371	1.9909		.1629
8		2.1719	2.3529	2.2443		.1448
9		2.1357	2.2262	2.2443		.1448
10		.1629	.1629			.1629
11		.1629	.1448		.1267	1.9909
12		.1086	.0905		.0724	
13		.0724	.1086		.0905	
14	.1086	.0648	.1086		.1267	
15	.1267	.081	.1267		.1086	
16	.1629	.081	.1267		.0905	
17	.1448	.0972	.1267		.1267	
18	.1267	.1267	.1267		.0905	2.2805
19	.181	.181	.2172		.1629	.181
20	.181	.181	.2172		.181	.2172
21	.181	.181	.181		.1629	.1629
22	.1991	.1448	.181		.181	.1629
23	.181	.1448	.181		.1448	.181
24	1.828	1.7013	1.9909	1.9909	1.8861	.1448
Max	1.828	2.1719	2.371	2.2443	1.8861	2.2805
Min	.1086	.0648	.0905	1.9004	.0724	.1267
Avg	.3110	.8506	.9841	2.0144	.2537	.3851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 208 / 11 KV KALANANI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0293
2					.0486
3					.0309
4					.0486
5					.0309
6					.0474
7					.0332
8					.0509
9					.0497
10	.0486				
11	.0497	.0316	.0305	.0486	
12	.0492	.048		.0309	
13	.0486	.048	.0297	.0463	
14	.0457	.0497	.0297	.032	
15	.0486	.0497	.0446	.0457	
16	.0457	.0332	.0446	.0469	
17	.0497	.0332	.0446	.0305	
18		.0332	.0446	.0474	
24					.0497
Max	.0497	.0497	.0446	.0486	.0509
Min	.0457	.0316	.0297	.0305	.0293
Avg	.0482	.0408	.0383	.0410	.0419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 209 / 11 KV SUTAR MALA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1524	.1524		2.6673
2		.1905	.1524	.1524		2.8197
3		.1905	.1524	.1905		2.7435
4		.1905	.1905	.2286		2.8578
5			.1905	.2667		3.0102
6		.1905	.2286	.2667		3.1245
7		.2667	.2286	.2286		3.315
8		.1905	.1905	.2286		3.5056
9		.1905	.1905	.1905		3.0483
10	.1524	.1905	.1905			.1524
11	1.9052	2.4768	2.2862		1.9433	.1143
12	3.3913		3.6199		3.4294	
13	3.3532	3.4294	3.4294		3.2388	
14	3.4294	3.3341	3.4294		3.3532	
15	3.3532	3.2388	3.3341		3.4294	
16	3.315	3.0483	3.3341		3.315	
17	3.2388	3.0483	3.2388		3.2388	
18	3.0483	3.0483	3.2388		3.315	.1524
19	.1905	.1905	.2286		.1143	.1905
20	.1905	.1905	.2286		.1524	.1905
21	.1905	.1905	.1905		.1905	.1524
22	.1905	.1524	.1905		.1524	.1524
23	.1905	.1524	.1524		.0762	.1143
24	.1524	.1905	.1524	.1524	.1715	2.4768
Max	3.4294	3.4294	3.6199	.2667	3.4294	3.5056
Min	.1524	.1524	.1524	.1524	.0762	.1143
Avg	1.7528	1.1128	1.2050	.2057	1.8657	1.7104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 201 / 11 KV TARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9							1.3375
10							.1783
11							.1783
12							.1783
17							.1635
24	2.1605	1.2498	1.2955	1.1736	1.1279	1.2193	.1715
Max	2.1605	1.2498	1.2955	1.1736	1.1279	1.2193	1.3375
Min	2.1605	1.2498	1.2955	1.1736	1.1279	1.2193	.1635
Avg	2.1605	1.2498	1.2955	1.1736	1.1279	1.2193	.3679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 202 / 11 KV KHARSOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0957	.1143	.1905	.1524	.381	.381	2.1338
Max	1.0957	.1143	.1905	.1524	.381	.381	2.1338
Min	1.0957	.1143	.1905	.1524	.381	.381	2.1338
Avg	1.0957	.1143	.1905	.1524	.381	.381	2.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 203 / 11 KV MAGARWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4969	1.5242	1.4661	1.6156	1.326	.1905
2	1.4661	1.6204	1.5242	1.6204	1.6613	1.3717	.1905
3	1.5432	1.7185	1.5546	1.6975	1.6975	1.4175	.1905
4	1.6204	1.7966	1.6004	1.7747	1.7747	1.4632	.2096
5	1.7071	1.8519	1.9052	2.0062	1.929	1.4937	.2286
6	1.8595	1.8519	2.1338	2.1605	2.0424	1.5242	.2286
7	2.037	2.2685	2.21	2.3148	2.21	2.0271	.2286
8	2.2377	2.4228	2.4387	2.4383	2.2184	2.3167	.1905
9	2.2184	2.1605	2.21	2.392	2.1872	2.2558	.1524
10	.0953	.1143	.1143	.0772	.0953	.0914	
11	.0953	.1143	.0953	.0772	.0953	.1905	
12	.0953	.1143	.0953	.1543	.0953	.1905	
13	.0953	.1524	.0762	.1524	.1905	.1905	2.1605
14	.0953	.1524	.0572	.1524	.1905	.2096	2.21
15	.0953	.1715	.0762	.1524	.1905	.1905	2.2558
16	.0953	.1524	.0762	.1524	.1905	.1905	2.0576
17	.0953	.1524	.0953	.1543	.1905	.1905	2.0576
18	.1334	.1143	.0953	.1543	.1905	.2286	1.9753
19	.1334	.1524	.1143	.1524	.1905	.2286	.2286
20	.1334	.1905	.0953	.1524	.1905	.2286	.2286
21	.1334	.1524	.0953	.1524	.1905	.1905	.0953
22	.1334	.1219	.0953	.1524	.1905	.1905	.0953
23	.1334	.1524	.0953	.1524	.1905	.1905	.0953
24	1.174	1.3889	1.3717	1.358	1.4815	1.2955	.1905
Max	2.2377	2.4228	2.4387	2.4383	2.2184	2.3167	2.2558
Min	.0953	.1143	.0572	.0772	.0953	.0914	.0953
Avg	.7832	.8577	.8229	.8841	.8833	.7997	.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 204 / Tarapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.2629	.2591	.2686	.2686	.2439	.2743
2	.3045	.2601	.2439	.2658	.2865	.2439	.2896
3	.3403	.3155	.2743	.3045	.3224	.2743	.3048
4	.3721	.3121	.3353	.3544	.3721	.3201	.381
5	.4477	.3467		.4656	.4477	.3963	.4572
6	.4908	.4161	.4268	.5014	.5014	.4268	.4877
7	.4477	.4784	.381	.443	.4477	.3963	.4268
8	.3761	.4334	.3353	.394	.3761	.3353	.3658
9	.2572		.3048	.3582	.3189	.3048	.3048
10	.2229	.3048	.3045	.2686		.2286	
11	.1886	.1981	.2686	.2686		.2286	
12	.2058	.1677	.2328	.2149	.2481	.2134	
13	.2229	.1718	.2149	.2328	.2303	.1829	.2686
14	.2229	.1829	.2149	.2328	.2303	.2134	.2328
15	.2401	.2134	.2328	.2686	.2658	.2286	.2686
16	.2401	.2134	.2686	.2686	.2658	.2439	.2865
17	.298	.2286	.3045	.2686	.2658	.2743	.3224
18	.3814	.2743	.3582	.3045	.3189	.3048	.3582
19	.4733	.3963	.4835	.4477	.443	.4115	.5068
20	.4681	.4115	.4477	.5014	.4784	.3963	.4525
21	.4334	.3658	.394	.4477	.443	.3658	.3582
22	.3814	.3048	.3582	.3761	.3048	.3353	.3224
23	.3467	.2743	.3045	.3045	.2743	.3048	.3077
24	.2686	.3121	.2591	.2865	.2686	.2439	.2743
Max	.4908	.4784	.4835	.5014	.5014	.4268	.5068
Min	.1886	.1677	.2149	.2149	.2303	.1829	.2328
Avg	.3291	.2976	.3134	.3353	.3354	.2966	.3453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 206 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1406	.2105	.1739	.1852	.1781	.0191
2	.1219	.1406	.2105	.1739	.1981	.1981	.0191
3	.1235	.1389	.2267	.2056	.2286	.2267	.0191
4	.1372	.1524	.2286	.2214	.2315	.2286	.0381
5	.1543	.1543	.2591	.2343	.2469	.2591	.0381
6	.2006	.1875	.2743	.25	.2778	.2591	.0381
7	.2439	.2343	.2743	.2812	.3086	.2743	.0381
8	.3125	.2401	.3201	.3281	.3125	.2896	.0381
9	.2968	.2469	.3048	.2343	.3125	.2743	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191	.0191	.0191	.0191	.0191	
12	.0191	.0191	.0191	.0191	.0191	.0191	
13	.0191	.0191	.0191	.0191	.0191	.0191	.3281
14	.0191	.0191	.0191	.0191	.0191	.0191	.3281
15	.0191	.0191	.0191	.0191	.0191	.0191	.2656
16	.0191	.0191	.0191	.0191	.0191	.0191	.2591
17	.0191	.0191	.0191	.0191	.0191	.0191	.3125
18	.0191	.0191	.0191	.0191	.0381	.0191	.2214
19	.0381	.0381	.0381	.0191	.0381	.0381	.0381
20	.0381	.0381	.0381	.0191		.0381	.0381
21	.0191	.0381	.0381	.0381	.0381	.0381	.0381
22	.0191	.0381	.0381	.0191	.0381	.0191	.0381
23	.0191	.0191	.0381	.0191	.0381	.0191	.0381
24	.1067	.1389	.1781	.1562	.1718	.1781	.0191
Max	.3125	.2469	.3201	.3281	.3125	.2896	.3281
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0879	.0882	.1187	.1061	.1225	.1121	.1043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 207 / 11 KV GANESH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7499	.6401	.463	.6173	.6097	.0953
2	.6097	.7407	.6401	.463	.6097	.6401	.0953
3	.6401	.7716	.6859	.5401	.6401	.6706	.1143
4	.6481	.787	.6859	.5401	.6481	.6859	.1524
5	.6636	.8025	.7316	.6173	.6706	.7011	.1524
6	.6944	.8488	.7621	.6944	.7407	.7164	.1524
7	.7716	.8025	.7621	.7407	.7926	.7621	.1524
8	.8488	.8592	.823	.8488	.7343	.7621	.1334
9	.7811	.7407	.8383	.7499	.7811	.7621	.0953
10	.0572	.0953	.0953	.0305	.0381	.0953	
11	.0572	.0953	.0572	.0309	.0381	.0953	
12	.0572	.0762	.0572	.0305	.0381	.0953	
13	.0572	.0953	.0381	.0463	.0381	.0953	.8488
14	.0572	.0953	.0381	.0457	.0572	.0953	.8025
15	.0572	.0953	.0572	.0457	.0572	.0953	.8488
16	.0572	.0953	.0572	.0772	.0572	.0762	.8179
17	.0572	.0953	.0572	.0772	.0572	.0953	.8642
18	.0572	.0953	.0572	.0772	.0572	.0953	.8179
19	.0953	.0953	.0953	.0772	.0953	.1524	.1334
20	.0953	.0953	.0572	.0772	.0953	.1143	.0953
21	.0953	.0572	.0572	.0762	.0953	.0953	.0572
22	.0953	.0572	.0572	.0762	.0953	.0953	.0572
23	.0953	.0572	.0572	.0772	.0953	.0953	.0572
24	1.0004	.7407	.6097	.5401	.5792	.6097	.0953
Max	1.0004	.8592	.8383	.8488	.7926	.7621	.8642
Min	.0572	.0572	.0381	.0305	.0381	.0762	.0572
Avg	.3441	.3769	.3341	.2934	.3220	.3463	.3161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.9431	.9835	.8688	.9835	.9431	.7964
2	.8573	.9431	1.0004	.8688	1.0174	.9431	.7964
3	.8916	1.0288	1.0343	1.0288	1.0802	1.0288	.8802
4	.9774	1.166	1.0852	1.166	1.2003	1.2003	.9829
5	1.1145	1.2498	1.2346	1.3032	1.3203	1.406	1.1873
6	1.2689	1.5242	1.5083	1.4918	1.4918	1.5604	1.3611
7		1.5851	1.7318	1.6975	1.6632	1.7318	1.0715
8		1.6156	1.643	1.6004	1.6575	1.8347	.8977
9		1.6766	1.448	1.4937	1.326	1.5546	.7735
10		.6093	.5068	.639	.5201	.5796	.5335
11	.6001	.4755	.3734	.4755	.3601	.431	1.3375
12	.5468	.4904	.3601	.4904	.3467	.431	1.3717
13	.5335	.4988	.3601	.5053	.3734	.431	.0191
14	.4934	.4988	.3868	.5201	.3601	.431	.0191
15	.5068	.5213	.4001	.5053	.3734	.4755	.0191
16		.4778	.4268	.4755	.4001	.4988	.0191
17	.6668	.6093	.4001	.5944	.4268	.5411	.0191
18	.6935	.6573	.6001	.6537	.6001	.6161	.0191
19	.8935	.9242	.9469	1.0145	.9202	.9431	1.0002
20	.9736	1.0997	.9736	1.0856	.9469	1.0715	1.0669
21	.8535	.9808	.8535	.9829	.8802	1.0136	.9602
22	.8002	.8949	.7868	.9065	.8002	.9701	.8935
23	.7602	.8069	.7602	.8173	.7468	.8833	.8535
24	.8413	.9431	.9496	.8688	.9496	.9431	.8109
Max	1.2689	1.6766	1.7318	1.6975	1.6632	1.8347	1.3717
Min	.4934	.4755	.3601	.4755	.3467	.431	.0191
Avg	.7954	.9259	.8648	.9189	.8644	.9359	.7371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 202 / 11 KV ADHIV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.381	.4115	.381	.4287	.3963	1.0814
2	.3506	.381	.4115	.381	.4287		1.0814
3	.381	.4458	.463	.4801	.463		1.1142
4	.5144	.5144	.5201	.5487	.5316		1.1498
5		.6516	.6415	.6859	.6274		1.2955
6	.7888	.7545	.7802	.8059	.7461		1.4737
7		.823	.8842	.5658	.583		1.7368
8		.4973	.5658	.4801	.463		1.8023
9		.4119	.3772	.3601	.3429		1.6309
10		.3681	.2534	.3506	.2572		.2896
11	1.7833	1.8515	1.5242	1.7604	1.387		.2915
12	2.0271	2.1125	1.9204	2.1963	1.89	1.9951	.2743
13	1.9509	2.2775	2.2291	2.2283	1.9509	1.9951	
14	1.829	2.3304	2.2634	2.2611	1.829	2.1216	
15	1.89	2.304	2.1948	2.2119	1.7985	2.1382	
16	1.9357	2.2119	2.2634	2.1792	1.7833	2.13	
17	2.0729	2.2298	1.7147	2.1548	1.7833	2.2119	
18	1.5089	1.781	1.89	1.9265	1.7985	2.1464	
19	.6173	.5658	.6344	.6001	.6687	.6173	.6516
20	.6687	.7628	.6516	.7802	.703	.7628	.7716
21	.6173	.6935	.6173	.6415	.6687	.7011	.7202
22	.5487	.6173	.4973	.5721	.583	.6415	.6001
23	.4801	.4801	.3963	.4801	.5144	.5201	.4973
24	.4917	.381	.4287	.381	.4458	.3963	1.0978
Max	2.0729	2.3304	2.2634	2.2611	1.9509	2.2119	1.8023
Min	.3506	.3681	.2534	.3506	.2572	.3963	.2743
Avg	1.0951	1.0762	1.0223	1.0589	.9448	1.3410	.9756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 203 / 11 KV AJANSOND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0212	1.0814	1.0822		1.0364	.0191
2	.9755	1.0212	1.0978	1.0822		1.0364	.0191
3	1.0212	1.0974	1.1469	1.1431	1.2929	1.0669	.0191
4	1.0822	1.1888	1.21	1.2193	1.3426	1.1279	.0191
5	1.1584	1.4022	1.3094	1.3413	1.4419	1.2498	.0191
6	1.2803	1.5546	1.4586	1.4327	1.5424	1.3565	.0191
7		1.6004	1.6263	1.7528	1.9784	1.6156	.0191
8		1.6004	1.668	1.7528	2.0388	1.6918	.0191
9		1.6057	1.6461	1.5242	1.6918	1.6804	.0191
10		.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	1.2193
12	.0191	.0191	.0191	.0191	.0191	.0191	1.4327
13	.0191	.0191	.0191	.0191	.0191	.0191	
14	.0191	.0191	.0191	.0191	.0191	.0191	
15	.0191	.0191	.0191	.0191	.0191	.0191	
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	1.0227	1.0212	1.065	1.0822	1.1142	1.0364	.0191
Max	1.2803	1.6057	1.668	1.7528	2.0388	1.6918	1.4327
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3874	.5575	.5657	.5700	.5777	.5486	.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 204 / 11 KV S.Dumala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.463	.4656	.463	.4477	.4801	.5731
2	.4115	.463	.4656	.463	.4656	.4801	.5731
3	.463	.4973	.5373	.5144		.5144	.591
4	.5316	.5487	.6024	.6516	.6024	.583	.6379
5	.6516	.6173	.6836	.7202	.6661	.6859	.7087
6	.8059	.6859	.7975	.7888	.7455	.8059	.7712
7		.7888	.7975	.8059	.7716	.7545	.9114
8		.6516	.6836	.7373	.6485	.6516	.964
9		.5731	.5487	.5487	.4801	.5144	.8916
10		.6984	.4287	.4207	.3944	.5194	.4287
11	1.0117	.964	.8573	.8573	.8059	.9313	.3601
12	1.0802	1.1568	1.0802	.964	1.0117	1.0402	.0191
13	1.0802	1.134	1.0288	.9465	.9945	1.1157	
14	1.0631	1.0985	.9945	.9816	.7735	1.0242	
15	1.046	.9922	.9945	.9991	.9945	.9511	
16	1.1317	.9214	1.0974	1.0387	.9945	1.0059	
17	1.0631	.9114	.3086	.9671	.8059	.9511	
18	.9602	1.0402	.9602	.9671	.8745	.9328	
19	.6516	.7059	.6687	.6219	.6687	.6584	.8402
20	.6687	.7701	.6516	.724	.703	.7783	.7888
21	.6173	.6584	.5487	.6401	.6173	.724	.6687
22	.5487	.6401	.5658	.6036	.5487	.6219	.6001
23	.5144	.5853	.5144	.5487	.5144	.5121	.5144
24	.4938	.463	.5014	.463	.4656	.4801	.5731
Max	1.1317	1.1568	1.0974	1.0387	1.0117	1.1157	.964
Min	.4115	.463	.3086	.4207	.3944	.4801	.0191
Avg	.7603	.7512	.6993	.7265	.6954	.7382	.6342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 205 / 65 ACRE GAONTHAN

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 201 / 11 KV PEHE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0152	.0305	.0857	.0686	.0762	.6859
2	.0343	.0305	.0305	.0686	.0686	.0762	.6859
3	.0343	.0305	.0305	.0686	.0857	.0914	.7164
4	.0343	.0305	.0305	.0857	.0857	.0914	.7316
5	.0343	.0305	.0305	.1029	.1029	.0914	.7621
6	.0343	.0305	.0305	.1029	.1029	.0914	.823
7	.0343	.0305	.0305	.0857	.0857	.0762	.8993
8	.0171	.0305	.0305	.0686	.0686	.0762	1.0364
9	.0171	.0305	.0305	.0514	.0686	.0457	1.1279
10	.0305	.0305	.0343	.1029	.0762	.1067	.1543
11	.3506	.3353	.2058	.5144	.6554	.8383	.0343
12	.6097	.5639	.583	1.2003	.6554	1.1431	.0343
13	.6554	.5944	.583	1.286	.6401	1.0974	
14	.5944	.6401	.5658	1.2689	1.0364	1.0822	
15	.5639	.6401	.5487	1.2346	1.0669	1.0669	
16	.5335	.6097	.5487	1.3203	.9145	1.1584	
17	.5182	.4877	.5487	1.286		1.2346	
18	.5182	.4268	.3429	1.2689	.8383	1.1126	.0514
19	.0305	.0305	.0343	.0686	.061	.1524	.1029
20	.0305	.0305	.0686	.0686	.0762	.1372	.12
21	.0305	.0457	.0857	.0686	.0914	.1219	.12
22	.0305	.0457	.0686	.0686	.0914	.1219	.1029
23	.0305	.0457	.0686	.0686	.0762	.1067	.0857
24	.6167	.0152	.0305	.0857	.0686	.0762	.6401
Max	.6554	.6401	.583	1.3203	1.0669	1.2346	1.1279
Min	.0171	.0152	.0305	.0514	.061	.0457	.0343
Avg	.2257	.2000	.1913	.4430	.3081	.4280	.4692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 202 / 11 KV SUGAON BHOSE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.1981	.1829	.2743	.3086	.1829	1.448
2	.3086	.2134	.1829	.2743	.3258	.2134	1.5394
3	.3429	.2286	.2286	.3086	.3601	.2439	1.6156
4	.3772	.2439	.2286	.3429	.3772	.2743	1.829
5	.4115	.2743	.3048	.3772	.3944	.3506	1.9204
6	.463	.3201	.3048	.4115	.4287	.381	1.9966
7	.463	.381	.3658	.4458	.3772	.3506	2.21
8	.3429	.2896	.3048	.3429	.2915	.3201	2.5301
9	.2743	2.1186	.2286		.2229	.1981	2.2558
10	.2439	.3048	.2058	.1886	.1372	.2134	.2743
11	2.0424	.1524	.1715	1.749	1.7528	2.0576	.1372
12	2.6216	.1981	3.2579	3.0178	2.3624	2.5911	.12
13	2.713	.1524	3.2922	3.1893	2.5453	2.5606	
14	2.8045	.1524	3.2579	3.0864	2.6063	2.3472	
15	2.9569	.1829	3.2236	3.0178	2.5911	2.2558	
16	2.8959	.1981	3.0864	3.0178	2.4387	2.3777	
17	2.8045		.1372	2.7778	2.5911	2.4691	
18		2.6368	2.2462	2.5892	2.5911	2.21	
19	.2591	.2896	.2229	.2915	.1677	.2286	
20	.2439	.2896	.3258	.2915	.2134	.2134	.3258
21	.2286	.2743	.3258	.2915	.2439	.1981	.3086
22	.2286	.2439	.2743	.2743	.2286	.1829	.2401
23	.2134	.2134	.2401	.2743	.2134	.1677	.2058
24	.2743	.1981	.1677	.2572	.2572	.1829	1.387
Max	2.9569	2.6368	3.2922	3.1893	2.6063	2.5911	2.5301
Min	.2134	.1524	.1372	.1886	.1372	.1677	.12
Avg	1.0350	.4241	.9486	1.1779	1.0011	.9488	1.1967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 203 / 11 KV BHOSE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3201	.3353	.3601	.3429	.3658	.3048
2	.3772	.3201	.3353	.3429	.3601	.3658	.3048
3	.4115	.3353	.3658	.3772	.3601	.3963	.3506
4	.4287	.381	.3658	.4115	.4287	.4572	.3963
5	.4973	.4572	.4572	.6001	.5487	.5792	.5335
6	.5487	.5639	.4877	.7202	.7202	.6249	.5792
7	.6516	.6097	.5792	.6859	.6859	.6249	.6249
8	.6516	.5487	.4268	.5658	.4973	.5335	.503
9	.4801	.4268	.3048	.4973	.4801	.3353	.4115
10	.3506	.381	.3601	.463	.3658	.3506	.3772
11	.3048	.2896	.3429		.3048	.3048	.3086
12	.2743	.2591	.2743		.2743	.2743	.3258
13	.2439	.2743	.2572	.2572	.2286	.2743	.2743
14	.2743	.2286	.2572	.2401	.1829	.2591	.2572
15	.3201	.2439	.2401	.2915		.2591	.2915
16	.3048	.2743	.2572	.2915	.1829	.2743	.3429
17	.381	.3048	.2743	.3258	.3353	.3048	.3772
18	.4115	.3963	.3772	.4458	.381	.442	.463
19	.5182	.4725		.6001	.5335	.5639	.6516
20	.5487	.4268	.4973	.5487	.5639	.5335	.6859
21	.4572	.3963	.4458	.463	.503	.4268	.6001
22	.381	.3353	.4115	.4115	.4572	.381	.5144
23	.3506	.3048	.3944	.3944	.3963	.3506	.4801
24	.3601	.3201	.3353	.3429	.3429	.3658	.3201
Max	.6516	.6097	.5792	.7202	.7202	.6249	.6859
Min	.2439	.2286	.2401	.2401	.1829	.2591	.2572
Avg	.4120	.3696	.3645	.4380	.4120	.4020	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 204 / 11 KV Sol Patti Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	1.2955	1.6766	2.3663	1.9547	1.6004	.2439
2	2.0919	2.1033	1.6766	2.4006	2.1948	1.6766	.2439
3	2.2634	2.1338	1.7528	2.4691	2.3491	1.9052	.2439
4	2.5377	2.2253	1.9052	2.4348	2.4691	2.0576	.2591
5	2.6578	2.5453	2.21	2.572	2.5377	2.1795	.2896
6	2.9321	2.652	2.8197	2.6749	2.6063	2.3167	.3201
7	3.0864	2.7435	2.9721	3.4465	3.2579	2.7892	.381
8	3.1722	2.6368	3.0026	3.3779	3.2407	2.9416	.3506
9	3.2579	2.1186	3.0026	3.3093	3.2236	2.8502	.2896
10	.3201	.3048	.3258	.3258	.2591	.2591	.4115
11	.3201	.1524	.2229	.2401	.1981	.1829	2.1776
12	.2439	.1981	.1543	.2401	.1981	.2134	2.3663
13	.1829	.1524	.1715	.2572	.2134	.2134	
14	.1981	.1524	.1886	.2229	.1829	.2286	
15	.1981	.1829	.1886	.2229	.1829	.2286	
16	.2134	.1981	.2058	.3086	.1829	.2439	
17	.2134	.2439	.2915	.2743	.2286	.2439	
18	.1981	.2743	.2058	.3258	.2286	.2439	2.4691
19	.3048	.3353	.4115	.4287	.3353	.3658	.3258
20	.2896	.3353	.4287	.3601	.3353	.3201	.3429
21	.2743	.3201	.3772	.3086	.3048	.2896	.3429
22	.2591	.3048	.3429	.2743	.3048	.2743	.3086
23	.2286	.2743	.2743	.2572	.3048	.2591	.2915
24	1.8176	1.2803	1.6004	1.9376	1.8519	1.5546	.2286
Max	3.2579	2.7435	3.0026	3.4465	3.2579	2.9416	2.4691
Min	.1829	.1524	.1543	.2229	.1829	.1829	.2286
Avg	1.2181	1.0485	1.1003	1.2932	1.2144	1.0599	.6256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 205 / 11 KV Nematwadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.9907	1.1431	1.2003	1.0288	.9907	.1219
2	1.4403	.9907	1.1431	1.3032	1.2689	1.1431	.1219
3	1.5261	1.0517	1.2955	1.286	1.3375	1.1431	.1219
4	1.6461	1.3717	1.2955	1.3375	1.3717	1.3717	.1372
5	1.7833	1.4327	1.3717	1.3717	1.4918	1.5242	.1524
6	1.9033	1.6156	1.448	1.4746	1.7318	1.5546	.1677
7	1.9547	1.7528	1.5242	1.8519	1.9719	1.6766	.1829
8	1.9204	1.5851	1.6766	1.9376	2.0405	1.8595	.1524
9	2.1091	1.5394	1.7528	2.0748	2.0405	1.7833	.1067
10	.0914	.1067	.1372	.1715	.1067	.1372	.2058
11	.0914	.0914	.0857	.12	.061	.0914	1.2346
12	.0914	.0762	.0514	.0857	.0457	.0914	1.3546
13	.0914	.0457	.0514	.0857		.0762	
14	.0762	.0457	.0686	.0857	.0457	.0762	
15	.061	.0457	.0686	.0686	.0457	.0762	
16	.0762	.0457	.0686	.0686	.0457	.0914	
17	.0762	.061		.0686	.0762	.1067	
18	.0762	.0762	.0857	.0857		.1067	1.9033
19	.1067	.1372	.1029	.1029	.0914	.1981	.1372
20	.1067	.1219	.12	.1029	.1067	.1829	.1543
21	.0914	.1219	.12	.1029	.1067	.1677	.1372
22	.0914	.1067	.1029	.1029	.0914	.1524	.1372
23	.0762	.1067	.1029	.1029	.0914	.1372	.12
24	1.2003	.7011	1.0974	.9602	.9259	.9907	.1219
Max	2.1091	1.7528	1.7528	2.0748	2.0405	1.8595	1.9033
Min	.061	.0457	.0514	.0686	.0457	.0762	.1067
Avg	.7525	.5925	.6484	.6730	.7329	.6554	.3564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 201 / 11 Kv NALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.823
Max	.823
Min	.823
Avg	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 202 / 11 Kv AMBE CHINCHOLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	1.4413		1.3763	1.3927	1.2717	.5121
2	1.2498			1.3108	1.4255	1.2887	.4854
3	1.2955	1.5091		1.3927	1.5074	1.3395	.4477
4	1.3717	1.6278		1.4419	1.5402	1.4922	.4344
5	1.448	1.8482		1.6385	1.5546	1.6108	.5121
6	1.5242	2.0348		1.7652	1.6518	1.7295	.6535
7	1.8442	2.1195		1.8947	1.8785	1.9161	.8402
8		2.0008		1.9919	2.1376	1.9839	.7842
9		2.0517		1.9433	2.0891	2.0348	.7655
10				.5716	.6668	.439	.5093
11	.6097		.6668	.4572	.6287	.4024	1.5089
12	.724		.7621	.7811	.7316	.061	1.7436
13	.7499		.9717		.8048	.5658	
14	.7701		.9717	.7049	.7682	.5935	
15	.8059		.9907	.8192	.7682	.6036	
16	.8954		.9717	.8002	.7682	.5487	
17	.8859		.9335	.8002	.7682	.6767	
18	.8954		.9717	.9145	.823		
19	.5731		1.0669	.8764	.695	.7922	.4954
20	.6089		.9145	.8764	.695	.7316	.4763
21	.6219		.8002	.8383	.6401	.6413	.5144
22	.6401		.724	.724	.4755	.6224	.5335
23	.6401		.5716	.6287	.4108	.5975	.5335
24	1.2407	1.4074		1.3927	1.3763	1.2717	.5415
Max	1.8442	2.1195	1.0669	1.9919	2.1376	2.0348	1.7436
Min	.5731	1.4074	.5716	.4572	.4108	.061	.4344
Avg	.9874	1.7823	.8705	1.1279	1.0916	1.0093	.6829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 203 / 11 Kv JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.094	.8192	.9614	.8987	
2	.9145	1.094	.9012	.9779	.8987	
3	.9907	1.1437	.9503	.9779	.9156	
4	.9907	1.1174	.9831	.9945	.9156	
5	1.0059	1.1498	1.065	.9831	.9116	
6	1.1736	1.1822	1.1012	.9995	.9116	
7	1.0822	1.1984	1.085	1.0159	.9614	
8	1.0517	1.166	1.1336	1.0688	.9779	
9	1.1279	1.166	1.1498	1.085	.9779	
11						.7377
12						.8048
24	1.0059	1.0774	.9724	.9614	.8987	
Max	1.1736	1.1984	1.1498	1.085	.9779	.8048
Min	.9145	1.0774	.8192	.9614	.8987	.7377
Avg	1.0258	1.1389	1.0161	1.0025	.9268	.7713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 201 / 11 Kv Kalamal
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	1.3117	
2	1.3765	
3	1.4575	
4	1.5623	
5	1.6404	
6	1.7814	
7	1.8842	
24	.1235	.6097
Max	1.8842	.6097
Min	.1235	.6097
Avg	1.3922	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 202 / 11 Kv Fulchincholi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	.1524
2	.1524
3	.1524
4	.1905
5	.1905
6	.1905
7	.1905
24	.1524
Max	.1905
Min	.1524
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 203 / 11 Kv Puluji Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
17		.2286
24	1.3232	
Max	1.3232	.2286
Min	1.3232	.2286
Avg	1.3232	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 204 / 11 kv PULUJ

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	1.2955
24	.1829
Max	1.2955
Min	.1829
Avg	.7392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 205 / 11 KV VITE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.0364
Max	1.0364
Min	1.0364
Avg	1.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 201 / 11 kv Nanure Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.2328	.2149	.2686	.2172	.2353	.1991
2	.197	.2507	.197	.2865	.2172	.2715	.1991
3	.2149	.2865	.2149	.3224	.2172	.2896	.1991
4	.2507	.3224	.2507	.3224	.2172	.3439	.2172
5	.3224	.3582	.3224	.3403	.2896	.362	.2534
6	.3224	.4119	.3582	.3582	.3258	.3982	.2896
7	.3224	.3761	.3403	.3982	.3258	.3982	.3258
8	.2865	.3403	.3045	.3439	.2896	.3439	.3258
9	.2865	.3045	.2328	.2715	.2534	.2715	.3439
10	.2507	.2507	.1433	.2534	.2534	.2534	
11	.2149	.2149	.197	.2534	.1448	.1991	
12	.2149	.2149	.1791	.2353	.1629	.1991	
13	.2328	.197	.1791	.2172	.1629		
14	.197	.197	.197	.2172	.1629		
15	.197	.197	.197	.2534	.1629		
16	.2328	.2149	.197	.2896	.181	.2172	
17	.2865	.2328	.197	.362	.2353	.3258	
18	.3109	.2686	.2686		.2896	.3258	
19	.2507	.3582	.3582	.3982	.3801	.362	
20	.3475	.3582	.3403	.3982	.3982	.3258	
21	.2926	.2865	.3045	.362	.2896	.3258	.3224
22	.2378		.2507	.3258	.2172	.2896	.2865
23	.2195	.2149	.2328	.2896	.2353	.2534	.2507
24	.2149	.2378	.2149	.2328	.2534	.2353	.1991
Max	.3475	.4119	.3582	.3982	.3982	.3982	.3439
Min	.197	.197	.1433	.2172	.1448	.1991	.1991
Avg	.2542	.2751	.2455	.3044	.2451	.2965	.2624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 202 / 11 KV Pehe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2211	2.2969	2.4697	2.3703		2.2708	.1823
2	2.3205	2.3137	2.5194	2.3868		2.3205	.1823
3	2.3205	2.2801	2.5526	2.3703		2.3205	.1823
4	2.3205	2.2708	2.5857	2.3703		2.3371	.1658
5	2.3537	2.2874	2.5526	2.4034		2.3371	.1658
6	2.5526	2.4034	2.6355	2.536		2.42	.1989
7	2.5526	2.6189	2.7018	2.5309		2.7515	.1989
8	2.652	2.7515	2.6686	2.7018		2.7515	.1989
9	2.8012	2.7183	2.5857	2.7018		2.7515	.1989
10	.1492	.116	.0995		.0995	.1326	
11	.0995	.1075	.0663		.0663	.1326	
12	.0995	.0995	.0663		.0829	.0995	
13	.0829	.0829	.0663		.0829		
14	.0995		.0663		.0829		
15	.0995		.0663		.0829		
16	.0995		.0829		.0829	.0829	
17	.116		.0995		.0995	.1326	
18	.116	.0829	.116		.116	.1658	
19	.1658	.1492	.1989		.1989	.1658	
20	.1658	.1658	.1823		.1823	.1823	
21	.1492	.1658	.1658		.1658	.1989	2.2542
22	.1326	.1823	.1326		.116	.1989	.1823
23	.1326	.1326	.1326		.1326	.1823	.1658
24	2.1548	2.1963	2.2377	2.2708	2.1548	2.1879	.1989
Max	2.8012	2.7515	2.7018	2.7018	2.1548	2.7515	2.2542
Min	.0829	.0829	.0663	2.2708	.0663	.0829	.1658
Avg	1.0815	1.2711	1.1271	2.4642	.2497	1.2439	.3443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 203 / 11 KV Ave

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1619	.1698	.1875	.1562	.1457	2.1376
2	.125	.1943	.1698	.1875	.1562	.1619	2.1376
3	.125	.2105	.1852	.2031	.1562	.1943	2.2348
4	.125	.2105	.1698	.2187	.1406	.1943	2.2348
5	.125	.2105	.1852	.2343	.1406	.2105	2.2348
6	.125	.2267	.2006	.25	.1562	.2429	2.332
7	.125	.1781	.1852	.2343	.1562	.2105	2.332
8	.125	.1457	.1698	.2031	.1562	.1619	2.332
9	.125	.1296	.108	.1718	.1094	.1134	2.3644
10	.1094		.1235		.1094	.1296	
11	2.1715	2.3278	2.2653	2.3434		2.2672	
12	2.4059	2.4371	2.4684	2.3434	2.5621	2.3967	
13	2.3746	2.5309	2.6246	2.4215	2.5465	2.3967	
14	2.5777	2.5934	2.6402	2.4215	2.5309	2.4291	
15	2.5777	2.5309	2.6871	2.3746	2.5309	2.4615	
16		2.5152	2.5621	2.4215	2.5152	2.4777	
17	2.5309	2.4684	2.5152	2.4996	2.5749	2.5101	
18	2.2965	2.4684	2.4996	.125	2.4291	2.5101	
19	.1562	.1543	.1562	.1562	.1943	.1134	
20	.1406	.1852	.1562	.1562		.1296	
21	.1406	.2006	.1562	.1562	.1619	.1296	.1619
22	.1406	.1852	.1718	.1718	.1457	.1296	.1781
23	.1406	.1698	.1562	.1718	.1296	.1296	.1457
24	.1406	.125	.1698	.1718	.1718	.1296	2.1376
Max	2.5777	2.5934	2.6871	2.4996	2.5749	2.5101	2.3644
Min	.1094	.125	.108	.125	.1094	.1134	.1457
Avg	.8273	.9809	.9540	.8619	.9059	.9156	1.7664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 201 / 11 KV Shevate Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.12	.12	.0762	.0686	.0857	.2058
2	.1219	.12	.12	.0762	.0686	.0686	.1715
3	.1219	.1029	.1029	.0914	.0857	.0686	.1715
4	.1067	.1029	.1029	.1067	.1029	.12	.1372
5	.1067	.0857	.1543	.1219	.1372	.1543	.1372
6	.1067	.0857	.1543	.1372	.1524	.1715	.12
7	.1219	.1029	.12	.1677	.1886	.1372	.1029
8	.1543	.1029	.1029	.1829	.2058	.1543	.1029
9	.12	.1886	.0857	.1067	.2229	.1886	.12
10	.3429	.2229	.1981	.1372	.4801	.4287	
11	.3429	.2401	.2134	.2743	.3944	.2743	.2896
12	.2743	.2401	.2134	.2915	.3601	.2572	.3048
13	.2572	.2572	.2286	.2058	.3258	.2743	.2134
14	.2401	.1715	.2286	.12	.1543	.2743	.1372
15	.2401	.1372	.1829	.1372	.1886	.2401	
16	.2229	.12	.1524	.1543	.2743	.2229	
17	.2058	.12	.1067	.1715	.2915	.2401	
18	.2229	.1029	.2591	.1715	.3258	.2401	
19	.2058	.2229	.1677	.12	.2743	.2572	
20	.1372	.2058	.1524	.1372	.2743	.2572	.2134
21	.12	.2058	.1219	.12	.2229	.2743	.1677
22	.1029	.1715	.1219	.1029	.1372	.2401	
23	.0857	.1372	.061	.0857	.1543	.2401	.3048
24	.1524	.1372	.1372	.061	.0857	.1886	.2572
Max	.3429	.2572	.2591	.2915	.4801	.4287	.3048
Min	.0857	.0857	.061	.061	.0686	.0686	.1029
Avg	.1765	.1543	.1503	.1399	.2157	.2108	.1857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 202 / 11 KV Shevate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	2.2862	2.3472	2.5149	2.1338	2.6235	
2	2.4387	2.4234	2.5453	2.5911	2.271	2.7206	
3	2.4691	2.5453	2.6216	2.6216	2.4539	2.834	
4	2.5149	2.7282	2.8045	2.7282	2.5758	2.9473	
5	2.5453	2.7282	2.8959	2.7892	2.6063	3.2388	
6	2.7435	2.8959	2.9264	2.8654	2.652	2.834	
7	2.8807	2.9111	2.9569	2.8959	2.5911	3.2065	
8	2.8197	2.9264	3.0483	2.9416		3.1093	
9	3.0178	2.7892	3.0788	2.9569		3.2712	
10	.3048	.2286	.2591	.3506		.2286	
11		.2896	.2743			.3353	.3048
12		.2743	.2896	.2286		.381	2.6063
13	.3201	.3048		.3353		.3658	
14	.3353			.2591		.3658	
15	.3506			.2896		.3963	
16	.3506			.381		.3048	
17	.3658			.3506		.2439	
18	.3048	.3048	.3201	.3658	.2743	.3353	
19	.381	.4268	.5944	.4877	.5487	.3963	
20	.3048	.3658	.5335	.4725	.5487	.3963	
21	.2896	.3048	.4877	.4572	.5144	.3963	.2896
22	.2743	.2439	.4572	.4725	.3772	.3658	.3353
23	.2439	.2134	.3963	.4725	.3429	.381	.3048
24	2.2253	2.1795	2.1948	2.4082	2.1186	2.3967	
Max	3.0178	2.9264	3.0788	2.9569	2.652	3.2712	2.6063
Min	.2439	.2134	.2591	.2286	.2743	.2286	.2896
Avg	1.3558	1.4685	1.6333	1.4016	1.5721	1.4198	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 203 / Ulabhagat Mala
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.1981	.2743	.2286	.1829	.2229	.2286
2	.2439	.1981	.2743	.2286	.1981	.2229	.2286
3	.2591	.1829	.2743	.2439	.2134	.2229	.2743
4	.2591	.1829	.3048	.2591	.2896	.2743	.2439
5	.2896	.2286	.3353	.2743	.3048	.3086	.2743
6	.3506	.2286	.3048	.3353	.3353	.3429	.2743
7		.2439	.2743				.3048
8		.2591					.2439
9		.2134			.1829		.2134
10	.2896	.1829	.1829		.2229	.1829	.2286
11	1.6613	1.5699	1.6918	1.4632	1.8176		1.3717
12	2.7282	1.9509	2.3624	2.4996	2.6235	2.9874	.2286
13	2.7282	2.0729	2.4996	1.7375	2.4291	2.8045	
14	2.6063	2.5758	2.5911	2.3472	2.5101	2.6216	
15	2.6216	2.5911	2.3015	2.3929	2.5911	2.4387	
16	2.652	2.3777	2.5149	2.4234	2.5263	2.4996	
17	2.6825	2.4996	2.5911	2.4539	2.4291	2.4387	
18	1.8138	2.6063	1.8442	2.1491	2.5101	2.4996	
19	.2896	.2439	.2134	.2134	.2572	.2591	
20	.2591	.2439	.2134	.1981	.2401	.2743	
21	.2591	.2743	.1981	.1981	.2401	.2743	.1981
22	.2439	.2439	.1981	.1829	.2229	.2439	.2286
23	.2134	.2439	.1981	.1677	.2058	.2439	.2134
24	.2286	.2134	.2591	.2134	.1829	.2229	.2439
Max	2.7282	2.6063	2.5911	2.4996	2.6235	2.9874	1.3717
Min	.2134	.1829	.1829	.1677	.1829	.1829	.1981
Avg	1.0916	.9094	.9955	1.0105	1.0325	1.0793	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 204 / CHOUFULA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1219	.1219	.1829	.1524	.1543	1.768
2	.1524	.1067	.1219	.1829	.1372	.1543	1.9509
3	.1677	.1067	.1067	.1677	.1524	.1543	2.1643
4	.1677	.1067	.1067	.1677	.1677	.1543	2.1948
5	.1677	.1219	.1067	.1677	.1829	.1715	2.3167
6	.1524	.1372	.1219	.1829	.1829	.1886	2.3472
7	.1677	.1524	.1524	.1829	.1677	.1886	2.2862
8	.1677	.1677	.1067	.1829	.1981	.1886	2.3167
9	.1829	.1829	.1219	.1677	.1981	.1715	2.3472
10	.3048	.2134	.1829	.1886	.2915	.1372	.3048
11	1.829	2.3624	2.1491	2.2805	2.2186	1.3108	.2591
12	2.7435	2.4387	2.6673	3.0864	3.1093	2.7435	.1677
13	2.7587	2.4691	2.9264	3.2579	3.1579	2.6978	
14	2.5758	2.9111	2.9721	3.0864	3.1741	2.6825	
15	2.5758	2.9569	2.6063	3.0864			
16	2.5911		2.6673	3.0693	3.0283	2.7435	
17	2.5911		2.7435	2.7435		2.774	
18	2.0424	2.5911	1.9814	2.8978	2.7044	2.6825	
19	.1981	.2134	.2134	.2743	.2572	.1524	
20	.1829	.2439	.1829	.2743	.2401	.1829	
21	.1829	.2134	.1981	.2572	.2229	.1981	.1829
22	.1981	.1677	.1981	.2572	.2058	.1829	.1981
23	.1829	.1524	.1829	.2134	.1886	.1829	.1829
24	.1524	.1219	.1372	.1829	.1677	.1543	1.4327
Max	2.7587	2.9569	2.9721	3.2579	3.1741	2.774	2.3472
Min	.1524	.1067	.1067	.1677	.1372	.1372	.1677
Avg	.9412	.8300	.9615	1.1142	.9321	.8848	1.4013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3121	.3366	.3544	.2947	.2947	.2947	.3121
2	.3641	.3544	.3544	.3121	.3467	.3467	.3467
3	.3988	.3721	.3898	.3467	.4161	.4161	.3988
4	.4854		.443	.4161	.4508	.4681	.4508
5	.5201	.5316	.5316	.5375	.5201	.5375	.5201
6	.5721	.567	.6024	.5721	.5721	.5721	.5375
7		.4961	.4961	.5028	.5375	.5201	.5028
8		.4252	.3681	.4508	.3814	.4161	.3988
9		.443	.3366	.4161	.3814	.3467	.3988
10		.4075	.3544	.3814	.3814	.3988	.3988
11	.4508	.3189	.3366	.3294	.2947	.3294	.3294
12	.3988	.3012	.2658	.3121	.3121	.2947	.3294
13	.3582	.2481	.2303	.2774	.2947	.2254	
14	.2686	.2658	.2481	.2427	.2601	.208	
15	.2686	.2481	.2658	.2601	.2774	.2601	
16	.2481	.2481	.2481	.2774	.208	.2254	.2601
17	.3189	.298	.3121	.2947	.2601	.2774	.3121
18	.3544	.3856	.3641	.3467		.3814	.3988
19	.4784	.4382	.5201	.4854	.5375	.5028	.5375
20	.4784	.4382	.5375	.5548	.5721	.5375	.5895
21	.5138	.5258	.5721	.5028	.5028	.5028	.5548
22	.4784	.4382	.4681	.4161	.4508	.4161	.4508
23	.4075	.3506	.3814	.3641	.3641	.3641	.3814
24	.3467	.333	.3544	.3467	.3294	.3294	.3294
Max	.5721	.567	.6024	.5721	.5721	.5721	.5895
Min	.2481	.2481	.2303	.2427	.208	.208	.2601
Avg	.4011	.3814	.3890	.3850	.3890	.3821	.4161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 202 / BABHULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0772	.0791	.0791	.0949	.0781	.0781	.7811
2	.0693	.0791	.0791	.0949	.0625	.0625	.7655
3	.0693	.0949	.0791	.0791	.0625	.0625	.7811
4	.0772	.0791	.0949	.0791	.0781	.0781	.8436
5	.0772	.0949	.0949	.0949	.0937	.0937	.8905
6	.0926	.0949	.1107	.0949	.0937	.0937	.9998
7	.0926	.0791	.0949	.0949	.0781	.0781	1.406
8		.0791	.0791	.0791	.0625		1.6091
9		.0633	.0474	.0633	.0469		1.6091
10		.0316	.0316	.0474	.0312		.0469
11	1.4198	1.3599	1.2334	.9488		.8592	.0469
12	2.0062	1.945	1.7236	1.656	1.5154	1.7029	.0312
13	2.3045	1.4864	1.692	1.7185	1.7966	1.8903	
14	2.1765	1.8027	1.6446	1.7497	1.7497	1.8435	
15	2.2565	1.8501	1.5181	1.7966	1.7185	1.7497	
16	2.0557	1.9925	1.5813	1.406	1.6404	1.781	
17	2.0241	1.8976	1.7711	1.5779	1.5623	1.7966	
18	1.5339	1.6762	1.6604	1.5779	1.3435	1.5278	
19	.0791	.0633	.0949	.0625	.0781	.0781	.0781
20	.0791	.0791	.0949	.0781	.0781	.0469	.0781
21	.0791	.0791	.0949	.0781		.0469	.0781
22	.0949	.0791	.0949	.0781	.0781	.0469	.0625
23	.0791	.0791	.0949	.0625	.0791	.0312	.0625
24	.0772	.0791	.0791	.0949	.0781	.0781	.6874
Max	2.3045	1.9925	1.7711	1.7966	1.7966	1.8903	1.6091
Min	.0693	.0316	.0316	.0474	.0312	.0312	.0312
Avg	.8010	.6352	.5904	.5712	.5639	.6679	.6032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3916	1.4373	1.4998	1.5181	1.6129	1.6446	.0791
2	1.4548	1.4373	1.4842	1.5181	1.6762	1.7078	.0791
3	1.5181	1.4373	1.4842	1.5181	1.7711	1.7711	.0633
4	1.5655	1.6827	1.4998	1.5813	1.8343	1.8976	.0791
5	1.6288	1.5623	1.5935	1.6446	1.8976	2.0241	.1107
6	1.7078	1.8122	1.8122	1.7711	1.9608	2.0873	.1265
7	1.7078	1.9372	2.0622	2.0873	2.2771	2.4036	.1265
8		2.1872	2.2497	2.2771	2.5934	2.5934	.1107
9		2.0622	2.3122	2.4036	2.4669	2.4669	.0949
10		.0625	.0625	.0633	.0633	.0633	.0633
11	.0633	.0625	.0625	.0633	.0633	.0633	1.8976
12	.0633	.0625		.0633	.0633	.0633	2.5934
13	.0625	.0625	.0625	.0633	.0633	.0633	
14	.0625	.0625	.0625	.0633	.0633	.0633	
15	.0625	.0625	.0625	.0633	.0633	.0633	
16	.0625	.0625	.0625	.0633	.0633	.0633	
17	.0781	.0625		.0633	.0633	.0633	
18	.0781	.0625	.0633	.0633	.0633	.0791	
19	.0781	.0625	.0791	.0633	.0633	.0791	.0949
20	.0781	.0625	.0791	.0791	.0633	.0949	.1107
21	.0781	.0625	.0791	.0633	.0633	.0791	.0949
22	.0781	.0625	.0791	.0633	.0633	.0949	.1107
23	.0625	.0781	.0791	.0633	.0633	.0791	.0949
24	1.3283	1.3748	1.4998		1.5813	1.6446	.0791
Max	1.7078	2.1872	2.3122	2.4036	2.5934	2.5934	2.5934
Min	.0625	.0625	.0625	.0633	.0633	.0633	.0633
Avg	.6291	.7425	.8332	.7488	.8566	.8856	.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 201 / 11KV SHINGARE/CHAWAN

SEPARATED AG FEEDERS HAVING SPECIAL

WASTI FE Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8592	.463	.9374	.9755	.9686	.7811	.125
2	.9374	.4938	.9374	.9755	.9686	.8592	.125
3	.9374	.4938	.9374	.9755	.9686	.9374	.1562
4	1.0155	.5556	1.0155	1.0364	1.0311	.9374	.1562
5	1.1717	.7407	1.1717	1.1736	1.1248	1.1717	.1562
6	1.2498	.9414	1.406	1.2193	1.1561	1.3279	.1875
7	1.3748		1.4998	1.2498	1.2498	1.4217	.1562
8	1.5623	1.4043	1.4969	1.448	1.2498	1.4373	.2343
9	1.5432	1.4842	1.4969	1.4022	1.4373	1.531	.2031
10	.1235	.0937	.1235	.1781	.1094	.125	.1875
11	.1543	.1372	.1389		.125	.125	.9061
12	.1543	.1406	.1389	.0648	.125	.0914	1.4998
13	.1698	.1406	.1543	.1457	.1094	.0937	
14	.1852	.1406	.1543	.1296	.1094	.125	
15	.1852	.1562	.1543	.1457	.125	.1562	
16	.1543	.1562	.1698	.1457	.1406	.1875	1.406
17	.1543	.1562		.1619	.1562	.1875	1.4998
18	.2469	.1406	.1698	.1619	.1406	.2031	1.406
19	.2315	.1562	.2006	.2429	.1718	.1875	.1875
20	.216	.2031	.1852	.1619	.2812	.1875	.1875
21	.1698	.2031	.1852	.1619	.25	.1875	.1875
22	.2006	.1875	.1698	.1943	.1562	.1875	.1562
23	.1852	.1406	.1543	.1781	.1562	.2031	.1406
24	.7343	.463	.7811	.884	.8905	.7343	.125
Max	1.5623	1.4842	1.4998	1.448	1.4373	1.531	1.4998
Min	.1235	.0937	.1235	.0648	.1094	.0914	.125
Avg	.5799	.3997	.5991	.5831	.5501	.5578	.4471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 202 / 11KV WATAR WAT FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1486	.1981	.1524	.2429	.208		.8535
2	.1486	.1981	.1524	.2429	.208	.1783	.8535
3	.1635	.2134	.1524	.2429	.208	.1783	.8535
4	.1783	.2286	.1829	.2915	.2526	.208	.8535
5	.208	.2743	.1981	.3725	.2824	.2675	1.2193
6	.2675	.2743	.2286	.3887	.3418	.3121	
7	.2972	.2896	.2591	.3725	.3715	.3418	1.2498
8	.2824	.2134	.2286	.3725	.3269	.3418	1.4022
9	.2374	.1067	.1981	.3563	.2378	.2591	1.3375
10	.1526	.0914	.1524		.2229	.2134	.1783
11	.6783	.7468	.8535	.884	.8768	1.2193	.1783
12	.9755	1.0517		1.7375	1.7535	1.448	.1783
13	1.0364	1.0517	1.1126	1.4784	1.7387	1.6309	
14	1.0669	1.0517	1.0974	1.448	1.7387	1.6461	
15	1.0822	1.0669	1.0669	1.5546	1.7238	1.6461	
16	1.1126	1.0364	1.0974	1.4784	1.6495	1.6156	
17	1.0974	.9907		1.5394	1.6347	1.5851	.1635
18	.9907	.945	1.4175	1.6309	1.5604	1.6766	.2286
19	.2134	.1524	.2896	.2267	.1932	.2286	.3201
20	.1981	.1829	.2743	.2267	.2824	.2439	.3201
21	.1677	.2134	.2591	.2105	.2526	.2286	.2896
22	.1677	.1829	.2286	.2105	.208	.2134	.2439
23	.1677	.1524	.2134	.1943	.1932	.1524	.2134
24	.1635	.1677	.1524	.2429	.1783	.1932	.7621
Max	1.1126	1.0669	1.4175	1.7375	1.7535	1.6766	1.4022
Min	.1486	.0914	.1524	.1943	.1783	.1524	.1635
Avg	.4668	.4617	.4531	.6933	.6935	.6969	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 203 / 11KV SUSTE RIVER SIDE SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9755	.9259	.9602	.9145	.884	.8383	.032
2	.9602	.9259	1.0082	.9145	.884	.8383	.032
3	.9907	.9259	1.0082	.9145	.884	.884	.032
4	.9907	.9568	1.0082	.9297	.945	.884	.032
5	1.0364	.9568	1.0082	.9907	.9755	.9145	.032
6	1.0364	1.0494	1.0402	1.0212	.9907	.945	.032
7	1.0669	1.0957	1.0402	1.0364	1.0517	.9755	.032
8	1.0974	1.1574	1.186	1.0669	1.0669	.9755	.032
9	1.1544	1.1683	1.186	1.0669	.9755	1.0242	.0305
10	.0316	.032	.0158	.0162	.0152	.032	.0152
11	.0316	.032	.0316	.0324	.0152	.032	.9145
12	.0474	.032	.0316	.0324	.0305	.032	1.0669
13	.0474	.032	.0316	.0162	.0152	.032	
14	.0474	.032	.0316	.0162	.0152	.032	
15	.0474	.032	.0316	.0162	.0152	.032	
16		.032	.0158	.0162	.0152	.032	1.0364
17	.0463	.032		.0324	.0152	.032	1.0822
18	.0463	.032	.0316	.0324	.0305	.032	1.1561
19		.032	.0316	.0324	.0305	.032	.0312
20	.0463	.032	.0316	.0324	.0305	.032	.0312
21	.0463	.048	.0316	.0324	.0305	.032	.0312
22	.0309	.032	.0316	.0324	.0305	.032	.0312
23	.0309	.032	.0316	.0162	.0305	.032	.0312
24	.945	.9259	.9602	.9145	.8993	.7926	.032
Max	1.1544	1.1683	1.186	1.0669	1.0669	1.0242	1.1561
Min	.0309	.032	.0158	.0162	.0152	.032	.0152
Avg	.4888	.4397	.4689	.4219	.4115	.3967	.2736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 201 / 11 KV KAROLE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1143	.1524	2.1338
2	.0953	.1334	.1143	.1524	2.1338
3	.1143	.1143	.0953	.1524	2.1338
4	.1143	.1524	.0953	.1524	2.1338
5	.1524	.1715	.0953	.1524	2.1338
6	.1905	.1905	.0953	.1905	2.1338
7	.1524	.2286	.0953	.1905	2.1338
8	.1524	.2286	.0953	.1905	2.2862
9	.1334	.1524	.0953	.1524	2.2862
10	.1905	.1524	.1143	.1143	.1143
11	2.2862	2.7435	2.1719	.1905	.0762
12	2.8578	2.9721	2.4006	2.4387	
13	2.8197	3.1245	2.4006	2.4387	
14	2.8197	3.0864	2.4006	2.4387	
15	2.8197	3.0864	2.3624	2.3815	
16	2.8197	3.1626	2.3624	2.3815	
17	2.7816	2.5149	2.3624	2.2862	
18	2.7435	2.5149	2.3624	2.3624	.1334
19	2.6673	.1524	.1524	.1524	
20	.1524	.1524	.1524	.1524	.1905
21	.1524	.1524	.1524	.1524	.1715
22	.1524	.1524	.1905	.1524	.1715
23	.1524	.1143	.1905	.1905	.1524
24	.1143	.1524	.1143	.1524	1.9052
Max	2.8578	3.1626	2.4006	2.4387	2.2862
Min	.0953	.1143	.0953	.1143	.0762
Avg	1.1137	1.0725	.8661	.8113	1.3191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 202 / 11 KV BELDAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.8764	1.1812	.1905
2	.9145	.9526	.9526	1.2955	.1905
3	.9526	.9526	1.0288	1.2955	.1905
4	.9526	.9526	1.0669	1.3717	.1905
5	.9526	.9907	1.105	1.4861	.1905
6	.9907	.9907	1.1431	1.4861	.1905
7	1.0288	.9907	1.2193	1.5242	.1905
8	1.0669	1.0669	1.3717	1.6004	.2286
9	1.0669	1.0669	1.4098	1.6766	.2286
10	.1143	.0762	.1143	.0953	.1905
11	.1143	.0572	.0762	.0953	1.3336
12	.1143	.0572	.1143	.0953	
13	.0762	.0381	.1143	.1143	
14	.0762	.0381	.1143	.1143	
15	.0762	.0381	.1143	.1524	
16	.0762	.0572	.1524	.1143	
17	.0762	.0572	.1524	.1143	
18	.0953	.0572	.1524	.1143	1.6004
19	.1143	.1143	.1524	.1143	.1524
20	.1143	.1143	.1143	.1143	.1524
21	.1143	.0953	.1143	.1143	.1524
22	.1143	.0953	.1143	.1524	.1524
23	.0762	.0953	.1143	.1524	.1524
24	.8764	.9145	.8383	1.105	.1524
Max	1.0669	1.0669	1.4098	1.6766	1.6004
Min	.0762	.0381	.0762	.0953	.1524
Avg	.4612	.4493	.5303	.6533	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 203 / 11 KV YAMGAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.1812	1.105	1.1431	.1143
2	1.0288	1.2193	1.1431	1.2574	.1143
3	1.0669	1.2193	1.2193	1.2955	.1143
4	.9526	1.2574	1.2574	1.2955	.1143
5	1.1431	1.2574	1.2955	1.2955	.1143
6	1.1431	1.2955	1.3336	1.3336	.1143
7	1.1431	1.3336	.1334	1.3717	.1143
8	1.3336	1.3717	1.3336	1.4098	.1143
9	1.3336	1.1812	1.3336	1.448	.1143
10	.1143	.0572	.0762	.1143	.1143
11	.0762	.0572	.0762	.1143	1.3717
12	.0762	.0381	.0572	.1143	
13	.0572	.0572	.0762	.0572	
14	.0572	.0572	.0762	.0572	
15	.0572	.0762	.0762	.0572	
16	.0572	.0572	.0762	.0572	
17	.0381	.0572	.0762	.0572	
18	.0762	.0572	.0762	.0762	1.5242
19	.0762	.0953	.0762	.0762	.0953
20	.0762	.0953	.0762	.0762	.0953
21	.0762	.0762	.0762	.1143	.0953
22	.0762	.0762	.0762	.1143	.0953
23	.0762	.0762	.0762	.1143	.0953
24	.9526	1.1812	1.0669	1.105	.1143
Max	1.3336	1.3717	1.3336	1.448	1.5242
Min	.0381	.0381	.0572	.0572	.0953
Avg	.5033	.5597	.5112	.5898	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 201 / 11 KV NARSALE PATTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1132	.0762	.1143	1.1694	1.3336	.1715
2	.1143	.0754	.0762	.1143	1.3203	1.7147	.1715
3	.0953	.0754	.0572	.0953	1.3203	1.8671	.1524
4	.0953	.1132	.0762	.0953	1.8484	1.9052	.1524
5	.1143	.1132	.0762	.1143	1.9239	2.0957	.1715
6	.0953	.0754	.0762	.1334	2.1125	2.2481	.1905
7	.0953	.0754	.0762	.1334	2.2257	2.2862	.1905
8		.0754	.0762	.1524	2.2634	2.2862	.1905
9		.0377	.0762	.1509	2.3243	1.8671	.2075
10		.1334		.1886	.1905	.2096	.1886
11	1.448	.5716	.8383	.9808	.0762	.1334	1.4335
12	1.3957	1.3717	.9717	1.773	.0762	.1524	
13	1.4335	1.3717	1.1812	.1132	.0572	.1143	
14	1.4335	.9335	1.0669	.1132	.0762	.1143	
15	1.3957	1.2193		.0943	.0762	.0953	
16	1.4335	1.1431		.0943	.0953	.1143	
17	1.3203	1.1431		.0943	.0953	.1143	
18	1.1694	1.1431		.0754	.1334	.1143	2.2257
19	.0754	.0762		.1509	.1524	.2286	.1509
20	.0754	.1143	.1715	.1509	.0762	.2286	.132
21	.0566	.0762	.1334	.1509	.1143	.2096	.1509
22	.0754	.0953	.1143	.1132	.0762	.2096	.1509
23	.0754	.0762	.1143	.1509	.0762	.1905	.1509
24	.1143	.0754	.0953	.1143	1.094	1.2384	.1905
Max	1.448	1.3717	1.1812	1.773	2.3243	2.2862	2.2257
Min	.0566	.0377	.0572	.0754	.0572	.0953	.132
Avg	.5822	.4291	.2974	.2276	.7906	.8780	.3540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 202 / 11 KV NEW JALOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.7167	.724	.7621	.7545	.8764	.0381
2	.5716	.7167	.7621	.9335	.7922	.8954	.0381
3	.6668	.7922	.8002	.9145	.8676	.9145	.0381
4	.7621	.8488	.8573	.9526	.8865	.9526	.0381
5	.8573	.9808	.9907	.9907	.9808	.9907	.0572
6	.9526	1.0562	.0953	.9717	1.0185	.9907	.0572
7	1.0669	1.0562	1.0288	1.0479	1.0562	.9907	.0572
8		1.1317	1.1431	1.105	1.0562	1.1431	.0572
9		1.094	1.105	1.1694	1.086	1.0669	.0566
10		.0572	.0572	.0754	.0572	.0572	.0566
11	.0377	.0572	.0381	.0377	.0381	.0572	.7545
12	.0377	.0381	.0381	.0189	.0191	.0381	
13	.0377	.0381	.0381	.0377	.0381	.0381	
14	.0377	.0381	.0381	.0377	.0381	.0381	
15	.0377	.0381		.0377	.0191	.0381	
16	.0377	.0381		.0377	.0191	.0381	
17	.0377	.0381		.0377	.0191	.0381	
18	.0377	.0572		.0377	.0381	.0381	1.0185
19	.0377	.0762		.0377	.0381	.0572	.0377
20	.0377	.0762	.0572	.0377	.0381	.0572	.0377
21	.0377	.0762	.0572	.0377	.0572	.0572	.0377
22	.0377	.0762	.0381	.1132	.0381	.0572	.0377
23	.0377	.0762	.0381	.1509	.0572	.0572	.0377
24	.5335	.6413	.6668	.5716	.5658	.724	.0381
Max	1.0669	1.1317	1.1431	1.1694	1.086	1.1431	1.0185
Min	.0377	.0381	.0381	.0189	.0191	.0381	.0377
Avg	.3082	.4090	.4512	.4231	.3991	.4255	.1386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 203 / 11 KV NEW SANGAVI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.1524	.1524	.1886	.1905	2.4387
2	.1905	.1886	.1905	.1524	.1886	.1905	2.4768
3	.1905	.2263	.2096	.1524	.2263	.2096	2.572
4	.1905	.1698	.2286	.1524	.2263	.2096	2.6292
5	.2286	.1886	.1905	.1905	.1886	.2286	2.6863
6	.2286	.1886	.1905	.1905	.2075	.2286	2.8197
7	.2667	.2263	.2096	.2286	.2263	.3048	2.8578
8		.2263	.2477	.2667	.2829	.3239	2.934
9		.1905	.1905	.2075	.2286	.2096	2.9424
10		.2477	.2477		.3048	.3429	.3018
11	2.7161	1.7147	2.0576		2.2862	2.2481	.1509
12	2.7161	2.4387	2.3053		2.8578	2.8578	
13	2.6783	2.5339	2.4768	2.6783	3.1436	3.1626	
14	2.6783	1.9814	2.3243	2.7161	3.0864	3.0483	
15	2.6595	2.2481		2.7538	3.0483	3.1626	
16	2.6783	2.2862		2.7915	3.1245	3.2007	
17	2.5652	2.3624		2.8292	2.8959	3.2007	
18	2.452	2.2481		2.8292	3.0102	3.0293	.1509
19	.1132	.1524		.3018	.3048	.4001	.3018
20	.132	.1905	.2477	.2641	.3429	.381	.2641
21	.1132	.1905	.2286	.2263	.3048	.2667	.2641
22	.1509	.1905	.2096	.2263	.3048	.2286	.2263
23	.1509	.1905	.2096	.1886	.2667	.1905	.2263
24	.1715	.1886	.1905	.1905	.1886	.1905	2.0576
Max	2.7161	2.5339	2.4768	2.8292	3.1436	3.2007	2.9424
Min	.1132	.1524	.1524	.1524	.1886	.1905	.1509
Avg	1.1163	.8732	.6478	.9376	1.1431	1.1669	1.5723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 276006 / 132/33/11 KV PULUJ

Feeder No / Name : 205 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.1888
Max	1.1888
Min	1.1888
Avg	1.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 276006 / 132/33/11 KV PULUJ

Feeder No / Name : 207 / 11 KV BEGUMPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6613
Max	.6613
Min	.6613
Avg	.6613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 241 / 11 KV IAKSHMINAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
17		.4287
18		.4287
19		.6001
20		.6859
21		.583
22		.4801
23		.4287
24	.381	
Max	.381	.6859
Min	.381	.4287
Avg	.381	.5193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 242 / 11 KV Thombarewadi feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 243 / 11 KV ACHAKDANI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.381	.3048	.1524	.381	1.7528
2	.3048		.3048	.381	.3048	.4572	1.829
3	.381		.2286	.3048	.381	.4572	1.6766
4	.4572		.3048	.3048	.2286	.6097	2.0576
5	.381		.3048	.381	.3048	.6097	2.2862
6	.3048		.3048	.4572	.3048	.5335	2.1338
7				.3048	.3048	.381	2.1338
8			.381	.2286	.381	.3048	
9			.3048	.3048	.381	.2286	
10			.3048	.1524	.2286	.1524	.1524
11			.2286	.1524	.1067	.1524	.2286
12			.2286	.0762	.0762	.1524	
13			.1981	.0762	.0762	.1524	
14			.1829	.0762	.0762	.1524	
15			.2286	.1219	.2286	.1524	
16			.9145	.2286	.1524	.2286	
17			2.4387	2.5911	2.6673	.381	.1524
18			2.7435	2.2862	.5335	.9145	.3048
19			2.4387	.9145	.4572	.6859	.1524
20			2.2862	.9907	.4572	1.5242	.381
21			2.2862	.7621	.4572	2.7435	.381
22		2.6673	2.2862	.7621	.6097	2.5911	.1524
23		2.6673	2.1338	.6859	2.21	2.3624	.2286
24	2.6673		2.7435	.3048	.6097	2.1338	2.1338
Max	2.6673	2.6673	2.7435	2.5911	2.6673	2.7435	2.2862
Min	.3048	2.6673	.1829	.0762	.0762	.1524	.1524
Avg	.6858	2.6673	1.0503	.5480	.4871	.7684	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 244 / 11 KV Khavaspur feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 245 / 11 KV Gaonthan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 241 / 11 KV Jawala feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 242 / 11 KV Sonand
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 243 / 11 KV Tarangewadi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 244 / 11 KV Gaothan feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 245 / Kashidwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 246 / 11kv lonvire Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 247 / 11kv bhopsewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 241 / 11 KV Gherdi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
1	.1829	.4572
2	.1829	.5944
3	.1829	.8993
4	.2134	1.1736
5	.2591	1.3108
6	.3048	
7	.2743	1.448
8	.2743	1.5851
9	.2439	1.5154
10	.2134	
11	1.1888	
12	1.4327	
13	1.7223	
14	1.4632	
15	1.6309	
16	1.5394	
17	1.6309	
18	1.0974	
19	.2286	
20	.2439	
21	.2286	
22	.2134	
23	.1981	
24	.381	.3658
Max	1.7223	1.5851
Min	.1829	.3658
Avg	.6471	1.0388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 242 / 11 KV Pare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1067	.3353
2	.1067	.1067	.4572
3	.1067	.1067	.6249
4	.1067		.823
5	.1372		1.0517
6	.1677		1.2041
7	.1829		1.326
8	.1829		1.1888
9	.1524		
10	.1524		
11	.9755		
12	1.2041		
13	1.4022		
14	1.1126		
15	1.2498		
16	1.0669		
17	1.326		
18	1.0974		
19	.1524		
20	.1829		
21	.1677		
22	.1219		
23	.1067		
24	.381		.2591
Max	1.4022	.1067	1.326
Min	.1067	.1067	.2591
Avg	.4979	.1067	.8078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 243 / 11 KV Hangirge feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
1	.4877	.1981
2	.5944	.1981
3	.6401	.1981
4	1.0669	.2439
5	1.3565	.2591
6	1.4937	.2743
7	1.5699	.3658
8	1.9509	.3048
9	2.0424	
10	.2286	
11	.1524	
12	.1219	
13	.1219	
14	.1219	
15	.1524	
16	.1524	
17	.1372	
18	.1677	
19	.1981	
20	.2896	
21	.2439	
22	.2286	
23	.1981	
24	.3963	.1981
Max	2.0424	.3658
Min	.1219	.1981
Avg	.5881	.2489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 244 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
1		.2439
2		.2439
3		.2439
4		.2439
5		.2743
6		.3048
7	.4268	.4877
8	.4572	.4268
9	.3658	
10	.3048	
11	.2743	
12	.2439	
13	.2439	
14	.2134	
15	.2134	
16	.2286	
17	.2591	
18	.2896	
19	.381	
20	.4877	
21	.3963	
22	.3048	
23	.2743	
24	.381	.2439
Max	.4877	.4877
Min	.2134	.2439
Avg	.3192	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 241 / 11 KV Kola feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 242 / 11 KV Gaudwadi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.25	.25	.2343	.2429	.2515	.2429
2	.3048	.25	.2343	.2343	.2429	.2683	.2486
3	.3201	.2656	.2343	.25	.2429	.2515	.2622
4	.3506	.2812	.2812	.2656	.2753	.2683	.2591
5	.3506	.3125	.3125	.2968	.2915	.2753	.2785
6	.381	.3281	.3281	.3281	.3725	.3812	.2753
7	.4115	.3281	.3593	.3281	.3401	.4024	.3077
8	.3048	.3437	.25	.1875	.2915	.2486	.2321
9	.1829	.2343	.1718	.1718	.2915	.2204	.1658
10	.1829	.2031	.125	.1094	.2591	.1526	.1619
11	1.1126	1.0623	1.3123	1.0623	.9393	1.2717	1.326
12	2.3167	1.9841	1.4529	1.6872	1.6356	1.9951	1.6385
13	2.3624	1.9372	1.5935	1.7185	1.7976	2.0388	1.8023
14	2.332	2.0309	1.4685	1.5623	1.8461	1.9498	2.0056
15	2.2405	1.9685	1.6716	1.8747	1.6194	1.9839	1.9725
16	2.21	1.7497	1.7654		1.7328	1.9498	1.7328
17	2.21	1.5779	1.7497	1.2342	1.8461	2.0008	1.7238
18	1.448	1.4217	1.6404	1.4685	1.1336	1.56	1.6385
19	.1981	.2343	.2187	.2031	.2429	.2347	.1781
20	.2439	.3593	.2968	.3125	.3401	.285	.2591
21	.2896	.3593	.3281	.3125	.2915	.2713	.2984
22	.2896	.2968		.2968	.2753	.2683	.2753
23	.2591	.2812	.2343	.2812	.2591	.2429	.2429
24	.4572	.2656	.25	.2343	.2591	.2429	.2429
Max	2.3624	2.0309	1.7654	1.8747	1.8461	2.0388	2.0056
Min	.1829	.2031	.125	.1094	.2429	.1526	.1619
Avg	.8777	.7636	.7186	.6371	.7112	.7923	.7405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 243 / 11 KV Junoni feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2031	.2187	.2343	.2267	.2683	.1943
2	.2286	.2031	.2187	.2343	.2267	.2652	.1943
3	.2439	.2187	.25	.25	.2267	.2785	.213
4	.2591	.2812	.2812	.2656	.2429	.2713	.2486
5	.2743	.3125	.2968	.2812	.2753	.3052	.2683
6	.3048	.3281	.3281	.3125	.3563	.3315	.2591
7	.3048	.3125	.3281	.2968	.3563	.3391	.2915
8	.2134	.2187	.1875	.2812	.2267	.2347	.2105
9	.1372	.1562	.1718	.1718	.1457	.1802	.1823
10	.1677	.2031	.125	.1718	.1457	.1844	.1296
11	.9907	1.0311	1.2967	1.2186	.9231	1.073	1.247
12	1.9357	2.1872	1.6872	1.9372	1.3441	1.5592	1.587
13	2.1338	1.906	1.656	1.4529	1.749	1.8275	1.8138
14	1.9814		1.6248	1.3435	1.5708	1.6956	1.6598
15	2.0119	1.6404	1.7029	1.5154	1.3765	1.6108	
16	1.9814	1.6248		1.2967	1.3927	1.3413	1.5249
17	2.0119	1.406		1.2342	1.1498	1.3599	1.2955
18	1.9814		1.656	1.406	1.0688	1.3245	1.1336
19	.2439	.2656	.2187	.25	.2591	.285	.2267
20	.2743	.2968	.2812	.2812	.2915	.285	.2915
21	.2743	.2812	.2656	.2812	.2915	.2543	.2753
22	.2591	.2656	.2656	.2812	.285	.218	.2294
23	.2439	.25	.25	.2656	.2591	.218	.2321
24	.4572	.2187	.2187	.2343	.2429	.2713	.1943
Max	2.1338	2.1872	1.7029	1.9372	1.749	1.8275	1.8138
Min	.1372	.1562	.125	.1718	.1457	.1802	.1296
Avg	.7976	.6278	.6150	.6457	.6097	.6659	.6045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 244 / 11 KV Pachegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4687	.5468	.3906	.4049	.4144	.4144
2	.3048	.4687	.6249	.4218	.4049	.4191	.4049
3	.381	.7811	.703	.4999	.4858	.503	.4534
4	.4115	.9374	.9374	.5468	.5668	.5935	.4915
5	.4725	1.1717	1.0155	.6562	.5668	.663	.5735
6	.5335	1.2498	1.0936	.7343	.8097	.6706	.8288
7	.8383	1.406	1.3279	1.1873	1.1336	1.1603	1.0774
8	.884	1.4842	1.6404	1.3279	1.1336	1.3413	1.2631
9	.9907	1.4842	1.7185	1.3279	1.1336	1.1736	1.1469
11							.0937
12							.0995
13							.0972
14							.0972
15							.1134
16	.0914	.0937	.125	.1094	.1134	.1357	.1134
17	.0914	.0937	.125	.1094	.1134	.1357	.0983
18	.1219	.1094	.125	.125	.1134	.1341	.0972
19	.1829	.1562	.1718	.1562	.1781	.1844	.1296
20	.1829	.1875	.2031	.1718	.1781	.2204	.1619
21	.1829	.1875	.2031	.1718	.1619	.1989	.1943
22	.1524	.1562	.1875	.1562	.1457	.2012	.1619
23	.1524	.1562	.1718	.1562	.1457	.1844	.1619
24	.4572	.4687	.5468	.3906	.4049	.4191	.4144
Max	.9907	1.4842	1.7185	1.3279	1.1336	1.3413	1.2631
Min	.0914	.0937	.125	.1094	.1134	.1341	.0937
Avg	.3743	.6145	.6371	.4800	.4552	.4863	.3777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 245 / KOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6249	.6249	.6802	.7125	.7125	.6562
2	.6554	.6249	.6249	.6802	.6802	.6802	.6562
3	.6962	.7186	.7499	.7449	.7125	.6802	.6874
4	.7773	.9374	.9998	.8421	.7773	.7773	.7499
5	.9393	1.1248	1.1561	1.1012	.9717	.9717	.8124
6	1.2308	1.2811	1.3123	1.3603	1.2955	1.3279	1.1873
7	1.073	1.1248	1.0936	1.166	1.0364	1.1336	1.1248
10	.5624	.6562	.6371	.6154	.6154	.6802	.6249
11	.5312	.5937	.5636	.4858	.5506	.583	.4687
12	.4999	.5624	.5182	.4858	.583	.583	.4999
13	.4999	.5312	.5182	.4858	.5182	.583	.5312
14	.4687	.4999	.4534	.5182	.5182	.6036	.5312
15	.5312	.5312	.5182	.5182	.6154	.6478	.4999
16	.4687	.5624	.5182	.583	.6154	.6154	.5937
17	.5312	.5624	.6299	.5182	.6478	.6783	
18	.6562	.6562	.663	.7449	.6802	.8139	.7499
19	.9374	.9374	1.004		.9717	1.153	.9998
20	.9998	1.0936	1.1736	1.166	1.0688	1.2407	1.0936
21	.8124	.9686	1.1065	1.0364	1.0688	1.1065	.9998
22	.7621	.8124	.852	.8745	.9069	.9061	.7811
23	.6706	.6874	.8048	.8097	.7773	.7186	.6874
24	.2286	.6249	.6249	.7042	.7125	.7125	.6562
Max	1.2308	1.2811	1.3123	1.3603	1.2955	1.3279	1.1873
Min	.2286	.4999	.4534	.4858	.5182	.583	.4687
Avg	.6904	.7598	.7794	.7677	.7744	.8140	.7425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 246 / 11 KV KOMBADWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4687	.6249	.6093	.5668	.5868	.1134
2	.5335	.5468	.7811	.703	.5668	.6706	.1134
3	.5335	.6249	1.0155	.7499	.6478	.5868	.1296
4	.6097	.7811	1.0155	.8905	.7287	.6478	.1296
5	.7621	.9374	1.0936	1.0623	.8907	.8383	.1296
6	.9907	.9374	1.2498	1.3279	1.2955	1.326	.1492
7	1.326	1.0155	1.7185	1.7497	1.7814	2.1052	.1658
8	1.448	1.0936	1.7966	1.7966	1.6194	1.9433	1.5746
9	1.448	1.0936	1.8747	1.8435	1.7814	1.9433	1.7814
16	.1067	.0937	.125	.125	.1296	.1296	.116
17	.1067	.0937	.1406	.125	.1296	.1326	.1134
18	.1372	.125	.1406	.1406	.1296	.1457	.1134
19	.1981	.2031	.1718	.1718	.1943	.2155	.1457
20	.1981	.2031	.2187	.1875	.1943		.2105
21	.1981	.2031	.2343	.1875	.1781	.0972	.2105
22	.1829	.1875	.1875	.1718	.1619	.1006	.1943
23	.1829	.1875	.1562	.1718	.1619	.0972	.1943
24	.381	.4687	.6249	.5468	.5668	.5868	.1134
Max	1.448	1.0936	1.8747	1.8435	1.7814	2.1052	1.7814
Min	.1067	.0937	.125	.125	.1296	.0972	.1134
Avg	.5445	.5147	.7317	.6978	.6514	.7149	.3166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 247 / 11 KV BUDDIHAL FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1562	.2031	.1875	.2105	.2622	.1781
2	.1524	.1562	.2031	.1875	.2105	.2294	.1989
3	.1524	.1562	.2187	.1875	.2105	.2321	.1943
4	.1677	.1875	.2187	.2031	.1943	.2155	.2267
5	.1829	.2031	.2343	.2031	.2429	.2321	.2591
6	.2134	.2031	.2343	.2343	.2753	.2622	.2591
7	.1829	.2187	.25	.2343	.2591	.2429	.2753
8	.1372	.1718	.1718	.1718	.1134	.2105	.2321
9	.1219	.1875	.1718	.1875	.1943	.1619	.2321
10	.1524	.1562	.1406	.2187	.2105	.1943	.1989
11	1.4937	1.5623	1.8747	1.7654	1.4899	1.6842	.9945
12	2.0576		2.1715	1.9997	1.7004	2.1052	1.3592
13	2.0576		2.4528	2.6402	2.4615	2.2708	1.5565
14	2.3167	2.2653		.3125	2.4777	2.17	2.2377
15	2.332			.2812	2.4939	2.1376	2.1628
16	2.2862		2.7027	2.234	2.1052	1.9559	2.1548
17	2.2253	2.6558	2.7808	2.1247	1.9109	2.1052	1.9595
18	2.1643	2.6715		2.0934	2.0567	2.1879	2.1382
19	.2286	.1875	.1406	.2187	.1943	.2321	.2155
20	.2591	.2343	.25	.2656	.2429	.2429	.2652
21	.2439	.25	.25	.25	.2591	.2267	.2486
22	.2286	.2812	.2187	.25	.2753	.1943	.2486
23	.2134	.25	.1875	.25	.2753	.1823	.2267
24	.4572	.2031	.2343	.1875	.2267	.2818	.1781
Max	2.332	2.6715	2.7808	2.6402	2.4939	2.2708	2.2377
Min	.1219	.1562	.1406	.1718	.1134	.1619	.1781
Avg	.8415	.6179	.7290	.7037	.8455	.8425	.7584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 241 / 11 KV Kolegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 242 / 11 KV Mahud feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 243 / 11 KV Itaki feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 244 / 11 KV Mahim feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 245 / 11 KV Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 241 / 11 KV Shirbhavi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9389	.8383	1.073	1.0059	1.1401	.9069	.8453
2	1.0395	.8718	1.1401	1.1233	1.1736	.9393	.9282
3	1.1401	.8718	1.1736	1.2407	1.2071	.9831	1.0111
4	1.2407	.9724	1.2071	1.358	1.2742	1.0688	1.094
5	1.3413	1.1065	1.4251	1.4754	1.6766	1.2955	1.1934
6	1.4419	1.4419	1.7436	1.6095	1.8778	1.9433	1.5424
7	2.3137	2.0119	2.3472		2.5149	2.2996	2.0317
8	2.3807	2.5819	2.5484	2.1963	2.7496	2.4939	2.5396
9	2.364	2.5652	2.4143	2.8334	2.079	2.2672	2.0119
10	.2683	.2683	.3018	.2683	.2591	.2804	.2347
11	.2683	.2012	.2347	.2012	.2267	.3155	
12	.2683	.2012	.1677	.2012	.1296	.1578	
13	.2012	.2012	.1677	.1677	.1619	.1753	.1677
14	.2012	.1677	.1677	.1677		.1677	
15	.2012	.1677	.1677	.2012	.1619	.1844	.1341
16	.2012	.2012	.2515	.2012	.1943	.1844	.1341
17	.2683	.2012	.2683	.2347	.1943	.2452	.1677
18	.3018	.3018	.4024	.2683	.2591	.2641	.2683
19		.4024	.3688	.3353	.3239	.4527	.3018
20	.3353	.4024	.4024	.3353	.3563	.4527	.4024
21	.3688	.3353	.3521	.3353	.3239	.3961	.3688
22	.3353	.2683	.3353	.2683	.2915	.3772	.3353
23	.3018	.2683	.3018	.2683	.2622		.3018
24	.381	.8048	.8383	.8886	.788	.6802	.7537
Max	2.3807	2.5819	2.5484	2.8334	2.7496	2.4939	2.5396
Min	.2012	.1677	.1677	.1677	.1296	.1578	.1341
Avg	.7871	.7356	.8250	.7472	.8533	.8057	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 242 / 11KV Dhyati Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.5182	.6036	.503	.6036	.7125	.3856
2	.4862	.5182	.6706	.6036	.6371	.7449	.4694
3	.5533	.5506	.6706	.7042	.6706	.8097	.5365
4	.6203	.6154	.7042	.8048	.7377	.8421	.6203
5	.6874	.7773	.7545	.9054	.7545	.9393	.7042
6	.7545	.8421	.8383	1.0059	.8383	1.1012	.8718
7	.9221	1.0688	1.1736	1.1568	1.0898	1.1336	1.0059
8	1.2407	1.166	1.2574	.9556	1.0898	1.0364	1.2574
9	.9878	1.1336	1.3413	1.0059	.9389	.9717	1.1568
10	.1943	.4614	.285	.1677	.1943	.2012	.1509
11	.1943	.1677	.2683	.1509	.1943	.1677	.1341
12	.1619	.1341	.285	.1341	.1619	.2515	.1174
13	.1619	.1341	.3185		.1619	.2347	.1174
14	.1619	.1341	.3018	.1341	.1619	.2683	.1174
15	.1619	.1341	.2012	.1341	.1619	.2012	.1341
16	.1943	.1341	.2347	.1509	.1619	.218	.1341
17	.1943	.1341	.3185	.1677	.1943	.3018	.1677
18	.2267	.1677	.2012	.2347	.2267	.2347	.1677
19	.2591	.3018	.3018	.3018	.2591	.4024	.2515
20	.2915	.285	.3018	.3018	.2915	.3521	.3353
21	.2591	.2683	.3185	.2683	.2591	.285	.2347
22	.2267	.2515	.2683	.2347	.2267	.285	.2347
23	.1943	.2347	.2683	.2347	.1943	.3185	.2012
24	.381	.4858	.4191	.4191		.583	.3185
Max	1.2407	1.166	1.3413	1.1568	1.0898	1.1336	1.2574
Min	.1619	.1341	.2012	.1341	.1619	.1677	.1174
Avg	.4139	.4424	.5128	.4643	.4439	.5249	.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 243 / 11 KV Haldahiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.2915	.285	.3185	.2683	.2591	.3353
2	.3521	.2915	.2683	.3521	.285	.2591	.3688
3	.3688	.2915	.3018	.3688	.2683	.2591	.4024
4	.4024	.3239	.3353	.4024	.3018	.2915	.4359
5	.4359	.3239	.4024	.4359	.3688	.3239	.4694
6	.4694	.3563	.503	.4694	.4359	.3563	.503
7	.4694	.421		.4694	.4359	.3887	.4359
8	.4024	.3887		.4694	.3018	.3239	.3353
9	.3887	.2267	.2683	.2347	.2347	.2591	.2347
10	.1943	.2267	.2347	.2012	.2267	.2347	.2012
11	1.0688	1.5424	.9389	1.3077	.8745	.9724	1.1401
12	2.2672	2.1795	2.0454	1.6766	1.8785	1.9784	1.7101
13	2.2672	1.8442	1.9113		1.5223	1.7436	1.5089
14	1.9757	1.7604	1.7772	1.2071	1.5223	1.6095	1.4083
15	1.9433	1.7436	1.6766	1.5424	1.587	1.576	1.3413
16	1.8138	1.8107	1.8442	1.8442	1.5546	1.6095	1.3413
17	1.8461	1.8778	1.9113	1.8107	1.8138		1.5089
18	1.6194	1.4419	1.1736	1.6095	1.3603	1.6095	1.3413
19	.2915	.3353	.3688	.3688	.3239	.3688	.2683
20	.3239	.3353	.3018	.3353	.3887	.3688	.3688
21	.3239	.3353	.3018	.3353	.2915	.3688	.3353
22	.2915	.3353	.3018	.3018	.2591	.3353	.3018
23	.2915	.3353	.3018	.3018	.2591	.3018	.3018
24	.5335	.2915	.3018	.3018	.3018	.2591	.3018
Max	2.2672	2.1795	2.0454	1.8442	1.8785	1.9784	1.7101
Min	.1943	.2267	.2347	.2012	.2267	.2347	.2012
Avg	.8608	.8046	.8071	.7246	.7110	.6981	.7042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 244 / Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3239	.3185	.2683	.285	.3239	.2683
2	.3353	.3239	.3353	.2683	.2683	.3239	.2683
3	.3353	.3239	.3521	.2683	.3018	.3239	.2683
4	.4024	.3239	.3688	.3353	.3353	.3239	.3353
5	.4694	.3563	.3856	.4024	.4024	.3563	.3688
6	.503	.3887	.4694	.4694	.503	.421	.4024
7	.4694	.4534		.4359	.4694	.4534	.3688
8	.4359	.4534		.4024	.3353	.421	.3353
9	.3887	.421	.3353	.3688	.2683	.3563	.3018
10	.3563	.3563	.3018	.2683	.2267	.3353	.2347
11	.2915	.2347	.2683	.2347	.1943	.3018	.1677
12	.2267	.2012	.2347	.2012	.1619	.2683	.1677
13	.1943	.2012	.2012	.2012	.1619	.2347	.1509
14	.1943	.1844	.1677	.218	.1619	.2012	.1677
15		.1677	.1341	.218	.1619	.1677	.2012
16	.2591	.1677	.1341	.2347	.1943	.1341	.2012
17	.2915	.2012	.2012	.2515	.2267	.2012	.2347
18	.3239	.2683	.2683	.3018	.2591	.2683	.2683
19		.4024	.3353	.4024	.3887	.3353	.3018
20	.4534	.3856	.4024	.4024	.4534	.4024	.4694
21	.421	.3688	.3688	.3688	.421	.3688	.4024
22	.3887	.3353	.3353	.3353	.3887	.3353	.3688
23	.3563	.3353	.3018	.3353	.3563	.3018	.3353
24	.1524	.3239	.3353	.2683	.3018	.3239	.2683
Max	.503	.4534	.4694	.4694	.503	.4534	.4694
Min	.1524	.1677	.1341	.2012	.1619	.1341	.1509
Avg	.3447	.3126	.2980	.3109	.3011	.3118	.2857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 245 / Devkatewadi feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.2591	.3353	.3521	.285	.2267	.3521
2	.3688	.2591	.3185	.3688	.3018	.2267	.3856
3	.3856	.2591	.3688	.3856	.3353	.2267	.4024
4	.4191	.2915	.4024	.4191	.3688	.2591	.4359
5	.4359	.3239	.4359	.4359	.4024	.2915	.4694
6	.4694	.3239	.5365	.4694	.4694	.3239	.4694
7	.4694	.3887		.4024	.4694	.3563	.5365
8	.4024	.3563		.4694	.2683	.3239	.5365
9	.3887	.3239	.2683	.3353	.2012	.2915	.2683
10	.3239	.2915		.3018	.1943	.2683	.2347
11	1.004	1.2574	.8048	1.2071	1.004	.7377	1.073
12	2.3644	1.8107	2.0119	1.8107	2.1376	.8718	1.5424
13	2.4615	2.146	2.079	1.8442	2.0729	1.4754	1.5089
14	2.0081	2.0119	2.146	1.7436	1.6194	1.6095	1.4754
15	1.9433	2.0119	1.4754	2.0119	1.6194	1.6766	1.5424
16	1.9433	2.0454		1.8778	1.7814	1.6766	1.3748
17	1.9109	2.0119	1.9448	1.8442	1.9757	1.6766	2.0119
18	1.7814	1.8442	1.4754	1.7436	1.7814	1.7436	
19		.3353	.3353	.4359	.2915	.2683	.3688
20	.3563	.3688	.3353	.4024	.3239	.3353	.4694
21	.3563	.3353	.4694	.3688	.2915	.3353	.3688
22	.3887	.3353	.4694	.3353	.2591	.3353	.3353
23	.2915	.3185	.3353	.3018	.2267	.3353	.3018
24	.381	.2591	.3353	.3353	.3018	.2267	.3353
Max	2.4615	2.146	2.146	2.0119	2.1376	1.7436	2.0119
Min	.2915	.2591	.2683	.3018	.1943	.2267	.2347
Avg	.922	.8404	.8442	.8418	.7909	.6708	.7304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 246 / 11KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0324	.0335	.0335	.0335	.0324	.0335
2	.0335	.0324	.0335	.0335	.0335	.0324	.0335
3	.0335	.0324	.0335	.0335	.0335	.1943	.0335
4	.0335	.0972	.0335	.0335	.2347	.1943	.0335
5	.0335	.1296	.0335	.0335	.2683	.1943	.0335
6	.0671	.1619	.0335	.0335	.2683	.1943	.0335
7	.0671	.2591		.0335	.3018	.1943	.0671
8	.0671	.3239	.0671	.0335	.3018	.0972	.0671
9	.0648	.3239	.0335	.0335	.2683	.0324	.0671
10	.0648	.3239	.0335	.0335	.3563	.0671	.0671
11	.0648	.2012	.0335	.0335	.3563	.0335	.0671
12	.0324	.2347	.0335	.0335	.2591	.0335	.0671
13	.0324	.2347	.0335	.0335	.2591	.0335	.0671
14	.0324	.2347		.0335	.2591	.0335	.1006
15	.0324	.2347		.0335	.1943	.0335	.0671
16	.0324	.2012	.0335	.0671	.1943	.0335	.0671
17	.0324	.1677	.0335	.0335	.1943	.0335	.0335
18	.0324	.0335	.0335	.0335	.0324	.0335	.0335
19	.0324	.0335	.0335	.0335	.0324	.0335	.0335
20	.0324	.0335	.0335	.0335	.0324	.0335	.0335
21	.0324	.0335	.0335	.0335	.0324	.0335	.0335
22	.0324	.0335	.0335	.0335	.0324	.0335	.0335
23	.0324	.0335	.0335	.0335	.0324	.0335	.0335
24	.4572	.0324	.0335	.0335	.0335	.0324	.0335
Max	.4572	.3239	.0671	.0671	.3563	.1943	.1006
Min	.0324	.0324	.0335	.0335	.0324	.0324	.0335
Avg	.0587	.1441	.0351	.0349	.1685	.0709	.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-
STATIONFeeder No / Name : 241 / 11 KV Nazara feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
23		.3239
24	.381	
Max	.381	.3239
Min	.381	.3239
Avg	.381	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-STATION

Feeder No / Name : 242 / 11 KV Rajuri feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	.1619
2	.1638
3	.1619
4	.1619
5	.1638
6	.1619
7	.1619
8	.1619
10	.1619
11	.2429
12	.8097
13	2.1052
23	.1619
24	.4572
Max	2.1052
Min	.1619
Avg	.3741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-
STATIONFeeder No / Name : 243 / 11 KV Chopadi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-
STATIONFeeder No / Name : 244 / 11 KV Karandewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.5335
Max	.5335
Min	.5335
Avg	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-STATION

Feeder No / Name : 245 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-STATION

Feeder No / Name : 246 / 11 KV Rajuri Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
23		.1134	.081
24	.381		
Max	.381	.1134	.081
Min	.381	.1134	.081
Avg	.381	.1134	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 241 / 11 KV Manjari feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2347	.2172	.0724	.0362	.0671	.0686
2	.2534	.3018	.2401	.0724	.0362	.0671	.061
3	.362	.3353	.2534	.0362	.0362	.0671	.0686
4	.4706	.503	.2896	.0724	.0724	.0671	.0686
5	.5228	.5365	.3258	.1086	.0724	.0671	.0671
6	.543	.6706	.3258	.1086	.0724	.0671	.0686
7	.583	.6371	.4706	.0724	.0724	.0671	.0686
8	.5068	.5365	.4115	.0362	.0671	.0671	.0335
9	.5792	.5365	.3772	.0362	.0335		.0335
10	.0362	.0335	.0335	.0362	.0335	.0655	.0335
11	.0362	.0335	.0335	.181	.1341	.3277	.2012
12	.0362	.0335	.0335	.6516	.3353	.3277	.3353
13	.0343	.0339	.0335	.543	.4694	.3932	.4024
14	.0343	.0678	.0335	.5068	.4359	.426	.4359
15	.0343	.0671	.0335	.4706	.4024	.426	.4024
16	.0362	.0671	.0335	.4344	.4024	.426	.4024
17	.0248	.0362	.0335		.3688	.3688	.4024
18	.0362	.0362	.0335	.4344	.4024	.4115	.2683
19	.021	.0343	.0335	.0724	.0335	.0754	.0671
20	.0362	.0686	.0335	.0724	.0671	.0686	.0671
21	.0362	.0724	.0335	.0724	.0335	.0678	.0335
22	.021	.0362	.0335	.0724	.0671	.0686	.0671
23	.0362	.0362	.0335	.0724	.0671	.0678	.0671
24	.381	.1677	.1448	.0362	.0362	.0671	.0671
Max	.583	.6706	.4706	.6516	.4694	.426	.4359
Min	.021	.0335	.0335	.0362	.0335	.0655	.0335
Avg	.2042	.2132	.1469	.1857	.1578	.1793	.1580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 242 / 11 KV Bamni feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3018	.3258	.0362	.0362	.0335	.0335
2	.3982	.3688	.3429	.0362	.0362	.0335	.0335
3	.3982	.503	.3429	.0362	.0362	.0335	.0335
4	.4344	.503	.3772	.0362	.0343	.0335	.0335
5	.6154	.7712	.4344	.0724	.0724	.0671	.0671
6	.6516	.823	.5068	.0724	.0724	.0671	.0671
7	.5487	.7042	.6878	.0724	.0362	.0671	.0671
8	.5144	.6706	.8478	.0686	.0328	.0335	.0335
9	.724	.6706	.57	.0362	.0335		.0335
10	.0362	.0343	.0335	.0362	.0335	.0328	.0335
11	.0343	.0335	.0335	.1448	.2012	.4915	.3688
12	.0248	.0335	.0335	.4706	.7042	.6226	.4359
13	.0362	.0335	.0335	.543	.6706	.6226	.4694
14	.0343	.0671	.0335	.5068	.7042	.6226	.4694
15	.0343	.0671	.0335	.543	.6706	.6226	.503
16	.0362	.0655	.0335	.543	.6371	.6226	.5365
17	.0362	.0373	.0335	.6154	.6036	.5487	.57
18	.0362	.0373	.0335	.6154	.4694	.5144	.4024
19	.0362	.0362	.1006	.0362	.0335	.0335	.0335
20	.0362	.0181	.0335	.0686	.0335	.0343	.0335
21	.0362	.0362	.0335	.0724	.0335	.0335	.0335
22	.0343	.0362	.0335	.0724	.0335	.0339	.0335
23	.0362	.0362	.0335	.0362	.0335	.0335	.0335
24	.381	.2012	.2896	.0362	.0362	.0335	.0335
Max	.724	.823	.8478	.6154	.7042	.6226	.57
Min	.0248	.0181	.0335	.0362	.0328	.0328	.0335
Avg	.2298	.2537	.2192	.2003	.2203	.2292	.1830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 243 / 11 KV Sangewadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2347	.2172	.5068	.9175	.9054	.6173
2	.2172	.2347	.2172	.543	.852	.9724	.6859
3	.2172	.2347	.2172	.724	.9503	1.0395	.7716
4	.2172	.2347	.2172	.8326	1.278	1.073	.8573
5	.2058	.2401	.2896	.9774	1.4746	1.1401	1.0059
6	.2614	.2743	.3086	.9774	1.5729	1.0395	1.0486
7	.2534	.2683	.2401	1.5565	1.6712	1.8107	1.6095
8	.2534	.2683	.2683	2.0271	1.5074	1.8107	1.9448
9	.2172	.2012	.2058	2.0271	1.3763		1.6766
10	.2172	.2012	.2012	.2058	.1966	.1966	.1006
11	1.1222	.2035	1.073	.181	.1966	.1966	.1006
12	1.7013	1.6461	1.7772	.1715	.2294	.1638	.1006
13	1.7375	1.5851	1.8442	.1448	.2713	.1638	.1341
14	1.3756	1.6766	1.6095	.181	.1966	.1638	.1341
15	1.7013	1.749	1.5089	.181	.1966		.1006
16	1.6289	1.3413	1.576	.181	.1966	.1638	.1006
17	1.7013	1.7375	1.8107		.1341	.2058	
18	1.6289	1.5775	1.0395	.2172	.1677	.2347	.2012
19	.2172	.2534	.2347	.2534	.3018	.3018	.2347
20	.2172	.2534	.2683	.2534	.2683	.2683	.2347
21	.1943	.2172	.2012	.2534	.2012	.2401	.2347
22	.2172	.2172	.2012	.2172	.2012	.2058	.2012
23	.2172	.2172	.2012	.2172	.2012	.2058	.2012
24	.381	.2347	.2172	.3982	.5571	.4359	.5144
Max	1.7375	1.749	1.8442	2.0271	1.6712	1.8107	1.9448
Min	.1943	.2012	.2012	.1448	.1341	.1638	.1006
Avg	.6799	.6376	.6644	.5751	.6299	.5881	.5570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 244 / 11 KV Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5087	.4706	.3772	.4706	.3353	.3429
2	.4706	.503	.3982	.3982	.5068	.3688	.3353
3	.5068	.6706	.4706	.4344	.5792	.4024	.4024
4	.724	.6706	.6516	.6154	.6516	.4694	.6173
5	.9412	.8383	.8688	.724	.7964	.57	.6706
6	1.086	.8718	.9412	.9412	.9412	.8048	.8048
7	1.0498	.6783	.9774	.905	.8688	.7712	.8048
8	.6516	.6706	.6173	.6859	.6554	.57	.6706
9	.5068	.5365	.5144	.6859	.4915		.4359
10	.5068	.4694	.3018	.463	.4588	.4588	.4359
11	.3772	.4024	.3018	.4344	.3932	.3277	.3353
12	.3258	.3353	.2515	.3982	.3277	.3277	.3353
13	.2896	.3018	.2012	.1886	.2622	.2949	.3353
14	.2896	.2949	.2347	.362	.3353	.2622	.3018
15	.3772	.2713	.2683	.3258	.3018	.2622	.3018
16	.4344	.2683	.2683	.362	.2683	.2949	.2683
17	.4706	.362	.3353	.362	.3353	.3353	
18	.4801	.4458	.4024	.4344	.4024	.4458	.5365
19	.543	.724	.7712	.7602	.7042	.6859	.7712
20	.4458	.7095	.8718	.6878	.7377	.7545	.7377
21	.3772	.6516	.6706	.6154	.6706	.6706	.6371
22	.3982	.2858	.57	.5792	.503	.6173	.5365
23	.3772	.543	.4024	.5068	.3688	.3772	.4024
24	.381	.3688	.4344	.3982	.4458	.3353	.3353
Max	1.086	.8718	.9774	.9412	.9412	.8048	.8048
Min	.2896	.2683	.2012	.1886	.2622	.2622	.2683
Avg	.5176	.5159	.5082	.5269	.5199	.4671	.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 245 / 11 KV DEVALE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2347	.2172	1.0498	.905	.8383	.8383
2	.2172	.2347	.2172	1.0136	.9412	.8718	.9054
3	.2058	.2012	.2401	1.0498	1.0498	.9724	1.0059
4	.2401	.2012	.2896	1.086	1.086	1.073	1.0395
5	.2743	.2012	.3258	1.2308	1.5089	1.1401	1.1065
6	.2743	.1715	.2896	1.3394	1.6289	1.2742	1.2452
7	.2896	.1677	.2534	1.7375	1.6461	1.7436	1.7147
8	.2896	.1341	.2401	2.0995	1.5402	1.7436	1.4419
9	.181	.1341	.2012	1.9547	1.4746		1.6766
10	.2058	.1006	.2012	.1715	.1311	.1638	.1006
11	1.1946	.3688	1.2742	.181	.1311	.1638	.1006
12	1.8099	1.6766	1.7101	.181	.1311		.1006
13	1.8461	1.8861	1.7772	.1448	.1311	.0983	.1006
14	1.6461	1.7604	1.7436	.0743	.1311	.0983	.1006
15	1.9185	1.6766	1.3748	.1448	.1311	.0983	.1006
16	1.9547	1.4754	1.576	.1448	.0983	.0983	.1341
17	1.8461	1.7013	1.8107	.181	.1006	.1006	.1341
18	1.8099	1.5565	1.4083	.2534	.1341	.1372	.1341
19	.2896	.2896	.2683		.2683	.2743	.3018
20	.2896	.2987	.3018	.2896	.3018	.2743	.3018
21	.2896	.2896	.2347	.2715	.2683	.2743	.2683
22	.2534	.2534	.2347	.2534	.2683	.2683	.2347
23	.2401	.2534	.2347	.2534	.285	.2743	.2683
24	.381	.2347	.2401	.9412	.6878	.8048	.8048
Max	1.9547	1.8861	1.8107	2.0995	1.6461	1.7436	1.7147
Min	.181	.1006	.2012	.0743	.0983	.0983	.1006
Avg	.7568	.6459	.6944	.6977	.6242	.5812	.5900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 246 / 11 KV Save Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4862	.4344	.2534	.3982	.3688	.3429
2	.5144	.5765	.4706	.2743	.4706	.4024	.3772
3	.5792	.8383	.5068	.3258	.5068	.4359	.3772
4	.583	.8718	.543	.362	.5792	.5365	.3932
5	.724	.6706	.6516	.4706	.6859	.6036	.5898
6	.9774	.8048	.905	.6878	1.0136	.7545	.7537
7	.9593	.6706	.9259	.6173	.9955	.9054	.8048
8	.6516	.6203	.6344	.4287	.6554	.6203	.6036
9	.3982	.3688	.3086	.362			.3688
10	.3982	.3353	.3688	.3258	.3277	.3605	.3688
11	.3944	.3018	.4527	.362	.3441	.3277	.3856
12	.3982	.3353	.3688	.3258	.3277	.3441	.4694
13	.3801	.3856	.3521	.3439	.3441	.3277	.503
14	.2915	.3353	.3353	.2915	.3353	.3932	.4024
15	.4163	.2683	.218	.3982	.3353	.3932	.3353
16	.4163	.1844	.4024	.3801	.3856	.3932	.3521
17	.5068	.362	.3856	.362	.3856	.3772	.4024
18	.543	.4163	.4694	.5611	.5197	.5316	.5197
19	.5068	.7602	.503	.6516	.6371	.6001	.6539
20	.543	.6516	.4191	.724	.4862	.5487	.57
21	.3772	.5792	.4527	.463	.6203	.5144	.57
22	.4706	.4458	.3856	.4344	.4694	.4458	.4694
23	.362	.4344	.3353	.3982	.4024	.3944	.3856
24	.4572	.3521	.3801	.3086	.362	.3856	.3521
Max	.9774	.8718	.9259	.724	1.0136	.9054	.8048
Min	.2915	.1844	.218	.2534	.3277	.3277	.3353
Avg	.5123	.5023	.4671	.4213	.5038	.4767	.4730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 247 / 11 KV Save AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0136	1.0288	1.0498	.2534	.2353	.2347	.2012
2	1.3394	1.5089	1.086	.2172	.2534	.2515	.2012
3	1.5023	1.7147	1.1946	.2353	.2534	.2683	.2683
4	1.6289	1.8442	1.3032	.2715	.3982	.3018	.2683
5	1.8519	2.0119	1.448	.3258	.3982	.3353	.3086
6	2.1719	2.1338	1.7147	.3439	.3982	.3521	.3353
7	2.2081	2.3472	2.19	.3772	.3801	.3688	.3521
8	2.3663	2.5149	2.146	.2601	.2458	.2515	.3353
9	2.0062	2.1795	2.0957	.2534	.213		.1844
10	.2353	.2058	.218	.2172	.1638	.213	.2012
11	.1886	.1802	.1341	1.2003	.852	1.1469	1.3748
12	.2401	.1677	.1341	2.2081	1.6385	2.2382	1.6766
13	.1886	.1696		2.3529	2.0645	2.13	2.0119
14	.1715	.1677		2.1357	2.0287	1.9662	2.1795
15	.1991	.1844	.1509	2.0814	1.8442	1.8842	1.9281
16	.1991	.1844	.2347	1.9547	1.861	2.13	1.8442
17	.2172	.1991	.2347	2.0271	1.9448	2.2291	.1799
18	.2896	.2353	.1509	1.5927	1.3413	2.0233	1.5592
19	.2715	.362	.3018	.2743	.3185	.3429	.285
20	.2715	.3801	.3856	.3077	.3353	.3601	.3353
21	.2572	.362	.285	.2896	.285	.3391	.3185
22	.2715	.362	.2515	.2896	.2515	.3086	.2683
23	.2715	.3258	.2347	.2534	.2683	.2743	.2515
24	.381	.8478	.8145	.2353	.2172	.2515	.2012
Max	2.3663	2.5149	2.19	2.3529	2.0645	2.2382	2.1795
Min	.1715	.1677	.1341	.2172	.1638	.213	.1799
Avg	.8226	.9007	.8072	.8316	.7579	.8783	.7112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 241 / 11 KV Waki Gheradi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 242 / 11 KV Alegaon Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1524		.1619	.4572	.4858	1.6194
2	.1619	.1524	.1619	.1619	.381	.4049	1.7814
3	.1619	.1524	.1619	.1619	.3048	.3239	1.9433
4	.1619	.1524	.1619	.1619	.5335	.4858	2.2672
5	.1619	.1524	.1619	.1619	.9145	.8097	2.3482
6	.1619	.1524	.1619	.1619	1.448	2.3482	2.753
7	.1619	.1524	.1619	.1619	2.5911	2.834	2.915
8	.1619	.1524	.1619	.1619	2.5149	2.915	2.9959
9	.1296	.1524	.1619	.1619	2.2862	2.834	2.915
10	.1296	.1524	.1619		.1134	.1067	.1067
11	1.448	.5668	.6097		.1134	.1067	.1067
12	2.7435	1.3765	1.448		.1134	.1067	.1067
13	2.5911	1.6194	2.4387		.1134	.1524	.1067
14	2.21	1.7814	2.6673		.1134	.1524	.1067
15	2.3624	1.9433	2.5911		.1134	.1524	.1067
16	2.5149	2.915	2.4387		.1134	.1524	.1067
17	2.8197	1.6194	2.3624			.1524	.1524
18	2.5911	1.7814	2.1338		.1134	.1524	.1524
19	.1619	.1619	.1619	.1134	.1134	.1524	.1524
20	.1619	.1524	.1619	.1134	.1134	.1524	.1524
21	.1619	.1524	.1619	.1134	.1134	.1524	.1524
22	.1619	.1524	.1619	.1134	.1134	.1524	.1524
23	.1619	.1524	.1619	.1134		.1524	.1524
24	.381	.1524	.1619	.1619	.381	.6478	1.5384
Max	2.8197	2.915	2.6673	.1619	2.5911	2.915	2.9959
Min	.1296	.1524	.1619	.1134	.1134	.1067	.1067
Avg	.9177	.6688	.8312	.1457	.5988	.6702	1.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 243 / 11 KV Medshingi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 244 / Alegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1886	.1886	.2105	.1781	.2058	.2401
2	.2105	.1715	.2743	.2429	.1781	.2229	.2743
3	.2267	.2058	.2401	.2753	.1619	.2401	.3086
4	.2753	.2743	.2058	.3077	.1781	.2915	.3772
5	.3563	.3429	.3086	.3239	.2267	.3772	.4115
6	.4049	.4458	.4115	.3887	.3887	.4287	.4458
7	.4858	.5144	.4458	.4534	.4534	.4973	.4801
8	.3725	.3429	.3772	.4049	.2753	.3601	.2915
9	.2429	.3086	.3429	.2267	.2429	.2401	.2743
10	.2753	.2229	.2572	.1619	.2267	.2058	.2401
11	.2267	.2058	.2058	.2105	.1943	.1886	.2229
12	.2105	.1886	.1715	.1781	.1619	.2229	.2058
13	.1943	.1886	.1715	.1781	.1457	.1886	.1715
14	.2105	.1715	.1715	.1619	.1457	.1715	.1543
15	.2267	.2058	.1715	.1457	.1619	.1886	
16	.2105	.2401	.1886	.1457	.1781	.1886	
17	.2267	.2743	.2058	.1781	.1943	.2058	.2058
18	.2591	.2915	.2572	.2267	.2591	.2229	.2572
19	.3725	.3086	.3429	.2591	.3077	.2743	.2743
20	.3887	.2743	.3258	.3239	.421	.3086	.3086
21	.3887	.2401	.2572		.3725	.2743	.3429
22	.3401	.2058	.2401	.3239	.2591	.2915	.2743
23	.2267	.2229	.2401	.2429		.2229	.2401
24	.381		.2058	.2105	.1943	.2229	.2058
Max	.4858	.5144	.4458	.4534	.4534	.4973	.4801
Min	.1943	.1715	.1715	.1457	.1457	.1715	.1543
Avg	.2878	.2624	.2586	.2513	.2394	.2601	.2821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 245 / Wanichanchale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.8097	1.448	1.4575		.1981	.3239
2	1.2193	.8097	1.5242	1.9433		.1829	.3239
3	1.3717	.8907	1.5242	1.9814		.1677	.3239
4	1.5242	1.0526	1.829	2.0576		.1524	.3239
5	1.5242	1.2955	2.1338	2.2862		.2286	.3239
6	1.829	2.1862	2.4387	2.4387		.3353	.3239
7	1.9814	2.4291	2.6673	2.5911		.3658	.3239
8	2.2862	2.5911	2.5911	2.6673		.3353	.3239
9	2.1338	2.4291	2.4387	2.2862		.2286	.3239
10	.2429	.1524	.3239	.2429		.2286	.3048
11	.1943	.1524	.3239	.1943		1.5242	1.7814
12	.1781		.2429	.2267	2.2672	2.5101	1.9433
13	.1943	.1524	.2429	.1943	2.4291	2.0243	
14	.2591	.1715	.2429	.1943	2.3482	1.9433	2.0243
15	.2267	.1524	.2429	.2105	2.2862	2.1052	2.2672
16	.3077	.1524	.2429		2.21	2.4291	2.5101
17	.3401	.1524	.2429		2.1338	2.5911	2.5911
18	.2591	.1524	.3239		1.9052	2.2672	2.5911
19	.4049	.2286	.3239		.3239	.3048	.3048
20	.3887	.2286	.3239		.4534	.3048	.3048
21	.3563	.2286	.3239		.421	.3048	.3048
22	.3401	.2286	.3239		.3239	.3048	.3048
23	.3239	.2286	.3239			.3048	.3048
24	.381	.7287	1.1431	1.1336		.2134	.3048
Max	2.2862	2.5911	2.6673	2.6673	2.4291	2.5911	2.5911
Min	.1781	.1524	.2429	.1943	.3239	.1524	.3048
Avg	.8119	.7654	.9911	1.3816	1.5547	.8981	.9025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 241 / 11 KV Watambare Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 242 / 11 KV Y.Mangewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 243 / 11 KV Balwadi Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 244 / 11 KV Ajnale Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 245 / Ligadewadi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 246 / Kamlapur feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 241 / 11 KV Gaigavan Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 242 / 11 KV Khilarwadi Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.5668
Max	.5668
Min	.5668
Avg	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 243 / 11 KV Dhalewadi Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	1.5546	1.5546	1.6766
9	1.4937		1.3717
10		.1372	.1372
11			.0857
16	.1029	.1029	.0857
24	.381		
Max	1.5546	1.5546	1.6766
Min	.1029	.1029	.0857
Avg	.8831	.5982	.6714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 244 / 11kv gaighavan gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.1524	.0838	.141
9	.1372	.0457	.1219
10	.1334	.0876	.0953
11	.1829	.1143	.0914
16	.0762	.0914	.0914
17			.0838
24	.3086		
Max	.3086	.1143	.141
Min	.0762	.0457	.0838
Avg	.1651	.0846	.1041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 241 / 11 KV Jujarpur Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 242 / 11 KV Junoni Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 243 / 11 KV H.Mangewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 244 / 11 KV JUNONI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3658
Max	.3658
Min	.3658
Avg	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 241 / Chopadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1886	.1715	.1715	.1543	.1715
2	.1715	.12	.1715	.1715	.2058	.1715	.1886
3	.2058	.1715	.2058	.2058	.2229	.1886	.2058
4	.2401	.2058	.2401	.2401	.2572	.2058	.2401
5	.3086	.3086	.2915	.2743	.3429	.2229	.2743
6	.4287	.3944	.4115	.3944	.4115	.2915	.3429
7	.4287	.4801	.4115	.463	.4115	.3086	.3601
8	.3429	.3944	.3601	.4115	.2915	.2401	.2743
9	.3086	.3258	.3086	.3258	.2572	.2229	.2401
10	.2743	.3258	.2915	.3086	.2915	.2572	.2572
11	.2915	.2753	.2743	.2743	.2572	.2401	.2229
12	.2743	.2429	.2572	.2058	.2401	.2229	.2229
13	.2572	.2267	.2229	.2058	.1715	.1886	.1715
14	.2401	.2267	.1886	.2058	.1886	.1715	.1886
15	.2743	.1781	.2058	.2401	.1886	.1886	.2229
16	.3086	.2401	.2229	.2229	.2229	.2229	.1715
17	.2915	.2401	.2229	.2572	.2743	.2401	.1886
18	.3086	.2915		.2915	.2743	.2915	.2401
19	.3772	.3944	.3944	.4287	.2743	.3429	.3086
20	.3601	.4287	.463	.4287	.3601	.3429	.3429
21	.3086	.3429	.3944	.3772	.2743	.2743	.2915
22	.2915	.2915	.2915	.2915	.2401	.2401	.2401
23	.2058	.2229	.2058	.2229	.1715	.1886	.1715
24	.1715	.1886	.2058	.1886	.1886	.1543	.1715
Max	.4287	.4801	.463	.463	.4115	.3429	.3601
Min	.1372	.12	.1715	.1715	.1715	.1543	.1715
Avg	.2836	.2780	.2796	.2836	.2579	.2322	.2379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 242 / balwadi feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	.9393	.9717	.9393	.3077	.3077	.3563
2	.9393	.9717	1.0364	1.0364	.3401	.3239	.3563
3	.9069	1.0364	1.1012	1.1336	.3887	.3725	.3887
4	1.0688	1.1498	1.1822	1.166	.4858	.4858	.4696
5	1.2308	1.2793	1.2631	1.2146	.5506	.4696	.4858
6	1.2955	1.5546	1.4413	1.3279	.6478	.5992	.6316
7	1.7328	2.17	1.9271	2.0729	.6802	.7125	.7125
8	2.0891	2.4291	2.0891	2.3644	.502	.502	.5182
9	1.4413	2.3805	2.1376	2.4615	.3563	.4534	
10	.3725	.3725	.3563	.3725	.3887	.3887	
11	.3239	.3077	.3077	.2915	1.2955	1.3279	
12	.3563	.3401	.2915	.2591	2.17	2.3482	
13	.3401	.3725	.3077	.2591	2.332	2.2672	
14	.3563	.3725	.3239	.3239	2.2996	2.1052	2.2834
15	.3887	.3239	.3401	.3725	2.2348	1.9595	2.3967
16	.421	.3401	.2915	.3563	2.251	2.1376	2.5587
17	.421	.3401	.3563	.3401	2.3158	1.7328	2.5587
18	.3725	.4534	.3401	.3887	2.1376	1.8138	2.4615
19	.5182	.583	.4858	.502	.4696	.5506	.4696
20	.5182	.583	.502	.5344	.4858	.5344	.5344
21	.5506	.4858	.502	.4696	.4372	.4858	.4858
22	.4534	.421	.4372	.4534	.4372	.4696	.4696
23	.3401	.3887	.3563	.4049	.3887	.4049	.4049
24	.381	.8745	.9231	.7935	.3239	.3077	.3725
Max	2.0891	2.4291	2.1376	2.4615	2.332	2.3482	2.5587
Min	.3239	.3077	.2915	.2591	.3077	.3077	.3563
Avg	.7359	.8529	.8030	.8266	1.0094	.9609	.9955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 243 / BANDGARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1457	.1457	.1457	.2915	.2915	.4049
2	.1457	.1134	.1457	.1619	.3401	.3239	.4049
3	.1781	.1619	.1619	.1781	.4049	.3401	.4372
4	.2105	.1943	.1943	.2267	.4534	.421	.502
5	.2267	.2591	.2915	.2753	.502	.4696	.5506
6	.2591	.3563	.3239	.3401	.583	.5344	.6964
7	.2915	.3401	.3077	.3401	.7773	.7287	.7935
8	.2105	.2429	.2267	.2591	.8421	.8421	.8421
9	.1457	.1619	.1296	.1781	.7935	.8583	.9555
10	.1457	.1296	.081	.1296	.1134	.1134	.1296
11	.4534	.5182	.4049	.5182		.1134	.0972
12	.8259	.5992	.7287	.7125	.0648	.1134	.081
13	.7773	.7449	.7449	.6964	.081	.0972	.081
14	.7125	.7611	.7773	.7125	.0972	.0972	.0972
15	.8421	.5992	.7611	.6964	.1296	.081	.1296
16	.8097	.7287	.9069	.7773	.1134	.0972	.1134
17	.7935	.8259	.9393	.4534		.1134	.0972
18	.7935	.7935	.7611	.6316	.1134	.1296	.1296
19	.1943	.2267	.1781	.1943	.2105	.2105	.2105
20	.1943	.2429	.2267	.2267	.1943	.2267	.2105
21	.1781	.1781	.1781	.1781	.1619	.1619	.1943
22	.1781	.1457	.1457	.1296	.1619	.1619	.1457
23	.1619	.1296	.1296	.1457	.1457	.1457	.1296
24	.381	.1457	.1296	.1296	.2915	.2753	.3887
Max	.8421	.8259	.9393	.7773	.8421	.8583	.9555
Min	.1296	.1134	.081	.1296	.0648	.081	.081
Avg	.3849	.3644	.3758	.3515	.3121	.2895	.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 244 / chopadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1781	.1457	.1619	.1781	.4696	.5992	.583
2	.2105	.1134	.1619	.1781	.5182	.583	.583
3	.2429	.1781	.1781	.1943	.5668	.6316	.6316
4	.2591	.2591	.2267	.2267	.6316	.6316	.664
5	.3401	.3401	.3077	.2915	.7287	.7611	.7449
6	.4534	.3563	.4372	.4372	.8421	.8745	.9555
7	.4372	.4049	.4372	.4534	1.0202	1.0202	1.2146
8	.2915	.3239	.3401	.3077	1.1984	1.2793	1.3603
9	.1619	.2105	.1943	.1886	1.2146	1.1498	1.3279
10	.1619	.1134	.1781	.1886	.1457	.1457	.1457
11	.8097	.8259	.5992	.7449	.1457	.1296	.1457
12	1.2631	1.0364	.9393	1.1984	.1296	.1134	.1619
13	1.2308	1.1498	1.0364	1.2631	.1134	.1296	.1296
14	1.2146	1.2955	1.1498	1.3441	.1134	.1134	.1296
15	1.2955	1.166	1.085	1.1984	.1134	.1296	.1457
16	1.3117	1.0202	1.1336	1.3117	.1457	.1457	.1619
17	.8421	1.1822	1.0364	.6154	.1619	.1457	.1457
18	.8745	1.0202	1.085	.9717	.1619	.2105	.1619
19	.2915	.3239	.2753	.3239	.3401	.3239	.3077
20	.2591	.3563	.3563	.3563	.3239	.3563	.3239
21	.2267	.2429	.2591	.2591	.2915	.2753	.2591
22	.2105	.2105	.2267	.2105	.2267	.2105	.2429
23	.1781	.1781	.1943	.1781	.1943	.1943	.1943
24	.381	.1619	.1781	.1943	.502	.583	.5506
Max	1.3117	1.2955	1.1498	1.3441	1.2146	1.2793	1.3603
Min	.1619	.1134	.1619	.1781	.1134	.1134	.1296
Avg	.5469	.5256	.5074	.5339	.4291	.4474	.4696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 241 / Wadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1067	.0914	.1067	.1029	.0914	.12
2	.1029	.1067	.0914	.1067	.1029	.0914	.12
3	.1029	.1067	.0914	.1067	.1372	.1219	.12
4	.1029	.1524	.1219	.1372	.1372	.1372	.1372
5	.1886	.2134	.1829	.1829	.2229	.1677	.2058
6	.3086	.2439	.2896	.2286	.2915	.2896	.2915
7	.3258	.2743	.2896	.2743	.2915	.2896	.3258
8	.2401	.1829	.1981	.2134	.2058	.2134	.2401
9	.1886	.1543	.1886	.1619	.1457	.1619	.1296
10	.1372	.1372	.1543	.0972	.1296	.0972	.1134
11	.1029	.1372	.1372	.0972	.1134	.0972	.1134
12	.1029	.1029	.12	.0972	.081	.1134	.081
13	.12	.1029	.12	.0972	.081	.1134	.081
14	.12	.12	.1029	.0972	.081	.1134	.081
15	.1134	.1372	.1029	.0972	.081	.1134	.0972
16	.1134	.1372	.12	.1134	.0914	.1134	.0972
17	.1134	.1296	.1219	.1134	.1067	.1372	.0972
18	.1296	.1619	.1219	.1457	.1372	.1372	.1372
19	.2105	.2267	.2439	.2429	.2134	.2401	.2286
20	.1981	.1943	.2134	.2572	.2439	.2572	.2134
21	.1677	.1619	.1677	.2058	.1677	.2058	.1829
22	.1372	.1296	.1219	.1543	.1372	.1543	.1524
23	.1067	.1219	.1067	.1029	.1219	.12	.1296
24	.1715	.1067	.1067	.1067	.1029	.0914	.12
Max	.3258	.2743	.2896	.2743	.2915	.2896	.3258
Min	.1029	.1029	.0914	.0972	.081	.0914	.081
Avg	.1545	.1520	.1503	.1477	.1470	.1529	.1506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
StationFeeder No / Name : 242 / RAJAPUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 243 / DIGHEMALA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.9335	.9069	.9602	.3429	.3201	.3429
2	1.0631	.9335	1.0002	1.0402	.3429	.3201	.3429
3	1.1145	.9335	1.0936	1.0669	.3429	.3201	.3429
4	1.0974	1.1336	1.1603	1.1336	.3772	.3658	.3772
5	1.2193	1.4403	1.2269	1.2003	.4801	.4115	.5144
6	1.4022	1.5604	1.5604	1.4403	.583	.4877	.583
7	2.3491	2.0671	2.0271	2.1338	.583	.5639	.583
8	2.2253	1.1603	2.0938	2.3339	.5658	.4572	.5658
9	2.2253	1.9814	2.2862	2.915	.4049	.3887	.4049
10	.2401	.2591	.2743	.3239	.3725	.3239	.1619
11	.2743	.2286	.3944	.3239	.6478	.6478	.6478
12	.3086	.4115	.3772	.3239	2.753	2.834	2.915
13	.3086	.3658	.3429	.3401	2.915	2.8664	2.834
14	.2915	.3658	.3772	.3401	2.5911	2.834	2.753
15	.2915	.3658	.3772	.3401	2.4777	2.834	2.6235
16	.3239	.4115	.4458	.3725	2.2672	2.8178	2.6235
17	.3563	.3887	.4115	.4049		2.2862	2.1605
18	.3887	.4049	.3963	.4534	1.387	2.1948	2.2005
19	.4534	.4858	.5182	.4858	.4725	.3772	.3601
20	.4268	.4858	.4572	.5144	.4268	.4801	.4001
21	.381	.4858	.3963	.4458	.3963	.4287	.381
22	.3048	.421	.3506	.3429	.3353	.3772	.3048
23	.3048	.3048	.3048	.3429	.3048	.3429	.3239
24	.381	.8269	.8135	.8002	.3429	.3048	.3429
Max	2.3491	2.0671	2.2862	2.915	2.915	2.8664	2.915
Min	.2401	.2286	.2743	.3239	.3048	.3048	.1619
Avg	.7831	.7648	.8164	.8491	.9440	1.0660	1.0454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 244 / BURLEWADI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1067	.1067	.1219	.3658	.3734	.3353
2	.1372	.1067	.1067	.1067	.3658	.3734	.3353
3	.1372	.1219	.1372	.1067	.4268	.4268	.3353
4	.1715	.1524	.1372	.1372	.4877	.4534	.3658
5	.2058	.1981	.1677	.1829	.5487	.5068	.4572
6	.2743	.2286	.2134	.2439	.6706	.6802	.7011
7	.2915	.2134	.2134	.2439	.945	1.0136	.9907
8	.2229	.1829	.1829	.1829	1.0669	1.1603	1.0059
9	.1372	.1543	.1372	.1619	1.1336	1.3765	1.085
10	.1715	.12	.1029	.1619	.1134	.1457	.1619
11	.3772	.3772	.3048	.4858	.0972	.1134	.1134
12	1.0364	1.1431	1.1584	.9231	.0972	.081	.1134
13	1.1126		1.2193	.9717	.081	.0648	.0972
14	1.1431	1.2193	1.1888	.9717	.0972		.0972
15	1.247	1.1431	1.1279	.9717	.081	.081	.081
16	1.1336	1.2517	1.1431	1.1336	.0762		.081
17	.8097	1.1822	1.0402	1.2308	.0914	.12	.0762
18	.583	1.1498	.9602	1.1012	.0914	.12	.0762
19	.1457	.1619	.2134	.2105	.1981	.1715	.1677
20	.1829	.3077	.1829	.2572	.1829	.1886	.2286
21	.2591	.2429	.1677	.2058	.1677	.1886	.1829
22	.1524	.2105	.1372	.1715	.1372	.1219	.1524
23	.1372	.1219	.1372	.1715	.1219	.1372	.1296
24	.6097	.1067	.1067	.1372	.2743	.3067	.3048
Max	1.247	1.2517	1.2193	1.2308	1.1336	1.3765	1.085
Min	.1372	.1067	.1029	.1067	.0762	.0648	.0762
Avg	.4507	.4436	.4414	.4414	.3300	.3729	.3198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 241 / Akola SSTn Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3601	.3601	.3429	.3258	.3429	.3429
2	.3086	.3429	.3429	.3086	.3258	.3086	.3086
3	.3429	.3086	.3258	.3086	.3258	.3086	.3086
4	.463	.463	.4801	.3944	.3429	.3944	.3944
5	.5658	.6001	.6001	.6001	.5316	.5144	.5658
6	.8573	.7888	.8059	.8573	.8745	.7202	.8573
7	.9088	.8059	.8916	.7373	.8402	.8573	.8402
8	.6859	.7202	.6687	.6516	.6344	.6001	.5316
9	.5316	.5316	.3944	.4801	.5144	.4287	.5144
10	.4458	.4458	.3944	.4458	.463	.4458	.4801
11	.3944	.4287	.3944	.3258	.4115	.3601	.4115
12	.3772	.3772	.4115	.3258	.2915	.3944	.3772
13	.3772	.3772	.4115	.2915	.3429	.3772	.2915
14	.3772	.3601	.4287	.3086	.3944	.3429	.2915
15		.3944	.2915	.3258	.3601	.3429	.3601
16		.3429	.3429	.3258	.3772	.3944	.3772
17	.5316	.4458	.4115	.3429	.3944	.3772	
18	.463	.5144	.4287	.3944	.4287	.4115	
19	.6173	.6516	.6173	.6344	.6173	.6516	
20	.6516	.6859	.583	.6173	.5144	.6173	
21	.5144	.5316	.5316	.4801	.5316	.5144	
22	.4115	.4287	.463	.4115	.4458	.4458	
23	.3944	.3944	.4115	.3601	.4115	.3944	
24	.4572	.3772	.3772	.3601	.3429	.3772	.3772
Max	.9088	.8059	.8916	.8573	.8745	.8573	.8573
Min	.3086	.3086	.2915	.2915	.2915	.3086	.2915
Avg	.5009	.4865	.4737	.4430	.4601	.4551	.4488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 246 / DATT MANDIR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.3086	.6516	1.0631	.583	.5487
2	.2401	.2915	.3086	.6859	1.1145	.6687	.6001
3	.2401	.3086	.3258	.7716	1.166	.7888	.6859
4	.3086	.3429	.3601	.8059	1.2517	1.2346	.8573
5	.3772	.4973	.4973	.9259	1.4575	1.1831	1.1145
6	.6001	.6001	.583	1.3717	1.749	1.8004	1.9204
7	.6516		.6001	1.2689	2.332	2.4177	2.2119
8	.4458		.3944	1.046	1.8347	2.3491	2.0062
9	.5144	.4287	.2743	1.4403	2.1948	2.6406	2.0748
10	.2058	.3086	.1886	.2401	.1886	.1886	.2229
11	1.3203	1.2174	1.046	.2743	.2058	.1715	.2401
12	2.4691	2.5892	2.2805	.2058	.2743	.1886	.2229
13	2.8121	2.572	2.4177	.1886	.2401	.1715	
14	2.5549	2.572	2.4691	.1715	.2229	.2058	.2058
15	2.7949	2.5549	2.0919	.1715	.2058		.2058
16	2.7778	1.6632	2.5549	.1715	.2229		.2058
17	1.8861	2.3834	2.6578	.2058	.2572	.2401	.1886
18	2.1776	2.4006	2.2119	.2572	.2743	.2743	.2572
19	.4287	.3772	.3601	.4287	.4115	.4287	.4115
20	.4801	.4801	.4458	.4458	.463	.4115	.4458
21	.3772	.3944	.3772	.4115	.4115	.3601	.4287
22	.3429	.3601	.3429	.3601	.3772	.3258	.3429
23	.3086	.3429	.3086	.3258	.3429	.2915	.3086
24	.381	.2915	.2915	.6344	.8573	.4973	.4973
Max	2.8121	2.5892	2.6578	1.4403	2.332	2.6406	2.2119
Min	.2058	.2743	.1886	.1715	.1886	.1715	.1886
Avg	1.0390	1.0569	.9874	.5609	.7966	.7919	.7045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 247 / SOMNATH MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6516	.7202	.12	.1543	.12	.1372
2	.4801	.7202	.7888	.12	.1372	.12	.12
3	.4287	.7716	.823	.12	.12	.12	.1372
4	.463	.8916	.8573	.12	.12	.1372	.1543
5	.4801	1.0288	.9259	.1715	.1372	.1715	.1886
6	.5658	1.2517	1.1317	.2572	.2058	.2229	.2229
7	.8059	1.6118	1.5775	.2743	.2401	.2401	.2572
8	1.0974	2.0062	1.9204	.2401	.2572	.2058	.1715
9	1.2517	1.6118	1.4918	.1715	.1715	.1543	.1715
10	.1372	.12	.1715	.1715	.1543	.1372	.1543
11	.12	.1029	.12	.8573	.9088	.8745	.6687
12	.1029	.0857	.1029	1.7318	1.7147	1.6461	1.5432
13	.1029	.1029	.12	1.6632	1.5432	1.3546	1.3889
14	.1029	.12	.1372	1.5432	1.5604	1.2517	1.3203
15	.1715	.12	.12	1.4918	1.3889	1.3717	1.286
16	.1715	.1543	.12	1.5432	1.5089	1.4575	1.3717
17	.1886	.1543	.12	1.7147	1.5261	1.5432	1.6289
18	.1886	.1543	.1543	1.5775	1.2174	1.4918	1.6118
19	.2572	.2572	.2229	.2229	.2058	.2058	.1886
20	.2915	.2401	.2229	.2572	.2229	.2058	
21	.2572	.2058	.2058	.2229	.2058	.1886	.2229
22	.2401	.1715	.1715	.2058	.1886	.1715	.2058
23	.2058	.1543	.1372	.1886	.1715	.1543	.1715
24	.381	.6001	.6001	.12	.1715	.1372	.1372
Max	1.2517	2.0062	1.9204	1.7318	1.7147	1.6461	1.6289
Min	.1029	.0857	.1029	.12	.12	.12	.12
Avg	.3753	.5537	.5401	.6294	.5930	.5701	.5852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 248 / AKOLA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.7202	.7545	.2401	.1715	.1372	.2229
2	.9088	.7716	.7888	.2058	.1715	.1372	.2229
3	.823	.823	.823	.1715	.1715	.1543	.2401
4	.823	.8573	.8573	.2401	.1886	.2401	.2572
5	.8573	.8916	.9259	.3086	.2401	.2915	.2743
6	.9088	1.1317	1.0974	.3944	.3772	.3601	.3429
7	1.406	1.6461	1.6461	.4115	.4115	.3944	.3601
8	1.5775	1.6118	1.5947	.3429	.2915	.3429	.3429
9	1.0802	1.3375	1.2517	.3086	.2229	.2401	.2401
10	.1886	.1543	.1715	.3086	.2401	.1715	.2058
11	.2401	.2229	.1715	.8916	.7716	.8059	.7545
12	.2058	.1886	.1543	1.4403	1.406	1.2689	1.2517
13	.1543	.2058	.1543	1.3375	1.3717	1.3717	1.0631
14	.2229	.1543	.1715	1.3375	1.3203	1.2689	1.1145
15	.2229	.1543	.12	1.3032	1.3375	1.0802	1.3032
16	.2743	.1715	.2058	1.4232	1.3889	1.2003	1.406
17		.2572	.1886	1.2517	1.4746	1.3717	1.2517
18	.2229	.2915	.2229	1.3889	.9945	1.3375	1.2689
19	.2743	.3429	.2401	.3086	.2401	.2401	.2229
20	.3086	.3086	.4115	.3601	.2229	.2743	.2915
21	.2743	.2743	.3429	.3086	.2743	.2572	.2915
22	.2401	.2572	.3086	.2572	.2229	.2401	.2572
23	.1886	.2401	.2915	.3086	.2058	.2401	.2401
24	.381	.703	.7202	.2915	.1886	.1715	.2229
Max	1.5775	1.6461	1.6461	1.4403	1.4746	1.3717	1.406
Min	.1543	.1543	.12	.1715	.1715	.1372	.2058
Avg	.5556	.5716	.5673	.6309	.5794	.5666	.5687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 201 / 11 KV KATAFAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7695	1.5565	1.9959	.213	.213	.2402	.1966
2	1.9662	1.6385	1.9662	.213	.2294	.2294	.1966
3	2.1792	1.7204	2.1628	.213	.2622	.2294	.2949
4	2.4905	1.7695	2.3758	.2294	.2949	.2458	.3113
5	2.6216		2.6216	.2622	.2949	.2458	.3605
6	3.0312	2.2939	2.8673	.2949	.3768	.2949	.3605
7	3.195	3.4408	3.0639	.3277	.3768	.3441	.2785
8	3.1459		2.9984	.3113	.2622	.2949	.2785
9	2.7035		2.7526	.213	.213	.2458	.213
10	.1802		.1802	.3932	.1802	.1966	.1638
11			.1475	2.2119		2.1956	1.9826
12		.2294	.1475	3.4244	3.3916	3.2606	
13		.1966	.1475	3.5391	3.4736	3.3753	
14	.1802	.2294	.1638	3.4899	3.1623	2.9329	
15	.2294	.213	.1802	3.3589	2.9984	2.7854	
16	.2785	.1966	.1638		3.2606	2.6707	
17	.2622	.2458		3.2442	2.6871	2.6543	3.4408
18	.2622	.213		3.0312	2.7526	2.2283	3.2933
19	.2949	.3113	.3113	.2949	.3113	.2785	.3277
20	.2949	.3441	.2949	.3113			.3441
21	.2785	.2949	.2785		.3113		.2949
22	.2458	.2622	.2294		.2622		.2622
23	.2294	.213	.213		.2458		.2294
24	.381	1.5074	1.4746	.213	.213	.213	.213
Max	3.195	3.4408	3.0639	3.5391	3.4736	3.3753	3.4408
Min	.1802	.1966	.1475	.213	.1802	.1966	.1638
Avg	1.2486	.8882	1.2153	1.2895	1.1715	1.2581	.6864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 202 / 11 KV ITAKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0486	.0486	.3113	.421		.4424
2	.0324	.0486	.0486	.2949	.421	.4096	.3932
3	.0324	.0486	.0486	.3277	.4534	.4588	.4588
4	.0486	.0486	.0486	.4096	.4534	.4915	.5243
5	.0648	.0648	.0648	.4588	.502	.6554	.4915
6	.081	.081	.0972	.5407	.5668	.7373	.6062
7	.0972	.0972	.1134	.8029		.852	.852
8	.0972		.0972	.8356	.8583	1.0486	.9175
9			.0819	.7773	.7773	.9339	.8192
10	.081		.0328	.0486	.0492	.0328	.0492
11			.3605	.0486		.0328	.0328
12		.8745	.639	.0324	.0328	.0492	
13		.8583	.8029	.0324	.0328	.0328	
14	.6802	.9231	.8684	.0324	.0328	.0328	
15	1.0364	.9393	.7373	.0324	.0328	.0328	
16	1.0202	.8421	.8684	.0324	.0328	.0328	
17	.8583	.8421		.0324	.0492	.0328	.0819
18	.6478	.5992		.0486	.0492	.0328	.0655
19	.081	.081	.0983	.081	.0983	.0983	.0983
20	.0648	.081	.0819	.081			.0819
21	.0648	.0648	.0655		.0655		.0655
22	.0648	.0486	.0492		.0492		.0655
23	.0648	.0324	.0492		.0492		.0492
24	.381		.0324	.3113	.3239	.3441	.3768
Max	1.0364	.9393	.8684	.8356	.8583	1.0486	.9175
Min	.0324	.0324	.0324	.0324	.0328	.0328	.0328
Avg	.2766	.3486	.2425	.2653	.2548	.3337	.3406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 203 / KATAFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1663	.1663	.1478	.1294	.1478	
2	.1294	.1478	.1478	.1294	.1294	.1478	.1478
3	.1294	.1294	.1294	.1294	.1478	.1663	.2772
4	.1294	.1663	.1294	.1478	.1478	.2218	.2772
5	.1663	.2218	.1663	.2033	.1478	.2957	.2458
6	.2772	.2772	.2587	.2772	.2772	.3142	.2957
7	.3881	.3142	.2957	.3164	.3142	.3511	.3511
8	.2772		.2587	.2587	.3326	.2957	.2957
9			.1848	.2218	.2033	.2033	.2402
10	.1848		.1663	.1478	.0924	.1294	.1663
11	.1848		.0739	.0924		.1109	.1109
12		.2033	.0924	.0924	.1294	.1294	
13		.1663	.0924	.0924	.1294	.1478	
14	.2033	.1294	.1294	.0924	.1109	.1109	
15	.2402	.1294	.1294	.1294	.1478	.1478	
16	.2402	.1478	.0924	.1478		.1478	
17	.2587	.1663		.1109	.1663	.1663	.2033
18	.2402	.1848		.2033	.2218	.1663	.2218
19	.2772	.2772	.2402	.2218	.3696	.3326	.3142
20	.2587	.2772	.2772	.2772			.2402
21	.2402	.2402	.2402		.2587		.2033
22	.2033	.1848	.1663		.2218		.1663
23	.1848	.1663	.1478		.1848		.1478
24	.381		.1663	.1478	.1294	.1478	.1478
Max	.3881	.3142	.2957	.3164	.3696	.3511	.3511
Min	.1294	.1294	.0739	.0924	.0924	.1109	.1109
Avg	.2258	.1945	.1705	.1708	.1901	.1940	.2251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 244 / MANEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.1029	.0857	.1372
2	.12	.0686	.12	.0857	.1067	.1029	.1543
3	.1372	.1029	.12	.1029	.12	.12	.1543
4	.1886	.12	.1372	.12	.1543	.1543	.1715
5	.2229	.1715	.1715	.1543	.2229	.1886	.1886
6	.2572	.2229	.2058	.2058	.2743	.2229	.2229
7	.2401	.2572	.2572	.2572	.2401		.2058
8	.2058	.1715	.12	.1715	.1715	.2058	.1372
9	.1543	.1543	.1372	.12	.1372	.1372	.1372
10	.12	.1372	.0914	.0857	.12	.1029	.1029
11	.0857	.12	.12	.1029	.0857	.0857	.0686
12	.0686	.0857	.0857	.0857	.1029	.0857	.0857
13	.0686	.0686	.0686	.1029	.0686	.0686	.0686
14	.12	.1029	.0686	.0857	.0857	.0514	.0514
15	.1029	.0857	.12	.0686	.1029	.0514	.0857
16	.1372	.1029	.1543	.0686	.1029	.1029	.0686
17	.1543	.12	.1715	.0857	.1372	.0857	.1029
18	.1715	.1543	.2058	.1543	.1715	.1886	.1372
19	.1543	.1543	.2229	.1886	.1543	.2743	.2058
20	.1543	.1715	.1715	.2229	.1372	.2572	.2229
21	.1372	.1372	.1543	.1715	.1029	.2401	.1715
22	.12	.12	.12	.1543	.1029	.2058	.1543
23	.12	.1029	.1029	.1372	.12	.1372	.12
24	.381	.1029	.1029	.1029	.12	.1029	.12
Max	.381	.2572	.2572	.2572	.2743	.2743	.2229
Min	.0686	.0686	.0686	.0686	.0686	.0514	.0514
Avg	.1545	.1300	.1381	.1300	.1352	.1416	.1365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 249 / NIJAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5992	.8259	.5506	.2753	.2753	.2591	.2915
2	.7287	1.0202	.5506	.3239	.2591	.2429	.2915
3	.7773	1.2308	.5992	.3401	.2915	.2753	.2915
4	.8259	1.4413	.6802	.3401	.3239	.3077	.3077
5	.8583	1.5384	.7773	.3887	.4049	.3077	.3239
6	.9717	1.7004	.8097	.3239		.3401	.3239
7	1.7652	1.8299	1.0688	.2591	.3077	.3239	.3563
8	1.7328	1.7328	1.8623	.2267	.1619	.2753	.3401
9	1.6518	1.7004	1.6842	.1943	.1134	.2429	.2915
10	.4696	.3239	.421	.1715	.1457	.2105	.1619
11	.421	.1457	.3887	.6802	.4049	.3077	.2429
12	.3239	.1619	.3401	1.6032	.6154	1.5384	1.3441
13	.3239	.1943	.2753	1.4737	1.0526	1.5061	1.4089
14	.2915	.1781	.2105	1.2308	1.1822	1.4575	1.2793
15	.2753	.2105	.2429	1.3441	1.3117	1.4089	1.1336
16	.2429	.2267	.2591	1.4413	1.5061	1.5061	1.247
17	.2267	.2591	.2915	1.5061	1.3765	1.5384	1.2308
18	.2591	.2429	.3401	1.247	1.2793	1.3927	1.3441
19	.2753	.2267	.3725	.3401	.4049	.3401	.3239
20	.2753	.2105	.3563	.3887	.3725	.3077	.3401
21	.3077	.2429	.3239	.3239	.3077	.2915	.3239
22	.3401	.2105	.2753	.3077	.2591	.2591	.3077
23	.3725	.2591	.2591	.2753	.2267	.2753	.2591
24	.381	.5668	.4534	.2429	.2591	.2429	.2753
Max	1.7652	1.8299	1.8623	1.6032	1.5061	1.5384	1.4089
Min	.2267	.1457	.2105	.1715	.1134	.2105	.1619
Avg	.6124	.6950	.5580	.6354	.5584	.6316	.5850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 251 / DONGARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3353	.2743	.9145	.4877	.6554	.6859
2	.3048	.381	.3048	1.1431	.5944	.8383	.7316
3	.3201	.381	.2896	1.2651	.6249	.945	.8688
4	.3963	.381	.3201	1.387	.7164	1.0669	.9907
5	.381	.3963	.3506		.8383	1.2498	1.1584
6	.4115	.3658	.4268	1.6461	1.2955	1.326	1.3413
7	.3506	.3201	.3658	1.6156	1.4632	1.3717	1.387
8	.2439	.2743	.2591	1.5089	1.3565	1.448	1.4784
9	.1981		.2286	1.4022	1.2651	1.5242	1.5394
10	.6859		.2591	.1219	.2896	.1829	.1677
11	.9907	1.2193	.503	.1372	.2286	.1677	.1219
12	1.4175	1.3108	.7621	.1372	.1829	.1372	.1296
13	1.4784	1.3717	.9907	.1219	.1372	.1219	.1219
14	1.6004	1.4632	1.4022	.1372	.1372	.1524	.1372
15	1.6613	1.448	1.4784	.1372	.1524		.1219
16	1.5699	1.4022	1.5851	.1219	.1829	.1677	.1524
17	1.4937	1.326	1.5089	.1372	.2134	.1829	.1829
18	.4115	.2439	1.448	.2286	.2286	.2286	.2134
19	.3963	.2286	.381	.3506	.2286	.3506	.2896
20	.3658	.2439	.3506	.381	.2439	.3201	.3506
21	.3658	.2743	.3201	.3353	.2743	.3048	.3201
22	.3506	.2591	.2896	.3048	.3048	.2896	.2896
23	.3048	.2896	.2591	.2439	.2896	.2743	.2743
24	.381	.3048	.2591	.5944	.381	.5335	.5639
Max	1.6613	1.4632	1.5851	1.6461	1.4632	1.5242	1.5394
Min	.1981	.2286	.2286	.1219	.1372	.1219	.1219
Avg	.6814	.6464	.6090	.6249	.5049	.6017	.5674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 241 / SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5487	.583	.5487	.4973	.5144	.5316
2	.5316		.583	.5487	.5144	.5144	.5316
3	.5487		.583	.583	.5316	.5144	.5487
4	.583		.6001	.6173	.5487	.5487	.583
5	.6173		.6173	.6516	.6001	.583	.6687
6	.6001		.6344	.6859	.6687	.6344	.703
7	.583		.583	.5144			.6173
8	.5487			.4115			
9	.3601			.3429			.3601
10	.3429		.2915	.3601	.3429	.3086	.3601
11	1.286		1.2346	1.2003	1.4575	.8745	.3429
12		1.8861	2.452	2.0576	2.0576	2.2634	2.2119
13		2.0748	2.452	2.2291	2.1948	2.3663	2.1605
14	1.8004	2.5892	2.5377	2.2634	2.1262	2.1262	2.1776
15	2.2634	2.4348	2.0748	2.3148	2.1434	2.0919	2.2119
16	2.4006	2.572	2.1948	2.3148	2.3148	1.9204	2.2634
17	2.572	1.8519	1.6632	2.3148	2.2634	2.0748	2.2634
18	2.1091	2.2462	2.1948	2.1262	2.0233	2.1605	1.3032
19	.4801	.5487	.5316	.5144	.4801	.4973	.4801
20	.5658	.5658	.5144	.4801	.5316	.583	.5316
21	.5316	.5658	.5316	.463	.4973	.5658	.5144
22	.5487	.5658	.5487	.5316	.4973	.583	.4801
23	.5658	.5658	.5316	.5316	.5144	.5658	.4458
24	.381	.5487	.5658	.5316	.4801	.5316	.5487
Max	2.572	2.5892	2.5377	2.3148	2.3148	2.3663	2.2634
Min	.3429	.5487	.2915	.3429	.3429	.3086	.3429
Avg	.9433	1.3975	1.1138	1.0474	1.1088	1.0868	.9930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 242 / WAKI SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.2346	1.166	1.2346
2					1.286	1.2955	1.286
3					1.3032	1.3603	1.286
4					1.3032	1.4413	1.406
5					1.6289	1.5708	1.4918
6					2.0919	1.8947	1.7318
7					2.7778	2.4291	2.4348
8	2.5892		2.1434	2.3491	2.6063	2.5587	2.1948
9					2.17	2.3148	2.2119
10					.1457	.2058	.1372
11					.1457	.2401	.12
12					.1296	.1372	.12
13					.1134	.1372	.12
14					.1134	.1543	.12
15					.1134	.1543	.1372
16	.2058	.1372	.1543	.2058	.1619	.1543	.1372
17					.1619		.1715
18						.2058	.2401
19					.2915	.3429	.3258
20					.2915	.3601	.3086
21					.2267	.3601	.2915
22					.2429	.2572	.2572
23	.2401	.2229	.2401	.2572	.2572	.2572	.2401
24	.381	1.0631	1.2003	1.166	1.0631	1.1174	1.1831
Max	2.5892	1.0631	2.1434	2.3491	2.7778	2.5587	2.4348
Min	.2058	.1372	.1543	.2058	.1134	.1372	.12
Avg	.8540	.4744	.9345	.9945	.8635	.8746	.7995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 243 / GALVEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.6687	.5144	.7716	.7716	.6802	.7202
2	.7373	.7716	.5487	.7716	.823	.6964	.7202
3	.8059	.7716	.8059	.8916	.8573	.7449	.7716
4	.9088	.8402	.8745	1.1488	.8916	.8097	.8916
5	1.0802	1.0288	.8916	1.3032	1.1317	.9555	1.0802
6	1.2689	1.3032	1.3546		1.3032	1.3927	1.2346
7	1.4575	1.6461	1.3375	1.749	1.5775	1.5223	1.4575
8	1.5261		1.2689	1.749	1.5775	1.5384	1.6632
9	1.406		1.5261	1.6118	1.5261	1.5089	1.5261
10	.12		.0857	.1372	.1029	.1029	.0686
11	.1029		.0857	.1029	.0857	.12	.0857
12		.1029	.0857	.0857	.0857	.0857	.1029
13		.1029		.0857	.0686		.0857
14	.0857	.0857		.0857	.0857		.0857
15	.1029	.0857		.0857	.12		.1029
16	.1543	.1372	.0686	.1029	.0857	.0857	.1029
17	.1715	.0857	.0857	.1029	.0857	.1029	.12
18	.12	.12	.1029		.1029	.1029	.12
19	.1715	.1886	.1029	.2229	.2058	.1886	.1715
20	.2058	.1715	.1715	.1886	.1886	.2058	.2058
21	.1715	.1543	.2401	.1715	.1029	.2058	.1715
22	.1543	.1372	.1886	.1372	.1029	.2058	.12
23	.12	.12	.1715	.1372	.1029	.2058	.12
24	.381	.4973	.4801	.6859	.5487	.6316	.583
Max	1.5261	1.6461	1.5261	1.749	1.5775	1.5384	1.6632
Min	.0857	.0857	.0686	.0857	.0686	.0857	.0686
Avg	.5419	.4510	.5234	.5604	.5223	.5758	.5130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274190 / 33/11 kV Diksal

Feeder No / Name : 201 / 11 kV Diksal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274190 / 33/11 kV Diksal

Feeder No / Name : 202 / 11 kV Pare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274190 / 33/11 kV Diksal

Feeder No / Name : 203 / 11 kV Narale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274216 / Sangola Urban

Feeder No / Name : 211 / Bilewadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101] BU 6343

Substation No/ Name :- 274216 / Sangola Urban

Feeder No / Name : 212 / 11 KV Sangola Pandharpur
Road Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 201 / WATAMBARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1029	.1372	.1372	.1372	.1029
2	.1715	.1543	.0857	.1372	.12	.1372	.12
3	.1715	.1372	.0857	.1715	.1372	.1543	.1029
4	.1886	.1543	.1029	.1715	.1372	.1715	.12
5	.2058	.1715	.12	.1886	.1543	.1886	.1372
6	.2401	.1886	.1372	.2058	.1715	.2058	.1543
7	.2229	.2058	.1543	.2401	.1886	.2401	.2058
8	.1886	.2058	.12	.2229	.2058	.1372	.1715
9	.1543	.1372	.1543	.2058	.12	.1372	.1372
10	.1715	.12	.1543	.1886	.1029	.12	.1715
11	.12	.1372	.1543	.1372	.12	.1372	.1029
12	.12	.1543	.1372	.1372	.1029	.1029	.12
13	.12	.12	.1543	.12	.1029	.1372	.1372
14	.1029	.1372	.1543	.1372	.1372	.12	.1372
15	.1029	.12	.1543	.1372	.1543	.12	.1372
16	.1372	.1372	.1372	.1372	.1543	.1372	.1372
17	.12	.12	.1372	.1715	.1543	.1372	.1372
18	.12	.12	.1543	.2229	.1543	.1372	.2229
19	.1886	.1886	.1543	.2058	.2058	.2401	.2058
20	.1886	.1715	.2401	.1886	.2058	.2229	.1886
21	.1715	.2058	.2229	.1715	.1886	.1886	.1715
22	.1886	.12	.2058	.1543	.1715	.1715	.1715
23	.1715	.0857	.1372	.1543	.1543	.12	.1543
24	.1715	.1715	.1029	.1029	.1372	.12	.1029
Max	.2401	.2058	.2401	.2401	.2058	.2401	.2229
Min	.1029	.0857	.0857	.1029	.1029	.1029	.1029
Avg	.1615	.1508	.1443	.1686	.1508	.1550	.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 202 / 11 KV WATAMBARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1886	.7545	.9431	1.046
2	.1715	.1715	.1543	.1886	.8573	.9774	1.166
3	.2058	.1372	.12	.2058	1.166	1.0288	1.2517
4	.2401	.1543	.12	.2058	1.3375	1.1145	1.3375
5	.2743	.1715	.1543	.2401	1.4746	1.286	1.4403
6	.3086	.1715	.2229	.2915	1.5089	1.5432	1.5089
7	.3086	.1886	.2401	.3772	1.5432	1.7147	1.5775
8	.2572	.2058	.2743	.2743	1.5775	1.6118	1.6461
9	.2229	.2229	.2058	.1886	1.6118	1.5947	1.5432
10	.1543	.12	.1715	.1886	.1715	.12	.1886
11	1.3717	.823	.8573	1.1317		.1372	.1715
12	1.3717	1.6804	1.5089	1.5089		.1372	.1543
13	1.406	1.6461	1.3717	1.5432	.1029	.1715	.1543
14	1.3717	1.5432	1.3375	1.5432	.1372	.1715	.1715
15	1.1317	1.5775	1.2689	1.5432	.2229	.1543	.1715
16	1.749	1.5432	1.3717	1.5775	.1715	.1543	.2058
17	1.6975	1.5432	1.286	1.5089	.1372	.1715	.2743
18	1.7147	1.5089	1.0631	.2401	.2058	.1715	.2572
19	.2743	.2229	.2743	.2229	.2572	.1715	.2401
20	.2401	.2058	.2915	.2058	.2401	.2743	.2229
21	.2058	.2401	.2572	.1886	.2401	.2743	.2058
22	.2058	.2229	.2401	.1886	.2058	.2229	.2058
23	.1886	.1886	.2058	.1886	.1886	.2229	.2058
24	.381	.1886	.1715	.1715	.7202	.8573	.9602
Max	1.749	1.6804	1.5089	1.5775	1.6118	1.7147	1.6461
Min	.1543	.12	.12	.1715	.1029	.12	.1543
Avg	.6510	.6187	.5558	.5880	.6742	.6344	.6795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 203 / 11 KV ANAKDHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8916	1.0288	.6859	.12	.1372	.1029
2	.8573	1.0288	1.0974	.8573	.1029	.1372	.12
3	.9431	1.1317	1.1831	.9431	.1029	.1543	.12
4	1.0288	1.2003	1.2517	1.0288	.12	.1715	.1372
5	1.2003	1.2689	1.286	1.1145	.1372		.1543
6	1.2689	1.3375	1.5261	1.166	.1715	.2058	.1543
7	1.286	1.3717	1.5089	1.2346	.2058	.2401	.12
8	1.3717	1.4918	1.4746	1.166	.2401	.12	.1715
9	1.5089	1.6461	1.5432	1.0631	.1543	.12	.1372
10	.1029	.0857	.0857	.1372	.1372	.1543	.12
11	.12	.0686	.0857	.0686	.6859	.5144	.7716
12	.12	.0857	.0686	.0857	1.5432	1.2346	1.3032
13	.1029	.0686	.0686	.0686	1.5089	1.2689	1.2003
14	.1029	.0857	.0686	.0686	1.3717	1.3032	1.0631
15	.1029	.0514		.0857	1.1317	1.3375	1.2346
16	.1029	.0686	.0857	.0857	1.2003	1.3889	1.3032
17	.1029	.0686	.0686	.0857	1.3717	1.3717	1.2689
18	.12	.0857	.0857	.12	1.406	1.3717	.1543
19	.1886	.12	.1715	.1543	.1543	.3086	.1543
20	.1886	.1543	.1715	.1543	.1372	.2229	.1372
21	.1715	.1372	.1543	.1372	.12	.1372	.12
22	.1543	.12	.1543	.1372	.12	.12	.12
23	.1372	.12	.1715	.1372	.1543	.1029	.7545
24	.381	.7716	.7716	.5487	.12	.1029	.1029
Max	1.5089	1.6461	1.5432	1.2346	1.5432	1.3889	1.3032
Min	.1029	.0514	.0686	.0686	.1029	.1029	.1029
Avg	.5146	.5608	.6136	.4723	.5215	.5316	.4594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 271 / 11 KV SANGOLA U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.3429	.2572	.3429	.2572
2	.2572	.2572	.3429	.2572	.3429	.3429
3	.2572	.2572	.2572	.2572	.3429	.3429
4		.2572	.3429	.3429	.4287	.3429
5	.3429	.3429	.3429	.3429	.4287	.3429
6	.5144	.3429	.4287	.5144	.5144	.5144
7	.5144	.5144	.5144	.5144	.5144	.5144
8	.5144	.5144	.4287	.4801	.5144	.4287
9	.3429	.4287	.5144	.3429	.3429	.3429
10	.4287	.3429	.3429	.3429	.3429	.3429
11	.3429	.3429	.3429	.3429	.3429	.3429
12	.3429	.3429	.3429	.3429	.3429	.2572
13	.3429	.3429	.3429	.3429	.3429	.2572
14	.3429	.3429	.2572	.3429	.3429	.2572
15	.3429	.3429	.3429	.3429	.3429	.2572
16	.3429	.3429	.3429	.4287	.3429	
17	.3429	.3429	.3429	.3429	.3429	
18	.2915	.3772	.2572	.4287	.4287	
19	.4287	.4287	.5144	.5144	.4287	.6001
20	.4287	.5144	.5144	.5144	.5144	.5144
21	.4287	.4287	.5144	.4287	.4287	.5144
22	.3429	.3429	.4287	.4287	.4287	.4287
23	.3429	.3429	.3429	.3429	.3429	.4287
24	.3429	.3429	.4287	.3429	.3944	.3429
Max	.5144	.5144	.5144	.5144	.5144	.6001
Min	.2572	.2572	.2572	.2572	.3429	.2572
Avg	.3705	.3622	.3822	.3808	.3951	.3797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 272 / 11 KV Gherdi Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.0288	1.2003	.2572	.3429	.3429	.3429
2	1.8004	1.2003	1.286	.2572	.3429	.3429	.3429
3	1.6289	1.2003	1.3717	.2572	.3429	.3429	.3429
4	1.6289	1.5432	1.5432	.3429	.3429	.3429	.3429
5	1.7147	1.6289	1.9719	.3429	.3429	.3429	.3429
6	1.7147	1.7147	2.2291				
7		1.9719					
8		2.0576	2.0576				
9	.4287	.4287	.2743	1.9719	1.5432		1.8004
10	.4287	.2572	.3429	2.1434	1.8004		1.8004
11		.1715	.3429	2.3148	1.8004	.0857	2.0576
12	.5144		.2572	1.4575	1.7147		
13	.5144		.2572	1.0288	1.2003		
14	.5144		.3429	1.4575	1.9719	1.9719	1.4575
15			.3429	1.286		.6859	1.8861
16	1.3717		.3258	1.7147	.2572		2.0576
17	.3429	.0857	.2572		.3429	1.9719	1.0288
18	.3258	.1715			.3429	1.8861	.2572
19		.5144		.3429	.4287	1.5432	.3429
20	.3429	.5144		.3429	.4287	.3429	.3429
21	.3429	.3429		.4287	.5144	.4287	.4287
22	.3429	.3429		.4287	.4287	.3429	.4287
23	.3429	.3429		.3429	.3429	.3429	.4287
24	1.8004	.3429	.2572	.2572	.2743	.3429	.2915
Max	1.8004	2.0576	2.2291	2.3148	1.9719	1.9719	2.0576
Min	.3258	.0857	.2572	.2572	.2572	.0857	.2572
Avg	.9422	.8348	.8624	.8934	.7553	.7287	.8591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 273 / 11 KV Wadegaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4049
Max	.4049
Min	.4049
Avg	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 274 / 11 KV Chincholi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	.2572
2	.2572
3	.2572
4	.2572
5	.2572
7	1.0288
8	1.3717
9	1.3717
10	1.0288
11	1.1145
12	.8573
24	.2572
Max	1.3717
Min	.2572
Avg	.693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 275 / 11 KV Gaothan Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 276 / 11 KV Mahud Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3429	.2572	.4287	.2572	.2572
2	.2572	.3429	.2572	.4287	.2572	.2572
3	.3429	.4287	.4287	.4287	.2572	.2572
4	.3429	.4287	.5144	.3429	.2572	.4287
5	.3429	.4287			.2572	.5144
6				.2572		
7				.3429		
9	.4287	1.8004	.5144	.4287	.5144	.4287
10	.4287	2.4006	.4287	.4287	.4287	.4287
11	.4287	2.8292	.4287	.4287	.4287	.3429
12		2.1434		.3429	.3429	.4287
13		2.6578			.3429	.3429
14	2.7435	2.572		.2572	.3429	.3429
15	2.915	2.4006		.3429	.3429	.3429
16	.3429	2.572		.5658	.3429	.3429
17	2.2291	.4287	2.572	2.4006	.4287	
18	2.2291	.4287	2.4863	2.572	.5144	.5144
19	.4287	.4287	2.2291	2.4863	.6001	2.2291
20	.4287	.3429	2.0576	2.3148	2.1434	2.572
21	.4287	.4287	2.0576	1.8861	2.0576	2.4006
22	.4287	.3429	1.8861	1.7147	2.2291	1.8004
23	.3429	.2572	1.7147	1.5432	1.9719	1.8861
24	.2572	.3429	.2572		1.5432	1.8004
Max	2.915	2.8292	2.572	2.572	2.2291	2.572
Min	.2572	.2572	.2572	.2572	.2572	.2572
Avg	.8212	1.1595	1.2060	.9971	.7553	.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 277 / 11 KV Chandolwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	1.2003	1.0288	1.0288	1.2003
2	.3429	.2572	1.1145	1.2003	1.1145	1.1145
3	.3429	.2572	1.2003	1.1145	1.1145	1.1145
4	.3429	.3429	1.1145	1.286	1.286	1.286
5		.4287	1.2003	1.286	1.286	1.3717
6			1.286	1.4575	1.3717	1.6289
7			1.7147	1.7147	1.8861	1.8861
8			1.6289	1.5947	1.6289	1.8004
9	.4287	.4287	.3429	.2572	.2572	.3429
10	.4287	.3429	.3429	.2572	.2572	
11	.3429	.3429	.3429	.2572	.2572	.1715
12	.4287	.3429	.2572	.1715	.2572	.2572
13	.4287	.3429	.2572	.1715	.2572	.2572
14	.3429	.3429	.2572	.1715	.1715	.3429
15	.3429	.3429	.2572	.2572	.2572	.2572
16	.3429	.3429	.2572	.6001	.2572	.3429
17	.4287	1.3717	.2572	.2572	.3429	.3429
18	.4458	1.8004	.2572	.2572	.3429	.4287
19	.4287	1.7147	.4287	.3429	.3429	.4287
20	.5144	1.8004	.4287	.3429	.4287	.4287
21	1.8004	1.8004	.3429	.3429	.3429	.4287
22	1.7147	1.8004	.2572	.3429	.3429	.4287
23	1.7147	1.7147	.2572	.2572	.2572	.2572
24	.381	1.7147	1.4575	.2572	.2572	.2743
Max	1.8004	1.8004	1.7147	1.7147	1.8861	1.8861
Min	.2572	.2572	.2572	.1715	.1715	.1715
Avg	.5900	.8614	.6859	.6344	.6394	.7127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 278 / 11 KV super feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.6001	.6001	.5144
2	.5144	.5144	.5144	.6001	.6001	.5144
3	.6001	.5144	.5144	.6001	.6001	.5144
4	.8573	.5144	.5144	.6859	.6859	.5144
5	.9431	.6859	.6859	.6859	.7716	.5144
6	1.0288	.7716	.8573	1.0288	.8573	.7716
7	.7716	.8573	.8573	1.0288	1.0288	.8573
8	.9431	.8573	.7716	.7545	1.0288	.6173
9	.8573	.8573	.6859	.7716	.8573	.5144
10	.9431	.7716	.6859	.8573	.8573	.5144
11	.7716	.7716	.6859	.8573	.8573	.6001
12	.6859	.7716	.6859	.7716	.8573	.5144
13		.6859	.7716	.6859	.7716	
14		.6859	.7716	.6859	.7716	
15	.8573	.6001	.6001	.6859	.6001	
16	.8573	.6859	.6001	.6859	.6859	.6001
17	.4801	.6859	.5144	.7716	.6859	.6001
18	.8573	.6859	.5144		.6859	.8573
19	.7716	.6001	.7716	.8573	.7202	.8573
20	.6859	.5144	.6859	.8573	.6859	.7716
21	.6859	.7716	.7716	.7716	.6859	.6859
22	.6001	.6859	.6859	.6859	.5144	.8573
23	.5144	.6001	.6001	.6859	.5144	.6001
24	.6001	.5144	.5144	.6001	.6001	.5487
Max	1.0288	.8573	.8573	1.0288	1.0288	.8573
Min	.4801	.5144	.5144	.6001	.5144	.5144
Avg	.7428	.6716	.6573	.7485	.7302	.6352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 401 / 33 KV New Soot Mill

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 402 / 33 KV Old Soot Mill

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 409 / 33 KV Fabtech (Sangola II) NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 410 / 33 KV RYB Solar Power

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.6004
Max	1.6004
Min	1.6004
Avg	1.6004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 201 / 11 KV CHUNGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3441	1.2536	1.5023	1.5775
2		1.3889	1.2574	1.5432	1.5775
3		1.3889	1.2574	1.6204	1.7147
4		1.4661	1.3108	1.6975	1.7147
5		1.5432	1.3108	1.7747	1.6766
6		1.6204	1.5203	1.7747	1.9719
7		1.6204	1.7966	1.929	2.191
8		1.7747	1.7604	2.0062	2.0005
9		1.8519	1.656	2.037	2.0481
10		1.8564	1.5623	1.9204	1.7528
17		.0537	.0671	.0701	.0686
18		.0732	.0829	.0716	.1052
19		.0895	.1006	.0716	.1227
20		.0876	.1187	.0914	.124
21		.0895	.12	.0895	.124
22		.0895	.1029	.0914	.1227
23		.0895	.0876		.1029
24	.9907	.0995	.0914	.0995	.0895
Max	.9907	1.8564	1.7966	2.037	2.191
Min	.9907	.0537	.0671	.0701	.0686
Avg	.9907	.9182	.8587	1.0818	1.0603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 202 / 11 KV BOREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1605	2.4006	2.1605	2.3205
2		2.392	2.3472	2.2377	2.3205
3		2.392	2.4577	2.4691	2.5396
4		2.4691	2.6216	2.5463	2.6406
5		2.7006	2.5606	2.7006	2.8121
6		2.7006	2.7206	2.7778	3.1245
7		2.7778	2.915	2.8549	3.1245
8		2.8549	2.9797	2.9321	3.2007
9		2.9321	3.0007	2.9321	2.4006
10		1.5432	2.572	2.2405	2.2138
17		.1075	.1696	.128	.1581
18		.1402	.1677	.16	.16
19		.1791	.2035	.16	.3239
20		.1753	.218	.192	.2591
21		.1753	.2155	.1966	.2105
22		.1753	.1989	.1966	.2622
23		.1772	.1677		.2591
24	.0829	.1966	.1753	.1966	.16
Max	.0829	2.9321	3.0007	2.9321	3.2007
Min	.0829	.1075	.1677	.128	.1581
Avg	.0829	1.4583	1.5607	1.5930	1.5828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 203 / 11 KV HANNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3525	.2553	.3525	.3334
2		.4001	.2553	.4344	
3		.4633	.2743	.4755	.3382
4		.5735	.3334	.5201	.3887
5		.5796	.4934	.5944	.3887
6		.639	.6001	.6539	.5258
7		.5201	.6001	.6687	.5916
8		.5201	.4734	.5944	.5411
9		.4458	.423	.6241	.4668
10		.4058	.3572	.4934	.4115
11		.3382	.2896	.282	.3429
12		.3334	.2858	.2705	.3477
13		.3239	.2896	.2667	.2743
14		.3429	.2896	.2705	.2782
15		.3525	.2858	.2667	.3477
16		.362	.2896	.282	.3429
17		.3525	.3572	.2705	.3477
18		.3525	.362	.2667	.4115
19		.4058	.5201	.3382	.5563
20		.4001	.5792	.4001	.5563
21		.3239	.5068	.4001	.4115
22		.2629	.362	.3286	.4115
23		.2667	.362		.3429
24	.362	.3525	.2591	.3525	.3382
Max	.362	.639	.6001	.6687	.5916
Min	.362	.2629	.2553	.2667	.2743
Avg	.362	.4029	.3793	.4090	.4041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 204 / 11 KV NANHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801	.2629	.3696	.2658
2		.2801	.2658	.462	.3544
3		.4668	.2658	.6401	.3506
4		.4668	.3506	.6401	.3506
5		.5487	.4477	.6767	.443
6		.5853	.5316	.6767	.5316
7		.5121	.4961	.5853	.5316
8		.4572	.4477	.462	.5316
9		.4668	.3506	.462	.2772
10		.1791	.2629	.3544	.1848
11		.1402	.2801	.3544	
12		.1402	.1867	.3582	.1867
13		.1417	.1867	.3582	.1867
14		.1417	.1867	.2658	.1867
15		.1402	.2801	.1772	
16		.1417	.2801	.1753	
17		.1791	.3734	.1772	
18		.1772	.2801	.1753	.1867
19		.2658	.4668	.2743	.3696
20		.3506	.4668	.3544	.4668
21		.3506	.4668	.3544	.4668
22		.2865	.3696	.2658	.3734
23		.2658	.2772		.2801
24	.1867	.1867	.2629	.2801	.2658
Max	.1867	.5853	.5316	.6767	.5316
Min	.1867	.1402	.1867	.1753	.1848
Avg	.1867	.2980	.3352	.3869	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 205 / 11 KV SULTANPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0162	.016	.0168	.016
2		.0162	.016	.0168	.016
3		.0162	.0156	.0168	.0164
4		.0162	.0156	.0168	.016
5		.0162	.016	.0168	.016
6		.0162	.0156	.0168	.016
7		.0162	.016	.0168	.0164
8		.0162	.016	.0168	.016
9		.0162	.0164	.0168	.016
10		.016	.0166	.016	.16
11		.5601	.3315	.4801	.5668
12		.6081	.6554	.6401	.6325
13		.6405	.7459	.6554	.6401
14		.6554	.663	.6401	.6478
15		.6401	.7209	.6401	.5735
16		.6401	.663	.5735	.663
17		.5601	.7545	.6081	.663
18		.6062	.663	.6226	.6478
19		.016	.0166	.016	.0164
20		.016	.0162	.0164	.0162
21		.0164	.0164	.016	.0162
22		.016	.0162	.016	.0162
23		.016	.0162		.0156
24	.0829	.0162	.0164	.0168	.016
Max	.0829	.6554	.7545	.6554	.663
Min	.0829	.016	.0156	.016	.0156
Avg	.0829	.2154	.2273	.2221	.2265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 206 / 11 KV BAWKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1638	.1311	.116	.128
2		.116	.128	.0995	.096
3		.0983	.128	.0995	.0983
4		.096	.0983	.0995	.08
5		.0995	.096	.0995	.08
6		.0995	.096	.0829	.08
7		.0995	.096	.0829	.0819
8		.0995	.08	.0829	.08
9		.0995	.0819	.0829	.08
10		.08	.0995	.08	.1781
11		2.4863	1.8442	1.9204	1.1736
12		2.7206	2.6825	2.3205	1.4918
13		2.7496	2.5101	2.4905	1.4918
14		2.7206	2.6216	2.4006	
15		2.4387	2.4863	2.4006	2.5149
16		2.2565	2.431		2.5692
17		2.2565	2.3472	1.7604	2.4863
18		2.3205	2.3472	1.3108	2.2672
19		.128	.1658	.112	.1943
20		.1638	.1844	.1311	.1943
21		.16	.1658	.128	.1802
22		.16	.1844	.128	.1823
23		.16	.1886		.1802
24	.0829	.1966	.1638	.116	.1311
Max	.0829	2.7496	2.6825	2.4905	2.5692
Min	.0829	.08	.08	.08	.08
Avg	.0829	.9154	.8899	.7338	.6974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 207 / 11 KV ANV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0168	.0164	.0168	.0164
2		.0168	.0168	.0168	.016
3		.0168	.0168	.0168	.016
4		.0168	.0175	.0168	.0164
5		.0168	.0175	.0168	.016
6		.0162	.0175	.0168	.016
7		.0162	.0175	.0168	.016
8		.016	.0179	.0168	.016
9		.0162	.0179	.0168	.0164
10		.016	.0168	.016	.0162
11		.016	.0166	.016	.0166
12		.0156	.0168	.016	.0166
13		.016	.0166	.0164	.0168
14		.016	.0166	.016	.0168
15		.016	.0168	.016	.0166
16		.016	.0166	.0164	.0166
17		.016	.0168	.016	.0168
18		.0164	.0168	.016	.0166
19		.0164	.0166	.016	.0166
20		.016	.0168	.0164	.0166
21		.016	.0166	.016	.0166
22		.016	.0166	.016	.0166
23		.016	.0168		.0168
24	.0166	.0168	.0164	.0168	.0164
Max	.0166	.0168	.0179	.0168	.0168
Min	.0166	.0156	.0164	.016	.016
Avg	.0166	.0162	.0169	.0164	.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 201 / 11 KV NAVADAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	.4572	.5144	.7716	.7202	.4801	.7888
2	1.4556	.4572	.5868	.763	.7202	.5468	.9602
3	1.829	.5487	.6478	.8097	.7202	.6249	1.0936
4	2.1948	.823	.6944	.8802	.9602	.6173	1.2498
5	2.5606	1.0059	.8383	.9488	1.0402	.7621	1.3889
6	2.9264	1.2803	.9536	1.0936	1.2803	.9031	1.5242
7	3.658	2.0119	1.7394		2.1605	1.7185	1.7309
8	4.0238	2.2862	1.9766		2.0005	1.8747	1.8747
9	4.3896	2.1033	1.7528		1.7604	1.6766	1.6404
10	4.0238	1.829	1.5404		1.5051	1.5804	1.4842
17	.1828	.0914	.0914	.08	.0857	.0857	.08
18	.3658	.0857	.0914	.16	.0857	.0857	.16
19	.3658	.0914	.1829	.16	.1791	.1715	.16
20	.3658	.1772	.1829	.192	.1791	.1734	.16
21	.1829	.1772	.1829	.16	.1772	.1772	.16
22	.1829	.1791	.1829	.16	.0876	.1791	.16
23	.1829	.1791	.1829	.16	.0867	.1791	.16
24	.3658	.1829	.1791	.1791	.16	.0876	.1791
Max	4.3896	2.2862	1.9766	1.0936	2.1605	1.8747	1.8747
Min	.1828	.0857	.0914	.08	.0857	.0857	.08
Avg	1.7066	.7759	.6956	.4656	.7727	.6624	.8308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 202 / 11 KV HAIDRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1619	.181	.1791	.1848	.1715	.1658
2	.1524	.16	.1829	.1848	.1848	.1753	.16
3	.1524	.16	.1848	.1848	.1848	.1772	.16
4	.1543	.16	.1848	.1848	.1848	.181	.16
5	.1524	.16	.1848	.1848	.1848	.2743	.16
6	.1524	.16	.1867	.1848	.2772	.2801	.16
7	.1619	.16	.2829		.2772	.2801	.16
8	.1638	.16	.2801		.1848	.2801	.16
9	.1619	.16	.1848		.1848	.1829	.16
10	.16	.16	.1715		.1562	.1581	.16
11	1.7604	1.6004	1.7147		1.2346	1.5813	1.5203
12	2.2405	2.1052	2.4539		1.8185	2.0805	2.0805
13	2.1605	2.0805	2.5072		1.8185	2.13	1.9204
14	2.0805	2.0805	2.3282		1.5432	1.2574	
15	1.9204	2.0005	2.0595	1.9404	1.7966	1.6575	
16	2.0805	2.0005	2.1491	2.5873	1.8185	1.8404	
17	2.2405	1.9204	2.1491	2.1253	1.6766	1.6004	1.7604
18	1.8404	1.2955		1.6632	1.247	1.6004	1.6004
19	.16	.1753	.1791	.1848	.1791	.16	.16
20	.16	.1734	.1791	.1848	.2686	.16	.16
21	.16	.1734	.1791	.1848	.2629	.16	.16
22	.16	.1791	.1791	.1848	.1715	.16	.16
23	.16	.1791	.1791	.1848	.1696	.16	.16
24	.16	.16	.1791	.1791	.1848	.1677	.16
Max	2.2405	2.1052	2.5072	2.5873	1.8185	2.13	2.0805
Min	.1524	.16	.1715	.1791	.1562	.1581	.16
Avg	.7856	.7386	.8026	.6577	.6748	.7032	.5451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 203 / 11 KV Nagansur GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6535	.6335	.6335	.6335	.543	.6335
2	.6335	.6335	.6335	.8145	.724	.543	.8145
3	.724	.8145	.6335	1.086	.8145	.6335	.9955
4	1.1765	1.086	.724	1.267	.905	.724	1.1765
5	1.267	1.267	.9955	1.3575	1.086	.9955	1.267
6	1.448	1.5384	1.448	1.448		1.3575	1.448
7				1.448			
8	1.267	1.267	1.267		1.1765	1.267	1.267
9	1.086	.905			.905	.9955	.9955
10	.905	.8145			.724	.8145	.724
11	.724	.724	.7392		.543	.6335	.543
12	.6335	.6335	.5487		.4525	.4525	
13	.6335	.543	.4572		.4525	.4525	.4525
14	.543	.4525	.4572		.362	.4525	.4525
15	.543	.4525	.4572	.543	.362	.4525	.4525
16	.4525	.4525	.4572	.543	.4525	.4525	.4525
17	.543	.543	.5487	.6335	.543	.543	.543
18	.6335	.6335		.8145	.6335	.6335	.6335
19	.9955	.905	1.0059	1.086	.9955	.905	.9955
20	1.086	.9955	1.0974	1.1765	1.1765	.9955	1.267
21	.9955	.9955	1.0974	.9955	.9955	1.086	.9955
22	.724	.8145	.823	.8145	.724	.8145	.8145
23	.6335	.724	.6401	.724	.6335	.6335	.724
24	.6335	.6335	.6335	.6335	.6335	.6335	.6335
Max	1.448	1.5384	1.448	1.448	1.1765	1.3575	1.448
Min	.4525	.4525	.4572	.543	.362	.4525	.4525
Avg	.8224	.8036	.7649	.9423	.724	.7397	.8310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 204 / 11kv Rly Station Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7354	.3734	.3734	.4572	.462	.3734	.4572
2	.9192	.3734	.3734	.4572	.462	.3734	.4572
3	1.0917	.4525	.3734	.5487	.462	.3734	.5544
4	1.4708	.5601	.4668	.6401	.5544	.4668	.6468
5	1.6546	.6535	.5601	.7392	.6468	.5601	.8316
6	1.8385	.8402	.8402	.8316	.924	.8402	.9335
7	1.6632	.8402	.8402		.8316	.8402	.8402
8	1.4784	.6535	.6535		.6468	.6535	.5601
9	1.1088	.5601	.4668		.462	.5601	.462
10	1.1088	.3734	.4668		.462	.4668	.4668
11	1.1088	.3734	.3696		.3696	.3696	.4668
12	.924	.3734	.3696		.3696	.3696	.3734
13	.7392	.3734	.462		.3696	.3696	.4668
14	.7392	.3734	.3658		.3734	.3696	.3734
15	.7392	.3734	.3658	.5544	.3734	.3696	.4668
16	.7392	.3734	.3658	.5544	.3734	.3696	.4668
17	.924	.4668	.4572	.6468	.3734	.462	.4668
18	1.1088	.4668	.5487	.6468	.4668	.462	.6535
19	1.2936	.6535	.6401	.7392	.6535	.6401	.8402
20	1.486	.7468	.7316	.8316	.7468	.7316	.7468
21	.6468	.6535	.6401	.6401	.6535	.6401	.6535
22	.5544	.5601	.4572	.5544	.5601	.5487	.5601
23	.462	.9335	.4572	.462	.4668	.4572	.4668
24	.7316	.3734	.3734	.4572	.462	.4668	.4572
Max	1.8385	.9335	.8402	.8316	.924	.8402	.9335
Min	.462	.3734	.3658	.4572	.3696	.3696	.3734
Avg	1.0528	.5323	.5008	.6101	.5219	.5056	.5695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 205 / 11 KV Gaudgaon Bk Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.16	.16	.2401	.16	.16	.16
2	.3201	.16	.16	.3201	.16	.16	.3201
3	.4001	.2401	.2401	.3201	.2401	.2401	.4001
4	.4001	.2401	.2401	.4001	.3201	.2401	.4001
5	.4001	.3201	.3201	.4001	.4001	.3201	.4801
6	.4801	.4001	.4801	.4801	.5601	.4001	.4801
7	.6401	.6401	.6401		.8002	.6401	.6401
8	.7202	.8002	.7202		.7202	.6401	.6401
9	.7202	.7202	.6401		.5601	.6401	.5601
10	.4801	.5601	.5601		.4801	.4801	.4801
17	.08	.08	.08	.08	.08	.08	.08
18	.08	.08	.08	.08	.08	.08	.08
19	.08	.08	.08	.08	.08	.08	.08
20	.08	.08	.08	.08	.08	.08	.08
21	.08	.08	.08	.08	.08	.08	.08
22	.08	.08	.08	.08	.08	.08	.08
23	.08	.08	.08	.08	.08	.08	.08
24	.08	.08	.08	.08	.08	.08	.08
Max	.7202	.8002	.7202	.4801	.8002	.6401	.6401
Min	.08	.08	.08	.08	.08	.08	.08
Avg	.3067	.2712	.2667	.2000	.2801	.2534	.2889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 201 / 11 KV MOTYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0953
2							.0953
3							.0953
4							.0953
5							.0953
6							.0953
7							.1905
8							.2858
9							.2858
10							.2858
11	.381	.2858	.0953		.1905	.1905	
12	.2858	.2858	.1905		.2858	.2858	
13	.2858	.2858	.1905	.1905	.2858	.381	
14	.381	.2858	.2858	.2858	.2858	.381	
15	.2858	.2858	.2858	.381	.2858	.2858	
16	.2858	.2858	.2858	.381	.2858	.381	
17	.2858	.2858	.2858	.381	.2858	.2858	
18		.2858	.2858	.2858	.2858	.2858	
24	.0829						
Max	.381	.2858	.2858	.381	.2858	.381	.2858
Min	.0829	.2858	.0953	.1905	.1905	.1905	.0953
Avg	.2842	.2858	.2382	.3175	.2739	.3096	.1620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 202 / 11 KV WAGADARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.7147	1.7147	1.7147	1.4289		.0953
2	1.9052	1.7147	1.8099	1.7147	1.5242		.0953
3	1.9052	1.7147	1.8099	1.7147	1.5242		.0953
4	1.9052	1.9052	1.9052	1.7147	1.7147		.0953
5	2.2862	2.0957	1.6194	1.8099	2.0005		.0953
6	2.572	2.3815	2.0005	2.2862	2.6673		
7	3.9057	3.3341	3.3341		1.9052		
8	3.4294	3.3341	3.5246		2.2862	3.0483	
9	3.1436	3.3341	3.1436		2.8578	2.6673	
10	2.8578	2.4768	3.2388		2.8578	2.7625	
11							3.2388
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	1.5242	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.9057	3.3341	3.5246	2.2862	2.8578	3.0483	3.2388
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.8481	1.6321	1.6385	1.0392	1.4162	1.1193	.3811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 203 / 11 KV SANGAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2384	1.1431	1.3336	1.3336	1.2384	.0953
2	1.2384	1.2384	1.1431	1.3336	1.3336	1.2384	.0953
3	1.2384	1.2384	1.1431	1.3336	1.3336	1.2384	.0953
4	1.3336	1.2384	1.2384	1.3336	1.5242	1.2384	.0953
5	1.3336	1.4289	1.3336	1.5242	1.8099	1.4289	.0953
6	1.5242	1.7147	1.5242	1.7147	1.9052	1.6194	
7	2.4768	2.0957	2.0957		2.3815	2.2862	
8	2.191	2.3815	2.2862		2.572	2.4768	
9	2.2862	1.8099	2.2862		2.3815	2.191	
10	2.191	1.8099	1.6194		2.191	1.5242	
11							2.2862
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953		.0953
22		.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0829	.0953	.0953	.0953	.0953	.0953	.0953
Max	2.4768	2.3815	2.2862	1.7147	2.572	2.4768	2.2862
Min	.0829	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.2443	1.1114	1.0860	.8227	1.2828	1.2044	.2945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 204 / 11 KV Shirwal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.4763	.381
2	.381	.381	.381	.4763	.381	.4763	.381
3	.4763	.4763	.4763	.5716	.4763	.4763	.4763
4	.6668	.6668	.6668	.6668	.6668	.6668	.6668
5	.8573	.8573	.8573	.7621	.8573	.8573	.7621
6	1.0479	1.1431	1.0479	1.0479	1.0479	.9526	.9526
7	.9526	1.0479	.9526		1.0479	.9526	1.1431
8	.8573	.9526	.8573		.9526	.6668	.7621
9	.6668	.6668	.6668		.5716	.5716	.6668
10	.4763	.5716	.4763		.4763	.5716	.4763
11	.381	.4763	.381		.381	.4763	.381
12	.4763	.381	.381		.381	.4763	
13	.381	.381	.381	.5716	.2858	.381	.381
14	.381	.381	.381	.4763	.2858	.381	.0953
15	.4763	.381	.381	.381	.2858	.381	.1905
16	.4763	.381	.381	.4763	.2858	.381	.381
17	.381	.381	.381	.4763	.2858	.381	.381
18	.4763	.381	.4763	.5716	.4763	.4763	.4763
19	.7621	.7621	.6668	.8573	.6668	.6668	.6668
20	.7621	.7621	.7621	.8573	.7621	.8573	.8573
21	.5716	.6668	.6668	.7621	.6668	.6668	.6668
22	.6668	.4763	.5716	.5716	.5716	.5716	.5716
23	.4763	.4763	.4763	.4763	.4763	.4763	.5716
24	.381	.4763	.381	.381	.4763	.4763	.4763
Max	1.0479	1.1431	1.0479	1.0479	1.0479	.9526	1.1431
Min	.381	.381	.381	.381	.2858	.381	.0953
Avg	.5755	.5795	.5596	.5980	.5477	.5716	.5550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 205 / 11kv Wagdari Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.381	.381	.381	.381
2	.2858	.2858	.2858		.381	.381	.381
3	.2858	.2858	.381	.381	.381	.381	.381
4	.4763	.381	.4763	.4763	.4763	.381	.4763
5	.6668	.4763	.5716	.5716	.5716	.4763	.5716
6	.8573	.5716	.6668	.7621	.7621	.6668	.6668
7	.7621	.8573	.6668		.8573	.6668	.7621
8	.5716	.6668	.4763		.6668	.6668	.5716
9	.4763	.5716	.4763		.4763	.4763	.4763
10	.381	.381	.4763			.381	.4763
11	.381	.381	.381		.381	.381	.381
12	.381	.381	.2858		.381	.381	
13		.381	.2858	.4763	.2858	.381	
14	.381	.381	.2858	.4763	.2858	.381	.381
15	.381	.381	.2858	.381	.2858	.2858	.381
16	.381	.381	.2858	.4763	.2858	.2858	.381
17	.381	.381	.2858	.381	.2858	.381	.381
18	.4763	.381	.381	.4763	.381	.381	.381
19	.5716	.5716	.5716	.6668	.5716	.6668	.5716
20	.5716	.6668	.6668	.6668	.6668	.6668	.6668
21	.5716	.5716	.5716	.5716	.5716	.5716	.5716
22	.4763	.381	.4763	.381	.4763	.4763	.4763
23	.2858	.381	.381	.381	.381	.381	.381
24	.2858	.2858	.381	.381	.381	.381	.381
Max	.8573	.8573	.6668	.7621	.8573	.6668	.7621
Min	.2858	.2858	.2858	.381	.2858	.2858	.381
Avg	.4597	.4445	.4287	.4875	.4597	.4525	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 206 / 11kv Borgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	2.191
2	.0953	.0953	.0953	.0953	.0953	.0953	2.2862
3	.0953	.0953	.0953	.0953	.0953	.0953	2.2862
4	.0953	.0953	.0953	.0953	.0953	.0953	2.3815
5	.0953	.0953	.0953	.0953	.0953	.0953	2.572
6							3.2388
7							3.6199
8							3.9057
9							3.9057
10							3.5246
11	3.9057	3.6199	4.0009		3.4294	3.8104	
12	4.0962	4.382	4.382		4.1914	4.0009	
13	4.1914	4.0962	4.0009	4.1914	4.2867	4.382	
14	4.0009	4.0962	4.1914	4.0009	4.382	4.0009	
15	4.0962	4.0009	4.1914	4.1914	4.1914	3.8104	
16	4.1914	4.0009	4.0009	4.1914	4.0962	4.0009	
17	4.1914	4.1914	4.0009	4.1914	4.0009	3.9057	
18	3.7151	4.0009	3.6199	3.8104	3.8104	2.8578	
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0829	.0953	.0953	.0953	.0953	.0953	.0953
Max	4.1914	4.382	4.382	4.1914	4.382	4.382	3.9057
Min	.0829	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.8516	1.8523	1.8523	1.5956	1.8523	1.7623	2.0259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 201 / 11 KV TADWAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.104	.1189	.1189	.1189	.1189	1.3077
2	.104	.104	.1337	.1189	.1337	.1189	1.3375
3	.1189	.1189	.1486	.1337	.1486	.1337	1.3375
4	.1505	.1337	.1486	.1486	.1486	.1337	1.3672
5	.1505	.1486	.1635	.1486	.1635	.1486	1.3969
6	.1806	.1783	.1783	.1635	.1783	.1635	1.4861
7							1.6941
8							1.9319
10							1.5901
11	1.6792	1.6792	1.7387	1.6941	1.6644	1.6941	
12	1.9022	1.9022	1.8278	1.917	1.813	1.9616	
13	1.9765	1.9616	1.8873		1.8873	1.9319	
14	2.0062	1.9319	1.8427		1.8278	1.8873	
15	2.0062	1.8873	1.7981		1.7833	1.8873	
16	1.9913	1.9319	1.709		1.8278	1.8724	
17	1.9319	1.8724	1.4563	1.9022	1.8576	1.8576	
18	1.813	1.8278	1.6792	1.6198	1.8278	1.7238	
19	.1337	.1189	.1337	.1189	.1337	.1189	.1337
20	.1337	.1486	.1337	.1337	.1486	.1337	.1337
21	.1486	.1486	.1337	.1337	.1486	.1337	.1337
22	.1486	.1337	.1337	.1486	.1337	.1189	.1189
23	.1189	.1337	.1189	.1189	.1337	.1189	.1189
24	.104	.1189	.1189	.1189	.1189	.1189	.1189
Max	2.0062	1.9616	1.8873	1.917	1.8873	1.9616	1.9319
Min	.104	.104	.1189	.1189	.1189	.1189	.1189
Avg	.8451	.8292	.7802	.5461	.8099	.8188	.9471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 202 / 11 KV KHANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	.945	1.2071	1.1128	.8993	1.1128	
2	1.0534	.9602	1.2449	1.1317	.9145	1.1317	
3	1.1088	.9907	1.2449	1.1694	.945	1.1694	.0754
4	1.1576	1.0212	1.2826	1.1883	.9602	1.226	.0754
5	1.1763	1.0669	1.3203	1.2449	.9907	1.3014	.0943
6	1.2696	1.1126	1.3957	1.3392	1.0059	1.3957	.0943
7	1.6244	1.3717	1.6032	1.7353	1.2346	1.6787	
8	1.7177	1.4175		1.7918	1.387	1.8296	
9	1.7177	1.4175	1.5278	1.8107	1.326	1.7918	
10	1.3565	1.2193	1.5089	1.7164	1.1584	1.7164	
11							1.326
12							1.4175
13							1.8296
14							1.4784
16							1.4175
17							1.448
18							1.4022
19	.061	.0754	.0943	.0762	.0943	.0943	.061
20	.0762	.0943	.0943	.0762	.0943	.0943	.0762
21	.0762	.0943	.0943	.0762	.0943	.0943	.0762
22	.0762	.0943	.0943	.0762	.0943	.0943	.0762
23	.0762	.0943	.0754	.0762	.0943	.0754	.061
24	1.0608	.9145	.0754	.0754	.884	.0754	.0754
Max	1.7177	1.4175	1.6032	1.8107	1.387	1.8296	1.8296
Min	.061	.0754	.0754	.0754	.0943	.0754	.061
Avg	.9175	.8056	.8576	.9186	.7611	.9301	.6520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 203 / 11 KV MHAISALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0364	1.1574	1.1883	1.0185	1.1574	1.2963	.108
2	1.0974	1.1883	1.2037	1.0185	1.1728	1.3117	.0772
3	1.1126	1.2191	1.2037	1.034	1.2037	1.3272	.0772
4	1.2037	1.2346	1.2346	1.0648	1.2346	1.3426	.0772
5	1.2037	1.2809	1.2963	1.1574	1.25	1.358	.0772
6	1.25	1.3272	1.4043	1.3272	1.2809	1.3735	.0772
7	1.5123	1.5586	1.6512	1.4815	1.5123	1.6049	
8	1.3889	1.6975		1.5432	1.6821	1.713	
9	1.5432	1.7284	***	1.6358	1.7438	1.7438	
10	1.5432	1.4661	1.6049	1.6821	1.7593	1.713	
11							1.5741
12							1.9444
15							2.037
17							1.7284
18							1.9444
19	.1389	.108	.1389	.1543	.1389	.1543	.1235
20	.1389	.108	.1389		.1543	.1543	.1389
21	.1389	.108	.108		.1543	.1543	.1389
22	.1389	.108	.0926		.1389	.1235	.1235
23	.1235	.108	.0772	.1389	.1389	.1235	.1235
24	1.0802	1.1111	.108	.0772	1.1265	.1235	.1235
Max	1.5432	1.7284	16.6667	1.6821	1.7593	1.7438	2.037
Min	.1235	.108	.0772	.0772	.1389	.1235	.0772
Avg	.9157	.9693	1.8745	1.0256	.9905	.9761	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 204 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1107	.128	.112	.112	.128	.112	.8642
2	.1107	.128	.112	.112	.128	.112	.8642
3	.1265	.144	.128	.128	.1219	.128	.8962
4	.144	.144	.16	.144	.144	.144	.9282
5	.144	.16	.16	.16	.1524	.16	.9602
6	.16	.176	.176	.176	.176	.16	1.0562
7							1.4883
8							1.6324
9							1.5844
10							1.4563
11	1.5844	1.1203	1.5043	1.4083	1.5524	1.4723	
12	1.7284	1.5844	1.8404	1.5684	1.6004	1.6644	
13	1.6804	1.6324	1.7764		1.6484	.1648	
14	1.6484	1.6004	1.7444		1.6804	1.6004	
15	1.6964	1.5684	1.7124		1.6004	1.6164	
16	1.7764	1.6484	1.6804		1.6324	1.6324	
17	1.7764	1.6004	1.6484	1.6964	1.6644	1.6324	
18	1.6164	1.4563	1.5364	1.1523	1.2963	1.6004	
19	.128	.128	.144	.144	.128	.16	.144
20	.16	.16	.144	.144	.144	.16	.144
21	.16	.16	.144	.144	.144	.16	.144
22	.144	.144	.144	.144	.128	.128	.1646
23	.128	.128	.128	.128	.128	.112	.144
24	.1107	.128	.128	.112	.128	.096	.112
Max	1.7764	1.6484	1.8404	1.6964	1.6804	1.6644	1.6324
Min	.1107	.128	.112	.112	.1219	.096	.112
Avg	.7567	.6970	.7562	.4671	.7163	.6508	.7865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 205 / 11KV TADWAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.5121	.5121	.5121	.4572	.5304	.5121
2	.5121	.5487	.5487	.567	.4938	.567	.5487
3	.6036	.6401	.6219	.695	.5304	.695	.6584
4	.7762	.695	.7316	.7682	.6219	.7865	.7682
5	.8871	.823	.8048	.8413	.7316	.823	.8413
6	.9979	.9694	.8413	.8962	.8413	.8779	.8962
9	.5487	.5304	.5121	.5487	.567	.4755	.4755
10	.4207	.5138	.4207	.4755	.439	.439	.4207
11	.4207	.3658	.3475	.4207	.4207	.3658	.3841
12	.4207	.3475	.4207	.3475	.4024	.3292	.3841
13	.4207	.3475	.3658		.3292	.3292	.3841
14	.4755	.3658	.3658		.3109	.3109	.3841
15	.4572	.3658	.3841		.3841	.3658	.4024
16	.4755	.3658	.3841		.4024	.3658	.3841
17	.4572	.3658	.4024	.4572	.439	.3841	.4024
18	.5121	.3841	.4572	.4755	.439	.4207	.439
19	.6767	.6584	.6036	.7499	.6584	.6219	.6219
20	.7133	.695	.7133	.7865	.7682	.6767	.7133
21	.7499	.6219	.6767	.7316	.695	.6219	.695
22	.6036	.567	.5853	.6401	.6401	.567	.6219
23	.5121	.5487	.5121	.5487	.567	.5121	.5487
24	.5121	.5121	.5121	.4938	.5121	.5121	.5121
Max	.9979	.9694	.8413	.8962	.8413	.8779	.8962
Min	.4207	.3475	.3475	.3475	.3109	.3109	.3841
Avg	.5749	.5338	.5329	.6086	.5296	.5263	.5454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 206 / 11 kv Gokul Mauli
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
1	.0532
2	.0532
3	.0358
4	.0537
5	.0532
6	.0532
7	.0537
8	.0732
9	.0537
10	.0543
11	.0543
12	.0543
13	.0724
14	.0724
15	.0724
16	.0724
24	.1183
Max	.1183
Min	.0358
Avg	.0620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 207 / 11 KV Mangrul Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1791	.1629	.1791	.1791	.197	.181
2	.1612	.2149	.1629	.197	.2328	.2149	.2172
3	.197	.2328	.2172	.2149	.2328	.2328	.2534
4	.2715	.3045	.2534	.2507	.2686	.2686	.2896
5	.3258	.3403		.3045	.3045	.3045	.3258
6	.362	.3761	.3841	.3582	.3582	.3582	.3761
9	.2172	.2149	.1448	.197	.1075	.197	.1629
10	.1433	.2149		.1612	.1612	.1433	.1448
11	.2149	.1448	.1254	.1254	.1433	.1448	.1433
12		.1267	.1254	.1433	.1254	.1448	.1254
13	.1254	.1267	.1433		.1254	.1267	.1254
14	.1612	.1267	.1433		.1433	.1267	.1254
15	.1612	.1267	.1433		.1433	.1267	.1254
16	.1433	.1267	.1433		.1433	.1267	.1433
17	.1433	.1267	.1433	.1612	.1433	.1267	.1075
18	.1433	.1267	.1612	.1791	.1612	.1448	.1433
19	.2328	.2534	.2507	.2686	.2686	.2715	.2328
20	.2686	.2896	.3045	.3045	.2865	.2896	.3045
21	.2328	.2534	.2686	.2686	.2865	.2353	.2686
22	.2149	.1991	.2149	.2507	.2328	.2172	.2328
23	.1791	.181	.197	.1791	.1791	.181	.2149
24	.1433	.1791	.1629	.197	.1791	.1791	.181
Max	.362	.3761	.3841	.3582	.3582	.3582	.3761
Min	.1254	.1267	.1254	.1254	.1075	.1267	.1075
Avg	.1993	.2029	.1926	.2189	.2003	.1981	.2011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 201 / 11 KV DUDHANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
8	2.1195	
24	.0995	.081
Max	2.1195	.081
Min	.0995	.081
Avg	1.1095	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 202 / 11 KV MAINDARGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
16	2.0576	
24	.0829	.081
Max	2.0576	.081
Min	.0829	.081
Avg	1.0703	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 203 / 11 KV SALAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0838
Max	.0838
Min	.0838
Avg	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 204 / 11 KV BOROTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
16	1.7004
24	.0829
Max	1.7004
Min	.0829
Avg	.8917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 205 / 11 KV UMARGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
16	1.1336
24	.0829
Max	1.1336
Min	.0829
Avg	.6083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 206 / 11 KV DUDHANI/BOROTI

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.08
Max	.08
Min	.08
Avg	.08

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 207 / 11KV UAMRGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 208 / 11KV MAINDARGI SEMI URBAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
8	.5087
16	.4239
24	.4239
Max	.5087
Min	.4239
Avg	.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 209 / 11KV SALAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
8	.4239
16	.2543
24	.2543
Max	.4239
Min	.2543
Avg	.3108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 211 / 11 KV Awtade Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder Feeder KV- 11 /

(CONTINUOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	01-MAR-18
HR	Load (MW)
8	.0351
16	.017
Max	.0351
Min	.017
Avg	.0261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 201 / 11 KV HILLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0373	.0343	.0373	.0171	.0343	.3772
2	.0343	.0373	.0343	.0373	.0343	.0343	.4801
3	.0343	.0373	.0343	.0373	.0343	.0343	.5487
4	.0343	.0373	.0343	.0373	.0343	.0343	.6859
5	.0343	.0373	.0343	.0373	.0343	.0343	.7716
6	.0343	.0373	.0343	.0373	.0343	.0343	.8573
7	.0343	.0373	.0343	.0373	.0343	.0343	.8916
8	.0343	.0373		.0373	.0343	.0343	1.0288
9	.0373	.0343	.0373	.0373	.0343	.0343	1.046
10	.0373	.0343	.0373	.0171	.0343	.7202	.9012
11	.8383	.8059	.78	.703	.8402	.7202	.0373
12	.8785	.8573	.9339	.7202	.8916	.9088	.0373
13	.8951	.7716	.8192	.7716	.9259	.8402	.0373
14	.8288	.8059	.763		.823	.7716	.0373
15	.8288	.7202	.8139		.7202		.0373
16	.9116	.8059	.8478	.6173	.7716	.7716	.0373
17	.9116	.9259	.8478	.7202	1.0288	.8059	.0373
18	.9116	1.0288	.9221	.4973	.9431	.8059	.0373
19	.0373	.0343	.0373	.0343	.0343	.0343	.0373
20	.0373	.0343	.0373	.0343	.0343	.0343	.0373
21	.0373	.0343	.0373	.0343	.0343	.0343	.0373
22	.0373	.0343	.0373		.0343	.0343	.0373
23	.0373	.0343	.0373	.0343	.0343		.0373
24	.0343	.0373	.0343	.0373	.0171	.0343	.0343
Max	.9116	1.0288	.9339	.7716	1.0288	.9088	1.046
Min	.0343	.0343	.0343	.0171	.0171	.0343	.0343
Avg	.3156	.3041	.3158	.2170	.3108	.3102	.3378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 202 / 11 KV HANDRAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.4477	.4287	.6335	.463	.5144	.0514
2	.7202		.4801	.6805	.6001	.5144	.0686
3	.7716	.5014	.5144	.6733	.6859	.6001	.0686
4	.7545	.5194	.6001	.6859	.7202	.6859	.0857
5	.8402	.5201	.6173	.703	.7716	.7716	.0857
6	.9602	.6268	.6859	.7202	.823	.7716	.0857
7	1.046	.6859	.7716	.7373	.8916	.8573	.0857
8	1.0631	.7716		.7716	.8573	.8402	.0514
9	1.0608	.8059	.7202	.7716	.8573	.823	.0514
10	.9945	.7716	.7716	.8916	.8745	.8059	.0373
11		.0857	.0373	.0343	.0857	.0514	.5258
12		.0343	.0373	.0343	.0857	.0514	.6135
13	.0373	.0343	.0373	.0343	.0857	.0514	.6516
14	.0373	.0343	.0373		.0857	.0514	.6859
15	.0373	.0343	.0373	.0343	.0857	.0514	
16	.0373	.0343	.0373	.0343	.0857	.0514	
17	.0373	.0514	.0373	.0343	.0857	.0514	.6068
18	.0373	.0514	.0373	.0343	.0514	.0514	.6859
19	.0373	.0514	.0373	.0343	.0514	.0514	.0373
20	.0373	.0514	.0373	.0343	.0514	.0514	.0373
21	.0373	.0514	.0373	.0343	.0514	.0514	.0373
22	.0373	.0514	.0373	.0171	.0514	.0514	.0373
23	.0373	.0514	.0373	.0343	.0514	.0514	.0373
24	.1172	.0373	.0514	.0373	.0171	.0343	.0514
Max	1.0631	.8059	.7716	.8916	.8916	.8573	.6859
Min	.0373	.0343	.0373	.0171	.0171	.0343	.0373
Avg	.4284	.2741	.2664	.3348	.3529	.3286	.2127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 203 / 11 KV AHERWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6173	.6859	.6859	.6859	.0686
2	.8573	.6001	.6516	.7716	.7202	.7202	.0686
3	.8745	.6344	.6859	.8383	.7716	.7202	.0686
4	.9088	.6859	.8478	1.0059	.8573	.823	.0686
5	1.0288	.8573	.9326	1.0774	.9431	.9945	.0686
6	1.1145	1.0288	1.0059	1.1469	1.0288	1.1145	.0857
7	1.166	1.1145	1.0395	1.1822	1.2003	1.286	.0857
8	1.3203	1.2517		1.2289	1.3375	1.286	.0686
9	1.2346	1.2003	1.0486	1.0802	1.2003	1.1145	.0514
10	1.2003	.7716	1.0526	1.166	1.1145	1.2689	.056
11	.0343	.0343	.0373	.0514	.0343	.0514	.7716
12	.0343	.0343	.0373	.0514	.0343	.0514	.7969
13	.0343	.0343	.0373	.0514	.0343	.0514	.8192
14	.0343	.0343	.0373		.0343	.0514	.8907
15	.0343	.0343	.0373		.0343	.0514	.9012
16	.0343	.0343	.0373	.0514	.0343	.0514	.9012
17	.0343	.0343	.056	.0514	.0514	.0514	.9012
18	.0343	.0343	.056	.0514	.0514	.0514	.9012
19	.0343	.0686	.0934	.0514	.0686	.0514	.0934
20		.0686	.0934	.0857	.0686	.0566	.0934
21	.0343	.0686	.0934	.0857	.0686	.0514	.0934
22	.0343	.0514	.0747	.0686	.0514	.0686	.0934
23	.0343	.0514	.056	.0514	.0514	.0514	.3658
24	.0829	.0343	.0514	.0934	.0343	.0514	.0514
Max	1.3203	1.2517	1.0526	1.2289	1.3375	1.286	.9012
Min	.0343	.0343	.0373	.0514	.0343	.0514	.0514
Avg	.4636	.3865	.3774	.4967	.4380	.4482	.3485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 204 / 11KV KARJAGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3086	.3292	.3475	.2058	.2743	.3086
2	.2058	.3086	.3258	.362	.1886	.2915	.2743
3	.2401	.3258	.3582	.4525	.2058	.2915	.3086
4	.3086	.3429	.394	.5373	.3086	.3086	.3772
5	.4115	.463	.5014	.5258	.5144	.3772	.4115
6	.5316	.5144	.5731	.6068	.5487	.4801	.4801
7	.6344	.6173	.6516	.6859	.6173	.6516	.6687
8	.583	.703		.6001	.6173	.6516	.583
9	.4973	.5316	.4163	.5201	.5144	.4973	.463
10	.4287	.4115	.3077	.4458	.4287	.3601	.4477
11	.4287	.3258	.3077	.3944	.3258	.3258	.3582
12	.3944	.3429		.3429	.3429	.3258	.3475
13	.3429	.3086		.3086	.2915	.3429	.3258
14	.3086	.2572	.362		.2915	.3258	.3077
15	.3258	.3086	.362		.3429	.2915	.3077
16	.3429	.3258	.362	.3772	.3258	.3258	.3258
17	.3429	.3429	.3658	.3772	.3086	.3258	.3439
18	.3429	.3601	.362	.3944	.2229	.2915	.3582
19	.4973	.4973	.543	.6516	.463	.3772	.5258
20	.5144	.4115	.543	.5487	.5144	.5316	.4477
21	.4287	.3772	.4525	.5316	.3772	.4115	.3982
22	.3944	.3258	.4024	.3772	.3772	.3601	.3582
23	.3429	.3429	.3658	.3429	.2915	.3429	
24	.2915	.3258	.3086		.2572	.2743	.2915
Max	.6344	.703	.6516	.6859	.6173	.6516	.6687
Min	.2058	.2572	.3077	.3086	.1886	.2743	.2743
Avg	.3915	.3908	.4092	.4634	.3701	.3765	.3921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 205 / 11 KV HILLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2561	.1543	.2926	.1886	.1886	.1543
2	.1715	.2561	.1543	.362	.1715	.1715	.1715
3	.2058	.2743	.2572	.3982	.2058	.2058	.2058
4	.2401	.3292	.3429	.4477	.2229	.2743	.3086
5	.3429	.4525	.3772	.5014	.3086	.3086	.3429
6	.4287	.5014	.4115	.5194	.4115	.3772	.3772
7	.4973	.5373	.463	.5316	.463	.4115	.4973
8	.4287	.4656		.4854	.3601	.2572	.3772
9	.3982	.3429	.3077	.4477	.3086	.2229	.2915
10	.362	.2915	.3077	.2572	.2401	.2401	.2715
11			.1991	.2229	.2401	.2401	.2715
12		.2058	.1829	.1886	.2058	.2058	.2715
13	.2715	.1886	.2012		.1886	.2058	.2715
14	.2743	.2229	.2195		.1886	.1886	.2715
15	.2743	.2229	.2195	.1715	.2401	.2229	
16	.2743		.2195	.2058	.1886	.2229	
17	.2743		.2561	.2401	.1886	.2058	.3109
18	.2743		.2743	.463	.2401	.2401	.3582
19	.4525		.4525	.583	.3772	.3429	.4477
20	.5014		.4344		.3772	.4458	.3582
21	.5316		.4119	.3601	.3429	.2743	.3224
22	.5316		.394	.3429	.2572	.2229	.2743
23	.2743	.1543	.3292	.2058	.1886	.1886	.2743
24	.1886	.2743	.1543	.2926	.1372	.1715	.1715
Max	.5316	.5373	.463	.583	.463	.4458	.4973
Min	.1715	.1543	.1543	.1715	.1372	.1715	.1543
Avg	.3358	.3110	.2924	.3581	.2601	.2515	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 206 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0934	.0857	.0934	.1029	.1029	.5144
2	.0857	.0934	.0857	.0934	.1029	.1029	.6173
3	.0857	.0934	.0857	.0934	.1029	.1029	.7202
4	.0857	.112	.0857	.0934	.12	.1029	.7716
5	.0857	.112	.0857	.0934	.12	.1029	.8916
6	.0857	.1307	.0857	.112	.12	.12	1.1145
7	.0857	.1494	.0857	.112	.1372	.1029	1.3032
8	.0857	.1494		.0934	.0857	.12	1.4575
9	.0934	.12	.0934	.0934		.0857	1.3375
10	.0934	.1029	.0934	.0857	.0857	.0857	1.1336
11	.8478	1.0288	.8573	.1029	1.5432	1.1145	.0934
12	1.1336	1.0288	.9221	.0857	1.0288	1.2003	.0934
13	1.1336	.8916	.9831	.0857	2.4006	1.166	.0934
14	1.065	.9431	1.0526		2.2291	1.0974	.0934
15	1.1105	.9431	1.0936		1.3717	1.0974	.0934
16	1.1469	1.0288	1.0936	1.1145	1.2003	1.2003	.0934
17	1.065	.0857	1.065	.8402	1.2003	1.2346	.0934
18	.9945	1.1145	.9945	.7202	1.0288	1.1145	.0934
19	.0934	.0857	.112	.0857	.12	.0857	.0934
20	.0934	.0857	.112	.0857	.1029	.0857	.1307
21	.0934	.1029	.1307	.0857	.12	.0857	.1494
22	.0934	.1029	.1307	.0857	.12	.0686	.1494
23	.0934	.1029	.112	.0857	.1029	.0857	.1307
24	.0857	.0934	.0857	.0934	.0857	.1029	.0857
Max	1.1469	1.1145	1.0936	1.1145	2.4006	1.2346	1.4575
Min	.0857	.0857	.0857	.0857	.0857	.0686	.0857
Avg	.4134	.3664	.4144	.2016	.5927	.4487	.4728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 207 / 11 KV HANDRAL GOATHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 201 / 11 KV SHEGAON MIX AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.6401	.7316	.6859	.7316	2.13
2	.6401	.5487	.6401	.7316	.6859	.7316	2.13
3	.6401	.5487	.6401	.7316	.6935	.7316	1.6385
4	.6401	.5487	.6401	.7316	.6859	.7316	1.6385
5	.6401	.5487	.6401	.7316	.6935	.7316	1.6385
6	.6401	.5487	.6401	.7316	.6935	.7316	1.6385
7							1.6385
8							1.6385
9							1.5565
10							1.5384
11	1.9662	1.95	1.9662	1.7604	1.6956		
12	1.9662	2.2119	2.13	1.8842	1.8652		
13	2.13	2.2119	2.13	1.9204	1.6956		
14	2.2939	2.13	2.13	2.0243	1.8652		
15	2.3758	2.13	2.13	1.9204	1.8652		
16	2.1348	2.2939	2.13	1.9662	1.95		
17	2.2929	2.2939	2.0481	1.9204	2.0348		.4572
18	2.2043	2.3758	2.0481	2.0481	1.95		.4572
19	.5487	.462	.5487	.6001	.5544		.4572
20	.5487	.5544	.7316	.6935	.6468		.4572
21	.5487	.6468	.7316	.6859	.7392		.4572
22	.5487	.6468	.7316	.6859	.7316		.4572
23	.5487	.6468	.7316	.6859	.7316		.4572
24	.5487	.5487	.6468	.7316	.6935	.7316	.5487
Max	2.3758	2.3758	2.13	2.0481	2.0348	.7316	2.13
Min	.5487	.462	.5487	.6001	.5544	.7316	.4572
Avg	1.2203	1.2198	1.2337	1.1958	1.1578	.7316	1.1631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 202 / 11 KV S.JAWALAGE MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1753	.1867	.3544	.1734	.1867	.6401
2		.1772	.1867	.3563	.1734	.1867	.6401
3	.1829	.1753	.1867	.8688	.1734	.1867	.6401
4	.1829	.1753	.1867	.3544	.1734	.1867	.6401
5	.1829	.1772	.1867	.3544	.1734	.1867	.6401
6	.1829	.1753	.1867	.3544	.1734	.1867	.6401
7							.8002
8							.9602
9							.8002
10							.9602
11	1.6385	1.387	1.1203	.9831	1.1393		
12	1.8023	1.5604	1.4403	.9831	1.387		
13	1.8023	1.387		1.0526	.8669		
14	1.6385	1.387	1.2803	1.065	1.0402		
15	1.2955	1.387	1.2803	.9831	1.2136		
16	1.2651	1.2136	1.2803	.8002	1.2136		
17	.1753	1.2136	.9602	.8192	1.387		.3658
18	1.406	1.2136	.9602	.8097	1.387		.1829
19	.1753	.1867	.1829	.1715	.1867		.1829
20	.1753	.1867	.1829	.1734	.1867		.1829
21	.1753	.1867	.1829	.1715	.1867		.1829
22	.1753	.1867	.1829	.1715	.1867		.1829
23	.1772	.1867	.1829	.1715	.1867		.1829
24	.2658	.1753	.1867	.3563	.1734	.1867	.1829
Max	1.8023	1.5604	1.4403	1.065	1.387	.1867	.9602
Min	.1753	.1753	.1829	.1715	.1734	.1867	.1829
Avg	.6885	.6457	.5549	.5677	.5891	.1867	.5004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 203 / 11 KV KORSEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9488	1.1269	1.9204	1.0402	1.2003	.2743
2	.9717	.9488	1.1269	1.9204	1.0402	1.2003	.2743
3	.9717	.9259	1.1269	1.9433	1.065	1.2003	.2743
4	.9717	.9488	1.1269	1.9433	1.1336	1.2003	.2743
5	.9717	1.0279	1.1269	1.9204	1.1336	1.2003	.2743
6	1.0526	1.186	1.2136	1.9204	1.2146	1.3717	.2743
7	1.0526	1.1717	1.4737	2.4292	1.6004	1.5432	
8	1.2146	1.4232	1.5604	2.5911	1.6385	1.286	
9	1.1336	1.2651	1.1336	1.2003	1.5203		
10	1.2146	1.387	1.1336	1.2289	1.4737		
11							1.2803
12							1.4403
13							1.4575
14							1.4575
15							1.4575
16							1.3765
17	.1753	.1867	.1829	.2572	.1867		1.3765
18	.1753	.1867	.1829	.2601	.1867		1.3765
19	.1753	.2801	.2743	.3467	.3696		.2743
20	.2629	.3696	.2743	.3467	.3696		.2743
21	.2658	.3696	.2743	.3467	.3696		.3658
22	.2658	.3696	.2743	.3429	.3696		.2743
23	.2629	.3696	.2743	.3467	.3696		.2743
24	.3572	.9488	.3696	.5344	.3467	.3696	.2743
Max	1.2146	1.4232	1.5604	2.5911	1.6385	1.5432	1.4575
Min	.1753	.1867	.1829	.2572	.1867	.3696	.2743
Avg	.6926	.7952	.7920	1.2111	.8571	1.1747	.7303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 204 / 11 KV KUMTHA MIX FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 205 / 11 KV KALKARJAL MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6325	.5487	.9716	.4915	.462	.1829
2	.6401	.6325	.5487	.9659	.4801	.462	.1829
3	.6401	.6325	.5487	.9602	.4915	.462	.1829
4	.6401	.6325	.5487	.9659	.4858	.462	
5	.6401	.6325	.5487	.9602	.4801	.462	.1829
6	.6401	.6325	.6401	.9716	.4915	.5544	.1829
7	.6401	.6173	.7973	1.2802	.6554	.6468	
8	.6401	.7907	.7973	1.4489	.6478	.6468	
9	.7202	.7907	.7202	.7373	.6401		
10	.6401	.8059	.7287	.7287	.7316		
11							.4801
12							.5601
13							.6401
14							.6401
15							.6401
16							.4801
17	.0088	.0943	.0914	.0857	.0934		.5601
18	.0088	.0943	.0914	.0867	.0934		.5601
19	.0088	.0943	.0914	.0857	.1867		.0914
20	.0088	.1867	.0914	.0857	.1867		.0914
21	.0088	.1867	.0914	.0867	.1867		.0914
22	.1753	.1867	.0914	.0876	.1867		.0914
23	.1753	.1867	.0914	.0867	.1867		.0914
24	.2658	.1753	.1867	.1781	.0857	.1867	.0914
Max	.7202	.8059	.7973	1.4489	.7316	.6468	.6401
Min	.0088	.0943	.0914	.0857	.0857	.1867	.0914
Avg	.3968	.4447	.4030	.5985	.3779	.4827	.3170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 201 / 11 KV RUDDREWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0373	.0747	.0373	.037	.0747	.0566
2	.056	.0373	.056	.0373	.0373	.0747	.0566
3	.0554	.037	.0554	.037	.0373	.0747	.0566
4	.0554	.037	.0554	.037	.0373	.0747	
11	1.829	2.2862	1.9753		1.9204	1.134	1.0974
12	2.0485	2.2862	2.0119		2.4691	2.3529	
13	2.3777	2.4691	2.3777		2.1195	2.2131	
14	2.0119	2.3777	2.4691		2.2634	2.1879	
15	2.2862	2.2862	2.5606		2.2634	2.13	
16	2.1948		2.652	2.5606	2.2119	2.1052	
17	2.524		2.1948	2.7435	2.2119	2.0729	
18	2.1719		1.9004	2.5606	2.1052	1.9433	
19	.037	.0747	.037	.037	.0732		.0373
20	.037	.0739	.037	.037	.0732	.0366	.0377
21	.037	.0739	.037	.037	.0739	.037	.0373
22	.0373	.0747	.0373	.0373	.0747	.0373	.0373
23	.0373	.0747	.0373	.0373	.0747	.056	.037
24	.1389	.0373	.0747	.0373	.0373	.0747	.056
Max	2.524	2.4691	2.652	2.7435	2.4691	2.3529	1.0974
Min	.037	.037	.037	.037	.037	.0366	.037
Avg	.9995	.8175	1.0358	.6336	1.0067	.9812	.1510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 202 / 11 KV BOROTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	.6468	.7468	.3174	.6468	.8316	.7468
2	1.4784	.9335	.7392	.5601	.6535	.924	.8131
3	1.4998	1.2136	.8316	.6653	.7392	.8402	1.1576
4	1.5364	1.2936	.4938	.7316	.7316	.8871	1.3306
5	1.5893	1.3904	.9145	.8779	.905	.9145	1.4632
6	1.5927	1.5089	1.0059	1.0974	.9955	.9955	1.5043
7	1.5261	1.6575	1.1888		1.4022	1.4746	1.7528
8	1.3565	1.4746	1.5546		1.2887	1.3108	1.7635
9	1.2289	1.4746	.9145		1.3108	1.2955	1.2289
10	1.1336	1.2146	1.1222		1.2289	1.2631	1.1336
19	.0366	.0732	.037	.037	.0554	.037	.0373
20	.0366	.0732	.037	.037	.056	.0366	.0373
21	.0373	.0747	.037	.037	.056	.037	.037
22	.0373	.0754	.0373	.0373	.0554	.0373	.0373
23	.037	.0754	.0373	.0373	.056	.0373	.0373
24	.1206	.0377	.0747	.0373	.0377	.0566	.037
Max	1.5927	1.6575	1.5546	1.0974	1.4022	1.4746	1.7635
Min	.0366	.0377	.037	.037	.0377	.0366	.037
Avg	.9003	.8261	.6108	.3727	.6387	.6862	.8199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 203 / 11 KV DUDHANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0373	.0377	.0373	.0377
2	.0373	.0373	.0373	.037	.0373	.0373	.0373
3	.037	.037	.0373	.037	.0373	.0373	.0373
4	.037	.037	.0373	.037	.0373	.0377	.0373
11	.3658	.823	.4207		.7023	.3696	.3142
12	.439		.4572		.823	.7316	.3391
13	.5121	.823	.4938		.763	.6783	
14	.5487	.823	.5487		.6962	.6706	
15	.6401	.7682	.5853		.6962	.6882	
16	.695		.6584	.5487	.6882	.6882	
17	.7133		.695	.823	.7373	.583	
18	.7133		.7316	.4938	.5735	.5506	
19	.0366	.037	.037	.037	.0366	.0366	.037
20	.037	.037	.037	.037	.0366	.037	.0373
21	.037	.0373	.0373	.037	.037	.0366	.0373
22	.0373	.0373	.0373	.0373	.0373	.0373	.0377
23	.0373	.0373	.0373	.0373	.0377	.0373	.0377
24	.1206	.0373	.0373	.0373	.0377	.0377	.0377
Max	.7133	.823	.7316	.823	.823	.7316	.3391
Min	.0366	.037	.037	.037	.0366	.0366	.037
Avg	.2823	.2578	.2757	.1721	.3362	.2962	.0856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 205 / Kallappawadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.3734	.3361	.2801	.3326	.5175	.2641
2	1.1203	.5601	.3361	.3174	.3361	.5853	.2263
3	1.1458	.6468	.2957	.3734	.3658	.5487	.2641
4	1.2567	.7762	.3658	.499	.543	.5087	.2641
5	1.2803	.961	.4938	.5544	.763	.5365	.2987
6	1.3535		.695	.7682	.8848	.6226	.3361
7	1.4632	1.1888	1.1888		1.0159	1.1469	.3258
8	1.6461	1.3535	1.4632		1.4251	1.2146	.543
9	1.1765	1.1888	.905		.9717	1.2308	.964
10		.7316	.6878		.703	.8421	.964
19	.037		.037	.037	.0732	.0366	.037
20	.037	.0554	.037	.037	.0732	.0732	.0373
21	.0373	.0554	.037	.037	.0747	.0739	.0373
22	.0373	.056	.0373	.0373	.0747	.0747	.0373
23	.0373	.056	.0373	.0373	.0747	.0747	.0377
24	.0747	.0373	.056	.0373	.0373	.0739	.0747
Max	1.6461	1.3535	1.4632	.7682	1.4251	1.2308	.964
Min	.037	.0373	.037	.037	.0373	.0366	.037
Avg	.7807	.5743	.4381	.2513	.4843	.5100	.2945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 206 / 11KV DUDHANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 207 / Sinnur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 201 / ALAGI MIX AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8951	1.0059	.9831	1.1736	1.1336	1.1069	.1143
2	.8951	1.0059	.9831	1.2548	1.1336	1.1523	.1143
3	.9686	.9945	1.2289	1.2548	1.1469	1.1523	.1143
4	1.0883	1.0059	1.2431	1.3413	1.1603	1.1523	.1143
5	1.1203	1.1022	1.326	1.3413	1.2574	1.1843	.1143
6	1.1523	1.1469	1.326	1.5089	1.2431	1.4255	
7	1.1523	1.2955	1.5089	1.491	1.3413	1.4746	
8	1.3108	1.4746	1.5089	1.6095	1.5089	1.4746	
9	1.326	1.4746	1.5089	1.6598	1.5927	1.4746	
10	1.326	1.3108	1.5089	1.4918	1.5089	1.4746	
11							1.2289
12							1.4746
14							1.6575
15							1.6575
16					1.873		1.8233
17					1.8564		1.8442
18					1.7404		1.8442
20	.0953	.1143	.1334	.0953	.1905	.1334	.1143
21	.0953	.1143	.1334	.0953	.1905	.1334	.1143
22	.0953	.1143	.1524	.0953	.1334	.1143	.1143
23	.0829	.0953	.1524	.0953	.1143	.1143	.1143
24	.1334	.0953	.0953	.1524	.0953	.1143	.1143
Max	1.326	1.4746	1.5089	1.6598	1.873	1.4746	1.8442
Min	.0829	.0953	.0953	.0953	.0953	.1143	.1143
Avg	.7825	.8234	.9195	.9774	1.0678	.9121	.7455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 202 / GUDDDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8025	.663	.6401	.8288	.6554	.703	.0572
2	.8025	.7287	.6401	.8288	.6554	.703	.0572
3	.8749	.7287	.8192	.8619	.6554	.703	.0572
4	.8749	.7287	.8097	.8718	.663	.703	.0572
5	1.0829	.8192	.9717	.8886	.7459	.7499	.0572
6	.9061	.8288	.9717	.9389	.8192	.8322	
7	.933	.9012	1.065	.9389	.9221	.9667	
8	.9442	.9717	1.065	1.0774	1.065	.9667	
9	.9602	1.1603	1.1469	1.1437	1.0774	.9667	
10	1.0279	1.1603	1.1469	1.1469	1.0774	.7865	
11							.8002
12							.8002
13							1.0402
14							1.0402
15							1.0526
16							1.065
17							1.1469
18							1.1469
20	.0953		.0572	.0953	.0762	.0762	.0572
21	.0953		.0572	.0953	.0762	.0762	.0572
22	.0953		.0572	.0953	.0762	.0762	.0572
23	.0953		.0572	.0953	.0762	.0572	.0572
24	.0572	.0953	.0953	.0572	.0953	.0762	.0572
Max	1.0829	1.1603	1.1469	1.1469	1.0774	.9667	1.1469
Min	.0572	.0953	.0572	.0572	.0762	.0572	.0572
Avg	.6432	.7987	.6400	.6643	.5824	.5628	.4813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 203 / GUDDWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2801	.2801	.3361	.2801	.2987	.2987
2	.3734	.2801	.2801	.3734	.2801	.2987	.2987
3	.3734	.2801	.3734	.3734	.2801	.2987	.2987
4	.3734	.2801	.4108	.4108	.2801	.2987	.2987
5	.4481	.3734	.4108	.4481	.3734	.3734	.4108
9	.2801	.2801	.1494	.4108	.1867	.1867	.1867
10	.1867	.2801	.1494	.1867	.1867	.1494	.1867
11	.1867	.1867	.1494	.1867	.1307	.112	.1867
12	.1867	.1867	.1494	.1867	.1307	.112	.1867
13	.1867	.1867	.1494	.1867	.112	.0934	
14		.1867	.1494	.1867	.112	.0934	.1867
15		.1867		.1867	.112	.0934	.1867
16	.1867	.1867	.1494	.1867	.112		.1867
17	.1867	.1867	.1494	.1867	.112	.1307	.2614
18	.1867	.1494	.2241	.1867	.1867	.1867	.2614
19	.2801	.1867	.2987	.3734	.3361	.2614	.2614
20	.2801	.1867	.2987	.3734	.3734	.3734	.2801
21	.2801	.2801	.2987	.3734	.3734		.3361
22	.3734	.2801	.3361	.2801	.3361	.2987	.3361
23	.2801	.2801	.3361	.2801	.2987	.2987	.3361
24	.3734	.2801	.2801	.3361	.2801	.2987	.2987
Max	.4481	.3734	.4108	.4481	.3734	.3734	.4108
Min	.1867	.1494	.1494	.1867	.112	.0934	.1867
Avg	.2840	.2383	.2511	.2881	.2321	.2240	.2642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 204 / 11KV ANKALGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.0953	.1524	.0953	.1905	1.1248
2	.1905	.1905	.0953	.1524	.0953	.1905	1.1248
3	.1905	.1905	.0953	.1143	.0953	.1905	1.1561
4	.1905		.0953	.1143	.0953	.1905	1.1717
5	.1905	.1905	.0953	.1143	.0953	.1905	1.1717
6							1.3763
7							1.5729
8							1.6057
9							1.5402
10							1.4746
11	1.7204	1.7204	2.1714	1.8233	1.8404	1.6804	
12		1.7204	2.2298	2.0719	1.9662	1.989	
13	1.9662	1.7604	2.1548	2.0481	1.8023	1.989	
14	2.2119	1.7604	2.1548	1.6004	1.8896	1.9559	
15	2.2634	2.0805	2.2211	1.7604	1.873	1.9227	
16	2.3205	2.1052	2.2131	1.8652	1.873	1.9062	
17	2.3472	2.2672	2.2131	1.8842	1.8564	1.7695	
18	2.1795		2.2377	1.9281	1.7404	1.7532	
20	.1905	.0953	.1524	.0953	.1905	.1905	.0953
21	.1905	.0953	.1524	.0953	.1905	.1905	.0953
22	.1905	.0953	.1524	.0953	.1905	.1905	.0953
23	.1905	.0953	.1524	.0953	.1905	.1905	.0953
24	.0829	.1905	.0953	.1524	.0953	.1905	.1905
Max	2.3472	2.2672	2.2377	2.0719	1.9662	1.989	1.6057
Min	.0829	.0953	.0953	.0953	.0953	.1905	.0953
Avg	1.0385	.9218	1.0432	.8979	.8986	.9373	.9260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 201 / ANDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.724	.7087	.8573	.9259	.7087	.0554
2	.7888	.724	.7362	.9088	.9259	.7011	.0549
3	.7888	.724	.7888	.9088	.9431	.6935	.0554
4	.8573	.724	.7888	.9088	.9431	.7011	.0554
5	.8573	.8145	.7973	.9602	.9431	.8764	.056
6	.8573	.8145	.8063	.9602	.9431	1.0517	.0739
7	.9431	.905	.6935	1.0288	.9945	1.0517	.0739
8	.9431	.9955	.7087	1.0288	.9945	1.0517	.0747
9	.9774	.9955	.8573	1.0802	1.0288	.964	.0739
10	.0934	.056	.0572	.9945	1.0288	.8764	.0747
11	.0543	.0554	.0572	.0572	.056	.056	.7888
12	.0543	.0549	.0572	.0572	.0554	.0554	.7888
13	.0543	.056	.0572		.0554	.0554	.8328
14	.0543	.056	.0572		.0554	.056	.8764
15	.0543	.0554	.0572		.056	.0554	.8764
16	.0514	.056	.0572		.056	.056	.9568
17	.056	.056	.0572		.0554	.056	.7888
18	.0514	.056	.0572		.0554	.0373	.7888
19	.0514	.0554	.0572	.0572	.056	.056	.0934
20	.0514	.056	.0572	.0572	.056	.0554	.0747
21	.056	.056	.0762	.0572	.0554	.0554	.0739
22	.056	.0554	.0762	.0572	.056	.0739	.0739
23	.056	.056	.0762	.0572	.056	.0739	.0747
24	.7545	.724	.7011	.0762	.0572	.724	.0747
Max	.9774	.9955	.8573	1.0802	1.0288	1.0517	.9568
Min	.0514	.0549	.0572	.0572	.0554	.0373	.0549
Avg	.3896	.3719	.3519	.5618	.4355	.4226	.3255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 202 / SANGMESHVAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0934	.0934	.0762	.0762	.0924	1.2269
2	.0762	.0905	.0934	.0762	.0572	.0934	1.3146
3	.0762	.0934	.0934	.0762	.0572	.0934	1.3146
4	.0762	.0934	.0924	.0762	.0572	.0934	1.3672
5	.0572	.0905	.0934	.0762	.0572	.0934	1.4022
6	.0572	.0934	.056	.0762	.0762	.0934	1.4022
7		.0934	.056	.0762	.0762	.0934	1.4737
8		.0934	.0554	.0762	.0572	.0934	1.5947
9		.0934	.0572	.0762	.0572	.0934	1.5947
10	.0572	.0924	.0572	.0762	.0572	.0934	1.6832
11	1.267	1.3146	1.3717	1.3375	1.5775	1.4022	.0747
12	1.6289	1.3289	1.4918	1.3375	1.5947	1.4899	.0739
13	1.6289	1.382	1.4918		1.5604	1.5424	.0747
14		1.4022	1.4918		1.6651	1.5947	.0747
15	1.6289	1.4022	1.5947		1.6651	1.5775	.0924
16	1.6289	1.4373	1.5947		1.647	1.647	.0924
17	1.6289	1.4737	1.6289		1.6832	1.7002	.0934
18	1.6289	1.5775	1.6632		1.6651	1.6832	.056
19	.0934	.056	.0762	.0762	.0934	.0934	.056
20	.0905	.0554	.0762	.0762	.0934	.0924	.0554
21	.0905	.056	.0762	.0762	.0934	.0924	.0747
22	.0934	.056	.0762	.0762	.0924	.0934	.0747
23	.0934	.0554	.0762	.0762	.0934	.0924	.0934
24	.0953	.0934	.0924	.0953	.0762	.0934	.0934
Max	1.6289	1.5775	1.6632	1.3375	1.6832	1.7002	1.6832
Min	.0572	.0554	.0554	.0762	.0572	.0924	.0554
Avg	.6046	.5257	.5646	.2174	.5929	.5886	.6439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 203 / DEVIKAWATHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.543	.4908	.4973	.5144	.5258	.0373
2	.6001	.543	.5316	.4973	.5487	.5258	.037
3	.6344	.5601	.5258	.5144	.5487	.5258	.0373
4	.6344	.6535	.5316	.5144	.6001	.5201	.037
5	.6344	.724	.5609	.5144	.6001	.5258	.0373
6	.6859	.724	.5548	.6001	.6344	.6068	.0373
7	.6859	.724	.6135	.6001	.6344	.6135	.037
8	.6859		.6201	.6344	.6516	.6135	.037
9	.4287	.7468	.6001	.6516	.6516	.6068	.0373
10	.0373	.0373	.0381	.6516	.6859	.5258	.0373
11	.0373	.037	.0381	.0381	.0373	.0373	.5258
12	.0373	.0373	.0381	.0381	.0373		.6135
13	.0362	.037	.0381		.037	.0373	.6201
14	.0362	.037	.0381		.037	.037	.6935
15	.0362	.0373	.0381		.0373	.0373	.7011
16	.0362	.037	.0381		.0373	.0373	.7442
17	.0373	.037	.0381		.0373	.037	.7011
18	.0373	.0373	.0381	.0381	.0373	.0373	.7087
19	.0373	.0373	.0381	.0381	.037	.037	.0373
20	.0373	.0373	.0381	.0381	.0366	.0373	.037
21	.0373	.0373	.0381	.0381	.0373	.0373	.037
22	.0373		.0381	.0381	.037	.037	.0373
23	.0829	.037	.0381	.0381	.037	.0373	.037
24	.0829	.543	.4382	.0381	.0381	.5316	.0373
Max	.6859	.7468	.6201	.6516	.6859	.6135	.7442
Min	.0362	.037	.0381	.0381	.0366	.037	.037
Avg	.2598	.2838	.2500	.3168	.2746	.2856	.2459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 201 / 11KV KURNUR (MIX AG)
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 202 / 11kv KURNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2096	.1905	.2096	.2286	.2286	.2096
2	.1715	.2096	.2286	.2096	.2286	.2286	.2286
3	.2286	.2858	.2286	.2858	.2477	.2858	.2667
4	.2858	.3429	.2477	.3429	.3239	.3429	.3048
5	.5716	.4191	.3429	.4191	.4191	.4572	.4191
6	.5716	.5373	.5175	.5175	.5716	.5716	.5544
7	.462	.5544	.462		.5906	.5906	.5359
8	.5144	.4572	.462		.4954	.4954	.4066
9	.4191	.4001	.3429		.4001	.381	.3239
10	.3239	.2667	.2477		.2667	.2858	.1905
11	.2477	.1905	.1715		.1905	.2286	.1715
12	.2667	.1905	.1524		.1715	.1715	.1334
13	.2477	.1524	.1334	.1715	.1524	.1524	.0983
14	.2286	.1334	.1334	.1715	.1334	.1524	.1143
15	.2096	.12	.1524	.1524	.1524	.1524	.0953
16	.2667	.1334	.1524	.1524	.1524	.1524	.1143
17	.2477	.12	.2096	.1715	.1715	.1715	.1334
18	.2858	.2507		.2286	.2477	.2477	.2477
19	.381	.4435	.4287	.4763	.4763	.4763	.3841
20	.3429	.4024	.4191	.4382	.4572	.4572	.4024
21	.2858	.3048	.3048	.3239	.3429	.362	.2477
22	.2286	.2477	.3048	.2667	.2858	.2667	.2286
23	.1905	.2286	.2096	.2096	.2286	.2286	.1715
24	.1905	.2096	.1905	.1905	.2096	.1905	.2096
Max	.5716	.5544	.5175	.5175	.5906	.5906	.5544
Min	.1715	.12	.1334	.1524	.1334	.1524	.0953
Avg	.3058	.2838	.271	.2743	.2977	.3032	.2580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 203 / 11 KV Badole Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 201 / 11 KV AKKALKOT URBAN

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.2323	1.2803		1.1888		
2	1.1706	1.2136	1.2803		1.1888		
3	1.1706	1.2136	1.2437		1.2071		
4	1.1888	1.2323	1.262		1.2437		
5	1.2437	1.2696	1.2437		1.2803		
6	1.3352	1.3256	1.2803		1.3169		
7	1.4083	1.4003	1.3717		1.3717		
8	1.39	1.4003	1.39		1.3535		
9	1.363	1.363	1.2986				
10	1.3443						
11	1.3256						
12	1.3443	.7468					
13	1.4003	1.307					
14	1.4003	1.3717					
15	1.4003	1.3535					
16	1.4003	1.3535					
17	1.4937			1.4266	1.4266	1.2986	1.2803
18	1.4632			1.5364	1.4815	1.3535	1.3717
19	1.6461			1.957	1.9753	1.829	1.7741
20	1.7924			1.957	1.957	1.829	1.829
21	1.7177			1.829	1.7558	1.7375	1.701
22	1.5364			1.7558	1.5364	1.4998	1.6461
23	1.4083			1.5546	1.39	1.3352	1.39
24	1.1888	1.251	1.3169		1.2437	1.2437	1.2437
Max	1.7924	1.4003	1.39	1.957	1.9753	1.829	1.829
Min	1.1706	.7468	1.2437	1.4266	1.1888	1.2437	1.2437
Avg	1.3876	1.2689	1.2968	1.7166	1.4323	1.5158	1.5295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4854	.5228		.5601		
2	.5487	.4854	.4854		.5601		
3	.5487	.4854	.5228		.5788		
4	.5853	.5041	.5601		.5975		
5	.6401	.5601	.5601		.6161		
6	.7316	.6722	.6535		.6535		
7	.823	.7468	.7282		.7282		
8	.7316	.8402	.7468		.6722		
9	.8775	1.0269	.8962				
10	.8402	.823					
11	.7468	.7316					
12	.8402	.6767					
13	.8962	.6584					
14	.6722	.5304					
15	.7842	.6036					
16	.9149	.6767					
17	.8402			.9335	.5601	.7468	.7282
18	.6161			.7095	.5788	.7468	1.7737
19	.8029			.7468	.7468	.7842	.7655
20	.6908			.8029	.7282	.7655	.8215
21	.7095			.7468	.7095	.8215	.8029
22	.6908			.7095	.6535	.7842	.7468
23	.5788			.6535	.5788	.6722	.6722
24	.567	.5228	.5228		.6161	.5415	.5788
Max	.9149	1.0269	.8962	.9335	.7468	.8215	1.7737
Min	.5487	.4854	.4854	.6535	.5601	.5415	.5788
Avg	.7178	.6488	.6199	.7575	.6336	.7328	.8612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 203 / 11 KV Swami Vihar FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0152	.0152		.0152		
2	.0162		.0152		.0152		
3	.0162	.0152	.0152		.0152		
4	.0162	.0152	.0152		.0152		
5	.0162	.0152	.0152		.0152		
6	.0162	.0152	.0152		.0152		
7	.0162	.0152	.0152		.0152		
8	.0162	.0152	.0305		.0152		
9	.0305	.0305	.0152				
10	.0305	.0305					
11	.0305	.0305					
12	.0305	.0305					
13	.0305	.0152					
14	.0457	.0152					
15	.0457	.0152					
16	.0457	.0152					
17	.0305			.0305	.0305	.0305	.0305
18	.0305			.0305	.0305	.0305	.0457
19				.0305	.0305	.0152	.0305
20	.0305			.0305	.0305	.0152	.0305
21	.0305			.0152	.0152	.0305	.0305
22	.0305			.0152	.0152	.0305	.0152
23	.0152			.0152	.0152	.0152	.0152
24	.0162	.0152	.0152		.0152	.0152	.0152
Max	.0457	.0305	.0305	.0305	.0305	.0305	.0457
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0262	.0190	.0167	.0239	.0190	.0229	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 201 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2241	.2801	.2801	.2801	.2614
2	.2241	.2987	.2614	.2801	.2801		.3361
3	.2614	.3361	.4066	.3361	.3361	.3361	.3361
4	.4481	.3734	.4854	.4108	.4108	.4108	.3734
5	.5601	.5228	.7468	.5975	.6535	.5601	.4854
6	.7095	.6653	.7842	.6535	.8029	.7095	.7023
7	.7392	.6283	.7095	.6535	.7468	.7655	.6653
8	.5975	.5914	.5975		.5601	.5041	.5601
9	.4108	.4481	.4108		.4481	.4108	.8215
10	.3361	.3361	.2801		.2801	.2614	.2614
11	.1867	.2241	.1867		.1867	.1867	.1867
12	.1494		.2241		.1494	.2241	.1867
13	.1867		.2241	.3174	.168	.1867	.1494
14	.1494		.1867	.2801	.1867	.2241	.1494
15	.1867		.1867	.2614	.1867	.1867	.2241
16	.1867		.1867	.2801	.2614	.2241	.2241
17	.2614		.2241	.2987	.2427	.2614	.2241
18	.3361		.3361	.3361	.3174	.3734	.2241
19	.4108		.5228	.4854	.5041	.5228	.5068
20	.4481		.5544	.5041	.4854	.4805	.5228
21	.3734		.4108	.4294	.3921	.4481	.4854
22	.2987		.3361	.3361	.3361	.3734	.3734
23	.2614		.2801	.3361	.2801	.2614	.2987
24	.0829	.2241	.2241		.2801	.2801	.2614
Max	.7392	.6653	.7842	.6535	.8029	.7655	.8215
Min	.0829	.2241	.1867	.2614	.1494	.1867	.1494
Avg	.3346	.4060	.3746	.3931	.3656	.3683	.3675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 202 / 11 KV KINI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.2186
2						1.2186
3						1.2498
4						1.2498
5						1.2811
6						1.3748
7						1.2651
8						1.6762
9						1.5935
10						1.5623
11	1.531	1.8233		1.4998	1.656	
12	1.7924	1.8564		1.7185	1.656	
13	1.7604	1.9204	1.7375	1.6872	1.6248	
14	1.7604	1.8564	1.6766	1.7497	1.7497	
15	1.7284	1.8884	1.829	1.7497	1.6248	
16	1.5043		1.768	1.6248	1.6872	
17	1.6004	1.8564	1.7071	1.6248	1.6872	
18	1.6644	1.7604	1.6309	1.6872	1.7185	
24	.0829					
Max	1.7924	1.9204	1.829	1.7497	1.7497	1.6762
Min	.0829	1.7604	1.6309	1.4998	1.6248	1.2186
Avg	1.4916	1.8517	1.7249	1.6677	1.6755	1.3690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 203 / 11 KV KAZIKANBUS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5401	.5556	.3953	.5053	.6173	.5468	
2	.5401	.6173	.5376	.5201	.6481	.5937	
3	.5401	.679	.6249	.5201	.6481	.5937	
4	.5401	.6874	.7274	.535	.6944	.6249	
5	.5401	.7499	.759	.5944	.7407	.703	
6	.5864	.7499	.9602	.602	.8333	.7811	
7	.6173	1.0623	1.0753	.6401	1.1574	.9998	
8	.9804	1.0311	1.2018		.9259	1.0185	
9	.9922	.9998	1.0753		1.0802	1.0185	
10	.8333	.9374	1.0437		1.0185	.9877	
11							.9061
12							1.0623
18							.8436
24	.0829						
Max	.9922	1.0623	1.2018	.6401	1.1574	1.0185	1.0623
Min	.0829	.5556	.3953	.5053	.6173	.5468	.8436
Avg	.6175	.8070	.8401	.5596	.8364	.7868	.9373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 201 / 11 KV Hattikanbas Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1717	1.6404	1.8404		1.8404	1.7966	
16	.1204			1.0802	.1204		
23					.1372		
24	.1067	.1505	.1219	.1067		.1204	.1204
Max	1.1717	1.6404	1.8404	1.0802	1.8404	1.7966	.1204
Min	.1067	.1505	.1219	.1067	.1204	.1204	.1204
Avg	.4663	.8955	.9812	.5935	.6993	.9585	.1204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 202 / 11 KV Basalegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.3279
16	2.0557	1.8747	1.7604	1.6484	1.6404	1.7966	
24	.0457	.0762	.061	.0457	.0762	.0457	.0762
Max	2.0557	1.8747	1.7604	1.6484	1.6404	1.7966	1.3279
Min	.0457	.0762	.061	.0457	.0762	.0457	.0762
Avg	1.0507	.9755	.9107	.8471	.8583	.9212	.7021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 203 / 11 KV Mirajgi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2614	.2218	.2218	.4108	.2427	.2957	.2218
16	.1478	.1478	.1109	.1848	.1478	.1478	.1478
24	.168	.1848	.1478	.168	.1867	.1848	.1848
Max	.2614	.2218	.2218	.4108	.2427	.2957	.2218
Min	.1478	.1478	.1109	.168	.1478	.1478	.1478
Avg	.1924	.1848	.1602	.2545	.1924	.2094	.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 202 / 11 KV CHAPALGAON MIX AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 203 / 11 KV RLY-STATION AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 204 / 11 KV WATER WORKS AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 205 / 11 KV KARJAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	.0829
24	.0829
Max	.0829
Min	.0829
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 207 / 11 KV KARJAL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.0332
Max	.0332
Min	.0332
Avg	.0332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV AKKALKOT S/S

Feeder No / Name : 407 / Matoshri-I co gen.

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0995
Max	.0995
Min	.0995
Avg	.0995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 201 / 11 KV ANAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6882
Max	.6882
Min	.6882
Avg	.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 202 / 11 KV KOMBADWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.3887
Max	.3887
Min	.3887
Avg	.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 203 / 11 KV KHANDOBACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 204 / 11 KV PASALEWADI MIX AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0886	.081	.0686	.0857	.0867	.0819
2	.0857	.0886	.0819	.0686	.0857	.0876	.0829
3	.0857	.0886	.081	.0686	.0857	.0876	.081
4	.0857	.0886	.0819	.0686	.0857	.0876	.0819
5	.0857	.0886	.0819	.0686	.0857	.0886	.0819
6	.0857	.0886	.0819	.0686	.0857	.0886	.081
7		.0886	.0819	.0686	.0857	.0886	.0819
8	.0857	.0876	.0819	.0686	.0857	.0886	.081
9	.4115	.3856	.426		.4458	.3544	.3768
10	.4207	.4144	.4458	.3944	.443	.3239	.3944
11	.443	.421	.4115	.4287	.4477	.3725	
12	.4252	.3647	.3772	.4458	.4252	.3768	
13	.4252	.4807	.3772	.4115	.4382	.3932	
14	.4607	.4096	.3772	.4115	.4477	.4096	
15	.4252	.3932	.3429	.3772	.4477	.3932	
16	.4075	.3481	.3086	.3601	.3582	.3768	
17	.0876	.0819	.0857	.0686	.0876	.081	
18	.0895	.0829	.0686	.0857	.0876	.0819	.0686
19	.0876	.0819	.0857	.0857	.0895	.0819	.0686
20	.0876	.0829	.0686	.0857	.0895	.0819	.0857
21	.0886	.0829	.0686	.0857	.0876	.0819	.0857
22	.0876	.0819	.0686	.0857	.0886	.081	.0857
23	.0886	.0819	.0686	.0857	.0876	.0819	.0686
24	.4915	.0876	.0819	.0686	.0857	.0886	.0819
Max	.4915	.4807	.4458	.4458	.4477	.4096	.3944
Min	.0857	.0819	.0686	.0686	.0857	.081	.0686
Avg	.2229	.1912	.1798	.1752	.2018	.1819	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 205 / 11 KV ANAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5258	.4915	.5144	.5144	.5258	.4858
2	.4287	.5316	.4915	.5144	.5144	.5316	.4915
3	.5144	.5373	.4915	.5144	.5144	.5316	.4858
4	.6001	.6268	.5668	.5144	.6859	.6135	.5668
5	.9431	.7888	.8192	.6859	.8573	.964	.8097
6	1.0288	1.0745		.7888	1.1145	1.0517	.9831
7	1.0288	1.2269	1.1336	.5144	1.0288	1.2269	1.065
8	1.1145	1.2536	1.065	.5144	1.1145	1.2269	1.065
9	.8573	.8764	.8192		.7716	.8859	.8907
10	.7087	.7459	.6859	.8573	.7087	.8192	.6859
11	.7011	.5304	.6001	.7716	.7164		
12	.7087	.6554	.6001	.7716	.7011	.6554	
13	.7011	.6554	.6001	.6001	.7087	.6226	
14	.7087	.5735	.6001	.4115	.7087		
15	.7087	.5801	.5144	.6001	.7011	.5735	.6001
16	.7973	.5801	.6001	.6001	.7164	.6062	.5144
17	.7973	.6226	.7888	.6001	.7087	.6554	.6001
18		.7373	1.0288	.6001	.985		.823
19	.8859	.9831	1.2003	.8573	.985	.9831	1.0288
20	1.0631	1.0526	1.0288	.9431	.8954	1.065	1.0631
21	.7973	.8097	.8573	.7716	.7087	.8192	.8573
22	.6135	.5407	.7888	.6001	.7164	.6478	.7888
23	.6201	.4915	.6859	.6001	.6135	.4858	.6859
24	.4287	.5258	.4915	.5144	.5144	.5258	.4915
Max	1.1145	1.2536	1.2003	.9431	1.1145	1.2269	1.065
Min	.4287	.4915	.4915	.4115	.5144	.4858	.4858
Avg	.7472	.7302	.7369	.6374	.7585	.7627	.7491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 201 / 11 KV ARDHANARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.0857	.4572		.3048	.3048	.2743
2	.7545	.0857	.4572	.4572	.3048	.3048	.2743
3	.6859	.0857	.4572	.4572	.381	.3048	.3048
4	.7545	.0857	.4572	.4572	.4268	.3048	.3048
5	.7545	.0857	.5335	.4572	.4572	.381	.3048
6	.8573	.0857	.4572	.4572	.4572	.3048	.3048
7	.9259	.0857	.4572	.5335	.4572		
8	.8573	.0857	.4572	.4572	.4572		
9	.8573	.0857	.4572	.4572	.4268		
10	.6859	.5144	.4572	.4572	.3048		
11						.5144	
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171		.0171	.0171	.0171	.0171
24	.4858	.0171	.0171	.0171	.0171	.0171	.0171
Max	.9259	.5144	.5335	.5335	.4572	.5144	.3048
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.5287	.0868	.3156	.2862	.2550	.194	.1559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 202 / 11 KV ARBALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.1886		.0857	.1372	.1543
2	.1372	.1029	.1715	.1372	.1029	.1372	.1372
3	.1372	.1029	.1715	.1543	.1372	.1372	.1372
4	.1372	.1029	.1886	.1543	.1372	.1372	.1372
5	.1372	.1372	.1886	.1715	.1543	.1543	.2058
6	.1372	.1372	.2058	.1886	.2058	.2572	.3086
11	2.21	2.5453	2.4082	2.3777			
12	2.713	2.2253	2.6673	2.652			
13		2.6978	2.7435				
14	2.6216	2.774	2.6978	2.4387			
15	2.6825	2.4996	2.7435	2.5149			
16	2.3167	2.6978	2.4234	2.3624			
17	2.3624	2.4387	2.4387	2.4387	2.3472	2.774	
18	2.6063	2.5911	2.4082	2.3167	2.5606	2.8197	2.6978
19	.1715	.1543	.1715	.1715	.2058	.2058	.1715
20	.1543	.1543	.2058	.1543	.2058	.2058	.2058
21	.1372	.1543	.1715	.1372	.1886	.2058	.2058
22	.1372	.1543	.1372	.1372	.1372	.1715	.1715
23	.12	.1372	.1372	.1372	.1715	.1886	.1372
24	.4915	.12	.0514	.1372	.1372	.1543	.1715
Max	2.713	2.774	2.7435	2.652	2.5606	2.8197	2.6978
Min	.12	.1029	.0514	.1372	.0857	.1372	.1372
Avg	1.0288	1.1015	1.1260	1.0434	.4841	.5490	.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 203 / 11 KV BEGAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5432	1.2193		1.3717	1.2193	1.2803
2	1.5432	1.5432	1.2803	1.5089	1.4327	1.3108	1.3565
3	1.7147	1.5432	1.2955	1.8004	1.4327	1.3717	1.4327
4	1.7147	1.749	1.4022	1.8138	1.4632	1.4937	1.4327
5	1.8519	1.8861	1.6004	1.9814	1.9814	1.6461	1.768
6	2.1948	2.1948	1.829	2.6235	1.9814	1.9966	2.1948
7	3.155	2.8807	2.713	2.7587	2.6978		
8	3.2922	3.2922	.1372	3.094	2.8045		
9	3.0178	.1715	.2134	2.4539	2.652		
10	2.572	.1715	.2743	2.2405	2.332		
17				2.2405			
18					.2401		
19	.2401	.2401	.2743	.3086	.2401	.2401	.2743
20	.2058	.2401	.2915	.2401	.2743	.2572	.2743
21	.1886	.2058	.2401	.2058	.2572	.2572	.2572
22	.1715	.1715	.2401	.1886	.2229	.2058	.2572
23	.1372	.1715	.1715	.1715	.1715	.1715	.2058
24	.4858	.1372	.1372	.1715	.1543	.1543	.1715
Max	3.2922	3.2922	2.713	3.094	2.8045	1.9966	2.1948
Min	.1372	.1372	.1372	.1715	.1543	.1543	.1715
Avg	1.5018	1.1339	.8325	1.4876	1.2770	.8604	.9088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 204 / 11 KV BEGAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3429		.2915	.3086	.3086
2	.3086	.3086	.3429	.3086	.2572	.2915	.3086
3	.2915	.3086	.3772	.3086	.2572	.2915	.2915
4	.3086	.3429	.5144	.2572	.2401	.2915	.3429
5	.3429	.4115	.6516	.4287	.4287	.4801	.4801
6	.583	.6173	.6859	.6859	.6001	.6173	.7373
10	.4973	.4801	.5658	.4287	.4287	.3086	.4458
11	.3429	.3601	.3601			.3086	.3772
12		.3086	.3429	.3601	.2915	.3086	.3601
13	.3601		.3429	.3258	.2915	.2743	.3601
14	.3086			.3086	.2915		.3258
15	.3086	.2915	.3086	.3429	.2743		.3086
16	.3258	.3353	.3601	.3601	.2915	.3086	.3086
17	.3944	.3658	.3772	.3772		.4801	.4115
18	.463	.5487	.4458	.3944	.3772	.4801	.4115
19	.5658	.6859	.6687	.7202	.5487	.7202	.6859
20	.6344	.6859	.6859	.6859	.6173	.7202	.6859
21	.5316	.583	.583	.583	.5487	.583	.6173
22	.4287	.4458	.4115	.4115	.4115	.4973	.4801
23	.3944	.3772	.3429	.3258	.3601	.4287	.4115
24	.3086	.3429	.3086	.2915	.3086	.3258	.3429
Max	.6344	.6859	.6859	.7202	.6173	.7202	.7373
Min	.2915	.2915	.3086	.2572	.2401	.2743	.2915
Avg	.4004	.4268	.4509	.4160	.3745	.4223	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 205 / 11KV YENKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.0686		.0686	.0857
2	.0857	.1029	.0686	.0686	.0686	.0857
3	.0857	.1029	.0686	.0686	.0686	.0857
4	.0857	.1029	.0857	.0686	.0686	.12
5	.0857	.1029	.1029	.1029	.1029	.1372
6	.0857	.1029	.1029	.1372	.1372	.1372
11	1.0059	1.2498	1.1126	1.0669		
12	1.1279	1.3413	1.3565	1.3565		
13	1.4632	1.4327	1.4022			
14	1.4327	1.4175	1.3565	1.4022		
15	1.4175	1.387	1.5432	1.4175		
16	1.4784	1.4327	1.448	1.387		
17	1.3565	1.3717	1.3717	1.326	1.3565	
18	1.3413	1.2498	1.3717	1.3108	1.3717	
19	.1715	.0857	.12	.1029	.1029	
20	.1543	.0857	.12	.12	.12	
21	.1372	.0857	.0857	.0686	.1029	
22	.1372	.0857	.0686	.0686	.0857	
23	.1372	.0686	.0686	.0857	.0857	
24		.1029	.0686	.0686	.0686	.0857
Max	1.4784	1.4327	1.5432	1.4175	1.3717	.1372
Min	.0857	.0686	.0686	.0686	.0686	.0857
Avg	.625	.6007	.5996	.5682	.2720	.1053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 206 / 11 KV KOTHALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0288	1.0059		.9145	.8535
2	1.166	1.0288	.9755	1.0364	.945	.8993
3	1.1317	1.0288	.9755	1.0669	.945	.9145
4	1.0974	1.0631	.9755	1.0517	.9755	.945
5	1.0631	1.0974	.9907	1.0517	.9755	.9907
6	1.0631	1.1317	1.0059	1.0669	.9755	1.0059
7	1.2346	1.2003	1.1888	1.0364	1.1279	
8	1.4403	1.3032	1.2193	1.1584	1.2193	
9	1.4403	1.2003	1.1584	1.1888	1.2193	
10	1.406	.945	1.326	1.0822	1.2193	
19	.12	.1029	.12	.0857	.1029	
20	.1029	.0686	.1029	.0686	.0857	
21	.0857	.0686	.1029	.0514	.0857	
22	.0686	.0514	.0514	.0514	.0686	
23	.0686	.0514	.0514	.0514	.0686	
24	.3239	.0686	.0514	.0343	.0514	.0686
Max	1.4403	1.3032	1.326	1.1888	1.2193	1.0059
Min	.0686	.0514	.0514	.0343	.0514	.0686
Avg	.8133	.7149	.7063	.6721	.6862	.8111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 401 / M/S JAKARAYA SUGAR LTD

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 201 / 11 KV SHINGOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8959	2.5911	3.1703	3.0483	2.5911	2.1338	3.0483
2	2.9721	2.5911	3.0483	2.8959	2.5911	2.1338	3.0483
3	3.0483	2.5911	3.0483	2.7435	2.5911	2.1338	2.8959
4	3.2007	2.7435	3.0483	3.2007	2.7435	2.2862	3.2007
5	2.8959	3.1855	3.1245	3.1245	2.8959	2.4387	3.2007
6	2.7435	3.0483	3.1245	3.2007	3.2769	2.7435	3.2007
7		.4572	.4725	.3353	.4877	.4877	.4877
8		.4877	.4725		.4572	.4572	.4572
9		.4877	.4572		.4268	.4268	.4268
10		.4877	.4572	.3658	.4877	.4572	
11				.3048			
12				.3048			
18			.2591	.3048			2.8197
19	.3658	.4877	.1829	.6097	.2743	.4877	.5182
20	.4268	.4877	.381	.5182	.4572	.4572	.5182
21	.4268	.4572	.4572	.4572	.3658	.4877	.4572
22	.3658	.4877	2.2862	.4268	.4268	.4268	.4268
23	2.5911	2.7435	2.4387	2.7435	2.4387	2.7435	.3658
24	2.5911	2.5911	3.2007	2.5911	2.8654	2.1338	3.0483
Max	3.2007	3.1855	3.2007	3.2007	3.2769	2.7435	3.2007
Min	.3658	.4572	.1829	.3048	.2743	.4268	.3658
Avg	2.0437	1.6204	1.7429	1.5986	1.5861	1.4022	1.7575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 202 / 11 KV ICHAGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1067	.1067	.0457	.1067	.1067	.0914
2	.1067	.1067	.1067	.0762	.1067	.1067	.0914
3	.0914	.1067	.1067	.0762	.1067	.1067	.0914
4	.1372	.1219	.1067	.0762	.1067	.1067	.1219
5	.1372	.1219	.1067	.0457	.1067	.1219	.1219
6	.1372	.1372	.1219	.1219	.1219	.1372	.1372
7	.1067	.1219	.1219	.1341	.1524	.1524	.1524
8	.1219	.1219	.1067	.1372	.1219	.1219	
9	.1067	.1219	.1219	.0914	.1067	.1067	.1067
10	.2896	.1219	.1677	.0914	.1219	.0914	
11	2.1338	1.9357	1.829	1.9662	2.332	1.8138	
12	2.5911	2.5301		2.0119	2.3472	2.4387	
13		2.713	2.2405	2.2862	2.3015	2.1643	
14	2.5149	2.21	2.1033	2.3167	2.0119	2.2862	
15	2.4387	2.2253	2.1338	2.2862	1.829	2.1795	
16	2.332	2.3624	2.0119	2.0271	1.7223	1.6156	
17	2.2862	2.4387	2.0271	1.6766	1.829	2.0119	
18	2.1338	2.4387	1.7528	1.6766	1.6766	2.0119	
19	.1677	.1372	.1677	.1677	.1219	.1524	.1829
20	.1829	.1524	.1677	.1829	.1829	.1829	.1829
21	.1829	.1524	.1677	.1524	.1524	.1829	.1524
22	.1524	.1372	.1372	.1219	.1524	.1524	.1372
23	.1219	.1219	.061	.1067	.1219	.1067	.1219
24	.0914	.1219	.1067	.0762	.1067	.1067	.0762
Max	2.5911	2.713	2.2405	2.3167	2.3472	2.4387	.1829
Min	.0914	.1067	.061	.0457	.1067	.0914	.0762
Avg	.8124	.8694	.6991	.7480	.7519	.7735	.1263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 203 / 11 KV WATWATE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.061	.0457	.0457	.0457	.0457
2	.0572	.0572	.061	.0457	.0457	.0457	.0457
3	.0572	.0572	.061	.0457		.0457	.0457
4	.0572	.0572	.061		.0457	.0457	.0457
5	.0572	.0572	.061	.0457	.0457	.0457	.0457
6	.0572	.0572	.0762	.0457	.0457	.0457	.0457
7	.0572	.0572	.0762	.0457	.0457	.0457	.0457
8	.0572	.0572	.0762	.0457	.0457	.0457	.061
9	.0572		.0762	.0457	.0457	.0457	.061
10	.0572	.0572	.0762	.0457	.0457	.0457	
11	.8764	.7316	.4572	.6706	.7621	.9145	
12	.8764	.9145	.7011	.8078	.6859	.8383	
13		1.0479	.7316	.7316	.6401	.9145	
14	1.0098	.5716	.823	.6859	.6097	.8383	
15	1.0479	.9526	.884	.6401	.6097	.9907	
16	.9526		.8535	.6401	.6097	1.0669	
17	1.0479	.8002	.9145	.6859	.5335	.6706	
18	.7621	.7621	.7621	.6097	.4572	.6097	
19	.0572	.0762	.0457	.061	.0457	.061	.0457
20	.0572	.0762	.0457	.061	.0457	.061	.0457
21	.0572	.0762	.0457	.061	.0457	.061	.0457
22	.0572	.0762	.0457	.061	.0457	.061	.0457
23	.0572	.0762	.0457	.061	.0457	.061	.0457
24	.0572	.0572	.061	.0457	.0503	.0457	.0457
Max	1.0479	1.0479	.9145	.8078	.7621	1.0669	.061
Min	.0572	.0572	.0457	.0457	.0457	.0457	.0457
Avg	.3256	.3061	.2959	.2710	.2434	.3188	.0477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 204 / 11 KV WIRWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.3717	1.2193	1.1431	1.3413	1.2193	1.3717
2	1.5242	1.3717	1.2955	1.2193	1.3413	1.2193	1.448
3	1.4289	1.5242	1.3717	1.5242	1.3413	1.2193	1.5242
4	1.8099	1.5242	1.5242	1.829	1.3717	1.448	1.5242
5	1.9052	1.829	1.6004	2.1338	1.829	1.6766	1.6004
6	3.4294	2.2253	1.7071	2.4387	2.0576		1.6766
7	3.2388	2.7435	2.21	2.8654	2.4387	2.21	2.1338
8	3.5246	2.7435	2.7435	2.8654	2.4387	2.4387	2.4387
9	3.2388	2.5911	2.8959	2.4387	2.4387	2.4387	2.21
10	3.2388	2.5911	2.7435	1.9814	2.4387	1.9814	
11				.1524			
12				.0762			
18			.0762				
19	.0953	.0762	.0762	.0762	.0762	.0762	.0762
20	.0953	.0762	.0762	.0762	.0762	.0914	.0762
21	.0953	.0762	.0762	.0762	.0762	.0914	.0762
22	.0953	.0762	.0762	.0762	.0762	.0914	.0762
23	.0953	.0762	.0762	.0762	.0762	.0914	.0762
24	.9717	.0838	.0762	1.0669	.0762	.0762	.0762
Max	3.5246	2.7435	2.8959	2.8654	2.4387	2.4387	2.4387
Min	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.6206	1.3113	1.1673	1.2286	1.2184	1.0913	1.0923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 205 / 11 KV KAMATI BK. GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.4572	.3963	.3048	.4268	.4268	.3353
2	.2743	.4268	.4268	.3353	.4268	.4268	.3353
3	.2743	.4268	.4572	.381	.4268	.4268	.3658
4	.3353	.4572	.4877	.4572	.4572	.4572	.3963
5	.3963	.5182	.5487	.5335	.5335	.5182	.5182
6	.4115	.6097	.6097	.6249	.6097	.5792	.6097
7	.6706	.5335	.7164	.4572	.6097	.6097	.6097
8	.5792	.4572	.5182	.7316	.5792	.5335	
9	.503	.4572	.4877	.5487	.5182	.4572	.4572
10	.5335	.4877	.5335	.3658	.3658	.503	.4572
11	.442	.4115	.5335	.4268	.3963	.4268	.4572
12	.503	.3963	.4877	.381	.381	.3963	.381
13	.5868	.442	.4572	.3658	.3048	.4572	.3353
14	.4572	.381	.4268	.3353	.3048	.4572	.381
15		.4115		.3048	.3048	.4572	.4572
16	.503	.3658	.442	.3353	.3658	.4115	.4572
17	.4877	.3963		.4268	.3963	.4572	
18	.5335	.4268	.5335	.4877	.4572	.5182	.5335
19	.6097	.6859	.6554	.6859	.5335	.6554	.6706
20	.6706	.7468	.6401	.6859	.6706	.7926	.6097
21	.6706	.6097	.4572	.6097	.5182	.7011	.5335
22	.4877	.4268	.4572	.5182	.4877	.4877	.4572
23	.4572	.3963	.3048	.4572	.4877	.4572	.4268
24	.2439	.4572	.4359	.2743	.4268	.4268	.3353
Max	.6706	.7468	.7164	.7316	.6706	.7926	.6706
Min	.2439	.3658	.3048	.2743	.3048	.3963	.3353
Avg	.4735	.4744	.5006	.4598	.4579	.5017	.4600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 206 / 11 KV HARALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1524	.2286	.1524	.1524	.1829	.2286
2	.1677	.1524	.2286	.1524	.1524	.1829	.2286
3	.1677	.1524	.2439	.1829	.1524	.1829	.2439
4	.1981	.1524	.2591	.1524	.1524	.1829	.2439
5	.2134	.2134	.2743	.1524	.2134	.2134	.2439
6	.2743	.2591	.2896	.2591	.3048	.2743	.2591
7	.2439	.3506	.3353	.1524	.3048	.3048	.3201
8	.2286	.3506					
9	.2134	.2286					
10	.2439	.2134					
11	2.1186	2.1795	2.1033	2.21	2.1338	2.1338	
12		2.3777	2.0424	2.2862	2.2862	2.4082	
13	2.21	2.1033	2.3624	2.2558	2.21	2.3167	
14	2.3472	2.3015	2.3167	2.1643	2.1795	2.4387	
15	2.4387	2.3167	2.3015	2.1338	2.0576	1.9814	
16	2.3624	2.332	2.2253	2.0271	1.9814	2.1338	
17	2.3624	2.3167	2.2862	2.0424	1.829	2.0271	
18	2.1338	2.3624	2.2253	1.829	1.6766	1.9052	
19	.2591	.2439	.2286	.2286	.1524	.2439	.3506
20	.2591	.2743	.2286	.2591	.2439	1.1584	.3353
21	.2286	.2591	.2286	.2439	.1829	.2591	.2591
22	.1981	.2439	.2134	.2134	.2439	.2591	.2439
23	.1524	.2286	.2134	.1981	.2134	.2439	.2134
24	.4858	.1524	.2134	.1829	.1524	.1829	.2286
Max	2.4387	2.3777	2.3624	2.2862	2.2862	2.4387	.3506
Min	.1524	.1524	.2134	.1524	.1524	.1829	.2134
Avg	.8568	.9132	1.0023	.9276	.9036	1.0103	.2615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 207 / 11 KV DADPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0669	1.2955	1.6766	1.6766	1.5242	1.3717
2	1.0669	1.0669	1.3717	1.3717	1.6766	1.5242	1.3717
3	1.2193	1.2193	1.6766	1.5242	1.6766	1.5242	1.6766
4	1.2955	1.2193	1.829	1.6004	1.7528	1.6004	1.829
5	1.3717	1.5242	1.9052	2.1338	1.9052	1.7985	1.9814
6	2.0119	1.9814	2.0576	2.1186	2.1338	1.9509	2.0119
7	2.6216	2.5149	2.6063	1.829	2.8197	2.6216	2.5606
8	2.8502	2.1338	2.6673	2.7435	2.7435	***	2.6368
9	2.3929	2.5911	2.5911	2.5758	2.7435	2.5911	2.4387
10	2.3624	2.3929	2.1338	2.3777	2.3015	2.3929	
18			.0762				
19	.2591	.2743	.2591	.2591	.1341	.2743	.2286
20	.2591	.2591	.2591	.2591	.2591	.2591	.2591
21	.2439	.2439	.1524	.2134	.2134	.2439	.2134
22	.1981	.1829	.1981	.1829	.1981	.2743	.1829
23	.1524	.1677	.1524	.1829	.1981	.1829	.1524
24	.3239	.1524	.1524	1.1126	.1829	.1829	.1677
Max	2.8502	2.5911	2.6673	2.7435	2.8197	21.0639	2.6368
Min	.1524	.1524	.0762	.1829	.1341	.1829	.1524
Avg	1.2405	1.1869	1.2579	1.3851	1.4135	2.5006	1.2722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 201 / 11 KV LAMBOTI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
9		2.934
10		2.7854
24	.4858	
Max	.4858	2.934
Min	.4858	2.7854
Avg	.4858	2.8597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 203 / 11 KV SAWALESHWAR
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
12		3.834
24	.4858	
Max	.4858	3.834
Min	.4858	3.834
Avg	.4858	3.834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 207 / 11KV TOLL PLAZA

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
1	.0528
2	.0509
3	.0547
4	.0566
5	.0547
6	.0472
7	.0207
8	.0207
24	.0547
Max	.0566
Min	.0207
Avg	.0459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 201 / 11 KV ANAGAR.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	1.9909	
2	2.7149	
3	3.2579	
4	3.4389	
5	3.3484	
6	3.6199	
7	3.9819	
8	3.8009	
9	3.9819	
10	4.5249	
16	.2715	
17	.2715	
18	.2715	
19	.543	
20	.5487	
21	.543	
22	.362	
23	.362	
24	.9717	1.7556
Max	4.5249	1.7556
Min	.2715	1.7556
Avg	2.0424	1.7556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 202 / 11 KV NARKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 203 / 11 KV WADWAL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.081
Max	.081
Min	.081
Avg	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 204 / 11 KV D.BABHULGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 205 / 11 KV MOHOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	1.267	
2	1.267	
3	1.448	
4	1.6289	
5	1.8099	
6	2.1719	
7	2.4434	
8	2.1719	
9	1.8099	
10	1.8099	
11	1.6289	
12	1.6289	
13	1.3575	
14	1.3575	
15	1.3575	
16	1.9004	
17	1.9909	
18	1.9909	
19	2.2624	
20	2.2624	
21	2.2624	
22	1.8099	
23	1.448	
24	.3353	1.448
Max	2.4434	1.448
Min	.3353	1.448
Avg	1.7259	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 206 / MOHOL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	.3258
2	.2911
3	.2896
4	.1448
11	.6335
12	1.5746
13	1.3575
14	1.3432
17	1.1765
18	.6335
19	.2743
20	.2715
21	.2715
22	.181
23	.181
24	.3248
Max	1.5746
Min	.1448
Avg	.5796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 201 / 11 KV PAPRI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.3725
Max	.3725
Min	.3725
Avg	.3725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 202 / 11 KV ASHTI LAKE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 203 / 11 KV KHANDALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.421
Max	.421
Min	.421
Avg	.421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 205 / 11 KV PAPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1677
Max	.1677
Min	.1677
Avg	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 206 / 11 KV DINAKAR KACHARE

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 207 / 11 KV YEWATI NALA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4915
Max	.4915
Min	.4915
Avg	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 209 / 11 KV DONGARE

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.2515
Max	.2515
Min	.2515
Avg	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 210 / 11 KV HARITKRANTI
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 201 / 11 KV KONHARI PAPRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4294		3.0864	2.7435	3.4294	1.8861	2.572
2	3.4294		3.0864	2.6578	3.4294	1.8861	2.6578
3	3.4294		2.915	2.6749	3.4294	2.0576	2.6578
4	3.4294		3.0007	2.9492	3.4294	2.0576	2.7435
5	3.4294		2.915	2.9835	3.4294	2.0576	3.0007
6	3.4294		3.0864	3.0864	3.4294	2.572	3.0864
7	3.4294		3.2579	3.0864	3.4294	3.0864	3.0864
8	3.4294		3.4294	3.0864	3.4294	3.3436	3.0864
9	3.4294	3.0007	3.4294	3.0864	3.4294	3.0864	3.4294
10		2.4863	3.2579	3.4294	3.0007	2.915	3.4294
19	3.0864	3.4294	2.8807	3.4294	2.7435	2.915	3.4294
20	3.0864	2.8292	2.9664	3.4294	2.915	3.0007	3.4294
21	2.915	2.6578	2.8121	3.4294	2.7435	3.0864	3.4294
22	2.7435	2.6578	.5144	3.4294	2.7435	2.7435	3.4294
23	2.572	2.572	.5144	3.4294	2.915	2.6578	3.4294
24	.4915		2.572	.5144	3.4294	2.572	2.4006
Max	3.4294	3.4294	3.4294	3.4294	3.4294	3.3436	3.4294
Min	.4915	2.4863	.5144	.5144	2.7435	1.8861	2.4006
Avg	3.0506	2.8047	2.7328	2.9653	3.2097	2.6202	3.0811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 202 / 11 KV PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5144	.5144	.5144	.5144
2	.5144	.5144	.5144	.5144	.5144	.5144	.5144
3	.5144	.5144	.5144	.5144	.5144	.5144	.5144
4	.5144	.5144	.5144	.5144	.5144	.5144	.5144
5	.5144	.5144	.5144	.5144	.5144	.5144	.5144
11	3.4294	3.4294	3.0864	1.7147	2.915	3.4294	3.2579
12		3.4294	3.4294	3.2579	3.4294	3.4294	
13	3.2579	2.7435	3.4294	3.2579	3.3436	3.4294	
14	3.6008	2.7435	3.4294	3.2579	3.3436	3.4294	
15	3.6008	2.6578	3.4294	3.2579	3.4294	3.4294	
16	3.4294	2.572	3.4294	3.6008	3.4294	3.4294	
17	3.1722	2.6578	2.7435	3.6008	3.6008	3.4122	
18	3.0864	2.572	3.4294		3.0864	3.0864	
19	.5144	.5144	.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144		.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.4858	.5144	.5144	.5144	.5144	.5144	.5144
Max	3.6008	3.4294	3.4294	3.6008	3.6008	3.4294	3.2579
Min	.4858	.5144	.5144	.5144	.5144	.5144	.5144
Avg	1.6226	1.4981	1.6876	1.5337	1.7623	1.7228	.7430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 203 / 11 KV PENUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5144	.5144		.5144
2	.5144	.5144	.5144	.5144	.5144	.5144	.5144
3	.5144	.5144	.5144	.5144	.5144	.5144	.5144
4	.5144	.5144	.5144	.5144	.5144	.5144	.5144
5	.5144	.5144	.5144	.5144	.5144	.5144	.5144
11	3.858	3.858	3.2579	2.0576	3.858	3.4294	3.6008
12	3.6866	3.6866	3.4294	4.1152	4.1152	3.6008	
13	3.9438	3.7723	3.4294	3.9438	4.0295	3.6008	
14	3.6866	3.6008	3.6008	3.7723	3.858	3.6008	
15	3.4294	3.6008	3.6008	3.4294	3.858	3.6008	
16	3.5151	3.5151	3.6008	3.5151	3.6866	3.6008	
17	3.3436	3.7723	3.5837		3.1722	3.4294	
18	3.4294	3.4294	3.4294		3.5151	3.3608	
19	.5144	.5144	.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Max	3.9438	3.858	3.6008	4.1152	4.1152	3.6008	3.6008
Min	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Avg	1.8185	1.8365	1.7679	1.5583	1.8816	1.8538	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 204 / 11 KV KHAWANI SAROLE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857		.0857
2		.0857	.0857		.0857
3		.0857	.0857		.0857
4		.0857	.0857		.0857
5		.0857	.0857		.0857
6		.0857	.0857		.0857
7		.0857	.0857		.0857
8		.0857	.0857		.0857
9		.0857	.0857		
10		.0857		.0857	
11	.0857	.0857		.0857	
12	.0857	.0857		.0857	
13	.0857	.0857		.0857	
14	.0857	.0857		.0857	
15	.0857	.0857		.0686	
16	.0857	.0857		.0857	
17	.0857	.0857		.0857	
18	.0857	.0857		.0857	
19	.0857	.0857		.0857	
20	.0857	.0857		.0857	
21	.0857	.0857		.0857	
22	.0857	.0857		.0857	
23	.0857	.0857		.0857	
24		.0857	.0857		.0857
Max	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0686	.0857
Avg	.0857	.0857	.0857	.0845	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 205 / 11 KV YEWATI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4294	1.7147	3.4294	2.6578	3.4294	2.0576	2.572
2	3.4294	1.8861	3.4294	2.6578	3.4294	2.2291	2.572
3	3.4294	2.0576	3.4294	2.7092	3.4294	2.2291	2.915
4	3.4294	2.2291	3.4294	2.7435	3.4294	2.2291	2.7435
5	3.4294	2.7435	3.4294	3.0864	3.4294	2.572	3.0864
6	3.4294		3.4294	3.0864	3.4294	2.915	3.0864
7	3.4294	2.915	3.4294	3.0864	3.4294	3.0864	3.0864
8	3.4294	3.0007	3.4294	2.915	3.4294	.1029	3.0864
9	3.4294	2.6578	3.4294	3.0864	3.4294	.0857	3.4294
10	3.4294	2.572	3.4294	.3429	2.915	3.2579	3.4294
19	.5144	.5144	.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.4858	.5144	.5144	2.0405	3.4294	.5144	2.4006
Max	3.4294	3.0007	3.4294	3.0864	3.4294	3.2579	3.4294
Min	.4858	.5144	.5144	.3429	.5144	.0857	.5144
Avg	2.3345	1.6575	2.3363	1.9365	2.4863	1.4907	2.1862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 206 / 11 KV PENUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.3429	.2572	.6859	.5144	.3944
2	.6859	.6859	.2572	.2572	.6859	.6859	.3944
3	.6859	.6859	.2572	.3429	.6859	.6859	.4287
4	.6859	.6859	.2572	.4287	.6859	.6859	.4458
5	.6859		.4287	.5144	.6859	.6859	.5144
6	.6859	.6859	.5144	.6859	.6859	.6859	.6859
7	.6859	.6859	.6001	.6859	.6859		.6859
12	.6859	.5144	.463	.6859	.6859	.4801	
13	.6859	.4287	.4287	.6859	.6859	.4973	
14	.6859	.4287	.5144	.6859	.6859	.5487	
15	.6859	.4287	.5487	.6859	.6859	.4973	
16	.6859	.5144	.463	.6859	.6859	.5487	
17	.6859	.4287	.4973	.6859		.4287	.6859
18	.6859	.5144	.5144			.5144	.6859
19	.6859	.6859	.6859	.6859		.6859	.6859
20	.6859	.6859	.6859	.6859		.6859	.6859
21	.6859	.6001	.5144	.6859	.6859	.6859	.6859
22	.6859	.5144	.3429	.6859	.6859	.4801	.6859
23	.6859	.4287	.3429	.6859	.5144	.5144	.5144
24	.6859	.6859	.3429	.3258	3.4294	.6859	.3429
Max	.6859	.6859	.6859	.6859	3.4294	.6859	.6859
Min	.6859	.4287	.2572	.2572	.5144	.4287	.3429
Avg	.6859	.5776	.4501	.5812	.8467	.5893	.5681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 201 / 11 KV ASHTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.1715
2			.1715
3			.1715
4			.1715
5			.1715
8			.2058
9			.1372
10			.1372
11		3.3532	2.1338
12		1.829	3.3532
13		3.2769	3.2007
14		3.0483	
15		3.2007	
19		.1886	
20		.2229	.2743
21		.2058	.2743
22		.2058	.2743
23		.1715	.2743
24	.4915		.1715
Max	.4915	3.3532	3.3532
Min	.4915	.1715	.1372
Avg	.4915	1.5703	.7059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 202 / 11 KV SHETFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4915
Max	.4915
Min	.4915
Avg	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 204 / 11 KV BAIRAGWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			1.6766
2			1.6766
3			1.6766
4			1.829
5			2.0424
6			2.2862
7			2.2558
16		1.829	1.9509
17		2.1338	2.3624
18		2.1795	1.3717
19		2.21	2.21
20		1.9052	2.1491
21		1.9052	1.9814
22		1.7528	1.8442
23		1.6766	1.7985
24	.3277		1.6766
Max	.3277	2.21	2.3624
Min	.3277	1.6766	1.3717
Avg	.3277	1.9490	1.9243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 205 / 11 KV SHETFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1677
Max	.1677
Min	.1677
Avg	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 209 / 11 KV TELANGWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.1372
2			.1372
3			.1372
4			.1543
5			.2058
11		1.4175	1.5699
12			2.332
13		1.8595	2.332
14		2.1643	2.2558
15		2.0729	2.21
16		2.2253	2.21
17		2.3472	2.2862
18		2.1795	1.6118
19		.2058	
20		.2229	.2401
21		.1886	.2401
22		.1543	.2058
23		.1372	.1715
24	.4915		.1372
Max	.4915	2.3472	2.332
Min	.4915	.1372	.1372
Avg	.4915	1.2646	1.0319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV DIKSAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.9945	.8288	.8383
2	1.326		1.1869
3	1.5089	.8288	1.267
4	1.6575	.8192	1.6289
5	2.0119		1.9909
6	2.1548	1.8099	1.9909
7	2.5692	2.2043	2.9864
8	2.4863	2.572	2.8959
9	2.4863	2.572	2.7149
10	2.5692	2.572	2.3282
16			.1696
17			.2543
18			.2572
19			.4287
20			.7716
21			.7716
22			.763
23			.4287
24	.4144	.3277	.2486
Max	2.5692	2.572	2.9864
Min	.4144	.3277	.1696
Avg	1.8345	1.6150	1.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV NARKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	1.3565	1.4937
2	1.6956	1.4937
3	1.8652	1.448
4	2.0119	1.4937
5	2.713	1.9909
6	3.0521	2.2405
7	3.3532	3.3608
8	3.7304	3.94
9	3.8561	4.201
10	3.7304	3.658
24	.8383	.7316
Max	3.8561	4.201
Min	.8383	.7316
Avg	2.5639	2.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV EKURKE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
1	.1677	.1677
2	.1658	.1867
3	.1658	.1696
4	.1658	
11	1.6766	1.4937
12		1.5089
13		2.0119
14		2.1472
24	.1658	.1677
Max	1.6766	2.1472
Min	.1658	.1677
Avg	.4179	.9817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV WALUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3413	1.0174	1.4327
2	1.5261	1.0288	1.6289
3	1.6766	1.0288	1.6118
4	1.8442	1.4022	1.9909
5	2.0119	1.3717	2.6863
6	2.5434	2.1033	2.8959
7	2.8178	2.2291	3.2579
8	3.1855	3.155	3.4389
9	3.0521	3.5056	3.2579
10	2.9835	3.6808	3.0445
16			.1658
17			.1658
18			.2486
19			.181
20			.2629
21			.2801
22			.2686
23			.1791
24	.1658	.3544	.1791
Max	3.1855	3.6808	3.4389
Min	.1658	.3544	.1658
Avg	2.1044	1.8979	1.4304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV BHOPALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
1	.1677
2	.1677
3	.1677
4	.1677
11	2.5987
24	.1658
Max	2.5987
Min	.1658
Avg	.5726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV HINGANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1658	.3391	.181
2	.1658	.3506	.181
3	.1677	.3506	.181
4	.1677		.1829
11	2.0957	2.0576	1.5432
12		2.1672	1.8861
13		1.9662	1.8861
14		2.191	1.8861
15			1.8861
16			1.8861
17			1.7147
18			1.7147
19			.1715
20			.2572
21			.2686
22			.1753
23			.1791
24	.1658	.3467	.181
Max	2.0957	2.191	1.8861
Min	.1658	.3391	.1715
Avg	.4881	1.2211	.9090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 201 / 11 KV OLD KURUL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1543		1.7394
5					1.6404
8					2.6216
9					2.4691
23		.216		.2469	
24	.4915		.1698		.1852
Max	.4915	.216	.1698	.2469	2.6216
Min	.4915	.216	.1543	.2469	.1852
Avg	.4915	.216	.1621	.2469	1.7311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 202 / 11 KV KATEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9488		.1094
8			1.5623		
23		.1406		.1296	
24	.9831		.1406		.1094
Max	.9831	.1406	1.5623	.1296	.1094
Min	.9831	.1406	.1406	.1296	.1094
Avg	.9831	.1406	.8839	.1296	.1094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 203 / 11 KV ANKOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.7716	1.1203	1.2003		.1094
2	.8573			1.1203	1.2003		
3	.8573			1.1203	1.2955		
4	.8621			1.2003	1.3717		
5	1.1145			1.2803	1.5432		
6	1.7147			1.6004	1.5242		
7	2.0576			1.9204	1.9433		
8	2.4006		2.1605	2.3205	2.0576		
9	2.2672			2.2405	2.3148		
10	1.9433			2.1434			
17				.1372	.0972		
18				.1372			1.7604
19				.2058			
20				.2401			
21				.2058			
22				.2058			
23		.1094		.1715		.1107	.16
24	.4858		.108	.128	.1372		.1265
Max	2.4006	.1094	2.1605	2.3205	2.3148	.1107	1.7604
Min	.4858	.1094	.108	.128	.0972	.1107	.1094
Avg	1.3860	.1094	1.0134	.9721	1.3350	.1107	.5391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 204 / 11 KV KURUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3696	.3201	.3772	.3658
2	.3601				.3772	
3	.3772			.4001	.3725	
4	.3772			.4161	.5144	
5	.4801			.4481	.6859	.5544
6	.5658			.4801	.6516	
7	.583			.5601	.583	
8	.583		.5895	.5121	.4877	.4801
9	.6516			.5441	.5144	.5426
10	.664			.6344		
11	.5344			.6001	.5344	
12	.5344			.6001	.502	
13	.4534			.4801	.502	
14				.3887		
15				.4115	.4696	
16				.3772	.4696	
17					.4696	
18				.6001		.5441
19				.7545		
20				.7888		
21				.6859		
22				.503		
23		.3772		.5144		.4161
24	.4801		.3801	.3201	.4115	
Max	.664	.3772	.5895	.7888	.6859	.5544
Min	.3601	.3772	.3696	.3201	.3725	.3658
Avg	.5015	.3772	.4464	.5154	.4952	.4839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 205 / 11 KV NEW KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081		.1389	.176	.1715		1.2346
2	.081			.176	.1715		
3	.1543			.176	.1715		
4	.1715			.208	.2229		
5							1.2346
8							1.9814
9							1.5432
10	.1619						
11	2.5263			2.4863	2.332		
12	2.8826			2.915	2.6882		
13	3.0445			2.915	2.4939		
14				2.572	2.5587		
15				2.572	2.4291		
16				2.7435	2.5263		
17				2.7435	2.5911		
18				2.4863			.192
19				.2572			
20				.2572			
21				.2572			
22				.2575			
23		.108		.2572		.1235	.16
24	.1619		.1543	.176	.2058		.1543
Max	3.0445	.108	.1543	2.915	2.6882	.1235	1.9814
Min	.081	.108	.1389	.176	.1715	.1235	.1543
Avg	1.0294	.108	.1466	1.3129	1.5469	.1235	.9286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 206 / 11 KV SHEJBABHULGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003		1.3546	1.6004			.2286
2	1.2003			1.7604	1.7147		
3	1.7147			1.7924	1.8861		
4	1.9719			1.8564	2.0576		
5	2.572			1.8884	2.0576		
6	2.4291			2.4006	2.2862		
7	2.915			3.0407	3.2388		
8	3.2388		2.8597	3.2007	3.0483		
9	3.1579			3.2808	3.4008		
10	2.5911			2.8292			
17				.3429	.2429		
18				.2915			
19				.3258			
20				.3429			
21				.3429			
22				.2915			
23		.2134		.2572		.2286	2.5606
24	.3239		.2439	.2401	.2572		.2439
Max	3.2388	.2134	2.8597	3.2808	3.4008	.2286	2.5606
Min	.3239	.2134	.2439	.2401	.2429	.2286	.2286
Avg	2.1195	.2134	1.4861	1.4492	2.0190	.2286	1.0110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 207 / 11 KV S.WARWADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1389	.128	.1715		1.0802
2	.1457			.128	.1715		
3	.1715			.1543	.1143		
4	.1943			.16	.2058		
5							1.0494
8							2.0833
9							2.0679
11	2.3482			1.8861	1.749		
12	2.6882			2.4777	2.0729		
13	2.5425			.2591	2.0729		
14				1.9814	2.0081		
15				1.9814	2.1214		
16				2.2672	2.4291		
17				2.2672	2.251		
18				2.2634			.192
19				.2058			
20				.2058			
21				.2058			
22				.2058			
23		.1543		.1717		.1698	.176
24	.4858		.1543	.128	.1717		.1543
Max	2.6882	.1543	.1543	2.4777	2.4291	.1698	2.0833
Min	.1457	.1543	.1389	.128	.1143	.1698	.1543
Avg	1.2252	.1543	.1466	.9487	1.2949	.1698	.9719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 201 / 11 KV CHANDRAMOULI ESTATE SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.5426	.6706	.5144	.6443	.5087	.5935
2	.1753	.5087	.6706	.5144	.6783	.5935	.5868
3	.1753	.5087	.7042	.4287	.6783	.5935	.5087
4	.1753	.5087	.7459	.5144	.6783	.5935	.5144
5	.1753	.4748	.7545	.5868	.6104	.5935	.4191
6	.1753	.4409	.6706	.5935	.6104	.5087	.3429
7	.1753	.4409	.6371	.5935	.5935	.5087	.2572
8	.1753	.4239	.6443	.6443	.6274	.5935	.1715
9	.3506	.4409	.6783	.6226	.6783	.5935	.1715
10	.4239		.7042	.7459	.5935	.6706	.1753
11	.7122	.5087	.7545	.9496		.7545	.2686
12	.7011	.5087	.8383	.8987	.5087	.8288	
13	.6001	.5935	.7545	.8478	.5087	.8048	
14	.5935	.5935	.6859	.8139	.5087	.8048	
15	.5935	.5426	.7042	.6783	.6783	.7545	
16	.5087	.5935	.6706	.5087	.5087	.6706	.1791
17	.5087		.7042	.5087	.5087		.1791
18	.5935		.7042	.5426	.5935	.7042	.2629
19	.6104		.7545	.6104	.5087	.6783	.2629
20	.6104		.7042	.6104	.5087	.6443	.2629
21	.5935		.6706	.6443	.6783	.6706	.2629
22	.5935		.6371	.6443	.5935	.7202	.1753
23	.5765		.6443	.6443	.6783	.7716	.1753
24	.1753	.5765	.6516	.5868	.6104	.5935	.6783
Max	.7122	.5935	.8383	.9496	.6783	.8288	.6783
Min	.1753	.4239	.6371	.4287	.5087	.5087	.1715
Avg	.4228	.5129	.6983	.6353	.5994	.6591	.3224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 202 / 11 KV GOTEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
1		.2401
2		.2058
3		.1886
4		.1886
11		3.2047
16		.2949
17		.3018
18		.3561
19		.4115
20		.3772
21		.3601
22		.3429
23		.3086
24	.4858	.2401
Max	.4858	3.2047
Min	.4858	.1886
Avg	.4858	.5015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 203 / 11 KV WADWAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3391	.3353	.3391	.3391	.373	.2984
2	.3155	.3391	.3429	.3429	.3391	.3391	.3052
3	.3155	.3391	.3429	.3086	.3391	.3391	.3353
4	.3506	.373	.3688	.3086	.3561	.39	.3812
5	.4287	.407	.4641	.3429	.4748	.39	.4191
6	.5487	.5087	.503	.4694	.5596	.3391	.5868
7	.6001	.5426	.5365	.5868	.5426	.39	.663
8	.5487	.4917	.4973	.6274	.5087	.373	.6203
9	.5093	.4578	.4694	.5087	.4239	.3391	.4527
10	.4239	.373	.4024	.5426	.373	.3772	.4835
11	.4239	.3561	.4527	.4578		.3429	.3898
12	.39	.39	.4144	.4239	.3391	.3353	
13	.373	.407	.4144	.407	.373	.373	
14	.373	.373	.3856	.373	.373	.3429	
15	.3391	.373		.373	.373	.373	
16	.407	.373	.3944	.4239	.39	.4191	.4477
17	.39		.4191	.407	.39	.5087	.443
18	.4239		.4578	.4409	.39	.5487	.5144
19	.5596		.5935	.5935	.4748	.6001	.6001
20	.5426		.5087	.5765	.39	.5868	.6135
21	.4748		.4578	.4748	.4239	.5533	.6135
22	.407		.4191	.373	.39	.4287	.5258
23	.373		.4287	.373	.3391	.3772	.4908
24	.3155	.373	.3315	.3856	.373	.3391	.3353
Max	.6001	.5426	.5935	.6274	.5596	.6001	.663
Min	.3155	.3391	.3315	.3086	.3391	.3353	.2984
Avg	.4229	.4010	.4322	.4358	.4033	.4074	.4760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 204 / 11 KV VARDHMAN EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0339	.0343	.0354	.0339	.0339	.0351
2	.0377	.0339	.0351	.0354	.0328	.0339	.0351
3	.0377	.0339	.0354	.0354	.0339	.0339	.0343
4	.0377	.0339	.0354	.0362	.0339	.0339	.0351
5	.0377	.0339	.0343	.0354	.0339	.0339	.0351
6	.0377	.0339	.0343	.0354	.0339	.0339	.0351
7	.0377	.0339	.0343	.0354	.0339	.0339	.0351
8	.0377	.0339	.0343	.0354	.0339	.0339	.0351
9	.0377	.0339	.0343	.0339	.0339	.0339	.0351
10	.0377	.0339	.0351	.0339	.0339	.0351	.0377
11	.0377	.0339	.0343	.0339	.0339	.0351	.0377
12	.0377	.0339	.0343	.0339	.0339	.0351	
13	.0377	.0339	.0343	.0339	.0339	.0351	
14	.0377	.0339	.0351	.0339	.0339	.0358	
15	.0377	.0339	.0343	.0339	.0339	.0351	
16	.0377	.0339	.0343	.0339	.0339	.0351	.0377
17	.0339		.0343	.0339	.0339	.0351	.0377
18	.0339		.0362	.0339	.0339	.0343	.0377
19	.0339		.0351	.0339	.0339	.0351	.0377
20	.0339		.0351	.0339	.0339	.0351	.0377
21	.0339		.0351	.0339	.0339	.0351	.0377
22	.0339		.0351	.0339	.0339	.0362	.0377
23	.0339		.0358	.0339	.0339	.0351	.0377
24	.0377	.0339	.0343	.0351	.0339	.0339	.0335
Max	.0377	.0339	.0362	.0362	.0339	.0362	.0377
Min	.0339	.0339	.0343	.0339	.0328	.0339	.0335
Avg	.0366	.0339	.0348	.0345	.0339	.0346	.0363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 201 / 11 KV BITALE BHAGIRATH

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
23	.2926
24	.2075
Max	.2926
Min	.2075
Avg	.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 202 / 11 KV CHIKHALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	.1478
24	.2926
Max	.2926
Min	.1478
Avg	.2202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 203 / 11 KV BITALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1886
Max	.1886
Min	.1886
Avg	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 204 / 11 KV GHATANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1509
Max	.1509
Min	.1509
Avg	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 205 / 11 KV BANDHARA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1943
Max	.1943
Min	.1943
Avg	.1943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 206 / 11 KV MALIKPETH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.116
Max	.116
Min	.116
Avg	.116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 201 / 11 KV SOUNDANE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
1		.3292
2		.3292
11		1.0059
19		.3696
20		.3696
21		.3696
22		.3658
23		.3696
24	.3239	.3258
Max	.3239	1.0059
Min	.3239	.3258
Avg	.3239	.4260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 202 / 11 KV TAMBOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
1		2.7435
2		2.8045
3		3.3951
4		3.3532
5		3.3532
6		3.3532
7		3.3979
8		3.6549
9		2.9007
10		2.9835
19		.7392
20		.7392
21		.6468
22		.6468
23		.6468
24	.3239	.6283
Max	.3239	3.6549
Min	.3239	.6283
Avg	.3239	2.2492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 203 / 11kv PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2743	.3326
2		.2743	.3326
11		3.2769	1.6766
12		3.4408	
13		3.4736	
14		3.4736	
15		3.4408	
16		3.3753	
17		3.3425	
18		3.2769	
19		.3292	.3696
20			.3696
21			.3696
22			.2772
23			.2772
24	.4915	.2743	.3696
Max	.4915	3.4736	1.6766
Min	.4915	.2743	.2772
Avg	.4915	2.3544	.4861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 204 / 11 KV TAKALI SIKANDAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.065	1.1736
2		1.065	1.1934
3		1.1469	1.2597
4			1.2944
5			1.2955
6			1.326
7			1.4918
8			1.6575
9			1.6194
10			1.4918
19			.3696
20			.3696
21			.2772
22			.2772
23			.2743
24	1.3298	.2195	.2402
Max	1.3298	1.1469	1.6575
Min	1.3298	.2195	.2402
Avg	1.3298	.8741	.9757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 205 / 11 KV TAKALI(S) GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1619
Max	.1619
Min	.1619
Avg	.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 201 / 11 KV BHAMBHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.191	1.9719	2.3243	2.3053	2.2481	2.0576	.381
2	2.21	2.0576	2.4387	2.3624	2.3624	2.1262	.381
3	2.2862	2.1434	2.5911	2.3624	2.5149	2.1434	.4382
4	2.3243	2.0576	2.7054	2.4577	2.6673	2.3834	.5144
5		2.4863	2.8578	2.4958	2.8197	2.4863	.5906
6	2.5339	2.6235	3.0864	2.6673	3.0102	2.6749	.743
7	3.1436	2.915	3.2198	2.8959	2.9721	2.9492	.6859
8	2.8769	3.035	3.2769	3.315	3.3532	3.0521	
9	3.3341	3.0864	2.572	3.4294	3.4675	2.7435	
10	2.8807	2.9664	2.8769	3.1245	2.9321	2.7778	
11							2.8635
12							2.915
13						.2058	
14	.3944	.3429	.3239	.3429	.2058	.2743	
15	.3772	.3772	.3429	.3429	.3086	.3086	
16	.3429		.3429	.362	.3429	.3429	
17	.3601	.4001	.4001	.381	.4458	.3086	
18	.3772	.4001	.5144	.4191	.583	.4191	
19	.4973	.7049	.6097	.5906	.5144	.6287	.6668
20	.583		.6668	.6287	.583	.6668	.743
21	.5487	.5906	.5906	.5906	.6516	.6097	.6287
22	.4973	.4954	.5144	.5144	.5487	.5335	.5525
23	.3944	.4191	.4191	.4572	.4458	.4954	.4954
24	.4191	.3429	.4001	.4001	.4191	.4458	.4191
Max	3.3341	3.0864	3.2769	3.4294	3.4675	3.0521	2.915
Min	.3429	.3429	.3239	.3429	.2058	.2058	.381
Avg	1.4286	1.5482	1.5750	1.5450	1.5903	1.3924	.8679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 202 / 11kv Ashte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1372	.2286	.2286	.2667	.1715	.5716
2	.2477	.1372	.2286	.2286	.2858	.1372	.5716
3	.3048	.1543	.2858	.2477	.3429	.1372	.6097
4	.3429	.1715	.3239	.2858	.4572	.1715	.6097
5	.4763	.2058	.4191	.3429	.5144	.2401	.724
6	.4954	.2401	.4763	.381	.5906	.4115	.8192
7	.4954	.2915	.5335	.5144	.5716	.463	1.0669
8							1.2193
9							1.1622
10							1.0631
11	1.6118	1.7318	1.2574	1.1431	1.2003	1.0631	
12	1.7147	1.749		1.4289	1.2174	1.166	
13	1.749	1.7661	1.6004	1.4098	1.3717	1.2003	
14	1.9376	1.5775	1.5432	1.2765	1.3717	1.2346	
15	1.8861	1.6289	1.4861	1.2574	1.0974	1.1488	
16	1.6289		1.4861		1.2003	1.1145	
17	1.6118	1.6385	1.3146	1.1812	1.1145	1.046	
18	1.3546	1.0479	1.2384	1.2003	.2058	1.1622	
19	.2401	.4191	.381	.3429	.2743	.3048	.4001
20	.2743		.4001	.4382	.2743	.362	.4001
21	.2401	.3239	.3429	.3239	.2058	.3239	.3239
22	.2058	.2858	.2858	.3048	.2058	.2286	.2286
23	.1715	.2858	.2667	.2667	.1715	.1715	.1905
24	.2477	.1715	.2667	.2286	.2667	.1715	.1715
Max	1.9376	1.7661	1.6004	1.4289	1.3717	1.2346	1.2193
Min	.1715	.1372	.2286	.2286	.1715	.1372	.1715
Avg	.8326	.7349	.7183	.6516	.6289	.5919	.6333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 201 / 11 KV KURANWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.1562	.1875	.1943	.2218	.2187	.1943
2	.2187	.1875	.2187	.2267	.2187	.2812	.2267
3	.3125	.25	.2812	.3239	.2812	.3125	.2591
4	.4062	.3437	.3437	.4534	.3125	.3749	.3239
5	.4999	.4687	.4062	.5344	.3906	.4374	.3887
6	.6249	.6562	.703	.7287	.7343	.7499	.6478
7	.7811	.8592	.9374	.9717	.9686	.9374	.9069
8	.9998	.9842	1.0155	1.1336	.9998	1.0155	.664
9	.9842	.9374	1.0623	1.0688	.9998	.9998	.8421
10	.953	.8436	.6874	1.0202	.9686	.9686	.8745
20	.0469	.0625	.0625	.0648	.0625	.0625	.0486
21	.0469	.0625	.0625	.0648	.0625	.0625	.0486
22	.0469	.0469	.0469	.0648	.0469	.0469	.0486
23	.0469	.0469	.0469	.0486	.0469	.0469	.0324
24	.0469	.0312	.0469	.0486	.0469	.0469	.0486
Max	.9998	.9842	1.0623	1.1336	.9998	1.0155	.9069
Min	.0469	.0312	.0469	.0486	.0469	.0469	.0324
Avg	.4135	.3958	.4072	.4632	.4241	.4374	.3703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 202 / 11 KV ASHTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1848	.2218	.2195	.2218	.2218	.2195
2	.2218	.2218	.2218	.2195	.2218	.2218	.2195
3	.2187	.2218	.2957	.2926	.2587	.2587	.2561
4	.2957	.2587	.3326	.3658	.2957	.2957	.2926
5	.3696	.3696	.3696	.4024	.3326	.3696	.3292
6	.4435	.3881	.4435	.439	.3696	.4066	.3658
7	.4805	.4066	.3696	.4024	.4066	.4435	.4024
8	.4066						.2926
9	.2957						
10				.2926			.1829
11				.2195			
12	.1848	.2218	.2587	.2195	.2587		
13	.2218	.1848	.2587	.2195	.2218	.2218	
14	.2218	.1478	.1848	.1829	.2218	.2218	
15	.2587	.1848	.1478	.1829	.1848	.1848	
16	.2587	.1848	.1478	.1829	.1848	.2218	
17	.2218	.2218	.1848	.2195	.2218	.2218	
18	.2587	.2957	.2587	.2561	.2218		
19	.3696	.4066	.3326	.4024	.4435	.4435	.4755
20	.4066	.4435	.4066	.3658	.4066	.3696	.439
21	.3326	.3696	.4435	.3292	.3696	.3326	.3658
22	.2957	.2957	.3696	.2926	.2957	.2957	.3292
23	.2587	.2587	.2957	.2561	.2587	.2587	.2926
24	.2218	.2218	.2218	.2195	.2218	.2218	.2195
Max	.4805	.4435	.4435	.439	.4435	.4435	.4755
Min	.1848	.1478	.1478	.1829	.1848	.1848	.1829
Avg	.2939	.2744	.2883	.2810	.2809	.2895	.3121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 203 / 11 KV MASOBA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.1619	.1619	.1638		.1619	.1311
2	.0972	.1943	.1619	.1638		.1619	.1638
3	.1296	.1943	.1619	.1966		.1943	.1966
4	.1619	.1943	.1943	.2294		.1943	.1966
5	.1619	.2187	.2591	.2622		.1943	
11	2.6882	2.332	2.332	2.4905	2.6235	2.4615	
12	2.753	2.753	2.834	2.8509	2.753	2.7206	2.2611
13	2.915	2.8826	2.915	2.9492	2.8826	2.8502	
14	2.9473	2.9797	2.753	2.982	2.9797		
15	3.0121	2.8502	2.6073	2.9165	2.915		
16	2.982	3.0445	2.7206		2.9473	1.6518	
17	2.7854	2.7854	2.753	.1638	3.0121		
18	2.6558	2.6235	2.8016		2.6558	1.3927	
20	.1619	.2267	.2267		.2267	.1943	.1638
21	.1619	.2267	.2267		.2267	.1943	.1638
22	.1619	.1943	.1943		.2267	.1943	.1638
23	.1619	.1619	.1619		.1943	.1619	.1475
24	.4915	.1943	.1619	.1638		.1943	.0983
Max	3.0121	3.0445	2.915	2.982	3.0121	2.8502	2.2611
Min	.0972	.1619	.1619	.1638	.1943	.1619	.0983
Avg	1.3625	1.3455	1.3126	1.2944	1.9703	.8615	.3686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.2743	.2915	.3258	.2572	
2	.3429	.3772	.2915	.2743	.3429	.2572	.2915
3	.3601	.3944	.2915	.3086	.3601	.2572	.3086
4	.3772	.3772	.3429	.3258	.3772	.3429	.3429
5	.3944	.4115	.3601	.3258	.3944	.3944	.3772
6							.3772
11	2.6406	2.2977	2.4006	2.4348	2.6235	2.2634	
12	2.6578	2.692	2.572	2.7606	2.0576	2.5377	
13	2.7435	2.8292	2.6406	2.7949	2.4863	2.7263	
14	2.6063	2.7435	2.6578	2.7606	2.572	2.8121	
15	2.572	2.7092	2.7092	2.7778	2.7435	2.8635	
16	2.4006	2.7606	2.7435	2.8121	2.8292	2.915	
17	2.0748	2.7949	2.7435	2.5377	2.8292	2.7949	
18	1.3717	1.5775	2.6406	2.2119	2.6578	2.6063	
20	.2743	.3944	.3429	.3258	.4458	.4287	.3772
21	.3086	.3601	.3086	.3429	.3601	.4287	.3601
22	.3086	.2915	.3086	.3086	.3429	.3086	.3429
23	.3086	.2743	.2915	.3601	.2915	.2743	.3258
24	.3772	.3429	.2743	.2743	.3258	.2915	.2915
Max	2.7435	2.8292	2.7435	2.8121	2.8292	2.915	.3772
Min	.2743	.2743	.2743	.2743	.2915	.2572	.2915
Avg	1.2489	1.3317	1.3441	1.3460	1.3536	1.3756	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 203 / 11 KV WAFALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	1.0631	.823	1.1488	1.3032	1.286	1.3375
2	1.5089	1.3717	1.1488	1.3717	1.4575	1.3717	1.406
3	1.6461	1.406	1.3546	1.5432	1.5775	1.3717	1.5432
4	1.9204	1.5432	1.6461	2.0233	1.6461	1.4918	1.8347
5	2.332	2.0233	2.1262	2.2977	1.7833	1.7147	2.2977
6	2.3834	2.4006	2.4863	2.8292	1.8861	2.1605	2.6063
7	2.5206	2.7435	2.7092	3.0864	2.5034	3.1722	3.155
8	2.9492	1.406	2.2119	1.4575	3.1036		3.0864
9	2.9321	1.6804	2.7435	2.5377	3.1379	2.7435	2.332
10	2.7778	2.0233	2.4348	1.749	2.7263	2.2119	2.5034
20	.3772	.583	.3772	.3429	.5658	.5487	.4458
21	.4287	.463	.4287	.3601	.4973	.4458	.463
22	.4458	.4115	.4458	.4115	.4287	.4115	.4458
23	.463	.3772	.4458	.3772	.3601	.3772	.4287
24	.3944	.4458	.4115	.4287	.3944	.3601	.3772
Max	2.9492	2.7435	2.7435	3.0864	3.1379	3.1722	3.155
Min	.3772	.3772	.3772	.3429	.3601	.3601	.3772
Avg	1.6289	1.3294	1.4529	1.4643	1.5581	1.4048	1.6175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 205 / 11 KV DEWADI - WAFAL

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3601	.2743	.3429	.3086	.2058	.2229
2	.3772	.3772	.2915	.3601	.3258	.2058	.2229
3	.3944	.3772	.2915	.3601	.3429	.2572	.2572
4	.3944	.3944	.3086	.3429	.3601	.2915	.2743
5	.4115	.3429	.3258	.3429	.3772	.3086	.3086
6							.3086
7							.3429
8							.3086
9							.2572
10			.2743				.2401
11			.2572			.1886	
12		.2229	.2058	.2229	.1886	.1543	
13		.2058	.1715	.2229	.1543	.1543	
14	.1543	.2058	.1886	.2058		.1543	
15	.1715	.1715	.1886	.2058		.1372	
16	.1886		.1715	.1886	.1372	.1372	
17	.2058	.1715	.1715	.2229	.1886	.1715	
18	.2229	.3086	.3086	.2572	.2058	.2058	
19	.2058	.3772	.3772	.3086	.3601	.3772	.2743
20	.3086	.4115	.3429	.3258	.3944	.3944	.3944
21	.3086	.3429	.3258	.2915	.3258	.3086	.3772
22	.3429	.2743	.3086	.3086	.2743	.2743	.3601
23	.3601	.2401	.3086	.2915	.2401	.2401	.3429
24	.3258	.3429	.2401	.3258	.2915	.2229	.2401
Max	.4115	.4115	.3772	.3601	.3944	.3944	.3944
Min	.1543	.1715	.1715	.1886	.1372	.1372	.2229
Avg	.2958	.3016	.2666	.2848	.2797	.2310	.2958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 201 / 11 KV NANDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 202 / 11 KV GOTEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.2429
Max	.2429
Min	.2429
Avg	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 203 / 11 KV D.BABHULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 201 / 11 KV NEW KOTHALE AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL
DEGA Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9526	.9526	.8383	.0572
2			.9526	.9526	.8383	.0572
3			.9526	.9526	.8383	.0572
4			1.0288	1.0288	1.0288	.0762
5			1.105	1.1241	1.0669	.1143
6			1.2765	1.2955	1.1949	.1143
7			1.6766	1.448	1.5623	
8			1.0288	1.5242	1.6766	
11	2.0957	2.3624				
12	2.2405	2.1719				
15	1.9559					
16	2.4143					
24	.4858		.0754	.0762	.0572	.0678
Max	2.4143	2.3624	1.6766	1.5242	1.6766	.1143
Min	.4858	2.1719	.0754	.0762	.0572	.0572
Avg	1.8384	2.2672	1.0054	1.0394	1.0113	.0777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 202 / 11 KV WAD-DEGOAN AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL
DEGAV Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.1715	.1524	1.6194
2			.1715	.1715	.1524	1.6194
3			.1715	.1715	.1524	1.6194
4			.1715	.1905	.1905	1.7147
5			.3048	.3048	.2858	1.9052
6			.3429	.3239	.2987	2.1529
7						2.8567
8						3.1367
11	2.7435	1.8671				
12	2.1658	2.553				
13	2.9874	2.0454				
14	2.838					
15	1.9559	3.3981				
16		3.5818				
24	.4858		.1698	.1524	.1143	.1017
Max	2.9874	3.5818	.3429	.3239	.2987	3.1367
Min	.4858	1.8671	.1698	.1524	.1143	.1017
Avg	2.1961	2.6891	.2148	.2123	.1924	1.8585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 203 / 11 KV AUNDHI AG (WAD-DEGAV SEPARATED AG FEEDERS HAVING SPECIAL
S.S Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1812	1.1431	1.0479	.2667
2			1.1812	1.1431	1.0479	.2667
3			1.1812	1.1431	1.0479	.2667
4			1.2955	1.2955	1.2955	.3048
5			1.6385	1.6194	1.5623	.381
6			2.1338	1.9433	1.9044	.4191
7			2.4768	2.4006	2.3243	
8			2.7435	2.5911	2.4768	
9	2.4387	2.191				
10		2.1338				
24	.3239		.1543	.2286	.1715	.1865
Max	2.4387	2.191	2.7435	2.5911	2.4768	.4191
Min	.3239	2.1338	.1543	.2286	.1715	.1865
Avg	1.3813	2.1624	1.554	1.5009	1.4309	.2988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 201 / 11 KV JAMGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4801	.5144	.5487	.4458	.5487	.4801
2	.6173	.5487	.583	.6173	.5144	.583	.5487
3	.7545	.583	.7202	.6859	.6859	.6859	.6173
4	.8573	.6516	.7545	.823	.7888	.7888	.7202
5	.9259	.823	.9259	.9259	1.0288	.9259	.8059
6	1.1317	1.0974	1.2689	1.1317	1.2689	1.2689	.9259
7	1.4403	1.4403	1.3375	1.4403	1.3717	1.406	1.3032
8	1.5432	1.4746	1.5432	1.5089	1.4746	1.5604	1.4403
9	1.2689	.9088	1.3889	1.4746	1.406	1.4746	1.406
10	1.2689	1.1317	1.406	1.3717	1.166	1.3032	1.3717
11	.0343	.0343	.0514	.0343	.0343	.0343	
12	.0343	.0343	.0343	.0343	.0343	.0514	
13	.0686	.0343	.0343	.0343	.0343	.0514	
14	.0343	.0343	.0343	.0343	.0343	.0514	
15	.0343	.0343	.0343	.0343	.0343	.0343	
16	.0343	.0343	.0343	.0343	.0343	.0343	
17	.0343	.0343	.0343	.0343	.0343	.0343	
18	.0343	.0343	.0343	.0343	.0343	.0343	
19	.0514	.0514	.0686	.0686	.0514	.0686	.0514
20	.0514	.0686	.0686	.0686	.0514	.0686	.0514
21	.0514	.0514	.0514	.0686	.0514	.0686	.0514
22	.0514	.0343	.0343	.0686	.0343	.0343	.0514
23	.0343	.0343	.0343	.0343	.0343	.0514	.0514
24	.0343	.0343	.0343		.0343	.0343	.0343
Max	1.5432	1.4746	1.5432	1.5089	1.4746	1.5604	1.4403
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4544	.4037	.4594	.4831	.4451	.4665	.6194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 202 / 11 KV KORAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.12	.1372	.1029	.1029	.1029
2	.1029	.1029	.12	.1372	.1029	.1029	.1029
3	.1029	.1029	.1029	.1372	.1372	.12	.12
4	.1029	.1029	.1029	.1543	.1372	.12	.1372
5	.1372	.1029	.1372	.1715	.1372	.1372	.1543
6	.1372	.1372	.1372	.1715	.1715	.1372	.1543
7	.1372	.1372	.1372	.1715	.1715	.1372	.1543
8	.0686	.1372	.1372		.1543	.1543	.1372
9	.0686	.1372	.1372		.0686	.1372	.12
10	.1372	.1372	.1543	.0686	.0857	.1372	.0686
11	2.8807	2.9664	2.3491	2.572	1.3717	2.4006	
12	2.5892	3.8237	3.5665	3.4979	2.9664	3.3608	
13	3.2236	3.8066	3.5151	3.2579	3.2407	3.155	
14	3.4465	3.6351	3.4808	2.9835	3.3951	2.9492	
15	3.4294	3.6694	3.4979	3.0864	3.0693	3.1722	
16	3.5494	3.4294	3.2236	2.915	2.4691	3.1722	
17	3.4979	3.3951	3.2922	2.915	2.3491	3.0178	
18	2.5549	3.0178	2.8635	2.915	2.2291	2.9492	
19	.1372	.1372	.1372	.1372	.1372	.1372	.1372
20	.1543	.1372	.1543	.1372	.1372	.12	.1372
21	.1543	.1372	.1543	.1372	.1372	.12	.1372
22	.1372	.12	.1543	.1372	.12	.1372	.1372
23	.12	.12	.1543	.1372	.1029	.1372	.1372
24	.1029	.12	.1029	.1372	.1372	.1029	.1029
Max	3.5494	3.8237	3.5665	3.4979	3.3951	3.3608	.1543
Min	.0686	.1029	.1029	.0686	.0686	.1029	.0686
Avg	1.1281	1.2389	1.1638	1.1870	.9638	1.0924	.1275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 203 / 11 KV JAMGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0686	.0857	.1029	.0857	.0686
2	.0686	.0686	.0686	.0686	.12	.0686	.0686
3	.0686	.0686	.0686	.0686	.1372	.0686	.1029
4	.1029	.0857	.0857	.1029	.1372	.1029	.1372
5	.12	.12	.1372	.1372	.1715	.1372	.1715
6	.1715	.1886	.1886	.2058	.2058	.1715	.2229
7	.2401	.2572	.2401	.2229	.2401	.2229	.2401
8	.1886	.2058	.1715	.1886	.1543	.2401	.1715
9	.1372	.12	.1029	.1543	.1029	.1543	.1372
10	.1372	.1029	.0686	.12	.1029	.1372	.1029
11	.1029	.0686	.0857	.1029	.0857		.0686
12	.1029	.0857	.0857	.1029	.0857	.1029	.0686
13	.1029	.0686	.0686	.0686	.0686	.0686	.0686
14	.12	.0686	.0857	.0686	.0686	.0857	.1029
15	.12	.1029	.0686	.0686	.0686	.0857	.1029
16	.12	.1029	.0686	.1029	.0686	.0686	.1029
17	.12	.1029	.0857	.1029	.1029	.1029	.1029
18	.1372	.1029	.1029	.12	.1372	.1372	.1029
19	.1886	.2058	.1886	.2401	.2058	.1715	.2229
20	.2229	.2229	.1886	.2058	.2229	.2058	.2401
21	.1715	.1372	.1543	.1715	.2229	.1715	.2058
22	.1372	.12	.1372	.1715	.1715	.1372	.1715
23	.1029	.1029	.1029	.1372	.12	.1029	.1372
24	.1029	.1029	.0857	.0857	.1029	.1029	.1029
Max	.2401	.2572	.2401	.2401	.2401	.2401	.2401
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.1329	.1200	.1129	.1293	.1336	.1275	.1343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 201 / 11 KV MIRI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
1	.415
2	.7922
3	.415
4	.415
5	.4527
6	.4904
10	.2641
11	.2263
12	.3018
13	.2641
14	.2263
15	.2641
16	.2829
17	.2829
18	.2829
19	.2829
20	.2829
21	.2829
22	.2829
23	.2829
24	.415
Max	.7922
Min	.2263
Avg	.3431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 202 / 11 KV MIRI AG (MIRI S.ST,) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	.0943
2	.0943
3	.0943
4	.0943
5	.0943
6	.0943
7	.0943
8	.0943
9	.0943
10	.0943
11	2.1691
12	2.3577
13	2.452
14	2.452
15	2.452
16	2.452
17	2.452
18	2.452
19	.0943
20	.0943
21	.0943
22	.0943
23	.0943
24	.0943
Max	2.452
Min	.0943
Avg	.8645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 203 / 11 KV NEW YENAKI AG(MIRI
S.ST. Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	1.3203
2	1.5089
3	1.6975
4	1.8861
5	2.0748
6	2.2634
7	2.6406
8	3.2065
9	3.3951
10	3.2442
19	.0943
20	.0943
21	.0943
22	.0943
23	.0943
24	.1372
Max	3.3951
Min	.0943
Avg	1.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 201 / 11 KV YAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.3963	.5144	.7202	.4801	.4572	.12
2	1.0288	.4572	.5335	.7621	.6001	.5487	.12
3	1.0631	.5335	.7468	.9945	.6859	.5944	.12
4	1.1145	.5792	1.0669	1.0288	1.0631	.6859	.1067
5	1.2003	.6097	1.2193	1.1831	1.0669	.7468	.1524
6	1.286	.7316	1.2955	1.2346	1.2498	.823	.1677
7	1.3375	1.2193		1.3375	1.2955	1.3108	.2743
8		1.2193	1.4022	1.3565	1.4784	1.4175	
9		.6097		1.3717	1.1736	.6001	
10	1.3717	.6097	.1715	1.2193	.8935	.1715	.3429
11	.061	.1067		.1715	.061		
12	.061	.1219	.1372	.1372	.061	.1715	
13	.0762	.1219	.12	.0686	.061	.1372	
14	.0914	.0914	.12	.0686		.0857	
15	.0762	.0914	.12	.0686		.0857	
16		.0914	.1029	.0686	.061	.1715	
17	.1067	.1372	.1029	.1029	.0914		1.166
18	.1372	.1524	.1372	.1372	.1219		.1372
19	.1981	.1981	.1372	.2229	.1981	.1143	.1372
20	.1524	.1829	.1543	.1886	.1829		.1543
21	.1219		.1372	.1715	.1524	.2058	.1715
22	.1219	.1524	.1372	.1372	.1219	.2058	.1715
23	.1067	.1372	.1715	.1372	.1219	.1715	.2058
24	.1372	.1067	.3086	.1543	.1543	.1067	.1372
Max	1.3717	1.2193	1.4022	1.3717	1.4784	1.4175	1.166
Min	.061	.0914	.1029	.0686	.061	.0857	.1067
Avg	.5099	.3764	.4208	.5435	.5171	.4406	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 202 / BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372	.1543	.1219	.1543	.1372	.1219
2	.1829	.1372	.1543	.1219	.1372	.1543	.1219
3	.1829	.1543	.1543	.1524	.12	.1543	.1524
4	.1829	.1715	.1543	.1524	.1715	.1715	.1219
5	.1829	.2401	.1543	.1524	.2572	.1886	.1219
6	.2134	.2743	.1715	.2134	.2743	.2401	.1524
7	.2134	.2743	.2229	.1524	.2401	.2229	.1981
8		.2401		.2058	.2058	.1715	
9		.1543		.2058	.1715	.1524	.1829
10	.1829	.1372	.1715	.2058	.1524	.1829	.1829
11	.1829	.1372	.1524	.1886	.1372	.1829	
12	.1372	.1543	.1524	.1715	.1372	.1829	
13	.1524	.1715	.1829	.1543	.1543		
14	.1372	.1715	.1829	.1543	.1372	.1524	
15	.1219	.1543	.1829	.1543	.1372	.1524	
16		.1543	.1829	.1715	.1543	.1524	.1372
17	.1524	.1715	.1829	.1886	.1715	.1829	.1524
18	.1829	.1715	.1524	.2058	.1372	.1524	.1524
19	.2058	.2401	.1829	.2743	.2058	.1829	
20	.2058	.2572	.1829	.2572	.2401	.1829	.1829
21		.2401	.1829	.2401	.1886	.1524	.1829
22	.1715	.1715	.1829	.2229	.1886	.1524	.1829
23	.1543	.1372	.1524	.1715	.1715	.1524	.1829
24		.1543	.1543	.1524	.1543	.1372	.1372
Max	.2134	.2743	.2229	.2743	.2743	.2401	.1981
Min	.1219	.1372	.1524	.1219	.12	.1372	.1219
Avg	.1736	.1836	.1703	.1830	.1750	.1693	.1569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 405 / Begumpur Wagholi Mill
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 408 / Kothari Agritec

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 409 / 33 KV SOLAR VISHWAJ ENERGY
PVT Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 704 / 132 KV Loknete SF Cogen
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(NON CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 201 / 11KV Sakal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527			.583	.5487	.5487	.5316
2	.5228			.5487	.5487	.5316	.5144
3	.4715			.5487	.5144	.5316	.5144
4	.5281			.5144	.583	.5144	.4973
5	.5175			.5144	.5487	.5487	.4801
6	.5175			.5487	.5487	.5487	.4458
7	.5228			.583	.583	.5487	.4668
8	.6722			.823	.6859	.5487	.5228
9		.8402				.679	.3841
10		1.0098	1.0562			.8865	.3506
11	.9709	1.086	1.0374			.7545	.3841
12	1.1203	.9997	.9808			.7545	.3243
13		1.0185	1.1431	.9997		.811	.2092
14		.8865	1.0479	1.0751		.7922	.3572
15		.9242		1.094		.7167	.3549
16		.8589		1.0562		.7922	.3384
17	1.0288	.8059		.9709	1.1576	.7468	
18	1.0288	.7545	.8589	.8029	1.0829	.7095	
19	.8745	.6516	.7545				
20	.8573	.583		.7468			
21	.8402	.583		.6516			
22	.8059	.5487					
23	.7373	.5144					
24	.4458			.6173	.6173	.583	.5788
Max	1.1203	1.086	1.1431	1.094	1.1576	.8865	.5788
Min	.4458	.5144	.7545	.5144	.5144	.5144	.2092
Avg	.7175	.8043	.9827	.7458	.6744	.6604	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 202 / 11KV VIDYAPEETH EXP. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075			.1715	.2058	.1715	.1543
2	.1848			.1715	.1886	.1715	.1372
3	.1509			.1543	.1715	.1372	.1372
4	.1494			.1372	.1543	.1372	.12
5	.1109			.1372	.1372	.1029	.1029
6	.0747			.1029	.1372	.1029	.0686
7	.0747			.0686	.1029	.0686	.0739
8	.0754			.1029	.0686	.0686	.0747
9		.1509	.132			.1509	
10		.1886	.1886			.2075	
11	.2241	.2452	.2641			.2452	
12	.3174	.2263	.3206			.2263	.3018
13		.2263	.3395	.2641		.2829	.3395
14		.132	.3206	.2263		.2263	.3018
15		.2263		.2452		.2452	.2829
16		.2263		.1886		.3018	.3206
17	.2401	.1715		.1867		.2427	
18	.2229	.1715	.2614	.1867		.2241	
19	.2058	.1715	.2241				
20	.2058	.1543		.168			
21	.2058	.1372		.1494			
22	.2058	.1372					
23	.1886	.1715					
24	.2058			.2058	.2229	.2229	.1867
Max	.3174	.2452	.3395	.2641	.2229	.3018	.3395
Min	.0747	.132	.132	.0686	.0686	.0686	.0686
Avg	.1806	.1824	.2564	.1686	.1543	.1861	.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 203 / 11 KV Smruti Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413			.5144	.583	.5487	.5487
2	.6036			.5144	.5144	.5144	.5316
3	.5914			.4801	.5487	.5144	.5658
4	.5658			.4801	.5487	.5487	.5658
5	.5544				.583	.5487	.5487
6	.5729			.5144	.583	.5487	.5316
7	.5788			.5316	.583	.583	.583
8	.5415			.5144	.6001	.5144	.6161
9			.6036				.6413
10		.6413	.6036				.6602
11	.6161		.7167				.6602
12	.5975	.679				.6413	.6602
13		.6413	.6979	.6036		.6602	
14		.6036	.7167	.6224		.6413	.6224
15		.7356		.5847		.6602	.6413
16		.7167		.5847		.679	.6224
17	.6344	.6687		.5601	.5788	.6348	
18	.6344	.6516	.6516	.6348	.6348	.6535	
19	.5658	.583	.7167				
20	.6001	.5487		.6535			
21	.6001	.5144		.5658			
22	.6001	.1372					
23	.583	.583					
24	.6001			.5316	.6173	.583	.5975
Max	.6413	.7356	.7167	.6535	.6348	.679	.6602
Min	.5415	.1372	.6036	.4801	.5144	.5144	.5316
Avg	.5934	.5926	.6724	.5557	.5795	.5921	.5998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 204 / 11KV BANG DATA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922			.6516	.7202	.7545	.7202
2	.7392			.6516	.6859	.7716	.703
3	.7392			.583	.6859	.823	.7373
4	.7922			.583	.7202	.823	.703
5	.7842			.6516	.7202	.8402	.7202
6	.7733			.6859	.7545	.823	.7373
7	.8299			.703	.7716	.8402	.6859
8	.6908			.7202	.7716	.6173	.8215
9			.6413			1.0374	
10		.1067	.811			1.1317	
11		.0328	.9054			.6979	
12		.0358	.9054			1.0562	.811
13		.0103	.8865	.9431		.9907	.7922
14		.0328	.8192	.9619		1.0374	.811
15		.0103		.9997		1.0098	.7733
16		.0947		.9808		1.0185	.811
17	.9774	.1543		.9335	1.1203	.9709	
18	.8745	.1372	.8962	.9709	1.0829	.9709	
19	.8916	.1029	.8775				
20	.8573	.1029		.7167			
21	.8573	.1029		.6908			
22	.8059	.1029					
23	.7716	.0857					
24	.7373			.6173	.7545	.7545	.8215
Max	.9774	.1543	.9054	.9997	1.1203	1.1317	.8215
Min	.6908	.0103	.6413	.583	.6859	.6173	.6859
Avg	.8071	.0794	.8428	.7673	.7989	.8931	.7606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 205 / 11KV BPL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527			.8573	1.0974	.9945	.9259
2	.4481			.8745	1.0288		.8573
3	.4066			.8573	1.0288	.9259	.823
4	.415			.8916	.9431	.8573	.7888
5	.3772			.8916	.9259	.8573	.6859
6	.3696			.9259	.8573	.823	.6001
7	.4108			.9259	.6859	.6859	.5601
8	.5281			.8573	.7545	.7888	.7282
9		1.6787	.6413			1.1694	
10		1.0562	.7167			1.1694	
11	1.1203	1.3203	1.0185			1.2449	
12	1.1576	1.0185	1.0562			1.0562	.4527
13		1.0562	1.2071	1.3957		1.3203	.4904
14		.9808	1.2071	1.2637		1.3957	.415
15		.9431		1.1694		.9808	.4338
16		1.2826		1.4712		.8299	.415
17	1.166	.9945		1.3817	1.307	.8962	
18	1.1488	.7716	1.307	1.1949	1.1949	1.0082	
19	.8916	.6173	1.2449				
20	.9088	.583		1.0288			
21	.9602	.5487		1.0829			
22	.9602	.5144					
23	.9945	.7545					
24	.4458			.8573	1.1317	1.0288	1.0829
Max	1.166	1.6787	1.307	1.4712	1.307	1.3957	1.0829
Min	.3696	.5144	.6413	.8573	.6859	.6859	.415
Avg	.7312	.9414	1.0499	1.0545	.9959	1.0018	.6614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 206 / 11KV INDIAN OIL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094			.9259	.9945	.9945	.8916
2	1.1273			.9431	1.0288	1.0288	.9259
3	1.1389			.9945	1.046	1.046	.9602
4	1.2071			.9945	1.0974	1.046	1.0117
5	1.226			1.0288	1.0974	1.0631	1.0631
6	1.226			1.0974	1.166	1.1145	1.1317
7	1.3256			1.1317	1.2003	1.1317	1.3443
8	1.1883			.9259	.8573	1.0631	1.1576
9		1.0164	1.1088			1.0829	
10		1.1283	.8131			1.1946	
11	1.0082	1.2437	1.1523			1.0974	
12	1.0829	1.1827	1.1403			1.1403	.8775
13		1.1317	1.262	.8048		1.0269	.8865
14		.9671	1.1041	.8328		.9882	.823
15		.9145		.8688		1.0679	
16		.9955		.8779		1.1584	.8596
17	1.0631	.9602		.9709	1.0082	1.2323	
18	1.1488	1.0631	.9709	.9335	1.2136	1.0082	
19	1.2517	1.3546	1.3443				
20	1.2174	1.2689		1.3817			
21	1.166	1.2003		1.166			
22	1.0974	1.1317					
23	1.0117	1.0631					
24	1.046			.9259	.9774	.9088	1.0082
Max	1.3256	1.3546	1.3443	1.3817	1.2136	1.2323	1.3443
Min	1.0082	.9145	.8131	.8048	.8573	.9088	.823
Avg	1.1459	1.1081	1.1120	.9885	1.0624	1.0733	.9955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 207 / 11KV AG PAKNI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089			1.406	1.3717	1.3717	.12
2	1.6598			1.4575	1.406	1.5089	.12
3	1.7372			1.5432	1.4403	1.6118	.1372
4	1.8484			1.6289	1.4403	1.8519	.1372
5	1.9959			1.7147	1.5775	1.8861	.1543
6	2.0748			1.8519	1.8861	1.9204	.1715
7	2.3152			2.0233	2.0062	1.9719	.1715
8	2.4272			2.0576	2.2291	2.1262	
9			1.9669			2.0178	
10		1.8364	1.9669			1.8233	
19	.1715	.1715	.1867				
20	.1715	.1715		.2054			
21	.1715	.1543		.2054			
22	.1543	.1372					
23	.1543	.1372					
24	.12			.2058	.1543	.1886	.1494
Max	2.4272	1.8364	1.9669	2.0576	2.2291	2.1262	.1715
Min	.12	.1372	.1867	.2054	.1543	.1886	.12
Avg	1.1793	.4347	1.3735	1.3000	1.5013	1.6617	.1451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 208 / 11kv volant

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5729			.8916	.8573	.7545	.5658
2	.5658			.8573	.823	.7202	.583
3	.5658			.8573	.823	.7202	.5487
4	.6036			.8745	.7202	.6859	.5144
5	.5975			.8573	.6859	.6516	.5144
6	.5914			.823	.6859	.6516	.4801
7	.5975			.823	.6859	.583	.4108
8	.6036			.9431	.7202	.3258	.2614
9	.7545		.5093			.6602	.5093
10	1.0082	.7733	.5093			.6979	.6602
11	1.1203	.7167	1.1317			.7356	.7733
12	.9709	.6224	1.0751			.7545	.6602
13		.6979	.9997	1.0562		.4904	.6413
14		.7733		1.2071		.6413	.3584
15		.679		1.2826		.7733	.5847
16		.7167		1.0562		.5847	.6979
17	.703	.6173			1.0269	.6348	
18	.703	.6001	1.2323	1.0082		.7095	
19	.6687	.6516	1.2323				
20	.6687	.6001		.8775			
21	.6687	.583		.8962			
22	.6859	.583					
23	.703	.5144					
24	.7202			.9259	.8916	.823	.6348
Max	1.1203	.7733	1.2323	1.2826	1.0269	.823	.7733
Min	.5658	.5144	.5093	.823	.6859	.3258	.2614
Avg	.7037	.6521	.9557	.9523	.7920	.6631	.5529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 209 / 11KV AG KONDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1029	.0686	.0686	.583
2				.1029	.0686	.0857	.6516
3				.0857	.0857	.0857	.6859
4				.0857	.0857	.0686	.7545
5				.0857	.0857	.0686	.7888
6				.0857	.0686	.0686	.8573
7				.0857	.0857	.0686	.9896
8							1.1389
9							1.0442
10							.8002
11	1.0269	.8796	.9414			.9619	
12	1.2696	1.1105	1.1203			1.1694	
13		1.0279	1.1105	1.1265		1.3957	
14		1.0111		1.2929			
15		.9962		1.1544		.9762	
16		.8817		1.1603		1.0277	
17	1.1317	1.0288			1.0642	1.1763	
18	1.1145	.6859	.7888	1.2323	1.1763	1.1576	
19	.1029	.0857	.0747				
20	.1029	.0686		.112			
21	.1029	.0686		.0934			
22	.0857	.0686					
23	.0857	.0686					
24	.0686			.1029	.0857	.0686	.5975
Max	1.2696	1.1105	1.1203	1.2929	1.1763	1.3957	1.1389
Min	.0686	.0686	.0747	.0857	.0686	.0686	.583
Avg	.5091	.6140	.8071	.4606	.2875	.5632	.8083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 210 / 11kv ASHOK POLYMERS Exp. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788			.463	.463	.4458	.5144
2	.5847			.463	.463	.4458	.5316
3	.5544			.4458	.4458	.4115	.5487
4	.5601			.4458	.4287	.4115	.5316
5	.6036			.4287	.4287	.4287	.5144
6	.5914			.4287	.4287	.4287	.5144
7	.6036			.4458	.4458	.4287	.5601
8	.6722			.4115	.5487	.463	.5788
9		.4401	.631			.502	1.0642
10		.5533	.6697			.4641	1.1883
11	.5228	.6984	.5935			.5493	.8954
12	.3361	.631	.5601			.5138	.2469
13		.6241	.4801	.5788		.5121	.2524
14		.5533	.6099	.5249		.5249	.1966
15		.5218		.5316		.4372	.4163
16		.5601		.6219		.4321	
17	.583	.5487		.6161	.5415	.5228	
18	.6001	.5144	.5658	.6161	.6348	.6348	
19	.6001	.5487	.6161				
20	.5658	.5144		.463			
21		.5144		.5228			
22	.5487	.5316					
23	.5487	.4287					
24	.5658			.4801	.4801	.4801	.5144
Max	.6722	.6984	.6697	.6219	.6348	.6348	1.1883
Min	.3361	.4287	.4801	.4115	.4287	.4115	.1966
Avg	.5659	.5455	.5908	.4993	.4826	.4756	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 201 / 11KV KARAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 203 / 11 KV AKOLEKATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2452	.3018	.4527	.4668	.415	.5719
2	.3018	.2263	.3018	.4527	.3921	.3961	.5569
3	.5281	.2641	.3018	.4338	.3361	.3772	.4967
4	.6413	.3961	.3018	.5041	.4108	.4715	.602
5	.7545	.5093	.3018	.5975	1.1016	.5847	.7773
6		.7356	.7356			.7545	.9602
7							1.0936
8	.6602				.6036		1.0669
9	.6602	.5658	.4715		.547	.5093	.8509
10	.6224	.5281	.3772	.5658	.4481	.3395	1.0059
11	1.0822	1.0686	.9878	1.0402	.8116	1.0686	.2054
12	1.1591	1.1736	1.2944	1.1279	1.0402	1.2498	.1867
13	1.1888	1.1431	1.3108	1.0551	1.07	1.2193	
14	1.2342	1.1279	1.2125	1.1145	1.0402	1.0084	.1886
15	1.174	1.0974	1.278	1.1888	1.0402	1.0364	.2075
16	1.0837	1.1126	1.2041	1.0822	1.1288	1.0364	.2452
17	1.1431	1.0974	1.1633	1.1431	1.189	1.0669	.2263
18	1.1883	1.0822	1.065	1.1888	1.174	.9722	.3018
19	.3361	.5658	.4527	.5788	.4715	.5658	.5228
20	.5601	.6036	.6036	.4854	.5847	.6979	.5601
21	.4854	.5281	.6602	.5281	.5093	.6036	.5975
22	.3174	.3961	.4715	.6036	.4715	.4904	.4668
23	.3174	.3206	.4527	.5658	.4527	.3395	.4108
24	.3018	.2801	.3206	.4527	.5228	.4338	.3018
Max	1.2342	1.1736	1.3108	1.1888	1.189	1.2498	1.0936
Min	.3018	.2263	.3018	.4338	.3361	.3395	.1867
Avg	.7318	.6849	.7078	.7581	.7188	.7108	.5393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 204 / 11KV MARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6952	.6805	.763	.763	.8139	.7042	.8029
2	.7545	.7362	.7291	.7545	.8025	.6706	.8029
3	.7716	.7716	.6706	.7537	.8309	.7712	.8402
4	.8322	.9114	.8048	.7407	.9326	.8417	.9335
5	.8573	1.0208	.9717	.8745	.9556	.8764	1.0829
6	.9774	1.0867	1.2209	.9326	1.0288	.9536	1.251
7	1.1831	1.2003	1.4243	1.3565	1.2209	1.2574	
8	1.2955	1.3748	1.5091	1.4043	1.3426	1.2929	1.1203
9	1.4251	1.4251	1.4752	1.4232	1.2929	1.2574	.8402
10	1.3435	1.1736	1.1191	1.4217	1.1043	1.1603	.7842
11				.6099			1.2163
12		.6161	.7356	.462			1.387
13		.6535	.6602	.3734			1.2517
14	.8316	.5788	.6224	.5041	.543	.7842	1.3176
15	.8029	.5601	.6036	.5788	.5611	.8215	1.1633
16	.7842	.5601	.6413	.6099	.5914	.7468	1.2071
17		.5788	.679	.6468	.6099	.7842	1.2717
18	.9522			.7282	.7468	.8402	1.3226
19	1.0269	1.2696	1.1694	1.2136	1.3443	1.1203	.9709
20	1.251	1.3817	1.3203	1.2696		1.4003	1.2136
21	1.1389	1.307	1.226	1.1576	1.1576	1.3817	1.251
22	1.0642	1.1389	1.094	1.2696	1.0269	1.1576	1.1576
23	.9709	.9522	.8865	1.0642	.9896	.9709	.8775
24	.8029	.9149	.8871	.8775	.9335	.9149	.8402
Max	1.4251	1.4251	1.5091	1.4232	1.3443	1.4003	1.387
Min	.6952	.5601	.6036	.3734	.543	.6706	.7842
Avg	.9881	.9497	.9642	.9079	.9415	.9861	1.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 205 / 11kv Banegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.6859	.9907	.9526	.8954	.9145	.1698
2	.7621	.8002	.9526	1.0669	1.0098	1.0479	.1698
3	.8192	.8573	.8764	1.105	1.1622	1.1241	.1635
4	.743	.9335	.8764	1.2193	1.3336	1.2384	.2389
5	1.3717	1.086	1.2003	1.3336	1.6385	1.2765	.2955
6	1.7147	1.3717	1.6575	1.6194	1.9052	1.4861	.3521
7	1.9433	1.8099	2.0195	2.0195	2.0386	2.0005	.4024
8	2.0195	1.9433	2.1529	2.2862	2.0767	2.21	.3395
9	1.9624	2.0195	2.1338	2.0957	2.0957	2.0957	.2534
10	1.9433	1.9433	1.7909	2.0005	1.9433	1.9052	.2317
11	.2134	.1486	.2012	.1823	.1257	.1783	1.7147
12	.1829	.1509		.1635	.1257		1.6385
13	.1829	.1509	.1635		.1257	.1572	1.7909
14	.1768	.1446	.1738	.1572	.128	.1635	1.5623
15		.1383	.1448	.176	.1402	.1509	1.105
16	.2201	.1257		.1882	.1429	.1698	1.4098
17	.2606	.176	.1738	.1823	.1486		1.5242
18	.2751	.2263	.176	.2263	.2073	.1886	1.6194
19	.3692	.3018	.2606	.3048	.3081	.3018	.2389
20	.3403	.3269	.2829	.3395	.3765	.3269	.3041
21	.3041	.2766	.2641	.3121	.3081	.2766	.3258
22	.2401	.2469	.2515	.2829	.2766	.2263	.2896
23	.2195	.148	.2263	.2743	.2515	.1713	.2317
24	.1715	.176	.1269	.2263	.2675	.2389	.176
Max	2.0195	2.0195	2.1529	2.2862	2.0957	2.21	1.7909
Min	.1715	.1257	.1269	.1572	.1257	.1509	.1635
Avg	.7452	.6745	.7771	.8137	.7930	.8113	.6895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 206 / 11kv BB Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.3269
2	.0381	.0381	.0381	.0381	.0381	.0381	.3144
3	.0381	.0381	.0381	.0381	.0381	.0381	.2766
4	.0381	.0572	.0381	.0572	.0381	.0572	.3269
5	.0572	.0762	.0762	.0762	.0572	.0953	.4401
6	.0572	.0953	.1334	.0953	.0953	.1334	.5533
7	.0953	.1334	.1715	.1334	.1524	.0953	.626
8	.0953	.1143	.1334	.1143	.0953	.0762	.7202
9	.0953		.0953	.0953	.0572	.0572	.7072
10	.0572		.0572	.0572	.0381	.0381	.7682
11	.6341	.6316		.7276	.6893	.7545	.0572
12	.6508	.8669	.7316	.7914	.7678	.7802	
13	.8669	.8669	.7554	.7255	.8049	.8042	
14	.8916	.9191	.8545	.8345	.8297	.8402	.0381
15	.8792	.8802	.7324	.756	.8297	.8642	.0381
16	.8916	.8551	.7438	.7678	.8291	.8402	.0381
17	.8162	.8299		.7922	.7562	.8421	.0381
18	.7562	.8552	.8421	.8169	.756	.8297	.0381
19	.0572	.0953	.0572	.0762	.0572	.0762	.0572
20	.0762	.1143	.0953	.1143	.0762	.1143	.0762
21	.0572	.0762	.0953	.0572	.0762	.0953	.1143
22	.0381	.0572	.0762	.0572	.0572	.0762	.1143
23	.0381	.0381	.0381	.0572	.0381	.0572	.0762
24	.964	.0381	.0381	.0381	.0381	.0381	.0381
Max	.964	.9191	.8545	.8345	.8297	.8642	.7682
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.3428	.3507	.2672	.3065	.3022	.3200	.2629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 207 / 11 KV Narotewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.381	.2667	.2286	.2286	.1143
2	.3048	.2858	.381	.2667	.2858	.2858	.1143
3	.2477	.3239	.3429	.3048	.2286	.3239	.12
4	.3429	.381	.3429	.3048	.381	.381	.156
5	.4001	.5335	.4954	.381	.5716	.4191	.204
6	.4763	.6097	.6097	.4954	.7049	.4954	.2641
7	.5906	.6859	.7621	.7621	.8002	.7049	.3447
8	.6478	.6859	.8192	.8002	.7621	.7621	.2681
9	.6859	.7049	.7621	.8002	.7049	.724	.2042
10	.6668	.6478	.724	.724	.6097	.6478	.1276
11	.1659	.096	.0953	.1021	.0667	.084	.6097
12	.1532	.096	.076	.0766	.0572	.0766	.6478
13	.1404	.096	.0787	.0766	.0709	.0766	.5716
14	.1276	.096	.0894	.0766	.0766	.0766	.5906
15	.1509	.096			.0766	.1021	.5335
16	.1532	.0762	.0894	.1021	.0894	.1149	.7621
17	.1532	.0953	.1021	.1286	.0894	.1276	.724
18	.1659	.1143	.1276	.1787	.1404	.2042	.8002
19		.216	.2042	.2683	.217	.2298	.2286
20	.2553	.2401	.2298	.2553	.2425	.2401	.2298
21	.217	.2042	.2553	.192	.2008	.2298	.2808
22	.1532	.1787	.2298	.216	.1915	.168	.2553
23	.1532	.1532	.2042	.18	.1787	.156	.2042
24	.1404	.1276	.1276	.2042	.1787	.1659	.1372
Max	.6859	.7049	.8192	.8002	.8002	.7621	.8002
Min	.1276	.0762	.076	.0766	.0572	.0766	.1143
Avg	.2939	.2921	.3274	.3114	.2981	.2927	.3539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 208 / 11KV SAWITRIBAI FULE EXP NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 201 / 11 KV PADASALI Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048	.3429	.3429	.2286	.381	1.6804
2	.2286	.2667	.3429	.3429	.2286	.381	1.8861
3	.2286	.2667	.3429	.3429	.2286	.381	1.7901
4	.2667	.3048	.3429	.3429	.2667	.381	1.8442
5	.3048	.381	.3429	.3429	.3048	.381	1.8896
6							2.0576
7							2.6825
8							2.8826
9							2.7854
10							2.556
11	2.915	3.0864	2.713	2.1033	2.572	2.2291	
12	3.0803	3.3303	3.0864	2.7846	3.0849	2.9504	
13	3.2007	3.3608	3.0521	2.6871	3.2236	3.2941	
14	3.1687	3.083	3.0178	2.9835	3.0045	3.155	
15	3.1687	3.3573	2.9835	3.2579	2.9995	3.2217	
16	3.0769	3.1893	2.9492	3.2526	2.9172	3.1161	
17	2.915	2.9835	2.8464	3.2556	3.0178	3.1855	
18	2.753	2.332	2.8807	3.2579	2.915	3.0476	
19	.4191	.381	.381	.2667	.4191	.4572	.381
20	.381	.381	.381	.3048	.4191	.381	.381
21	.3429	.381	.381	.3048	.4191	.3048	.381
22	.3048	.381	.381	.2667	.381	.2667	.3048
23	.3048	.3429	.3429	.2667	.381	.2667	.2286
24	.2286	.3048	.3429	.3429	.2667	.381	.2667
Max	3.2007	3.3608	3.0864	3.2579	3.2236	3.2941	2.8826
Min	.2286	.2667	.3429	.2667	.2286	.2667	.2286
Avg	1.4483	1.4957	1.4449	1.4237	1.4357	1.4822	1.4999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 204 / 11KV Gaothan Wadala
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7888	.7362	.6554	.8916	.8139	.9259
2	.8764	.823	.7202	.6401	.9362	.8573	.9602
3	1.046	1.0059	.7625	1.0402	.9945	.9282	1.0631
4	1.2887	1.278	1.0174	1.3765	1.2125	1.166	1.3435
5	1.5415	1.5074	1.4746	1.6385	1.531	1.5074	1.6385
6					1.406		
10	1.1736	1.0631	1.0898	1.0898	.9945	1.166	1.0288
11	.8916	.8478	.9831	.8916	.7545	.8817	.823
12	.823	.7888	.8192	.7362	.7282	.7888	.7011
13	.8916	.6554	.7287	.6415	.7619	.7282	.7011
14	.6516	.6859	.6554	.6859	.724	.7265	.6661
15	.6516	.5937		.663	.7316	.7362	.7362
16	.6516	.6554	.6554	.703	.6516	.6859	.7362
17	.9389	.9602	.7202	.7712	.6962	.7628	
18	.9831	1.0513	.8192	1.0288	.8048	.8149	.8916
19	1.358	1.2003	1.387	1.3003	.9503	1.3923	1.326
20	1.2689	1.4255	1.4746	1.5261	1.2597	1.4091	1.4083
21	1.1317	1.2003	1.3003	1.262	1.4746	1.166	1.2689
22	.9816	.9496	.9389	1.0576	.9389	1.0174	.9259
23	.7888	.7888	.7625	1.0631	.8288	.9189	.8413
24	.8505	.7888	.7087	.6554	1.0166	.823	.8764
Max	1.5415	1.5074	1.4746	1.6385	1.531	1.5074	1.6385
Min	.6516	.5937	.6554	.6401	.6516	.6859	.6661
Avg	.9823	.9529	.9344	.9713	.9661	.9645	.9927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 205 / 11KV Gawadi Darfal Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	1.1317
2	.0762	.0762	.0762	.0762	.0762	.0762	1.2403
3	.0762	.0762	.0762	.0762	.0762	.0762	1.1317
4	.0762	.0762	.0762	.0762	.0762	.0762	1.2003
5	.0762	.0762	.0762	.0762	.0762	.0762	1.2407
6							1.3077
7							1.8004
8							2.1605
9							2.3148
10							2.2131
11	2.7035	2.3061	2.3472	1.6956	1.6385	1.56	
12	2.5232	2.42	2.5434	2.1548	1.8842	2.2291	
13	2.6886	2.4577	2.6825	2.4177	2.0719	2.572	
14	2.6406	2.572	2.4387	2.5434	2.2801	2.4646	
15	2.6406		2.652	2.3537	1.8861	2.5434	
16	2.6406	2.4577	2.6216	2.3148	1.7901	2.5377	
17	2.6406	2.572	2.3148	2.2382	2.0119	2.1795	
18	2.4291	2.146	2.3434	2.2291	1.7147	2.0856	
19	.0762		.0762	.0762	.0762	.0762	.0762
20	.0762		.0762	.0762	.0762	.0762	.0762
21	.0762		.0762	.0762	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	2.7035	2.572	2.6825	2.5434	2.2801	2.572	2.3148
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.1445	1.1694	1.0938	.9887	.8482	1.0005	1.0124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 206 / 11KV Nannaj Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.0288	1.166	1.1336	1.0974	1.166	.2286
2	1.2136	1.0288	1.2269	1.1336	1.1163	1.2003	.2286
3	1.2971	1.0288	1.2136	1.1469	1.0974	1.262	.2286
4	1.3032	1.1317	1.2597	1.1469	1.1271	1.39	.2667
5	1.3523	1.2689	1.3717	1.4089	1.1736	1.3565	.3048
6	1.3717	1.3413	2.1262	1.5089	1.6244	1.5912	
7	2.2211	2.4249	2.4006	2.4577	2.1365	2.4348	
8	2.7526	2.5911		2.5526	2.649	2.5857	
9	2.3594	2.6235	2.7435	2.6825	2.6406	2.7435	
10	2.2283	2.8045	2.5149	1.8233	2.652	2.4577	
11							2.2939
12							2.8826
19	.2667	.3429	.2858	.2667	.2286	.2667	.2286
20	.2667	.3429	.2286	.3048	.2286	.2667	.2667
21	.2667	.2286	.2286	.2667	.2286	.3048	.2286
22	.2286	.2286	.2286	.2286	.2286	.3048	.2286
23	.1905	.2286	.1905	.2286	.2286	.3048	.1905
24	.1905	.1905	.2286	.1905	.1905	.1905	.2667
Max	2.7526	2.8045	2.7435	2.6825	2.652	2.7435	2.8826
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	1.1715	1.1772	1.1609	1.1551	1.1655	1.2391	.6033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 207 / 11KV LokmangalR&D Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0191						
10		.0381	.0572	.0572	.0381		.0381
11			.0572	.0572	.0381	.0191	.0572
12		.0381	.0572	.0381	.0381	.0381	.0381
13		.0381	.0572	.0381	.0381	.0572	.0381
14		.0381	.0572	.0381	.0381	.0572	.0381
15		.0381	.0572	.0381	.0381	.0572	.0381
16		.0381	.0572	.0381	.0381	.0381	.0381
17		.0381	.0381	.0381	.0191	.0191	.0381
18			.0191	.0191	.0191		
Max	.0191	.0381	.0572	.0572	.0381	.0572	.0572
Min	.0191	.0381	.0191	.0191	.0191	.0191	.0381
Avg	.0191	.0381	.0508	.0402	.0339	.0409	.0405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9							2.7161
11			2.4006				
15		2.4691					
16			2.4691	2.7435		3.0178	
17					2.6749		
18					2.4897		
19							.2263
24	.1509	.1509		.1509	.1509	.1509	.1509
Max	.1509	2.4691	2.4691	2.7435	2.6749	3.0178	2.7161
Min	.1509	.1509	2.4006	.1509	.1509	.1509	.1509
Avg	.1509	1.31	2.4349	1.4472	1.7718	1.5844	1.0311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV KAWATHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1317			
2				1.2071			
3				1.2071			
4				1.2826			
5				1.358			
6				1.7353			
7				2.4143			
8				2.037		2.1125	
9	2.037	.3772			2.2634	2.037	
10			1.7147	2.037			
16							2.1125
19							.2263
24	.7545	.0754		.0754	.0754	.1509	.0754
Max	2.037	.3772	1.7147	2.4143	2.2634	2.1125	2.1125
Min	.7545	.0754	1.7147	.0754	.0754	.1509	.0754
Avg	1.3958	.2263	1.7147	1.4486	1.1694	1.4335	.8047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV DONGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3772			
2				.3395			
3				.3395			
4				.4527			
5				.5658			
6				.7545			
7				.8299			
8				.7545		.679	
9	.6036	.5281			.5281	.5281	.5281
10			.3772	.4527			
11			.3018				
15		.3772					
16			.3018	.3772		.3018	.3018
17					.4527		
18					.5281		
19							.8299
24	.3018	.3018		.3772	.3018	.3772	.3018
Max	.6036	.5281	.3772	.8299	.5281	.679	.8299
Min	.3018	.3018	.3018	.3395	.3018	.3018	.3018
Avg	.4527	.4024	.3269	.5110	.4527	.4715	.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV NANDUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9							2.8669
11			2.5034				
15		3.155					
16			2.9492	2.8464		3.1687	
17					2.9047		
18					3.0178		
19							.2829
24	.1509	.2829		.2263	.2829	.2829	.2263
Max	.1509	3.155	2.9492	2.8464	3.0178	3.1687	2.8669
Min	.1509	.2829	2.5034	.2263	.2829	.2829	.2263
Avg	.1509	1.7190	2.7263	1.5364	2.0685	1.7258	1.1254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV SOREGAON GFSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5281			
2				.4904			
3				.4527			
4				.4904			
5				.5281			
6				.6036			
7				.679			
8				.6979		.6979	
9		.6602			.547		.547
10			.6224	.6224			
11			.6036				
15		.5658					
16			.547	.5281		.4904	
17					.6036		
18					.6413		
19							.8676
24	.4904	.5658		.5658	.5658	.5847	.5658
Max	.4904	.6602	.6224	.6979	.6413	.6979	.8676
Min	.4904	.5658	.547	.4527	.547	.4904	.547
Avg	.4904	.5973	.591	.5624	.5894	.591	.6601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 206 / 11 KV PATHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4335			
2				1.5089			
3				1.5844			
4				1.6975			
5				1.9616			
6				2.452			
8				2.7726		2.7161	
9	2.999	2.8464			2.6783	2.6595	.1886
10			2.572	2.4006			
11			.132				
15		.132					
16			.132	.132		.132	2.9801
17					.1509		
18					.1698		
19							.1698
24	1.0562	.1886		.1509	.1886	.1886	.1509
Max	2.999	2.8464	2.572	2.7726	2.6783	2.7161	2.9801
Min	1.0562	.132	.132	.132	.1509	.132	.1509
Avg	2.0276	1.0557	.9453	1.6094	.7969	1.4241	.8724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 207 / 11KV Commissioner SMC, NON SHEDDABLE WATER SUPPLY AND
P.Nagar Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509			
2		.132			
3		.132			
4		.132			
5		.0189			
6		.0189			
7		.1509			
8		.0189			
9	.1509		.2452	.0189	.132
16				.0189	
24	.2641	.1509	.1509		.2263
Max	.2641	.1509	.2452	.0189	.2263
Min	.1509	.0189	.1509	.0189	.132
Avg	.2075	.1006	.1981	.0189	.1792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 201 / 11KV Rama

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3429	.2641	.2743	.3086	.3018	.2401
2	.1886	.3086	.2641	.2743	.2743	.2263	.2401
3	.1886	.3086	.2641	.2401	.2743	.2263	.2058
4	.1886	.2743	.2641	.2401	.2743	.2263	.2103
5	.1886	.2743	.2263	.2401	.2401	.1886	.1715
6	.1886	.2401	.2641	.2058	.2401	.1886	.1715
7	.1886	.2058	.2641	.1715	.1715	.1886	.12
8	.1886	.2401	.2263	.2401	.2743	.2263	.1372
9	.3395	.2743	.4904	.3429	.3772		.1715
10	.4527	.4527	.6413	.4715	.5281	.4527	.1886
11	.5281	.4904	.6413	.5658	.6036	.6036	.1509
12	.5281	.415	.5658	.6036	.5658	.5281	.1509
13	.4904	.3018	.5658	.5658	.5658	.3772	.1509
14	.4527	.3395	.5658	.5658	.5281	.3772	.1509
15	.4527	.3772	.5658	.4904	.4904	.4527	.1509
16	.4904	.3772	.5658	.415	.4904	.4904	.1509
17	.4115	.4527	.4801	.3772	.4904	.4115	.1509
18	.3429	.3395	.4115	.4115	.4527	.3429	.1509
19	.3086	.2263	.3429	.3429	.4527	.3086	.1509
20	.3086	.2641	.3429	.3086	.3395	.2401	.1509
21	.3086	.2641	.2572	.3086	.2641	.2401	.1509
22	.3086	.2641	.2572	.2743	.2263	.2743	.1509
23	.3429	.2641	.2743	.3086	.2263	.2743	.1886
24	.2263	.3429	.2641	.2743	.3086	.3018	.2743
Max	.5281	.4904	.6413	.6036	.6036	.6036	.2743
Min	.1886	.2058	.2263	.1715	.1715	.1886	.12
Avg	.3266	.3184	.3862	.3547	.3736	.3238	.1721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 202 / 11KV Bhutada

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	1.2003	1.2934	1.406	1.286	1.226	.7545
2	.7545	1.2003	1.3121	1.3717	1.2003	1.226	.7202
3	.7545	1.166	1.3112	1.3717	1.2003	1.1694	.7202
4	.8299	1.166	1.2936	1.3375	1.1145	1.1317	.7202
5	.8676	1.1317	1.2936	1.3375	1.1145	1.1317	.6859
6	.9054	1.1317	1.3611	1.286	1.1145	1.1317	.6859
7	.9619	1.0802	1.5339	1.2346	1.0288	1.094	.6344
8	1.358	1.2517	1.6632	1.6461	1.1145	1.3203	1.046
9	1.6409	1.4575	1.7684	1.7147	1.6632		1.1145
10	1.8861	1.6598	1.7918	2.5463	1.8861	1.3203	1.2826
11	2.1125	1.6975	2.2068	2.2445	2.0182	1.358	1.3203
12	2.0748	1.6409	2.1125	2.1125	1.9616	1.358	1.3769
13	2.0748	1.6409	2.0748	2.037	1.8861	1.3769	1.4335
14	1.9427	1.5089	2.0559	1.8673	1.8861	1.2826	1.4146
15	1.9427	1.4146	1.9239	1.7918	1.7918	1.2071	.3772
16	1.6787	1.4146	1.8861	1.7164	1.6409	.9808	1.0185
17	1.5432	1.3306	1.6289	1.4575	1.5089	.9088	1.226
18	1.5775	1.3717	1.4575	1.3032	1.358	.9431	1.3203
19	1.4575	1.2536	1.3717	1.3032	1.2637	.8573	1.3203
20	1.2689	1.1458	1.406	1.3032	1.4712	.6859	1.1317
21	1.1317	1.2012	1.286	1.2689	1.5089	.7202	1.1317
22	1.1831	1.2382	1.3375	1.2517	1.5278	.7202	1.1317
23	1.2003	1.2567	1.3717	1.286	1.5089	.7202	1.1694
24	.7356	1.2003	1.2936	1.406	1.286	1.358	.7545
Max	2.1125	1.6975	2.2068	2.5463	2.0182	1.3769	1.4335
Min	.7356	1.0802	1.286	1.2346	1.0288	.6859	.3772
Avg	1.3591	1.3234	1.5848	1.5667	1.4725	1.0969	1.0205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 205 / 11KV LDK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	1.0974	.8488	1.3032	1.1317	.9431	1.1317
2	.6602	1.0974	.7947	1.2003	1.1317	.9431	1.0288
3	.6224	1.0288	.7947	1.2003	1.0631	.9431	1.0288
4	.6224	.9431	.7392	1.0288	1.0631	.9431	.9431
5	.6224	.9431	.7577	.9431	1.0288	.8676	.8573
6	.6224	.8573	.7023	.8916	1.0288	.8676	.6859
7	.6036	.7716	.6602	.6859	.9431	.8676	.5487
8	.5847	.8059	.6602	.7545	1.0288	.9431	.583
9	.8865	.9945	1.2567	.7888	1.1831		.6173
10	1.1694	1.0374	1.3014	1.1317	1.3392	1.1883	.5658
11	1.358	1.0562	1.4335	1.4335	1.3769	1.4712	.3584
12	1.6032	1.0185	1.2826	1.2826	1.3769	1.3203	.6413
13	1.6975	1.0185	1.4712	1.2449	1.3203	1.2449	.6413
14	1.6975	.9808	1.5089	1.2071	1.3203	1.3957	.5847
15	1.6975	.9808	1.4146	1.3203	1.3392	1.5089	.5847
16	1.6032	.9808	1.4146		1.3392	1.4335	.6979
17	1.286	.9795	1.286	1.286	1.4146	1.2003	.7545
18	1.0288	1.0349	1.286	1.2346	1.4712	1.0802	.811
19	1.0288	.9335	1.286	1.1317	1.4712	.9945	.811
20	.9774	.961	1.2003	1.0974	1.3957	.8573	.7545
21	.9259	.924	1.1145	1.0974	1.3957		.7356
22	1.1488	.9979	1.0631	1.0974	1.3957	1.0974	.7356
23	1.1317	.8316	1.0288	1.0974	1.3957	1.0631	.7167
24	.6602	1.1317	.8871	1.0288	1.1317	.9997	1.1317
Max	1.6975	1.1317	1.5089	1.4335	1.4712	1.5089	1.1317
Min	.5847	.7716	.6602	.6859	.9431	.8573	.3584
Avg	1.0374	.9753	1.0914	1.1081	1.2536	1.0988	.7479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 206 / 11KV V.Datta

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.6859	.6602	.4973	.6859	.679	.5144
2	.5281	.6516	.0377	.5144	.6859	.6036	.5144
3	.5658	.6516	.5658	.5144	.6516	.6036	.4801
4	.5658	.6173	.6036	.4973	.6173	.6036	.4801
5	.5658	.6173	.5658	.4973	.5144	.5658	.4458
6	.5847	.5658	.6413	.4973	.5144	.5658	.4458
7	.5847	.5144	.6036	.463	.4801	.547	.4287
8	.6413	.5658	.6413	.5316	.5144	.6036	.5316
9	.6224	.6173	.7167	.583	.5487		.5658
10	.7545	.7545	.811	.7545	.7167	.679	.6224
11	.8299	.8488	.8488	.8865	.8676	.7167	.6036
12	.7922	.7922	.7167	.9431	.8299	.679	.6413
13	.7545	.6602	.7922	.8488	.7922	.6036	.6413
14	.7167	.7545	.8676	.6979	.7545	.6413	.5658
15	.7167	.8299	.9242	.7545	.7922	.679	.4715
16	.9054	.8299	.9242	.7733	.7922	.679	.4527
17	.7545	.7577	.823	.7202	.7922	.5658	.5281
18	.6687	.7023	.823	.7545	.7733	.5658	.6036
19	.6859	.6602	.8059	.7545	.7733		.6036
20	.703	.6413	.7716	.7545	.7545	.6173	.6413
21	.6173	.6602	.6859	.6859	.7167	.5487	.679
22	.6516	.6413	.6859	.7202	.7167	.5487	.679
23	.6859	.6413	.6859	.7545	.7167	.5487	.5658
24	.547	.6859	.679	.6859	.7545	.7167	.5487
Max	.9054	.8488	.9242	.9431	.8676	.7167	.679
Min	.5281	.5144	.0377	.463	.4801	.547	.4287
Avg	.6662	.6811	.7034	.6702	.6982	.6164	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 207 / 11KV Venky Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0288	1.1458	1.0288	.6859	.6602	.6859
2		1.0288	1.1643	1.0288	.6859	.6602	.6859
3	1.1506	.9945	1.2012	1.0288	.6516	.6602	.6516
4		.9945	1.1088	.9945	.6516	.5658	.6516
5		.9602	1.1643	.9945	.6173	.5658	.6173
6	1.094	.9602	1.1088	.9602	.6173	.5658	.7545
7	1.0751	1.0631		.9259	.5487	.5658	.5487
8	1.1694	1.1488	1.1273	1.046	.583	.5658	
9	1.226	1.1145	1.1827	1.0974	.6001		
10	1.3203	1.2071	1.1694	1.1317	.6602	.7545	.8299
11	1.358	1.1883	1.2826	1.0374	.6979	.7545	.7733
12	1.358	1.0374	1.3203	.9619	.7545	.7545	.8676
13	1.358	.8865	1.226	.9431			.8676
14	1.3203	1.094	1.1317	.8865	.7167	.7545	.9242
15	1.3203	1.2071	1.1883	.8676	.7167	.7545	.9242
16	1.3203	1.2071	1.1883	.8676	.7167	.7733	.811
17	1.166	1.3352	1.0974	.6859	.679	.7202	.8676
18	1.0631	1.3169	1.0974	.7373	.679	.7373	.8676
19	1.0631	1.2012	1.0974	.6859	.679	.6516	.8676
20	1.0631	1.0903	1.0974	.6516	.6413	.583	.7545
21	.9602	.961	.9945	.6859	.6036	.583	.7167
22	.9945	.7356	.9945	.703	.6036	.6859	.7167
23	1.0288	1.0349	1.0288		.6036		.6413
24	1.1317	1.0288	1.1458	1.0288	.7202	.6602	.6859
Max	1.358	1.3352	1.3203	1.1317	.7545	.7733	.9242
Min	.9602	.7356	.9945	.6516	.5487	.5658	.5487
Avg	1.1749	1.0760	1.1419	.9121	.6571	.6656	.7596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 401 / 33KV KOTHARI PRIMA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029		.3086	.2058	.3395	.2058
2		.1029		.3086	.2058	.2829	.1543
3		.1029		.3086	.3086	.2829	.1543
4		.1029		.2572	.3086	.2263	.1029
5		.1029		.2572	.3086	.2263	.1029
6		.2572		.2058	.3086	.1698	.1029
7		.2572		.2058	.2058	.1698	.1029
8		.2572		.2058	.2058	.1698	.0514
9		.2572		.1543	.2058		.0514
10	.1698	.2263	.2263				
11	.1698	.2263	.1698				
12	.1698	.1698	.2829				
13	.0566	.1698	.2829				
14	.1132	.1698	.2263				
15	.1132	.2263	.2263				
16	.0566	.2263	.1698				
17	.1029		.1543	.2058	.2263	.2058	.0566
18	.1029		.1543	.2058	.2263	.2058	.0566
19	.1029		.1543	.2058	.2263	.1543	.0566
20	.1029		.1543	.2058	.1698	.1543	.0566
21	.1029		.2572	.2058	.1698	.2058	.0566
22	.1029		.3086	.2058	.1698	.2058	.0566
23	.463		.3086	.2058	.1698	.2058	.0566
24		.1029		.3086	.2058	.3395	.2058
Max	.463	.2572	.3086	.3086	.3086	.3395	.2058
Min	.0566	.1029	.1543	.1543	.1698	.1543	.0514
Avg	.1378	.1800	.2197	.2330	.2251	.2215	.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 201 / 11KV Vasant Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2896	.3077	.3403	.3045	.3224	.3224
2	.2896	.2715	.2896	.3224	.3045	.3045	.3224
3	.2715	.2715	.2715	.3045	.2686	.3045	.3045
4	.2715	.2534	.2715	.3045	.2686	.2865	.3045
5	.2896	.2534	.2534	.3045	.2865	.2865	.2865
6	.3439	.2896	.3077	.3224	.3045	.3045	.3224
7	.3801	.2715	.3258	.3403	.3403	.3045	.3403
8	.3801	.3077	.3077	.3582	.3761	.3224	.3403
9	.3439	.3439	.3258	.3258	.3403	.3045	.3045
10	.3439	.3077	.3439	.3801	.3224	.2686	.2507
11	.3258	.3439	.3077	.3439	.2865	.3224	.2328
12	.2715	.362	.3077	.3258	.2865	.3224	.2507
13	.2896	.2896	.2353	.2896	.2686	.2686	.2328
14	.2534	.2715	.2715	.2715	.2686	.3045	.2507
15	.2534	.2534	.2686	.2896	.2686	.2865	.2686
16	.2534	.3077	.2865	.2686	.2686	.2865	.2507
17	.2715	.2896	.3077	.2686	.2865	.2715	.2715
18	.2896	.3077	.2896	.2534	.2686	.2896	.2715
19	.4163	.362	.4163	.4163	.3582	.4163	.3982
20	.4163	.3801	.3801	.4344	.3761	.4163	.3982
21	.3982	.3982	.3801	.3982	.3761	.394	.3801
22	.3982		.394	.3761	.394	.3761	.394
23	.3439		.3761	.3582	.3761	.3582	.394
24	1.9195	.3077	.3258	.3403	.3403	.3582	.3403
Max	1.9195	.3982	.4163	.4344	.394	.4163	.3982
Min	.2534	.2534	.2353	.2534	.2686	.2686	.2328
Avg	.3884	.3061	.3147	.3307	.3142	.32	.3097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 202 / 11KV BHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.3394	1.3213	1.3253	1.2536	1.3432	1.3969
2	1.2851	1.2489	1.2851	1.3432	1.2536	1.3611	1.2894
3	1.2489	1.2489	1.2489	1.3073	1.2357	1.3611	1.3073
4	1.3575	1.3756	1.3032	1.3611	1.2894	1.379	1.3611
5	1.7194	1.5384	1.4842	1.4685	1.5939	1.5402	1.4864
6	1.9909	1.7737	1.7909	2.0237	2.0058	1.7909	1.8804
7	1.9547	2.009	1.9547	2.0237	2.0774	1.8983	1.97
8	1.8461	2.0271	1.8099	1.9521	1.773	1.9342	1.7013
9	1.7737	1.8823	1.5203	1.7193	1.5939	1.6834	1.6297
10	1.6108	1.5927	1.5023	1.4661	1.3432	1.5581	1.4148
11	1.6289	1.5565	1.4299	1.448	1.4327		1.379
12	1.5746	1.5927	1.5927	1.5203	1.4327		1.4685
13	1.448	1.6651	1.4377	1.5939	1.5581		1.4864
14	1.4842	1.6289	1.5746	1.5746	1.3969	1.4148	1.5223
15	1.647	1.3756	1.5043	1.4327	1.4506	1.7013	1.5581
16	1.647	1.4299	1.6476	1.4118	1.5043	1.6476	1.576
17	1.7375	1.6651	1.6297	1.5581	1.5402	1.6289	1.7918
18	1.6108	1.7013	1.6651	1.5927	1.6118	1.5565	1.7375
19	1.8642	1.9728	1.9728	2.0271	1.9521	2.0271	1.9728
20	1.8642	1.7918	1.8804		1.8804	1.9728	1.9909
21	1.6651	1.7194	1.773	1.7737	1.6655	1.8625	1.9004
22	1.6108		1.6476	1.5581	1.6476	1.7193	1.7551
23	1.5023		1.4506	1.2715	1.5043	1.5223	1.4506
24	1.3213	1.3756	1.3575	1.379	1.2715	1.3611	1.4327
Max	1.9909	2.0271	1.9728	2.0271	2.0774	2.0271	1.9909
Min	1.2489	1.2489	1.2489	1.2715	1.2357	1.3432	1.2894
Avg	1.6108	1.6141	1.5743	1.5709	1.5528	1.6316	1.6025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 201 / 11KV RANMASALE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.8747
Max	1.8747
Min	1.8747
Avg	1.8747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 202 / 11KV BIBIDARFAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7202
Max	.7202
Min	.7202
Avg	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 203 / 11 KV RANMASALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7202
Max	.7202
Min	.7202
Avg	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 201 / 11KV BHAGAIWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1905	.1867	.1494	.1867	.1905	.2261
2	.1494	.1524	.1494	.168	.1494	.1715	.1867
3	.1494	.1715	.1494	.168	.1307	.2286	.168
4	.1494	.2477	.1494	.3361	.1307	.2858	.3734
5	.1867	.3429	.1867	.3734	.2241	.362	.5041
6	.5041	.4954	.4481	.4481	.4854	.4382	.3734
7	.4481	.4572	.3921	.3921	.4294	.4001	
8	.3921	.3361	.3361	.2241	.3361	.3174	.1867
9	.3429	.2987		.1581	.2801	.2427	.168
10	.2667	.1867	.2987	.1867	.1867	.1423	.1524
11	.2858	.1867	.2614	.1494	.1334	.0949	.1524
12	.2477	.2241	.1867	.1494	.1524	.0949	.1334
13	.2286	.1494	.112	.1307	.1524	.1307	.1334
14	.1905	.1307	.112	.1307	.1334	.0934	.1524
15	.1715	.1307	.1307	.1307	.1524	.112	.1524
16	.1905	.1307	.1307	.1867	.1715	.1307	.1715
17	.2096	.1867	.112	.2241	.1905	.112	.1905
18	.2667	.2614	.3921	.2801	.2667	.2614	.2477
19	.3429	.4481		.3921	.4001	.2987	.4382
20	.4001	.3921		.4481	.4572	.3921	.4191
21	.3429	.3361	.3921	.3361	.3429	.2801	.362
22	.2667	.2801	.3921	.3361	.2858	.2614	.3048
23	.2286	.2241	.3734	.2801	.2477	.2241	.2477
24	.2241	.2286	.2241	.1494	.2241	.2286	.2241
Max	.5041	.4954	.4481	.4481	.4854	.4382	.5041
Min	.1494	.1307	.112	.1307	.1307	.0934	.1334
Avg	.2655	.2579	.2436	.2470	.2437	.2289	.2465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 202 / 11KV SAKHAREWADI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6009
2							.6642
3							.8223
4							.8855
5							1.0437
6							1.3441
7							1.3757
8							1.5181
9							1.4864
11	1.8861	1.5971	.6009	1.5181	1.8671	1.5181	
12	2.5339	2.1506	1.866	1.9608	2.4006	1.866	
13	2.5911	2.5393	1.8976	1.9766	2.3243	2.0399	
14	2.7054	2.0715	1.945	1.9292	2.21	1.866	
15	2.6673	1.9292	1.9608	1.8343	2.191	2.0557	
16	2.6101	2.0715	1.8976	1.8343	2.3243	1.7869	
17	2.5911	1.9292	1.8343	1.8501	2.3624	1.9608	
18	1.9052	1.7711	1.7711	2.1822	1.9052	1.7236	
20				1.5181			
Max	2.7054	2.5393	1.9608	2.1822	2.4006	2.0557	1.5181
Min	1.8861	1.5971	.6009	1.5181	1.8671	1.5181	.6009
Avg	2.4363	2.0074	1.7217	1.8449	2.1981	1.8521	1.0823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 203 / 11KV KAUTHALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.7049	.506	.5535	.506	.6859	
2	.5851	.743	.5851	.6642	.5851	.743	
3	.8223	.8573	.7274	.8962	.6009	.8383	
4	1.0595	.9526	.8223		.8381	1.1431	
5	1.2651	1.105	1.0279	.8855	.9962	1.105	
6	1.2809	1.3527	1.0437	.8855	1.1544	1.4098	
7	1.4232	1.448	1.2334	1.0437	1.2018	1.5623	
8	1.4706	1.3916	1.3757	.8855	1.4706		
9	1.6004	1.2651		.6009	1.3757		
10	1.5051	1.1069		.5693	1.2651	1.3599	
11							1.2384
12							1.6385
13							1.7147
14							1.7528
15							1.6194
16							1.5242
17							1.467
18							1.3336
Max	1.6004	1.448	1.3757	1.0437	1.4706	1.5623	1.7528
Min	.4111	.7049	.506	.5535	.506	.6859	1.2384
Avg	1.1423	1.0927	.9152	.7760	.9994	1.1059	1.5361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 203 / 11KV NEHRU NAGAR Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0781						
8	.0857						
9	.0838	.081	.0857	.0905		.081	
10	.0838	.0724	.0857	.0867		.0838	
11	2.6282	2.713		1.8023		1.5746	
12	2.713	2.7978		2.0119			
13	2.7978	2.7349	2.7664	2.2119		2.713	
14	2.2634	2.7349	2.7035	2.7978		2.7978	
15	2.1795	2.7349	2.8178	2.7978		2.8826	
16	3.0664	2.7349	2.8178	2.8826		2.2119	
17			2.6825	2.9673	2.2119	2.7349	.0848
18			2.4006	2.5149		2.4863	.0867
19			.0876		.0953	.0905	.0886
20			.0848	.0829	.0838	.0905	.0895
21			.0848	.0819	.0838	.0905	.0886
24	.0781						
Max	3.0664	2.7978	2.8178	2.9673	2.2119	2.8826	.0895
Min	.0781	.0724	.0848	.0819	.0838	.081	.0848
Avg	1.4598	2.0755	1.5107	1.6940	.6187	1.4865	.0876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 204 / 11KV DEGAON-AG-
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0769						
2	3.0769						
3	3.0769						
4	3.1131						
5	3.2769						
6	3.6466						
7	3.8952						
8	4.1438						
9	3.3589	3.8952	3.8866	3.6046		3.6437	
10	3.1207	4.0695	3.9676	3.5627		3.2026	
11	.0953	.0953		.0953		.0953	
12	.0953	.0953		.0953		.0953	
13	.0953	.0953		.0953		.0953	
14	.0953	.0953		.0953		.0953	
15	.0953	.0953		.0953		.0953	
16	.0953	.0953		.0953		.0953	
17			.0953	.0953	.0953		
18				.0953	.0953		3.5227
19			.0953		.0953		.0953
20			.0953	.0953	.0953		.0953
21				.0953	.0953		.0953
23			.0953				
24	.0953						
Max	4.1438	4.0695	3.9676	3.6046	.0953	3.6437	3.5227
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	2.0266	1.0671	1.3726	.6767	.0953	.9273	.9522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 207 / 11KV BALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.181						
8	.181						
9	.1848	.1867	.1886	.1867		.1886	
10	.1886	.1886	.1867	.1886		.1886	
11	2.4863	2.6825	2.3205	2.431		2.1548	
12	2.5987	2.934		1.8023			
13	2.5987	2.8502	2.934	2.6825		2.6282	
14	2.3205	2.5987	2.5692	2.5987		1.7814	
15		2.5987	2.8349	2.5149		2.5149	
16	2.8178	2.6825	2.8349	2.5149			
17			2.6825	2.8502	2.4034		.1867
18			2.431		1.7814		.1867
19			.1829	.1715	.1696		.1829
20			.2715	.1829	.1543		.1848
21			.1848	.181	.181		.1829
24	.181						
Max	2.8178	2.934	2.934	2.8502	2.4034	2.6282	.1867
Min	.181	.1867	.1829	.1715	.1543	.1886	.1829
Avg	1.3738	2.0902	1.6351	1.5254	.9379	1.5761	.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 209 / 11KV TIKEKAR WADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572						
2	.4572						
3	.4572						
4	.4572						
5	.5401						
6	.6249						
7	.8002						
8	.8697						
9	.8697	.6944	.8802	.8488		.4572	
10	.4344	.6325	.5335	.7621		.5268	
11	.0819	.0819	.0953	.0819		.0819	
12	.081	.0819		.0819		.0819	
13	.081	.081	.0819	.0829			
14	.081	.081	.0953	.081		.0838	
15	.081	.081	.0953	.081		.0819	
16	.081	.081	.0819	.0953		.0819	
17			.0819		.0953		.8697
18				.0953	.0953		.8002
19				.0953	.0953		.0819
20			.0819	.0819	.0495		.0819
21			.0819	.0819	.0829		.0819
24	.0819						
Max	.8697	.6944	.8802	.8488	.0953	.5268	.8697
Min	.081	.081	.0819	.081	.0495	.0819	.0819
Avg	.3845	.2268	.2109	.2058	.0837	.1993	.3831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 210 / 11KV GAONTHAN DEGAON
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335						
2	.6335						
3	.6335						
4	.6335						
5	.8316						
6	1.0269						
7	1.1203						
8	1.1203						
9	.8145	.8316	.8059	.8059		.924	
10	.6335	.6401	.823	.8145		.8316	
11	.6268	.6401	.7316	.6401		.724	
12	.6335	.6335		.6335		.6401	
13	.6335	.6401	.6401	.6401		.5544	
14	.7316	.6335	.6335	.6335		.543	
15	.8145	.7392	.6335	.5544		.6401	
16	.8145	.724	.6335	.543		.6335	
17			.6335	.6335	.7316		.724
18			.7316	.7392	.7316		.8316
19			1.1203	.9335	1.0269		1.0269
20			1.0164	.924	1.0269		1.1203
21			.823	.8316	.924		.9335
24	.6335						
Max	1.1203	.8316	1.1203	.9335	1.0269	.924	1.1203
Min	.6268	.6335	.6335	.543	.7316	.543	.724
Avg	.7629	.6853	.7688	.7174	.8882	.6863	.9273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 213 / 11KV URBAN DEGAON NEW

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791						
2	.1791						
3	.1791						
4	.1791						
5	.2743						
6	.2772						
7	.2772						
8	.2772						
9	.2772	.2772	.2743	.2772		.2743	
10	.1772	.2715	.2772	.2743		.2715	
11	.1791	.2743	.1829	.1848		.2658	
12	.1848	.2715		.1829		.2715	
13	.1829	.2715	.1772	.1829		.2772	
14	.1848	.2772	.1829	.1848		.2772	
15	.1848	.1848	.1848	.1848		.2686	
16	.1829	.1829	.1848	.181		.2686	
17			.181	.181	.181		.2686
18			.181	.181	.181		.2715
19			.3696	.2743	.3696		.3696
20			.2772	.2743	.2772		.3696
21			.2772	.2743	.2772		.3696
24	.1791						
Max	.2772	.2772	.3696	.2772	.3696	.2772	.3696
Min	.1772	.1829	.1772	.181	.181	.2658	.2686
Avg	.2091	.2514	.2292	.2183	.2572	.2718	.3298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 405 / 33KV SIDHANATH MINERALS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 605 / 110 KV Sidhnath Exp.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	3.2735
Max	3.2735
Min	3.2735
Avg	3.2735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277024 / 132/33 KV SOREGAON

Feeder No / Name : 401 / 33KV PWW Soregaon
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	2.2119
Max	2.2119
Min	2.2119
Avg	2.2119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 402 / 33KV HT CONSUMER FEEDER
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	4.4239
Max	4.4239
Min	4.4239
Avg	4.4239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 403 / 33KV PAKNI Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	1.0802
Max	1.0802
Min	1.0802
Avg	1.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 404 / 33KV CIMCO Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.1091
Max	2.1091
Min	2.1091
Avg	2.1091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 405 / 33KV PRECISION

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.7263
Max	2.7263
Min	2.7263
Avg	2.7263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 406 / 33KV Betul Express

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.0802
Max	1.0802
Min	1.0802
Avg	1.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 407 / 33KV MIDC C. KATI 2

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.8868
Max	4.8868
Min	4.8868
Avg	4.8868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 278005 / 220/132/33 KV BALE

Feeder No / Name : 402 / 33KV Arihant Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.7202
Max	.7202
Min	.7202
Avg	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 278005 / 220/132/33 KV BALE

Feeder No / Name : 407 / 33 KV BIO-ENERGY

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.0802
Max	1.0802
Min	1.0802
Avg	1.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 201 / 11 KV VINCHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.381	.4191	.4382	.381	.381	2.5873
2	.2858	.381	.4763	.4382	.381	.381	2.5873
3	.2858	.381	.4763	.4382	.381	.381	2.5873
4	.2858	.381	.5716	.4382	.381	.381	2.5873
5	.2858	.381	.6478	.4763	.4763	.381	2.7721
6	.2858	.5716	.724	.5335	.5716	.4763	2.9569
7	.3429	.6287	.724	.5906	.6668	.6668	3.1417
8	.381	.5716	.724	.5335	.381	.4763	3.3634
9	.362	.4763	.6668	.4001	.381	.3239	2.4949
10	2.4006	.381	.4001	.381		.2858	2.7721
11	.2286	3.0121	2.8645	2.7435	2.4451	2.7721	.2286
12	.2286	3.5101	3.4189	3.2579	2.8045	3.3634	.2286
13	.2286	3.6595	3.5113	3.4294	2.8395	3.4004	
14	2.9622	3.6595	3.5113	3.2579	2.9447	3.4189	
15	3.1024	3.6408	3.5113	3.0864	3.0007	3.0308	
16	2.4006	3.6408	3.5113	2.915	3.1024	3.2341	
17	1.8861	3.3608	3.6037	3.2579	2.9447	3.2341	.381
18	2.4863	3.1367	2.9569	2.915	2.8921	3.0493	.381
19	.4763	.381	.4572	.4763	.5144	.5525	.4763
20	.4763	.381	.5335	.4763	.5525	.6287	.4763
21	.4763	.4382	.5906	.4763	.4763	.6097	.4763
22	.5335	.4382	.4572	.4763	.4763	.5335	.381
23	.4763	.381	.4763	.381	.381	.4382	.2858
24	.3429	.381	.362	.4382	.381	.381	.381
Max	3.1024	3.6595	3.6037	3.4294	3.1024	3.4189	3.3634
Min	.2286	.381	.362	.381	.381	.2858	.2286
Avg	.8961	1.4398	1.4832	1.3440	1.2937	1.3659	1.5773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 202 / 11 KV VADAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2584	4.4582	5.967	5.5442	5.144	5.83	.5716
2	5.2584	4.4582	6.1328	5.5442	5.3441	5.83	.5716
3	5.3156	4.4582	6.2986	5.5442	5.144	5.83	.5716
4	5.3726	4.4582	6.7216	5.5442	5.144	5.83	.5716
5	5.3156	4.4582	7.0542	6.2834	5.83	6.5158	.5716
6	5.2584	5.487	6.7902	5.729	7.3732	7.2016	.6858
7	6.3786	6.8588		7.3922	7.3732	7.716	.762
8	6.9844	7.3732		7.577	6.8588	6.2072	.6858
9	7.0112	6.7064		7.2074	6.8588	6.6256	.4954
10	6.6606	6.0022	.5334	7.0226	4.4582	4.5222	.381
11	.343	.4572	.4572	.381	.362	.4954	6.5158
12	.4572		.4191	.381	.381	.4192	7.8876
13	.4191	.381	.381	.381	.4572	.4192	7.8876
14			.4572	.381	.4572	.4192	
15	.5716		.4382	.381	.4572	.4572	
16	.5716	.4572	.4954	.381	.4954	.5334	
17			.4572	.1905	.4572	.4954	7.8876
18	.762	.6858	.2477	.381	.5716	.6478	7.838
19	.762	.6858		.381	.8764	.8764	4.1533
20	.762	.6858	.2858	.5715	.9144	.9144	.762
21	.762	.724	.3429	.762	.6858	.8382	.762
22	.762	.724	.3239	.762	.5716	.724	.762
23	.5716	.6478	.5716	.5716	.5716	.6096	.5716
24	.343	.5716	.5716	.381	.5716	.5716	.5716
Max	7.0112	7.3732	7.0542	7.577	7.3732	7.716	7.8876
Min	.343	.381	.2477	.1905	.362	.4192	.381
Avg	2.9955	3.0369	2.2473	2.9031	2.8066	2.9387	2.4508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 203 / 11 KV KUSUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2291	3.0007	2.5873	2.0576	2.4539	.8573
2	2.2786	2.2291	3.0007	2.5873	2.4006	2.4006	.8573
3	2.2786	2.2291	3.1893	2.5873	2.4006	2.4539	.8573
4	2.2786	2.2291	3.1893		2.4006	2.4006	.8573
5	2.2786	2.2291	3.2247	2.7721	2.4006	2.4539	.8573
6	2.2786	2.7435	3.1539	3.1417	2.915	2.8045	.9526
7	2.572	3.2579	3.1539	3.4189	2.915	3.0148	.9907
8	3.0178	3.4294	3.2217	3.3265	2.915	2.5377	.8573
9	2.9447	3.5665	3.658	3.1417	2.915	2.7343	.5335
10	2.7343	3.5269	.5335	3.0493	.6859	2.5377	.0762
11	.6097	.5716	.5335	.5716	.2286	.6859	2.4863
12	.6859	.6478	.4382	.6668	.2286	.6859	2.7435
13	.6859	.6859	.8383	.6668	.2286	.6859	2.7435
14	.7621	.6859	.8383	.6668	.2286	.743	
15	.7621	.724	.8383	.7621	.2667	.6859	
16	.7621	.743	.8002	.6668	.3048	.6859	
17			.8383	.7621		.7621	3.1722
18		.6287	.7621	.7621	.4763	.8383	3.0864
19	.5716	.5716	.7621	.7621	.6859	.9907	.6668
20	.5716	.4763	.6097	.4763	.6097	1.0098	.8573
21	.5716	.381	.5335	.4763	.6097	.9907	.8573
22	.5716	.2286	.4572	.4763	.5335	.9526	.8573
23	.2858	.2286	.4572	.2858	.381	.8954	.7621
24		.2858	.1524	.3048	.2858	.2858	.8573
Max	3.0178	3.5665	3.658	3.4189	2.915	3.0148	3.1722
Min	.2858	.2286	.1524	.2858	.2286	.2858	.0762
Avg	1.4751	1.5012	1.5910	1.5182	1.2641	1.5287	1.2756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 204 / 11 KV INDIAN PUBLIC SCHOOL SINGLE PHASING
(IP Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.1143	.1143	.0953	.0762	1.2936
2	.0762	.0953	.1524	.1143	.0953	.0762	1.2936
3	.0762	.0953	.1524	.1143	.0953	.0762	1.2936
4	.0762	.0953	.1905	.1143	.0953	.0762	1.2936
5	.0762	.0953	.1905	.1143	.1905	.0762	1.2936
6	.0762	.1905	.2286	.1524	.1905	.0953	1.4784
7	.0762	.1905	.2286	.1905	.1905	.0953	1.6632
8	.0762	.0953	.2286	.1715	.1905	.0953	1.848
9	.0762	.0953	.1905	.1334	.0953	.0762	1.848
10	1.8229	.0953	.1524		.0953	.0762	1.5708
11	.0572	1.286	1.5893	1.5432	1.1488	1.386	.0953
12	.0572	1.7814	1.885	1.8004	1.1393	1.848	.0953
13	.0572	1.6724	1.848	1.8004	1.1317	1.848	.0953
14			1.9404	1.8004	1.1568	1.9035	
15	1.6832		1.9404	1.8004	1.0867	1.848	
16	1.6832	1.8187	1.9404	1.7147	1.046		
17		1.5746	2.0698	1.5432	1.3847	1.848	.0953
18	1.7147	1.5261	2.0328	1.3717	1.0288	1.6632	.0953
19	.1524	.0953	.1334	.1905	.0953	.1524	.1905
20	.1524	.1334	.1905	.1524	.0953	.1524	.1524
21	.1524	.1334	.1715	.1524	.0762	.1524	.1524
22	.1524	.1334	.1143	.1524	.0762	.1334	.1524
23	.0953	.1334	.1143	.0953	.0762	.1143	.0953
24	.2286	.0953	.1143	.1143	.0953	.0762	.1143
Max	1.8229	1.8187	2.0698	1.8004	1.3847	1.9035	1.848
Min	.0572	.0953	.1143	.0953	.0762	.0762	.0953
Avg	.3952	.5239	.7464	.6718	.4571	.6063	.7719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 205 / 11 KV EXPRESS FDR
CRE/PHONIX Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0924	.1097	.0739	.1463	.0905	.0739
2	.0554	.0924	.1097	.0732	.1463	.0914	.0732
3	.0543	.0924	.1097	.0732	.1463	.0905	.0732
4	.0532	.0924	.0924	.0924	.1463	.0914	.0716
5	.0537	.0924	.0924	.0914	.1463	.0905	.0905
6	.0543	.0924	.0924	.1097	.1463	.0914	.0905
7	.0532	.0924	.0924	.1075	.1463	.1109	.0895
8	.0377	.0924	.0924	.0709	.1463	.0754	.0905
9	.0366	.0924	.0914	.0709	.0914	.0754	.0924
10	.056	.0739	.128	.0886	.0924	.0739	.0924
11	.0566	.0739	.1109	.0895	.1109	.1294	.0924
12	.0566	.0943	.1097	.0905	.1063	.1294	.0924
13	.0549	.0943	.1086	.0905	.1086	.1294	.0924
14	.0373	.132	.1097	.1448	.1109	.1109	.1109
15	.0554	.1478	.1109	.1463	.112	.1109	.1109
16	.1109	.1478	.1109	.1848	.1294	.0934	.1109
17	.1109	.1448	.1109	.1848	.0943	.0739	.1097
18	.1109	.1402	.0934	.1848	.0739	.0537	.0924
19	.1109	.1402	.0924	.1478	.0754	.0739	
20	.1109	.1254	.0739	.1478	.0362	.0934	.0914
21	.0924	.1254	.0739	.1478	.0543	.0924	.0914
22	.0924	.1097	.0747	.1478		.0924	.0914
23	.0924	.1029	.0924	.1463		.0739	.0914
24	.0554	.0924	.1097	.0924	.1463		.0739
Max	.1109	.1478	.128	.1848	.1463	.1294	.1109
Min	.0366	.0739	.0739	.0709	.0362	.0537	.0716
Avg	.0691	.1074	.0997	.1166	.1142	.0930	.0908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 207 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5716	.4954	.4382	.5144	.381	1.5708
2	.381	.5716	.4954	.4382	.5144	.381	1.5708
3	.381	.5716	.4954	.4382	.5144	.381	1.5708
4	.381	.5716	.4954	.4382	.5144	.381	1.5708
5	.381	.5716	.5335	.4382	.5144	.381	1.6632
6	.381	.6097	.5335	.4763	.5144	.4191	1.848
7	.381	.6287	.5335	.4763	.5144	.4763	1.9774
8	.4763	.5716	.5335	.4382	.5144	.4954	2.1253
9	.3429	.4763	.4763	.4763	.381	.4382	2.1253
10	2.0157	.381	.3429	.381	.381	.4763	2.0328
11	.2096	1.7147	2.1253	1.8004	1.8642	1.9774	.381
12	.3429	1.4586	2.1622	2.0576	2.1033	2.3655	.5716
13	.4001	1.4586	2.0328	2.0576	2.1735	2.3655	.5716
14			1.9774	1.7147	2.2085	2.3285	
15	2.191		1.9589	2.0576	2.1605	2.2177	
16	2.1434	2.1795	1.9774	2.1434	2.1605		
17		2.0957	2.1253	2.1434	2.0858	1.9959	.5716
18	2.2291	2.0622	2.0698	1.9719	2.0157		.5716
19	.4287	.4191	.4382	.5716	.4382	.381	.4763
20	.5716	.4191	.4382	.5716	.4191	.4382	.4763
21	.5716	.4954	.4763	.5716	.5335	.4382	.4763
22	.5716	.4954	.4572	.5716	.4191	.4191	.381
23	.5716	.4382	.4382	.5144	.4191	.381	.2858
24	.4954	.5716	.4954	.4382	.5144	.381	.381
Max	2.2291	2.1795	2.1622	2.1434	2.2085	2.3655	2.1253
Min	.2096	.381	.3429	.381	.381	.381	.2858
Avg	.7377	.8788	1.0045	.9844	1.0164	.9045	1.1047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 201 / 11 KV BALAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5074	1.5432	1.5089	1.0059	1.5432	1.4251	.3961
2	1.5565	1.5432	1.6095	1.4918	1.5432	1.5249	.4108
3	1.6385	1.6289	1.6575	1.5089	1.5432	1.7238	.3772
4	1.7736	1.7147	1.8107		1.7147	1.8842	.3772
5	1.8842	1.8861	1.989	1.8442	1.8004	2.0553	.4481
6	2.4863	2.2291	2.1628	1.8896	1.9719	2.1548	.4715
7	2.4034	2.4863	2.2874	2.1795	2.2291	2.1956	.5281
8	2.2939	2.6235	2.42		2.4348	2.2542	.3921
9	2.4086	2.572	2.5069	2.3758	2.4006	2.2611	.2452
10	2.4863	2.3537	2.3266	.3772	2.2466	2.2377	.1307
11	.1715	.3018	.2949	.2915	.2641	.1886	2.1628
12	.1715	.3734	.3734	.3772		.2829	2.2939
13	.0154	.415		.3429		.2829	
14	.1715	.4115		.3429	.3018	.3361	
15	.1886	.4115	.3174	.3772	.3395	.3734	2.4086
16		.4115	.3174	.3944	.3772	.3206	2.4577
17		.3944	.3109	.3772	.3772	.3772	2.5888
18	.0857	.415	.3174	.3086	.3584		2.5857
19	.3258	.3395	.3734	.3086	.3395	.3395	.2801
20	.3601	.3772	.3734	.3086	.2641	.4481	.2801
21	.2915	.2987	.3734	.2058	.2241	.4481	.2801
22	.2058	.2263	.2829	.1715	.2263	.3961	.2452
23	.1886	.1886	.1867	.1372	.1886		.2427
24	.1715	.1029	.1509	.1307	.1372	.1698	.3772
Max	2.4863	2.6235	2.5069	2.3758	2.4348	2.2611	2.5888
Min	.0154	.1029	.1509	.1307	.1372	.1698	.1307
Avg	1.0357	1.052	1.0887	.7612	1.0375	1.0764	.9082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 203 / 11 KV B'KAWATHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	.415	.5601	.463	.4527	.852
2	.3772	.3429	.3734	.6036	.463	.5228	1.2929
3	.3429	.4287	.415	.5601	.5144	.6036	1.7238
4	.6001	.6001	.5228		.5487	.7468	2.1548
5	.8573	.6859	.7545		.6859	.8676	2.3102
6	.9945	.9259	.8962		.8916	.9054	2.5652
7	.8573	.8916	.9808	1.1016	.6859	.9619	2.7183
8	.6001	.5487	.7545		.5487	.7167	2.9007
9	.4801	.5144	.4904	.5847		.4338	2.556
10	2.4006		.3734	.4287	.3772	.2743	1.8842
11	2.452	3.1824	3.2769	3.5322	2.7846	2.8509	.3361
12	2.915	3.2819	3.3589	3.7037	2.9835	3.1327	.3734
13	3.2579	3.514	3.4736	3.738	3.0803	2.9656	
14	3.4294	3.6866	3.7304		3.1459	2.9656	
15	3.6008	3.5637	3.5608	2.915	3.1131	3.1327	.4668
16	3.7723	3.1295	3.6702	3.155	3.0996	3.0639	.4668
17	3.6866	3.7894	3.7626	3.1207		2.9492	.4715
18	3.6866	4.0962	3.7294	3.1379	2.982	2.536	
19	.3429	.6413	.6722	.4287	.6224	.5847	.7842
20	.5487	.6722	.7468	.6859	.7095	.7545	.7842
21	.5144	.6036	.6535	.5487	.7545	.6722	.7095
22	.4801	.5281	.5975	.5144	.679	.5658	.5975
23	.463	.4715	.5601	.463	.5658		.5041
24	.4287	.4287	.4527	.5041	.463	.5281	.4904
Max	3.7723	4.0962	3.7626	3.738	3.1459	3.1327	2.9007
Min	.3429	.3429	.3734	.4287	.3772	.2743	.3361
Avg	1.5632	1.6031	1.5926	1.5940	1.3710	1.4429	1.2830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 204 / LOKMANGAL EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 205 / 11 KV AMBEDKAR NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.6036	.6718	.8573	1.0395	.2801
2	.6516	.5144	.6371	.6554	.8573	1.0898	.3018
3	.6299	.6001	.663	.6962	1.0288	1.1603	.3018
4	.663	.6001	.7042	.6882	1.1145	1.1934	.3018
5	.6554	.6001	.7293	.6882	1.2003	1.2742	.2801
6	.7459	.6859	.7712	.6962	1.2003	1.2929	.2801
7	.7459	.7373	.7625	.8122	1.286	1.2763	.3174
8	.779	.7545	.8048	.8122	1.3717	1.3108	.3018
9	.8192	.6859	.8288	.8122	1.3375	1.2929	.3772
10	.8478	.6706	.8192	.823	1.3245	1.2763	.2801
11	.1886	.132	.1867	.2058		.1372	1.278
12		.1307	.2241	.2058	.2614	.1543	
13			.2614	.2058	.2829	.1543	
14				.2058	.2829	.2241	
15			.1867	.2058	.2452	.2241	1.2289
16			.2241	.2058	.2263	.2241	1.3108
17	.1715		.2241	.1715	.2263	.2452	1.4255
18	.1715		.2614	.1715	.2452	.2452	1.4089
19	.1715		.2427	.1715	.1698	.3018	.2801
20	.1715	.0943	.2241	.1715	.168	.2801	.2801
21	.1372	.1494	.1886	.12	.1509	.2801	.2614
22	.1029	.1132	.1307	.0857	.1132	.2801	.2427
23	.0514	.0754	.0934	.0514	.0943		.2427
24	.0343	.0514	.0754	.0934	.0514	.0754	.2801
Max	.8478	.7545	.8288	.823	1.3717	1.3108	1.4255
Min	.0343	.0514	.0754	.0514	.0514	.0754	.2427
Avg	.4208	.4031	.4281	.4011	.6129	.6536	.5363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 207 / 11 KV TELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3772	.5228	.2743	.3772	.6962
2	.3429	.3086	.3361	.5658	.2743	.3361	1.1437
3	.3429	.3429	.3395	.5228	.3086	.3395	1.5746
4	.3772	.3772	.3734	.5228	.3429	.3734	2.0454
5	.4287	.4458	.415	.5601	.3772	.4527	2.0719
6	.463	.4458	.4527	.5975	.4458	.5281	2.1216
7	.4458	.4458	.4527	.6036	.3772	.5658	2.3807
8		.3429		.4854	.3429	.4904	2.4531
9	.2572	.3086	.3772	.4527	.2743	.3961	2.4531
10	.2572	.2572	.2987				2.3266
11	2.915	2.7846	2.6871	2.9492	2.6852	2.6216	
12	2.9492	2.8837	3.0312	2.9835	2.8841	3.083	
13	2.9835	2.9504	3.2769	3.0178	2.9492	2.9492	
14	3.0178	2.982	3.1878	3.0864	3.0476	3.2819	
15	3.0864	3.2712	2.9835	3.1207	3.0148	2.982	.2801
16	3.155	3.2712	2.9843	3.155	2.9835	3.0498	.3734
17	3.1207	3.195	3.0476	3.155	2.982	2.9165	.4668
18	3.155	3.5063	3.0167	3.0864	2.967	2.9835	.5658
19	.3086	.4527	.5228	.3086	.3961	.3772	.5658
20	.3429	.5281	.5415	.2743	.4715	.3772	.5041
21	.3429	.4854	.4854	.2743	.5228	.2987	.4294
22	.3429	.4527	.5041	.2743	.4527	.2987	.3174
23	.3429	.4527	.4854	.2743	.415		.3174
24	.3429	.3429	.4338	.5228	.2743	.4338	.3018
Max	3.155	3.5063	3.2769	3.155	3.0476	3.2819	2.4531
Min	.2572	.2572	.2987	.2743	.2743	.2987	.2801
Avg	1.2897	1.2976	1.3309	1.3616	1.2636	1.3415	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 201 / 11 KV FATATEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9431	.8402	.7545	.8488	.8488	.6859
2	.8488	.9431	.8402	.8488	.8488	.9335	.6859
3	.8488	.9431	.9335	1.0374	.9431	1.1203	.8288
4	1.0269	1.0374	1.1203	1.2136	1.0374	1.2136	.9831
5		1.1317	1.307		1.3203		1.3108
6		1.226	1.307				1.4403
7		.924	1.307				1.7604
8		1.0269	.9335		.9431		1.7604
9	1.1203	.7545	.6535	1.1203	.9431	1.2136	1.8976
10		.7468	.5601	.8488	.7545	.8402	1.2146
11	1.8023	1.4746	1.3108	1.7528	1.3717	1.4746	.4668
12	1.7814	1.7814	1.7604	2.0576	1.7147	1.9433	.3734
13	1.9204	1.8623	1.7604	2.0576	1.8442	1.9204	
14	1.6004	1.7004	1.7604	2.0576	1.8442	1.9204	
15	1.8623	1.7004	1.6004	1.8861	1.8442	1.7604	
16	1.6194	1.9662	1.7814	1.8861	1.6766	1.7604	
17	1.8023	2.0243	1.7814	1.7337	1.7604		.8402
18	1.8233	1.8023	2.0481	1.8004	1.5089	1.6194	.9335
19	1.1317	.7468	1.1203	1.226	1.1203	1.0059	1.226
20	1.3203	1.307	1.2136	1.3203	1.1203	1.1088	1.3203
21	1.3203	1.307	1.2136	1.3203	1.1203	1.1888	1.307
22	1.226	1.2136	1.1203	1.1317	1.2136	1.0164	1.1203
23	.9431	1.0269	.8402	.9431	1.1203	.7316	.9335
24	.9335	.9431	.8402	.7545	.8488	.8488	.6401
Max	1.9204	2.0243	2.0481	2.0576	1.8442	1.9433	1.8976
Min	.8488	.7468	.5601	.7545	.7545	.7316	.3734
Avg	1.3569	1.2722	1.2481	1.3876	1.2613	1.2879	1.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 202 / 11 KV AUJ HIPPALE YATNAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6554	.6001	.6001	.6783	.6001	.6401
2	.6859	.7459	.6001	.6001	.663	.6859	.6401
3	.7716	.8383	.6001	.6859	.7373	.6859	.7316
4	.9431	1.0174	.763	.7716	.8192	.9431	1.0059
5	1.0288	1.1022	.9326	1.0174	.9945	1.0288	1.1765
6	1.2003	1.3565	1.0174	1.3565	1.2574	1.2003	1.2536
7	1.6766	1.7147	1.6194	1.6575	1.7147	1.6766	
8	1.6766	1.7147	1.6004	1.6575	1.7147	1.6766	
9	1.3717	1.3717	1.4403	1.6575	1.3565	1.5261	.8402
10	1.326	1.3413	1.2803	1.0059	1.2003	1.3413	.6468
11	.6535	.5601	.5601	.5544	.5658	.5601	.8002
12	.5601	.5601	.5601	.462	.4715	.5601	1.3108
13	.5601	.5601	.5601	.4668	.4715	.5487	1.3108
14	.5601	.5601		.4668	.4715	.5487	.9602
15	.7468	.5601		.5658	.4715	.543	.9602
16	.6535	.5601	.5601	.4715	.4715	.5373	1.0155
17	.7468	.5601	.5601	.4668	.5658		1.0669
18	.7468	.6535	.5601	.6468	.5658	.724	1.0936
19	1.0374	.7468	.9431	.9335	.9431	.8316	1.0164
20	1.0269	1.0269	1.0374	1.1317	.9335	1.0059	1.0269
21		1.0269	.9431	.9431	.9335	1.0059	.9431
22	.8316	.8402	.8402	.8488	.9335	.8316	.9431
23	.6468	.6535	.7468	.7468	.7468	.6468	.7545
24	.6602	.6535	.6535	.5658	.5544	.6602	.6401
Max	1.6766	1.7147	1.6194	1.6575	1.7147	1.6766	1.3108
Min	.5601	.5601	.5601	.462	.4715	.5373	.6401
Avg	.9042	.8908	.8627	.8450	.8432	.8856	.9444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 203 / 11 KV HOTAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6001	.6001	.5144	.6001	.6001	.6602
2	.6859	.5935	.6001	.5144	.5935	.6001	.6602
3	.7716	.5935	.6001	.5144	.5868	.6859	.6602
4	.7716	.6706	.6859	.6001	.6706	.7716	.7545
5	.8573	.7545	.8573	.8478	.7716	.9431	.9431
6	1.1145	.9431	.9431	1.0174	.8573	1.1145	1.1317
7	1.2003	1.2003	1.2003	1.1869	1.2136	1.3717	
8	1.2003	1.286	1.1869	1.1869	1.286	1.286	
9	1.1145	1.2136	1.065	1.1022	1.0059	1.286	.9431
10	.9831	1.065	.9831	1.0059	1.0898	1.4918	.6602
11	.5658	.5658	.5658	.5544	.5658	.5658	.5144
12	.6602	.5658	.5658	.4668	.5658	.5658	.4191
13	.5658	.5658	.5658	.4715	.5658	.5658	.3315
14	.5658	.5658	.5658	.4715	.5658	.5658	.7373
15	.5658	.5658		.4715	.4715	.5658	.9012
16	.6602	.5658	.5658	.4715	.5658	.5658	1.1603
17	.6602	.5658	.5658	.4715	.5658		1.4089
18	.6602	.5658	.5658	.5658	.6602	.6602	.9221
19	.7545	.7545	.9431	.8488	.9431	.9431	.8402
20	.8488	1.0374	.9431	.9431	.8488	.9431	.8488
21	.7545	.9431	.8488	.8488	.8488	.8488	.8488
22	.6602	.7545	.7545	.7468	.7545	.6602	.7545
23	.5601	.6602	.6602	.5601	.6602	.6602	.6535
24	.2286	.5601	.6602	.5658	.5601	.5658	.6602
Max	1.2003	1.286	1.2003	1.1869	1.286	1.4918	1.4089
Min	.2286	.5601	.5658	.4668	.4715	.5658	.3315
Avg	.7540	.7565	.7605	.7062	.7424	.8186	.7915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 204 / 11 KV BHARAT GARMENT
EXPRESS Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381			.0381	.0381	.0381
2	.0381			.0381	.0381	.0381
3	.0381			.0381	.0381	.0381
4	.0381			.0381	.0381	.0381
5	.0381			.0381	.0381	.0381
6	.0381			.0381	.0381	.0381
7				.0381	.0381	.0381
8	.0953			.0381	.0381	.0381
9	.0381			.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381
14		.0381	.0381	.0381	.0381	.0381
15		.0381		.0381	.0381	.0381
16			.0381	.0381	.0381	.0381
17	.0381		.0381	.0381	.0381	
18			.0381	.0381	.0381	
19			.0381	.0381	.0381	
20			.0381	.0381	.0381	
21			.0381	.0381	.0381	
22			.0381	.0381	.0381	
23			.0381	.0381	.0381	
24	.0381			.0381	.0381	.0381
Max	.0953	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0422	.0381	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 201 / 11 KV YELEGAON(KANDALGAON) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	05-MAR-18
HR	Load (MW)
1	1.3413
2	1.5927
3	1.8442
4	1.8442
5	2.0119
6	2.2634
7	2.2634
8	2.0119
9	2.431
10	2.2634
11	.1867
12	.1867
13	.1867
14	.1867
15	.1867
16	.1867
17	.1867
18	.1867
19	.3734
20	.4668
21	.4668
22	.2801
23	.1867
24	.1867
Max	2.431
Min	.1867
Avg	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 202 / 11 KV BASAVNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-MAR-18
HR	Load (MW)
1	.2801
2	.2801
3	.2801
4	.2801
5	.3734
6	.3734
7	.4668
8	.3734
9	.2801
10	.2801
11	1.1736
12	1.3413
13	1.3413
14	1.3413
15	1.3413
16	1.3413
17	1.2574
18	1.1736
19	.3734
20	.3734
21	.3734
22	.3734
23	.3734
24	.3734
Max	1.3413
Min	.2801
Avg	.6591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 203 / 11 KV WANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
20		.2801
21		.2801
22		.2801
23		.1867
24	.2286	.1867
Max	.2286	.2801
Min	.2286	.1867
Avg	.2286	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 205 / 11 KV MANDRUP

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
1		.4668
24	.2286	
Max	.2286	.4668
Min	.2286	.4668
Avg	.2286	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 206 / 11 KV KARKAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 201 / 11 KV AUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.7147	1.7147	1.9719	1.8004	1.8861	.2715
2	1.8861	1.7147	1.7147	1.9719	1.8004	1.8861	.2715
3	1.8861	1.7147	1.7147	1.9719	1.8861	1.8861	.2715
4	1.8861	1.7147	1.7147	1.9719	1.8861	1.8861	.2715
5	2.0233	1.7147	1.8004	1.9719	1.9719	1.8861	.3258
6	2.0233	1.8861	1.8861	2.0576	2.0576	1.8004	.362
7	2.0919	2.2291	2.1434	2.3148	2.1434	1.8861	.3258
8	2.1091	2.3148	2.3148	2.2291	2.2291	2.1434	.2715
9	2.1434	2.4006	2.2291	2.3148	2.3148		.2715
10	2.2291	2.4006	2.4006	2.3148	2.3148		.181
11	.3429	.2172		.2715	.2172		2.3148
12	.3429	.2172	.3429	.181	.2715		2.3148
13	.3429	.2172	.3429	.181	.2353		2.3148
14	.3429	.2172	.3429	.181	.2715		2.2634
15	.3429	.2172	.3429	.181	.2172		
16	.3429	.2172	.3429	.181	.181		1.286
17	.3429	.181	.3429	.181	.3429		1.2003
18	.3429	.181		.181	.3429		1.3375
19	.3772	.2715	.5144	.4344	.5144		.3258
20	.4287	.2715	.5144	.3258	.5144		.362
21	.3086	.2715	.3429	.2715	.4115		.543
22	.2572	.2715		.2715	.3429		.2715
23	.2572	.2715	.2572	.2715	.2572		.2715
24	.2058	.2572	.2715	.2572	.2715	.2572	.3258
Max	2.2291	2.4006	2.4006	2.3148	2.3148	2.1434	2.3148
Min	.2058	.181	.2572	.181	.181	.2572	.181
Avg	1.0309	.9619	1.1234	1.0192	1.0332	1.7242	.7806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 202 / 11 KV TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.8004	1.8004	2.2291	2.0576	1.9719
2	2.0576	1.8004	1.8004	2.2291	2.0576	1.9719
3	2.1605	1.8004	1.8004	2.2291	2.3148	1.9719
4	2.3148	1.8004	1.8004	2.2291	2.3148	1.9719
5	2.3148	1.8861	1.8861	2.2291	2.4006	1.9719
6	2.3148	1.9719	1.8861	2.3663	2.4863	2.1434
7	2.4863	2.1948	2.4863	2.6406	2.6406	2.452
8		2.4006	2.7263	2.6749	2.7435	2.5377
9	2.4348	2.572	2.6406	2.7949		
10	2.3491	2.3148	2.572	2.6063	2.6063	
11	.3429	.3801	.3429	.362		
12	.4458	.3982	.3601	.3801		
13	.4287	.3982	.4115	.3801	.362	
14	.4287	.4163	.4115	.3982	.4344	
15	.3944	.3982	.3944	.4525	.4163	
16		.4344	.4287	.6878	.4163	
17	.4115		.4287	.4525	.3944	
18	.4801		.4287	.4887	.4287	
19	.5658	.5973	.6001	.543	.5658	
20	.5658	.6878	.6001	.5973	.5658	
21	.5316	.6335	.5316	.543	.5487	
22	.5144	.5068	.5144	.4525	.5144	
23	.5144	.4344	.4287	.3982	.463	
24	.2286	.4115	.3982	.4287	.3982	.4115
Max	2.4863	2.572	2.7263	2.7949	2.7435	2.5377
Min	.2286	.3801	.3429	.362	.362	.4115
Avg	1.1974	1.1927	1.1533	1.2830	1.2919	1.9338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 203 / 11 KV NANDANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.3258	.2915	.2715	.2915	1.2003
2	.3086	.2915	.3258	.2915	.2715	.2915	1.2003
3	.3086	.2915	.3258	.2915	.2715	.2915	1.2003
4	.3429	.2915	.3801	.2915	.3258	.2915	1.2003
5	.3944	.3429	.3801	.3429	.3258	.3429	1.286
6	.3429	.4115	.4163	.4115	.3801	.4287	1.286
7	.3258	.3772	.4163	.3601	.3801	.3601	1.3375
8	.2915	.3086	.3258	.3258	.3077	.2743	1.3375
9	.2229	.2534	.2401	.2534	.2172		1.3375
10	.2401	.2353	.2401	.3258	.2172		1.1317
11	1.5432	1.3889	1.406	1.3889	1.3546		.181
12	1.8861	1.6975	1.5775	1.5604	1.3717		.2172
13	1.9204	1.6804	1.5775	1.6804	1.3375		.2172
14	1.8004	1.6461	1.5775	1.6804	1.3032		.2172
15	1.7833	1.6461	1.5775	1.6804	1.3717		
16	1.8519	1.6975	1.6289	1.6975	1.3889		
17	1.6118	1.6804	1.6289	1.6804	1.4746		.2715
18	1.6118	1.6632	1.6289	1.5604	1.2003		.362
19	.3944	.3801	.4115	.4163	.3429		.4525
20	.4287		.4115	.4344	.4287		.5068
21	.3601	.4163	.4115	.3801	.4287		.4525
22	.3429	.3801	.3772	.3439	.4287		.362
23	.3429	.3439	.3429	.3258	.3429		.3258
24	.2915	.2915	.3258	.2915	.2715	.2915	.3077
Max	1.9204	1.6975	1.6289	1.6975	1.4746	.4287	1.3375
Min	.2229	.2353	.2401	.2534	.2172	.2743	.181
Avg	.8023	.7829	.7608	.7628	.6673	.3182	.7450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV KUDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4801	.4887	.5144	.543	.5144	2.2291
2	.5144	.4801	.4887	.5144	.543	.5144	2.2291
3	.5144	.4801	.5792	.5144	.543	.5144	2.3148
4	.4801	.5144	.6516	.5144	.6335	.5144	2.4006
5	.4801	.6859	.724	.6001	.6878	.6001	2.4006
6	.6173	.8402	.7964	.7888	.7421	.7545	2.5377
7	.6687	.7202	.4706	.7716	.7602	.6687	2.572
8	.6173	.6173	.543	.6154	.5611	.4458	2.5892
9	.3772	.3982	.2915	.4344	.3077		2.572
10	.3258	.3982	.3086	.3801	.2743		2.3663
11	2.7092	2.7435	2.8807	2.7092	2.7092		.3258
12	2.7606	2.8292	2.8121	2.7949	2.572		.3258
13	2.6749	2.8807	2.8121	2.7092	2.6578		.3258
14	2.915	2.8807	2.7435	2.7092	2.6578		.3258
15	3.035	2.8807	2.7263	2.6749	2.7092		.3258
16	3.0007	3.2922	3.0007	2.7092	2.7092		.362
17	3.0007	3.3951	3.0864	2.8635	2.7606		.362
18	2.8807	3.4808	3.0864	2.7435	2.9492		.4706
19	.583	.6697	.6173	.6516	.6344		.6516
20	.6516	.7421	.6859	.6697	.6859		.7783
21	.6344	.6335	.6687	.5973	.6173		.6878
22	.6001	.543	.6001	.543	.5487		.5973
23	.5144	.4887	.5144	.5068	.5144		.543
24	.4973	.4801	.4887	.5144	.4887	.5144	.543
Max	3.035	3.4808	3.0864	2.8635	2.9492	.7545	2.5892
Min	.3258	.3982	.2915	.3801	.2743	.4458	.3258
Avg	1.3153	1.3981	1.3361	1.2935	1.2838	.5601	1.2848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV KURGHOT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0686		.0686	
8			.0686	.0686	.0686	
9		.0686		.0686	.0686	
10		.0686		.0686	.0686	
11						.0686
12						.0686
13						.0686
14						.0686
24	.2286					
Max	.2286	.0686	.0686	.0686	.0686	.0686
Min	.2286	.0686	.0686	.0686	.0686	.0686
Avg	.2286	.0686	.0686	.0686	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV RTO CHECK POST
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0181
2	.0343	.0343	.0343	.0343	.0343	.0343	.0362
3	.0343	.0343	.0343	.0343	.0343	.0343	.0362
4	.0343	.0343	.0343	.0343	.0343	.0343	.0362
5	.0343	.0343	.0171	.0343	.0171	.0343	.0362
6	.0343	.0171	.0171	.0343	.0171	.0171	
7	.0171	.0171	.0171	.0171	.0171	.0171	.0181
8	.0171	.0171	.0171	.0171	.0171	.0171	.0181
9	.0171	.0171	.0171	.0171	.0181		.0181
10	.0171	.0171	.0171	.0171	.0181		.0181
11	.0171	.0171	.0171	.0171	.0181		.0181
12	.0171	.0171	.0171	.0171	.0181		.0181
13	.0171	.0171	.0171	.0171	.0181		.0181
14	.0171	.0171	.0171	.0171	.0181		.0181
15	.0171	.0171	.0171	.0171	.0181		
16	.0171	.0171	.0171	.0171	.0181		
17	.0171	.0171	.0171	.0171	.0171		
18	.0171	.0171	.0171	.0171	.0171		
19	.0343	.0171	.0171	.0171	.0171		
20	.0343	.0171	.0343	.0171	.0343		
21	.0343	.0171	.0343	.0171	.0343		
22	.0343	.0171	.0343	.0171	.0343		
23	.0343	.0171	.0343	.0171	.0343		
24	.0343	.0343	.0171	.0343	.0171	.0343	.0362
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0362
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0181
Avg	.0257	.0214	.0228	.0221	.0232	.0286	.0246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / 11 KV TANDULWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.3048	.1524	.1524	.1524	.5487
2	.1524	.1524	.1524	.1524	.1524	.1524	.5487
3	.2286	.2286	.2286	.2286	.2286	.2286	.6516
4	.3048	.4572	.4572	.3048	.4572	.381	.6859
5	.6097	.6859	.6859	.4572	.6859	.5335	.6859
6	.7621	.8383	.7621	.7621	.8383	.7621	.823
7							1.0288
8							1.0288
9	.6859	.7621	.6097	.6859	.6859	.6859	.9602
10	.6097	.5335	.4572	.6097	.4572	.4572	.8916
11	1.0288	.823	.6173	.7545	.6859	.8916	.1524
12	1.0288	.823	.8916	.823	.9602	.9602	.0762
13	1.0974	1.0974	.823	.8916	.9602	.9602	.0762
14	1.2346	1.0288		.8916	.8916	.8916	.0762
15	2.4006	1.0974	.823	.8916	.8916	.8916	.1524
16	1.0974	1.0288	.9602	.823	.8916	.9709	.1524
17	1.0288	.8916	.9602	.8916	.8916	.8916	.2286
18	.8916	.9602	.823		.823	.6859	.2286
19	.4572	.5335	.5335	.2286	.5335	.5335	.6097
20	.5335	.5335	.6097	.4572	.5335	.6859	.381
21	.4572	.5335	.5335	.5335	.4572	.5335	.3048
22	.381	.381	.3048	.2286	.3048	.2286	.2286
23	.2286	.2286	.2286	.2286	.3048	.2286	.1524
24	.2286	.1524	.3048	.1524	.2286	.1524	.2286
Max	2.4006	1.0974	.9602	.8916	.9602	.9709	1.0288
Min	.1524	.1524	.1524	.1524	.1524	.1524	.0762
Avg	.7091	.6329	.5748	.5309	.5916	.5845	.4542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / 11 KV MUSTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6668	.7621	.7621	.7621	.6097	1.3717
2	.743	.6668	.7621	.7621	.7621	.7621	1.3717
3	.8383	.7621	.9145	.8002	.9145	.9907	1.4403
4	.9907	.9526	.9907	.9145	.9526	.9907	1.5432
5	1.1812	1.1431	1.1431	1.1812	1.2955	1.0288	1.5432
6	1.2955	1.1622	1.2193	1.3527	1.3908	1.0669	1.989
7							2.3491
8							2.3663
9	1.0288	1.0098	.8764	1.0669		.7621	2.3491
10	.7621	.7621	.5716	.7621	.8002	.7621	1.9547
11	2.3148	2.0576	2.0919	1.9204	1.749	1.9547	.5335
12	2.7435	2.4863	2.6063	2.3663	2.2996	2.572	.4763
13	2.8292	2.6216	2.6406	2.3834	2.5377	2.572	.4572
14	2.7435	2.5888	2.5377	2.6578		2.332	.4382
15	2.572	2.4905	2.5549	2.572	2.2672	2.2291	.4572
16	2.4863	2.4249	2.6749	2.5377	2.2024	2.2291	.4572
17	2.572	2.3922	2.7435	2.1262	2.2672	2.5549	.5335
18	2.4006	2.3922	2.2634	2.1605	2.2024	2.3834	.6859
19	1.1431	.9907	1.086	.9145	.9907	1.0669	.9526
20	1.1431	1.0669	1.105	.9526	1.0288	1.1431	1.0479
21	.8954	.9907	.9526	1.0098	.9907	1.0098	1.0098
22	.8383	.9145	.8573	.9526	.9526	.9526	.7621
23	.7621	.8002	.8002		.9526	.9145	.6859
24	.6859	.6668	.7621	.7621	.8192	.8002	.8764
Max	2.8292	2.6216	2.7435	2.6578	2.5377	2.572	2.3663
Min	.6859	.6668	.5716	.7621	.7621	.6097	.4382
Avg	1.5298	1.4550	1.4962	1.4723	1.4069	1.4403	1.1522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3717	1.5775	.9602	1.2003	1.6461	1.3336
2	1.3717	1.3717	1.6461	1.3032	1.2003	1.7147	1.3717
3	1.5089	1.5089	1.7147	1.3717	1.2346	1.7147	1.4861
4	1.7147	1.5775	1.7833	1.5775	1.3717	1.7833	1.5242
5	2.0576	1.8861	1.9204	1.7833	1.5089	1.8519	1.7528
6	2.1948	2.0576	2.0576	1.9204	1.7147	1.9204	
7	2.5377	2.8807	2.8197	2.6749	2.332	2.4006	
8	2.7435	2.9492	2.7435	2.8121	2.6749	2.7435	
9	2.5377	2.7435	1.5775	2.7435	2.4691	2.5377	
10	2.0576	2.4006	1.8519	1.3032	1.989	2.0576	
11	.9145	.9907	.7621	.8383	1.0669	.9145	
12	.9907	.8383	.7621	.7621	.7621	.8383	
13	1.0669	.8383	.7621	.8383	.7621	.8383	2.4691
14	.9145	.7621	.7621	.8383	.6859	.7621	2.4006
15	.8383	.7621	.8383	.8383	.6859	.7621	2.4006
16	.9145	.7621	.8383	.8383	.7621	.7621	2.4691
17	.8383		.9145	.9145	.7621	.8383	2.4006
18	.9907	.9907	1.0669		.9145		2.1262
19	1.5242	1.448	1.5242	1.1431	1.3717	1.7528	1.6004
20	1.5242	1.6004	1.6004	1.3717	1.5242	1.6766	1.6004
21	1.448	1.5242	1.5242	1.5242	1.5242	1.6004	1.6766
22	1.3717	1.3717	1.3717	1.3336	1.448	1.5242	1.5242
23	1.2955	1.2955	1.2955	1.2384	1.3717	1.3336	1.5242
24	.6173	1.2193	.823	.7545	1.166	1.2955	1.2955
Max	2.7435	2.9492	2.8197	2.8121	2.6749	2.7435	2.4691
Min	.6173	.7621	.7621	.7545	.6859	.7621	1.2955
Avg	1.4699	1.5283	1.4391	1.3775	1.3543	1.5334	1.8209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 204 / 11 KV NEW KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1143	.0953	.0953	.0762	.0953	.7888
2	.0762	.0953	.0953	.0953	.0762	.0953	.823
3	.1143	.0762	.0953	.0953	.0762	.1143	.8916
4	.1143	.0762	.1143	.1143	.0762	.1524	1.0288
5	.1524	.1524	.1524	.1524	.1334	.1905	1.0974
6	.1143	.1905	.1715	.1905	.2096	.2096	1.166
7							1.749
8							1.8861
9	.1143	.1905	.1524	.1905	.1524	.1334	
10	.0953	.1905	.1143	.1524	.1143	.1143	1.2003
11	1.7147	1.5432	1.4746	1.7147	1.6461	1.3032	.0762
12	2.0576	1.9204	1.9204	1.8176	1.9204	1.749	.0762
13	1.9204	1.9204	1.8519	2.1605	1.8519	1.9204	.0762
14	1.9204	1.9204	1.8861	1.8519	1.7833	1.989	.0762
15		2.0576	1.8861	1.8861	1.7833	1.9204	.0762
16	1.8004	2.0576	1.9204	1.8861	1.8519	1.8861	.0762
17	1.8861	1.9204	1.9204	1.8861	1.7833	1.8176	.0762
18	1.7147	1.989	1.7833	1.7833	1.7147	1.2003	.0953
19	.1905	.1524	.1524	.3239	.1715	.1905	.1524
20	.2096	.1334	.2096	.1334	.2096	.1905	.1905
21	.1905	.1143	.1905	.1334	.1905	.1524	.1905
22	.1524	.0953	.1143	.1143	.1334	.1524	.1524
23	.1524	.0953	.1143	.0762	.1334	.1334	.1143
24	.0953	.1143	.0953	.1143	.0762	.0953	.1143
Max	2.0576	2.0576	1.9204	2.1605	1.9204	1.989	1.8861
Min	.0762	.0762	.0953	.0762	.0762	.0953	.0762
Avg	.7077	.7782	.7505	.7713	.7347	.7184	.5293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 205 / 11 KV SANGDARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.166	.9945	.823	.823	1.1317	1.7147
2	1.0117	1.166	1.166	.9945	.8573	1.166	1.105
3	1.1317	1.2003	1.2346	1.166	1.0288	1.2346	1.1431
4	1.3717	1.3375	1.3717	1.3032	1.0288	1.3032	1.1812
5	1.4403	1.3717	1.3717	1.3717	1.2346	1.3717	1.3336
6	1.5261	1.4575	1.6461	1.6118	1.406	1.6461	1.6194
7	1.9547	2.0576	1.7833	1.989	1.9376	1.9204	
8	2.0576	2.2291	1.9547	2.1262	.6001	2.2977	
9	1.9204	1.7147	1.8176	1.5089	1.6804	1.8519	1.086
10	1.5089	1.4918	.9602	1.5432	1.4403	1.4403	.8383
11	.5906	.6097	.4382	.4954	.6097	.5716	1.5432
12	.6668	.6097	.381	.5335	.4191	.5335	1.4746
13	.6287	.4572	.4572		.4572	.5335	1.5089
14	.6668	.5335	.4954	.4954	.5335	.5144	
15	.743	.5335	.5144	.4954	.5335	.5525	1.5432
16	.6668	.5335	.5335	.4954	.5335	.5335	1.5604
17	.6668	.6097	.5525	.4954	.4954	.5335	1.5947
18	.743	.6097	.6478	.5716	.6097	.724	1.2955
19	1.2003	1.2193	1.2955	.7621	1.2193	1.2765	1.2193
20	1.1431	1.4098	1.3527	1.0479	1.2955	1.3336	1.2765
21	1.2193	1.2193	1.2955	1.2384	1.2955	1.3527	1.3146
22	1.2955	1.2955	1.2765	1.1812	1.2193	1.2384	1.3336
23	1.2003	1.2193	1.2003	1.1622	1.2193	1.1431	1.2574
24	.6173	1.2193	.8573	.6859	.7888	1.1812	
Max	2.0576	2.2291	1.9547	2.1262	1.9376	2.2977	1.7147
Min	.5906	.4572	.381	.4954	.4191	.5144	.8383
Avg	1.1222	1.1363	1.0666	1.0477	.9694	1.1411	1.3472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 206 / 11 KV PINJARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1524	.1143	.1143	.1524	.1715
2	.0953	.0762	.1143	.1143	.0953	.1524	.2058
3	.1143	.0762	.0953	.1143	.1143	.1524	.2401
4	.1905	.0762	.1143	.1524	.1524	.1524	.2401
5	.2286	.1524	.1524	.1905	.1905	.1905	.2401
6	.2286	.2667	.2286	.2286	.2286	.2286	.2401
7							.2743
8							.3258
9	.0953	.2286	.1905	.2286	.1905		.3258
10	.1143	.1905	.1524	.1524	.1524	.1905	.3944
11	.6001	.5144	.4973	.4115	.2743		.0762
12	.6001	.3429	.4801	.3772	.4801	.4458	.0762
13	.5658	.4801	.4801	.3772	.5144	.4115	.0762
14	.4801	.4458	.4801	.4115	.5144	.3772	.0953
15	.4287	.4115	.463	.4115	.4801	.3086	.0953
16	.4287	.4801	.4801	.4115	.4801	.3772	.0953
17	.5144	.5487	.4801	.4115	.4115	.4458	.1143
18	.5144	.5487	.4458	.3772	.4458	.3772	.1524
19	.1905	.2096	.1715	.1524	.2286	.2286	.1905
20	.1905	.2096	.1905	.1905	.2286	.2286	.1905
21	.1905	.2096	.1715	.2096	.1905	.2286	.2286
22	.1524	.1715	.1905	.1905	.1905	.1905	.1905
23	.1715	.1715	.1524	.1524	.1715	.1905	.1524
24	.1143	.1524	.1524	.1524	.1524	.1524	.1524
Max	.6001	.5487	.4973	.4115	.5144	.4458	.3944
Min	.0953	.0762	.0953	.1143	.0953	.1524	.0762
Avg	.2866	.2771	.2743	.2515	.2728	.2591	.1893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 201 / 11 KV ULEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4694	.0566
2				.4694	.0566
3				.4862	.0566
4				.503	.0754
5				.5533	.0943
6				.6393	.1132
7				.7712	.1509
8				.8215	.1132
9	.9556	.6371	.8886		
10	.9389	.6203	.8383		
11	.0566	.0754	.0566		
12	.0566	.0754	.0754		
13	.0377	.0754	.0754		
14	.0377	.0754	.0943		
15	.0377	.0754	.0943		
16	.0566	.0943	.0948		
24				.0754	.0566
Max	.9556	.6371	.8886	.8215	.1509
Min	.0377	.0754	.0566	.0754	.0566
Avg	.2722	.2161	.2772	.5321	.0859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 202 / 11 KV KASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	.2286
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 204 / 11 KV MANCHUKONDA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0566
2				.0566
3				.0566
4				.0566
5				.0566
6				.0566
7				.0566
8				.0686
9	.0754	.0754	.1132	
10	.0754	.0754	.0566	
11	.0566	.0754	.0758	
12	.0566	.0566	.1132	
13	.0568	.0566	.1509	
14	.0566	.0754	.0754	
15	.0566	.0754		
16	.0566	.0943	.0754	
24				.0943
Max	.0754	.0943	.1509	.0943
Min	.0566	.0566	.0566	.0566
Avg	.0613	.0731	.0944	.0621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 205 / 11 KV KHADAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3395	1.0395
2					.3398	1.1401
3					.3584	1.2742
4					.3258	1.3748
5					.3772	1.5089
6					.415	1.9281
7					.4908	2.4143
8					.4527	2.5316
9		.4287	.4904	.3772		
10		.415	.2829	.3018		
11		1.3413	1.1401	2.4478		
12		2.1795	2.2466	1.9113		
13		2.6825	3.1855	2.2801		
14		2.7664	3.1687	2.4981		
15			3.2023	2.7664		
16		2.8334	3.1855	2.9843		
24	.2286				.3395	.3395
Max	.2286	2.8334	3.2023	2.9843	.4908	2.5316
Min	.2286	.415	.2829	.3018	.3258	.3395
Avg	.2286	1.8067	2.1128	1.9459	.3821	1.5057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 206 / 11 KV Stone Crusher
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2452	.1509
2					.2452	.1509
3					.2641	.132
4					.2641	.132
5					.2829	.132
6					.2829	.1509
7					.2829	.1509
8					.2572	.1698
9		.2829	.4527	.415		
10		.415	.6602	.5847		
11		.4527	.7167	.6979		
12		.5281	.5847	.7545		
13		.5658	.3584	.7167		
14		.5281	.5847	.679		
15		.5847	.679	.6224		
16		.6224	.7922	.6413		
24	.2263				.2263	.1509
Max	.2263	.6224	.7922	.7545	.2829	.1698
Min	.2263	.2829	.3584	.415	.2263	.132
Avg	.2263	.4975	.6036	.6389	.2612	.1467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 207 / 11 KV ULE GAONTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1904	.5281
2					1.2239	.5658
3					1.2742	.6036
4					1.3535	.679
5					1.4754	.7575
6					1.643	.9808
7					2.079	1.2071
8					1.8778	.9431
9		1.8442	1.7772	1.7772		
10		1.3245	1.643	1.576		
11		.4904	.3584	.3584		
12		.4347	.3395	.3961		
13		.415	.3395	.3772		
14		.3772	.3395	.3969		
15		.3961	.3587	.3961		
16		.415	.415	.4527		
24	1.0562				.6036	.547
Max	1.0562	1.8442	1.7772	1.7772	2.079	1.2071
Min	1.0562	.3772	.3395	.3584	.6036	.5281
Avg	1.0562	.7121	.6964	.7163	1.4134	.7569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 208 / 11 KV EKRUKH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.235	.0943
2				.235	.0943
3				.2543	.0754
4				.2543	.0943
5				.3052	.1132
6				.4527	.1509
7				.5426	.1886
8				.5365	.1509
9	.6036	.503	.503		
10	.5868	.503	.503		
11	.0943	.0758	.0754		
12	.0754	.0566	.0754		
13	.0566	.0566	.0754		
14	.0566	.0566	.0754		
15	.0754	.0566	.0754		
16	.0943	.0566	.0758		
24				.1132	.1132
Max	.6036	.503	.503	.5426	.1886
Min	.0566	.0566	.0754	.1132	.0754
Avg	.2054	.1706	.1824	.3254	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 209 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715				1.1317	1.0898
2	.4527				1.1694	1.2742
3	.4527				1.1145	1.3916
4	.5093				1.226	1.5089
5	.0566				1.3203	1.7604
6	.6602				1.4712	1.9784
7	.7356				1.8107	2.1963
8	.7922				1.5432	2.3472
9		.6602	1.094	.6413		
10		.4904	1.0562	.6036		
11		1.7604	1.7939	1.7305		
12		2.5316	2.3137	2.2801		
13		2.1963	2.5149	2.2634		
14		2.5149	2.6155	2.2298		
15		2.5484	2.5101	2.2131		
16		2.649	2.5819	2.2634		
23	.7356					
24	.4527				1.1694	.547
Max	.7922	2.649	2.6155	2.2801	1.8107	2.3472
Min	.0566	.4904	1.0562	.6036	1.1145	.547
Avg	.5319	1.9189	2.0600	1.7782	1.3285	1.5660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 201 / 11 KV DINDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.6516		.5914	.2667
2		.4108	.6613		.6653	.2858
3		.4458	.6706		.695	.3048
4		.6516	.7127		.7316	.3429
5		.6859	.7701		.7682	.381
6	.7468	.823	1.0526		.9619	.4572
7		1.142	1.1363		1.0402	.5335
8		1.4255	1.3123		1.2346	.381
9		1.2346	1.2963			.3048
10	.9414			.8697		.1905
11	.2286			.1524		1.0059
12	.2286			.1524		.9604
13	.2096			.1334		1.0551
14	.2286			.1715		.9412
15	.2477			.1905		.9536
16	.2096			.1715		1.0202
17	.2096			.1905		1.2289
18	.2286	.1905		.2096	.1905	
19	.3921	.4191		.4382	.381	
20	.4294	.5144		.4763	.4191	
21	.3658	.4191		.4382	.4382	
22	.3142	.362	.3048		.3239	
23	.2454	.2667	.2667	.2858	.2858	
24		.2452	.2477		.2477	.2477
Max	.9414	1.4255	1.3123	.8697	1.2346	1.2289
Min	.2096	.1905	.2477	.1334	.1905	.1905
Avg	.3484	.6008	.7569	.2985	.5983	.6034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 202 / 11 KV ACHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.381	.3429	.3258	.362	.3429	.3086
2	.3239	.4191	.362	.3429	.362	.381	.3561
3	.3239	.4572	.4001	.3772	.381	.4572	.407
4	.3429	.5335	.4572	.4458	.4001	.4572	.4527
5	.4382	.5525	.5525	.5121	.4763	.4954	.6371
6	.7811	.7049	.6097	.7133	.743	.6668	.8684
7	.7621	.6859	.724	.6401	.7049	.724	1.1797
8	.5716	.5525	.5525	.567	.5335	.5335	1.3117
9	.4382	.4572	.381	.439	.2286		1.247
10	.362	.3239	.2858	.3429	.1715	.2591	.9991
11	1.2174	1.2445	.9511	1.0364	1.046	.9755	.3239
12	1.3735	1.4232	1.1443	1.0669	1.2717	1.1736	.2667
13	1.291	1.335	1.1138	1.1126	1.2407	1.4289	.2477
14	1.3077	1.166	1.0837	1.0212	1.0608	.9145	.2667
15	1.3108	1.2269	1.0709	1.0364	1.1142	1.1126	.3048
16	1.3279	1.2795	1.1149	.9907	1.278	1.4289	.2858
17	1.2955	1.3289	1.1296	1.0822	1.2616	1.2193	.2667
18	1.21	1.2445	1.0848	1.2955	1.2289	1.1138	.2096
19	.5716	.5716	.5906	.5335	.5716	.6097	.6287
20	.6097	.6668	.6668	.6287	.6097	.6097	.6668
21	.5335	.5906	.5525	.5716	.5906	.5906	.6097
22	.4763	.4954	.4382	.4954		.4763	.4572
23	.381	.381	.381	.381	.381	.4001	.4001
24	.5715	.362	.3239	.1715	.362	.3429	.3239
Max	1.3735	1.4232	1.1443	1.2955	1.278	1.4289	1.3117
Min	.3239	.3239	.2858	.1715	.1715	.2591	.2096
Avg	.7561	.7660	.6797	.6721	.7122	.7267	.5427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 203 / 11 KV L.CHINCHOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3856	.4001		.4001	.3601
2		.4527	.4191		.4191	.3772
3		.4904	.4572	.4572	.4191	.407
4		.5658	.4954		.4954	.4409
5		.6722	.6668		.6097	.5197
6		.7865	.7811		.7762	.7293
7		.8131	.8383		.8865	.9667
8		.7133	.724		.6516	1.0526
9		.5658	.5525			.9878
10	.4191			.3048		.6382
11	1.0174			.8059		.2858
12	1.1233			.9326		.3239
13	.8886			.9389		.3189
14	.9892			.9282		.3475
15	.9175			.8356		.2829
16	.9878			.7865		.2401
17	1.0526			.9175		.25
18	.7644	.7531		.434	.9762	
19	.5784	.6287		.6478	.6478	
20	.6661	.7049		.724	.6668	
21	.5853	.6478		.6097	.6859	
22	.5083	.5144	.5335		.5144	
23	.4252	.4382	.3658	.4572	.4382	
24		.3856	.381		.4001	.381
Max	1.1233	.8131	.8383	.9389	.9762	1.0526
Min	.4191	.3856	.3658	.3048	.4001	.2401
Avg	.7802	.5949	.5512	.6986	.5991	.4950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 204 / 11 KV SOOT MIL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3772	.5316	.333	.3658	.3086	.8383
2	.2896	.415	.5087	.333	.381	.3292	.8573
3		.415	.5365	.3403	.4763	.3658	.9145
4	.3201	.4527	.5304	.3403	.4115	.3841	.9526
5	.3506	.415	.5407	.3403	.4572	.4024	.9907
6	.381	.3772	.7611	.333	.5335	.4572	1.086
7	.6097	.6224	.8642	.4207	.7468	.5853	1.2003
8	.7316	.6224	.8802	.5493	.7468	.6036	.9335
9	.6859	.6068	.6722	.4938	.7621		.8764
10	.6173	.5144	.4858	.5639	.5921	.6249	.2096
11	.7621	.7621	.6287	.8383	.7049	.7049	.5083
12	.8383	.743	.6287	.8002	.5906	.7621	.5853
13	.7621	.8002	.6859	.7621	.743	.7621	.5914
14	.7621	.6859	.6859	.8002	.8002	.7621	.6036
15	.8002	.724	.743	.743	.8002	.8573	.5121
16	.8192	.7621	.6859	.7621	.8002	.7811	.4382
17	.8192	.7621	.6859	.7621	.743	.7621	.5258
18	.5144	.724	.743	.8573	.4763	.8383	.6401
19	.7545	1.1241	.8573	1.1622	.7811	1.1812	1.2384
20	.811	1.2384	1.1431	1.2384	.8573	1.2003	1.2574
21	.7545	1.2193	1.1431	1.1812	.8383	1.2384	1.2574
22	.6135	1.086	.6859	1.0288		1.086	1.105
23	.5083	.8573	.5525	.9145	.5906	.9526	.9717
24	.2286	.5093	.8383	.5335	.8002	.5525	.8192
Max	.8383	1.2384	1.1431	1.2384	.8573	1.2384	1.2574
Min	.2286	.3772	.4858	.333	.3658	.3086	.2096
Avg	.6097	.7007	.7091	.6846	.6521	.7175	.8297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 205 / 11 KV HANJAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801	.2743		.2896	.0572
2		.2987			.2896	.0572
3		.2804	.3052	.3048	.3269	.0572
4		.3506	.3185		.3475	.0762
5		.3841	.4144		.3475	.0953
6		.4481	.4752		.3429	.1143
7		.4252	.5441		.4633	.1143
8		.5792	.5921		.4868	.0762
9		.5213	.5921			.0572
10	.4001			.4664		.0572
11				.0381		.3868
12	.0381			.0381		.4534
13	.0381			.0381		.4733
14	.0381			.0381		.4212
15	.0572			.0381		.4024
16	.0572			.0381		.4275
17	.0572			.0381		.4001
18	.0572	.0381		.0381	.0381	
19	.0943	.0953		.0953	.0953	
20	.0943	.1143		.1143	.1143	
21	.0914	.1143		.0953	.0953	
22	.0732	.0953	.0762			
23	.0549	.0762	.0754	.0762	.0762	
24		.0566	.0762		.0572	.0572
Max	.4001	.5792	.5921	.4664	.4868	.4733
Min	.0381	.0381	.0754	.0381	.0381	.0572
Avg	.0886	.2599	.3403	.1041	.2408	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 206 / Kardehalli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2096		.2477	.2401
2		.2641	.2096		.2477	.2713
3		.3018	.2286		.2667	.285
4		.3772	.2477		.2858	.2984
5		.415	.2667		.3048	.3605
6		.3961	.3048		.362	.4915
7		.3292			.3429	.7865
8		.2743	.2286		.2477	.9878
9		.2378	.1524			.9717
10	.1524			.1334		.7042
11	.9088			.703		.1334
12	.9496			.7969		.1294
13	.8551			.7712		.128
14	.8718			.7625		.1494
15	.7701			.6718		.1509
16	.7611			.8356		.1509
17	.8259			.8029		.1509
18	.6882	.7011		.7042	.7968	
19	.2858	.3239		.3048	.3239	
20	.3361	.3429		.3239	.3429	
21	.3109	.3239		.3429	.3429	
22	.2454	.2858	.2858		.3048	
23	.2279	.2477	.2477	.2667	.2667	
24		.2075	.2286		.2477	.2286
Max	.9496	.7011	.3048	.8356	.7968	.9878
Min	.1524	.2075	.1524	.1334	.2477	.128
Avg	.5849	.3284	.2373	.5708	.3287	.3677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 201 / 11 KV HATTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.1317			1.0288		.8488
2	1.5089	1.1317	.9602	1.166	1.0402	1.1736	.8488
3	1.5089	1.3203			1.387		.8488
4	2.0748	1.6975	.9488	1.166	1.7528	1.1469	.8488
5	2.2634	1.8861			2.0576		1.1317
6	2.452	2.0748	1.4403	2.2634	2.0576	1.8442	
7	2.452	2.2634			1.9662		.9808
8	2.452	2.452	1.9433	2.5377	2.0576	2.1862	.9431
9	2.452			.6859	1.8861	2.4143	
10	2.2634		1.8861	2.4006	1.8861	.5658	.7545
11	.415			.5658		.5658	
12	.4715	.5281	.4715	.5658		.5281	2.2291
13	.4904			.5658		.4527	
14	.5658		.4527	.5658	.5281	.5281	2.2291
15	.5658			.5658		.5281	
16	.5658	.5658	.3772	.5658		.5658	2.2291
17	.7167			.6602		.5658	
18	.7545		.415	.9431	.7922	.6602	1.9719
19	.8488			1.1317		.9808	
20	.8488		1.1128	1.0974		1.1317	1.1317
21	.9431			.985		1.1317	
22	.8488		.9054	.9431		.9808	1.0185
23	.7545	.7545	.7922	1.0974	.9431	.8488	.9808
24	.2286	1.1317	.6371	.7167	1.0288	.8299	.8488
Max	2.452	2.452	1.9433	2.5377	2.0576	2.4143	2.2291
Min	.2286	.5281	.3772	.5658	.5281	.4527	.7545
Avg	1.2481	1.4115	.9494	1.0595	1.4580	.9815	1.2403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 202 / 11KV WADAKBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772					.0943
2		.3772		.2926		.2715	.0943
3		.3772					.0943
4		.378		.2926			.0943
5		.3772					.0943
6		.3772		.6805			.0943
7		.4715					.0943
8	.3772	.4715	.7164	.8954		.5316	.0943
9	.3772					.7545	
10	.3772		.0943			.0943	
11	.3772					.0943	
12	.3772	.1132	.0943			.0943	
13	.0943					.0943	
14	.0943		.0943		.132	.0943	
15	.0943					.0943	
16	.0943	.1132	.0943			.0943	.8573
17	.0943					.0943	
18	.0943				.1509	.0943	
19	.0943					.0943	
20	.0943					.0943	
21	.0943					.0943	
22	.0943					.0943	
23	.0943	.1132	.0943		.1509	.0943	.0857
24	.3229	.3772	.132	.0943		.1132	.0943
Max	.3772	.4715	.7164	.8954	.1509	.7545	.8573
Min	.0943	.1132	.0943	.0943	.132	.0943	.0857
Avg	.1910	.3270	.1886	.4511	.1446	.1662	.1629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 203 / 11 KV RAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395					.5658
2		.3395		.2641			.5658
3		.3395					.7545
4		.3395		.2641		.2263	.7545
5		.3395					1.1317
6		.3772		.5281			1.3203
7		.4527					1.5089
8	.3772	.3772	.4904	.3772		.3734	1.8861
9	.3772					.3018	
10	.1886		.3018			.3395	
11	2.2634					2.2634	
12	2.452	.8573	2.0576				
13	2.6406					2.452	
14	2.6406		2.2291		1.0402	2.452	
15	2.6406					2.452	
16	2.452	1.1203	2.1948			2.5274	.1886
17	2.452					2.6406	
18	2.6406				1.0974	2.6406	
19	.3772					.4904	
20	.4527					.4527	
21	.415					.3772	
22	.3772					.3772	
23	.3772	.3018	.2641		.3018	.3395	.2641
24	.2286	.3395	.3018	.2641		.2263	.3395
Max	2.6406	1.1203	2.2291	.5281	1.0974	2.6406	1.8861
Min	.1886	.3018	.2641	.2641	.3018	.2263	.1886
Avg	1.3737	.4603	1.1199	.3395	.8131	1.2313	.8436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 204 / 11 KV AURAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566			.0566		.0566
2		.0566		.0566	.0566	.0566	.2829
3		.0566			.0566		.2829
4		.0566	.0566	.0566	.0566		.2829
5		.0566			.0566		.3395
6		.0566		.0566	.0566	.0566	.3772
7		.0566			.0566		.4527
8	.0566	.0566	.0566	.0566	.0566	.0566	.4527
9	.0566			.0566	.0566	.0566	
10	.0566		.0566	.0566	.0566	.0566	.4755
11	.415			.3429		.3772	
12	.4527	.3688	.5121	.4801		.4527	.0566
13	.4527			.3429		.4527	
14	.5658		.4801	.3429	.4252	.4904	.0566
15	.6036			.3429		.5281	
16	.5658	.4656	.463	.3429		.5281	.0566
17	.5658			.3429		.5281	
18	.5658		.4755	.3429	.4161	.5281	.0566
19	.0566			.0566		.0566	
20	.0566		.0566	.0514		.0566	.0566
21	.0566			.0514		.0566	
22	.0566		.0566	.0566		.0566	.0566
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.6036	.4656	.5121	.4801	.4252	.5281	.4755
Min	.0566	.0566	.0566	.0514	.0566	.0566	.0566
Avg	.2763	.1167	.2115	.1775	.1086	.2373	.2033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 205 / SINDHKHED AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566			.0566		
2		.0566	.0566	.0377	.0566	.0566	
3		.0566			.0566		
4		.0566		.0566	.0566		
5		.0566			.0566		
6		.0566	.0566	.0566	.0566	.0543	
7		.0566			.0566		
8	.0566	.0549	.0566	.0566	.0566	.056	
9	.0566				.0566	.0566	
10	.0566		.0566		.0566		
12							.0566
14							.0566
16							.0566
18							.0566
24	.0566	.0566				.0543	
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0566	.0549	.0566	.0377	.0566	.0543	.0566
Avg	.0566	.0564	.0566	.0519	.0566	.0556	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 206 / 11 KV MANGOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545			1.0288		.2263
2		.7545	.6859	.9145	1.0288	.8859	.2263
3		.7545			1.3717		.2263
4		1.1317	.6706	.9145	1.6956	.8192	.2263
5		1.5089			1.7147		.2829
6		1.7918	1.1203	1.7833	1.8861	1.3413	.415
7		1.8861			1.9071		.4527
8	1.5089	1.8107	1.0288	1.8176	1.8861	1.5684	.3961
9	1.5089			1.7147	1.7147	1.5089	
10	1.5089		.8573	.0857	1.7147	.1886	.2641
11	.1886			.0943		.1886	
12	.1886	.1509	.0943	.0943		.1886	1.5089
13	.1886			.0943		.1886	
14	.1886		.0943	.0943	.1509	.1509	1.5432
15	.1886			.0943		.1509	
16	.1886	.132	.0943	.1509		.1509	1.5432
17	.1886			.1886		.1509	
18	.2263		.1886		.1509	.1509	1.3717
19	.2641			.2829		.3206	
20	.3395		.2829	.2829			.3018
21	.2829			.1886		.2829	
22	.2452		.1886			.2452	.2075
23	.2263	.1509	.1509	.1886	.132	.2263	.1886
24	.1886	.5658	.1402	.1509	.2572	.132	.2263
Max	1.5089	1.8861	1.1203	1.8176	1.9071	1.5684	1.5432
Min	.1886	.132	.0943	.0857	.132	.132	.1886
Avg	.4482	.9494	.4305	.5075	1.1885	.4652	.5651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 207 / 11 KV WANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6602			.0566		.1886
2		.6602	.5144	.5853	.0566	.3353	.1886
3		.6602			.3429		.1886
4		.7545	.4915	.5853	.5144	.3544	.1886
5		.9431			.6935		.2829
6		1.1317	1.0059	.8596	.6859	.7011	.3772
7		1.1317			.6859		.3772
8	1.1317	1.1317	1.0288	.9114	.2572	.7712	.3206
9				.8573	.6783	.7545	
10	1.1317		.9259	.8573	.6859	.1509	.1886
11	.0943			.0943		.0943	
12	.0943	.1509	.1132	.0943		.0943	.8573
13	.0943			.0943		.0943	
14	.1509		.1132	.0943	.1132	.1509	.9431
15	.1509			.0943		.132	
16	.1132	.1132	.132	.1509		.132	.9431
17	.1132			.1509		.132	
18	.1886		.132	.1886	.132	.132	.8573
19	.2829			.2829		.2829	
20	.3772		.2829	.2829		.3206	.3206
21	.2829			.2829		.2829	
22	.1886		.2263	.1886		.2263	.2263
23	.2263	.2263	.2263	.1886	.2641	.1886	.2263
24	.5115	.6602	.1677	.2263		.2263	.1886
Max	1.1317	1.1317	1.0288	.9114	.6935	.7712	.9431
Min	.0943	.1132	.1132	.0943	.0566	.0943	.1886
Avg	.3208	.6853	.4123	.3535	.3974	.2778	.4037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 201 / 11 KV GODUTAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7842	.7468	.7095	.8215	.7842	.7468
2	.7842	.7468	.7095	.7468	.7842	.7842	.7095
3	.7468	.7095	.7095	.7282	.7468	.7468	.7282
4	.7468	.7468	.7095	.7842	.7842	.7468	.7468
5	.7468	.7468	.7468	.7468	.7095	.7095	.7095
6	.7468	.7468	.7468	.7842	.7468	.7468	.7468
7	.7468	.7468	.7468	.7842	.7468	.7468	.7468
8	.7468	.7095	.7095	.7468	.7468	.7468	.7095
9	.6348	.6722	.5975	.7282	.6535	.6722	.6722
10	.5975	.5975	.5601	.6908	.5975	.6722	.5658
11	.5975	.6348	.5975	.6722	.6348	.6348	.5658
12	.5975	.6722	.6348	.7468	.6722	.5975	.5658
13	.5975	.6722	.6535	.7095	.6722	.6722	.6413
14	.5601	.6722	.6535	.6722	.6722	.6348	.6413
15	.5975	.6722	.6348	.7095	.6722	.6348	.6413
16	.5601	.6722	.6535		.6722	.6348	.6413
17	.6348	.7468	.6722	.6722	.7842	.8402	.5658
18	.5975	1.0082	.9149	.7095	1.0829	1.0829	.6413
19	1.1203	1.1576	1.1203	.9335	1.1949	1.1203	1.0562
20	1.1576	1.1949	1.1203	1.2323	1.1949	1.0829	1.1317
21	1.1203	1.1949	1.1389	1.1949	1.1949	1.1203	1.1694
22	1.1203	1.1203	1.1576	1.0829	.9335	.9709	1.1317
23	.9709	.9709	.9335	.9709	.8589	.8402	.9808
24	.8215	.8589	.7468	.7655	.8962	.8215	.7682
Max	1.1576	1.1949	1.1576	1.2323	1.1949	1.1203	1.1694
Min	.5601	.5975	.5601	.6722	.5975	.5975	.5658
Avg	.7640	.8106	.7756	.8053	.8114	.7935	.7593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 202 / 11 KV KUMBHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.2241	.2801	.2987	.2987	.3361
2	.2614	.2987	.2241	.3174	.2987	.2987	.3547
3	.2614	.2987	.2241	.3361	.4108	.2987	.3734
4	.2614	.4108	.2241	.3734	.5228	.3361	.5228
5	.2987	.5228	.2614	.4668	.5975	.4108	.7095
6	.5975	.5975	.5975	.5975	.6722	.6348	.7468
7	.7468	.7468	.7468	.6535	.7468	.7095	
8	.5975		.6348	.6722	.5975	.6348	
9	.5601	.5228	.4481	.5041	.5228	.5228	.6161
10	.4481	.3734	.3734	.4481	.3734	.3361	.4338
11	.3734	.2987	.2801	.2987	.2987	.3361	.3395
12	.3734	.0187	.2614	.2614	.2614		.3018
13	.3361	.0187	.2614	.2614	.2614	.1494	.2829
14	.3361	.1867	.2801	.2241	.2614	.2801	.2641
15	.2614	.2241	.3361	.2987	.2614	.2801	.2641
16	.2614	.2614	.2987	.2614	.2614	.2987	.2641
17	.2987	.2614	.2987	.3361	.2614	.3734	.2263
18	.3361	.2987	.4668	.3734	.3361	.4668	.2641
19	.5228	.5975	.5041	.4854	.4854	.5228	.5281
20	.5228	.5601	.5041	.5975	.5228	.4668	.5281
21	.4854	.5228	.5228	.5228	.5228	.4294	.5281
22	.4481	.4108	.4481	.4481	.4854	.221	.415
23	.3361	.2987	.3361	.3734	.4481	.3361	.3395
24	.2987	.3361	.2241	.2427	.3361	.2987	.3361
Max	.7468	.7468	.7468	.6722	.7468	.7095	.7468
Min	.2614	.0187	.2241	.2241	.2614	.1494	.2263
Avg	.3968	.3653	.3742	.4014	.4185	.3887	.4080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 203 / 11KV MICROWAVE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0526	.1029	.0701	.0537	.0686	.0549
2	.1029	.0526	.1029	.0732	.0716	.0686	.0549
3	.1006	.0514	.1006	.0914	.0701	.1006	.0549
4	.1341	.0678	.1341	.1097	.1063	.0983	.0549
5	.1638	.1147	.1638	.1646	.1433	.1311	.0549
6	.1966	.1372	.1966	.2195	.1829	.16	.0732
7	.192	.1875	.208	.2378	.208	.208	.0914
8	.2458	.2515	.2458	.2561	.2204	.2683	.1097
9	.218	.2012	.2347	.2195	.218	.1886	.0732
10	.0709	.0514	.2103	.2378	.1715	.298	.0732
11	.0537	.0366	.0366	.0358	.0366	.0366	.1646
12	.0543	.0366	.0366	.0366	.0366	.0366	.1829
13	.0543	.0366	.0366	.0366	.0366	.0366	.1715
14	.0537	.0366	.0366	.0362	.0366	.0366	.1696
15	.0549	.0183	.0366	.0373	.0366	.0366	.1677
16	.0549	.0366	.0366	.037	.0366	.0549	.1677
17	.056	.0366	.0366	.0366	.0366	.0549	.1658
18	.056	.0549	.0549	.0543	.0366	.0549	.1475
19	.0747	.0732	.0732	.0701	.0732	.0732	.0554
20	.0716	.0732	.0732	.0701	.0732	.0549	.0739
21	.0709	.0732	.0549	.0716	.0732	.0549	.0554
22	.0549	.0732	.0549	.0543	.0732	.0549	.0554
23	.0366	.0732	.0732	.0549	.0549	.0549	.037
24	.2286	.0366	.0701	.0549	.0549	.0526	.0549
Max	.2458	.2515	.2458	.2561	.2204	.298	.1829
Min	.0366	.0183	.0366	.0358	.0366	.0366	.037
Avg	.1029	.0776	.1004	.0986	.0892	.0951	.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 204 / 11 KV LOKMANGAL MEDICAL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0762	.0762	.0762	.0762
2	.0762	.0953	.0762	.0762	.0762	.0762	.0762
3	.0572	.0762	.0762	.0762	.0762	.0572	.0762
4	.0572	.0762	.0762	.0762	.0762	.0572	.0762
5	.0572	.0762	.0762	.0762	.0762	.0572	.0762
6	.0572	.0762	.0762	.0762	.0762	.0572	.0762
7	.0572	.0762	.0762	.0762	.0572	.0572	.0762
8	.0762	.0762	.0953	.0762	.0762	.0762	.0953
9	.0953	.0953	.1143	.0953	.0953	.0953	.1143
10	.1524	.1334	.1334	.0953	.1524	.0762	.1143
11	.1334	.1334	.1334	.0953	.1524	.0762	.1143
12	.1334	.1334	.1334	.0762	.1524	.0762	.1524
13	.1143	.1334	.1143	.0762	.1524	.0953	.1334
14	.0953	.1334	.1143	.0762	.1143	.0762	.1334
15	.0953	.1143	.1143	.0762	.1143	.0762	.1334
16	.0953	.1143	.0953	.0762	.0953	.0762	.1334
17	.0953	.0953	.0953	.0762	.0953	.0762	.1143
18	.0762	.0953	.0953	.0762	.0953	.0762	.0953
19	.0762	.0762	.0953	.0953	.0953	.0762	.0953
20	.0953	.0762	.0762	.0953	.1143	.0762	.0953
21	.0762	.0762	.0762	.0953	.1097	.0762	.0953
22	.0953	.0762	.0762	.0953	.0953	.0762	.1143
23	.0953	.0762	.0762	.0762	.0953	.0762	.1143
24	.0953	.0953	.0762	.1524	.0762	.0762	.0762
Max	.1524	.1334	.1334	.1524	.1524	.0953	.1524
Min	.0572	.0762	.0762	.0762	.0572	.0572	.0762
Avg	.0889	.0961	.0937	.0849	.0998	.0738	.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 205 / 11 KV MINAXI TAI SANE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2926	.2926	.2743	.3292	.2926	.3109
2	.2926	.2561	.2926	.2378	.2926	.2926	.2743
3	.2561	.2561	.2561	.2743	.2926	.2926	.3292
4	.2561		.2561	.2195	.2561	.2561	.3658
5	.2926	.2561	.2926	.2195	.2561	.2926	.3658
6	.2926	.2926	.2926	.2378	.2926	.2926	.3475
7	.2926	.2561	.2926	.2743	.2561	.3292	.2987
8	.2561	.2926	.2561	.2561	.2561	.2561	.2561
9	.2195	.2561	.2561	.2926	.2195	.2561	.2195
10	.1829	.2195	.2012	.2378	.2195	.2378	.2195
11	.2195	.2195	.2195	.2561	.2195	.2378	.2195
12	.2195	.2195	.2378	.2195	.2195	.2378	.2195
13	.2195	.2195	.2195	.2561	.2561	.2378	.2195
14	.2195	.2195	.2195	.2561	.2561	.2378	.2195
15	.2195		.2195	.2561	.2561	.2378	.2195
16	.2195		.2195	.2926	.2561	.2378	.2195
17	.2195	.2561	.2195	.2561	.2926	.2743	.2195
18	.4024	.2926	.3292	.2561	.3292	.3292	.2195
19	.3658	.439	.3658	.3658	.439	.3658	.4572
20	.4024	.439	.3658	.4755	.439	.3475	.4572
21	.3658	.439	.3658	.439	.439	.3658	.4755
22	.3658	.439	.3841	.3658	.4024	.3292	.439
23	.3292	.4024	.3292	.3292	.4024	.3292	.4024
24	.3292	.2926	.3292	.3292	.3292	.3292	.3292
Max	.4024	.439	.3841	.4755	.439	.3658	.4755
Min	.1829	.2195	.2012	.2195	.2195	.2378	.2195
Avg	.2805	.2979	.2797	.2866	.3003	.2873	.3043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 206 / 11 KV KUMBHARI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557	.5959	.3856	.3292	.3856		.1646
2	.5609	.5609	.5258	.5487	.4908		.1829
3	.5959	.7362	.5609	.5853	.5609		.2195
4	.7011	.7011	.7011	.7316	.8063		.2743
5	1.1568	.7362	1.1919	.7682	.8413		.3292
6	1.1919	.8413	1.2269	1.0974	.8764		.3292
7	1.2269	1.2971	1.262	1.1919	1.262		.4024
8	1.5775	1.5424	1.3496	1.5074	1.4723	1.1218	.3475
9	1.4022	1.5074	1.4022	1.4899	1.3321	1.1218	.2378
10	.2149	.2103		1.2445	1.1706	1.1919	.2195
11	.2149	.1829		.1791	.1463	.1463	1.0867
12	.1433	.1463		.1791	.1463	.1463	1.2269
13	.2149	.1463		.1433	.1463		1.1919
14	.1791	.1463		.1433	.1463	.1463	1.0517
15	.1791	.1463	.1463	.1433	.1463	.1463	1.0867
16	.1791	.1463	.1463	.1433	.1463	.1463	1.2384
17	.1433	.1829	.1829	.1791	.1463	.1646	1.0517
18	.1433	.1829	.2195	.1791		.2195	1.0166
19	.2507	.2561	.2561	.2149	.2561	.2926	.2195
20	.2865	.2561	.2743	.3403	.2561	.2195	.2195
21	.2149	.2561	.2195	.2149	.2195	.2195	.2561
22	.2149	.2561	.2195	.2149	.2195	.1829	.2195
23	.1791	.2195	.1829	.2149	.1829	.1463	
24	.2103	.1791	.2103	.1463	.1753	.1753	.1463
Max	1.5775	1.5424	1.4022	1.5074	1.4723	1.1919	1.2384
Min	.1433	.1463	.1463	.1433	.1463	.1463	.1463
Avg	.4932	.4763	.5612	.5054	.5014	.3617	.5530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 201 / 11 KV BANKALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333		.3269	.3227	.3121		.2667
2	.3462		.3668	.3567	.3418		.3048
3	.3567		.4064	.4161	.3715		.3429
4	.3864		.4877	.4515	.4214		.381
5	.4365		.6327	.5182	.5268		.4572
6	.4816		.8179	.6636	.5944		.6287
7	.9922		1.0936	.953	.9065		.5716
8	1.0364		1.1702	1.0802	1.0669		.4191
9	.8688		1.1203	.888	.9633		.2286
10		.7362	.9488	.8173		1.0031	.1905
11		.1524	.1524	.1905		.1524	.873
12		.1905	.1905	.1524		.1524	.9362
13		.1905	.1905	.1905		.1524	.8916
14		.1905	.2096	.1905		.1715	.8215
15		.1905	.1905	.1524		.1524	.7133
16		.1905	.1524	.1715		.1715	.8619
17		.2096	.1524	.2096		.1905	.8802
18		.2286	.1905	.2096		.2477	.8655
19		.3048	.3429	.3429		.4001	.4001
20		.381	.4001	.362		.4572	.4191
21		.3429	.381	.3429		.381	.381
22		.2858	.3239	.2286		.3239	.3429
23		.2286		.1715		.2858	.3048
24	.1143		.1905	.1524			.2667
Max	1.0364	.7362	1.1702	1.0802	1.0669	1.0031	.9362
Min	.1143	.1524	.1524	.1524	.3121	.1524	.1905
Avg	.5352	.2730	.4538	.3973	.6116	.3030	.5312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 202 / 11 KV AHERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3048	.381	.2858	.7225
2		.3048	.3048	.4191	.2858	.7827
3		.3048	.3429	.4572	.3429	.823
4		.4763	.4191	.4954	.4001	.8535
5		.5716	.5716	.5716	.5144	.8951
6		.6668	.6668	.6668	.5716	.9804
7		.724	.6097		.6859	1.2498
8		.6097	.5716	.5716	.5144	1.1439
9		.5525	.5335	.5335	.4001	1.0364
10		.4763	.381	.4763	.2858	1.0974
11		.6602	1.1589	.9145	.7827	.2858
12		.8025	1.2186	1.0669	.884	.2477
13		.8749	1.2041	1.0364	.9568	.2667
14		.9804	1.1589	1.0059	1.0494	.3048
15		1.0311	1.2342	.9145	1.0669	.2667
16		1.0494	1.1888	1.0974	1.3413	.2477
17		1.1288	1.2342	1.1431	.9145	.2858
18		1.1888	1.2041	1.0364	.884	.3429
19		.6097	.6668	.5525	.5335	.5716
20		.6668	.6097	.6859	.6668	.5335
21	.5716	.5335	.5716	.5144	.5335	.4572
22	.4572	.4763	.4382	.4001	.4763	.4001
23		.4763	.381	.3429	.3429	.381
24		.4191	.3429	.3429	.3429	.3048
Max	.5716	1.1888	1.2342	1.1431	1.3413	1.2498
Min	.4572	.3048	.3048	.3429	.2858	.2477
Avg	.5144	.6636	.7216	.6794	.6276	.6034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 201 / 11 KV LAWANGI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 202 / 11 KV KARKAL

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 203 / 11 KV AUJ (M)

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 204 / 11 KV MALKAWATHE

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 205 / 11 KV GAIKWAD WASTI
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 206 / 11 KV PATIL NAGAR
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 201 / 11 KV AKOLE (M)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3125	.3125	.3715	.3906	.4001	.3906	.0156
2	.3125	.3125	.3715	.4374	.4062	.3906	.0156
3	.3906	.4062	.4458	.4374	.4374	.4374	.0156
4	.4687	.4374	.4458	.4687	.4687	.4687	.0156
5	.5468	.4687	.5201	.4999		.5468	.0312
6	.5937	.5937	.5944	.6093	.578	.578	.0312
7	.7186	.6874	.6687	.7343	.4999	.7499	.0312
8	.6718	.7655	.743	.7655	.6562	.7811	.0156
9	.7343	.7343	.743	.7499	.6718	.7811	.0156
10	.7499	.5944	.4458	.7186	.6562	.7811	.0156
11	.0156	.0743	.0156			.0156	.6249
12	.0156	.0743	.0156				.7499
13	.0156	.0743	.0156				.7655
14	.0156	.0743	.0156		.0156		.7655
15	.0156	.0743	.0156				.828
16	.0156	.0743	.0156		.0156		.4687
17	.0312	.0743	.0156	.0156	.0156		.7811
18	.0156		.0156	.0156	.0312	.0156	.6718
19	.0156	.0743	.0156	.0156	.0312	.0156	.0312
20	.0312	.0743	.0156	.0156	.0312	.0156	.0312
21	.0312	.0743	.0156	.0156	.0156	.0312	.0312
22	.0156	.0743	.0156	.0156	.0156	.0312	.0312
23		.0743	.0156		.0156	.0156	.0156
24	.0156	.0156	.0743	.0156	.0156	.0156	.0156
Max	.7499	.7655	.743	.7655	.6718	.7811	.828
Min	.0156	.0156	.0156	.0156	.0156	.0156	.0156
Avg	.2500	.2704	.2344	.3483	.2620	.3367	.2506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 202 / 11 KV KANDALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2483	1.3441	1.5364	1.5203	1.4842	.3521
2	1.3603	1.3123	1.3441	1.6004	1.6804	1.5203	.3681
3	1.4403	1.4403	1.5023	1.6644	1.7604	1.6804	.3681
4	1.5623	1.7604	1.8185	1.6804	1.8404	1.7604	.3681
5	1.7604	1.8564	1.8976	1.7604	1.9204	1.8884	.4001
6	2.2405	2.1125	1.9766	2.0005	2.0325	2.0485	.4801
7	2.8807	2.5606	2.6092	2.6886	1.9364	2.7526	.6081
8	2.8967	2.7846	2.7673	2.7526	2.6726	2.8807	.6562
9	2.6406	2.6406	2.7673	2.6086	2.6246	2.7526	.3041
10	2.4486	2.5301	1.8976	2.5926	2.4966	2.5606	.3361
11	.3201	.3163	.3041	.3361	.4321	.2881	2.3525
12	.3041	.2372	.3361	.3437	.3681	.3201	2.9447
13	.3201	.3163	.3361	.3841	.3521	.3681	2.9607
14	.3361	.2372	.3041	.3681	.3361	.3681	2.4486
15	.3521	.2372	.3201	.3521	.3361	.3681	2.6086
16	.3841	.3163	.3041	.3521	.3201	.3841	1.6004
17	.3201	.3163	.3361	.3681		.4001	2.7686
18	.3361		.3521	.4161	.4641	.4001	2.6406
19	.3841	.5535	.5601	.5921	.6401	.5761	.5441
20	.5121	.5535	.5601	.6401	.6081	.5441	.5441
21	.4801	.4744	.5281	.5601	.4481	.5121	.5121
22	.4321	.3953	.4321	.4801	.4481	.4481	.4481
23		.3953	.3681	.3841	.4481	.3841	.3841
24	.3201	.3201	.3163	.3361	.3521	.3681	.3521
Max	2.8967	2.7846	2.7673	2.7526	2.6726	2.8807	2.9607
Min	.3041	.2372	.3041	.3361	.3201	.2881	.3041
Avg	1.1005	1.0833	1.0534	1.1166	1.1321	1.1274	1.1396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 203 / 11 KV GUNJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2187	.1875	.2658		.2031	.2187	1.0936
2	.2343	.1875	.2658	.2187	.2031	.25	1.2186
3	.25	.2187	.2658	.2187	.2187	.2812	1.3279
4	.3125	.2812	.443	.25	.25	.3125	1.4373
5	.4374	.3906	.5316	.3906	.3125	.3437	1.7185
6	.5624	.4687	.6201	.5155	.4062	.5312	2.1091
7	.3125	.5624	.6201	.6093	.5624	.5624	2.359
8	.4531	.4687	.5316	.4999	.4843	.4374	2.5152
9	.3125	.3437	.443	.3593	.3593	.3593	2.484
10	.2812		.2658	.3125	.2812	.2656	2.3903
11	2.6558	3.0121	2.609	2.5152	2.1872	2.2653	
12	3.2964	3.8094	2.9058	2.8487	2.8121	2.6558	.1718
13	3.2651	3.7209	3.0464	3.0247	2.734	2.9214	.1718
14	3.2026	3.5437	2.9058	2.9127	2.6558	2.8277	.1718
15	3.0933	3.3665	2.7808	2.8327	2.3434	2.7652	.1562
16	3.0308	3.1893	2.734	2.7206	2.3434	2.6246	.1562
17	2.8433	2.1262	2.8121	2.6406	2.0309	2.4996	.2031
18	2.7496		2.5934	2.4806	1.9528	2.4215	.25
19	.3125	.5316	.2031	.4321	.3906	.4062	.2187
20	.3749	.5316	.2656	.4481	.4062	.3749	.2187
21	.3125	.3544	.25	.3521	.3593	.3125	.2187
22	.2656	.3544	.2812	.2561	.2812	.2812	.2187
23		.3544	.2187	.2343	.2187	.25	.2187
24	.2187	.2031	.2658	.2031	.2187	.2187	.2343
Max	3.2964	3.8094	3.0464	3.0247	2.8121	2.9214	2.5152
Min	.2187	.1875	.2031	.2031	.2031	.2187	.1562
Avg	1.2607	1.2821	1.1718	1.1859	1.0090	1.0994	.9244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 204 / Ecosol Exp. Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.0248
2			.0248
3			.0248
4			.0248
10		6.291	
11	.0248		
12	.0248		
13	.0248		
14	.0248		
15	.0248		
16	.0248		
17	.0248	.0248	
18	.0248	.0248	
21		.0248	
22		.0248	
Max	.0248	6.291	.0248
Min	.0248	.0248	.0248
Avg	.0248	1.2780	.0248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 201 / 11 KV KANBAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.1905	.2286	.1905	.1905	.2321
2	.2286	.1905	.1905	.2477	.1905	.1905	.2652
3	.2286	.1905	.1905	.2477	.1905	.1905	.2622
4	.2477	.2286	.1905	.2477	.1905	.1905	.2683
5	.2667	.2286	.1905	.3048	.1905	.2286	.2984
6	.4001	.2858	.2286	.381	.2286	.2667	.3978
7	.381	.381	.2286	.4001	.2286	.3429	.639
8	.3239	.3429	.3239	.3048	.3239	.2858	.7373
9	.1715	.2667	.1905	.2286	.1905	.1905	.7293
10	.1715	.1905	.1524	.1905	.1334	.1524	.5304
11	.6316	.5735	.4696	.3429	.4428	.4752	.1715
12	.7202	.7042	.6401	.724	.506	.6962	.1524
13	.7274	.6962	.6882	.6325	.5401	.6554	.1715
14	.6642	.6796	.6562	.5693	.6249	.6783	.1715
15	.7116	.6554	.5441	.2846	.6481	.5898	.1524
16	.6642	.6226	.6081		.6249	.5304	.1715
17	.7116	.6962	.6562	.5693	.7407	.6299	.1524
18	.6642	.6554	.6401	.6009	.6481	.5079	.1334
19	.2286	.2667	.2858	.2858	.2286	.2477	.2096
20	.2667	.3048	.2858	.2858	.2477	.2667	.2858
21	.2858	.2667	.2477	.2477	.2667	.2286	.3048
22	.2286	.2286	.2286	.2286	.2858	.1905	.2477
23	.1905	.1905	.2286	.2286	.2096	.1905	.2286
24	.1905	.1905	.1905	.1905	.1905	.1905	.1524
Max	.7274	.7042	.6882	.724	.7407	.6962	.7373
Min	.1715	.1905	.1524	.1905	.1334	.1524	.1334
Avg	.3972	.3844	.3519	.3466	.3443	.3461	.2944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 202 / 11 KV TILLEHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2286	.2667	.2286	.2477	.2949
2	.3429	.2667	.2286	.2667	.2286	.2477	.3277
3	.2858	.2667	.2286	.2667	.2286	.2477	.3277
4	.2858	.2667	.2286	.3048	.2286	.2667	.3315
5	.3429	.2858	.2667	.3239	.2667	.3048	.4641
6	.381	.381	.381	.4763	.381	.381	.7209
7	.362	.4954	.5144	.4954	.5144	.5144	1.0774
8	.2858	.4191	.4001	.381	.4001	.4191	1.0814
9	.2096	.2858		.3048	.2096	.2286	1.1233
10	.1715	.2477	.1715	.2286	.1905	.1905	.9892
11	.8962	.7125	.6401	.6882	.7287	.7373	.1334
12	1.0202	.9831	.9282	.9945	.8802	1.0774	.1334
13	1.1336	1.004	.9762	.9614	.9717	1.065	.1905
14	1.0402	1.0159	.9602	.8322	.9922	1.0277	.2286
15	.9686	.9945	.8962	.8802	.9488	.9779	.2667
16	.9374	1.0442	.9922	.884	.9282	.9012	.2667
17	1.0936	1.1142	1.0883	.9602	.8697	.9339	.2286
18	.9374	.9831	1.0402	.9231	.9602	1.0814	.3429
19	.3048	.3429	.362	.362	.2286	.362	.381
20	.4001	.4001	.381	.381	.4191	.381	.4763
21	.362	.362	.381	.381	.381	.362	.4572
22	.3429	.3048	.3429	.3429	.3429	.3239	.4001
23	.2858	.2667	.2858	.2858	.2858	.2667	.3429
24	.2667	.2286	.2286	.2667	.2477	.2477	.2286
Max	1.1336	1.1142	1.0883	.9945	.9922	1.0814	1.1233
Min	.1715	.2286	.1715	.2286	.1905	.1905	.1334
Avg	.5385	.5375	.5283	.5191	.5026	.5331	.4506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 203 / 11 KV INGALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.4858	.3277	.3605	.3277	.2372	.2286
2	.3887	.4858	.3647	.3932	.3978	.2372	.2286
3	.3887	.5668	.3647	.3932	.3932	.2591	.2286
4	.4372	.5535	.3978	.3887	.426	.2881	.2286
5	.4696	.5535	.4752	.6154	.4915	.4858	.2667
6	.7125	.6642	.6299	.8322	.852	.7935	.381
7	.8002	.7274	.8619	.8642	1.0277	.9172	.4191
8	.9602	.9488	1.0159	.9282	.8848	.8697	.3239
9	.7522	.9172	.7701	.7522	.6859	.7682	.2286
10	.6401	.7773	.7127	.6097		.7449	.1715
11	.1524	.1524	.1334	.1905	.1334	.1143	.3239
12	.1524	.1715	.1334	.1524	.1524	.1334	
13	.1524	.0953	.1524	.0953	.1524	.1524	
14	.1524	.1524	.1715	.1715	.1334	.1524	
15	.1524	.1715	.1715	.1715	.1334	.1715	.9717
16	.1905	.1715	.1715	.1715	.1524	.1715	.9393
17	.1715	.1715	.1524	.1715	.1524	.1715	.8907
18	.2096	.2096	.1715	.1715	.1524	.1715	.7287
19	.3429	.3429	.362	.362	.1905	.3429	.2667
20	.4001	.381	.3429	.3429	.381	.381	.3429
21	.381	.3429	.362	.362	.3429	.362	.362
22	.3048	.3048	.3239	.3239	.3048	.3239	.3239
23	.2477	.2667	.3048	.2858	.2858	.2667	.2286
24	.2286	.2286	.2286	.2477	.2286	.2477	.2286
Max	.9602	.9488	1.0159	.9282	1.0277	.9172	.9717
Min	.1524	.0953	.1334	.0953	.1334	.1143	.1715
Avg	.3826	.4101	.3793	.3899	.3645	.3652	.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274207 / 33/11 KV NIMBARGI S/S

Feeder No / Name : 201 / NIMBARGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2987	.2241	.2195	.2987	.3361	2.3663
2	.2641	.2614	.2263	.2614	.2829	.3772	2.3472
3	.2641	.2263	.2561	.3018	.2195	.3018	2.5139
4	.2263	.2263	.2614	.3658	.2241	.2641	2.5139
5	.2614	.2957	.2772	.4108	.2587	.2614	2.5149
6	.2987	.3361	.2829	.4435	.2801	.2957	2.6578
7	.3696	.3361	.2957	.4904	.3772	.3696	2.8045
8	.4108	.2957	.3361	.4024	.3326	.4108	3.2768
9	.3734	.2957	.2829	.2987	.3361	.2926	2.9334
10	.2587	.2801		.2829	.2801	.2218	3.0864
11	3.4122	3.0864	2.7496	2.9664	3.2579	2.7496	.2957
12	3.7449	3.5711	3.3951	3.6984	3.3436	3.2579	.2614
13		3.6062	3.6984	3.437	3.3436	3.4004	
14	3.4979	3.5837	3.5151	3.4294	3.2941	3.2726	
15	3.3114	3.6808	3.504	3.3829	1.6289	3.2941	
16	3.6866	3.6582	3.6866	3.2526	3.3573	3.4004	
17	3.7102	3.5711	3.6808	3.2556	3.4675	3.3913	.2614
18	3.6283	3.4979	2.9843	3.2922	3.4675	3.3981	.2957
19	.4481	.3361	.3696	1.5775	.3395	.4024	.415
20	.4805	.3772	.4904	.2218	.4108	.4481	.5175
21	.4481	.3018	.4481	.3361	.439	.415	.4904
22	.439	.2743	.3658	.3658	.439	.3658	.3734
23	.3696	.2743	.3734	.3395	.4108	.3326	.3326
24	.2987	.2957	.2772	.2587	.2957	.3734	2.2291
Max	3.7449	3.6808	3.6984	3.6984	3.4675	3.4004	3.2768
Min	.2263	.2263	.2241	.2195	.2195	.2218	.2614
Avg	1.3263	1.3736	1.3905	1.3871	1.2661	1.3180	1.6244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274207 / 33/11 KV NIMBARGI S/S

Feeder No / Name : 202 / SADEPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	1.3748	1.3413	1.5089	1.3003	1.4022	.5658
2	1.5074	1.5089	1.4899	.2915	1.3413	1.4563	.5228
3	1.7337	1.6461	1.5604	1.8229	1.4899	1.5257	.4435
4	1.8861	1.9825	1.6289	1.8778	1.5604	1.5775	.4904
5	1.8861	1.9547	1.6766	2.0805	1.5927	1.7147	.5121
6	2.0348	2.1262	1.8652	2.2043	1.7833	1.8861	.5601
7	2.3739	2.34	2.2291	2.3472	2.2786	2.3739	.5914
8	2.572	2.1776	2.6818	2.6749	2.5316	2.4691	.4854
9	2.572	2.4272	2.6006	2.2786	2.7343	2.6993	.3292
10	2.4272	2.4013	2.5095	2.2634	2.6406	2.4417	
11		.2801	.2587	.2829	.2614	.2218	.8916
12		.2218	.3018	.2772	.2614	.2195	1.491
13		.2263	.3292	.2987	.2587	.2987	
14	.2957	.2218	.3734	.3292	.3018	.3772	
15	.2987	.2614	.5487	.3326	.3326	.4435	
16	.2987	.2641		.3772	.3696	.439	
17	.2957	.2743	.4481	.3658	.4024	.4108	2.2634
18	.3734	.3696	.4805	.4108	.4481	.4904	2.4272
19	.4066	.4715	.5853	.4715	.5487	.6653	.4435
20	.5658	.3326	.6722	.5601	.5487	.8299	.4805
21	.4854	.5601	.5548	.6224	.5175	.695	.4854
22	.4435	.462	.3772	.5175	.4435	.6653	.3696
23	.4108	2.2634	.3292	.3734	.4108	.6348	.3361
24	.2286	.3361	.2801	.2987	.3395	.3734	.5853
Max	2.572	2.4272	2.6818	2.6749	2.7343	2.6993	2.4272
Min	.2286	.2218	.2587	.2772	.2587	.2195	.3292
Avg	1.1666	1.1035	1.0923	1.0362	1.0291	1.0963	.7513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 201 / 11 KV SANJWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.945	
5					.9297		
6				.8993			
8	.9755	.9297	.0686	.0686	.9145	.9145	.1143
11	.0171				.0171		
12						.0686	.945
13							.0171
16	.0686	.0686	.0686	.0686	.0686	.0686	.0343
23				.0686			
24	.0857	.0686	.0686	.3963	.4572	.4572	.1029
Max	.9755	.9297	.0686	.8993	.9297	.945	.945
Min	.0171	.0686	.0686	.0686	.0171	.0686	.0171
Avg	.2867	.3556	.0686	.3003	.4774	.4908	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 202 / 11 KV BANDALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.0686		
4				.0686			
8	.1372	.1715	.1372	.1715	.1372	.1372	.9755
12				.945	.945	.9755	
16	.945	.9145	.8993	.884	.7621	.9145	.0686
23				.061			
24	.0857	.0171	.1029	.0686	.1715	.0686	.6249
Max	.945	.9145	.8993	.945	.945	.9755	.9755
Min	.0857	.0171	.1029	.061	.0686	.0686	.0686
Avg	.3893	.3677	.3798	.3665	.4169	.5240	.5563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 203 / 11 KV TEMPLE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.3086						
6						.4458	.3353
7				.3944	.4287		
8	.3086	.3258	.2743	.2743	.2229	.2572	.2286
10	.1543					.1886	
16	.2134	.1829	.2286	.2134	.1829	.2134	.1886
24	.2058	.2401	.12	.1981	.1715	.2058	.1677
Max	.3086	.3258	.2743	.3944	.4287	.4458	.3353
Min	.1543	.1829	.12	.1981	.1715	.1886	.1677
Avg	.2381	.2496	.2076	.2701	.2515	.2622	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 404 / Enrich Solar 1

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 409 / 33 KV NAMRATA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 410 / Enrich Solar 2

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 702 / 132 KV LOKMANGAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 201 / 11 KV Urja Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 205 / 11KV Shoubray

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 206 / 11KV Choupad

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 207 / 11KV Nirale wasti
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 208 / 11KV Hiraj Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 201 / 11KV WATER WORKS SOLAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.2357	1.3256	1.2936	1.2803	1.3306	1.3032
2	1.2382	1.182	1.2567	1.2437	1.2437	1.2936	1.2851
3	1.2197	1.182	1.2197	1.2437	1.2254	1.2567	1.2489
4	1.2071	1.1222	1.2012	1.2071	1.2197	1.2567	1.2308
5	1.2803	1.1462	1.3676	1.2437	1.2567	1.2567	1.3717
6	1.46	1.3352	1.5524	1.3717	1.46	1.2936	1.5729
7	1.4937	1.3717	1.5154	1.4266	1.4969	1.2936	1.4998
8	1.423	1.423	1.5154	1.5339	1.386	1.4045	1.4784
9	1.39	1.5364	1.4266	1.4815	1.39	1.3535	1.3717
10	1.3432	1.4969	1.4842	1.4815	1.3394	1.3032	1.3969
11	1.3969	1.46	1.5546	1.4815	1.5043	1.3535	1.5181
12	1.4118	1.4998	1.647	1.4815	1.5402	1.3676	1.5043
13	1.4266	1.46	1.6078	1.4998	1.5181	1.3575	1.5384
14	1.4327	1.39	1.5546	1.423	1.4969	1.3169	1.4998
15	1.4864	1.4415	1.7002	1.386	1.5154	1.3213	1.5684
16	1.4864	1.46	1.6644	1.46	1.6095	1.3213	1.5497
17	1.5402	1.5546	1.6817	1.4449	1.6278	1.423	1.587
18	1.5402	1.5384	1.7375	1.6118	1.7924	1.4632	1.6078
19	2.0199	2.0595	2.1262	1.9313	2.1312	1.8088	2.009
20	1.8804	1.9342	2.0416	1.8446	2.0416	1.773	2.0271
21	1.7013	1.7013	1.7909	1.7013	1.8446	1.6834	1.8099
22	1.647	1.6644	1.6651	1.6108	1.6832	1.7193	1.7193
23	1.4661	1.4998	1.5181	1.5181	1.6095	1.4998	1.6263
24	1.3121	1.2851	1.4003	1.386	1.3352	1.423	1.3394
Max	2.0199	2.0595	2.1262	1.9313	2.1312	1.8088	2.0271
Min	1.2071	1.1222	1.2012	1.2071	1.2197	1.2567	1.2308
Avg	1.4611	1.4575	1.5648	1.4712	1.5228	1.4114	1.5277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 202 / 11 KV DAV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6401	.7023	.7023	.695	.6468	.6584
2	.6219	.6154	.7023	.6838	.695	.6283	.6767
3	.5973	.6154	.6653	.6653	.6584	.6468	.6767
4	.6154	.6219	.6468	.6653	.6653	.6283	.695
5	.6767	.6401	.7023	.7023	.7392	.6468	.7023
6	.8413	.7023	.7762		.924	.6468	.7577
7	1.0534	.8131	.8871	.7392	.8686	.6653	.7947
8	.8962	.8131	.8871	.8316	.8413	.7023	.6653
9	.8048	.7421	.7602	.8059	.7164	.6584	.5853
10	.7282	.6767	.7087	.6878	.7442	.6201	.6089
11	.7282	.6089	.6733	.6154	.691	.5731	.5316
12	.7282	.567	.6447	.6335	.7164	.6024	.4961
13	.6135	.591	.6516	.6516	.6733	.5068	.5316
14	.6024	.5138	.6154	.6219	.6089	.5611	.5249
15	.6024	.6089	.695	.6767	.6697	.567	.567
16		.6036	.6984	.6219	.6733	.5487	.5068
17	.4607	.6626	.7059	.6154	.6268	.6516	.6335
18	.9036	.6447	.6201	.6661		.6878	.6516
19	1.0576	1.0631	1.0166	.9536	1.0867	1.0631	.9492
20	.9991	.9922	.985	.9671	1.0454		.985
21	.9492	.9593	.9568	.9774	1.0387		.985
22	.8869	.9231	.905	.9328	1.0317	.9694	.9877
23	.7964	.8048	.8413	.8413	.7865	.7499	.7865
24	.695	.6767	.7392	.7392	.7499	.6838	.6584
Max	1.0576	1.0631	1.0166	.9774	1.0867	1.0631	.9877
Min	.4607	.5138	.6154	.6154	.6089	.5068	.4961
Avg	.7613	.7125	.7578	.7390	.7802	.6661	.6923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 203 / 11 KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5068	.5359	.5914	.567	.6099	.5853
2	.4887	.4755	.5175	.5487	.5487	.5914	.5853
3	.4938	.4477	.499	.5121	.5121	.5544	.5487
4	.4755	.4525	.499	.5121	.4755	.5544	.5487
5	.5068	.4656	.499	.5487	.5487	.5544	.5487
6	.6036	.5014	.6099	.6036	.6584	.5729	.6219
7	.6283	.543	.6224	.5853	.695	.5544	.5853
8	.6626	.5611	.5973		.7442	.5914	.6348
9	.631	.6201	.6733	.6984	.7265	.5316	.567
10	.6173	.6626	.6859	.6733	.6516	.5731	.591
11	.6068	.7087	.691	.7087	.7011	.5552	.5847
12	.6068	.6588	.7537	.7802	.7455	.5611	.567
13	.5895	.6485	.7164	.6379	.7522	.5487	.567
14	.631	.631	.6556	.6335	.6379	.4706	.5853
15	.6201	.7108	.6878	.6516	.6805	.4938	.5975
16	.6135	.6984	.7522	.6697	.7059	.5228	.5975
17		.6762	.7164	.7619	.7186	.5415	.6283
18	.6516	.8688	.7802	.8063	.7628	.5601	.6283
19	.9088	1.0166	.9362	.9015	.9816	.8505	.8764
20	.8495	.9991	.9922	.9536	.964	.8775	.8939
21	.7619	.8682	.9114	.8413	.8682	.815	.8682
22	.6626	.7602	.8238	.8059	.788	.7783	.788
23	.5731	.6584	.7682	.7059	.7421	.695	.7316
24	.5544	.5228	.5544	.6283	.6036	.6468	.6036
Max	.9088	1.0166	.9922	.9536	.9816	.8775	.8939
Min	.4755	.4477	.499	.5121	.4755	.4706	.5487
Avg	.6195	.6526	.6866	.6852	.6992	.6085	.6389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 204 / 11 KV SAMACHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3988	.4161	.4382	.4334	.4207	.4287
2	.373	.4161	.4207	.4161	.3988	.4207	.4207
3	.3521	.4161	.3856	.3988	.3988	.4031	.4031
4	.3391	.4161	.3856	.3988	.3988	.3856	.4031
5	.3601	.4115	.3898	.3988	.4161	.3856	.4075
6	.3944	.4161	.4075	.4115	.4508	.3856	.443
7	.4252	.4334	.3801	.3944	.4334	.3681	.4252
8	.4607	.4557	.3761	.5014	.4161	.394	.4252
9	.5014	.5249	.4207	.4607	.443	.3814	.443
10	.4961	.6219	.4854	.6089	.4733	.39	.5258
11	.5316	.6584	.6268	.6089	.5552	.407	.6135
12	.5847	.6335	.7343	.6878	.6024	.4161	.6556
13	.6268	.7059	.6878	.6447	.6154	.3772	.6626
14	.6089	.5973	.6697	.6626	.5853	.3988	.6335
15	.6089	.6089	.6584	.5973	.6036	.4031	.6584
16	.6089	.6697	.6283	.5973	.5973	.3761	.6219
17	.6878		.7133	.5973	.6447	.4294	.5853
18	.7059	.6878	.788	.6733	.6268	.4298	.724
19	.9465	.9568	.9922	.8238	.8505	.583	.9671
20	.8764	.9214	.9214	.7796	.815	.583	.8505
21	.6344	.6762	.6588	.5895	.6001	.5487	.6661
22	.5144	.5144	.5658	.5487	.5316	.5201	.5548
23	.4801	.463	.5028	.4973	.5028	.4681	.5028
24	.3988	.3988	.4382	.4382	.4334	.4382	.4287
Max	.9465	.9568	.9922	.8238	.8505	.583	.9671
Min	.3391	.3988	.3761	.3944	.3988	.3681	.4031
Avg	.5372	.5653	.5689	.5489	.5344	.4297	.5604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 205 / 11 KV JODHAVI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1612	.1867	.2012	.2241	.2241	.2241
2	.1663	.1612	.1848	.1829	.2054	.2054	.2054
3	.1478	.1612	.1848	.1829	.1867	.1867	.2054
4	.1463	.1612	.1848	.1829	.1867	.1867	.1867
5	.1663	.1612	.2033	.2012	.2054	.1867	.1867
6	.2033	.1612	.2033	.2195	.2427	.2054	.2263
7	.2054	.1791	.2054	.181	.2427	.1867	.2452
8	.2507	.2149	.197	.2481	.2454	.2033	.1867
9	.2686	.2601	.2601	.2429	.2713	.2229	.2195
10	.2591	.2683	.2984	.2591	.2656	.2321	.2172
11	.2591	.2785	.3041	.2594	.3185	.2315	.2195
12	.2591	.2591	.3163	.2949	.3321	.2374	.2353
13	.2721	.2688	.3041	.2753	.2881	.2454	.2402
14	.2267	.2469	.2753	.2427	.2652	.2254	.2218
15	.2267	.2812	.2949	.2195	.3149	.2743	.2195
16	.2267	.2622	.2915	.253	.3277	.2507	.2195
17	.2515	.2721	.3239	.2818	.2846	.2303	.2075
18	.2515	.2683	.2846	.3149	.2753	.2601	.2241
19	.3441	.3647	.3932	.373	.3768	.3121	.3224
20	.3185	.3391	.3353	.3429	.3521	.3012	.3224
21	.2743	.2915	.3086	.298	.3222	.3045	.298
22	.2835	.2658	.3155	.3109	.3155	.3109	.3045
23	.2303	.2195	.2926	.2801	.2926	.2987	.2957
24		.1612	.1867	.2402	.2452	.2614	.2427
Max	.3441	.3647	.3932	.373	.3768	.3121	.3224
Min	.1463	.1612	.1848	.181	.1867	.1867	.1867
Avg	.2349	.2362	.2640	.2537	.2745	.2410	.2365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 207 / 11 KV PUMP HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2378	.3326	.3142	.2957	.2401	.2772
2	.3142	.2561	.3326	.3142	.3511	.2134	.2957
3	.3326	.2561	.3326	.3142	.2957	.2134	.2772
4	.3109	.3109	.3326	.3142	.2926	.1829	.2772
5	.3109	.3109	.3326	.3142	.2743	.3326	.2772
6	.2957	.3109	.3511	.3326	.2926	.1829	.2926
7	.2926	.0183	.3326	.3142	.3475	.1981	.2743
8	.2926	.0419	.3326	.3142	.2926	.064	.6653
9	.2926	.0545	.3326	.3142	.2772	.1635	.2926
10	.2926	.2957	.3292	.3121	.2743	.1738	.2715
11	.2926	.3109	.1006	.3121	.029	.2926	.2686
12	.2926	.3142	.2957	.3109	.3109	.2926	.2835
13	.2686	.3361	.2772	.3109	.2772	.1692	.2896
14	.2926	.3326	.2926	.2926	.1593	.1593	.2926
15	.2926	.3326	.3326	.2926	.3326	.2896	.2926
16	.2926	.3547	.3326	.2926	.3292	.2926	.2957
17	.2926	.3511	.3292	.3109	.3292	.2149	.2957
18	.2896	.3511	.3292	.2957	.3292	.2896	.2926
19	.2896	.3511	.3326	.3142	.3326	.2896	.2926
20	.2896	.3511	.3326	.3109	.3326	.2926	.2926
21	.2926	.3511	.3142	.3142	.3326	.2926	.2926
22	.2926	.3511	.3326	.3142	.3326	.2926	.2926
23	.2926	.3511	.3326	.3142	.3326	.2926	.2926
24	.3142	.2378	.3511	.3326	.3142	.3326	.2957
Max	.3326	.3547	.3511	.3326	.3511	.3326	.6653
Min	.2686	.0183	.1006	.2926	.029	.064	.2686
Avg	.2971	.2821	.3178	.3115	.2945	.2399	.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 201 / 11 KV SAKHAR PETH FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0208	1.0566	1.0745	1.0924	1.0924	1.1104	1.1222
2	.9774	1.0136	1.0277	1.0099	1.0277	1.0387	1.0745
3	.9412	.9593	.964	.9745	.964	.9745	1.0387
4	.9877	.9511	.9391	.929	.9114	.9745	.9745
5	.9877	.9877	1.0029	.985	.9745	1.0745	1.0631
6	1.0719	1.0719	1.0498	1.0387	1.1283	1.1283	1.1462
7	1.0903	1.0349		1.086	1.1222	1.1403	1.1222
8	1.0974	1.134	1.0498	1.1403	1.1403	1.134	1.1157
9	1.182	1.1888	1.1283	1.2803	1.2127	1.1041	1.1641
10	1.2934	1.3213	1.2536	1.3394	1.2715	1.2178	1.2536
11	1.4118	1.5746	1.4299	1.4632	1.4506	1.2715	1.2489
12	1.5238	1.5912	1.4661	1.4661	1.4685	1.2715	1.4148
13	1.4685	1.6644	1.5023	1.448	1.5223	1.2715	1.3969
14	1.4299	1.4266	1.3937	1.3717	1.4148	1.2489	1.3717
15	1.3756	1.4266	1.4266	1.2489	1.3611	1.1946	1.3169
16		1.3352	1.448	1.262	1.379	1.1765	1.3352
17	1.4299	1.4299	1.5023	1.3394	1.4506	1.1706	1.4083
18	1.6289	1.5203	1.6478	1.3998	1.5581	1.2357	1.5203
19		2.0858	2.1033	1.8404	2.1384	1.6827	1.9845
20	1.9982	2.0022	2.0199	1.7684	1.9982	1.6301	1.9136
21	1.7177	1.7187	1.7878	1.5775	1.7703	1.5592	1.6832
22	1.4706	1.4883	1.5061	1.4175	1.5415	1.4685	1.4883
23	1.3466	1.3253	1.3432	1.3073	1.379	1.2757	1.3611
24	1.0924	1.0566	1.1403	1.182	1.1641	1.2127	1.1765
Max	1.9982	2.0858	2.1033	1.8404	2.1384	1.6827	1.9845
Min	.9412	.9511	.9391	.929	.9114	.9745	.9745
Avg	1.2974	1.3485	1.3568	1.2903	1.3517	1.2320	1.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 202 / 11 KV NETAJI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4477	.5014	.5014	.5194	.5014	.5373	.5068
2	.4163	.4344	.443	.443	.4607	.5014	.4477
3	.3801	.3982	.3856	.3898	.4382	.4607	.4119
4	.3658	.3658	.3898	.3506	.3856	.3898	.3898
5	.4024	.4024	.4298	.4119	.443	.4477	.443
6	.4435	.4435	.4706	.4656	.5014	.5194	.5194
7	.462			.4706	.5068	.5249	.5068
8	.5121	.5121	.5068	.5068	.5249	.5487	.4938
9	.567	.5304	.5373	.5304	.5068	.4887	.4835
10	.6154	.5792	.5792	.5373	.5373	.4161	.4755
11	.6335	.6089	.6268	.5973	.6268	.4525	.5121
12	.6024	.6447	.6268	.6154	.6268	.4706	.5611
13	.5731	.6154	.6697	.5792	.691	.4706	.5487
14	.6335	.5359	.5973	.5175	.6468	.3841	.5359
15	.5611	.567	.5729	.5304	.5853	.439	.5544
16		.6516	.6335	.567	.7164	.439	.5359
17	.6335	.6626	.6584	.591	.6516	.4344	.5359
18	.7059	.6805	.6805	.6201	.6984	.5014	.6516
19	.8939	.8495	.8589	.7628	.9114	.6836	.7796
20	.8063	.8238	.8413	.7373	.8939	.6836	.7619
21	.7011	.7537	.7362	.6762	.7712	.6379	.7087
22	.6485	.6556	.691	.6733	.7011	.6447	.6379
23	.567	.5731	.6447	.591	.6268	.6201	.6268
24	.4835	.4835	.5068	.5552	.5194	.5611	.5249
Max	.8939	.8495	.8589	.7628	.9114	.6836	.7796
Min	.3658	.3658	.3856	.3506	.3856	.3841	.3898
Avg	.5676	.5771	.5908	.5516	.6030	.5107	.5481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 201 / 11 KV RAMLAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3169	1.2254	1.2803	1.3352
2			1.2437	1.1706	1.2437	1.2437
3			1.1706	1.1706	1.2254	1.2071
4			1.1706	1.1157	1.1523	1.2254
5			1.1706	1.1157	1.1706	1.1888
6			1.2437	1.2803	1.2254	1.3717
7			1.2254	1.4632	1.2071	1.3169
8			1.3169	1.4815		1.3535
9	1.5123	1.2986	1.3352	1.5912	1.3535	1.4083
10	1.6278	1.39		1.701	1.39	1.8473
11	1.7375	1.5181		1.701	1.39	2.1033
12	1.7558	1.5364		1.7741	1.5181	2.1582
13	1.7193	1.5364		1.8839	1.4815	2.0851
14	1.6461	1.5364		1.7375	1.4632	2.0302
15		1.5181		1.7193	1.4449	2.0668
16	1.5729	1.5546		1.7558	1.39	2.1216
17	1.9022					
18	1.8107					
19	2.1765					
20	2.0302					
21	1.829					
22	1.6278					
23	1.5364					
24	1.2986		1.39	1.3717	1.39	1.39
Max	2.1765	1.5546	1.39	1.8839	1.5181	2.1582
Min	1.2986	1.2986	1.1706	1.1157	1.1523	1.1888
Avg	1.7189	1.4861	1.2584	1.4858	1.3329	1.6149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 204 / 11 KV BAPUJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8589		.929	.8939
2			.8589		.9114	.8764
3			.8413		.8764	.8589
4			.8238		.8764	.8764
5			.8413		.9114	.9114
6			.929		.9816	.964
7			.964		.9114	.9465
8			1.0867		.929	.9816
9	.929	1.0517	1.0867	.964	.9114	.9465
10	.7712	.9991		.8764	.8764	.8764
11	.7888	.964		.8589	.8688	.8063
12	.8063	.9816		.8764	.9114	.7537
13	.8238	.929		.929	.8764	.7186
14	.8589	.8764		.964	.8589	.7888
15	.8869	.8589		1.1273	.8413	.8063
16	.8413	.8238		1.1088	.8063	.8063
17	.8764					
18	.9114					
19	1.2971					
20	1.3672					
21	1.3146					
22	1.1744					
23	1.1043					
24	.9114		.9816		1.0166	.964
Max	1.3672	1.0517	1.0867	1.1273	1.0166	.9816
Min	.7712	.8238	.8238	.8589	.8063	.7186
Avg	.9789	.9356	.9272	.9631	.8997	.8692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 205 / 11 KV JAGDAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1888		1.2254	1.2437
2			1.2071		1.1888	1.2071
3			1.0608		1.1706	1.2071
4			1.0608		1.1888	1.3169
5			1.2254		1.4632	1.3717
6			1.4998		1.5546	1.4266
7			1.4449		1.5181	1.39
8			1.4632		1.4815	1.4083
9	1.4083	1.2803	1.4632	1.2803	1.3717	1.3535
10	1.2803	1.2803		1.0242	1.3352	1.2437
11	1.1157	1.2803		1.1706	1.2986	1.0974
12	.9145	1.2254		1.0059	1.0242	1.1157
13	1.0242	1.1157		1.1706	1.0425	1.2071
14	1.134	1.0974		1.0974	1.0974	1.1523
15	1.134	1.0974		1.0425	1.134	1.134
16	.9145	1.0242		1.0608	1.1888	1.0974
17	.9511					
18	1.0059					
19	1.6095					
21	1.7558					
22	1.5912					
23	1.4266				1.3717	
24	1.3352		1.39		1.3535	1.3169
Max	1.7558	1.2803	1.4998	1.2803	1.5546	1.4266
Min	.9145	1.0242	1.0608	1.0059	1.0242	1.0974
Avg	1.2401	1.1751	1.3004	1.1065	1.2783	1.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 206 / 11 KV DAK BUNGLOW
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8596	.8048	.823	.8048
2			.7865	.7865	.823	.7865
3			.7865	.7682	.7865	.7316
4			.8048	.695	.7499	.7133
5			.7682	.7133	.8048	.823
6			.8048	.7865	.8048	.8779
7			.7865	.8048	.7682	.8596
8			.8779	.823	.8413	.9328
9	.9877	.8413	.9511	.9145	.8596	.9511
10	.8779	.8779		.9145	.8779	.9511
11	.9145	.8962		1.0059	.8779	.9511
12	.9328	.9145		.9511	.823	.9511
13	.9145	.8779		.9694	.8413	.9328
14	.8962	.8779		.9694	.9145	1.0059
15	.8962	.8779		.9328	.9511	1.0242
16	.9328	.8962		1.0425	.8413	.9511
17	1.0791					
18	1.0974					
19	1.2803					
20	1.3169					
21	1.1888					
22	1.0608					
23	.9511					
24	.8779		.9145	.8962	.9511	.8413
Max	1.3169	.9145	.9511	1.0425	.9511	1.0242
Min	.8779	.8413	.7682	.695	.7499	.7133
Avg	1.0128	.8825	.8340	.8693	.8435	.8876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 207 / 11 KV SHIDDHESHWAR PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2715		.2715	.2715
2			.2534		.2534	.2715
3			.2534		.2534	.2715
4			.2353		.2353	.2715
5			.2353		.2534	.2715
6			.2896		.2896	.3077
7			.3439		.2715	.2715
8			.3439		.2715	.2715
9	.3077	.2896	.3439	.2715	.3439	.2896
10	.3077	.3077		.3077	.362	.3439
11	.3439	.362		.3801	.3258	.3439
12	.3258	.362		.3258	.3439	.3801
13	.3258	.362		.362	.362	.3439
14	.3439	.362		.362	.3439	.362
15	.362	.362		.362	.3439	.3801
16	.3439	.3801		.3801	.3258	.362
17	.362					
18	.3982					
19	.2715					
20	.3982					
21	.3801					
22	.3439					
23	.3077					
24	.2896		.3077		.2896	.2896
Max	.3982	.3801	.3439	.3801	.362	.3801
Min	.2715	.2896	.2353	.2715	.2353	.2715
Avg	.3382	.3484	.2878	.3439	.3024	.3120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 208 / 11KV CIVIL EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1086
Max	.1086
Min	.1086
Avg	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 201 / 11 KV Limyewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8507	.8507	.8688	.8869	.905	.905	.9412
2	.8326	.8145	.8507	.8688	.8869	.8869	.9412
3	.8145	.8145	.8145	.8507	.8688	.8688	.905
4	.8507	.8145	.8507	.8507	.8962	.8688	.9231
5	.9511	.8688	.9511	.9412	1.0059	.905	1.0425
6	1.2437	1.1157	1.1706	1.086	1.3121	1.0136	1.2803
7	1.2936	1.1827	1.2012	1.1827	1.386	1.1946	1.3676
8	1.3121	1.2752	1.2567	1.3491	1.2696	1.2308	1.2752
9	1.0269	1.2883	1.1203			1.0136	.961
10	1.0059	.961	.8869			.8326	.8871
11	.8507	.7392	.7133			.8048	.3511
12	.7964	.7207	.6335			.823	.3326
13	.7865	.8131	.6516			.8596	.3326
14	.8326	.8131	.6697			.8413	.3326
15	.823	.7762	.8316			.8413	.3511
16	.8048	.7762	.695			.8779	.7392
17	.7865	.8316	.7865	.9795	.8316	.9145	.8131
18	.9231	.9055	.8871	.924	.8316	1.1088	1.0164
19	1.2308	1.2936	1.386	1.386	1.3676	1.4784	1.3676
20	1.2357	1.3491	1.2803	1.262	1.3491	1.4784	1.3676
21	1.2536	1.2382	1.2437	1.2936	1.2936	1.386	1.3306
22	1.2178	1.1827	1.2197	1.2382	1.2197	1.2936	1.2936
23	1.1041	1.0317	1.0679	1.0679		1.0679	1.1403
24	.8869	.8869	.8869	.9231	.9231	1.0374	.9774
Max	1.3121	1.3491	1.386	1.386	1.386	1.4784	1.3676
Min	.7865	.7207	.6335	.8507	.8316	.8048	.3326
Avg	.9881	.9727	.9552	1.0682	1.0898	1.0222	.9279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 202 / 11 KV Modi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9593	.9593	1.0317	1.1041	1.0242	1.0059	1.0791
2	1.0136	.9774	1.0498	.9955	1.0242	.9877	1.0242
3	.9593	.9593	1.0498	.9774	1.0791	.9877	1.0059
4	.9412	.9774	1.0317	.9593	.9877	.9877	.9877
5	1.0974	.9511	1.0974	1.0974	1.0534	1.0242	1.0349
6	1.1888	1.0791	1.2254	1.2071	1.2012	1.0791	1.2197
7	1.1273	1.1458	1.1458	1.1458	1.1458	1.0791	1.1389
8	1.1273	1.2012	1.0903	1.2382	1.1643	1.0791	1.1763
9	1.0136	1.0903	1.1088	1.2197		1.0242	
10	1.0317	1.086	1.0029	1.0498		.9328	.9979
11	1.0425	1.0349	.9979	1.1088		.8779	1.0349
12	1.1041	1.0534		1.0719		.9145	1.0164
13	1.0679	1.0164	.961	1.0974		1.0059	1.1827
14	1.1157	1.0534	1.0164	1.1584		.9511	1.2197
15	1.1523	1.0534	1.1576	1.0425		.9145	1.1827
16	1.1088	1.0082	1.2071	1.0719		.9877	1.1458
17	1.1458	1.2012	1.2012	1.0974	1.1088	1.0974	1.2012
18	1.1765	1.2012	1.4784	1.2936	1.2936	1.2012	1.0164
19	1.5384	1.6632	1.9035	1.7375	1.8111	1.7556	1.848
20	1.576	1.7556	1.9035	1.6632	1.8111	1.7187	1.9035
21	1.5402	1.6632	1.7556	1.5708		1.5708	1.7187
22	1.4118	1.4784	1.5708	1.386	1.4784	1.386	1.4784
23	3.1408	1.267	1.2127	1.262		1.2254	1.3535
24	1.1041	1.0136	1.0498	1.1403	1.0974	1.0974	1.0791
Max	3.1408	1.7556	1.9035	1.7375	1.8111	1.7556	1.9035
Min	.9412	.9511	.961	.9593	.9877	.8779	.9877
Avg	1.2369	1.1621	1.2282	1.1957	1.2343	1.1205	1.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 203 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.6135	.631	.6485	.6485	.6588	.6836
2	.6268	.5959	.5959	.6135	.6135	.6485	.6485
3	.6089		.5959	.6135	.5959	.631	.6485
4	.591	.5784	.5784	.6135	.5959	.6135	.6447
5	.6626	.6268	.6268	.6805	.6447	.6485	.6805
6	.8507	.7343	.788	.7701	.8059	.6661	.8238
7	.9492	.788	.8596	.8417	.9671	.7522	.9671
8	.9231	.8775	.8417	.8775	.8954	.8596	.9492
9	.7628	.8238	.7712	.8596		.7701	.9313
10	.6964	.7202	.7545	.7802		.6687	.7522
11	.6344	.7011	.6613	.6661		.7011	.6805
12	.6133	.631	.6173	.631		.6516	.6335
13	.6371	.5784	.6001	.6415		.6661	.6697
14	.6104	.5895	.6173	.6173		.6485	.6516
15	.5895	.6485	.6379	.6415		.6836	.6154
16	.6173	.631	.6068	.6661		.6836	.6516
17	.6173	.6135	.6001	.6859	.6135	.6859	.6135
18	.6859	.7011	.6859	.6001	.7011	.6859	.6135
19	.8745	.8764	.8573	.8573	.8764	.964	.8764
20	.9259	.8573	.8573	.8573	.9431	.9745	.8764
21	.9189	.8573	.8573	.8573	.9431	.964	.8764
22	.9114	.8573	.7716	.8573	.9431	.8669	.8764
23	.7712	.7455	.7282	.7628		.7802	.8238
24	.6556	.6415	.6415	.6588	.6762	.7282	.7011
Max	.9492	.8775	.8596	.8775	.9671	.9745	.9671
Min	.5895	.5784	.5784	.6001	.5959	.6135	.6135
Avg	.7241	.7082	.6993	.7208	.7642	.7334	.7454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 204 / 11 KV RAILWAY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2641	.2452	.2829	.2829	.2641	.2829
2	.2641	.2641	.2641	.2641	.2641	.2641	.2829
3	.2641	.2641	.2829	.2641	.2641	.2641	.2641
4	.2641	.2641	.2641	.2641	.2641	.2829	.2641
5	.2641	.2641	.2829	.2452	.2829	.2829	.2641
6	.2641	.2641	.3018	.2641	.2829	.2829	.2829
7	.2641	.2641	.2829	.2641	.2829	.2829	.3206
8	.2641	.2641	.3018	.2641	.3206	.3206	.3018
9	.3395	.2641	.2641	.2641		.3395	.3395
10	.3584	.2829	.3395			.3961	.3772
11	.415	.3206	.3206			.3772	.3772
12	.415	.3395	.3395			.415	.3584
13	.3772	.3018	.3395			.3772	.3772
14	.3584	.2829	.3206			.3772	.3395
15	.3772	.2829	.3395			.3772	.3395
16	.415	.2829	.3206			.3772	.3772
17	.3772	.2829	.2829	.2829	.3772	.3772	.3772
18	.3584	.2829	.2829	.2829	.3772	.3772	.3772
19	.3772	.3772	.3772	.3395	.3772	.3772	.415
20	.3584	.3772	.3772	.3772	.2829	.3772	.3395
21	.3395	.2829	.3395	.3395	.2829	.3772	.3395
22	.3206	.2829	.3395	.2829	.2829	.3772	.2829
23	.2829	.2829	.3018	.3018		.3018	.3018
24	.2829	.2829	.2829	.3018	.2641	.2829	.3018
Max	.415	.3772	.3772	.3772	.3772	.415	.415
Min	.2641	.2641	.2452	.2452	.2641	.2641	.2641
Avg	.3285	.2884	.3081	.2874	.2993	.3387	.3285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 205 / 11KV GANGA EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0189	.0189	.0377	.0377	.0189	.0189
2	.0189	.0189	.0189	.0189	.0377	.0189	.0189
3	.0377	.0189	.0189	.0189	.0189	.0189	.0189
4	.0377	.0189	.0189	.0189	.0189	.0189	.0377
5	.0377	.0189	.0189	.0189	.0189	.0189	.0189
6	.0377	.0189	.0377	.0189	.0189	.0189	.0377
7	.0377	.0189	.0189	.0377	.0566	.0377	.0189
8	.0566	.0377	.0377	.0377	.0377	.0566	.0377
9	.0377	.0377	.0566			.0377	.0189
10	.0189	.0189	.0377			.0377	.0189
11	.0566	.0377	.0189			.0181	.0189
12	.0377	.0377	.0189			.0181	.0189
13	.0189	.0377	.0189			.0181	.0189
14	.0189	.0189	.0377			.0181	.0189
15	.0377	.0189	.0377			.0181	.0189
16	.0377	.0377	.0377			.0181	.0189
17	.0514	.0566	.0566	.0377	.0566	.0377	.0377
18	.0566	.0566	.0566	.0566	.0377	.0566	.0377
19	.0566	.0566	.0377	.0377	.0566	.0566	.0377
20	.0566	.0566	.0566	.0377	.0566	.0377	.0566
21	.0377	.0377	.0377	.0377	.0566	.0377	.0377
22	.0377	.0377	.0377	.0377	.0566	.0377	.0377
23	.0377	.0377	.0377	.0377		.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0189	.0189	.0189	.0189	.0189	.0181	.0189
Avg	.0391	.0330	.0338	.0330	.0402	.0305	.0283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274200 / 33/11KV GADDA MAIDAN

Feeder No / Name : 201 / 11KV COLLECTOR OFFICE

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.7842	.8215	.8215	.7842	.7842	.8029
2	.8029	.7468	.8215	.8215	.7842	.7842	.7842
3	.7842	.7545	.7842	.7468	.7468	.7468	.7655
4	.7842	.7733	.7922	.7545	.7545	.7392	.7842
5	.7655	.7356	.8299	.7545	.7545	.7282	.8215
6	.8215	.7922	.8299	.7733	.7733	.7655	.8402
7	.8402	.7733	.8299	.7922	.8299	.7468	.8775
8	.8962	.8676	.9431	.8488	.8865	.7842	.9709
9	.8865	.8402	.9522	.8402	.9431	.9335	1.0374
10	1.0374	.8962	1.1203	.8402	1.1016	1.0374	1.1317
11	1.3203	1.0269	1.3443	.9896	1.3392	1.226	1.4146
12	1.4146	1.1203	1.419	1.0456	1.3769	1.2071	1.475
13	1.3957	1.1763	1.3817	1.0829	1.4146	1.2071	1.3817
14	1.3203	1.0642	1.3443	1.0642	1.3203	1.1317	1.3443
15	1.2696	1.0642	1.3256	1.0269	1.3203	1.1128	1.3817
16	1.3443	1.0642	1.307	.9896	1.358	1.1317	1.4003
17	1.363	1.0751	1.3256	1.0269	1.358	1.226	1.4003
18	1.2696	1.1506	1.2826	1.0829	1.419	1.2637	1.3817
19	1.46	1.4146	1.423	1.3256	1.5123	1.3014	1.4937
20	1.3676	1.3676	1.3306	1.307	1.419	1.2449	1.3443
21	1.2197	1.1827	1.2012	1.251	1.2883	1.2071	1.307
22	1.0719	1.0829	1.1203	1.1016	1.1203	1.1506	1.1576
23	.9709	1.0082	1.0082	.9979	1.0082	1.0185	1.0829
24	.8402	.8402	.8962	.8589	.8962	.8962	.9149
Max	1.46	1.4146	1.423	1.3256	1.5123	1.3014	1.4937
Min	.7655	.7356	.7842	.7468	.7468	.7282	.7655
Avg	1.0869	.9834	1.1014	.9643	1.1046	1.0156	1.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 201 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1217	.1698	.1656	.1829	.1823	
2	.0953	.1217	.1698	.1783	.1791	.1989	
3	.0953	.1217	.1698	.1734	.1734	.176	
4	.1143	.1353	.1886	.2	.1734	.1715	
5	.1143	.1353	.1886	.2115	.1543	.1543	
6	.1334	.1353	.2075	.2225	.1612	.1734	
7	.1334	.1353	.1524	.2435	.2012	.1886	
8	.3858	.5681	.5213	.5817	.5721	.3125	
9	.514	.751	.6087	.6573	.6722	.3841	.1829
10	.6996	.7682	.7682	.7754	.744	.3978	.1505
11	.7093	.8368	.8251	.8402	.8402	.4115	.1875
12	.751	.744	.8251	.7846	.7099	.4115	.1372
13	.5007	.3948	.487	.719	.5216	.2115	.156
14	.6899	.5563	.514	.5921	.6036	.1738	.128
15	.751	.7331	.8128	.7977	1.2346	.1509	.1235
16	.6859	.8116	.8128	.7074	.7659	.1128	.112
17	.7232	.7716	.6996	.7202	.7183		.0995
18	.4664	.6628	.5498	.5335	.5841		.0972
19	.23	.3681	.3612	.3688	.3763		.1006
20	.1353	.1966	.253	.3174	.3326		.1006
21	.1082	.2103	.1943	.2601	.2543		.1006
22	.0947	.1658	.1865	.1734	.2035		.0829
23		.1698	.1572	.1949	.2241		.0819
24	.0848	.1217	.1698	.1524	.2195	.1966	
Max	.751	.8368	.8251	.8402	1.2346	.4115	.1875
Min	.0848	.1217	.1524	.1524	.1543	.1128	.0819
Avg	.3614	.4057	.4164	.4405	.4501	.2358	.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 202 / 11KV Bhadrawati
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1886	.1886		.1905	.1886	
2	.1334	.181	.1886		.1715	.2241	
3	.1334	.181	.1886		.1715	.2378	
4	.1715	.1772	.1886		.1905	.2218	
5	.1334	.1753	.1886		.1905	.2241	
6	.1905	.1734	.2075		.1715	.2641	
7	.2195	.1715	.2641		.3174	.2614	
8	.4239	.6133	.5304		.6036	.2835	
9	.664	.6539	.6562	.7042	.68	.39	.2328
10	.8796	.8642	.7621	.8482	.68	.4961	.3149
11	.8745	.9172	.953	.9488	.8697	.4696	.3077
12	.8745	.8488	.9014	.8025	.8905	.4144	.257
13	.6613	.6882	.6783	.6554	.7099	.3521	.2538
14	1.0802	.571	.6613	.7127	.7611	.197	.2149
15	.6874	.5411	.8322	.7253	.8749	.2012	.2378
16	.6882	.8002	.7407	.8583	.8383	.1991	.181
17	.7935	.7655	.8383	.8322	.7727		.181
18	.6468	.7116	.7522	.8097	.6944		.181
19	.3921	.3856	.5201	.5087	.4915		.1848
20	.2012	.2774	.3801	.3921	.3772		.1629
21	.1629	.2743	.2957	.3206	.3206		.1433
22	.1578	.2054	.2218		.2772		.1214
23		.1886	.1612	.1791	.2587		.0949
24	.1143	.1848	.1886		.2195	.2279	
Max	1.0802	.9172	.953	.9488	.8905	.4961	.3149
Min	.1143	.1715	.1612	.1791	.1715	.1886	.0949
Avg	.4529	.4475	.4787	.6641	.4885	.2855	.2046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 203 / 11KV MIDC NO.4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1715	.1905	.1715	.1905	
2	.1715	.1524	.1715	.2096	.1524	.2477	
3	.1905	.1715	.1715	.2477	.1715	.2286	
4	.1905	.1715	.1715	.2429	.1715	.2096	
5	.1905	.1715	.1715	.2753	.1715	.2286	
6	.2096	.1905	.1905	.3113	.1524	.2286	
7	.2096	.1905	.1905	.3441	.2096	.2353	
8	.4111	.7209	.5335	.6093	.5182	.3763	
9	.7232	.8459	.9574	.8762	.8779	.5401	.1715
10	1.0574	1.0425	.9875	.9198	1.001	.5213	.1715
11	1.0987	1.1822	1.2492	1.1092	1.1111	.5563	.1715
12	1.0153	1.142	1.1279	1.1439		.5068	.1715
13	.7225	.8655	.7482	.7628	1.1111	.2774	.1524
14	.8642	1.0433	.8362	.8002	.8318	.2987	.2096
15	.8901	.9877	1.0288	1.001	.9739	.1905	
16	.8901	1.0151	1.001	.787	.9875	.1905	
17	.9179	.9596	.9736	.9063	.9877		.1905
18	.7287	.8368	.8484	.8269	.7846		.1905
19	.4115	.5281	.506	.6036	.5201		.2096
20	.2195	.2614	.2801	.2801	.3688		.1905
21	.1905	.1905	.1905	.2096	.2515		.1905
22	.1905	.1715	.156	.1905	.3018		.1905
23		.1715	.1524	.1715	.2778		.1905
24	.1715	.1524	.1715	.1715	.1524	.3048	
Max	1.0987	1.1822	1.2492	1.1439	1.1111	.5563	.2096
Min	.1715	.1524	.1524	.1715	.1524	.1905	.1524
Avg	.5155	.5549	.5411	.5496	.5329	.3136	.1847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 204 / 11 KV MIDC NO.5

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.362	.4344		.4108	.439	
2	.2926	.362	.3982		.4108	.4435	
3	.2926	.3801	.3801		.3696	.4294	
4	.2686	.4024	.3801		.3696	.415	
5	.2481	.4207	.3841		.3921	.4294	
6	.2926	.4527	.4024		.462	.4294	
7	.3696	.4572	.4887		.5194	.4252	
8	.7655	1.0288	.8916		.9181	.7468	
9	1.0856	1.1498	1.4239	1.2018	1.3003	1.0242	.4694
10	1.3003	1.283	1.5203	1.4769	1.5348	.8642	.5668
11	1.3321	1.5367	1.5927	1.5927	1.6147	.9334	.583
12	1.286	1.5432	1.1888	1.6347	1.5367	.8459	.4586
13	1.028	1.1888	1.1004	1.2308	1.2887	.5864	.3814
14	1.2191	.9869	1.4003	1.0269	1.2029	.2096	.3641
15	.3185	1.2483	1.5059	1.1831	1.3957	.4119	.3403
16	1.2146	1.3496		.9465	1.3908	.4075	.3403
17	1.21	1.419	1.3957	1.3466	1.3717		.3761
18	1.0595	1.3146	1.3375	1.3032	1.3937		.3224
19	.9116	1.085	.9922	1.0364	1.0212		.4024
20	.6001	.7449	.7293	.7611	.7545		.394
21	.5138	.5784	.5493	.5721	.5487		.3721
22	.4835	.5487	.4887		.5959		.362
23		.4887	.4755	.4344	.4908		.3258
24	.2534	.3439	.4344		.4108	.4557	
Max	1.3321	1.5432	1.5927	1.6347	1.6147	1.0242	.583
Min	.2481	.3439	.3801	.4344	.3696	.2096	.3224
Avg	.7218	.8615	.8650	1.1248	.9043	.5586	.4039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 205 / 11 KV SANKURI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2286	.2477	.2096	.2477	
2	.1905	.2477	.2286	.2667	.2096	.2477	
3	.1905	.2477	.2286	.2343	.2286	.2286	
4	.1905	.2667	.2286	.2591	.2286	.2477	
5	.2096	.2667	.2286	.285	.2286	.2286	
6	.2286	.2858	.2477	.3086	.2667	.2477	
7	.2286	.2858	.3048	.3506	.2858	.3048	
8	.3681	.6401	.5304	.503	.5197	.3856	
9	.6093	.7099	.7316	.7274	.6923	.4854	.2241
10	.7716	.7676	.8253	.7621	.8173	.5304	.2587
11	.7748	.8278	.743	.9031	.7674	.5079	.2587
12	.7748	.8383	.9326	.8916	.8802	.4752	.2452
13	.5256	.5959	.5304	.6133	.5647	.3841	.2096
14	.7225	.6241	.7049	.664	.7253	.192	.2096
15	.743	.9326	.9326	.8796	.884	.2829	.1905
16	.7225	.7407	.888	.7282	.8579	.2801	.2096
17	.7375	.7977	.8025	.8179	.8069		.1905
18	.5935	.5556	.5668	.703	.6173		.1715
19	.3772	.3361	.2957	.4096	.3932		.2096
20	.3048	.2286	.2096	.2801	.3395		.1905
21	.2286	.2096	.1905	.2667	.2477		.1715
22	.2286	.2286	.2096	.2477	.2667		.1905
23		.2286	.2286	.2286	.2427		.1905
24		.2286	.2477	.2286	.2477	.2477	
Max	.7748	.9326	.9326	.9031	.884	.5304	.2587
Min	.1905	.2096	.1905	.2286	.2096	.192	.1715
Avg	.4505	.4716	.4694	.4919	.4803	.3249	.2080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 206 / 11 KV VINKAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2477	.2096		.1905	.3772	
2	.1715	.2477	.2096		.1905	.3772	
3	.1715	.2477	.1715		.1905	.3395	
4	.1524	.2667	.1715		.1905	.2987	
5	.1715	.2534	.1715		.2452	.2829	
6	.1715	.2561	.1715			.3292	
7	.2096	.2587	.2402		.3361	.4108	
8	.4111	.6748	.5201		.5312	.4915	
9	.7095		.8398	.9145	.7754	.5761	.2452
10	.9511		1.0416	1.0974	1.1145	.6704	.3174
11	1.1126		1.3643	1.2803	1.3245	.7935	.2772
12	1.0235	1.2346	1.1888	1.1702	1.2631	.6019	.2477
13	.779	.9014	.8539	.8642	.873	.3437	.2477
14	.7655	.7716	.8333	.8951	.9728	.3641	.1715
15	1.012	1.0235	1.1888	.9465	1.1591	.2515	.2286
16	1.0402	1.0669	1.2191	.9412	1.1589	.2374	.1905
17	1.0385	1.0974	1.0987	1.0254	1.1728		.1905
18	.6964	1.0254	1.012	1.0155	1.065		.1715
19	.5434	.6859	.7186	.6554	.7122		.1905
20	.4066	.443	.4755	.499	.5914		.1905
21	.2743	.3142	.3511	.3584	.5228		.1715
22	.3109	.2477	.2743		.4715		.1715
23		.2286	.2353	.1886	.4382		.1715
24	.1715	.2477	.2096		.1905	.3641	
Max	1.1126	1.2346	1.3643	1.2803	1.3245	.7935	.3174
Min	.1524	.2286	.1715	.1886	.1905	.2374	.1715
Avg	.5428	.5591	.6154	.8466	.6817	.4182	.2122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.9936	8.3516	7.3909	8.0778	7.5978	8.0064	1.2323
2	6.7129	8.2962	7.6749	8.1344	7.2732	7.8366	1.1763
3	6.5998	8.2973	7.0524	8.1219	7.1731	7.7235	1.1763
4	6.5998	8.2973	7.0524	8.2482	7.0605	7.7383	1.1763
5	6.7129	8.4094	7.1645	8.3483	7.3308	7.9647	1.1763
6	7.7858	8.5769	8.3951	8.7277	8.2167	8.3459	1.4415
7	8.9084	9.0038	8.7243	9.1592	9.1501	8.5546	1.5912
8	9.9337	10.7785	10.7922	10.6653	10.4241	9.8663	1.6289
9	11.1026	11.1575	11.9496	11.4609	11.7004	10.3996	9.1003
10	11.07	11.4163	11.9634	11.5427	11.0505	10.3058	9.6085
11	11.569	11.8364	12.2508	11.9788	12.0627	10.3601	9.4507
12	11.9771	12.6652	12.6383	11.8502	12.2777	9.5005	9.1193
13	10.9346	11.2615	11.5775	10.463	11.5209	8.934	9.5799
14	10.8247	10.3446	10.6327	9.9651	11.1111	8.2602	9.429
15	11.2546	11.5369	11.5244	10.6899	12.1622	8.2179	8.7997
16	11.1283	11.4803	12.1651	10.818	12.084	8.2888	8.742
17	11.3557	11.5621	12.5218	11.1031	12.084	1.3146	9.1616
18	12.188	12.5555	13.1105	11.8387	12.8572	1.2757	9.8222
19	13.5111	14.6205	15.0634	13.7089	14.5708	1.8073	12.7841
20	12.9115	13.6957	13.9507	12.8744	13.8529	1.8604	12.6738
21	11.8656	12.4143	12.5309	11.9571	12.492	1.9342	11.9976
22	10.6568	11.0082	11.3243	1.773	11.5295	1.7375	10.9585
23	1.4118	9.4187	1.701	9.8474	10.0531	1.5364	9.628
24	7.7835	8.4614	8.0653	8.1739	8.4002	8.7792	1.2752
Max	13.5111	14.6205	15.0634	13.7089	14.5708	10.3996	12.7841
Min	1.4118	8.2962	1.701	1.773	7.0605	1.2757	1.1763
Avg	9.6580	10.6436	10.3007	9.9803	10.5848	6.6895	6.7804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 201 / 11 KV BIDIGHARKUL
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 203 / 11KV GANDHI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			1.8061	1.6347	1.6871	1.0669	
10			1.9319	1.6766	1.7585	1.1288	1.0174
11			2.0538	1.7528	1.7623	1.1288	1.0059
12			1.9566	1.7604	1.8576	1.2041	.9431
13			1.6404	1.6432	1.5623	1.1431	.9145
14			1.8842	1.669	1.7309	1.0898	.8316
15			1.8842		1.8328	.8573	.8402
16			1.9319	1.6461	1.8099	.7316	.8402
17	1.7394	1.6766	1.5051	1.5718	1.8576		1.8576
18	1.6385	1.6766	1.5051	1.4861	1.8061		1.9566
19	1.5061	1.3717	1.448	1.2955	1.6289		1.6289
20	1.3289	1.4661	1.0669	1.0669	1.3003		
21	1.0745	1.0155	1.0031	1.0031	1.1517		
22	1.1641	.9145	.9488	.9145	1.1517		
23	.8954	.8573	.905	.8954			
Max	1.7394	1.6766	2.0538	1.7604	1.8576	1.2041	1.9566
Min	.8954	.8573	.905	.8954	1.1517	.7316	.8316
Avg	1.3353	1.2826	1.5647	1.4297	1.6356	1.0438	1.1836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 207 / 11 KV GADAGI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0374	1.0374	1.0374	.9431
2				1.0374	.9431	1.0374	.9431
3				.9431	.9431	1.0374	.9431
4				.9431	.9431	1.0374	.9431
5				.9431	.9431	1.0374	.9431
6				.9431	1.1317	1.1317	1.0374
7				1.0374	1.226	1.226	1.226
8				1.2136	1.1088	1.2136	1.0374
9	1.1088	1.0164	.924	1.1088	1.0164	1.0974	
10	1.0059	1.0059	.9955	1.1088	.905	.9955	
11	.924	1.0059	.905	1.0059	1.0164	.9955	
12	.8954	.9955	.905	1.0059	.905	.985	
13	.9145	1.0059	.9431	.9955	.905	.8859	.823
14	.905	.924	.924	.8954	.924	.8954	.8316
15	.924	1.0164	.924	.8669	.905	.905	.924
16	.9145	1.0164	1.0059	.9431	.9145	.9145	.924
17	.985	1.0059	1.1641	1.1269	.9335		
18	1.0631	1.0974	1.5775	1.286	1.0164		
19	1.5947	1.8099	1.7718	1.3413	1.5384		
20	1.6118	1.7375	1.7013	1.6108	1.448		
21	1.5061	1.6118	1.7194	1.5927	1.6461		
22	1.4632	1.4327	1.3289	1.2431	1.5546		
23	1.2269	1.2536	1.2136	1.307			
24				1.0374	1.0374	1.1317	1.0374
Max	1.6118	1.8099	1.7718	1.6108	1.6461	1.226	1.226
Min	.8954	.924	.905	.8669	.905	.8859	.823
Avg	1.1362	1.1957	1.2002	1.1072	1.0844	1.0332	.9659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 201 / AMRAPALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3584	.3395	.4338	.4338	.4338	.415
2	.3018	.3206	.3395	.415	.3961	.415	.3961
3	.3018	.3206	.3395	.3961	.3961	.415	.3961
4	.3018	.3206	.3395	.3961	.3772	.415	.3961
5	.3018	.3395	.3772	.4338	.3772	.415	.3961
6	.3395	.3584	.4108	.4294	.4294	.4294	.4338
7	.4715	.4715	.5415	.4668	.5601	.4715	.4668
8	.6661	.6859	.8288	.703	.6859	.5611	.5228
9	.8381	.8436	.9145	.8488	.8688	.6299	.5304
10	.8429	.8749	.9031	.9214	.9511	.6464	.5175
11	.9105	.945	.9659	.9602	.9242	.663	.5544
12	.9414	1.0059	1.0059	.9217	.9934	.6036	.5788
13	.8482	.8684	.9122	.7522	.8642	.5552	.5975
14	.7625	.7373	.8002	.7274	.7842	.4755	.5788
15	.9282	.8592	.9332	.8383	.9783	.4572	.5281
16	.8951	.8642	.9755	.8796	.9646	.4572	.5658
17	.9259	.9105	1.0084	.884	.9488	.4755	.5975
18	.933	.9259	.9808	.945	.9374	.4525	.6099
19	.9391	1.0288	1.0774	.9835	1.0117	.6401	.8131
20	.8596	.9214	.9134	.8507	.9134	.6468	.7392
21	.7392	.7762	.7762	.7316	.7865	.6468	.7392
22	.5975	.5975	.6401	.5914	.6036	.5601	.6468
23	.4668	.4527	.5601	.5601	.5359	.5041	.5415
24	.415	.415	.3961	.4904	.4527	.4854	.4338
Max	.9414	1.0288	1.0774	.9835	1.0117	.663	.8131
Min	.3018	.3206	.3395	.3961	.3772	.415	.3961
Avg	.6611	.6751	.7200	.6900	.7156	.5190	.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 202 / 11 KV ASHOK CHOWK1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3258	.3475	.4066	.4066	.4163	.3658
2	.3109	.3258	.3109	.4066	.4066	.4207	.3475
3	.3109	.3258	.3109	.4066	.4024	.4207	.3292
4	.3109	.3258	.3109	.3841	.3801	.4207	.3292
5	.3292	.362	.3292	.3982	.3761	.4066	.3292
6	.3658	.4119	.3582	.443	.443	.439	.4835
7	.5068	.567	.4784	.4854	.5784	.4525	.5316
8	.7202	.7343	.823	.6706	.7621	.6325	.5316
9	.8431	.823	.9202	.8642	.8802	.7331	.4908
10	.771	.8505	.881	.8901	.8291	.719	.463
11	.8762	.9334	.9191	.9739	.9198	.727	.407
12	.8545	.9198	.9334	.9469	.9328	.6537	.4115
13	.751	.86	.7928	.8177	.7981	.4999	.4252
14	.6308	.7482	.7331	.7472	.7145	.4858	.4075
15	.7895	.8623	.8522	.8901	.9054	.4641	.4024
16	.8135	.904	.9536	.8484	.8935	.4359	.4024
17	.7735	.8928	.8916	.8368	.8928	.4115	.3982
18	.7133	.9469	.8939	.8251	.8545	.3944	.4252
19	.7773	.9602	.9332	.828	.8688	.5548	.6661
20	.6796	.7956	.8288	.7209	.7459	.5959	.6935
21	.6344	.7377	.7461	.6539	.6952	.6135	.6588
22	.5548	.6379	.6661	.5784	.6762	.5552	.5316
23	.4656	.4706	.5552	.5373	.5552	.4755	.4525
24	.3841	.3801	.4024	.4572	.439	.4525	.3841
Max	.8762	.9602	.9536	.9739	.9328	.7331	.6935
Min	.3109	.3258	.3109	.3841	.3761	.3944	.3292
Avg	.6048	.6709	.6738	.6674	.6815	.5159	.4528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 203 / 11 KV PATHAN BAG1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.3921	.4854	.5041	.5228	.4668
2	.3734	.3921	.3547	.4854	.4904	.5228	.4481
3	.3734	.3547	.3361	.4854	.4715	.5359	.4294
4	.3734	.3547	.3361	.4715	.4668	.4854	.4294
5	.3734	.3547	.3547	.4294	.4668	.4854	.4294
6	.4294	.4108	.3734	.462	.5601	.5175	.5228
7	.5601	.5359	.4854	.5544	.5914	.5544	.5914
8	.6556	.6762	.6859	.7087	.7108	.6556	.5853
9	.7122	.6783	.6882	.7291	.6962	.57	.5487
10	.6167	.663	.6718	.6802	.6325	.5182	.6762
11	.6241	.6241	.6093	.6882	.6405	.5121	.5201
12	.6019	.8029	.6081	.6009	.6874	.4534	.407
13	.5243	.6874	.5243	.5197	.5668	.3681	.4973
14	.4578	.6706	.5407	.547	.5801	.3582	.4801
15	.6062	.7956	.6478	.5921	.68	.3801	.4163
16	.5801	.7545	.663	.6036	.663	.4207	.439
17	.6554	.7625	.6964	.6478	.6882	.4525	.5068
18	.6783	.7625	.7045	.7045	.6874	.4207	.5014
19	.7087	.8939	.8059	.7362	.7362	.6401	.7682
20	.6805	.8238	.7796	.6805	.7343	.6697	.724
21	.6516	.7602	.7059	.6335	.6626	.6697	.724
22	.6219	.695	.6584	.6036	.7133	.6219	.6036
23	.5121	.5544	.5914	.6468	.6767	.5544	.5729
24	.4481	.4668	.4668	.5228	.5788	.5729	.4854
Max	.7122	.8939	.8059	.7362	.7362	.6697	.7682
Min	.3734	.3547	.3361	.4294	.4668	.3582	.407
Avg	.5512	.6202	.5700	.5924	.6202	.5193	.5322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 201 / 11 KV SIDDHESHWAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 202 / 11 KV MIDC NO 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 203 / 11 KV GANDHI NAGAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 204 / 11 KV POLYTECHNIC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 205 / 11 KV YASHAWANT MILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 207 / 11 KV MIDC NO 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 401 / 33 KV JULE SOLAPUR

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 402 / 33 KV INDUSTRIAL ESTATE

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 404 / 33 KV BIDII GHARKUL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.703	.6562	.703	.6562	.8436	
2	.4687	.703	.6562	.7499	.6093	.8436	
3	.4687	.7499	.6093	.7968	.6093	.8436	
4	.4687	.7499	.6093	.8905	.6093	.7499	
5	.4687	.7968	.7116	.9842	.703	.7499	
6	.5155	.7968	.759	1.1248	.703	.8436	
7	.6562	.8436	.8065	1.3592	.8436	.9374	
8	1.5466	2.3434	2.0399	2.6715	2.0153	1.4529	
9	2.5777	2.7183	3.562	2.9995	2.9527	2.0153	.8436
10	3.2339	3.4214	3.9369	3.6557	3.5151	2.1559	1.1717
11	3.4682	3.9369	3.8432	4.0306	4.0306	2.2028	1.2186
12	3.3276	3.75	2.021	3.7963	3.9838	1.8747	1.0311
13	2.5309	2.8589	2.6715	2.8121	2.8589	1.2654	.8905
14	2.6246	2.484		2.6715	3.0464	.8436	.6642
15	3.0464	3.2808	3.1402	3.187	3.6557	.7499	.5693
16	3.187	3.3745	3.6088	3.3276	3.7026	.7968	.5693
17	3.2339	3.3745	3.5151	3.2808	3.7026		.6167
18	2.1091	3.187	3.1402	3.3333	3.3745		.5693
19	1.6872	2.0153	2.0622	2.1759	2.2497		.6642
20	1.0311	1.3592	1.406	1.4815	1.4998		.6167
21	.8905	.9842	1.0311	1.1248	1.1717		.5693
22	.7499	.8436	.8436	.9842	1.1717		.5693
23		.7499	.7499	.6562	1.0311		.5218
24	1.7078	.6562	.6093	.6562	.6562	.9374	
Max	3.4682	3.9369	3.9369	4.0306	4.0306	2.2028	1.2186
Min	.4687	.6562	.6093	.6562	.6093	.7499	.5218
Avg	1.7595	1.9450	1.8691	2.0605	2.0563	1.1827	.7390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3375	7.356	6.677	7.6955	6.8467	7.2428	
2	6.1677	7.4691	6.6204	7.8087	6.5072	7.1296	
3	6.0545	7.5823	6.4506		6.4506	6.9599	
4	6.1111	7.6955	6.4506	8.0916	6.394	7.0165	
5	6.2243	7.8087	6.5638	8.3745	6.677	7.2428	
6	7.2428	7.9784	7.8087	8.6574	7.356	7.5823	
7	7.9218	8.1482	7.9218	8.8272	8.0916	7.8087	
8	9.2798	11.0906	10.5247	10.8642	10.1852	9.2798	
9		11.5998	12.4486	12.1091	12.2788	11.8827	8.035
10	12.1657	12.4486	12.9578	12.4486	12.0525	10.355	8.6008
11	12.6183	12.9578	13.3539	13.1276	13.2973	10.4681	8.6008
12	12.8447	13.5803	13.6369	12.9013	13.2408	9.5062	8.3745
13	11.0906	11.3169	12.4486	10.9774	11.7696	8.6008	8.6008
14	11.3735	10.6945	28.4054	10.8642	11.7696	7.5823	8.1779
15	13.9198	12.4486	12.3354	11.713	13.1842	7.6389	7.8652
16	11.7696	12.2222	13.2408	11.7696	13.071	7.4691	7.6955
17	12.2788	12.392	13.2973	11.8827	13.0144		8.1482
18	12.392	12.7315	13.1276	12.3354	13.3539		8.7706
19	12.5052	13.1276	13.4671	12.9013	13.75		11.0906
20	11.4301	11.8261	12.2222	11.6564	12.6749		10.9774
21	10.4115	10.751	10.8642	10.6379	11.3169		10.4115
22	9.3364	9.6194	9.9023		10.4681		9.6194
23		8.3745	8.8272	8.6008	9.1101		8.5443
24	8.3025	7.2994	7.2428	7.5823	7.5257	7.9784	
Max	13.9198	13.5803	28.4054	13.1276	13.75	11.8827	11.0906
Min	6.0545	7.2994	6.4506	7.5823	6.394	6.9599	7.6955
Avg	9.8990	10.3550	11.1165	10.5376	10.4328	8.3379	8.9008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 406 / 33 KV PAPER PLANT - I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
15		13.0144
24	1.286	
Max	1.286	13.0144
Min	1.286	13.0144
Avg	1.286	13.0144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 407 / 33 KV PAPER PLANT - II

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 201 / 11KV RAMWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.964	.8859	.9568	.9922	.9745	.9568	1.0099
2	.964	.8505	.9391	.9568	.9568	.9568	.9922
3	.964	.8505	.9391	.9568	.9568	.9214	.9391
4	.964	.8505	.9214	.9391	.9391	.8859	.9214
5	.9816	.8505	.9036	.9214	.9568	.8505	.9214
6	1.0166	.8505	.9036	.9036	1.0099	.8859	.9922
7	1.0517	.8505	.9214	.8505	.9745	.8505	.9568
8	.8764	.8859	.9391	.8682	.9214	.8682	.9568
9		.9568	.9568	.8682	.8859	.9214	.9568
10		.9036	.9391	.8682		.8859	.9568
11		.8505	.8859	.8505		.9745	.9214
12		.8505	.8859	.815		.9036	.9214
13		.9214	.9214	.7796		.9568	.9391
14		.815	.9036			.8682	.9568
15		.7973	.9391	.8328		.9391	.9745
16			.9214	.9214		.9036	1.0099
17	.9492	.8859	.8859	.8328	.9391		
18		.8682	1.0277	.9214	1.0277	.9922	1.0208
19	1.3073	1.2048	1.3998	1.1744	1.2934	1.3112	
20	1.3253	1.2403	1.2934	1.2094	1.3466	1.3112	1.3253
21	1.258	1.2403	1.2403	1.1919	1.3289	1.2934	1.3073
22	1.1694		1.1871	1.1694	1.2403	1.2757	1.3073
23	1.0985	1.1163	1.0985	1.1163	1.134	1.1694	1.2048
24	.9816	.9745	.9745	.9922	.9745	1.0277	1.0454
Max	1.3253	1.2403	1.3998	1.2094	1.3466	1.3112	1.3253
Min	.8764	.7973	.8859	.7796	.8859	.8505	.9214
Avg	1.0581	.9318	.9952	.9536	1.0506	.9961	1.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 202 / 11KV PRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.2286	.2286	.2286	.2477	.2096
2	.2096	.2286	.2286	.2286	.2096	.2477	.2096
3	.2096	.2286	.2286	.2286	.2096	.2477	.2096
4	.2096	.2286	.2286	.2286	.2096	.2477	.2096
5	.2096	.2286	.2286	.2286	.2096	.2477	.2096
6	.2263	.2286	.2477	.2477	.2286	.2477	.2286
7	.2075	.2286	.2477	.2286	.2096	.2286	.2096
8	.2096	.2286	.2096	.2096	.1905	.2286	.1905
9		.2263	.2096	.2096	.2096	.1905	.1905
10		.2641	.2477	.2667		.3048	.1715
11		.3018	.2858	.3239		.2477	.1524
12		.3018	.2858	.2858		.2286	.1524
13		.2452	.2477	.2477		.2096	.1715
14		.2641	.2667			.2286	.1715
15		.2829	.3239	.3429		.2477	.1715
16			.2667	.3048		.2263	.1905
17	.3239	.3018	.2641	.2667	.362		
18		.2829	.3018	.2829	.3048	.1905	.1905
19	.2667	.2641	.2641	.2477	.2858	.2096	
20	.2286	.2263	.2452		.2667	.2286	.2096
21	.2286	.2263	.2452	.2286	.2667	.2286	.9145
22	.2096		.2452	.2286	.2477	.2286	.2096
23	.2096	.2286	.2477	.2286	.2477	.2096	.2096
24	.2075	.2096	.2286	.2286	.2286	.2477	.2096
Max	.3239	.3018	.3239	.3429	.362	.3048	.9145
Min	.2075	.2096	.2096	.2096	.1905	.1905	.1524
Avg	.2244	.2471	.2510	.251	.2421	.2335	.2269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 203 / 11KV POLYTECHNIC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5365	.6468	.6722	.6468	.6468	.6283
2	.5658	.5365	.6283	.6722	.6283	.6283	.6283
3	.5658	.5365	.6283	.6535	.6283	.6161	.6161
4	.6161	.5365	.6348	.6535	.6348	.5975	.5975
5	.6001	.5487	.6535	.6722	.6535	.5975	.5788
6	.6001	.5487	.6722	.7282	.6722	.6535	.6535
7	.5868	.6173	.6908	.8215	.7023	.6584	.6722
8	.7545	.7716	.8383	.9189	.7628	.7619	.7023
9		.9831	.8539	.9995	.9122	.7125	.6626
10		.9431	.8539	1.1706		.9774	.6024
11		1.0208	.8173	1.0159		.8063	.5373
12		1.0029	.7727	.9012		.7973	.567
13		.7973	.6944	.852		.6447	.5611
14		.8417	.7209			.6154	.5731
15		.8954	.8718	.8745		.6268	.5853
16			.8482	.8421		.6268	.5847
17		.8402	.9259	.9568			
18		.8848	.9442	.9745	.9835	.695	.6089
19	.9882	1.046	1.0852	.9313	1.0974	.9877	
20	.9922	1.0341	1.0745	1.0166	1.0341	1.0029	.9134
21	.9313	.9511	.9877	1.0242	.929	.9328	
22	.8417		.8589	.9145	.8954	.8962	.8779
23	.703	.7682	.7865	.7682	.7947	.7577	.7682
24	.5658	.57	.6468	.6908	.6468	.6653	.6468
Max	.9922	1.046	1.0852	1.1706	1.0974	1.0029	.9134
Min	.5658	.5365	.6283	.6535	.6283	.5975	.5373
Avg	.7055	.7823	.7973	.8576	.7889	.7350	.6460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 204 / 11KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9465	.9214	1.0029	1.0745	1.0387	1.0208	1.0208
2	.9465	.8859	.985	1.0566	1.0208	.9492	.985
3	.9465	.8859	.9671	1.0387	.9671	.9134	.9492
4	.9465	.8859	.9492	1.0029	.9671	.8775	.9134
5	.9465	.8859	.9313	.9671	.9671	.8417	.8954
6	.9465	.8859	.9134	.9313	.985	.9313	.9492
7	1.0166	.8859	.9492	.9671	1.0029	.9134	1.0029
8	.964	.9568	.9313	1.0387	1.0029	.8954	.9492
9		.9922	.9671	1.0208	.9134	.8596	.9134
10		.9492	.8954	.985		.8596	.8596
11		.8954	.8596	.9313		.8238	.8059
12		.8775	.8954	.8954		.8238	.8775
13		.8238	.9671	.8954		.8238	.8954
14		.8059	.9313			.8775	.8775
15		.8238	.9492	.9313		.9134	.8775
16			.8954	.8775		.9134	.9313
17	.7964	.8059	.8775	.8775	.8417		
18		.9134	1.0208	.9671	.8596	.9492	.9671
19	1.2894	1.3969	1.4864	1.3969	1.3969	1.379	
20	1.3253	1.379	1.4864	1.2715	1.4506	1.4327	1.4148
21	1.2536	1.3432	1.4148	1.379	1.4148	1.379	1.379
22	1.2178		1.3289	1.2178	1.379	1.3432	1.3611
23	1.0985	1.1462	1.1641	1.1462	1.2536	1.1641	1.1999
24	.9816	1.0277	1.0208	1.0924	1.0387	1.0924	1.0566
Max	1.3253	1.3969	1.4864	1.3969	1.4506	1.4327	1.4148
Min	.7964	.8059	.8596	.8775	.8417	.8238	.8059
Avg	1.0415	.9715	1.0329	1.0418	1.0882	.9990	1.0037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 206 / 11KV ESTATE 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2241	.1981	.208	.1808	.1635	.1743
2	.1797	.216	.1932	.1974	.1758	.152	.16
3	.184	.216	.1907	.2054	.1783	.148	.1574
4	.184	.2134	.1907	.2107	.1833	.1372	.1437
5	.184	.2134	.1882	.2214	.1858	.1372	.1437
6	.184	.2134	.2	.2401	.2027	.1467	.1574
7	.2147	.2622	.2622	.221	.2241	.176	.1654
8	.2134	.3429	.3814	.3601	.3163	.2362	.161
9		.3772	.4805	.4668	.4294	.2896	.1932
10		.463	.5914	.5228		.4344	.3315
11		.4835	.4435	.5121		.3898	.3772
12		.5434	.5544	.5121		.4207	.4207
13		.4835	.5175	.4784		.439	.3988
14		.4961	.5068			.4887	.3681
15		.5138	.5373	.5083			.3721
16			.5093	.5144		.4508	.3944
17		.5552	.5281	.5258	.5093		
18		.5601	.4938	.4607	.4805	.3475	.285
19	.3988	.5601	.3612	.3506	.3681	.2743	
20	.2949	.3403		.3155	.2972	.217	.2263
21	.2984	.3155	.2743	.2629	.241	.2256	.2054
22	.2347		.2458	.2187	.2054	.2	.1886
23	.1654	.2267	.2214	.216	.18	.18	.1802
24	.1677	.2347	.2031	.2134	.1858	.1677	.1743
Max	.3988	.5601	.5914	.5258	.5093	.4887	.4207
Min	.1654	.2134	.1882	.1974	.1758	.1372	.1437
Avg	.2199	.3661	.3597	.3453	.2673	.2646	.2445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 207 / 11 KV ESTATE-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	.1715
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 209 / 11KV MITRAGOTRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 201 / 11 KV MANTRI CHANDAK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5853	.5975	.5853	.6401	.6401
2			.6535	.6036	.567	.5487	.6219
3			.6584	.5121	.5487	.5121	.5487
4			.5487	.5304	.5121	.5304	.567
5			.5853	.567	.567	.5487	.5601
6			.5729	.5601	.5853	.567	.567
7			.5487	.5853	.6219	.6036	.6036
8	.6036	.6401	.5853	.6348	.6036	.6401	.6535
9	.5487	.6036		.6602			.5138
10	.5487	.5487		.5847			.4961
11	.4525	.5487		.5601			.4115
12	.4525	.5121	.5304	.5093			.4668
13	.5068	.4938		.4715			.4854
14	.4525	.4755		.4668			
15	.4854	.4755		.4668			
16	.5228	.5093		.5121			
17	.6535	.5281	.5975	.5228	.543	.4668	.5601
18	.7682	.5658	.6348	.547	.5847	.5041	.5975
19	.8413	.8589	.8589	.7842	.7973	.7655	.8029
20	.7682	.8402	.8589	.7947	.8215	.7762	.8029
21	.7316	.7842	.8215	.7762	.7842	.7392	.7655
22	.7133	.7282	.7468	.7392	.7468	.7023	.7468
23		.6838	.695	.695	.7282	.695	.7133
24	.567		.6401	.6535	.6767	.6584	.6584
Max	.8413	.8589	.8589	.7947	.8215	.7762	.8029
Min	.4525	.4755	.5304	.4668	.5121	.4668	.4115
Avg	.6010	.6123	.6542	.5973	.6421	.6186	.6087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 202 / 11 KV VIMANTAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4755	.4938	.5121	.5487	.5853
2			.4572	.4805	.5359	.5304	.567
3			.5041	.4668	.4854	.5121	.5304
4			.5121	.4481	.4572	.4938	.5487
5			.5304	.4207	.4938	.5121	.5487
6			.5304	.4207	.4938	.4938	.5601
7			.4938	.4066	.4572	.4572	.5304
8	.4024	.4024	.4572	.439	.4024	.3841	.5228
9	.439	.4938		.4904			.5544
10	.439	.4887		.5847			.5544
11	.439	.5175		.4572			.4435
12	.4572	.5068	.4344	.4024			.415
13	.3961	.4108		.3658			.499
14	.3395	.3772		.3841			
15	.3395	.3772		.3841			.5544
16	.4115	.4338		.4108			.5359
17	.5487	.4715	.4481	.4108	.415	.4066	.5544
18	.5304	.5093	.5093	.4338	.415	.4435	.5544
19	.567	.5281	.6224	.5847	.547	.5601	.5914
20	.5487	.5658	.6602	.5658	.5847	.5847	.6224
21	.5304	.5658	.6602	.5658	.5658	.5658	.6224
22	.4572	.547	.6979	.5281	.5658	.5281	.6602
23		.5304	.5487	.5853	.6036	.6219	.567
24	.4207		.4938	.5121	.5487	.5853	.6036
Max	.567	.5658	.6979	.5853	.6036	.6219	.6602
Min	.3395	.3772	.4344	.3658	.4024	.3841	.415
Avg	.4541	.4829	.5315	.4684	.5052	.5143	.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 203 / 11 KV SHINDU VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9795	.7133	.9145	.9335	.9145
2			.9511	.7468	.8779	.9694	.9328
3			.9694	.7842	.8596	.9877	.9335
4			1.0059	.7865	.8962	.9896	.9328
5			1.0456	.8962	.9328	.9328	1.0242
6			1.0242	.9328	.9694	.9511	1.0608
7			1.0242	1.0456	.9877	1.0829	1.0425
8	1.0719	.9593	1.0425	1.0791	1.0164	1.0974	1.0349
9	.8962	.905		1.0374			.8962
10	.8402	.8326		.9619			.8589
11	.7842	.788		.9054			.7655
12	.7655	.7964	.7392	.8676			.7468
13	.7655	.7964		.7888			.6979
14	.7186	.7964		.8676			.7545
15	.7186	.8326		.8488			.7545
16	.7011	.8326		.8488			.7733
17	.823	.8676	.7922	.8676	.811	.8299	.7922
18	1.0425	.8299	.8488	.8865	.8488	.8299	.8488
19	1.1576	1.2136	1.1883	1.1203	1.226	1.1883	1.1506
20	1.1203	1.1949	1.2071	1.1576	1.1949	1.2071	1.2071
21	1.1157	1.1576	1.1883	1.1203	1.1576	1.1694	1.1694
22	1.0974	1.094	1.1506	1.0829	1.1506	1.1317	
23		.9979	.9877	.9877	1.0425	1.0242	1.0425
24	.8686		.9694	.9145	.9511	1.0059	.9694
Max	1.1576	1.2136	1.2071	1.1576	1.226	1.2071	1.2071
Min	.7011	.788	.7392	.7133	.811	.8299	.6979
Avg	.9054	.9309	1.0067	.9270	.9898	1.0207	.9262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 204 / 11 KV SHIVASHAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2614	.2241	.1867	.2614	.2241
2			.2195	.2195	.2241	.2743	.2561
3			.2561	.2561	.2561	.2378	.2743
4			.2801	.2801	.2743	.2743	.2926
5			.2926	.2743	.2926	.2926	.2743
6			.2743	.2743	.2926	.2926	.2987
7			.2926	.2743	.2743	.2743	.3109
8	.3142	.2743	.2926	.2378	.2614	.2801	.3292
9	.2743	.2801		.3547			.2402
10	.2587	.2801		.2614			.2218
11	.2172	.2801		.2427			.2033
12	.1991	.2572	.2715	.2427			.2054
13	.1991	.2229		.2427			.2054
14	.1991	.2229		.2328			.2054
15	.2172	.2378		.2149			.2054
16	.2195	.2804		.2195			.2263
17	.2195	.2452	.2427	.2195	.2772	.2328	.2263
18	.2587	.2641	.2427		.2801	.2507	.2452
19	.2614	.3326	.3361	.3292	.3361	.3224	.3395
20	.2561	.3475	.3361	.3142	.3206	.3109	.3361
21	.2195	.3142	.3174	.3142	.3206	.2926	.3174
22	.2926	.2829	.2957	.2957	.2987	.2743	.2801
23		.2926	.2743	.2561	.2926	.2561	.2926
24	.2195		.2561	.2561	.2195	.2743	.2195
Max	.3142	.3475	.3361	.3547	.3361	.3224	.3395
Min	.1991	.2229	.2195	.2149	.1867	.2328	.2033
Avg	.2391	.2759	.2789	.2625	.2755	.2751	.2596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 205 / 11 KV KUMATHA GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4938	.4668	.5304	.5121	.4854
2			.4572	.4755	.5487	.5304	.4572
3			.5415	.4938	.5788	.5487	.4755
4			.5487	.5228	.5853	.5304	.5487
5			.5914	.5487	.6535	.567	.567
6			.6219	.567	.6219	.5487	.5975
7			.5487	.5121	.5487	.5487	.5121
8	.4382	.4572	.4572	.4572	.4755	.5304	.4755
9	.3506	.2743		.439			.3881
10	.3292	.439		.3734			.333
11	.3155	.3961		.3506			.3294
12	.3801	.4527	.362	.3361			.3467
13	.3506	.4527		.3155			.3641
14	.3506	.4527		.3155			.3429
15	.1402	.439		.3506			.3429
16	.4251	.462		.3841			.3658
17	.439	.462	.4163	.4163	.4066	.4338	.3658
18	.4755	.439	.4298	.5853	.4066	.4527	.4024
19	.5304	.6219	.6154	.5914	.6653	.6413	.6584
20	.5975	.6838	.6767	.5544	.6908	.6722	.6767
21	.6036	.6468	.6348	.5544	.6535	.6348	.6401
22	.5487	.5847	.5658	.5175	.6036	.6161	.6036
23		.5121	.5121	.5304	.5228	.5121	.5121
24			.4755	.4755	.5121	.4938	.4938
Max	.6036	.6838	.6767	.5914	.6908	.6722	.6767
Min	.1402	.2743	.362	.3155	.4066	.4338	.3294
Avg	.4183	.486	.5264	.4639	.5628	.5483	.4702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 206 / 11 KV SANTOSH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8779	1.0349	1.0608	1.0242	1.0242
2			.8596	.9145	.961	1.0059	1.0082
3			.8413	.8775	.9328	.9877	.9145
4			.8316	.8779	.9145	1.0349	.9328
5			.8596	.8686	.9328	1.0608	.9511
6			.9149	.8779	.9694	1.0425	.9511
7			.9335	.8962	1.0242	1.0242	.9335
8	.9694	.9877	.9694	.9335	1.0534	.9877	.8962
9	.8145	.9328		.9145			.8686
10	.7602	.8596		.9328			.8059
11	.1524	.7865		.8779			.7442
12	.631		.7392	.8402			.7087
13	.631	.7499		.8059			.703
14	.6836	.7499		.8059			.703
15	.7133	.7499		.8059			.7202
16	.788	.7865		.8413			.8145
17	1.0242	.8326	.924	.9145	.8779	.788	.8507
18	1.134	.9774	1.0056	1.0136	.9774	.8059	.905
19	1.3169	1.3756	1.382	1.3394	1.2851	1.3432	1.3394
20	1.2803	1.3611	1.4661	1.3937	1.3213	1.382	1.3611
21	1.2986	1.2894	1.3756	1.3575	1.3032	1.3466	1.3253
22	1.2071	1.2127	1.2489	1.267	1.267	1.2757	1.2536
23		1.1203	1.1763	1.1389	1.1827	1.1763	1.2136
24	.8962		1.0642	1.0974	1.0974	1.1203	1.0974
Max	1.3169	1.3756	1.4661	1.3937	1.3213	1.382	1.3611
Min	.1524	.7499	.7392	.8059	.8779	.788	.703
Avg	.8938	.9848	1.0276	.9845	1.0726	1.0879	.9594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 207 / 11KV WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.181	.2172	.181	.181	.181
2			.181	.2172	.2172	.2172	.2172
3			.2172	.2172	.2172	.2172	.181
4			.2172	.2172	.181	.2172	.2172
5			.3801	.2172	.3801	.3801	.2172
6			.1991	.4163	.4163	.4163	.2172
7			.3801	.3801	.3982	.3801	.3801
8	.3982	.2172	.2172	.3982	.4163	.2172	.2172
9	.3982	.4163		.1991			.3982
10	.4163	.4163		.362			.4344
11	.3982	.2172		.2172			.2172
12	.4344	.4163	.4163	.362			.3982
13	.2172	.4163		.2353			.4163
14	.3982	.3982		.2353			
15	.3982	.2172		.3982			
16	.4344	.1991		.2172			
17	.3801	.2172	.2172	.2172	.2172	.3982	.3982
18	.3801	.2172	.2172	.4163	.3982	.2172	.2172
19	.3982	.2172	.4163	.2172	.3982	.2172	.4163
20	.2172	.2172	.2172	.2172	.2172	.2172	.2172
21	.2172	.2172	.2172	.2172	.2172	.2172	.2172
22	.1991	.2172	.2172	.2172	.2172	.2172	.2172
23		.1991	.2172	.2172	.2172	.2172	.2172
24	.2172		.2172	.181	.2172	.2172	.2172
Max	.4344	.4163	.4163	.4163	.4163	.4163	.4344
Min	.1991	.1991	.181	.181	.181	.181	.181
Avg	.3439	.2760	.2545	.2670	.2817	.2591	.2767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 208 / 11 KV SHANTIVAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5853	.5975	.5788	.5415	.0943
2			.5544	.5729	.5487	.5788	.1132
3			.5304	.6401	.5853	.5853	.0943
4			.6335	.7316	.6401	.7468	.0943
5			.7316	.823	.7682	.823	.1132
6			.8048	.8686	.7865	.8501	.1132
7			.8779	.8779	.9328	.9145	.0943
8			.0943	.1132	.0943	.0943	.0943
9	.0943	.0943		.0934			.7545
10	.0857	.0943		.0914			.9054
11	.0943	.0943		.0914			.9516
12	.0943	.0943		.0914			.9808
13	.0943	.1132		.1132			.6219
14	.0943	.1097					
15	.1132	.1132		.1097			
16	.1132	.0075		.1097			
17	.0943	.0754	.0943	.1097	.1132	.0943	.0943
18	.0754	.0943	.1132	.128	.1132	.1132	.1132
19	.0943	.132	.1509	.1646	.1509	.1698	.1698
20	.0943	.1509	.1698	.1646	.1698	.1698	.1698
21	.0943	.132	.1509	.1463	.1698	.1509	.1509
22	.4527	.4338	.415	.4207	.415	.132	.132
23		.5487	.5975	.6036	.5847	.0943	.132
24			.5487	.5487	.5487	.5487	.0943
Max	.4527	.5487	.8779	.8779	.9328	.9145	.9808
Min	.0754	.0075	.0943	.0914	.0943	.0943	.0943
Avg	.1206	.1525	.4408	.3570	.45	.4130	.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 209 / 11 KV IMS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8779	.7842	.8596	.9145	.8779
2			.8596	.7947	.8413	.8962	.8413
3			.8779	.823	.9335	.8596	.8316
4			.9335	.8589	.9328	.8589	.8962
5			.9896	.8962	1.0059	.8402	.9896
6			1.0059	.8596	1.1157	.823	1.0425
7			1.1088	1.0974	1.1763	1.0059	1.0608
8	1.2254	1.0808	1.134	1.1576	1.2437	1.0829	1.0791
9	.8682	.9214		.9391			.8326
10	.815	.7442		.7973			.7964
11	.691	.7087		.7442			.6878
12	.6379	.691	.7316	.7922			.6516
13	.5373	.6556		.7442			.6335
14	.5373	.6556		.7087			
15	.5373	.6556		.691			
16	.5552	.6733		.691			
17	.7865	.7087	.7499	.7619	.7865	.7682	.6878
18	1.0608	.7619	.8048	.8682	.8596	.823	.724
19	1.1157	1.0277	1.0608	1.0631	1.0974	1.134	1.0498
20	1.0242	1.0277	1.0974	1.0277	1.134	1.1523	1.0498
21	1.0059	1.0099	1.0974	1.0099	1.1157	1.0974	1.0136
22	1.0082	.9922	1.0608	.9922	1.0791	1.0608	.9593
23		.9511	.9145	.9328	.9877	.9877	.9511
24	.8048		.9145	.8962	.9145	.9511	.9145
Max	1.2254	1.0808	1.134	1.1576	1.2437	1.1523	1.0791
Min	.5373	.6556	.7316	.691	.7865	.7682	.6335
Avg	.8257	.8291	.9541	.8721	1.0052	.9535	.8843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 210 / 11 KV BOMBAY PARK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7133	.695	.7316	.7468	.7499
2			.7316	.6767	.7282	.7282	.7468
3			.7207	.7133	.7392	.7023	.7282
4			.7316	.6535	.7133	.6767	.7682
5			.7682	.6468	.7133	.6584	.8048
6			.8048	.6219	.7133	.6908	.823
7			.823	.7682	.8029	.8048	.8596
8	.8413	.8413	.8775	.7865	.8402	.7865	.8962
9	.6036	.6626		.7023			.6878
10	.567	.591		1.1643			.6154
11	.5487	.5373		.6099			.5068
12	.5121	.5194	.5487	.5544			.5068
13	.4938	.5014		.5544			.0452
14	.4938	.5014		.5544			
15	.4938	.4835		.5544			
16	.5304	.5194		.5601			
17	.5853	.5373	.5487	.5914	.5731	.5014	.4887
18	.7316	.6089	.6036	.6099	.5552	.5373	.543
19	.8029	.8059	.823	.8501	.788	.8417	.8326
20	.7842	.8059	.8413	.8501	.8596	.8954	.8507
21	.8215	.8059	.8413	.8501	.8417	.8596	.8326
22	.8048	.8059	.8413	.8316	.8238	.8238	.7964
23		.7316	.7316	.7865	.8048	.7865	.7865
24	.6036		.7316	.7133	.7682	.7865	.7316
Max	.8413	.8413	.8775	1.1643	.8596	.8954	.8962
Min	.4938	.4835	.5487	.5544	.5552	.5014	.0452
Avg	.6387	.6412	.7460	.7041	.7498	.7392	.6953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 211 / 11 KV NEHARU NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7468	.6401	.7133	.7316	.823
2			.7682	.6219	.695	.6767	.7865
3			.7655	.6401	.7133	.6722	.7316
4			.7865	.6219	.7468	.6767	.7316
5			.8215	.6401	.7499	.6767	.7865
6			.823	.6584	.7316	.695	.8048
7			.823	.6767	.7133	.7316	.7316
8	.7499	.7682	.8048	.7133	.695	.7682	.7133
9	.6268	.6697		.6733			.6584
10	.5552	.6135		.567			.5853
11	.5373	.5784		.0532			.5304
12	.5194	.5609	.5487				.5304
13		.5258		.5316			.4572
14		.5258		.5316			
15		.5258		.5316			
16		.5083		.5316			
17	.5975	.5258	.6401	.567	.6447	.5853	.5853
18	.7682	.5784	.6767	.6024	.6984	.6401	.6401
19	.8413	.8238	.9145	.8859	.8596	.8779	.823
20	.8596	.8238	.9328	.8682	.8775	.9145	.8413
21	.8589	.8238	.8413	.8328	.8417	.8779	.823
22	.7865	.8238	.7865	.7619	.788	.8596	.7865
23		.8402	.7133	.7499	.7682	.8962	.7499
24	.6401		.7865	.6767	.7316	.7499	.8596
Max	.8596	.8402	.9328	.8859	.8775	.9145	.8596
Min	.5194	.5083	.5487	.0532	.6447	.5853	.4572
Avg	.6951	.6573	.7753	.6338	.7480	.7519	.7133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 212 / 11KV NTPC SMC
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0377	.0377	.0566	.0754	.0189
2			.0189	.0189	.0189	.0189	.0189
3			.0189	.0377	.0189	.0189	.0189
4			.0377	.0189	.0189	.0189	.0189
5			.0943	.1132	.0189	.132	.0189
6			.0189	.0189	.0189	.0189	.1132
7			.0189	.0189	.0943	.0566	.1132
8			.0189	.0189	.1132	.1132	.132
9	.0377	.132		.0377			.1132
10	.1132	.0377		.0566			.1132
11	.0377	.0377		.0566			.1132
12	.0377	.0377		.0377			.0377
13	.0377	.132		.0377			.0343
14	.0377	.0373		.1132			
15	.132	.0377		.0566			
16	.0377	.1132		.132			
17	.0377	.0189	.0189	.0189	.1132	.0377	.1132
18	.0189	.0189	.0189	.0189	.1132	.0377	.1132
19	.0189	.0377	.0189	.1132	.1132	.0377	.1132
20	.0943	.0189	.0189	.132	.1132	.1132	.1132
21	.1132	.0189	.0189	.1132	.1132	.1132	.1132
22	.0189	.0189	.0189	.0189	.1132	.1132	.1132
23		.0189	.0189	.1132	.1132	.1132	.1132
24			.0189	.0189	.0943	.0943	.0943
Max	.132	.132	.0943	.132	.1132	.132	.132
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0552	.0478	.0260	.0566	.0778	.0696	.0834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 202 / 11 KV SHANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.1576		1.1949	1.1203	1.1576	1.1576
2	1.0456	1.1203	1.0642	1.0642	1.0829	1.1576	1.1203
3	1.0082	1.0269	1.0456	1.0642	1.0829	1.1203	1.1203
4	1.0082	1.0082	1.0456	1.0642	1.0456	1.0829	1.1016
5	1.0456	1.1576	1.0829	1.0829	1.1763	1.1016	1.1763
6	1.1203	1.2696	1.3817	1.1949	1.3443	1.307	1.3817
7	1.4003	1.3443	1.475	1.307	1.4003	1.3256	1.5497
8	1.419	1.4003	1.3817	1.2883	1.3256	1.307	1.4377
9	1.1576	1.307	1.2323	1.1949	1.0642	1.2136	1.1949
10	1.1016	1.3256	1.1949	1.2696	1.1016	1.251	1.1203
11	.9522	1.2696	1.1763	1.2136	1.0642	1.2136	1.0829
12	.3734	1.2136	1.2136	1.251	1.1016	1.1949	.9896
13	1.0829	1.1389	1.1576	1.1763	1.0829	1.1949	1.0829
14	1.0456	1.0642	1.1949	1.1389	1.1389	1.1763	1.0642
15	1.0456	1.1763	1.1389	1.1949	1.1016	1.2136	1.1016
16	1.0269	1.1203	1.1949	1.1949	1.1576	1.2136	1.1389
17	1.0082	1.1763	1.0269	1.1576	1.1203	1.1763	1.0456
18	1.0829	1.1203	1.1949	1.4003	1.2883	1.1016	1.1203
19	1.8484	1.7737	1.8111	1.8298	1.7924	1.6991	1.7364
20	1.7551	1.587	1.7177	1.8298	1.8111	1.7364	1.6804
21	1.7177	1.7364	1.7177	1.7737	1.7364	1.8298	1.6617
22	1.6057	1.587	1.6244	1.643	1.6804	1.6991	1.6617
23	1.4377	1.4377	1.475	1.4563	1.475	1.475	1.4937
24	1.1949	1.251	1.251	1.2883	1.2883	1.3256	1.3256
Max	1.8484	1.7737	1.8111	1.8298	1.8111	1.8298	1.7364
Min	.3734	1.0082	1.0269	1.0642	1.0456	1.0829	.9896
Avg	1.1895	1.2821	1.2956	1.3031	1.2743	1.3031	1.2727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 203 / 11 KV SHIDDHESHWAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747	.0747	.0747	.0747	.0747	.0747
2	.056	.0747	.0747	.0747	.0747	.0747	.0747
3	.056	.0747	.0747	.0747	.0747	.056	.0747
4	.056	.0747	.0747	.0747	.0747	.0747	.0747
5	.0747	.0934	.0934	.0747	.0934	.0934	.0934
6	.0934	.0934	.0934	.112	.112	.0934	.1307
7	.0934	.0934	.0934	.0934	.0934	.0934	.0934
8	.0747	.0934	.0934	.0934	.0934	.0934	.0934
9	.0934	.0934	.0934	.0934	.0934	.0934	.0934
10	.0934	.0747	.0934	.112	.0934	.0934	.0934
11	.0934	.112	.1307	.168	.0934	.1867	.0934
12	.0934	.0747	.0934	.112	.0934	.1867	.0934
13	.0934	.112	.0934	.0747	.0934	.0934	.0934
14	.0934	.1307	.0934	.0934	.1494	.1307	.0934
15	.0934	.1494	.1307	.0934	.1307	.0934	.0934
16	.0934	.0934	.1494		.2054	.0934	.0934
17	.0934	.1307	.1307	.0934	.0934	.0934	.0934
18	.0934	.0934	.0934	.0934	.0934	.0934	.0934
19	.0934	.0934	.0934	.0934	.0934	.0934	.0934
20	.0934	.0934	.0934	.0934	.0934	.112	.0934
21	.0934	.0934	.0934	.0934	.0934	.0934	.0934
22	.0934	.0934	.0934	.0934	.0934	.0934	.0934
23	.1963	.0943	.0934	.0934	.0934	.0934	.0934
24	.0747	.0934	.0934	.0934	.0934	.0934	.0934
Max	.1963	.1494	.1494	.168	.2054	.1867	.1307
Min	.056	.0747	.0747	.0747	.0747	.056	.0747
Avg	.0891	.0958	.0973	.0942	.0996	.0996	.0918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 204 / 11 KV SWAGAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	1.2437	1.2437	1.3169	1.3717	1.3717	1.2254
2	1.0791	1.2437	1.2437	1.2986	1.3535	1.3717	1.2071
3	1.0425	1.2254	1.1888	1.2437	1.2986	1.2803	1.1706
4	1.0425	1.134	1.1949	1.2071	1.262	1.2986	1.1706
5	1.1157	1.262	1.2254	1.2437	1.3352	1.3535	1.2254
6	1.3717	1.5181	1.4998	1.4632	1.3352	1.5912	1.4449
7	1.4449	1.6644	1.5364	1.6827	1.5181	1.6278	1.4632
8	1.6278	1.7193	1.5912	1.7375	1.6827	1.5912	1.3817
9	1.6278	1.701	1.5546	1.7375	1.6461	1.7924	1.2071
10	1.5912	1.7741	1.6278	1.7558	1.701	1.4998	1.0974
11	1.6461	1.7193	1.6278	1.829	1.6461	1.4998	1.0974
12	1.7193	1.8473	1.5181	1.829	1.6644	1.4266	.9877
13	1.4998	1.7741	1.4815	1.5364	1.6095	1.3717	.9877
14	1.4998	1.6644	1.4632	1.4998	1.5729	1.39	1.0791
15	1.7193	1.7924	1.7558	1.7558	1.701	1.4083	1.1157
16	1.701	1.7558	1.7375	1.6827	1.7741	1.4266	1.1157
17	1.7193	1.7924	1.7741	1.6278	1.7193	1.3535	.9511
18	1.6095	1.701	1.7558	1.7924	1.829	1.3717	1.0608
19	2.1033	2.1582	2.1582	2.1033	2.1765	1.9022	1.6827
20	2.0302	2.0851	2.1948	2.1582	2.1582	1.9022	1.7375
21	1.957	1.9753	2.0302	1.9936	2.1216	1.8839	1.7741
22	1.829	1.8473	1.8839	1.9022	1.9753	1.7375	1.7375
23	1.6095	1.6461	1.6644	1.6644	1.7375	1.4815	1.5181
24	1.2071	1.3717	1.39	1.4632	1.4632	1.4266	1.3535
Max	2.1033	2.1582	2.1948	2.1582	2.1765	1.9022	1.7741
Min	1.0425	1.134	1.1888	1.2071	1.262	1.2803	.9511
Avg	1.5379	1.6507	1.5976	1.6469	1.6522	1.5150	1.283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 205 / 11 kv Hatture Nager

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2743	.2743	.2926	.2926	.2926	.2926
2	.2561	.2561	.2561	.2926	.2926	.2743	.2743
3	.2427	.2561	.2743	.2926	.2743	.2743	.2743
4	.2561	.2561	.2743	.2926	.2743	.2743	.2743
5	.2926	.2743	.3109	.3109	.3109	.2926	.3109
6	.3475	.3109	.3841	.3361	.3292	.3109	.3841
7	.3658	.3475	.439	.3475	.4024	.3475	.4207
8	.3292	.3109	.4024	.3174	.3109	.3109	.4024
9	.2561	.3109	.3841	.2926	.2743	.2561	.3841
10	.2195	.2743	.3658	.2743	.2378	.2378	.3475
11	.2195	.2378	.3475	.2561	.2012	.2195	.3475
12	.2195	.2378	.3292	.2378	.2378	.2561	.3109
13	.2378	.2561	.3109	.2743	.2378	.2561	.2926
14	.2195	.2743	.2926	.2561	.2561	.2743	.2743
15	.2561	.2378	.3109	.2743	.2378	.2743	.2561
16	.2378	.2561	.2926	.2743	.2378	.2561	.2561
17	.2743	.2743	.2926	.2926	.2743	.2561	.2378
18	.2561	.3292	.2926	.3475	.2926	.2743	.3109
19	.3841	.439	.4207	.439	.4755	.439	.439
20	.3841	.4024	.4024	.4024	.4024	.4572	.4207
21	.3841	.3841	.4024	.3841	.4024	.4024	.4207
22	.3475	.3658	.3475	.3841	.3658	.3658	.3658
23		.3292	.3109	.3109	.3109	.3109	.3109
24	.2561	.2743	.2743	.2926	.2926	.2743	.2743
Max	.3841	.439	.439	.439	.4755	.4572	.439
Min	.2195	.2378	.2561	.2378	.2012	.2195	.2378
Avg	.2825	.2987	.3330	.3115	.3010	.2995	.3285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 403 / 33 KV KIRLOSKAR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.425	8.1219	4.9291	5.2092	8.2899	4.201	6.8896
2	3.3608	8.1219	4.5931	5.6573	7.3377	8.4019	8.2899
3	4.8731	7.5057	4.481	6.3295	6.4975	3.9209	3.8649
4	5.0972	7.3937	4.425	5.3212	8.0659	5.0412	3.7529
5	3.4728	7.9538	4.7611	7.3937	6.6655	8.1219	4.8171
6	6.8336	5.9374	5.7693	6.4975	8.514	6.2734	7.8978
7	6.1614	4.313	4.537	5.8253	6.6655	5.0972	1.4003
8	5.6573	8.738	6.0494	4.0889	7.1696	3.7529	1.4563
9	6.6655	7.1696	4.481	4.481	4.537	7.7298	1.1763
10	8.57	8.9621	6.7776	6.1614	7.8418	8.0659	1.2323
11	3.1927	6.8896	4.0889	6.1054	2.8567	6.5535	.9522
12	5.7693	5.9374	6.6095	6.6095	2.1948	7.2257	.8402
13	4.425	8.682	6.1054	8.2339	7.8418	3.9769	.8962
14	8.3459	9.2421	6.4975	2.9687	8.738	4.369	.8402
15	5.7133	8.738	6.8336	8.682	5.6573	3.9209	.8962
16	6.4975	6.5535	1.9044	7.1696	4.425	5.9374	.8962
17	5.2092	6.2174	2.6326	8.906	8.514	8.0098	.9522
18	6.8336		5.3772	8.1219	6.3855	8.682	.9522
19	2.9127	8.4579	8.85	7.2257	6.2734	7.2257	1.0082
20	6.6655	8.4579	4.201	6.8336	4.537	6.3855	1.3443
21	6.4415	6.2734	6.8336	4.537	8.1219	3.7529	1.4003
22	8.2339	6.3855	6.7215	7.9538	8.682	8.626	2.6886
23	6.6095	6.8896	7.1136	8.1219	5.9934	5.7133	2.5766
24	4.145	5.7693	3.9209	7.7298	7.3937	7.0576	7.1136
Max	8.57	9.2421	8.85	8.906	8.738	8.682	8.2899
Min	2.9127	4.313	1.9044	2.9687	2.1948	3.7529	.8402
Avg	5.6713	7.3352	5.3539	6.5068	6.6333	6.1684	2.6723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 404 / 33 KV HOTGI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1091	2.2634	2.1605	2.1091	2.1091	2.4646	1.4918
2	2.1605	2.3148	2.1605	2.1605	2.2634	2.3148	1.5947
3	2.2634	2.4691	2.2634	2.3148	2.3663	2.5206	1.6975
4	2.3663	2.572	2.4177	2.4177	2.5206	2.6749	1.8004
5	1.9547	2.7263	2.3663	1.9033	2.6235	2.0576	2.0062
6	2.2119	2.572	2.7263	2.2119	2.2119	2.3148	2.1605
7	2.9835	3.5494	3.3951	1.749	2.8807	3.035	1.9547
8	3.0864	3.0864	3.3951	3.1893	2.9835	3.0864	2.0576
9	3.1893	3.3436	3.1893	2.3148	3.3951	3.7037	2.6235
10	3.035	2.2119	2.7778	1.4918	.463	3.1379	1.9044
11	2.5206	2.3148	2.1605	2.1605	.5144	2.4691	.6722
12	2.5206	2.572	2.4691	2.7778	2.2119	2.8292	2.4691
13	2.7778	2.3148	2.8292	2.6235	2.572	2.6235	1.8519
14	2.3148	2.4691	2.6235	2.5206	2.5206	2.7778	1.9033
15	2.6749	2.6235	1.9547	2.3663	2.6235	2.4177	2.2119
16	2.4691	2.7778	2.572	2.8567	2.4691	2.4177	2.3663
17	2.8292	2.572	2.6749	2.1605	2.4177		2.8292
18	2.4177	2.2634	2.7778	2.6235	2.1605	2.2634	2.8807
19	1.1317	.5601	1.1317	1.0802	1.1317	.9774	1.1317
20	1.2346	1.1831	1.1831	1.286	1.1317	.9774	1.0802
21	1.1317	1.1831	1.1831	1.2346	1.1317	1.1317	1.0802
22	1.0802	1.0802	1.0802	1.0802	1.1317	1.0288	1.0802
23	.9259	.8745	.8745	.9259	.9774	.7716	.9259
24	.823	.8745	.5144	.7716	1.8004	.8745	.7202
Max	3.1893	3.5494	3.3951	3.1893	3.3951	3.7037	2.8807
Min	.823	.5601	.5144	.7716	.463	.7716	.6722
Avg	2.1755	2.1988	2.2034	2.0138	2.0255	2.2117	1.7706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 201 / 11 KV FURDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3439	.4525	.3258	.362	.3439	.3982
2	.3077	.3439	.4344	.3258	.3439	.3439	.362
3	.3077	.3258	.4163	.3258	.3439	.3439	.362
4	.3077	.3258	.3982	.3258	.3439	.3439	.362
5	.3258	.3258	.362	.3258	.3439	.3439	.362
6	.362	.3439	.362	.362	.362	.3439	.3982
7	.3982	.362	.3439	.3982	.3801	.3439	.4344
8	.3801	.362	.3439	.4163	.3544	.362	.3982
9	.3439	.362	.3258	.362	.362	.3544	.362
10	.3077	.3077	.3077	.362	.3439	.3189	.3077
11	.3189	.3012	.3258	.3439	.3258	.3189	.3077
12	.3439	.2896	.3258	.3258	.3077	.3012	.3077
13	.362		.3258	.3077	.3258	.3366	.3077
14	.362	.3012	.3258	.3077	.3258	.3544	.3077
15	.3439	.3077	.3258	.3077	.3258	.362	.3077
16	.362	.3077	.3258	.3077		.362	.3077
17		.3077	.3077	.3258			.3439
18		.3077	.3077	.2715			.3258
19		.362	.3801	.4706			.4344
20		.4525	.4163	.4525			.4344
21		.4706	.4163	.4525			.4344
22		.4887	.4163	.4525			.4163
23		.4706	.3982	.4344			.4163
24	.3077	.362	.4706	.3801	.3982	.362	.4163
Max	.3982	.4887	.4706	.4706	.3982	.362	.4344
Min	.3077	.2896	.3077	.2715	.3077	.3012	.3077
Avg	.3382	.3536	.3673	.3612	.3468	.3435	.3673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 202 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3258	.362			.3189	.3366
2	.2715	.2896	.362			.3189	.3366
3	.2715	.2896	.362				.3189
4	.2715	.2896	.362			.3189	.3189
5	.2715	.2896	.362			.3189	.3366
6	.3258	.3077	.362			.3189	.3544
7	.3982	.3439	.362			.3366	.3721
8	.3982	.362	.3439		.3439	.3721	.3366
9	.362	.3439	.2896		.3258	.3012	.3012
10	.2896	.3439	.2715		.2896	.3077	.2835
11	.2896	.2896	.2715		.3077	.3077	.2658
12	.2896	.3077	.2715		.3077	.3077	.2481
13	.2896	.2896	.2896		.3077	.2896	.2658
14	.2896	.2896	.2896		.2896	.2896	.2835
15	.3077	.3077	.3189		.3012	.2896	.3012
16	.3077	.3077	.3366			.3077	.3189
17		.3077	.3366				.3189
18		.3258	.3544				.3258
19		.362	.4075				.4252
20		.4163	.4784				.4607
21		.4163		.443			.443
22		.4163		.443			.443
23		.3982		.3721			.3898
24	.2896	.3439	.3801			.3366	.3544
Max	.3982	.4163	.4784	.443	.3439	.3721	.4607
Min	.2715	.2896	.2715	.3721	.2896	.2896	.2481
Avg	.3056	.3318	.3416	.4194	.3092	.3150	.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 203 / 11 KV VIJAPUR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1991		.2172		.3258	.181
2	.2172	.1991	.2534	.2172		.3258	.181
3	.2172	.1991	.2534	.2172		.3077	.181
4	.2172	.181	.2534	.2172		.2896	.181
5	.2172	.181	.2534	.2172		.2715	.1991
6	.2534	.2172	.2534	.2353		.2534	.2172
7	.2715	.2353	.2534	.2715		.2534	.2534
8	.2715	.2534	.2534	.2715	.2534	.2534	.2534
9	.2715	.2534	.2715		.2534	.2715	.2353
10		.2353	.2715		.2353	.2172	.2353
11	.2715	.2534	.2896		.2353	.2353	.2534
12	.2715	.3077	.2534		.2353	.2353	.2715
13	.2715	.2534	.2534		.2534	.2353	.2715
14	.2715	.2534	.2534		.2534	.2353	.2534
15	.2534	.2534	.2534		.2534	.2353	.2353
16	.2715	.2534	.2353			.2715	.2172
17		.2534	.2353				.2534
18		.2715	.2353				.2715
19		.2896	.2896				.3801
20		.3077	.362				.3801
21		.3077	.3077	.3439			.362
22		.3077	.3077	.3077			.3258
23		.2896	.2715	.2715			.2896
24	.2172	.3439	.2715	.2353		.3258	.181
Max	.2715	.3439	.362	.3439	.2534	.3258	.3801
Min	.2172	.181	.2353	.2172	.2353	.2172	.181
Avg	.2489	.2542	.2668	.2519	.2466	.2672	.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 204 / 11 KV ITI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
9	.0181	
10	.0543	.0181
11		.0181
12		.0181
13		.0181
14		.0181
15		.0181
17		.0181
18		.0181
19		.0181
20		.0181
Max	.0543	.0181
Min	.0181	.0181
Avg	.0362	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 205 / 11 KV RAMLING NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448	.1629	.1629		.1448	.181
2	.1448	.1448	.1629	.1448		.1448	.181
3	.1448	.1448	.1629	.1448		.1448	.1629
4	.1417	.1448	.1629	.1448		.1448	.1629
5	.1448	.1267	.1629	.1448		.1448	.181
6	.181	.1448	.1629	.1448		.1267	.1991
7	.1991	.1448	.1629	.181		.1267	.2172
8	.1991	.1448	.1629	.181	.181	.1991	.1991
9	.181	.1629	.181	.181	.181	.1629	.181
10	.1595	.1629	.1991	.1629	.181	.1629	.181
11	.1448	.1629	.1267	.1629	.1629	.1629	.1448
12	.124	.1629	.1267	.1629	.1629	.1448	.1448
13	.1448	.1267	.1448	.1629	.1448	.1629	.1448
14	.1448	.1267	.1448	.1629	.1448	.1629	.1448
15	.1448	.1448	.1629	.1629	.1448	.1448	.1448
16	.1448	.1448	.1629	.1448		.1448	.1448
17		.1086	.1629	.1991			.1448
18		.1448	.1629				.1448
19		.1448	.1991				.1991
20		.1629	.1991				.1991
21		.181	.1991				.1991
22		.181	.181	.181			.1991
23		.1629	.181	.181			.1991
24	.1629	.1267	.1629	.1629		.1629	.181
Max	.1991	.181	.1991	.1991	.181	.1991	.2172
Min	.124	.1086	.1267	.1448	.1448	.1267	.1448
Avg	.1560	.1478	.1667	.1638	.1629	.1523	.1742