

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0914		.0857	.0914		.0857	.0914
4	.0914	.0934	.0857	.0914	.1109	.0857	.0914
6	.0914		.0686	.0914		.0686	.0914
7				.0914			.0914
8	.0914	.1109	.1029	.1097	.0934	.1029	.1097
10		.112	.1109	.1097	.1109	.1109	
11	.0934						.1097
12		.1494	.1307	.1307	.1494	.1307	.1494
13	.0924						
14		.1478	.1109	.1109	.1307	.1307	.1478
15	.1307		.168				
16		.1663	.1478	.2033	.1478	.1294	.1848
17			.128			.128	
18		.1372	.1463		1.9376	.128	
19	.1294		.128	.1307		.1097	.1307
20		.1029			.1029	.1097	
21	.112		.1097	.1294		.1097	
22		.0857			.0857		.1109
23			.1097			.128	
24	.0914	.1109	.1029	.0914	.0934	.0857	.0914
Max	.1307	.1663	.168	.2033	1.9376	.1307	.1848
Min	.0914	.0857	.0686	.0914	.0857	.0686	.0914
Avg	.1015	.1217	.1157	.1151	.2963	.1096	.1167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.2382						
4	1.0719						
6	1.0164						
8	1.0164						
10			2.3101		2.4459	2.4579	
11							1.9959
12			2.5019		2.6326	2.6513	2.1658
14			2.726		2.6797	2.6612	2.1098
15			2.6797				
16			2.5688		2.6981	2.6797	2.1253
17			2.4764				
18		1.8519	2.0328				
19	1.1888		1.7372				
20		1.4575					
21	1.2752		1.4415				
22		1.3032					
23			1.423				
24	1.3491			1.3121			1.2936
Max	1.3491	1.8519	2.726	1.3121	2.6981	2.6797	2.1658
Min	1.0164	1.3032	1.423	1.3121	2.4459	2.4579	1.2936
Avg	1.1651	1.5375	2.1897	1.3121	2.6141	2.6125	1.9381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.924		.9259	.9795		.8573	.9795
4	.8871	.9335	.8402	.9425	.9795	.7888	.9055
6	.8501		.7716	.9055		.7888	.8501
7				.8871			.8686
8	.8131	.924	.8573	.9979	.9896	.9259	.9055
10		1.8671	1.922	1.9959	1.8665	1.922	
11	1.1203						1.2936
12		2.2032	2.2218	2.1845	2.2032	2.2405	1.643
13	1.1273						
14		2.1807	2.0698	2.1068	2.2405	2.2965	1.5708
15	1.1203		2.2405				
16		2.0883	2.1437	2.1807	2.1253	2.1807	1.5154
17			2.1253			2.1992	
18		1.6804	1.7741		1.6118	1.922	
19	.9979		1.4784	1.4937		1.5524	1.1016
20		1.1831			1.2174	1.3491	
21	1.0269		1.1827	1.2012		1.2382	
22		1.0631			1.0631		1.1273
23			1.1458			1.2012	
24	1.0719	1.1088	1.0117	1.1088	1.1576	.9259	1.1273
Max	1.1273	2.2032	2.2405	2.1845	2.2405	2.2965	1.643
Min	.8131	.924	.7716	.8871	.9795	.7888	.8501
Avg	.9939	1.5232	1.5141	1.4153	1.5455	1.4926	1.1574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3142		.2743	.3326		.3086	.3881
4	.2926	.2987	.2743	.3142	.3142	.2743	.2772
5					.3142		
6	.2743		.2743	.3142		.2915	.2957
7				.3326			.2772
8	.2378	.4066	.3121	.3696	.3547	.3429	.2957
10		.6535	.5544	.6468	.6283	.5914	.4805
11	.3174						
12		.6535	.6535	.7095	.6908	.6722	.5975
13	.3326						
14		.5729	.6838	.6099	.6535	.6653	.5729
15	.3734						
16		.6283	.7023	.7392	.7023	.6838	.5729
17			.6838			.7207	
18		.4458	.5914		.5487	.5914	
19	.3142		.5175	.5041		.499	.4066
20		.3258			.7888	.4805	
21	.3547		.4066	.3881		.4251	
22		.3944			.4287		.3734
23			.462			.4435	
24	.3696	.3696	.3429	.4251	.4108	.3944	.4251
Max	.3734	.6535	.7023	.7392	.7888	.7207	.5975
Min	.2378	.2987	.2743	.3142	.3142	.2743	.2772
Avg	.3181	.4749	.4809	.4738	.5305	.4923	.4136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6838		.6516	.7023		.6516	.7207
4	.6653	.6722	.6173	.6468	.6908	.6001	.6283
6	.6468		.703	.7577		.6001	.6838
7				.6468			.6283
8	.7023	.7023	.6344	.6838	.7577	.6687	.7762
10		.7095	.5914	.5359	.7023	.5359	.7023
11	.5544						
12		.4854	.4854	.5415	.5041	.5228	.6161
13	.5415						
14		.4854	.4854	.5228	.5544	.5415	.5975
15	.5729						
16		.5175	.5914	.5729	.5729	.5729	.5359
17			.499			.6283	
18		.5658	.7023		.5144	.6283	
19	.6348		.6283	.6099		.6283	.5975
20		.6344			.6516	.6838	
21	.7023		.7207	.7468		.7207	
22		.6516			.7202		.7762
23			.7762			.8501	
24	.7392	.7207	.703	.7947	.7947	.7202	.8131
Max	.7392	.7207	.7762	.7947	.7947	.8501	.8131
Min	.5415	.4854	.4854	.5228	.5041	.5228	.5359
Avg	.6443	.6145	.6278	.6468	.6463	.6369	.6730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7577		.7888	.924		.823	.924
4	.7207	.7282	.7716	.9055	.8402	.7888	.8871
6	.7023		.8059	.8501		.8059	.8686
7				.8871			.8131
8	.7577	.924	.9259	.9795	.9979	.9259	.8871
10		1.6632	1.8296	1.7556	1.7737	1.7741	1.3121
11	.8316						
12		1.8671	1.8858	1.8858	1.9605	1.8111	1.4377
13	.8215						
14		1.922	1.7741	1.8665	1.8298	1.9589	1.4415
15	.7947						
16		1.8665	1.9404	1.9774	1.9959	1.9959	1.4045
17			1.9589			2.0144	
18		1.4918	1.6632		1.286	1.8296	
19	.8871		1.46	1.5708		1.5154	1.1088
20		1.166			1.1145	1.2012	
21	.8775		1.0903	1.1576		1.1088	
22		.9259			.9431		.8402
23			.9979			.9979	
24	.7947	.8131	.8745	.9425	.924	.8916	.9425
Max	.8871	1.922	1.9589	1.9774	1.9959	2.0144	1.4415
Min	.7023	.7282	.7716	.8501	.8402	.7888	.8131
Avg	.7946	1.3368	1.3405	1.3085	1.3666	1.3628	1.0723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1097		.1029	.128		.0857	.1097
4	.0914	.112	.1029	.1097	.1109	.0857	.1097
6	.0914		.1029	.1097		.0857	.1097
7				.1097			.0914
8	.0914	.1109	.12	.1097	.112	.1029	.1097
10		.0924	.0924	.1097	.1109	.0924	.0914
11	.112						
12		.1307	.0934	.112	.0934	.1307	.112
13	.1109						
14		.1109	.1109	.0924	.0934	.1109	.1294
15	.112						
16		.0924	.1294	.1109	.1109	.1109	.1109
17			.1097			.1097	
18		.0686	.1097		.1029	.1097	
19	.0924		.1097	.0934		.1097	.0934
20		.1029			.1029	.1097	
21	.0934		.128	.1478		.1097	
22		.1029			.12		.0924
23			.1097			.128	
24	.128	.1294	.1372	.128	.1307		.128
Max	.128	.1307	.1372	.1478	.1307	.1307	.1294
Min	.0914	.0686	.0924	.0924	.0934	.0857	.0914
Avg	.1033	.1053	.1113	.1134	.1088	.1058	.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4805		.3944	.5359		.4458	.499
4	.462	.4805	.4115	.499	.462	.4287	.499
6	.462		.463	.5175		.4458	.499
7				.5544			.499
8	.499	.6722	.6173	.6468	.6535	.583	.5359
10		1.9044	1.8296	1.885	1.7924	1.848	.8871
11	.5175						
12		2.1845	1.9978	1.9791	2.0725	2.0911	1.0829
13	.5788						
14		2.0911	2.0165	1.9791	2.0328	2.0911	.9709
15	.5729						
16		1.9774	1.9589	2.0328	1.9774	2.0513	.9055
17			1.8665			1.9589	
18		1.0631	1.2012		1.1145	1.2382	
19	.5041		.9055	.9709		.961	.6283
20		.6516			.703	.7207	
21			.6283	.5914		.6099	
22		.463			.5144		
23			.5175			.5544	
24	.4805	.5228	.4458	.5175	.5415	.5144	.499
Max	.5788	2.1845	2.0165	2.0328	2.0725	2.0911	1.0829
Min	.462	.463	.3944	.499	.462	.4287	.499
Avg	.5064	1.2011	1.0896	1.0591	1.1864	1.1028	.6823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1097		.0857	.1097		.1029	.1097
4	.0914	.112	.0857	.1097	.112	.0857	.128
6	.0914		.12	.1097		.12	.1097
7				.128			.1097
8	.1097	.1294	.12	.1097	.1109	.12	.1097
10		.3142	.3326	.3292	.3326	.3142	.2012
11	.1307						
12		.4108	.4294	.3921	.4481	.4294	.3174
13	.1294						
14		.3881	.3511	.3326	.4294	.3696	.2587
15	.112						
16		.4251	.4251	.4251	.4435	.4251	.2957
17			.4066			.3881	
18		.3258	.3326		.2915	.3881	
19	.1294		.2402	.2218		.2195	.1867
20		.1372				.1463	
21	.112		.1097	.1494		.1463	
22		.1029					.1294
23			.128			.1829	
24	.128	.1109	.1029	.128	.1294	.12	.128
Max	.1307	.4251	.4294	.4251	.4481	.4294	.3174
Min	.0914	.1029	.0857	.1097	.1109	.0857	.1097
Avg	.1144	.2456	.2335	.2121	.2872	.2372	.1737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 33 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.9239		1.6975	1.8673		1.6975	1.8107
4	1.8673	1.6461	1.6461	1.8107	1.7741	1.6461	1.8107
6	1.8673		1.6461	1.8673		1.6461	1.9239
7				1.2226			1.2757
8	1.2757	1.3169	1.2346	1.2757	1.3306	1.1831	1.2757
11	.3292						
13	.3292						
15	.3326						
17			.0972			.0972	
18		.2572	.0972		.0514	.0972	
19	.3292		.2458	.1109		.0972	.1097
20		.3086				.2458	
21	1.3169		1.3289	1.3717		1.4352	
22		1.6461					1.7558
23			1.6975			1.8673	
24	1.8673	1.7558	1.5947	1.8673	1.701	1.6975	1.8673
Max	1.9239	1.7558	1.6975	1.8673	1.7741	1.8673	1.9239
Min	.3292	.2572	.0972	.1109	.0514	.0972	.1097
Avg	1.1439	1.1551	1.1286	1.4242	1.2143	1.0646	1.4787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV SECTOR 8-A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203		1.1431	1.1576		1.1763	1.2384
2			1.0479				1.1431
3	.9335	.9709	.9526	1.0082	1.0829		1.0479
4			.9145			.9709	.9526
5	.8402		.8764	.9335		.9335	.8573
6	.8402	.8402	.8764	.9335	.8589		.8764
7	.7095	.8402	.8764	.8488	.8962		.8383
8				.8402			.8764
9	.7842	1.0456	.9717	.8962	.8589	.9717	.8962
10	.8402	1.0098	.9522	.9709		.9717	
11	.8589	.9717	.9335	.9335	.8962	1.0288	1.0082
12		1.0098	.8775	.8962	.8962	.8764	.9335
13		.8764	.8589	.8962	.8775	.9145	
14	.7842	.8573	.8402	.8962		.9526	.8962
15	.8589	.9145	.9149	.9335	.9522	.9526	
16	.8589	.8954	.8775	.8962	.8962	.9717	
17	.8029	.8002	.8589	.8775	.8215	.8002	
18	.8402	.7049	.7468	.8402	.7468	.8002	
19	.9335	.8764	.9335	1.0082	.9896	1.105	
20	.9709	1.0288	1.0642	1.1203	1.0456	1.105	
21	1.0269	1.1431	1.1389		1.2323	1.2003	
22		1.1622	1.2136			1.2384	
23		1.2955	1.3443		1.3443	1.3527	
24	1.1576	1.2323	1.2574	1.251	1.2696	1.307	1.3336
Max	1.1576	1.2955	1.3443	1.251	1.3443	1.3527	1.3336
Min	.7095	.7049	.7468	.8402	.7468	.8002	.8383
Avg	.8918	.9724	.9770	.9546	.9791	1.0331	.9922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443		1.4289	1.4563		1.419	1.5242
2			1.3717				1.4289
3	1.1203	1.2323	1.4289	1.1949	1.3443		1.2384
4			1.1431			1.0829	1.1431
5	1.0082		1.1431	1.1203		1.0082	1.1431
6	1.0269	1.0829	1.1431	1.1576	1.1203		1.1431
7	.8962	1.1203	1.086	1.2323	1.0829		.9907
8				1.1949			1.105
9	1.1576	1.1203	1.2765	1.1576	1.1949	1.2003	1.2323
10	1.0829	1.105	1.1576	1.1949		1.2003	
11	1.1203	1.086	1.0642	1.1203	1.0829	1.2384	1.0456
12		1.105	.9709	1.0642	1.0269	1.0098	1.1203
13		.9717	.9896	1.0456	1.0082	1.0479	
14	.9335	.9907	.9896	1.0082		1.1241	1.1576
15	1.0642	.9526	.9896	1.0269	1.0269	1.1241	
16	1.0082	1.0669	.9335	.9709	1.0829	.9526	
17	.9709	.9717	.9709	1.0082	1.0829	.9526	
18	.9709	.9907	1.0082	.9709	1.0829	1.0288	
19	1.1949	1.2384	1.2323	1.2696	1.2696	1.105	
20	1.2323	1.3527	1.307	1.307	1.3443	1.2384	
21	1.251	1.3717	1.419		1.4563	1.3146	
22		1.4289	1.4563			1.5242	
23		1.5242	1.5497		1.6244	1.6575	
24	1.4563	1.4563	1.4861	1.5497	1.531	1.5684	1.6575
Max	1.4563	1.5242	1.5497	1.5497	1.6244	1.6575	1.6575
Min	.8962	.9526	.9335	.9709	1.0082	.9526	.9907
Avg	1.1082	1.1668	1.1976	1.1605	1.2101	1.1998	1.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112		.1143	.1307		.1307	.1334
2			.1143				.1143
3	.0934	.112	.1143	.112	.1307		.0953
4			.1143			.112	.0953
5	.0934		.1143	.112		.112	.0953
6	.0934	.112	.1143	.112	.1307		.0953
7	.0934	.1307	.1334	.112	.1307		.0953
8				.112			.1143
9	.0934	.112	.1334	.112	.1307	.1334	.112
10	.0934	.0953	.0934	.112			
11	.0934	.0953	.0934	1.0082	.0934	.1143	.112
12		.0953	.0934	.0934	.0934	.0953	.112
13		.1143	.0934	.0747	.0934	.1143	
14	.0747	.0953	.0934	.0934		.0953	.112
15	.1307	.1143	.0934	.0934	.0934	.0953	
16	.0934	.0953	.0934	.0934	.0934	.0953	
17	.0934	.0953	.0934	.0934	.0934	.0953	
18	.112	.7049	.0934	.0747	.112	.0953	
19	.0934	.0953	.112	.0934	.112	.0953	
20	.0934	.1524	.112	.0934	.112	.1334	
21	.112	.1143	.112		.1494	.1143	
22		.1334	.1307			.1715	
23		.1334	.168		.168	.1715	
24	.1307	.1494	.1334	.1494	.1494	.1494	.1715
Max	.1307	.7049	.168	1.0082	.168	.1715	.1715
Min	.0747	.0953	.0934	.0747	.0934	.0953	.0953
Avg	.1	.1447	.1114	.1513	.1179	.1180	.1122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108		.4763	.4481		.4481	.5335
2			.4191				.4954
3	.3361	.3734	.381	.3361	.3734		.4191
4			.3429			.3361	.381
5	.2987		.3429	.3361		.3361	.381
6	.3361	.3361	.3429	.3361	.3361		.3429
7	.2801	.3361	.3239	.3174	.3361		.3429
8				.3547			.362
9	.3734	.4108	.4763	.4668	.4108	.4763	.4108
10	.4108	.5335	.5228	.4854		.5335	
11	.4108	.6097	.5975	.5975	.6161	.5525	.5601
12		.6097	.6348	.6348	.6161	.6478	.6348
13		.6287	.6161	.6535	.6161	.6478	
14	.3734	.5716	.5788	.5601		.6668	.6535
15	.4481	.5906	.6161	.5975	.5975	.6097	
16	.4108	.5525	.6161	.5975	.6161	.6097	
17	.4108	.5716	.5975	.5601	.6161	.5906	
18	.4108	.5906	.6348	.5601	.5601	.5525	
19	.5228	.6478	.6535	.6535	.6722	.5906	
20	.5601	.6097	.6535	.6348	.6161	.6097	
21	.5601	.6097	.5788		.6348	.5525	
22		.5716	.5228				
23		.5716	.5601		.5228	.5906	
24	.4668	.5041	.5144	.5041	.5601	.5041	.5906
Max	.5601	.6478	.6535	.6535	.6722	.6668	.6535
Min	.2801	.3361	.3239	.3174	.3361	.3361	.3429
Avg	.4130	.5384	.5219	.5071	.5438	.5475	.4698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589		.9145	.9335		.9335	1.0479
2			.8383				.9526
3	.6722	.7842	.7621	.7468	.7842		.8573
4			.7621			.7282	.7621
5	.6348		.7621	.6535		.7095	.7621
6	.6535	.7468	.7621	.6722	.7095		.7621
7	.6161	.7095	.7621	.6722	.7095		.6859
8				.6722			.7049
9	.7468	.7468	.7621	.7468	.8402	.8573	.8215
10	.7468	.7049	.7095	.6722		.7621	
11	.6535	.5906	.6161	.5975	.6722	.6859	.6908
12		.5906	.5975	.5601	.6161	.6478	.6535
13		.6097	.6348	.6722	.6535	.6668	
14	.6348	.6097	.6535	.6722		.724	.7468
15	.6722	.6478	.6161	.6722	.6535	.6668	
16	.6535	.9907	.6161	.6722	.6348		
17	.5975	.6097	.5975	.5975	.5975	.6478	
18	.5975	.5906	.6348	.5975	.5975	.6097	
19	.7095	.7621	.6722	.7842	.7468	.7811	
20	.8215	.8573	.8402	.8402	.8215	.8954	
21	.8402	.9145	.8775		.8775	.9145	
22		1.105	.9335			.9907	
23		1.0098	1.0269		1.0456	1.086	
24	.8962	.9709	.9907	1.0269	.9335	.9709	1.086
Max	.8962	1.105	1.0269	1.0269	1.0456	1.086	1.086
Min	.5975	.5906	.5975	.5601	.5975	.6097	.6535
Avg	.7062	.7659	.7540	.7085	.7433	.7932	.8103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV GOVT. OFFICES SECTOR SHEDDABLE URBAN
11 Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7621	.7095		.6161	.7621
2			.5335				.724
3		.5601	.5335	.6348	.5975		.6859
4			.5335			.6161	.6859
5			.5335	.6348		.5975	.6859
6	.5228	.6722	.6097	.6535	.6348		.6859
7	.6161	.6722	.6668	.6722	.6722		.6859
8				.7468			.6859
9	.5975	1.1576	1.1241	1.307	1.1203	1.2003	.7468
10	.7468	2.2481	2.0725	2.2405		2.2672	
11	.7468	2.6101	2.3525	2.6139	2.4646	2.6673	1.2323
12		2.4387	2.5019	2.5393	2.4272	2.4006	1.251
13		2.3624	2.3525	2.4646	2.5206	2.5339	
14	.8215	2.3624	2.2405	2.4272		2.553	1.307
15	.7842	2.4006	2.4272	2.4646	2.4832	2.553	
16	.7842	2.4006	2.3899	2.4646	2.5019	2.6101	
17	.7842	2.3434	2.3339	2.4272	2.4272		
18	.7842	1.9814	1.8484	1.9791	1.9231	2.0576	
19	.7842	1.6385	1.4377	1.5684	1.4563	1.6194	
20	.8215	.9335	.8962	.9709	.9335	.724	
21	.7842	.8192	.8775		.8962	1.0098	
22		.8383	.8215			.9335	
23		.7811	.7282		.7468	.8192	
24	.6535	.5975	.6097	.7095	.6722	.7095	.8192
Max	.8215	2.6101	2.5019	2.6139	2.5206	2.6673	1.307
Min	.5228	.5601	.5335	.6348	.5975	.5975	.6859
Avg	.7308	1.5694	1.3559	1.5910	1.5299	1.5827	.8429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5335	.5975		.5975	.6097
2			.5335				.5716
3		.5228	.5335	.5975	.5601		.5335
4			.5335			.6161	.5335
5			.5335	.5975		.5975	.5335
6	.5601	.5228	.5335	.5975	.5601		.5335
7	.5228	.5228	.5906	.5975	.5601		.5144
8				.5975			.5525
9	.5601	.6535	.6478	.6722	.6348	.6668	.4854
10	.5601	.9717	.9522	.9335		1.0098	
11	.5601	1.0288	.9808	1.0082	.9896	1.0288	.5601
12		1.0669	1.0642	.9335	.9335	1.0479	.6348
13		.9907	1.0082	.9709	.9335	.9526	
14	.5228	1.0098	.9522	.9335		.9717	.6348
15	.5601	1.0288	.9522	.9335	.9709	.9526	
16	.5228		.9335	.9335	.8962	.9526	
17	.5228	.9526	.8962	.8402	.9896	.8764	
18	.5228	.7049	.6908	.6348	.6348	.6668	
19	.5228	.6478	.6161	.5975		.6478	
20	.5601	.6668	.6161	.5975	.6535	.5906	
21	.5601	.6287	.6348		.6535	.6478	
22		.5716	.5975			.6097	
23		.6668	.6161		.6348	.6668	
24	.5975	.5601	.5716	.6161	.5975	.6161	.6478
Max	.5975	1.0669	1.0642	1.0082	.9896	1.0479	.6478
Min	.5228	.5228	.5335	.5975	.5601	.5906	.4854
Avg	.5468	.7621	.7183	.7468	.7468	.7745	.5650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	1.5684	1.531	1.5524	1.531	1.531	1.5844
2	1.2696	1.5655	1.4937	1.4784	1.419	1.4377	1.5278
3	1.2136	1.5089	1.4937	1.4045	1.4003	1.3817	1.475
4	1.2136	1.4335	1.4563	1.3817	1.3443	1.3443	1.419
5	1.1949	1.4335	1.4003	1.3817	1.3443	1.3256	1.386
6	1.1949	1.4003	1.363	1.3817	1.363	1.363	1.2936
7	1.1949	1.307	1.3817	1.307	1.3817	1.3817	1.2567
8	1.2136	1.3256	1.363	1.363	1.3256	1.3443	1.2197
9	1.2696	1.251	1.2323	1.2136	1.251	1.2323	1.1706
10	1.2696	1.1203	1.1016		1.1389	.9979	1.134
11	1.1576	.9896	1.0269	1.0829	1.0829	.961	1.0498
12	1.1016	.961	1.0082	1.0456	1.0456	.9877	.9955
13	1.1389	.9511	1.0269	1.0829	1.0642	1.0242	1.0498
14	1.1016	.9511	1.0642	1.0642	1.1016	1.0242	1.0745
15	1.1389	1.0242	1.0829	1.1016	1.0642	.9877	1.1104
16	1.1389	.9511	1.0269	1.0829	1.0534	.9877	1.1283
17	1.1827	1.0059	1.0829	1.1763	1.1088	1.0059	1.1104
18	1.2012	1.0791	1.1203	1.1389	1.0903	1.0164	1.0745
19	1.2197	1.2382	1.2883	1.2323	1.2323	1.1458	1.1283
20	1.3817	1.3817	1.423	1.4377	1.363	1.2382	1.2127
21	1.3817	1.4563	1.46	1.4937	1.4937	1.3817	1.3394
22	1.4563	1.4563	1.5524	1.5684	1.5684	1.4937	1.4632
23	1.6244	1.5497	1.6632	1.6804	1.6975	1.587	1.39
24	1.531	1.6244	1.6244	1.5893	1.6244	1.6409	1.6409
Max	1.6244	1.6244	1.6632	1.6804	1.6975	1.6409	1.6409
Min	1.1016	.9511	1.0082	1.0456	1.0456	.961	.9955
Avg	1.2580	1.2722	1.3028	1.3148	1.2954	1.2426	1.2598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9709	.9709		.9522
2			.9335	.9335		.924
3			.8962	.9054		.8871
4			.8676	.8676		.8413
5			.8676	.8676		.8048
6			.9054	.8865		.7762
7	.7356		.8676	.7922		.7282
8			.811	.7733		.7095
9			.7356		.7282	.6653
10		.6161			.6099	.7023
11		.5975	.6224		.5853	.6219
12		.5788	.6224		.5853	.6036
13		.5601	.5658		.6219	.6219
14		.5975	.6224		.6584	.6516
15		.5975	.5847		.6219	.6335
16		.6161	.6224		.6036	.6335
17		.6161	.6224		.5853	.6283
18		.5788	.5788		.5914	.6099
19		.6908	.6535		.6653	.695
20		.7842	.7655		.7316	.6859
21		.8589	.8589		.823	.8048
22		.9709	.9335		.9055	.8686
23		1.0456	1.0456		1.0269	.9055
24			1.0269	1.0269		.9896
Max	.7356	1.0456	1.0456	1.0269	1.0269	.9896
Min	.7356	.5601	.5658	.7733	.5853	.6036
Avg	.7356	.6935	.7818	.8915	.6896	.7477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER

R.M.U S Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.0762	.0572	.0572	.0572
2	.0572	.0572	.0572	.0762	.0572	.0572	.0572
3	.0572	.0572	.0381	.0572	.0572	.0572	.0572
4	.0572	.0381	.0572	.0572	.0572	.0381	.0572
5	.0572	.0572	.0381	.0572	.0572	.0381	.0572
6	.0572	.0381	.0572	.0381	.0572	.0572	.0572
7	.0762	.0572	.0572	.0572	.0572	.0572	.0572
8	.0381	.0572	.0572	.0762	.0572	.0572	.0572
9	.0572	.0572	.0762	.0572	.0762	.0762	.0381
10	.0381	.0572	.0381		.0381	.0762	.0572
11	.0572	.0572	.0572	.0572	.0572	.0762	.0572
12	.0762	.0762	.0762	.0572	.0762	.0762	.0572
13	.0762	.0572	.0762	.0572	.0572	.0762	.0572
14	.0762		.0572	.0762	.0572	.0762	.0572
15	.0572	.0572	.0762	.0572	.0572	.0762	.0572
16	.0572	.0572	.0572	.0762	.0572	.0762	.0762
17	.0572	.0572	.0762	.0572	.0572	.0762	.0762
18	.0572	.0762	.0572	.0762	.0762	.0762	.0572
19	.0572	.0762	.0762	.0762	.0572	.0762	.0762
20		.0572	.0762	.0762	.0762	.0572	.0762
21		.0762	.0762	.0572	.0762	.0572	.0762
22	.0762	.0762	.0572	.0762		.0572	.0762
23	.0762	.0762	.0572	.0762	.0572	.0572	.0762
24	.0762	.0762	.0572	.0762	.0572	.0572	.0572
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0624	.0613	.0611	.0655	.0605	.0643	.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.39	1.2567		1.3253
2			1.3306	1.1458		1.2403
3			1.1088	1.0608		1.2048
4			1.1088	1.0242		1.1568
5			1.0719	1.0059		1.0341
6			1.0534	1.0059		.9391
7	.815		.9795	.9877		1.0498
8			1.0164	.9694		1.086
9			1.3491		1.5203	1.1641
10		1.7926			1.7909	1.3969
11		1.922	2.0513		2.0058	1.5415
12		1.9035	1.9774		2.0416	1.701
13		1.9589	1.9035		2.1132	1.7364
14		1.9589	2.0328		2.1132	1.8229
15		2.1253	2.1068		2.0774	1.8755
16		2.0883	2.0883		2.0774	1.858
17		1.9774	2.0144		1.6834	1.7878
18		1.7926	1.7926		1.8461	1.701
19		1.6263	1.7926		1.7741	1.6655
20		1.5524	1.5708		1.6478	1.6126
21		1.5893	1.7187		1.6126	1.6476
22		1.5524	1.5524		1.595	1.6301
23		1.4784	1.6263		1.5415	1.5402
24			1.4415	1.3121		1.4148
Max	.815	2.1253	2.1068	1.3121	2.1132	1.8755
Min	.815	1.4784	.9795	.9694	1.5203	.9391
Avg	.815	1.8085	1.5686	1.0854	1.8294	1.4638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5729	.5731	.5914	.6283	.5729	.5914
2	.5487	.4805	.5014	.5544	.5544	.5544	.5121
3	.5121	.4251	.4252	.4706	.5175	.5175	.439
4	.4435	.4251	.4252	.4344	.4527	.4024	.439
5	.4435	.3921	.4075	.3982	.4527	.3881	.4066
6	.4066	.3921	.4119	.4024	.4338	.4294	.3696
7	.4108	.3734	.3761	.439	.415	.4294	.3921
8	.4481	.4294	.4525	.3961	.415	.4294	.4066
9	.4668	.4481	.5068	.5093	.4668	.5975	.4024
10	.4668	.6908	.7059		.8215	.7023	.567
11	.6348	.9522	.7682	.9896	.9709	.924	.7964
12	.6653	.9335	.9425	1.0456	1.0456	.9511	.9412
13	.7023	1.0082	.9795	1.0082	1.0456	.9877	.9671
14	.7207	1.0269	.8871	1.0456	.9896	.9511	1.0029
15	.7577	.9522	1.0534	1.1389		.9145	.9492
16	.7947	.9149	.9979	1.0456	1.0269	.8688	.8859
17	.695	.9335	.9055	.9896	.9522	.8688	.7712
18	.6767		.8871	.9335	.9335	.8775	.8063
19	.8048	.7947	.9055	.9149	.8686	.8954	.8063
20	.7865	.8316	.8871	.9055	.8316	.8596	.8688
21	.8596	.7762	.7947	.8316	.8501	.7964	.8326
22	.6767	.6767	.7762	.7207	.7023	.7059	.7682
23	.6767	.6401	.7023	.7207	.7207	.7133	.695
24	.6584	.6219	.6219	.6468	.6653	.6653	.6468
Max	.8596	1.0269	1.0534	1.1389	1.0456	.9877	1.0029
Min	.4066	.3734	.3761	.3961	.415	.3881	.3696
Avg	.6184	.6823	.7039	.7449	.7287	.7084	.6777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 207 / 11KV OLD R.M.U SECTOR-15 SHEDDABLE URBAN
S/STN Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3841	.3841	.4435	.4066	.3898	.4344
2	.3086	.3292	.3292	.4066	.3658	.3721	.394
3	.3086	.3258	.3142	.3696	.3292	.3681	.3544
4	.2683	.3077	.3142	.3326	.3224	.3121	.3544
5	.2683	.3258	.2957	.3326	.3403	.3121	.3155
6	.2683	.3258	.3547	.3326	.3403	.3506	.3189
7	.2683	.3439	.3584	.3881	.394	.3761	.3224
8	.2347	.4066	.3174	.3511	.3582	.4119	.3403
9	.2572	.4805	.3734	.499	.4706	.4656	.3403
10	.2835	.499	.4854		.4525	.4961	.3403
11	.3721	.4854	.5041	.499	.5175	.4961	.3544
12	.394	.5041	.5041	.5175	.5041	.4908	.3366
13	.3582	.4854	.4854	.499	.5041	.5258	.3189
14	.3761	.5041	.4294	.5544	.5415	.5434	.3155
15	.4298	.5228	.4854	.5359	.5415	.5028	.298
16	.3658	.5041	.5041	.5175	.5041	.4681	.2915
17	.4938	.5041	.4854	.5544	.5415	.4681	.2774
18	.3881	.4854	.4854	.4805	.499	.4681	.2804
19	.3696	.4108	.5175	.4805	.4066	.5083	.2804
20	.3511	.4066	.3696	.4251	.4207	.4733	
21	.4251	.4435	.462	.462	.4207	.443	.3189
22	.462	.4572	.462	.4435	.4572	.4298	.3544
23	.462	.4755	.499	.462	.4755	.4477	.3582
24	.4207	.462	.439	.4805	.4435	.4755	.4525
Max	.4938	.5228	.5175	.5544	.5415	.5434	.4525
Min	.2347	.3077	.2957	.3326	.3224	.3121	.2774
Avg	.3540	.4325	.4233	.4508	.4399	.4415	.3370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT SHEDDABLE URBAN
SECT Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3253	1.3611		1.3717
2			1.262	1.2346		1.3226
3			1.1568	1.166		1.1728
4			1.0288	1.1145		1.073
5			.9945	1.0288		.9614
6			.9602	.9774		.8951
7	.8539		.9774	.9945		.9724
8			.9991	1.046		.9389
9			1.2971		1.3077	.9448
10		1.9909			1.6385	1.278
11		1.7918	2.3411		1.8244	1.278
12		2.1216	2.1399			1.3927
13		2.0851	2.0668		1.8564	1.587
14		1.9936	2.1216		1.8244	1.6644
15		2.2862	2.2497		1.7711	1.4403
16		2.1033	2.1948		1.7869	1.1305
17		2.0302	2.0302		1.7284	1.2631
18		1.6644	1.7924		1.4251	1.1305
19		1.6118	1.6095		1.4899	1.1797
20		1.4327	1.4998		1.3272	1.1603
21		1.379	1.4083		1.2929	1.2266
22		1.4327	1.4449		1.2407	1.1904
23		1.4864	1.5546		1.3395	1.1568
24			1.3969	1.4506		1.3889
Max	.8539	2.2862	2.3411	1.4506	1.8564	1.6644
Min	.8539	1.379	.9602	.9774	1.2407	.8951
Avg	.8539	1.8150	1.5588	1.1526	1.5609	1.2133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2315	.2315	.2315	.2229	.2229	.2229	.2229
2	.2315	.2315	.2315	.2229	.1337	.2229	.2229
3	.2315	.2315	.2315	.2229	.2229	.2229	.2229
4	.2315	.2315	.2315	.2229	.2229	.2229	.2229
5	.2315	.2315	.2315	.2229	.2229	.2229	.2229
6	.2315	.2315	.2315	.2229	.2229	.2229	.2229
7	.1389	.2315	.2315	.2229	.2229	.2229	.2229
8	.2315	.2315	.5155	.2229	.2229	.2229	.2229
9	.2315	.5155	1.1568	.7042	.823	.2229	.2229
10	.2315	.7202	1.3032	1.3032	1.3717	1.3717	.2229
11	.2315	1.3432	1.3717	1.3717	1.4415	1.4415	.9465
12	.2315	1.3432	1.3717	1.4415	1.4415	1.4415	.6036
13	.2315	1.5364	1.3717	1.3717	1.3717	1.3717	.4915
14	.2315	1.5364	1.3717	1.3717	1.3717	1.3717	.4915
15	.2315	1.4118	1.3032	1.4415	1.3717	1.3717	.4915
16	.2315	1.4118	1.3717	1.4415	1.3717	1.4415	.6613
17	.2315	1.4118	1.3717	1.3717	1.2226	1.3717	.4915
18	.2315	1.4118	.9465	.9465	.9259	.9259	.4915
19	.2315	.7202	.7202	.823	.8048	.8048	.2229
20	.2315	.503	.4973	.503	.4687	.4687	.2229
21	.2315		.2229	.2229	.2229	.2229	.2229
22	.0926		.2229	.2229	.2229	.2229	.2229
23	.2315		.2229	.2229	.1337	.2229	.2229
24	.2315	.2315	.2315	.2229	.2229	.2229	.2229
Max	.2315	1.5364	1.3717	1.4415	1.4415	1.4415	.9465
Min	.0926	.2315	.2229	.2229	.1337	.2229	.2229
Avg	.2219	.7595	.7164	.6986	.6868	.6783	.3431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 403 / 33KV SBI - 1 & SUB ST/N NON SHEDDABLE EXPRESS HV FEEDERS
 XMER Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0869	.0869	.0869	.0869	.0869	.0869	.0869
2	.0869	.0869	.0869	.0869	.0869	.0869	.0869
3	.0869	.0869	.0869	.0869	.0869	.0869	.0869
4	.0869	.0869	.0869	.0869	.0869	.0869	.0869
5	.0869	.0869	.0869	.0869	.0869	.0869	.0869
6	.0869	.0869	.0869	.0869	.0869	.0869	.0869
7	.0869	.0869	.0869	.0869	.0869	.0869	.0869
8	.2172	.0869	.0869	.0869	.0869	.0869	.0869
9	.0869	.0869	.0869	.0869	.0869	.0869	.0869
10	.0869	.0869	.0869	.0869	.0869	.0869	.0869
11	.0869	.0869	.0869	.0869	.0869	.0869	.0869
12	.0869	.0869	.0869	.0869	.0869	.0869	.0869
13	.0869	.0869	.0869	.0869	.0869	.0869	.0869
14	.0869	.0869	.0869	.0869	.0869	.0869	.0869
15	.0869	.0869	.0869	.0869	.0869	.0869	.0869
16	.0869	.0869	.0869	.0869		.0869	.0869
17	.0869	.0869	.0869	.0869	.0869	.0869	.0869
18	.0869	.0869	.0869	.0869	.0869	.0869	.0869
19	.0869	.0869	.0869	.0869	.0869	.0869	.0869
20	.0869	.0869	.0869	.0869	.0869	.0869	.0869
21	.0869		.0869	.0869	.0869	.0869	.0869
22	.0869		.0869	.0869	.0869	.0869	.0869
23	.0869		.0869	.0869	.0869	.0869	.0869
24	.0869	.0869	.0869	.0869	.1337	.0869	.0869
Max	.2172	.0869	.0869	.0869	.1337	.0869	.0869
Min	.0869	.0869	.0869	.0869	.0869	.0869	.0869
Avg	.0923	.0869	.0869	.0869	.0889	.0869	.0869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 404 / 33KV NMMC - 2 (1)

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1337	.1337	.1337	.1337	.1337	.1337	.1337
2	.1337	.1337	.1337	.1337	.1337	.1337	.1337
3	.1337	.1337	.1337	.1337	.1337	.1337	.1337
4	.1337	.1337	.1337	.1337	.1337	.1337	.1337
5	.1337	.1337	.1337	.1337	.1337	.1337	.1337
6	.1337	.1337	.1337	.1337	.1337	.1337	.1337
7	.1337	.1337	.1337	.1337	.1337	.1337	.1337
8	.1337	.1337	.1337	.1337	.1337	.1337	.1337
9	.1337	.1337	.3018	.4024	.5087	.1337	.1337
10	.1337	.4024	.5258	.5258	.5784	.5784	.1337
11	.1337	.463	.591	.591	.6447	.6447	.4024
12	.1337	.463	.591	.6584	.6447	.6447	.2949
13	.1337	.5258	.591	.591	.5784	.5784	.192
14	.1337	.5258	.591	.591	.5784	.5784	.192
15	.1337	.5258	.5258	.6584	.5784	.5784	.192
16	.1337	.5258	.591	.6584	.5784	.6447	.3481
17	.1337	.5258	.591	.591	.463	.5784	.192
18	.1337	.5258	.4024	.4024	.4024	.4024	.192
19	.1337	.3086	.2881	.2881	.2881	.2881	.1337
20	.1337	.2012	.1875	.1829	.1829	.1337	.1337
21	.1337		.1337	.1337	.1337	.1337	.1337
22			.1337	.1337	.1337	.1337	.1337
23	.1337		.1337	.1337	.1337	.1337	.1337
24	.1337	.1303	.1337	.1337	.1337	.1337	.1337
Max	.1337	.5258	.591	.6584	.6447	.6447	.4024
Min	.1337	.1303	.1337	.1337	.1337	.1337	.1337
Avg	.1337	.3013	.3076	.3227	.3180	.3079	.1727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 201 / 11 KV SECTOR-19 ULWE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5056	3.9628	3.5056	4.02	4.0009		
2	3.3341	3.6961	3.5818	3.9628	3.9438		
3	3.1817	3.4675	3.7342	3.7723	3.8104		
4	3.0864	3.3913	3.7723	3.5818	3.7913		
5	3.2007	3.5056	3.8295	3.7723	3.6961		
6	3.2769	3.6199	3.8485	3.7342	3.7151		
7	3.3913	3.4675	3.7913	3.5818	3.677		
8	3.1245	3.2007	3.5437	3.315	2.8959		3.296
9	3.0483		3.0674	2.9721	2.7816		2.9531
10	2.9531	2.7816	2.9531	2.8387	2.8769		2.9531
11	3.0102	2.8578	3.0293		2.7816		2.9531
12	3.0864	2.9721	2.934		2.7244		2.8959
13	3.0483	2.553	2.7244		2.5149		2.8006
14	2.8197	2.8197	3.1245		2.6673		3.0864
15	3.0674	2.8959			2.8578		3.3341
16	3.0674	2.8769			2.8769		3.3341
17	2.9912	2.9721					3.0102
18	3.0483	3.0864					3.0102
19	3.658	3.2007					3.5627
20	3.8104	3.3532					3.9057
21	3.8104	3.7342					3.7532
22	3.9057	3.7723					4.0962
23	4.1724	3.8295					
24	3.8676	4.0581	3.9247	4.1343	4.0581	4.0009	
Max	4.1724	4.0581	3.9247	4.1343	4.0581	4.0009	4.0962
Min	2.8197	2.553	2.7244	2.8387	2.5149	4.0009	2.8006
Avg	3.3111	3.3076	3.4243	3.6078	3.2747	4.0009	3.2630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 202 / 11 KV SECTOR-21 ULWE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4001	.3429	.4191	.4954		
2	.3239	.381	.362	.4001	.4763		
3	.3429	.3429	.362	.362	.4191		
4	.362	.3429	.381	.3429	.4191		
5	.4001	.381	.4191	.381	.4191		
6	.381	.4191	.381	.381	.4001		
7	.4191	.4191		.4191	.362		
8	.3239	.362			.381		.4001
9	.3239	.3429		.3239	.3239		.3239
10	.3239	.3239		.2858	.3429		.3239
11	.3429	.3048			.3048		.3239
12	.4001	.2286			.2858		.3239
13	.4001	.2477			.2858		.2858
14	.3429	.2667			.2858		.3048
15	.362	.2667			.3048		.362
16	.362	.2858			.3048		.362
17	.3239	.2858					.3239
18	.3239	.3048					.3239
19	.362	.3048					.3429
20	.381	.3239					.362
21	.381	.4001					.362
22	.4001	.4001					.381
23	.4572	.4191					
24	.4382	.4382	.4001	.4572		.4191	
Max	.4572	.4382	.4191	.4572	.4954	.4191	.4001
Min	.3239	.2286	.3429	.2858	.2858	.4191	.2858
Avg	.3691	.3413	.3783	.3772	.3632	.4191	.3404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 203 / 11 KV UNNATI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.1431	1.0098	1.1622	1.1431		
2	.9335	1.105	.9335	1.105	1.086		
3	.8764	1.0288	.8764	1.0288	1.0288		
4	.9145	.9907	.9145	1.0288	.9907		
5	.9526	1.105	.9907	1.105	.9526		
6	.9907	1.1431	1.105	1.1431	1.1431		
7	1.0288	1.1431	1.0288	1.105	1.105		
8	.9526	1.0288	1.0288	.9717	.9526		.9145
9	.8383	.7621		.8383	.8764		.9145
10	.8192	.7811		.8192	.8573		.8002
11	.8383	.7621			.7811		.8002
12	.8002	.743			.743		.7621
13	.8002	.7621			.724		.743
14	.7621	.7621			.7621		.7811
15	.8002	.6668			.8192		.8192
16	.8002	.8383			.743		.8192
17	.8192	.7049					.7811
18	.6859	.724					.7811
19	.9145	.8383					.9526
20	.9717	.9717					1.0098
21	.9717	1.0669					1.0098
22	1.1241	1.086					1.086
23	1.1812	1.105					
24	1.086	1.1812	1.1241	1.2003	1.1622	1.0669	
Max	1.1812	1.1812	1.1241	1.2003	1.1622	1.0669	1.086
Min	.6859	.6668	.8764	.8192	.724	1.0669	.743
Avg	.9105	.9351	1.0013	1.0461	.9335	1.0669	.8650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 204 / 11 KV SECTOR-5 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.105	1.105	1.1431	1.1241		
2	.9145	1.0288	1.0479	1.105	1.086		
3	.9526	1.0288	1.0288	1.0288	1.0288		
4	.9335	1.0669	1.0669	1.0288	1.0288		
5	.9717	1.1431	1.105	1.105	1.0288		
6	.9526	1.1431	1.1431	1.0669	1.1431		
7	.9145	1.0288	1.1622	.9907	1.1812		
8	.8573	.9335	.8573	.8764	.8954		.8573
9	.8002	.8192		.8192	.8002		.9145
10	.8192	.7049		.7049	.724		.9335
11	.7621	.6859			.7049		.9335
12	.7621	.7049			.8573		.8573
13	.7811	.6859			.724		.7811
14	.7811	.7049			.743		.9907
15	.8383	.743			.724		.8573
16	.8383	.7621			.724		.8573
17	.8192	.7049					.9526
18	.9907	.8002					.9526
19	.9335	.8383					1.1241
20	1.0288	.9526					1.0288
21	1.0288	1.0288					1.0288
22	1.2574	1.0669					1.0669
23	1.1622	1.1431					
24	1.105	1.1431	1.1431	1.1622	1.1622	.9907	
Max	1.2574	1.1431	1.1622	1.1622	1.1812	.9907	1.1241
Min	.7621	.6859	.8573	.7049	.7049	.9907	.7811
Avg	.9248	.9153	1.0733	1.0028	.9223	.9907	.9424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 205 / 11 KV Sector-20 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	.5525	.6859	.7049		
2	.5144	.6097	.4954	.6097	.6859		
3	.4954	.5525	.4763	.5716	.6668		
4	.5144	.5335	.4954	.5716	.6478		
5	.5335	.5716	.5335	.6097	.6478		
6	.5716	.6097	.5716	.6097	.6478		
7	.6097	.5716	.6097	.5716	.6478		
8	.5525	.4954	.5716	.5335	.5716		.5335
9	.5716	.5335		.5144	.5525		.6097
10	.6097	.5335		.5525	.5335		.5906
11	.6287	.4954			.5335		.5906
12	.5335	.5144			.5525		.5906
13	.5335	.4763			.5144		.5716
14	.5144	.4763			.4954		.5716
15	.5716	.4763			.5144		.5716
16	.5716	.5335			.5335		.5716
17	.5716						.5906
18	.6097						.5906
19	.6287						.6668
20	.6478						.6668
21	.6478						.724
22							.7049
23	.7049						
24	.6859	.6859	.6668	.7049	.743	.6668	
Max	.7049	.6859	.6668	.7049	.743	.6668	.724
Min	.4954	.4763	.4763	.5144	.4954	.6668	.5335
Avg	.5840	.5481	.5525	.5941	.5996	.6668	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 206 / 11 KV Sec-5 Plot No-70

SHEDDABLE URBAN

Ulwe Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0572	.0572	.0572		
2	.0381	.0572	.0381	.0572	.0572		
3	.0381	.0572	.0381	.0572	.0572		
4	.0381	.0381	.0572	.0572	.0572		
5	.0572	.0381	.0381	.0572	.0572		
6	.0381	.0381	.0381	.0572	.0381		
7	.0381	.0381	.0381	.0572	.0381		
8		.0381	.0381	.0572	.0572		.0572
9		.0572		.0572	.0572		.0572
10	.0572	.0762		.0572	.0572		.0572
11		.0762			.0762		.0572
12		.0762			.0762		.0572
13	.0572	.0572			.0572		.0572
14		.0572			.0762		.0572
15		.0762			.0953		.0572
16	.0572	.0572			.0762		.0572
17		.0572					.0572
18	.0572	.0572					.0572
19		.0572					.0572
20	.0572	.0572					.0572
21	.0572	.0572					.0572
22	.0572	.0762					.0762
23	.0572	.0762					
24	.0381	.0572	.0572	.0572	.0572	.0572	
Max	.0572	.0762	.0572	.0572	.0953	.0572	.0762
Min	.0381	.0381	.0381	.0572	.0381	.0572	.0572
Avg	.0488	.0580	.0445	.0572	.0617	.0572	.0585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 207 / 11 KV ULWE SUB STATION
TRANSFO Feeder KV- 11 / OUTGOING

DATE	09-APR-18
HR	Load (MW)
9	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 208 / 11 KV WAHAL SEC-23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.8861		1.9243	1.9814		
2	1.4861	1.6766		1.829	1.9624		
3	1.5242	1.5242		1.6766	1.9052		
4	1.6194	1.4861		1.6004	1.9052		
5	1.6385	1.6766		1.6004	1.8671		
6	1.5623	1.7147		1.6766	1.7909		
7	1.6004	1.6385		1.5623	1.7337		
8	1.5051	1.4289		1.467	1.4861		1.4289
9	1.448	1.4098		1.3908	1.467		1.6385
10	1.4098	1.3336		1.448	1.4098		1.5051
11		1.2955			1.3717		1.5051
12	1.467	1.2574			1.2955		1.4289
13	1.467	1.2574			1.3146		1.3527
14		1.3717			1.3717		1.5051
15	1.5432	1.467			1.4861		1.5623
16	1.5432	1.448			1.467		1.5623
17		1.0288					1.448
18	1.2955	1.1431					1.448
19		1.2955					1.4861
20	1.7718	1.4289					1.6766
21	1.7718	1.7909					1.7718
22	1.9433	1.8671					1.9624
23	2.0386	1.9243					
24	2.0767	1.9624	1.9624	1.9624	2.0767	1.9243	
Max	2.0767	1.9624	1.9624	1.9624	2.0767	1.9243	1.9624
Min	1.2955	1.0288	1.9624	1.3908	1.2955	1.9243	1.3527
Avg	1.6213	1.5130	1.9624	1.6489	1.6407	1.9243	1.5521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 412 / 33 KV T.S. REHMAN
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	3.4294		2.2862	2.4577		
2		3.2007		2.4006	2.4577		
3	1.9433	2.9721	1.9433	2.4006	2.4006		
4		2.6292	2.0576	2.2862	2.2862		
5	2.0576	2.4006	2.0005	2.0576	2.2862		
6		2.1719	2.2862	1.829	2.2862		
7	2.4006	2.1719	2.1719	1.829	2.2862		
8		2.1148	1.9433	2.0005	2.1719		2.4006
9	2.0005	3.1436		2.9721	2.5149		3.2007
10		3.3722		3.315	3.5437		1.2574
11	1.9433	2.9721			3.1436		1.2574
12		3.1436			3.6008		1.7147
13	1.9433	2.2862			3.2007		1.829
14		3.3722			3.315		2.6292
15	2.1148	2.9721			3.4294		2.8006
16		3.1436			4.1724		2.9721
17	1.9433	2.6292					3.0293
18		2.4006					3.0293
19	2.2291	2.1719					3.0293
20	2.0576	2.0576					2.1148
21	2.0576	2.1719					2.0576
22	2.2291	1.829					2.5149
23	2.3434	1.9433					
24	2.4577	3.5437	2.0005	2.2862	2.5149	2.2862	
Max	2.4577	3.5437	2.2862	3.315	4.1724	2.2862	3.2007
Min	1.9433	1.829	1.9433	1.829	2.1719	2.2862	1.2574
Avg	2.1262	2.6768	2.0576	2.333	2.8275	2.2862	2.3891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.3443	1.363	1.4563	1.307	1.4937	1.4937
2	1.2136	1.1203	1.1949	1.307	1.1949	1.4003	1.4003
3	1.1203	1.1203	1.1203	1.1203	1.1203	1.307	1.307
4	1.0082	1.0456	1.0456	1.0829	1.1203	1.2136	1.2136
5	.9709	1.0829	.9709	.9896	1.0456	1.1203	1.0269
6	.9522	1.0829	1.0269	1.0082	1.0082	1.1016	1.0642
7	.8775	1.1576	1.1203	1.0829	1.0642	1.1763	1.0082
8	.8215	1.0082	1.1576	.9709	.9896	1.0082	.9896
9	.9335	.9335	.9149	.9335	.9149	1.0269	.9896
10	1.0082	.8775	.8775	.9522	.9709	.9522	.9896
11	1.0456	.8962	.9149	.8589	.9149	.9335	1.0269
12	1.0269	.8402	.8962	.9522	.8029	.9709	1.0082
13	1.0082	.9522	.9335	.8962	.9335	.9522	1.0829
14	.9522	.8775	.7655	.9149	.9522	.9896	1.1016
15	.9709	.8962	.9709	1.0269	.9709	.9522	1.1389
16	1.0456	.9335	.9522	.9896	.9522	.9709	1.1389
17	1.0082	.9149	.9522	.9896	.9709	.9522	1.0269
18	1.0082	.8402	.9335	.9335	.8962	.9896	.9522
19	1.1203	.9709	1.0082	1.0642	1.0269	.9896	1.0269
20	1.1016	1.0642	1.1016	1.1949	1.1203	1.1203	1.1576
21	1.1016	1.2136	1.1763	1.1949	1.1763	1.1763	1.1203
22	1.2323	1.2323	1.2883	1.2696	1.3256	1.2696	1.2883
23	1.4377	1.5497	1.5497	1.587	1.5497	1.5123	1.4003
24	1.4377	1.5684	1.4937	1.5497	1.531	1.587	1.587
Max	1.4377	1.5684	1.5497	1.587	1.5497	1.587	1.587
Min	.8215	.8402	.7655	.8589	.8029	.9335	.9522
Avg	1.0728	1.0635	1.0720	1.0969	1.0775	1.1319	1.1475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3174	.3174	.2987	.3361	.3174	.2801
2	.2987	.2801	.2987	.2987	.2801	.2801	.2427
3	.2801	.2427	.2801	.2801	.2801	.2241	.2241
4	.2614	.2427	.2427	.2614	.2241	.2241	.2241
5	.2614	.2614	.2427	.2614	.2241	.2427	.2241
6	.2614	.2614	.2614	.2614	.2427	.2801	.2427
7	.2054	.2427	.2241	.2614	.2427	.2054	.2054
8	.2427	.2614	.2427	.2427	.2241	.2427	.2241
9	.2614	.2614	.2241	.2054	.2427	.2054	.2241
10	.3174	.3547	.2987	.3174	.3174	.3174	.2801
11	.3361	.3547	.3734	.3547	.3547	.3361	.3174
12	.3174	.3174	.4108	.3174	.3734	.2987	.2987
13	.3361	.2614	.3174	.2801	.2801	.3174	.2241
14	.3361	.2801	.2987	.2987	.2987	.3174	.2987
15	.2987	.0187	.4108	.3547	.3174	.4108	.3361
16	.3361	.4108	.3921	.4481	.3921	.4294	.3921
17	.2987	.3547	.3174	.3921	.4108	.2427	.3734
18	.2987	.2054	.2801	.2614	.2801	.2801	.2801
19	.3174	.1867	.2801	.2614	.2427	.2801	.2987
20	.3734	.2241	.2987	.3174	.2987	.3361	.3174
21	.3547	.2801	.2987	.2987	.2987	.3174	.2801
22	.4481	.3361	.3921	.3734	.3174	.3547	.3547
23	.3734	.3547	.3734	.3734	.4108	.3734	.3547
24	.3547	.3547	.3547	.3361	.3734	.3921	.3361
Max	.4481	.4108	.4108	.4481	.4108	.4294	.3921
Min	.2054	.0187	.2241	.2054	.2241	.2054	.2054
Avg	.3120	.2777	.3096	.3065	.3026	.3011	.2847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5228	.3734	.4668	.4108	.3547	.4668
2	.4668	.3734	.3734	.4481	.3734	.3547	.3734
3	.4108	.3734	.3734	.3361	.3734	.3547	.3547
4	.4108	.3734	.3734	.2801	.3734	.3734	.3547
5	.4481	.4854	.4854	.5601	.6722	.4668	.4481
6	.4481	.5601	.5788	.5601	.7468	.5415	.5601
7	.6908	.7468	.8589	.6348	.7655	.7468	.7655
8	.8589	.7468	.8589	1.3817	.8589	.7282	.7468
9	.8962	.6161	.8589	1.1389	.6348	.7468	.5975
10	.3734	.7468	.3921	.6722	.3174	.3361	.4854
11	.8029	.7655	.2987	.6535	.2987		.3734
12	.7282	.8215	.4108	.2054	.3174	.3734	.3734
13	.7282	.8215	.3734	.2241	.2987	.3921	.3547
14	.7282	.4668	.2054	.2241	.5228	.3734	.5601
15	.6348	.4854	.5788	.4481	.4668	.6908	.5975
16	.5975	.5041	.5601	.4668	.7095	.6908	.6535
17	.5601	.6908	.6348	.6161	.5601	.5415	.5228
18	.6722	.6535	.6348	.6161	.6908	.9335	.6161
19	.9335		.7842	.8402	.9149	.9335	.6161
20	.7282	.7095	.8775	.6535	.5601	.7095	.9149
21	.5415	.5228	.6535	.6908	.5788	.6908	.6722
22	.7282	.7282	.6722	.6535	.5788	.5788	.5601
23	.8589	.8215	.6722	.6161	.5041	.6348	.7095
24	.5228	.5975	.5228	.5601	.5228	.4668	.5415
Max	.9335	.8215	.8775	1.3817	.9149	.9335	.9149
Min	.3734	.3734	.2054	.2054	.2987	.3361	.3547
Avg	.6372	.6145	.5586	.5811	.5438	.5658	.5508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.4481	.4668	.4481	.4854	.4481
2	.3547	.3734	.4108	.4108	.3734		.3734
3	.3174	.3734	.3734	.3734	.3361	.3734	.3361
4	.2987	.2987	.2987	.3361	.3361	.3361	.2987
5	.2987	.2801	.2614	.3174	.2987	.2987	.2987
6	.2987	.2614	.2801	.3174	.3734	.3174	.3174
7	.2427	.2987	.3174	.3361	.3547	.2801	.2427
8	.2801	.3174	.3174	.3921	.3174	.2987	.2987
9	.3174	.2987	.3361	.3734	.3547	.3174	.3547
10	.2614	.2801	.2614	.2987	.2987	.2614	.3361
11	.2614	.2241	.2427	.2614	.2241	.2614	.3174
12	.3361	.2614	.2987	.3361	.2987	.3174	.3547
13	.2427	.2054	.3361	.2614	.2614	.2614	.3174
14	.2987	.2801	.2801	.2801	.2987	.3174	.3361
15	.2241	.2801	.3361	.3174	.3174	.3174	.3734
16	.2614	.2801	.2801	.2987	.2987	.2801	.3547
17	.2801	.2427	.2614	.2801	.2614	.2801	.3174
18	.2987	.2614	.2614	.2987	.2614	.2987	.2801
19	.2614	.3361	.3174	.2987	.2614	.2987	.3361
20	.2987	.5788	.3174	.2987	.3174		.3174
21	.3547	.3174	.3734	.3547	.3547	.3734	.3174
22	.3921	.4108	.4294	.4108	.4294	.4108	.4108
23	.4668	.5041	.5041	.4854	.5041	.5041	.5228
24	.4481	.4854	.5415	.5041	.5228	.5415	.5041
Max	.4668	.5788	.5415	.5041	.5228	.5415	.5228
Min	.2241	.2054	.2427	.2614	.2241	.2614	.2427
Avg	.3127	.3275	.3369	.3462	.3376	.3378	.3485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7468	.6908	.7468	.7468	.7468	.7468
2	.6348	.6722	.6535	.6535	.6722	.6722	.6722
3	.5601	.6348	.5975	.5788	.5975	.5975	.5601
4	.4854	.5601	.5228	.5415	.5601	.5601	.4481
5	.4668	.5228	.4481	.5041	.5601	.5601	.4481
6	.5041	.5228	.4854	.5041	.4854	.5601	.4668
7	.4294	.4481	.4854	.4668	.4481	.4108	.4108
8	.3921	.4294	.5228	.4294	.5041	.3921	.3921
9	.4481	.4481	.5415	.4668	.4481	.3921	.4668
10	.5041	.4668	.5041	.5415	.4668	.4668	.5228
11	.4854	.4668	.4481	.4294	.4481	.4854	.5601
12	.5041	.5601	.4481	.5228	.4481	.3921	.5228
13	.5041	.3734	.4294	.4108	.4481	.4294	.5415
14	.5228	.4294	.4668	.4668	.4854	.5601	.6161
15	.4854	.4294	.5415	.4668	.5415	.5788	.6348
16	.5228	.4854	.5601	.5788	.5415	.5975	.6535
17	.5228	.4854	.5228	.5601	.5041	.4854	.5788
18	.4668	.4108	.4294	.4481	.4668	.5975	.5041
19	.5041	.4668	.5601	.5788	.4854	.5975	.5975
20	.5601	.5788	.5975	.6161	.6161	.5788	.5975
21	.5788	.5975	.6161	.6161	.6161	.6535	.5975
22	.6535	.6348	.6722	.7095	.6348	.6908	.6908
23	.7842	.7655	.8215	.8215	.7842	.8029	.7468
24	.7842	.8029	.9709	.8029	.8589	.8589	.8775
Max	.7842	.8029	.9709	.8215	.8589	.8589	.8775
Min	.3921	.3734	.4294	.4108	.4481	.3921	.3921
Avg	.5422	.5391	.5640	.5609	.5570	.5695	.5772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	.9709	.9709	1.0829	1.1203	1.0642	1.0829
2	.8962	.8962	.8962	.9335	.9709	.9709	.9709
3	.7842	.8215	.8215	.8589	.8962	.8962	.8962
4	.6535	.7468	.7468	.7842	.8215	.8215	.7468
5	.6908	.7468	.7095	.7468	.7468	.7468	.7468
6	.6908	.7842	.6908	.7468	.7468	.7655	.7655
7	.6161	.7282	.6535	.6908	.7095	.6161	.6908
8	.6348	.7282	.6722	.7655	.7282	.6908	.6908
9	.6908	.6348	.6908	.6697	.7095	.7095	.7468
10	.6908	.6348	.6161	.6908	.5601	.6535	.7095
11	.7095	.5975	.6348	.6161	.6722	.5975	.6908
12	.6722	.5788	.5601	.6535	.6348		.7095
13	.6161	.5601	.5788	.5788	.5228	.5415	.6535
14	.6908	.5415	.5415	.5788	.6348	.6161	.7282
15	.6722	.5415	.5975	.6348	.6535	.6161	.7842
16	.6722	.5415	.5788	.5975	.0187	.6348	.7095
17	.6535	.5415	.5788	.5601	.5788	.5975	.6722
18	.6161	.5415	.5788	.5975	.5975	.7095	.7095
19	.7655	.6535	.7468	.7282	.7282	.7095	.7468
20	.7842	.7468	.7655	.7655	.7842	.7655	.7468
21	.8402	.7842	.8962	.8775	.8589	.8589	.8215
22	1.0082	.9709	1.0829	1.0269	1.1203	1.0269	1.0829
23	.5788	1.1949	1.251	1.1949	1.307	1.1949	1.1389
24	1.1203	1.1016	1.0829	1.1763	1.2136	1.1763	1.1763
Max	1.1203	1.1949	1.251	1.1949	1.307	1.1949	1.1763
Min	.5788	.5415	.5415	.5601	.0187	.5415	.6535
Avg	.7414	.7328	.7476	.7732	.7640	.7817	.8091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187	.0187	.0187	.0187
2	.0187	.0187	.0187	.0187	.0187	.0187	.0187
3	.0187	.0187	.0187	.0187	.0187	.0187	.0187
4	.0187	.0187	.0187	.0187	.0187	.0187	.0187
5	.0187	.0187	.0187	.0187	.0187	.0187	.0187
6	.0187	.0187	.0187	.0187	.0187	.0187	.0187
7	.0187	.0187	.0187	.0187	.0187	.0187	.0187
8	.0187	.0187	.0187	.0187	.0187	.0187	.0187
9	.0187	.0187	.0187	.0187	.0187	.0187	.0187
10	.0187	.0187	.0187	.0187	.0187	.0187	.0187
11	.0187	.0187	.0187	.0187	.0187	.0187	.0187
12	.0187	.0187	.0187	.0187	.0187	.0187	.0187
13	.0187	.0187	.0187	.0187	.0187	.0187	.0187
14	.0187	.0187	.0187	.0187	.0187	.0187	.0187
15	.0187	.0187	.0187	.0187	.0187	.0187	.0187
16	.0187	.0187	.0187	.0187	.0187	.0187	.0187
17	.0187	.0187	.0187	.0187	.0187	.0187	.0187
18	.0187	.0187	.0187	.0187	.0187	.0187	.0187
19	.0187	.0187	.0187	.0187	.0187	.0187	.0187
20	.0187	.0187	.0187	.0187	.0187	.0187	.0187
21	.0187	.0187	.0187	.0187	.0187	.0187	.0187
22	.0187	.0187	.0187	.0187	.0187	.0187	.0187
23	.0187	.0187	.0187	.0187	.0187	.0187	.0187
24	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Max	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6908	.7282	.7095	.7282	.7095	.7468
2	.6348	.5975	.6908	.6535	.679	.679	.6908
3	.5975	.5658	.6722	.5658	.5847	.6224	.6535
4	.5601	.5093	.6348	.6036	.5093	.5601	.6161
5	.5228	.5281	.5601	.5601	.4715	.5601	.5601
6	.5415	.547	.5975	.5788	.5281	.5975	.6348
7	.5601	.5658	.5601		.547	.547	.5658
8	.5975	.6602	.6161		.5847	.6036	.5658
9	.6036		.6535		.6224	.6224	
10	.6413	.6348	.7468		.7167	.7282	
11	.679	.8215	.7842		.7842	.8215	
12	.6602	.8402	.8402	.4934	.7842	.8029	
13	.6979	.8215	.8316	.8686	.8402	.8215	
14	.7356	.8029	.8215	.7762	.8215	.8962	
15	.7167	.7842	.8029	.8029	.7655	.8215	
16	.679	.7282	.7468	.8215	.7655	.8029	
17		.7095	.7468	.7282	.7468	.7842	
18		.6908	.7095		.7167	.7282	
19		.924	.9055		.8589	.8962	.8589
20		.8686	.8686		.8686	.924	
21		.8871	.8686		.8316	.9055	
22		.8316	.8316		.8501	.8501	
23		.7947	.8029		.8215	.8131	
24	.7468	.7468	.8029	.7468	.7842	.7842	.8029
Max	.7468	.924	.9055	.8686	.8686	.924	.8589
Min	.5228	.5093	.5601	.4934	.4715	.547	.5601
Avg	.6402	.7196	.7427	.6853	.7171	.7451	.6696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7619	.7602	.7964	.8145	.8145	.6878	.8238
2	.6733	.7059	.7522	.7602	.724	.6335	.7343
3	.6201	.5792	.7164	.6878	.6516	.5316	.6626
4	.5493	.5249	.6379	.5373	.5552	.4961	.6201
5	.5316	.543	.6024	.5552	.5194	.5194	.5316
6	.567	.5552	.5609	.5731	.543	.5373	.6024
7	.5316	.5552	.5959	.6697	.567	.5373	.5847
8	.6201	.591	.6024	.6767	.5973	.6089	.567
9	.6335		.6626	.6584	.6516	.6268	
10	.6154	.591	.6268		.6089	.6268	
11	.6036	.6335	.6516		.6335	.6878	
12	.679	.6516	.7059	.6805	.6697	.7059	
13	.6447	.6516	.6447	.6516	.6984	.6878	
14	.6268	.6878	.6984	.6878	.724	.724	
15	.6447	.7059	.6878	.7059	.724	.724	
16	.6697	.6878	.6335	.7316	.6878	.7059	
17		.6516	.5552	.6697	.6516	.6697	
18		.5792	.6024		.6379	.6335	
19		.7265	.7087		.7796	.8145	.7442
20		.7796	.7796		.7796	.815	
21		.7796	.7619		.8238	.7973	
22		.7442	.7701		.8238	.7796	
23		.8682	.8417		.9412	.9036	
24	.8869	.8326	.9231	.8507	.8869	.7421	.8954
Max	.8869	.8682	.9231	.8507	.9412	.9036	.8954
Min	.5316	.5249	.5552	.5373	.5194	.4961	.5316
Avg	.6388	.6689	.6883	.6819	.6956	.6748	.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7207	.7762	.8131	.7762	.8131	.8316
2	.7133	.6283	.7392	.7762	.7577	.7577	.7577
3	.6767	.5729	.7023	.7023	.7392	.7023	.6838
4	.6036	.5544	.6468	.5487	.6468	.5487	.6283
5	.567	.4805	.6468	.5121	.5544	.567	.5544
6	.6219	.5121	.6584	.567	.5853	.5853	.6036
7	.5121	.567	.567	.5729	.6401	.5729	.6036
8	.5121	.5359	.5487		.5359	.5729	.6219
9	.567		.5914		.5544	.567	
10	.5853	.499	.5544		.5175	.5914	
11	.5359	.5729	.5359		.5359	.5914	
12	.5121	.5544	.5359	.5544	.5304	.5544	
13	.5121	.5729	.4755	.5175	.4938	.5729	
14	.5304	.5544	.5175	.5359	.5175	.6468	
15	.5544	.5359	.5788	.5359	.5975	.5544	
16	.5729	.5359	.5175	.5415	.5175	.5544	
17		.5359	.5175	.5359	.5175	.5544	
18		.5175	.5121		.4887	.5359	
19		.6335	.5973		.6036	.6468	.6516
20		.7059	.6584		.6767	.695	
21		.724	.695		.7133	.7133	
22		.724	.7499		.7316	.8048	
23		.8507	.8501		.8501	.8779	
24	.8316	.7577	.8316	.8501	.8775	.8501	.8596
Max	.8316	.8507	.8501	.8501	.8775	.8779	.8596
Min	.5121	.4805	.4755	.5121	.4887	.5359	.5544
Avg	.5986	.6020	.6252	.6117	.6233	.6430	.6796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5093	.5658	.5658		.5658	.5847
2	.5093	.4715	.5281	.5335		.5281	.5281
3	.4715	.415	.4904	.4763		.4191	.4715
4	.4338	.3961	.4572	.4954		.4001	.415
5	.415	.4338	.4572	.5144		.4191	.3961
6	.4527	.4715	.4763	.5335		.4763	.4572
7	.4715	.4904	.6097	.5601		.5975	.5144
8	.5658	.5847	.6287	.5847		.5788	.6413
9	.5041		.4904	.4904		.4668	
10	.5041	.3772	.4904		.4854	.4854	
11	.4527	.4715	.4527		.4527	.4904	
12	.3584	.415	.3772	.415	.381	.4338	
13	.4001	.3881	.3772	.3772	.381	.4527	
14	.4572	.3511	.3772	.3961	.381	.4338	
15	.4382	.3881	.3961	.4001	.4001	.3772	
16	.4382	.3961	.381	.4001	.415	.3772	
17		.3772	.381	.3961	.415	.3961	
18		.3772	.3961		.3772	.3772	
19		.4904	.4527		.4527	.4715	.4527
20		.5658	.5281		.5658	.547	
21		.547	.5281		.547	.5658	
22		.5544	.5847		.6036	.6036	
23		.6099	.6036		.6602	.6413	
24	.5847	.5658	.6036	.5847		.6036	.6413
Max	.5847	.6099	.6287	.5847	.6602	.6413	.6413
Min	.3584	.3511	.3772	.3772	.3772	.3772	.3961
Avg	.4708	.4629	.4847	.4827	.4656	.4878	.5102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	1.0059	.9145	1.0059	.9877		1.0242
2	.8413	.9055	.9145	.9145	.9328	.9511	.9145
3	.7865	.7842	.8779	.823	.8501	.823	.8596
4	.7316	.7207	.8413	.7762	.7577	.7392	.8048
5	.7316	.7392	.8413	.7947	.7762	.7023	.7316
6	.7499	.7577	.8596		.8131	.7577	.8048
7	.7682	.7762	.823	.6908	.8316	.8131	.7577
8	.8048	.7762	.8048	.7842	.8131	.8316	.8316
9	.7577		.8316	.7392	.7392	.7499	
10	.7762	.7023	.7577		.7392	.7133	
11	.7316	.7762	.7499		.7392	.7316	
12	.7602	.7762	.7316	.7499	.7682	.7499	
13	.7964	.8131	.7316	.6335	.7865	.7499	
14	.8413	.7577	.7316	.8048	.7682	.823	
15	.823	.7023	.7762	.8048	.7947	.7682	
16	.8048	.7577	.7577	.7865	.7499	.7499	
17		.7762	.7316	.8145	.7316	.7133	
18		.7577	.724		.7602	.7865	
19		.9774	.9231		.9774	1.0242	.9774
20		1.0317	1.0679		1.0679	1.0136	
21		1.0498	1.0679		1.0498	1.0679	
22		1.086	1.0791		1.0791	1.1222	
23		1.1222	1.1157		1.1706	1.1946	
24	1.0974	1.0608	1.0608	1.0608	1.0425	1.0974	1.086
Max	1.0974	1.1222	1.1157	1.0608	1.1706	1.1946	1.086
Min	.7316	.7023	.724	.6335	.7316	.7023	.7316
Avg	.8112	.8527	.8631	.8122	.8636	.8554	.8792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8029	.8589	.8775	.2241	.8962	.9149
2	.7356	.7468	.8589	.8402	.7468	.8488	.8402
3	.679	.6348	.8215	.7545	.6535	.7545	.7842
4	.6602	.5601	.8029	.7167	.5788	.679	.7468
5	.7167	.5228	.8215	.7842	.5601	.7095	.7842
6	.7655	.5788	.8589	.8402	.5975	.7842	.8215
7	.5788	.6161	.6348	.6535	.6348	.6722	.6348
8	.7282	.8402	.8402	.8775	.8589	.8215	.8589
9	.8215		.8589	.8029	.8402	.6722	
10	.6908	.6722	.7282		.7282	.7282	
11	.7655	.7842	.7842		.7282	.7282	
12	.7282	.7842	.7842	.7842	.7655	.7655	
13	.7095	.8029	.7655	.7842	.7468	.7655	
14	.6908	.7468	.7655	.8029	.7468	.8215	
15	.6908	.7655	.7468	.8029	.8029	.7842	
16	.6908	.7655	.7468	.8029	.8029	.8029	
17		.7655	.7282	.8402	.7842	.8215	
18		.7842	.7468		.7655	.7655	
19		1.0751	1.0456		1.0829	1.0456	1.0534
20		1.094	1.0082		1.0829	.9335	
21		.8865	.9335		.9709	.9149	
22		.9054			.8962	.8589	
23		.9808	.9335		.9149	.9896	
24	.9242	.8775	.8962	.9149	.9149	.9335	1.0082
Max	.9242	1.094	1.0456	.9149	1.0829	1.0456	1.0534
Min	.5788	.5228	.6348	.6535	.2241	.6722	.6348
Avg	.7309	.7823	.8248	.8050	.7679	.8124	.8447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.2858	.3048	.3048	.2858	.3048
2	.2667	.2667	.2667	.2477	.2667	.2477	.3048
3	.2477	.2477	.2477	.2286	.2286	.2096	.2858
4	.2286	.2286	.2096	.2096	.2096	.2286	.2477
5	.2075	.2096	.2263	.2263	.2096	.2096	.2075
6	.2452	.2096	.2452	.2452	.2286	.2477	.2641
7	.2075	.2477	.2641		.2286	.2477	.2452
8	.2075	.3048	.3206		.3239	.2829	.3018
9	.3018		.3961		.381	.3961	
10	.3395	.4954	.5093		.4715	.4904	
11	.4382	.6413	.5847		.5847	.5658	
12	.4382	.679	.6036	.3395	.6036	.6602	
13	.4382	.6413	.5847	.6413	.6224	.6413	
14	.4382	.6224	.5658	.6036	.6413	.6224	
15	.4191	.6413	.6224	.6413	.679	.6036	
16	.4001	.6224	.6036	.6602	.679	.679	
17		.6413	.6036	.6413	.6602	.6979	
18		.5847	.6036		.6036	.6036	
19		.5281	.6224		.6036	.6224	.4763
20		.5093	.547		.5281	.547	
21		.3772	.4191		.415	.3772	
22		.3772	.381		.362	.3772	
23		.3772	.362		.362	.3395	
24	.3048	.3429	.3429	.3239		.3239	.3429
Max	.4382	.679	.6224	.6602	.679	.6979	.4763
Min	.2075	.2096	.2096	.2096	.2096	.2096	.2075
Avg	.3196	.4392	.4341	.4087	.4434	.4378	.2981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.9936	2.2131	2.3228	2.3411	2.396	2.3777
2	1.8473	1.829	2.0485	2.1582	2.1948	2.1948	2.1765
3	1.701	1.6827	1.9022	1.8473	2.0485	2.0485	1.8107
4	1.5546	1.6095	1.7375	1.7193	1.9753	1.9387	1.6095
5	1.4632	1.4998	1.6095	1.5546	1.829	1.829	1.5729
6	1.4998	1.39	1.5181	1.6095	1.701	1.701	1.5729
7	1.2803	1.4449		1.5181	1.6461		1.3535
8	1.2803	1.386		1.5364	1.5339	1.6095	1.4266
9	1.5181	1.4415	1.39	1.5546	1.4969	1.4998	1.5181
10	1.5181	1.4045	1.3535	1.4266	1.4969	1.4815	1.5546
11	1.4449		1.3169	1.2986			1.6278
12	1.4998	1.2803	.4251	1.3169	1.3352	1.3352	1.6095
13	1.5546	1.2437	1.3352	1.3535	1.3717	1.39	1.6095
14	1.829			1.5729			1.8656
15	1.9936	1.6095	1.4632	1.7924	1.6827	1.6827	2.1216
16	1.829		1.6278	1.7002	1.5546		1.9022
17	1.5546	1.2437		1.4632	1.4632	1.4632	1.7558
18	1.5154	1.2254	1.2437	1.4415	1.3535		1.6632
19	1.4784	1.5181	1.4083	1.4045	1.5912	1.5912	1.5893
20	1.7926	1.6461	1.7375	1.6632	1.8473	1.829	1.7372
21	1.922	1.9022		2.0513	2.1216		2.0513
22	2.1807	2.1582	2.2862	2.3655	2.4143	2.2314	2.2916
23	2.3101	2.4143	2.524	2.5873	2.6337	2.4691	2.4394
24	2.0851	2.1807	.9145	2.4143	2.4764	2.5606	2.4874
Max	2.3101	2.4143	2.524	2.5873	2.6337	2.5606	2.4874
Min	1.2803	1.2254	.4251	1.2986	1.3352	1.3352	1.3535
Avg	1.6944	1.6240	1.5818	1.7364	1.8231	1.8473	1.8219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1399	2.1948	2.2862	2.3411	2.3411	2.396	2.3594
2	1.9022	2.0485	2.1582	2.1582	2.1582		2.0119
3	1.7193	1.829	2.0302	1.9022	1.9753	2.0302	1.7924
4	1.5546	1.6827	1.9022	1.7375	1.829	1.8656	1.6461
5	1.4815	1.6095	1.7924	1.7193	1.7193	1.7375	1.6095
6	1.5364	1.7558	1.9936	1.8107	1.829	1.8839	1.701
7	1.6278	1.829		1.829	1.8473		1.6827
8	1.6461	1.8296	1.7558	1.6278	1.848	1.6644	1.5912
9	1.5181	1.6804	1.6461	1.6461	1.6263	1.7741	1.6644
10	1.7375	1.5893	1.5729	1.6644	1.5339	1.6827	1.6644
11	1.7741		1.5181	1.6827			1.701
12	1.7558	1.6461	1.701	1.6095	1.5364	1.701	1.7375
13	1.7193	1.4266	1.5181	1.5546	1.5546	1.5364	1.7741
14	1.7924			1.701			1.8107
15	1.8473	1.6644	1.7924	1.7741	1.6827	1.8107	1.8107
16	1.8473		1.701	1.829	1.7375		1.8839
17	1.8656	1.7558		1.8656	1.7924	1.6827	1.8839
18	1.885	1.6461	1.829	1.9404	1.829		1.9404
19	1.9404	1.9387	1.957	1.9774	1.9022	1.829	1.9959
20	1.922	2.0485	1.9204	2.0328	1.9204	1.8656	2.0328
21	1.9035	1.9387		2.0883	2.0668		2.0698
22	2.1068	2.1582	2.1948	2.3655	2.2497	2.1216	2.2177
23	2.3655	2.396	2.4691	2.5318	2.5972	2.524	2.3655
24	2.2497	2.2965	2.4143	2.4508	2.4579	2.5057	2.5606
Max	2.3655	2.396	2.4691	2.5318	2.5972	2.524	2.5606
Min	1.4815	1.4266	1.5181	1.5546	1.5339	1.5364	1.5912
Avg	1.8266	1.8554	1.9076	1.9100	1.9106	1.9183	1.8961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.2614	.4108	.4294	.3361	.4108	.1867
2	.4854	.2987	.3734	.3921	.2614	.3734	.2241
3	.4481	.3361	.3361	.4108	.2614	.2801	.2614
4	.4481	.2614	.2801	.3361	.2241	.2241	.3174
5	.3361	.2241	.3734	.1867	.2987	.1867	.2987
6	.2614	.3361	.4854	.1867	.2241	.1867	.2801
7	.3921	.3921		.5601	.2801		.168
8	.1867	.3881	.3734	.5788	.462	.4108	.2801
9	.2427	.6468	.5041	.4481	.5544	.6535	.6348
10	.4481	.5415	.5788	.4294	.5175	.5041	.6161
11	.5975		.7468	.7468			.5228
12	.5228	.6722	.5975	.7356	.6722	.5228	.4668
13	.4668	.4854	.4854	.7282		.6161	.4108
14	.4108			.6908			.5601
15	.3361	.3361	.4854	.6535	.4108	.6348	.7842
16	.4481		.5788	.5601	.4108		.7095
17	.5975	.3734		.4108	.4668	.5041	.2614
18	.5175	.3921	.4294	.3696	.5228		.3326
19	.5914	.4108	.4668	.3696	.2801	.5601	.4251
20	.5544	.3734	.3734	.4251	.6161	.1867	.4435
21	.5359	.4854		.4251	.2054		.4435
22	.4435	.4108	.168	.4066	.6161	.4294	.4066
23	.3511	.3361	.4854	.4066	.5601	.4294	.3511
24	.5041	.3361	.4668	.4481	.3734	.4481	.1867
Max	.5975	.6722	.7468	.7468	.6722	.6535	.7842
Min	.1867	.2241	.168	.1867	.2054	.1867	.168
Avg	.4437	.3951	.4500	.4723	.4074	.4201	.3988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.0572	.0381	.0381	.0572
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0572
5	.0381	.0381	.0381	.0381	.0381	.0381	.0572
6	.0572	.0572	.0572	.0381	.0572	.0381	.0572
7	.0572	.0572		.0572	.0572		.0572
8	.0953	.1334	.1143	.0572	.0953	.0953	.0572
9	.0762	.1524		.0953	.2096	.1143	.0572
10	.0572	.1524	.1524	.1143	.1524	.1143	.0572
11	.0572		.1334	.1143			.0381
12	.0381	.1715	.1143	.0953	.1143	.1143	.0381
13	.0762	.1334	.0953	.0953	.1524	.0762	.0572
14	.0572			.0762			.0572
15	.0762	.0572	.0572	.0572	.0572	.0572	.0381
16	.0572		.0381	.0572	.0572		.0381
17	.0572	.0572		.0572	.0572	.0572	.0381
18	.0572	.0572	.0572	.0572	.0572		.0572
19	.0572	.0572	.0572	.0381	.0572	.0572	.0572
20	.0572	.0381	.0572	.0381	.0572	.0572	.0572
21	.0572	.0572		.0381	.0572		.0572
22	.0572	.0572	.0572	.0381	.0572	.0572	.0381
23	.0381	.0572	.0572	.0381	.0381	.0572	.0572
24	.0381	.0381	.0572	.0572	.0381	.0381	.0572
Max	.0953	.1715	.1524	.1143	.2096	.1143	.0572
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0556	.0726	.0682	.0596	.0710	.0625	.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1948	1.9959	2.0851	2.2131	2.3285	2.3411	2.2862
2	2.0851	1.848	1.8839	1.9753	2.2177	2.2131	2.1216
3	1.7924	1.7002	1.7558	1.8107	2.1068	2.0485	1.8656
4	1.6644	1.6263	1.6461	1.7375	1.9774	1.9204	1.6461
5	1.5546	1.7372	1.7924	1.8473	1.848	1.8473	1.6095
6	1.6461	1.848	2.0302	1.957	1.9774	2.0485	1.7558
7	1.6461	1.9404		1.957	1.9774		1.6461
8	1.5546	1.829	1.9022	1.9022	1.9022	1.9753	1.5912
9	1.6827	1.7558		1.829	1.8473	1.8656	1.6827
10	1.701	1.8107	1.7741	1.8839	1.829	1.8656	1.701
11	1.8296		1.8656	1.9035			1.885
12	1.848	1.8839	1.9387	1.9404	1.957	1.9204	1.9404
13	1.848	1.8473	1.9022	1.9774	1.957	2.0119	1.9404
14	1.922			2.0698			2.0328
15	1.9589	1.9204	2.1216	2.1437	2.1216	2.0485	2.1068
16	1.9959		2.0485	2.0698	1.8839		2.0883
17	2.0513	1.9936		1.9959	2.0119	2.0119	2.0883
18	1.957	1.829	1.829	1.9387	1.957		2.0119
19	1.9936	1.957	1.957	1.9022	2.0119	1.8656	1.957
20	2.0119	1.9204	1.9387	2.0119	2.1216	1.9204	2.0119
21	1.9936	2.0851		2.1033	2.2314		2.0668
22	2.1399	2.2497	2.268	2.3228	2.3777	2.1582	2.2131
23	2.2862	2.4326	2.4691	2.5972		2.524	2.3411
24	2.2497	2.2314	2.2862	2.524	2.524	2.4691	2.5057
Max	2.2862	2.4326	2.4691	2.5972	2.524	2.524	2.5057
Min	1.5546	1.6263	1.6461	1.7375	1.829	1.8473	1.5912
Avg	1.9003	1.9258	1.9734	2.0256	2.0556	2.0586	1.9623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.386	1.3817	1.4784	1.4969	1.531	1.5154	1.6632
2	1.2567	1.307	1.4045	1.4045	1.4563	1.3121	1.5524
3	1.1273	1.2136	1.3121	1.3121	1.3443	1.1827	1.4045
4	1.0164	1.1203	1.1458	1.1827	1.2696	.961	1.2936
5	.9979	1.0456	1.2197	1.2012	1.2323	1.1088	1.2936
6	1.0349	1.1203	1.3306	1.2382	1.3443	1.2197	1.1273
7	.9055	1.2136		1.1273	1.2323		.9979
8	1.0349	1.1827	1.1458	1.1643	1.2012	1.1827	1.0534
9	1.1273	1.1273		1.1273	1.1088	1.1088	1.1088
10	1.1273	1.0534	1.0349	1.0534	1.0534	1.0719	1.2197
11	1.1203		.9795	.9335			1.1016
12	1.1203	.924	.9795	.8962	1.0164	.9055	1.0456
13	1.1203	.8871	.8871	.8962	.8686	.8686	1.0456
14	1.0829			.9335			1.1016
15	1.0642	.924	.9425	.9709	1.0164	.9425	1.1576
16	1.0082		.961	1.0082	1.0164		1.1203
17	1.0829	.924		1.0456	1.0164	.961	1.1203
18	1.1203	.8686	.9425	1.0719	1.0164		1.1458
19	1.1643	1.1088	1.1827	1.0719	1.2012	1.2012	1.2012
20	1.1827	1.1827	1.2012	1.1827	1.2567	1.2012	1.2197
21	1.2197	1.2382		1.2936	1.3306		1.2567
22	1.386	1.3491	1.4045	1.5154	1.4415	1.2936	1.4045
23	1.5339	1.5893		1.6263	1.7556	1.6632	1.5708
24	1.386	1.4415	1.5708	1.5893	1.5708	1.6632	1.7002
Max	1.5339	1.5893	1.5708	1.6263	1.7556	1.6632	1.7002
Min	.9055	.8686	.8871	.8962	.8686	.8686	.9979
Avg	1.1503	1.1525	1.1735	1.1810	1.2400	1.1868	1.2461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11KV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.7372	1.7924	1.7741	1.848	1.7193	1.829
2	1.6644	1.6263	1.6644	1.6461	1.7002	1.6095	1.6644
3	1.5364	1.4415	1.5729	1.5546	1.5524	1.4815	1.5181
4	1.39	1.3306	1.4632	1.4632	1.4784	1.4266	1.3717
5	1.2803	1.3676	1.3717	1.5181	1.4415	1.4632	1.3535
6	1.3169	1.4415	1.5364	1.5729	1.5524	1.5546	1.4266
7	1.3169	1.4784		1.3717	1.4784		1.5729
8	1.4266	1.4266	1.3535	1.39	1.4266	1.4266	
9	1.3169	1.4266		1.39	1.4266	1.5546	1.4083
10	1.5729	1.5546	1.6827	1.957	1.6095	1.6095	1.5729
11	1.6632		1.6644	2.0513			1.6078
12	1.7002	1.5912	1.5912	1.9774	1.5912	1.5912	1.6632
13	1.7002	1.5181	1.5729	1.885	1.5364	1.6095	1.7372
14	1.6632			2.0328			1.8111
15	1.7002	1.701	1.7558	2.1992	1.7741	1.7741	1.8665
16	1.6632		1.7741	1.7002	1.7741		1.848
17	1.7372	1.6461		1.7372	1.7924	1.7193	1.8111
18	1.6827	1.701	1.7193	1.7375	1.7924		1.829
19	1.7375	1.7924	1.9753	1.7741	1.9204	1.8473	1.8473
20	1.7924	1.7924	1.9204	1.8473	1.8839	1.8656	1.9204
21	1.829	1.8839		1.9387	2.0485		1.9753
22	1.848	1.8473	1.957	1.9204	1.9753	1.957	2.0328
23	1.8839	1.9387	1.9387	1.9936	2.0302	1.9387	1.9753
24	1.829	1.829	1.9204	1.829	1.9022	1.8656	1.9753
Max	1.8839	1.9387	1.9753	2.1992	2.0485	1.957	2.0328
Min	1.2803	1.3306	1.3535	1.3717	1.4266	1.4266	1.3535
Avg	1.6261	1.6225	1.6961	1.7609	1.7061	1.6674	1.7225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 209 / 11KV SEAWOODS PH-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121	1.2696	1.4045	1.386	1.4377	1.4969	1.4969
2	1.1827	1.1576	1.2936	1.3121	1.3443	1.3306	1.386
3	1.0719	1.0829	1.2012	1.1827	1.2696	1.1643	1.2567
4	.9795	1.0082	1.1088	1.0534	1.1949	1.0719	1.1273
5	.924	.9335	.9979	.9425	1.1576	.961	.9979
6	.924	1.0829	1.1088	1.0164	1.0829	1.1088	1.0349
7	.9425	1.1763		1.1458	1.1763		.9979
8	.8316	.9335	.924	1.0164	1.0829	1.0534	.9795
9	.8871	.8962		.8501	.8775	.8871	.924
10	.8501	.8775		.8871	.9149	.924	.961
11	.9896		.8871	.8775			.9522
12	.9896	.8871	.8686	.8962	.8871	.8871	1.0269
13	.9896	.924		.9335	.924	.961	1.1203
14	1.0642			1.0082			1.1576
15	1.1203	.9795	1.0719	1.0829	1.0719	1.0534	1.1949
16	1.1203		1.0349	1.1203	1.0719		1.1576
17	1.1576	1.0164		1.1203	1.0534	1.0534	1.1763
18	1.1203	.9795	.961	1.0829	1.0534		1.1203
19	1.1016	.9979	1.0349	1.0269	1.0719	1.0349	1.0642
20	1.1016	1.0349	1.0349	1.0456	1.0719	.9425	1.0829
21	1.1016	1.1273		1.0829	1.1827		1.1389
22	1.251	1.2936	1.2936	1.2883	1.2936	1.1827	1.2696
23	1.419	1.5893	1.4969	1.531	1.5708	1.4784	1.4937
24	1.3491	1.3443	1.4969	1.4415	1.4937	1.6078	1.5708
Max	1.419	1.5893	1.4969	1.531	1.5708	1.6078	1.5708
Min	.8316	.8775	.8686	.8501	.8775	.8871	.924
Avg	1.0742	1.0758	1.1306	1.0971	1.1493	1.1222	1.1537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 210 / 11KV SEAWOODS PH-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18
HR	Load (MW)
10	1.5181
Max	1.5181
Min	1.5181
Avg	1.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 201 / 11 KV Stn T/F Wadhva
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	10-APR-18
HR	Load (MW)
17	.0183
Max	.0183
Min	.0183
Avg	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 202 / 11 KV Juinagar sec 25

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.267	1.267	1.267	1.2308	1.3032	1.3394
2	1.2308	1.2127	1.267	1.2127	1.1765	1.2308	1.3032
3	1.1403	1.1403	1.2127	1.1584	1.0317	1.1584	1.267
4	1.1403	1.086	1.1765	1.086	.9955	1.086	1.267
5	1.1584	1.0317	1.1584	.9774	.9955	.9955	1.1584
6	1.1584	.9593	1.086	.9231	.9774	.9412	.9412
7	.905	.9412	.9231	.9593	.9774	.905	.8507
8	.9593	1.0136	1.0679	1.0317	1.1222	.9955	1.0498
9	.9412	.905	.8869	.905	.9231	.9955	.9774
10	.8869	.7602	.7783	.8145	.724	.7964	.9231
11	.8507	.6516	.6878	.724	.7059	.7059	.7602
12	.724	.6516	.6697	.6516	.6878	.6697	.724
13	.7059	.6516	.6335	.6154	.6878	.6878	.7602
14	.7602	.6878	.6697	.6697	.6878	.724	.7964
15	.7783	.6516	.6878	.7059	.7421	.724	.7964
16	.7964	.6516	.7059	.7059	.7059	.6878	.724
17	.7421	.6697	.6878	.6878	.6878	.6697	.724
18	.724	.6335	.6697	.7964	.6697	.6878	.7602
19	.9231	.8507	.8688	.8688	.905	.9412	.9955
20	1.086	1.0498	1.086	1.1222	1.1041	1.1222	1.1765
21	1.1765	1.2308	1.1584	1.1584	1.1765	1.2308	1.2308
22	1.1946	1.3394	1.1765	1.2489	1.2127	1.267	1.2127
23	1.2489	1.267	1.3394	1.3756	1.3937	1.4118	1.448
24	1.267	1.3213	1.3213	1.3394	1.3213	1.3756	1.4118
Max	1.267	1.3394	1.3394	1.3756	1.3937	1.4118	1.448
Min	.7059	.6335	.6335	.6154	.6697	.6697	.724
Avg	.9887	.9427	.9661	.9585	.9518	.9714	1.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 203 / 11 KV E type Wadhva

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7842	.6908	.7842	.7282	.7842	.7468
2	.5975	.7468	.6535	.7468	.6908	.7468	.6908
3	.5975	.7095	.6722	.7095	.5975	.7095	.6348
4	.6161	.6722	.6722	.6722	.6348	.6722	.6535
5	.6161	.6348	.5975	.5975	.6348	.6535	.6535
6	.5975	.6348	.5975	.6348	.5788	.6535	.5601
7	.5415	.5601	.5788	.6722	.5788		.5041
8	.5415	.5975	.5228	.6161	.5788	.5975	.5041
9	.6535	.5975	.5975	.5975	.5788	.6348	.5601
10	.5601	.5228	.5975	.6535	.5415	.6161	.6722
11	.5601	.4854	.5601	.5228	.5788	.5228	.6722
12	.6535	.4481	.5415	.5228	.4668	.5228	.5601
13	.5975	.4108	.5041	.4294	.4668	.5041	.6348
14	.6535	.5601	.5415	.5415	.6161	.6161	.7095
15	.7842	.4854	.6348	.6161	.6722	.6161	.7095
16	.7095	.5041	.6722	.5415	.6722	.7282	.6908
17	.6908	.5975	.6722	.5788	.5788	.6348	.6161
18	.6535	.5041	.5788	.5601	.6348	.6348	.5601
19	.5788	.5601	.6161	.5788	.6535	.6722	.5975
20	.6535	.6348	.7282	.6535	.8029	.6908	.6722
21	.7282	.8326	.7655	.7468	.7282	.8402	.6908
22	.7468	.7655	.8215	.9149	.8589	.8029	.6908
23	.7468	.8589	.8962	.8589	.8775	.8215	.8402
24	.7095	.8215	.7468	.8215	.7842	.8215	.8029
Max	.7842	.8589	.8962	.9149	.8775	.8402	.8402
Min	.5415	.4108	.5041	.4294	.4668	.5041	.5041
Avg	.6434	.6220	.6442	.6488	.6473	.6738	.6511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-4 Nerul

Feeder No / Name : 204 / 11 KV Great Eastern

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.7372	1.7002	1.7551	1.6991	1.8671	1.7924
2	1.419	1.6817	1.6263	1.6991	1.6057	1.7924	1.6804
3	1.419	1.6078	1.6263	1.6244	1.475	1.6804	1.587
4	1.3443	1.5524	1.5684	1.5684	1.419	1.587	1.531
5	1.307	1.4969	1.531	1.4937	1.3817	1.4937	1.475
6	1.307	1.4045	1.4563	1.419	1.3817	1.419	1.4003
7	1.0456	1.2197	1.307	1.2883	1.307	1.307	1.1949
8	1.1949	1.3306	1.307	1.2883	1.3256	1.3443	1.2696
9	1.2136	1.3676	1.4563	1.3443	1.307	1.475	1.3443
10	1.2696	1.5524	1.419	1.419	1.531	1.5497	1.475
11	1.1949	1.5339	1.475	1.4937	1.6244	1.4563	1.4377
12	1.2883	1.4969	1.475	1.531	1.4377	1.4563	1.419
13	1.2696	1.4784	1.4003	1.5123	1.4563	1.4563	1.4563
14	1.2696	1.4784	1.419	1.419	1.6057	1.5684	1.587
15	1.3256	1.423	1.4937	1.531	1.4937	1.5497	1.4937
16	1.251	1.4415	1.4003	1.587	1.4937	1.4937	1.4563
17	1.251	1.4969	1.4377	1.3817	1.4937	1.475	1.307
18	1.1949	1.2936	1.3443	1.3817	1.363	1.3443	1.2323
19	1.3817	1.2936	1.4937	1.4003	1.4377	1.4563	1.4937
20	1.5497	1.423	1.643	1.6057	1.587	1.6057	1.5497
21	1.5684	1.6448	1.6991	1.5123	1.7177	1.6057	1.587
22	1.7364	1.7002	1.7551	1.7924	1.7737	1.6804	1.6617
23	1.7926	1.848	1.9044	1.9418	1.9605	2.0165	1.9418
24	1.587	1.8111	1.7741	1.8298	1.8298	1.9605	1.9231
Max	1.7926	1.848	1.9044	1.9418	1.9605	2.0165	1.9418
Min	1.0456	1.2197	1.307	1.2883	1.307	1.307	1.1949
Avg	1.3614	1.5131	1.5297	1.5341	1.5295	1.5684	1.5123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 202 / RHYAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0366	.0366	.0316	.0297	.0366	.0316
2	.0316	.0366	.0366	.0316	.0297	.0366	.0316
3	.0316	.0366	.0366	.0316		.0366	.0316
4	.0316	.0366	.0366	.0316	.0297	.0366	.0316
5	.0316	.0366	.0366	.0316		.0366	.0316
6	.0316	.0366	.0366	.0316	.0297	.0366	.0316
7	.0316	.0366	.0366	.0316	.0297	.0366	.0316
8	.0316	.0366	.0366	.0316	.0297	.0366	.0316
9	.0366	.0366	.0366	.0474	.0297	.0366	.0474
10	.0366	.0549	.0474	.0446	.0366	.0474	.0446
11	.0366	.0549	.0474	.0446	.0366	.0474	.0446
12	.0366	.0549	.0474	.0446	.0549	.0474	.0297
13	.0366	.0732	.0474	.0297	.0732	.0474	.0446
14	.0366	.0549	.0474	.0297	.0566	.0474	.0446
15	.0366	.0549	.0474	.0297	.0549	.0474	.0446
16	.0366	.0366	.0474	.0297	.0549	.0474	.0446
17	.0366	.0366	.0316	.0297	.0366	.0474	.0297
18	.0366	.0366	.0316		.0366	.0316	.0446
19	.0366	.0366	.0316	.0297	.0366	.0316	.0446
20	.0366	.0366	.0316	.0297	.0366	.0316	.0446
21	.0366	.0366	.0316	.0297	.0366	.0316	.0446
22	.0366	.0366	.0316	.0297	.0377	.0316	.0297
23	.0366	.0366	.0316	.0297	.0366	.0316	.0297
24	.0316	.0366	.0366	.0316	.0297	.0366	.0316
Max	.0366	.0732	.0474	.0474	.0732	.0474	.0474
Min	.0316	.0366	.0316	.0297	.0297	.0316	.0297
Avg	.0347	.0419	.0383	.0332	.0392	.0390	.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 204 / NCRD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	1.9204	2.0302	2.1472	2.3101	2.0302	2.2032
2	1.8671	1.8107	1.7741	1.8671	2.2546	1.9022	2.0538
3	1.7737	1.5181	1.6095	1.6804	2.1992	1.7924	1.8671
4	1.587	1.46	1.4632	1.587	2.0513	1.6827	1.7737
5	1.4003	1.39	1.4083	1.4937	1.848	1.5546	1.6804
6	1.419	1.4632	1.4815	1.6032	1.7372	1.6644	1.587
7	1.4377	1.5181	1.5546	1.643	1.5708		1.5123
8	1.4563	1.4998	1.4632	1.5497	1.6817	1.5912	1.587
9	1.5546	1.5181	1.5546	1.587	1.6632	1.6827	1.643
10	1.6827	2.0485	2.0538	1.922	1.9204	1.9791	1.8111
11	1.8473	2.2497	2.4272	2.3101	2.3594	2.3339	2.1992
12	1.8656	2.3045	2.5206	2.4579	2.4143	2.5019	2.2546
13	1.9936	2.3594	2.4646	2.4949	2.5057	2.5393	2.3655
14	1.8473	2.1948	2.4086	2.4394	2.4874	2.4272	2.5318
15	2.0119	2.3228	2.5393	2.5133	2.4874	2.4832	2.4394
16	2.0302	2.2862	2.5206	2.4764	2.5652	2.4832	2.4394
17	2.0485	2.1948	2.5019	2.4394	2.4508	2.4832	2.2177
18	1.9022	2.2497	2.2965	2.2916	2.3594	2.4646	2.2177
19	2.1582	2.2862	2.3152	2.3101	2.3777	2.3339	2.3655
20	2.1582	2.2497	2.3152	2.3101	2.268	2.3152	2.2731
21	2.1948	2.0668	2.2965	2.2177	2.268	2.2592	2.2177
22	2.1399	2.1216	2.3339	2.2916	2.2314	2.3339	2.2731
23	2.1582	2.3411	2.4646	2.3655	2.3228	2.4832	2.2916
24	2.2218	2.2862	2.268	2.2965	2.347	2.3045	2.4086
Max	2.2218	2.3594	2.5393	2.5133	2.5652	2.5393	2.5318
Min	1.4003	1.39	1.4083	1.4937	1.5708	1.5546	1.5123
Avg	1.8632	1.9859	2.0861	2.0956	2.1950	2.1576	2.0922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 205 / Navdurga S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9694	1.0425	1.1203	1.0608	1.0242	1.0829
2	.8962	.8962	.8962	1.0269	1.0059	.9328	1.0269
3	.7468	.823	.7499	.9335	.9694	.8596	.9335
4		.7499	.695	.8402	.9145	.7865	.8402
5	.5544	.6767	.6401	.7468	.823	.7316	.7468
6	.5544	.6401	.7133	.7207	.7316	.7682	.7095
7	.6161	.6584	.6767	.7207	.6767	.7316	.6535
8	.5788	.6767	.6401	.6838	.6584	.695	.6161
9	.6219	.6584	.6401	.6653	.6584	.6584	.6348
10	.6401	.7133	.7468	.7316	.7133	.7842	.7316
11	.7316	.7316	.7468	.695	.7316	.7468	.7682
12	.7499	.6584	.7468	.7316	.695	.7468	.7865
13	.695	.6219	.7468	.695	.7316	.7655	.8048
14	.7316	.6584	.7468	.6767	.8048	.8215	.8779
15	.7133	.6584	.8215	.7316	.7682	.8029	.8962
16	.7316	.6401	.7468	.7316	.7682	.8029	.8779
17	.7316	.6584	.6722	.7133	.8048	.8029	.823
18	.7133	.6584	.6908	.6584	.7133	.7207	
19	.7865	.7316	.8029	.7316	.7682	.8029	.7682
20	.7682	.823	.8775	.7682	.8413	.8589	.8779
21	.8048	.8048	.8962	.8779	.8779	.9709	.9145
22	.8779	.9511	.9896	.9511	.9511	.9709	.9145
23	1.0425	1.0242	1.1576	1.0974	1.1157	1.1763	1.0608
24	1.0829	1.0608	1.0974	1.1576	1.0974	1.1523	1.1576
Max	1.0829	1.0608	1.1576	1.1576	1.1157	1.1763	1.1576
Min	.5544	.6219	.6401	.6584	.6584	.6584	.6161
Avg	.7539	.7560	.7992	.8086	.8284	.8381	.8480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 206 / 11 KV DY Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8048	.9328	.9335	.8676	.9145	.8775
2	.7095	.7499	.8962	.8962	.7733	.8417	
3	.6468	.695	.8413	.8402	.7167	.7865	.8402
4	.6468	.6401	.8048	.7468	.7356	.7316	.8962
5	.7095	.6979	.7316	.8402	.8299	.6767	.9335
6	.7468	.811	.7865	.8962	.9431	.7499	.9335
7	.8402	.8779	.9412	.9335	.9619	.8779	.9522
8	.8589	1.0608	1.0608	1.251	1.1506	1.0059	.9896
9	.9054	1.39	1.3535	1.419	1.3769	1.3535	.9335
10	1.0059	1.7741	1.8484	1.7541	1.7558	1.7364	.9997
11	1.0608	1.8839	1.9418	1.9239	1.7741	1.9418	1.0562
12	1.0791	1.9387	1.9231	1.9427	1.7924	1.9418	1.0751
13	.9694	1.829	1.8298	1.9427	1.7375	1.8671	1.0751
14	.8779	1.829	1.9418	1.828	1.8107	1.8671	1.0562
15	.9877	1.8839	1.9418	1.9616	1.829	1.8671	1.2071
16	.8962	1.7558	1.8671	1.8673	1.6827	1.7737	1.1128
17	.8413	1.6461	1.7177	1.7164	1.4998	1.6617	1.0562
18	.823	1.3717	1.419	1.4335	1.2986	1.2883	1.0185
19	.8048	1.1888	1.2883	1.2071	1.134	1.1576	.9619
20	.8048	1.1157	1.0642	1.0562	1.0425	1.0642	.9997
21	.7865		.9522	.9808	.8962	1.0456	.9808
22	.7865	.9511	.9709	1.0562	.9328	.9709	.9054
23	.8048	.8779	.9522	.9619	.8779	.9709	.9054
24	.8215	.9145	.8413	.9709	.9054	.9145	.9149
Max	1.0791	1.9387	1.9418	1.9616	1.829	1.9418	1.2071
Min	.6468	.6401	.7316	.7468	.7167	.6767	.8402
Avg	.8400	1.2473	1.2853	1.3067	1.2219	1.2503	.9861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 207 / 11 KV Brahmakumari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9978	1.9753	1.957	2.0538	2.1719	2.0485	2.1472
2	1.8671	1.7741	1.7375	1.8671	2.1176	1.8839	1.9978
3	1.6804	1.6644	1.6278	1.7737	2.0814	1.7741	1.8671
4	1.4937	1.5912	1.5364	1.531	1.9366	1.6278	1.7737
5	1.4563	1.5546	1.4998	1.587	1.8099	1.5912	1.6804
6	1.4003	1.4632	1.5546	1.643	1.6651	1.6095	1.587
7	1.475	1.4815	1.5181	1.587	1.5023	1.5546	1.4937
8	1.419	1.39	1.4266	1.5497	1.5123	1.5364	1.475
9	1.4998	1.4632	1.4632	1.5123	1.4842	1.5912	1.587
10	1.39	1.4266	1.4937	1.448	1.4449	1.4937	1.5203
11	1.4998	1.4632	1.5497	1.4661	1.4632	1.587	1.5927
12	1.4998	1.4998	1.531	1.448	1.4998	1.5684	1.5203
13	1.4632	1.3717	1.475	1.3937	1.4998	1.5123	1.647
14	1.4998	1.39	1.4563	1.4661	1.4998	1.643	1.6832
15	1.6095	1.5655	1.5684	1.5203	1.6095	1.6244	1.7375
16	1.5729	1.3717	1.531	1.5023	1.6278	1.5684	1.647
17	1.4632	1.4266	1.4937	1.4842	1.4998	1.475	1.5746
18	1.4266	1.3717	1.4563	1.4661	1.4998	1.5497	1.5384
19	1.6461	1.6827	1.7924	1.6108	1.701	1.6991	1.6108
20	1.701	1.829	1.9044	1.7918	1.8656	1.9231	1.7737
21	1.7193	1.7558	1.9418	1.8461	1.9387	1.8858	1.8099
22	1.9204	1.9022	2.0725	1.9004	2.1033	2.0165	1.8099
23	2.0485	2.1399	2.3339	2.19	2.3045	2.2965	2.2624
24	2.1658	2.1033	2.268	2.2965	2.2624	2.2862	2.3339
Max	2.1658	2.1399	2.3339	2.2965	2.3045	2.2965	2.3339
Min	1.39	1.3717	1.4266	1.3937	1.4449	1.475	1.475
Avg	1.6215	1.6107	1.6745	1.6640	1.7542	1.7228	1.7363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 208 / 11 KV Anand Vaibhav Garden

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4938	.4572	.4854	.5601	.5304	.5415
2	.4294	.4024	.4207	.4481	.5228	.4207	.5228
3	.3734	.3475	.3841	.4108	.4668	.3658	.4481
4	.3361	.3109	.3841	.3734	.3734	.3109	.3734
5	.3361	.2561	.3475	.3361	.3547	.3109	.3361
6	.2772	.2926	.3109	.3361	.2987	.2926	.2402
7	.2772	.2926	.2743	.3174	.2614	.3292	.2402
8	.2957	.3475	.3109	1.475	.2801	.3658	.2772
9	.2743	.2926	.2743	1.531	.2614	.2743	.3361
10	.3292	.2926	.3174	1.7551	.2743	.2772	.3361
11	.3475	.2561	.3174	1.6991	.3292	.3142	.3174
12	.3658	.2743	.3361	1.4563	.2926	.3142	.3921
13	.3475	.2743	.3547	.2801	.3292	.3734	.3734
14	.3658	.3658	.3174	.2987	.3292	.3361	.4294
15	.3658	.3292	.4108	.3547	.3292	.3921	.4108
16	.3109	.2926	.3734	.3174	.3475	.3734	.3921
17	.3109	.2743	.2987	.2801	.2926	.3361	.3734
18	.3109	.2743	.3361	.3361	.3109	.3547	.3734
19	.3658	.4207	.4294	.3921	.3841	.4481	.4294
20	.3841	.4024	.4294	.3734	.4207	.4294	.4481
21	.4207	.4024	.4108	.4481	.439	.4854	.4481
22	.3841	.4572	.4481	.4294	.4207	.4108	.3921
23	.4755	.4755	.5228	.4854	.5121	.5601	.5415
24	.5041	.5304	.5121	.5228	.5788	.5487	.5601
Max	.5041	.5304	.5228	1.7551	.5788	.5601	.5601
Min	.2743	.2561	.2743	.2801	.2614	.2743	.2402
Avg	.3606	.3483	.3741	.6309	.3737	.3814	.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284051 / 33/11KV SBI S/Stn

Feeder No / Name : 201 / 11KV SBI I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.6468	.5359	.5729	.5729	.6653	.6653
2	.6468	.6653	.5359	.5544	.5544	.5729	.6653
3	.5729	.6468	.499	.6099	.5914	.5544	.5729
4	.6099	.6283	.5359	.5359	.6099	.5359	.5544
5	.5544	.5544	.5175	.5175	.5729	.5175	.5359
6	.5175	.5729	.5359	.5544	.5544	.5359	.5544
7	.5359	.5359	.5359	.5729	.5359	.4805	.5729
8	.4435	.5729	.4805	.6099	.6283	.5544	.5914
9	.6099	.5544	.5544	.5729	.6099	.5729	.5729
10	.5729	.4805	.5729	.5544	.4435	.5359	.5228
11	.5359	.462	.499	.5544		.5544	.5359
12	.5175	.4435	.4805	.4805		.499	.5175
13	.5729	.4435	.499	.462	.4435	.462	.499
14	.4805	.4251	.4251	.462	.462	.462	.5175
15	.499	.4251	.462	.4435	.4805	.4435	.5729
16	.4805	.4066	.5175	.4435	.499	.4805	.5359
17	.4435	.3696	.499	.4805	.499	.4805	.5544
18	.4435	.4251	.462	.462	.5175	.462	.5729
19	.6283	.5175	.499	.5914	.5729	.5729	.5914
20	.6283	.5914	.5359	.5729	.5544	.5914	.6283
21	.6283	.6099	.5914	.6099	.6468	.5544	.7023
22		.5729	.6099	.6283	.6838	.6653	.6653
23		.5359	.7392	.6838		.7392	.7023
24	.6838	.6468	.7023	.7023	.7023	.7762	.7762
Max	.6838	.6653	.7392	.7023	.7023	.7762	.7762
Min	.4435	.3696	.4251	.4435	.4435	.4435	.499
Avg	.5578	.5305	.5344	.5513	.5588	.5529	.5908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 301 / 22KV Feeder No 1- Fugro SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286			.3048	.2667	
2	.2667	.1905	.2286		.3048	.2667	
3	.2667	.1905	.2286		.3048	.2286	
4	.2286	.1905	.2286		.3048	.2286	
5	.2286	.1905	.2286		.2667	.1905	
6	.2286	.1905	.1905		.2667	.1905	
7	.2286	.1905	.1905		.2667	.2286	
8	.2286	.1905	.1905		.2667	.2667	
9	.2286	.2667	.2286	.2667	.3048	.2667	
10	.2667	.3429	.3429		.3429	.4191	
11	.3048	.4572	.4954	.8764	.4954	.4191	
12	.3048	.381		.4572	.4572	.4572	
13	.3048	.4191	.4954	.4572	.4572	.4572	
14	.2667	.4572		.381	.381		
15	.2667	.4572		.4954	.4954	.5335	
16	.2286	.4191		.4191	.4191		
17	.2286			.4572	.4191		
18	.2286			.3429	.3429	.381	
19	.1905			.3048	.3048		
20	.1905			.2667			
21	.2286			.1143			
22	.2286			.2667			
23	.2286			.2667			
24	.2286	.2286	.2286	.2667	.3048	.2667	.3048
Max	.3048	.4572	.4954	.8764	.4954	.5335	.3048
Min	.1905	.1905	.1905	.1143	.2667	.1905	.3048
Avg	.2429	.2936	.2731	.3759	.3505	.3167	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 302 / 22KV Feeder No2- Vilaxmi- SHEDDABLE FEEDER HAVING WEEKLY
 Hari Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3336	1.2955		1.4861	1.3336	
2	1.4098	1.2574	1.2574		1.4861	1.3717	
3	1.2574	1.1812	1.2574		1.3336	1.3336	
4	1.2193	1.0669	1.2193		1.2193	1.2574	
5	1.1431	.9526	1.2193		1.1431	1.1812	
6	1.1812	.9145	1.1812		1.105	1.0669	
7	1.1431	.8383	1.1431		1.105	.9526	
8	1.105	.8383	1.105		1.105	1.105	
9		1.0288	1.2955		1.2193	1.1812	
10	.9907	1.2193	1.5623		1.6004	1.5623	
11	1.0669	1.829	1.9052	1.9433	1.9433	1.6766	
12	1.105	1.9052		1.9052	1.9052	1.8671	
13	1.2193	2.0195		1.9052		1.829	
14	1.2193	1.9814		1.7909			
15	1.0288	1.9052		2.0576	2.0576	1.8671	
16	.9907	1.829		1.9052	1.9052		
17	.9526			1.8671	1.9814		
18	.8764			1.8671	1.7909	1.6766	
19	.8002			1.5242	1.5242		
20	.8383			1.2574			
21	.8764			.9526			
22	.9145			.9526			
23	1.3717			1.0288			
24	1.3336	1.3717	1.3336	1.3336	1.4861	1.4098	1.5623
Max	1.4098	2.0195	1.9052	2.0576	2.0576	1.8671	1.5623
Min	.8002	.8383	1.105	.9526	1.105	.9526	1.5623
Avg	1.105	1.3807	1.3146	1.5922	1.5220	1.4170	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 303 / 22KV Feeder No3- Dy. Patil SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4572		.5335	.4572	
2	.4191	.381	.4954		.5335	.381	
3	.5335	.381	.4954		.4954	.3429	
4	.4954	.4572	.4954		.4954	.3048	
5	.4572	.4954	.4572		.4572	.3429	
6	.4572	.4954	.4572		.4954	.381	
7	.381	.4954	.4954		.5716	.381	
8	.3429	.4954	.5335		.5716	.4572	
9		.5716	.6097	.6478	.724	.6097	
10	.381		.724		.6859	.6859	
11	.4191		.7621	.7621	.7621	.6859	
12	.4954			.7621	.7621	.6859	
13	.4191		.6859	.8002	.8002	.6859	
14	.3429			.8002	.8002		
15	.4572			.7621	.7621	.7621	
16	.4191			.8002	.8002		
17	.4191			.724	.8002		
18	.4572			.8002	.8764	.6478	
19	.3048			.6859	.6097		
20	.3048			.5716			
21	.3429			.5335			
22	.3429			.4954			
23	.3048			.5716			
24	.3048	.3048	.4572	.4572	.5716	.4954	.4954
Max	.5335	.5716	.7621	.8002	.8764	.7621	.4954
Min	.3048	.3048	.4572	.4572	.4572	.3048	.4954
Avg	.3976	.4420	.5481	.6783	.6554	.5192	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 304 / 22KV Feeder No4- Lalit SHEDDABLE FEEDER HAVING WEEKLY
Vitessi Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7621	.7621		.7621	.7621	
2	.5716	.7621	.8002		.7621	.6478	
3	.6859	.6859	.8002		.7621	.7621	
4	.6097	.6097	.8383		.724	.6859	
5	.6478	.6859	.9145		.6859	.6097	
6	.6478	.8383	.9526		.724		
7	.6859	.9145	.9907		.8764	.6478	
8	.7621	.9526	.9907		1.0288	.7621	
9		1.1431	1.105	1.2574	1.2193	.9526	
10	.8002		1.1812		1.2955	1.1431	
11	.8002		1.4098	1.5242	1.5242	1.1812	
12	.8383			1.4098	1.4098	1.2193	
13	.8764		1.2955	1.3336	1.3336	1.105	
14	.8764			1.4861	1.4861		
15	.9145			1.5242	1.5242	1.1431	
16	.8383			1.448	1.448		
17	.8764			1.2955	1.3717		
18	.7621			1.1812	1.1431	1.0288	
19	.6859			1.0669	1.0288		
20	.6478			.9907			
21	.6478			.8002			
22	.6097			.9145			
23	.6478			.7621			
24	.724	.6478	.7621	.7621	.7621	.8383	.6859
Max	.9145	1.1431	1.4098	1.5242	1.5242	1.2193	.6859
Min	.5716	.6097	.7621	.7621	.6859	.6097	.6859
Avg	.7290	.8002	.9848	1.1838	1.0936	.8993	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 305 / 22KV Feeder No5- Jaspal - SHEDDABLE FEEDER HAVING WEEKLY
 Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.5242	1.6385		1.6385	1.7147	
2	1.3336	1.4098	1.5623		1.6004	1.5623	
3	1.4861	1.448	1.5242		1.5242	1.448	
4	1.4098	1.3336	1.5623		1.448	1.4098	
5	1.448	1.4098	1.5623		1.3336	1.4861	
6	1.5623	1.4861	1.6004		1.5242		
7	1.7147	1.6766	1.6385		1.7528		
8	1.4861	1.7909	1.6385		2.0195	1.5623	
9		1.7909	1.829	2.1338	1.7909	1.448	
10	1.6766		1.9433		2.21	2.2862	
11	1.7147		2.0576	2.3243	2.3243	2.2481	
12	1.7528			2.5149	2.5149	2.2862	
13	1.6385		2.2862	2.8197	2.8197	2.2862	
14	1.7528			2.7435	2.7435		
15	1.8671			2.8197	2.8197	2.2862	
16	1.7147			2.7054	2.7054		
17	1.7147			2.2481	2.3624		
18	1.6766			1.9433	2.0957	1.9814	
19	1.5242			1.9052	1.7909		
20	1.448			1.6766			
21	1.3336			1.5623			
22	1.2574			1.5623			
23	1.5242			1.6385			
24	1.4861	1.5623	1.6766	1.7147	1.6766	1.7909	1.5623
Max	1.8671	1.7909	2.2862	2.8197	2.8197	2.2862	1.5623
Min	1.2574	1.3336	1.5242	1.5623	1.3336	1.4098	1.5623
Avg	1.5573	1.5432	1.7323	2.1542	2.0348	1.8426	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 306 / 22KV Feeder No6- Elder - SHEDDABLE FEEDER HAVING WEEKLY
 Geldop Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048			.2667	.2286	
2	.2286	.2667			.2667	.2286	
3	.2286	.2667			.2667	.1905	
4	.2286	.2286			.2286	.1905	
5	.2667	.2286			.2286	.2286	
6	.2667	.2286			.2286		
7	.2667	.2667			.2667	.2667	
8	.2667	.2667			.2667	.2667	
9	.2667	.2667		.3429	.3048	.2667	
10	.381				.381	.3048	
11	.4191			.4572	.4572	.3048	
12	.4572			.4191	.4191	.3048	
13	.4191		.3429	.4572	.4572	.3048	
14	.4572			.381	.381		
15	.4572			.381	.381	.3048	
16	.381			.4191	.4191		
17	.3429			.3429	.4191		
18	.3429			.4191	.4191	.3048	
19	.2667			.381	.4191		
20	.2667			.3048			
21	.2667			.2667			
22	.2667			.2286			
23	.2667			.2286			
24	.2286	.3048		.2286	.2667	.2286	.2667
Max	.4572	.3048	.3429	.4572	.4572	.3048	.2667
Min	.2286	.2286	.3429	.2286	.2286	.1905	.2667
Avg	.3112	.2629	.3429	.3505	.3372	.2616	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.8916	1.1088	1.0242	.9431	.9259	1.2803
2	.9877	.7716	1.0164	.9511	.823	.9774	1.134
3	.823	.7202	.924	.8048	.7202	.9259	.9877
4	.7499	.6001	.8871	.695	.6001	.703	.823
5	.695	.5487	.8316	.6584	.5487	.6001	.695
6	.6401	.5658	.7762	.695	.5487	.5487	.6401
7	.5487	.583	.7392	.6584	.5658	.583	.567
8	.6219	.5144	.6283	.6036	.5316	.5487	.6401
9	.5487	.5144	.5914	.6584	.5658	.6001	.7133
10	.6001	.5658	.7023	.7682	.6344	.6001	.7865
11	.7202	.6283	.7133	.6859	.7023	.6859	.7316
12	.6687	.6468	.6767	.6516	.7023	.6001	.7865
13	.583	.6468	.6036	.5658	.6838	.5487	.7133
14	.6001	.6468	.5853	1.2567	.7023	.6344	.7682
15	.6687	.7392	.7316	.6687	.7392	.703	.823
16	.6516	.7577	.7682	.6516	.7577	.7499	.7202
17	.6173	.6468	.7682	.6516	.7577	.7316	.6859
18	.6173	.6283	.6584	.583	.7392	.7316	.7202
19	.6344	.6468	.7133	.6859	.7762	.7133	.7545
20	.6516	.6838	.7499	.6859	.7762	.7682	.7373
21	.6687	.8316	.8779	.8059	.6859	.7865	.7888
22	.8916	1.0164	.9877	.9259	.6344	.9511	.9774
23	.9774	1.1643	1.0974	1.0631	1.0288	1.1706	.9774
24	.9877	.9774	1.1273	1.1157	1.0974	1.0974	1.262
Max	.9877	1.1643	1.1273	1.2567	1.0974	1.1706	1.2803
Min	.5487	.5144	.5853	.5658	.5316	.5487	.567
Avg	.7127	.7057	.8027	.7714	.7194	.7452	.8214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1543	.1848	.2195	.1715	.1715	.2012
2	.1646	.1543	.1848	.2195	.1543	.1715	.1829
3	.1463	.1372	.1848	.1829	.1543	.1715	.1463
4	.1463	.12	.1663	.1463	.1372	.1372	.1463
5	.1463	.12	.1663	.1463	.1372	.1372	.1463
6	.1646	.1372	.1663	.1829	.1715	.1543	.1829
7	.1646	.1715	.1478	.1829	.1715	.1715	.2012
8	.1829	.1543	.1478	.1829	.1543	.1543	.1829
9	.1646	.1543	.2033	.1646	.1543	.1543	.1829
10	.1372	.1543	.1848	.1646	.1543	.1543	.1646
11	.12	.1663	.1646	.1543	.1663	.1372	.1463
12	.1372	.1663	.1646	.1543	.1663	.1543	.1646
13	.1372	.1663	.1646	.1543	.1848	.1372	.1829
14	.12	.1663	.1646	.1543	.1715	.1543	.1646
15	.1372	.1663	.1646	.1715	.1715	.1715	.2012
16	.1372	.1663	.1829	.1886	.1715	.1829	.1715
17	.1372	.1663	.2012	.1715	.1715	.1829	.1715
18	.1372	.1848	.1829	.1715	.1715	.1646	.1543
19	.1543	.1848	.1463	.1715	.1715	.1829	.1543
20	.1543	.1848	.1829	.1715	.1886	.1829	.1715
21	.1715	.1848	.1646	.1715	.1715	.1829	.1886
22	.1715	.2033	.2012	.1715	.1543	.1646	.1715
23	.1715	.2402	.2378	.1886	.2058	.1829	.1886
24	.1829	.1715	.2033	.1829	.1886	.1886	.2195
Max	.1829	.2402	.2378	.2195	.2058	.1886	.2195
Min	.12	.12	.1463	.1463	.1372	.1372	.1463
Avg	.1529	.1657	.1776	.1738	.1673	.1645	.1745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2915	.4066	.3841	.2915	.3258	.4024
2	.3292	.2572	.3696	.3292	.2572	.2915	.3292
3	.2926	.2229	.3511	.2926	.2229	.2743	.2743
4	.2561	.2229	.3511	.2195	.2229	.2229	.2378
5	.2012	.2058	.3326	.1829	.2058	.2229	.2378
6	.2195	.2401	.3142	.2561	.2572	.2572	.2743
7	.2195	.2229	.2957	.2561	.2572	.2401	.2743
8	.2743	.2401	.2772	.3109	.2743	.2572	.3292
9	.2378	.3601	.4066	.3658	.3772	.2915	.3658
10	.2572	.5144	.5729	.5487	.4973	.5144	.439
11	.3601	.5914	.6219	.5487	.5914	.5658	.4938
12	.3772	.6468	.6401	.6516	.6468	.6001	.5304
13	.3772	.6653	.6219	.6001	.6838	.6001	.5853
14	.3772	.6838	.5853	.6344	.6468		.5487
15	.3944	.6653	.6584	.6516	.6099	.6173	.5853
16	.3772	.6653	.6584	.6516	.5544	.6401	.5316
17	.3601	.6468	.695	.6001	.5359	.6767	.5316
18	.3429	.5729	.6401	.5658	.4801	.6036	.463
19	.3258	.5544	.6036	.5316	.463	.6036	.463
20	.3772	.5175	.4938	.463	.463	.5121	.4287
21	.3944	.4805	.4572	.4287	.463	.4755	.4115
22	.3944	.499	.4572	.4115	.4973	.4755	.3944
23	.3944	.462	.439	.4287	.4115	.439	.4287
24	.4024	.3429	.4435	.4207	.3944	.3944	.439
Max	.4024	.6838	.695	.6516	.6838	.6767	.5853
Min	.2012	.2058	.2772	.1829	.2058	.2229	.2378
Avg	.3295	.4488	.4872	.4473	.4294	.4392	.4166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 206 / 11 KV MORAJ COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0343	.0381	.0381	.0381
2	.0381	.0343	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381
5	.0381	.0343	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381
7	.0381	.0343	.0381	.0381	.0381
8	.0381	.0343	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381
10	.0343	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0366	.0381	
15	.0381	.0381	.0381	.0381	
16	.0381	.0381	.0381	.0381	
17	.0343	.0381	.0381	.0381	
18	.0381	.0381	.0381	.0381	
19	.0343	.0381	.0381	.0381	
20	.0343	.0381	.0381	.0381	
21	.0381	.0381	.0381	.0381	
22	.0381	.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	
24	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0381
Min	.0343	.0343	.0366	.0381	.0381
Avg	.0374	.0373	.0380	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1715	.2218	.1829	.1715	.1886	.1829
2	.1646	.1372	.2218	.1646	.1372	.1372	.1463
3	.128	.12	.2033	.128	.12	.1543	.1463
4	.1097	.1029	.2033	.1097	.12	.12	.128
5	.1097	.1029	.1848	.1097	.12	.1029	
6	.1097	.1029	.1848	.128	.1372	.12	.128
7	.0914	.12	.1663	.128	.12	.1372	.128
8	.128	.12	.2033	.1463	.1543	.1372	.1829
9	.128	.2915	.2587	.2195	.2743	.2058	.2378
10	.1715	.463	.5544	.5121	.4801	.3772	.3475
11	.2058	.5175	.5304	.4801	.5359	.5144	.4207
12	.2058	.5175	.567	.5144	.5544	.5316	.5487
13	.1886	.5359	.567	.5144	.5729	.4801	.4938
14	.2058	.5359	.6036	.5144	.5316	.5316	.5121
15	.2401	.5175	.6036	.5316	.5487	.5487	.5304
16	.1886	.5175	.6219	.5487	.5487	.5487	.4287
17	.1543	.499	.5304	.4973	.5144	.5853	.3944
18	.1715	.499	.4938	.4115	.4801	.4938	.3429
19	.1886	.4435	.439	.3086	.4287	.439	.2401
20	.2058	.3511	.2012	.2743	.3429	.2926	.2401
21	.1886	.3142	.2743	.2401	.4115	.2561	.1886
22	.1715	.2772	.2561	.2058	.4801	.2195	.2058
23	.2058	.2587	.2378	.2401	.2229	.2561	.2058
24	.2096	.2058	.2402	.2195	.1886	.1886	.0549
Max	.2401	.5359	.6219	.5487	.5729	.5853	.5487
Min	.0914	.1029	.1663	.1097	.12	.1029	.0549
Avg	.1689	.3218	.3570	.3054	.3415	.3153	.2798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada
S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0572	.0762	.0762	.0762
2	.0762	.0572	.0762	.0762	.0572	.0572	.0572
3	.0762	.0572	.0762	.0549	.0572	.0572	.0762
4	.0762	.0572	.0762	.0572	.0572	.0572	.0762
5	.0549	.0762	.0762	.0762	.0762	.0762	.0572
6	.0762	.0762	.0762	.0762	.0762	.0762	.0549
7	.0572	.0762	.0762	.0572	.0762	.0762	.0762
8	.0762	.0762	.0762	.0572	.0762	.0762	.0732
9	.0572	.0762	.0572	.0762	.0762	.0762	.0732
10	.0762	.0762	.0762	.0762	.0762	.0762	.0549
11	.0762	.0762	.0762	.0762	.0762	.0762	.0732
12	.0762	.0762	.0732	.0762	.0762	.0762	.0732
13	.0762	.0762	.0732	.0762	.0762	.0762	.0732
14	.0762	.0762	.0572	.0762	.0762	.0762	.0762
15	.0762	.0762	.0762	.0762	.0762	.0762	.0732
16	.0762	.0762	.0762	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0549	.0762
18	.0762	.0762	.0762	.0762	.0762	.0732	.0762
19	.0762	.0762	.0572	.0762	.0762	.0762	.0762
20	.0762	.0762	.0762	.0762	.0762	.0732	.0762
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0572	.0762	.0572	.0572	.0762	.0732	.0572
23	.0572	.0762	.0762	.0572	.0572	.0762	.0572
24	.0572	.0762	.0762	.0762	.0762	.0762	.0572
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0549	.0572	.0572	.0549	.0572	.0549	.0549
Avg	.0706	.0738	.0728	.0706	.0730	.0726	.0697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0754	.0762	.0762	.0762	.0762	.0762
3	.0762	.0754	.0762	.0762	.0762	.0762	.0762
4	.0762	.0754	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0754	.0762	.0762	.0762	.0762	.0762
7		.0754		.0762		.0762	
8						.0762	
19			.0762	.0762		.0762	.0762
20	.0754	.0762	.0762	.0762		.0762	.0762
21	.0754	.0762	.0762	.0762		.0762	.0762
22	.0754	.0762	.0762	.0762		.0762	.0762
23	.0754	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0754	.0762	.0762	.0762	.0762	.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0754	.0754	.0762	.0762	.0762	.0762	.0762
Avg	.0759	.0758	.0762	.0762	.0762	.0762	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.381	.381	.3429	.4191	.381
2	.3239	.3429	.3429	.3429	.3429	.381	.3429
3	.2858	.3395	.3429	.3429	.3239	.3429	.3048
4	.2667	.3018	.3239	.3239	.3048	.3239	.2858
5	.2477	.2858	.3048	.381	.3048	.3048	.2858
6	.2667	.2858	.3429	.3048	.3239	.3048	.2858
7	.2667	.2829	.381	.3048	.3239	.2667	.3048
8	.2667	.2801	.3429		.2858	.3048	.2858
9	.2667	.2263	.3048	.2667	.2667	.2667	.2667
10	.2858	.2263	.2667	.2858	.2477	.2477	.3239
11	.2829	.2286	.2667	.2667	.2477	.2477	.3048
12	.2614	.2286	.2858	.2667	.2477	.2477	.2667
13	.2829	.2477	.2286	.2858	.2477	.2858	.2858
14	.2829	.2667	.2858	.3048	.2858	.3048	.3239
15	.2829	.2667	.2858	.2858	.2858	.2858	.362
16	.3206	.2667	.2858	.3048	.2858	.2667	
17	.2829	.2667	.2667	.2858	.2286	.2477	.3048
18	.2427	.2477	.2477	.2477	.2667	.2286	.3048
19	.2829	.2477	.2858	.2667	.2477	.2477	.3048
20	.3018	.2667		.2667	.4763	.2667	.3048
21	.2829	.2858	.3239	.2858	.3048	.3429	.3048
22	.3206	.3048	.4001	.3429	.362	.381	.3239
23	.3772	.381	.4763	.4001	.4191	.4001	.4191
24	.381	.4191	.381	.381	.381	.4382	.4191
Max	.381	.4191	.4763	.4001	.4763	.4382	.4191
Min	.2427	.2263	.2286	.2477	.2286	.2286	.2667
Avg	.2919	.2864	.3197	.3098	.3064	.3064	.3172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0953	.0953	.1143	.0762	.0953
2	.0953	.0762	.0953	.0953	.1143	.0762	.0953
3	.0953	.0754	.0762	.0762	.0953	.0762	.0953
4	.0762	.0754	.0762	.0762	.0953	.0762	.0953
5	.0762	.0762	.0762	.0762	.0953	.0762	.0953
6	.0762	.0754	.0762	.0762	.0953	.0762	.0953
7	.0762	.0754	.0953	.0762	.0953	.0762	.0953
8	.0762	.0754	.0953	.0762	.0953	.0762	.0953
9	.0953	.0754	.0953	.0762	.1524	.0762	.0953
10	.0953	.1509	.1524	.1905	.1905	.0953	.1905
11	.0943	.1524	.1143	.1715	.1905	.1334	.1715
12	.0943	.1334	.1334	.1905	.1715	.1715	.1524
13	.0754	.1334	.1143	.1524	.1715	.1715	.1715
14	.0754	.1524	.1524	.1715	.1715	.1715	.1715
15	.0754	.1524	.1524	.1905	.1715	.1715	.1715
16	.0754	.1334	.1524	.1715		.1715	
17	.0747	.1334	.1715	.1334	.0953	.1524	.0953
18	.0754	.0762	.0953	.0953	.0762	.0953	.0953
19	.0754	.0953	.0953	.1143	.0953	.0953	.0953
20	.0754	.0953	.1143	.1143	.0762	.0953	.0953
21	.0754	.0953	.0953	.1143	.0953	.0953	.1143
22	.0754	.0953	.0953	.0953	.0953	.1143	.1143
23	.0754	.0953	.0953	.1143	.0953	.1143	.1143
24	.0953	.0953	.0953	.0953	.1143	.0762	
Max	.0953	.1524	.1715	.1905	.1905	.1715	.1905
Min	.0747	.0754	.0762	.0762	.0762	.0762	.0953
Avg	.0821	.1029	.1088	.1183	.1201	.1088	.1187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4904	.5144	.5144	.5144	.4763	.4954
2	.4763	.4191	.4954	.4954	.4954	.4572	.4763
3	.4572	.381	.4191	.4191	.4763	.4191	.4572
4	.4191	.3429	.381	.381	.4572	.4191	.381
5	.4001	.3772	.381	.4001	.4191	.4382	.4191
6	.4763	.415	.4001	.4001	.4191	.4382	.4572
7	.381	.415	.4763	.4191	.4382	.2667	.4763
8	.4191	.4904	.5716	.4763	.5716	.5906	.5525
9	.4763	.0754	.7049	.8002	.743	.9717	.7049
10	.6668	.9619	.9907	1.0288	1.0288	1.0288	.9145
11	.9054	1.1431	.9907	1.1812	1.1431	1.0669	1.105
12	.9054	1.2003	1.1812	1.2003	1.1812	1.2384	1.1812
13	.7922	1.1431	1.1241	1.1241	1.2003	1.2384	.3239
14	.8002	1.1431	1.2193	1.2384	1.2384	1.2955	1.2003
15	.8299	1.1431		1.3336	1.2574	1.3336	1.0669
16	.9054	1.1622	1.2193	1.2955	1.2955	1.3717	.9526
17	.8775	1.1622	1.2574	1.2384	1.2765	1.3336	1.0288
18	.7922	1.1622	1.105	1.105	1.2955	1.1812	
19	.8299	1.0098	1.1431	.9526	1.3146	1.1431	1.0479
20	.8299	.8764	.8764	.9145	1.0479	.9907	.9335
21	.7356	.7621	.743	.7621	.8764	.9526	.8192
22	.5847	.5716	.5906	.5716	.6287	.7621	.6859
23	.5281	.5335	.5525	.5716	.5335	.5716	.5716
24	.5716	.5093	.5144	.5144	.5335	.4954	.5335
Max	.9054	1.2003	1.2574	1.3336	1.3146	1.3717	1.2003
Min	.381	.0754	.381	.381	.4191	.2667	.3239
Avg	.6497	.7454	.7762	.8057	.8494	.8534	.7298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 206 / 11 KV CIDCO WATER PUMP
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.381	.381	.381	.3239	.362	.381
2	.381	.3429	.3429	.3429	.3048	.3239	.381
3	.3429	.3018	.3239	.3239	.2858	.3048	.3429
4	.3239	.3018	.3048	.3048	.2858	.2858	.3239
5	.3429	.3395	.3239	.3239	.3048	.2858	.3048
6	.381	.3206	.3429	.3429	.3239	.3048	.3429
7	.4001	.3395	.381	.362	.362	.3239	.381
8	.4001	.3395	.4191		.362	.4191	.4191
9	.4001	.415	.4572	.4763	.4763	.4191	.4763
10	.381	.6722	.7049	.8192	.6668	.6859	.6287
11	.415	.7621	.9335	1.0479	.8573	.8573	.381
12	.5093	1.0669	1.0669	1.086	1.0669	1.086	.9907
13	.4904	1.0669	1.086		1.0479		.4001
14	.5093	1.0669	1.105	1.0479	1.0479	1.0288	1.1622
15	.5335	1.0479		1.105	1.0479	1.0669	1.0288
16	.4481	1.0288	1.0669	1.0669	1.0669	1.105	1.0288
17	.4108	.9526	1.0288	.9526	1.0288	.9526	.8764
18	.4527	.8573	.8192	.8764	.9335	.8764	.7621
19	.4527	.743	.6859	.7621	.724	.7621	.5906
20	.415	.5906	.4954	.5144	.5716	.5525	.5335
21	.415	.5335	.4001	.4763	.4382	.5525	.5716
22	.3772	.4191	.4001	.4001	.381	.5144	.5716
23	.4191	.381	.381	.381	.4001	.4572	.4763
24	.4191	.415	.381	.381	.362	.381	.4191
Max	.5335	1.0669	1.105	1.105	1.0669	1.105	1.1622
Min	.3239	.3018	.3048	.3048	.2858	.2858	.3048
Avg	.4175	.6119	.6014	.6261	.6113	.6047	.5739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0754	.0953	.0953	.0953	.0762	.0762
2	.0762	.0762	.0953	.0762	.0953	.0762	.0762
3	.0762	.0754	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0754	.0762	.0762	.0762	.0762	.0762
6	.0762	.0754	.0762	.0762	.0953	.0762	.0762
7	.0762	.0754	.0762	.0762	.0953	.0762	.0762
8	.0762	.0754	.0762	.0762	.0953	.0762	.0762
9	.0953	.132	.0762	.0762	.1524	.0762	.0953
10	.2096	.415	.0762	.4191	.3048	.0953	.1715
11	.6413	.5716	.0762	.0762	.6668	.3048	.7621
12	.7356	.6859	.8192	.7621	.7621	.8764	.7621
13	.8488	.7621	.743	.5716	.7621	.8764	.8192
14	.9054	.8764	.6097	.7621	.7621	.8383	.7811
15		.8764	.6097	.8764	.8002	.8573	.8573
16	.8589	.8573	.9145	.8954	.8383	.8764	
17	.8589	.8192	.9335	.9145	.7811	.8573	.8573
18	.8865	.7811	.9145	.9145	.7621	.8192	.9526
19	.9431	.9145	.9907	.8954	.8383	.8192	.9526
20	.7922	.8192	.9717	.8573	.8764	.8002	.9526
21	.547	.381	.8192	.7621	.8383	.7621	.8954
22	.2263	.1524	.4001	.2286	.1715	.2286	.4191
23	.0754	.0953	.1715	.0953	.0762	.0762	
24	.0762	.0762	.0953	.0953	.0953	.0762	.0762
Max	.9431	.9145	.9907	.9145	.8764	.8764	.9526
Min	.0754	.0754	.0762	.0762	.0762	.0762	.0762
Avg	.4048	.4092	.4112	.4096	.4247	.4104	.4529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 402 / 33 KV BSEL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286		.2286	.2286	.2286
2	.2286	.2286	.2286		.2286	.2286	.2286
3	.2286	.2263	.2286		.2286	.2286	.2286
4	.2286	.2286	.2286		.2286	.2286	.2286
5	.2286	.2286	.2286	.2286	.2286	.2286	.2286
6	.2286	.2263	.2286	.2286	.2286	.2286	.2286
7	.2286	.2263	.2286	.2286	.2286	.2286	.2286
8	.2286	.2263	.2286	.2286	.2286	.2286	.2286
9	.2286	.4527	.4572	.4572	.4572	.4572	.2286
10	.2286	.9054	.6859	.9145	.9145	.9145	.2286
11	.2263	.9145	.9145	.9145	.9145	.9145	.4572
12	.2263	.9145	.6859	.9145	.9145	.9145	.4572
13	.2263	.9145	.6859	.6859	.9145	.9145	.4572
14	.2263	.9145	.6859	.9145	.9145	.9145	.4572
15	.2263	.9145	.9145	.9145	.9145	.9145	.4572
16	.2263	.9145	.9145	.9145	.9145	.9145	5.0297
17	.2263	.9145	.6859	.9145	.6859	.9145	.2286
18	.2263	.9145	.6859	.6859	.6859	.6859	.2286
19	.2263	.4572	.4572	.6859	.2286	.6859	.2286
20	.2263	.2286	.2286	.2286	.2286	.2286	
21	.2263	.2286	.2286	.2286	.2286	.2286	.2286
22	.2263	.2286	.2286	.2286	.2286	.2286	.2286
23	.2263	.2286	.2286	.2286	.2286	.2286	.2286
24	.2286	.2263	.2286	.2286	.2286	.2286	.2286
Max	.2286	.9145	.9145	.9145	.9145	.9145	5.0297
Min	.2263	.2263	.2286	.2286	.2286	.2286	.2286
Avg	.2274	.5038	.4477	.5487	.4763	.5049	.4870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 403 / 33 KV VISHWAROOP
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.1431	1.4861	1.4861	1.4861	1.4861	1.2574
2	1.1431	1.1317	1.2574	1.2574	1.3717	1.3717	1.1431
3	1.0288	1.0185	1.1431	1.1431	1.2574	1.2574	1.0288
4	1.0288	1.0185	1.1431	1.1431	1.2574	1.2574	1.0288
5	1.0288	1.1317	1.1431	1.1431	1.2574	1.3717	1.1431
6	1.1431	1.2449	1.2574	1.2574	1.3717	1.6004	1.1431
7	1.1431	1.358	1.2574	1.2574	1.3717	1.3717	1.1431
8	1.1431	1.2449	1.4861	1.4861	1.6004	1.4861	1.1431
9	1.1431	1.4712	1.829	1.9433	1.7147	1.9433	1.2574
10	1.1431	2.3765	2.0576	2.5149	2.0576	2.0576	1.4861
11	1.1317	2.2862	2.0576	2.1719	2.1719	2.1719	
12	1.2449	2.0576	2.0576	2.1719	2.1719	2.1719	1.4861
13	1.2449	2.1719	2.2862	2.0576	2.1719	2.1719	1.4861
14	1.2449	2.2862	2.0576	2.1719	2.2862	2.1719	1.3717
15	1.2449	2.1719	2.1719	2.0576	2.1719	2.2862	1.4861
16	1.2449	1.7147	2.1719	2.0576	2.1719	2.2862	1.4861
17	1.2449	1.829	2.2862	2.2862	2.1719	2.2862	1.6004
18	1.2449	2.2862	2.1719	2.2862	2.4006	2.1719	1.1431
19	1.2449	1.9433	2.0576	2.1719	2.0576	2.1719	.6859
20	1.2449	1.829	1.829	1.829	1.9433	1.9433	
21	1.1317	1.7147	1.7147	1.7147	1.7147	1.829	1.3717
22	1.1317	1.6004	1.6004	1.6004	1.6004	1.7147	1.2574
23	1.2449	1.6004		1.6004	1.4861	1.4861	1.2574
24	1.2574	1.1317	1.6004	1.6004	1.6004	1.6004	1.4861
Max	1.2574	2.3765	2.2862	2.5149	2.4006	2.2862	1.6004
Min	1.0288	1.0185	1.1431	1.1431	1.2574	1.2574	.6859
Avg	1.1793	1.6568	1.7445	1.7671	1.7861	1.8195	1.2678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM NON SHEDDABLE EXPRESS HV FEEDERS
VASHI Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.5947	1.9959	1.8656	1.6461	1.6461	2.0851
2	1.7558	1.3889	1.885	1.7558	1.4403	1.5947	1.8107
3	1.4815	1.2346	1.7741	1.4815	1.286	1.5432	1.5912
4	1.3169	1.1317	1.6632	1.2071	1.1317	1.2346	1.3717
5	1.2071	1.0288	1.6078	1.1523	1.0802	1.1317	1.262
6	1.2071	1.0802	1.4969	1.3169	1.1831	1.0802	1.2071
7	1.0974	1.1317	1.386	1.262	1.1831	1.1831	1.2071
8	1.262	1.0802	1.3306	1.262	1.1831	1.1317	1.3717
9	1.1523	1.3889	1.5524	1.4815	1.4403	1.286	1.5364
10	1.2346	1.8004	2.1068	2.0851	1.8519	1.6461	1.7558
11	1.4918	1.9959	2.0851	1.9547	2.0513	1.9547	2.2497
12	1.4403	2.0513	2.1399	2.0576	2.1068	1.9033	2.0851
13	1.3375	2.0513	2.0302	1.9033	2.1622	1.8004	1.9753
14	1.3889	2.1068	1.9753	1.9547	2.0062	1.9547	2.0302
15	1.4918	2.1622	2.3045	2.0576	2.0062	2.0576	2.1399
16	1.4403	2.1622	2.3045	2.1091	1.9547	2.1399	1.9033
17	1.3375	2.0513	2.2497	2.0062	1.9033	2.1948	1.8004
18	1.3375	1.9404	2.0302	1.8004	1.8519	2.0302	1.749
19	1.3375	1.885	1.9753	1.749	1.8519	1.9753	1.6461
20	1.4918	1.7741	1.701	1.6461	1.749	1.8107	1.5947
21	1.4918	1.885	1.8656	1.749	1.749	1.7558	1.5947
22	1.6975	2.0513	1.9753	1.8004	1.8004	1.8656	1.749
23	1.8004	2.2177	2.0851	2.0062	1.9033	2.0851	1.8004
24	1.8107	1.749	2.1068	2.0302	1.9547	1.9033	2.2291
Max	1.8107	2.2177	2.3045	2.1091	2.1622	2.1948	2.2497
Min	1.0974	1.0288	1.3306	1.1523	1.0802	1.0802	1.2071
Avg	1.4319	1.7060	1.9011	1.7373	1.6865	1.7045	1.7394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7177	1.6095	1.9044	1.8111	1.8484	1.8473	1.848
2	1.4937	1.5844	1.8298	1.7556	1.7364	1.7741	1.6078
3	1.4937	1.4901	1.7737	1.6817	1.6244	1.6827	1.5339
4	1.251	1.3769	1.6617	1.5893	1.5123	1.5912	1.46
5	1.2136	1.3392	1.4377	1.4969	1.419	1.5181	1.3491
6	1.1576	1.3014	1.363	1.4045	1.2883	1.4083	1.2012
7	1.0829	1.2637	1.2883	1.2936	1.1203	1.2803	1.1088
8	1.0642	1.1506	1.2136	1.1273	1.2136	1.2254	1.0903
9	1.307	1.2071	1.1949	1.1273	1.1389	1.3169	1.1088
10	1.307	1.2071	1.1203	1.2382	1.1203	1.2803	1.0719
11	1.251	1.1694	1.1576	1.2012	1.1203	1.1157	1.0719
12	1.1949	1.1317	1.0456		1.1763	1.134	1.0534
13	1.2696	.9997	1.0456			1.0791	1.0903
14		1.0562	.9896	1.2567		1.1523	1.1273
15	1.2696	1.0751	1.1576			1.2071	1.1273
16		1.0751	1.1949	1.1827	.4854	1.1888	1.1643
17						1.262	1.1088
18	1.1576		1.2883			1.3352	1.4415
19	1.643	1.5466		1.1827		1.4449	
20		1.531	1.6244	1.5524		1.4815	1.5893
21				1.6817		1.5181	1.7002
22		1.6409			1.6244	1.5546	1.7926
23					1.9978	1.7924	1.848
24	1.8111	1.9044	1.9616	1.8671	1.9035	1.9791	1.9753
Max	1.8111	1.9044	1.9616	1.8671	1.9978	1.9791	1.9753
Min	1.0642	.9997	.9896	1.1273	.4854	1.0791	1.0534
Avg	1.3344	1.3330	1.3817	1.4382	1.3956	1.4237	1.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.467	1.3443	1.4045	1.39	1.4003	.1905	1.3817
2	1.3908	1.307	1.2752	1.2986	1.3256	.1715	1.2696
3	1.3146	1.251	1.2567	1.2437	1.2696	.1715	1.2136
4	1.2574	1.1763	1.2012	1.1706	1.2136	.1715	1.1389
5	1.2193	1.1203	1.1458	1.0974	1.1576	.1524	1.0829
6	1.1622	1.0642	1.0903	1.0425	1.1016	.1524	1.0269
7	1.1241	1.0456	1.0349	1.0974	1.1389	.1334	1.0642
8	1.105		1.1273	1.134	1.1763	.1334	1.1763
9	1.2384	1.2323	1.386	1.262	1.3817	.1524	1.251
10	1.3908		1.7372	1.6095	1.6991	.1715	1.6057
11	1.448	1.5497	1.7926	1.7375	1.7177	.3239	1.643
12	1.4861	1.8298	1.7741		1.7924	.3239	1.6057
13	1.4861	1.7364	1.5893			.3239	1.643
14		1.8111		1.39			1.6804
15	1.5242	1.7364	1.8111			.3239	1.7177
16	1.4861	1.7737	1.7372	1.7741		.3048	1.7737
17					.3174	1.5242	1.531
18	1.3908		1.7187			1.6575	1.6617
19	1.5623	1.8484		1.8107		1.7909	
20		.2218	1.6263	1.6278		1.7147	1.5684
21				1.5912		1.6385	1.531
22		1.5684			.2801	1.5432	1.587
23					.2054	1.5623	1.4937
24	1.4901	1.467	1.475	1.4784	1.4632	.1867	1.5242
Max	1.5623	1.8484	1.8111	1.8107	1.7924	1.7909	1.7737
Min	1.105	.2218	1.0349	1.0425	.2054	.1334	1.0269
Avg	1.3635	1.3935	1.4546	1.3974	1.1650	.6443	1.4422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1848	.2286	.2667	.2218	.2286	.2427
2	.2075	.2033	.2477	.2667	.2033	.2477	.2054
3	.2263	.2218	.2477	.2477	.2033	.2096	.2054
4	.2452	.2218	.2286	.2286	.1848	.2096	.1867
5	.2263	.2033	.1905	.2286	.1848	.1905	.1867
6	.2452	.1663	.1905	.2096	.1848	.1905	.1867
7	.1698	.1478	.1905	.2096	.2033	.2096	.2054
8	.1698	.1663	.1715	.1905	.1848	.1905	.1867
9	.1698	.1848	.1905	.1905	.1848	.2096	.1867
10	.1886		.2858	.2667	.2218		.2427
11	.1698	.2587	.2858	.3429	.3142	.2286	.3547
12	.1886	.3142	.3048		.3326	.3048	.3174
13		.2033	.2096			.2858	.3361
14	.1886	.2957		.2858			.3361
15	.2263	.2957	.3048			.362	.3361
16	.1886	.3142	.3048	.3429		.3048	.3547
17					.3326	.3429	.3174
18	.1886		.2858			.3429	.2801
19	.1886	.2587		.3048		.3429	
20		.2218	.2667	.2477		.3239	.2427
21				.2096		.2667	.2241
22		.2402			.3142	.2286	.2054
23					.2402	.2286	.2614
24	.1905	.1886	.2033	.2477	.2286	.2218	.2477
Max	.2452	.3142	.3048	.3429	.3326	.362	.3547
Min	.1698	.1478	.1715	.1905	.1848	.1905	.1867
Avg	.1982	.2259	.2410	.2522	.2337	.2578	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION SHEDDABLE URBAN
TRANSFO Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.9335	.9431	.9425	.9694	1.1273	.9511
2	.8131	.8573	.8865	.8871	.8962	1.0349	.8413
3	.7207	.743	.8299	.7947	.8048	.9425	.7499
4	.6838	.5906	.7167	.7207	.7133	.8686	.6584
5	.5175	.5335	.6224	.6099	.6036	.7762	.567
6	.4805	.4954		.5544	.5121	.6653	.5487
7	.4251	.4572	.5093	.5175	.4572	.5175	.5304
8	.4435	.4382	.5281	.499	.4938	.499	.4938
9	.462	.4763	.4904	.4805	.4572	.5175	.4572
10	.5175	.4572	.4904	.462	.4938		.5304
11	.5175	.4382	.4904	.5359	.4572	.4805	.5121
12	.4805	.4382	.5093		.5121	.4435	.5121
13	.5175	.5144	.4527			.462	.5304
14		.4763		.499			.567
15	.6283	.4954	.5658			.6099	.5853
16	.6099	.5525	.5658	.5544		.6283	.6036
17					.4938	.6099	.5487
18	.499		.4904			.5729	.567
19	.4805	.4763		.5359		.5359	
20		.5906	.6413	.6099		.6468	.6219
21				.6653		.7207	.695
22		.8192			.5853	.7577	.7499
23					1.0242	1.1458	.9328
24	.9335	.9979	.9907	1.0374	.9979	1.1706	1.0903
Max	.9335	.9979	.9907	1.0374	1.0242	1.1706	1.0903
Min	.4251	.4382	.4527	.462	.4572	.4435	.4572
Avg	.5899	.5891	.6308	.6415	.6545	.7152	.6454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10

SHEDDABLE URBAN

SANPADA Feeder KV- 11 /
OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6161	.6413	.6478	.6099	.6668	.6036
2	.5525	.5788	.6224	.5906	.5729	.5906	.5281
3	.4572	.5415	.5847	.5335	.5175	.5144	.4715
4	.4191	.5228	.547	.4572	.4435	.4382	.3961
5		.4854	.5093	.4001	.3881	.381	.3584
6	.362	.4108	.4338	.381	.4066	.4001	.3395
7	.3429	.3734	.3961	.4191	.4251	.4382	.3772
8	.4191	.4294	.4715	.4572	.4435	.4763	.3772
9	.4382	.4854	.4715	.4954	.462	.4763	.3772
10	.3429	.4481	.4527	.4191	.4251	.4001	.3395
11	.4191	.4668	.4527	.4572	.4435	.4954	.3584
12	.3429	.4294	.4527		.4066	.4572	.3206
13			.4338			.4572	.3584
14	.362	.4481					.3395
15	.4382	.4108	.4715			.4572	.3109
16	.362	.3547	.3772	.4191		.362	.3772
17					.3881	.381	.3395
18	.3429		.415			.4001	.3584
19	.4191	.4108		.4572		.4191	
20		.4108	.5281	.4954		.4382	.4527
21				.5335		.4763	.5093
22		.4668			.462	.4954	.4904
23					.6838	.5906	.6413
24	.6668	.6287	.6535	.679	.7049	.7023	.743
Max	.6668	.6287	.6535	.679	.7049	.7023	.743
Min	.3429	.3547	.3772	.381	.3881	.362	.3109
Avg	.4292	.4694	.4953	.4902	.4864	.4745	.4247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7 SHEDDABLE URBAN
 SANPADA Feeder KV- 11 /
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4377	1.5154	1.6244	1.5912	1.6461	1.6804	1.6817
2	1.307	1.4415	1.5497	1.5181	1.5912	1.6244	1.386
3	1.0082	1.386	1.475	1.4449	1.5181	1.531	1.3121
4	1.0829	1.2936	1.3817	1.3717	1.4266	1.419	1.2382
5	1.0082	1.2197	1.2883	1.2986	1.3169	1.3256	1.1643
6	.9709	1.0903	1.251	1.2254		1.2323	1.1088
7	.9149	1.0534	1.2136	1.1888	1.2254	1.1203	1.1273
8	1.0082	1.0903	1.1949	1.2437		1.2136	1.2382
9	1.0642	1.1643	1.1576	1.262	1.2803	1.3443	1.3306
10	1.1949	1.1458	1.2883	1.1523	1.2986	1.3817	1.2936
11	1.307	1.2567	1.3256	1.262	1.3352	1.251	1.3676
12	1.1763	1.2382	1.251		1.1888	1.2696	1.3676
13		1.1458	1.1949			1.2323	1.3306
14	1.1203	1.2567		1.262			1.2936
15	1.251	1.2752	1.4003			1.419	1.2936
16	1.0829	1.2567	1.251	1.3535		1.419	1.2752
17					1.3535	1.3443	1.3491
18	1.0642		1.2696			1.3817	1.3121
19	1.307	1.3306		1.39		1.4563	
20		1.4969	1.531	1.4815		1.4563	1.5524
21				1.5181		1.475	1.4969
22		1.5708			1.4815	1.4937	1.4415
23					1.6461	1.6991	1.6448
24	1.531	1.6057	1.6632	1.6991	1.7375	1.7193	1.8298
Max	1.531	1.6057	1.6632	1.6991	1.7375	1.7193	1.8298
Min	.9149	1.0534	1.1576	1.1523	1.1888	1.1203	1.1088
Avg	1.1576	1.2917	1.3506	1.3684	1.4318	1.4126	1.3668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3285	2.4025	2.4897	2.5206	2.6101	2.6326	2.4764
2	2.1992	2.4143	2.4143	2.4272	2.4768	2.5019	2.2731
3	2.1437	2.2822	2.3011	2.3525	2.3434	2.3899	2.1622
4	2.0328	2.2445	2.2445	2.2405	2.1719	2.2592	2.0513
5	1.9589	2.1502	2.2068	2.1845	2.0957	2.1285	1.922
6	1.885	2.0559	2.1502	2.1098	2.0576	2.0538	1.848
7	1.8296	2.037	2.0936	2.0538	2.1719	2.0351	1.885
8	1.848	1.9805	2.037	2.1098	2.0386	1.9978	1.9589
9	1.8665	1.8673	1.8484	1.9044	2.0005	1.9044	1.922
10	1.7372	1.5466	1.5844	1.6617	1.7528	1.8858	1.7372
11	1.7002	1.5466	1.5655	1.643	1.6575	1.5497	1.6448
12	1.6263	1.4523	1.3203		1.5623	1.5684	1.5893
13	1.5708	1.4146	1.6221			1.5684	1.5524
14		1.5466		1.643			1.5708
15	1.7187	1.6032	1.7353			1.6244	1.6448
16	1.7187	1.5278	1.6787	1.6057		1.6617	1.6817
17					1.6766	1.7177	1.6078
18	1.6817		1.6975			1.7924	1.8111
19	1.885	1.8673		1.9418		1.8484	
20		2.3577	2.2068	2.1472		1.9791	2.1253
21				2.2032		2.1285	2.1992
22		2.3388			2.4196	2.2592	2.3101
23					2.6863	2.5019	2.4764
24	2.5503	2.4579	2.5463	2.6217	2.5206	2.8006	2.6513
Max	2.5503	2.4579	2.5463	2.6217	2.6863	2.8006	2.6513
Min	1.5708	1.4146	1.3203	1.6057	1.5623	1.5497	1.5524
Avg	1.9045	1.9547	1.9857	2.0806	2.1401	2.0343	1.9609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6409	1.5844	1.8484	1.8484	1.7541	1.7187	1.8484
2	1.5278	1.4146	1.7918	1.773	1.4901	1.531	1.7353
3	1.3957	1.3203	1.6787	1.7164	1.4563	1.423	1.6032
4	1.2637	1.2826	1.5844	1.6221	1.419	1.3817	1.5278
5	1.1506	1.2826	1.5089	1.5655	1.4377	1.4003	1.4335
6	1.094	1.4712	1.3957	1.4335	1.4712	1.419	1.3203
7	1.1694	1.3014	1.3203	1.358	1.3392	1.3443	1.2071
8	1.226	1.3203	1.2826	1.3014	1.4146	1.2883	1.3014
9	1.3203	1.1883	1.226	1.4146	1.4377	1.307	1.358
10	1.2637	1.1694	1.226	1.1883	1.1389	1.1506	1.2071
11	1.2071	1.094	1.1506	1.1763	1.1016	1.1694	1.226
12	1.1694	1.0185	1.0374	1.0374	1.0082	1.0751	1.1883
13	1.1128	.9619	.9808	1.0185	1.0082	1.0751	1.1763
14	1.2071	1.0374	.9997	1.1203	1.1458	1.1883	1.3014
15	1.2826	1.0374	.9808	1.1576	1.1949	1.2071	1.419
16	1.358	1.0185	1.0562	1.1763	1.1458	1.1694	1.3443
17	1.2696	1.0185	1.094	1.1203	1.1389	1.1128	1.2323
18	1.1883	1.0374	1.0562	1.0374	1.1016	1.226	1.1763
19	1.1694	1.1694	1.1506	1.1317	1.307	1.2826	1.2136
20	1.4335	1.4523	1.4901	1.4335	1.5684	1.5278	1.5466
21	1.5655	1.5844	1.6598	1.6221	1.6804	1.7541	1.6787
22	1.6409	1.6975	1.773	1.7541	1.8858	1.6975	1.7353
23	1.8296	1.8296	1.8861	1.9616	1.9044	1.905	1.8296
24	1.7353	1.8296	1.9239		1.9427	1.9035	1.9239
Max	1.8296	1.8296	1.9239	1.9616	1.9427	1.905	1.9239
Min	1.094	.9619	.9808	1.0185	1.0082	1.0751	1.1763
Avg	1.3426	1.2967	1.3793	1.3899	1.3955	1.3857	1.4389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 204 / Spare (11 KV Sec 30 Nerul link Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

DATE	09-APR-18
HR	Load (MW)
11	.0566
Max	.0566
Min	.0566
Avg	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION

SHEDDABLE URBAN

TRANSFORMER S Feeder KV- 11 /
OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.056	.0566
2	.0566	.0566	.0566	.0566	.0377	.0566	.0566
3	.0566	.0566	.0566	.0566	.0377	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0566	.0566
7	.0566	.0566	.0566	.0566	.0377	.0566	.0566
8	.0566	.0566	.0566	.0566	.0566	.0566	.0566
9	.0566	.0566	.0566	.0566	.056	.056	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.056	.056	.0566	.0566
12	.0377	.0566	.0566	.0566	.056	.0566	.0566
13	.0566	.0566	.0566	.0566		.0566	.0566
14	.0566	.0566	.0566	.0943	.0566	.0566	.0566
15	.0566	.0568	.0566	.0566	.056	.0566	.0566
16	.0566	.0566	.0566	.0566	.0566	.0566	.056
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0566	.0566	.0566	.0566	.0566	.0566	.0566
19	.0566	.0566	.0566	.0566	.056	.0566	.0566
20	.0566	.0566	.0566	.0566	.056	.0566	.0566
21	.0754	.0566	.0566	.0566	.056	.0566	.0566
22	.0566	.0566	.0566	.0566	.056	.0566	.0566
23	.0566	.0566	.0566	.0566	.0566	.0566	.0754
24	.0566	.0566	.0566		.0754	.056	.0566
Max	.0754	.0568	.0566	.0943	.0754	.0566	.0754
Min	.0377	.0566	.0566	.056	.0377	.056	.056
Avg	.0566	.0566	.0566	.0582	.0547	.0565	.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2068	2.2068	1.8673	2.3577	2.3388	2.2779	2.4143
2	2.0748	2.0538	1.7918	2.2257	2.1313	2.0351	2.1691
3	1.9805	1.9044	1.7353	2.0559	2.0351	1.8671	2.0182
4	1.8484	1.8298	1.6787	1.8861	2.0165	1.773	1.8861
5	1.7918	1.8111	1.5466	1.8484	1.9978	1.6617	1.7918
6	1.9239	1.9791	1.4901	1.9239	2.0165	1.9404	1.7353
7	2.037	2.1313	1.6598	2.1502	2.2822	2.1658	1.9239
8	2.1125	2.2634	1.7918	2.3765	2.1313	2.1845	2.0748
9	1.905	1.7918	1.905	1.9616	1.8858	1.8671	1.9239
10	1.8107	1.7353	1.6787	1.6617	1.7353	1.7918	1.7918
11	1.7353	1.5466	1.5466	1.7164	1.587	1.6787	1.6409
12	1.5466	1.5278	1.5466	1.5466	1.5497	1.4901	1.6409
13	1.5466	1.4146	1.4335	1.5089	1.587	.0566	1.643
14	1.5844	1.4712	1.4901	1.5497	1.6057	1.6598	1.7164
15	1.6221	1.4335	1.5089	1.6221	1.6057	1.6409	1.773
16	1.6975	1.4712	1.5278	1.5497	1.6057	1.6409	1.7177
17	1.6409	1.5466	1.5655	1.5844	1.6804	1.6221	1.7164
18	1.7541	1.5466	1.6409	1.643	1.7002	1.6221	1.6804
19	1.9805	1.9427	2.0559	1.9993	2.2257	2.037	2.1285
20	2.4897	2.4331	2.5652	2.5086	2.2177	2.3011	2.452
21	2.2634	2.3765	2.3765	2.4143	2.347	2.3765	2.3954
22	2.4143	2.32	2.4709	2.4331		2.5086	2.452
23	2.5086	2.5086	2.5652	2.6406	2.6057	2.584	2.5866
24	2.4143	2.4331	2.452		2.5274	2.4764	2.5463
Max	2.5086	2.5086	2.5652	2.6406	2.6057	2.584	2.5866
Min	1.5466	1.4146	1.4335	1.5089	1.5497	.0566	1.6409
Avg	1.9537	1.9033	1.8288	1.9637	1.9746	1.8858	1.9924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6602	.7545	.7545	.7167	.7207	.5281
2	.6413	.5975	.6979	.7167	.679	.5975	.7922
3	.5658	.5601	.6602	.6602	.6348	.5544	.7545
4	.5093	.5415	.6036	.6036	.6348	.5415	.6602
5	.4527	.5601	.547	.5658	.5975	.5228	.6036
6	.415	.6413	.5281	.5281	.679	.6224	.547
7	.4715	.6036	.547	.5658	.6224	.5093	.4715
8	.5281	.5658	.5658	.6224	.6224	.5228	.5093
9	.5847	.6036	.5847	.5658	.5415	.5729	.6036
10	.547	.5281	.4904	.4854	.5281	.5093	.6036
11	.5281	.4904	.4904	.4481	.462	.4527	.5281
12	.4904	.4904	.5093	.4527	.4668	.4904	.547
13	.4715	.4715	.4527	.4904	.5041	.5281	.5041
14	.4904	.4904	.4527	.4715	.4854	.4904	.5658
15	.5847	.4527	.4527	.5041	.5041	.4904	.547
16	.6979	.4715	.4527	.4854	.4854	.4904	.7095
17	.7545	.4904	.4527	.4854	.4854	.4904	.7733
18	.7356	.5093	.4904	.4668	.5041	.5281	.9054
19	.6224	.4715	.5093	.5093	.5228	.5658	.7167
20	.6224	.5847	.5658	.5658	.5975	.5847	.7167
21	.5788	.6036	.6036	.6036	.6348	.6224	.7733
22	.6413	.6224	.679	.6979	.7282	.7167	.7545
23	.7545	.7545	.8488	.811	.8215	.7545	.8299
24	.7545	.7167	.7733		.7545	.7762	.8299
Max	.7545	.7545	.8488	.811	.8215	.7762	.9054
Min	.415	.4527	.4527	.4481	.462	.4527	.4715
Avg	.5900	.5617	.5714	.5678	.5922	.5690	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.382			1.3889	1.3375	
2		1.2757			1.4403	1.286	
3		1.3289					
4		1.2226			1.1317	1.0288	
5		1.1694					
6		1.1163			1.0288	.9259	
7		1.0099					
8		.9036			.9259	.8745	
9		.9036		.9259	.9259	.9774	
10		.8939		.9774	1.0288		
11			1.0802	1.1831	1.1317		
12			1.1831	1.2346	1.1317		
13			1.0802	1.0802	1.0802		
14			1.0802			1.0631	1.2757
15			1.2346	1.1317	1.1317	1.0099	1.4003
16			1.1831	1.2346	1.1317	1.0631	1.2757
17				1.1317		1.1163	1.2757
18			1.0802	1.1317			1.2757
19			1.2346	1.2346	1.2346	1.2757	1.2757
20			1.3889	1.286		1.382	1.3289
21			1.3889	1.3375	1.3889	1.4352	1.382
22				1.3889	1.3889	1.4883	1.4883
23	1.382		1.4403		1.4403	1.4883	1.4883
24		1.4352		1.3889	1.4403	1.4403	1.5415
Max	1.382	1.4352	1.4403	1.3889	1.4403	1.4883	1.5415
Min	1.382	.8939	1.0802	.9259	.9259	.8745	1.2757
Avg	1.382	1.1492	1.2158	1.1905	1.1983	1.1995	1.3643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN SHEDDABLE URBAN
NERU Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.0233	1.9845
2					1.8861		2.0538
3						1.8519	1.9136
4					1.7147		1.7718
5						1.8004	
6		1.9044			1.6804		1.8671
7		1.8484				1.7661	1.8484
8		1.8298			1.6632	1.7318	1.6057
9		1.587		1.4746	1.5089	1.5432	
10		1.4377		1.3889	1.5089	1.4937	1.531
11			1.2174	1.2174	1.4918	1.419	1.5123
12			1.2003	1.2174	1.3889	1.419	1.4003
13			1.2174	1.2003	1.3717	1.4937	1.419
14			1.166			1.4937	1.4712
15			1.1831	1.286	1.2517	1.4563	1.4563
16			1.166	1.286	1.2346	1.419	1.4563
17				1.2689		1.3817	
18			1.1145	1.2003		1.4003	1.4377
19			1.2517	1.4746	1.4232	1.6804	1.6057
20			1.5604	1.6632		1.9044	1.8298
21	1.9418		1.5775	1.8004	1.749	2.0165	
22	2.0351			1.869	1.9376	2.0911	
23	2.1285		2.0576		2.1434	2.1845	2.1658
24		2.0911		1.989	1.9719	2.0233	2.2218
Max	2.1285	2.0911	2.0576	1.989	2.1434	2.1845	2.2218
Min	1.9418	1.4377	1.1145	1.2003	1.2346	1.3817	1.4003
Avg	2.0351	1.7831	1.3374	1.4526	1.6204	1.6949	1.7133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN SHEDDABLE URBAN
NERUL Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.12	.12	.1494
2						.12	.1494
3					.1029		.168
4						.1029	.168
5					.1029		.1509
6		.1307				.12	.1494
7		.1494			.12		
8		.132			.12	.12	
9		.1307		.1029	.12	.12	
10		.1307		.1372	.12	.1307	.1494
11			.12	.1372	.12	.1307	.1494
12			.12	.1029	.12	.112	.112
13			.12	.12	.12	.1494	.1494
14			.12			.1307	.1494
15			.12	.1029	.12	.1494	.1494
16			.1029	.12	.12	.1307	.1494
17				.1029			.1494
18			.12	.12		.1494	.1494
19			.12	.12	.12		
20	.168		.12	.12		.1307	.112
21	.1307		.12	.12	.12	.1494	
22	.1494			.12	.12	.1494	
23	.1494		.12		.12	.168	.168
24		.1494		.12	.12	.12	.1307
Max	.168	.1494	.12	.1372	.12	.168	.168
Min	.1307	.1307	.1029	.1029	.1029	.1029	.112
Avg	.1494	.1372	.1184	.1176	.1180	.1318	.1474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0686	.0686	.056
2					.0686	.0686	.056
3						.0686	.056
4					.0686		.0747
5						.0686	.056
6					.0686		.0747
7		.0747				.0686	.0747
8		.056			.0686	.0686	.056
9		.056		.0686	.0686	.0686	.056
10	.0747	.0747		.0686	.0686	.0747	.0747
11	.0934		.0686	.0686	.0686	.056	.056
12	.0934		.0686	.0686	.0686	.056	.056
13	.0934		.0686	.0686	.0686	.056	.056
14	.0747		.0686			.056	.056
15	.0934		.8916	.0514	.0686	.056	.056
16	.0747		.0686	.0686	.0686	.0747	.056
17	.0747			.0686		.056	.056
18	.0747		.0686	.0686		.0747	.056
19	.0934		.0686	.0686	.0686	.0747	.056
20	.0754		.0686	.0686		.056	.0747
21	.0934		.0686	.0686	.0686	.056	.0754
22	.056			.0686	.0686	.0747	.0747
23	.0373		.0686		.0686	.0754	.0747
24		.0747		.0686	.0686	.0686	.0747
Max	.0934	.0747	.8916	.0686	.0686	.0754	.0754
Min	.0373	.056	.0686	.0514	.0686	.056	.056
Avg	.0788	.0672	.1434	.0674	.0686	.0657	.0630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	10-APR-18
HR	Load (MW)
11	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-APR-18
HR	Load (MW)
11	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE Sec 28 Nerul SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5228			.3601	.4973	.5601
2		.5041					.5228
3		.4854			.3601		.5041
4		.4108					.4854
5		.3921			.4115	.4801	.4294
6		.3734					
7		.3544			.3772	.6516	
8		.3366			.4115	.3258	
9		.3361		.2915	.583	.3258	
10		.3475		.3086	.3429		.3361
11			.2743	.2915	.3601		.3547
12			.2915	.3086	.3601		.3547
13			.2743	.2915	.3086		.3361
14			.2915			.2801	.3174
15			.3086	.2572	.2915	.2987	.2987
16			.2915	.2915	.2915	.2829	.3174
17				.2743			.3174
18			.2572	.2915			.2987
19			.2915	.3258	.2743		.3361
20			.3429	.3429		.3734	.3734
21			.3258	.3429	.3772	.4527	.4108
22				.3772	.2229	.5228	.4854
23	.5415		.5144		.3601	.5601	.5601
24		.5415		.5316	.3429	.5144	.5601
Max	.5415	.5415	.5144	.5316	.583	.6516	.5601
Min	.5415	.3361	.2572	.2572	.2229	.2801	.2987
Avg	.5415	.4186	.3149	.3233	.3550	.4281	.4079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 201 / 11 KV RAGHULEELA NEW

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.3961	.3772	.3734	.3961	.3772	.3772
2	.3772	.3772	.3395	.3547	.3772	.3395	.3395
3	.3395	.3772	.3395	.3174	.3772	.3018	.3018
4	.3018	.3395	.2829	.2614	.3395	.3018	.2641
5	.3018	.3395	.2829	.2241	.3395	.2829	.2641
6	.2829	.3018	.3018	.2241	.2829	.2829	.2452
7	.2829	.3018	.3018	.2614	.3018	.2641	.2263
8	.3584	.3018	.3206	.2801	.3018	.3395	.415
9	.415	.3961	.4338	.5788	.415	.6036	1.1016
10	1.7541	1.8673	.9149	2.1472	1.9239	1.1694	2.0165
11	2.32	2.4331	2.3339	2.3525	2.3954	1.7353	2.726
12	2.3577	2.32		2.3899	2.5652	2.452	2.726
13	2.4709	2.1502		2.3899	2.4709	2.2779	2.3339
14	2.5463	2.4143		2.3712	2.5086	2.1472	2.4086
15	2.6029	2.0936		2.3712	2.5652	2.1658	2.4086
16	2.4143	2.2445		2.3388	2.0936	2.2032	2.4086
17	2.4331	2.2257		2.2592	2.2445	2.2634	2.4272
18	2.3765	2.1502	2.3899	2.3011	2.1125	2.2592	2.3899
19	2.3011	2.1879	2.0911	2.3011	2.1502	2.2634	2.3152
20	2.2822	2.1125			2.3011	2.2634	2.2592
21	2.2445	2.0182		2.2634	2.2445	1.8673	2.1845
22	1.5466	1.0185		.8299	1.0374	1.8107	.9709
23	.8676	.5658		.6413	.5658	.6979	
24	1.0185	.3961	.3961		.3961	.3772	.3772
Max	2.6029	2.4331	2.3899	2.3899	2.5652	2.452	2.726
Min	.2829	.3018	.2829	.2241	.2829	.2641	.2263
Avg	1.4445	1.3054	.7933	1.3560	1.3627	1.2936	1.4560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2452	.2241	.2641	.2641	.2263
2	.2075	.2263	.2263	.2054	.2641	.2452	.2263
3	.2075	.2263	.2263	.2054	.2452	.2452	.2263
4	.2075	.2263	.2263	.1867	.2452	.2263	.2263
5	.2263	.2263	.2452	.1867	.2263	.2263	.2263
6	.2452	.2263	.2452	.2054	.2263	.2452	.2263
7	.2452	.2452	.2641	.2241	.2641	.2263	.2452
8	.2641	.2641	.2829	.2614	.2829	.2829	.2829
9	.3018	.4338	.3772	.3547	.3772	.3584	.3361
10	.3206	.4527	.5788	.5415	.4715	.415	.3547
11	.3395	.4527	.4854	.4294	.5281	.4527	.3547
12	.3018	.4338		.5228	.4338	.4854	.3361
13	.3206	.3584		.5281	.5281	.5041	.3547
14	.3018	.4904		.5228	.4904	.5228	.3361
15	.3395	.4338		.5281	.5281	.5228	.3361
16	.3206	.415		.4904	.4904	.5415	.3361
17	.2829	.4338		.4668	.5093	.5415	.3361
18	.3018	.4904	.5041	.4904	.5281	.5601	.3734
19	.3018	.415	.5975	.4904	.4715	.4904	.3547
20	.3206	.3395			.415	.4338	.3361
21	.3206	.3772		.4715	.3772	.415	.3174
22	.3018	.3206		.3395	.3206	.3961	.2614
23	.2641	.2641		.2829	.2829	.2829	
24	.2263	.2263	.2452	.2427	.2641	.2641	.2263
Max	.3395	.4904	.5975	.5415	.5281	.5601	.3734
Min	.2075	.2263	.2263	.1867	.2263	.2263	.2263
Avg	.2790	.3419	.3393	.3653	.3764	.3812	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 204 / 11 KV MICROTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.547	.5281	.5228	.5658	.5658	.5847
2	.4715	.5093	.4904	.4854	.5281	.5281	.5658
3	.4904	.5093	.4527	.4481	.5281	.4904	.5658
4	.4715	.4904	.4527	.4108	.5093	.4904	.547
5	.4338	.4904	.4527	.3734	.5093	.4715	.547
6	.4338	.4715	.4715	.3547	.4715	.4715	.547
7	.4527	.5093	.4715	.3547	.5281	.4527	.4527
8	.4527	.547	.5281	.4854	.5847	.5658	.4527
9	.4715	.7545	.811	.6908	.7167	.7545	.4668
10	.3772	1.0562	1.0456	.9896	.9808	1.0185	.5788
11	.4715	1.2826	1.1576	1.2323	1.1883	1.1694	.7095
12	.6036	1.2637		1.2883	1.2449	1.3392	.7842
13	.6036	1.3769		1.2883	1.226	1.307	.7842
14	.6413	1.3392		1.307	1.2826	1.251	.8402
15	.6602	1.3769		1.307	1.3203	1.251	.7842
16	.6036	1.2637		1.2136	1.1694	1.1763	.7468
17		1.226		1.1317	1.1694	1.1576	.6161
18	.6036	1.094	1.1016	1.094	1.1317	1.1203	.6161
19	.679	1.094	1.1016	1.0374	1.1694	1.1317	.6348
20	.6979	.9431			1.0185	1.094	.7282
21	.7167	.8676		.9619	.9431	.9054	.7095
22	.679	.7545		.7922	.7733	.811	.6535
23	.6036	.6413		.679	.6413	.679	
24	.5658	.547	.547	.5601	.5658	.6036	.5847
Max	.7167	1.3769	1.1576	1.307	1.3203	1.3392	.8402
Min	.3772	.4715	.4527	.3547	.4715	.4527	.4527
Avg	.5527	.8731	.6866	.8265	.8653	.8669	.6304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 205 / 11 kV SUBSTATION TRF
Raghuleel Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0566	.0566
7	.0566	.0566	.0566	.0514	.0566	.0754	.0566
8	.0754	.0566	.0566	.0566	.0566	.0754	.0566
9	.0754	.0754	.0566	.0934	.0566	.0566	.056
10	.0566	.0754	.0934	.0747	.0754	.0566	.0747
11	.0754	.0754	.0747	.0747	.0754	.0566	.0747
12	.0566	.0754		.0747	.0754	.0566	.0747
13	.0754	.0566		.0747	.0754	.056	.0747
14	.0566	.0566		.0747	.0754	.056	.0747
15	.0566	.0566		.0747	.0754	.056	.0747
16	.0754	.0566		.0566	.0566	.056	.056
17	.0754	.0566		.0566	.0566	.056	.056
18	.0754	.0566	.0747	.0566	.0566	.056	.056
19	.0754	.0566	.056	.0566	.0754	.0566	.056
20	.0754	.0566			.0754	.0566	.056
21	.0754	.0754		.0566	.0566	.0566	.056
22	.0566	.0754		.0566	.0566	.0566	.056
23	.0566	.0754		.0566	.0566	.0566	
24	.0566	.0566	.0566	.0747	.0566	.0566	.0566
Max	.0754	.0754	.0934	.0934	.0754	.0754	.0747
Min	.0566	.0566	.056	.0514	.0566	.056	.056
Avg	.0644	.0621	.0618	.0635	.0629	.0580	.0611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.358	1.3957	1.3443	1.3769	1.4146	1.3957
2	1.358	1.358	1.358	1.307	1.3769	1.3769	1.3769
3	1.3203	1.3392	1.3203	1.2883	1.3769	1.3769	1.3769
4	1.3203	1.3392	1.3203	1.2883	1.358	1.358	1.3392
5	1.3203	1.3392	1.3203	1.2883	1.358	1.358	1.3392
6	1.358	1.3203	1.358	1.307	1.358	1.3203	1.3203
7	1.358	1.358	1.3392	1.3256	1.3957		1.3769
8	1.358	1.3957	1.4146	1.3443	1.4335	1.4523	1.3769
9	1.4146	1.8484	1.7541	1.6991	1.7541	1.7353	1.4937
10	1.3957	2.1691	2.2405	2.0725	2.1502	1.9616	1.8484
11	1.5278	2.4331	2.3525	2.3339	2.3765	2.1879	1.9418
12	1.7353	2.4897		2.2965	2.3577	2.3011	2.0725
13	1.7541	2.3011		2.2965	2.3577	2.2779	1.9231
14	1.7353	2.3388		2.2965	2.3388	2.2779	
15	1.7541	2.452		2.2965	2.3765	2.2405	
16	1.8296	2.3765		2.3011	2.3765	2.2405	
17	1.7918	2.32		2.2779	2.3954	2.2032	
18	1.6975	2.2068	2.2218	2.2257	2.2634	2.1845	
19	1.6221	2.1125	2.0165	2.0936	2.037	2.037	
20	1.5844	1.8107			1.9993	1.905	
21	1.5278	1.6032		1.9239	1.6975	1.7353	1.6057
22	1.4712	1.4712		1.5655	1.5089	1.5466	1.419
23	1.3957	1.3957		1.4712	1.4335	1.4146	
24	1.4146	1.358	1.3957	1.3817	1.3769	1.4146	1.3957
Max	1.8296	2.4897	2.3525	2.3339	2.3954	2.3011	2.0725
Min	1.3203	1.3203	1.3203	1.2883	1.358	1.3203	1.3203
Avg	1.5168	1.8123	1.6291	1.7837	1.8264	1.7965	1.5376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1506	1.1317	1.0456	1.1506	1.1317	1.1694
2	1.0562	1.1317	1.0374	.9709	1.0374	1.0374	1.1317
3	1.0374	1.1317	.9877	.9335	.9808	1.0374	1.1317
4	.9808	1.0562	.9808	.9149	.9431	1.0185	1.094
5	.9808	1.0562	.9808	.8402	.9242	1.0185	1.0562
6	.9431	.9997	.9431	.7716	.9054	.9808	1.0185
7	.9431	.9431	.9431	.7888	.8865	.9808	1.0185
8	.9054	.8865	.8779	.8775	.8865	.9431	.9431
9	.7733	.7922	.8488	.9149	.8299	.8676	.8775
10	.7922	.8865	.7842	.811	.9054	.7922	.8402
11	.7733	.7733	.7468	.7282	.7733	.7545	.8589
12	.6979	.7167		.7468	.7545	.7356	
13	.6979	.7167		.7655	.7922	.7842	
14	.7167	.7733		.7842	.8676	.8589	
15	.7545	.7545		.8029	.8865	.8589	
16	.7733	.7922		.7922	.7356	.8215	
17	.7545	.7733		.7922	.8299	.7842	
18	.811	.7733	.7655	.8299	.811	.7842	
19	.8488	.9054	.9149	.8488	.9054	.9054	
20	.9431	1.0562			1.0374	1.0185	
21	1.0562	.9997		.9431	1.094	1.094	1.0456
22	1.0562	1.094		1.0374	1.094	1.2449	1.1016
23	1.0751	1.1317		1.1694	1.1506	1.2071	
24	1.1317	1.1506	1.1317	1.1016	1.1506	1.1317	1.1694
Max	1.1317	1.1506	1.1317	1.1694	1.1506	1.2449	1.1694
Min	.6979	.7167	.7468	.7282	.7356	.7356	.8402
Avg	.9014	.9352	.9339	.8787	.9305	.9497	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1509	.1886	.168	.2075	.2075	.2075
2	.1698	.1509	.1698	.1494	.2075	.1886	.2075
3	.1698	.1509	.1698		.1886	.1886	.1886
4	.1509	.1698	.1698	.1307	.1886	.1698	.1886
5	.1509	.1698	.1698	.1307	.1698	.1698	.1886
6	.1698	.1698	.1698	.1307	.1698	.1698	.1698
7	.1698	.2263	.1698	.1494	.2263	.1698	.1886
8	.1698	.3206	.3018	.1543	.2829	.2452	.1698
9	.1886	.5658	.5281	.4668	.4715	.4904	.2801
10	.2829	1.0185	.9896	1.0642	.9431	.6036	.5041
11	.2452	1.0185	.9896	1.0082	1.1317	.7733	.5041
12	.3206	1.1506		1.0082	1.0562	1.0374	
13	.2452	.8676		.9709	.9242	.9709	
14	.2452	.8865		.9335	.9619	.9149	
15	.2641	1.094		.8962	1.094	.8775	
16	.2263	.9997		.9054	1.0751	.8775	
17	.2641	.9054		.8962	.9808	.8589	
18	.2829	.8299	.8775	.7545	.9431	.8215	
19	.2829	.7167	.6161	.6224	.6602	.5847	
20	.2263	.4338			.4338	.3772	
21	.1886	.3395		.5093	.3018	.3395	.2801
22	.1698	.2641		.2452	.2641	.2452	.2054
23	.1698	.2075		.2263	.2263	.2452	
24	.1886	.1509	.1886	.1867	.2075	.2075	.2075
Max	.3206	1.1506	.9896	1.0642	1.1317	1.0374	.5041
Min	.1509	.1509	.1698	.1307	.1698	.1698	.1698
Avg	.2138	.5399	.4071	.5321	.5548	.4889	.2493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 209 / 11 KV CIDCO BUSINESS
CENTER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0566	.0566	.056	.0566	.0566	.0566
2	.0566	.0566	.0566	.056	.0566	.0566	.0566
3	.0566	.0566	.0566	.0373	.0566	.0566	.0566
4		.0566	.0566	.0373	.0566	.0566	.0566
5	.0566	.0566	.0566	.0373	.0566	.0566	.0566
6	.0566	.0566	.0566	.0373	.0566	.0566	.0566
7	.0566	.0566	.0566	.0373	.0566	.0566	.0377
8	.0566	.0566	.0566	.056	.0566	.0566	.0377
9	.0943	.0566	.0566	.1307	.132	.4904	.112
10	.1132	.0566	.0373	.1494	.132	.1509	.168
11	.1132	.0754	.056	.168	.1509	.132	.168
12	.1132	.0754		.0934	.1509	.132	
13	.0943	.0566		.112	.132	.112	
14	.1132	.0566		.1509	.1886	.112	
15	.1132	.0566		.168	.132	.1132	
16	.2075	.132		.1509	.3584	.1307	
17	.2263	.0566		.132	.3395	.132	
18	.2641	.0566	.056	.1132	.3395	.132	
19	.2829	.0566	.056	.1132	.3395	.132	
20	.2829	.0566			.3018	.132	
21	.2829	.0566		.0566	.2829	.1132	.2801
22	.0566	.0566		.0566	.0754	.0377	.168
23	.0566	.0566		.0566	.0566	.0377	
24	.1132	.0566	.0566	.056	.0566	.0566	.0566
Max	.2829	.132	.0566	.168	.3584	.4904	.2801
Min	.0566	.0566	.0373	.0373	.0566	.0377	.0377
Avg	.1288	.0613	.0551	.0897	.1509	.1083	.0977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 401 / 33 KV VASHI RLY S/STN FRM NON SHEDDABLE EXPRESS HV FEEDERS
RAGH Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	09-APR-18	13-APR-18
HR	Load (MW)	Load (MW)
23		.1132
24	.4527	
Max	.4527	.1132
Min	.4527	.1132
Avg	.4527	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 201 / 11 KV RELIANCE Sanpada
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0548	.0724	.0365	.0762	.0913	.0762	.0759
2	.0548	.0724	.0365	.0762	.0548	.0762	.0725
3	.0548	.0724	.0365	.0762	.0548	.0381	.0598
4	.0548	.0724	.0365	.0762	.0548	.0381	.0759
5	.0548	.0724	.0365	.0762	.0548	.0762	.0759
6	.0548	.0543	.0365	.0762	.0548	.0762	.038
7	.0548	.0543	.0365	.0762	.0548	.0381	.038
8	.0548	.1086	.0724	.0762	.0724	.0381	.0362
9	.0724	.1086	.1086	.1267	.1267	.0905	.0724
10	.1086	.1086	.1267	.0905	.1086	.1267	.0905
11	.1086	.1086	.1086	.0905	.1086	.1086	.0724
12	.0905	.0905	.1086	.1086	.0905	.0905	.0724
13	.0724	.1086	.0905	.0905	.1086	.0905	.0905
14	.0905	.0905	.0905	.0905	.1086	.0905	.1086
15	.0724	.0905	.0905	.0724	.0905	.0905	.0724
16	.0724	.0905	.0724	.0724	.0762	.0724	.073
17	.0724	.0365	.0762	.0548	.0381	.038	.0548
18	.0724	.0365	.0762		.0381	.038	.0548
19	.0724	.0365	.0762	.0548	.0381	.038	.0548
20	.0724	.0365	.0762	.0548	.0762	.0759	.0548
21	.0724	.073		.073	.0762	.0759	.0548
22	.0724	.073		.073		.0759	.073
23	.1086	.073		.0913	.0762	.0759	.1095
24	.073	.0905	.073	.0762	.0913	.0762	
Max	.1086	.1086	.1267	.1267	.1267	.1267	.1095
Min	.0548	.0365	.0365	.0548	.0381	.038	.0362
Avg	.0726	.0763	.0715	.0795	.0759	.0713	.0687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9113	1.9292	2.2144	2.4006	2.0069	2.4958	2.3916
2	1.8157	1.8976	2.0643	2.0957	1.8317	2.3053	2.2286
3	1.7042	1.8027	1.9892	1.9814	1.7202	2.0195	2.0111
4	1.6087	1.7394	1.8766	1.8671	1.6246	1.9243	1.8338
5	1.4972	1.6129	1.7828	1.7909	1.5609	1.8671	1.7394
6	1.3857	1.5181	1.7095	1.7147	1.4653	1.8671	1.7049
7	1.3698	1.5813	1.764	1.7337	1.545	1.829	1.6244
8	1.2264	1.4232	1.3283	1.7147	1.3916	1.829	1.2967
9	1.3757	1.5497	1.5813	1.6446	1.5971	1.6762	1.5023
10	1.3599	1.6762	1.7078	1.6762	1.8185	1.7394	1.7711
11	1.4864	1.7394	1.8185	1.8976	1.8343	1.7394	1.8976
12	1.4232	1.6288	1.8343	1.6762	1.8027	1.8027	1.8343
13	1.4864	1.6762	1.7394	1.6446	1.7394	1.7869	1.8343
14	1.6129	1.7236	1.7078	1.6604	1.7711	1.8501	1.9925
15	1.6129	1.8027	1.8976	1.8976	1.8976	1.8976	2.0241
16	1.6762	1.7394	1.9134	1.866	2.2862	1.9292	1.9591
17	1.5813	1.9031	2.4006	1.6405	2.2862	1.9024	1.7998
18	1.6762	2.0727	2.1719	1.752	2.1719	1.8481	1.6246
19	1.6446	1.9596	2.0957	1.752	2.0957	2.0293	1.7202
20	1.5971	1.9219	2.0576	1.6883	2.0576	1.9951	1.6565
21	1.7394	2.0161		1.8157	2.2481	1.9024	1.6883
22	1.866	2.1163		1.9909		2.0655	1.7998
23	2.1822	2.5897		2.2776	2.8578		2.0706
24	2.0069	2.1822	2.547	2.7054	2.2458	2.7054	
Max	2.1822	2.5897	2.547	2.7054	2.8578	2.7054	2.3916
Min	1.2264	1.4232	1.3283	1.6405	1.3916	1.6762	1.2967
Avg	1.6186	1.8251	1.9144	1.8702	1.9068	1.9568	1.8263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 203 / 11 KV SEWERAGE TREATMENT
PLANT Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2838	.5228	.3704	.4954	.473	.381	.4504
2	.2838	.4854	.3704	.4191	.4351	.3048	.4316
3	.2649	.4854	.3704	.381	.4351	.3429	.436
4	.2459	.4668	.3889	.3429	.4162	.3429	.4133
5	.2459	.5041	.4074	.4382	.4162	.4572	.3945
6	.2459	.4854	.4074	.4954	.4162	.5525	.263
7	.2081	.5228	.4074	.5716	.5865	.5716	.4133
8	.3973	.8029	.7095	.6478	.5601	.6097	.4108
9	.5041	.9149	.7842	.8402	.8215	.8962	.5788
10	.4854	1.1203	.9896	.9709	1.0456	1.1763	.5601
11	.5041	.9522	1.0082	.8589	.9896	1.0456	.6908
12	.6161	1.0456	.8775	.8589	.8775	.9896	.5975
13	.5415	.9896	.9709	.7095	.9335	.8589	.7842
14	.5415	.9896	.9709	.7655	.9522	.9149	.7095
15	.5041	.9522	1.0082	.8402	.8402	1.1016	.7095
16	.5041	.8775	.8215	.7468	.8192	.9709	.5297
17	.4854	.7946	.7621	.8135	.8002	.9383	.7567
18	.4668	.6048	.7049	.6054	.8764	.8069	.6054
19	.4854	.6054	.6668	.5676	.6478	.7514	.5486
20	.4294	.4919	.5335	.4919	.4954	.5636	.3595
21	.4854	.4162		.5297	.6097	.4508	.4919
22	.5228	.4347		.4351		.4508	.5297
23	.5041	.378		.5486	.4572		.5486
24	.3784	.5041	.378	.5716	.4919	.4572	
Max	.6161	1.1203	1.0082	.9709	1.0456	1.1763	.7842
Min	.2081	.378	.3704	.3429	.4162	.3048	.263
Avg	.4223	.6811	.6623	.6227	.6694	.6929	.5310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 204 / 11 KV PAN INDIA VASHI
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3575	.4108	.4403	.4572	.4225	.4191	.4859
2	.3575	.4108	.4403	.381	.4063	.381	.4673
3	.3575	.3921	.422	.3429	.39	.3429	.449
4	.3575	.3734	.422	.381	.3738	.3429	.4303
5	.3413	.3921	.4403	.381	.3575	.3048	.4112
6	.3575	.4108	.4036	.4191	.3575	.3429	.4112
7	.3575	.3921	.4036	.4572	.3575	.381	.4486
8		.5228	.4854	.4954	.4854	.4572	.4481
9	.4481	.6722	.7282	.7282	.6722	.7095	.5041
10	.4668	.9335	.8962	.9335	.9149	.8775	.6161
11	.4854	1.0082	1.0456	1.0456	1.0082	1.0456	.7468
12	.5041	1.0829	1.1203	1.1203	1.0456	1.0269	.7655
13	.4854	1.0642	1.1203	1.1389	1.0456	1.0269	.7282
14	.5041	1.0829	1.0642	1.0456	.9896	1.0642	.7655
15	.5041	1.1949	1.0829	1.0456	1.0642	1.1203	.7655
16	.5228	1.1949	1.1203	1.1203	1.0288	1.1016	.6501
17	.4668	1.0984	1.105	1.2676	.9907	.9719	.585
18	.5041	1.0984	.9526	.8776	.9526	.9355	.52
19	.4668	.909	.8192	.6826	.7621	.8232	.4875
20	.4668	.6818	.6097	.5525	.6478	.6355	.455
21	.4294	.606		.455	.5716	.5618	
22	.4294	.5308		.455		.5613	.4225
23	.4481	.4929		.455	.4954		.4063
24	.3738	.4294	.4929	.4572	.4225	.4954	
Max	.5228	1.1949	1.1203	1.2676	1.0642	1.1203	.7655
Min	.3413	.3734	.4036	.3429	.3575	.3048	.4063
Avg	.4344	.7244	.7436	.6956	.6853	.6926	.5441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 205 / 11 KV KESHAV KUNJ
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.4175	1.3104	1.4861	1.3837	1.5242	1.6977
2	1.2336	1.3643	1.2587	1.3336	1.3336	1.4861	1.6084
3	1.1503	1.3112	1.2242	1.2574	1.2336	1.4098	1.5369
4	1.0836	1.1694	1.2069	1.2193	1.1836	1.2765	1.467
5	1.0336	1.134	1.1897	1.1431	1.1336	1.1812	1.3611
6	.9669	1.0985	1.0345	1.105	1.0169	1.105	1.1104
7	.9002	1.1163	1.0345	1.0479	1.1003	1.0669	1.0365
8	.9002	1.0454	1.0631	1.0288	1.0985	1.0288	.9568
9	1.0277	1.0631	1.0631	1.0631	1.0277	1.0277	.9922
10	1.0631	1.1871	1.134	1.1517	1.1517	1.1871	1.1517
11	1.1694	1.3112	1.3112	1.3643	1.3466	1.3112	1.3289
12	1.258	1.2757	1.3289	1.2934	1.2757	1.3289	1.2757
13	1.1517	1.2934	1.2403	1.2403	1.2226	1.2403	1.3289
14	1.2403	1.3112	1.258	1.258	1.2934	1.3112	1.3998
15	1.3466	1.3289	1.3998	1.3112	1.3112	1.4352	1.3466
16	1.2934	1.258	1.2757	1.2403	1.4098	1.4883	1.267
17	1.1871	1.3484	1.4098	1.2336	1.4098	1.4833	1.2836
18	1.0985	1.311	1.4098	1.2336	1.2574	1.2688	1.1003
19	1.1517	1.3859	1.3717	1.1336	1.2955	1.3939	1.1669
20	1.1517	1.3672	1.3336	1.1836	1.3717	1.3403	1.2003
21	1.2226	1.3699		1.2836	1.5242	1.3224	1.2336
22	1.3643	1.5764		1.4003		1.5548	1.3503
23	1.5061	1.5601		1.4337	1.6766		1.5003
24	1.4337	1.4352	1.5451	1.6766	1.5504	1.6385	
Max	1.5061	1.5764	1.5451	1.6766	1.6766	1.6385	1.6977
Min	.9002	1.0454	1.0345	1.0288	1.0169	1.0277	.9568
Avg	1.1778	1.2933	1.2573	1.2551	1.2873	1.3222	1.2913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 206 / 11 KV LADIES HOSTELL, SEC SHEDDABLE URBAN
10, SA Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6032	1.773	1.6032	1.829	1.6032	3.0102	1.4682
2	1.5278	1.6975	1.5655	1.7147	1.6032	2.9721	1.4335
3	1.4901	1.7164	1.5466	1.6004	1.5655	2.934	1.4146
4	1.4335	1.6598	1.5278	1.5242	1.4901	2.8578	1.3929
5	1.4335	1.6409	1.5104	1.4861	1.4712	2.7816	1.3741
6	1.3957	1.6975	1.3783	1.5813	1.4146	2.7054	1.3553
7	1.5089	1.6787	1.6615	1.6766	1.6221	2.6673	1.6188
8	1.5844	1.7541	1.773	1.7909	1.7164	2.7054	1.6598
9	1.4146	1.5655	1.5278	1.5089	1.4901	2.6406	1.5844
10	1.3957	1.3957	1.3957	1.4523	1.4146	2.8292	1.4712
11	1.3203	1.3769	1.3203	1.358	1.3392	2.5652	1.3203
12	1.3014	1.3014	1.2826	1.3203	1.3392	2.5086	1.3203
13	1.4146	1.3014	1.226	1.226	1.2449	2.4897	1.2826
14	1.3375	1.4712	1.3203	1.3957	1.3392	2.9047	1.3203
15	1.3392	1.4335	1.4901	1.4712	3.0556	2.9235	1.5278
16	1.3014	1.1317	1.5278	1.3392	3.0102	2.9047	1.4523
17	1.4712	1.3957	1.6194	1.3203	2.934	2.6729	1.3203
18	1.4712	1.3957	1.6956	1.4712	3.0864	2.9741	1.5089
19	1.7353	1.6293	1.7528	1.7353	3.2007	1.6941	1.7164
20	1.8296	1.7828	1.9814	1.8107	3.2769	1.7882	1.8484
21	1.9239	1.7792		1.905	3.2007	1.92	1.8673
22	1.7918	1.8391		2.1125		1.8259	1.773
23	1.8107	1.773		1.9805	3.3532		1.7353
24	1.7353	1.8107	1.6787	1.9052	1.6975	3.0864	
Max	1.9239	1.8391	1.9814	2.1125	3.3532	3.0864	1.8673
Min	1.3014	1.1317	1.226	1.226	1.2449	1.6941	1.2826
Avg	1.5238	1.5834	1.5421	1.6048	2.0639	2.6244	1.5116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 207 / Sector 11 sanpada Bhoomi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4844	.5144	.5704	.5335	.519	.6097	.6655
2	.4325	.4801	.5324	.4572	.4325	.5335	.6655
3	.4152	.4801	.4753	.4191	.4152	.4572	.6465
4	.3806	.4458	.4753	.381	.3979	.4191	.6275
5	.346	.4115	.4563	.3429	.3806	.3429	.5324
6	.3114	.3429	.4183	.381	.3633	.3429	.4183
7	.3114	.3601	.4183	.4191	.3979	.3429	.3423
8	.3114	.4115	.3429	.4572	.3944	.381	.3429
9	.4115	.583	.583	.5658	.5144	.5144	.5144
10	.4287		.703	.7202	.7202	.703	.5316
11	.4458	.7716	.7888	.8402	.8402	.7888	.6344
12	.4458	.7888	.8573	.7888	.7716	.7716	.6344
13		.6687	.7545	.7202	.703	.7202	.6001
14	.4287	.7545	.7202	.6859	.703	.7888	.6344
15	.463	.7545	.7545	.7888	.7888	.8059	.6516
16	.463	.7716	.7716	.8059	.8002	.823	.6228
17	.4287	.816	.8002	.7266	.7621	.7796	.5882
18	.3772	.6439	.7621	.6574	.6859	.7225	.5882
19	.4287	.5687	.6668	.5882	.6097	.7225	.519
20	.3944	.4929	.5335	.5363	.5716	.5894	.519
21	.4287	.5308		.5363	.5335	.5704	.4844
22	.4801			.6055		.6275	.5017
23	.583	.6066		.6055	.6859		.5882
24	.5363	.5487	.6262	.6478	.6401	.6859	
Max	.583	.816	.8573	.8402	.8402	.823	.6655
Min	.3114	.3429	.3429	.3429	.3633	.3429	.3423
Avg	.4233	.5794	.6196	.5921	.5927	.6106	.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stn

Feeder No / Name : 209 / Cidco Exhibition

Centre, Vashi Feeder KV- 11 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0373	.038	.0572	.0561	.0381	
2	.0374	.0373	.057	.0572	.0561	.0381	
3	.0374	.0373	.057	.0572	.0561	.0381	
4	.0374	.0373	.057	.0572	.0561	.0572	
5	.0374	.056	.057	.0572	.0561	.0572	
6	.0374	.056	.057	.0381	.0561	.0381	
7	.0374	.0373	.057	.0381	.0561	.0381	.0381
8	.0561	.0373	.056	.0381	.056	.0381	.0373
9	.0373	.0373	.0373	.0373	.0373	.0373	.0373
10	.0373	.0373	.0373	.0373	.0373	.0373	.0373
11	.0373	.0373	.1494	.0373	.0373	.0373	.056
12	.0373	.0373	.2241	.0373	.0373	.0373	.0373
13	.0373	.0373	.1307	.0373	.0373	.0373	.0373
14	.0373	.4854	.0373		.0373	.0373	.0373
15	.0373	.6535	.0373	.0373		.0373	.0373
16	.0373	.0373	.0373	.0373	.0381	.0373	.0374
17	.0373	.0377	.0381	.0561	.0381	.038	.0561
18	.0373	.0377	.0381	.0374	.0381	.038	.0561
19	.0373	.0377	.0381	.0374	.0381	.038	.0561
20	.0373	.0377	.0381	.0561	.0381	.038	.0561
21	.056	.0377		.0561		.038	.0561
22	.056	.0377		.0561		.057	.0561
23	.0373	.0564		.0561	.0381		.0561
24		.056	.057	.0381	.0561	.0381	
Max	.0561	.6535	.2241	.0572	.0561	.0572	.0561
Min	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Avg	.0398	.0849	.0636	.0459	.0456	.0403	.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 401 / Feeder No1-33KV IC Sec14 NON SHEDDABLE EXPRESS HV FEEDERS
 Nerul Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		3.3048	3.3722	3.4294	3.3722	3.5437
24	3.9769					
Max	3.9769	3.3048	3.3722	3.4294	3.3722	3.5437
Min	3.9769	3.3048	3.3722	3.4294	3.3722	3.5437
Avg	3.9769	3.3048	3.3722	3.4294	3.3722	3.5437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 402 / Feeder No 2- 33KV IC NRI NON SHEDDABLE EXPRESS HV FEEDERS
 Sec 5 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		.4001	.4001	.4001	.4001	.4001
24	.4572					
Max	.4572	.4001	.4001	.4001	.4001	.4001
Min	.4572	.4001	.4001	.4001	.4001	.4001
Avg	.4572	.4001	.4001	.4001	.4001	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 417 / 33 KV IC SEC 30 NERUL STN NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.7209			3.6008	3.4465	
2		3.6145				3.4465	3.9209
3		3.4019			2.6235		3.6145
4		3.2956				3.2407	3.3488
5		3.1893			2.9835		3.1893
6		3.083				3.3436	3.1361
7		2.8704			3.035		3.083
8		2.8172			2.8292	2.9321	3.0298
9		.9036		2.2119	2.6749	2.572	2.8172
10		2.4188		2.1605	2.4691	2.6046	2.7641
11			2.5206	2.0576	2.4691	2.5514	2.7109
12			2.4177	1.9547	2.2634	2.4983	2.6578
13			2.4177	1.9547	2.4177	2.4451	2.6578
14			2.2634			2.4451	2.6046
15			2.4691	2.0062	2.4691	2.4451	2.5514
16			2.4177	2.4691	2.5206	2.4451	2.6046
17				2.4691		2.4451	2.7109
18			2.2634	2.4691		2.4983	2.6046
19			2.6235	2.9835	2.9321	2.7109	2.9767
20			3.3436	2.7263		3.083	3.3488
21			3.3436	3.3436	3.3951	3.2956	3.6145
22				3.5494	3.5494	3.7209	3.7209
23	3.7209		3.9095		3.9609	3.8803	3.774
24		3.7209		3.6523	3.7037	3.7551	
Max	3.7209	3.7209	3.9095	3.6523	3.9609	3.8803	3.9209
Min	3.7209	.9036	2.2634	1.9547	2.2634	2.4451	2.5514
Avg	3.7209	3.0033	2.7263	2.572	2.9351	2.9431	3.0655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 201 / 11 KV KL-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4394		2.4394		2.4949	
2	2.2546		2.3525			
3			2.2177			
4			2.1437			
5			2.2361			
6			2.3101			
7			2.4025			
8			2.1437			2.2546
9			2.0698			
10			2.0328			
11						2.0698
12			1.9631	1.9791		
13			2.0538	1.9791	2.0883	
14			1.9978			
15			2.0165			
16			2.0538	2.0144	1.9774	
17			2.1285		1.9404	
18			2.1845	2.0144	1.9404	
20			2.7166			
21						2.6981
24	2.6797	2.6057	2.7905		2.6981	2.7905
Max	2.6797	2.6057	2.7905	2.0144	2.6981	2.7905
Min	2.2546	2.6057	1.9631	1.9791	1.9404	2.0698
Avg	2.4579	2.6057	2.2239	1.9968	2.1899	2.4533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 202 / 11 KV B G SHIRKE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		.9945			
2	.9602		.8745			
3			.823			
4			.7888			
5			.823			
6			.8573			
7			.8916			
8			.8573			.8495
9			.8402			
10			.823			
11			.7716			.6241
12			.9313	.9465		
13			1.4373	.9465	.8589	
14			.929			
15			.9465			
16			.9816	.929	.7712	
17			.8413		.8063	
18			.7362	.7712	.8589	
20			.9709			
21						1.0166
24	1.0631	1.1317	1.166		1.0631	1.1616
Max	1.0631	1.1317	1.4373	.9465	1.0631	1.1616
Min	.9602	1.1317	.7362	.7712	.7712	.6241
Avg	1.0174	1.1317	.9142	.8983	.8717	.9130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3838			
2			2.1559			
3			1.8229			
4			1.7528			
5			1.7878			
6			1.8404			
7			1.8755			
8			1.7703			1.8755
9			1.7353			
10			1.7528			
11			1.7177			1.6476
12			1.531	1.6124		
13			1.701	1.6301	1.6478	
14			1.6655			
15			1.6655			
16			1.6655	1.7364	1.7541	
17			1.7364		1.7187	
18			1.8099	1.8073	1.7926	
20			2.3137			
21						2.4086
24	2.5941	2.5065	2.6292		2.6993	2.7343
Max	2.5941	2.5065	2.6292	1.8073	2.6993	2.7343
Min	2.5941	2.5065	1.531	1.6124	1.6478	1.6476
Avg	2.5941	2.5065	1.8656	1.6966	1.9225	2.1665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4272		2.4646			
2	2.2779		2.3525			
3			2.2032			
4			1.8671			
5			1.8671			
6			1.8858			
7			1.8671			
8			1.6804			1.7177
9			1.531			
10			1.5684			
11						1.6804
12			1.3603	1.5524		
13			1.5893	1.5524	1.643	
14			1.5074			
15			1.7002			
16			1.8111	1.8298	1.7551	
17			1.7372		1.7551	
18			1.6817	1.6804	1.7551	
20			2.0165			
21						2.0538
24	2.6326	2.6139	2.6326		2.7073	2.7073
Max	2.6326	2.6139	2.6326	1.8298	2.7073	2.7073
Min	2.2779	2.6139	1.3603	1.5524	1.643	1.6804
Avg	2.4459	2.6139	1.8591	1.6538	1.9231	2.0398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 205 / 11 KV SEC 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5133		2.4025			
2	2.2177		2.0698			
3			1.922			
4			1.8665			
5			1.922			
6			1.9589			
7			1.9959			
8			1.9774			.462
9			1.9404			
10			1.8665			
11			1.9774			.5359
12			1.9791	1.9959		
13			1.6842	1.9404	.5359	
14			1.6518			
15			1.9959			
16			2.0513	1.8111	.499	
17			1.9959		.499	
18			1.922	.499	.499	
20			2.5318			
21						.4066
24	2.6242	2.5503	2.7166		.5544	.5544
Max	2.6242	2.5503	2.7166	1.9959	.5544	.5544
Min	2.2177	2.5503	1.6518	.499	.499	.4066
Avg	2.4517	2.5503	2.0214	1.5616	.5175	.4897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 206 / 11 KV STP 12 FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218		.0739			
2	.3326		.0739			
3			.0739			
4			.0739			
5			.0739			
6			.0924			
7			.0739			
8			.1848			.3142
9			.0924			
10			.0924			
11						.3881
13			.168		.2587	
14			.168			
15			.3395			
16			.4854	.1848	.1109	
17			.3361		.1109	
18			.2054	.3511	.0739	
20			.2033			
21						.2402
24	.2241	.2957	.0739		.3142	.2218
Max	.3326	.2957	.4854	.3511	.3142	.3881
Min	.2218	.2957	.0739	.1848	.0739	.2218
Avg	.2595	.2957	.1603	.2680	.1737	.2911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 207 / SEC-9/E FEEDER NO-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2614			
2			.2241			
3			.1718			
4			.1624			
5			.1139			
6			.1158			
7			.1158			
8			.1568			.14
9			.1494			
10			.1587			
11			.1793			.2016
12			.1679	.1641		
13			.1283	.1735	.1301	
14			.0981			
15			.1547			
16			.1584	.1811	.1867	
17			.1641		.1584	
18			.166	.1905	.1452	
20			.168			
21						.2169
24	.2987	.2614	.2987		.2987	.2913
Max	.2987	.2614	.2987	.1905	.2987	.2913
Min	.2987	.2614	.0981	.1641	.1301	.14
Avg	.2987	.2614	.1657	.1773	.1838	.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 208 / SEC-9/E FEEDER NO-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.112
11						.1886
12			.1547	.1867		
13			.1547	.1962	.1679	
14			.1528			
15			.2056			
16			.215	.183	.1924	
17			.1962		.1886	
18			.166	.166	.1886	
20			.211			
21						.2433
24	.1867	.1736	.1979		.1718	.2054
Max	.1867	.1736	.215	.1962	.1924	.2433
Min	.1867	.1736	.1528	.166	.1679	.112
Avg	.1867	.1736	.1838	.1830	.1819	.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 209 / 11KV NEW LIG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0688		1.0364			
2	.9393		.9717			
3			.9231			
4			.9069			
5			.8907			
6			.9393			
7			.9717			
8			1.004			.9878
9			.9717			
10			.9717			
11						.9717
12			1.0374	.9431		
13			.9808	.8865	.9054	
14			.9431			
15			.9808			
16			.9997	.9242	.9054	
17			.9997		.9054	
18			.9997	.9997	.9242	
20			1.166			
21						1.3203
24	1.2631	1.1012	1.1336		1.1336	1.2308
Max	1.2631	1.1012	1.166	.9997	1.1336	1.3203
Min	.9393	1.1012	.8907	.8865	.9054	.9717
Avg	1.0904	1.1012	.9909	.9384	.9548	1.1277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.127	.1344	.1321	.1195	.1285	.112	.1307
2	.1344	.1307	.1303	.1214	.1176	.112	.1344
3	.1307	.127	.1249	.1232	.1213	.1083	.127
4	.1232	.1232	.1303	.1139	.1122	.1046	.1232
5	.1158	.1195	.1339	.1195	.1122	.1046	.1195
6	.1139	.112	.1122	.1232	.1158		.1158
7	.112		.0977	.112	.1104		.1158
8	.1102	.1344	.114		.1303		.1102
9		.1979	.1755	.2091	.1755	.2651	.2045
10	.1494	.362	.3473	.3174	.366		.3457
11	.1606	.5321	.5228	.5975	.5452	.6722	
12	.1942	.5882		.6161	.5975	.6161	.5176
13	.1867	.59	.3118	.6012	.6348	.6236	.514
14	.1792	.5683	.6572	.5601	.6161	.5601	.5104
15	.1792	.5774	.6497	.5975	.5975	.5975	.5448
16		.6045	.6722	.6199	.5713	.6255	.5267
17		.5466	.5601	.5756	.6012	.5564	.4543
18		.4398	.4668	.4543	.4929	.4854	.3873
19		.3348	.3734	.3529	.3846	.4332	.3005
20	.2465	.2425	.2651	.257	.2614	.2745	.2081
21	.1904	.1647	.1718	.1973	.1792	.1811	.1738
22	.168	.1484	.1531	.1466	.1419	.1512	.1231
23	.1419	.1394	.1307		.1232	.1307	
24	.1251	.1568	.1466	.1195	.1321	.1158	.127
Max	.2465	.6045	.6722	.6199	.6348	.6722	.5448
Min	.1102	.112	.0977	.112	.1104	.1046	.1102
Avg	.1520	.3076	.2861	.3207	.3070	.3415	.2688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							3.0493
2							2.8645
3							2.5873
4							2.5133
5							2.4025
6							2.3101
7	2.2177			2.5873	2.6139		2.3101
8	2.2177			2.3655	2.4272	2.5393	
9	2.2177	2.2405	2.3152	2.4025		2.2405	
10	2.3101	2.3655			2.4272	2.4272	
11	2.4394	2.2546		2.3655		2.2546	.6653
12	2.2916		2.2405		2.2177	2.2546	
13				2.2177	2.2916	2.2177	2.4394
14			2.1285	2.2177		2.2916	
15		2.2546	2.4025		2.4025		
16			2.4025	2.3285	2.3655		2.7166
17	2.2546	2.2546	2.2546	2.4394	2.2916	2.2546	2.5133
18			2.3101			2.5873	
19			2.5873	2.8006		2.5873	2.5393
20	2.726	2.8753	2.7721	2.9874	3.062	2.809	2.9127
21			2.9569	3.0994	3.062	2.9569	3.0247
22			3.0493			3.1417	
23			3.4743	3.5475	3.6222	3.5113	3.3981
24	3.0493	3.2114	3.0994	3.3265	3.2114	3.4728	3.2895
Max	3.0493	3.2114	3.4743	3.5475	3.6222	3.5113	3.3981
Min	2.2177	2.2405	2.1285	2.2177	2.2177	2.2177	.6653
Avg	2.4138	2.4938	2.6149	2.6681	2.6662	2.6364	2.596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO
 STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478			.0057			.1478
2	.1478			.0057			.1478
3	.1478			.0057			.1478
4	.1478			.0057			.1478
5	.1478			.0057			.1478
6	.1478						.1478
7	.1478			.0739	.1509		.1478
8	.1478			.1478	.112	.1509	
9	.1109	.1143	.1132	.1848		.1494	
10		.1848			.1494	.1509	
11	.1109	.1848		.1848		.1478	.1109
12	.1109		.1524		.1478	.1478	
13				.1848	.1848	.1848	.1478
14			.1509	.1478		.1848	
15		.1478	.1658		.1478		
16			.1478	.1478	.1478		.1478
17	.1478	.1478	.1478	.1478	.1478	.1848	.1109
18			.037				
19			.0095	.1509		.1848	.1509
20	.1143	.1524	.0095	.1509	.1132	.1848	.1494
21			.0095	.1433	.112	.1848	.1509
22			.0057			.1478	
23			.0057	.1075	.1509	.1478	.1509
24	.1478	.1143	.1143	.0057	.112	.1132	.1478
Max	.1478	.1848	.1658	.1848	.1848	.1848	.1509
Min	.1109	.1143	.0057	.0057	.112	.1132	.1109
Avg	.1375	.1495	.0822	.1004	.1397	.1617	.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185			.0187			.0185
2	.0185			.0185			.0185
3	.0185			.0187			.0185
4	.0185			.0185			.0185
5	.0185			.0185			.0185
6	.0185			.0187			.0185
7	.0185			.0187	.0189		.1478
8	.0185			.0185	.0189	.0189	
9	.0185	.0191		.0185		.0189	
10	.0185	.0189			.0189	.0187	
11	.0189	.0189		.0189		.0189	.0189
12	.0189		.0189		.0189	.0189	
13				.0189	.0189	.0189	.0189
14			.0191	.0189		.0189	
15		.0189	.0185		.0189		
16			.0185	.0189	.0189		.0189
17	.0189	.0754	.0185	.0189	.0189	.0189	.0189
18			.0187				
19			.0185	.0189		.0185	.0189
20	.0191	.0191	.0185	.0189	.0189	.0187	.0189
21			.0185	.0189	.0189	.0185	
22			.0185			.0185	
23			.0185	.0189	.0189	.0185	.0189
24	.0185	.0191	.0191	.0185	.0189	.0189	.0185
Max	.0191	.0754	.0191	.0189	.0189	.0189	.1478
Min	.0185	.0189	.0185	.0185	.0189	.0185	.0185
Avg	.0186	.0271	.0187	.0187	.0189	.0188	.0273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7721			2.9874			3.3265
2	2.5873			2.7721			3.0493
3	2.5873			2.6797			2.8645
4	2.5133			2.4025			2.4394
5	2.4025			2.4025			2.4025
6	2.2916			2.4394			2.2916
7	2.2916			2.4394	2.4356		2.2916
8	2.2177			2.4394	2.4646	2.3899	
9	2.2546	2.4646		2.4949		2.364	
10	2.3655	2.2916	2.4646		2.2405	2.3899	
11	2.4394	2.2916		2.2177		2.2916	2.5133
12	2.3655		2.2405		2.2177	2.2177	
13				2.2177	2.2916	2.2177	2.2916
14			2.2405	2.2916		2.2916	
15		2.2916	2.5873		2.4394		
16			2.4949	2.3655	2.2177		2.5133
17	2.2177	2.2177	2.3655	2.2916	2.4394	2.2177	2.3655
18			2.3655			2.2177	
19			2.809	2.6139		2.5873	2.6139
20	2.9874	2.9874	2.9569	2.9264	3.0087	2.9569	2.7938
21			3.1047	3.062	3.2114	3.3265	
22			3.3265			3.3265	
23			3.77	3.5818	3.6534	3.6961	3.5101
24	2.9569	3.5101	3.5101	3.3265	3.219	3.3669	3.6222
Max	2.9874	3.5101	3.77	3.5818	3.6534	3.6961	3.6222
Min	2.2177	2.2177	2.2405	2.2177	2.2177	2.2177	2.2916
Avg	2.4834	2.5792	2.7874	2.6291	2.6533	2.6572	2.7259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6797			2.9569			3.1417
2	2.4949			2.7721			2.9199
3	2.2177			2.5873			2.5873
4	1.9959			2.4025			2.3101
5	1.9959			2.2177			2.2177
6	1.9959			2.2177			2.0698
7	1.9959				2.2565		2.0698
8	1.922			2.3655	2.0774		
9	1.9404	2.1658		2.3655		2.2923	
10	2.1437	2.2177	2.1948		2.2923	2.2923	
11	2.0698	2.2177		2.2177		2.2916	2.5873
12	1.848		2.0485		2.2177	2.3285	
13				2.2177	2.1437	2.1437	2.2916
14			1.9753	2.1807		2.2177	
15		1.9959	2.0328		2.2916		
16			2.1437	2.2177	2.2177		2.2177
17	2.0144	1.848	1.922	2.0698	2.0698	2.0698	2.2177
18			1.922			1.9959	
19			2.3655	2.364		2.3655	2.2923
20	2.4143	2.268	2.4394	2.5072	2.4356	2.4394	2.4356
21			2.5873	2.6505	2.6505	2.6612	
22			2.8829			2.8829	
23			3.4004	3.3669	3.2952	3.4004	2.9371
24	2.9569	3.1459	2.9995	3.1786	3.0087	1.3611	3.3265
Max	2.9569	3.1459	3.4004	3.3669	3.2952	3.4004	3.3265
Min	1.848	1.848	1.922	2.0698	2.0698	1.3611	2.0698
Avg	2.1790	2.2656	2.3780	2.492	2.4131	2.3387	2.5081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175			.5544			.5175
2	.4805			.5175			.4805
3	.5175			.5175			.4805
4	.5544			.5175			.4805
5	.4805			.5175			.5175
6	.4435			.5175			.5175
7	.4435				.6805		.5544
8	.5175			.8131	.7522	.788	
9	.5175	1.0562		1.0719		1.0829	
10	.4805	1.1827	1.0562		1.2178	1.2178	
11	.5175	1.2567		1.1827		1.2567	.6283
12	.5544		1.3203		1.2936	1.1827	
13				1.3676	1.3306	1.1827	.5914
14			1.3203	1.1458			
15		1.2936	1.1827		1.2197		
16			1.0349	1.1088	1.0719		.5175
17	.5175	.924	.8871	.924	1.0719	.924	.5914
18			.8131			.7762	
19			.7023	.7316		.7392	.5487
20	.5281	.6413	.6653	.7095	.6516	.6653	.5975
21			.6283	.6089	.6173	.6653	
22			.6653			.5914	
23			.6283	.6219	.6516	.5914	.5373
24	.5175	.5281	.6413	.6283	.5731	.6268	.5544
Max	.5544	1.2936	1.3203	1.3676	1.3306	1.2567	.6283
Min	.4435	.5281	.6283	.5175	.5731	.5914	.4805
Avg	.5059	.9832	.8881	.7809	.9277	.8779	.5410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 207 / 11 kv khandeshwar railway NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 stn Feeder KV- 11 / OUTGOING (NON CONTINOUS PROCESS)(NO
 STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739			.0739			.0739
2	.0739			.0739			.0739
3	.0739			.0739			.0739
4	.0739			.0739			.0739
5	.0739			.0739			.0739
6	.0381			.0739			.0381
7	.0122			.0152	.0686		.0152
8	.0122			.0137	.0686	.0343	
9	.0114	.0244		.0137		.0343	
10	.0114	.0739	.0267		.0686	.0343	
11	.0152	.0739		.0152		.037	
12	.0739		.0427		.0739	.0185	.0739
13				.0739	.0152	.037	.0739
14			.0427	.0152			
15		.0739	.0114		.0152		
16			.0114	.0152	.0739		.0739
17	.0152	.0152	.0114	.0152	.0152	.037	.0152
18			.0152			.0152	
19			.037	.0716		.0381	.0686
20	.0526	.0526	.0739	.0373	.0366	.0739	.0343
21			.0739		.0343	.0739	
22			.0739			.0739	
23			.0739	.0366	.0343	.0739	.0343
24	.0739	.0686	.0686	.0739	.0343	.0343	.0739
Max	.0739	.0739	.0739	.0739	.0739	.0739	.0739
Min	.0114	.0152	.0114	.0137	.0152	.0152	.0152
Avg	.0457	.0546	.0433	.0467	.0449	.0440	.0581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 208 / MGM (EXPRESS)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-APR-18
HR	Load (MW)
11	.0739
Max	.0739
Min	.0739
Avg	.0739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566		.0566		.0566	
2		.0566		.0566		.0566	
3		.0566		.0566		.0566	
4	.0549	.0566	.0549	.0566	.0549	.0566	.0549
5		.0566		.0566		.0566	
6		.0566		.0566		.0566	
7	.0549	.0566	.0549	.0566	.0549	.0566	.0549
8	.0566		.0566		.0566		.0566
9	.0566		.0566		.0566		.0566
10	.0566		.0566		.0566		.0566
11	.0566		.0566		.0566		.0566
12	.0566	.0549	.0566	.0549	.0566	.0549	.0566
13	.0566		.0566		.0566		.0566
14	.0566		.0566		.0566		.0566
15	.0566		.0566		.0566		.0566
16	.0566	.0549	.0566	.0549	.0566	.0549	.0566
17	.0566		.0566		.0566		.0566
18	.0566		.0566		.0566		.0566
19	.0566		.0566		.0566		.0566
20	.0566	.0549	.0566	.0549	.0566	.0549	.0566
21	.0566		.0566		.0566		.0566
22	.0566		.0566		.0566		.0566
23	.0566	.0549	.0566	.0549	.0566	.0549	.0566
24	.0549	.0566	.0549	.0566	.0549	.0566	.0549
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0549	.0549	.0549	.0549	.0549	.0549	.0549
Avg	.0563	.0560	.0563	.0560	.0563	.0560	.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.3951		3.3196		3.2065	
2		3.1121		3.0933		2.9424	
3		2.8292		2.8292		2.7161	
4	2.396	2.452	2.6703	2.5274	2.6886	2.6029	2.7252
5		2.452	2.7726	2.5463		2.6406	
6		2.9235	2.7726	2.7538		2.6406	
7	2.4143	3.3951	2.7915	2.8669	2.7984	2.8669	2.6155
8	2.6783		2.9424		3.0178		2.8292
9	3.0556		3.0933		3.0556		3.2065
10	3.1121				3.1121		3.3196
11	3.1687				3.3008		3.3196
12	3.0933	3.0544		3.1824	3.0556	3.0361	3.1687
13	3.1121				2.9235		3.0933
14	3.0178		2.1125		3.0178		3.131
15	2.9047		3.9609		3.0556		3.4328
16	3.1687		3.263	2.8898	2.8292	2.8166	3.0556
17	2.9424		3.2065				2.8292
18	2.8669		2.9424		2.6029		2.7915
19	3.0556		3.6969		3.4705		3.5082
20	3.2819	3.219	3.4705	3.4385	3.546	3.3836	3.6969
21	3.3951		3.6214		3.81		3.7346
22	3.4328		3.7346		3.7723		3.7346
23	3.9609	3.6214	4.225	3.6763	3.9986	3.9689	3.81
24	3.1276	3.7723	3.5117	3.5837	3.4568	3.6969	3.658
Max	3.9609	3.7723	4.225	3.6763	3.9986	3.9689	3.81
Min	2.396	2.452	2.1125	2.5274	2.6029	2.6029	2.6155
Avg	3.0624	3.1115	3.2228	3.0589	3.1951	3.0432	3.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3011		2.452		2.4143	
2		2.0748		2.2257		2.1691	
3		1.9239		2.037		1.9993	
4	1.8473	1.8861	1.9936	1.9616	2.0119	1.9616	2.0485
5		1.8861		1.9805		1.9805	
6		1.9993		2.1125		2.037	
7	1.9753	2.2257	2.2497	2.3011	2.1765	2.3388	2.0485
8	2.4143		2.2634		2.2634		2.2634
9	2.3388		2.1125		2.3011		2.3765
10	2.2634		2.1125		2.1879		2.2634
11	2.0748				2.0748		2.1125
12	2.037	1.9387		1.957	1.9239	1.8656	2.037
13	1.9805				1.9993		2.0748
14	1.9805				1.9805		1.9993
15	1.9616		2.4143		1.9805		2.1125
16	1.9616	1.7741	2.2257	1.8473	1.9239	1.829	2.037
17	1.905		2.0748		1.9239		1.9427
18	2.0748		1.9805		1.9805		2.037
19	2.3011		2.4143		2.452		2.452
20	2.452	2.5057	2.5274	2.524	2.7161	2.4691	2.6029
21	2.4897		2.7161		2.6406		2.5652
22	2.4897		2.6972		2.6783		2.452
23	2.5652	2.5423	2.8669	2.7069	2.7915	2.652	2.6783
24	2.396	2.5274	2.396	2.6783	2.5789	2.6783	2.6337
Max	2.5652	2.5423	2.8669	2.7069	2.7915	2.6783	2.6783
Min	1.8473	1.7741	1.9805	1.8473	1.9239	1.829	1.9427
Avg	2.1847	2.1321	2.3363	2.2320	2.2413	2.1996	2.2493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4897		2.6783		2.584	
2		2.2634		2.452		2.3577	
3		2.0748		2.2634		2.1691	
4	1.9022	1.9993	2.1216	2.0748	2.2314	2.0748	2.0851
5		2.037		2.0748		2.037	
6		2.1125		2.2257		2.0748	
7	1.829	2.2634	2.1948	2.3388	2.2497	2.2822	2.0302
8	2.1502		2.2634		2.2634		2.1691
9	2.1879		2.1691		2.1502		2.2634
10	2.3011		2.0748		2.0748		2.2257
11	2.2257		1.8861		2.037		2.2257
12	2.1125	1.9387	1.9805	2.0668	1.9805	1.9387	2.2257
13	2.037		1.8484		1.9239		2.1125
14	2.0748		1.8107		2.037		2.1879
15	2.0748		2.1125		2.0748		2.4143
16	2.1125	1.9387	1.9616	1.957	2.1125	1.9022	2.3011
17	2.1313		1.9616		2.0748		2.2634
18	2.4143		2.1502		2.2634		2.4143
19	2.6595		2.5652		2.6783		2.8292
20	2.7915	2.6155	2.7915	2.7252	2.9047	2.7984	2.8669
21	2.9047		2.9424		3.1687		2.9801
22	2.8481		3.0933		3.1121		2.9235
23	2.8292	2.7618	3.0933	3.0361	3.0933	2.9813	2.8292
24	2.5606	2.7161	2.6886	2.9047	2.8349	2.9047	2.8898
Max	2.9047	2.7618	3.0933	3.0361	3.1687	2.9813	2.9801
Min	1.829	1.9387	1.8107	1.957	1.9239	1.9022	2.0302
Avg	2.3235	2.2676	2.3005	2.3998	2.3824	2.3421	2.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.0556		3.1687		3.131	
2		2.8292		2.9424		2.9047	
3		2.6029		2.6783		2.6406	
4	2.2862	2.4143	2.5423	2.5274	2.5972	2.4897	2.5972
5		2.452		2.4897		2.4897	
6		2.5274		2.5274		2.5463	
7	2.3411	2.6029	2.5789	2.5652	2.6703	2.6783	2.5606
8	2.5463		2.6406		2.4897		2.5652
9	2.5652		2.4897		2.3388		2.4897
10	2.452		2.3765		2.3011		2.4143
11	2.2257		2.1879		2.3011		2.3388
12	2.4143	2.0119	1.9993	2.1399	2.1502	2.0119	2.3388
13	2.3577		2.1502		2.1125		2.3765
14	2.3765		2.037		2.2257		2.4897
15	2.4143		2.1879		2.3011		2.6406
16	2.452	2.0302	2.1691	2.1399	2.2634	2.2131	2.4897
17	2.452		2.2257		2.3011		2.5463
18	2.6595		2.3765		2.5463		2.7538
19	2.8669		2.9047		3.0556		3.2442
20	3.1687	2.9995	3.131	3.0544	3.3951	3.1276	3.2442
21	3.1687		3.2442		3.3951		3.3196
22	3.2065		3.4328		3.4328		3.3573
23	3.4705	3.4751	3.6214	3.5665	3.5837	3.5117	3.546
24	3.1093	3.3573	3.3288	3.3951	3.3288	3.3951	3.3288
Max	3.4705	3.4751	3.6214	3.5665	3.5837	3.5117	3.546
Min	2.2257	2.0119	1.9993	2.1399	2.1125	2.0119	2.3388
Avg	2.6597	2.6965	2.6118	2.7662	2.6731	2.7616	2.7706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754		.0754		.0754	
2		.0566		.0754		.0754	
3		.0566		.0566		.0754	
4	.0732	.0566	.0732	.0566	.0732	.0566	.0732
5		.0566		.0566		.0566	
6		.0566		.0754		.0566	
7		.0754	.0549	.0754	.0732	.0754	.0732
8	.1509		.0754		.0754		.0754
9	.1509		.132		.1509		.1509
10	.1509		.1509		.1509		.1509
11	.1509		.1509		.1509		.132
12	.132	.1463	.132	.128	.1509	.1463	.1509
13	.132		.0754		.1509		.1509
14	.132		.132		.1509		.1509
15	.1509		.132		.1509		.1509
16	.132	.1463	.132	.1097	.132	.128	.1509
17	.1509		.0754		.0754		.1509
18	.1509		.1509		.1509		.1509
19	.1509		.1509		.1509		.1509
20	.1509	.128	.1509	.1463	.1509	.1463	.1509
21	.1509		.1509		.1509		.1509
22			.1509		.0754		.0754
23		.0549	.0754	.1463	.0566	.0732	.0754
24	.0732	.0754	.0549	.0754	.0732	.0754	.0732
Max	.1509	.1463	.1509	.1463	.1509	.1463	.1509
Min	.0732	.0549	.0549	.0566	.0566	.0566	.0732
Avg	.1365	.0821	.1158	.0898	.1208	.0867	.1257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 210 / SPARE OUTGOING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18
HR	Load (MW)
4	.0732
Max	.0732
Min	.0732
Avg	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 211 / BHAGWATI HEIGHTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3203		1.358		1.3769	
2		1.1694		1.1694		1.2826	
3		1.0562		1.094		1.1694	
4	.9511	.9808	1.0974	1.0562	1.0974	1.0562	1.0974
5		1.0185		1.0374		1.0185	
6		1.0562		1.1128			
7	.9511	1.1694	1.262	1.1694	1.1706	1.1694	1.1523
8	1.0751		1.1694		1.1694		1.1694
9	1.094		1.1317		1.1317		1.1506
10	1.1694		1.0562		1.094		1.1694
11	1.2449		1.0751		1.0751		3.7723
12	1.1128	1.0059	1.0185	1.0242	1.0751	1.0242	1.2449
13	1.094		.9619		1.0185		1.1883
14	1.1317		.9808		1.0751		1.1506
15	1.2071		1.0751		1.094		1.2826
16	1.1128	.9877	1.0562	1.0791	1.1317	1.0791	1.2071
17	1.1317		1.0374		1.1128		1.1506
18	1.2826		1.094		1.3203		1.3014
19	1.4146		1.4146		1.5278		1.4901
20	1.4712	1.4266	1.4712	1.4998	1.5466	1.4815	1.5278
21	1.4901		1.4901		1.5089		1.4901
22	1.3769		1.5089		1.5278		1.4523
23	1.4712	1.4815	1.6787	1.6095	1.6787	1.5546	1.5089
24	1.3717	1.4901	1.4632	1.5655	1.4815	1.5278	1.4632
Max	1.4901	1.4901	1.6787	1.6095	1.6787	1.5546	3.7723
Min	.9511	.9808	.9619	1.0242	1.0185	1.0185	1.0974
Avg	1.2186	1.1802	1.2128	1.2313	1.2546	1.2491	1.4194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 212 / SHIVSENA OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089		1.5844		1.5844	
2		1.3203		1.4335		1.4335	
3		1.1694		1.2449		1.2826	
4	1.1157	1.1317	1.1706	1.2071	1.2803	1.2449	1.134
5		1.1694		1.2071		1.226	
6		1.1694		1.226			
7	1.0242	1.358	1.2071	1.3392	1.2986	1.358	1.1523
8	1.4146		1.2826		1.358		1.3203
9			1.3203		1.4146		1.4712
10	1.4146		1.3203		1.3203		1.4335
11	1.4523		1.3392		1.2826		1.3957
12	1.3392	1.2071	1.3203	1.2254	1.3203	1.262	1.3392
13	1.4146		1.2826		1.3014		1.3203
14	1.4146		1.2071		1.2449		1.2826
15	1.4335		1.2071		1.3203		1.3957
16	1.3392	1.1157	1.2826	1.2803	1.3392	1.2437	1.3392
17	1.1506		1.1506		1.226		1.3014
18	1.1317		1.0751		1.1694		1.226
19	1.2826		1.2826		1.3957		1.3769
20	1.3392	1.3169	1.4335	1.39	1.4335	1.4266	1.4712
21	1.5089		1.3957		1.5089		1.5278
22	1.4523		1.5844		1.6221		1.5278
23	1.6221	1.6278	1.773	1.7741	1.8107	1.7193	1.7353
24	1.5364	1.6598	1.5912	1.7164	1.6461	1.773	1.6461
Max	1.6221	1.6598	1.773	1.7741	1.8107	1.773	1.7353
Min	1.0242	1.1157	1.0751	1.2071	1.1694	1.226	1.134
Avg	1.3548	1.3129	1.3277	1.3857	1.3838	1.414	1.3893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861		1.9239		2.037	
2		1.6975		1.8107		1.8861	
3		1.5466		1.6975		1.7353	
4	1.4632	1.5089	1.5364	1.6598	1.5364	1.6221	1.6461
5		1.5466		1.6975		1.6598	
6		1.6221		1.6221			
7	1.4632	1.773	1.6095	1.6975	1.6461	1.8107	1.5729
8	1.7353		1.6975		1.6975		1.6598
9	1.8861		1.7353		1.8484		1.8861
10	1.8861		1.773		1.773		1.8107
11	1.8861		1.6598		1.6975		1.7353
12	1.7353	1.5729	1.5466	1.6461	1.6975	1.5364	1.6975
13	1.6975		1.5466		1.6598		1.7353
14	1.6975		1.5089		1.6221		1.6975
15	1.6975		1.6598		1.5844		1.8484
16	1.6598	1.4998	1.5466	1.5364	1.5466	1.4998	1.7353
17	1.6221		1.4335		1.5844		1.5466
18	1.5844		1.5089		1.5089		1.5466
19	1.8484		1.8107		1.9616		1.9616
20	1.9239	1.9022	1.9239	1.9022	2.037	1.8656	1.9616
21	1.9993	1.9022	1.9616		2.1125		1.9993
22	2.037		2.0748		2.1879		2.037
23	2.1879	4.1701	2.2634	2.1948	2.2634	2.2314	2.1125
24	1.9753	2.037	1.9753	2.1502	2.0485	2.1879	2.1948
Max	2.1879	4.1701	2.2634	2.1948	2.2634	2.2314	2.1948
Min	1.4632	1.4998	1.4335	1.5364	1.5089	1.4998	1.5466
Avg	1.7887	1.8973	1.7248	1.7949	1.7902	1.8247	1.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9616		1.358		1.9239	
2		1.8861		1.358		1.9616	
3		1.8484		1.3203		1.8861	
4	1.829	1.8861	1.8656	1.3203	1.9022	1.8861	2.1948
5		1.9616		1.358		1.8861	
6		1.9993		1.3203			
7	1.6095	1.773	1.6461	1.7353	2.268	2.2634	2.1948
8	1.9616		1.9616		2.4143		2.4143
9	2.1125		2.1125		3.3196		2.9801
10	2.9424		2.1879		3.4705		3.3951
11	2.6783		2.2634		3.3951		3.4705
12	3.0178	3.4751	2.2257	3.8409	3.7723	3.9872	3.3196
13	2.3011		2.1125		3.0933		3.3196
14	2.3388		2.1125		3.6969		
15	2.452		2.4143		3.9232		3.5837
16	3.1687	3.7677	2.3388	3.7311	3.8477	3.5482	3.6214
17	2.4897		2.1125		3.7723		3.1687
18	2.7161		1.7353		2.9424		3.0556
19	2.2634		1.6221		2.5652		2.3011
20	2.1125	2.1948	1.5089	2.3045	2.1879	2.4143	2.3388
21	2.4143	2.0851	1.5089		2.1502		2.3388
22	1.9616		1.4335		2.2257		2.452
23	2.037	2.0851	1.3957	2.1216	2.1125	2.4874	2.3388
24	2.0119	2.0748	2.0119	1.3957	2.0119	2.3388	2.3411
Max	3.1687	3.7677	2.4143	3.8409	3.9232	3.9872	3.6214
Min	1.6095	1.773	1.3957	1.3203	1.9022	1.8861	2.1948
Avg	2.3378	2.2307	1.9247	1.9303	2.8985	2.4166	2.8238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224015 / 33/11 KV ROADPALI SUBSTATION

Feeder No / Name : 205 / NEW SECTOR NO. 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		2.2497	2.0119
2		2.32	1.9753
3		1.7741	1.7558
4		1.7558	1.6827
5		1.7353	1.5729
6		1.4937	1.4632
7		1.5729	1.5181
8		1.5089	1.4815
9		1.5655	1.4998
10		1.4632	1.4083
11		1.4266	1.4712
12		1.3535	1.4998
13		1.3535	1.6057
14		1.4998	1.6975
15		1.5729	1.8111
16		1.531	1.6991
17		1.4083	1.643
18	1.7558	1.5497	1.4998
19	1.8839	1.7375	1.8656
20	2.0351	1.9022	1.8839
21	2.0851	1.9387	1.9204
22	2.2032	2.1399	1.9936
23	2.0119	2.2314	2.1582
24		2.5019	2.1216
Max	2.2032	2.5019	2.1582
Min	1.7558	1.3535	1.4083
Avg	1.9958	1.7328	1.7183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 201 / 11 kv pl no.39, sec-27 SHEDDABLE URBAN
feeder Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0343			.0343
4				.0343			.0171
6	.0171	.0171		.0171	.0171		.0171
7		.0171			.0171		
8	.0171	.0171	.0343	.0171	.0343		.0171
9	.0171			.0171	.0171		
10	.0171	.0171	.0171			.0171	.0171
11	.0171	.0343		.0343		.0171	
12	.0171	.0343	.0171	.0171	.0343		.0171
13	.0171	.0171		.0171		.0171	.0171
14	.0171	.0171	.0171	.0171			
15	.0171	.0171		.0171	.0171	.0171	.0343
16	.0171	.0171	.0171				
17	.0171			.0171		.0171	
18	.0171		.0171	.0171			
19	.0171			.0171	.0343	.0171	
20		.0343	.0171	.0171			.0343
21						.0171	
22			.0343				
23			.0343	.0343		.0343	
24	.0171		.0171	.0343	.0343	.0343	.0343
Max	.0171	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0218	.0223	.0225	.0257	.0209	.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 207 / 11 kv Juhi developers SHEDDABLE URBAN
 feeder Feeder KV- 11 /
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.0631			1.2346
4				1.2003			1.2003
6	.8745	.823		1.0288	.9774		1.0631
7		.8573			.8916		
8	.7888	.9774	.823	.7545	.7888		.7202
9	.823			.823	.823		
10	.9602	.8573	.8573			.8745	.7545
11	.9774	.823		.7888		.823	
12	.8745	.8573	.7545	.8402	.823		.9774
13	.9774	.9088		.8402		.7545	.9259
14	.9774	.8402	.7202	.8573			
15	1.0974	.823		.8573	.9774	.8573	1.2689
16	1.0631	.8916	.8573				
17	1.0974			1.0117		.9259	
18	1.166		1.046	1.0288			
19	1.2346			1.0802	.9774	1.046	
20		1.046	1.0288	1.2003			1.2003
21				1.0288		.8916	
22			1.0288				
23			1.0631	1.3717		1.2003	
24	1.286		.8745	1.0631	1.3203	1.1488	1.2689
Max	1.286	1.046	1.0631	1.3717	1.3203	1.2003	1.2689
Min	.7888	.823	.7202	.7545	.7888	.7545	.7202
Avg	1.0141	.8823	.9054	.9905	.9474	.9469	1.0614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 208 / 11KV Station Transformer SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0171			.0171
4				.0171			.0171
6	.0171			.0171	.0171		.0171
7		.0171			.0171		
8	.0171	.0171	.0171	.0171	.0171		.0171
9	.0171				.0171		
10	.0171	.0171	.0171			.0171	.0171
11	.0171	.0171		.0171		.0171	
12	.0171	.0171	.0171	.0171	.0171		.0171
13	.0171	.0171		.0171		.0171	.0171
14	.0171	.0171	.0171	.0171			
15	.0171	.0171		.0171	.0171	.0171	.0171
16	.0171	.0171	.0171				
17	.0171			.0171		.0171	
18	.0171		.0171	.0171			
19	.0171			.0171	.0171	.0171	
20		.0171	.0171	.0171			.0171
21				.0171		.0171	
22			.0171				
23			.0171	.0171		.0171	
24	.0171		.0171	.0171	.0171	.0171	.0171
Max	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 212 / 11 kv Ramsheth thakur SHEDDABLE URBAN
 feeder Feeder KV- 11 /
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0171			.0171
4				.0171			.0171
6	.0171	.0171		.0171	.0171		.0171
7		.0171			.0171		
8	.0171	.0171	.0171	.0171	.0171		.0171
9	.0171			.0171	.0171		
10	.0171	.0171	.0171			.0171	.0171
11	.0171	.0171		.0171		.0171	
12	.0171	.0171	.0171	.0171	.0171		.0171
13	.0171	.0171		.0171		.0171	.0171
14	.0171	.0171	.0171	.0171			
15	.0171	.0171		.0171	.0171	.0171	.0171
16	.0171	.0171	.0171				
17	.0171			.0171		.0171	
18	.0171		.0171	.0171			
19	.0171			.0171	.0171	.0171	
20		.0171	.0171	.0171			.0171
21				.0171		.0171	
22			.0171				
23			.0171	.0171		.0171	
24	.0171		.0171	.0171	.0171	.0171	.0171
Max	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 402 / 33KV Incomer No-II

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.1317			1.1317
4				1.0288			1.0288
6	.9259	.8745		.8745	1.0288		1.0288
7		.9259			.9259		
8	.8745	.7716	.9259	.9259	.823		.8745
9	.8745			.8745	.8745		
10	.9774	.9259	.9774			.9259	.8745
11	.9259	.8745		.8745		.823	
12	.8745	.8745	.8745	.9259	.9774		1.0288
13	.7716	.9774		.9259		.8745	.9259
14	.8745	.823	.9259				
15	1.0802	.9259		.9259	1.0802	.9259	1.3889
16	1.1317	.9774	.823				
17	1.0802			1.0802		.8745	
18	1.2346		.8745	1.0288			
19	1.1317			1.1317	1.0288	.9774	
20		1.1317	.9774	1.2346			1.2346
21				1.0802		.9774	
22			1.0288				
23			1.1317	1.4918		1.286	
24	1.4403		1.286	1.1831	1.4403	1.3375	1.286
Max	1.4403	1.1317	1.286	1.4918	1.4403	1.3375	1.3889
Min	.7716	.7716	.823	.8745	.823	.823	.8745
Avg	1.0141	.9166	.9825	1.0449	1.0224	1.0002	1.0803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 201 / Spare Link feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	14-APR-18
HR	Load (MW)
3	.9955
5	.905
7	.905
Max	.9955
Min	.905
Avg	.9352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 202 / 11 KV PUMP HOUSE SEC 11

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.9955		.905		1.086	1.086
2			.905		1.1765		
3	.905	.8145		.905		.9955	
4			.8145		1.086		
5	.8145	.724		.905		1.086	
6			.9955		1.086		
7		.9955		1.086			
8	.8145	1.086	1.086	1.448	1.086		
9	.905	1.3575	.905	1.6289	1.448	.905	1.086
10	.9955	1.267	.905	1.267	1.448		
11	.9955	1.086	1.086	1.086	1.448	1.086	1.086
12	.905	1.1765	1.086	1.086	1.448		
13	.8145	1.267	1.086	1.267	1.3575	.905	1.086
14	.905	1.267	1.086	1.086	1.267		
15	1.086	1.086	1.1203	1.086	1.267	1.086	1.267
16			1.086	1.086	1.267		1.267
17	1.086	.9955		.724		.8145	1.267
18			.905	1.086	1.267		1.086
19	1.267	1.086		1.086		1.086	1.086
20			1.086	.9955			1.086
21	1.086	1.086		1.086		1.086	1.086
22			1.086	1.267			1.086
23	1.267	1.267	1.086	1.267		1.3575	1.086
24	1.086	1.086	1.086	1.086	1.3575	1.086	1.267
Max	1.267	1.3575	1.1203	1.6289	1.448	1.3575	1.267
Min	.8145	.724	.8145	.724	1.086	.8145	1.086
Avg	1.0012	1.0966	1.0241	1.1162	1.2864	1.0483	1.1377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.8145		.724		.8145	.905
2			.724		.724		
3	.543	.724		.543		.6335	.724
4			.543		.543		
5	.543	.724		.543		.543	.543
6			.543		.543		
7		.543		.6335			.543
8	.543		.543	.6335	.6335		
9	.543	.543	.543	.6335	.6335	.543	.543
10	.6335		.543	.6335	.6335		
11	.6335	.543	.543	.543	.6335	.6335	.6335
12	.6335		.543	.6335	.6335		
13	.6335	.543	.543	.6335	.6335	.6335	.724
14	.6335		.6335	.6335	.6335		
15	.724	.543	.6335	.724	.6335	.724	.724
16			.724	.724	.6335		.724
17	.6335	.6335		.6335		.724	.724
18			.6335	.6335	.6335		.6335
19	.724	.724		.724		.724	.724
20			.724	.724			.724
21	.724	.724		.724		.724	.724
22			.8145	.905			.8145
23	.905	.905	.9955	.905		.9955	.905
24	.905	.905		.905	.905	.905	.905
Max	.905	.905	.9955	.905	.905	.9955	.905
Min	.543	.543	.543	.543	.543	.543	.543
Avg	.6731	.6822	.6392	.6852	.6464	.7165	.7187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.8099		1.8099		1.9004	1.9909
2			1.6289		1.6289		
3	1.5384	1.5384		1.267		1.448	1.6289
4			1.267		1.448		
5	1.267	1.3575		1.1765		1.267	1.3575
6			1.267		1.448		
7		1.448		1.448			1.267
8	1.1765	1.267	1.3575	1.448	1.3575		
9	1.448	1.3575	1.267	1.3575	1.448	1.267	1.6289
10	1.6289	1.6289	1.448	1.6289	1.448		
11	1.6289	1.6289	1.448	1.6289	1.448	1.6289	1.7194
12	1.6289	1.448	1.6289	1.5384	1.448		
13	1.6289	1.448	1.6289	1.448	1.448	1.6289	1.8099
14	1.6289	1.448	1.6289	1.6289	1.448		
15	1.9004	1.448	1.6289	1.7194	.543	1.7194	1.8099
16			1.6289	1.8099	1.448		1.8099
17	1.8099	1.6289		1.6289		1.6289	1.8099
18			1.6289	1.6289	1.6289		1.8099
19	1.8099	1.8099		1.8099		1.6289	1.9909
20			1.9004	1.9004			1.9909
21	1.9909	1.9909		1.9909		1.9909	2.1719
22			2.2624	2.1719			2.2624
23	1.9909	1.9909	2.2624	2.1719		2.1719	2.1719
24	1.9909	1.9909	2.8054	2.1719	2.1948	2.1719	2.0814
Max	1.9909	1.9909	2.8054	2.1719	2.1948	2.1719	2.2624
Min	1.1765	1.267	1.267	1.1765	.543	1.267	1.267
Avg	1.6798	1.6023	1.6875	1.6850	1.4561	1.7043	1.8419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3529	2.3529		2.3529		2.4434	2.6244
2			2.0814		2.0814		
3	1.8099	1.9909		1.6289		1.9909	2.1719
4			1.6289		1.8099		
5	1.6289	1.8099		1.448		1.8099	1.7194
6			1.6289		1.7194		
7		1.9004		1.8099			1.6289
8	1.6289	1.8099	1.8099	1.8099	1.6289		
9	1.6289	1.8099	1.6289	1.8099	1.7194	1.8099	1.8099
10		1.448	1.6289	1.6289	1.7194		
11	1.8099	1.6289	1.6289	1.7194	1.7194	1.7194	1.8099
12	1.8099	1.6289	1.6289	1.6289	1.7194		
13	1.8099	1.6289	1.6289	1.6289	1.6289		1.9909
14	1.8099	1.6289	1.6289	1.6289	1.6289		
15	1.9909	1.6289	1.7194	1.8099	1.6289	1.8099	2.0814
16			1.7194	1.8099	1.6289		2.0814
17	1.8099	1.6289		1.7194		1.7194	1.9909
18			1.7194	1.7194	1.6289		1.9004
19	1.7194	1.6289		1.8099		1.8099	1.9909
20			2.0814	1.9004			1.9909
21	1.9909	2.2624		2.0814		1.9909	2.1719
22			2.3529	2.5339			2.2624
23	2.6244	2.5339	1.9004	2.7149		2.6244	2.7149
24	2.6244	2.6244	2.5339	2.7149	2.7149	2.8054	2.7149
Max	2.6244	2.6244	2.5339	2.7149	2.7149	2.8054	2.7149
Min	1.6289	1.448	1.6289	1.448	1.6289	1.7194	1.6289
Avg	1.9366	1.8791	1.8205	1.9004	1.7840	2.0485	2.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.0814		2.1719		2.1719	2.1719
2			1.9004		2.1719		
3	1.8099	1.6289		1.448		1.8099	1.7194
4			1.448		1.448		
5	1.5384	1.448		1.448		1.5384	1.448
6			1.448		1.448		
7		1.5384		1.6289			1.448
8	1.448	1.4632	1.448	1.6289	1.448		
9	1.448	1.267	1.448	1.448	1.448	1.448	1.448
10	1.5384	***	1.448	1.448	1.448		
11	1.6289	1.3575	1.267	1.448	1.448	1.448	1.6289
12	1.6289	1.3575	1.267	1.448	1.448		
13	1.448	1.3575	1.448	1.448	1.448	1.448	1.8099
14	1.448	1.267	1.448	1.448	1.448		
15	1.8099	1.267	1.6289	1.7194	1.448	1.6289	1.8099
16			1.6289	1.6289	1.448		1.8099
17	1.6289	1.448		1.6289		1.448	1.8099
18			1.448	1.448	1.6289		1.6289
19	1.8099	1.5384		1.6289		1.6289	1.8099
20			1.8099				1.8099
21	1.8099	1.8099		.905		1.8099	1.9909
22			2.1719	2.5339			2.1719
23		2.3529	2.5339	1.267		2.3529	2.5339
24	2.3529	2.3529	2.3529	2.5339	2.5339	2.5339	2.3529
Max	2.3529	13.5746	2.5339	2.5339	2.5339	2.5339	2.5339
Min	1.448	1.267	1.267	.905	1.448	1.448	1.448
Avg	1.7013	2.3006	1.6556	1.6154	1.5902	1.7722	1.8472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7194	1.8099		1.8099		1.9909	1.9004
2			1.5384		1.6289		
3	1.448	1.5384		1.267		1.6289	1.6289
4			1.448		1.448		
5	1.267	1.267		1.1765		1.448	1.448
6			1.448		1.448		
7		1.448		1.448			1.267
8	1.1765	1.267	1.267	1.448	1.3575		
9	1.267	1.1765	1.267	1.3575	1.267	1.3575	1.267
10	1.267	1.267	1.267	1.267	1.267		
11	1.267	1.267	1.1765	1.1765	1.1765	1.267	1.267
12	1.267	1.1765	1.1765	1.1765	1.086		
13	1.267	1.086	1.1765	1.1765	1.086	1.086	1.3575
14	1.1765	1.086	1.1765	1.086	1.086		
15	1.448	1.086	1.267	1.267	1.086	1.3575	
16			1.267	1.267	1.086		1.5384
17	1.3575	1.1765		1.267		1.267	1.3575
18			1.1765	1.1765	1.1765		1.1765
19	1.267	1.1765		1.1765		1.267	
20			1.3575	1.3575			1.448
21	1.3575	1.448		1.5384		1.6289	1.6289
22			1.8099	1.9909			1.7194
23	1.9909	1.9909	2.1719	2.1719		1.9909	2.0814
24	1.9909	2.0814	1.9909	2.1719	2.1719	2.1719	
Max	1.9909	2.0814	2.1719	2.1719	2.1719	2.1719	2.0814
Min	1.1765	1.086	1.1765	1.086	1.086	1.086	1.1765
Avg	1.4084	1.3734	1.4107	1.4178	1.3122	1.5385	1.5061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 211 / 11 kV Sector 27

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2715		.2715		.181	.2715
2			.181		.181		
3	.181	.181		.181		.181	.2715
4			.181		.181		
5	.181	.181		.181		.181	.181
6			.2715		.2715		
7		.2715		.2715			.181
8	.2715	.362	.2715	.2715	.2715		
9	.2715	.2715	.2715	.2715	.2715	.2715	.2715
10	.2715	.2715	.2715	.2715	.2715		
11	.2715	.2715	.362	.2715	.181	.2715	
12	.2715	.181	.362	.181	.181		
13	.2715	.181	.362	.181	.181	.2715	
14	.2715	.181	.2715		.181		
15	.181	.181	.2715	.181	.181	.181	
16			.2715	.181	.181		.2715
17	.181	.181		.181		.181	.2715
18			.2715	.181	.181		.2715
19	.181	.2715		.2715		.2715	.362
20			.362	.2715			.362
21	.181	.2715		.2715		.362	.362
22			.362	.2715			.2715
23	.362	.2715	.362	.2715		.2715	.362
24	.2715	.2715	.2715	.362	.2715	.2715	.2715
Max	.362	.362	.362	.362	.2715	.362	.362
Min	.181	.181	.181	.181	.181	.181	.181
Avg	.2376	.2396	.2928	.2398	.2133	.2413	.2844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 201 / 11 kv CIDCO Sewrage Pump SHEDDABLE URBAN
Secto Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	1.7924	1.8298	2.2032		1.8858	
2	1.9605	1.7177	1.6804	2.0538		1.6804	
3	1.8671	1.5684	1.6057	2.0538		1.475	
4	1.7737	1.4563	1.5497	1.8671		1.4003	
5	1.6804	1.419	1.4937	1.7737		1.1949	
6	1.587	1.4563	1.4937	1.6804		1.1203	
7	1.4003	1.531	1.531	1.587			
8		1.4937	1.363	1.475		1.0456	
9			1.4377	1.6991	1.6804	1.251	
10	1.4563		1.9605	2.3525	2.1285	1.643	1.8298
11	1.7551	2.1658	2.3525	2.2032		1.9231	2.1658
12	1.9044		2.4272	2.1285		2.0911	2.3152
13	1.7737		2.5019	2.5393		2.3339	2.5393
14	2.0165	2.3899	2.5766	2.1098		2.5019	2.3712
15	2.2592		2.6139		2.6699	2.6139	2.5019
16	2.0538		2.6513			2.6699	2.4646
17	1.9978	2.1658	2.2032			2.6139	2.1285
18	1.9791		2.1285			2.4272	1.8858
19	1.8858	1.9044	2.0351	2.3899	2.1845	2.1845	2.0165
20	1.9044		2.1472				2.2779
21	1.8671	2.2405	2.2965				2.2405
22	2.1658		2.2032				2.0911
23	2.0538	2.0538	2.2405	2.2218	2.0911		.2054
24	2.1285	1.9978	2.0165	2.2779	2.0725	1.9791	2.1658
Max	2.2592	2.3899	2.6513	2.5393	2.6699	2.6699	2.5393
Min	1.4003	1.419	1.363	1.475	1.6804	1.0456	.2054
Avg	1.8875	1.8235	2.0141	2.0362	2.1378	1.8966	2.0800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.1949	1.2136	1.1203		1.307	
2	.9709	1.0829	1.0456	1.0829		1.2136	
3	.9335	1.0082	.9709	1.0456		1.1203	
4	.8962	.9335	.9335	1.0082		1.0082	
5	.8962	.9335	.8962	.9709		1.0082	
6	.8775	.9522	.9149	.9335		.9709	
7	.8775	.9896	.9522	.9335			
8		.8029	.9149	.9335		.9709	
9			.8029	.8589	.8402	.8775	
10	.9149		.8402	.8775	.8402	.8775	.9335
11	.8589	.7842	.8402			.8775	.9709
12	.9149		.8402			.8775	.9709
13	.9522		.8589	.7842		.8962	.9149
14	.9522	.8029	.8589	.8402		.9149	1.0269
15	1.0456		.8402		1.0082	.9149	1.1576
16	1.0642		.8402			.9149	1.1203
17	.9896	.8215	.8029			.9522	1.0642
18	1.0082		.8589			.9709	1.0456
19	1.0456	.8775	.9335	.9149	1.0082	1.0082	1.0082
20	1.0642		.9709				1.0269
21	1.1016	.9149	.9896				.9709
22	1.1576		1.1203				1.0829
23	1.251	1.2323	1.1576	1.3443	1.3443		1.307
24	1.0829	1.2883	1.2696	1.1576		1.3443	1.307
Max	1.251	1.2883	1.2696	1.3443	1.3443	1.3443	1.307
Min	.8589	.7842	.8029	.7842	.8402	.8775	.9149
Avg	.9938	.9746	.9445	.9871	1.0082	1.0013	1.0605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.1203	1.1576	1.4937		1.2883	
2	1.2696	1.0082	1.0082	1.4003		1.1576	
3	1.1203	.9149	.9335	1.307		1.0269	
4	1.0269	.8589	.9149	1.2136		1.0269	
5	.9335	.8215	.8962	1.1203		.9149	
6	.8402	.8215	.8962	1.0269		.8962	
7	.7095	.8962		.9335			
8		.8215	.8589	.8962		.8775	
9			.9522	.9709	.9709	.9522	
10	.9335		1.307	1.4377	1.1576	1.307	1.0829
11	1.587	1.6244	1.7551			1.4937	1.4937
12	1.587		1.7551			1.7737	1.8671
13	1.6057		1.7551	1.7924		1.7737	1.8671
14	1.5684	1.6617	1.7177	1.7924		1.7737	1.9044
15	1.6804		1.7177		1.8298	1.8671	1.9791
16	1.643		1.7177			1.9231	1.9418
17	1.587	1.4937	1.7737			1.9044	1.8858
18	1.6057		1.7177			1.8671	1.7177
19	1.6991	1.7924	1.6991	1.7551	1.8298	1.8111	1.8671
20	1.7177		1.643				1.8298
21	1.8111	1.4937	1.5497				1.8484
22	1.5123		1.4937				1.4937
23	1.4377	1.3443	1.531	1.5123	1.4937		1.4003
24	1.3817	1.3443	1.307	1.5684	1.3817	1.3817	1.4937
Max	1.8111	1.7924	1.7737	1.7924	1.8298	1.9231	1.9791
Min	.7095	.8215	.8589	.8962	.9709	.8775	1.0829
Avg	1.3910	1.2012	1.3938	1.3480	1.4439	1.4219	1.7115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- SHEDDABLE URBAN
2 kh Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.531	1.6057	1.5684	1.6804		1.7551	
2	1.4003	1.3817	1.419	1.587		1.6804	
3	1.307	1.2323	1.307	1.4937		1.587	
4	1.2136	1.1576	1.2323	1.4003		1.587	
5	1.1203	1.1576	1.2323	1.307		1.4937	
6	1.0269	1.1949	1.2696	1.307		1.4003	
7	1.0456	1.251	1.307	1.307			
8		1.2696	1.3256	1.2883		1.307	
9			1.3256	1.4003	1.363	1.3256	
10	1.307		1.307	1.307	1.3443	1.3256	1.3443
11	1.3256	1.4563	1.307			1.3256	1.4003
12	1.363		1.307			1.3256	1.4003
13	1.1949		1.307	1.251		1.3256	1.3817
14	1.2323	1.2323	1.307	1.3256		1.3256	1.4377
15	1.4003		1.307		1.3817	1.3443	1.587
16	1.363		1.307			1.363	1.419
17	1.307	1.2136	1.2136			1.3817	1.419
18	1.307		1.307			1.4003	1.2883
19	1.3817	1.3443	1.419	1.3817	1.363	1.4003	1.3817
20	1.3817		1.4937				1.4003
21	1.4563	1.475	1.5497				1.4937
22	1.587		1.6991				1.587
23	1.7737	1.7551	1.7177	1.9044	1.9418		1.8858
24	1.587	1.7924	1.7924	1.7551	1.8858	1.8858	1.9418
Max	1.7737	1.7924	1.7924	1.9044	1.9418	1.8858	1.9418
Min	1.0269	1.1576	1.2136	1.251	1.3443	1.307	1.2883
Avg	1.3460	1.3680	1.3887	1.4464	1.5466	1.4494	1.4912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1494	.1494	.1494		.1494	
2	.0934	.1307	.1494	.112		.1494	
3	.0747	.112	.1307	.0934		.112	
4	.0747	.1307	.112	.0934		.112	
5	.0747	.112	.112	.0934		.0934	
6	.0934	.1307	.1307	.0934		.0934	
7	.0934	.112	.112	.0934			
8		.0747	.112	.0934		.0934	
9			.112	.0934	.0934	.0934	
10	.0934		.1307	.1307	.1307	.112	.112
11	.112	.1494	.1307			.1307	.1307
12	.112		.1307			.1307	.1307
13	.1307		.1307	.1307		.1494	.168
14	.1307	.1307	.1494	.1494		.1494	.1867
15	.1494		.1494		.1494	.1494	.168
16	.1307		.1494			.1494	.1494
17	.112	.112	.1307			.168	.1494
18	.1307		.1494			.1867	.0934
19	.1494	.1867	.168	.1867	.168	.1867	.1867
20	.2054		.1867				.2241
21	.2054	.1867	.1867				.2241
22	.1867		.1867				.2241
23	.2054	.1867	.1867	.1867	.168		.1867
24	.1494	.1494	.168	.1867	.1494	.1494	.1494
Max	.2054	.1867	.1867	.1867	.168	.1867	.2241
Min	.0747	.0747	.112	.0934	.0934	.0934	.0934
Avg	.1282	.1369	.1439	.1257	.1432	.1346	.1656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0187		
2	.0187		.0187		
3	.0187		.0187		
4	.0187		.0187		
5	.0187		.0187		
6	.0187		.0187		
7	.0187		.0187		
8			.0187		
9			.0187		
10		.0187		.0187	
11		.0187		.0187	
12		.0187		.0187	
13		.0187	.0187	.0187	
14		.0187		.0187	
15		.0187		.0187	
16		.0187		.0187	
17		.0187		.0187	
18		.0187		.0187	
19		.0187		.0187	
20		.0187		.0187	
21		1.8671		.0187	
22		.0187		.0187	
23		.0187			
24	.0187		.0187		.0187
Max	.0187	1.8671	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.1507	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.2054	.112	.0373		.0747	
2	.0373	.1307	.0373	.0373		.0373	
3	.0373	.0747	.0373	.0373		.0373	
4	.0373	.0373	.0373	.0373		.0373	
5	.0373	.0373	.0373	.0373		.0373	
6	.0373		.0373	.0373			
7	.0373	.0373	.0373	.0373			
8		.0373	.0373	.0373		.0373	
9			.2054	.1494	.2054	.2241	
10	.2054		.2614	.2427	.2427	.2614	.3174
11	.3174	.3547	.2987			.2987	.3174
12	.3547		.2987			.3361	.3361
13	.3921		.3174	.3361		.3734	.3174
14	.3921	.3547	.3361	.3174		.3734	.3361
15	.3734		.3361		.2614	.3734	.3547
16	.3921		.3547			.3361	.3734
17	.4108	.2987	.3547			.3361	.3921
18	.3734		.3174			.3174	.3734
19	.3921	.2801	.3547	.3174	.3361	.3174	.3361
20	.3921		.2987				.3174
21	.3921	.2614	.3174				.3734
22	.3174		.2614				.2801
23	.2054	.2054	.1867	.2427	.2427		.2427
24	.1494	.2054	.2054	.1494	.1867	2.8006	.1867
Max	.4108	.3547	.3547	.3361	.3361	2.8006	.3921
Min	.0373	.0373	.0373	.0373	.1867	.0373	.1867
Avg	.2419	.1800	.2116	.1369	.2458	.3672	.3236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.4086	2.2032	2.6139		2.6139	
2	2.0538	2.2405	2.0165	2.5206		2.5019	
3	1.8671	2.2032	1.9044	2.4272		2.4272	
4	1.7737	2.0538	1.8298	2.3339		2.4272	
5	1.6804	2.0165	1.8298	2.2405		2.4272	
6	1.643	2.0351	1.8671	2.1472		2.3152	
7	1.643	2.0538	1.9418	2.1472			
8		2.2032	2.0165	2.1285		2.2779	
9			2.3899	2.4646	2.6139	2.4646	
10	2.3525		2.8006	2.9874	3.1367	2.7073	2.2405
11	2.2779	2.9874	3.1367			2.894	2.3152
12	2.2779		3.062			3.0994	2.3152
13	2.0538		2.9874	2.95		3.062	2.3525
14	2.2405	2.8006	2.9313	2.95		3.0247	2.3899
15			2.8753		3.3608	3.0247	2.5019
16	2.2405		2.8006			2.9874	2.5019
17	2.0538	2.5393	2.4646			2.8006	2.2405
18	2.0538		2.4272			2.6139	2.0538
19	2.0911	2.2405	.2058	2.3525	2.3525	2.2405	2.2779
20	2.2032						2.2032
21	2.2032	2.2779					2.4272
22	2.3899						2.5766
23	2.726	2.6513	2.7446	2.8006	2.8753		2.726
24	2.3899	2.5766	2.5393	2.7073	2.8006	2.8006	
Max	2.726	2.9874	3.1367	2.9874	3.3608	3.0994	2.726
Min	1.643	2.0165	.2058	2.1285	2.3525	2.2405	2.0538
Avg	2.1169	2.3526	2.3321	2.5181	2.8566	2.6690	2.3659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187			
2	.0187	.0187	.0187	.0187			
3	.0187	.0187	.0187	.0187			
4	.0187	.0187	.0187	.0187			
5	.0187	.0187	.0187	.0187			
6	.0187	.0187	.0187	.0187			
7	.0187	.0187	.0187	.0187			
8		.0187	.0187	.0187		.0187	
9			.0187	.0187		.0187	
10	.0187		.0187	.0187		.0187	.0187
11	.0187	.0187	.0187			.0187	.0187
12	.0187		.0187			.0187	.0187
13	.0187		.0187	.0187		.0187	.0187
14	.0187	.0187	.0747			.0187	.0187
15	.0187		.0187		.0187	.0187	.0187
16	.0187		.0187			.0187	.0187
17	.0187	.0187	.0187			.0187	.0187
18	.0187		1.8671			.0747	.0187
19	.0187	.0187	.0187	.0187	.0187	.0187	.0187
20	.0187		.0187			.0187	.0187
21	.0187	.0187				.0187	.0187
22	.0187					.0187	.0187
23	.0187	.0187	.0187	.0187	.0187		.0187
24	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Max	.0187	.0187	1.8671	.0187	.0187	.0747	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.1053	.0187	.0187	.0222	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9418	2.2405	2.3525	2.2405		2.4459	
2	1.8671	2.2032	2.0538	2.1472		2.4272	
3	1.7737	2.0165	1.9418	2.0538		2.2405	
4	1.7177	1.6804	1.8111	1.9605		2.0725	
5	1.6804	1.643	1.7924	1.8671		2.0538	
6	1.643	1.6804	1.7551	1.7737		1.7737	
7	1.643	1.7177	1.7924	1.7737			
8		1.643	1.6991	1.7924		1.7364	
9			1.6617	1.5684	1.3817	1.2696	
10	1.643		1.587	1.5123	1.3443	1.531	1.7177
11	1.7364	1.4563				1.4937	1.6804
12	1.6244		1.4937			1.475	1.7364
13	1.587		1.5684	1.4377		1.5497	1.6617
14	1.6244	1.3443	1.643	1.5497		1.6244	1.8298
15	1.7737		1.6804		1.307	1.643	1.9978
16	1.7924		1.7177			1.643	2.0351
17	1.7737	1.1949	.1494			1.6617	1.8858
18	1.7924		1.6804			1.7364	1.6991
19	1.7924	1.6057	1.6991	1.6617	1.6804	1.8111	1.8858
20	1.8298		1.8671				2.0165
21	1.9231	1.8858	2.0165				2.0725
22	2.1285		2.2779				2.2965
23	2.3152	2.4272	2.3152	2.7446	2.726		2.4832
24	2.0165	2.4646	2.5019	2.3339	2.5766	2.5766	2.6886
Max	2.3152	2.4646	2.5019	2.7446	2.726	2.5766	2.6886
Min	1.587	1.1949	.1494	1.4377	1.307	1.2696	1.6617
Avg	1.8009	1.8136	1.7851	1.8945	1.836	1.8297	1.9791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.1203	1.1203	1.1949		1.2136	
2	1.0082	1.0456	1.0456	1.1576		1.1576	
3	.9709	.9709	.8962	1.1203		1.1576	
4	.9335	.8215	.8215	1.0829		1.1203	
5	.8589	.8215	.8589	1.0269		1.0829	
6	.8029	.8962	.8962	1.0269		1.0269	
7	.7282	.9709	.9896	1.0269			
8		1.0082	1.1016	1.0642		1.0642	
9			1.0456	1.1203	1.0642		
10	.8589		1.0642	1.1203	1.1949	1.2323	.8962
11	.8402	1.1389	1.0642			1.1949	.8589
12	.8775		1.0829			1.1576	.8962
13	.8775		1.0829	1.1203		1.1576	.8962
14	.8402	1.0829	1.0829	1.1203		1.1763	.9522
15	.8775		1.0829		1.2323	1.1576	.9709
16	.9149		1.0829			1.1203	1.0082
17	.8962	.9149	.8589			1.0456	.8775
18	.9149		.9335			.9896	.8029
19	.8962	.9335	.9896	.9149	.9709	.9149	.9149
20	.9709		1.0642				.9709
21	.9896	1.0269	1.1203				1.0082
22	1.1016		1.1763				1.0082
23	1.1576	1.1763	1.1949	1.251	1.251		1.1949
24	1.1203	1.1763	1.1949	1.2323	1.251	1.2696	1.2323
Max	1.1576	1.1763	1.1949	1.251	1.251	1.2696	1.2323
Min	.7282	.8215	.8215	.9149	.9709	.9149	.8029
Avg	.9310	1.0070	1.0355	1.1053	1.1607	1.1244	.9659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 212 / 11kV Siemens Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0373	.0373	.0373		.0373	
2	.0187	.0187	.0373	.0373		.0373	
3	.0187	.0187	.0373	.0373		.0373	
4	.0187	.0187	.0373	.0373		.0373	
5	.0187		.0373	.0373		.0373	
6	.0187	.0373	.056	.0373			
7	.0373	.0747	.2614	.0747			
8		.3174	.2801	.3174		.2427	
9			.2614	.2427	.2427	.2614	
10	.0373		.2427	.2427	.2241	.2614	.0373
11	.0187	.2987	.2427			.2614	.0373
12	.0373		.2614			.2614	.0373
13	.0373		.2614	.2987		.2614	.056
14	.0373	.2614	.2801	.2801		.2614	.056
15	.0373		.2987		.2614	.2614	.056
16	.056		.2987			.2241	.056
17	.0373	.112	.112			.2241	.056
18	.0373		.0747			.1494	.0373
19	.0373	.0747	.056	.0934	.0747	.0934	.0373
20	.0373		.056				.0373
21	.0187	.0373	.056				.0373
22	.0187		.056				.056
23	.0373	.0373	.0373	.0373	.0373		.0373
24	.0187	.0373	.0373	.0373	.0373	.0373	.0373
Max	.056	.3174	.2987	.3174	.2614	.2614	.056
Min	.0187	.0187	.0373	.0373	.0373	.0373	.0373
Avg	.0297	.0987	.1424	.1232	.1463	.1660	.0448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0373	.0187	.0373		.0373	
2	.0187	.0187	.0187	.0373		.0373	
3	.0187	.0187	.0187	.0373		.0373	
4	.0187	.0187	.0187	.0373		.0373	
5	.0187	.0187	.0373	.0373		.0373	
6	.0187	.0187	.0373	.0373			
7	.0187	.0373	.0373	.056			
8		.056	.056	.1494		.0934	
9			.2427	.2801	.2427	.2427	
10	.0373		.2241	.2987	.2614	.2614	.0934
11	.0373	.2427	.2241			.2801	.112
12	.0373		.2241			.3174	.112
13	.0187		.2241	.2987		.2987	.112
14	.0373	.2801	.2241	.2801		.2801	.1307
15	.0373		.2427		.2801	.2801	.1307
16	.056		.2427			.2801	.112
17	.056	.2614	.2241			.2614	.112
18	.0373		.1867			.2241	.0934
19	.0373	.0747	.0747	.056	.056	.0373	.056
20	.0373		.0747				.0373
21	.0373	.0747	.0747				.0373
22	.0373		.0747				.0373
23	.0373	.0373	.0373	.0373	.0373		.0373
24	.0187	.0373	.0373	.0373	.0373	.0373	.0373
Max	.056	.2801	.2427	.2987	.2801	.3174	.1307
Min	.0187	.0187	.0187	.0373	.0373	.0373	.0373
Avg	.0314	.0822	.1198	.1145	.1525	.1711	.0834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.8807	3.0521	3.2114	3.1722	3.2407	3.3951	3.2065
Max	2.8807	3.0521	3.2114	3.1722	3.2407	3.3951	3.2065
Min	2.8807	3.0521	3.2114	3.1722	3.2407	3.3951	3.2065
Avg	2.8807	3.0521	3.2114	3.1722	3.2407	3.3951	3.2065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.1029	.1063	.1029	.0857	.1029	.1029
Max	.0857	.1029	.1063	.1029	.0857	.1029	.1029
Min	.0857	.1029	.1063	.1029	.0857	.1029	.1029
Avg	.0857	.1029	.1063	.1029	.0857	.1029	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 203 / LIG MASS HOUSING Feder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4458	.463	.543	.5316	.4973	.5316	.5144
Max	.4458	.463	.543	.5316	.4973	.5316	.5144
Min	.4458	.463	.543	.5316	.4973	.5316	.5144
Avg	.4458	.463	.543	.5316	.4973	.5316	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 & 43, sec-35D

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1715	.1886	.2054	.1886	.1886	.1715	.1886
Max	.1715	.1886	.2054	.1886	.1886	.1715	.1886
Min	.1715	.1886	.2054	.1886	.1886	.1715	.1886
Avg	.1715	.1886	.2054	.1886	.1886	.1715	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 206 / PLOT NO 53 & 54 STATUS SHEDDABLE URBAN
VIHAR S Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9259	.9945	1.0456	.9945	1.0288	.9774
Max	.9259	.9945	1.0456	.9945	1.0288	.9774
Min	.9259	.9945	1.0456	.9945	1.0288	.9774
Avg	.9259	.9945	1.0456	.9945	1.0288	.9774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1029	.1029	.1132	.1029	.1029	.12	.0857
Max	.1029	.1029	.1132	.1029	.1029	.12	.0857
Min	.1029	.1029	.1132	.1029	.1029	.12	.0857
Avg	.1029	.1029	.1132	.1029	.1029	.12	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 208 / pl no.171, sec-30 feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2915	.2915	.2614	.2743	.2915	.2572	.3258
Max	.2915	.2915	.2614	.2743	.2915	.2572	.3258
Min	.2915	.2915	.2614	.2743	.2915	.2572	.3258
Avg	.2915	.2915	.2614	.2743	.2915	.2572	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1543	.1886	.1991	.1715	.2229	.1715	.1715
Max	.1543	.1886	.1991	.1715	.2229	.1715	.1715
Min	.1543	.1886	.1991	.1715	.2229	.1715	.1715
Avg	.1543	.1886	.1991	.1715	.2229	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0514	.0686	.0686	.0686	.0686	.0514	.0514
Max	.0514	.0686	.0686	.0686	.0686	.0514	.0514
Min	.0514	.0686	.0686	.0686	.0686	.0514	.0514
Avg	.0514	.0686	.0686	.0686	.0686	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.1262	2.0233	2.1765	1.9033	2.2291	2.0748	2.2291
Max	2.1262	2.0233	2.1765	1.9033	2.2291	2.0748	2.2291
Min	2.1262	2.0233	2.1765	1.9033	2.2291	2.0748	2.2291
Avg	2.1262	2.0233	2.1765	1.9033	2.2291	2.0748	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING
ST

Feeder No / Name : 302 / 22 KV PANVEL-I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	3.7723	4.1076	3.9438	4.1152	4.3317	4.1152
2	3.5322	3.7037	4.0329	3.3951	4.1838	4.2943	3.7723
3	3.3608	3.2579	3.9209	3.2579	4.0466	4.1076	3.4979
4	2.915	2.8807	3.7342	3.1207	3.7723	4.0329	3.2579
5	2.7435	2.8121	3.4355	3.0178	3.155		3.0864
6	2.8464	2.8121	3.2861	2.8807	2.8121	3.8462	2.915
7	2.6749	2.8464	3.1367	2.8121	2.8464	3.7342	2.7778
8	2.6406	2.7778	2.9874	2.7435	2.7778	3.3981	2.7435
9	2.6749	3.0178	2.9835	3.0178	2.9835	3.1893	3.0521
10	2.7435	3.6222	3.0178	3.2579	3.3608	3.4637	3.1893
11	2.8121	3.9209	2.2634	3.4294	3.3234	3.5322	3.3608
12	3.0178	3.6969	2.1605	3.6008	3.8836	3.5322	3.3951
13	2.9835	3.7342		3.4979	3.6008	3.4979	3.3608
14	2.915	3.7342	3.4294	3.9781	3.6694	3.4979	3.7723
15	2.9835		3.7037	3.9095	3.7037	3.8752	3.9095
16	3.0178		3.6351	3.9781	3.738	3.8409	3.5322
17	2.7778		3.2922	3.5322	3.5322	3.5665	3.3951
18	2.6406	3.155	3.155	3.6008	3.5101	3.2579	3.4294
19	3.1207	4.0703	3.4294	3.5665	3.6008	3.6008	3.6351
20	3.5665	3.738	3.7037	3.8409	4.2943	3.8066	3.9438
21	3.5322	3.9956	3.738	3.9095	4.2196	3.8409	3.9438
22	3.8409	4.0703	3.9095	4.0466	4.4437	3.9438	3.9095
23	3.9438	4.369	4.2524	4.1838	4.6677	4.2524	4.1838
24	3.9781	3.8752	4.257	4.0809	4.1838	4.4437	4.2524
Max	3.9781	4.369	4.257	4.1838	4.6677	4.4437	4.2524
Min	2.6406	2.7778	2.1605	2.7435	2.7778	3.1893	2.7435
Avg	3.1264	3.5173	3.4596	3.5251	3.6844	3.7777	3.5180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 307 / Sainagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3896	4.1495	4.7554	4.6639	4.8011	5.1212	4.8011
2	4.1495	3.7723	4.4627	4.0809	4.5268	4.9897	4.6296
3	3.9438	3.6008	4.1396	3.9438	4.1152	4.731	4.4582
4	3.6008	3.2579	3.9179	3.7723	3.8409	4.2875	4.1152
5	3.2579	2.8807	3.7342	3.6008	3.2579	4.0329	3.8066
6	3.155	2.8464	3.6222	3.3951	3.0864	3.6595	3.4979
7	3.0178	2.8121	3.5117	3.3265	3.1207	3.4728	3.3265
8	2.9835	2.8464	3.4355	2.9835	3.0521	3.1824	3.0864
9	2.8807	2.6406	2.8464	3.0178	2.8464	3.0178	2.7778
10	2.8121	2.8532	2.7778	2.7435	2.8898	2.8464	2.8807
11	2.8464	2.6337	2.7778	2.8121	2.8532	2.7092	2.6406
12	2.7435	2.8006	2.6749	2.6749	2.8006	2.7435	2.7092
13	2.6749	2.8532	2.7092	2.7435	2.8464	2.8121	3.1207
14	2.8464	2.963	2.7778	3.2579	3.0864	3.0864	3.2579
15	2.9835		3.155	3.4294	3.1207	3.4979	3.3608
16	3.0864		3.1893	3.155	3.155	3.2236	3.3951
17	2.7092		2.8464	3.0864	2.915	3.0521	3.2579
18	2.572	2.6063	2.7435	2.9835	2.8829	2.6749	2.8464
19	3.0521	3.0727	2.915	3.0521	3.155	3.0864	3.2579
20	3.3265	3.3265	3.0864	3.2579	3.7715	3.4979	3.4637
21	3.3608	3.4751	3.6694	3.5322	3.9582	3.5665	3.7723
22	4.0466	4.0969	4.0124	4.2867	4.6304	3.9781	3.8066
23	4.3553		4.8697	4.7325	5.2675	4.7668	4.4925
24	4.5268	4.561	5.048	4.904	4.8697	5.4146	4.9383
Max	4.5268	4.561	5.048	4.904	5.2675	5.4146	4.9383
Min	2.572	2.6063	2.6749	2.6749	2.8006	2.6749	2.6406
Avg	3.3050	3.2024	3.4866	3.4765	3.5354	3.6438	3.5708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 310 / 22 KV PANVEL-III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	2.1262	2.5019	2.1262	2.4006	2.6139	2.4348
2	2.0576	2.0576	2.3899	1.9547	2.3663	2.5393	2.332
3	1.8861	1.989	2.2405	1.8861	2.332	2.4272	2.0576
4	1.7147	1.8519	2.0911	1.7147	1.7833	2.2405	1.7147
5	1.5432	1.7147	1.9418	1.6461	1.7147	2.0911	1.3717
6	1.6461	1.5089	1.7924	1.7147	1.6461	1.9791	1.4403
7	1.5775	1.5432	1.7177	1.749	1.6118	1.9044	1.5432
8	1.5089	1.5432	1.5684	1.6461	1.5775	1.7924	1.5775
9	1.6804	1.5089	1.5432	1.6118	1.5432	1.7147	1.5775
10	2.2634	2.0538	1.8519	1.9204	1.8671	1.9204	1.989
11	2.572	2.9127	2.4006	2.572	2.95	2.6749	2.8121
12	2.8121	2.8753	2.4691	2.6063	2.95	2.7778	2.8807
13	2.6406	2.838	2.5377	2.6063	2.6749	2.7435	2.915
14	2.7435	2.8006	2.5034	2.7435	2.6406	2.8121	
15	2.7778		2.7778	2.8807	2.7435	2.9492	3.155
16	2.8121		2.8464	2.8464	2.8807	2.8807	3.2922
17	2.7778		2.6406	2.6063	2.7778	2.6749	3.0864
18	2.7435	2.4691	2.5377	2.7092	2.9424	2.7092	3.0864
19	2.9492	3.0247	2.7435	2.7778	2.8121	2.915	3.0864
20	2.7435	2.9492	2.915	2.915	3.2861	3.0864	3.155
21	3.0521	3.0994	2.915	2.915	3.1741	2.9835	3.2236
22	2.6063	2.6886	2.6406	2.915	2.9874	2.6749	2.8807
23	2.5377	2.8753	2.7092	2.7778	3.0178	2.7778	2.7778
24	2.3663	2.1948	2.5766	2.3663	2.5377	2.726	2.5034
Max	3.0521	3.0994	2.915	2.915	3.2861	3.0864	3.2922
Min	1.5089	1.5089	1.5432	1.6118	1.5432	1.7147	1.3717
Avg	2.3434	2.3155	2.3688	2.3420	2.4674	2.5254	2.4736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 201 / 11 kV Station Trasformer

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191				.0191
2					.0191
6	.0191	.0191			.0191
7	.0191	.0191			.0191
8	.0191	.0191			.0191
9			.0191		
10	.0191		.0191		.0191
11	.0191		.0191		.0191
12	.0191		.0191		.0191
13	.0191				.0191
14	.0191		.0191		.0191
15	.0191		.0191		.0191
16	.0191		.0191		.0191
17	.0191		.0191		.0191
18	.0191		.0191		.0191
19	.0191		.0191	.0191	.0191
20	.0191		.0191	.0191	.0191
21	.0191			.0191	.0191
22	.0191			.0191	.0191
23	.0191			.0191	.0191
24	.0191	.0191			.0191
Max	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 205 / 11 kV Sector 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829				2.0005
2					1.5051
6	1.2765	1.4289			1.4098
7	1.2384	1.4098			1.3527
8	1.3336	1.4098			1.2384
9			1.2955		
10	1.3717		1.2574		1.7909
11	1.3527		1.2384		1.5432
12	1.1622		1.1622		1.3717
13					1.2765
14	1.2765		1.2003		1.3527
15	1.3717		1.3146		1.6004
16	1.3527		1.3908		1.4861
17	1.3336		1.3527		1.3146
18	1.3146		1.3336		1.2765
19	1.4861		1.4861	1.448	
20	1.6575		1.6575	1.6194	1.6766
21	1.7528			1.6956	1.7718
22				1.8861	1.848
23	2.0767			2.191	2.1719
24	2.0386	2.0957			2.2291
Max	2.0767	2.0957	1.6575	2.191	2.2291
Min	1.1622	1.4098	1.1622	1.448	1.2384
Avg	1.4838	1.5861	1.3354	1.7680	1.5903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667				.2858
2					.2477
6	.1524	.1905			.1524
7	.1905	.1715			.1524
8	.1905	.1524			.1524
9			.2286		
10	.2096		.2096		.3048
11	.2477		.2286		.2667
12	.2096		.2477		
13	.2096				
14	.1905		.2286		.2477
15	.2286		.2286		.2286
16	.2286		.2286		.2667
17	.2286		.2286		.2477
18	.2286		.2477		.2286
19	.2286		.2286	.2286	.2286
20	.2286		.2286	.2667	.2286
21	.2286			.2858	.2286
22	.2477			.2858	.2096
23	.2667			.3048	.3048
24	.2858	.3048			.3239
Max	.2858	.3048	.2477	.3048	.3239
Min	.1524	.1524	.2096	.2286	.1524
Avg	.2246	.2048	.2303	.2743	.2392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812				1.105
2					1.0288
6	.8192	.9145			.8383
7	.8002	.9145			.8192
8	.8192	.8954			.8002
9			.9145		
10	1.105		1.2003		1.2003
11	1.2574		1.1812		1.6194
12	1.2193		1.3717		1.3717
13	1.1431		1.2003		1.2765
14	1.2003		1.2193		1.3527
15	1.2193		1.3717		1.3717
16	1.2193		1.3527		1.3527
17	1.105		1.2574		1.2765
18	1.1431		1.105		1.2384
19	1.1812		1.1431	1.2193	1.2003
20	1.086		1.1812	1.3146	1.2955
21	1.0479			1.1431	1.1431
22	1.2003			1.2193	1.1431
23	1.4289			1.2765	1.2574
24	1.3146	1.3336			1.2574
Max	1.4289	1.3336	1.3717	1.3146	1.6194
Min	.8002	.8954	.9145	1.1431	.8002
Avg	1.1311	1.0145	1.2082	1.2346	1.1974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909				1.7718
2					1.5813
6	1.2384	1.2955			1.2193
7	1.2003	1.2384			1.105
8	1.086	1.1622			.5906
9			1.2003		
10	1.3908		1.3146		1.6004
11	1.3908		1.467		1.7528
12	1.4289		1.448		1.6004
13	1.4861				1.5432
14	1.448		1.448		1.6766
15	1.5813		1.6194		1.7718
16	1.5623		1.6194		1.6766
17	1.5432		1.5623		1.5432
18	1.448		1.5623		1.4289
19	1.5432		1.6194	1.5623	1.5432
20	1.6766		1.7147	1.6766	1.6575
21	1.7337			1.6956	1.7337
22	1.7718			1.7528	1.6956
23	1.9433			1.9052	1.9052
24	1.9243	1.9814			1.9624
Max	1.9433	1.9814	1.7147	1.9052	1.9624
Min	1.086	1.1622	1.2003	1.5623	.5906
Avg	1.5362	1.4194	1.5069	1.7185	1.5680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144				.8002
2					.6859
6	.4382	.4572			.6287
7	.4763	.4954			.6097
8	.4382	.4572			.5906
9			.4572		
10	.4572		.4382		.6097
11	.381		.381		.5716
12	.4001		.4001		.4572
13	.362				.4763
14	.362		.4001		.5716
15	.4001		.381		.6287
16	.381		.3429		.6097
17	.381		.381		.4572
18	.362		.381		.4954
19	.4191		.4191	.5335	.4954
20	.4954		.5144	.6478	.5906
21	.4954			.6478	.5144
22	.4572			.6859	.5716
23	.5525			.8002	.724
24	.5906	.5906			.8383
Max	.5906	.5906	.5144	.8002	.8383
Min	.362	.4572	.3429	.5335	.4572
Avg	.4402	.5001	.4087	.6630	.5963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.2075	.2075	.2075	.1886	.1886
2	.132	.1132	.1698	.1886	.1509	.1698	.1509
3	.0943	.0943	.132	.1509	.132	.1509	.132
4	.0943	.0754	.1132	.1132	.132	.1132	.132
5	.1132	.0754	.1132	.0943		.0943	.1132
6	.132	.1132	.1132	.1509	.132	.1509	.132
7	.132	.1509	.132	.1698	.1509	.1698	.132
8	.1132	.1132	.132	.1509	.1509	.1698	.132
9	.1698	.1132	.1132	.132	.132	.1698	.1509
10	.1509	.0943	.132	.132	.132	.1509	.1698
11	.0943	.0754	.1132	.132	.132	.1132	.1509
12	.1509	.0943	.1132	.132	.132	.1132	.132
13	.1509	.0943	.1132	.132	.132	.1132	.132
14	.1509	.1132	.1132	.132	.132	.1132	.1509
15	.1132	.1132	.1132	.132	.1509	.1132	.1886
16	.1132	.1132	.132	.1509	.1509	.132	.1886
17	.132	.1132	.1509	.1509	.132	.132	.1509
18	.132	.1509	.1698	.132	.1509	.1509	.132
19	.1509	.0943	.1698	.1509	.1509	.1509	.1509
20	.1509	.132	.1698	.1509	.1509	.1509	.1509
21	.1698	.1698	.1698	.1698	.1698	.1886	.1698
22	.1886	.2075	.1886	.1886	.1886	.2075	.1886
23	.1886	.2263	.2075	.2075	.2075	.2263	.2263
24	.2075	.1886	.2263	.2452	.2263	.2075	.2263
Max	.2075	.2263	.2263	.2452	.2263	.2263	.2263
Min	.0943	.0754	.1132	.0943	.132	.0943	.1132
Avg	.1415	.1242	.1462	.1540	.1533	.1517	.1572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1097	.132	.1698	.1509	.1509	.132
2	.1132	.0943	.1132	.1509	.1132	.1132	.1132
3	.0943	.0754	.0943	.1132	.0943	.0943	.0943
4	.0754	.0754	.0943	.0943	.0943	.0754	.0943
5	.0943	.0943	.0943	.1132	.0943	.0943	.0943
6	.0943	.1132	.0943	.1509	.1132	.1132	.0943
7	.132	.132	.0943	.1698	.1132	.1132	.0943
8	.0943	.1132	.0943	.1132	.0943	.1132	.0943
9	.1132	.0943	.0943	.1132	.0943	.0943	.1132
10	.1132	.0943	.132	.0943	.1132	.0754	.1132
11	.128	.0754	.1132	.0943	.1132	.0754	.0943
12	.132	.0943	.1132	.0943	.0943	.0754	.0943
13	.132	.0943	.1132	.0943	.0754	.0943	.0943
14	.132	.0943	.1132	.0943	.0754	.0943	.1132
15	.1132	.0943	.132	.0943	.0943	.1132	.132
16	.1132	.0943	.1132	.1132	.0943	.132	.132
17	.1132	.0943	.1132	.1132	.0943	.132	.1509
18	.0943	.0754	.0943	.1132	.0943	.1132	.1132
19	.0943	.0943	.1132	.0754	.0943	.0754	.0943
20	.1132	.1132	.132	.0943	.1132	.0943	.0943
21	.1132	.1132	.132	.1132	.132	.1132	.0943
22	.132	.132	.132	.1509	.1509	.132	.1698
23	.1509	.1509	.1509	.1698	.1698	.1698	.1509
24	.1509	.1509	.1509	.1886	.1698	.1698	.1698
Max	.1509	.1509	.1509	.1886	.1698	.1698	.1698
Min	.0754	.0754	.0943	.0754	.0754	.0754	.0943
Avg	.1146	.1028	.1147	.1203	.1100	.1092	.1140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.12	.1132	.12	.1029	.12
2	.1029	.0857	.1029	.0943	.1029	.0857	.1029
3	.0857	.0686	.0857	.0754	.1029	.0686	.0857
4	.0857	.0686	.0857	.0943	.1029	.0686	.0857
5	.0857	.0857	.0857	.1029	.12	.0857	.0857
6	.1029	.1029	.1029	.1029	.12	.1029	.1029
7	.1029	.1372	.1029	.12	.1372	.1029	.1029
8	.0857	.1029	.1029	.1029	.1029	.1372	.1029
9	.1029	.1097	.1372	.1029	.1029	.1543	.1029
10	.1097	.0857	.1029	.1029	.1029	.12	.12
11	.12	.0857	.1029	.1029	.12	.0857	.1029
12	.12	.0686	.1029	.1029	.1029	.0857	.1029
13	.12	.0686	.1029	.0857	.0857	.0857	.1029
14	.1029	.0857	.1029	.1029	.0857	.0857	.1029
15	.1029	.1029	.1029	.1029	.1029	.1029	.12
16	.1029	.12	.12	.1029	.12	.12	.12
17	.1372	.12	.12	.1029	.12	.1372	.12
18	.1029	.0857	.1029	.1029	.12	.12	.1029
19	.1029	.0857	.12	.1029	.12	.1029	.1029
20	.1029	.1029	.12	.12	.1372	.12	.12
21	.1029	.12	.12	.12	.1372	.12	.1372
22	.12	.1543	.12	.1372	.1372	.1372	.12
23	.1372	.1372	.1372	.1372	.1372	.1372	.12
24	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Max	.1372	.1543	.1372	.1372	.1372	.1543	.1372
Min	.0857	.0686	.0857	.0754	.0857	.0686	.0857
Avg	.1082	.1010	.1100	.1072	.1157	.1086	.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2115	5.1212	5.2484	5.8528	5.8029	5.8528	5.5811
2	4.8049	4.3896	4.694	5.487	5.2484	5.6584	5.2484
3	4.3614	4.0238	4.4353	5.1212	4.4353	4.904	4.9897
4	4.0287	3.658	4.1396	4.7554	4.1396	4.1495	4.4353
5	3.6222	3.4751	3.8809	4.0238	3.9179	3.658	4.1396
6	3.8439	3.658	3.8809	4.0238	3.8809	3.658	3.9179
7	3.733	3.8043	3.8809	4.0969	3.9179	3.8775	4.0657
8	3.6591	3.8775	3.807	3.8775	3.8439	3.9506	3.9918
9	3.8809	3.8775	4.0287	4.3164	4.1027	4.2067	4.1766
10	4.3896	5.655	4.792	5.5441	5.1212	5.8029	4.8788
11	4.9749	6.0246	4.7554	5.9877	5.8894	6.1725	5.9507
12	5.048	5.9507	.1463	6.2094	6.2186	5.9137	6.0246
13	5.048	5.9137	.1463	6.2833	6.5844	6.0616	6.1725
14	5.1212	5.8029	.1463	6.4682	6.5112	6.0616	6.0246
15	5.1943	5.4332	.1463	6.653	6.5844	6.1355	6.579
16	5.1212	5.5811	.1463	6.4682	6.5112	6.2094	6.616
17	5.1578	5.8029	7.316	6.3573	6.2186	6.3573	6.3203
18	5.048	5.9137	7.1696	6.1355	6.0357	6.5421	6.0985
19	5.7796	6.4682	7.5354	6.653	6.9502	6.6899	6.7638
20	5.8528	6.1355	6.9502	6.7638	7.0965	6.9117	6.653
21	5.6333	5.8029	6.5844	6.4312	6.2186	6.4312	6.4312
22	5.4138	5.3963	6.1454	5.8768	6.0723	5.8398	5.8894
23	5.8894	6.1355	6.4381	6.2833	6.4746	6.2464	6.1725
24	5.7289	5.7796	5.8029	6.3649	6.1725	6.3649	5.9877
Max	5.8894	6.4682	7.5354	6.7638	7.0965	6.9117	6.7638
Min	3.6222	3.4751	.1463	3.8775	3.8439	3.658	3.9179
Avg	4.8561	5.1534	4.2590	5.6681	5.5812	5.569	5.5462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1

Feeder KV- 33 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.6127	5.6127	5.6698	6.4403	6.2757	6.3831	5.999
2	5.0617	4.6754	5.064	5.7247	5.6127	5.6676	5.6127
3	4.6205	4.2341	4.7325	5.5555	4.7325	5.4458	5.3384
4	4.2913	4.0695	4.401	5.3887	4.4581	4.401	4.7325
5	4.1816	4.0169	4.1267	4.4581	4.1838	4.1267	4.401
6	4.2387	3.8409	4.2935	4.5153	4.4605	4.2959	4.1838
7	4.1861	4.3507	4.3484	4.6822	4.3507	4.4742	4.4033
8	4.074	4.3507	4.2387	4.3484	4.2935	4.4605	4.4033
9	4.3484	4.3462	4.4033	4.7325	4.4581	4.7897	4.5702
10	4.7897	5.8825	.3429	5.8299	5.5555	6.1042	5.1738
11	5.5579	6.2643	5.4458	6.3237	6.326	6.4312	6.1591
12	5.503	6.2666	.3978	6.4883	6.4883	6.2117	6.2688
13	5.503	6.2117	.3407	6.5981	6.9273	6.2666	6.3786
14	5.6104	6.0471	.3407	6.8175	6.9273	6.2666	6.3809
15	5.6653	5.7201	.455	6.9821	9.6708	6.4334	6.9867
16	5.6104	5.8847	.455	6.8747	6.5844	6.5455	6.9318
17	5.7225	6.1042	7.4234	6.765	6.4883	6.6553	6.6553
18	5.6676	6.1591	7.5332	6.4334	6.4358	6.8747	6.4358
19	6.1591	6.5958	7.5172	6.9273	7.4234	6.9273	6.9821
20	6.5112	6.4334	7.3137	7.204	7.4783	7.204	6.9296
21	6.2849	6.1614	6.9867	6.8199	6.6026	6.7672	6.765
22	6.1156	5.9465	6.6026	6.3306	6.6049	6.3306	6.3283
23	6.438	6.5501	7.0988	6.7696	7.156	6.717	6.7696
24	6.2209	6.2734	6.2757	6.9914	6.717	7.0462	6.4975
Max	6.5112	6.5958	7.5332	7.204	9.6708	7.204	6.9867
Min	4.074	3.8409	.3407	4.3484	4.1838	4.1267	4.1838
Avg	5.3323	5.4999	4.4086	6.0834	6.0921	5.9511	5.8870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				1.7961		1.8728	
10						2.1372	1.5388
11						2.2848	1.609
12						2.547	1.8016
13						2.6193	1.8354
14						2.6996	1.8391
17			2.1125				
18			1.6385				
19					2.6783		
20	1.5089						1.8484
21		2.037	1.8709			2.4143	
22				2.0954			
24			1.8785	1.609	2.0206		
Max	1.5089	2.037	2.1125	2.0954	2.6783	2.6996	1.8484
Min	1.5089	2.037	1.6385	1.609	2.0206	1.8728	1.5388
Avg	1.5089	2.037	1.8751	1.8335	2.3495	2.3679	1.7454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 303 / 22 KV Chirner

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				4.9995		4.427	4.2756
10						5.7513	5.9086
11						6.5837	6.8864
12						6.5458	6.4702
13						5.7134	5.9783
14						5.5999	5.3351
17			3.3573				
18			6.0585				
19					5.6584		
20	4.6022						5.3567
21		5.5453	7.0827			5.8848	
22				5.7192			
24			6.955	3.8633	6.7418		
Max	4.6022	5.5453	7.0827	5.7192	6.7418	6.5837	6.8864
Min	4.6022	5.5453	3.3573	3.8633	5.6584	4.427	4.2756
Avg	4.6022	5.5453	5.8634	4.8607	6.2001	5.7866	5.7444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.7189		.6831	.7211
10				.6072	.6445
11				.5687	.6066
12				.4929	.6054
13				.6066	.5693
14				.6066	.6824
17	.4904				
18	.5716				
20					.7922
21	.8659			.8676	
22		.9072			
24		.8307	.8694		
Max	.8659	.9072	.8694	.8676	.7922
Min	.4904	.7189	.8694	.4929	.5693
Avg	.6426	.8189	.8694	.6332	.6602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 223038 / 22/22 KV KOTNAKA URAN

Feeder No / Name : 301 / 22 KV URAN COURT

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
10	1.0434	1.0807
11		1.0807
Max	1.0434	1.0807
Min	1.0434	1.0807
Avg	1.0434	1.0807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223038 / 22/22 KV KOTNAKA URAN

Feeder No / Name : 302 / 22 KV MORA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
10	1.8578	2.148
Max	1.8578	2.148
Min	1.8578	2.148
Avg	1.8578	2.148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 201 / 11 KV Sector - 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5322					
2			3.7723	3.6694		
4			2.8669			
6	3.0864		2.6029			
7				2.5549	2.7244	
8	2.1948	2.4958	2.7349	2.5206		
9		2.4196			2.6217	
10		2.572	2.5463		2.4348	
11	2.4177					
12		2.5652			2.7915	
13					2.7161	
14		2.7349				
15					2.8292	
16	2.8197				2.6783	
17		2.5463				
18		2.5463			2.6029	
20		3.3573				
21	3.4865			3.5437		
22		3.5837		3.7532		
24	3.6523		4.3004	3.9095	4.2867	4.4136
Max	3.6523	3.5837	4.3004	3.9095	4.2867	4.4136
Min	2.1948	2.4196	2.5463	2.5206	2.4348	4.4136
Avg	3.0271	2.7579	3.1373	3.3252	2.8540	4.4136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403						
2			1.2449	1.5432		1.7541	
4			1.094			1.226	
6	1.1145		.9997			1.094	
7				.9431	1.086		
8	.823	1.0288	1.0751	.9088		1.0185	
9		1.0669					
10		1.2384	1.2826		1.3392	1.1694	
11	1.2689						
12		1.3014			1.358	1.2517	
13					1.3392		
14		1.226					
15					1.4335		
16	1.2955				1.3769		1.4861
17		1.2071				1.1488	
18		1.2449			1.2826		
20		1.4146			1.5089		1.5432
21	1.3908			1.5813		1.3717	
22		1.5844		1.6004			
23						1.5432	
24			1.7541	1.6632	1.8099	1.5089	1.6118
Max	1.4403	1.5844	1.7541	1.6632	1.8099	1.7541	1.6118
Min	.823	1.0288	.9997	.9088	1.086	1.0185	1.4861
Avg	1.2222	1.2569	1.2417	1.3733	1.3927	1.3086	1.5470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 203 / 11 KV Sector - 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8409						
2			3.5837	3.8409		3.5082	
4			2.8292			3.0367	
6	2.4006		2.7161			2.9613	
7				2.4348	2.7816		
8	2.2634	2.7054	2.7349	2.452		2.8292	
9					2.7915		
10		2.4768	2.6406		2.6029	2.6595	
11	2.5377						
12		2.6029			2.6217	2.2291	
13					2.5652		
14		2.5274					
15					2.6029		
16	3.0102				2.5274		3.1055
17		2.2445					
18		2.4331			2.5463		
20		3.2253			3.3196		3.5246
21	3.5437			3.8295		3.2407	
22		3.7534		3.9438			
23						4.0638	
24			4.489	4.1324	4.6868	4.5645	4.1324
Max	3.8409	3.7534	4.489	4.1324	4.6868	4.5645	4.1324
Min	2.2634	2.2445	2.6406	2.4348	2.5274	2.2291	3.1055
Avg	2.9328	2.7461	3.1656	3.4389	2.9046	3.2326	3.5875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945						
2			.8488	.9431		2.6029	
4			.679			3.0556	
6	.6516		.5658			2.4143	
7				.6173	.6478		
8	.5144	.6287	.5847	.583		2.2822	
9		.5906					
10		.5716	.5658		.6413	2.1879	
11	.5487						
12		.679			.7733	2.0233	
14		.6413					
15					.7733		
16	.724				.7545		2.9721
17		.6413				1.9547	
18		.6224			.6413		
20		.9242			1.0562		3.7532
21	.9526			.9907		3.4294	
22		.9808		.9907			
23						4.2867	
24			1.2449	1.0802	1.1812	1.1694	4.3724
Max	.9945	.9808	1.2449	1.0802	1.1812	4.2867	4.3724
Min	.5144	.5716	.5658	.583	.6413	1.1694	2.9721
Avg	.7310	.6978	.7482	.8675	.8086	2.5406	3.6992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 205 / 11 KV Railway

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	13-APR-18
HR	Load (MW)
10	2.1879
Max	2.1879
Min	2.1879
Avg	2.1879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029						
2			.1132	.1372		.1132	
4			.1132			.1132	
6	.12		.1132			.1132	
7				.12	.1143		
8	.1372	.1143	.1132	.12		.1132	
9		.1143					
10		.1143	.1132		.1132	.1132	
11	.1029						
12		.1132			.1132	.12	
14		.1132					
15					.1132		
16	.1143				.1132		.1334
17		.1132				.12	
18		.1132			.1132		
20		.1132			.1132		.1334
21	.1143			.1334		.12	
22		.1132		.1334			
23						.1372	
24			.1132	.1543	.1334	.1132	.1372
Max	.1372	.1143	.1132	.1543	.1334	.1372	.1372
Min	.1029	.1132	.1132	.12	.1132	.1132	.1334
Avg	.1153	.1136	.1132	.1331	.1159	.1176	.1347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432						
2			1.6032	1.5432		1.5655	
4			1.3014			1.3769	
6	1.2003		1.3203			1.358	
7				1.2517	1.448		
8	1.1145	1.3527	1.358	1.2689		1.358	
9		1.2574					
10		1.2384	.132		1.3203		
11	1.2174						
12		1.3769			1.4523	1.2517	
13					1.4523		
14		1.3392					
15					1.3957		
16	1.3527				1.4335		1.5051
17		1.226				1.2003	
18		1.1883			1.3392		
20		1.6221			1.7353		1.7337
21	1.8671			1.9624		1.6632	
22		1.6787		1.829			
23						1.749	
24			1.8107	1.749	1.9052	1.9616	1.8004
Max	1.8671	1.6787	1.8107	1.9624	1.9052	1.9616	1.8004
Min	1.1145	1.1883	.132	1.2517	1.3203	1.2003	1.5051
Avg	1.3825	1.3644	1.2543	1.6007	1.4980	1.4982	1.6797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118						
2			1.5089	1.5432		1.3769	
4			1.3957			1.226	
6	1.286		1.1128			1.094	
7				1.0631	1.1622		
8	1.046	1.4098	1.358	1.0802		1.2637	
9		1.4289					
10		1.3908	1.3392		1.3769	1.3203	
11	1.2003						
12		1.4901			1.3769	1.1831	
13					1.3203		
14		1.2449					
15					1.3203		
16	1.3717				1.226		1.3336
17		.9619			1.3769		
18		.9431			1.1128	.9945	
20		1.3203			1.3957		1.3527
21	1.4098			1.5242		.9259	
22		1.5466		1.5242			
23						1.6632	
24			1.905	1.6118	1.8671	1.7353	1.6461
Max	1.6118	1.5466	1.905	1.6118	1.8671	1.7353	1.6461
Min	1.046	.9431	1.1128	1.0631	1.1128	.9259	1.3336
Avg	1.3209	1.3040	1.4366	1.3911	1.3535	1.2783	1.4441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 210 / 11 KV Sector-20A NG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346						
2			1.226	1.3203		1.226	
4			1.0374			1.0374	
6	.8573		.9808			.9808	
7				.8573	1.0669		
8	.7716	.8954	.9431			.7733	
9		.9145					
10		.7811	.8488		.7733	.7733	
11	.8573						
12		.7356			.7167	.6344	
13		.6979					
15					.7733		
16	1.0288				.8299		1.0669
17		.7356				.703	
18					.7356		
20		.9619			.9808		.9907
21	1.105			1.105		.9945	
22				1.2765			
23						1.3546	
24			1.4901	1.3889	1.5242	1.5278	1.3375
Max	1.2346	.9619	1.4901	1.3889	1.5242	1.5278	1.3375
Min	.7716	.6979	.8488	.8573	.7167	.6344	.9907
Avg	.9758	.8174	1.0877	1.1896	.9251	1.0005	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 211 / 11KV Sector-14A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-APR-18
HR	Load (MW)
10	.017
Max	.017
Min	.017
Avg	.017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 212 / 11 KV Sector-20C,Shivani.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687						
2			.7545	.6859		.6979	
4			.6413			.6036	
6	.4115		.5292			.5658	
7				.463	.5144		
8	.3944	.4763	.5093			.5093	
9		.4572					
10		.4763	.4527		.4715	.4715	
11	.4458						
12		.4527			.4338	.4287	
14		.4527					
15					.5281		
16	.5335				.547		.6478
17		.3772					
18		.4527			.4904	.4458	
20		.5847			.6413		.7811
21	.6478			.6097		.6859	
22		.6687		.7621			
23						.9602	
24			.9054	.7888	.8573	.8676	.9431
Max	.6687	.6687	.9054	.7888	.8573	.9602	.9431
Min	.3944	.3772	.4527	.463	.4338	.4287	.6478
Avg	.5170	.4887	.6321	.6619	.5605	.6236	.7907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 214 / 11 KV Sector-19,Bhoomi

SHEDDABLE URBAN

kolsa Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5206						
2			2.452	2.6406		3.9232	
4			2.4143			3.5837	
6	2.1948		2.2634			3.3573	
7				2.2119	2.3053		
8	1.7661	2.1148	2.2822			3.4139	
9		2.1719					
10		2.0957			2.1313	3.3196	
11	1.8347						
12		1.9427			2.037	2.8635	
14		1.9427					
15					2.1879		
16	2.1148				2.1125		2.7435
17		1.8107					
18		1.7164			1.8861	2.7263	
20		2.2634			2.4143		3.3722
21	2.8006			2.8197		2.9835	
22		2.6595		2.7054			
23						3.3608	
24			2.9801	2.8121	3.0102	3.0556	3.5151
Max	2.8006	2.6595	2.9801	2.8197	3.0102	3.9232	3.5151
Min	1.7661	1.7164	2.2634	2.2119	1.8861	2.7263	2.7435
Avg	2.2053	2.0798	2.4784	2.6379	2.2606	3.2587	3.2103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.1694	1.0974			
4			.9808				
6	.8916		.9808				
7				.9602	.9907		
8	.823	.9145	.9431				
9		.9526					
10		.8002	.7545		.9054		
11	.823						
12		.8676			.7545	.7545	
16	1.0669	.8299			1.0562		.9907
18					.8676	.7545	
20					1.2071		1.2193
21	1.0669			1.2955		1.1317	
22		1.2449		1.2955			
23						1.3032	
24			1.2449	.823	1.4098		1.2689
Max	1.0669	1.2449	1.2449	1.2955	1.4098	1.3032	1.2689
Min	.823	.8002	.7545	.823	.7545	.7545	.9907
Avg	.9343	.9350	1.0123	1.0943	1.0273	.9860	1.1596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 301 / Sub Station Transformer

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18
HR	Load (MW)
22	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 302 / Hamara Mahanagar (R.M.U. SHEDDABLE FEEDER HAVING WEEKLY
W-404 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9259		1.0974	1.166	1.0974	
2		.823		1.0631	1.0974	.8573	
3	.9431	.7545	.7545		1.0288	.6859	.7545
4		.6859		.9602	1.0288	.6859	
5		.6859		.9945	1.0288	.823	
6	1.1317	1.0288	1.4712	1.0974	1.0631	1.0288	1.3203
7		1.166		1.0288	1.5089	1.166	
8		1.3032		1.5089	1.5089	1.5432	
9	1.3957	2.0919	2.3388	1.989	2.3663	1.749	1.9616
10	1.5089		2.8121	2.8807	2.6749		2.4006
11	1.6804		3.0521	2.332	2.8807		2.8464
12	1.5432	3.2065	2.9492	3.0521	2.9492		2.5377
13	1.3032		2.5377	2.4006	2.3663		1.9547
14	1.4746		2.6406	2.7778	2.9835		2.5377
15	1.3717	3.5837	3.1207	3.0178	2.9835		2.6406
16	1.3375		3.1893	2.8807	3.1893		2.5034
17	1.3375		2.915	2.6063	3.0178		2.5034
18	1.2003	2.6406	2.2634	2.4348	2.4348		2.1605
19	1.0974		2.1948	1.8519	2.0233		1.7833
20	1.0288		1.7833	1.7147	1.7833		1.7147
21	.9259		1.4746	1.406	1.5432		1.406
22	.9259		1.3375	1.3032	1.3375		1.2346
23	1.0288		1.2003	1.2346	1.3375		1.0974
24	1.3957	1.0288	1.3203	1.2346	1.2003	1.3032	1.2826
Max	1.6804	3.5837	3.1893	3.0521	3.1893	1.749	2.8464
Min	.9259	.6859	.7545	.9602	1.0288	.6859	.7545
Avg	1.2572	1.5327	2.1864	1.8638	1.9376	1.0940	1.9244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 304 / R.M.U. R-496/1

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516		.6859	.823	.7545	
2		.6173		.6516	.7545	.6859	
3	.5658	.5144	.5658	.6516	.6859	.6516	.5281
4		.5144		.583	.6859	.583	
5		.5487		.6516	.7202	.583	
6	1.1317	.6173	.8676	.7202	.7888	.6859	.7545
7		.6859		.7202	.823	.6516	
8		.6859		.7545	.823	.7545	
9	1.0562	1.0288	1.2449	.9945	1.2003	.7545	1.0185
10	1.166		1.5775	1.3375	1.4403		1.4746
11	1.2346		1.7147	1.5432	1.6118		1.6461
12	1.2003	1.5089	1.6118	1.6118	1.7147		1.6118
13	.8916		1.4403	1.2003	1.2689		1.2346
14	1.2003		1.6804	1.5432	1.5775		1.5775
15	1.0974	1.7353	1.6461	1.5775	1.6118		1.6118
16	1.0288		1.6461	1.5089	1.6804		1.6118
17	.9945		1.6804	1.4403	1.6118		1.5432
18	.823	1.3957	1.166	1.166	1.3375		1.3717
19	.823		1.0631	1.0288	1.2346		1.2689
20	.7202		.9259	.9602	1.0974		.9945
21	.6173		.823	.9259	.9602		.8916
22	.6859		.7888	.7888	.8916		.823
23	.6516		.7202	.7545	.823		.7545
24	.9054	.6859	.8676	.7545	.823	.8573	.7167
Max	1.2346	1.7353	1.7147	1.6118	1.7147	.8573	1.6461
Min	.5658	.5144	.5658	.583	.6859	.583	.5281
Avg	.9330	.8608	1.2239	1.0231	1.1245	.6962	1.1907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 305 / NARAYAN DAIRY (R.M.U. W- SHEDDABLE FEEDER HAVING WEEKLY
413) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4348	2.4006	2.5377	
2		2.332	2.4006	1.989	
3		2.2634	2.1948	1.7147	1.5089
4		2.2291	2.0576	1.8861	
5		2.2291	1.8519	1.989	
6		2.2634		2.1948	2.3388
7		1.9204	1.9204	1.5775	
8		3.1207	2.9835	1.7833	
9		3.9438	3.8752	2.0919	3.8477
10		4.3553	4.6639		4.3896
11		4.6982	4.8011		4.6296
12		4.561	4.1838		4.4925
13		3.8752	3.9095		4.0124
14		5.144	4.2867		4.5268
15		5.0755	4.2181		4.8011
16		4.6639	4.904		
17		4.0466	4.7325		4.9383
18		3.8409	3.8752		4.3553
19		3.1893	3.8752		3.4637
20		3.0864	3.155		3.7723
21	2.8464	2.8807	3.2236		2.9835
22	3.155	2.9835	2.7435		2.7435
23	2.572	2.4006	2.6063		2.4348
24		2.6749	2.4691	2.915	2.0748
Max	3.155	5.144	4.904	2.915	4.9383
Min	2.572	1.9204	1.8519	1.5775	1.5089
Avg	2.8578	3.3422	3.3623	2.0679	3.6067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 306 / Roshn Hotel (R.M.U. R-320) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288		1.0631	.9602	.8916	
2		.9602		.9602	.9259	.8916	
3	.7545	.9259	.7545	.9259	.823	.9945	.7545
4		.823		.9945	.823	.9602	
5		.823		1.1317	.9602	.9602	
6	1.1317	.9602	1.094	1.1317	1.0631	1.0288	1.0562
7		1.0288		.9945	1.166	1.0288	
8		1.0974		1.2003	1.166	.9602	
9	1.5844	1.6461	1.5844	1.5432	1.749	1.166	1.5089
10	1.4746		2.1262	1.8861	2.0233		1.749
11	1.8176		2.0919	2.1605	2.2634		2.1605
12	1.6804	2.2634	2.2977	2.0919	2.1605	1.5089	2.0576
13	1.4746		1.7833	1.8176	2.0233		1.6461
14	1.8519		2.2634	2.0919	2.0919		2.0919
15	1.8519	2.2634	2.0919	2.1262	2.332	1.4712	2.0233
16	1.7833		2.0919	2.0576	2.332		2.2634
17	1.749		2.2977	1.9547	2.1605		1.9547
18	1.3032	1.8107	1.9204	1.749	1.9204	1.2449	1.7833
19	1.3032		1.8176	1.7147	1.6118		1.7833
20	1.2689		1.5089	1.5775	1.7147		1.4403
21	1.2003		1.4746	1.3717	1.4403		1.4403
22	1.2003		1.2689	1.2346	1.2346		1.2003
23	1.0631		1.2346	1.0974			1.0974
24	1.2071	1.0288	1.2071	1.0974	.9945	1.0288	1.0562
Max	1.8519	2.2634	2.2977	2.1605	2.332	1.5089	2.2634
Min	.7545	.823	.7545	.9259	.823	.8916	.7545
Avg	1.4278	1.2815	1.7172	1.4989	1.5626	1.0874	1.6148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 307 / R.M.U. R-201

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974		1.166	1.5089	1.3717	
2		1.0288		1.0974	1.3717	1.4403	
3	1.0185	.9602	1.1317	.9945	1.3717	1.5432	.7545
4		.9259		.9945	1.2346	1.406	
5		.9259		1.3032	1.0288	1.166	
6	1.1694	.9602	1.2449	1.3032	1.1317	1.0288	1.094
7		1.0288		1.2689	1.0288	1.0288	
8		1.0631		1.3032	1.2003	1.2346	
9	.9808	.9602	1.094	1.3717	1.2689	1.4403	1.0562
10	1.0288		1.5089	1.9547	1.5775		1.0288
11	1.1317		1.6804	2.1948	1.7833		1.0631
12	1.0974	1.5089	1.6118	2.2291	1.8176	2.3388	1.0974
13	.8916		1.989	1.989	2.0919		1.406
14	1.2689		2.2634	2.1948	2.2291		1.4403
15	1.2689	1.9993	2.4348	2.1948	2.0919	2.1879	1.5089
16	1.2689		2.0576	2.0576	2.2291		1.6118
17	1.2689		1.9547	1.8861	2.2291		1.5089
18	1.2003	1.4712	1.4403	1.3375	1.406	1.4335	.9602
19	1.2346		1.3717	1.0974	1.0974		.9602
20	1.2346		1.0288	1.0288	.8916		.9259
21	1.406		1.1317	.9259	1.0631		.8916
22	1.2689		1.2346	.823	1.2003		1.3032
23	1.2689		1.4403	1.2346	1.3032		1.3375
24	1.5466	1.2346	1.6598	1.3375	1.5432	1.4746	1.4335
Max	1.5466	1.9993	2.4348	2.2291	2.2291	2.3388	1.6118
Min	.8916	.9259	1.0288	.823	.8916	1.0288	.7545
Avg	1.1974	1.1665	1.5710	1.4703	1.4875	1.4688	1.1879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 308 / TECHNOPROCESS (R.M.U. R- SHEDDABLE FEEDER HAVING WEEKLY
260) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089		1.749	1.7147	1.749	
2		1.3717		1.5775	1.6461	1.749	
3	1.3203	1.2346	1.3203	1.4746	1.5775	1.8176	.7545
4		1.166		1.406	1.5089	1.6804	
5		1.166		1.3032	1.3717	1.6118	
6	1.773	1.3717	1.5089	1.3375	1.5775	1.5775	
7		1.7147		1.3375	1.5089	1.2003	
8		1.7833		1.4403	1.6804	1.0631	
9	2.2634	2.7435	2.4143	2.1948	2.6063	1.2689	2.452
10	2.2291		3.2579	2.9492	2.8121		2.7092
11	2.6406		3.3951	2.8464	3.4294		2.8464
12	2.6406	3.2065	3.1893	2.8464	3.0178	1.8484	2.6406
13	2.1262		2.8464	2.4348	2.7435		2.572
14	2.6406		2.9835	2.8121	3.0864		2.8121
15	2.6406	3.131	2.8464	3.0178	3.155	1.8484	2.8807
16	2.6063		2.9835	2.8807	3.2236		2.9492
17	2.6063		3.1893	2.7435	2.9835		2.6406
18	2.3663	2.7538	2.7092	2.5034	2.7435	1.358	2.2291
19	2.0576		2.8121	2.1605	2.572		2.1262
20	1.8519		2.2291	2.0576	2.1605		2.0919
21	1.8519		1.9547	1.989	2.1262		1.749
22	1.9204		2.1262	1.6118	1.6461		1.8176
23	1.6118		1.6118	1.5775	1.5432		1.7833
24	1.8861	1.5775	1.8484	1.8861	1.7833	1.7833	1.3957
Max	2.6406	3.2065	3.3951	3.0178	3.4294	1.8484	2.9492
Min	1.3203	1.166	1.3203	1.3032	1.3717	1.0631	.7545
Avg	2.1685	1.9022	2.5126	2.0891	2.2591	1.5812	2.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.7215	7.2017	5.3841	5.5899	5.487	5.3498	5.487
2	6.5158	6.893	5.2126	5.3841	5.3498	4.8697	5.3498
3	6.3786	6.5844	5.0755	5.2126	5.144	4.6982	5.0755
4	6.1728	6.3786	4.9726	4.8011	4.9726	4.5268	4.6296
5	5.8985	5.8299	5.0755	4.6296	4.6982	4.1495	4.4925
6	5.8299	5.9328	5.1783	4.5268	4.7325	4.0809	
7	5.487	6.0357	4.5953	4.4582	4.6639	4.4239	4.3553
8	5.8299	6.1728	4.4239	4.5268	4.5268	4.2181	4.4239
9	6.2071	6.2414	4.2181	4.2524	4.4239	4.1152	4.4582
10	6.3443	6.4129	4.0466	4.1495	4.1152	4.0809	4.321
11	6.2414	3.9438	3.8752	3.7723	3.7037	3.8409	3.9781
12	6.0014	3.7723	3.7723	3.7723	3.7723	3.7723	3.9781
13	5.8299	3.6008	3.6351	3.6351	3.8409	3.738	
14	6.2757	3.9781	3.9438	3.9438	3.9095	3.9095	4.1152
15	6.3786	3.8752	3.9781	4.0124	4.0466	3.8409	
16	6.1728	3.7723	3.9438	3.9438	3.9438	3.738	
17	5.9671	3.7037	3.7723	3.8752	3.8752	3.5665	
18	5.8985	3.6351	3.8409			3.6008	
19	6.6187	4.4239	4.6639		5.2126	4.561	
20	7.2017	5.144	5.2469	5.3155	5.487	5.0069	5.144
21	7.476	5.3498	5.5213	5.6242	5.7956	5.2469	
22	7.5446	5.6927	5.6584	5.7613	2.4348	5.487	
23	7.6818	5.9671	5.8985	5.9328	5.9328	5.8299	5.8299
24	7.7504	7.3045	5.5213	5.727	5.6584	5.6242	5.5899
Max	7.7504	7.3045	5.8985	5.9328	5.9328	5.8299	5.8299
Min	5.487	3.6008	3.6351	3.6351	2.4348	3.5665	3.9781
Avg	6.4343	5.3269	4.6439	4.6749	4.5968	4.4282	4.7485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli -1(O/G)

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.5103	8.1276	8.0933	8.0933	7.8875	5.144	7.9561
2	7.2017	7.6475	7.8875	7.6818	7.5446	6.8587	8.0247
3	6.7558	6.9959	7.5789	6.6187	6.5158	5.144	7.8189
4	6.1728	6.7558	7.3045	5.9328	5.8985	7.5789	5.487
5	5.8985	6.31	7.0988	5.727	5.5556	5.7613	5.2812
6	4.6982	5.9328	6.8244	5.6584	5.5899	4.9726	4.904
7	4.6296	5.6927	6.6873	5.8299	5.8985	4.4582	4.6296
8	3.1093	6.2757	6.4472	6.3786	6.3786	5.2469	4.8011
9	4.6982	7.0645	6.4129	2.8121	6.5844	5.7613	5.727
10	4.9726	7.4417	6.6873	2.8121	7.0302	6.1728	5.8299
11	5.4184	7.5446	6.8587	2.8807	7.4074	5.8299	6.4815
12	5.2812	7.3731	7.3045	2.6063	7.4417	6.0014	7.3731
13	5.3155	7.2017	7.0302	2.6749	7.6132	5.9671	
14	5.8299	7.3045	7.3731	3.0521	7.5446	6.1728	8.3333
15	5.9328	7.4417	7.7161	2.915	7.9561	6.2071	
16	6.0014	7.5446	7.6818	3.155	7.8875	6.2414	
17	5.9328	7.3045	7.8875	3.4294	7.7161	6.3443	
18	6.0357	7.1331	7.7504		7.5446	6.8587	
19	6.6873	7.6132	8.3676		7.9904	7.0302	
20	6.8587	8.2305	8.5391	8.2305	8.0933	6.9959	8.1276
21	7.0645	8.1619	8.2991	8.3676	8.2305	7.8875	
22	7.3045	8.4705	7.9904	7.6475	8.3676	7.9561	
23	7.9561	8.9163	9.3279	9.3964	8.5734	8.2305	8.4019
24	8.0933	8.2305	8.2305	8.8477	9.0192	8.4705	8.0933
Max	8.0933	8.9163	9.3279	9.3964	9.0192	8.4705	8.4019
Min	3.1093	5.6927	6.4129	2.6063	5.5556	4.4582	4.6296
Avg	6.0566	7.3631	7.5575	5.4885	7.3446	6.3872	6.7044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.7435	2.5034	2.4691		1.5775	2.6749
2	2.4691	2.6063	2.4006	2.4006	1.3717	1.5089	2.7092
3	2.4006	2.5377	2.2977	2.3663	1.3375	1.4746	2.6749
4	2.3663	2.4006	2.1605	2.2291	1.3032	1.4403	2.5034
5	2.332	2.5034	2.0576	2.332	1.3375	1.3717	2.4006
6	2.4006	2.4006	1.989	2.4691	1.406	1.4403	2.4691
7	2.4691	2.4691	2.1262	2.5377	1.3717	1.3375	2.4691
8	1.6461	2.4006	2.2977	2.5377	1.5775	1.2689	2.5034
9	2.6063	2.6406	2.1605	2.6063	1.3717	1.2346	2.6749
10	2.6063	2.8464	2.572	2.572	1.3032	1.3032	2.915
11	2.6406	2.332	2.7778	2.4691	1.166	1.1317	2.8464
12	2.6406	2.0576	2.8121	2.2977	1.2003	1.0974	
13	2.0919	1.9547	2.332	1.9547	1.2689	1.0631	2.8121
14	2.4348	2.332	2.5377	2.7778	1.3032	1.0974	2.8464
15	2.2977	2.3663	2.8121	2.9492	1.406	1.1317	
16	2.2977	2.332	2.6749	2.8121	1.4403	1.8861	
17	2.332	2.4006	2.4348	2.8464	1.3717	1.7833	
18	2.1262	2.0233	2.2291		1.2689	1.7833	
19	2.332	2.2291	2.332		1.5089	1.9547	
20	2.4691	2.4691	2.4691	1.4403	1.5432	2.1605	2.4691
21	2.332	2.332	2.4006	1.6461	1.6118	2.1948	
22	2.6063	2.572	2.6406	1.6461	1.7147	2.4006	
23	2.8121	2.7778	2.8807	1.749	1.7833	2.7778	2.8121
24	2.6749	2.7435	2.6406	2.6406	1.6804	1.6461	2.7435
Max	2.8121	2.8464	2.8807	2.9492	1.7833	2.7778	2.915
Min	1.6461	1.9547	1.989	1.4403	1.166	1.0631	2.4006
Avg	2.4148	2.4363	2.4391	2.3522	1.4195	1.5861	2.6578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2922	3.155	3.5322	3.8409	3.6008	3.9095	3.0864
2	3.2236	3.0864	3.7037	3.738	3.3608	3.6351	3.0178
3	3.155	3.0178	3.3951	3.6008	3.0864	3.5322	3.0864
4	3.0521	2.915	3.5322	3.4294	3.155	3.4294	3.0521
5	2.915	2.8464	3.7037	3.2922	3.155	3.3265	2.9835
6	2.9492	2.9835	3.9438	3.3608	3.1893	3.2579	3.0178
7	3.3265	3.1893	4.0466	3.4979	3.2236	3.1207	2.9835
8	3.2579	3.6351	4.1838	4.2867	3.9438	3.3951	3.3608
9	4.2181	5.2469	5.3498	5.5899	5.0412	3.8409	4.2867
10	5.0069	6.4472	6.4472	6.8587	7.0988	4.1495	5.487
11	5.144	6.6187	7.3388	7.2702	6.9616	4.5268	6.07
12	5.4184	5.727	7.4074	7.2017	6.893	4.3896	6.0014
13	4.0809	5.4184	5.5213	5.5899	7.1674	4.1838	
14	5.2469	7.2017	6.9959	7.1331	6.7901	4.3896	6.1728
15	5.2126	7.476	6.8587	6.8587	6.4472	4.321	
16	5.0755	6.6873	6.653	6.893	6.893	4.3553	
17	4.6639	6.2071	6.5501	6.7558	6.7215	3.9095	
18	4.321	5.6242	5.9328		5.6584	3.7037	
19	4.4239	5.3155	5.2126		5.3498	3.4637	
20	4.1495	4.904	4.6982	4.6639	4.561	3.6008	4.4239
21	3.6694	4.4582	4.2867	4.1838	4.1495	3.4979	
22	3.4294	3.9095	4.1152	3.9781	3.9095	3.4637	
23	3.3608	3.7037	3.8752	3.8409	3.7037	3.2579	3.6008
24	3.8066	3.3265	3.6351	4.0466	3.8066	3.8409	3.155
Max	5.4184	7.476	7.4074	7.2702	7.1674	4.5268	6.1728
Min	2.915	2.8464	3.3951	3.2922	3.0864	3.1207	2.9835
Avg	4.0166	4.7125	5.0383	4.9960	4.9111	3.7709	3.9866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.059	7.2702	7.8875	8.4705	7.7504	8.0247	8.2305
2	7.8875	6.9616	7.8189	7.6475	7.5103	7.4074	7.9904
3	7.6818	6.8587	7.5789	7.4417	7.4074	7.2017	7.8532
4	7.0645	6.7558	7.476	7.2702	7.2017	6.9616	7.6818
5	6.9273	6.6873	7.1674	7.1331	7.8532	7.1674	7.4417
6	7.3731	7.0988	7.2359	7.7504	7.8532	7.5789	7.5789
7	7.6475	7.9904	7.3045	8.0933	7.8875	7.9218	7.8875
8	7.7161	7.6132	7.8875	7.9218	7.8875	7.6475	7.9218
9	8.0247	7.3388	7.9904	7.6475	7.5446		7.476
10	7.2359	6.893	6.893	7.0988	6.893		7.0645
11	6.5844	6.4472	6.4472	6.5844	6.7215	7.5446	6.6873
12	6.8587	6.1728	6.0014	6.3443	6.5158	7.2702	6.4472
13	6.4472	5.487	6.0014	6.0357	6.4815	6.893	
14	6.8587	5.6242	6.2414		6.4129	6.8587	6.8587
15	7.0645	5.6584	6.2757	6.5844	6.4815	6.5844	
16	6.8587	5.6927	6.31	6.2414	6.3786	6.4129	
17	6.5158	5.7613	6.2414	6.1728	6.1728	6.0357	
18	6.5844	5.7956	6.2757		5.8299	6.1043	
19	7.5446	6.9273	7.6132		7.7504	9.6708	
20	8.642	8.642	9.0192	8.7792	8.7792	8.9163	8.7792
21	8.9163	9.0535	9.1221	9.1907	9.5336	8.9506	
22	8.9506	8.9163	9.225	9.1907	9.4307	8.9506	
23	8.4705	8.7449	9.1907	9.0535	9.2936	9.1221	9.0535
24	8.2305	7.8532	8.0933	8.642	8.5391	8.3333	8.4019
Max	8.9506	9.0535	9.225	9.1907	9.5336	9.6708	9.0535
Min	6.4472	5.487	6.0014	6.0357	5.8299	6.0357	6.4472
Avg	7.5060	7.0102	7.3874	7.5854	7.5046	7.6163	7.7096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458	.4801	.4458	.4801	.4801	.4458
2		.4458	.4458	.4458		.4801	.4458
3	.4115	.4458	.4458	.4458		.4801	.4458
4		.4458	.4458	.4458		.4458	.4458
5		.4458	.4458	.4458		.4458	.4458
6	.4115	.4458	.4801	.4458	.4115	.4458	.4115
7		.4115	.4458	.4458		.4458	.4458
8		.4458	.4115	.4458		.4458	.4458
9	.4458	.4458	.4458	.4458	.4458	.4458	.4458
10	.4458	.4458	.4458	.4801	.4801	.4458	.4801
11	.4458	.4801	.4801	.4801	.4801	.4801	.4458
12	.4115	.4801	.4801	.4801	.4801	.4801	.4458
13	.4458	.4801	.4801	.4801	.4801	.4801	
14	.4458	.4801	.4801		.4801	.4801	.4458
15	.4458	.4801	.4801	.4801	.4801	.4801	
16	.4458	.4801	.4801	.4801	.4801	.4801	
17	.4458	.4458	.4801	.4801	.4801	.4801	
18	.4115	.4458	.4458		.4458	.4458	
19	.4458	.4801	.4458		.4801	.4458	
20	.4801	.4801	.4458	.4801	.4801	.4458	.4801
21	.4801	.4458	.4801	.4801	.4801	.4801	
22	.4458	.4458		.4801	.4801	.4801	
23	.4458	.4801	.4458	.4801	.4801	.4801	.4801
24	.4801	.4801	.4801	.4801	.4801	.4801	.4801
Max	.4801	.4801	.4801	.4801	.4801	.4801	.4801
Min	.4115	.4115	.4115	.4458	.4115	.4458	.4115
Avg	.4439	.4587	.4607	.4654	.4725	.4658	.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8807	2.9835	2.8464	3.0864	3.0864	2.8807	2.9835
2	2.8121	2.8464	2.7435	2.9835	2.915	2.5377	2.915
3	2.7435	2.7435	2.572	2.915	2.7435	2.4006	2.8464
4	2.6063	2.6749	2.4006	2.7435	2.6406	2.2634	2.7435
5	2.5034	2.572	2.1605	2.6063	2.7092	2.0919	2.6406
6	2.4348	2.6063	2.0576	2.6406	2.7778	1.989	2.6749
7	2.4691	2.6406	2.2977	2.6406	2.7435		2.4348
8	2.332		2.5034	2.5034	2.6749		2.4691
9	2.4691	2.2977	2.4006	2.1948	2.0919		2.1948
10	2.572	2.2291	2.2291	2.332	2.0576		2.4006
11	2.3663	2.2977	2.1262	2.1948	2.1948	1.6804	2.4006
12	2.2291		2.0919	2.2291	2.2977	1.7147	2.4006
13	2.2977	2.2291	2.2634	2.2634	2.332	2.6406	
14	2.1948	2.3663	2.1948		2.4006	2.7435	2.2977
15	2.332	2.1605	2.1262	2.1948	1.989	2.5034	
16	2.1948	1.989	1.8861	2.1262	2.1605	2.0576	
17	2.1262	2.0576	2.1605	2.0576	2.0919	2.1262	
18	2.0576	1.989	1.7147		2.0233	2.1262	
19	2.1948	2.2977	2.332		2.332	2.4691	
20	2.572	2.6749	2.8464	2.8464	2.572	2.8121	2.8464
21	2.7778	2.9492	2.8464	2.8121	2.9492	2.8807	
22	2.9835	3.2579	3.0864	3.0178	3.2922	2.8807	
23	3.155	3.5322	3.4294	3.4637	3.4979	3.155	3.3608
24	3.0178	3.155	2.9492	3.2236	3.2236	3.0864	3.1207
Max	3.155	3.5322	3.4294	3.4637	3.4979	3.155	3.3608
Min	2.0576	1.989	1.7147	2.0576	1.989	1.6804	2.1948
Avg	2.5134	2.5705	2.4277	2.6226	2.5749	2.4520	2.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 310 / 22 KV HINDALCO INCOMER TO NON SHEDDABLE EXPRESS HV FEEDERS
 22/1 Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.155	3.3265	3.2579	3.3265	3.3608	3.4294	3.5322
2	3.0864	3.1893	3.0864	3.0864	3.3265	2.9492	3.4294
3	2.915	3.0864	2.9835	2.7778	3.0864	2.8464	3.0178
4	2.7435	2.9835	2.8464	2.6063	2.7435	2.7435	2.8121
5	2.4006	2.7435	2.7435	2.5034	2.6063	2.6749	2.572
6	2.4691	2.4691	2.572	2.4348	2.5034	2.572	2.4006
7	2.2977	2.332	2.4006	2.4006	2.4691	2.4006	2.2291
8	2.2634	2.4006	2.5034	2.5377	2.5034	2.4691	2.4691
9	2.4691	2.6063	2.6063	2.7435	2.6749	2.4348	2.4006
10	2.4348	2.5377	2.572	2.572	7.2017	2.5034	2.5034
11	2.4348	2.5034	2.4348	2.5034	6.7558	2.5034	2.4348
12	2.3663	2.4006	2.4006	2.4006	2.7435	2.4691	2.4348
13	2.4348	2.2977	2.332	2.4006	2.8121	2.5034	
14	2.4348	2.4006	2.4348		2.6063	2.5377	
15	2.4691	2.3663	2.2291		2.572	2.5034	
16	2.332	2.332	2.4006	2.5034	2.5377	2.4348	
17	2.1948	2.2291	2.3663	2.4006	2.5034	2.2291	
18	2.2977	2.1948	2.332		2.5034	2.2291	
19	2.7778	2.572	2.8121		2.915	2.8807	
20	2.8807	2.8464	3.155	3.0178	3.0178	3.0864	3.1207
21	2.9835	2.9835	3.155	3.1207	3.0864	3.155	
22	3.0178	3.1893	3.155	3.155	3.3265	3.1207	
23	3.2922	3.4294	3.4637	3.4294	3.5665	3.3265	3.4294
24	3.2579	3.4294	3.4294	3.3608	3.6008	3.5322	3.6008
Max	3.2922	3.4294	3.4637	3.4294	7.2017	3.5322	3.6008
Min	2.1948	2.1948	2.2291	2.4006	2.4691	2.2291	2.2291
Avg	2.6420	2.7021	2.7364	2.7641	3.2093	2.7306	2.8258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3663	2.5034	2.2977	2.4691	2.332	2.5034	2.6749
2	2.2634	2.4006	2.1605	2.332	2.0576	2.332	2.4691
3	2.0919	2.2977	2.0576	2.0576	1.9547	2.1605	2.1605
4	1.989	2.1605	1.989	1.8861	1.8861	2.0576	2.0576
5	1.9204	2.0576	1.8861	1.989	1.9547	1.9547	1.9204
6		1.989	2.2291	2.0576	2.0919	1.8861	1.9547
7		2.0919	2.2634	2.0576	2.0576	2.1262	1.8519
8		1.9547	1.1317	2.0919	2.1262	2.0576	1.8519
9	1.9204	1.9204	2.2291	1.9204	1.8176	1.9547	1.9204
10	1.7833	1.9204	2.1605	2.0576	1.749	1.989	1.6118
11	1.7833	2.2291	2.0576	2.1948	1.8861	2.1948	2.1262
12	1.9547	2.0576	2.1948	2.0576	1.9547	2.0576	1.989
13	1.7833	1.8861	2.0576	2.0576	2.0919	1.9547	
14	1.9204	1.9204	1.8519	2.0576	2.1948	2.2634	2.1948
15	2.0919	1.9547	1.8176	2.0576	2.1262	2.0576	
16	1.9204	1.9204	2.0576	2.0576	2.0576	1.989	
17	1.6461	1.7147	1.9204	1.0288	1.9204	1.8519	
18	1.7147	1.5775	1.8176		1.7833	1.8519	
19	2.0233	1.8861	2.1262		2.1262	1.9547	
20	2.1948	2.1948	2.4691	2.1948	2.2291	2.2634	
21	2.1948	2.2634	2.4348	2.3663	2.332	2.3663	2.3663
22	2.2634	2.3663	2.4006	2.572	2.5377	2.1948	
23	2.572	2.6063	2.7435	2.8121	2.6749	2.7435	2.6063
24	2.6063	2.572	2.4348	2.572	2.4691	2.6406	2.7435
Max	2.6063	2.6063	2.7435	2.8121	2.6749	2.7435	2.7435
Min	1.6461	1.5775	1.1317	1.0288	1.749	1.8519	1.6118
Avg	2.0478	2.1019	2.1162	2.1340	2.1005	2.1419	2.1562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 312 / 22 KV Vodafone

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3717	1.1317	1.2003	1.2003	1.2346	1.6118
2	1.2003	1.3032	1.0288	1.166	1.166	1.166	1.5089
3	1.1317	1.166	.9602	1.0288	1.0974	1.1317	1.406
4	1.0974	1.0974	1.1317	1.0974	1.1317	1.0288	1.3717
5	1.2003	1.0288	1.0974	1.0288	1.166	1.0974	1.3032
6	1.3375	1.0974	1.3032	1.166	1.2346	1.1317	1.2003
7	1.3717	1.1317	1.3717	1.166	1.2003	1.2003	1.2003
8	1.6461	1.166	1.5432	1.7833	1.7147	1.3032	1.2346
9	1.5775	1.2346	1.3717	1.6461	1.6461	1.5432	1.8861
10	1.2003	1.7833	1.1317	1.6118	1.2346	1.7147	1.749
11	1.2346	1.6461	1.2346	1.3032	1.2689	1.2346	1.2689
12	1.2346	1.5089	1.7147	1.2346	1.3717	1.166	
13	1.749	1.2346	1.2346	1.2346	1.5432	1.2003	
14	1.5775	1.2346	1.2346		1.7833	1.8176	
15	1.2003	1.3717	1.2346	1.6118	1.2346	1.3717	
16	1.2003	1.6804	1.7147	1.6118	1.3032	1.3032	
17	1.2003	1.4746	1.749	1.6804	1.5432	1.2346	
18	1.7833	1.2003	1.6461		1.7833	1.2346	
19	1.5775	1.4746	1.2003		1.6461	1.7833	
20	1.2003	1.7833	1.2003	1.2346	1.3717	1.2346	
21	1.2003	1.5775	1.2003	1.7833	1.2346	1.2346	
22	1.2003	1.3717	1.7833	1.6118	1.5089	1.2346	
23	1.8519	1.2003	1.6118	1.2346	1.7147	1.6461	
24	1.5775	1.5775	1.2003	1.2003	1.2346	1.2003	1.6804
Max	1.8519	1.7833	1.7833	1.7833	1.7833	1.8176	1.8861
Min	1.0974	1.0288	.9602	1.0288	1.0974	1.0288	1.2003
Avg	1.3689	1.3632	1.3346	1.3636	1.3889	1.3103	1.4518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6668	.6478	.6478	.6668	.6668	.6668
2	.6478	.6478	.6287	.6287	.6478	.6478	.6478
3	.6287	.6287	.6287	.6287	.6287	.6287	.6478
4	.6287	.6287	.6287	.6287	.6287	.6287	.6478
5	.6287	.6287	.6287	.6287	.6478	.6287	.6478
6	.6287	.6287	.6478	.6478	.6668	.6097	.6478
7	.6478	.6668	.6859	.6668	.6668	.6287	.6668
8	.6668	.7621	.724	.724	.743	.6859	.6859
9	.6097	.9717	.9335	1.0669	1.0479	.9717	.8002
10	.6287	1.2574	1.2003	1.2193	1.1812	1.1812	.9335
11	.6668	1.3146	1.2384	1.2384	1.2003	1.1622	.9526
12	.6859	1.2765	1.1622	1.2384	1.1812	1.2193	.9145
13	.6668	1.1622	1.1622	1.1241	1.1622	1.1812	.8764
14	.6287	1.2765	1.2193	1.2193	1.1622	1.2384	.9335
15	.6287	1.2384	1.3146	1.2384	1.2193	1.2574	.9526
16	.6478	1.2193	1.2003	1.2765	1.2193	1.2384	.8573
17	.6668	1.2193	1.2003	1.2003	1.2574	1.1812	.8002
18	.6478	1.1622	1.086	1.1622	1.086	1.1431	.7621
19	.743	1.105	1.0669	1.086	1.0669	.8573	.8002
20	.743	1.0288	1.086	.9335	.9907	.8573	.7621
21	.7811	.8573	.8383	.8383	.8192	.7811	.724
22	.7621	.7811	.7811	.7621	.7811	.7621	.743
23	.6859	.743	.7621	.724	.743	.724	.7049
24	.6478	.6668	.6859	.6859	.6859	.7049	.6859
Max	.7811	1.3146	1.3146	1.2765	1.2574	1.2574	.9526
Min	.6097	.6287	.6287	.6287	.6287	.6097	.6478
Avg	.6652	.9391	.9232	.9256	.9208	.8994	.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.381	.362	.4001	.381	.4191
2	.362	.362	.362	.362	.381	.381	.381
3	.362	.362	.362	.3429	.381	.381	.381
4	.362	.362	.3429	.3429	.381	.381	.381
5	.362	.362	.3429	.3429	.381	.381	.381
6	.362	.381	.381	.381	.4001	.4191	.381
7	.362	.4572	.5335	.4572	.4191	.8192	.362
8	.381	.9526	.9907	.8954	1.0098	1.0288	.4191
9	.381	.9907	.9526	.5335	1.0288	1.0288	.724
10	.2096	1.0669	1.0288	1.086	1.0669	.8764	.724
11	.362	1.1431	1.0479	1.105	1.0479	.9717	.724
12	.4001	1.0098	.9907	1.105	1.0669	.9335	.7621
13	.4001	.9717	.9717	.9335	1.0288	.9335	.743
14	.4001	.9335	.9526	.9335	1.0288	.9335	.7049
15	.381	.9335	.9335	1.1241	.8764	.9145	.7049
16	.381	.9335	.9145	.9335	.8764	.8764	.4763
17	.3429	.8954	.8764	.8954	.8192	.8383	.4954
18	.3429	.8383	.8383	.724	.8383	.8383	.4191
19	.3429	.8192	.8383	.8573	.8002	.5335	.4191
20	.381	.6287	.6097	.6287	.724	.5335	.4191
21	.362	.5525	.5525	.4954	.4954	.4191	.4191
22	.3429	.5335	.4763	.4954	.4572	.4191	.381
23	.381	.4382	.4572	.4572	.4382	.4382	.4191
24	.362	.362	.4001	.4001	.4001	.4191	.4191
Max	.4001	1.1431	1.0479	1.1241	1.0669	1.0288	.7621
Min	.2096	.362	.3429	.3429	.381	.381	.362
Avg	.3620	.6938	.6890	.6747	.6978	.6700	.5025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.2477	.2096	.2858	.2858	.2286
2	.2286	.2286	.2286	.2096	.2667	.2858	.2286
3	.2286	.2286	.2286	.1905	.2096	.2858	.2096
4	.2286	.2286	.2286	.1905	.2096	.2858	.2096
5	.2286	.2286	.2286	.1905	.2096	.2858	.2096
6	.2286	.2286	.2667	.2286	.2096	.2858	.2096
7	.2286	.3048	.3048	.2858	.362	.4572	.2667
8	.2286	.4572	.362	.3429	.4572	.4763	.2858
9	.2667	.5906	.5144	.3048	.5716	.5525	.381
10	.2667	.6478	.5335	.6097	.5906	.5716	.4001
11	.2667	.6097	.5716	.6097	.5525	.5716	.4191
12	.2667	.6287	.6097	.6097	.5906	.5716	.4191
13	.2667	.6478	.6287	.6478	.5716	.5716	.381
14	.2667	.6478	.6287	.6097	.6287	.6478	.4001
15	.2858	.6287	.6097	.6097	.6097	.6287	.4001
16	.2858	.6287	.6478	.6859	.6097	.6478	.4382
17	.2858	.6097	.6478	.6287	.6287	.6287	.4382
18	.2667	.6097	.5906	.6097	.5335	.5906	.381
19	.2858	.4763	.5335	.5716	.5335	.362	.362
20	.2858	.4191	.4763	.4001	.4572	.362	.3239
21	.2477	.381	.4572	.4001	.3429	.3239	.2858
22	.2477	.4191	.362	.3429	.3239	.362	.2477
23	.2858	.4001	.3239	.2858	.3239	.362	.2286
24	.2858	.2477	.3239	.2096	.3239	.2858	.2858
Max	.2858	.6478	.6478	.6859	.6287	.6478	.4382
Min	.2286	.2286	.2286	.1905	.2096	.2858	.2096
Avg	.2588	.4469	.4398	.4160	.4334	.4454	.3183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3429	.3239	.3429	.3429	.3429
2	.3048	.3048	.3239	.3048	.3239	.3239	.3239
3	.3048	.3048	.3239	.3048	.3048	.3048	.3239
4	.3048	.3048	.3239	.3048	.3048	.3048	.3239
5	.3048	.3048	.3239	.3048	.3048	.3048	.3239
6	.3048	.3048	.3429	.3048	.3239	.3048	.3239
7	.3239	.3429	.381	.3048	.3429	.3048	.3239
8	.362	.5144	.4382	.4382	.4572	.362	.4191
9	.3429	.5906	.5335	.5716	.5716	.5144	.4572
10	.362	.6668	.6097	.6287	.6097	.5716	.4954
11	.362	.6668	.6287	.6478	.6097	.5906	.4763
12	.4001	.6859	.6478	.6478	.6478	.5525	.4954
13	.381	.6478	.6287	.6859	.6287	.5525	.5144
14	.381	.6478	.6859	.7049	.6287	.6478	.4954
15	.4001	.6859	.6668	.6287	.6668	.6478	.5525
16	.4001	.6478	.6668	.6097	.6668	.6287	.5144
17	.381	.6859	.6287	.6287	.6097	.6287	.4954
18	.3429	.6097	.6097	.5906	.5906	.5716	.4572
19	.4001	.6287	.5716	.5906	.5525	.5716	.4572
20	.4191	.5525	.5144	.5335	.5335	.5525	.4572
21	.4001	.5144	.4572	.4954	.4954	.5335	.4763
22	.381	.4763	.4001	.4572	.4191	.4954	.4572
23	.362	.4382	.362	.381	.4001	.4001	.381
24	.3239	.3239	.362	.3429	.3429	.362	.381
Max	.4191	.6859	.6859	.7049	.6668	.6478	.5525
Min	.3048	.3048	.3239	.3048	.3048	.3048	.3239
Avg	.3564	.5065	.4906	.4890	.4866	.4739	.4279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3048	.362	.3429	.4191	.4191	.4191
2	.2858	.3048	.3429	.3429	.381	.381	.381
3	.2858	.3048	.3429	.3239	.3429	.3429	.3239
4	.2858	.3048	.3239	.3239	.3429	.3429	.3239
5	.2858	.3048	.3239	.3429	.3429	.3429	.3239
6	.2858	.3048	.3429	.4191	.3429	.3429	.3239
7	.2858	.6097	.4191	.7049	.7049	.7049	.3239
8	.3048	.7621	.8192	.7621	.8383	.7049	.3429
9	.3239	1.0669	.9907	.8954	1.0479	.8954	.4572
10	.3239	1.2574	1.2003	1.1431	1.1622	1.1431	.6287
11	.381	1.3527	1.3146	1.2384	1.2574	1.2384	.743
12	.4191	1.3527	1.3527	1.2765	1.2765	1.2765	.7811
13	.4001	1.4289	1.3146	1.2765	1.2955	1.2765	.743
14	.4382	1.3527	1.3527	1.2765	1.3336	1.3336	.7811
15	.4572	1.4098	1.3908	1.2765	1.3336	1.3336	.8002
16	.4572	1.4098	1.3717	1.3146	1.3336	1.3336	.7811
17	.4191	1.3336	1.3336	1.2574	1.2955	1.3336	.743
18	.4191	1.2384	1.2003	1.086	1.1241	1.086	.724
19	.362	1.105	1.0288	.9335	.8383	.9526	.6287
20	.3239	.8573	.8002	.7621	.7811	.7621	.381
21	.3239	.743	.724	.6668	.7049	.5716	.4001
22	.3429		.5906	.4954	.4572	.4954	
23	.362	.4572	.4191	.4572	.4572	.4572	.3239
24	.2858	.3048		.381	.4382	.4191	.4382
Max	.4572	1.4289	1.3908	1.3146	1.3336	1.3336	.8002
Min	.2858	.3048	.3239	.3239	.3429	.3429	.3239
Avg	.3477	.8639	.8548	.8041	.8272	.8121	.5268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953		.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953	.1715	.0953
8	.0953	.0953	.0953	.0953	.0953	.362	.4001
9	.0953	.4572	.4572	.3048	.4763	.4191	.362
10	.0953	.4382	.4191	.4572	.4382	.4001	.3429
11	.0953	.381	.4001	.4382	.4191	.362	.3429
12	.0953	.381	.3429	.4001	.3429	.362	.3429
13	.0953	.381	.4001	.381	.3429	.381	.3429
14	.0953	.4382	.4191	.4763	.4572	.5144	.3429
15	.0953	.4191	.4572	.4382	.4572	.4572	.362
16	.0953	.362	.362	.4001	.381	.381	.3429
17	.0953	.362	.362	.3429	.362	.3239	.3239
18	.0953	.362	.362	.3239	.3429	.3429	.2096
19	.0953	.3048	.2477	.2858	.2286	.1715	.2096
20	.0953	.1715	.2477	.0953	.1905	.1715	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.0953	.4572	.4572	.4763	.4763	.5144	.4001
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.2334	.2402	.2286	.2326	.2405	.2112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2477	.2477	.0953	.1524	.2858
2	.1905	.1905	.2286	.2286	.0953	.1524	.2667
3	.1905		.2096	.2096	.0953	.1524	.2667
4	.1905	.1905	.2096	.2096	.0953	.1524	.2667
5	.1905	.1905	.2096	.2096	.0953	.1524	.2667
6	.1905	.1905	.2096	.2286	.0953	.1524	.2667
7	.1905	.1905	.2286	.2286	.0953	.1524	.2477
8	.2286	.2096	.2286	.2286	.0953	.1524	.2286
9	.2096	.4001	.362	.3239	.381	.3048	.2477
10	.2096	.5335	.4382	.4572	.4382	.4572	.2477
11	.2096	.4763	.4954	.4572	.4572	.4763	.2667
12	.2096	.4954	.5144	.4382	.4763	.5144	.2667
13	.2096	.4763	.4763	.5144	.4763	.5144	.2667
14	.2286	.4954	.5335		.4763	.5144	.2858
15	.2286	.5144	.5335	.4954	.4763	.4954	.2858
16	.2286	.4763	.5144	.5144	.4763	.5144	.3048
17	.2286	.4763	.4954	.4763	.4954	.4572	.2858
18	.2096	.4763	.4572	.4382	.4572	.4382	.2858
19	.1905	.4001	.362	.3429	.2858	.3048	.2667
20	.1905	.3239	.3239	.3239	.2286	.3048	.2667
21	.1905	.2858	.3048	.2286	.2096	.3048	.2477
22	.1905	.2858	.2286	.2286	.1905	.3048	.2667
23	.2096	.2667	.2667	.0953	.0953	.2858	.2286
24	.1905	.1905	.2477	.2477	.0953	.1524	.2858
Max	.2286	.5335	.5335	.5144	.4954	.5144	.3048
Min	.1905	.1905	.2096	.0953	.0953	.1524	.2286
Avg	.2040	.3446	.3469	.3206	.2699	.3151	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.724	.7621	.7811	.7621	.7621	.724
2	.7049	.724	.7621	.7621	.7811	.7621	.724
3	.7049	.724	.743	.7621	.7621	.7621	.724
4	.7049	.724	.743	.7621	.7621	.7621	.724
5	.7049	.724	.743	.7621	.7811	.7621	.724
6	.7049	.724	.8002	.7621	.7621	.7621	.724
7	.7049	.7621	.8573	.8002	.7811	.8573	.743
8	.7049	1.0098	.9335	.9145	.9717	.9526	.7621
9	.7049	1.2765	1.2765	1.4289	1.2765	1.2955	1.0098
10	.724	1.5623	1.448	1.5623	1.5813	1.5051	1.1812
11		1.5813	1.6575	1.5242	1.5813	1.467	1.2193
12		1.5051	1.4289	1.5051	1.467	1.4861	1.1812
13		1.448	1.467	1.448	1.467	1.4861	1.2574
14		1.5623		1.6385	1.6004	1.6004	1.3336
15		1.5432	1.6956	1.6385	1.6385	1.6194	1.2003
16		1.6004	1.6766	1.7147	1.6575	1.6575	1.1622
17	.7811	1.6194	1.6766	1.6194	1.6385	1.6004	1.0669
18	.7621	1.467	1.5432	1.448	1.467	1.467	.9717
19	.7811	1.2765	1.3146	1.2003	1.105	1.3336	.9145
20	.7621	1.0098	1.0669	.9526	.9145	1.0098	.8383
21	.7621	.9335	.9335	.8764	.9145	.8192	.8002
22	.743	.8192	.8764	.8573	.8383	.8002	.8002
23	.7049	.8192	.8383	.8383	.8192	.7621	.743
24	.724	.724	.743	.8192	.7621	.743	.724
Max	.7811	1.6194	1.6956	1.7147	1.6575	1.6575	1.3336
Min	.7049	.724	.743	.7621	.7621	.743	.724
Avg	.7282	1.1193	1.1299	1.1408	1.1288	1.1265	.9272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8002	.9145	.9335	.9145	.8954	.8764
2	.8573	.8002	.8954	.9145	.8573	.8764	.8954
3	.8573	.8002	.8954	.8954	.8954	.8764	.8764
4	.8573	.8002	.8954	.8764	.8954	.8954	.8764
5	.8573	.8002	.9145	.8764	.8954	.8954	.8764
6	.8573	.724	.9145	.8764	.8954	.8954	.8764
7	.8573	.7621	.9335	.8954	.9145	.9335	.8764
8	.8573	1.0098	.9717	1.0288	1.0479	1.0479	.8954
9	.8954	1.448	1.1431	1.4289	1.4098	1.3336	1.0669
10	.9145	1.6385	1.5623	1.5813	1.6575	1.5813	1.2003
11		1.7337	1.6194	1.6004	1.6385	1.6004	1.2193
12		1.5813	1.6004	1.6194	1.5813	1.6385	1.2003
13		1.5623	1.5623	1.5623	1.5623	1.6385	1.1812
14		1.5051	1.5813	1.6194	1.5623	1.6004	1.2193
15		1.5623	1.6575	1.6956	1.6385	1.6575	1.2384
16		1.6004	1.6194	1.5813	1.6956	1.6004	1.1622
17	1.1812		1.5623	1.6004	1.6004	1.5813	1.1431
18	.9145	1.5051	1.4861	1.5242	1.5242	1.5051	1.086
19	.8383	1.3336	1.3146	1.2955	1.2765	1.3527	1.0288
20	.8764	1.105	1.1241	1.086	1.2193	1.086	.8573
21	.8383	.9907	1.0669	1.0098	1.0669	.9335	.8764
22	.8573	.9717	1.0098	1.0098	.9526	.9335	.8954
23	.8383	.9526	.9717	.9335	.9145	.9335	.8573
24	.8573	.8192	.9145	.9335	.8954	.8954	.8954
Max	1.1812	1.7337	1.6575	1.6956	1.6956	1.6575	1.2384
Min	.8383	.724	.8954	.8764	.8573	.8764	.8573
Avg	.8817	1.1655	1.2138	1.2241	1.2296	1.2161	1.0074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.3048	.3048	.3048	.2667	.2667
2	.2667	.2667	.3048	.3048	.3048	.2667	.2667
3	.2667	.2667	.3048	.3048	.3048	.2667	.2667
4	.2667	.2667	.3048	.3048	.3048	.2667	.2667
5	.2667	.2667	.3048	.3048	.3048	.2667	.2667
6	.2667	.2667	.3048	.3048	.3048	.2667	.2667
7	.2667	.3048		.3048	.3048	.2667	.2667
8	.2667	.3239	.3048	.3048	.3048	.3048	.2667
9	.2667	.3429	.3239	.381	.362	.362	.3048
10	.2667	.381	.381	.381	.362	.4001	.362
11		.4001	.4191	.4382	.4382	.4191	.362
12		.4382	.4572	.4572	.4191	.4954	.362
13		.4001	.4191	.4572	.4191	.4382	.362
14		.4382	.4191	.4572	.4001	.4382	.4001
15		.4191	.4191	.4382	.4001	.4191	.4382
16		.4001	.4382	.4382	.362	.4382	.362
17		.381	.4001	.4382	.381	.4001	.3429
18	.2667	.362	.381	.4382	.4001	.362	.3048
19	.3048	.3429	.362	.4001	.362	.362	.3048
20	.3048	.381	.3429	.362	.3429	.3429	.3048
21	.3048	.362	.3239	.3429	.3048	.3048	.3048
22	.2667	.3429	.3048	.3239	.3048	.3048	.3048
23	.2667	.3239	.3048	.3048	.3048	.3048	.3048
24	.2667	.2667	.3048	.3048	.3048	.3048	.3048
Max	.3048	.4382	.4572	.4572	.4382	.4954	.4382
Min	.2667	.2667	.3048	.3048	.3048	.2667	.2667
Avg	.2734	.3421	.3537	.3667	.3461	.3445	.3151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381	.381		.381	.381
2			.381	.381	.381	.381	.381
3	.3772	.3772	.381	.381		.381	.381
4			.381	.381	.381	.381	.381
5			.1905	.381		.1905	.381
6	.1886	.0189	.1905	.1905	.1905	.1905	.1905
7		.1905	.1905	.1905	.1905	.1905	.1905
8		.1905	.1905			.1905	.1905
9	.1886	.1905	.1905			.1905	.1905
10		.1905	.1905			.381	.1905
11		.1905	.381		.1905	.381	.381
12	.1886	.1905	.1905		.1905	.381	.381
13		.1905	.1905	.1905	.381	.381	.381
14		.1905	.1905		.381	.381	.381
15	.1886	.1905	.1905		.1905	.381	.3772
16		.1905	.1905	.1905	.1905	.1905	
17			.1905		.1905	.1905	
18	.1886	.1905	.1905		.1905	.1905	
19		.1905	.1905		.1905	.1905	
20		.1905	.1905		.1905	.1905	
21	.1886		.1905		.1905	.1905	
22		.1905	.381		.1905	.381	
23	.3772	.1905	.381	.381	.381	.381	
24	.3772	.3772	.381	.381	.381	.381	.381
Max	.3772	.3772	.381	.381	.381	.381	.381
Min	.1886	.0189	.1905	.1905	.1905	.1905	.1905
Avg	.2515	.2017	.254	.3117	.254	.2937	.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7621	.7621		.7621	.7621
2			.7621	.7621	.381	.7621	.7621
3	.5658	.5658	.7621	.7621		.7621	.7621
4			.7621	.7621	.7621	.7621	.7621
5			.7621	.7621		.7621	.7621
6	.5658	.5658	.7621	.7621	.7621	.7621	.7621
7		.5716	.7621	.7621	.7621	.7621	.7621
8		1.1431	.7621		1.1431	.7621	.7621
9	.5658	1.5242	1.5242		1.5242	.7621	1.1431
10		1.9052	1.5242		1.9052	1.5242	1.1431
11		1.9052	1.5242		1.9052	1.9052	1.1431
12	.5658	1.9052	1.5242		1.9052	1.9052	1.1431
13		1.9052	1.5242	1.5242	1.9052	1.9052	1.1431
14		1.9052	1.5242		1.9052	1.9052	1.3336
15	.5658	1.9052	1.9052		1.9052	1.9052	1.3203
16		1.9052	1.9052		1.9052	1.9052	
17		1.5242	1.9052	1.9052	1.9052	1.9052	
18	.5658	1.5242	1.5242		1.5242	1.9052	
19		1.5242	1.1431		1.5242	1.1431	
20		.7621	1.1431		1.1431	1.1431	
21	.5658	.7621	1.1431		1.1431	1.1431	
22		.7621	.7621		.7621	1.1431	
23	.5658	.7621	.7621	.7621	.7621	.7621	
24	.5658	.5658	.7621	.7621	.7621	.7621	.7621
Max	.5658	1.9052	1.9052	1.9052	1.9052	1.9052	1.3336
Min	.5658	.5658	.7621	.7621	.381	.7621	.7621
Avg	.5658	1.2947	1.1749	.9353	1.3427	1.2384	.9518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381	.381		.381	.5716
2			.381	.381	.381	.381	.5716
3	.3772	.1886	.381	.381		.381	.5716
4			.381	.381	.7621	.381	.5716
5			.381	.381		.381	.5716
6	.3772	.3772	.381	.7621	.7621	.381	.5716
7		.1905	.381	.7621	.7621	.381	.5716
8		.381	.7621		.7621	.381	.7621
9	.3772	1.1431	1.3336		1.1431	1.1431	1.1431
10		1.1431	1.1431		1.9052	1.1431	1.1431
11		1.448	1.1431		1.1431	1.1431	1.1431
12	.3772	1.1431	1.1431		1.1431	1.1431	1.1431
13		1.1431	1.1431	1.1431	1.1431	1.1431	1.1431
14		1.1431	1.1431		1.1431	1.1431	1.3336
15	.3772	1.1431	1.1431		1.1431	1.1431	1.3203
16		1.1431	1.1431	1.1431	1.1431	1.1431	
17		1.1431	1.1431		1.1431	.7621	
18	.3772	1.1431	.7621		.7621	.7621	
19		1.1431	.7621		.7621	.7621	
20		.7621	.7621		.7621	.7621	
21	.1886	.7621	.7621		.7621	.7621	
22		.7621	.7621		.381	.7621	
23	.1886	.381	.381	.381	.7621	.7621	
24	.3772	.1886	.381	.381	.381	.381	.5716
Max	.3772	1.448	1.3336	1.1431	1.9052	1.1431	1.3336
Min	.1886	.1886	.381	.381	.381	.381	.5716
Avg	.3353	.8436	.77	.5889	.9072	.7462	.8565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 305 / 22KV Repro Press

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
1		.3048
4		.3048
11	.1905	
Max	.1905	.3048
Min	.1905	.3048
Avg	.1905	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&T - II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381	.381		.381	.381
2			.381	.381	.381	.381	.381
3	.3772	.3772	.381	.381		.381	.381
4			.381	.1905	.1905	.381	.381
5			.381	.1905		.381	.381
6	.3772	.3772	.381	.1905	.1905	.381	.381
7		.381	.381	.1905	.1905	.381	.381
8		.381	.381		.381	.381	.381
9	.3772	.381	.381		.381	.381	.381
10		.381	.381		.381	.381	.381
11		.381	.381		.381	.381	.381
12	.3772	.381	.381		.381	.381	.381
13		.381	.381	.381	.381	.381	.381
14		.381	.381		.381	.381	.381
15	.3772	.381	.381		.381	.381	.3772
16		.381	.381	.381	.381	.381	
17		.381	.381		.381	.381	
18	.3772	.381	.381		.381	.381	
19		.381	.381		.381	.381	
20		.381	.381		.381	.381	
21	.3772	.381	.381		.381	.381	
22		.381	.381		.381	.381	
23	.3772	.381	.381	.381	.381	.381	
24	.3772	.3772	.381	.381	.381	.381	.381
Max	.3772	.381	.381	.381	.381	.381	.381
Min	.3772	.3772	.381	.1905	.1905	.381	.3772
Avg	.3772	.3804	.381	.3117	.3538	.381	.3808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.6673	2.2862		2.6673	2.2862
2			2.6673	2.2862	2.2862	2.6673	2.2862
3	3.0178	3.0178	2.6673	2.2862		2.6673	2.2862
4			2.6673	2.2862	2.2862	2.6673	2.2862
5			2.6673	2.2862			2.2862
6	2.6406	3.0178	2.6673	2.2862	2.2862	2.6673	2.2862
7		3.0483	2.6673	2.2862	2.2862	2.6673	2.2862
8		3.0483	2.6673		3.4294	2.6673	2.2862
9	3.0178	4.5725	4.1914		4.5725	4.1914	3.0483
10		6.0966	5.3346		6.0966	4.5725	4.9535
11		6.0966	6.0966		6.4777	6.0966	4.9535
12	3.0178	6.0966	6.0966		6.4777	6.0966	4.9535
13		6.0966	6.0966	6.0966	6.4777	5.7156	4.9535
14		6.0966	6.0966		6.4777	6.0966	5.3346
15	3.0178	6.0966	6.4777		6.4777	6.4777	5.2812
16		6.0966	6.0966		6.4777	6.0966	
17		6.0966	6.0966	6.0966	6.4777	6.0966	
18	3.0178	5.3346	4.5725		4.5725	5.3346	
19		3.8104	4.1914		4.1914	3.8104	
20		3.4294	3.8104		3.8104	3.0483	
21	2.6406	3.4294	3.0483		3.4294	3.0483	
22		3.4294	3.0483		3.4294	3.0483	
23	3.0178	3.0483	3.0483	3.0483	3.0483	2.6673	
24	3.3951	3.0178	2.6673	3.0483	3.0483	2.6673	2.6673
Max	3.3951	6.0966	6.4777	6.0966	6.4777	6.4777	5.3346
Min	2.6406	3.0178	2.6673	2.2862	2.2862	2.6673	2.2862
Avg	2.9759	4.5488	4.0962	3.1176	4.4818	4.0755	3.4022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 310 / Systime computers EL-207 NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1905	.1905		.1905	.1905
2			.1905	.1905	.1905	.1905	.1905
3	.1886	.1886	.1905	.1905		.1905	.1905
4			.1905	.1905	.1905	.1905	.1905
5			.1905	.1905		.1905	.1905
6	.1886	.1886	.1905	.1905	.1905	.1905	.1905
7		.1905	.1905	.1905	.1905	.1905	.1905
8		.1905	.1905		.1905	.1905	.1905
9	.1886	.1905	.1905		.1905	.1905	.1905
10		.1905	.1905		.1905	.1905	.1905
11		.1905	.1905		.1905	.1905	.1905
12	.1886	.1905	.1905		.1905	.1905	.1905
13		.1905	.1905	.1905	.1905	.1905	.1905
14		.1905	.1905		.1905	.1905	.1905
15	.1886	.1905	.1905		.1905	.1905	.1886
16		.1905	.1905	.1905	.1905	.1905	
17		.1905	.1905		.1905	.1905	
18	.1886	.1905	.1905		.1905	.1905	
19		.1905	.1905		.1905	.1905	
20		.1905	.1905		.1905	.1905	
21	.1886	.1905	.1905		.1905	.1905	
22		.1905	.1905		.1905	.1905	
23	.1886	.1905	.1905	.1905	.1905	.1905	
24	.1886	.1886	.1905	.1905	.1905	.1905	.1905
Max	.1886	.1905	.1905	.1905	.1905	.1905	.1905
Min	.1886	.1886	.1905	.1905	.1905	.1905	.1886
Avg	.1886	.1902	.1905	.1905	.1905	.1905	.1904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 203 / 11KV P/3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.7922	.7922	.7922	.8299	.811	.8299
2	.7733	.7545	.7545	.7545	.7733		.7922
3	.7167	.679	.7545	.7545		.7167	.7545
4	.6602	.6036	.679	.7545	.6602	.7167	.7545
5	.6413	.5658	.7545	.679	.6413	.7545	.7167
6	.6602	.5658	.7545	.7545	.7356	.811	.7545
7	.7167	.5847	.811	.8676	.8865	.8865	.8488
8	.7733	.6224	.6036	.6413	.679	.6602	.6036
9	.6224	.5281	.5847	.6036	.6224	.5847	
10	.6036	.5093	.547	.5658	.547	.5281	
11	.5847	.5093	.5093	.5281	.4904		
12	.6036	.4904	.4904	.5093	.5281	.5658	
13	.5847	.4715	.4715	.5281	.5281	.5281	
14	.5847	.5281	.5093	.5093	.5281	.5281	
15	.6036	.4904	.5281	.5658		.547	
16	.6413	.4904	.5093	.5093	.5658	.5281	
17	.5847		.5093		.5658	.5281	
18	.5847		.5093		.547	.5281	
19	.6602		.6413		.6413	.6224	
20	.7922		.7922		.7733	.7545	
21	.9997		1.0185		1.0185	1.0185	
22	.811		.8488		.8865	.7922	
23	.8865		.8865		.9242	.8299	
24	.8488	.8488	.8676	.8676	.8676	.8676	.8676
Max	.9997	.8488	1.0185	.8676	1.0185	1.0185	.8676
Min	.5847	.4715	.4715	.5093	.4904	.5281	.6036
Avg	.6979	.5903	.6720	.6579	.6927	.6867	.7691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9805	1.9239	2.037	2.2634	2.0559	2.1691	2.1879
2	1.905	1.4712	1.9616	2.0748	1.9805	2.0748	2.0748
3	1.8296	1.358	1.8673		1.9427	1.8107	2.0748
4	1.773	1.2826	1.7918	1.6975	1.8673	1.5466	1.8861
5	1.7164	1.2826	1.6975		1.8296	1.6032	1.5089
6	1.6409	1.3203	1.5844	1.5466	1.7918	1.6598	1.5089
7	1.5655	1.3392	1.7353	1.6598	1.773	1.7164	1.5466
8	1.5466	1.3769	1.6032	1.5655	1.5655	1.7353	1.5466
9	1.4523	1.3769	1.5844	1.5844	1.5466	1.6032	
10	1.4335	1.3014	1.4523	1.5089	1.5278	1.4335	
11	1.6032	1.3392	1.3769	1.4335	1.4146		
12	1.5089	1.226	1.358	1.4146	1.358	1.5844	
13	1.4146	1.226	1.3014	1.4335	1.3957	1.358	
14	1.4146	1.358	1.3769	1.4523	1.3957	1.4712	
15	1.5844	1.3203	1.4335	1.4712	1.3957	1.5089	
16	1.6221	1.4335	1.4146	1.4523	1.5089	1.4335	
17	1.4901		1.4146		1.5278	1.4335	
18	1.5278		1.4523		1.3769	1.3957	
19	1.6032		1.6598		1.5466	1.5844	
20	1.7164		1.6975		1.7353	1.6787	
21	1.7164		1.8107		1.8673	1.773	
22	1.9239		1.9427		1.9239	1.905	
23	2.1502		2.3765		2.2634	2.2634	
24	2.037	2.3011	2.1691	2.3765	2.1502	2.3954	2.3011
Max	2.1502	2.3011	2.3765	2.3765	2.2634	2.3954	2.3011
Min	1.4146	1.226	1.3014	1.4146	1.358	1.358	1.5089
Avg	1.6732	1.4257	1.6708	1.6623	1.6975	1.7016	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1499	3.1121	3.1876	3.2065	3.1499	3.1687	3.3951
2	3.0556	2.8669	3.131	3.2065	3.0744	3.0178	3.2065
3	2.9801	2.6406	3.0367	3.0178	2.999	2.6406	3.0178
4	2.8669	2.452	2.9801	2.8292	2.9424	2.4897	3.0178
5	2.7538	2.3577	2.9047	2.6406	2.8669	2.5463	2.452
6	2.6595	2.4143	2.8481	2.6783	2.7915	2.6783	2.4897
7	2.5652	2.5086	2.7726	2.8669	2.7349	2.8292	2.6406
8	2.6029	2.6595	2.6406	2.6029	2.452	2.6406	2.6029
9	2.4709	2.3954	2.5086	2.5274	2.4897	2.4897	
10	2.3954	2.2257	2.1691	2.3011	2.1313	2.1502	
11	2.2068	1.9616	2.0748	2.1125	2.0182		
12	2.1313	1.9805	1.9616	2.1502	1.9616	2.3388	
13	2.1125	1.8861	1.9239	2.0748	2.037	2.1125	
14	2.2068	2.0748	2.037	2.037	2.1125	2.1879	
15	2.3011	2.0559	2.0936	2.1502	2.1125	2.1125	
16	2.3388	2.0936	2.1502	2.2257	2.3011	2.1125	
17	2.3765		2.0936		2.1691	2.1502	
18	2.4143		2.1691		2.2257	2.1502	
19	2.6029		2.4897		2.4897	2.4709	
20	2.5463		2.6783		2.6217	2.6783	
21	2.8292		2.9235		2.9047	2.8104	
22	2.8858		3.0367		3.0933	2.9801	
23	3.2253		3.4139		3.5837	3.0178	
24	3.2253	3.4328	3.2819	3.3951	3.2253	3.5082	3.4705
Max	3.2253	3.4328	3.4139	3.3951	3.5837	3.5082	3.4705
Min	2.1125	1.8861	1.9239	2.037	1.9616	2.1125	2.452
Avg	2.6210	2.4187	2.6045	2.5896	2.6037	2.5775	2.9214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.358	1.4712	1.5089	1.5278	1.4335	1.5089
2	1.3392	1.2637	1.3957	1.3957	1.4335	1.3203	1.3203
3	1.3014	1.2071	1.3203	1.3957	1.3769	1.2071	1.1317
4	1.226	1.1317	1.2449	1.1317	1.3014	1.1317	1.1317
5	1.1506	1.0562	1.1694	.9808	1.2071	.9808	.9054
6	1.0374	.9997	1.094	.9808	1.1506	.9997	.9054
7	.9054	1.0562	1.0374	1.0562	1.094	1.0185	.9242
8	.8488	.9808	.9431	.9431	.9808	1.0185	.9242
9	.8865	.9619	.9997	.9431	1.0185	.9808	1.1317
10	.9997	1.0751	1.0374	1.1128	1.0185	.9997	
11	1.094	1.094	1.2071	1.1694	1.2637		
12	1.1317	1.1128	1.1128	1.1128	1.0562	1.3014	
13	1.0751	1.1128	.9997	1.1317	1.226	1.0562	
14	1.1128	1.1506	1.1317	1.1694		1.226	
15	1.1883	1.2449	1.2637	1.3014	1.2826	1.2449	
16	1.2637	1.2637	1.1694	1.2826	1.2826	1.2071	
17	1.1694		1.3014		1.2826	1.1694	
18	1.0562		1.1317		1.1883	1.1694	
19	1.1883		1.2826		1.3392	1.2449	
20	1.358		1.358		1.4523	1.3392	
21	1.3769		1.4335		1.4523	1.3957	
22	1.4901		1.4901		1.5466	1.4146	
23	1.5466		1.6975		1.6598	1.5089	
24	1.5278	1.6221	1.5278	1.5844	1.6032	1.6787	1.5844
Max	1.5466	1.6221	1.6975	1.5844	1.6598	1.6787	1.5844
Min	.8488	.9619	.9431	.9431	.9808	.9808	.9054
Avg	1.1961	1.1583	1.2425	1.1883	1.2932	1.2194	1.1468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4527	.4715	.4527	.4527	.5093	.4904
2	.415	.4338	.4338	.4527	.415	.4715	.4904
3	.415	.415	.415	.4527	.3772	.415	.4527
4	.3961	.3772	.415	.415	.3772	.3772	.3772
5	.3772	.3772	.3961	.3772	.3961	.3772	.3772
6	.3772	.3772	.3772	.3772	.4338	.415	.3772
7	.3961	.3961	.415	.4338	.4338	.4527	.415
8	.3961	.415	.4338	.4338	.3772	.415	.3961
9	.3772	.3772	.3961	.3772	.3961	.415	
10	.3772	.3206	.3018	.3395	.3206	.3395	
11	.3395	.3018	.3018	.3395	.3206		
12	.3018	.3018	.2829	.3206	.3206	.3584	
13	.3018	.3018	.3018	.3018	.3206	.3018	
14	.3395	.2829	.3206	.3018	.3584	.3206	
15	.3395	.2829	.3395	.3206	.3395	.3395	
16	.3584	.3018	.3395	.3584	.3395	.3206	
17	.3772		.3206		.3206	.3206	
18	.3584		.3395		.3395	.3206	
19	.4338		.3772		.3772	.3961	
20	.4527		.4527		.4338	.4338	
21	.4527		.4527		.4715	.4527	
22	.4715		.4904		.5281	.4904	
23	.5093		.547		.5281	.4904	
24	.4715	.4715	.5093	.4904	.4715	.5281	.5281
Max	.5093	.4715	.547	.4904	.5281	.5281	.5281
Min	.3018	.2829	.2829	.3018	.3206	.3018	.3772
Avg	.3945	.3639	.3930	.3850	.3937	.4027	.4338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5658	.5847	.7167	.6413	.7167	.6036
2	.4715	.547	.5658	.679	.5658	.6413	
3	.4527	.5281	.5281	.6036	.5658	.6036	.6036
4	.4527	.4904	.4904	.5658	.5281	.6036	.5658
5	.415	.4904	.4715	.5658	.4715	.6224	.4904
6	.4715	.4904	.547	.5658	.5281	.6602	.4904
7	.5093	.547	.6413	.6413	.6036	.7167	.5658
8	.5847	.6036	.6602	.7167	.7733	.7545	.6602
9	.547	.3772	.6224	.6413	.679	.6979	
10	.6036	.5281	.5281	.6224	.679	.6036	
11	.5658	.5281	.4527	.5281	.5658		
12	.6224	.4527	.4904	.4527	.547	.5281	
13	.6602	.4338	.5093	.4527	.4904		
14	.5658	.4527	.5093	.4527	.4715	.4904	
15	.7356	.4904	.5281	.4527	.547	.5658	
16	.6413	.415	.547	.5093	.5847	.415	
17	.6413		.4338		.5281	.3772	
18	.6036		.415		.4338	.3772	
19	.4527		.4338		.4527	.4904	
20	.6036		.5281		.6036	.547	
21	.6036		.679		.7167	.6413	
22	.6224		.7922		.7545	.6602	
23	.6413		.811		.811	.6602	
24	.5281	.5658	.6602	.7545	.6979	.7922	.679
Max	.7356	.6036	.811	.7545	.811	.7922	.679
Min	.415	.3772	.415	.4527	.4338	.3772	.4904
Avg	.5619	.5004	.5596	.5836	.5933	.5984	.5824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 211 / 11 KVMetro Bar Sectore -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4139	3.3951	3.6591	3.5837	3.7912	3.3951	3.3951
2	3.3196	3.0744	3.4705	3.3951	3.6591	3.0178	3.2065
3	3.1876	2.8292	3.3196	3.3951	3.5648	2.8292	3.0178
4	3.0367	2.6783	3.2253	3.2065	3.4705	2.6406	2.452
5	2.9047	2.5652	3.1121	3.0178	3.3762	2.4897	2.2634
6	2.7349	2.6029	2.999	3.131	3.263	2.6029	2.1879
7	2.584	2.7538	2.8481	3.3008	3.1876	2.7161	2.2257
8	2.7538	2.8669	2.7915	2.8669	2.9047	2.7161	2.5274
9	2.4709	2.7538	2.7538	2.8292	2.7349	2.4143	
10	2.8669	2.7538	2.9424	3.0556	2.9801	2.8292	
11	3.131	3.0556	3.2819	3.131	3.3008		
12	2.9801	2.8669	2.9047	2.9801	2.9613	2.4897	
13	2.8858	3.0178	3.0933	3.0178		2.8292	
14	3.0556	3.131	3.1121	3.0556		3.0178	
15	2.9801	3.0367	3.131	3.0178	3.2065	2.7915	
16	3.0933	2.8669	3.1499	3.2819	3.0556	2.7161	
17	3.0367		3.0556		2.8669	2.6406	
18	2.7538		2.9424		2.5652	4.4513	
19	3.2065		3.4705		2.7161	2.7915	
20	3.2819		3.6969		3.2065	2.9801	
21	3.2819		3.4705		3.2442	3.3573	
22	3.4894		3.6969		3.263	3.2065	
23	3.8855		4.0741		3.6214	3.4328	
24	3.6591	3.7346	3.7912	3.7534	3.9232	3.546	3.4894
Max	3.8855	3.7346	4.0741	3.7534	3.9232	4.4513	3.4894
Min	2.4709	2.5652	2.7538	2.8292	2.5652	2.4143	2.1879
Avg	3.0831	2.9402	3.2497	3.1776	3.2210	2.9522	2.7517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 212 / 11 KV KOPERKHIRANE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	1.1317	1.2826	1.2449	1.2071	1.2071	1.1317
2	1.1883	.9808	1.226	1.1317	1.1317	1.1317	1.1317
3	1.1694	.9431	1.1506	1.1317	1.0562	1.0562	1.1317
4	1.1317	.9431	1.1128	1.0562	1.0374	1.0185	1.0562
5	1.1128	.9431	1.0374	.9808	.9808	1.0751	1.0185
6	1.0751	.9808	1.1128	.9808	1.0751	1.1883	1.0185
7	1.094	1.0374	1.2071	1.046	1.1317	1.1506	1.094
8	.9808	1.094	1.1128	1.0562	1.094	1.1317	1.0562
9	.9242	.9242	.9808	.9619	.9997	1.0185	
10	.9619	.8676	.811	.8488	.8676	.8488	
11	.6036	.7733	.7922	.811	.8299		
12	.9054	.7922	.7733	.8299	.811	.8676	
13	.9054	.7922	.7733	.7922	.811	.8299	
14	.9808	.7922	.7922	.8299	.8865	.9054	
15	.9431	.7922	.8299	.7922	.811	.8676	
16	.9242	.7733	.811	.8299	.6036	.8676	
17	.8676		.811		.8676	.8676	
18	.9619		.8488		.9242	.8488	
19	1.094		1.0751		1.0374	.9997	
20	1.1128		1.1317		1.1506	1.1317	
21	1.1694		1.1694		1.2449	1.1317	
22	1.1506		1.1883		.8488	1.2071	
23	1.2826		1.3014		1.3203	1.2071	
24	1.2637	1.3392	1.358	1.3014	1.2637	1.2826	1.2449
Max	1.2826	1.3392	1.358	1.3014	1.3203	1.2826	1.2449
Min	.6036	.7733	.7733	.7922	.6036	.8299	1.0185
Avg	1.0429	.9353	1.0287	.9780	.9997	1.0366	1.0982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 213 / 11KV AVENUE SUPERMART

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8488	.9808	.9431	.9431	.9242	.9431
2	.7922	.7356	.9431	.9431	.8676	.8676	.9431
3	.7545	.6413	.9054	.8676	.8299	.8299	.8676
4	.7356	.6413	.8676	.7545	.7922	.7922	.7545
5	.6979	.6413	.811	.7545	.7545	.7922	.7167
6	.6602	.679	.7733	.7545	.7733	.8299	.7167
7	.6413	.7167	.7167	.811	.811	.8676	.7922
8	.7356	.7545	.7167	.8299	.7545	.8488	.7545
9	.7167	.9242	.9242	.9242	.9808	.8865	
10	.7733	.9808	.9619	.9431	1.0751	.9431	
11	.9054	.9808	.9997	1.0374	1.0751		
12	.9808	1.0374	1.0374	1.0751	1.0751	1.094	
13	.9808	1.0185	1.0185	.9619	1.0374	1.0751	
14	.9808	.9808	1.0374	1.0751	1.0562	1.0751	
15	1.0185	1.0185	1.0751	1.094	1.0751	1.0562	
16	.9997	.9619	1.0374	1.0562		1.0185	
17	.9431		1.0374		1.0374	1.0185	
18	.9808		1.0185		.9997	1.0185	
19	1.0562		1.094		1.0562	1.094	
20	1.1317		1.2071		1.1883	1.1883	
21	1.1883		1.2449		1.226	1.2449	
22	1.1506		1.1317			1.1317	
23	.9619		1.0374		1.0751	1.0562	
24	.8865	.9242	.9997	1.0185	.9808	.9808	.9808
Max	1.1883	1.0374	1.2449	1.094	1.226	1.2449	.9808
Min	.6413	.6413	.7167	.7545	.7545	.7922	.7167
Avg	.8959	.8521	.9824	.9320	.9757	.9841	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 214 / 11 KV JIMMY TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7164	1.5089	1.6598	1.6975	1.7164	2.0559	2.0748
2	1.6598	1.4335	1.5278	1.6975	1.6598	1.8861	1.8861
3	1.6032	1.3203	1.4523	1.5089	1.6032	1.8107	1.8861
4	1.5278	1.2071	1.4146	1.5089	1.5278	1.7353	1.8861
5	1.5089	1.2449	1.4901	1.2689	1.5089	1.9239	1.6975
6	1.6032	1.358	1.7164	1.3957	1.7164	2.0748	1.7353
7	1.6975	1.5089	1.8861	1.9993	1.9239	2.3011	2.2257
8	1.7164	1.3957	1.4523	1.4335	1.4712	1.8296	1.6975
9	1.4146	1.3014	1.3203	1.3203	1.3392	1.6975	
10	1.3957	1.3014	1.2071	1.2637	1.2826	1.6221	
11	1.2826	1.1883	1.1883	1.2071	1.2071	1.6975	
12	1.2826	1.1128	1.1317	1.1883	1.1694	1.6975	
13	1.2826	1.094	1.1128	1.1883	1.1694	1.5278	
14	1.2449	1.094	1.1317	1.1883	1.5278	1.6975	
15	1.2826	1.094	1.1506	1.1694	1.6221	1.3769	
16	1.1694	1.1317	1.1317	1.1694	1.5278	1.3957	
17	1.2071		1.1694		1.6409	1.3957	
18	1.3014		1.226		1.6975	1.6032	
19	1.5089		1.4335		1.8861	1.8861	
20	1.6221		1.7353		2.2068	2.1125	
21	2.4143		2.452		2.8292	2.4143	
22	1.773		1.8673			2.2634	
23	1.7918		1.8861		2.4331	2.2634	
24	1.773	1.7164	1.7353	1.5947	1.7918	2.2634	2.2445
Max	2.4143	1.7164	2.452	1.9993	2.8292	2.4143	2.2445
Min	1.1694	1.094	1.1128	1.1694	1.1694	1.3769	1.6975
Avg	1.5325	1.2948	1.4783	1.4000	1.6721	1.8555	1.9260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1905	.3429	.3429		.2667	.3048
2	.3429	.1905	.3429	.3429	.1905	.2667	.3048
3	.3429	.1905	.3429	.2286	.1905	.2286	.3048
4	.3429	.1905	.3429	.2667	.1905	.2286	.3048
5	.2667	.1905	.3429	.2667	.1905	.2286	.3048
6	.2667	.1905	.3048	.2286	.1905	.2286	.3048
7	.2667	.1905	.3048	.2286	.1905	.2286	.3048
8	.2286	.1905	.3048	.2286	.1905	.2286	.2667
9	.2286	.1905	.3429	.2667	.1905	.2286	.3048
10	.2286	.3048	.381	.1905	.2667	.2286	
11	.2286	.4191	.381	.1905	.3429	.2286	
12	.2286	.4572	.4191	.1905	.3429	.2286	
13	.2286	.3429	.381	.1905	.381	.1905	
14	.2286	.3429	.381	.1905	.3048	.1905	
15	.2286	.3429	.381	.1905	.3048	.2286	
16		.381	.381	.1905	.2286	.1905	
17	.2286	.381	.3048	.1905	.2286	.1905	
18	.2286	.2286	.2286	.1905	.2286	.1905	
19	.2286	.1905	.2286	.1905	.2286	.1905	
20	.1905	.1905	.2286	.1905	.2286	.1905	
21	.1905	.1905	.3429	.1905	.2286	.1905	
22	.1905	.3048	.3429	.1905	.2286	.2667	
23	.1905	.3048	.3048	.1905	.2286	.2667	
24	.3048	.1905	.3429	.3429	.1905	.2667	.3048
Max	.3429	.4572	.4191	.3429	.381	.2667	.3048
Min	.1905	.1905	.2286	.1905	.1905	.1905	.2667
Avg	.2501	.2619	.3334	.2254	.2385	.2238	.3010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.3336	1.9052	1.9052	1.5242		1.7147
2	1.7909	1.3336	1.9052	1.9052	1.5242	1.7147	2.0957
3	1.7909	1.3336	1.9052	1.9052	1.5242	1.9052	1.7147
4	1.7147	1.3336	1.9052	1.9052	1.5242	1.9052	1.7147
5	1.448	1.3336	1.6766	1.9052	1.3336	1.9052	1.7147
6	1.448	1.3336	1.6766	2.0957	1.3336	2.2862	1.6004
7	1.4098	1.5242	2.0957	2.0957	1.3336	2.2862	1.6385
8	1.3336	1.5242	2.21	2.0957	1.3336	2.4768	1.7147
9	1.2574	1.5242	2.4006	2.6673	1.9052	2.4768	1.8671
10	1.5242	2.5149	2.4768	2.2862	2.6673	2.4006	
11	1.5242	2.5149	2.4768	2.2862	2.6673	2.4006	
12	1.5242	2.4768	2.4768	2.2862	2.6673	2.5911	
13	1.5242	2.3624	2.4768	2.2862	2.6673	2.3624	
14	1.5242	2.4768	2.6673	2.2862	2.6673	2.4768	
15	1.5242	2.6673	2.6673	2.2862	2.8578	2.553	
16	1.3336	2.4768	2.6673	2.2862	2.6673	2.4768	
17	1.3336	2.2862	2.4768	2.2862	2.6673	2.4768	
18	1.3336	2.5911	2.4768	2.2862	2.4768	2.1719	
19	1.3336	2.1719	2.4768	1.9052	2.2862	2.1719	
20	1.3336	1.9433	1.9052	1.9052	2.0957	1.7147	
21	1.3336	2.0957	1.7147	1.9052	2.0957	1.6766	
22	1.3336	2.0957	1.5242	1.9052	2.0957	1.6766	
23	1.3336	2.1338	1.7147	1.9052	1.7147	1.6385	
24	1.7147	1.3336	1.7147	1.9052	1.9052	1.7147	1.7147
Max	1.7909	2.6673	2.6673	2.6673	2.8578	2.5911	2.0957
Min	1.2574	1.3336	1.5242	1.9052	1.3336	1.6385	1.6004
Avg	1.4797	1.9465	2.1497	2.1036	2.0640	2.1504	1.7490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1914	4.1914	4.382	4.5725	3.8104	4.1914	4.3439
2	4.1914	3.8104	4.382	4.1914	3.8104	4.1914	4.3439
3	4.1914	3.8104	4.382	4.1914	3.8104	3.8104	4.3439
4	4.1914	3.8104	4.382	4.1914	3.4294	3.4294	4.3439
5	4.1914	3.8104	4.382	4.5725	3.4294	3.4294	3.8104
6	3.8104	3.8104	4.0009	4.1914	3.4294	3.8104	3.7342
7	3.4294	3.8104	3.9628	4.1914	3.4294	3.8104	3.7342
8	3.7342	4.1914	4.4963	4.1914	4.1914	3.8104	4.1914
9	4.0009	4.1914	4.9535	4.1914	4.1914	3.8104	4.3439
10	3.8104	5.0297	4.9535	4.1914	4.9535	3.9628	
11	3.8104	5.0297	5.3346	4.1914	4.5725	4.1152	
12	4.1914	5.144	5.3346	4.5725	4.5725	4.1914	
13	4.1914	4.5725	4.5725	4.5725	4.1914	3.8866	
14	4.1914	5.0297	4.5725	4.5725	4.5725	3.9628	
15	4.1914	5.0297	4.1914	4.9535	4.5725	4.039	
16	4.1914	4.9535	4.1914	4.9535	4.5725	4.1914	
17	4.1914	4.9535	4.5725	4.9535	4.1914	4.4201	
18	4.1914	4.5725	4.5725	4.9535	3.8104	4.382	
19	4.1914	4.382	4.9535	3.8104	3.8104	4.2676	
20	4.1914	4.5725		3.8104	3.8104	4.4963	
21	4.1914	4.5725	4.5725	3.8104		4.382	
22	4.1914	4.5725	4.5725	3.8104	4.1914	4.382	
23	4.1914	4.5725	4.5725	3.8104	4.1914	4.1914	
24	4.1914	4.1914	4.382	4.5725	3.8104	4.1914	4.3439
Max	4.1914	5.144	5.3346	4.9535	4.9535	4.4963	4.3439
Min	3.4294	3.8104	3.9628	3.8104	3.4294	3.4294	3.7342
Avg	4.0850	4.4423	4.5510	4.3343	4.0589	4.0565	4.1534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.9052	2.2862	2.2862	1.9052	2.2862	2.0576
2	2.2862	1.9052	2.2862	2.2862	1.9052	2.2862	2.0576
3	2.2862	1.9052	2.2862	1.9052	1.9052	1.9052	2.0576
4	2.2862	1.9052	2.2862	1.9052	1.9052	1.9052	2.0576
5	2.2862	1.9052	2.2862	2.2862	1.9052	1.9052	2.0576
6	2.2862	1.9052	2.2862	2.2862	1.9052	1.9052	2.1338
7	2.2862	2.2862	2.2862	2.4768	1.9052	1.9052	2.1338
8	2.2862	2.2862	2.6673	2.6673	2.2862	1.9052	2.8578
9	3.1245	2.2862	3.4294	3.4294	3.0483	2.2862	3.0483
10	3.4294	4.1152	3.8104	3.4294	4.5725	2.5911	
11	3.4294	4.382	4.9535	3.4294	4.5725	2.7435	
12	4.1914	4.763	4.5725	3.8104	4.9535	2.8959	
13	4.1914	4.1914	4.5725	3.8104	3.8104	2.7435	
14	4.1914	4.039	4.5725	3.8104	4.5725	2.7816	
15	4.1914	4.763	4.5725	3.8104	4.9535	2.8578	
16	3.8104	4.5725	4.5725	4.1914	3.8104	2.6673	
17	3.8104	4.382	3.8104	4.1914	3.0483	2.5911	
18	3.8104	3.6199	3.0483	4.1914	3.0483	2.3624	
19	3.4294	3.2388	3.0483	3.8104	3.0483	2.2862	
20	3.0483	2.8197	2.6673	3.4294	3.0483	2.21	
21	2.2862	2.5911	2.6673	3.0483	3.0483	2.1338	
22	2.2862	2.3624	2.2862	2.6673	2.2862	2.0576	
23	1.9052	2.2862	2.2862	2.2862	2.6673	2.0576	
24	2.2862	1.9052	2.2862	2.2862	2.2862	2.2862	2.0576
Max	4.1914	4.763	4.9535	4.1914	4.9535	2.8959	3.0483
Min	1.9052	1.9052	2.2862	1.9052	1.9052	1.9052	2.0576
Avg	2.9880	3.0134	3.1594	3.0721	3.0166	2.3148	2.2519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6673	2.4768	2.6673	2.4768	2.4768	2.4768	2.6673
2	2.6673	2.4768	2.6673	2.4768	2.4768	2.4768	2.6673
3	2.6673	2.4768	2.6673	2.2862	2.4768	2.4768	2.6673
4	2.6673	2.4768	2.6673	2.2862	2.4768	2.2862	2.6673
5	2.6673	2.4768	2.6673	2.2862	2.4768	2.2862	2.6673
6	2.4768	2.4768	2.5911	2.4768	2.4768	2.2862	2.7435
7	2.4387	2.4768	2.5911	2.4768	2.4768	2.2862	2.4768
8	2.4768	2.4768	2.5911	2.4768	2.4768	2.2862	2.5149
9	2.4768	2.4768	2.8578	2.6673	2.6673	2.8578	2.553
10	2.4768	2.7816	2.8578	2.6673	2.6673	2.7435	
11	2.4768	2.8197	2.8578	2.6673	2.6673	2.6673	
12	2.4768	2.6673	2.6673	2.6673	2.4768	2.4768	
13	2.4768	2.5149	2.6673	2.6673	2.4768	2.5911	
14	2.6673	2.7435	2.6673	2.2862	2.4768	2.553	
15	2.6673	2.7435	2.6673	2.2862	2.6673	2.553	
16	2.6673	2.6673	2.6673	2.2862	2.6673	2.4768	
17	2.6673	2.6673	2.6673	2.2862	2.4768	2.4006	
18	2.6673	2.6673	2.6673	2.4768	2.4768	2.3624	
19	2.6673	2.7816	2.6673	2.4768	2.4768	2.4768	
20	2.6673	2.7054	2.4768	2.4768	2.4768	2.4387	
21	2.6673	2.5911	2.4768	2.4768	2.4768	2.4768	
22	2.6673	2.5911	2.4768	2.4768	2.4768	2.4768	
23	2.6673	2.553	2.4768	2.4768	2.4768	2.3624	
24	2.4768	2.6673	2.5911	2.4768	2.4768	2.4768	2.553
Max	2.6673	2.8197	2.8578	2.6673	2.6673	2.8578	2.7435
Min	2.4387	2.4768	2.4768	2.2862	2.4768	2.2862	2.4768
Avg	2.5943	2.6022	2.6467	2.4609	2.5165	2.4688	2.6178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 201 / 11 KV PATEL HEIGHT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8255	3.5113	3.5848	3.9918	3.8089	3.6595	3.7885
2	3.6961	3.3634	3.3608	3.6961	3.5475	3.3608	3.4004
3	3.5298	3.1602	3.0807	3.5298	3.2674	3.1367	3.1417
4	3.1786	2.7721	2.8006	3.1417	2.9874	2.9938	3.0678
5	2.8645	2.5503	2.6513	2.8275	2.7633	2.9014	2.9384
6	2.4949	2.4025	2.5766	2.5688	2.6139	2.7721	2.7905
7	2.3101	2.4949	2.5019	2.5873	2.5206	2.6797	2.5318
8	2.1992	2.5873	2.6139	2.5503	2.6139	2.6139	2.6057
9	2.2916	2.7351	2.5393	2.6427	2.6886	2.7633	2.5503
10	2.6057	2.8645	2.726	2.7536	2.8567	2.8753	2.7905
11	2.8829	2.7633	2.8567	3.0247	2.9874	2.4832	3.062
12	2.7536	2.838	2.8006	2.7633	2.9313	2.9569	2.7633
13	2.8193	2.7446	2.5953	2.8567	2.838	2.6981	3.006
14	2.8275	2.7073	2.8006	2.8567	2.9874	2.8829	3.1181
15	3.0862	2.6139	2.6886	2.8006	2.9874	2.9938	3.5288
16	3.0493	2.5766	2.8753	2.8006	2.9874	2.9569	3.3608
17	2.846	2.6981	2.7633	2.8567	2.838	2.9014	3.1927
18	2.8645	2.846	2.6513	2.7446	2.9874	2.7536	3.3234
19	3.1047	2.9569	3.0807	3.062	3.3048	3.2114	3.4541
20	3.308	3.271	3.345	3.4355	3.5101	3.4004	3.3234
21	3.5298	3.4189	3.5113	3.6595	3.6969	3.6961	3.4374
22	3.8255	3.733	3.8994	3.8439	4.0329	3.8809	3.7885
23	4.1951	4.232	4.3244	4.3983	4.481	4.0287	4.3059
24	3.9179	4.1766	4.1076	4.1581	4.2196	4.481	4.2875
Max	4.1951	4.232	4.3244	4.3983	4.481	4.481	4.3059
Min	2.1992	2.4025	2.5019	2.5503	2.5206	2.4832	2.5318
Avg	3.0836	3.0007	3.0307	3.1480	3.1857	3.1284	3.2316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2114	2.9313	3.0994	3.1971	3.1741	3.1554	3.3608
2	2.9874	2.8006	2.95	3.0493	3.0807	2.8753	3.1367
3	2.8349	2.6699	2.8006	2.846	2.838	2.6139	2.838
4	2.7446	2.5579	2.6886	2.5688	2.6139		2.6699
5	2.5206	2.4646	2.6139	2.4764	2.5206		2.5019
6	2.4272	2.3525	2.5206	2.4025	2.4272	2.0538	2.4272
7	2.3339	2.2405	2.4272	2.5318	2.5766	1.9791	2.5206
8	2.3712	2.3525	2.5953	2.5688	2.726	2.0538	2.4832
9	2.5019		2.5019	2.5133	2.5019	2.1472	2.5019
10	2.7446	2.5766	2.4646	2.5503	2.5393	2.2405	2.6326
11	2.6699	2.4086	2.4646	2.6326	2.5953	2.1658	2.7073
12	2.6699	2.3339	2.3899	2.4832	2.5019	2.1472	2.6886
13	2.6513	2.3152	2.3525	2.4272	2.5393	1.9978	2.6513
14	2.4459	2.2032	2.2592	2.4086	2.4272	2.4832	2.6513
15	2.7073	2.3152	2.2592	2.2405	2.4272	2.4272	2.8006
16	2.5766	2.4272	2.3525	2.2779	2.4459	2.3899	2.7633
17	2.4459	2.5766	2.384	2.3339	2.5393	2.2592	2.7073
18	2.4646	2.726	2.2731	2.3899	2.6513	2.4086	2.8753
19	3.0247	2.8753	2.9199	2.894	3.062	2.8567	3.2114
20	3.1741	3.1181	3.2156	3.2487	3.3234	3.2487	3.308
21	3.3048	3.2895	3.4743	3.3981	3.4728	3.3421	3.345
22	3.2861	3.345	3.5298	3.5475	3.6408	3.3794	3.3265
23	3.3421	3.3819	3.5113	3.6222	3.6782	3.4541	3.5482
24	3.3421	3.4355	3.3981	3.4743	3.6035	3.4915	3.6222
Max	3.3421	3.4355	3.5298	3.6222	3.6782	3.4915	3.6222
Min	2.3339	2.2032	2.2592	2.2405	2.4272	1.9791	2.4272
Avg	2.7826	2.6825	2.7269	2.7535	2.8294	2.5987	2.8866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV Severage Pump

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.7468	.7545	.7655	.811	.8865	.6908
2	.5041	.6348	.6602	.7095	.7545	.7922	.6161
3	.4668	.5228	.6036	.6348	.7167	.7167	.5415
4	.4294	.4481	.5281	.5228	.6413	.6413	.5228
5	.4294	.4294	.4527	.4668	.5658	.5658	.4854
6	.3734	.3734	.4904	.4108	.5281	.5281	.4294
7	.3921	.4108	.5281	.4294	.4904	.4904	.4668
8	.3921	.4481	.5847	.4481	.5281	.5658	.4668
9	.5228	.4854	.6036	.5788	.5093	.6413	.5228
10	.6535	.5281	.6413	.5228	.679	.6413	.6908
11	.5975	.5847	.6602	.4338	.6036	.5847	.7922
12	.7095	.3584	.5093	.4338	.5093	.547	.6979
13	.5228	.6224	.4527	.5093	.5281	.6036	.6224
14	.5975	.5281	.0566	.5281	.4904	.4904	.5281
15		.5281	.3584	.4904	.5487	.5093	.6979
16	.5601	.5281	.4715	.4527	.6413	.6908	.6584
17	.4854	.5658	.547	.4715	.6602	.5601	.6413
18	.3734	.6036	.4338	.6036	.7167	.6161	.6413
19	.5601	.679	.5093	.0943	.7545	.5228	.6413
20	.5788	.4338	.5658	.679	.7167	.6348	.679
21	.5788	.7545	.4854	.7922	.6602	.6535	.5281
22	.8029	.6413	.6722	.6413	.8299	.6722	.6979
23	.7282	.7545	.6722	.7733	.7545	.7282	.8865
24	.6722	.8402	.8488	.8402	.7545	.7545	.8215
Max	.8029	.8402	.8488	.8402	.8299	.8865	.8865
Min	.3734	.3584	.0566	.0943	.4904	.4904	.4294
Avg	.5431	.5604	.5454	.5514	.6414	.6266	.6236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.1132	.0943	.1132	.1132	.0943
2	.0934	.0943	.0943	.0754	.0943	.1132	.0754
3	.0747	.0943	.0943	.0754	.0943	.0943	.0754
4	.0747	.0754	.0754	.0754	.0754	.0943	.0754
5	.0747	.0754	.0754	.0566	.0754	.0943	.0754
6	.0747	.0754	.0754	.0754	.0754	.0754	.0754
7	.0943	.0566	.0754	.0754	.0754	.0754	.0754
8	.0943	.0566	.0754	.1132	.0754	.0754	.0754
9	.0754	.0754	.0943	.0943	.0943	.0943	.0943
10	.0754	.0943	.0754	.0943	.0754	.0943	.0943
11	.0943	.0566	.0566	.0754	.0754	.0943	.0943
12	.0754	.0566	.0754	.0566	.0566	.0943	.1132
13	.0754	.0566	.0754	.0754	.0943	.0943	.0943
14	.0754	.0754	.0754	.0943	.0566	.0943	.0566
15	.0754	.0754	.0943	.0754	.0754	.0943	.0943
16	.0754	.0754	.0754	.0754	.0754	.0943	.0754
17	.0754	.0754		.0566	.0754	.1132	.0754
18	.0754	.0943		.0566	.0943	.0943	.0943
19	.1132	.0943		.0943	.1132	.1132	.1132
20	.1132	.0754	.1132	.1132	.1132	.1132	.1132
21	.1132	.0943	.1132	.0943	.0943	.0943	.0943
22	.1132	.0943	.0943	.0943	.1132	.1132	.1132
23	.1132	.1132	.0943	.0943	.1509	.0943	.1132
24	.1132	.112	.1132	.1132	.1132	.1132	.0943
Max	.1132	.1132	.1132	.1132	.1509	.1132	.1132
Min	.0747	.0566	.0566	.0566	.0566	.0754	.0566
Avg	.0886	.0817	.0871	.0833	.0896	.0975	.0896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.112	.1132	.0934	.1509	.132	.1307
2	.0943	.112	.1132	.1307	.1132	.1132	.112
3	.0754	.112	.0754	.0747	.0754	.1132	.0934
4	.0754	.0934	.0754	.0747	.0754	.112	.0747
5	.0566	.0747	.0754	.0934	.0754	.1109	.0747
6	.0943	.0747	.1132	.1494	.1509	.1478	.1494
7	.1509	.1494	.1886	.168	.1886	.1848	.168
8	.2075	.1867	.1886	.1867	.2075	.2054	.2054
9	.2263	.2218	.2263	.2241	.2263	.2263	.1867
10	.2263	.2218	.2263	.2241	.2263	.2452	.2241
11	.2614	.2402	.1132	.2241	.2263	.2641	.2241
12	.0934	.2402	.0943	.1886	.2263	.2427	.2241
13	.112	.1109	.0754	.1886	.2263	.2452	.2614
14	.0934	.2402	.0754	.1886	.2452	.0943	.2614
15	.2427	.2218	.0754	.1886	.2452	.132	.2614
16	.2987	.2241	.0943	.2263	.2641	.2452	.2427
17	.2801	.2241	.2452	.2263	.1132	.1132	.2427
18	.2801	.2427	.2263	.2075	.2263	.2263	.2241
19	.2801	.2641	.2075	.2263	.2829	.0943	.2241
20	.112	.2641	.2263	.2263	.2829	.0943	.2427
21	.2614	.2641	.2263	.2452	.2641	.1132	.1886
22	.1307	.2829	.2452	.2452	.2641	.132	.2263
23	.2987	.3018	.2614	.2452	.1509	.1509	.2829
24	.132	.2054	.1132	.1307	.2641	.1509	.2829
Max	.2987	.3018	.2614	.2452	.2829	.2641	.2829
Min	.0566	.0747	.0754	.0747	.0754	.0943	.0747
Avg	.1757	.1952	.1531	.1824	.1988	.1621	.2004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0953	.0953	.1143	.0943
2	.0762	.0762	.0762	.0762	.0762	.1143	.0754
3	.0572	.0762	.0572	.0572	.0762	.0762	.0754
4	.0572	.0572	.0572	.0572	.0572	.0762	.0566
5	.0381	.0572	.0572	.0572	.0572	.0762	.0566
6	.0381	.0572	.0572	.0572	.0572	.0572	.0566
7	.0381	.0572	.0762	.0572	.0762	.0572	.0566
8	.0381	.0762	.0762	.0572	.0762	.0572	.0566
9	.0572	.0762	.1143	.0762	.0762	.0572	.0566
10	.0953	.0762	.0762	.0572	.0953	.0572	.0754
11	.0572	.0762	.0953	.0572	.0953	.0572	.0754
12	.0572	.0572	.0953	.0572	.0762	.0754	.0754
13	.0572	.0572		.0572	.0572	.0377	.0566
14	.0572		.0572	.0572		.0377	.0754
15	.0572		.0381	.0572	.0572	.0377	.0754
16	.0762		.0381	.0572	.0572	.0377	.0566
17	.0762	.0572	.0381	.0572	.0572	.0381	.0566
18	.0953	.0572	.0381	.0572	.0572	.0572	.0572
19	.0762	.0762	.0762	.0953	.0762	.6287	.0572
20	.0572	.0572	.0566	.0762	.0762	.0762	.0572
21	.0572	.0762	.0566	.0762	.0572	.0762	.0572
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.0762	.0953	.0943	.0953	.0953	.0953	.0953
24	.0762	.1143	.0953	.1132	.0953	.0953	.0943
Max	.0953	.1143	.1143	.1132	.0953	.6287	.0953
Min	.0381	.0572	.0381	.0572	.0572	.0377	.0566
Avg	.0635	.0708	.0687	.0683	.0729	.0904	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 301 / 22KV Mahape MIDC (O/G-I) SHEDDABLE FEEDER HAVING WEEKLY
 Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5451	1.3717		1.4712	
2			1.4697	1.5242		1.3957	
3			1.432	1.3717		1.3203	
4			1.432	1.5242		1.2449	1.2193
5			1.3943	1.5242		1.2071	
6		1.1431	1.319	1.2955		1.1317	
7		1.1431	1.319	1.2955		1.094	1.1431
8	1.5242		1.5451	1.6004	1.6004	1.2826	1.1431
9	1.7147	1.9433	2.2611	2.1338	1.9052	1.5089	1.7909
10		2.5149	2.4006		2.2611		2.3624
11		2.7915	2.6292		2.6003		
12		2.7538	2.7054		2.452		2.4387
13		2.4797	2.3624		2.4897		2.21
14		2.6702			2.6029		2.4006
15		2.8206			2.8292	1.829	
16		2.6326			2.9047		
17		2.5574	2.3624				2.3243
18		2.2212	2.553		2.3765		1.9052
19		1.6188	1.9052	2.0195	1.9993		1.6004
20		1.5812	1.7147		1.7353		1.4098
21		1.5812	1.4098		1.4335		
22		1.7712			1.4712		1.2955
23		1.6204	1.4098	1.6004	1.5089		1.1812
24	1.4098	1.2193	1.5828	1.6766	1.6766	1.5089	1.2193
Max	1.7147	2.8206	2.7054	2.1338	2.9047	1.829	2.4387
Min	1.4098	1.1431	1.319	1.2955	1.4335	1.094	1.1431
Avg	1.5496	2.0591	1.8376	1.5781	2.1154	1.3631	1.7096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV LnT Mahape Swt stn

Feeder No / Name : 302 / 22KV Mahape MIDC (O/G-II) SHEDDABLE FEEDER HAVING WEEKLY
New Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	13-APR-18
HR	Load (MW)
20	1.105
Max	1.105
Min	1.105
Avg	1.105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 303 / 22KV Shil

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6824	.6859		.5687	
2			.6445	.6097		.5687	
3			.6445	.6097		.5687	
4			.6445	.6478		.5308	.6478
5			.6066	.6859		.5308	
6		.6097	.6066	.6097		.5308	
7		.4572	.6066	2.8959		.5308	.5716
8	.6097		.5687	.5716	.5716	.5308	.4954
9	.6097	.6478	.7204	.6859	.5335	.5687	.9908
10		.8002	.7621		.6818		.6478
11		.8711	.8764		.7575		
12		.909	.8383		.6824		.724
13		.9081	.7621		.7204		.6478
14		.8324			.7583		.6097
15		.8324			.7962	.724	
16		.8324			.7962		
17		.8324	.8383		.7204		.6478
18		.7567	.7621		.6445		.5716
19		.8324	.7621	.4954	.6445		.6097
20		.7567	.724		.5687	.5716	.5716
21		.7189	.6859		.5687		
22		.7189			.5687		.6097
23		.7189	.7621	.5335	.6066		.5716
24	.6097	.6097	.6811	.724	.5335	.5687	.6097
Max	.6097	.909	.8764	2.8959	.7962	.724	.9908
Min	.6097	.4572	.5687	.4954	.5335	.5308	.4954
Avg	.6097	.7581	.7090	.8129	.6561	.5661	.6351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 304 / 22 Kv Ekvira

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.0803	3.2007		2.9721	
2			3.0042	3.0102		2.934	
3			2.9662	2.8197		2.8578	
4			2.8521	2.9721		2.8578	2.3624
5			2.8521	2.6673		2.6673	
6		2.4387	2.8056	2.7435		2.553	
7		2.7435	2.8056	2.8959		2.4387	2.5911
8	3.1626		3.2704	3.315	3.315	2.6673	2.9721
9	4.1533	5.0297	5.4489	5.5251	.5335	4.2676	2.7816
10		6.6301	6.4777		6.1728		5.9061
11		6.4396	6.4777		6.7825		
12		6.7444	6.592		6.5539		6.4396
13		5.514	5.0297		4.9916		5.1821
14		6.5028			6.4015		6.5158
15		6.592			6.7063	4.9154	
16		6.4267			6.8206		
17		6.2366	6.4015		6.592		5.9061
18			5.3727		5.487		5.1059
19		4.2591	3.8485	4.2676	3.9628		3.9628
20		3.6507	3.4294		3.4294	3.0102	3.6961
21		3.2324	2.9721		3.1245		
22		3.0422			3.1245		3.2007
23		2.9662	3.2007		2.9721		3.1245
24	3.0483	2.4768	3.1563	3.2388	3.2388	3.0864	2.4768
Max	4.1533	6.7444	6.592	5.5251	6.8206	4.9154	6.5158
Min	3.0483	2.4387	2.8056	2.6673	.5335	2.4387	2.3624
Avg	3.4547	4.7603	4.1022	3.3324	4.7182	3.1023	4.1482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0556	3.0493	3.0123	3.1093	3.1876	3.1093	3.2819
2	2.8481	2.8275	2.7721	2.9995	2.9613	2.9447	3.0933
3	2.6972	2.6797	2.6242	2.7435	2.7915	2.7069	2.8669
4	2.6029	2.5873	2.5133	2.652	2.6783	2.6337	2.7538
5	2.5086	2.4949	2.4394	2.5423	2.584	2.524	2.6029
6	2.6217	2.5873	2.5688	2.5606	2.7161	2.5606	2.7726
7	3.3951	3.4928	3.5298	3.4751	3.6214	3.4751	3.6025
8	3.131	2.7166	2.809	2.7435	2.8104	2.7069	2.6595
9	2.6029	2.6057	2.6797	2.7069	2.7538	2.6703	2.5652
10	2.5463	2.4764	2.5688	2.6155	2.6595	2.524	2.5463
11	2.5652	2.4025	2.396	2.5652	2.5057	2.584	2.0513
12	2.4764	2.3101	2.3228	2.5274	2.524	2.4709	2.3655
13	2.3285	2.2731	2.3045	2.4897	2.4508	2.5463	2.3285
14	2.384	2.3655	2.3777	2.4897	2.524	2.6783	2.4949
15	2.4949	2.3655	2.4691	2.5652	2.524	2.6595	2.4949
16	2.4394	2.2916	2.3411	2.5463	2.4143	2.5652	2.4209
17	2.347	2.2916	2.268	2.4331	2.3228	2.3577	2.384
18	2.3285	2.2177	2.3411	2.3388	2.268	2.3388	2.6981
19	2.5873	2.6797	2.7435	2.7161	2.7435	2.5652	2.6981
20	2.8275	2.9384	2.9995	3.0367	3.0178	2.9801	2.9754
21	3.9363	3.9179	4.0421	4.1684	4.2433	4.225	4.1951
22	3.0862	3.1786	3.2373	3.2442		3.263	3.271
23	3.2895	3.3634	3.3836	3.4328	3.4385	3.5082	3.345
24	3.2819	3.1786	3.2526	3.3653	3.4328	3.2007	
Max	3.9363	3.9179	4.0421	4.1684	4.2433	4.225	4.1951
Min	2.3285	2.2177	2.268	2.3388	2.268	2.3388	2.0513
Avg	2.7659	2.7205	2.7498	2.8361	2.8336	2.8249	2.8029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6173	.6001	.583	.6602	.5506	.7545
2	.6036	.6268	.5487	.5182	.5847	.4858	.6224
3	.547	.5144	.4801	.4696	.547	.4534	.5847
4	.5093	.463	.4458	.4534	.4904	.421	.5281
5	.4715	.4287	.4287	.421	.4527	.421	.4715
6	.4338	.4115	.4287	.4049	.415	.4049	.4338
7	.3961	.4115	.4287	.3725	.4338	.3725	.415
8	.3961	.3944	.4115	.3887	.4527	.421	.415
9	.415	.3258	.4251	.3401	.415	.3563	.4338
10	.3961	.3429	.3601	.3563	.3772	.2915	.415
11	.3961	.3429	.3239	.4338	.2915	.4338	.4161
12	.4287	.3429	.3401	.3772	.3563	.3961	.4508
13	.3944	.3429	.3401	.3772	.3401	.3584	.4508
14	.3601	.3258	.3239	.3772	.3563	.415	.4161
15	.4458	.3601	.3563	.415	.3563	.3584	.4334
16	.4287	.3429	.3239	.3961	.3239	.3584	.4334
17	.3944	.3601	.3077	.3772	.3239	.3961	.4161
18	.3772	.3601	.3401	.3961	.3563	.3961	.4681
19	.4287	.4115	.4049	.4338	.3563	.4338	.4681
20	.4801	.4115	.4372	.5281	.4049	.4904	.463
21	.4973	.463	.4534	.5658	.4534	.5281	.5201
22	.5316	.4801	.502	.6036		.5847	.5548
23	.5658	.6001	.5992	.679	.583	.6979	.6068
24	.679	.6516	.6173	.6154	.6979	.5668	
Max	.679	.6516	.6173	.679	.6979	.6979	.7545
Min	.3601	.3258	.3077	.3401	.2915	.2915	.415
Avg	.4690	.4305	.4261	.4535	.4360	.4413	.4857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7164	1.6118	1.6297	1.4403	1.6221	1.5089	1.6598
2	1.5278	1.4685	1.4864	1.3032	1.4523	1.3889	1.4523
3	1.3203	1.3969	1.3432	1.2174	1.2826	1.286	1.3769
4	1.226	1.1999	1.1641	1.0974	1.2071	1.0974	1.1883
5	1.1506	1.1104	1.0745	.9945	1.1317	1.0288	1.1317
6	1.1317	1.0745	1.0029	.9945	1.1694	.9774	1.094
7	1.094	1.0745	1.0745	1.0117	1.1506	1.0117	1.0562
8	1.0751	.9492	1.0534	.9602	1.1506	.9602	1.0374
9	1.0562	.9671	.9492	.9945	1.0562	1.0117	1.0562
10	1.094	.9313	.9134	.9259	.9997	.9602	1.1883
11	1.1506	.8596	.8573	.9808	.8059	.9619	1.1104
12	1.1104	.8417	.823	.9808	.8402	.9808	.985
13	.985	.788	.8402	.9054	.8916	.9242	1.0387
14	1.0745	.8417	.8745	.9619	.9774	1.0562	1.182
15	1.182	1.0029	1.0117	1.0562	.9945	1.094	1.1641
16	1.0745	.9134	.9945	1.1128	.9774	1.7541	1.1283
17	1.0029	.8059	.8573	.9242	.9088	.9808	1.0745
18	.985	.788	.7202	.8865	.823	.8676	.8954
19	1.0208	.9313	.9088	.9808	.9259	1.0185	1.0387
20	1.1104	1.0387	.9945	1.1506	1.0288	1.1883	1.1643
21	1.1283	1.1283	1.1831	1.3014	1.166	1.2449	1.1999
22	1.3253	1.3253	1.2346	1.4901		1.4146	1.3432
23	1.5581	1.6655	1.6118	1.8296	1.5947	1.7353	1.5402
24	1.6787	1.6476	1.7013	1.5775	1.8107	1.5432	
Max	1.7164	1.6655	1.7013	1.8296	1.8107	1.7541	1.6598
Min	.985	.788	.7202	.8865	.8059	.8676	.8954
Avg	1.1991	1.0984	1.0960	1.1283	1.1290	1.1665	1.1785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6595	2.7721	2.6242	2.6337	2.6972	2.7069	2.7161
2	2.5086	2.6797	2.4394	2.5057	2.4897	2.5423	2.5086
3	2.3765	2.5133	2.3101	2.2862	2.4143	2.3411	2.4331
4	2.2445	2.3655	2.1807	2.1765	2.2634	2.1216	2.3388
5	2.1313	2.2731	2.0698	2.0485	2.0936	2.0668	2.1313
6	2.2257	2.2177	2.1253	2.0668	2.2445	2.1033	2.2634
7	2.6783	2.4949	2.4764	2.4691	2.5652	2.524	2.5463
8	2.3577	2.0144	2.0698	2.1216	2.1691	2.0485	2.0936
9	1.9993	1.885	1.9404	1.8656	2.0182	1.9204	2.037
10	1.9805	1.7741	1.8296	1.7741	1.8673	1.7741	1.9805
11	2.0182	1.7002	1.7193	1.7918	1.7558	1.773	1.8111
12	1.9589	1.6263	1.6461	1.7541	1.7741	1.7918	1.8111
13	1.7926	1.6263	1.6095	1.7164	1.701	1.7164	1.8296
14	1.8665	1.6448	1.701	1.7541	1.7741	1.8107	1.9959
15	2.0513	1.7187	1.7558	1.8673	1.8839	1.8484	1.9959
16	2.0328	1.6817	1.701	1.8861	1.7741	1.7541	1.7372
17	1.9774	1.7556	1.7741	1.8484	1.7741	1.7918	2.0513
18	1.8665	1.7556	1.7558	1.773	1.829	1.773	1.9404
19	2.0328	2.0698	2.0851	2.1125	2.0668	1.9805	2.1437
20	2.3655	2.347	2.4508	2.4709	2.4326	2.4331	2.3655
21	2.9384	2.9938	3.0178	2.9424	3.0544	3.0556	3.0123
22	2.5318	2.6427	2.7252	2.7538		2.6972	2.7166
23	2.7351	2.846	2.9264	2.9613	2.8715	2.4709	2.8275
24	2.8104	2.8275	2.8829	2.8898	2.9047	2.7801	
Max	2.9384	2.9938	3.0178	2.9613	3.0544	3.0556	3.0123
Min	1.7926	1.6263	1.6095	1.7164	1.701	1.7164	1.7372
Avg	2.2558	2.1761	2.1590	2.1862	2.1921	2.1594	2.2299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3765	2.4209	2.3655	2.3411	2.4143	2.4143	2.5086
2	2.1313	2.3655	2.1622	2.1948	2.2634	2.2314	2.3388
3	2.037	2.2177	2.0698	2.0485	2.0748	2.1216	2.1879
4	1.8861	2.1253	1.885	1.9204	1.9427	1.9022	2.0559
5	1.773	1.9404	1.6817	1.8107	1.8484	1.8656	1.8673
6	1.6975	1.7741	1.7741	1.8107	1.773	1.7924	1.7541
7	1.6221	1.7187	1.6448	1.6827	1.6975	1.701	1.6787
8	1.5466	1.5708	1.5154	1.701	1.6598	1.6461	1.6221
9	1.5466	1.4784	1.5154	1.5546	1.6032	1.4998	1.6787
10	1.5655	1.423	1.386	1.4449	1.4712	1.4632	1.7353
11	1.4523	1.4045	1.39	1.358	1.4266	1.3957	1.5524
12	1.5524	1.2567	1.2803	1.3769	1.3169	1.3957	1.5893
13	1.6448	1.3676	1.3352	1.3957	1.39	1.4335	1.5893
14	1.6078	1.4415	1.3717	1.4712	1.5729	1.5844	1.7741
15	1.6448	1.46	1.5729	1.6409	1.6095	1.7918	1.885
16	1.6263	1.5154	1.5546	1.6598	1.5912	1.6598	1.7926
17	1.6448	1.3306	1.3352	1.5089	1.4998	1.5089	1.6263
18	1.4415	1.386	1.3169	1.358	1.3169	1.4146	1.5708
19	1.6263	1.5154	1.6095	1.5655	1.5912	1.5844	1.6632
20	1.6448	1.6078	1.701	1.6975	1.7558	1.7918	1.8111
21	1.7741	1.7926	1.8839	1.905	1.8656	1.9616	1.9035
22	1.9404	2.0144	2.1033	2.0748		2.0559	2.0883
23	2.2546	2.4025	2.5057		2.4508	2.3954	2.4025
24	2.3954	2.4764	2.4949	2.5057	2.6029	2.4326	
Max	2.3954	2.4764	2.5057	2.5057	2.6029	2.4326	2.5086
Min	1.4415	1.2567	1.2803	1.358	1.3169	1.3957	1.5524
Avg	1.7680	1.7503	1.7273	1.7403	1.7712	1.7935	1.8555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV VASHI PLAZA OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9979	1.0349	.9335	1.0349	1.0349	1.0719	1.0534
2	.924	.9795	.8962	.961	.9709	.9979	.9979
3	.8501	.9335	.8215	.9149	.8962	.924	.9522
4	.7842	.8589	.7468	.8589	.8402	.8316	.8962
5	.7023	.7947	.7095	.8029	.8215	.7392	.8316
6	.6283	.7392	.6722	.7655	.7842	.6653	.7762
7	.5729	.6838	.6908	.7282	.7655	.7023	.7207
8	.6099	.7207	.6908	.7842	.8402	.7392	.6468
9	.924	1.1222	1.1016	1.182	1.1765	1.134	.9149
10	.9795	1.848	1.7741	1.7375	1.6644	1.7737	1.3121
11	1.1827	2.1992	2.1582	2.2546	2.1765	2.1948	1.8665
12	1.3121	2.2731	2.3655	2.3655	2.268	2.268	1.885
13	1.262	2.1399	2.1253	2.2497	2.2131	2.2131	1.8665
14	1.3717	2.1216	2.1399	2.1765	2.268	2.3228	1.9753
15	1.4632	2.2131	2.2497	2.3655	2.3101	2.4764	1.9774
16	1.39	2.2361	2.3285	2.3101	2.2731	2.3655	1.9978
17	1.2986	2.1437	2.2361	2.2177	2.4025	2.2862	1.8858
18	1.1523	2.0485	1.9936	2.0485	2.0851	1.9936	1.6244
19	1.2012	1.8665	1.8107	1.8473	1.7741	1.701	1.587
20	1.2071	1.6448	1.5729	1.5912	1.6817	1.4998	1.5546
21	1.0719	1.386	1.423	1.4969	1.4415	1.386	1.386
22	1.0164	1.2323	1.2382	1.2936	1.2567	1.2197	1.2382
23	1.0719	1.1576	1.1273	1.1949	1.1643	1.1643	1.1458
24	1.0719	1.1088	1.0269	1.0719	1.1576	1.1458	1.1273
Max	1.4632	2.2731	2.3655	2.3655	2.4025	2.4764	1.9978
Min	.5729	.6838	.6722	.7282	.7655	.6653	.6468
Avg	1.0436	1.4786	1.4514	1.5106	1.5111	1.4923	1.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5339	1.5708	1.5893	1.643	1.5684	1.7177	1.6991
2	1.4937	1.5123	1.5154	1.5684	1.5123	1.6057	1.587
3	1.4377	1.4563	1.4045	1.4937	1.4563	1.4937	1.5089
4	1.3817	1.3817	1.2567	1.4377	1.3817	1.419	1.4335
5	1.3256	1.3256	1.1827	1.3769	1.3256	1.2696	1.358
6	1.2752	1.2382	1.2012	1.3014	1.2883	1.1203	1.2323
7	1.2382	1.1827	1.1827	1.2323	1.2136	1.0642	1.1088
8	.924	1.1827	1.0269	1.1576	1.1763	1.0269	.9795
9	1.1763	1.0374	1.0903	1.1883	1.094	1.1203	.9808
10	1.1016	1.0349	1.1016	1.1694	1.1317	1.1763	1.0374
11	1.0374	1.0903	1.1389	1.1883	1.1949	1.1763	1.0751
12	1.094	1.1016	1.0642	1.2193	1.1763	1.0829	1.0829
13	1.0185	1.1203	1.1203	1.1694	1.1576	1.1949	1.1016
14	1.094	1.0903	1.1389	1.1883	1.2323	1.2696	
15	1.1389	1.1949	1.2323	1.2637	1.2883	1.3443	1.251
16	1.1389	1.2136	1.2696	1.3203	1.2696	1.307	1.1694
17	1.1203	1.1949	1.2696	1.1763	1.307	1.1949	1.1883
18	1.0829	1.0829	1.1016	1.1203	1.1016	1.251	1.1506
19	1.2883	1.1949	1.2936	1.307	1.251	1.2936	1.251
20	1.4377	1.475	1.5524	1.4969	1.5684	1.5524	1.4784
21	1.5154	1.386	1.6461	1.5339	1.587	1.475	1.423
22	1.46	1.531	1.6278	1.5154	1.7364	1.531	1.4969
23	1.6632	1.7364	1.7551	1.7364	1.7924	1.6817	1.7737
24	1.5708	1.6448	1.6617	1.7177	1.7551	1.7737	1.7737
Max	1.6632	1.7364	1.7551	1.7364	1.7924	1.7737	1.7737
Min	.924	1.0349	1.0269	1.1203	1.094	1.0269	.9795
Avg	1.2728	1.2908	1.3093	1.3551	1.3569	1.3393	1.3105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 203 / 11KV MGM OG

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4382	.4191		.4191	.4954	.4763
2	.4001	.4001	.381	.4382	.381	.4572	.4382
3	.381	.362	.3584	.4001	.362	.4191	.4001
4	.362	.3429	.3772	.381	.381	.3961	.381
5	.3429	.381	.3921	.4191	.4191	.4382	.4191
6	.362	.4001	.415	.4382	.4191	.4527	.4382
7	.4001	.4191	.415	.4382	.4382	.4763	.4572
8	.3429	.4763	.4904	.4191	.5525	.5144	.5144
9	.2477	.4572	.4904	.4763	.4904	.5525	.5906
10	.4572	.547	.4572	.5716	.6281	.6287	.6097
11	.362	.6036	.6478	.6859	.5716	.6668	.6287
12	.4954	.5658	.6478	.6478	.5144	.6478	.6287
13	.5525	.5144	.5906	.6668	.679	.6668	.6859
14	.4001	.5658	.6097	.6097	.724	.7049	.7621
15	.4763	.5716	.6478	.5906	.6602	.743	.6859
16	.4572	.6161	.5335	.6097	.724	.6478	.7049
17	.4763	.6287	.6287	.6097	.6859	.6859	.6859
18	.381	.6097	.4763	.5906	.6036	.6859	.5906
19	.362	.5335	.5906	.5144	.5847	.6097	.5525
20	.2858	.6097	.5335	.4954	.5525	.5525	.5658
21	.381	.4568	.4954	.4763	.5335	.5906	.5525
22	.4572	.4904	.4001	.5906	.4572	.5144	.5335
23	.4382	.5093	.4572	.5144	.4954	.4763	.5144
24	.4572	.4572	.4338	.4954	.4572	.5335	.4954
Max	.5525	.6287	.6478	.6859	.724	.743	.7621
Min	.2477	.3429	.3584	.381	.362	.3961	.381
Avg	.4048	.4982	.4954	.5252	.5306	.5649	.5547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	1.0185	1.0185	1.0751	.9997	1.1128	1.1203
2	.9709	.9808	.9808	1.0374	.9619	1.0562	1.0642
3	.9242	.9242	.9431	.9997	.9242	.9431	.9896
4	.8676	.8865	.9054	.9242	.8488	.9054	.9335
5	.811	.8299	.8676	.8676	.7733	.8299	.8676
6	.7545	.7733	.8299	.811	.7545	.7922	.811
7	.6979	.811	.811	.8488	.7922	.7733	.7545
8	.7356	.7733	.9242	.8488	.8676	.811	.8299
9	.9709	1.0374	1.0751	.9997	.7947	1.0751	.9997
10	1.1203	2.0911	1.8858	1.8484	1.8107	1.7924	1.5466
11	1.5497	2.7915	2.6699	2.6886	2.782	2.7446	2.4646
12	1.7364	2.838	2.8193	2.8753	2.8753	2.782	2.5086
13	1.6244	2.6513	2.6886	2.782	2.8006	2.7633	2.5206
14	1.7177	2.6326	2.5579	2.6699	2.7633	2.8193	2.5463
15	1.6057	2.5579	2.8006	2.8292	2.894	2.8567	2.5953
16	1.6057	2.6699	2.838	2.7915	2.8567	2.838	2.5766
17	1.6244	2.6513	2.5953	2.6699	2.7633	2.8006	2.3765
18	1.5497	2.4832	2.5766	2.5579	2.6139	2.5953	2.2405
19	1.8298	2.3655	2.5206	2.4086	2.4832	2.4025	2.2779
20	1.7187	2.0538	2.2592	2.2177	2.2405	2.1622	2.0725
21	1.6617	1.8111	1.8858	1.7741	1.8298	1.7924	1.8111
22	1.4377	1.5089	1.475	1.46	1.5497	1.4563	1.5524
23	1.1883	1.1883	1.226	1.226	1.2637	1.2323	1.1694
24	1.0829	1.0751	1.0642	1.094	1.1317	1.1506	1.1949
Max	1.8298	2.838	2.838	2.8753	2.894	2.8567	2.5953
Min	.6979	.7733	.811	.811	.7545	.7733	.7545
Avg	1.2839	1.7252	1.7591	1.7627	1.7656	1.7703	1.6593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9149	.9997	.9335	1.0642	.8775	.9242	1.0269
2	.8775	.9431	.8962	1.0082	.8215	.8676	.9896
3	.8402	.9054	.8589	.9522	.7842	.7922	.9522
4	.8029	.8402	.8215	.8962	.7468	.7167	.8962
5	.7655	.8029	.7842	.8215	.6979	.679	.8402
6	.7282	.7655	.8029	.7468	.7356	.6602	.7842
7	.7577	.7282	.8215	.7655	.7545	.679	.8215
8	.8029	.7655	.6908	.8402	.7922	.7922	.7655
9	.8501	.6602	.8775	.7922	.8029	.8676	.7733
10	.8215	.9149	.9896	.9808	.9522	.9808	.8488
11	.9054	.9896	1.0456	1.0185	1.1016	1.0374	.8865
12	.9619	1.1203	1.0456	1.094	1.1389	1.0456	.9242
13	1.0082	1.1016	1.0829	1.1016	1.1088	1.0829	1.0374
14	.9522	1.0562	1.0829	1.1128	1.094	1.1506	1.0185
15	.9242	1.0185	1.1016	1.1506	1.1128	1.1763	1.0185
16	.8676	1.0082	1.0185	1.1128	1.1506	1.1576	1.0185
17	.811	.9431	1.0269	.9619	1.0562	1.0185	.9335
18	.8316	.9431	.9335	.9808	.9709	.9795	.9335
19	.9335	1.0642	1.1458	1.1389	1.1763	1.1643	1.0642
20	1.1157	1.1576	1.2382	1.2752	1.3121	1.2437	1.2936
21	1.0269	1.0829	1.1016	1.1576	1.2752	1.0642	1.2752
22	.9335	.9979	.9709	1.0269	1.0269	1.0269	1.0719
23	.9709	.9896	1.0642	1.1949	1.0829	1.0534	1.0829
24	.9522	1.0374	.9808	1.0829	1.0456	.9896	1.0534
Max	1.1157	1.1576	1.2382	1.2752	1.3121	1.2437	1.2936
Min	.7282	.6602	.6908	.7468	.6979	.6602	.7655
Avg	.8898	.9515	.9715	1.0116	.9841	.9646	.9713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.5339	1.5154	1.5524	1.6448	1.6461	1.5708
2	1.4045	1.423	1.46	1.4937	1.5524	1.4266	1.4937
3	1.3121	1.3676	1.2936	1.4003	1.4415	1.2437	1.3817
4	1.2136	1.2696	1.2012	1.3256	1.363	1.2071	1.2883
5	1.1088	1.1763	1.0719	1.2323	1.2136	1.0974	1.1763
6	1.0164	1.0719	.9979	1.1458	1.0829	1.0719	1.0719
7	.9145	.9979	.961	1.0719	1.0082	.924	.9795
8	.8779	.9425	.961	.9795	.9149	.961	.8686
9	1.1523	.8962	.9055	.8962	.8775	.8871	.9054
10	.961	.8589	.9149	.8962	.9335	.9335	.9335
11	.8871	.8402	.8589	.8402	.8215	.8402	.8589
12	.924	.7468	.7842	.8029	.8029	.8215	.8215
13	.8871	.7842	.8402	.8029	.8775	.8589	.8962
14	1.0642	.8402	.8962	.9149	.9709	.9896	1.1203
15	1.0903	.9896	1.0269	1.0269	1.0642	1.1016	1.1576
16	1.0082	.9149	.9709	.9522	.9522	1.0082	1.1016
17	.9149	.8589	.8686	.8775	.9522	.9335	1.0082
18	.8501	.7842	.8686	.8131	.8402	.8501	.8775
19	.961	.924	.9055	.8871	1.0269	1.0349	1.0425
20	1.1523	1.1643	1.0791	1.1523	1.2071	1.2071	1.1888
21	1.1523	1.1888	1.2382	1.1827	1.2254	1.2012	1.1827
22	1.2986	1.2803	1.3491	1.3491	1.4449	1.4045	1.3676
23	1.5524	1.6078	1.6078	1.6263	1.6448	1.6448	1.7002
24	1.6078	1.6263	1.5912	1.6448	1.7002	1.701	1.6817
Max	1.6078	1.6263	1.6078	1.6448	1.7002	1.701	1.7002
Min	.8501	.7468	.7842	.8029	.8029	.8215	.8215
Avg	1.1170	1.0870	1.0903	1.1195	1.1485	1.1248	1.1531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2408	.3018	.1524	.1738	.3018
2		.2	.2408	.3018	.1524	.1738	.2743
3		.2	.2408	.3018	.0133	.1738	.2743
4		.2286	.2408		.1334	.1738	.2743
5		.2107	.2408	.3018	.0152	.1738	.2743
6		.2683	.2408	.3018	.2134	.1738	.2401
7	.3018		.2408	.3018	.2439	.1738	.2401
8		.2107	.2408		.1738	.1738	.2401
9	.3018	.2408	.2408	.3018	.1738	.1738	.2743
10	.3018	.2408		.3018	.1738	.1738	.2743
11	.3018	.2408	.3018	.3018	.1738	.3018	.2743
12	.3018	.2408	.3018	.3018	.1738	.3018	.2743
13	.3018	.2408	.3018	.3018	.1738	.3018	.2743
14	.3018	.2408		.3018	.1738		.2743
15	.3018	.2408	.3018	.3018	.1738	.3018	.2743
16	.3018	.2408		.3018	.1738		.2743
17	.3018	.2408		.3018	.1738		.2743
18		.2408	.3018	.3018	.1738		.1029
19		.2408	.3018	.3018	.1738		.2743
20		.2408		.3018	.152	.2401	.2743
21		.2408	.3018	.3018	.1738		.2401
22		.2408		.3018	.1738	.2263	.2401
23	.3018	.2408		.3018	.1738		.2401
24	.3018	.3018	.3018	.3018	.1128	.3018	.3018
Max	.3018	.3018	.3018	.3018	.2439	.3018	.3018
Min	.3018	.2	.2408	.3018	.0133	.1738	.1029
Avg	.3018	.2374	.2695	.3018	.1582	.2184	.2609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV AKSHAR FEEDER (OLD SHEDDABLE FEEDER HAVING WEEKLY
 PHIZER Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT))

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2826	1.3203	1.2826	1.358	1.2071	1.1317
2		1.2071	1.3203	1.2826	1.3203	1.1317	1.1317
3		1.2071	1.2449	1.2826	1.3203	1.1317	1.1317
4		1.1694	1.1694	1.2071	1.2826	1.094	1.1317
5		1.1694	1.1317	1.2071	1.2071	1.0562	1.1317
6		1.2071	1.094	1.2071	1.2071	1.1317	1.1351
7	1.1317	1.2071	1.1694	1.2071	1.2826	1.2071	1.1317
8		1.3203	1.3203		1.358	1.2449	1.2826
9	1.3957	1.6975	1.6598	1.6221	1.8107	1.6221	1.594
10	1.5844	2.0748		1.9616	2.3011	1.9993	2.3388
11	1.6598	2.1502	2.0494	2.1502	2.1879	2.1502	2.2634
12	1.5844	1.9616	2.0094	1.8861	2.4143	2.1879	2.5274
13	1.3203	1.5844	1.9239	1.6598	2.452	1.9993	2.2257
14	1.3957	1.8107		2.1879	2.5274		2.5274
15	1.4335	2.2257	2.1125	2.2634	2.3388	2.2634	2.5652
16	1.6221	2.1125		2.4897	2.3011		2.5274
17	1.4712	2.0748		2.1125	1.8861		2.1125
18		1.6598	1.5089	1.5089	1.5844		1.6598
19		1.2071	1.3203	1.2826	1.2826		1.3957
20		1.1317		1.2071	1.094	1.1317	1.3957
21		1.094	.9808	1.0562	1.0185		1.358
22		1.2826		1.094	1.358	1.3203	1.358
23	1.3203	1.2449		1.2071	1.2826		1.358
24	1.3203	1.2826	1.358	1.358	1.358	1.2071	1.1317
Max	1.6598	2.2257	2.1125	2.4897	2.5274	2.2634	2.5652
Min	1.1317	1.094	.9808	1.0562	1.0185	1.0562	1.1317
Avg	1.4366	1.5152	1.4525	1.5532	1.6472	1.4756	1.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0457	.0686	.0457		.0686
2				.0457	.0457		.0686
3		.0457	.0457	.0457	.0457		.0686
4		.0457		.0457	.0457		.0686
5			.0457	.1143	.0457		.0686
6		.0457		.0457	.0495		.0686
7	.0686	.0457	.0457	.0457	.0495		.0686
8		.0457			.0495		.0686
9	.0686	.0457	.0457	.0457		.0495	.0686
10	.0457	.0457		.0457	.0495	.0495	.0686
11	.0457	.0457	.069	.0457	.0495	.0754	
12	.0457	.0457		.0457		.0686	.0655
13	.0457	.0457		.0457	.0495	.0686	.0655
14	.0457			.0457	.0495		.0655
15	.0457			.0457	.0495	.0686	.0655
16	.0457	.0457		.0457	.0495		.0655
17	.0457			.0457	.0495		.0655
18			.0457	.0457			.0655
19		.0457	.0457	.0457			.061
20	.0457	.0457		.0457	.0495	.0686	.061
21			.0686	.0046			.061
22		.0457		.0457		.0686	.061
23	.0457			.0457	.0495		.061
24	.0686	.0343	.0754	.0686		.0754	.0686
Max	.0686	.0457	.0754	.1143	.0495	.0754	.0686
Min	.0457	.0343	.0457	.0046	.0457	.0495	.061
Avg	.0510	.0450	.0533	.0489	.0484	.0659	.0660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0015	.0152		.0015		.0457
2		.0152			.0015		.0457
3		.0152	.0152				.0457
4		.0152			.0015		.0457
5		.0152			.0015		.0457
6		.0152	.0152		.0015		.0457
7	.0152	.0152			.0015		.0457
8		.0152			.0015		.0457
9	.0152	.0152	.0152			.0015	.0152
10	.0152	.0152					.0457
11	.0152		.0229		.0015		
12	.0152	.0152					.0041
13	.0152						.0041
14	.0152						.0412
15	.0152	.0152	.0152				.0442
16	.0152			.0015	.0015		.0442
17	.0152			.0015			.029
18				.0152	.0015		.0442
19				.0015			.0442
20		.0152		.0015		.0457	.0442
21				.0015			
22				.0015		.0518	.0442
23	.0152	.0152		.0015	.0015		.0442
24	.0686	.0472	.0754		.0472	.0754	.0457
Max	.0686	.0472	.0754	.0152	.0472	.0754	.0457
Min	.0152	.0015	.0152	.0015	.0015	.0015	.0041
Avg	.0197	.0164	.0249	.0032	.0053	.0436	.0391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.773	1.6975			1.7353
2		1.773	1.6221			1.7353
3		1.7353	1.5844			1.7353
4		1.7353	1.5089			1.7353
5		1.6975	1.5089			1.7353
6		1.6975	1.4335			1.7353
7	1.5089	1.5844	1.4335			1.7353
8		1.5844	1.2449			1.7353
9	1.4422	1.6975	1.358	1.773		1.8107
10	1.5089	1.7353		1.8484		1.773
11	1.5844	1.8107	1.8107	1.8861		
12	1.5089	1.7353		1.8107		
13	1.358	1.8484		1.6598		
14	1.4335	1.8484		1.3957		
15	1.4712	1.8107		1.773		
16	1.5089	1.773		1.773		
17	1.5089	1.6598		1.8107		
18	1.5844	1.6598				
19	1.6598	1.8107				
20	2.1125	1.7353			1.8957	
21	1.8861	1.6975				
22	1.8484	1.6975			1.8107	
23	1.8107	1.7353				.0305
24	1.773	1.7353	1.6975			1.7353
Max	2.1125	1.8484	1.8107	1.8861	1.8957	1.8107
Min	1.358	1.5844	1.2449	1.3957	1.8107	.0305
Avg	1.6182	1.7321	1.5364	1.7478	1.8532	1.6027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132			.0023		
2					.0023		
4		.1132			.0229		
6					.0023		
7	.1132	.1132			.0023		
8		.1132		.0023	.0023		.0023
9	.1139	.1132	.1132	.0023		.0023	.1132
10	.1132	.1132		.0023	.0023	.0023	.0023
11	.1132	.1132	.1132	.0023		.0023	.0023
12	.1132	.1132	.0023	.0023		.0023	.0023
13	.0514		.0023	.0023		.0023	.0023
14	.1132			.0023			.0023
15	.1132		.0023	.0023		.0023	.0023
16	.1132			.0023	.0023		.0023
17	.1132			.0023			.0023
18				.0023			.0229
19			.0023	.0023	.0023		.0023
20		.1132		.0023		.0023	.0023
21			.0023	.0023			.0023
22				.0023		.0023	.0023
23	.1132	.1132		.0023	.0023		.0023
24	.1132	.0686	.1132	.0023	.0018	.1132	.0023
Max	.1139	.1132	.1132	.0023	.0229	.1132	.1132
Min	.0514	.0686	.0023	.0023	.0018	.0023	.0023
Avg	.1081	.1091	.0439	.0023	.0041	.0146	.0100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.0748
2				1.9993
3				1.9993
4				1.9616
5				1.9616
6				1.6975
7				1.5089
8			1.5844	1.2826
9			1.9616	1.3203
10			1.9616	1.2826
11	.0015		2.3388	
12			1.773	1.3203
13			1.9993	1.1317
14				1.1317
15			1.7423	1.1317
16	.0015	.0015		1.2071
17		.0015		1.1694
18		.0015		1.2071
19				1.2826
20			1.8107	1.2071
21				1.2826
22			1.9239	1.358
23				1.358
24				2.0748
Max	.0015	.0015	2.3388	2.0748
Min	.0015	.0015	1.5844	1.1317
Avg	.0015	.0015	1.8995	1.4761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV ZOETIS PHARMA (PHIZER NON SHEDDABLE EXPRESS HV FEEDERS
EX Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.6413	.7545	.7167	.7167	.679
2		.3772	.6413	.7545	.7167	.679	.679
3		.3395	.679	.679	.679	.679	.679
4		.3395	.679	.679	.679	.679	.679
5		.3772	.679	.679	.6413	.6413	.679
6		.415	.6413	.6036	.6413	.6413	.7545
7	.3395	.415	.6413	.6036	.679	.6413	.7545
8		.8299	.6036		.679	.679	.7545
9	.3395	.6413	.7167	.8299	.9054	.679	.6413
10	.3395	.679		.8676	.8299	.7167	.8299
11	.3395	.679	.7545	.9054	.7545	.7545	.6036
12	.3772	.7922	.7545	.9054	.9054	.759	.7545
13	.3772	.8299	.7545	.7167	.7545	.8676	.7167
14	.3772	.679		.7545	.7545		.7167
15	.3772		.7545	.8299	.8299	.7545	.679
16	.3772	.8299		.9431	.7545		.6413
17	.3395	.7922		.7545	.7167		.6413
18		.6036	.7938	.679			.6413
19			.679	.679			
20		.5658		.7545	.679	.7545	.6036
21		.6036	.7545	.7167	.7922		.5658
22		.5658		.6413	.679	.7545	.5281
23	.3772	.5658		.6036	.6036		.5281
24	.3772	.3395	.6413	.7545	.6413	.7167	.6413
Max	.3772	.8299	.7938	.9431	.9054	.8676	.8299
Min	.3395	.3395	.6036	.6036	.6036	.6413	.5281
Avg	.3615	.5744	.6947	.7430	.7287	.7126	.6692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 310 / 22 KV MAZDA FEEDER
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2641	.3018	.2641	1.6975	1.6221	1.5089
2		.2641	.3018	.2641	1.6975	1.5844	1.5089
3		.3018	.3018	.2641	1.6598	1.5089	1.5089
4		.3018	.3018	.2641	1.6598	1.4712	1.5089
5		.2641	.3018	.2641	1.6221	1.5089	1.5844
6		.3018	.3018	.3018	1.6221	1.5466	1.5844
7	1.5844	.3018	.3018	.3018	1.6221	1.5844	1.5844
8		.3018	.3772		1.773	1.7353	1.6598
9	1.8861	.3772	.415	.3772		1.8484	1.8861
10	2.037	.6036		.7545	2.2634	1.9993	2.1125
11	2.1125	.7167	.7545	.679	2.3388	2.1125	2.0748
12	2.037	.679	.7545	.7167	2.3765	2.1125	2.1125
13	.9335	.5658	.6036	.4904	2.3011	2.1125	2.037
14	.9149	.679		.679	2.3011		2.1125
15	.9335	.7167	.7545	.679	2.2634	1.9616	
16	1.0082	.6413		.679	2.3765		1.8861
17	.6908	.6413		2.1879	2.1879		2.037
18		.5281	.5281	1.9616	1.8107		1.9616
19		.4527	.3395	1.8484	1.9993		1.8107
20		.3395		1.773	1.7353	1.5844	1.6975
21		.3395	.3018	1.7353	1.7353		1.5089
22		.3395		1.7353	1.5466	1.5089	1.4335
23	.1307	.3018		1.6975	1.6598		1.4335
24		.2641	.3018	.2641	1.6975		1.5089
Max	2.1125	.7167	.7545	2.1879	2.3765	2.1125	2.1125
Min	.1307	.2641	.3018	.2641	1.5466	1.4712	1.4335
Avg	1.2971	.4370	.4261	.8775	1.9107	1.7376	1.7418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 311 / 22KV EVEREST NIVARA
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4904	.5658	.5658	.6036	.5658	.4904
2		.5281	.5658	.5658	.6036	.5658	.4904
3		.4904	.5281	.5658	.5658	.5281	.4904
4		.4527	.5281	.5658	.5658	.5281	.4904
5		.4904	.4904	.5281	.5658	.5281	.4531
6		.5281	.4904	.5281	.5281	.4904	.4527
7	.4527	.4527	.5658	.5658	.5281	.4904	.4527
8		.4904	.4904		.5658	.4527	.4527
9	.4527	.6413	.7167	.7545	.7545	.679	.5658
10	.4904	.8299		.7922	.7922	.679	.6036
11	.5281	.7922	.7922	.8299	.8676	.7922	.6413
12	.5281	.679	.8299	.8299	.8676	.7545	.7167
13	.4904	.9431	.8299	.7167	.7922	.6413	.679
14	.4904	.9054		.8299	.7922		.6036
15	.5281	.8676	.7922	.9054	.8299	.7545	.7167
16	.5658	.8676		.8676	.8299		.6413
17	.5281	1.094		.8676	.8299		.6413
18		.679	.7545	.7545	.415		.2263
19		.6036	.7545	.7167	.3772		.6036
20		.6413		.6036	.679	.5658	.5658
21		.6036	.7545	.6413	.7167		.6036
22		.6036		.6413	.7545	.5658	.6036
23	.5658	.5658		.6413	.679		.6036
24	.7922	.5281	.5658	.5658	.6413	.5658	.4909
Max	.7922	1.094	.8299	.9054	.8676	.7922	.7167
Min	.4527	.4527	.4904	.5281	.3772	.4527	.2263
Avg	.5344	.6570	.6479	.6888	.6727	.5969	.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 312 / 22KV CHUNABHATTI

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.7167	.7545	.8676	.8299	.5658
2		.7167	.7167	.7545	.7545	.7922	
3		.7167	.679	.7545	.7545	.7545	.5658
4		.7545	.679	.7545	.7167	.7545	.5658
5		.7922	.679	.7545	.7167	.7167	.5658
6		.7545	.7167	.7545	.679	.7167	.5658
7	.679	.7545	.7167	.7545	.679	.679	.5658
8		.8299	.7545		.7545	.679	.5658
9	.8299	.9431	.7922	.9054	.8676	.6413	.679
10	.8676	1.1694			.9431	.8676	.9808
11	.9054		.9808		1.094	.8676	1.0185
12	.9054	1.2071	1.0562		1.094	.8676	1.0562
13	.9054	.9808	.9054	1.0562	1.0562	.7545	1.094
14	.8676	1.1317		1.0562	1.094		1.0562
15	.9054	1.1317	1.0185	1.0185	1.2071	.8676	1.0185
16	.8676	1.0185		1.0185	1.0562		.9431
17		1.094		1.094	1.094		1.0562
18		1.0562	.7545	.9431	1.0562		.9054
19		.9808	.8676	1.3203	.9054		.8299
20		.8676		.9808	.8676	.6831	
21		.8299	.8299	.8299	.7922		.8676
22		.7167		.7545	.7922	.6413	.9054
23	.7922	.7922		.8299	.7545		.9054
24	.7545	.7922	.7167	.7545	.8299	.8676	.5658
Max	.9054	1.2071	1.0562	1.3203	1.2071	.8676	1.094
Min	.679	.7167	.679	.7545	.679	.6413	.5658
Avg	.8436	.9037	.7988	.8922	.8928	.7636	.8110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7545	.8215	.8131	.8299	.8589	.8589
2	.7682	.8299	.8676	.7682	.8299	.8215	.8131
3	.7602	.7545	.8131	.724	.7545	.8589	.8501
4	.7164	.8299	.7682	.7682	.7545	.8131	.8048
5	.7087	.9054	.7011	.7602	.9054	.7682	.7316
6	.7602	.9808	.6859	.8501	1.0185	.724	.9709
7	.7087	1.0562	.6706	.7164	1.1317	.7682	.8501
8	.663	1.1317	.724	.7682	1.2071	.8048	.9335
9	.7762	1.2826	.8871	.8131	1.2826	.9709	1.0185
10	.9335	1.3203	1.2449	1.1694	1.358	1.2323	1.2071
11	.8299	1.1576	1.3203	1.2449	1.3203	1.2449	1.358
12	.7545	1.1694	1.2449	1.2826	1.3203	1.3957	1.3957
13	.8299	1.419	.9979	1.3957	1.2449	1.2071	1.358
14	.7545	.9979	1.0082	1.4335	1.2449	1.2071	1.4335
15	.7545	1.0456	1.0082	1.2826	1.3203	1.2071	1.4335
16	.7545	.9808	.9335	1.358	1.2826	1.1694	1.0562
17	.8299	.8962	.8589	1.1317	1.2449	1.094	.9054
18	.7545	.7468	.8589	1.0562	1.1317	.8215	.8299
19	.8299	.7392	.7842	.9054	.9335	.8215	.9808
20	.7545	.6859	.7316	.8299	.7392	.7087	1.0562
21	.8299	.6478	.7164	1.0562	.724	.724	.9808
22	.7545	.663	.7316	1.1317	.8589	.7164	1.0185
23		.7164	.8501		.8589	.7964	.9808
24	.8131	.7545	.724	.8501	.9054	.8501	.8871
Max	.9335	1.419	1.3203	1.4335	1.358	1.3957	1.4335
Min	.663	.6478	.6706	.7164	.724	.7087	.7316
Avg	.7742	.9361	.8730	1.0048	1.0501	.9410	1.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.1694	1.0669	1.105	1.1694	1.0669	1.105
2	1.0288	1.1317	1.0669	1.105	1.1317	1.0669	1.0669
3	.9907	1.094	1.0669	1.0669	1.1317	1.0669	1.0288
4	.9907	1.1317	1.0288	.9907	1.094	1.0288	.9907
5	1.0669	1.1694	.9907	1.0288	1.2071	.9907	1.0288
6	1.0669	1.3203	1.0288	1.0288	1.1317	1.0288	1.0669
7	1.0288	1.3957	1.0669	1.0669	1.358	1.0669	1.0669
8	1.0669	1.4335	1.1812	1.1812	1.3203	1.1431	1.0669
9	1.0669	1.4712	1.4861	1.4861	1.4335	1.3336	1.1812
10	1.105	1.4335	1.448	1.5242	1.5089	1.5242	1.2574
11	1.094	1.5623	1.5623	1.6004	1.5242	1.6004	1.358
12	1.1317	1.5623	1.6004	1.6004	1.5242	1.6004	1.3957
13	1.094	1.448	1.6766	1.4712	1.5242	1.6004	1.358
14	1.1694	1.6004	1.5623	1.3957	1.5242	1.6004	1.3203
15	1.2071	1.5242	1.5242	1.4335	1.5242	1.5623	1.2826
16	1.1317	1.4861	1.5242	1.4712	1.6004	1.6004	1.1317
17	1.094	1.448	1.5242	1.5089	1.5242	1.5242	1.0562
18	1.1317	1.4098	1.5242	1.5466	1.5242	1.4861	1.1694
19	1.094	1.3336	1.3717	1.3203	1.3336	1.4098	1.2071
20	1.1694	1.2193	1.2193	1.2071	1.2193	1.2574	1.1317
21	1.094	1.1431	1.1431	1.2071	1.3717	1.1431	1.094
22	1.1317	1.1431	1.105	1.1317	1.1431	1.105	1.1317
23		1.0288	1.105	1.1694	1.105	1.105	1.094
24	1.0669	1.094	1.0669	1.105	1.094	1.0669	1.105
Max	1.2071	1.6004	1.6766	1.6004	1.6004	1.6004	1.3957
Min	.9907	1.0288	.9907	.9907	1.094	.9907	.9907
Avg	1.0908	1.3231	1.2892	1.2813	1.3343	1.2908	1.1540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL + HPCL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1694	1.448	1.1431	1.1317	1.3336	1.3717
2	1.2955	1.1317	1.4098	1.105	1.0562	1.1812	1.3336
3	1.2574	1.094	1.3717	1.0669	1.094	1.2193	1.2955
4	1.1812	1.1317	1.2955	1.0669	1.1694	1.2955	1.3336
5	1.2193	1.0562	1.2193	1.105	1.094	1.2193	1.3717
6	1.1431	1.773	1.3336	1.105	1.358	1.2574	1.2955
7	1.105	1.8484	1.6004	1.2574	1.5466	1.3336	1.5623
8	1.2574	1.9239	1.6385	1.6766	1.8484	2.0195	1.3717
9	1.2193	2.037	1.8671	1.6766	2.1125	2.0576	1.4098
10	1.2955	1.8107	1.9814	1.9814	2.1125	2.0957	1.3717
11	1.1694	2.0576	2.0957	2.0195	1.9814	1.2193	1.3957
12	1.2826	2.1338	2.0957	2.0195	1.9052	1.2574	1.358
13	1.2071	.9907	1.105	1.9239	1.0288	2.0576	1.2826
14	1.2826	2.0195	.9907	1.8484	2.0576	2.0576	1.358
15	1.1694	1.9814	1.1431	1.773	1.4098	2.0957	1.2826
16	1.2071	2.0576	.9907	1.7353	1.9052	2.1719	1.1694
17	1.1694	1.9814	.9907	1.8484	2.0195	1.9814	1.1317
18	1.1694	1.6385	.9145	1.6975	1.9814	1.7528	1.094
19	1.1694	1.6004	1.1431	1.5466	1.5242	1.5623	1.1317
20	1.2449	1.5242	1.105	1.5089	1.4098	1.5242	1.2071
21	1.1694	1.448	1.1431	1.4712	1.3336	1.4861	1.2826
22	1.2826	1.3717	1.105	1.358	1.2574	1.4861	1.1694
23		1.3336	1.0669	1.1694	1.1812	1.4861	1.2071
24	1.2574	1.2071	1.448	1.105	1.094	1.2955	1.3717
Max	1.2955	2.1338	2.0957	2.0195	2.1125	2.1719	1.5623
Min	1.105	.9907	.9145	1.0669	1.0288	1.1812	1.094
Avg	1.2129	1.5967	1.3543	1.5087	1.5255	1.6019	1.2983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 307 / 22KV AMINES

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	2.2257	2.1719	2.2862	1.358	.9907	.9907
2	.9526	2.3011	2.21	2.21	1.3957	.9526	.9907
3	.9145	2.1879	2.1338	2.2481	1.358	.9526	.9907
4	.9526	2.2257	2.0957	2.1338	1.4712	.9145	.9526
5	.8764	2.2634	2.0576	2.0957	1.358	.8764	.9145
6	.9145	2.1502	2.0576	2.1719	1.2071	.8764	.9526
7	.8764	2.4143	2.0576	2.2481	1.2826	.8764	.9526
8	.8764	2.5274	2.4768	2.553	1.3203	.9145	1.0669
9	.9907	2.5652	2.6673	2.9721	1.358	.9145	1.3717
10	1.1431	2.8669	3.1245	3.1245	1.5089	1.0288	1.4098
11	.9808	3.0483	3.0483	3.0483	1.6385	1.1431	1.5466
12	1.094	2.8578	3.0483	3.0864	1.6766	1.2193	1.3957
13	1.1317	2.5149	2.934	3.0178	1.3717	1.0669	1.4335
14	.9808	2.7435	2.9721	2.9801	1.5242	1.0669	1.5466
15	.9054	2.7054	2.934	2.6783	1.6004	1.1431	1.5089
16	.9808	2.6673	3.1245	2.452	1.5242	1.0669	1.5466
17	.9054	2.6673	2.934	2.3011	1.448	1.0669	1.4712
18	.823	2.6292	2.6673	1.4712	1.4098	1.0669	1.4335
19	1.773	2.553	2.6673	1.0562	1.2955	1.0288	1.3957
20	2.1879	2.4768	2.5149	.8299	1.2574	1.0288	1.2826
21	2.2634	2.4387	2.3624	1.0562	1.0669	.9907	1.1317
22	2.1879	2.3243	2.3243	.9808	1.0288	.9907	1.094
23		2.21	2.1719	1.2826	1.0669	.9907	1.0562
24	.9145	2.2634	2.21	2.2481	1.3957	1.0669	.9907
Max	2.2634	3.0483	3.1245	3.1245	1.6766	1.2193	1.5466
Min	.823	2.1502	2.0576	.8299	1.0288	.8764	.9145
Avg	1.1556	2.4928	2.5403	2.1889	1.3718	1.0098	1.2261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 308 / 22KV Vishal

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4527	.381	.4572	.4527	.381	.4572
2	.4572	.415	.3429	.381	.415	.3429	.4572
3	.4572	.4527	.4191	.4191	.415	.4191	.381
4	.381	.415	.381	.4572	.4527	.381	.4191
5	.4191	.415	.4572	.4572	.4527	.381	.4191
6	.4572	.4527	.381	.4572	.415	.381	.4191
7	.381	.415	.381	.4191	.4527	.381	.4191
8	.381	.4527	.381	.381	.4527	.3429	.381
9	.381	.415	.4191	.381	.415	.381	.381
10	.381	.4527	.4572	.4572	.4527	.4572	.4572
11	.3772	.4572	.4954	.4954	.4954	.6097	.4904
12	.3772	.4954	.5335	.5716	.4572	.5716	.4527
13	.415	.4954	.5716	.4904	.4572	.5716	.4904
14	.415	.4572	.5335		.4191	.5335	.5281
15	.3772	.4954	.6097		.4572	.6097	.5281
16	.3772	.5335	.5335		.5335	.6097	.4527
17	.415	.4954	.5335		.5335	.5335	.5281
18	.3772	.4191	.4572		.4191		.4904
19	.415	.4572	.4954		.4572	.4954	.5281
20	.3772	.4191	.4954		.4954	.4954	.4527
21	.415	.4572	.4954		.4572	.4572	.4904
22	.415	.4572	.4954		.4572	.4572	.4527
23		.4191	.4954		.4191	.4572	.415
24	.4572	.4527	.4572	.4572	.4527	.381	.4572
Max	.4572	.5335	.6097	.5716	.5335	.6097	.5281
Min	.3772	.415	.3429	.381	.415	.3429	.381
Avg	.4071	.4521	.4668	.4487	.4536	.4622	.4562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV R & D

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6413	.8383	.9145	.7545	.8764	.8383
2	.6859	.7167	.8764	.8764	.7545	.8383	.9145
3	.6859	.5658	.7621	.9145	.8299	.8764	.9526
4	.7621	.6036	.7621	.8764	.7545	.8002	.9145
5	.6859	.6413	.724	.9145	.8299	.8383	.8383
6	.724	.7545	.6859	.9145	.7922	.7621	.9907
7	.724	.8299	.724	.8764	.8299	.7621	.8002
8	.6859	.7922	.6478	.724	.7545	.7621	.7621
9	.724	.8299	.7621	.8764	.8299	.8383	.724
10	.724	.7545	.6859	.9907	.9054	.8764	.9145
11	.6036	.6859	.6478	1.0288	.9526	.8383	1.0185
12	.679	.6859	.724	1.0669	.9907	.9907	1.0562
13	.6036	.724	.8002	1.0562	1.1431	1.2193	1.0185
14	.5281	.8764	.8383	1.0185	1.0669	1.1431	1.0562
15	.4527	.8383	.8383	1.094	1.1812	1.1812	1.094
16	.3772	.7621	.8764	.9054	1.0288	1.1431	.9808
17	.4527	.6859	.6478	.8676	.8383	1.0669	.9054
18	.3772	.6097	.4954	.8299	.6478	.6478	.8676
19	.4527	.5716	.4572	.7545	.5716	.4572	.8299
20	.4904	.5335	.6097	.7545	.4954	.4954	.7922
21	.4527	.4954	.5716	.8299	.5335	.381	.8299
22	.4904	.4191	.5335	.8676	.5335	.5716	.7545
23		.4572	.5716	.9054	.4191	.5716	.8299
24	.724	.5658	.8002	.8764	.8299	.8764	.8002
Max	.7621	.8764	.8764	1.094	1.1812	1.2193	1.094
Min	.3772	.4191	.4572	.724	.4191	.381	.724
Avg	.6004	.6684	.7034	.9056	.8028	.8256	.8951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 310 / 22KV ALKALI GROUP (MANISH SHEDDABLE FEEDER HAVING WEEKLY
) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.1317	1.5242	1.6385	1.5089	1.5242	1.3717
2	1.5623	1.094	1.448	1.5623	1.4712	1.5242	1.3336
3	1.448	1.1317	1.4861	1.6766	1.5089	1.4861	1.3717
4	1.5242	1.0562	1.2955	1.6004	1.5466	1.4861	1.448
5	1.6004	1.4335	1.3717	1.5242	1.4712	1.3336	1.3717
6	1.5242	1.3957	1.2955	1.7528	1.8861	1.3717	1.5623
7	1.5242	1.3957	1.3336	1.7147	1.773	1.448	1.5623
8	1.2955	1.4712	1.2193	1.7528	1.7353	1.4861	1.6766
9	1.5623	1.5089	1.5623	1.8671	1.9616	1.5623	1.829
10	1.5242	1.7353	1.7528	2.2862	2.037	1.7909	1.9433
11	1.2826	2.1719	2.2862	2.3243	2.0957	1.8671	2.1502
12	1.4335	2.3243	2.2862	2.4387	2.1338	2.0576	1.9616
13	1.2826	1.829	2.0957	2.2634	1.9052	1.829	2.037
14	1.4335	2.0195	1.9814	2.2257	2.0195	1.829	1.8861
15	1.2826	2.0576	2.2481	2.3011	2.3243	2.0576	2.037
16	1.1317	2.0957	2.21	2.2257	2.0957	2.0576	1.773
17	1.2071	1.9052	1.9433	2.2634	2.0195	1.829	1.5466
18	1.2071	1.5623	1.7909	1.5466	1.9052	1.6766	1.4712
19	1.1317	1.5242	1.4861	1.6598	1.7147	1.5623	1.4335
20	1.1317	1.4861	1.5242	1.4335	1.5623	1.5242	1.358
21	1.0562	1.105	1.7147	1.358	1.448	1.2193	1.3957
22	1.0562	1.4861	1.6004	1.358	1.1431	1.3336	1.5089
23		1.5623	1.6766	1.5089	1.6004	1.5242	1.5089
24	1.5242	1.1694	1.4861	1.6004	1.4712	1.4098	1.3336
Max	1.6004	2.3243	2.2862	2.4387	2.3243	2.0576	2.1502
Min	1.0562	1.0562	1.2193	1.358	1.1431	1.2193	1.3336
Avg	1.3620	1.5689	1.6925	1.8285	1.7641	1.6163	1.6196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 311 / 22KV BALMER EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9239	1.4712	1.9791	2.0538	2.1502	1.8671
2	1.8861	1.5089	2.0538	1.9418	2.037	1.9044
3	1.8671	1.5466	2.1285	1.8671	1.9239	1.8298
4	1.7353	1.4335	1.8671	1.9418	1.8484	1.8671
5	1.8107	1.5089	1.9044	1.8298	1.773	1.7177
6	1.9239	1.5844	1.7924	1.9044	2.037	1.4563
7	1.6598	1.6598	1.4937	1.643	2.1125	1.3443
8	1.5466	1.8484	1.5684	1.8671	2.1502	
9	1.7353	1.8107	1.8671	2.3525	2.2257	
10	1.773	2.0748	1.9044	2.2779	2.1879	
11	1.6975	2.1658	2.2405	2.1285	2.1658	
12	1.7353	1.8671	1.7924	1.8671	2.2032	
13	1.773	1.9791	1.8298	1.9239	1.9418	
14	1.6975	2.1338	1.9044	1.8484	1.7924	
15	1.5466	2.2405	1.6057	1.7353	1.7177	
16	1.5089	2.2779	1.9418	1.773	1.8671	
17	1.4712	2.1658	1.643	1.6975	1.7177	
18	1.5466	2.0911	1.8298	1.773	1.8671	
19	1.358	1.8671	2.0165	1.6975	1.9418	
20	1.3957	1.8671	1.8298	1.7353	1.6804	
21	1.5466	1.6804	1.9044	1.9239	1.9044	
22	1.7353	1.8298	1.9418	2.1125	2.0538	
23		1.6057	1.5684		1.4563	
24	1.9993	1.5466	1.9418	2.1285	2.1125	1.9418
Max	1.9993	2.2779	2.2405	2.3525	2.2257	1.9418
Min	1.358	1.4335	1.4937	1.643	1.4563	1.3443
Avg	1.6901	1.8235	1.8562	1.9141	1.9528	1.7411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 202 / 11 KV 'L' WING DANA MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2229	.2402	.1886	.2229	.2378	.2572
2	.2229	.2058	.2195	.2058	.2058	.2195	.2401
3	.2229	.2058	.2197	.2058	.2058	.2012	.2401
4	.2058	.1886	.1829	.1886	.1886	.1829	.2229
5	.2058	.1715	.1646	.1715	.1715	.1646	.2229
6	.1886	.1543	.1463	.1372	.1543	.1463	.2058
7	.1543	.1372	.1463	.1543	.12	.1463	.1372
8	.1372	.1372	.1646	.1372	.1543	.1463	.1372
9	.1715	.2353	.1886	.2401	.2033	.1886	.1886
10	.1886	.4706	.4458	.463	.4024	.4458	.4755
11	.1886	.724	.6859	.7202	.7316	.7373	.7865
12	.2572	.8048	.7716	.8573	.8962	.7545	.8596
13	.2915	.8413	.7373	.8059	.8779	.7545	.8048
14	.2743	.8413	.7545	.7545	.8596	.8059	.823
15	.2572	.8779	.7888	.8916	.8596	.8059	.8238
16	.2915	.8962	.823	.8573	.905	.8745	.8417
17	.2401	.8869	.7888	.8402	.8779	.7888	.788
18	.2058	.8869	.7545	.7202	.8413	.7373	.6984
19	.2401	.8779	.7545	.583	.6584	.703	.7164
20	.2572	.6516	.5144	.4287	.5121	.7545	.4656
21	.2401	.3658	.3258	.2915	.3658	.3258	.3658
22	.2401	.2715	.2743	.2572	.5121	.2915	.2926
23	.2229	.2561	.2401	.2229	.2743	.2743	.2561
24	.2401	.2229	.2378	.2058	.2229	.2561	.2572
Max	.2915	.8962	.823	.8916	.905	.8745	.8596
Min	.1372	.1372	.1463	.1372	.12	.1463	.1372
Avg	.2244	.4806	.4404	.4387	.4760	.4560	.4628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 203 / 11 KV 'C' WING MASALA

SHEDDABLE URBAN

MARKET Feeder KV- 11 /
OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7202	.6838	.7888	.8059	.8048	.6859
2	.7888	.703	.6584	.6001	.7716	.8048	.6344
3	.7373	.6859	.6219	.5144	.7545	.7133	.5658
4	.6859	.6859	.5853	.5316	.7373	.6036	.583
5	.6687	.6687	.5853	.583	.7202	.6036	.6344
6	.6687	.6687	.695	.583	.6859	.5487	.7202
7	.6859	.6859	.7316	.6859	.6859	.567	.6687
8		.6859	.7499	.7545	.7373	.7499	.6687
9		1.0317	.9431	.9774	1.0349	.9088	.8745
10		1.3535	1.2689	1.1317	1.2752	1.2517	1.1888
11	.703	1.7194	1.6461	3.1207	2.1216	1.8519	1.6461
12	.8402	2.1765	2.0576	2.0233	2.1765		1.9753
13	.7202	2.2497	1.9547	2.0405	2.3228		2.1399
14	.7888	2.1033	2.0748	2.1091	2.2862	2.0576	2.1582
15	.8745	2.2131	2.0233	2.2291	2.3411	2.2462	2.0953
16	.7888	2.3045	1.9719	2.1776	2.1538	2.1262	2.073
17	.7545	2.1582	1.989	2.0233	1.957	2.1434	
18	.6859	1.9936	1.6461	1.6975	1.8107	1.869	1.7909
19	.7545	1.8839	1.6289	1.6289	1.5729	1.6975	1.6124
20	.8916	1.5546		1.3375	1.4632	1.3203	1.4529
21	.8573	1.1827	1.0288	1.0631	1.1523	1.0631	1.1584
22	.7888	.9877	.9774	.9259	1.0608	.9774	1.0608
23	.8059	.8326		.9088	1.0317	.8059	.9328
24	.8745	.7202	.9328	.703	.8745	.8145	.7373
Max	.8916	2.3045	2.0748	3.1207	2.3411	2.2462	2.1582
Min	.6687	.6687	.5853	.5144	.6859	.5487	.5658
Avg	.7708	1.3321	1.2479	1.2974	1.3556	1.2059	1.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 207 / 11 KV UTI SUB STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6235	2.5034	2.5606	2.5034	2.7778	2.7984	2.6578
2	2.5034	2.332	2.4143	2.3148	2.6749	2.6155	2.5034
3	2.3491	2.1776	2.2314	2.1948	2.6063	2.524	2.3834
4	2.1262	2.0576	2.1948	2.0748	2.3491	2.3045	2.1776
5	2.0576	2.0576	2.1216	1.989	2.2977	2.1948	2.0233
6	1.9547	2.0405	2.0485	1.9547	2.2291	2.1948	1.9719
7	1.8347	1.9547	2.0119	2.0919	2.0919	2.1399	1.9547
8	1.9204	1.869	1.9936	1.9719	1.8004	2.1033	1.9547
9	1.8861	2.0119	1.8861	1.9547	2.1807	1.9719	1.9719
10	1.8519	1.9909	1.9547	1.869	2.0485	1.989	2.0119
11	1.9376	1.9387	1.9033	1.8861	2.0119	1.8861	2.1176
12	2.0062	1.8107	1.8861	1.9547	1.9936		2.1582
13	1.9376	1.8839	1.8861	1.8347	2.0302		2.1216
14	1.9719	2.0668	1.9719	1.9547	2.1948	2.0576	2.268
15	2.0576	2.0271	1.989	2.1605	2.268	2.1434	2.3565
16	1.989	2.009	2.0233	2.0919	2.1538	2.1605	2.4356
17	1.7833	2.0485	2.0233	2.0576	2.1216	1.9547	2.2923
18	1.869	2.0668	1.9719	1.9547	2.0851	2.0576	2.1262
19	1.9719	2.0633	2.2634	2.4348	2.2081	2.1605	2.3282
20	2.0062	2.1948	2.2634	2.1776	2.4143	2.4348	2.3388
21	2.1605	2.4253	2.4006	2.3148	2.5158	2.5206	2.5339
22	2.1776	2.5423	2.7606	2.7606	2.7149	2.572	2.7252
23	2.6406	2.9264	2.9664	2.8978	3.2674	2.915	2.8532
24	2.7778	2.5034	2.963	2.9664	2.8121	3.0407	2.8121
Max	2.7778	2.9264	2.9664	2.9664	3.2674	3.0407	2.8532
Min	1.7833	1.8107	1.8861	1.8347	1.8004	1.8861	1.9547
Avg	2.0998	2.1459	2.1954	2.1819	2.327	2.3063	2.2949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 208 / 11 KV SUNVILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.406	1.4998	1.4403	1.5261	1.5729	1.3203
2	1.3375	1.3717	1.2437	1.3032	1.4403	1.3535	1.2517
3	1.2174	1.3203	1.1523	1.2174	1.3546	1.0425	1.1488
4	1.0974	1.2346	.8779	1.1488	1.3032	1.0242	1.0631
5	.9945	1.1317	.8048	1.046	1.166	1.0242	1.0117
6	1.8518	1.046	.823	.9774	1.0631	1.0242	.9945
7	1.7832	.9945	.8779	.9602	.9945	1.0242	.9088
8	.8059	.9602	.9511	1.7832	.9088	.9694	.9088
9	.823	1.0242	.9602	.9774	.9795	.9774	.8402
10	.8402	1.0498	.9945	.9945	.9877	.9945	1.0791
11	.9602	1.0425	.9945	1.0631	1.0242	1.046	1.0498
12	1.0117	.9877	.9088	.9945	1.0425	2.0234	1.0791
13	.9431	.9511	.9431	.9945	1.0425	2.1604	1.0608
14	1.2174	1.0059	.9945	1.0117	1.086	2.092	1.2254
15	1.2517	1.0498	1.0288	1.1488	1.1946	2.3662	1.134
16	1.1145	1.086	1.0631	1.0802	1.1888	2.1262	1.0985
17	1.0117	1.0974	.9774	.9602	1.1157	1.989	1.0924
18	.9259	1.0679	.8916	.8916	1.0425	1.046	1.0745
19	1.0117	1.0425	1.0974	.9945	1.0288	1.0974	1.2178
20	1.0974	1.2254	1.0974	1.1831	1.1888	1.1317	1.1999
21	1.1145	1.2127	1.2003	1.2003	1.3575	1.2689	1.2803
22	1.2517	1.39	1.4746	1.3889	1.4998	1.3203	1.39
23	1.406	1.5927	3.1894	1.6461	1.6651	1.5261	1.4998
24	1.5089	1.4575	1.6827	3.1894	1.5604	1.6827	1.4232
Max	1.8518	1.5927	3.1894	3.1894	1.6651	2.3662	1.4998
Min	.8059	.9511	.8048	.8916	.9088	.9694	.8402
Avg	1.1667	1.1562	1.1554	1.2331	1.1984	1.4118	1.1397