

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&M)[226] BU 0612

Substation No/ Name :- 124032 / 33/11 KV VELHALE

Feeder No / Name : 202 / 11 KV Velhale -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 09-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 17   | .8907     |
| Max  | .8907     |
| Min  | .8907     |
| Avg  | .8907     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124032 / 33/11 KV VELHALE

Feeder No / Name : 204 / 11 KV Shindi Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 17   | 1.1336    |
| Max  | 1.1336    |
| Min  | 1.1336    |
| Avg  | 1.1336    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124040 / 33/11 KV CHORWAD

Feeder No / Name : 203 / 11 KV Sunasgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | .6001     |
| 7    |           |           |           | .7545     |           |
| 8    |           |           |           | .8916     | .9088     |
| 15   |           |           | .3944     |           |           |
| 18   | .4805     | .4271     | .7458     |           |           |
| Max  | .4805     | .4271     | .7458     | .8916     | .9088     |
| Min  | .4805     | .4271     | .3944     | .7545     | .6001     |
| Avg  | .4805     | .4271     | .5701     | .8231     | .7545     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124040 / 33/11 KV CHORWAD

Feeder No / Name : 204 / 11 KV Kurha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           |           | .4973     |
| 7    |           |           |           |           | .703      |           |
| 8    |           |           |           |           |           | .7373     |
| 15   |           |           | .5316     |           |           |           |
| 18   | .4753     | .4753     | .423      |           |           |           |
| 20   |           |           |           | .088      |           |           |
| Max  | .4753     | .4753     | .5316     | .088      | .703      | .7373     |
| Min  | .4753     | .4753     | .423      | .088      | .703      | .4973     |
| Avg  | .4753     | .4753     | .4773     | .088      | .703      | .6173     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 202 / 11 KV BHUSAWAL CITY

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .0133     |           |           |           |
| 5    | .0171     |           | .0152     |           | .0171     | .0171     | .0171     |
| 8    | .0171     | .0171     | .0152     | .0133     | .0171     | .0171     | .0171     |
| 10   |           | .0533     |           |           |           |           |           |
| 11   | .0533     |           |           |           |           |           |           |
| 12   | .0133     | .0533     |           |           | .0133     | .061      | .0457     |
| 15   |           |           |           |           |           | .061      | .0133     |
| 16   | .0133     | .0133     | .0133     |           | .0133     |           | .0457     |
| 17   |           |           |           |           | .0533     |           |           |
| 18   |           |           | .061      |           |           |           |           |
| 19   |           | .061      |           |           |           |           |           |
| 20   | .0133     | .0457     | .0133     | .0171     | .0171     | .0533     | .061      |
| 21   |           |           |           | .0133     |           |           |           |
| 24   | .0171     |           | .0171     | .0133     | .0171     | .0171     | .0171     |
| Max  | .0533     | .061      | .061      | .0171     | .0533     | .061      | .061      |
| Min  | .0133     | .0133     | .0133     | .0133     | .0133     | .0171     | .0133     |
| Avg  | .0206     | .0406     | .0225     | .0141     | .0212     | .0378     | .031      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 203 / 11 KV SHANTINATH

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .1524     |           |           |           |
| 5    | .1372     |           | .1067     |           | .1524     | .1524     |           |
| 6    |           | .1219     |           |           |           |           |           |
| 8    | .1372     |           |           | .1524     | .1829     | .1829     | .1524     |
| 11   | .0934     |           |           |           |           |           |           |
| 12   | .1067     |           |           |           | .1524     | .1524     | .1524     |
| 15   |           |           |           |           |           | .1829     | .1677     |
| 16   | .1067     | .1677     | .1524     |           | .1829     | .1829     | .1677     |
| 17   |           |           |           |           | .4877     |           |           |
| 18   |           |           | .1677     |           |           |           |           |
| 19   |           | .1829     |           |           |           |           |           |
| 20   | .1524     | .1219     | .1219     | .1524     | .2058     | .1219     | .1524     |
| 21   |           |           |           | .1524     |           |           |           |
| 24   | .1372     |           | .1219     | .0914     | .1524     | .1524     | .1372     |
| Max  | .1524     | .1829     | .1677     | .1524     | .4877     | .1829     | .1677     |
| Min  | .0934     | .1219     | .1067     | .0914     | .1524     | .1219     | .1372     |
| Avg  | .1244     | .1486     | .1341     | .1402     | .2166     | .1611     | .1550     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 204 / 11 KV Railway Express

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .0133     |           |           |           |
| 8    |           |           |           | .0133     |           |           |           |
| 10   |           | .0133     |           |           |           |           |           |
| 11   | .0133     |           |           |           |           |           |           |
| 12   |           |           |           |           | .0133     | .0133     | .0133     |
| 15   |           |           |           |           |           | .0133     | .0133     |
| 16   |           |           | .0152     |           | .0133     | .0133     |           |
| 17   |           |           |           |           | .0133     |           |           |
| 18   |           |           | .0133     |           |           |           |           |
| 19   |           | .0133     |           |           |           |           |           |
| 20   |           | .0133     | .0133     |           |           |           | .0133     |
| 21   |           |           |           | .0133     |           |           |           |
| 24   |           |           |           | .0133     |           |           |           |
| Max  | .0133     | .0133     | .0152     | .0133     | .0133     | .0133     | .0133     |
| Min  | .0133     | .0133     | .0133     | .0133     | .0133     | .0133     | .0133     |
| Avg  | .0133     | .0133     | .0139     | .0133     | .0133     | .0133     | .0133     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 205 / 11 KV Sakegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .6097     |           |           |           |
| 5    | .5487     |           | .6001     |           | .6001     | .6516     | .583      |
| 6    |           | .5487     |           |           |           |           |           |
| 8    | .4877     | .5792     | .583      |           | .6859     | .6516     | .6859     |
| 10   |           | .6516     |           |           |           |           |           |
| 11   | .583      |           |           |           |           |           |           |
| 12   | .5144     | .5144     |           |           | .5182     | .583      | .5792     |
| 15   |           |           |           |           |           |           | .6097     |
| 16   | .583      | .6516     | .6097     |           | .5792     |           | .6249     |
| 17   |           |           |           |           | .6859     |           |           |
| 18   |           |           | .6706     |           |           |           |           |
| 19   |           | .5182     |           |           |           |           |           |
| 20   | .583      | .5182     | .5792     | .6173     | .5487     | .6173     | .5182     |
| 21   |           |           |           | .6173     |           |           |           |
| 24   | .583      |           | .583      | .5182     | .5487     | .6173     | .5144     |
| Max  | .583      | .6516     | .6706     | .6173     | .6859     | .6516     | .6859     |
| Min  | .4877     | .5144     | .5792     | .5182     | .5182     | .583      | .5144     |
| Avg  | .5547     | .5688     | .6043     | .5906     | .5952     | .6242     | .5879     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 206 / 11 KV MIDC PWW  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .4877     |           |           |           |
| 5    | .4801     |           | .4115     |           | .4458     | .4115     | .4458     |
| 6    |           | .3963     |           |           |           |           |           |
| 8    | .5487     | .5182     | .4287     | .4572     | .583      | .5487     | .4115     |
| 10   |           | .6173     |           |           |           |           |           |
| 11   | .5182     |           |           |           |           |           |           |
| 12   | .5144     | .6173     |           |           | .5487     | .5182     | .4572     |
| 15   |           |           |           |           |           | .583      | .3048     |
| 16   | .3048     | .5487     | .3658     |           | .4572     | .4572     | .4572     |
| 17   |           |           |           |           | .5144     |           |           |
| 18   |           |           | .3658     |           |           |           |           |
| 19   |           | .3658     |           |           |           |           |           |
| 20   | .4877     | .4877     | .3048     | .583      | .583      | .5487     | .3658     |
| 21   |           |           |           | .5182     |           |           |           |
| 24   | .4115     |           | .4115     | .4268     | .583      | .583      | .5487     |
| Max  | .5487     | .6173     | .4287     | .583      | .583      | .583      | .5487     |
| Min  | .3048     | .3658     | .3048     | .4268     | .4458     | .4115     | .3048     |
| Avg  | .4665     | .5073     | .3814     | .4946     | .5307     | .5215     | .4273     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 207 / 11kv WANJOLA ROAD  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .0133     |           |           |           |
| 5    | .0171     |           | .0114     |           | .0114     | .0114     | .0114     |
| 6    |           | .0171     |           |           |           |           |           |
| 8    | .0171     | .0171     | .0114     | .0133     | .0343     | .0114     | .0114     |
| 10   |           | .04       |           |           |           |           |           |
| 11   | .0133     |           |           |           |           |           |           |
| 12   | .0133     | .0267     |           |           | .0267     | .0152     | .0133     |
| 15   |           |           |           |           |           |           | .0267     |
| 16   | .0133     | .0133     | .061      |           | .0133     |           | .0457     |
| 17   |           |           |           |           | .0457     |           |           |
| 18   |           |           | .0133     |           |           |           |           |
| 19   |           | .0133     |           |           |           |           |           |
| 20   | .0133     | .0133     | .0133     | .0114     | .0171     | .0267     | .0133     |
| 21   |           |           |           | .0133     |           |           |           |
| 24   | .0171     |           | .0114     | .0133     | .0114     | .0114     | .0114     |
| Max  | .0171     | .04       | .061      | .0133     | .0457     | .0267     | .0457     |
| Min  | .0133     | .0133     | .0114     | .0114     | .0114     | .0114     | .0114     |
| Avg  | .0149     | .0201     | .0203     | .0129     | .0228     | .0152     | .0190     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124041 / 33/11 KV SAKEGAON

Feeder No / Name : 208 / 11KV Jogalkheda ( R ) SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .2439     |           |           |           |
| 5    | .2096     |           | .2        |           | .2        | .2743     | .2896     |
| 6    |           | .2096     |           |           |           |           |           |
| 8    | .2477     | .2286     | .1467     | .1829     |           | .3353     | .3658     |
| 10   |           | .0533     |           |           |           |           |           |
| 11   | .0667     |           |           |           |           |           |           |
| 12   | .0667     | .583      |           |           |           | .1524     | .0914     |
| 15   |           |           |           |           |           | .0914     | .1219     |
| 16   | .08       | .4115     | .2743     |           | .1219     | .0914     | .1219     |
| 17   |           |           |           |           | .08       |           |           |
| 18   |           |           | .3353     |           |           |           |           |
| 19   |           | .2134     |           |           |           |           |           |
| 20   | .1829     | .1524     | .1829     | .1334     | .0953     | .1829     | .1829     |
| 21   |           |           |           | .1524     |           |           |           |
| 24   | .2286     |           | .0934     | .1219     | .0934     | .2439     | .2743     |
| Max  | .2477     | .583      | .3353     | .2439     | .2        | .3353     | .3658     |
| Min  | .0667     | .0533     | .0934     | .1219     | .08       | .0914     | .0914     |
| Avg  | .1546     | .2645     | .2054     | .1669     | .1181     | .1959     | .2068     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124145 / 33/11 KV Kinh MIDC S/Stn.

Feeder No / Name : 202 / 11 KV KINHI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2597     |           |           |           |           |           | .2134     |
| 2    | .2591     |           |           |           |           |           | .2286     |
| 3    |           |           |           |           |           |           | .2591     |
| 4    |           |           |           |           |           |           | .2286     |
| 5    | .2107     |           |           |           |           |           | .2286     |
| 6    | .2088     |           |           |           |           | .325      | .2286     |
| 7    | .2841     | .3349     | .3182     | .3449     | .4194     | .3589     | .2439     |
| 8    | .2765     | .3697     | .3155     | .4211     | .2406     | .3637     | .0686     |
| 9    | .4115     | .4801     | .4287     | .3772     | .4458     | .679      | .1236     |
| 10   | .4287     | .5144     | .5658     | .4287     | .5144     | .6602     | .156      |
| 11   | .4458     | .4973     | .5658     | .463      | .5316     | .7545     |           |
| 12   | .5487     | .5316     | .5487     | .3353     | .4973     | .679      |           |
| 13   | .3772     | .5144     | .5316     | .3772     | .4801     | .6005     |           |
| 14   | .463      | .4973     | .583      | .3048     | .4801     | .6413     | .0918     |
| 15   | .4458     | .5144     | .5658     | .4973     | .4801     | .679      | .1265     |
| 16   | .3601     | .463      | .583      | .4458     | .5144     | .4444     | .1353     |
| 17   |           |           |           |           | .4458     | .5123     | .12       |
| 18   |           |           |           |           | .4115     | .4545     | .1082     |
| 19   |           |           |           |           | .3601     | .4668     | .1187     |
| 20   |           |           |           |           | .3258     | .3696     |           |
| 21   |           |           |           |           | .2743     | .2826     | .1566     |
| 22   |           |           |           |           | .2743     |           |           |
| 24   | .26       | .3542     | .3593     | .3737     | .4696     | .3471     | .2286     |
| Max  | .5487     | .5316     | .583      | .4973     | .5316     | .7545     | .2591     |
| Min  | .2088     | .3349     | .3155     | .3048     | .2406     | .2826     | .0686     |
| Avg  | .3493     | .4610     | .4878     | .3972     | .4215     | .5070     | .1703     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124145 / 33/11 KV Kinhi MIDC S/Stn.

Feeder No / Name : 203 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6543     |           |           |           |           |           | .6173     |
| 2    | .6435     |           |           |           |           |           | .583      |
| 3    | .6435     |           |           |           |           |           | .6001     |
| 4    | .8871     |           |           |           |           |           | .6516     |
| 5    | 1.0402    |           |           |           |           |           | .8402     |
| 6    | 1.2497    |           |           |           |           | 1.2087    | .9774     |
| 7    | 1.0402    | 1.0206    | .9259     | .888      | .9454     | .96       | .8573     |
| 8    | .7865     | .727      | .7247     | .7074     | .6753     | .7081     | .7202     |
| 9    | .6516     | .5487     | .583      | .5316     | .5316     | .6004     | .5916     |
| 10   | .583      | .4973     | .5316     | .4458     | .4973     | .5615     | .4945     |
| 11   | .5487     | .4458     | .5144     | .463      | .5144     | .5083     | .5111     |
| 12   | .5316     | .463      |           | .4458     | .5144     | .5645     | .5293     |
| 13   | .5316     | .4801     | .4801     | .4801     | .5144     | .5548     | .5985     |
| 14   | .5144     | .4973     | .5144     | .4973     | .5144     | .5548     | .5784     |
| 15   | .4973     |           | .5316     | .583      | .5144     | .5548     | .631      |
| 16   | .583      | .5316     | .583      | .6173     | .5658     | .5895     | .631      |
| 17   |           |           |           |           | .5658     | .6024     | .6516     |
| 18   |           |           |           |           | .6001     | .7164     | .6907     |
| 19   |           |           |           |           | .8059     | .8006     | .8048     |
| 20   |           |           |           |           | .8916     | .8213     |           |
| 21   |           |           |           |           | .823      | .8543     | .8697     |
| 22   |           |           |           |           | .8573     |           |           |
| 24   | .6842     | .7029     | .6992     | .7007     | .7036     | .7562     | .5944     |
| Max  | 1.2497    | 1.0206    | .9259     | .888      | .9454     | 1.2087    | .9774     |
| Min  | .4973     | .4458     | .4801     | .4458     | .4973     | .5083     | .4945     |
| Avg  | .7100     | .5914     | .6088     | .5782     | .6491     | .7010     | .6678     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124145 / 33/11 KV Kinh MIDC S/Stn.

Feeder No / Name : 204 / 11 KV KANHALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .155      |           |           |           |           |           | .1048     |
| 2    | .1578     |           |           |           |           |           | .1143     |
| 3    | .1571     |           |           |           |           |           | .1372     |
| 4    | .1827     |           |           |           |           |           | .1372     |
| 5    | .2085     |           |           |           |           |           | .1372     |
| 6    | .2196     |           |           |           |           | .1605     | .16       |
| 7    | .2625     |           |           |           | .3251     | .2318     | .2667     |
| 8    | .3508     |           |           |           | .3746     | .3358     | .3601     |
| 9    | .2858     |           |           |           | .3086     | .3288     |           |
| 11   |           | .2362     | .3334     | .3734     |           |           |           |
| 12   |           | .4134     | .3601     | .3734     |           |           |           |
| 13   |           | .4973     | .2629     | .3734     |           |           |           |
| 14   |           | .3201     | .2515     | .2286     |           |           |           |
| 15   |           | .2801     | .2286     | .3201     |           |           |           |
| 16   |           | .3067     | .2286     | .2534     |           |           |           |
| 24   | .1548     |           |           |           | .0967     | .0989     | .1486     |
| Max  | .3508     | .4973     | .3601     | .3734     | .3746     | .3358     | .3601     |
| Min  | .1548     | .2362     | .2286     | .2286     | .0967     | .0989     | .1048     |
| Avg  | .2135     | .3423     | .2775     | .3204     | .2763     | .2312     | .1740     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124145 / 33/11 KV Kinh MIDC S/Stn.

Feeder No / Name : 205 / KHADKA GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6235     |           |           |           |           |           | 1.0802    |
| 2    | .6281     |           |           |           |           |           | 1.1145    |
| 3    | .6193     |           |           |           |           |           | 1.0631    |
| 4    | .8248     |           |           |           |           |           | 1.0974    |
| 5    | .9145     |           |           |           |           |           | 1.1145    |
| 6    | .9877     |           |           |           |           | 1.5107    | 1.3546    |
| 7    | .9623     | .9088     | .9743     | .8179     | .8615     | 1.3915    | 1.2174    |
| 8    | .7913     | .697      | .7668     | .6315     | .7272     | 1.2059    | .9945     |
| 9    | .703      | .6687     | .6687     | .6001     | .6516     | 1.2437    | 1.0082    |
| 10   | .6687     | .6001     | .6344     | .6001     | .6173     | 1.2894    | 1.1157    |
| 11   | .6516     | .6001     | .6516     | .583      | .6344     | 1.3394    | 1.0791    |
| 12   | .6687     | .6173     | .6173     | .6173     | .6001     | 1.3575    | 1.1054    |
| 13   | .6687     |           | .6001     | .6344     | 1.1317    | 1.0667    | .9425     |
| 14   | .6516     | .6001     | .6344     | .5487     | 1.1831    | 1.2449    | 1.0062    |
| 15   | .6687     | .5658     |           | .6173     | 1.3889    | 1.1283    | 1.0674    |
| 16   | .6687     | .5487     | .7545     | .6516     | 1.286     | 1.1283    | 1.073     |
| 17   |           |           |           |           | 1.2346    | 1.2688    | .963      |
| 18   |           |           |           |           | 1.166     | 1.1935    | .9221     |
| 19   |           |           |           |           | 1.3203    | 1.1595    |           |
| 20   |           |           |           |           | 1.2689    | 1.3929    |           |
| 21   |           |           |           |           | 1.2174    | 1.366     | 1.1458    |
| 22   |           |           |           |           | 1.3032    |           |           |
| 24   | .6563     | .6591     | .7394     | .6858     | .7537     | 1.267     | 1.0631    |
| Max  | .9877     | .9088     | .9743     | .8179     | 1.3889    | 1.5107    | 1.3546    |
| Min  | .6193     | .5487     | .6001     | .5487     | .6001     | 1.0667    | .9221     |
| Avg  | .7269     | .6466     | .7042     | .6352     | 1.0203    | 1.2679    | 1.0764    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124145 / 33/11 KV Kinh MIDC S/Stn.

Feeder No / Name : 206 / Khadka Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           | .2783     | .2932     | .2692     |           |           |           |
| 8    |           | .3096     | .309      | .3141     |           |           |           |
| 9    |           | .2591     | .2591     | .2743     |           |           |           |
| 11   | .1829     |           |           | .2096     | .2667     | .5405     | .3278     |
| 12   | .3144     |           |           |           | .2591     | .3454     | .3567     |
| 13   | .3887     |           |           |           | .2591     | .3224     | .3292     |
| 14   | .2591     |           |           |           | .2667     | .298      | .3292     |
| 15   | .2667     |           |           |           | .2591     | .2865     | .2926     |
| 16   | .3239     |           |           |           | .2591     | .2865     | .3081     |
| 17   |           |           |           |           | .2591     | .3272     | .3395     |
| 18   |           |           |           |           | .2667     | .298      | .3057     |
| 24   |           | .1587     | .1909     | .1917     |           |           |           |
| Max  | .3887     | .3096     | .309      | .3141     | .2667     | .5405     | .3567     |
| Min  | .1829     | .1587     | .1909     | .1917     | .2591     | .2865     | .2926     |
| Avg  | .2893     | .2514     | .2631     | .2518     | .2620     | .3381     | .3236     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124167 / 33/11 kV KURHA PN.

Feeder No / Name : 201 / KURHA PN GAVATAHN NEW  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5647     | .5392     | .5607     | .499      | .4974     |           | .4795     |
| 5    |           |           |           |           |           | .501      |           |
| 8    | .5293     | .4907     | .4661     | .4544     | .5014     | .4582     | .4815     |
| 12   | .4202     | .3761     | .4387     | .3745     | .3844     | .3536     | .5759     |
| 16   | .4833     | .4058     | .4134     | .4602     | .4023     | .4363     | .5765     |
| 20   | .6355     | .5992     | .6375     | .6225     | .6557     | .6704     | .6199     |
| 22   |           | .5688     |           |           |           |           |           |
| 24   | .5365     | .5148     | .5527     | .476      | .5137     | .5132     | .5153     |
| Max  | .6355     | .5992     | .6375     | .6225     | .6557     | .6704     | .6199     |
| Min  | .4202     | .3761     | .4134     | .3745     | .3844     | .3536     | .4795     |
| Avg  | .5283     | .4992     | .5115     | .4811     | .4925     | .4888     | .5414     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL (E&amp;M)[226] BU 0612

Substation No/ Name :- 124167 / 33/11 kV KURHA PN.

Feeder No / Name : 203 / VARADSIM AG NEW

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .8937     | .7842     |           |           |           | .7764     |
| 5    |           |           |           |           | .7176     |           |
| 8    | 1.0047    | .8785     |           |           | .9568     | .888      |
| 12   |           | .8877     | .9465     | .9781     |           |           |
| 16   |           | .6424     | .8653     | .8905     |           |           |
| 24   | .831      | .762      |           |           | .71       | .7099     |
| Max  | 1.0047    | .8877     | .9465     | .9781     | .9568     | .888      |
| Min  | .831      | .6424     | .8653     | .8905     | .71       | .7099     |
| Avg  | .9098     | .7910     | .9059     | .9343     | .7948     | .7914     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124139 / 33/11 KV Nahata Chauk

Feeder No / Name : 201 / 11 KV TIMBER MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    | 2.9447    | 2.9813    | 3.0769    |           |           |           |           |
| 4    |           |           |           | 3.0407    | 2.3891    | 2.4977    | 2.4615    |
| 6    |           |           | 3.1131    |           | 2.4615    | 2.5158    | 2.4434    |
| 7    | 2.7801    | 2.9447    |           | 2.9683    | 2.2986    | 2.3167    | 2.2443    |
| 8    | 2.7984    | 2.7435    | 2.7692    |           |           | 2.3348    | 2.1719    |
| 9    | 2.9081    |           | 2.8054    |           |           |           |           |
| 10   |           | 2.9264    |           | 3.0407    |           | 2.3891    |           |
| 11   | 3.2739    |           | 2.9321    |           |           |           |           |
| 12   |           | 3.3471    | 3.095     | 3.4027    | 3.6561    | 3.4027    | 2.8054    |
| 13   | 3.3105    |           |           |           |           | 3.095     |           |
| 14   |           | 3.2556    |           |           | 3.2398    |           | 2.7692    |
| 15   | 3.3288    |           |           | 3.4027    |           | 2.8416    |           |
| 16   |           | 3.2739    |           |           | 3.095     | 2.8054    | 2.7692    |
| 17   | 3.3105    |           |           |           |           |           |           |
| 18   |           | 3.2217    | 3.5837    |           | 2.8959    | 2.7511    | 2.6968    |
| 19   | 3.7494    |           |           |           |           |           |           |
| 20   | 3.786     | 3.819     | 3.6176    | 2.3348    | 3.3303    | 3.3122    | 3.2217    |
| 22   | 3.4751    | 3.5656    | 3.5639    | 1.0498    | 3.0588    | 2.8778    |           |
| 23   |           |           |           |           |           |           | 2.7873    |
| 24   |           |           |           | 3.546     | 2.9683    | 2.7873    | 2.8054    |
| Max  | 3.786     | 3.819     | 3.6176    | 3.546     | 3.6561    | 3.4027    | 3.2217    |
| Min  | 2.7801    | 2.7435    | 2.7692    | 1.0498    | 2.2986    | 2.3167    | 2.1719    |
| Avg  | 3.2423    | 3.2079    | 3.1730    | 2.8482    | 2.9393    | 2.7636    | 2.6524    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124139 / 33/11 KV Nahata Chauk

Feeder No / Name : 202 / 11 KV PRERNA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    | .8417     | .8682     | .8328     |           |           |           |           |
| 4    |           |           |           | .8328     | .8328     | .9214     | .8682     |
| 6    |           |           | .7796     |           | .9214     | .9036     | .815      |
| 7    | .815      | .8682     |           | .9036     | .8505     | .8328     | .7796     |
| 8    | .7265     | .7442     | .7265     |           | .7619     | .7265     | .7619     |
| 9    | .7164     |           | .6733     |           |           |           |           |
| 10   |           | .6268     |           | .6447     | .6201     | .691      |           |
| 11   | .6626     |           | .5847     |           |           |           |           |
| 12   |           | .6447     | .6379     | .6805     | .6024     | .6379     | .7087     |
| 13   | .6626     |           |           |           |           | .6733     |           |
| 14   |           | .6984     | .7265     |           | .6556     |           | .7619     |
| 15   | .7522     |           |           | .7442     |           | .7442     |           |
| 16   |           | .7522     | .7619     |           | .7087     | .7619     | .8328     |
| 17   | .6805     |           |           | .7442     |           |           |           |
| 18   |           | .7265     | .703      |           | .7265     | .691      | .7442     |
| 19   | .8596     |           |           | .7619     |           |           |           |
| 20   | .8954     | .8505     | .8745     | .8682     | .8682     | .8859     | .8505     |
| 22   | .985      | .9745     | .9709     | .9922     | 1.0631    | 1.0985    |           |
| 23   |           |           |           |           |           |           | 1.0808    |
| 24   |           |           |           | .9882     | .9745     | 1.1163    | 1.134     |
| Max  | .985      | .9745     | .9709     | .9922     | 1.0631    | 1.1163    | 1.134     |
| Min  | .6626     | .6268     | .5847     | .6447     | .6024     | .6379     | .7087     |
| Avg  | .7816     | .7754     | .7520     | .8161     | .7988     | .8219     | .8489     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124139 / 33/11 KV Nahata Chauk

Feeder No / Name : 204 / 11 KV Vikas Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    | 2.5701    | 2.7149    |           |           |           |           |           |
| 4    |           |           |           | 2.7149    | 2.6787    | 2.7149    |           |
| 6    |           |           |           |           | 2.7511    | 2.7149    |           |
| 7    |           | 2.6063    |           | 2.5701    | 2.5339    | 2.6425    |           |
| 8    |           | 2.371     |           |           | 2.4253    | 2.4072    | 2.5701    |
| 10   |           |           |           | 2.2443    | 2.2443    | 2.6787    |           |
| 12   | 2.3348    |           |           | 2.4253    | 2.371     | 2.5158    | 2.3891    |
| 13   |           |           |           |           |           | 2.4977    |           |
| 14   | 2.4796    |           |           |           | 2.4977    |           | 2.6968    |
| 15   |           |           |           | 2.6063    |           | 2.6787    |           |
| 16   | 2.6063    |           |           |           | 2.6606    | 2.7149    | 2.7873    |
| 17   |           |           |           | 2.4796    |           |           |           |
| 18   | 2.3891    | 2.4977    | 2.552     |           | 2.4977    | 2.5701    | 2.4434    |
| 19   |           |           |           | 2.7692    |           |           |           |
| 20   | 2.8597    | 2.914     | 2.9683    | 2.914     | 3.0769    |           | 2.9321    |
| 22   | 3.276     | 3.2579    | 3.3303    | 3.3122    | 3.4027    |           |           |
| 23   |           |           |           |           |           |           | 3.276     |
| 24   |           |           |           | 3.2217    | 3.2036    | 3.3122    |           |
| Max  | 3.276     | 3.2579    | 3.3303    | 3.3122    | 3.4027    | 3.3122    | 3.276     |
| Min  | 2.3348    | 2.371     | 2.552     | 2.2443    | 2.2443    | 2.4072    | 2.3891    |
| Avg  | 2.6451    | 2.7270    | 2.9502    | 2.7258    | 2.6953    | 2.6771    | 2.7278    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB  
STATIFeeder No / Name : 201 / Railway Express Bhusawal  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .9858     | 1.0426    | 1.2701    |           | 1.2701    | 1.1753    | 1.2322    |
| 4    | 1.1753    | 1.1564    | 1.2701    | 1.2511    | 1.308     | 1.2511    | 1.2701    |
| 6    | 1.2511    | 1.2322    | 1.2132    | 1.1564    | .9668     | 1.0237    | 1.0805    |
| 8    | 1.1184    | 1.1374    | 1.1753    | 1.0995    | 1.0995    | 1.1184    | 1.2132    |
| 10   | .3223     | 1.3459    | 1.5165    | .6445     | 1.3459    | 1.3459    | 1.2891    |
| 12   | 1.1943    | 1.4028    | 1.4786    | 1.2511    | 1.308     | 1.4218    | 1.0047    |
| 14   | 1.2322    | 1.2132    | 1.0426    | 1.2132    | 1.1184    | 1.2322    | 1.0047    |
| 16   | 1.1943    | 1.1943    | 1.4028    | 1.4597    | 1.3838    | 1.5545    | 1.2891    |
| 18   | 1.1374    | 1.2701    | 1.327     | 1.2701    | 1.2701    | 1.327     | 1.1374    |
| 20   | 1.1564    | 1.1943    |           | 1.1753    | 1.0805    | 1.1943    |           |
| 22   | 1.1753    | 1.0426    | 1.1184    | 1.1184    |           | 1.2891    | 1.0995    |
| 23   | 1.1753    |           |           |           | 1.2322    |           |           |
| 24   | 1.2132    | 1.1753    | 1.1564    | 1.2511    | 1.2132    | 1.308     | 1.2511    |
| Max  | 1.2511    | 1.4028    | 1.5165    | 1.4597    | 1.3838    | 1.5545    | 1.2891    |
| Min  | .3223     | 1.0426    | 1.0426    | .6445     | .9668     | 1.0237    | 1.0047    |
| Avg  | 1.1024    | 1.2006    | 1.2701    | 1.1719    | 1.2164    | 1.2701    | 1.1701    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB

STATI

Feeder No / Name : 202 / TAPINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .9059     | .8697     | .8688     | .9107     | .9031     | .8869     | .9221     |
| 4    | .7972     | .8516     | .8507     | .8378     | .8317     | .8507     | .8859     |
| 6    | .8162     | .8878     | .8516     | .8934     | .8145     | .8326     | .8498     |
| 8    | .7799     | .7429     | .7791     | .765      | .7602     | .7964     | .7594     |
| 10   | .8334     | .8153     | .8145     | .8887     | .8317     | .8326     | .8679     |
| 12   | .8878     | .9603     | .9412     | .9583     | 1.0125    | 1.0125    | .9221     |
| 14   | .9603     | .9412     | .9412     | .9753     | .9572     | 1.0125    | .904      |
| 16   | .924      | 1.0136    | 1.0136    | 1.0295    | 1.0295    | 1.0848    | .9402     |
| 18   | .9422     | .9231     | .8869     | 1.0273    | .9753     | .9753     | .8859     |
| 20   | 1.0509    | 1.1765    |           | 1.0994    | 1.0656    | 1.174     |           |
| 22   | .9965     | 1.0679    | 1.0509    | 1.0465    |           | 1.1017    | 1.0487    |
| 23   |           |           |           |           | 1.1017    |           |           |
| 24   | .9965     | .9784     | .9955     | 1.036     | .9934     | 1.0125    | 1.0656    |
| Max  | 1.0509    | 1.1765    | 1.0509    | 1.0994    | 1.1017    | 1.174     | 1.0656    |
| Min  | .7799     | .7429     | .7791     | .765      | .7602     | .7964     | .7594     |
| Avg  | .9076     | .9357     | .9085     | .9557     | .9397     | .9644     | .9138     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB

STATI

Feeder No / Name : 203 / COURT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .988      | .988      | 1.0398    | 1.0476    | 1.0409    | 1.042     | 1.0585    |
| 4    | .8997     | .8997     | .9516     | .9588     | .9537     | 1.0136    | 1.0056    |
| 6    | .935      | .988      | 1.0232    | .9954     | .9724     | .9901     | .988      |
| 8    | .8468     | .8292     | .8821     | .8701     | .8487     | .8487     | .8645     |
| 10   | .8292     | .9174     | .8115     | .8505     | .8831     | 1.0597    | .8468     |
| 12   | .8292     | .9869     | .9164     | .8831     | .8997     | 1.0232    | .8812     |
| 14   | .9174     | .934      | .9516     | .9174     | .9527     | 1.0409    | .9164     |
| 16   | .9174     | .9516     | .9164     | .9703     | .9693     | .9869     | 1.0045    |
| 18   | .8635     | .8988     | .8659     | .9506     | .9164     | .8812     | 1.0045    |
| 20   | 1.0574    | 1.0398    |           | 1.143     | 1.1103    | 1.1631    |           |
| 22   | 1.1807    | 1.216     | 1.2283    | 1.2499    |           | 1.2689    | 1.1984    |
| 23   |           |           |           |           | 1.2689    |           |           |
| 24   | 1.1115    | 1.1467    | 1.1103    | 1.1682    | 1.182     | 1.1644    | 1.216     |
| Max  | 1.1807    | 1.216     | 1.2283    | 1.2499    | 1.2689    | 1.2689    | 1.216     |
| Min  | .8292     | .8292     | .8115     | .8505     | .8487     | .8487     | .8468     |
| Avg  | .9480     | .9830     | .9725     | 1.0004    | .9998     | 1.0402    | .9986     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB

STATI

Feeder No / Name : 204 / SHANTINAGAR BHUSAWAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .3239     | .3239     | .3239     | .3239     | .3239     | .3429     | .362      |
| 4    | .2667     | .2477     | .2858     | .2858     | .3048     | .2858     | .3048     |
| 6    | .2477     | .2477     | .2858     | .2858     | .2477     | .2667     | .2477     |
| 8    | .2667     | .2477     | .2477     | .2477     | .2477     | .2667     | .2477     |
| 10   | .2477     | .2667     | .2667     | .2286     | .2667     | .2667     | .2477     |
| 12   | .2096     | .2477     | .2477     | .2477     | .2477     | .2667     | .2667     |
| 14   | .2858     | .2477     | .2858     | .2667     | .2477     | .2667     | .2858     |
| 16   | .2858     | .2858     | .2858     | .2858     | .2858     | .2858     | .3048     |
| 18   | .2477     | .2286     | .2667     | .2477     | .2286     | .2858     | .2858     |
| 20   | .3239     | .3239     |           | .3429     | .362      | .362      |           |
| 22   | .381      | .4382     | .4191     | .4191     |           | .4191     | .4382     |
| 23   | .381      |           |           |           | .4382     |           |           |
| 24   | .381      | .381      | .4001     | .4001     | .381      | .4191     | .4382     |
| Max  | .381      | .4382     | .4191     | .4191     | .4382     | .4191     | .4382     |
| Min  | .2096     | .2286     | .2477     | .2286     | .2286     | .2667     | .2477     |
| Avg  | .2960     | .2906     | .3014     | .2985     | .2985     | .3112     | .3118     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB

STATI

Feeder No / Name : 205 / JALGAONNAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.0994    | 1.0983    | 1.1343    | 1.1727    | 1.169     | 1.1883    | 1.2063    |
| 4    | 1.0093    | 1.0082    | 1.0622    | 1.1017    | 1.0442    | 1.1163    | 1.1343    |
| 6    | 1.0273    | 1.0814    | 1.0983    | 1.1041    | 1.0994    | 1.1355    | 1.0802    |
| 8    | .9372     | .9012     | .8822     | 1.0317    | .9192     | .9192     | .9362     |
| 10   | .8831     | .757      | .8102     | .848      | .8282     | .8291     | .8822     |
| 12   | .9012     | .8462     | .8822     | .8282     | .8273     | .9002     | .9362     |
| 14   | .9542     | .9182     | .9722     | .9712     | .9712     | 1.0262    | 1.0431    |
| 16   | .9542     | .9362     | .9722     | 1.042     | 1.0252    | 1.0611    | 1.1151    |
| 18   | .9362     | .9722     | .9619     | .9681     | .9881     | 1.0072    | 1.0431    |
| 20   | 1.1703    | 1.1343    |           | 1.2357    | 1.2037    | 1.2217    |           |
| 22   | .8642     | 1.4043    | 1.4963    | 1.4163    |           | 1.5107    |           |
| 23   |           |           |           |           | 1.4779    |           |           |
| 24   | 1.2423    | 1.2783    | 1.2963    | 1.3654    | 1.2936    | 1.3669    | 1.3669    |
| Max  | 1.2423    | 1.4043    | 1.4963    | 1.4163    | 1.4779    | 1.5107    | 1.3669    |
| Min  | .8642     | .757      | .8102     | .8282     | .8273     | .8291     | .8822     |
| Avg  | .9982     | 1.0280    | 1.0517    | 1.0904    | 1.0706    | 1.1069    | 1.0744    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BHUSAWAL U-I S/DN.[225] BU 0621

Substation No/ Name :- 124150 / 33kv/11kv TAPI NAGAR SUB

STATI

Feeder No / Name : 206 / GANESH COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .8291     | .8282     | .8642     | .8943     | .8906     | .8813     | .8822     |
| 4    | .775      | .7382     | .8102     | .8213     | .8196     | .7922     | .8282     |
| 6    | .8651     | .7742     | .8642     | .8587     | .9289     | .8471     | .8282     |
| 8    | .8471     | .7022     | .7382     | .7118     | .8213     | .739      | .7202     |
| 10   | .793      | .6301     | .6662     | .6914     | .7232     | .6662     | .7562     |
| 12   | .811      | .6481     | .7022     | .6711     | .7562     | .6842     | .7382     |
| 14   | .8462     | .6842     | .7742     | .7421     | .7905     | .7194     | .8453     |
| 16   | .8462     | .7202     | .7922     | .7775     | .8435     | .8085     | .8813     |
| 18   | .7202     | .7382     | .8002     | .7766     | .8426     | .8085     | .8273     |
| 20   | .9182     | .9002     |           | .9104     | .985      | .9332     |           |
| 22   | 1.0622    | 1.0082    | 1.1075    | 1.0656    |           | 1.042     | 1.0431    |
| 23   |           |           |           |           | 1.0983    |           |           |
| 24   | .9192     | .9362     | .9542     | .9965     | .9815     | 1.0093    | 1.0072    |
| Max  | 1.0622    | 1.0082    | 1.1075    | 1.0656    | 1.0983    | 1.042     | 1.0431    |
| Min  | .7202     | .6301     | .6662     | .6711     | .7232     | .6662     | .7202     |
| Avg  | .8527     | .7757     | .8249     | .8264     | .8734     | .8276     | .8507     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 201 / 11 KV Nadgaon-Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .12       | .1372     | .12       | .1029     | .12       | .12       | .0857     |
| 2    | .12       | .1372     | .12       | .1029     | .12       | .1029     | .0857     |
| 3    | .12       | .1372     | .12       | .1029     | .12       | .1029     | .0857     |
| 4    | .1372     | .1372     | .1372     | .1029     | .1372     | .1029     | .4287     |
| 5    | .1543     | .1372     | .1372     | .12       | .1372     | .12       | .4287     |
| 6    | .1372     | .1543     | .1715     | .1372     | .1543     | .1372     | .1029     |
| 7    | .1372     | .1372     | .1543     | .1715     | .1715     | .1029     | .0857     |
| 8    | .0857     | .12       | .12       | .12       | .12       | .1372     | .0857     |
| 9    | .0857     | .0857     | .0857     | .1029     | .1029     | .12       | .0857     |
| 10   | .0343     | .0857     | .0857     | .0857     | .1029     | .1029     | .0857     |
| 11   | .0343     | .0857     | .0857     | .0686     | .1029     | .0857     | .1029     |
| 12   | .0857     | .0857     | .0857     | .0686     | .1029     | .0857     | .0857     |
| 13   | .0857     | .0857     | .0857     | .0686     | .0857     | .1029     | .0857     |
| 14   | .0857     | .0857     | .0857     | .0857     | .1029     | .1029     | .1029     |
| 15   | .0857     | .0343     | .0857     | .0857     | .0857     | .0857     | .0686     |
| 16   | .0857     | .0857     | .0857     | .1029     | .0857     | .0686     | .0686     |
| 17   | .12       | .12       | .0857     | .1029     | .0857     | .0857     |           |
| 18   | .1372     | .1372     | .1372     | .1372     | .0857     | .1029     | .0857     |
| 19   | .1543     | .1543     | .1543     | .1543     | .0857     | .12       | .0857     |
| 20   | .1715     | .12       | .1543     | .1543     | .0343     | .1543     | .0857     |
| 21   | .1543     | .12       | .1543     | .1543     | .0857     | .1543     | .0857     |
| 22   | .1372     | .1372     | .1372     | .1372     | .1715     | .0857     | .1543     |
| 23   | .1372     | .1372     |           | .1372     | .1543     | .0857     | .1543     |
| 24   | .12       | .1372     | .1372     | .12       | .12       | .12       | .0857     |
| Max  | .1715     | .1543     | .1715     | .1715     | .1715     | .1543     | .4287     |
| Min  | .0343     | .0343     | .0857     | .0686     | .0343     | .0686     | .0686     |
| Avg  | .1136     | .1165     | .1185     | .1136     | .1114     | .1079     | .1222     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 202 / 11 KV BODWAD URBAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5432    | 1.6461    | 1.7147    | 1.5775    | 1.6975    | 1.7833    | .9431     |
| 2    | 1.5261    | 1.5775    | 1.6804    | 1.5432    | 1.6804    | 1.7318    | 1.1145    |
| 3    | 1.5604    | 1.5775    | 1.6632    | 1.5432    | 1.6804    | 1.7147    | 1.1145    |
| 4    |           | 1.6632    | 1.6461    | 1.5947    | 1.7147    | 1.7147    | 1.1145    |
| 5    | 1.5432    | 1.6804    | 1.7318    | 1.6804    | 1.749     | 1.6461    | 1.1145    |
| 6    | 1.9719    | 2.0062    | 1.8004    | 1.749     | 1.8519    | 1.7147    | 1.1145    |
| 7    | 1.9719    | 1.8004    | 1.9204    | 1.869     | 1.989     | 1.8004    | 1.1145    |
| 8    | 1.749     | 1.7147    | 1.6461    | 1.4746    | 1.6975    |           | 1.1145    |
| 9    | 1.1145    | 1.1145    | 1.1145    |           | 1.6804    | 1.9376    | 1.5775    |
| 10   | .9431     | 1.1145    | 1.1145    |           | 1.3889    | 1.7147    | 1.6632    |
| 11   | 1.1145    | .9431     | 1.1145    | 1.6804    | 1.6461    | 1.6461    | 1.5261    |
| 12   | 1.1145    | 1.1145    | .9431     | 1.7661    | 1.6461    | 1.6289    | 1.5432    |
| 13   | 1.1145    | .9431     | 1.1145    | 1.6804    |           | 1.6804    | 1.5775    |
| 14   | 1.1145    | 1.1145    | 1.1145    | 1.5604    | 1.5089    | 1.5261    | 1.4918    |
| 15   |           | 1.1145    | 1.1145    | 1.6118    | 1.749     | 1.286     | 1.6118    |
| 16   | 1.1145    | 1.1145    | 1.1145    | 1.6289    | 1.7147    | 1.4575    | 1.6118    |
| 17   | 1.7147    | 1.6289    | 1.6632    | 1.7147    | 1.1145    | 1.5432    | 1.1145    |
| 18   | 1.6975    | 1.5947    | 1.7833    | 1.7147    | 1.1145    | 1.6632    | 1.1145    |
| 19   | 1.8347    | 1.7833    | 1.8176    | 1.8519    | 1.1145    | 1.8004    | 1.1145    |
| 20   | 1.869     | 1.8519    | 1.8519    | 1.8519    | 1.1145    | 1.9033    | 1.1145    |
| 21   | 1.7833    | 1.8004    | 1.7833    | 1.8519    | 1.1145    | 1.9547    | 1.1145    |
| 22   | 1.869     | 1.7833    | 1.8519    | 1.8347    | 1.9033    | 1.1145    | 1.9376    |
| 23   | 1.5775    | 1.749     |           | 1.8347    | 1.869     | 1.1145    | 1.6804    |
| 24   | 1.5775    | 1.5947    | 1.7318    | 1.6289    | 1.7833    | 1.8347    | 1.1145    |
| Max  | 1.9719    | 2.0062    | 1.9204    | 1.869     | 1.989     | 1.9547    | 1.9376    |
| Min  | .9431     | .9431     | .9431     | 1.4746    | 1.1145    | 1.1145    | .9431     |
| Avg  | 1.5190    | 1.5011    | 1.5231    | 1.6929    | 1.5879    | 1.6483    | 1.3189    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 203 / 11 KV Salshingi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 14-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 2    | .0191     |
| Max  | .0191     |
| Min  | .0191     |
| Avg  | .0191     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 204 / 11 KV Selwad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3944     | .3772     | .3086     | .3429     | .3429     | .3429     | .4287     |
| 2    | .3772     | .3772     | .3429     | .3429     | .3429     | .3429     | .4287     |
| 3    | .3944     | .3772     | .3429     | .3429     | .3429     | .3429     | .4287     |
| 4    | .4115     | .3772     | .3429     | .3772     | .3429     | .3772     | .4287     |
| 5    | .4287     | .3772     | .3772     | .3944     | .3772     | .4458     | .4287     |
| 6    | .5658     | .5144     | .4115     |           | .4458     | .5487     | .4287     |
| 7    | .5658     | .5144     | .3772     | .5144     | .5144     | .6859     | .4287     |
| 8    | .5144     | .3772     | .3429     | .4287     | .3429     | .5144     | .4287     |
| 9    | .0343     | .4287     | .4287     | .3772     | .3429     | .3429     | .3429     |
| 10   | .4287     | .4287     | .4287     | .2858     | .3429     | .3429     | .3429     |
| 11   | .4287     | .4287     | .4287     | .3772     | .3429     | .3429     | .3429     |
| 12   | .4287     | .4287     | .4287     | .3944     | .3429     | .3429     | .3429     |
| 13   | .4287     | .4287     | .4287     | .4115     | .3429     | .3429     | .3429     |
| 14   | .4287     | .4287     | .4287     | .4287     | .3429     | .3429     | .1715     |
| 15   | .4287     | .4287     | .4287     | .4287     | .3429     | .1715     | .1715     |
| 16   | .4287     | .4801     | .4287     | .3772     | .3429     | .1715     | .3429     |
| 17   |           | .4801     | .4115     | .3772     |           | .3086     | .4287     |
| 18   | .3429     | .3429     | .4801     | .3429     | .4287     | .3429     | .4287     |
| 19   | .3772     | .3601     | .5144     | .4801     | .4287     | .3429     | .4287     |
| 20   | .4115     | .4115     | .3944     | .4115     | .4287     | .3772     | .4287     |
| 21   | .3429     | .3429     | .4458     | .4458     | .4287     | .3429     | .4287     |
| 22   | .3429     | .3429     | .3772     | .3086     | .3429     | .4287     | .3429     |
| 23   | .3772     | .3429     |           | .3429     | .3429     | .4287     | .5144     |
| 24   | .3772     | .3772     | .3429     | .3429     | .3429     | .3429     | 1.1145    |
| Max  | .5658     | .5144     | .5144     | .5144     | .5144     | .6859     | 1.1145    |
| Min  | .0343     | .3429     | .3086     | .2858     | .3429     | .1715     | .1715     |
| Avg  | .4026     | .4072     | .4018     | .3859     | .3712     | .3715     | .4144     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 205 / 11 KV Jamathi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2401     | .3086     | .3429     | .3429     | .1886     | .1886     | .4287     |
| 2    | .2229     | .3086     | .3601     | .3429     | .1886     | .1886     | .4287     |
| 3    | .2229     | .3086     | .3601     | .3772     | .2058     | .1886     | .4287     |
| 4    | .2401     | .2572     | .3772     | .4115     | .2058     | .2058     | .4287     |
| 5    | .2572     | .3429     | .3944     | .3772     | .2401     | .2401     | .4287     |
| 6    | .3944     | .5144     | .4287     | .3944     | .2743     | .2915     | .4287     |
| 7    | .3772     | .4801     | .463      | .4287     | .3086     | .3258     | .4287     |
| 8    | .3429     | .2915     | .3772     | .3601     | .3601     | .3429     | .4287     |
| 9    | .4287     | .4287     | .4287     | .1543     | .2743     | .2743     | .2915     |
| 10   | .4287     | .4287     | .4287     | .2743     | .2915     | .2401     | .2401     |
| 11   | .4287     | .4287     | .4287     | .2572     | .2401     | .2572     | .2572     |
| 12   | .4287     |           | .4287     | .2229     | .2229     | .2401     | .2572     |
| 13   | .4287     | .4287     | .4287     | .2401     | .2572     | .2572     | .2572     |
| 14   | .4287     | .4287     | .4287     | .2058     | .2229     | .2743     | .2743     |
| 15   | .4287     | .4287     | .4287     | .2229     | .2401     | .2572     | .3086     |
| 16   | .4287     | .4287     | .4287     | .1886     | .2743     | .2743     | .3086     |
| 17   |           | .3086     | .2229     | .2401     | .4287     | .2572     | .4287     |
| 18   | .3258     | .3086     | .3086     | .2743     | .4287     | .2572     | .4287     |
| 19   | .3772     | .3772     | .4458     | .3944     | .4287     | .3429     | .4287     |
| 20   | .4287     | .4458     | .3772     | .4458     | .4287     | .463      | .4287     |
| 21   | .4115     | .3772     | .4115     | .3772     | .4287     | .4287     | .4287     |
| 22   | .3772     | .3944     | .3944     | .1886     | .1886     | .4287     | .2229     |
| 23   | .3086     | .3772     |           | .1886     | .1886     | .4287     | .2229     |
| 24   | .2743     | .3086     | .3429     | .3601     | .1886     | .1886     | .4287     |
| Max  | .4287     | .5144     | .463      | .4458     | .4287     | .463      | .4287     |
| Min  | .2229     | .2572     | .2229     | .1543     | .1886     | .1886     | .2229     |
| Avg  | .3579     | .3787     | .3929     | .3029     | .2794     | .2851     | .3601     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 206 / 11 KV Nadgaon-Pure Ag.-

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6516     | .6516     |           |           |           |           |
| 2    |           | .6516     | .6173     |           |           |           |           |
| 3    |           | .6859     | .6173     |           |           |           |           |
| 4    |           | .823      | .6173     |           |           |           |           |
| 5    |           | .823      | .6859     |           |           |           |           |
| 6    |           | .823      | .7888     |           |           |           |           |
| 7    |           | .8573     | .8573     | .3429     |           |           |           |
| 10   |           |           |           |           |           | .8573     | .9602     |
| 11   | 1.1145    |           |           |           |           | .8916     | .8059     |
| 12   | 1.1145    |           |           |           |           | .9602     | .823      |
| 13   | 1.1145    |           |           |           | .8573     | .823      | .823      |
| 14   | 1.1145    |           |           |           | .7202     | .4287     | .7373     |
| 15   | 1.1145    |           |           |           | .823      | .4287     | .7716     |
| 16   | .7716     |           |           |           | .823      | .463      | .823      |
| 17   | .6859     |           |           |           |           | .6859     | .6859     |
| 22   | .5487     | .6859     | .6859     |           |           |           |           |
| 23   | .5487     | .6859     |           |           |           |           |           |
| 24   |           | .5487     | .6859     |           |           |           |           |
| Max  | 1.1145    | .8573     | .8573     | .3429     | .8573     | .9602     | .9602     |
| Min  | .5487     | .5487     | .6173     | .3429     | .7202     | .4287     | .6859     |
| Avg  | .9030     | .7236     | .6897     | .3429     | .8059     | .6923     | .8037     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124024 / 33/11 KV BODWAD S/STN

Feeder No / Name : 207 / BODWAD INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .823      | .7545     | .7888     | .4115     | .5144     | .8916     | 1.1145    |
| 2    | .8059     | .7716     | .7888     | .4115     | .5144     | .8573     | 1.1145    |
| 3    | .8402     | .7202     | .7888     | .4287     | .5144     | .8573     | 1.1145    |
| 4    | .7716     | .8916     | .7716     | .4458     | .4973     | .823      | 1.1145    |
| 5    | .7888     | .8573     | .7202     | .4458     | .4801     | .7888     | 1.1145    |
| 6    | .7545     | .8402     | .6859     | .5144     | .4801     | .7373     | 1.1145    |
| 7    | .7545     | .4973     | .6001     | .5658     | .4801     | .703      | 1.1145    |
| 8    | .6173     | .4801     | .4458     | .3772     | .7716     | .703      | .4287     |
| 9    | .4287     | .0857     | .4287     | .5144     | .823      | .6001     | .9259     |
| 10   | .0857     | .4287     | .4287     | .5144     | .8916     | .8402     | .8573     |
| 11   | .4287     | .4287     | .0857     | .5144     | .7716     | .8059     | 1.0802    |
| 12   | .4287     | .4287     | .4287     | .5316     | .823      | .8059     | 1.0974    |
| 13   | .4287     | .4287     | .4287     | .5487     | .8059     | .823      | 1.0631    |
| 14   | .4287     | .4287     | .4287     | .5658     | .6173     | .8573     | .823      |
| 15   | .4287     | .4287     | .4287     | .4973     | 1.0974    | .8059     | 1.046     |
| 16   | .4287     | .4287     | .4287     | .3601     | .9602     | .7888     | 1.0117    |
| 17   | .5658     | .6173     | .8573     | .2743     | .4287     | .7888     | .4287     |
| 18   | .5658     | .583      | .8059     | .2401     | .4287     | .7888     | .4287     |
| 19   | .6516     | .5316     | .5658     | .2401     | .4287     | .7202     | .4287     |
| 20   | .7545     | .5144     | .8916     | .2572     | .0857     | .6859     | .4287     |
| 21   | .8573     | .5144     | 1.0288    | .4287     | .4287     | .8402     | .4287     |
| 22   | .8573     | .8573     | 1.046     | .463      | .8573     | .4287     | .8745     |
| 23   | .823      | .823      |           | .5316     | .9259     | .4287     | .7716     |
| 24   | .8573     |           | .823      |           | .5144     | .9088     | 1.1145    |
| Max  | .8573     | .8916     | 1.046     | .5658     | 1.0974    | .9088     | 1.1145    |
| Min  | .0857     | .0857     | .0857     | .2401     | .0857     | .4287     | .4287     |
| Avg  | .6323     | .5800     | .6389     | .4384     | .6309     | .7616     | .8766     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124025 / 33/11 KV ENGAON

Feeder No / Name : 201 / 11 KV Engaon-Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2715     | .2957     | .2772     | .2378     | .2743     | .2896     | .2534     |
| 2    | .2715     | .2772     | .2772     | .2378     | .2378     | .2896     | .2534     |
| 3    | .2896     | .2772     | .2772     | .2378     | .2561     | .3258     | .2957     |
| 4    | .3258     | .3174     | .3174     | .2957     | .2957     | .3696     | .3326     |
| 5    | .4066     | .3734     | .3734     | .3734     | .3696     | .4251     | .3881     |
| 6    | .5729     | .5228     | .4481     | .5228     | .5601     | .5729     | .462      |
| 7    | .4066     | .3547     | .3547     | .3696     | .3696     | .439      | .4251     |
| 8    | .3142     | .2614     | .3174     | .2587     | .2926     | .3258     | .3077     |
| 9    | .2587     | .2241     | .2103     | .2328     | .2279     | .2865     | .2353     |
| 10   | .2378     | .2054     | .197      | .2149     |           | .2507     | .2172     |
| 11   | .2195     | .2033     | .1402     | .197      | .1949     | .2507     | .2172     |
| 12   | .2195     | .2218     | .1753     | .1991     | .1928     | .2303     | .1991     |
| 13   | .2195     | .2402     | .1928     | .2126     | .2103     | .2303     | .2172     |
| 14   | .2378     | .2402     | .1928     | .2279     | .2454     | .2254     | .2172     |
| 15   | .2378     | .2378     | .2103     | .2229     | .2279     | .2279     | .2561     |
| 16   | .2587     |           | .2279     | .2427     | .2279     | .2303     | .2743     |
| 17   | .2957     | .2587     | .208      | .2347     | .2713     | .2713     | .3142     |
| 18   | .2957     | .3142     | .2743     | .3086     | .3018     | .2947     | .3511     |
| 19   | .3547     | .4108     | .3544     | .362      | .394      | .3856     | .3921     |
| 20   | .3921     | .3734     | .3721     | .362      | .3982     | .3366     | .3921     |
| 21   | .3547     | .3547     | .3258     | .3258     | .362      | .3045     | .3361     |
| 22   | .3174     | .2987     | .2926     | .3077     | .3258     | .3224     | .2957     |
| 23   | .3142     | .2987     | .2561     | .2715     | .2896     | .2686     | .2957     |
| 24   | .2896     | .3142     | .2772     | .2378     | .2715     | .2896     | .2507     |
| Max  | .5729     | .5228     | .4481     | .5228     | .5601     | .5729     | .462      |
| Min  | .2195     | .2033     | .1402     | .197      | .1928     | .2254     | .1991     |
| Avg  | .3068     | .2990     | .2729     | .2789     | .2955     | .3101     | .2991     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124025 / 33/11 KV ENGAON

Feeder No / Name : 202 / 11 KV Harankheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2587     | .1943     | .1619     | .1311     | .2195     | .2587     | .2587     |
| 2    | .2587     | .1943     | .1619     | .1311     | .1829     | .2587     | .2402     |
| 3    | .2587     | .1943     | .1781     | .1311     | .1829     | .2772     | .2587     |
| 4    | .2987     | .2294     | .2294     | .1658     | .2195     | .2587     | .2987     |
| 5    | .3361     | .2486     | .3185     | .2012     | .2614     | .2987     | .3361     |
| 6    | .3734     | .285      | .407      | .4024     | .3734     | .3921     | .3734     |
| 7    | .3361     | .3201     | .4049     | .3841     | .2614     | .3961     | .2987     |
| 8    | .2987     | .112      | .2241     | .2241     | .2241     | .2801     | .2614     |
| 9    |           | .2241     | .1848     | .2241     | .2012     | .2218     | .1848     |
| 10   | .2656     | .2241     | .1867     | .1509     | .3281     | .2846     | .2591     |
| 11   | .2656     | .168      | .1848     | .1478     | .3437     | .3125     | .3281     |
| 12   | .1875     | .168      | .1478     | .1478     | .3125     | .3086     | .25       |
| 13   | .2968     | .1848     | .1848     | .1478     | .3241     | .3086     | .25       |
| 14   | .3163     | .1848     | .1478     | .1848     | .2778     | .2778     | .2688     |
| 15   | .2812     | .1848     | .1848     | .1848     | .2591     | .2846     | .2721     |
| 16   | .2623     | .1829     | .1848     | .1463     | .3048     | .2915     | .2812     |
| 17   | .2378     | .1829     | .1478     | .1463     | .3048     | .2469     | .3086     |
| 18   | .2033     | .1829     | .1829     | .181      | .181      | .1448     | .2218     |
| 19   | .3174     | .2987     | .2987     | .2987     | .2987     | .3361     | .3361     |
| 20   | .3547     | .3361     | .2987     | .3326     | .3361     | .3326     | .3361     |
| 21   | .2957     | .2957     | .2957     | .2957     | .3142     | .2926     | .2957     |
| 22   | .208      | .2056     | .2241     | .2957     | .2801     | .2957     | .2957     |
| 23   | .192      | .192      | .16       | .2587     | .2772     | .2587     | .2772     |
| 24   | .2587     | .1781     | .1638     | .1562     | .2587     | .2587     | .2587     |
| Max  | .3734     | .3361     | .407      | .4024     | .3734     | .3961     | .3734     |
| Min  | .1875     | .112      | .1478     | .1311     | .181      | .1448     | .1848     |
| Avg  | .2766     | .2155     | .2193     | .2113     | .2720     | .2865     | .2812     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124025 / 33/11 KV ENGAON

Feeder No / Name : 204 / kolhadi Gavthan Feeder  
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1829     | .1663     | .1848     | .2012     | .1829     | .1991     | .1829     |
| 2    | .2012     | .1663     | .1848     | .1829     | .1829     | .1991     | .1829     |
| 3    | .2033     | .1867     | .2054     | .1829     | .2012     | .2218     | .2218     |
| 4    | .2587     | .2427     | .2641     | .2033     | .2033     | .2587     | .2587     |
| 5    | .2987     | .3018     | .3395     | .2614     | .2427     | .2987     | .3174     |
| 6    | .3921     | .3772     | .3961     | .4294     | .3772     | .4108     | .4108     |
| 7    | .2987     | .2829     | .2641     | .1867     | .1867     | .2218     | .2614     |
| 8    | .2054     | .1867     | .1494     | .1663     | .1663     | .1829     | .1848     |
| 9    | .128      | .1448     | .1463     | .1478     | .1629     | .0358     | .1848     |
| 10   | .1463     | .1294     | .1063     | .1448     | .1448     | .1646     | .1463     |
| 11   | .128      | .1463     | .1267     | .1097     | .1463     | .1463     | .1463     |
| 12   | .1109     | .1478     | .1097     | .1086     | .1629     | .1448     | .1646     |
| 13   | .1294     | .1463     | .1463     | .1086     | .128      | .1433     | .1448     |
| 14   | .1478     | .1448     | .1463     | .1109     | .1646     | .1612     | .1646     |
| 15   | .1478     | .1448     | .1463     | .1097     | .1463     | .1629     | .1646     |
| 16   | .1294     | .1448     | .1448     | .1448     | .1448     | .1629     | .1829     |
| 17   | .0739     | .1629     | .1753     | .1791     | .1433     | .1753     | .197      |
| 18   | .1417     | .1753     | .2103     | .197      | .1772     | .156      | .2149     |
| 19   | .2353     | .2587     | .2743     | .2587     | .2587     | .2378     | .2378     |
| 20   | .2378     | .2427     | .2378     | .2195     | .2218     | .2195     | .2587     |
| 21   | .2012     | .2033     | .2378     | .2195     | .2012     | .2012     | .2218     |
| 22   | .1829     | .2033     | .2195     | .2012     | .2195     | .2012     | .2195     |
| 23   | .1829     | .2033     | .2012     | .2012     | .2195     | .2012     | .2195     |
| 24   | .1829     | .1848     | .1848     | .2012     | .1829     | .1991     | .1829     |
| Max  | .3921     | .3772     | .3961     | .4294     | .3772     | .4108     | .4108     |
| Min  | .0739     | .1294     | .1063     | .1086     | .128      | .0358     | .1448     |
| Avg  | .1895     | .1956     | .2001     | .1865     | .1903     | .1961     | .2113     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124025 / 33/11 KV ENGAON

Feeder No / Name : 205 / kolhadi Ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3944     |           |           |           | .3048     | .3688     | .3688     |
| 2    | .4031     |           |           |           | .3048     | .3563     | .373      |
| 3    | .4207     |           |           |           | .3125     | .3772     | .407      |
| 4    | .4572     |           |           |           | .3441     | .3856     | .4656     |
| 5    | .4572     |           |           |           | .3772     | .4207     | .4938     |
| 6    | .5228     |           |           |           | .5658     | .547      | .5847     |
| 7    | .6602     |           |           |           | .5658     | .6413     | .679      |
| 10   |           | .5415     | .6036     | .547      |           |           |           |
| 11   |           | .7167     | .6224     | .5658     |           |           |           |
| 12   |           | .679      | .5658     | .5228     |           |           |           |
| 13   |           | .6224     | .4854     | .4854     |           |           |           |
| 14   |           | .5847     | .4481     | .4525     |           |           |           |
| 15   |           | .5658     | .4163     | .4572     |           |           |           |
| 16   |           | .1478     | .4075     | .4854     |           |           |           |
| 17   |           | .5175     | .439      | .5281     |           |           |           |
| 22   |           |           |           | .3361     | .4344     | .4207     | .3814     |
| 23   |           |           |           | .3281     | .3563     | .4115     | .3772     |
| 24   | .3988     |           |           |           | .3201     | .3647     | .3688     |
| Max  | .6602     | .7167     | .6224     | .5658     | .5658     | .6413     | .679      |
| Min  | .3944     | .1478     | .4075     | .3281     | .3048     | .3563     | .3688     |
| Avg  | .4643     | .5469     | .4985     | .4708     | .3886     | .4294     | .4499     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124025 / 33/11 KV ENGAON

Feeder No / Name : 206 / Chikhali Single phasing SINGLE PHASING  
feeder Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2957     | .1829     | .1957     | .1829     | .2561     | .2987     | .2587     |
| 2    | .2772     | .1829     | .1981     | .1677     | .2561     | .2987     | .2772     |
| 3    | .2987     | .2214     | .2187     | .1677     | .2195     | .2801     | .3142     |
| 4    | .3361     | .2591     | .2561     | .1829     | .2772     | .3174     | .3361     |
| 5    | .3921     | .3149     | .3441     |           | .3547     | .3547     | .3734     |
| 6    | .4854     | .3647     | .4424     | .3978     | .4854     | .4668     | .4668     |
| 7    | .3772     | .4062     | .427      | .3906     | .3206     | .3174     | .3018     |
| 8    | .2427     | .1867     | .2241     | .1867     | .2033     | .2241     | .1698     |
| 9    | .2054     |           | .1663     | .1478     | .1463     | .2054     | .2012     |
| 10   | .4374     | .168      | .1494     | .1629     | .286      | .3549     | .3549     |
| 11   | .3963     | .168      | .1867     | .1109     | .3549     | .3201     | .3506     |
| 12   | .3612     | .168      | .1663     | .0934     | .3201     | .3161     | .301      |
| 13   | .301      | .1663     | .1478     | .112      | .3048     | .2347     | .2675     |
| 14   | .2526     | .1663     | .1663     | .1663     | .2972     | .1882     | .2172     |
| 15   | .2824     | .1848     | .1663     | .1663     | .2675     | .2229     | .2526     |
| 16   | .3121     | .181      | .1848     | .1663     | .2896     | .2591     | .2824     |
| 17   |           | .181      | .1646     | .1829     | .3418     | .3185     | .3269     |
| 18   | .1734     | .1829     | .1629     | .1791     | .1949     | .1578     | .1991     |
| 19   | .2801     | .3174     | .3174     | .3142     | .2987     | .3361     | .3109     |
| 20   | .3361     | .3361     | .3174     | .3142     | .3547     | .3326     | .3511     |
| 21   | .3142     | .3174     | .3142     | .3326     | .3142     | .3326     | .3326     |
| 22   | .2107     | .2559     | .2526     | .3142     | .2957     | .3142     | .3142     |
| 23   | .2107     | .2258     | .2027     | .2957     | .2957     | .2957     | .3142     |
| 24   | .2957     | .1829     | .1932     | .1783     | .2772     | .2801     | .2772     |
| Max  | .4854     | .4062     | .4424     | .3978     | .4854     | .4668     | .4668     |
| Min  | .1734     | .1663     | .1478     | .0934     | .1463     | .1578     | .1698     |
| Avg  | .3076     | .2313     | .2319     | .2136     | .2922     | .2928     | .2980     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124043 / 33/11 KV JAMTHI

Feeder No / Name : 202 / 11 KV Jamthi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     | .1029     | .1029     | .1029     | .12       | .1543     | .1886     |
| 2    | .1715     | .1029     | .12       | .1372     | .12       | .1543     | .1886     |
| 3    | .1886     | .1372     | .1543     | .1372     | .1372     | .1715     | .2058     |
| 4    | .2058     | .1543     | .1886     | .1543     | .1543     | .1886     | .2229     |
| 5    | .2572     | .1715     | .1886     | .2229     | .1543     | .2058     | .2572     |
| 6    | .3086     | .2229     | .2058     | .2229     | .2229     | .2229     | .3086     |
| 7    | .3086     | .2229     | .2401     | .1886     | .2058     | .2401     | .2401     |
| 8    | .2572     | .2058     | .1886     |           | .1886     | .1886     | .2229     |
| 9    | .1715     | .1543     | .1543     | .1372     | .1715     | .2058     | .2058     |
| 10   | .1543     | .1715     | .1543     | .1543     | .1372     | .1372     | .1372     |
| 11   | .1543     | .1543     | .1372     | .1543     | .1543     | .1372     | .1372     |
| 12   | .1372     | .1543     | .1543     | .1372     | .1372     | .1372     | .1372     |
| 13   | .1543     | .1715     | .1372     | .1372     | .1543     | .1372     | .12       |
| 14   | .1372     | .1715     | .1543     | .1372     | .1372     | .1372     | .0857     |
| 15   | .12       | .1715     | .1543     | .1543     | .12       | .1372     | .12       |
| 16   | .1029     | .1543     | .1715     | .1543     | .1372     | .1372     | .1372     |
| 17   | .1029     | .1543     | .1543     | .1543     | .12       | .1372     | .1372     |
| 18   | .1372     | .1715     | .1372     | .1543     | .1543     | .1543     | .1543     |
| 19   | .2058     | .2401     | .2058     | .2058     | .2058     | .2229     | .3086     |
| 20   | .2229     | .2229     | .1886     | .2229     | .1886     | .2743     | .2743     |
| 21   | .1715     | .2058     | .1886     | .1886     | .2058     | .2229     | .2401     |
| 22   | .1715     | .1372     | .1543     | .1715     | .1886     | .2229     | .2229     |
| 23   | .1372     | .12       | .1372     | .1543     | .1715     | .2058     | .2058     |
| 24   | .1715     | .1372     | .1029     | .1029     | .1543     | .1543     | .1886     |
| Max  | .3086     | .2401     | .2401     | .2229     | .2229     | .2743     | .3086     |
| Min  | .1029     | .1029     | .1029     | .1029     | .12       | .1372     | .0857     |
| Avg  | .1801     | .1672     | .1615     | .1603     | .1600     | .1786     | .1936     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124043 / 33/11 KV JAMTHI

Feeder No / Name : 203 / DHONKHEDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1524     | .1543     | .1372     | .1886     | .1372     | .1543     | .1677     |
| 2    | .1677     | .1715     | .1372     | .2058     | .1543     | .1543     | .1829     |
| 3    | .1829     | .1715     | .1524     | .2058     | .1715     | .1886     | .1829     |
| 4    | .1981     | .2058     | .1677     | .2401     | .1886     | .1886     | .1981     |
| 5    | .2286     | .2229     | .1677     | .2743     | .2058     | .2058     | .2286     |
| 6    | .2743     | .2572     | .1829     | .3086     | .2572     | .2058     | .5182     |
| 7    | .2743     | .1886     | .2134     | .2572     | .2229     | .2401     | .2439     |
| 8    | .2401     | .2229     | .1981     | .2229     | .2058     | .2229     | .3086     |
| 9    | .1715     | .1524     | .1886     | .1543     | .1677     | .2401     | .2743     |
| 10   | .1543     | .1543     | .1524     | .1886     | .1524     | .2058     | .1715     |
| 11   | .1543     | .1715     | .1372     | .1715     | .1524     | .1886     | .1886     |
| 12   | .1372     | .1543     | .1219     | .1543     | .1677     | .1886     | .2058     |
| 13   | .12       | .1715     | .1372     |           | .1524     | .1715     | .2058     |
| 14   | .1372     | .1543     | .1219     | .1372     | .1219     | .1372     | .2229     |
| 15   | .12       | .1886     | .1219     | .1543     | .1372     | .1886     | .2229     |
| 16   | .1543     | .2058     | .1524     | .1543     | .1524     | .2229     | .2229     |
| 17   | .1715     | .2229     | .1524     | .1886     | .1524     | .2401     | .2229     |
| 18   | .1543     | .1543     | .1886     | .1372     | .1524     | .2058     | .2572     |
| 19   | .2229     | .2401     | .2572     | .2401     | .1829     | .2572     | .3601     |
| 20   | .1886     | .2058     | .2058     | .2229     | .1677     | .3258     | .3429     |
| 21   | .1886     | .1886     | .2229     | .2058     |           | .3086     | .3258     |
| 22   | .1886     | .1715     | .2229     | .1886     | .1677     | .1829     | .1981     |
| 23   | .1715     | .1715     | .2058     | .1715     | .1524     | .1829     | .1829     |
| 24   | .1524     | .1543     | .1543     | .2058     | .1543     | .1372     | .1677     |
| Max  | .2743     | .2572     | .2572     | .3086     | .2572     | .3258     | .5182     |
| Min  | .12       | .1524     | .1219     | .1372     | .1219     | .1372     | .1677     |
| Avg  | .1794     | .1857     | .1708     | .1991     | .1686     | .2060     | .2418     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124043 / 33/11 KV JAMTHI

Feeder No / Name : 204 / SHEVAGA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .381      | .2058     |           | .2401     | .2401     | .2915     | .3506     |
| 2    | .4115     | .2229     | .2134     | .2743     | .2401     | .2915     | .3658     |
| 3    | .4268     | .2229     | .2286     | .2743     | .2572     | .3772     | .3963     |
| 4    | .4877     | .2572     | .2286     | .2915     | .2743     | .463      | .4572     |
| 5    | .5182     | .2572     | .2591     | .3429     | .3086     | .4973     | .5335     |
| 6    | .5487     | .2915     | .2591     | .3944     | .4801     | .5144     | .5792     |
| 7    | .6401     | .3258     | .2743     | .2915     | .4973     | .5316     | .5792     |
| 8    | .2401     | .2572     | .2439     | .1543     | .1372     | .2401     | .1829     |
| 9    | .2058     | .1372     | .1372     | .1372     | .2134     | .2401     | .1677     |
| 10   | .1715     | .463      | .4115     | .3944     | .2286     | .1886     | .2401     |
| 11   | .1543     | .4287     | .442      | .4458     | .2286     | .1886     | .2229     |
| 12   | .1715     | .463      | .4268     | .703      | .1981     | .1886     | .2058     |
| 13   | .1715     | .463      | .3658     | .4458     | .1677     | .1886     | .2229     |
| 14   | .1543     | .4973     | .3353     | .3429     | .1372     | .2058     | .2401     |
| 15   | .1543     | .5144     | .3506     | .3429     | .1372     | .2229     | .2401     |
| 16   | .1886     | .5487     | .3658     | .4115     | .1524     | .2401     | .2401     |
| 17   | .1543     | .5658     | .4268     | .3944     | .1677     | .2058     | .2229     |
| 18   |           | .2058     | .1886     | .1372     | .1524     | .1886     | .2229     |
| 19   | .2743     | .2401     | .2401     | .1372     | .1981     | .2401     | .2401     |
| 20   | .2229     | .2401     | .2743     | .12       | .1829     | .2572     | .2401     |
| 21   | .2401     | .2572     | .2743     | .12       | .2134     | .2572     | .2401     |
| 22   | .2058     | .2572     | .2572     | .2915     | .2896     | .3658     | .381      |
| 23   | .2058     | .2401     | .2743     | .2743     | .2591     | .3506     | .3658     |
| 24   | .381      | .1886     | .2401     | .2401     | .2572     | .2439     | .3201     |
| Max  | .6401     | .5658     | .442      | .703      | .4973     | .5316     | .5792     |
| Min  | .1543     | .1372     | .1372     | .12       | .1372     | .1886     | .1677     |
| Avg  | .2917     | .3229     | .2921     | .3001     | .2341     | .2908     | .3107     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124043 / 33/11 KV JAMTHI

Feeder No / Name : 205 / REOTI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2229     | .4572     | .6344     | .4725     | .0914     | .2134     | .2229     |
| 2    | .2401     | .4877     | .6344     | .503      | .0914     | .2134     | .2401     |
| 3    | .2401     |           | .6859     | .5335     | .1067     | .2286     | .2401     |
| 4    | .2572     | .5335     | .7202     | .5335     | .1219     | .2439     | .2572     |
| 5    | .3086     | .6097     | .7202     | .5944     | .1219     | .2439     | .2915     |
| 6    | .3601     | .6859     | .7373     | .7011     | .1677     | .2591     | .3258     |
| 7    | .2915     | .6097     | .7716     | .6554     | .1219     | .2896     | .2743     |
| 8    | .2572     | .2743     | .2401     | .08       | .1067     | .1524     | .2229     |
| 9    | .1543     | .1886     | .1715     |           | .1829     | .1886     | .1886     |
| 10   | .7926     | .1372     | .12       | .1029     | .6687     | .7316     | .6859     |
| 11   | .7621     | .1372     | .1372     | .0686     | .6859     | .7011     | .6554     |
| 12   | .7316     | .1372     | .1372     | .0857     | .6859     | .6859     | .6097     |
| 13   | .7011     | .1524     |           | .1029     | .7202     | .6554     | .5792     |
| 14   | .6401     | .1524     | .1715     | .0686     | .7202     | .6401     | .5487     |
| 15   | .6706     | .1372     | .1543     | .1029     | .6687     | .6401     | .5792     |
| 16   | .7011     | .1219     | .1715     | .1029     | .6687     | .6401     | .6097     |
| 17   |           | .1067     | .1543     | .0857     | .6687     | .6249     | .6249     |
| 18   | .1886     | .1524     | .1543     | .1029     | .1886     | .1886     | .1886     |
| 19   | .2743     | .2286     | .2743     | .1029     | .2401     | .2401     | .2743     |
| 20   | .2572     | .2134     | .2743     | .1372     | .2401     | .2743     | .2572     |
| 21   | .2572     | .2286     | .2572     | .12       | .2572     | .2401     | .2401     |
| 22   | .4268     | .5944     | .5792     | .12       | .2572     | .2229     | .2401     |
| 23   | .4877     | .5639     | .5487     | .12       | .2401     | .2229     | .2401     |
| 24   | .2229     | .4572     | .5487     | .4572     | .12       | .2401     | .2229     |
| Max  | .7926     | .6859     | .7716     | .7011     | .7202     | .7316     | .6859     |
| Min  | .1543     | .1067     | .12       | .0686     | .0914     | .1524     | .1886     |
| Avg  | .4107     | .3203     | .3912     | .2589     | .3393     | .3742     | .3675     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124164 / 33/11 kv MUKTAL SUBSTATION

Feeder No / Name : 201 / 11 KV MUKTAL FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9145     | .2743     | .1829     | .3429     | .6859     | 1.0631    | 1.1317    |
| 2    | 1.046     | .2743     | .2058     | .3429     | .7545     | 1.0288    | 1.2003    |
| 3    | .9145     | .3048     | .2058     | .3601     | .823      | 1.0631    | 1.0364    |
| 4    | .9602     | .3048     | .2134     | .3353     | .8916     | 1.0288    | 1.0974    |
| 5    | .9602     | .3772     | .3086     | .4115     | .8535     | 1.0631    | 1.0288    |
| 6    | 1.1145    | .4115     | .3429     | .4115     | 1.0288    | 1.1317    | 1.0288    |
| 7    | .9907     | .3963     | .2401     | .3963     | .9602     | 1.0974    | 1.0117    |
| 8    | .3048     | .3658     | .2058     | .4458     | .5144     | .1715     | .2058     |
| 9    | .3601     | .4458     | .1524     | .4458     | .3429     | .1524     |           |
| 10   | .2743     | .884      | .9145     | .7621     | .1715     | .2058     | .2743     |
| 11   | .2401     | 1.0288    | 1.046     | .823      | .2743     | .2058     | .2058     |
| 12   | .2743     | 1.0288    | 1.0288    | .8535     | .3086     | .1715     | .1715     |
| 13   | .3048     | 1.0288    | 1.0288    | .7316     | .2743     | .1715     | .2058     |
| 14   | .3048     | .884      | 1.0802    | .5792     | .1372     | .2058     | .1981     |
| 15   | .3086     | .9602     | 1.1145    | .6859     | .1715     | .1715     | .2229     |
| 16   | .2743     | .823      | 1.0669    | .6706     | .1715     | .2058     | .2401     |
| 17   | .2134     | .8916     | 1.0669    | .8916     | .3772     | .1829     | .2915     |
| 18   | .2743     | .2439     | .3429     | .3048     | .3429     | .2058     | .1715     |
| 19   | .2439     | .2743     | .3601     | .3772     | .3429     | .2058     | .1829     |
| 20   | .2743     | .2743     | .3201     | .3658     | .3772     | .1715     | .1829     |
| 21   | .3086     | .2401     | .3772     | .3086     | .3086     | .2058     | .1715     |
| 22   | .2439     | .2134     | .3944     | .6173     | .7202     | .7888     | .6706     |
| 23   | .2134     |           | .3772     | .6859     | .8573     | .7316     | .6401     |
| 24   | .9907     | .2134     | .2058     | .3429     | .6859     | .8916     | .6859     |
| Max  | 1.1145    | 1.0288    | 1.1145    | .8916     | 1.0288    | 1.1317    | 1.2003    |
| Min  | .2134     | .2134     | .1524     | .3048     | .1372     | .1524     | .1715     |
| Avg  | .5129     | .5280     | .5326     | .5205     | .5157     | .5217     | .5329     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

BODWAD[230]

BU 0698

Substation No/ Name :- 124164 / 33/11 kv MUKTAL SUBSTATION

Feeder No / Name : 202 / 11 KV VARAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3601     | .6859     | .4877     | .6097     | .4115     | .6859     | .4572     |
| 2    | .3772     | .7545     | .4877     | .7621     | .5144     | .6859     | .4877     |
| 3    | .4287     | .823      | .6173     | .7773     | .583      | .6859     | .4572     |
| 4    | .5144     | .8573     | .7202     | .8383     | .6516     | .7716     | .5487     |
| 5    | .5316     | .8916     | .8573     | .8383     | .6859     | .7545     | .6097     |
| 6    | .5487     | .8573     | .8916     | .9145     | .6859     | .7716     | .6859     |
| 7    | .5487     | .8916     | .8573     | .9145     | .7888     | .7888     | .6706     |
| 8    | .5658     | .5144     | .4877     | .5144     | .5144     | .5658     | .6097     |
| 9    | .5658     | .4801     | .4268     | .5316     | .4115     | .5144     | .4572     |
| 10   | .6859     | .3772     | .3429     | .4801     | .4572     | .6706     | .6401     |
| 11   | .6706     | .3601     | .3601     | .4115     |           | .7316     | .6097     |
| 12   | .6401     | .3429     | .3429     | .3429     | .7316     | .5792     | .6097     |
| 13   | .6097     | .3429     | .3772     | .3429     | .7316     | .6097     | .6401     |
| 14   | .6097     | .3086     | .3086     | .3429     | .7621     | .6401     | .6859     |
| 15   | .6097     | .3086     | .3258     | .3429     | .7621     | .6097     | .583      |
| 16   | .4572     | .3429     | .3258     | .3772     | .6706     | .6706     | .5144     |
| 17   | .4268     | .3772     | .3429     | .4115     | .5792     | .6401     | .5144     |
| 18   | .4268     | .4801     | .3944     | .5144     | .6859     | .7202     | .5487     |
| 19   | .5144     | .6516     | .4115     | .6859     | .7202     | .7888     | .5144     |
| 20   | .583      | .6516     | .4287     | .7888     | .7545     | .583      | .6001     |
| 21   | .6516     | .6516     | .4287     | .6859     | .6516     | .6516     | .6859     |
| 22   | .6173     | .5487     | .6097     | .6173     | .583      | .6173     | .5487     |
| 23   | .5144     | .6173     | .6249     | .583      | .5144     | .5144     | .5144     |
| 24   | .3601     | .6516     | .5487     | .6097     | .2743     | .5144     | .5182     |
| Max  | .6859     | .8916     | .8916     | .9145     | .7888     | .7888     | .6859     |
| Min  | .3601     | .3086     | .3086     | .3429     | .2743     | .5144     | .4572     |
| Avg  | .5341     | .5737     | .5003     | .5932     | .6141     | .6569     | .5713     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124026 / 33/11 KV CHANGDEO S/STN

Feeder No / Name : 201 / Changdev Water Supply

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | .0762     | .0762     | .0762     | .0762     | .0762     |
| 18   |           |           | .0762     |           | .0762     |
| Max  | .0762     | .0762     | .0762     | .0762     | .0762     |
| Min  | .0762     | .0762     | .0762     | .0762     | .0762     |
| Avg  | .0762     | .0762     | .0762     | .0762     | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124026 / 33/11 KV CHANGDEO S/STN

Feeder No / Name : 202 / 11 KV Chinchol

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | 2.6658    | 2.1963    | 1.3413    | 1.3916    | 1.4251    |
| 18   |           |           | 1.2742    |           | 1.291     |
| Max  | 2.6658    | 2.1963    | 1.3413    | 1.3916    | 1.4251    |
| Min  | 2.6658    | 2.1963    | 1.2742    | 1.3916    | 1.291     |
| Avg  | 2.6658    | 2.1963    | 1.3078    | 1.3916    | 1.3581    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124026 / 33/11 KV CHANGDEO S/STN

Feeder No / Name : 203 / 11 KV Manegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | 2.4629    | 2.073     | 1.5769    | 1.2934    | 1.3998    |
| 18   |           |           | 1.0985    |           | 1.1163    |
| Max  | 2.4629    | 2.073     | 1.5769    | 1.2934    | 1.3998    |
| Min  | 2.4629    | 2.073     | 1.0985    | 1.2934    | 1.1163    |
| Avg  | 2.4629    | 2.073     | 1.3377    | 1.2934    | 1.2581    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124027 / 33/11 KV KURHA

Feeder No / Name : 201 / 11 KV Kurha AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.4118    | .9808     |           |           |           |           |
| 2    |           | 1.448     | .9808     |           |           |           |           |
| 3    |           | 1.5203    | 1.07      |           |           |           |           |
| 4    |           | 1.5565    | 1.07      |           |           |           |           |
| 5    |           | 1.5927    | 1.2631    |           |           |           |           |
| 6    |           | 1.6289    | 1.4723    |           |           |           |           |
| 7    |           |           | 1.4723    |           |           |           |           |
| 10   | 1.8461    |           |           |           | 1.358     | 1.4575    | 1.6975    |
| 11   | 1.8461    |           |           |           | 1.9239    | 1.6095    | 1.8107    |
| 12   | 1.8099    |           |           |           | 2.037     | 1.6095    | 1.6975    |
| 13   | 1.8461    |           |           |           | 1.9239    | 1.6095    | 1.5844    |
| 14   | 1.7375    |           |           |           | 1.8107    | 1.6095    | 1.4712    |
| 15   | 1.6651    |           |           |           | 1.6975    | 1.5089    | 1.4712    |
| 16   | 1.6289    |           |           |           | 1.6975    | 1.4083    | 1.6975    |
| 17   | 1.6289    |           |           | 1.1222    |           | 1.3123    | 1.6975    |
| 18   |           |           |           | 1.1765    |           |           |           |
| 19   |           |           |           | 1.2308    |           |           |           |
| 20   |           |           |           | 1.267     |           |           |           |
| 21   |           |           |           | 1.3575    |           |           | 1.6975    |
| 22   | 1.3394    | 1.3077    |           |           |           |           |           |
| 23   | 1.3394    | 1.3077    |           |           |           |           |           |
| 24   |           | 1.3756    | 1.07      |           |           |           |           |
| Max  | 1.8461    | 1.6289    | 1.4723    | 1.3575    | 2.037     | 1.6095    | 1.8107    |
| Min  | 1.3394    | 1.3077    | .9808     | 1.1222    | 1.358     | 1.3123    | 1.4712    |
| Avg  | 1.6687    | 1.4610    | 1.1724    | 1.2308    | 1.7784    | 1.5156    | 1.6472    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124027 / 33/11 KV KURHA

Feeder No / Name : 202 / 11 KV KURHA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1706    | 1.1222    | 1.0364    | 1.245     | 1.1584    | 1.245     | 1.1584    |
| 2    | 1.2437    | 1.1584    | 1.0364    | 1.245     | 1.2308    | 1.245     | 1.2193    |
| 3    | 1.2437    | 1.2308    | 1.1561    | 1.3182    | 1.3394    | 1.3182    | 1.3413    |
| 4    | 1.3169    | 1.3394    | 1.1984    | 1.3915    | 1.4118    | 1.3915    | 1.4083    |
| 5    | 1.4998    | 1.3394    | 1.5424    | 1.4647    | 1.4842    | 1.4647    | 1.643     |
| 6    | 1.7193    | 1.5927    | 1.5775    | 1.6844    | 1.5565    | 1.6844    | 1.6651    |
| 7    | 1.6095    | 1.7013    | 1.4022    | 1.538     | 1.6289    | 1.4647    | 1.5927    |
| 8    | 1.2437    | 1.448     | 1.2308    | 1.245     | 1.3032    |           | 1.3032    |
| 9    | 1.1222    | .9755     | 1.0985    | 1.1584    | 1.1718    | 1.0105    | 1.1706    |
| 10   | 1.1584    | .9069     | 1.0985    | 1.1222    | 1.0985    | .9145     | 1.0974    |
| 11   | 1.1222    | .8322     | 1.0253    | 1.086     | 1.0985    | .8573     | 1.0974    |
| 12   | 1.086     | .8322     | 1.0253    |           | 1.0985    | .8573     | .9511     |
| 13   | 1.086     | .8749     | 1.0253    |           | 1.0985    | .8916     | 1.0242    |
| 14   | 1.0136    | .9145     | 1.0253    | 1.086     | 1.0985    | .8916     | 1.0974    |
| 15   | 1.0136    | .9717     | 1.0985    | 1.086     | 1.1718    | .9717     | 1.0242    |
| 16   | .9412     | .8916     | 1.0985    | 1.1222    | 1.245     | 1.0364    | 1.0974    |
| 17   | 1.086     | .8916     | 1.1718    | 1.1584    | 1.245     | 1.0364    | 1.1706    |
| 18   | 1.1584    | .9145     | 1.1718    | 1.3032    | 1.0985    | 1.1401    | 1.2437    |
| 19   | 1.267     | 1.0974    | 1.4647    | 1.3575    | 1.3915    | 1.2071    | 1.39      |
| 20   | 1.3394    | 1.2193    | 1.538     | 1.4118    | 1.6112    | 1.2308    | 1.4632    |
| 21   | 1.3756    | 1.2955    | 1.4647    | 1.448     |           | 1.2955    | 1.4632    |
| 22   | 1.2308    | 1.1873    |           | 1.3394    | 1.538     | 1.4083    | 1.39      |
| 23   | 1.1584    | 1.0974    |           | 1.3032    | 1.4647    | 1.2742    | 1.39      |
| 24   |           | 1.1222    | 1.1248    | 1.245     | 1.1584    | 1.3915    | 1.3169    |
| Max  | 1.7193    | 1.7013    | 1.5775    | 1.6844    | 1.6289    | 1.6844    | 1.6651    |
| Min  | .9412     | .8322     | 1.0253    | 1.086     | 1.0985    | .8573     | .9511     |
| Avg  | 1.2263    | 1.1232    | 1.2096    | 1.2891    | 1.2914    | 1.1838    | 1.2799    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124027 / 33/11 KV KURHA

Feeder No / Name : 203 / 11 KV JONDHANKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3521     |           |           |           | .4344     | .3521     | .4572     |
| 2    | .4694     |           |           |           | .4344     | .3521     | .4001     |
| 3    | .4694     |           |           |           | .4706     | .2934     | .3841     |
| 4    | .5281     |           |           |           | .5068     | .2934     | .3841     |
| 5    | .5281     |           |           |           | .5068     | .3521     | .5182     |
| 6    | .7042     |           |           |           | .543      | .5281     | .5144     |
| 7    | .7628     |           |           |           | .5792     | .6455     | .5944     |
| 10   |           | .8322     | .7051     | .8688     |           |           |           |
| 11   |           | .743      | .7638     | .905      |           |           |           |
| 12   |           | .6859     |           | .9412     |           |           |           |
| 13   |           | .7125     | .4701     | .8688     |           |           |           |
| 14   |           | .6249     | .4113     | .905      |           |           |           |
| 15   |           | .535      | .4113     | .6878     |           |           |           |
| 16   |           | .4801     | .4113     | .5792     |           |           |           |
| 17   |           | .6539     | .5288     | .6154     |           |           |           |
| 22   |           |           |           | .4344     | .4694     | .583      | .5281     |
| 23   |           |           |           | .4344     | .4108     | .583      | .5281     |
| 24   |           |           |           |           | .4344     | .4108     | .4694     |
| Max  | .7628     | .8322     | .7638     | .9412     | .5792     | .6455     | .5944     |
| Min  | .3521     | .4801     | .4113     | .4344     | .4108     | .2934     | .3841     |
| Avg  | .5449     | .6584     | .5288     | .724      | .4790     | .4394     | .4778     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124028 / 33/11 KV GHODASGAON

Feeder No / Name : 201 / 11 KV Ghodasgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2402     | .2772     | .2772     | .2772     | .2686     | .2772     |
| 2    | .2658     | .2587     | .2772     | .2772     | .2772     | .2772     | .2772     |
| 3    | .3224     | .2561     | .2772     | .2772     | .2772     | .2772     | .2772     |
| 4    | .4572     | .2743     | .4066     | .2957     | .3142     | .3142     | .2957     |
| 5    | .5601     | .3326     | .4805     | .3326     | .4435     | .5175     | .3326     |
| 6    | .5975     | .5914     | .5544     | .5544     | .5544     | .5788     | .5544     |
| 7    | .5121     | .5544     | .4805     | .4805     | .5175     | .5228     | .462      |
| 8    | .4668     | .4435     | .4066     | .3696     | .4251     | .462      | .3511     |
| 9    | .3658     | .3326     | .2957     | .3326     | .3326     | .4066     | .3142     |
| 10   | .2587     | .2957     | .2218     | .2957     | .2587     | .2896     | .2896     |
| 11   | .2587     | .2587     | .2587     | .2587     | .2218     | .2481     | .2587     |
| 12   | .2587     | .2587     | .2587     | .2957     | .2587     | .2254     | .2507     |
| 13   | .2587     | .2587     | .2587     | .2587     | .2587     | .2103     | .2658     |
| 14   | .2587     | .2587     | .2587     | .2587     | .2957     | .2507     | .2658     |
| 15   | .2218     | .2587     | .2587     | .2587     | .3292     | .2865     | .2774     |
| 16   | .2218     | .2957     | .2587     | .2587     | .3292     | .3077     | .3189     |
| 17   | .2772     | .3326     | .2587     |           | .3326     |           | .2957     |
| 18   | .3326     | .3696     | .2587     |           | .3658     |           | .3696     |
| 19   | .3696     | .4435     | .3326     |           | .4755     |           | .3696     |
| 20   | .4435     | .3881     | .4066     |           | .4755     |           | .3696     |
| 21   | .3696     | .3696     | .3326     |           | .3696     |           | .3696     |
| 22   | .3326     | .2957     |           |           | .3326     |           | .3326     |
| 23   | .2957     | .2957     | .2957     |           | .2957     |           | .2957     |
| 24   | .2743     | .2957     | .2957     | .2772     | .2957     | .2772     | .2772     |
| Max  | .5975     | .5914     | .5544     | .5544     | .5544     | .5788     | .5544     |
| Min  | .2218     | .2402     | .2218     | .2587     | .2218     | .2103     | .2507     |
| Avg  | .3470     | .3316     | .3222     | .3152     | .3464     | .3365     | .3228     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124028 / 33/11 KV GHODASGAON

Feeder No / Name : 203 / 11 KV Ruikheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .282      |           |           |           | .2439     | .2515     | .3185     |
| 2    | .282      |           |           |           | .2439     | .2477     | .3185     |
| 3    | .3001     |           |           |           | .2401     | .2477     | .3185     |
| 4    | .3144     |           |           |           | .2439     | .2477     | .3185     |
| 5    | .3185     |           |           |           | .2439     | .2229     | .3185     |
| 6    | .3185     |           |           |           | .2681     | .2515     | .3374     |
| 7    | .3715     |           |           |           | .2721     | .2936     | .3567     |
| 10   |           | .4344     | .3374     | .2896     |           |           |           |
| 11   |           | .4401     | .3616     | .3121     |           |           |           |
| 12   |           | .4401     | .3616     | .3612     |           |           |           |
| 13   |           | .4401     | .3525     | .3658     |           |           |           |
| 14   |           | .4365     | .3521     | .3506     |           |           |           |
| 15   |           | .431      | .3567     | .3593     |           |           |           |
| 16   |           | .4161     | .3567     | .3048     |           |           |           |
| 17   |           | .4161     | .3567     |           |           |           |           |
| 22   |           |           |           |           | .2439     |           | .2705     |
| 23   |           |           |           |           | .2515     |           | .2743     |
| 24   | .306      |           |           |           | .2591     | .2515     | .3227     |
| Max  | .3715     | .4401     | .3616     | .3658     | .2721     | .2936     | .3567     |
| Min  | .282      | .4161     | .3374     | .2896     | .2401     | .2229     | .2705     |
| Avg  | .3116     | .4318     | .3544     | .3348     | .2510     | .2518     | .3154     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124028 / 33/11 KV GHODASGAON

Feeder No / Name : 204 / 11 KV Ghodasgaon Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .703      | .6944     |           |           |           |           |
| 2    |           | .703      | .6944     |           |           |           |           |
| 3    |           | .6874     | .6944     |           |           |           |           |
| 4    |           | .7186     | .6859     |           |           |           |           |
| 5    |           | .7343     | .6859     |           |           |           |           |
| 6    |           | .7811     | .6859     |           |           |           |           |
| 7    |           | .7621     | .7773     |           |           |           |           |
| 10   | .8749     |           |           |           | .8962     | .9488     | .9374     |
| 11   | .8855     |           |           | .6173     | .9998     | .9602     | 1.0402    |
| 12   | .8855     |           |           | .6173     | 1.0242    | 1.0402    | 1.0402    |
| 13   | .8962     |           |           | .6173     | 1.0242    | 1.0402    | 1.0279    |
| 14   | .8855     |           |           | .7499     | .8749     | .9488     | 1.0279    |
| 15   | .8855     |           |           | .7499     | .8535     | .9488     | .9374     |
| 16   | .8749     |           |           | .7186     | .8535     | .8592     | .8592     |
| 17   | .8749     |           |           |           | .8642     |           | .8855     |
| 22   | .6401     | .6923     |           |           |           |           |           |
| 23   | .679      | .6923     |           |           |           |           |           |
| 24   |           | .6944     | .6923     |           |           |           |           |
| Max  | .8962     | .7811     | .7773     | .7499     | 1.0242    | 1.0402    | 1.0402    |
| Min  | .6401     | .6874     | .6859     | .6173     | .8535     | .8592     | .8592     |
| Avg  | .8382     | .7169     | .7013     | .6784     | .9238     | .9637     | .9695     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124028 / 33/11 KV GHODASGAON

Feeder No / Name : 205 / Pimpri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2303     | .2303     | .2218     | .2195     | .2279     | .2507     | .2715     |
| 2    | .2303     | .2303     | .2218     | .2195     | .2481     | .2507     | .2715     |
| 3    | .2715     | .2507     | .2218     | .2195     | .2658     | .2534     | .2715     |
| 4    | .3658     | .2507     | .3326     | .2378     | .2686     | .2686     | .2715     |
| 5    | .4668     | .3292     | .3881     | .3258     | .439      | .3224     | .3224     |
| 6    | .4854     | .439      | .4572     | .439      | .439      | .439      | .3982     |
| 7    | .439      | .4119     | .4024     | .4207     | .4207     | .4207     | .362      |
| 8    | .362      | .3475     | .4119     | .3658     | .3582     | .3475     | .362      |
| 9    | .2686     | .2629     | .3012     | .2926     | .298      | .3189     | .3189     |
| 10   | .2658     | .2601     |           | .2126     | .2279     | .2229     | .2507     |
| 11   |           | .2572     | .2229     | .208      | .2229     | .208      | .2279     |
| 12   | .2454     | .2401     | .2229     | .2058     | .208      | .208      | .2254     |
| 13   | .208      | .2401     | .2058     | .208      | .208      | .1715     | .2279     |
| 14   | .2427     | .2058     | .2058     | .208      | .2229     | .2058     | .2279     |
| 15   | .2427     | .2058     | .2229     | .2126     | .213      | .2427     | .2254     |
| 16   | .2572     | .2401     | .2401     | .2454     | .213      | .2572     | .2774     |
| 17   | .2804     | .2804     | .2629     |           | .2713     |           | .3155     |
| 18   | .3012     | .3506     | .3189     |           | .3012     |           | .333      |
| 19   | .3898     | .3856     | .3721     |           | .3439     |           | .0421     |
| 20   | .4119     | .3155     | .3582     |           | .3258     |           | .2658     |
| 21   | .2507     | .2835     | .2715     |           | .2686     |           | .2481     |
| 22   | .2507     | .2658     | .2454     |           | .2507     |           | .2507     |
| 23   | .2507     | .2658     | .2254     |           | .2507     |           | .2507     |
| 24   | .2328     | .2481     | .2303     | .2195     | .2481     | .2507     | .2715     |
| Max  | .4854     | .439      | .4572     | .439      | .439      | .439      | .3982     |
| Min  | .208      | .2058     | .2058     | .2058     | .208      | .1715     | .0421     |
| Avg  | .3022     | .2832     | .2854     | .2624     | .2809     | .2729     | .2704     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124028 / 33/11 KV GHODASGAON

Feeder No / Name : 206 / Kund AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .5001     | .5502     | .3018     |           |           |           |
| 2    |           | .5201     | .5502     | .3155     |           |           |           |
| 3    |           | .5135     | .5502     | .3102     |           |           |           |
| 4    |           | .5068     | .5647     | .3102     |           |           |           |
| 5    |           | .5201     | .5944     | .3429     |           |           |           |
| 6    |           | .5639     | .5944     | .3525     |           |           |           |
| 7    |           | .571      | .6093     | .3525     |           |           |           |
| 10   | .6859     |           |           |           | .4374     | .8592     | .7811     |
| 11   |           |           |           |           | .7407     | .9172     |           |
| 12   | .8124     |           |           |           | .8592     | .9488     | .8259     |
| 13   | .8962     |           |           |           | .7499     | .8905     | .8002     |
| 14   | .8436     |           |           |           | .8128     | .8697     | .8162     |
| 15   | .8078     |           |           |           | .8362     | .8539     | .7274     |
| 16   | .7621     |           |           |           | .8069     | .7655     | .7202     |
| 17   | .7316     |           |           |           | .8025     |           | .703      |
| 18   |           |           |           |           |           |           | .703      |
| 22   | .5312     | .5647     | .4115     |           |           |           |           |
| 23   | .5556     | .5647     | .439      |           |           |           |           |
| 24   |           | .5468     | .5647     | .3102     |           |           |           |
| Max  | .8962     | .571      | .6093     | .3525     | .8592     | .9488     | .8259     |
| Min  | .5312     | .5001     | .4115     | .3018     | .4374     | .7655     | .703      |
| Avg  | .7363     | .5372     | .5429     | .3245     | .7557     | .8721     | .7596     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124029 / 33/11 KV NIMKHEDI

Feeder No / Name : 201 / 11 KV Nandwel

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4691    | 2.5911    | 2.5362    | 2.4691    |           | 3.0864    | 2.8032    |
| 2    | 2.4691    | 2.753     | 2.5484    | 2.5463    |           | 3.5494    | 2.7461    |
| 3    | 2.6235    | 2.753     | 2.6246    | 2.5772    |           | 2.9321    | 1.2772    |
| 4    | 2.7778    |           | 2.695     | 2.5926    |           | 2.9321    | 1.2803    |
| 5    | 2.7778    | 2.753     | 2.8018    | 2.6235    |           | 3.0864    | 1.2803    |
| 6    |           |           |           | 2.7006    |           |           |           |
| 9    |           |           |           |           |           |           | 1.2346    |
| 10   |           |           |           |           |           |           | 2.6235    |
| 11   |           |           |           |           |           |           | 2.7778    |
| 12   |           |           |           |           | 3.0864    |           | 2.9321    |
| 13   |           |           |           |           | 3.0864    |           | 3.0864    |
| 14   |           | 3.4163    | 2.6235    |           | 3.0864    | 3.3684    | 3.0864    |
| 15   |           | 3.3227    | 2.7778    |           | 3.0864    | 3.3803    | 2.9321    |
| 16   |           | 3.1824    | 2.9321    |           | 3.0864    | 3.3192    | 2.9321    |
| 17   |           | 3.2674    | 3.0864    |           | 3.0864    | 3.2503    | 2.9321    |
| 18   |           | 2.6609    | 3.0864    |           | 3.2047    | 3.1143    | 3.0864    |
| 19   |           |           |           |           | 3.3951    |           | 2.9321    |
| 20   |           |           |           |           | 3.6808    |           | 2.7778    |
| 21   |           | 2.8851    | 2.6235    |           | 3.5494    | 3.0471    | 2.9321    |
| 22   |           | 2.8224    | 2.7006    |           | 3.5494    | 2.9872    | 2.7778    |
| 23   |           | 2.8258    | 2.4691    |           | 3.5494    | 2.9236    | 2.6235    |
| 24   | 2.4691    | 2.5911    | 2.7898    | 2.7778    |           | 3.3951    | 2.8669    |
| Max  | 2.7778    | 3.4163    | 3.0864    | 2.7778    | 3.6808    | 3.5494    | 3.0864    |
| Min  | 2.4691    | 2.5911    | 2.4691    | 2.4691    | 3.0864    | 2.9236    | 1.2346    |
| Avg  | 2.5977    | 2.9096    | 2.7354    | 2.6124    | 3.2873    | 3.1694    | 2.5677    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124029 / 33/11 KV NIMKHEDI

Feeder No / Name : 202 / 11 KV Charthana Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.6766    |           |           | 1.5623    | 1.406     |
| 7    | 1.6766    |           |           | 1.5623    | 1.7185    |
| 8    | 1.829     |           |           | 1.7029    | 1.7185    |
| 9    |           |           |           | 1.7185    | 1.6204    |
| 10   |           |           |           | 1.6404    |           |
| 11   |           | 1.8747    | 1.6204    | 1.6248    | 1.3889    |
| 12   |           | 1.9528    | 1.6975    | 1.5935    | 1.4661    |
| 13   |           | 1.7966    | 1.7747    | 1.6248    | 1.5432    |
| 14   |           | 1.6404    | 1.6975    |           | 1.4661    |
| 15   |           | 1.5623    | 1.6204    |           | 1.3889    |
| 16   |           | 1.4842    | 1.5432    |           |           |
| 17   |           | 1.5623    | 1.5123    |           |           |
| 18   |           | 1.406     | 1.4661    |           |           |
| Max  | 1.829     | 1.9528    | 1.7747    | 1.7185    | 1.7185    |
| Min  | 1.6766    | 1.406     | 1.4661    | 1.5623    | 1.3889    |
| Avg  | 1.7274    | 1.6599    | 1.6165    | 1.6287    | 1.5241    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124031 / 33/11 KV ANTURLI S/STN

Feeder No / Name : 201 / 11 KV NARWEL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3546    | 1.2346    | 1.0174    | 1.2346    | 1.2346    | 1.2209    |
| 2    | 1.3375    | 1.2689    | 1.1869    | 1.1831    | 1.2346    | 1.1869    |
| 3    | 1.3717    | 1.3375    | 1.2717    | 1.2003    | 1.2346    | 1.2717    |
| 4    | 1.3546    | 1.4232    | 1.3565    | 1.2174    | 1.2346    | 1.3565    |
| 5    | 1.4232    | 1.5604    | 1.6278    | 1.2517    | 1.2346    | 1.3056    |
| 9    | 1.406     | 1.5432    | 1.6448    | 1.5604    | 1.7147    | 1.4413    |
| 10   | 1.3375    | 1.3717    | 1.4243    |           |           | 1.3375    |
| 11   | 1.3375    | 1.1869    | 1.3375    | 1.046     |           | 1.2689    |
| 12   | 1.3717    | 1.2717    |           | 1.1145    |           | 1.1145    |
| 13   | 1.3546    |           |           | 1.166     |           |           |
| 14   |           | 1.2887    |           | 1.0631    |           |           |
| 15   |           | 1.1869    |           | 1.0802    |           |           |
| 16   |           | 1.2378    |           | 1.166     |           |           |
| 17   |           | 1.1869    | 1.6194    | 1.2003    |           |           |
| 18   |           | 1.3395    |           |           |           |           |
| 19   | 1.3889    |           |           |           |           |           |
| 20   | 1.4403    | 1.1869    |           | 1.4918    |           |           |
| 21   |           | 1.2887    |           |           |           |           |
| 22   | 1.3032    |           |           | 1.2346    |           |           |
| 23   | 1.2346    |           |           | 1.3375    |           |           |
| 24   | 1.406     | 1.2003    | 1.2039    | 1.2003    | 1.3032    | 1.3226    |
| Max  | 1.4403    | 1.5604    | 1.6448    | 1.5604    | 1.7147    | 1.4413    |
| Min  | 1.2346    | 1.1869    | 1.0174    | 1.046     | 1.2346    | 1.1145    |
| Avg  | 1.3615    | 1.3008    | 1.3690    | 1.2205    | 1.3130    | 1.2826    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124031 / 33/11 KV ANTURLI S/STN

Feeder No / Name : 202 / 11 KV Anturli -R II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.9376    | 2.0576    | 1.1869    | 2.7778    | 2.915     | 2.713     |
| 2    |           | 1.9719    | 2.0576    | 1.2717    | 2.8635    | 2.915     | 2.7978    |
| 3    |           | 1.989     | 2.0919    | 1.3565    | 2.8292    | 2.9492    | 2.713     |
| 4    |           | 2.0233    | 2.1948    | 1.4413    | 2.8635    | 2.915     | 2.7469    |
| 5    |           | 2.0062    | 2.1948    | 1.5091    | 2.9492    | 2.915     | 2.713     |
| 6    |           | 1.9719    | 2.2634    | 1.6956    |           |           |           |
| 7    |           | 2.0062    | 1.989     | 1.7804    |           |           |           |
| 8    |           | 1.989     |           | 1.8652    |           |           |           |
| 10   |           | 2.9492    | 2.9321    | 2.6282    |           |           |           |
| 11   |           | 2.8635    | 2.9504    | 2.6063    |           |           | 2.5892    |
| 12   |           | 2.8464    | 2.8826    | 2.6578    | 2.2634    |           | 2.5892    |
| 13   |           | 3.1722    |           | 4.2696    | 2.4691    |           |           |
| 14   |           |           | 2.4926    | 4.2181    | 2.0748    |           |           |
| 15   |           |           | 2.4587    | 4.2181    | 2.0576    |           |           |
| 16   |           |           | 2.2552    |           | 2.1605    |           |           |
| 17   |           | 3.0693    | 2.2043    | 2.9321    | 2.2805    |           |           |
| 18   |           |           | 2.5943    |           | 2.2805    |           |           |
| 19   |           | 2.8464    |           |           | 2.2977    |           |           |
| 20   |           | 2.8121    | 2.3739    |           | 2.9492    |           |           |
| 21   |           | 3.0434    | 2.6452    |           | 3.0007    |           |           |
| 22   |           | 2.6578    |           |           | 3.0007    |           |           |
| 23   | 1.9719    | 2.1434    |           |           | 2.9492    |           |           |
| 24   |           | 2.0062    | 2.1262    | 1.5939    | 2.8978    | 2.9835    | 2.9504    |
| Max  | 1.9719    | 3.1722    | 2.9504    | 4.2696    | 3.0007    | 2.9835    | 2.9504    |
| Min  | 1.9719    | 1.9376    | 1.989     | 1.1869    | 2.0576    | 2.915     | 2.5892    |
| Avg  | 1.9719    | 2.4371    | 2.3758    | 2.3269    | 2.6092    | 2.9321    | 2.7266    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124031 / 33/11 KV ANTURLI S/STN

Feeder No / Name : 203 / 11 KV NAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3086     | .3429     | .2883     | 1.9547    | 2.0919    | .3052     |
| 2    |           | .3258     | .3429     | .3052     | 1.9204    | 2.1262    | .3391     |
| 3    |           | .3429     | .3429     | .3222     | 1.8519    | 2.2291    | .373      |
| 4    |           | .3601     | .3429     | .3222     | 1.8861    | 2.2634    | .3391     |
| 5    |           |           | 2.1948    |           | 1.9719    | 2.2634    | .3391     |
| 6    |           |           | 2.2634    |           | 1.989     | 2.2291    | 2.1026    |
| 7    |           |           | 2.1776    |           | 2.0062    | 2.1776    | 2.2043    |
| 8    |           |           | 2.1776    |           | 1.9547    | 2.0919    | 2.2382    |
| 9    |           |           | 1.989     |           | .4458     | .3086     | 2.0348    |
| 10   |           |           | 2.452     |           |           |           | 2.4006    |
| 11   |           | 2.2634    |           | 2.0919    |           |           | .3086     |
| 12   |           | 2.5377    |           | 2.0576    |           |           |           |
| 13   |           | 2.3663    |           | 2.1091    |           |           |           |
| 14   |           | 1.989     |           | 2.2977    |           |           |           |
| 15   |           | 1.8861    |           | 2.0576    |           |           |           |
| 16   |           | 2.0748    |           |           |           |           |           |
| 17   |           |           |           | 2.3663    | .3429     |           |           |
| 18   |           | 2.0405    |           | 2.1776    |           |           |           |
| 19   |           | .3772     | .407      | 2.1434    | .3429     |           |           |
| 20   |           | .3772     | .3222     | .3772     | .3429     |           |           |
| 21   |           | .4115     | .3222     | .4115     | .3429     |           |           |
| 22   |           | .4287     |           | .3944     | .3429     |           |           |
| 23   | .2915     | .3429     |           | 2.0576    | 2.0233    |           |           |
| 24   |           | .3086     | .3429     | .2883     | 2.0748    | 2.0576    | .3429     |
| Max  | .2915     | 2.5377    | 2.452     | 2.3663    | 2.0748    | 2.2634    | 2.4006    |
| Min  | .2915     | .3086     | .3222     | .2883     | .3429     | .3086     | .3052     |
| Avg  | .2915     | 1.1024    | 1.1443    | 1.2981    | 1.3621    | 1.9839    | 1.1106    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124031 / 33/11 KV ANTURLI S/STN

Feeder No / Name : 205 / 11 KV Anturli R-1 Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 2.6063    | 1.6956    |           |           |           |
| 2    |           | 2.4348    | 2.6063    | 1.8991    |           |           |           |
| 3    |           | 2.5549    | 2.5377    | 1.8821    |           |           |           |
| 4    |           | 2.4863    | 2.5377    | 1.9161    |           |           |           |
| 5    |           | 2.4348    | 2.5034    | 1.8991    |           |           |           |
| 6    |           | 2.4863    | 2.5034    | 1.8821    | 2.3491    | 2.7778    | 2.332     |
| 7    |           | 2.4863    | 2.2291    | 1.6956    | 2.3491    | 2.7092    | 2.2977    |
| 8    |           | 2.4691    | 2.4006    | 1.8991    | 2.4006    | 2.6406    | 2.4006    |
| 9    |           |           |           |           | 2.7092    | 2.1948    | 2.6406    |
| 10   |           |           |           |           |           |           | 2.7435    |
| 11   |           |           |           |           | 2.7092    |           | 2.7778    |
| 12   |           |           |           |           | 2.6063    |           | 2.8635    |
| 13   |           |           |           |           | 2.9835    |           |           |
| 23   | 2.4006    | 2.6406    |           |           |           |           |           |
| 24   |           | 2.452     | 2.6406    | 1.8991    |           |           |           |
| Max  | 2.4006    | 2.6406    | 2.6406    | 1.9161    | 2.9835    | 2.7778    | 2.8635    |
| Min  | 2.4006    | 2.4348    | 2.2291    | 1.6956    | 2.3491    | 2.1948    | 2.2977    |
| Avg  | 2.4006    | 2.4939    | 2.5072    | 1.8520    | 2.5867    | 2.5806    | 2.5794    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124036 / 33/11 KV NAIGAON S/STN

Feeder No / Name : 201 / 11 KV KARKI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .3429     | 2.1795    | 2.3137    | 2.0119    | .4024     | .4287     | .3353     |
| 4    | .4191     | 2.3137    | 2.3739    | 2.0957    | .503      | .5028     | .4694     |
| 6    | .6516     | 2.3472    | 2.5987    | 2.146     | .7042     | .5316     | .6371     |
| 8    | .6001     | 2.2131    | 2.5149    | 2.1795    | .6036     | .5087     | .6783     |
| 10   | 2.3922    | .407      | .4115     | .4207     | 2.0957    | 2.5774    | 2.5316    |
| 12   | 2.6322    | .3258     | .3391     | .3506     | 2.4813    | 2.6825    | 2.6452    |
| 14   | 2.2119    | 2.2377    | .3086     | .3681     | 2.3472    |           | 2.713     |
| 16   | 2.0481    | .39       | .3391     | .4161     | 2.3569    | 2.713     | 2.3137    |
| 18   | .6097     | .5258     | .5935     | .5365     | .5087     | 2.5484    | 2.13      |
| 20   | .5868     | .5784     | .6706     | .6036     | .5658     | .3429     | .6203     |
| 22   | .4287     | .3506     | .5144     | .503      | .463      |           | .4409     |
| 24   | .3429     | 2.146     | 2.1795    | 1.9784    | .4024     | .3429     | .3688     |
| Max  | 2.6322    | 2.3472    | 2.5987    | 2.1795    | 2.4813    | 2.713     | 2.713     |
| Min  | .3429     | .3258     | .3086     | .3506     | .4024     | .3429     | .3353     |
| Avg  | 1.1055    | 1.3346    | 1.2631    | 1.1342    | 1.1195    | 1.3179    | 1.3236    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124036 / 33/11 KV NAIGAON S/STN

Feeder No / Name : 202 / 11 KV NAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.9281    | .1715     | .1402     | .1543     | 2.0919    | 2.2131    | 2.0687    |
| 4    | 2.0119    | .2012     | .1753     | .1696     | 2.1434    | 2.2211    | 2.1704    |
| 6    | 2.0957    | .3018     | .208      | .2572     | 2.2291    | 2.2891    | 2.2801    |
| 8    | 2.1293    | .3353     | .1753     | .1677     | 2.4863    | 2.2382    | 2.3148    |
| 10   |           | 1.873     | 2.0719    | 1.8652    | .1402     | .1402     | .1402     |
| 12   | .1865     | 2.3569    | 2.1874    | 2.5484    | .1227     | .1402     | .1402     |
| 14   | .1509     | 2.2119    | 2.4249    | 2.5265    | .1402     |           | .1402     |
| 16   | .1696     | 2.1548    | 1.9433    | 2.0405    | .1402     | .1402     | .1734     |
| 18   | .2515     | .2629     | .2347     | .3353     | .2374     | .1715     | .1865     |
| 20   | .3429     | .2254     | .3353     | .3688     | .2774     | .0857     | .3601     |
| 22   | .2743     | .1402     | .2058     | .3353     | .2058     |           | .2229     |
| 24   | 1.9281    | .1677     | .1402     | .1509     | 2.0919    | 2.1628    | 2.0348    |
| Max  | 2.1293    | 2.3569    | 2.4249    | 2.5484    | 2.4863    | 2.2891    | 2.3148    |
| Min  | .1509     | .1402     | .1402     | .1509     | .1227     | .0857     | .1402     |
| Avg  | 1.0426    | .8669     | .8535     | .9100     | 1.0255    | 1.1802    | 1.0194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124036 / 33/11 KV NAIGAON S/STN

Feeder No / Name : 203 / 11 KV BELASWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .1715     | 1.5089    | 1.6278    | 1.4586    | .2683     | .2572     | .1677     |
| 4    | .2058     | 1.6095    | 1.6263    | 1.5089    | .3018     | .2401     | .2572     |
| 6    | .3429     | 1.6766    | 1.7126    | 1.576     | .3353     | .3052     | .3353     |
| 8    | .2713     | 1.7604    | 1.7661    | 1.6263    | .3018     | .3222     | .3772     |
| 10   | 1.704     | .2012     | .2035     | .1734     | 1.6448    | 1.7604    | 1.7804    |
| 12   | 1.7859    | .1696     | .1696     | .1578     | 1.8442    | 1.9281    | 1.8442    |
| 14   | 1.7368    | .2035     | .1543     | .1753     | 1.95      |           | 1.6095    |
| 16   | 1.7204    | .2713     | .2058     | .1753     | 1.8313    | 1.9113    | 1.7101    |
| 18   | .3353     | .2804     | .3086     | .2683     | .2374     | 1.9616    | .2915     |
| 20   | .3688     | .2601     | .3688     | .3353     | .2883     | .1677     | .3601     |
| 22   | .2012     | .2427     | .2572     | .3018     | .2374     |           | .2883     |
| 24   | .1677     | 1.5089    | 1.5927    | 1.4251    | .2683     | .2035     | .2035     |
| Max  | 1.7859    | 1.7604    | 1.7661    | 1.6263    | 1.95      | 1.9616    | 1.8442    |
| Min  | .1677     | .1696     | .1543     | .1578     | .2374     | .1677     | .1677     |
| Avg  | .7510     | .8078     | .8328     | .7652     | .7924     | .9057     | .7688     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124036 / 33/11 KV NAIGAON S/STN

Feeder No / Name : 204 / 11 KV DHABE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 2.5149    | .1677     | .2103     | .1696     | 2.0576    | 2.4587    | 2.2634    |
| 4    | 2.5987    | .2058     | .2427     | .2058     | 2.2291    | 2.5316    | 2.3472    |
| 6    | 2.7664    | .3086     | .2774     | .2743     | 2.572     | 2.4034    | 2.5434    |
| 8    | 2.7831    | .3429     | .2103     | .2572     | 2.8635    | 2.3807    | 2.6658    |
| 10   | .2713     | 2.652     | 2.7362    | 1.8442    | .2629     | .1578     | .156      |
| 12   | .2743     | 2.753     | 2.7362    | 2.2634    | .1402     | .1578     | .1578     |
| 14   | .2543     | 2.6543    | 2.769     | 2.9005    | .1753     |           | .1402     |
| 16   | .2229     | 2.6216    | 2.8018    | 2.5774    | .1578     | .1402     | .1578     |
| 18   | .3052     | .3467     | .3353     | .3353     | .3601     | .2515     | .2543     |
| 20   | .3688     | .3155     | .4191     | .3688     | .2401     | .1696     |           |
| 22   | .2515     | .2601     | .2515     | .3018     | .2401     |           | .1865     |
| 24   | 2.4981    | .1715     | .1734     | .1677     | 1.9719    | 2.2721    | 2.1795    |
| Max  | 2.7831    | 2.753     | 2.8018    | 2.9005    | 2.8635    | 2.5316    | 2.6658    |
| Min  | .2229     | .1677     | .1734     | .1677     | .1402     | .1402     | .1402     |
| Avg  | 1.2591    | 1.0666    | 1.0969    | .9722     | 1.1059    | 1.2923    | 1.1865    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124036 / 33/11 KV NAIGAON S/STN

Feeder No / Name : 205 / 11 KV PIMPRI NANDU

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .1372     | 1.5089    | 1.3904    | 1.3413    | .1341     | .1715     | .1341     |
| 4    | .1715     | 1.5927    | 1.5261    | 1.4251    | .1341     | .1865     | .1509     |
| 6    | .2572     | 1.6766    | 1.6766    | 1.5089    | .2012     | .2427     | .1715     |
| 8    | .1715     | 1.6766    | 1.5261    | 1.5089    | .1677     | .2629     | .2543     |
| 10   | 1.4419    | .1696     | .1715     | .2103     | 1.3565    | 1.2717    | 1.4251    |
| 12   | 1.5592    | .1543     | .1543     | .1578     | 1.5775    | 1.5261    | 1.5261    |
| 14   | 1.6598    | .1715     | .1372     | .1387     | 1.6108    |           | 1.6108    |
| 16   | 1.6194    | .1865     | .1696     | .1402     | 1.643     | 1.3565    | 1.6956    |
| 18   |           | .2254     | .2515     | .2012     | .2374     | 1.5089    | .2401     |
| 20   | .2572     | .2279     | .2058     | .2012     | .2058     | .1696     | .2713     |
| 22   | .1677     | .1734     | .1715     | .1677     | .2374     |           | .2713     |
| 24   | .1372     | 1.5089    | 1.3413    | 1.3413    | .1341     | .1715     | .1715     |
| Max  | 1.6598    | 1.6766    | 1.6766    | 1.5089    | 1.643     | 1.5261    | 1.6956    |
| Min  | .1372     | .1543     | .1372     | .1387     | .1341     | .1696     | .1341     |
| Avg  | .6891     | .7727     | .7268     | .6952     | .6366     | .6868     | .6602     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124037 / 33/11 KV PURNAD S/STN

Feeder No / Name : 201 / 11 KV Shemlada

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.9007    |           |           |           |           |           |
| 2    | 2.9007    |           |           |           |           |           |
| 3    | 2.9007    |           |           |           |           |           |
| 4    | 2.9007    |           |           |           |           |           |
| 5    | 3.0521    |           |           |           |           |           |
| 6    | 3.0521    |           |           |           |           |           |
| 7    | 3.476     |           |           |           |           |           |
| 10   |           | 3.1131    | 3.0864    | 3.0312    |           |           |
| 11   |           | 3.1493    | 3.1855    | 3.195     |           |           |
| 12   |           | 3.3979    | 3.6046    | 3.3589    |           |           |
| 13   |           |           | 3.3913    | 3.4408    |           |           |
| 14   |           | 3.437     | 3.476     | 3.3979    |           |           |
| 15   |           | 3.5208    | 3.3913    | 3.4808    |           |           |
| 16   |           |           |           | 3.5208    |           |           |
| 17   |           |           |           | 3.6008    |           |           |
| 22   |           |           |           |           | 2.9835    | 3.2693    |
| 23   |           |           |           |           | 3.1493    | 3.0178    |
| 24   |           |           |           |           |           | 3.0178    |
| Max  | 3.476     | 3.5208    | 3.6046    | 3.6008    | 3.1493    | 3.2693    |
| Min  | 2.9007    | 3.1131    | 3.0864    | 3.0312    | 2.9835    | 3.0178    |
| Avg  | 3.0261    | 3.3236    | 3.3559    | 3.3783    | 3.0664    | 3.1016    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124037 / 33/11 KV PURNAD S/STN

Feeder No / Name : 202 / 11 KV Melsangwe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.0864    | .9945     | .8907     | 1.1022    |           |           |           |
| 2    | 2.7435    | .9945     | .8907     | 1.1022    |           |           |           |
| 3    | 2.9835    | 1.1603    | .9717     | 1.1869    |           |           |           |
| 4    | 3.2322    | 1.4918    | 1.2955    | 1.3565    |           |           |           |
| 5    | 3.315     | 1.6575    | 1.5384    | 1.6956    |           |           |           |
| 6    | 3.476     | 1.7404    | 1.7004    | 1.7804    |           |           |           |
| 7    | 3.4808    | 1.7604    | 1.5384    | 1.8004    |           |           |           |
| 8    | 1.4918    | 1.6108    | 1.2146    | 1.5261    |           |           |           |
| 9    | 1.3565    | 1.3413    | 1.2146    | 1.5261    |           |           |           |
| 10   | .9831     | 3.6885    | 3.613     | 3.7304    | .9831     | .9717     | .9116     |
| 11   | .8192     | 3.6885    | 3.6866    | 3.7304    | .8907     | .9945     | .7459     |
| 12   | .8192     | 3.7304    | 3.6046    | 3.858     | .6478     | .7459     | .7459     |
| 13   |           | 3.8999    | 3.8504    | 3.858     | .4915     | .8288     |           |
| 14   |           | 3.8999    | 3.7247    | 3.6866    | .4915     | .8288     | .663      |
| 15   |           | 3.9847    | 3.5227    | 3.6866    | .5735     | .9945     | .663      |
| 16   |           |           |           | 3.7723    | .663      |           | .7459     |
| 17   |           |           |           | 3.8152    | .9012     |           | .8192     |
| 18   |           |           |           | 1.7147    | 1.065     | 1.3413    | 1.2717    |
| 19   |           |           |           |           | 1.4784    | 1.4251    | 1.4413    |
| 20   |           |           |           |           | 1.5708    | 1.1736    | 1.3413    |
| 21   |           |           |           |           | 1.0898    | 1.1736    |           |
| 22   |           |           |           |           | 3.3532    | 3.437     |           |
| 23   |           |           |           |           | 3.2693    | 3.5208    |           |
| 24   |           |           |           |           | 3.1017    | 3.5208    |           |
| Max  | 3.4808    | 3.9847    | 3.8504    | 3.858     | 3.3532    | 3.5208    | 1.4413    |
| Min  | .8192     | .9945     | .8907     | 1.1022    | .4915     | .7459     | .663      |
| Avg  | 2.3156    | 2.3762    | 2.2171    | 2.4960    | 1.3714    | 1.6120    | .9349     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124037 / 33/11 KV PURNAD S/STN

Feeder No / Name : 203 / 11 KV Dui

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5316     | 3.315     | 3.7723    |           |           |           |           |
| 2    | .5316     | 3.3913    | 3.6885    |           |           |           |           |
| 3    | .6201     | 3.3913    | 3.7723    | 3.4294    |           |           |           |
| 4    | .6201     | 3.3913    | 3.7723    | 3.4294    |           |           |           |
| 5    | .8859     | 3.476     | 3.8561    | 3.4294    |           |           |           |
| 6    | .8859     | 3.9438    | 3.8561    | 3.5151    |           |           |           |
| 7    |           |           | 4.1076    | 3.5151    |           |           |           |
| 8    | .7087     |           | .6706     |           |           |           |           |
| 9    | .5544     |           | .503      | 3.476     | .5868     |           | .6783     |
| 10   | 3.9438    |           | .3658     | .4239     | 3.6456    | 3.858     | 3.3589    |
| 11   | 3.7723    | .5087     | .2601     | .4191     | 3.7304    | 3.858     | 3.4808    |
| 12   | 3.9438    | .4191     | .2601     | .3353     | 3.9438    | 4.0752    | 3.4808    |
| 13   | 4.0295    | .3277     | .2686     | .3277     | 4.0295    | 4.0752    | 3.8123    |
| 14   | 4.1152    | .3277     | .2686     | .4144     | 4.0695    | 4.0752    | 3.8123    |
| 15   |           | .2401     |           |           | 4.0695    | .6201     | 3.8123    |
| 16   |           |           |           | .4144     | 4.0695    |           | 3.6466    |
| 17   |           |           |           |           | 3.8504    | .7011     | .5487     |
| 18   |           |           |           | .6001     |           | 3.6808    | .5487     |
| 19   |           |           |           | 3.7209    | .5544     | 3.8561    | .7316     |
| 20   |           |           |           | 3.7209    | .7392     | .7973     | .7316     |
| 21   |           |           |           |           | .6554     | .7087     |           |
| 22   |           |           |           |           | .5735     | .5487     |           |
| 23   |           |           |           |           | .4915     | .5316     |           |
| 24   |           |           |           |           | .4915     | .5316     |           |
| Max  | 4.1152    | 3.9438    | 4.1076    | 3.7209    | 4.0695    | 4.0752    | 3.8123    |
| Min  | .5316     | .2401     | .2601     | .3277     | .4915     | .5316     | .5487     |
| Avg  | 1.9341    | 2.0665    | 2.1016    | 2.0781    | 2.3667    | 2.2798    | 2.3869    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124037 / 33/11 KV PURNAD S/STN

Feeder No / Name : 204 / 11 KV Border Check Post NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .04       | .04       | .0429     | .04       |           |           |           |
| 2    | .0391     | .04       | .04       | .04       |           |           |           |
| 3    | .04       | .04       | .04       | .04       |           |           |           |
| 4    | .04       | .04       | .04       | .04       |           |           |           |
| 5    | .04       | .04       | .04       | .04       |           |           |           |
| 6    | .04       | .04       | .04       | .04       |           |           |           |
| 7    | .04       | .04       | .04       | .04       |           |           |           |
| 8    | .04       | .04       | .04       | .04       |           |           |           |
| 9    | .0505     | .04       | .0429     | .04       | .04       |           | .04       |
| 10   | .0505     | .04       | .04       | .04       | .04       | .04       | .04       |
| 11   | .04       | .04       | .0495     | .04       | .04       | .04       | .04       |
| 12   | .04       | .04       | .0495     | .04       | .04       | .04       | .04       |
| 13   | .0495     | .04       | .04       | .04       | .04       | .04       | .04       |
| 14   | .0505     | .04       | .0495     | .04       | .04       | .04       | .04       |
| 15   | .0495     | .04       | .0495     |           | .04       | .0429     | .04       |
| 16   |           |           |           | .0495     | .04       | .04       | .04       |
| 17   |           |           |           | .04       | .04       | .04       | .0495     |
| 18   |           |           |           | .04       | .04       | .04       | .0495     |
| 19   |           |           |           | .04       | .04       | .04       | .0495     |
| 20   |           |           |           | .0495     | .04       | .7973     | .0495     |
| 21   |           |           |           |           | .04       | .04       |           |
| 22   |           |           |           |           | .04       | .0429     |           |
| 23   |           |           |           |           | .04       | .04       |           |
| 24   |           |           |           |           | .04       | .04       |           |
| Max  | .0505     | .04       | .0495     | .0495     | .04       | .7973     | .0495     |
| Min  | .0391     | .04       | .04       | .04       | .04       | .04       | .04       |
| Avg  | .0433     | .04       | .0429     | .041      | .04       | .0909     | .0432     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124044 / 33/11 KV VADHODA

Feeder No / Name : 201 / 11 KV Vadhoda

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9709     | .8215     | .8962     |           | .9335     | .9709     | .8962     |
| 2    | 1.0082    | .8589     | .8962     | .8962     | .8775     | .9709     | .9149     |
| 3    | 1.0642    | .8589     | .8962     | .8962     | .9149     | .8775     | .9709     |
| 4    | 1.1016    | .8962     | 1.0082    | .9709     | .9896     | .8589     | .9709     |
| 5    | 1.1016    | .9335     | 1.0456    | .9709     | 1.0642    | .9335     | 1.0269    |
| 6    | 1.2323    | 1.1203    | 1.1203    | 1.0829    | 1.1389    | .9709     | 1.0456    |
| 7    | 1.0082    | .9709     | .9335     | 1.0082    | .9149     | 1.0456    | 1.0829    |
| 8    | .9149     | .8775     | .7842     | .8215     | .2801     | .8402     | .7842     |
| 9    | .7095     | .6535     | .7468     | .7095     | .2614     | .7468     | .7842     |
| 10   | .6535     | .5975     | .6722     | .2427     | .2427     | .6161     | .7842     |
| 11   | .6535     | .5601     | .5975     | .5975     |           | .6535     | .6161     |
| 12   | .5975     | .6348     | .5975     | .6348     | .5975     | .6535     | .6348     |
| 13   | .5601     | .6722     | .6348     | .6161     | .6161     | .6161     | .6348     |
| 14   | .5601     | .7095     |           | .6348     | .5975     |           | .6161     |
| 15   | .6161     | .6722     | .6348     | .6348     | .5975     | .6535     | .6348     |
| 16   | .6722     | .6722     | .7468     | .6348     | .5788     | .6348     | .6722     |
| 17   | .7095     | .6722     | .6722     | .7282     | .6908     | .1867     | .7468     |
| 18   | .8962     | .7468     | .7095     | .8029     | .2241     | .8775     | .8962     |
| 19   | 1.0269    | 1.0082    | .9709     | 1.0082    | 1.0269    |           | 1.0456    |
| 20   | 1.0829    | 1.1203    | 1.0829    | 1.1389    | 1.1389    | 1.1016    | 1.0829    |
| 21   | 1.0456    | 1.0456    | 1.0829    | 1.0829    |           |           | 1.1203    |
| 22   | 1.0082    | 1.0082    | 1.0829    | 1.0082    | 1.0269    | 1.0642    | 1.0456    |
| 23   | .9709     | .9709     |           | .9335     |           |           | 1.0082    |
| 24   |           | .9335     | .9335     |           | .9335     | .9522     | .9335     |
| Max  | 1.2323    | 1.1203    | 1.1203    | 1.1389    | 1.1389    | 1.1016    | 1.1203    |
| Min  | .5601     | .5601     | .5975     | .2427     | .2241     | .1867     | .6161     |
| Avg  | .8767     | .8340     | .8521     | .8207     | .7451     | .8112     | .8729     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124044 / 33/11 KV VADHODA

Feeder No / Name : 202 / 11 KV Sule Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8192     | .0305     | .0259     |           | .6882     | .6554     | .7373     |
| 2    | .9012     | .0305     | .0274     | .0549     | .6882     | .6226     | .7373     |
| 3    | 1.065     | .0305     | .0267     | .0549     | .7537     | .7373     | .7842     |
| 4    | 1.1469    | .0914     | .1128     | .1128     | .8029     | .7701     | .7701     |
| 5    | 1.1797    | .1219     | .1738     | .1715     | .8684     | .8192     | .8356     |
| 6    | 1.2125    | .1829     | .2229     | .2538     | .9231     | .8356     | .9995     |
| 7    | 1.2125    | .2591     | .2858     | .3269     | 1.0486    | .852      | 1.2125    |
| 8    | 1.278     |           |           |           |           |           |           |
| 10   | .2439     | .9602     | 1.1888    | 1.0978    | .3605     | .2785     | .2294     |
| 11   | .1829     | 1.1843    | 1.3435    | 1.1142    |           | .3734     | .2743     |
| 12   | .1524     | 1.2193    | 1.07      | 1.1142    | .2949     | .3163     | .2286     |
| 13   | .1524     | 1.1873    | .9717     | 1.0814    | .3277     | .2949     | .2134     |
| 14   | .1219     | 1.07      |           | 1.0814    | .3113     |           | .2134     |
| 15   | .1219     | 1.0715    | .9305     | 1.0322    | .1638     | .1475     | .1829     |
| 16   | .1219     | 1.0151    | 1.0974    | .9831     | .1966     | .1638     | .1524     |
| 17   | .1829     | 1.0997    | 1.1248    | .9503     | .213      | .2622     | .1524     |
| 18   |           |           | .9328     |           |           |           |           |
| 22   | .0305     | .0533     | .0533     | .8029     | .7865     | .7045     | .6249     |
| 23   | .0305     | .0274     |           | .7701     |           |           | .6562     |
| 24   |           | .0305     | .0274     |           | .7209     | .6882     | .7209     |
| Max  | 1.278     | 1.2193    | 1.3435    | 1.1142    | 1.0486    | .852      | 1.2125    |
| Min  | .0305     | .0274     | .0259     | .0549     | .1638     | .1475     | .1524     |
| Avg  | .5642     | .5370     | .5656     | .6877     | .5718     | .5326     | .5403     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124045 / 33/11 KV MUKTAINAGAR

Feeder No / Name : 201 / 11 KV HARTALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8164     |           |           |           | .7883     | .6262     | .6577     |
| 2    | .8135     |           |           |           | .6607     | .4938     | .6584     |
| 3    | .8145     |           |           |           | .66       | .495      | .6584     |
| 4    | .8192     |           |           |           | .6584     | .6584     | .6554     |
| 5    | .8211     |           |           |           | .6478     | .66       | .7563     |
| 6    | .825      |           |           |           | .855      | .6584     | .857      |
| 7    | .9293     |           |           |           | .9261     | .8579     | .9175     |
| 8    |           |           |           |           |           |           | 1.7878    |
| 10   |           | .9934     | .2347     |           |           |           |           |
| 11   |           | 1.1401    | .1968     | 1.03      |           |           |           |
| 12   |           | .968      |           | .9694     |           |           |           |
| 13   |           | 1.144     | .9592     | .9762     |           |           |           |
| 14   |           | 1.043     | 1.03      | .9968     |           |           |           |
| 15   |           | .8599     | 1.0348    | .9625     |           |           |           |
| 16   |           |           | 1.0669    | .8971     |           |           |           |
| 18   |           | .2603     | 1.0608    |           |           |           |           |
| 22   |           |           |           | .7746     | .8776     | .9111     | .6674     |
| 23   |           |           |           | .6938     | .726      | .849      | .6409     |
| 24   | .8342     |           |           |           | .6938     | .6262     | .689      |
| Max  | .9293     | 1.144     | 1.0669    | 1.03      | .9261     | .9111     | 1.7878    |
| Min  | .8135     | .2603     | .1968     | .6938     | .6478     | .4938     | .6409     |
| Avg  | .8342     | .9155     | .7976     | .9126     | .7494     | .6836     | .8133     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124045 / 33/11 KV MUKTAINAGAR

Feeder No / Name : 202 / 11 KV Changdeo

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7217     | .7217     | .7182     | .7554     | .7194     | .7202     | .7202     |
| 2    | .6502     | .6878     | .6831     | .6509     | .6834     | .6481     | .7202     |
| 3    | .6509     | .655      | .6571     | .7037     | .6834     | .7209     | .724      |
| 4    | .727      | .6639     | .655      | .7066     | .6834     | .7202     | .8343     |
| 5    | .7964     | .9259     | .963      | .8907     | .6834     | .7209     | .9183     |
| 6    | 1.0424    | 1.1248    | 1.1214    | 1.0093    | 1.0796    | .7209     | 1.0031    |
| 7    | 1.0434    | 1.0123    | .9659     | .9719     | .8935     | .8527     | .925      |
| 8    | .7997     | .7293     | .6892     | .955      | .6849     | .7618     | .7586     |
| 9    |           | .6372     | .6337     | .6559     | .6863     | .7263     | .7255     |
| 10   |           | .5356     | .6372     |           | .695      | .724      | .6141     |
| 11   |           | .6044     | .6372     | .6392     | .6863     | .6141     | .5847     |
| 12   |           | .6044     | .5658     | .531      | .6543     | .5802     | .6244     |
| 13   |           | .607      | .5979     | .6372     | .6914     | .6212     | .6502     |
| 14   |           | .5627     | .6385     | .7049     | .6516     | .6996     |           |
| 15   |           | .6057     | .6718     | .7026     | .6141     | .727      | .6704     |
| 16   |           | .6235     | .6358     | .6024     | .6543     | .6863     | .7095     |
| 17   | .6379     |           | .6856     |           | .631      | .6024     | .674      |
| 18   | .6711     | .7972     | .724      |           | .6303     | .5985     | .729      |
| 19   | .788      | .9511     | .8688     |           | .7602     | .7905     | .7922     |
| 20   | .7905     | .8761     | .8993     |           | .7972     | .7913     | .7922     |
| 21   | .7913     | .8669     | .8669     |           | .7972     | .7939     | .7922     |
| 22   |           | .8006     |           | .8605     | .8352     | .8334     |           |
| 23   | .7947     | .793      | .6842     | .7913     | .7997     | .7972     | .7964     |
| 24   | .727      | .7285     | .7586     | .7164     | .7554     | .7202     | .7562     |
| Max  | 1.0434    | 1.1248    | 1.1214    | 1.0093    | 1.0796    | .8527     | 1.0031    |
| Min  | .6379     | .5356     | .5658     | .531      | .6141     | .5802     | .5847     |
| Avg  | .7755     | .7441     | .7373     | .7492     | .7271     | .7155     | .7507     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124045 / 33/11 KV MUKTAINAGAR

Feeder No / Name : 204 / 11 KV Belaswadi

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6818     | .8247     | .5693     | .5287     | .8014     | .8006     | .6193     |
| 2    | .5902     | .8422     | .5373     | .5865     | .8131     | .7642     | .6557     |
| 3    | .5816     | .957      | .5544     | .5816     | .8387     | .8006     | .6557     |
| 4    | .5816     | .8361     | .5556     | .5853     | .8396     | .8733     | .653      |
| 5    | .5792     | .8361     | .5926     | .5871     | .8743     | .8733     | .6612     |
| 6    | .6626     | .9531     | .5914     | .5963     | .877      | .9461     | .6605     |
| 7    | .6591     | .9774     | .6735     | .6632     | .5972     | .8761     | .6783     |
| 8    | .9481     | .6639     | .6543     | .5895     | .9441     | .8669     | .7102     |
| 9    |           | .7578     | .5233     | .6351     | 1.0189    | .9753     | .7434     |
| 10   |           | .8352     | .8064     | .8361     | 1.0442    | 1.0146    | 1.0456    |
| 11   |           | .7794     | .8064     | .8282     | 1.0498    | 1.0476    | 1.0734    |
| 12   |           | .8148     | .7362     | .765      | 1.0476    | 1.0837    | 1.0802    |
| 13   |           | .8448     | .777      | .8308     | 1.0476    | .9825     | 1.0677    |
| 14   |           | .8131     | .7882     | .8291     | 1.0553    | .9392     | 1.0665    |
| 15   |           | 1.1245    | .7778     | .8378     | 1.0498    | .8669     | 1.0688    |
| 16   |           | .7746     | .844      | .7981     | 1.0476    | .8697     | 1.0768    |
| 17   | .8006     | .7586     | .8431     |           | 1.0157    | .8089     | 1.0487    |
| 18   | .7194     | .8115     | .7964     |           | .9753     | .7955     | .9105     |
| 19   | .7796     | .6965     | .6878     |           | .9671     | .6979     | .8935     |
| 20   | .856      | .6502     | .6584     |           | .9382     | .6385     | .9342     |
| 21   | .7118     | .5798     | .6154     |           | .9753     | .6639     | .8745     |
| 22   |           | .5196     |           | .5682     | .904      | .6335     | .8177     |
| 23   | .8048     | .5276     |           | .6173     | .8779     | .6066     | .7838     |
| 24   | .5804     | .8387     | .5276     | .5271     | .655      | .837      | .5999     |
| Max  | .9481     | 1.1245    | .844      | .8378     | 1.0553    | 1.0837    | 1.0802    |
| Min  | .5792     | .5196     | .5233     | .5271     | .5972     | .6066     | .5999     |
| Avg  | .7025     | .7924     | .6780     | .6732     | .9273     | .8443     | .8491     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124045 / 33/11 KV MUKTAINAGAR

Feeder No / Name : 205 / 11 KV Muktainagar U-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7321    | 1.6238    | 1.6221    | 1.5927    | 1.7737    | 1.77      | 1.8442    |
| 2    | 1.6238    | 1.5187    | 1.5961    | 1.5582    | 1.77      | 1.6978    | 1.7719    |
| 3    | 1.6238    | 1.5631    | 1.6011    | 1.6324    | 1.6978    | 1.6978    | 1.77      |
| 4    | 1.6616    | 1.6461    | 1.6289    | 1.6461    | 1.9909    | 1.7357    | 1.9105    |
| 5    | 1.7812    | 1.8347    | 1.8695    | 1.9101    | 2.0229    | 1.9888    | 2.0119    |
| 6    | 2.2868    | 2.2245    | 2.4025    | 2.1807    | 2.3309    | 2.2781    | 2.1852    |
| 7    | 2.301     | 2.2268    | 2.0719    | 2.1482    | 2.2616    | 2.1459    | 2.1046    |
| 8    | 2.0182    | 1.7147    | 1.7849    | 1.8617    | 1.8442    | 1.8982    | 1.965     |
| 9    |           | 1.7229    | 1.5743    | 1.7812    | 1.7756    | 1.7812    | 1.8004    |
| 10   |           | 1.6906    | 1.6924    | 1.6011    | 1.7812    | 1.7031    | 1.7228    |
| 11   |           | 1.6511    | 1.6852    | 1.6546    | 1.7193    | 1.7868    | 1.6599    |
| 12   |           | 1.5793    | 1.6067    | 1.6118    | 1.6844    | 1.6616    | 1.6307    |
| 13   |           | 1.5827    | 1.6152    | 1.5793    | 1.6307    | 1.7522    | 1.7085    |
| 14   |           | 1.7193    | 1.6476    | 1.6169    | 1.7831    | 1.7831    | 1.7229    |
| 15   |           | 1.6152    | 1.7156    | 1.7588    | 1.7085    | 1.8481    | 1.7357    |
| 16   |           |           | 1.6494    | 1.7174    | 1.6978    | 1.7812    | 1.7644    |
| 17   | 1.7046    | 1.7339    | 1.6906    |           | 1.5676    | 1.6424    | 1.7302    |
| 18   | 1.5123    | 1.8176    | 1.9909    |           | 1.5508    | 1.6301    | 1.6336    |
| 19   | 1.8903    | 2.0077    | 2.0485    |           | 1.9362    | 1.97      | 1.8983    |
| 20   | 1.9547    | 2.1447    | 2.0229    |           | 2.0271    | 2.0951    | 1.9165    |
| 21   | 1.9125    | 2.1447    | 2.0869    |           | 1.9972    | 2.0929    | 1.9125    |
| 22   |           | 1.9993    |           | 2.0973    | 2.1106    | 2.1357    | 2.0357    |
| 23   | 1.7812    | 1.8665    | 1.8784    | 1.9506    | 1.9993    | 2.0314    | 1.9589    |
| 24   | 1.8461    | 1.7013    | 1.7339    | 1.7302    | 1.8423    | 1.8423    | 1.9165    |
| Max  | 2.301     | 2.2268    | 2.4025    | 2.1807    | 2.3309    | 2.2781    | 2.1852    |
| Min  | 1.5123    | 1.5187    | 1.5743    | 1.5582    | 1.5508    | 1.6301    | 1.6307    |
| Avg  | 1.8420    | 1.7969    | 1.7920    | 1.7700    | 1.8543    | 1.8646    | 1.8463    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124045 / 33/11 KV MUKTAINAGAR

Feeder No / Name : 206 / 11 KV Muktainagar U-II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4572     | .3983     | .3294     |           |           |           |
| 2    |           | .4578     | .3993     | .3232     |           |           |           |
| 3    |           | .4567     | .431      | .3244     |           |           |           |
| 4    |           | .459      | .4268     | .3253     |           |           |           |
| 5    |           | .4601     | .3953     | .329      |           |           |           |
| 6    |           | .4715     | .4262     | .3278     |           |           |           |
| 7    |           | .495      | .329      | .3644     |           |           |           |
| 10   |           |           |           |           | .5713     | .6341     | .5775     |
| 11   |           |           |           |           | .6016     | .7042     | .583      |
| 12   |           |           |           |           | .6318     | .5995     | .5844     |
| 13   |           |           |           |           | .6052     | .6067     | .5748     |
| 14   |           |           |           |           | .6183     | .5761     | .5121     |
| 15   |           |           |           |           | .5761     | .5493     | .5103     |
| 16   |           |           |           |           | .5789     | .5396     | .5091     |
| 17   | .5312     |           |           |           | .4342     | .5364     | .5066     |
| 22   |           | .4236     |           |           |           |           |           |
| 23   | .4572     | .4246     | .3589     |           |           |           |           |
| 24   |           | .4584     | .371      | .293      |           |           |           |
| Max  | .5312     | .495      | .431      | .3644     | .6318     | .7042     | .5844     |
| Min  | .4572     | .4236     | .329      | .293      | .4342     | .5364     | .5066     |
| Avg  | .4942     | .4564     | .3929     | .3271     | .5772     | .5932     | .5447     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124087 / 33/11 KV RUIKHEDA S/STN

Feeder No / Name : 201 / 11 KV Ruikheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           | .4801     | .3258     | .1715     | .2947     | .2058     |
| 2    | .1715     | .4191     | .5258     | .3258     | .1753     | .2947     | .2058     |
| 3    |           |           | .5144     | .333      | .2058     | .3045     | .2229     |
| 4    | .2629     | .503      | .5609     | .4287     | .2401     | .3439     | .2572     |
| 5    |           |           | .583      | .5258     | .2743     | .5249     | .2804     |
| 6    | .2915     | .5868     | .6173     | .5144     | .2804     | .5914     | .2743     |
| 7    | .2401     |           | .5959     | .5197     | .2401     | .439      | .2279     |
| 8    | .2229     | .3353     | .2572     | .2012     | .2347     | .3315     | .1886     |
| 9    | .3391     | .1781     |           | .2012     | .2347     | .3277     | .1844     |
| 10   | .4801     | .1715     | .2865     | .2012     | .5365     | .4588     | .4862     |
| 11   | .5155     | .1067     | .2774     | .2012     | .5197     | .4915     | .4862     |
| 12   | .4641     | .1107     | .2427     | .2012     | .5197     | .4588     | .503      |
| 13   | .4372     | .1402     | .2427     | .1677     | .5197     | .426      | .503      |
| 14   | .3906     | .1174     | .2427     | .1677     | .5197     | .426      | .503      |
| 15   | .3749     | .1067     | .2686     | .1696     | .4359     | .3932     | .4191     |
| 16   | .4001     | .1187     | .2804     | .1677     | .4321     | .4287     | .4191     |
| 17   |           | .2374     | .2915     | .2515     | .4534     | .4382     | .3887     |
| 18   | .3353     | .2915     | .3239     | .3361     | .3277     |           | .3239     |
| 19   |           | .4409     | .421      |           | .373      | .2572     | .4144     |
| 20   | .4191     | .407      | .3887     |           | .3647     | .2454     | .4372     |
| 21   |           | .2058     | .1943     | .2915     | .4024     | .2401     | .421      |
| 22   | .4191     | .4801     | .3239     | .2743     | .3601     | .2401     | .3641     |
| 23   | .4191     | .4801     | .3429     | .1677     | .3258     | .2103     | .3467     |
| 24   | .1715     | .4191     | .4801     | .3429     | .1715     | .3155     | .2058     |
| Max  | .5155     | .5868     | .6173     | .5258     | .5365     | .5914     | .503      |
| Min  | .1715     | .1067     | .1943     | .1677     | .1715     | .2103     | .1844     |
| Avg  | .3435     | .2928     | .3801     | .2871     | .3466     | .3688     | .3445     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124087 / 33/11 KV RUIKHEDA S/STN

Feeder No / Name : 202 / 11 KV Taroda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .6001     | .5144     | .1029     | .1052     | .1029     |
| 2    | .1052     | .503      | .6135     | .5144     | .1052     | .1052     | .1052     |
| 3    |           |           | .6516     | .5258     | .1029     | .1075     | .1029     |
| 4    | .1402     | .5868     | .6661     | .5144     | .1227     | .128      | .1227     |
| 5    |           |           | .6859     | .583      | .1372     | .1629     | .12       |
| 6    | .1715     | .5868     | .703      | .5959     | .1372     | .2054     | .1402     |
| 7    | .1372     |           | .8063     | .6706     | .12       | .1663     | .1029     |
| 8    | .1372     | .1341     | .1715     | .1677     | .1174     | .1067     | .0686     |
| 9    | .1094     | .0663     | .1187     | .1174     | .1006     | .1107     | .0848     |
| 10   | .6093     | .104      | .1134     | .1006     | .7545     | .0949     | .7377     |
| 11   | .6882     |           | .1134     | .1006     | .788      | .6325     | .7545     |
| 12   | .6802     | .0876     | .0995     | .0838     | .788      | .6642     | .7545     |
| 13   | .664      | .0819     | .0983     | .0838     | .7042     | .6478     | .6706     |
| 14   | .6154     | .0633     | .0819     | .0838     | .7042     | .6478     | .6783     |
| 15   | .5921     | .0819     | .0876     | .0838     | .6706     | .6154     | .5935     |
| 16   | .6154     | .0709     | .104      | .0838     | .6964     | .6836     | .5868     |
| 17   |           | .1063     | .0972     | .0838     | .7287     | .6687     | .664      |
| 18   | .1341     | .1147     | .1134     | .0838     | .1189     | .1402     | .1235     |
| 19   |           | .1715     | .1781     |           | .1677     | .1029     | .1423     |
| 20   | .1844     | .1696     | .1619     |           | .1578     | .1052     | .1781     |
| 21   |           | .1715     | .12       | .1715     | .1433     | .12       | .1619     |
| 22   | .4191     | .6001     | .5182     | .1372     | .1372     | .12       | .1372     |
| 23   | .4191     | .6001     | .4858     | .1311     | .1227     | .1227     | .1372     |
| 24   | .1029     | .4191     | .6001     | .5144     | .1052     | .1254     | .1029     |
| Max  | .6882     | .6001     | .8063     | .6706     | .788      | .6836     | .7545     |
| Min  | .1029     | .0633     | .0819     | .0838     | .1006     | .0949     | .0686     |
| Avg  | .3625     | .2484     | .3329     | .2703     | .3264     | .2787     | .3072     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124087 / 33/11 KV RUIKHEDA S/STN

Feeder No / Name : 203 / 11 KV Nimkhedi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .1029     | .1029     | 1.2003    | 1.0883    | 1.0288    |
| 2    | 1.2003    | .1341     | .1029     | .1029     | 1.2269    | 1.085     | 1.0288    |
| 3    |           |           | .1402     | .1052     | 1.2003    | 1.0722    | 1.0867    |
| 4    | 1.2346    | .1844     | .1372     | .1029     | 1.2689    | 1.1523    | 1.1145    |
| 5    |           |           | .1715     | .1402     | 1.286     | 1.2308    | 1.1919    |
| 6    | 1.3321    | .2012     | .1715     | .1543     | 1.286     | 1.3435    | 1.166     |
| 7    | 1.3889    |           | .1578     | .1341     | 1.3717    | 1.2955    | 1.4022    |
| 8    | .1753     | .1844     | .1886     | .1341     | .2012     | .16       | .1372     |
| 9    | .2315     | .1677     | .2429     | .1341     | .2012     | .125      | .1341     |
| 10   | .2204     | 1.2269    | 1.1043    | 1.3413    | .1865     | .0937     | .1174     |
| 11   | .16       | 1.3077    | 1.3603    | 1.3748    | .1341     | .0937     | .1174     |
| 12   | .1781     | 1.2934    | 1.3435    | 1.3748    | .1174     | .0937     | .1006     |
| 13   | .1457     | 1.1069    | 1.2944    | 1.3413    | .1174     | .0937     | .1006     |
| 14   | .144      | 1.1145    | 1.1768    | 1.2574    | .1187     | .0937     | .1006     |
| 15   | .116      | 1.3169    | 1.1768    | 1.2071    | .1006     | .0937     | .0838     |
| 16   | .1296     | 1.085     | 1.1469    | 1.1904    | .1296     | .1029     | .0838     |
| 17   |           | 1.1305    | 1.1012    | 1.1736    | .1457     | .1029     | .1715     |
| 18   | .2012     | .1677     | .1619     | .1844     | .1406     | .1753     | .2107     |
| 19   |           | .2785     | .2429     |           | .108      | .1715     | .1858     |
| 20   | .218      | .2949     | .2105     |           | .1027     | .1578     | .2187     |
| 21   |           | .1715     | .1372     | .1802     | .088      | .1029     | .2134     |
| 22   | .1844     | .1372     | .1372     | 1.1145    | 1.0883    | 1.0288    | 1.0883    |
| 23   | .1844     | .1372     | .1029     | 1.166     | 1.078     | 1.0288    | 1.1174    |
| 24   | 1.166     | .1677     | .1311     | .1029     | 1.166     | 1.0883    | 1.0288    |
| Max  | 1.3889    | 1.3169    | 1.3603    | 1.3748    | 1.3717    | 1.3435    | 1.4022    |
| Min  | .116      | .1341     | .1029     | .1029     | .088      | .0937     | .0838     |
| Avg  | .4784     | .5904     | .5101     | .6418     | .5860     | .5448     | .5512     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124157 / 33/11 KV SAROLA

Feeder No / Name : 201 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1772     | .1638     | .1886     | .1772     | .1886     | .1772     | .1772     |
| 2    | .1867     | .1677     | .1696     | .1867     | .1928     | .1829     | .1867     |
| 3    | .1829     | .2012     | .1715     | .1865     | .1772     | .1886     | .1734     |
| 4    | .2075     | .1772     | .1867     | .1677     | .197      | .1696     | .2033     |
| 5    | .1677     |           | .1867     | .1966     | .181      | .2126     | .1829     |
| 6    | .2103     | .1772     | .132      | .1928     |           | .1307     | .2103     |
| 7    | .1772     | .1715     | .128      | .2241     | .1886     | .1214     | .1867     |
| 8    | .1463     | .1734     | .124      | .1907     | .1907     | .1638     | .1907     |
| 9    | .1494     | .1715     | .1294     | .1677     | .1844     |           |           |
| 10   | .1387     | .1715     | .128      | .1372     | .1781     | .1696     |           |
| 11   | .1734     | .1949     | .1307     | .0671     | .1928     | .1802     |           |
| 12   | .1638     | .1844     | .128      |           | .1772     | .1844     |           |
| 13   | .1417     | .1734     | .1772     |           | .1829     | .1696     |           |
| 14   | .1463     | .1677     | .1734     | .1715     | .1802     | .1949     |           |
| 15   | .1494     | .1734     | .1802     | .1949     | .1848     | .1802     |           |
| 16   | .1341     | .1715     | .1772     | .1907     | .1772     | .1949     |           |
| 17   | .1311     | .1907     | .1867     | .1928     | .1715     | .1949     |           |
| 18   | .1311     | .1907     | .1677     | .1949     | .1907     |           |           |
| 19   | .1341     | .1907     | .1949     | .1886     | .1949     | .1886     |           |
| 20   | .197      | .1928     | .208      | .1907     | .1109     | .2058     |           |
| 21   | .197      | .1829     | .2054     | .1886     | .1715     | .1886     |           |
| 22   | .1802     | .0924     | .1907     | .1907     | .208      | .1886     |           |
| 23   | .1772     | .0905     |           | .1753     | .1829     | .8589     |           |
| 24   | .1867     | .1254     |           | .1715     |           | .1715     | .1772     |
| Max  | .2103     | .2012     | .208      | .2241     | .208      | .8589     | .2103     |
| Min  | .1311     | .0905     | .124      | .0671     | .1109     | .1214     | .1734     |
| Avg  | .1661     | .1694     | .1666     | .1793     | .1820     | .2099     | .1876     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124157 / 33/11 KV SAROLA

Feeder No / Name : 202 / 11 KV Sarola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2378     | .0869     | .0884     | .1772     | .1581     | .1524     | .1738     |
| 2    | .2439     | .0869     | .0899     | .1524     |           | .1753     | .16       |
| 3    | .3086     | .0869     | .0991     | .213      | .1715     | .1638     | .1581     |
| 4    | .1947     | .1143     | .16       | .1334     | .1772     | .2204     | .2294     |
| 5    | .3185     | .1829     | .2401     | .1783     | .208      | .2317     | .3086     |
| 6    | .2915     | .2347     | .2835     | .1429     | .2629     | .2401     | .2629     |
| 11   | .3125     | .3479     | .3521     |           | .3311     | .3102     |           |
| 12   | .2743     | .3048     | .3185     | .3086     | .2934     | .2972     |           |
| 13   | .2778     | .3395     | .2934     | .2972     | .2572     | .2606     |           |
| 14   | .2408     | .3005     | .2743     | .2896     | .2256     | .2641     |           |
| 15   | .2        | .2656     | .2408     | .2709     | .2086     | .2429     |           |
| 19   | .2408     | .2968     | .2675     | .2709     | .253      | .2846     |           |
| 20   | .1758     | .208      | .1894     | .2134     | .16       | .2256     |           |
| 21   | .1555     | .1932     | .2439     | .1915     | .1581     | .2058     |           |
| 22   | .1276     | .2675     | .16       | .1867     | .1509     | .1867     |           |
| 23   | .1124     | .1734     | .1966     | .1957     | .1448     | .2        |           |
| 24   | .2126     | .1334     |           | .1593     |           | .1829     | .1898     |
| Max  | .3185     | .3479     | .3521     | .3086     | .3311     | .3102     | .3086     |
| Min  | .1124     | .0869     | .0884     | .1334     | .1448     | .1524     | .1581     |
| Avg  | .2309     | .2131     | .2186     | .2113     | .2107     | .2261     | .2118     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

EDLABAD[227]

BU 0671

Substation No/ Name :- 124157 / 33/11 KV SAROLA

Feeder No / Name : 203 / 11 KV Forest Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3479     | .3048     | .3086     | .3277     | .3086     | .4161     | .3277     |
| 2    | .2675     | .2778     | .2896     | .3506     | .3048     | .4428     | .2675     |
| 3    | .4207     | .3125     | .286      | .2675     | .2824     | .3605     | .4075     |
| 4    | .3277     | .3841     | .407      | .3856     | .4409     | .4973     | .4409     |
| 5    | .431      | .5365     | .5658     | .2782     | .4207     | .5533     | .4572     |
| 6    | .4374     | .6733     | .6135     | .4096     | .4287     | .5182     | .4588     |
| 9    |           |           |           |           |           | .5182     |           |
| 11   | .6371     | .6249     | .5765     | .4321     | .6371     | .5868     |           |
| 12   | .5636     | .6173     | .5365     | .4268     | .5898     | .5571     |           |
| 13   | .4915     | .5898     | .4973     | .3666     | .5801     | .5304     |           |
| 14   | .5304     | .5182     | .5243     | .3963     | .5243     | .5087     |           |
| 15   | .5304     | .463      | .4111     | .3704     | .4858     | .5087     |           |
| 19   | .5304     | .5721     | .5407     | .5548     | .4214     | .5434     |           |
| 20   | .4858     | .4641     | .4666     | .3978     | .3765     | .4801     |           |
| 21   | .4588     | .426      | .4428     | .3978     | .4588     | .431      |           |
| 22   | .4161     | .3978     | .3763     | .3768     | .3715     | .3374     |           |
| 23   | .3749     | .3768     | .3768     | .3563     | .3898     | .3605     |           |
| 24   | .4031     | .3241     |           | .3201     |           | .3567     | .3506     |
| Max  | .6371     | .6733     | .6135     | .5548     | .6371     | .5868     | .4588     |
| Min  | .2675     | .2778     | .286      | .2675     | .2824     | .3374     | .2675     |
| Avg  | .4503     | .4625     | .4512     | .3774     | .4388     | .4726     | .3872     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124035 / 33/11 KV MALDABHADI

Feeder No / Name : 201 / 11 KV Waghari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4252     | .427      | .5041     | .486      | .4065     | .4188     | .4015     |
| 2    | .428      | .4319     | .5052     | .5132     | .4774     | .4234     | .4737     |
| 3    | .4726     | .4995     | .5062     | .4854     | .5578     | .4607     | .5456     |
| 4    | .4498     | .5584     | .5792     | .5121     | .6057     | .4686     | .6135     |
| 5    | .5585     | .5584     | .6238     | .6406     | .7278     | .6219     | .7311     |
| 6    | .8119     | .6313     | .7274     | .6722     | .8056     | .8073     | .8222     |
| 7    | .7087     | .5267     | .6143     | .5601     | .6907     | .6406     | .7022     |
| 8    | .6351     | .4609     | .5121     | .5816     | .6235     | .6632     | .6207     |
| 9    | .4876     | .5105     | .4627     | .5985     | .5304     | .5642     | .5256     |
| 10   | .4079     | .3521     | .4042     | .3457     | .4553     | .475      | .4428     |
| 11   | .5389     | .3749     | .4065     | .3378     | .4706     | .4321     | .4646     |
| 12   | .3739     | .3891     | .4015     | .3825     | .4627     | .4128     | .4636     |
| 13   | .3705     | .3873     | .3969     | .3641     | .4607     | .4257     | .4449     |
| 14   | .3739     | .385      | .363      | .3969     | .4234     | .442      | .4632     |
| 15   | .3747     | .402      | .3987     | .3939     | .4508     | .4234     | .4636     |
| 16   | .3951     | .4196     | .4131     | .4275     | .4537     | .4506     | .4617     |
| 17   | .3996     | .4424     | .4359     | .4265     | .4924     | .4651     | .5127     |
| 18   | .4716     | .5599     | .5235     | .4275     | .5816     | .5676     | .6215     |
| 19   | .6898     | .7324     | .7442     | .7339     | .7682     | .7339     | .6653     |
| 20   | .5207     | .655      | .6654     | .6979     | .618      | .6315     | .6379     |
| 21   | .5267     | .5941     | .5853     | .6089     | .5627     | .596      | .6057     |
| 22   | .4652     | .4371     | .5453     | .5356     | .5014     | .5581     | .5682     |
| 23   | .4379     | .5177     | .559      | .4666     | .4612     | .5384     | .5338     |
| 24   | .3806     | .4419     | .4993     | .4854     | .3869     | .4161     | .3812     |
| Max  | .8119     | .7324     | .7442     | .7339     | .8056     | .8073     | .8222     |
| Min  | .3705     | .3521     | .363      | .3378     | .3869     | .4128     | .3812     |
| Avg  | .4877     | .4873     | .5157     | .5034     | .5406     | .5265     | .5486     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124035 / 33/11 KV MALDABHADI

Feeder No / Name : 202 / Maldabhadi Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4344     | .3655     | .5054     | .5765     | .4184     | .4161     | .4358     |
| 2    | .4353     | .3996     | .5152     | .57       | .4557     | .4152     | .4934     |
| 3    | .4627     | .3996     | .5322     | .6104     | .57       | .4537     | .5725     |
| 4    | .4656     | .4705     | .5836     | .6241     | .655      | .4607     | .655      |
| 5    | .6543     | .5098     | .7011     | .8102     | .7554     | .6502     | .7423     |
| 6    | .8971     | .5778     | .8642     | 1.0067    | .8562     | .8165     | .8402     |
| 7    | .7415     | .5981     | .8221     | 1.0867    | .7461     | .7316     | .7274     |
| 8    | .695      | .8345     | .9101     | 1.1009    | .6591     | .4982     | .5798     |
| 9    | .4262     | .7746     | .991      | .7167     | .4696     | .5985     |           |
| 10   | .5224     | .5132     | .5105     | .4266     | .7243     | .5741     | .5926     |
| 11   | .5304     | .4348     | .4024     | .3388     | .8848     | .8002     | .7636     |
| 12   | .5921     | .3589     | .3953     | .3272     | .8983     | .7379     | .7645     |
| 13   | .6569     | .3544     | .3999     | .3042     | .8919     | .7133     | .8569     |
| 14   | .7226     | .3547     | .3898     | .3236     | .8601     | .7283     | .7274     |
| 15   | .8421     | .389      | .3999     | .3633     | .893      | .6841     | .6949     |
| 16   | .8516     | .4252     | .3898     | .3305     | .8797     | .6702     | .6975     |
| 17   | .4769     | .503      | .4636     | .4207     | .9437     | .68       | .7581     |
| 18   |           | .5804     | .5853     | .5597     | .4854     | .5238     | .6057     |
| 19   | .5438     | .7247     | .7634     | .7225     | .757      | .6821     | .767      |
| 20   | .4769     | .6392     | .6283     | .6351     | .6488     | .594      | .6516     |
| 21   | .5255     | .5201     | .5441     | .5258     | .5328     | .5258     | .5341     |
| 22   | .4598     | .4844     | .5121     | .4491     | .4854     | .4742     | .4705     |
| 23   | .3996     | .4234     | .4785     | .4249     |           | .4161     | .4748     |
| 24   | .412      | .3655     | .492      | .5221     | .3948     | .4134     | .3974     |
| Max  | .8971     | .8345     | .991      | 1.1009    | .9437     | .8165     | .8569     |
| Min  | .3996     | .3544     | .3898     | .3042     | .3948     | .4134     | .3974     |
| Avg  | .5750     | .5000     | .5742     | .5740     | .6898     | .5941     | .6436     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124035 / 33/11 KV MALDABHADI

Feeder No / Name : 203 / 11KV Wadikilla Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0696     | .071      | .0698     | .0698     | .0697     | .07       | .07       |
| 2    | .0697     | .071      | .0699     | .0698     | .0698     | .0699     | .07       |
| 3    | .0698     | .071      | .0699     | .0697     | .0697     | .0699     | .0701     |
| 4    | .0699     | .0715     | .0699     | .0872     | .0874     | .0874     | .087      |
| 5    | .1047     | .0894     | .0874     |           | .1051     | .1049     | .1045     |
| 6    | .1219     | .1068     | .1048     | .1222     | .1228     | .1224     | .1402     |
| 7    | .1395     | .143      | .1398     | .1393     | .1398     | .1396     | .1402     |
| 8    | .1045     | .143      | .1048     | .1047     | .1219     | .1049     | .1404     |
| 9    | .071      | .0884     | .0873     | .0874     | .1047     | .0875     | .0875     |
| 10   | .0715     | .0699     | .0698     | .07       | .0874     | .07       | .07       |
| 11   | .0715     | .0699     | .0697     | .07       | .0698     | .0697     | .07       |
| 12   | .0704     | .0699     | .0699     | .0699     | .0698     | .0698     |           |
| 13   | .0715     | .0699     | .0696     | .0698     | .0697     | .0699     | .07       |
| 14   | .0715     | .0699     | .0698     | .0699     | .07       | .07       | .07       |
| 15   | .0715     | .0699     | .0699     | .07       | .07       | .07       | .07       |
| 16   | .071      | .0874     | .0696     | .0874     | .07       | .0701     | .0874     |
| 17   | .0715     | .0874     | .0873     | .1049     | .0874     | .0877     | .0874     |
| 18   | .0897     | .1048     | .1045     | .1226     | .1049     | .1053     | .1049     |
| 19   | .1251     | .1396     | .1223     | .1402     | .1399     | .1393     | .1224     |
| 20   | .1421     | .1047     | .1396     | .1228     | .1224     | .1224     | .1399     |
| 21   | .1421     | .0873     | .1049     | .1047     | .0873     | .1048     | .1049     |
| 22   | .1251     | .0699     | .0698     | .0697     | .07       | .0872     | .07       |
| 23   | .1072     | .0699     |           | .0697     | .0698     | .0697     | .07       |
| 24   | .0696     | .0712     | .0699     | .0699     | .0697     | .0698     | .07       |
| Max  | .1421     | .143      | .1398     | .1402     | .1399     | .1396     | .1404     |
| Min  | .0696     | .0699     | .0696     | .0697     | .0697     | .0697     | .07       |
| Avg  | .0913     | .0874     | .0865     | .0896     | .0895     | .0888     | .0920     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 201 / 11 KV Fattepur

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .1715     |
| 2    |           |           |           |           |           |           | .1715     |
| 3    | .1219     |           |           |           | .1372     |           |           |
| 4    |           |           |           |           |           | .1372     | .2058     |
| 6    | .2439     |           |           |           | .3086     |           | .3429     |
| 7    | .2743     |           |           |           | .3772     |           |           |
| 8    | .3353     |           |           |           | .4115     | .4115     | .3944     |
| 9    |           |           |           |           |           | .3772     | .3772     |
| 11   |           | .4115     |           |           |           |           |           |
| 12   |           | .3772     | .4115     | .2572     |           |           |           |
| 14   |           | .3772     | .3429     | .3772     |           |           |           |
| 16   |           | .3429     | .3086     | .3429     |           |           |           |
| 17   |           | .3429     |           |           |           |           |           |
| 18   |           | .2743     |           | .3086     |           |           |           |
| 24   |           |           |           |           | .1219     | .2401     | .2401     |
| Max  | .3353     | .4115     | .4115     | .3772     | .4115     | .4115     | .3944     |
| Min  | .1219     | .2743     | .3086     | .2572     | .1219     | .1372     | .1715     |
| Avg  | .2439     | .3543     | .3543     | .3215     | .2713     | .2915     | .2719     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 203 / 11 KV Tondapur

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .5144     |
| 2    |           |           |           |           |           |           | .5144     |
| 3    | .4801     |           |           |           | .5487     |           |           |
| 4    |           |           |           |           |           | .4801     | .5487     |
| 6    | .5487     |           |           |           | .6344     |           | .6516     |
| 7    | .5487     |           |           |           | .823      |           |           |
| 8    | .7888     |           |           |           | .9431     | .9088     | .9602     |
| 9    |           |           |           |           |           | .8745     | .9259     |
| 11   |           | .4458     |           |           |           |           |           |
| 12   |           | .4115     | 1.0288    | 1.0288    |           |           |           |
| 14   |           | .583      | .7373     | .9259     |           |           |           |
| 16   |           | .8402     | .7716     | .9431     |           |           |           |
| 17   |           | 1.0631    |           |           |           |           |           |
| 18   |           | .9431     | .7716     | .9259     |           |           |           |
| 24   | .5487     |           |           |           | .583      | .5144     | .5487     |
| Max  | .7888     | 1.0631    | 1.0288    | 1.0288    | .9431     | .9088     | .9602     |
| Min  | .4801     | .4115     | .7373     | .9259     | .5487     | .4801     | .5144     |
| Avg  | .583      | .7145     | .8273     | .9559     | .7064     | .6945     | .6663     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 204 / 11 KV Godri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .5144     |           |           |           |           |
| 3    | .1029     |           |           |           | .1372     |           | .1029     |
| 4    |           | .583      | .6173     | .703      |           |           |           |
| 6    |           |           | .8916     |           |           |           |           |
| 8    |           |           | 1.2689    |           |           |           |           |
| 9    |           |           | 1.166     |           |           |           |           |
| 12   | 1.0288    |           |           |           | 1.3375    | 1.1317    | 1.2346    |
| 14   |           |           |           |           |           | 1.166     | 1.1145    |
| 16   | .6859     |           |           | .7545     | .9259     | 1.0288    | .7202     |
| 17   |           | .1029     |           |           |           |           |           |
| 18   |           | .1029     | .1029     | .0686     |           | .9602     | 1.046     |
| 19   |           |           | .1029     |           |           |           |           |
| 20   | .1029     |           | .0857     | .1029     | .12       | .1029     | .12       |
| 22   |           | .1029     |           | .1372     |           | .1372     |           |
| 23   |           |           |           |           |           | .1372     |           |
| 24   | .1219     | .6173     | .5487     | .6859     | .1029     | .1029     | .2401     |
| Max  | 1.0288    | .6173     | 1.2689    | .7545     | 1.3375    | 1.166     | 1.2346    |
| Min  | .1029     | .1029     | .0857     | .0686     | .1029     | .1029     | .1029     |
| Avg  | .4085     | .3018     | .5887     | .4087     | .5247     | .5959     | .6540     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 205 / Tondapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .2058     |
| 2    |           |           | .1886     |           |           |           | .2058     |
| 3    | .2058     |           |           |           | .1886     |           |           |
| 4    |           | .2229     | .2743     | .2572     |           | .2229     | .2572     |
| 6    | .4287     |           | .3772     | .4287     | .2058     |           | .3429     |
| 7    | .3772     |           |           |           | .1886     |           |           |
| 8    | .1886     | .1715     | .3086     | .2743     | .2229     | .2229     | .2743     |
| 9    |           |           | .2572     |           |           | .2058     | .2229     |
| 10   |           | .2058     | .2229     | .1886     |           | .1715     | .2058     |
| 12   | .1543     | .1543     | .1715     | .12       | .1543     | .1715     | .1715     |
| 14   |           | .1715     | .1372     | .1372     |           | .1715     | .1543     |
| 16   | .1543     | .1543     | .1543     | .1886     | .1543     | .2058     | .1886     |
| 17   |           | .1886     |           |           |           |           |           |
| 18   |           | .2401     | .2229     | .2401     |           | .3086     | .2401     |
| 19   |           |           | .3258     |           |           |           |           |
| 20   | .1886     |           | .2743     |           | .2572     | .3258     | .2743     |
| 22   |           |           |           | .2058     |           | .2401     |           |
| 23   |           |           |           |           |           | .2401     |           |
| 24   | .2058     | .1886     | .1886     | .2058     | .1886     | .1886     | .2058     |
| Max  | .4287     | .2401     | .3772     | .4287     | .2572     | .3258     | .3429     |
| Min  | .1543     | .1543     | .1372     | .12       | .1543     | .1715     | .1543     |
| Avg  | .2379     | .1886     | .2387     | .2246     | .1950     | .2229     | .2269     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 206 / Fattapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .9602     |
| 2    |           |           | .9259     |           |           |           | .9602     |
| 3    | .9602     |           |           |           | .9602     |           |           |
| 4    |           | 1.2174    | 1.166     | 1.0631    |           | 1.2174    | 1.3032    |
| 6    | 1.9719    |           | 1.989     | 1.9033    | 1.989     |           | 1.9204    |
| 7    | 1.869     |           |           |           | 1.7318    |           |           |
| 8    | 1.6289    | 1.5261    | 1.4918    | 1.4918    | 1.4232    | 1.5089    | 1.5261    |
| 9    |           |           | 1.1831    |           |           | 1.3032    | 1.2689    |
| 10   |           | 1.1831    | .9774     | 1.1317    |           | .9945     | 1.0802    |
| 12   | .9602     |           | .8402     | .8745     | .8059     | .9259     | .9602     |
| 14   |           | .8573     | .7716     | .8573     |           | .8916     | .8916     |
| 16   | .9774     | .9945     | .8916     | .9431     | .9774     | .9602     | .9431     |
| 17   |           | 1.046     |           |           |           |           |           |
| 18   |           | 1.286     | 1.286     | 1.3032    |           | 1.3375    | 1.2517    |
| 19   |           |           | 1.6975    |           |           |           |           |
| 20   | 1.3546    | 1.4746    | 1.4232    | 1.4403    | 1.4403    | 1.4918    | 1.4746    |
| 22   |           | 1.0802    |           | 1.0974    |           | 1.1317    |           |
| 23   |           |           |           |           |           | .9945     |           |
| 24   | .9259     | .9259     | .9259     | .9774     | .9774     | .9431     | .9602     |
| Max  | 1.9719    | 1.5261    | 1.989     | 1.9033    | 1.989     | 1.5089    | 1.9204    |
| Min  | .9259     | .8573     | .7716     | .8573     | .8059     | .8916     | .8916     |
| Avg  | 1.3310    | 1.1591    | 1.1976    | 1.1894    | 1.2882    | 1.1417    | 1.1924    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 207 / Godri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .2401     |
| 2    |           |           | .2058     |           |           |           | .2401     |
| 3    | .3086     |           |           |           | .3086     |           |           |
| 4    |           | .2743     | .2401     | .2915     |           | .2743     | .2743     |
| 6    | .3772     |           | .3772     | .4115     | .4115     |           | .3086     |
| 7    | .3258     |           |           |           | .3429     |           |           |
| 8    | .3258     | .3429     | .8573     | .3086     | .2743     | .2743     | .3086     |
| 9    |           |           | .2743     |           |           | .2743     | .2743     |
| 10   |           | .2743     | .2058     | .2572     |           | .2572     | .1886     |
| 12   | .2058     | .2058     | .1715     | .2401     | .2058     | .2058     | .2058     |
| 14   |           | .2058     | .1715     | .2401     |           | .2058     | .1886     |
| 16   | .2229     | .2401     | .2058     | .2058     | .2572     | .2229     | .1886     |
| 17   |           | .2401     |           |           |           |           |           |
| 18   |           | .2743     | .2572     | .2743     |           | .3429     | .2572     |
| 19   |           |           | .3086     |           |           |           |           |
| 20   | .3258     | .3086     | .3258     | .1372     | .3772     | .3429     | .1372     |
| 22   |           | .2743     |           | .3086     |           | .2743     |           |
| 23   |           |           |           |           |           | .2572     |           |
| 24   | .3086     | .2572     | .2401     | .2743     | .3086     | .2743     |           |
| Max  | .3772     | .3429     | .8573     | .4115     | .4115     | .3429     | .3086     |
| Min  | .2058     | .2058     | .1715     | .1372     | .2058     | .2058     | .1372     |
| Avg  | .3001     | .2634     | .2955     | .2681     | .3108     | .2672     | .2343     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124038 / 33/11 KV FATTEPUR

Feeder No / Name : 208 / 11 KV DEULGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           |           | .4801     |
| 2    |           |           |           |           |           |           | .5144     |
| 3    | .3601     |           |           |           | .3944     |           |           |
| 4    |           |           |           |           |           | .3601     | .4973     |
| 6    | .4115     |           |           |           | .4458     |           | .5487     |
| 7    | .4973     |           |           |           | .4801     |           |           |
| 8    | .5144     |           |           |           | .583      | .6344     | .6687     |
| 9    |           |           |           |           |           | .5144     | .5487     |
| 11   |           | .6687     |           |           |           |           |           |
| 12   |           | .6859     | .5658     | .5316     |           |           |           |
| 14   |           | .6687     | .5144     | .6001     |           |           |           |
| 16   |           | .583      | .5658     | .583      |           |           |           |
| 17   |           | .5658     |           |           |           |           |           |
| 18   |           | .4801     | .4973     | .583      |           |           |           |
| 24   | .2743     |           |           |           | .4287     | .4115     | .5316     |
| Max  | .5144     | .6859     | .5658     | .6001     | .583      | .6344     | .6687     |
| Min  | .2743     | .4801     | .4973     | .5316     | .3944     | .3601     | .4801     |
| Avg  | .4115     | .6087     | .5358     | .5744     | .4664     | .4801     | .5414     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 201 / 11 KV Jamner -II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .526      |           | .5926     | .5865     | .6381     | .5538     | .4985     |
| 4    | .4504     |           | .5538     | .5521     | .4874     | .5175     | .4601     |
| 5    | .4499     |           |           |           | .5228     |           |           |
| 6    | .4864     |           | .555      | .551      | .6316     | .5544     | .5544     |
| 7    | .4854     |           |           |           | .5573     |           |           |
| 8    |           |           | .4979     | .4211     |           | .4785     | .3873     |
| 9    |           |           |           |           |           | .3378     |           |
| 10   |           |           |           | .3475     | .3135     | .3374     | .2752     |
| 12   |           |           |           | .3865     | .3508     | .3742     | .3666     |
| 14   |           |           |           | .3885     | .3885     | .4108     | .4242     |
| 15   |           |           |           |           |           | .4303     |           |
| 16   |           |           |           | .3749     | .4066     | .3873     | .4133     |
| 18   |           | .3869     |           | .3566     | .3881     | .3677     | .3757     |
| 20   |           | .6257     |           | .7499     | .7052     | .5175     | .5265     |
| 22   |           | .723      |           |           | .7377     | .6296     |           |
| 23   |           |           |           | .7138     |           |           | .7153     |
| 24   | .5442     |           | .668      | .6605     | .3135     | .5914     | .5544     |
| Max  | .5442     | .723      | .668      | .7499     | .7377     | .6296     | .7153     |
| Min  | .4499     | .3869     | .4979     | .3475     | .3135     | .3374     | .2752     |
| Avg  | .4904     | .5785     | .5735     | .5074     | .4955     | .4634     | .4626     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 202 / 11 KV Garkheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | 2.2222    | 2.2245    |           |           |           |
| 4    |           | 2.2222    | 2.4124    |           |           |           |
| 6    |           | 2.2199    | 2.2222    |           |           |           |
| 8    |           | 2.2199    | 2.2245    |           |           |           |
| 9    | 2.058     |           |           |           |           |           |
| 11   |           |           |           |           | 2.5926    |           |
| 12   |           |           |           | 2.5953    | 2.5873    | 2.7778    |
| 14   |           |           |           | 2.3975    | 2.4025    | 2.4       |
| 15   |           |           |           |           | 2.2565    |           |
| 16   |           |           |           | 2.3975    |           | 2.5979    |
| 18   |           |           |           | 2.4049    |           | 2.4148    |
| 24   |           | 2.2222    | 2.037     |           |           |           |
| Max  | 2.058     | 2.2222    | 2.4124    | 2.5953    | 2.5926    | 2.7778    |
| Min  | 2.058     | 2.2199    | 2.037     | 2.3975    | 2.2565    | 2.4       |
| Avg  | 2.058     | 2.2213    | 2.2241    | 2.4488    | 2.4597    | 2.5476    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 203 / 11 KV Kekatnimbhora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 1.7025    |           |           |           | 1.7587    |           |
| 10   |           | 1.7774    | 1.9794    | 1.8148    | 2.4815    | 1.8671    | 2.2593    |
| 12   |           | 1.6498    | 2.3704    | 1.8148    | 2.1253    | 1.826     | 2.2731    |
| 14   |           | 1.4219    | 2.3172    | 1.6263    | 2.0861    | 1.6718    | 2.0698    |
| 15   |           | 1.6464    |           |           |           | 1.6296    |           |
| 16   |           |           | 2.1068    | 1.643     | 2.0818    | 1.5877    | 2.1055    |
| 18   |           | 1.7037    | 2.2407    | 1.7924    | 2.2085    | 1.665     | 1.4876    |
| 20   |           | 1.5524    | 1.9979    | 1.4937    | 2.1415    | 1.4969    | 2.0911    |
| 22   |           | 1.4769    | 1.8538    |           | 2         | 1.4784    |           |
| 23   |           |           |           | 1.4219    |           |           | 1.9832    |
| 24   | 1.2722    |           | 1.4074    | 1.7037    | 1.406     | 1.9457    | 1.4444    |
| Max  | 1.2722    | 1.7774    | 2.3704    | 1.8148    | 2.4815    | 1.9457    | 2.2731    |
| Min  | 1.2722    | 1.4219    | 1.4074    | 1.4219    | 1.406     | 1.4784    | 1.4444    |
| Avg  | 1.2722    | 1.6164    | 2.0342    | 1.6638    | 2.0663    | 1.6927    | 1.9643    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 204 / 11 KV Jamner Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 2.8121    |           | 2.7778    | 2.6215    | 2.95      | 2.9538    | 2.7238    |
| 4    | 2.6513    |           | 2.7721    | 2.5635    | 2.7949    | 2.9508    | 2.5424    |
| 5    | 2.5475    |           |           |           |           |           |           |
| 6    | 2.7093    |           | 3.2913    | 3.099     | 2.9938    | 3.4098    | 2.7778    |
| 7    | 2.9199    |           |           |           | 3.0308    |           |           |
| 8    |           |           | 2.8431    | 2.7905    |           | 3.1482    |           |
| 9    |           |           |           |           |           | 2.8763    |           |
| 10   |           |           |           | 3.1175    | 2.7407    | 1.6347    | 2.8859    |
| 12   |           |           |           | 2.7778    | 2.3975    | 3.0836    | 2.8431    |
| 14   |           |           |           | 2.7266    | 2.5741    | 2.6405    | 2.9199    |
| 15   |           |           |           |           |           | 2.752     |           |
| 16   |           |           |           | 2.8235    | 2.7222    |           | 2.95      |
| 18   |           | 2.8889    |           | 2.7492    | 2.7806    |           | 2.6139    |
| 20   |           | 3.4098    |           | 3.1786    | 3.3402    |           | 3.1676    |
| 22   |           | 3.2526    |           |           | 3.2593    |           | 3.2301    |
| 23   |           |           |           | 3.1676    |           |           |           |
| 24   | 2.8554    |           | 2.8889    | 2.8704    | 2.9965    | 3.0741    | 2.9169    |
| Max  | 2.9199    | 3.4098    | 3.2913    | 3.1786    | 3.3402    | 3.4098    | 3.2301    |
| Min  | 2.5475    | 2.8889    | 2.7721    | 2.5635    | 2.3975    | 1.6347    | 2.5424    |
| Avg  | 2.7493    | 3.1838    | 2.9146    | 2.8738    | 2.8817    | 2.8524    | 2.8701    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 205 / 11 KV Shahapur

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .7499     |           |           | .5987     |           |
| 4    | .9335     |           |           | .6361     |           |
| 5    | .9288     |           |           |           |           |
| 6    | 1.1134    |           |           | .7453     |           |
| 7    | 1.4784    |           |           | 1.2963    |           |
| 9    |           |           |           |           | 1.4937    |
| 11   |           | 1.8728    |           |           |           |
| 12   |           | 1.8709    |           |           |           |
| 14   |           | 1.4967    |           |           |           |
| 16   |           |           | 1.307     |           |           |
| 18   |           |           | 1.1203    |           |           |
| 24   | .5641     |           |           | .5624     |           |
| Max  | 1.4784    | 1.8728    | 1.307     | 1.2963    | 1.4937    |
| Min  | .5641     | 1.4967    | 1.1203    | .5624     | 1.4937    |
| Avg  | .9614     | 1.7468    | 1.2137    | .7678     | 1.4937    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 206 / 11 KV Kekatnimbhora

GAOTHAN FEEDER

Gavthan Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.1248    |           | .8834     | .956      | 1.1248    | .8834     | .959      |
| 4    | 1.3096    |           | 1.1458    | 1.1088    | 1.307     | 1.2197    | 1.1088    |
| 5    | 1.8671    |           |           |           | 1.8519    |           |           |
| 6    | 2.2222    |           | 2.1526    | 2.157     | 2.2177    | 2.122     | 2.0433    |
| 7    | 2.2177    |           |           |           | 2.0328    |           |           |
| 8    |           |           | 1.5154    | 1.5185    |           | 1.48      | 1.4784    |
| 9    |           | 1.3123    |           |           |           | 1.3096    |           |
| 10   |           | 1.1248    | 1.0402    | .9979     | .9959     | 1.0082    | 1.0708    |
| 12   |           | .8632     | .8115     | .8098     | .8834     | .8215     | .8466     |
| 14   |           | .8453     | .8282     | .8098     | .8641     | .8571     | .8861     |
| 15   |           | .9364     |           |           |           | .9709     |           |
| 16   |           |           | .8148     | .824      | .9435     | 1.036     | .898      |
| 18   |           | 1.1088    | 1.184     | 1.4937    | .924      | 1.1088    | 1.3096    |
| 20   |           | 1.5185    | 1.483     | 1.6804    | 1.4815    | 1.5572    | 1.6804    |
| 22   |           | 1.1088    | 1.184     |           | 1.1088    | 1.1134    |           |
| 23   |           |           |           | 1.307     |           |           | 1.1974    |
| 24   | 1.1248    |           | .961      | 1.0338    | 1.1271    | .964      | .999      |
| Max  | 2.2222    | 1.5185    | 2.1526    | 2.157     | 2.2177    | 2.122     | 2.0433    |
| Min  | 1.1248    | .8453     | .8115     | .8098     | .8641     | .8215     | .8466     |
| Avg  | 1.6444    | 1.1023    | 1.1670    | 1.2247    | 1.2971    | 1.1751    | 1.2065    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 207 / Garkheda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.1974    |           | 1.1399    | 1.1619    | 1.1949    | 1.1827    | 1.1458    |
| 4    | 1.3096    |           | 1.3676    | 1.2567    | 1.3003    | 1.3746    | 1.2593    |
| 5    | 1.6701    |           |           |           | 1.6632    |           |           |
| 6    | 1.6667    |           |           |           | 1.8073    |           |           |
| 8    |           |           | 1.7055    | 1.3333    |           | 1.2936    | 1.3704    |
| 9    |           |           |           |           |           | 1.0456    |           |
| 10   |           |           | .9969     | 1.1088    | 1.0534    | 1.0851    | 1.0719    |
| 12   |           |           | .9774     | .8816     | .9406     | 1.0082    | 1.0338    |
| 14   |           |           | .96       | 1.0349    | 1.0556    | 1.0477    | 1.1088    |
| 15   |           |           |           |           |           | 1.0477    |           |
| 16   |           |           | .9969     | 1.0434    | 1.0741    | .9918     | 1.0456    |
| 18   |           | 1.0741    | 1.073     | .9709     | 1.0349    | .9979     | 1.0456    |
| 24   | 1.2186    |           | 1.2147    | 1.267     | 1.2774    | 1.2593    | 1.2963    |
| Max  | 1.6701    | 1.0741    | 1.7055    | 1.3333    | 1.8073    | 1.3746    | 1.3704    |
| Min  | 1.1974    | 1.0741    | .96       | .8816     | .9406     | .9918     | 1.0338    |
| Avg  | 1.4125    | 1.0741    | 1.1591    | 1.1176    | 1.2402    | 1.1213    | 1.1531    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 208 / Express Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .2457     |           | .2447     |           |           |
| 4    | .2452     |           | .244      |           |           |
| 5    | .2447     |           |           |           |           |
| 6    | .2245     |           | .2432     |           |           |
| 7    | .2619     |           | .2427     |           |           |
| 9    |           |           |           | .3753     |           |
| 10   |           |           |           | .4879     |           |
| 12   |           |           |           | .2993     |           |
| 14   |           |           |           | .1867     |           |
| 15   |           |           |           | .2427     |           |
| 16   |           | .3381     |           |           | .3385     |
| 18   |           | .319      |           |           | .2818     |
| 20   |           | .2432     |           |           | .2066     |
| 22   |           |           |           |           | .2068     |
| 23   |           | .2447     |           |           |           |
| 24   | .2452     |           | .245      |           |           |
| Max  | .2619     | .3381     | .245      | .4879     | .3385     |
| Min  | .2245     | .2432     | .2427     | .1867     | .2066     |
| Avg  | .2445     | .2863     | .2439     | .3184     | .2584     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124042 / 33/11 KV JAMNER

Feeder No / Name : 209 / 11 KV Takarkheda Gaothan  
feede Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .7499     |           | .6986     | .7354     | .6756     | .6619     | .773      |
| 4    | 1.1203    |           | .9979     | .9367     | .9335     | .9969     | .961      |
| 6    |           |           | 1.4444    | 1.4074    |           | 1.3704    | 1.5991    |
| 7    | 1.6632    |           |           |           | 1.4045    |           |           |
| 9    |           |           |           |           |           | .9374     |           |
| 10   |           |           |           | .7362     | .7377     | .8215     | .9231     |
| 12   |           |           |           | .6605     | .5705     | .5963     | .6619     |
| 14   |           |           |           | .6605     | .6428     | .5578     | .6653     |
| 15   |           |           |           |           |           | .5758     |           |
| 16   |           |           |           | .7095     | .6838     | .5533     | .7095     |
| 18   |           | .8834     |           | .8402     | .7754     | .8308     | .8589     |
| 20   |           | .9969     |           | 1.0082    | 1.1111    | 1.0556    | 1.1225    |
| 22   |           | .8089     |           |           | .8871     | .865      |           |
| 23   |           |           |           | .7514     |           |           | .8249     |
| 24   | .7506     |           | .7362     | .7377     | .7138     | .7392     | .7593     |
| Max  | 1.6632    | .9969     | 1.4444    | 1.4074    | 1.4045    | 1.3704    | 1.5991    |
| Min  | .7499     | .8089     | .6986     | .6605     | .5705     | .5533     | .6619     |
| Avg  | 1.071     | .8964     | .9693     | .8349     | .8305     | .8125     | .8962     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124119 / 33/11 KV GARKHEDA

Feeder No / Name : 201 / 11kv Gangapuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4518     | .5077     | .4158     |           | 1.7121    | 1.624     |
| 2    |           | .415      | .5255     | .3788     |           | 1.6918    | 1.6385    |
| 3    |           |           | .5426     | .4518     |           | 1.7087    | 1.6385    |
| 4    |           | .4884     | .6161     | .4884     |           | 1.823     | 1.6202    |
| 5    | 1.8673    | .5607     | .6756     | .5228     |           | 2.0119    | 1.6452    |
| 6    | 2.0809    | .6161     |           | .5975     |           | 2.1411    | 1.7756    |
| 7    |           | .58       | .6212     | .5271     | 1.9997    | 2.0813    |           |
| 8    |           | .5271     | .4884     | .3772     | 1.8317    | 2.0924    | 2.0388    |
| 9    | 2.1652    |           | .3388     | .3015     | 1.8631    |           | 1.9222    |
| 10   | .335      |           | .3765     | 1.6232    | .3547     | .3        | .3388     |
| 11   | .32       |           | 2.0065    | 2.1913    | .3558     |           | .3024     |
| 12   | .32       |           | 2.1125    | 1.9757    | .3203     |           | .3388     |
| 13   | .2824     |           | .192      | 2.0217    | .3392     | .3184     | .3206     |
| 14   | .3392     |           | 2.1125    | 1.9861    | .3203     |           | .3012     |
| 15   | .3392     | 2.1436    | 2.0979    | 1.9103    | .3203     |           |           |
| 16   | .3203     |           | 2.0454    | 2.0027    | .3547     | .3573     | .3576     |
| 17   | .3392     | 2.13      | 2.0177    |           | .3388     | .3555     | .3193     |
| 18   | .4312     | 1.8244    | 1.9109    |           | .3576     | .3742     | .3933     |
| 19   | .5249     | .5426     | .5233     |           | .3388     | .4859     |           |
| 20   | .5794     | .5975     | .5607     |           | .5981     | .6174     |           |
| 21   | .5641     | .6155     | .5788     |           | .5981     | .5987     |           |
| 22   | .526      | .5806     | .5601     |           | .5271     | .5601     |           |
| 23   | .526      | .5426     | .5255     |           | .5082     | .5228     |           |
| 24   |           | .4518     | .5077     | .4141     |           | 1.7198    | 1.6076    |
| Max  | 2.1652    | 2.1436    | 2.1125    | 2.1913    | 1.9997    | 2.1411    | 2.0388    |
| Min  | .2824     | .415      | .192      | .3015     | .3203     | .3        | .3012     |
| Avg  | .6977     | .8167     | .9758     | 1.0698    | .6663     | 1.1301    | 1.0696    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124119 / 33/11 KV GARKHEDA

Feeder No / Name : 202 / 11kv Dohari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 1.7574    |           |           |           |           |
| 2    |           |           | 1.6737    |           |           |           |           |
| 3    |           |           | 1.6831    |           |           |           |           |
| 4    |           |           | 1.6831    |           |           |           |           |
| 5    |           |           | 1.7269    |           |           |           |           |
| 6    |           | 1.9742    | 1.7962    |           |           |           |           |
| 7    |           | 1.9742    | 2.007     | 2.0302    |           |           |           |
| 8    |           | 1.9162    | 2.0285    | 2.2131    |           |           |           |
| 9    |           |           | 2.3585    | 1.9757    |           |           |           |
| 10   |           |           |           |           | 1.8633    |           |           |
| 11   | 2.4206    |           |           |           | 2.2404    |           | 2.182     |
| 12   | 2.4148    |           |           |           | 2.3021    |           | 2.1558    |
| 13   | 2.0631    |           |           |           | 2.2245    |           | 1.4681    |
| 14   | 2.1476    |           |           |           | 2.1215    |           | 2.0813    |
| 15   | 1.9766    |           |           |           | 2.0448    |           |           |
| 16   | 1.9656    |           |           |           | 1.9997    | 2.0448    | 1.9625    |
| 17   | 2.0477    |           |           |           | 1.9997    | 2.0873    | 1.8076    |
| 18   | 1.7352    |           |           |           | 2.1582    | 2.0202    | 1.7305    |
| 24   |           | 1.861     | 1.6728    | 1.821     |           |           |           |
| Max  | 2.4206    | 1.9742    | 2.3585    | 2.2131    | 2.3021    | 2.0873    | 2.182     |
| Min  | 1.7352    | 1.861     | 1.6728    | 1.821     | 1.8633    | 2.0202    | 1.4681    |
| Avg  | 2.0964    | 1.9314    | 1.8387    | 2.01      | 2.1060    | 2.0508    | 1.9125    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124119 / 33/11 KV GARKHEDA

Feeder No / Name : 203 / 11KV Khadgaon gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .909      | 1.0154    | .9202     |           | 1.0697    | 1.1238    |
| 2    |           | .8501     | .9865     | .9749     |           | 1.0349    | 1.1619    |
| 3    |           | .9221     | 1.0031    | .9729     |           | .9959     | 1.1607    |
| 4    |           | 1.0123    | 1.1134    | 1.1458    |           | 1.0974    | 1.1607    |
| 5    | 1.4378    | 1.5844    | 1.4548    | 1.434     |           | 1.6375    | 1.3067    |
| 6    | 1.7647    | 1.6297    | 1.7828    | 1.7364    |           | 1.9547    | 1.5444    |
| 7    |           | 1.3503    | 1.5623    | 1.5951    | 1.5828    | 1.6511    | 1.2761    |
| 8    |           | 1.2536    | 1.2035    | 1.1065    | 1.105     | 1.2285    | 1.3136    |
| 9    | 1.0983    |           | 1.2186    | 1.1134    | 1.184     |           | 1.1655    |
| 10   | 1.173     |           | .9694     | 1.0059    | 1.1378    | .9481     | 1.0434    |
| 11   | 1.063     |           | .8436     | .958      | 1.0674    |           | 1.0154    |
| 12   | .9603     |           | .785      | .8435     | .8342     |           | .962      |
| 13   | .7783     |           | .8589     | .9441     | .8527     |           | .963      |
| 14   | .8153     |           | .8249     | .9441     | .8887     |           | .9145     |
| 15   | .9069     | .8677     | .8632     | .8435     | .8761     |           |           |
| 16   | .9794     |           | .7842     | .9659     | .8596     | .7766     | .8282     |
| 17   | 1.0498    | 1.0299    | 1.1157    |           | .9362     | .7997     | .9347     |
| 18   | 1.0674    | 1.1523    | .8031     |           | 1.0802    | 1.0542    | .9386     |
| 19   | 1.4175    | 1.4647    | 1.5579    |           | 1.4864    | 1.3619    |           |
| 20   | 1.386     | 1.4236    | 1.287     |           | 1.5418    | 1.3633    |           |
| 21   | 1.2308    | 1.2581    | 1.2071    |           | 1.4043    | 1.3435    |           |
| 22   | 1.0951    | 1.1523    | 1.1811    |           | 1.3973    | 1.2344    |           |
| 23   | 1.0164    | 1.0948    | 1.126     |           | 1.3278    | 1.1411    |           |
| 24   |           | .9335     | .9871     | 1.1447    |           | 1.2178    | 1.1238    |
| Max  | 1.7647    | 1.6297    | 1.7828    | 1.7364    | 1.5828    | 1.9547    | 1.5444    |
| Min  | .7783     | .8501     | .7842     | .8435     | .8342     | .7766     | .8282     |
| Avg  | 1.1318    | 1.1699    | 1.1056    | 1.0970    | 1.1507    | 1.2172    | 1.1076    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124154 / 33/11 kv RANJANI SUBSTATION

Feeder No / Name : 201 / 11 KV RANJANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2058     | .2058     |           | .1829     | .1715     | .2058     |
| 2    |           | .2401     | .2229     |           |           | .2058     | .2401     |
| 3    | .3258     | .2743     | .2058     | .2743     |           | .2743     | .3086     |
| 4    |           | .3258     | .3086     |           | .2134     | .3429     | .4115     |
| 5    |           | .3429     | .4287     | .463      |           | .3772     | .4801     |
| 6    |           | .4115     | .5144     |           | .4725     | .4458     | .5144     |
| 7    | .5144     | .3944     | .4801     | .4801     | .442      | .4801     | .4973     |
| 8    | .463      | .463      | .4115     | .4458     | .4115     | .4458     | .4287     |
| 9    | .3429     |           |           | .4115     | .3944     |           | .3601     |
| 10   | .2572     | .2743     | .3086     | .3086     | .2743     | .2572     | .3048     |
| 11   | .2401     |           |           | .2743     | .2229     | .2401     |           |
| 12   | .2229     |           | .2572     | .2134     |           | .2058     | .1829     |
| 13   | .1886     |           | .2058     |           | .1886     | .2058     |           |
| 14   |           | .2572     |           | .1829     | .1886     | .1886     | .1829     |
| 15   | .2058     | .2229     | .2229     |           | .1715     |           |           |
| 16   | .2229     | .2401     | .2572     | .2134     | .1886     | .2401     | .1829     |
| 17   | .3258     | .2915     | .2572     | .2896     | .2058     | .2572     |           |
| 18   | .3944     | .4115     | .4115     | .3048     | .3429     | .3429     | .3201     |
| 19   | .4115     | .4115     | .4801     |           | .4458     | .5144     |           |
| 20   | .2915     | .2915     |           | .3048     | .2743     | .3429     | .2743     |
| 21   |           |           |           |           | .2401     | .2401     |           |
| 22   |           | .2572     |           | .2134     |           | .2401     | .2286     |
| 23   |           | .2401     | .2572     |           |           | .2401     |           |
| 24   | .2229     |           | .2058     | .2229     | .1981     |           | .2058     |
| Max  | .5144     | .463      | .5144     | .4801     | .4725     | .5144     | .5144     |
| Min  | .1886     | .2058     | .2058     | .1829     | .1715     | .1715     | .1829     |
| Avg  | .3086     | .3086     | .3134     | .3069     | .2810     | .2980     | .3135     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124154 / 33/11 kv RANJANI SUBSTATION

Feeder No / Name : 202 / 11 KV KAPUSWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6859     | .7202     |           | .4725     | .5658     | .6001     |
| 2    |           | .7202     | .6516     |           |           | .6001     | .6516     |
| 3    | .5144     | .7888     | .6859     | .9259     |           | .6859     | .7716     |
| 4    |           | .823      | .8573     |           | .5335     | .823      | .823      |
| 5    |           | .9431     | 1.0802    | 1.1145    |           | .9431     | .8573     |
| 6    |           | .9259     | 1.1145    |           | .8383     | .9945     | .8745     |
| 7    | .7373     | .7716     | 1.0974    | 1.166     | .8688     | .9945     | .8402     |
| 8    | .6344     | 1.046     | 1.1317    | 1.2003    | .823      | .9259     | .8916     |
| 9    | .5487     |           | 1.0974    | 1.5947    | .7545     |           | .7545     |
| 10   | .7716     | .6173     | .703      | .9259     | .6859     | .6859     | .7011     |
| 11   | 1.2003    |           |           | .8383     | 1.1488    | 1.1145    |           |
| 12   | 1.286     |           | .7716     | .7926     | 1.2003    | 1.1317    | .945      |
| 13   | 1.2517    |           | .7888     |           | 1.2003    | 1.1317    |           |
| 14   | 1.286     | .7545     |           | .7621     | 1.1145    | 1.0974    | .8535     |
| 15   | 1.2517    | .7888     | .7716     |           | .6859     | 1.0631    |           |
| 16   | 1.2003    | .9088     | .8059     | .7773     | 1.0974    | 1.0802    | .8993     |
| 17   | .8402     |           | .8402     | .8688     | 1.2346    | 1.2003    |           |
| 18   | .7888     | .8573     | .9431     | .9755     | 1.2003    | 1.2174    | 1.0669    |
| 19   | .6516     | .9088     | .8745     |           | .7888     | .8402     |           |
| 20   | .583      | .6344     |           | .7011     | .6859     | .823      | .6706     |
| 21   |           | .6173     |           |           | .6516     | .8573     |           |
| 22   |           |           |           | .5182     |           | .8573     | .5182     |
| 23   |           | .5487     | .7716     |           |           | .4973     |           |
| 24   | .4287     |           | .703      | .6859     | .4725     |           | .4801     |
| Max  | 1.286     | 1.046     | 1.1317    | 1.5947    | 1.2346    | 1.2174    | 1.0669    |
| Min  | .4287     | .5487     | .6516     | .5182     | .4725     | .4973     | .4801     |
| Avg  | .8734     | .7847     | .8637     | .9231     | .8662     | .9150     | .7764     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

JAMNER[229]

BU 0680

Substation No/ Name :- 124154 / 33/11 kv RANJANI SUBSTATION

Feeder No / Name : 203 / 11 KV NADRAHAVELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2743     | .4115     |           | .2591     | .2743     | .3086     |
| 2    |           | .3086     | .3772     |           |           | .3086     | .3601     |
| 3    | .4287     | .3944     | .3772     | .4287     |           | .3429     | .4458     |
| 4    |           | .4115     | .5144     |           | .2591     | .4115     | .4801     |
| 5    |           | .4458     | .6173     | .583      |           | .4801     | .5144     |
| 6    |           | .4801     | .6001     |           | .3963     | .5144     | .5316     |
| 7    | .5487     | .4458     | .5144     | .5144     | .4268     | .4973     | .5487     |
| 8    | .4973     | .3944     | .4973     | .5658     | .3963     | .4973     | .4287     |
| 9    | .4287     |           | .4458     | .4287     | .4115     |           | .4115     |
| 10   | .3429     | .3429     | .3601     | .3601     | .4115     | .2401     | .3353     |
| 11   |           |           |           | .3353     |           | .3086     |           |
| 12   | .3429     |           | .3429     | .1715     | .3258     | .3086     | .2896     |
| 13   | .3086     |           | .3601     |           | .2915     | .3258     |           |
| 14   | .3086     | .463      |           | .2743     | .2915     | .3429     | .2591     |
| 15   | .2401     | .3772     | .3601     |           | .2915     | .2915     |           |
| 16   | .2743     | .3429     | .3429     | .2743     | .3086     | .2915     | .3048     |
| 17   | .3258     | .3772     | .3086     | .2591     | .2572     | .3086     |           |
| 18   | .3944     | .4458     | .3944     | .3048     | .3772     | .3772     | .3963     |
| 19   | .4801     | .5316     | .6173     |           | .4801     |           |           |
| 20   | .4287     | .583      |           | .4877     | .3772     | .3944     | .4877     |
| 21   |           |           |           |           | .3429     | .463      |           |
| 22   |           | .4801     |           | .3963     |           | .4801     | .4115     |
| 23   |           | .4115     | .3944     |           |           | .3944     |           |
| 24   | .3601     |           | .3944     | .3601     | .2591     |           | .2743     |
| Max  | .5487     | .583      | .6173     | .583      | .4801     | .5144     | .5487     |
| Min  | .2401     | .2743     | .3086     | .1715     | .2572     | .2401     | .2591     |
| Avg  | .3807     | .4172     | .4332     | .3829     | .3424     | .3740     | .3993     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 201 / 11 KV Neri ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .5121     | .5152     | 1.0277    |           |           |           |
| 2    |           | .5981     | .5158     | .9934     |           |           |           |
| 3    |           | .6487     | .5513     | 1.1072    |           |           |           |
| 4    |           | .6783     | .6125     | 1.0277    |           |           |           |
| 5    |           | .6494     | .6508     | 1.167     |           |           |           |
| 6    |           |           | .7253     | 1.079     |           |           |           |
| 7    |           | .8535     | .9037     | 1.2235    |           |           |           |
| 8    |           | 1.0425    |           | 1.1304    |           |           |           |
| 9    |           | 1.0105    | 1.0596    | 1.0174    |           |           |           |
| 11   | 1.3687    |           |           |           | 1.2332    | 1.0352    | 1.1963    |
| 12   | 1.2511    |           |           |           | 1.1304    | .8088     | 1.1437    |
| 13   | 1.0277    |           |           |           | 1.1976    | .7746     | .9912     |
| 14   | .956      |           |           |           | 1.1598    | .7262     | .8887     |
| 15   | .9412     |           |           |           | 1.1408    | .6939     | .9389     |
| 16   | 1.0729    |           |           |           | .8194     | .8097     | .8877     |
| 17   | .7511     |           |           |           | .8817     | .7969     | .9228     |
| 18   | .5469     |           |           |           | .7178     | .9709     | .8097     |
| 24   |           | .4609     | .4801     | 1.0619    |           |           |           |
| Max  | 1.3687    | 1.0425    | 1.0596    | 1.2235    | 1.2332    | 1.0352    | 1.1963    |
| Min  | .5469     | .4609     | .4801     | .9934     | .7178     | .6939     | .8097     |
| Avg  | .9895     | .7171     | .6683     | 1.0835    | 1.0351    | .8270     | .9724     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 202 / 11 KV Mohadi ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 10-APR-18 | 12-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .3734     |
| 2    |           |           | .362      |
| 3    |           |           | .3753     |
| 4    |           |           | .362      |
| 5    |           |           | .3753     |
| 6    |           |           | .3391     |
| 7    |           |           | .3734     |
| 8    |           |           | .3734     |
| 9    |           | .3734     |           |
| 17   | .3765     |           |           |
| 18   | .3426     |           |           |
| 24   |           |           | .3765     |
| Max  | .3765     | .3734     | .3765     |
| Min  | .3426     | .3734     | .3391     |
| Avg  | .3596     | .3734     | .3678     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 203 / 11 KV NERI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0509    | 1.0458    | 1.1459    | 1.1385    | 1.1283    | 1.2359    | 1.2334    |
| 2    | 1.052     | 1.0458    | 1.1283    | 1.1157    | 1.1635    | 1.1765    | 1.1459    |
| 3    | 1.1237    | 1.1017    | 1.1095    | .9835     | 1.1237    | 1.1408    | 1.1203    |
| 4    | 1.2398    | 1.1385    | 1.1811    | 1.2235    | 1.2722    | 1.1777    | 1.1955    |
| 5    | 1.531     | 1.6732    | 1.4623    | 1.3901    | 1.4937    | 1.6732    | 1.6702    |
| 6    | 2.0538    | 1.8634    | 2.0497    | 1.6956    | 1.8671    | 1.7113    | 1.8861    |
| 7    | 1.8671    | 1.8804    |           | 1.9794    | 1.6804    | 1.8634    | 1.7399    |
| 8    | 1.4204    | 1.2169    |           | 1.3512    |           | 1.4831    | 1.4422    |
| 9    | 1.1203    | 1.1385    | 1.3663    | 1.0918    |           | 1.3093    | 1.2929    |
| 10   | 1.2423    | 1.1791    | 1.1967    | 1.1237    | 1.4846    | 1.1949    | 1.2549    |
| 11   | 1.0884    | 1.0608    | 1.0816    | .9364     | 1.0884    | 1.1203    | 1.1777    |
| 12   | 1.0541    | .9412     | 1.0907    | 1.0456    | 1.1293    | 1.0456    | 1.1397    |
| 13   | 1.0321    | .9965     | 1.1006    | 1.1203    | 1.2323    | 1.0456    | 1.1777    |
| 14   | .9946     | .9613     | 1.1397    | 1.1203    | 1.2696    | 1.0456    | 1.2145    |
| 15   | .9897     | .9432     | 1.1317    | 1.0456    | 1.1385    | 1.0456    | 1.1598    |
| 16   | 1.0353    | 1.036     | 1.1218    | 1.0456    | 1.2549    | 1.0456    | 1.1967    |
| 17   | 1.1028    | 1.2541    | 1.2235    | 1.1203    | 1.1317    | 1.1203    | 1.1777    |
| 18   | 1.2359    | 1.3394    | 1.3176    | 1.307     | 1.3676    | 1.1883    | 1.1974    |
| 19   | 1.5972    | 1.4873    | 1.7873    | 1.6804    | 1.8634    | 1.8107    | 1.6057    |
| 20   | 1.6732    | 1.5961    | 1.5812    | 1.6907    | 1.7493    | 1.7918    | 1.6804    |
| 21   | 1.4451    | 1.4389    | 1.5951    | 1.6139    | 1.5782    | 1.5623    | 1.3512    |
| 22   | 1.4042    | 1.3394    | 1.3176    | 1.3553    | 1.4611    | 1.4422    | 1.311     |
| 23   | 1.2916    | 1.1645    | 1.126     | 1.2411    | 1.369     | 1.3323    | 1.2023    |
| 24   | 1.1611    | 1.2169    | 1.1271    | 1.167     | 1.1611    | 1.312     | 1.153     |
| Max  | 2.0538    | 1.8804    | 2.0497    | 1.9794    | 1.8671    | 1.8634    | 1.8861    |
| Min  | .9897     | .9412     | 1.0816    | .9364     | 1.0884    | 1.0456    | 1.1203    |
| Avg  | 1.2836    | 1.2525    | 1.2901    | 1.2743    | 1.3640    | 1.3281    | 1.3219    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 204 / 11kv Mohadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4325     | .4563     | .4701     | .3765     | .4572     | .4554     | .4527     |
| 2    | .4191     | .4939     | .4687     | .4141     | .4338     | .4939     | .4668     |
| 3    | .4527     | .5324     | .5437     | .5228     | .4884     | .5324     | .5448     |
| 4    | .5636     | .5698     | .6017     | .6161     | .563      | .5693     | .5987     |
| 5    | .7491     | .7514     | .9186     | .8729     | .824      | .7218     | .6613     |
| 6    | .8232     | .8928     | 1.1271    | 1.226     | .9355     | .6655     | 1.1039    |
| 7    | .7484     | .9516     | .7138     | .72       | .7484     | .5704     | .797      |
| 8    | .6728     | .6458     |           | .6756     | .5613     | .6845     | .7015     |
| 9    | .5601     | .5704     | .5319     | .6602     | .5647     | .7225     | .6838     |
| 10   | .6776     | .3881     | .5894     | .3742     | .5271     | .5613     | .6452     |
| 11   | .526      | .296      | .4554     | .3742     | .4409     | .3361     | .4744     |
| 12   | .4894     | .2957     | .4175     | .3742     | .4527     | .3742     | .4175     |
| 13   | .4692     | .3685     |           | .3399     | .373      | .412      | .3985     |
| 14   | .4518     | .4426     |           | .3746     | .3391     | .4116     | .4179     |
| 15   | .4187     | .3873     | .4179     | .4116     | .3961     | .3929     | .4559     |
| 16   | .4518     | .4435     | .3989     | .3734     | .4329     | .4108     | .4744     |
| 17   | .3795     | .407      | .4744     | .3734     | .4749     | .4329     | .4753     |
| 18   | .6078     | .5527     | .5271     | .5613     | .5693     | .4481     | .5613     |
| 19   | .9127     | .8668     | .9035     | .8215     | .8366     | .7225     | .6882     |
| 20   | .7978     | .7577     | .8471     | .7506     | .7978     | .7341     | .7491     |
| 21   | .6078     | .592      | .7153     | .5618     |           | .6776     | .5993     |
| 22   | .4944     | .5533     | .4282     | .5658     | .5319     | .5324     | .5244     |
| 23   | .4559     | .499      | .3753     | .5335     | .4944     | .4904     | .4884     |
| 24   | .4508     | .4563     | .4701     | .3803     | .4527     | .4554     | .4854     |
| Max  | .9127     | .9516     | 1.1271    | 1.226     | .9355     | .7341     | 1.1039    |
| Min  | .3795     | .2957     | .3753     | .3399     | .3391     | .3361     | .3985     |
| Avg  | .5672     | .5488     | .5903     | .5523     | .5520     | .5337     | .5777     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 205 / 11kv Gadegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.2134    | 1.1896    | 1.1989    |           |           |           |
| 2    |           | 1.1949    | 1.1909    | 1.2332    |           |           |           |
| 3    |           | 1.2209    | 1.2093    | 1.2161    |           |           |           |
| 4    |           | 1.3315    | 1.2305    | 1.3699    |           |           |           |
| 5    |           | 1.2277    | 1.2789    | 1.2503    |           |           |           |
| 6    |           | 1.2646    | 1.3315    | 1.3929    |           |           |           |
| 7    |           | 1.1621    | 1.1556    | 1.2846    |           |           |           |
| 8    |           | 1.1936    |           | 1.2846    |           |           |           |
| 9    |           | 1.2675    | 1.1869    | 1.3817    |           |           |           |
| 11   | 1.5435    |           |           |           | 1.2887    | 1.3458    | 1.3159    |
| 12   | 1.5227    |           |           |           | 1.4243    | 1.2099    | 1.0584    |
| 13   | 1.3553    |           |           |           | 1.643     | 1.2742    | 1.0925    |
| 14   | 1.2332    |           |           |           |           | 1.3152    | 1.1267    |
| 15   | 1.2147    |           |           |           | 1.1949    | 1.2209    | 1.0754    |
| 16   | 1.5623    |           |           |           | 1.4014    | 1.3565    | 1.1267    |
| 17   | 1.2305    |           |           |           | 1.1608    | 1.3904    | 1.1267    |
| 18   | 1.1608    |           |           |           | 1.0242    | 1.3687    | 1.0174    |
| 24   |           | 1.2134    | 1.1869    | 1.1989    |           |           |           |
| Max  | 1.5623    | 1.3315    | 1.3315    | 1.3929    | 1.643     | 1.3904    | 1.3159    |
| Min  | 1.1608    | 1.1621    | 1.1556    | 1.1989    | 1.0242    | 1.2099    | 1.0174    |
| Avg  | 1.3529    | 1.2290    | 1.2178    | 1.2811    | 1.3053    | 1.3102    | 1.1175    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 206 / 11 Kv Chinchkheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.2588    | 2.2508    | 2.064     |           |           |           |
| 2    |           | 2.3669    | 2.2533    | 2.2266    |           |           |           |
| 3    |           | 2.4045    | 2.2362    | 2.2382    |           |           |           |
| 4    |           | 2.4446    | 2.2994    | 2.3008    |           |           |           |
| 5    |           | 2.56      | 2.3216    | 2.5976    |           |           |           |
| 6    |           | 2.5574    | 2.3505    | 2.3739    |           |           |           |
| 7    |           | 2.6003    | 2.3216    | 2.3739    |           |           |           |
| 8    |           | 2.56      |           | 3.9225    |           |           |           |
| 9    |           | 2.4421    | 2.5198    | 2.6541    |           |           |           |
| 11   | 2.809     |           |           |           |           | 2.0348    | 3.2564    |
| 12   | 3.2564    |           |           |           | 2.7469    | 2.2357    | 3.0386    |
| 13   | 2.7404    |           |           |           | 2.8656    | 2.8135    |           |
| 14   | 2.7233    |           |           |           | 2.809     | 2.8317    | 2.8679    |
| 15   | 2.6034    |           |           |           | 2.3739    | 2.7282    | 2.7002    |
| 16   | 5.6803    |           |           |           | 3.0432    | 2.7282    | 2.9583    |
| 17   | 2.4258    |           |           |           | 2.9711    | 3.0247    | 2.8554    |
| 18   | 2.1813    |           |           |           | 2.7802    | 2.5434    | 2.5577    |
| 24   |           | 2.2588    | 2.3531    | 2.0553    |           |           |           |
| Max  | 5.6803    | 2.6003    | 2.5198    | 3.9225    | 3.0432    | 3.0247    | 3.2564    |
| Min  | 2.1813    | 2.2588    | 2.2362    | 2.0553    | 2.3739    | 2.0348    | 2.5577    |
| Avg  | 3.0525    | 2.4453    | 2.3229    | 2.4807    | 2.7986    | 2.6175    | 2.8906    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 207 / 11 KV INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     | .0183     | .0183     | .0191     | .0191     | .0182     | .0191     |
| 2    | .0191     | .0182     | .0183     | .0191     | .0191     | .0182     | .0191     |
| 3    | .0191     | .0182     | .0182     | .0191     | .0191     | .0182     | .0191     |
| 4    | .0191     | .0182     | .0183     | .0191     | .0191     | .0183     | .0191     |
| 5    | .0191     | .0182     | .0183     | .0191     | .0191     | .0182     | .0191     |
| 6    | .0191     | .0182     | .0183     | .0191     | .0191     | .0183     | .0191     |
| 7    | .0191     | .0183     | .0182     | .0191     | .0191     | .0183     | .0191     |
| 8    | .0191     | .0182     | .0182     | .0191     | .0191     | .0182     | .0191     |
| 9    | .0191     | .0182     | .0182     | .0191     | .0191     | .0183     | .0182     |
| 10   | .0191     | .0167     |           | .0191     | .0191     | .0191     | .0182     |
| 11   | .0191     | .0167     | .0183     | .0191     | .0191     | .0191     | .0183     |
| 12   | .0191     | .0167     | .0183     | .0191     | .0191     | .0191     | .0182     |
| 13   | .0191     | .0167     | .0182     | .0191     | .0191     | .0191     | .0181     |
| 14   | .0191     | .0166     | .0182     |           | .0191     | .0191     | .0182     |
| 15   | .0191     | .0167     | .0183     | .0191     | .0191     | .0191     | .0182     |
| 16   | .0191     | .0167     | .0182     | .0191     | .0182     | .0191     | .0182     |
| 17   | .0182     | .0166     | .0167     | .0191     | .0181     | .0191     | .0183     |
| 18   | .0182     | .0167     | .0191     | .0191     | .0182     | .0191     | .0191     |
| 19   | .0182     | .0167     | .0191     | .0191     | .0183     | .0191     | .0191     |
| 20   | .0182     | .0167     | .0191     | .0191     | .0182     | .0191     | .0191     |
| 21   | .0183     | .0166     | .0191     | .0191     | .0183     | .0191     | .0191     |
| 22   |           | .0167     | .0191     | .0191     | .0182     | .0191     | .0191     |
| 23   |           | .0167     | .0191     | .0191     | .0182     | .0191     | .0191     |
| 24   | .0191     | .0182     | .0167     | .0191     | .0191     | .0182     | .0191     |
| Max  | .0191     | .0183     | .0191     | .0191     | .0191     | .0191     | .0191     |
| Min  | .0182     | .0166     | .0167     | .0191     | .0181     | .0182     | .0181     |
| Avg  | .0189     | .0173     | .0183     | .0191     | .0188     | .0187     | .0188     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124030 / 33/11 KV NERI

Feeder No / Name : 208 / 11 KV WAGHUR DAM

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 2    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 3    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 4    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 5    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 6    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 7    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 8    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 9    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 10   | .0572     | .0572     |           | .0572     | .0572     | .0572     | .0572     |
| 11   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 12   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 13   | .0572     | .0572     | .0572     | .0572     |           | .0572     | .0572     |
| 14   | .0572     | .0572     | .0572     | .0572     |           | .0572     | .0572     |
| 15   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 16   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 17   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 18   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 19   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 20   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 21   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 22   |           | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 23   |           | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 24   | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| Max  | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| Min  | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| Avg  | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124039 / 33/11 KV SHENDURNI

Feeder No / Name : 202 / 11 KV SHENDURNI GAONTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.829     | 1.829     | 2.0195    |           | 2.0195    | 1.8671    |
| 2    | 1.829     | 1.829     | 1.829     | 2.0195    | 2.0195    | 2.0195    | 1.8671    |
| 3    |           | 1.9433    | 1.9052    | 2.0957    |           | 2.2862    | 1.9052    |
| 4    | 2.5911    | 2.2862    | 2.2862    | 2.1338    | 2.1338    | 2.7054    | 2.2862    |
| 5    |           | 2.5149    | 2.7435    | 3.0483    |           | 2.8578    | 2.7435    |
| 6    | 3.1245    | 3.1626    | 2.9721    | 3.3913    | 3.3913    | 3.4675    | 3.1626    |
| 7    |           | 3.2769    | 3.0483    | 3.3913    |           | 3.4294    | 3.3532    |
| 8    | 3.0102    | 2.8578    | 3.0102    | 2.7816    | 2.7816    | 2.8959    | 2.934     |
| 9    | 2.5149    | 2.6673    | 2.5911    | 2.553     | 2.4768    | 2.6292    | 2.5911    |
| 10   | 2.4006    |           | 2.3624    | 2.4387    | 2.2481    | 2.3624    | 2.2862    |
| 11   | 2.0576    |           | 2.1719    |           | 1.9814    | 2.2481    | 2.0957    |
| 12   | 1.5623    | 2.1719    | 1.9433    | 1.7147    | 1.9814    | 1.9814    | 1.9052    |
| 13   | 1.5623    | 2.0576    | 1.7147    |           | 1.829     | 1.8671    | 1.7909    |
| 14   |           | 1.9433    | 1.6766    | 1.6766    | 1.7909    | 1.7147    | 1.7528    |
| 15   |           | 1.829     | 1.6766    |           | 1.7147    | 1.6385    | 1.7528    |
| 16   | 1.4861    | 1.7147    | 1.6385    | 1.7528    | 1.9052    | 1.7528    | 1.829     |
| 17   | 1.9433    | 2.0576    | 1.9433    |           | 1.9433    | 1.829     | 1.9814    |
| 18   | 2.2481    | 2.2862    | 2.2481    | 2.0957    | 2.21      | 1.9433    | 2.3243    |
| 19   | 2.7816    | 2.7816    | 2.8959    |           | 2.5911    | 2.8578    | 3.0483    |
| 20   | 2.7435    | 2.5911    | 2.7435    | 3.0483    | 2.8578    | 2.7816    | 2.7816    |
| 21   | 2.4006    | 2.3243    | 2.4387    |           | 2.4006    | 2.4768    | 2.3624    |
| 22   | 2.1338    | 2.2481    | 2.1719    | 2.1719    | 2.2862    | 2.21      | 2.21      |
| 23   | 1.9814    | 1.9814    | 2.0957    |           | 2.0957    | 2.0576    | 2.0576    |
| 24   | 1.8671    | 1.9052    | 1.8671    | 2.0195    | 2.0195    | 2.0576    | 1.9052    |
| Max  | 3.1245    | 3.2769    | 3.0483    | 3.3913    | 3.3913    | 3.4675    | 3.3532    |
| Min  | 1.4861    | 1.7147    | 1.6385    | 1.6766    | 1.7147    | 1.6385    | 1.7528    |
| Avg  | 2.2354    | 2.2845    | 2.2418    | 2.3737    | 2.2329    | 2.3370    | 2.2831    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124039 / 33/11 KV SHENDURNI

Feeder No / Name : 203 / 11 KV MENGAON AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           | .381      | .1905     |
| 2    | .1905     |           |           |           | .381      | .3429     | .1905     |
| 3    |           |           |           |           |           | .3429     | .2286     |
| 4    | .2286     |           |           |           | .3429     | .381      | .2667     |
| 5    |           |           |           |           |           | .381      |           |
| 6    | .3048     |           |           |           | .2667     | .3429     |           |
| 7    |           |           |           |           |           | .3429     |           |
| 8    | .381      |           |           |           | .3429     | .381      | .3429     |
| 9    | .3429     |           |           |           | .3429     | .3048     | .4191     |
| 11   |           | .4572     | .381      | .381      |           |           |           |
| 12   |           | .4191     | .3048     |           |           |           |           |
| 13   |           | .381      | .3048     | .3429     |           |           |           |
| 14   |           | .3048     | .3048     |           |           |           |           |
| 15   |           | .2667     | .2667     |           |           |           |           |
| 16   |           | .2667     | .2667     | .3048     |           |           |           |
| 17   |           | .3429     | .3048     | .3429     |           |           |           |
| 18   |           | .2667     | .3048     | .3048     |           |           |           |
| 24   | .2286     |           |           |           | .3429     | .381      | .1905     |
| Max  | .381      | .4572     | .381      | .381      | .381      | .381      | .4191     |
| Min  | .1905     | .2667     | .2667     | .3048     | .2667     | .3048     | .1905     |
| Avg  | .2794     | .3381     | .3048     | .3353     | .3366     | .3581     | .2613     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124039 / 33/11 KV SHENDURNI

Feeder No / Name : 204 / 11 KV BILWADI AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1905     | .1905     | .1524     |           |           |           |
| 2    |           | .1524     | .1905     | .1524     |           |           |           |
| 3    |           | .1524     | .2667     | .1524     |           |           |           |
| 4    |           | .1524     | .2667     | .1524     |           |           |           |
| 5    |           | .1524     | .3429     | .1905     |           |           |           |
| 6    |           | .2286     | .4572     | .2667     |           |           |           |
| 7    |           | .5716     | .6478     | .6097     |           |           |           |
| 8    |           | .6859     | .6859     | .724      |           |           |           |
| 9    |           | .6478     | .5335     | .6478     |           |           |           |
| 11   | .6478     |           |           |           | .724      | .724      | .724      |
| 12   | .5335     |           |           |           | .6478     | .6478     | .5716     |
| 13   | .4954     |           |           |           | .5335     | .5335     | .4191     |
| 14   |           |           |           |           | .381      | .381      | .3429     |
| 15   |           |           |           |           | .2286     | .3429     | .3048     |
| 16   | .4191     |           |           |           | .381      | .3048     | .4191     |
| 17   | .4191     |           |           |           | .4954     | .381      | .4572     |
| 18   | .2286     |           |           |           | .4191     | .381      | .3048     |
| 24   |           | .1905     | .1905     | .1524     |           |           |           |
| Max  | .6478     | .6859     | .6859     | .724      | .724      | .724      | .724      |
| Min  | .2286     | .1524     | .1905     | .1524     | .2286     | .3048     | .3048     |
| Avg  | .4573     | .3125     | .3772     | .3201     | .4763     | .462      | .4429     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124039 / 33/11 KV SHENDURNI

Feeder No / Name : 205 / 11 KV MENGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6478     | .6859     | .6478     |           | .6859     | .6859     |
| 2    | .6859     | .6478     | .6859     | .6478     | .6478     | .6859     | .6859     |
| 3    |           | .724      | .724      | .6859     |           | .7621     | .724      |
| 4    | .7621     | .8764     | .8383     | .724      | .724      | .8383     | .8002     |
| 5    |           | .9907     | .9526     | 1.0669    |           | .9526     | .9907     |
| 6    | 1.2574    | 1.1812    | 1.1431    | 1.3336    | 1.3717    | 1.2193    | 1.2193    |
| 7    |           | 1.0288    | 1.2574    | 1.0288    |           | 1.0669    | 1.1431    |
| 8    | .9907     | .8002     | .9907     | .9526     | .9526     | .724      | .9907     |
| 9    | .8764     | .7621     | .8764     | .8383     | .8002     | .6478     | .724      |
| 10   | .6478     | .5716     | .724      | .6478     | .6097     | .5716     | .6478     |
| 11   | .5716     | .5335     | .4954     |           | .5335     | .4954     | .5335     |
| 12   | .4954     | .4954     | .4954     | .4572     | .4954     | .5335     | .4954     |
| 13   | .4954     | .4954     | .5335     |           | .4572     | .4954     |           |
| 14   |           | .4572     | .4572     | .4572     | .5335     | .4572     | .5335     |
| 15   |           | .4191     | .4954     |           | .4572     | .4954     | .5335     |
| 16   | .5716     | .5335     | .5335     | .4954     | .4954     | .5716     | .6097     |
| 17   | .381      | .6478     | .724      |           | .5716     | .6097     | .6859     |
| 18   | .5716     | .8002     | .8383     | .7621     | .724      | .6859     | .8383     |
| 19   | .7621     | .9145     | .8764     |           | .8764     | .9526     | .9907     |
| 20   | .8764     | .8764     | .8002     | .9145     | .8383     | .9145     | .8383     |
| 21   | .8002     | .8002     | .7621     |           | .8002     | .8383     | .8002     |
| 22   | .724      | .7621     | .7621     | .7621     | .7621     | .7621     | .6859     |
| 23   | .6478     | .724      | .6859     |           | .724      | .724      | .724      |
| 24   | .6859     | .6478     | .6859     | .6478     | .6478     | .6859     | .6859     |
| Max  | 1.2574    | 1.1812    | 1.2574    | 1.3336    | 1.3717    | 1.2193    | 1.2193    |
| Min  | .381      | .4191     | .4572     | .4572     | .4572     | .4572     | .4954     |
| Avg  | .7113     | .7224     | .7510     | .7688     | .7011     | .7240     | .7638     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124118 / 33/11 KV TONDAPUR

Feeder No / Name : 201 / 11 kv Tondapur Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9328     | .823      | .823      | .9145     | .924      | .924      | 1.0059    |
| 2    | .9328     | .823      | .823      | .9145     | .924      | .924      | 1.0608    |
| 3    | .9877     | .8779     | .8779     | 1.0974    | .9979     | .9979     | 1.1706    |
| 4    | 1.0608    | 1.0425    | 1.0425    | 1.0974    | 1.1088    | 1.1273    | 1.4083    |
| 5    | 1.5912    | 1.5546    | 1.5729    | 1.39      | 1.2936    | 1.5524    | 1.7193    |
| 6    | 1.957     | 1.8656    | 1.7558    | 1.7741    | 1.7926    | 2.1253    | 1.8656    |
| 7    | 1.7193    | 1.4632    | 1.4815    | 1.5729    | 1.5893    | 1.6448    | 1.6827    |
| 8    | 1.386     | 1.3352    | 1.1523    | 1.7002    | 1.3676    | 1.3535    | 1.4632    |
| 9    | 1.0059    | 1.2437    | 1.0059    | 1.46      | 1.2752    | 1.2437    | 1.1888    |
| 10   | 1.0059    |           | .7865     | .961      | 1.1273    | 1.1706    | 2.0484    |
| 11   | .7865     | .7682     | .6401     | .9055     | 1.1643    | .9877     | 1.646     |
| 12   | .7682     | 1.0059    | .695      | .9055     | 1.1458    | .9145     | .7682     |
| 13   | .8048     | .8596     | .6584     | .9795     | 1.1273    | .9145     | .9511     |
| 14   | .8962     | .8779     | .6767     | .9795     | 1.0903    | .8962     | .9145     |
| 15   | .9877     | .8779     | .7682     | .9795     | 1.0719    | .8413     | .9511     |
| 16   | .7316     | .9511     | .8048     | 1.0349    | 1.2567    | 1.0974    | 1.0059    |
| 17   | 1.134     | 1.1706    | .9145     | 1.1643    | 1.3306    | 1.134     |           |
| 18   | 1.2254    | 1.3535    | 1.1888    | 1.4415    | 1.5154    | 1.1888    |           |
| 19   | 1.1888    | 1.134     | 1.39      | 1.7187    | 1.7187    | 1.3169    |           |
| 20   | 1.0791    | 1.0608    | 1.1888    | 1.3306    | 1.3306    | 1.4632    |           |
| 21   | .9877     | 1.0059    |           | 1.1643    | 1.1643    | 1.3352    |           |
| 22   | .9511     | .9511     | .9877     | 1.0534    | 1.0534    | 1.1706    |           |
| 23   | .8779     | .8779     | .9877     | .9425     | .9979     | .9877     |           |
| 24   | .9328     | .823      | .823      | .8596     | .9425     | .9979     | .9511     |
| Max  | 1.957     | 1.8656    | 1.7558    | 1.7741    | 1.7926    | 2.1253    | 2.0484    |
| Min  | .7316     | .7682     | .6401     | .8596     | .924      | .8413     | .7682     |
| Avg  | 1.0805    | 1.0759    | 1.0020    | 1.1809    | 1.2213    | 1.1796    | 1.2824    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124118 / 33/11 KV TONDAPUR

Feeder No / Name : 202 / TONDAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8871     | 1.7002    | 1.7002    | 1.9418    | .4481     | .5601     | .7468     |
| 2    | .8871     | 1.7002    | 1.6078    | 1.9418    |           | .5601     | .8402     |
| 3    | .924      | 1.7372    | 1.6078    | 1.9791    | .4668     | .5601     | .8962     |
| 4    | .924      | 1.7926    | 1.5524    | 2.0538    | .4668     | .5601     | .9709     |
| 5    | .9425     | 1.8296    | 1.5708    | 2.0538    | .4854     | .5601     | .9896     |
| 6    | .9425     | 1.8111    | 1.5339    | 2.1658    | .5228     | .6535     | 1.0269    |
| 7    | .9425     | 1.848     | 2.1992    | 2.3339    | .7468     | .8589     | 1.0082    |
| 8    | .9979     | 2.1068    | 2.2916    | 2.3899    | .7468     | .8779     | 1.0269    |
| 9    |           | 1.922     | .5975     | 2.3899    | .7842     | .9335     | 1.0269    |
| 11   | 2.4579    | .8131     | .9896     | .9896     | 2.6326    | 2.4272    | 2.4832    |
| 12   | 2.4025    | .8779     | .9896     | .9896     | 2.7073    | 2.4691    | 2.4832    |
| 13   | 2.4025    | 1.0059    | .9335     | .8589     | 2.6699    | 2.5393    | 2.4646    |
| 14   | 2.2916    | .961      | .8589     | .8589     | 2.6513    | 2.4832    | 2.4832    |
| 15   | 2.2546    | .9055     | .8215     | .8029     | 2.6139    | 2.4646    | 2.4272    |
| 16   |           | .8316     | .7842     | .7468     | 2.4272    | 2.4272    | 2.4272    |
| 17   |           | .8131     | .8029     | .8402     | 2.4646    | 2.4272    |           |
| 18   | 1.7556    | .8131     | .8029     | .7842     | 2.2779    | 2.4272    |           |
| 24   | .7023     | 1.5708    | 1.7187    | 1.9231    | .5601     | .5601     | .6535     |
| Max  | 2.4579    | 2.1068    | 2.2916    | 2.3899    | 2.7073    | 2.5393    | 2.4832    |
| Min  | .7023     | .8131     | .5975     | .7468     | .4481     | .5601     | .6535     |
| Avg  | 1.4476    | 1.3911    | 1.2979    | 1.558     | 1.5101    | 1.4639    | 1.4972    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124128 / 33/11 NACHANKHEDA

Feeder No / Name : 201 / 11 KV BHARADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5093     | .4207     | .3814     | .3104     | .4715     | .4854     | .5258     |
| 2    | .547      | .3856     | .3814     | .3093     | .4904     | .5028     | .5083     |
| 3    | .6036     | .4382     | .3641     | .3437     | .547      | .4854     | .5434     |
| 4    | .7356     | .4557     | .4334     | .3621     | .6036     | .5895     | .5609     |
| 5    | .8488     | .6661     | .5201     | .4828     | .6979     | .7975     | .6661     |
| 6    | 1.2071    | .7888     | .7975     | .638      | 1.1694    | 1.0402    | 1.0166    |
| 7    | 1.1317    | .8413     | .9189     | .6874     | .9709     | 1.0229    | 1.0341    |
| 8    | .9114     | 1.0166    | .9138     | .638      | .8669     | .8413     | .9054     |
| 9    | .631      | .7628     | .8276     | .6979     |           | .6135     | .7545     |
| 10   | .5959     | .5201     | .5862     | .5093     |           | .5959     | .5281     |
| 11   | .4908     | .5548     | .5        | .3772     | .6588     | .6485     | .6413     |
| 12   | .5258     | .4854     | .4655     | .3395     | .5895     | .5258     | .5658     |
| 13   | .4733     | .4854     | .4828     | .3018     | .5201     | .4908     | .5281     |
| 14   | .4382     | .4681     |           | .4527     | .4854     | .4733     | .4904     |
| 15   | .4557     | .4854     | .4483     | .3772     | .4508     | .4557     | .4715     |
| 16   | .5258     | .5028     | .5173     | .547      | .4508     | .5083     | .547      |
| 17   | .4908     | .5895     |           | .6602     |           | .5258     | .6036     |
| 18   | .4908     | .7108     | .7069     | .6979     | .6068     | .5609     | .7167     |
| 19   | .8063     | .9015     | .8621     | .9808     | .9362     | .9114     | .9431     |
| 20   | .7888     | .8669     |           | .8299     | .8149     | .8764     | .569      |
| 21   | .6542     | .6588     |           | .679      | .6241     | .7011     | .6035     |
| 22   | .5784     | .6241     | .4483     | .6036     | .5721     | .5959     | .5517     |
| 23   | .5258     | .5548     | .4138     | .5658     | .5375     | .5784     | .5173     |
| 24   | .547      | .4382     | .3641     | .3448     | .5093     | .5028     | .5258     |
| Max  | 1.2071    | 1.0166    | .9189     | .9808     | 1.1694    | 1.0402    | 1.0341    |
| Min  | .4382     | .3856     | .3641     | .3018     | .4508     | .4557     | .4715     |
| Avg  | .6464     | .6093     | .5667     | .5307     | .6464     | .6387     | .6383     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124128 / 33/11 NACHANKHEDA

Feeder No / Name : 202 / 11 KV NANDRA PL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5258     | .6084     | .6224     | .5704     | .4557     | .5658     | .4949     |
| 2    | .5258     | .5704     | .6413     | .5704     | .4908     | .547      | .5139     |
| 3    | .5609     | .6084     | .6413     | .6275     | .5258     | .5281     | .5329     |
| 4    | .631      | .6845     | .7167     | .7035     | .5784     | .5847     | .571      |
| 5    | .6836     | .9887     | .8676     | .7606     | .631      | .7167     | .6852     |
| 6    | .7712     | 1.0648    | 1.0562    | .7986     | .7888     | .8299     | .7613     |
| 7    | .6485     | .9127     |           | .8176     | .7545     | .5847     | .7233     |
| 8    | .5258     |           | .8556     | .7986     | .6224     | .7225     | .5609     |
| 9    | .7225     | .8299     | .7796     | .7362     | .6413     | .6845     | .6135     |
| 10   | .6845     | .7922     | .7225     | .5784     | .6036     | .7225     | .5609     |
| 11   | .5704     | .6413     | .5894     | .4382     | .6413     | .6465     | .5609     |
| 12   | .5324     | .547      | .5514     | .4908     | .5658     | .6084     | .5083     |
| 13   | .5134     | .5658     | .5324     | .4243     | .547      | .552      | .4382     |
| 14   | .5324     | .547      |           | .4207     | .5847     | .5329     | .4908     |
| 15   | .6084     | .5658     | .5134     | .4382     | .6224     | .5139     | .4557     |
| 16   | .6275     | .547      | .4563     | .4382     | .6036     | .5329     | .5083     |
| 17   |           | .5093     |           | .4557     |           | .6091     | .5434     |
| 18   | .4563     | .679      | .7035     | .5258     | .6036     | .6471     | .5784     |
| 19   | 1.0648    | .9242     | .9317     | .8676     | .9431     | .9136     | .8413     |
| 20   | .9127     | .7922     | .7606     | .7362     | .7922     | .8374     | .7415     |
| 21   | .7225     | .7545     | .6655     | .5609     | .6413     | .7233     | .5894     |
| 22   | .6084     | .679      | .6465     | .5258     | .5658     | .6662     | .5894     |
| 23   | .5324     | .6413     | .6084     | .5083     | .547      | .6091     | .5704     |
| 24   | .5609     | .5704     | .6413     | .5704     | .4908     | .5658     | .4949     |
| Max  | 1.0648    | 1.0648    | 1.0562    | .8676     | .9431     | .9136     | .8413     |
| Min  | .4563     | .5093     | .4563     | .4207     | .4557     | .5139     | .4382     |
| Avg  | .6314     | .6967     | .6906     | .5985     | .6192     | .6435     | .5804     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124128 / 33/11 NACHANKHEDA

Feeder No / Name : 203 / 11 KV NACHANKHEDA NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6335     | .6355     | .4887     | .4716     | .6335     | .4887     | .4539     |
| 2    | .6335     | .6536     | .4706     | .6167     | .6335     | .5068     | .5084     |
| 3    | .6697     | .6718     | .4887     | .6167     | .6516     | .5068     | .4918     |
| 4    | .6878     | .7263     | .6154     | .7255     | .6697     | .5792     | .5629     |
| 5    | .7059     | 1.1257    | .7421     | .9976     | .7118     | .6878     | .817      |
| 6    | 1.1222    | 1.3981    | 1.2308    | 1.451     | 1.0317    | 1.1403    | 1.162     |
| 7    | 1.086     | 1.3254    | .905      | 1.2152    | .9412     | 1.0498    | .9986     |
| 8    | 1.0317    | 1.1257    | 1.1245    | 1.0701    | .8507     | 1.0349    | .9231     |
| 9    | .8715     | .8145     | .9432     | .8869     | .8326     | .9805     | .8326     |
| 10   | .6899     | .6878     | .9613     | .8688     | .5973     | .817      | .7602     |
| 11   | .7263     | .6516     | .4172     | .5973     | .5792     | .7626     | .6878     |
| 12   | .6173     | .543      | .3809     | .5249     | .5068     | .7444     | .6516     |
| 13   | .5992     | .5068     | .399      | .5068     | .4706     | .6899     | .5611     |
| 14   | .6355     | .5249     |           | .5068     | .4887     | .6355     | .5973     |
| 15   | .6173     | .5068     | .3628     | .5249     | .4887     | .6173     | .5973     |
| 16   | .6536     | .5068     | .4353     | .543      | .5068     | .7081     | .6154     |
| 17   | .7081     | .6516     |           | .5792     |           | .6899     | .6516     |
| 18   | .7989     | .724      | .4172     | .6697     | .5792     | .721      | .8688     |
| 19   | 1.2165    | .9955     | 1.2696    | 1.3032    | 1.0136    | 1.2346    | 1.267     |
| 20   | 1.0894    | .8145     | 1.0338    | 1.0498    | .8688     | 1.1983    | .6348     |
| 21   | .8715     | .6335     | .9069     | .905      | .7059     | .9441     | .9432     |
| 22   | .7081     | .543      | .7799     | .7783     | .5792     | .8534     | .7981     |
| 23   | .6536     | .5068     | .6167     | .7059     | .543      | .7263     | .7255     |
| 24   | .6697     |           | .4706     | .5079     | .6516     |           | .4539     |
| Max  | 1.2165    | 1.3981    | 1.2696    | 1.451     | 1.0317    | 1.2346    | 1.267     |
| Min  | .5992     | .5068     | .3628     | .4716     | .4706     | .4887     | .4539     |
| Avg  | .7790     | .7510     | .7027     | .7760     | .6755     | .7964     | .7318     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124159 / 33/11 KV PIMPALGAON ( GOLAIT  
)Feeder No / Name : 201 / 11 KV Pimpalgaon-Bhagdara SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .439      | .3856     | .563      | .5121     | .4572     | .4207     | .4854     |
| 2    | .439      | .4207     | .563      | .5121     | .4572     | .4755     | .4854     |
| 3    | .4755     | .4207     | .5975     | .5487     | .4572     | .5487     | .5228     |
| 4    | .5487     | .4557     | .7095     | .6584     | .5716     | .6584     | .5944     |
| 5    | .6584     | .5258     | .7762     | .7499     | .724      | .7316     | .6687     |
| 6    | .7682     | .7362     | .8779     | .8048     | .7621     | .7865     | .7023     |
| 7    | .8413     | .8063     | .8779     | .8596     | .8002     | .8048     | .7602     |
| 8    | .8215     | .8589     | .8413     | .7682     | .8383     | .7133     | .6733     |
| 9    | .5937     | .7701     |           | .6859     | .7316     | .6219     | .6478     |
| 10   | .6325     | .4961     |           | .4572     | .4938     | .5487     | .6097     |
| 11   | .6173     | .4961     | .427      | .4572     | .567      | .4656     | .6097     |
| 12   |           | .4835     | .4755     | .4191     | .6036     | .4252     | .6478     |
| 13   | .5155     | .5373     | .439      | .4191     | .567      | .4031     | .6097     |
| 14   | .4748     | .4525     | .4572     | .4382     | .5304     | .4031     | .6097     |
| 15   | .4687     | .3801     | .5121     | .4572     | .5304     | .4031     | .5716     |
| 16   |           | .4163     | .5487     | .4572     | .4938     | .4252     | .5525     |
| 17   |           | .4706     | .567      | .5906     | .5304     | .4435     | .6097     |
| 18   |           | .5973     | .6036     | .6668     | .6036     | .4805     | .6859     |
| 19   |           | .7316     | .6219     | .7621     | .5487     | .7059     | .724      |
| 20   |           | .6584     | .5487     | .8383     | .567      | .6722     | .6668     |
| 21   | .4607     | .6283     | .5487     | .6097     | .5487     | .5975     | .5716     |
| 22   | .4252     | .5601     | .5304     | .5716     | .4755     | .5041     | .4763     |
| 23   | .3898     | .5228     | .4572     | .5144     | .4207     | .4854     | .4382     |
| 24   | .4755     | .3801     | .4879     | .3841     | .4572     | .3841     | .4879     |
| Max  | .8413     | .8589     | .8779     | .8596     | .8383     | .8048     | .7602     |
| Min  | .3898     | .3801     | .427      | .3841     | .4207     | .3841     | .4382     |
| Avg  | .5581     | .5496     | .5923     | .5893     | .5724     | .5462     | .6005     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124159 / 33/11 KV PIMPALGAON ( GOLAIT  
)

Feeder No / Name : 202 / 11 KV Sonala Ag

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0183     | .1494     | .112      | .1254     | .0191     | .0171     | .0188     |
| 2    | .0183     | .1494     | .112      | .1433     | .0191     | .0171     | .0188     |
| 3    | .0183     | .1494     | .112      | .1448     | .0191     | .0171     | .0188     |
| 4    | .0183     | .1494     | .1478     | .181      | .0191     | .0171     | .0187     |
| 5    | .0183     | .1494     | .1463     | .1791     | .0191     | .0171     | .0187     |
| 6    | .0183     | .1543     | .1829     | .1991     | .0191     | .0171     | .0187     |
| 7    | .0183     | .192      | .181      | .1991     | .0191     | .0171     | .0179     |
| 8    | .0187     | .2187     | .2149     | .2534     | .0191     | .0171     | .0177     |
| 9    |           | .1907     | .2172     | .2286     | .0171     | .0183     | .0191     |
| 10   | .0017     | .0175     | .0171     | .0191     | .0171     | .0183     | .0191     |
| 11   | .2883     | .0175     | .017      | .0191     | .1629     | .1772     | .2667     |
| 12   | .2883     | .0175     | .0171     | .0191     | .197      | .1949     | .2667     |
| 13   | .285      | .0177     | .0171     | .0191     | .2353     | .197      | .2477     |
| 14   | .285      | .0177     | .0171     | .0191     | .1991     | .2149     | .2286     |
| 15   | .285      | .0177     | .0171     | .0191     | .2172     | .1772     | .2286     |
| 16   |           | .0177     | .0171     | .0191     | .1991     | .1433     | .2477     |
| 17   |           | .0181     | .0171     | .0191     | .2353     | .1463     | .2286     |
| 18   |           | .0183     | .0171     | .0191     | .2534     | .128      | .2096     |
| 19   |           | .0185     | .0171     | .0191     | .0171     | .0185     | .0191     |
| 20   | .0187     | .0185     | .0171     | .0191     | .0171     | .0187     | .0191     |
| 21   |           | .0185     | .0171     | .0191     | .0171     | .0187     | .0191     |
| 22   |           | .0186     | .0171     | .0191     | .0171     | .0188     | .0191     |
| 23   |           | .0187     | .0171     | .0191     | .0171     | .0188     | .0191     |
| 24   | .0183     | .1494     | .1501     | .1052     | .0191     | .0171     |           |
| Max  | .2883     | .2187     | .2172     | .2534     | .2534     | .2149     | .2667     |
| Min  | .0017     | .0175     | .017      | .0191     | .0171     | .0171     | .0177     |
| Avg  | .1011     | .0794     | .0756     | .0844     | .0830     | .0693     | .0959     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

PAHUR[567]

BU 8176

Substation No/ Name :- 124159 / 33/11 KV PIMPALGAON ( GOLAIT  
)

Feeder No / Name : 203 / 11 KV Takali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2987     | .3258     | .3734     | .3982     | .2667     | .3258     | .2987     |
| 2    | .2926     | .3155     | .3734     | .4163     | .2667     | .3258     | .2987     |
| 3    | .3292     | .3439     | .3696     | .4706     | .2667     | .362      | .3361     |
| 4    | .3658     | .362      | .4805     | .4706     | .3429     | .4163     | .4087     |
| 5    | .5487     | .543      | .5853     | .5487     | .3429     | .4706     | .483      |
| 6    | .5487     | .6626     | .6767     | .6219     | .381      | .5304     | .5201     |
| 7    | .4755     | .5784     | .5853     | .6401     | .4001     | .3258     | .4656     |
| 8    | .3841     | .5083     | .5316     | .5249     | .381      | .2534     | .3292     |
| 9    | .3688     | .4119     | .567      | .4572     | .3258     | .2378     | .3429     |
| 10   | .3906     | .2353     | .4163     | .2286     | .2353     | .2195     | .3429     |
| 11   | .3563     | .2534     | .218      | .3429     | .3258     |           | .5144     |
| 12   | .4359     | .2353     | .2534     | .362      | .4163     | .3189     | .5335     |
| 13   | .4744     | .2353     | .2353     | .381      | .4344     | .3012     | .5716     |
| 14   | .4801     | .2507     | .2534     | .381      | .4163     | .3506     | .5335     |
| 15   | .39       | .2729     |           | .4001     | .3982     | .3856     | .5335     |
| 16   |           | .2911     | .5487     | .362      | .3801     | .443      | .5144     |
| 17   |           | .2729     |           | .3429     | .3801     | .4163     | .5144     |
| 18   |           | .3292     | .362      | .3048     | .3982     | .3982     | .5335     |
| 19   |           | .439      | .3801     | .4191     | .362      | .439      | .4191     |
| 20   | .3801     | .4435     | .3982     | .4572     | .3801     | .4251     | .4382     |
| 21   | .3506     | .4087     | .3982     | .4382     | .3439     | .3715     | .381      |
| 22   | .3155     | .3696     | .3982     | .4001     | .3439     | .3344     | .362      |
| 23   | .2896     | .3734     | .3077     | .362      | .2896     | .3361     | .3048     |
| 24   | .2896     | .2896     | .3361     | .3077     | .2667     | .2896     | .2987     |
| Max  | .5487     | .6626     | .6767     | .6401     | .4344     | .5304     | .5716     |
| Min  | .2896     | .2353     | .218      | .2286     | .2353     | .2195     | .2987     |
| Avg  | .3882     | .3646     | .4113     | .4183     | .3477     | .3599     | .4283     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124033 / 33/11 KV TALWEL

Feeder No / Name : 201 / 11 KV Daryapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           | 1.8656    |           |           |           |
| 8    | 1.2437    |           | 1.0136    |           | .9979     | 1.0164    | 1.2437    |
| 12   | 2.1262    | .6584     | .6516     | .394      | 2.2502    | 2.0058    | 2.0058    |
| 16   | 1.9342    |           | .7421     | .7421     | 1.9342    | 1.949     | 1.8267    |
| 20   | 1.2071    | 1.2567    | 1.1888    |           | 1.2197    |           | 1.2071    |
| 23   | 1.9547    |           |           | .9694     | .9694     | .9877     | 1.0425    |
| 24   | .8779     | 1.448     | 1.6118    | 1.2437    | .9328     | .8962     | .9511     |
| Max  | 2.1262    | 1.448     | 1.6118    | 1.8656    | 2.2502    | 2.0058    | 2.0058    |
| Min  | .8779     | .6584     | .6516     | .394      | .9328     | .8962     | .9511     |
| Avg  | 1.5573    | 1.1210    | 1.0416    | 1.0430    | 1.3840    | 1.3710    | 1.3795    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124033 / 33/11 KV TALWEL

Feeder No / Name : 202 / 11 KV Aachegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           | .9795     |           |           |           |
| 8    | .8131     | .6401     | .7133     |           |           | .7133     | .6516     |
| 12   | .5194     | 1.6095    | 1.5927    |           | .4477     | .4961     | .4252     |
| 16   | .5194     | 1.2452    | 1.4419    | 1.6598    | .4252     | .5373     | .5552     |
| 20   | .9231     | .9328     | .9231     |           | 1.4083    |           | .9231     |
| 23   | .8145     |           |           | 1.21      | 1.2929    | 1.2643    | 1.3757    |
| 24   | 1.3108    | .7421     | .7421     | .7164     | 1.2174    | 1.2631    | 1.2003    |
| Max  | 1.3108    | 1.6095    | 1.5927    | 1.6598    | 1.4083    | 1.2643    | 1.3757    |
| Min  | .5194     | .6401     | .7133     | .7164     | .4252     | .4961     | .4252     |
| Avg  | .8167     | 1.0339    | 1.0826    | 1.1414    | .9583     | .8548     | .8552     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124033 / 33/11 KV TALWEL

Feeder No / Name : 203 / 11 KV Pimpalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           | .6468     |           |           |           |
| 8    | .5535     | .4666     | .4401     |           | .4904     | .3894     | .5182     |
| 12   | .3161     | 1.2654    | 1.2176    | 1.2191    | .3353     | .3269     | .3395     |
| 16   | .3567     | 1.1248    | 1.0936    | 1.1248    | .3462     | .3269     | .421      |
| 20   | .6001     | .5502     |           |           | .5639     |           | .5216     |
| 23   | .4199     |           |           | 1.0031    | 1.0059    | .9659     | 1.0385    |
| 24   | 1.0059    | .3858     | .3909     | .3868     | .9722     | .945      | .8619     |
| Max  | 1.0059    | 1.2654    | 1.2176    | 1.2191    | 1.0059    | .9659     | 1.0385    |
| Min  | .3161     | .3858     | .3909     | .3868     | .3353     | .3269     | .3395     |
| Avg  | .5420     | .7586     | .7856     | .8761     | .6190     | .5908     | .6168     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124033 / 33/11 KV TALWEL

Feeder No / Name : 204 / 11 KV Talwel-Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           | .6838     |           |           |           |
| 8    | .4481     | .5068     | .4706     |           | .4961     | .4706     | .4784     |
| 12   |           | .3086     | .2401     | .2713     | .2947     | .2835     | .3086     |
| 16   | .3582     | .4115     | .4207     | .3561     | .3814     | .3814     | .4908     |
| 20   | .5493     | .591      |           |           | .5792     |           | .5373     |
| 23   | .4031     |           |           | .4458     | .3944     | .463      | .4382     |
| 24   | .4031     | .4031     | .4334     | .4239     | .4287     |           | .4458     |
| Max  | .5493     | .591      | .4706     | .6838     | .5792     | .4706     | .5373     |
| Min  | .3582     | .3086     | .2401     | .2713     | .2947     | .2835     | .3086     |
| Avg  | .4324     | .4442     | .3912     | .4362     | .4291     | .3996     | .4499     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124033 / 33/11 KV TALWEL

Feeder No / Name : 205 / 11 KV Talwel-AG-  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           | 1.3836    |           |           |           |
| 12   | 2.0199    |           |           |           | 2.0989    | 2.218     | 2.1879    |
| 16   | 1.9248    |           |           |           | 1.8052    | 1.9019    | 1.7933    |
| 23   | 1.5895    |           |           |           |           |           |           |
| 24   |           | 1.5432    | 1.5974    | 1.0918    |           |           |           |
| Max  | 2.0199    | 1.5432    | 1.5974    | 1.3836    | 2.0989    | 2.218     | 2.1879    |
| Min  | 1.5895    | 1.5432    | 1.5974    | 1.0918    | 1.8052    | 1.9019    | 1.7933    |
| Avg  | 1.8447    | 1.5432    | 1.5974    | 1.2377    | 1.9521    | 2.0600    | 1.9906    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124161 / 33/11 kV GOLEGAON

Feeder No / Name : 201 / 11 KV DHANORI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .1524     | .0343     | .0343     | .0343     | .061      | .061      | .0457     |
| 8    | .0343     | .0343     | .0343     | .0343     | .0343     | .0343     | .0343     |
| 12   | .0343     | .1524     | .1524     | .1219     | .0343     | .0343     | .0343     |
| 16   | .0343     | .0762     | .061      | .0686     | .0343     | .0343     | .0343     |
| 20   | .0343     | .0343     | .0343     | .0343     | .0343     | .0514     | .0343     |
| 24   | .1219     | .0343     | .0343     | .0343     | .061      | .0457     | .0457     |
| Max  | .1524     | .1524     | .1524     | .1219     | .061      | .061      | .0457     |
| Min  | .0343     | .0343     | .0343     | .0343     | .0343     | .0343     | .0343     |
| Avg  | .0686     | .0610     | .0584     | .0546     | .0432     | .0435     | .0381     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124161 / 33/11 kV GOLEGAON

Feeder No / Name : 202 / 11 KV SUSRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .8383     | .823      | .7716     | .6859     | .503      | .5792     | .6097     |
| 8    | .7716     | .7373     | .7202     | .6516     | .7545     | .7202     | .7545     |
| 12   | .463      | .8078     | .6554     | .6097     | .463      | .5144     | .5144     |
| 16   | .5658     | .7164     | .6706     | .6554     | .5487     | .5316     | .6001     |
| 20   | .9088     | .8916     | .7888     | .8402     | .9088     | .8573     | .8573     |
| 24   | .4572     | .6516     | .6173     | .5487     | .4572     | .5335     | .5639     |
| Max  | .9088     | .8916     | .7888     | .8402     | .9088     | .8573     | .8573     |
| Min  | .4572     | .6516     | .6173     | .5487     | .4572     | .5144     | .5144     |
| Avg  | .6675     | .7713     | .7040     | .6653     | .6059     | .6227     | .6500     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

BHUSAWAL DIVISION[621]

VARANGAON S/DN[566] BU 5606

Substation No/ Name :- 124161 / 33/11 kV GOLEGAON

Feeder No / Name : 203 / 11 KV GOLEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5335     | .4801     | .3772     | .6516     | .3048     | .3048     | .442      |
| 8    | .4801     | .4287     | .5144     | .3944     | .3944     | .3944     | .4801     |
| 12   | .2743     | .4268     | .4725     | .4268     | .2572     | .2743     | .2743     |
| 16   | .2743     | .4268     | .4115     | .442      | .2915     | .2915     | .3429     |
| 20   | .463      | .5144     | .5144     | .463      | .4801     | .5144     | .4287     |
| 24   | .3658     | .3086     | .3429     | .3601     | .2896     | .2896     | .381      |
| Max  | .5335     | .5144     | .5144     | .6516     | .4801     | .5144     | .4801     |
| Min  | .2743     | .3086     | .3429     | .3601     | .2572     | .2743     | .2743     |
| Avg  | .3985     | .4309     | .4388     | .4563     | .3363     | .3448     | .3915     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124002 / 33/11 KV BAHAL

Feeder No / Name : 201 / 11 KV BORKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | 1.7147    |           |           | .2629     |           |
| 3    | 1.2308    |           |           | 1.4723    |           |           |           |
| 4    |           | 1.4255    | 1.8004    |           |           | .3856     |           |
| 5    |           |           |           |           | .3441     |           |           |
| 6    | 1.7328    | 1.7204    | 2.0062    | 1.8404    | .7045     | .7108     | .7202     |
| 7    |           |           | 2.2291    |           |           | .5258     | .5487     |
| 8    | 1.9433    | 1.9662    | 2.1948    | 1.9524    | .3113     | .4031     | .3772     |
| 9    |           |           |           |           | .3086     |           |           |
| 10   | .2785     | .2915     | .3277     | .4075     | .2572     | .2591     | .2591     |
| 12   | .2622     | .2429     | .2622     | .3189     | 2.4348    | 2.0805    | 2.0805    |
| 14   | .2622     | .2267     | .2294     | .2835     | 2.2291    | 1.9757    | 1.8884    |
| 16   | .2949     | .2915     | .2785     | .3189     | 1.8861    | 1.8623    | 1.8564    |
| 18   | .3113     | .3721     | .2915     | .3277     | 1.9204    | 1.8861    | 1.6964    |
| 20   | .4915     | .4733     | .4858     | .5079     | .4733     | .4801     | .4481     |
| 22   |           | .3681     |           |           | .333      | .3429     |           |
| 23   | .3113     |           | .3201     | .2949     |           |           | .2881     |
| 24   | 1.2631    |           | 1.749     | 1.5384    |           | .2804     | .2743     |
| Max  | 1.9433    | 1.9662    | 2.2291    | 1.9524    | 2.4348    | 2.0805    | 2.0805    |
| Min  | .2622     | .2267     | .2294     | .2835     | .2572     | .2591     | .2591     |
| Avg  | .7620     | .7378     | 1.0684    | .8421     | 1.0184    | .8812     | .9489     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124002 / 33/11 KV BAHAL

Feeder No / Name : 202 / 11 KV BAHAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           |           |           |           | 1.6476    |           |
| 4    |           |           |           |           |           | 1.7187    |           |
| 5    |           |           |           |           | 1.4737    |           |           |
| 6    |           |           |           |           | 1.647     | 1.949     | 2.1491    |
| 7    |           |           |           |           |           | 2.1849    | 2.6505    |
| 8    |           |           |           |           | 2.0631    | 2.2386    | 2.4714    |
| 9    |           |           |           |           | 2.1491    |           |           |
| 12   | 2.7913    | 2.4272    |           | 2.8296    |           |           |           |
| 14   | 2.5312    | 2.4272    | 2.4792    | 2.5431    |           |           |           |
| 16   | 2.4619    | 2.3926    | 2.6179    | 2.2386    |           |           |           |
| 18   | 1.7684    | 2.1132    | 2.2192    | 1.8551    |           |           |           |
| 24   |           |           |           |           |           | 1.7013    | 1.7193    |
| Max  | 2.7913    | 2.4272    | 2.6179    | 2.8296    | 2.1491    | 2.2386    | 2.6505    |
| Min  | 1.7684    | 2.1132    | 2.2192    | 1.8551    | 1.4737    | 1.6476    | 1.7193    |
| Avg  | 2.3882    | 2.3401    | 2.4388    | 2.3666    | 1.8332    | 1.9067    | 2.2476    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124002 / 33/11 KV BAHAL

Feeder No / Name : 203 / 11 KV BHAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           |           |           |           | 1.6108    |           |
| 4    |           |           |           |           |           | 1.643     |           |
| 5    |           |           |           |           | 1.5223    |           |           |
| 6    |           |           |           |           | 1.6518    | 1.7072    | 1.6244    |
| 7    |           |           |           |           |           | 2.1051    | 1.8233    |
| 8    |           |           |           |           | 1.9595    | 2.0891    | 1.8623    |
| 9    |           |           |           |           | 1.9559    |           |           |
| 12   | 2.3967    | 2.3739    | 2.1538    | 2.2542    |           |           |           |
| 14   | 2.1214    | 2.2801    | 2.17      | 2.2377    |           |           |           |
| 16   | 2.0891    | 2.2131    | 2.0729    | 2.1879    |           |           |           |
| 18   | 2.0081    | 1.9826    | 2.0348    | 1.9757    |           |           |           |
| 24   |           |           |           |           |           | 1.6617    | 1.4998    |
| Max  | 2.3967    | 2.3739    | 2.17      | 2.2542    | 1.9595    | 2.1051    | 1.8623    |
| Min  | 2.0081    | 1.9826    | 2.0348    | 1.9757    | 1.5223    | 1.6108    | 1.4998    |
| Avg  | 2.1538    | 2.2124    | 2.1079    | 2.1639    | 1.7724    | 1.8028    | 1.7025    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124002 / 33/11 KV BAHAL

Feeder No / Name : 204 / 11 KV BAHAL GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .3258     |           |           | .362      |           |
| 3    | .362      |           |           | .3582     |           |           |           |
| 4    |           | .3582     | .3982     |           |           | .4525     |           |
| 5    |           |           |           |           | .4119     |           |           |
| 6    | .7964     | .7701     | .7602     | .7164     | .7164     | .7964     | .6733     |
| 7    |           |           | .6335     |           |           | .5973     | .567      |
| 8    | .4887     | .4119     | .4706     | .4656     | .4835     | .5249     | .4961     |
| 9    |           |           |           |           | .4252     |           |           |
| 10   | .3582     | .3258     | .3582     | .4525     | .3544     | .4477     | .4656     |
| 12   | .3224     | .3403     | .2865     | .3077     | .3544     | .3761     | .394      |
| 14   | 2.3461    | .3582     | .2686     | .3258     | .3544     | .3224     | .394      |
| 16   | 2.3102    | .3982     | .3403     | .3439     | .3544     | .3582     | .3761     |
| 18   | .4298     | .4525     | .362      | .4119     | .5249     | .3898     | .4656     |
| 20   | .4298     | .5973     | .543      | .5014     | .6878     | .567      | .6268     |
| 22   |           | .4706     |           |           | .5792     | .5316     |           |
| 23   | .394      |           | .4477     | .4119     |           |           | .4119     |
| 24   | .3982     |           | .3801     | .4477     |           | .4344     | .3544     |
| Max  | 2.3461    | .7701     | .7602     | .7164     | .7164     | .7964     | .6733     |
| Min  | .3224     | .3258     | .2686     | .3077     | .3544     | .3224     | .3544     |
| Avg  | .7851     | .4483     | .4288     | .4312     | .4770     | .4739     | .4750     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124002 / 33/11 KV BAHAL

Feeder No / Name : 206 / 11 KV TARWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .5601     |           |           | .7282     |           |
| 3    | .462      |           |           | .4854     |           |           |           |
| 4    |           | .5175     | .6535     |           |           | .8402     |           |
| 5    |           |           |           |           | .8871     |           |           |
| 6    | .7468     | .8131     | .8507     | .8402     | 1.2197    | 1.2936    | 1.2323    |
| 7    |           |           | 1.1576    |           |           | .9979     | 1.0185    |
| 8    | .8316     | 1.0642    | 1.1458    | 1.1088    | .7577     | .7095     | .7167     |
| 9    |           |           |           |           | .7762     |           |           |
| 10   | .5175     | .5121     | .462      | .4904     | .4066     | .5544     | .5544     |
| 12   | .499      | .5175     | .4435     | .5228     | .9979     | .8402     | .8402     |
| 14   | .5544     | .5544     | .5544     | .5415     | .8871     | .7468     | .7468     |
| 16   | .5914     | .5544     | .5914     | .5788     | .8962     | .7095     | .7095     |
| 18   | .6283     | .5975     | .6099     | .5914     | .7468     | .7023     | .7468     |
| 20   | .961      | 1.0269    | 1.0642    | .961      | .9149     | .9979     | 1.0082    |
| 22   |           | .8775     |           |           | .8775     | .8871     |           |
| 23   | .7577     |           | .7947     | .7947     |           |           | .8029     |
| 24   | .4854     |           | .5415     | .5228     |           | .7468     | .7392     |
| Max  | .961      | 1.0642    | 1.1576    | 1.1088    | 1.2197    | 1.2936    | 1.2323    |
| Min  | .462      | .5121     | .4435     | .4854     | .4066     | .5544     | .5544     |
| Avg  | .6396     | .7035     | .7253     | .6762     | .8516     | .8273     | .8287     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 202 / 11 KV MEHUNBARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    |           |           |           | .5247     |           |           |           |
| 4    |           |           |           | .5247     |           |           |           |
| 5    |           |           |           | .5556     | .5864     |           |           |
| 6    |           |           |           | .7099     | .7099     | .6661     | .6836     |
| 7    |           |           |           | .8333     | .8488     |           | .7628     |
| 8    |           |           |           | .724      | .8333     | .7529     | .8322     |
| 9    |           |           |           | .6661     | .7133     |           | .5792     |
| 11   |           | .8951     |           |           |           |           |           |
| 12   | .9556     | .9568     | .9414     |           |           |           |           |
| 13   |           | .8642     |           |           |           |           |           |
| 14   |           | .8642     |           |           |           |           |           |
| 15   | .724      | .7716     | .8025     |           |           |           |           |
| 16   |           |           | .6944     |           |           |           |           |
| 17   | .7385     | .7133     | .6944     |           |           |           |           |
| 18   | .6661     | .6573     | .679      |           |           |           |           |
| 24   |           |           |           | .5556     | .5864     | .5792     | .535      |
| Max  | .9556     | .9568     | .9414     | .8333     | .8488     | .7529     | .8322     |
| Min  | .6661     | .6573     | .679      | .5247     | .5864     | .5792     | .535      |
| Avg  | .7711     | .8175     | .7623     | .6367     | .7130     | .6661     | .6786     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 203 / 11 KV PALTHADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | .9172     |           |           |           |           |           |
| 5    | .8951     | .9488     |           |           |           |           |           |
| 6    | .9568     | 1.0437    |           |           |           |           |           |
| 7    | 1.2191    | 1.1385    | 1.2186    |           |           |           |           |
| 8    | 1.1574    | 1.2334    | 1.1888    |           |           |           |           |
| 9    | 1.1702    | 1.1561    |           |           |           |           |           |
| 11   |           |           |           | 1.3599    | 1.3969    |           |           |
| 12   |           |           |           |           | 1.4266    | 1.3426    | 1.3916    |
| 13   |           |           |           | 1.2967    |           |           | 1.1385    |
| 14   |           |           |           |           |           | 1.2654    | 1.2651    |
| 15   |           |           |           | 1.1702    |           |           | 1.1702    |
| 16   |           |           |           | 1.142     | 1.0402    | 1.2191    | 1.2029    |
| 17   |           |           |           |           | 1.2334    | 1.1591    | 1.2498    |
| 18   |           |           |           | 1.0957    | 1.1702    | 1.0997    | 1.0936    |
| 24   | .9568     | .9488     | .8322     |           |           |           |           |
| Max  | 1.2191    | 1.2334    | 1.2186    | 1.3599    | 1.4266    | 1.3426    | 1.3916    |
| Min  | .8951     | .9172     | .8322     | 1.0957    | 1.0402    | 1.0997    | 1.0936    |
| Avg  | 1.0592    | 1.0552    | 1.0799    | 1.2129    | 1.2535    | 1.2172    | 1.2160    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 204 / 11 KV KHEDGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | .0267     |           |           |           |           |           |
| 5    | .0274     | .0267     |           |           |           |           |           |
| 6    | .0274     | .0267     |           |           |           |           |           |
| 7    | .0274     | .0267     | .0297     |           |           |           |           |
| 8    | .0274     | .0267     | .0594     |           |           |           |           |
| 9    |           | .0282     |           |           |           |           |           |
| 11   |           |           |           | .0533     | .0297     |           |           |
| 12   |           |           |           |           | .0594     | .0274     | .0267     |
| 13   |           |           |           | .0533     |           |           |           |
| 14   |           |           |           |           |           | .0274     | .0533     |
| 15   |           |           |           | .0267     |           |           | .0267     |
| 16   |           |           |           | .0267     | .0297     | .0274     | .0282     |
| 17   |           |           |           |           | .0267     | .0297     | .0282     |
| 18   |           |           |           | .0274     | .0267     | .0297     | .0282     |
| 24   | .0274     | .0267     | .0297     |           |           |           |           |
| Max  | .0274     | .0282     | .0594     | .0533     | .0594     | .0297     | .0533     |
| Min  | .0274     | .0267     | .0297     | .0267     | .0267     | .0274     | .0267     |
| Avg  | .0274     | .0269     | .0396     | .0375     | .0344     | .0283     | .0319     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 205 / 11 KV JAMDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | .3479     |           |           |           |           |           |
| 3    |           |           |           | .9831     |           |           |           |
| 4    |           |           |           | .9831     |           |           |           |
| 5    | .421      | .4111     |           | 1.0486    | 1.085     |           |           |
| 6    | .5668     | .5693     |           | 1.2125    | 1.1984    | 1.1069    | 1.1248    |
| 7    | .421      | .5376     | .6104     | 1.3108    | 1.3279    | 1.2018    | 1.3123    |
| 8    | .421      | .4111     | .4409     | 1.2651    | 1.3279    | 1.1385    | 1.2498    |
| 9    | .2846     | .2622     |           | .7274     | 1.1561    |           | .9488     |
| 10   | .2846     | .2458     | .2267     | .253      | .2713     | .2591     | .2846     |
| 11   |           | 1.3763    |           | .2214     | .2713     |           |           |
| 12   | 1.4232    | 1.6385    | 1.6194    |           | .2926     | .2267     | .2214     |
| 13   |           | 1.4746    |           | .1898     |           |           | .2214     |
| 14   |           | 1.3435    |           |           |           | .2429     | .2372     |
| 15   | 1.2334    | 1.278     | 1.166     | .2214     |           |           | .253      |
| 16   |           |           | 1.2955    | .253      | .2713     |           | .2949     |
| 17   | 1.2651    | 1.2498    | 1.1797    |           | .2214     |           | .2622     |
| 18   | 1.2334    | 1.1561    | 1.1469    | .2591     | .0949     | .3052     | .2622     |
| 19   | .4428     | .4298     | .426      |           |           | .4961     | .3932     |
| 20   |           |           | .5243     | .5182     |           |           | .4915     |
| 21   | .4428     | .5228     | .4588     |           |           |           | .426      |
| 22   | .3795     |           | .4096     |           | .4111     | .4755     | .4096     |
| 23   | .3479     |           | .3605     | .3887     | .3637     | .439      | .3932     |
| 24   | .3563     | .3163     | .4024     | .9831     | 1.0202    | .9804     | .9998     |
| Max  | 1.4232    | 1.6385    | 1.6194    | 1.3108    | 1.3279    | 1.2018    | 1.3123    |
| Min  | .2846     | .2458     | .2267     | .1898     | .0949     | .2267     | .2214     |
| Avg  | .6349     | .7983     | .7334     | .6761     | .6652     | .6247     | .5437     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 206 / 11 KV DAHIWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    |           |           |           | .1027     |           |           |           |
| 4    |           |           |           | .1027     |           |           |           |
| 5    |           |           |           | .1027     | .0869     |           |           |
| 6    |           |           |           | .132      | .2172     | .1783     | .1783     |
| 7    |           |           |           | .2201     | .3765     | .4161     | .3567     |
| 8    |           |           |           | .2378     | .2896     | .3567     | .3269     |
| 9    |           |           |           | .0892     | .2934     |           | .2561     |
| 11   |           | .3521     |           |           |           |           |           |
| 12   | .4755     | .3814     | .3765     |           |           |           |           |
| 13   |           | .3668     |           |           |           |           |           |
| 14   |           | .3227     |           |           |           |           |           |
| 15   | .2675     | .2641     | .3041     |           |           |           |           |
| 16   |           |           | .362      |           |           |           |           |
| 17   | .3864     | .2675     | .4108     |           |           |           |           |
| 18   | .2675     | .2378     | .2641     |           |           |           |           |
| 24   |           |           |           | .1174     |           | .0743     | .0892     |
| Max  | .4755     | .3814     | .4108     | .2378     | .3765     | .4161     | .3567     |
| Min  | .2675     | .2378     | .2641     | .0892     | .0869     | .0743     | .0892     |
| Avg  | .3492     | .3132     | .3435     | .1381     | .2527     | .2564     | .2414     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124005 / 33/11 KV MEHUNBARE

Feeder No / Name : 207 / 11 KV PALASARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | .1829     |           |           |           |           |           |
| 3    |           |           |           | .1448     |           |           |           |
| 4    |           |           |           | .1629     |           |           |           |
| 5    | .2195     | .2195     |           | .181      | .1829     |           |           |
| 6    | .3292     | .3292     |           | .3077     | .3109     | .2926     | .2987     |
| 7    | .2561     | .2561     | .2614     | .2353     | .2195     | .1829     | .2241     |
| 8    | .2012     | .1463     | .1867     | .1463     | .1646     | .1829     | .1867     |
| 9    | .1829     | .181      |           | .1097     | .1494     |           | .1646     |
| 10   | .1829     | .1448     | .1463     | .1463     | .1494     | .1463     | .1097     |
| 11   |           | .1267     |           | .1097     | .1494     |           |           |
| 12   | .1646     | .1267     | .1097     |           | .1494     | .1463     | .1097     |
| 13   |           | .1267     |           | .1097     |           |           | .1097     |
| 14   |           | .1267     |           |           |           | .1463     | .1097     |
| 15   | .1646     | .1267     | .1097     | .1097     |           |           | .1097     |
| 16   |           |           | .1097     | .1463     | .1494     | .1829     | .1448     |
| 17   | .1829     | .1494     | .1448     |           | .1463     | .168      | .1448     |
| 18   | .1829     | .1494     | .1448     | .128      | .1097     | .1867     | .1629     |
| 19   | .2561     | .2241     | .1991     |           |           | .2241     | .1991     |
| 20   |           |           | .2534     | .2195     |           |           | .2172     |
| 21   | .2561     | .2614     | .2172     |           |           |           | .1991     |
| 22   | .2195     |           | .2172     |           | .2561     | .1867     | .2172     |
| 23   | .1829     |           | .181      | .1829     | .1829     | .1867     | .181      |
| 24   | .1829     | .1829     | .1867     | .181      | .1646     | .1829     | .1494     |
| Max  | .3292     | .3292     | .2614     | .3077     | .3109     | .2926     | .2987     |
| Min  | .1646     | .1267     | .1097     | .1097     | .1097     | .1463     | .1097     |
| Avg  | .2110     | .1800     | .1763     | .1638     | .1775     | .1858     | .1688     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124130 / 33/11 kV POHARA SUBSTATION

Feeder No / Name : 201 / 11 KV POHARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6468     | .6722     | .6722     | .6908     | .6722     | .6722     | .7095     |
| 2    | .6468     | .6722     | .6722     | .6908     | .6722     | .6722     | .7095     |
| 3    | .7207     | .6722     | .6722     | .6908     | .6722     | .6722     | .7282     |
| 4    | .7207     | .7095     | .7468     | .7655     | .7095     | .7282     | .7842     |
| 5    | .9709     | .9431     | .9431     | .9522     | .9242     | .9431     | .8775     |
| 6    | 1.4523    | 1.3769    | 1.3392    | 1.3014    | 1.3392    | 1.3392    | 1.3203    |
| 7    | 1.1317    | 1.1128    | 1.0185    | 1.094     | 1.0374    | 1.0751    | 1.0185    |
| 8    | .8775     | .8962     | .6908     | .8775     | .7655     | .8215     | .8029     |
| 9    | .7577     | .6535     | .6348     | .6653     | .6584     | .7023     | .7023     |
| 10   | .6099     | .6219     | .5611     | .567      | .6036     | .6036     | .6099     |
| 11   | .5359     | .5487     | .5487     | .5487     | .5914     | .5068     | .5731     |
| 12   | .5359     | .5729     | .5487     | .567      | .5914     | .5611     | .4887     |
| 13   | .5544     | .5729     | .5853     | .5487     | .6219     | .543      | .543      |
| 14   | .5729     | .5914     | .5853     | .5853     | .6036     | .5611     | .6516     |
| 15   | .567      | .5853     | .6219     | .6036     | .6468     | .5853     | .6584     |
| 16   | .5853     | .5853     | .6401     | .6099     | .6154     | .5853     | .6584     |
| 17   | .5973     | .5973     | .6447     | .6335     | .6024     | .591      | .7011     |
| 18   | .6626     | .6733     | .6805     | .6485     | .7108     | .6805     | .7202     |
| 19   | .9511     | .8764     | .8962     | .9231     | .8869     | .9328     | .9671     |
| 20   | .9055     | .8962     | 1.0829    | 1.1016    | 1.0059    | 1.0829    | .9145     |
| 21   | .8501     | .8871     | .8962     | .8686     | .8779     | .8962     | .8779     |
| 22   | .8131     | .8215     | .7842     | .8316     | .8048     | .8402     | .7865     |
| 23   | .7023     | .7468     | .7282     | .7392     | .7499     | .7282     | .7499     |
| 24   | .6653     | .6722     | .6722     | .6908     | .6838     | .7023     | .7095     |
| Max  | 1.4523    | 1.3769    | 1.3392    | 1.3014    | 1.3392    | 1.3392    | 1.3203    |
| Min  | .5359     | .5487     | .5487     | .5487     | .5914     | .5068     | .4887     |
| Avg  | .7514     | .7482     | .7444     | .7581     | .7520     | .7511     | .7609     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124130 / 33/11 kV POHARA SUBSTATION

Feeder No / Name : 202 / 11 KV KALMADU AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .3018     | .3864     | .3067     |
| 2    |           |           |           |           | .3155     | .3864     | .3067     |
| 3    |           |           |           |           | .3155     | .3864     | .3111     |
| 4    |           |           |           |           | .3155     | .3864     | .3246     |
| 5    |           |           |           |           | .3243     | .5418     | .3517     |
| 6    |           |           |           |           | .5569     | .7133     | .6371     |
| 7    |           |           |           |           | .7335     | .9065     | .8949     |
| 8    |           |           |           |           | .7895     | .9288     | .8949     |
| 9    |           |           |           |           | .6447     | .8573     | .7613     |
| 11   | 1.2342    | 1.0911    | .9511     | .9482     |           |           |           |
| 12   | 1.5364    | 1.2643    | 1.2037    | 1.1431    |           |           |           |
| 13   | 1.4373    | 1.2483    | 1.1145    | .9602     |           |           |           |
| 14   | 1.2809    | 1.2163    | 1.0848    | .9783     |           |           |           |
| 15   | 1.3395    | 1.1561    | .9242     | .9633     |           |           |           |
| 16   | 1.0709    | 1.0936    | .9242     | 1.0235    |           |           |           |
| 17   | .9976     | 1.0122    | .9446     | .9659     |           |           |           |
| 18   | .7287     | .8345     | .7613     | .8036     |           |           |           |
| 24   |           |           |           |           | .3018     | .3864     | .3067     |
| Max  | 1.5364    | 1.2643    | 1.2037    | 1.1431    | .7895     | .9288     | .8949     |
| Min  | .7287     | .8345     | .7613     | .8036     | .3018     | .3864     | .3067     |
| Avg  | 1.2032    | 1.1146    | .9886     | .9733     | .4599     | .5880     | .5096     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124130 / 33/11 kV POHARA SUBSTATION

Feeder No / Name : 203 / 11 KV KUNZAR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2715     | .5218     | .2263     | .2643     |           |           |           |
| 2    |           | .5218     | .2263     | .2643     |           |           |           |
| 3    | .2538     | .5218     | .2462     | .2715     |           |           |           |
| 4    | .2679     | .583      | .2462     | .2858     |           |           |           |
| 5    | .2538     | .6554     | .3467     | .3041     |           |           |           |
| 6    | .2709     | .78       | .4464     | .4344     |           |           |           |
| 7    | .5533     | 1.0174    | .6773     | .5647     |           |           |           |
| 8    |           | .7712     | .5937     | .5357     |           |           |           |
| 9    | .1947     | .4527     | .6226     | .4793     |           |           |           |
| 11   |           |           |           |           | .5281     | .4489     | .423      |
| 12   |           |           |           |           | .7407     | .6093     | .5937     |
| 13   |           |           |           |           | .7099     | .6241     | .5573     |
| 14   |           |           |           |           | .6944     | .4012     | .5287     |
| 15   |           |           |           |           | .6015     | .4287     | .5287     |
| 16   |           |           |           |           | .5721     | .4287     | .5144     |
| 17   |           |           |           |           | .5937     | .443      | .443      |
| 18   |           |           |           |           | .4451     | .443      | .2858     |
| 24   | .2858     | .3953     | .2515     | .2503     |           |           |           |
| Max  | .5533     | 1.0174    | .6773     | .5647     | .7407     | .6241     | .5937     |
| Min  | .1947     | .3953     | .2263     | .2503     | .4451     | .4012     | .2858     |
| Avg  | .2940     | .6220     | .3883     | .3654     | .6107     | .4784     | .4843     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124136 / 33/11 KV DAHIWAD SUBSTATION

Feeder No / Name : 201 / 11 KV LONDHE MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5569    | 1.2974    | 1.3824    | 1.3997    | 1.2787    | 1.1059    | 1.3133    |
| 2    | 1.5569    | 1.2974    | 1.3824    | 1.417     | 1.2615    | 1.1232    | 1.3133    |
| 3    | 1.5569    | 1.3147    | 1.3997    | 1.4343    | 1.2787    | 1.1405    | 1.3479    |
| 4    | 1.5915    | 1.3493    | 1.4515    | 1.4861    | 1.296     | 1.1578    | 1.3824    |
| 5    | 1.6434    | 1.4358    | 1.5552    | 1.5898    | 1.3824    | 1.2269    | 1.4343    |
| 6    | 1.8856    | 1.6261    | 1.6935    | 1.728     | 1.6416    | 1.5207    | 1.6243    |
| 7    | 1.8683    | 1.7299    | 1.849     | 1.8663    | 1.6589    | 1.417     | 1.728     |
| 8    | 1.9548    | 1.6434    | 1.8663    | .2765     | 1.7971    | 1.6935    | 1.7799    |
| 9    | 2.1278    | 1.9548    | 2.1427    | 1.7453    | 1.9008    |           | 1.5552    |
| 10   | 2.0413    | 1.9872    | 2.281     | 1.8663    | 1.9008    | .4147     | 1.7453    |
| 11   | 2.2489    | 2.1082    | 1.9699    | 1.9181    | 1.728     | .3629     | 1.9008    |
| 12   | 2.3873    | 2.1946    | 2.2119    | 2.0736    | 1.9008    | .9158     | 2.0909    |
| 13   | 2.3527    | 2.2291    | 2.0736    | 2.1082    | 2.0045    | .8813     | 2.1082    |
| 14   | 2.2489    |           | 1.8835    | 1.6416    | 1.9008    | .8467     | 2.0391    |
| 15   | 2.1624    | 1.8835    | 2.0218    | 1.7626    |           | .985      | 2.0218    |
| 16   | 2.1624    |           | 2.1427    | 1.9527    | 1.7971    | 1.0541    | 1.4343    |
| 17   | 2.2143    |           | 2.3527    | 2.1255    | 2.0909    | 1.9181    | 2.1255    |
| 18   | 1.9894    | 2.4019    | 2.2662    | 2.2637    | 2.0045    | 2.1427    | 2.0391    |
| 19   | 1.5396    | 2.4019    | 2.0391    | 2.0391    |           | 2.0563    | 1.3824    |
| 20   | 1.6953    | 1.6589    | 1.8663    | 1.8144    | .3629     | 1.9527    | 1.4515    |
| 21   | 1.5742    | 1.6416    | 1.7626    | 1.6935    | .311      | 1.7453    | 1.1923    |
| 22   | 1.4877    | 1.5207    | 1.5898    | 1.4861    | 1.2269    | 1.9527    | 1.1232    |
| 23   | 1.3493    | 1.4515    | 1.4861    | 1.3824    | .8813     | 1.406     | 1.0368    |
| 24   | 1.5396    | 1.2801    | 1.417     | 1.417     | 1.2615    | 1.1232    | 1.3306    |
| Max  | 2.3873    | 2.4019    | 2.3527    | 2.2637    | 2.0909    | 2.1427    | 2.1255    |
| Min  | 1.3493    | 1.2801    | 1.3824    | .2765     | .311      | .3629     | 1.0368    |
| Avg  | 1.8640    | 1.7337    | 1.8370    | 1.6870    | 1.4939    | 1.3106    | 1.6042    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124136 / 33/11 KV DAHIWAD SUBSTATION

Feeder No / Name : 202 / 11 KV DAHIWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2259     | .2257     | .2257     | .2445     | .2633     | .2257     | .2257     |
| 2    | .2259     | .2257     | .2257     | .2633     | .2445     | .2257     | .2257     |
| 3    | .2447     | .2257     | .2804     | .2445     | .2633     | .2445     | .2257     |
| 4    | .2447     | .2633     | .2633     | .2633     | .2633     | .2633     | .2633     |
| 5    | .3953     | .3573     | .3949     | .3761     | .3573     | .4137     | .3573     |
| 6    | .5835     | .5641     | .5829     | .6017     | .5829     | .5829     | .6017     |
| 7    | .5271     | .4513     | .4325     | .4889     | .4889     | .4701     | .4889     |
| 8    | .3761     | .3009     | .3197     | .3009     | .3385     | .3197     | .3197     |
| 9    | .3009     | .2821     | .3197     | .2633     |           | .3009     | .3197     |
| 10   | .2821     | .2445     | .2633     | .2257     | .3009     | .2445     | 1.8992    |
| 11   | .188      | .1692     | .2633     | .2257     | .2445     | .2445     | .3197     |
| 12   | .2445     | .2068     | .2445     | .2257     | .2445     | .2257     | .2633     |
| 13   | .2257     | .2257     | .2257     | .1692     | .2257     | .2633     | .2445     |
| 14   | .2257     |           | .2445     | .2445     | .1692     | .2633     | .3197     |
| 15   | .2445     | .2633     | .2068     | .2445     |           | .2633     | .2821     |
| 16   | .2257     |           | .2445     | .2445     | .2821     | .2633     | .2821     |
| 17   | .2257     |           | .2821     | .2633     | .2821     | .3009     | .2445     |
| 18   | .2633     | .2068     | .2821     | .2821     | .3197     | .3009     | .2821     |
| 19   | .3573     | .3802     | .3761     | .3761     | .3283     | .4325     | .3949     |
| 20   | .3761     | .4325     | .4325     | .4137     | .3573     | .4137     | .4137     |
| 21   | .3009     | .2068     | .3385     | .3197     | .3197     | .3385     | .3385     |
| 22   | .2633     | .2821     | .3009     | .3009     | .3009     | .2821     | .3009     |
| 23   | .2633     | .2633     | .2633     | .2633     | .2633     | .2633     | .2821     |
| 24   | .2259     | .2445     | .2445     | .2633     | .2445     | .2445     | .2445     |
| Max  | .5835     | .5641     | .5829     | .6017     | .5829     | .5829     | 1.8992    |
| Min  | .188      | .1692     | .2068     | .1692     | .1692     | .2257     | .2257     |
| Avg  | .2932     | .2868     | .3024     | .2962     | .3039     | .3080     | .3808     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON R-III[580] BU 0580

Substation No/ Name :- 124136 / 33/11 KV DAHIWAD SUBSTATION

Feeder No / Name : 203 / RAJMANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .2874     | .2716     | .2411     | .2559     |
| 2    |           |           |           | .3025     | .2867     | .2562     | .2709     |
| 3    |           |           |           | .3177     | .3018     | .2713     | .2709     |
| 4    |           |           |           | .3328     | .3169     | .2713     | .286      |
| 5    |           |           |           | .3631     | .332      | .2863     | .301      |
| 6    |           |           |           | .4387     | .4979     | .5124     | .4666     |
| 7    |           |           |           | .7695     | .7545     | .2411     | .7225     |
| 8    |           |           |           | .9065     | .8148     | .7384     | .6321     |
| 9    |           |           |           | .5734     | .8148     | .6171     | .3161     |
| 11   | .9681     | .6959     |           |           |           |           |           |
| 12   | 1.074     | .8925     |           |           |           |           |           |
| 13   | .9681     | 1.1847    |           |           |           |           |           |
| 14   | .9833     | .6505     |           |           |           |           |           |
| 15   | .8774     | .6807     |           |           |           |           |           |
| 16   | .7866     |           |           |           |           |           |           |
| 17   | .832      | .7412     |           |           |           |           |           |
| 18   | .7715     | .6959     | .5295     |           |           |           |           |
| 24   |           |           |           | .3025     | .2867     | .2565     | .2709     |
| Max  | 1.074     | 1.1847    | .5295     | .9065     | .8148     | .7384     | .7225     |
| Min  | .7715     | .6505     | .5295     | .2874     | .2716     | .2411     | .2559     |
| Avg  | .9076     | .7916     | .5295     | .4594     | .4678     | .3692     | .3793     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124001 / 33/11 KV WAGHALI S/S

Feeder No / Name : 201 / 11 kv Waghali SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .9755     | 1.0059    |           | 1.0898    |           | 1.0898    |
| 2    | 1.0059    | 1.0364    | 1.0059    | 1.0974    | 1.0898    | 1.0974    | 1.0898    |
| 3    |           | 1.1248    | 1.0059    |           | 1.0898    |           | 1.3413    |
| 4    | 1.0974    | 1.2346    | 1.0898    | 1.1888    | 1.1736    | 1.1888    | 1.3413    |
| 5    |           | 1.5424    | 1.1736    |           | 1.4251    |           | 1.4251    |
| 6    | 1.4632    | 1.7556    | 1.2574    | 1.5546    | 1.7604    | 1.829     | 1.6766    |
| 7    |           | 1.3169    | 1.6766    |           | 1.5089    |           | 1.4251    |
| 8    | 1.829     | 1.3032    | 1.8442    | 1.4632    |           | 1.3717    | 1.291     |
| 9    | 1.4251    |           | .961      | 1.7604    | 1.1736    |           |           |
| 10   | 1.0059    | 1.0974    | .7926     | 1.0059    | 1.0059    | 1.0059    | 1.0898    |
| 11   |           |           | .7926     | .9221     | 1.5927    | 1.6766    | 1.7604    |
| 12   | 1.0974    | 1.0059    | .7773     | .8383     | 1.8442    | 1.6766    | 1.6766    |
| 13   |           |           | .8124     | .9221     | 1.6766    |           |           |
| 14   | 1.0059    | 1.0059    | .852      | .9221     | 1.6766    | 1.4251    | 1.3717    |
| 15   |           |           | .8421     | .9221     | 1.4251    | 1.2574    |           |
| 16   | 1.0974    | 1.0059    | .8962     | 1.0059    | 1.5546    | 1.2574    | 1.3717    |
| 17   | .9831     |           |           | 1.0059    |           | 1.4419    |           |
| 18   | .9282     | 1.0059    | 1.0059    | .9556     | 1.4632    | 1.1736    | 1.3717    |
| 19   | 1.2483    | 1.3413    |           | 1.4251    |           | 1.4251    |           |
| 20   | 1.4266    |           | 1.7375    | 1.5927    | 1.7375    | 1.6766    | 1.6461    |
| 21   | 1.3375    |           |           | 1.5927    |           | 1.5089    |           |
| 22   | 1.1591    |           | 1.4632    | .9221     | 1.4632    | 1.4251    | 1.4632    |
| 23   | 1.0105    |           |           | 1.2574    |           | 1.2239    |           |
| 24   | 1.0059    | .9511     | .8383     | 1.0974    | 1.1736    |           | 1.1736    |
| Max  | 1.829     | 1.7556    | 1.8442    | 1.7604    | 1.8442    | 1.829     | 1.7604    |
| Min  | .9282     | .9511     | .7773     | .8383     | 1.0059    | 1.0059    | 1.0898    |
| Avg  | 1.1839    | 1.1802    | 1.0915    | 1.1726    | 1.4171    | 1.3918    | 1.3885    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124001 / 33/11 KV WAGHALI S/S

Feeder No / Name : 202 / 11 KV Jawale SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3414     | .5201     |           | .6935     |           | .8669     |
| 2    | .6401     | .3307     | .5201     | .6401     | .6935     | .9145     | .8669     |
| 3    |           | .3658     | .5201     |           | .6935     |           | .9536     |
| 4    | .823      | .4024     | .6068     | .7316     | .6935     | 1.0974    | 1.0402    |
| 5    |           | .6036     | .7802     |           | .8669     |           | 1.0402    |
| 6    | 1.2803    | .7545     | .8669     | 1.3717    | 1.0402    | 1.0974    | 1.387     |
| 7    |           |           | .8669     |           | 1.647     |           | 1.9071    |
| 8    | .7316     | .7316     | .8669     | 1.0059    | 1.647     | 2.0119    | 1.9071    |
| 9    | .6935     |           | .506      | .8669     | 1.387     |           |           |
| 10   | .6068     | .5487     | .3658     | .5201     | .7802     | .4572     | .6068     |
| 11   |           |           | .9088     | 1.4737    | .6068     | .3467     | .4334     |
| 12   | 2.1948    | 1.0059    |           | 1.3003    | .6068     | .3467     | .4334     |
| 13   |           |           | .7522     | 1.7337    | .6068     |           |           |
| 14   | 2.1033    | 1.0059    | .7287     | 1.5604    | .6068     | .4334     | .4572     |
| 15   |           |           | .6859     | 1.3003    | .6935     | .3467     |           |
| 16   | 1.829     | 1.5604    | .703      | 1.387     | .7316     | .4508     | .6401     |
| 17   | .6516     |           |           | 1.387     |           | .4161     |           |
| 18   | .4961     | 1.387     | 1.2803    | 1.1443    | .6401     | .5201     | .7316     |
| 19   | .7865     |           |           | .9536     |           | .8669     |           |
| 20   | .7209     |           | 1.0974    | 1.1269    | 1.2803    | 1.3003    | 1.2803    |
| 21   | .6478     |           |           | .9536     |           | .8669     |           |
| 22   | .583      |           | .9145     | .7802     | 1.0974    | .7802     | .823      |
| 23   | .4428     |           |           | .6068     |           | .6935     |           |
| 24   | .7316     | .3414     | .6068     | .6401     | .6935     | .9145     | .8669     |
| Max  | 2.1948    | 1.5604    | 1.2803    | 1.7337    | 1.647     | 2.0119    | 1.9071    |
| Min  | .4428     | .3307     | .3658     | .5201     | .6068     | .3467     | .4334     |
| Avg  | .9390     | .7215     | .7420     | 1.0742    | .8853     | .7701     | .9554     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124001 / 33/11 KV WAGHALI S/S

Feeder No / Name : 203 / 11kv Ozar Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6335     | .543      |           | .6335     |           | .6335     |
| 2    | .6401     | .6154     | .6335     | .6401     | .6516     | .6401     | .6335     |
| 3    |           | .6516     | .6335     |           | .6335     |           | .6335     |
| 4    | .823      | .724      | .6335     | .7316     | .6335     | .823      | .724      |
| 5    |           | .8688     | .8145     |           | .8145     |           | .8145     |
| 6    | 1.0974    | .8049     | 1.086     | 1.0974    | 1.086     | 1.0974    | 1.0288    |
| 7    |           | .9412     | .9955     |           | .905      |           | .905      |
| 8    | .7316     | .6697     | .6697     | .7316     | .6335     | 2.1033    | .6335     |
| 9    | .6335     |           | .5249     | .6335     | .543      |           |           |
| 10   | .543      | .4572     | .4706     | .543      | .543      | .5487     | .543      |
| 11   |           |           | .4344     | .543      | .4525     | .5068     | .543      |
| 12   | .4572     | .4572     | 1.9185    | .543      | .4525     | .4706     | .543      |
| 13   |           |           | .4887     | .543      | .5068     |           |           |
| 14   | .5487     | .4572     | .543      | .543      | .4525     | .543      | .5487     |
| 15   |           |           | .5249     | .543      | .543      | .5068     |           |
| 16   | .5121     | .543      | .543      | .543      | .5487     | .4887     | .5487     |
| 17   | .5611     |           |           | .543      |           | .543      |           |
| 18   | .543      | .6335     | .5487     | .543      | .5853     | .543      | .7316     |
| 19   | .7783     | .724      |           | .724      |           | .724      |           |
| 20   | .7602     |           | .823      | .905      | .9145     | .905      | .823      |
| 21   | .724      |           |           | .724      |           | .7783     |           |
| 22   | .6878     |           | .7316     | .724      | .7316     | .724      | .7316     |
| 23   | .6335     |           |           | .724      |           | .724      |           |
| 24   | .6401     | .6335     | .6335     | .6401     | .6335     | .9145     | .6335     |
| Max  | 1.0974    | .9412     | 1.9185    | 1.0974    | 1.086     | 2.1033    | 1.0288    |
| Min  | .4572     | .4572     | .4344     | .543      | .4525     | .4706     | .543      |
| Avg  | .6656     | .6543     | .7097     | .6581     | .6449     | .7547     | .6854     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124001 / 33/11 KV WAGHALI S/S

Feeder No / Name : 205 / 11 kV Wadale

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0133     |           |           |           |           |           |
| 7    |           | .0137     |           |           |           |           |
| 8    |           | .0137     |           |           |           |           |
| 9    | .0183     |           |           |           |           |           |
| 11   |           |           | .0412     | .0274     | .0412     | .0274     |
| 12   |           |           | .0412     | .0274     | .0412     | .0137     |
| 13   |           |           | .0274     | .0137     |           |           |
| 14   |           |           | .0137     |           | .0274     | .0183     |
| 15   |           |           | .0137     |           | .0137     |           |
| 16   |           |           | .0137     | .0183     | .0137     |           |
| 17   |           |           | .0274     |           |           |           |
| 18   |           |           | .0274     | .0366     | .0137     |           |
| 19   |           |           | .0274     |           |           |           |
| Max  | .0183     | .0137     | .0412     | .0366     | .0412     | .0274     |
| Min  | .0133     | .0137     | .0137     | .0137     | .0137     | .0137     |
| Avg  | .0158     | .0137     | .0259     | .0247     | .0252     | .0198     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124080 / 33 kv sangavi s/s

Feeder No / Name : 201 / 11 KV Bodhare SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     |           |           |           |           |           |           |
| 2    | .2743     |           |           |           |           |           |           |
| 3    | .2652     |           |           |           |           |           |           |
| 4    | .2591     |           |           |           |           |           |           |
| 5    | .4115     |           |           |           |           |           |           |
| 6    | .5548     |           |           |           |           |           |           |
| 7    | .7865     |           |           |           |           |           |           |
| 8    | .7682     | .3048     |           |           |           |           |           |
| 16   |           |           | .3048     | .6325     | .9511     | .4816     | .4816     |
| 17   |           |           | .3048     | .6173     | .602      | .4755     | .5944     |
| 18   |           |           | .381      | .4816     | .4512     | .3521     | .4633     |
| 19   |           |           | .4572     | .4572     | .4572     | .4572     | .4572     |
| 20   |           |           | .5716     | .6097     | .4572     | .6097     | .6097     |
| 21   |           |           | .5525     | .6097     | .4572     | .4572     | .6097     |
| 22   |           |           | .5335     | .4572     | .4572     | .4572     | .4572     |
| 23   |           |           | .4572     | .4572     | .4572     | .4572     | .4572     |
| 24   |           |           |           | .4572     | .4572     | .4161     | .4572     |
| Max  | .7865     | .3048     | .5716     | .6325     | .9511     | .6097     | .6097     |
| Min  | .2591     | .3048     | .3048     | .4572     | .4512     | .3521     | .4572     |
| Avg  | .4492     | .3048     | .4453     | .5311     | .5275     | .4626     | .5097     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124080 / 33 kv sangavi s/s

Feeder No / Name : 202 / 11 kv Ranjangaon feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE       | 08-APR-18    | 11-APR-18    | 12-APR-18    | 13-APR-18    | 14-APR-18    |
|------------|--------------|--------------|--------------|--------------|--------------|
| HR         | Load (MW)    | Load (MW)    | Load (MW)    | Load (MW)    | Load (MW)    |
| 1          | .16          |              |              |              |              |
| 2          | .16          |              |              |              |              |
| 3          | .16          |              |              |              |              |
| 4          | .2134        |              |              |              |              |
| 5          | .2225        |              |              |              |              |
| 6          | .2225        |              |              |              |              |
| 7          | .3567        |              |              |              |              |
| 8          | .6097        |              |              |              |              |
| 16         |              | .7316        | .5944        | .535         | .535         |
| 17         |              |              | .6539        | .4694        | .5213        |
| 18         |              | .535         | .4755        | .4108        | .3338        |
| <b>Max</b> | <b>.6097</b> | <b>.7316</b> | <b>.6539</b> | <b>.535</b>  | <b>.535</b>  |
| <b>Min</b> | <b>.16</b>   | <b>.535</b>  | <b>.4755</b> | <b>.4108</b> | <b>.3338</b> |
| <b>Avg</b> | <b>.2631</b> | <b>.6333</b> | <b>.5746</b> | <b>.4717</b> | <b>.4634</b> |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124080 / 33 kv sangavi s/s

Feeder No / Name : 204 / 11 KV Wakadi Gaothan  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .964      |           |           |           |           |           |
| 2    | .9816     |           |           |           |           |           |
| 3    | .964      |           |           |           |           |           |
| 4    | 1.0341    |           |           |           |           |           |
| 5    | 1.1568    |           |           |           |           |           |
| 6    | 1.4022    |           |           |           |           |           |
| 7    | 1.4198    |           |           |           |           |           |
| 8    | 1.2445    |           |           |           |           |           |
| 16   |           | 1.3321    | 1.0402    | 1.0402    | 1.0517    | 1.0166    |
| 17   |           | 1.4548    | 1.0749    | 1.1963    | 1.1218    | 1.1919    |
| 18   |           | 1.2971    | 1.1096    | 1.0923    | 1.2094    | 1.2269    |
| 19   |           | 1.2445    | 1.283     | 1.2483    | 1.3847    | 1.3672    |
| 20   |           | 1.3672    | 1.387     | 1.387     | 1.4373    | 1.4373    |
| 21   |           | 1.1218    | 1.2483    | 1.2483    | 1.2971    | 1.2445    |
| 22   |           | 1.1393    | 1.1269    | 1.1269    | 1.1043    | 1.0867    |
| 23   |           | 1.0402    | 1.0229    | 1.0749    | 1.0166    | 1.0166    |
| 24   |           |           | .6935     | .9189     | .8764     | .8939     |
| Max  | 1.4198    | 1.4548    | 1.387     | 1.387     | 1.4373    | 1.4373    |
| Min  | .964      | 1.0402    | .6935     | .9189     | .8764     | .8939     |
| Avg  | 1.1459    | 1.2496    | 1.1096    | 1.1481    | 1.1666    | 1.1646    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124126 / 33/11 KV Bhoras Substation

Feeder No / Name : 201 / 11 KV Bhoras SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6661     | .631      | .6661     | .7011     | .3856     | .4908     | .5258     |
| 2    | .6661     | .631      | .7011     | .631      | .3856     | .4557     | .5258     |
| 3    | .631      | .631      | .7011     | .7011     | .3681     | .4557     | .5609     |
| 4    | .6661     | .7011     | .7011     | .7362     | .4207     | .4557     | .631      |
| 5    | .9114     | .9114     | .9465     | .9816     | .5609     | .631      | .5258     |
| 6    | 1.262     | 1.262     | 1.1919    | 1.262     | .8764     | 1.0517    | 1.0517    |
| 7    | 1.1568    | 1.2269    | 1.1919    | 1.1568    | 1.0166    | 1.1218    | 1.262     |
| 8    | .964      | .9114     |           | .8764     | .8764     | .9114     | .8063     |
| 9    | .7712     | .631      | .7011     | .7011     | .8063     | .6661     | .7362     |
| 10   | .7011     | .5959     | .7011     | .631      | .6661     | .7011     | .7011     |
| 11   | .9465     | .7362     | .6661     | .7011     | .631      | .5959     | .5959     |
| 12   | 1.0517    | .7888     | .7362     | .8764     | .5959     | .5959     | .5609     |
| 13   | 1.0517    | .7011     | .8063     | .8063     | .5959     | .5609     | .5609     |
| 14   | .9816     | .7011     | .7362     | .7362     | .5609     | .5609     | .5609     |
| 15   | .8764     | .7011     | .7011     | .7011     | .5609     | .5609     | .5959     |
| 16   | .8413     |           | .7712     | .7712     | .5258     | .5609     | .5609     |
| 17   | .8764     | .7362     | .8063     | .7362     |           | .5959     | .631      |
| 18   | .7011     | .5609     | .631      | .631      | .631      | .6661     | .7011     |
| 19   | .8413     | .9816     | .9816     | .9816     | .9465     | .9465     | .964      |
| 20   | .8764     | .9114     | 1.0166    | 1.0517    | .9465     | 1.0867    | 1.0867    |
| 21   | .9114     | .8413     | .9114     | .8764     | .8764     | .9816     | .8764     |
| 22   | .7011     | .7712     | .8764     | .8764     | .7712     | .8413     | .7888     |
| 23   | .7362     | .7011     | .7712     | .8063     | .7011     | .7712     | .7712     |
| 24   | .6661     | .6661     | .631      | .7362     | .3856     | .4908     | .5258     |
| Max  | 1.262     | 1.262     | 1.1919    | 1.262     | 1.0166    | 1.1218    | 1.262     |
| Min  | .631      | .5609     | .631      | .631      | .3681     | .4557     | .5258     |
| Avg  | .8523     | .7796     | .8063     | .8194     | .6561     | .6982     | .7128     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124126 / 33/11 KV Bhoras Substation

Feeder No / Name : 203 / 11 KV stone crusher

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0381     | .0381     | .1143     | .1132     | .0377     | .0377     | .0377     |
| 2    | .0381     | .0381     | .0381     | .0754     | .0377     | .0377     | .0377     |
| 3    | .0381     | .0381     | .0381     | .0754     | .0377     | .0377     | .0377     |
| 4    | .0762     | .0762     | .0762     | .0754     | .0377     | .0754     | .0377     |
| 5    | .0762     | .0762     | .0762     | .0943     | .0754     | .0754     | .0377     |
| 6    | .0762     | .0762     | .0762     | .0754     | .0754     | .0754     | .0754     |
| 7    | .0953     | .0762     | .0762     | .0943     | .0943     | .0754     | .0943     |
| 8    | .0762     | .0762     |           | .0943     | .0754     | .0754     | .0943     |
| 9    | .0953     | .0943     | .0762     | .0953     | .0943     | .0377     | .0377     |
| 10   | .0762     | .0754     | .0953     | .0762     | .0943     | .0754     | .0754     |
| 11   | .1143     | .0754     | .1143     | .0953     | .0377     | .0754     | .0754     |
| 12   | .1143     | .0754     | .1334     | .0762     | .1132     | .0754     | .0943     |
| 13   | .1143     | .0754     | .1143     | .0762     | .132      | .0754     | .0943     |
| 14   | .1143     | .0754     | .1143     | .0953     | .1132     | .0943     | .0943     |
| 15   | .1143     | .0943     | .0953     | .1143     | .1132     | .0943     | .0754     |
| 16   | .1143     |           | .0953     | .0762     | .132      | .0943     | 1.6598    |
| 17   | .0762     | .0953     | .1132     | .0754     |           | .0943     | .0754     |
| 18   | .0762     | .1143     | .0754     | .0754     | .0953     | .0754     | .0754     |
| 19   | .1143     | .0953     | .0754     | .0754     | .0762     | .0943     | .0754     |
| 20   | .0381     | .0762     | .0943     | .0377     | .0762     | .0943     | .0754     |
| 21   | .1524     | .1524     | .1698     | .0754     | .1524     | .0754     | .1132     |
| 22   | .1524     | .1334     | .1509     | .0377     | .1334     | .1698     | .1132     |
| 23   | .1143     | .1334     | .1509     | .0377     | .1334     | .1509     | .1132     |
| 24   | .0381     | .0381     | .1524     | .1509     | .0377     | .0377     | .0377     |
| Max  | .1524     | .1524     | .1698     | .1509     | .1524     | .1698     | 1.6598    |
| Min  | .0381     | .0381     | .0381     | .0377     | .0377     | .0377     | .0377     |
| Avg  | .0889     | .0826     | .1007     | .0820     | .0872     | .0794     | .1391     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124140 / MIDC S/S CHALISGAON

Feeder No / Name : 213 / 11 KV JUNE VIMANTAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3969    | 1.379     | 1.4685    | 1.4685    | 1.4685    |           | 1.576     |
| 2    | 1.3253    | 1.3611    | 1.3969    | 1.3969    | 1.4148    |           | 1.5223    |
| 3    | 1.2536    | 1.3611    | 1.3611    | 1.3611    | 1.3611    |           | 1.4685    |
| 4    | 1.2178    | 1.3253    | 1.3253    | 1.3611    | 1.3611    |           | 1.379     |
| 5    | 1.2357    | 1.3073    | 1.3969    | 1.3432    | 1.379     |           | 1.3611    |
| 6    | 1.3969    | 1.6655    | 1.576     | 1.5043    | 1.6655    |           | 1.4327    |
| 7    | 1.4685    | 1.576     | 1.6118    | 1.5581    | 1.5043    |           | 1.3611    |
| 8    | 1.2178    | 1.3611    | 1.379     | 1.2894    | 1.2894    |           | 1.2715    |
| 9    |           | 1.182     | 1.182     | 1.2178    | 1.182     |           | 1.1641    |
| 10   | 1.182     | 1.2894    | 1.1283    | 1.1104    | 1.3253    |           | 1.1999    |
| 11   | 1.1462    | 1.1462    | 1.1462    | 1.1104    | 1.2894    |           | 1.1999    |
| 12   | 1.1641    | 1.182     | 1.1462    | 1.0924    | 1.182     |           | 1.1641    |
| 13   | 1.1462    | 1.182     | 1.1462    | 1.182     | 1.2357    |           | 1.2178    |
| 14   | 1.182     | 1.2178    | 1.2894    | 1.1999    | 1.2894    |           | 1.3253    |
| 15   | 1.2715    | 1.2715    | 1.2894    | 1.2715    | 1.2894    |           | 1.379     |
| 16   | 1.2178    | 1.2357    | 1.2894    | 1.2536    | 1.2357    |           | 1.3253    |
| 17   | 1.1999    | 1.182     | 1.2894    | 1.2178    | 1.2536    | 1.3253    | 1.3432    |
| 18   | 1.2536    | 1.2536    | 1.2715    | 1.1999    | 1.2536    | 1.2715    | 1.2536    |
| 19   | 1.4685    | 1.3969    | 1.4685    | 1.379     | 1.3969    | 1.4864    | 1.4506    |
| 20   | 1.5043    | 1.5223    | 1.5581    | 1.5581    | 1.5402    | 1.6476    | 1.5402    |
| 21   | 1.5402    | 1.576     | 1.6118    | 1.6118    | 1.6297    | 1.7013    | 1.5939    |
| 22   | 1.5939    | 1.6297    | 1.6834    | 1.7193    | 1.7551    | 1.773     | 1.7193    |
| 23   | 1.6297    | 1.6297    | 1.7193    | 1.6834    | 1.7193    |           | 1.7909    |
| 24   | 1.4685    | 1.4864    | 1.5402    | 1.576     | 1.576     |           | 1.6655    |
| Max  | 1.6297    | 1.6655    | 1.7193    | 1.7193    | 1.7551    | 1.773     | 1.7909    |
| Min  | 1.1462    | 1.1462    | 1.1283    | 1.0924    | 1.182     | 1.2715    | 1.1641    |
| Avg  | 1.3253    | 1.3633    | 1.3865    | 1.3611    | 1.3999    | 1.5342    | 1.4044    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124140 / MIDC S/S CHALISGAON

Feeder No / Name : 214 / 11 KV MIDC-II Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0377     | .0377     | .6602     | .0943     | .2263     |           | .0377     |
| 2    | .0377     | .1509     | .6224     | .1132     | .2263     |           | .0377     |
| 3    | .0377     | .2452     | .6036     | .0377     | .2263     |           | .0377     |
| 4    | .0189     | .2829     | .5847     | .0377     | .2263     |           | .0377     |
| 5    | .0189     | .2452     | .6602     | .0189     | .2263     |           | .0189     |
| 6    | .0377     | .2641     | .5847     | .0377     | .2263     |           | .0189     |
| 7    | .0377     | .0377     | .7167     | .0377     | .2452     |           | .0189     |
| 8    |           | .0377     | .7733     |           | .2075     |           | .0189     |
| 9    |           | .0189     | .7922     | .0189     | .2075     |           | .0189     |
| 10   | .0189     | .2263     | .6224     | .0189     | .2075     |           | .0189     |
| 11   | .0189     | .2075     | .6979     | .0189     | .2075     |           | .0189     |
| 12   | .0377     | .2075     | .6413     | .0189     | .4338     |           | .0189     |
| 13   | .0189     | .2075     | .5847     | .0189     | .7733     |           | .0189     |
| 14   | .0377     | .2075     | .6224     | .0189     | .679      |           | .0189     |
| 15   | .0377     | .2075     | .6036     | .0189     | .679      |           | .0189     |
| 16   | .0377     | .0377     | .5281     | .0189     | .679      |           |           |
| 17   | .0377     | .0377     | .547      | .0377     | .6602     | .0377     | .0189     |
| 18   | .0377     | .1509     | .2263     | .2263     | .7545     | .1132     | .0189     |
| 19   | .0377     | .0377     | .2263     | .2263     | .8299     | .0358     | .2263     |
| 20   | .0377     | .0377     | .2263     | .2263     | .7356     | .0377     | .2263     |
| 21   | .0377     | .0377     | .2263     | .2452     | .7356     | .0377     | .0566     |
| 22   | .0377     | .1698     | .0566     | .2263     | .8865     | .0566     | .0189     |
| 23   | .0377     | .415      | .0377     | .2263     | .7545     |           | .0189     |
| 24   | .0377     | .0377     | .7545     | .0377     | .2263     |           | .0377     |
| Max  | .0377     | .415      | .7922     | .2452     | .8865     | .1132     | .2263     |
| Min  | .0189     | .0189     | .0377     | .0189     | .2075     | .0358     | .0189     |
| Avg  | .0334     | .1478     | .5250     | .0861     | .4692     | .0531     | .0427     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124140 / MIDC S/S CHALISGAON

Feeder No / Name : 215 / 11 KV MIDC-I FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0189     | .0189     | .0189     | .0377     | .0377     |           | .0377     |
| 2    | .0189     | .0189     | .0189     | .0377     | .0377     |           | .0189     |
| 3    | .0189     | .0189     | .0189     | .0377     | .0377     |           | .0377     |
| 4    | .0189     | .0189     | .0189     | .0377     | .0377     |           | .0377     |
| 5    | .0189     | .0189     | .0377     | .0377     | .0377     |           | .0377     |
| 6    |           | .0189     | .0377     | .0377     | .0377     |           | .0566     |
| 7    |           |           | .0754     | .0377     | .0377     |           | .0754     |
| 8    | .1132     |           | .0754     | .0377     | .0377     |           | .0566     |
| 9    |           | .0754     | .0754     | .1132     | .0377     | .0943     | .0377     |
| 10   | .0566     | .0754     | .0754     | .0566     | .0754     | .0566     | .0377     |
| 11   | .0754     | .0943     | .1132     | .0566     | .0754     | .0566     | .0566     |
| 12   | .0754     | .1132     | .0943     | .0377     | .0754     | .0754     | .0377     |
| 13   | .0754     | .0377     | .0943     | .0754     | .0943     | .0566     | .0377     |
| 14   | .0754     | .0754     | .0566     | .0189     | .0754     |           | .0377     |
| 15   | .0943     | .1132     | .0943     | .0377     | .0943     |           | .0189     |
| 16   | .0754     | .132      | .1132     | .0754     | .0754     |           | .0377     |
| 17   | .0566     | .0377     | .0377     | .0754     | .0943     | .0377     | .0566     |
| 18   | .0377     | .0377     | .0377     | .0377     | .0377     | .0377     | .0566     |
| 19   | .0377     | .0377     | .0377     | .0189     | .0377     | .0377     | .0189     |
| 20   | .0377     | .0566     | .0377     | .0189     | .0377     | .0377     | .0189     |
| 21   | .0377     | .0189     | .0189     |           | .0377     | .0377     | .0189     |
| 22   | .0189     | .0189     | .0189     |           | .0377     | .0377     |           |
| 23   | .0189     | .0189     | .0189     |           | .0189     |           | .0566     |
| 24   | .0189     | .0189     | .0189     | .0189     | .0377     |           | .0377     |
| Max  | .1132     | .132      | .1132     | .1132     | .0943     | .0943     | .0754     |
| Min  | .0189     | .0189     | .0189     | .0189     | .0189     | .0377     | .0189     |
| Avg  | .0476     | .0489     | .0519     | .0449     | .0518     | .0514     | .0402     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124152 / 33/11KV HATALE SUBSTATION

Feeder No / Name : 201 / 11 KV Hatale Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3772     | .3772     | .3772     |           | .3961     | .415      |           |
| 2    |           | .3772     | .415      |           | .3961     | .4527     |           |
| 3    |           | .3772     | .4527     |           | .3961     | .4904     |           |
| 4    |           | .3961     | .5281     |           | .3961     | .5281     |           |
| 5    | .5281     | .679      | .6036     | .4904     | .4715     | .5847     | .5093     |
| 6    | .7922     | .7922     | .7922     | .7733     | .6979     | .7733     | .7545     |
| 7    | .7733     | .7356     | .7545     | .7167     | .6413     | .7167     | .7356     |
| 8    | .6036     | .5658     | .5658     | .5847     | .5658     | .5658     | .5658     |
| 9    | .547      | .4904     | .5093     | .4527     | .415      | .4904     | .4527     |
| 10   | .3772     | .3961     | .3395     | .2829     | .3961     | .3584     | .3961     |
| 11   | .3395     | .2641     |           |           | .3206     | .3395     | .3395     |
| 12   | .2829     | .2641     |           | .2829     | .3018     | .2829     | .2829     |
| 13   | .2829     | .2641     | .2641     | .3018     | .3018     |           | .2641     |
| 14   | .2829     | .2641     |           | .3018     | .3018     | .3395     | .3018     |
| 15   |           |           |           | .2829     | .3018     | .3018     | .3206     |
| 16   | .2829     | .3018     |           | .2829     | .3206     |           |           |
| 17   | .2829     | .2829     | .3395     | .2829     | .3395     | .3584     | .3961     |
| 18   | .3772     | .3961     | .3584     | .3961     | .3772     | .4338     | .415      |
| 19   |           | .547      | .5658     |           | .5658     |           | .5658     |
| 20   |           | .6979     |           | .679      | .6413     | .6979     | .6979     |
| 21   | .6036     | .547      | .5281     | .5658     | .547      | .6036     | .5658     |
| 22   |           | .4904     |           | .5093     | .5093     |           | .5093     |
| 23   | .4338     | .415      | .4527     | .4338     | .4527     | .4715     | .4527     |
| 24   | .3961     | .3772     | .3961     | .415      | .3961     | .415      | .415      |
| Max  | .7922     | .7922     | .7922     | .7733     | .6979     | .7733     | .7545     |
| Min  | .2829     | .2641     | .2641     | .2829     | .3018     | .2829     | .2641     |
| Avg  | .4449     | .4478     | .4849     | .4464     | .4354     | .4810     | .4706     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124152 / 33/11KV HATALE SUBSTATION

Feeder No / Name : 202 / 11 KV Hatale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1128    |           | 1.1317    |           |           |           |           |
| 2    |           | 1.2071    | 1.1317    |           |           |           |           |
| 3    |           | 1.2071    | 1.1317    |           |           |           |           |
| 4    |           | 1.2071    | 1.1506    |           |           |           |           |
| 5    | 1.1128    | 1.4712    | 1.1506    |           |           |           |           |
| 6    | 1.1694    | 1.5844    | 1.1694    |           |           |           |           |
| 7    | 1.8296    | 1.8107    | 1.4901    |           |           |           |           |
| 8    | 1.6221    | 1.7353    | 1.6409    |           |           |           |           |
| 9    | 1.6221    | 1.2071    | 1.3014    |           |           |           |           |
| 11   |           |           |           | 1.9044    | 1.8484    | 1.7541    | 1.773     |
| 12   |           |           |           | 1.9791    | 1.8484    | 1.9239    | 1.8296    |
| 13   |           |           |           | 1.8671    |           |           | 1.7164    |
| 14   |           |           |           | 1.8671    | 1.8296    | 1.8484    | 1.6975    |
| 15   |           |           |           | 1.7551    | 1.8673    | 1.5655    | 1.3957    |
| 16   |           |           |           | 1.7353    | 1.7164    |           |           |
| 17   |           |           |           | 1.7353    | 1.6409    | 1.1317    | 1.4146    |
| 18   |           |           |           | 1.3957    | 1.4712    | 1.5844    | 1.3957    |
| 24   | 1.094     | 1.1694    | 1.2637    |           |           |           |           |
| Max  | 1.8296    | 1.8107    | 1.6409    | 1.9791    | 1.8673    | 1.9239    | 1.8296    |
| Min  | 1.094     | 1.1694    | 1.1317    | 1.3957    | 1.4712    | 1.1317    | 1.3957    |
| Avg  | 1.3661    | 1.3999    | 1.2562    | 1.7799    | 1.7460    | 1.6347    | 1.6032    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124152 / 33/11KV HATALE SUBSTATION

Feeder No / Name : 203 / 11 kV Chambhardi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .4338     | .3772     |           |
| 2    |           |           |           |           | .4338     | .3772     |           |
| 3    |           |           |           |           | .4338     | .3772     |           |
| 4    |           |           |           |           | .4338     | .3961     |           |
| 5    |           |           |           | .3018     | .4338     | .3961     | .3584     |
| 6    |           |           |           | .3206     | .3772     | .3961     | .3584     |
| 7    |           |           |           | .3961     | .5093     | .3961     | .4904     |
| 8    |           |           |           | .4527     | .5093     | .4338     | .4904     |
| 9    |           |           |           | .415      | .4527     | .4338     | .4338     |
| 11   | .6602     | .5658     |           |           |           |           |           |
| 12   | .6602     | .6413     |           |           |           |           |           |
| 13   | .6602     | .4904     | .4338     |           |           |           |           |
| 14   | .6979     | .415      |           |           |           |           |           |
| 16   | .6036     | .3772     |           |           |           |           |           |
| 17   | .5658     | .3961     | .4527     |           |           |           |           |
| 18   | .3772     | .3584     | .4527     |           |           |           |           |
| 24   |           |           |           | .3018     | .4527     | .3772     | .4338     |
| Max  | .6979     | .6413     | .4527     | .4527     | .5093     | .4338     | .4904     |
| Min  | .3772     | .3584     | .4338     | .3018     | .3772     | .3772     | .3584     |
| Avg  | .6036     | .4635     | .4464     | .3647     | .4470     | .3961     | .4275     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124170 / Pimperkhed Substation

Feeder No / Name : 201 / 11 KV Pimperkhed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1886     |           | .0305     |           | .2058     |           |           |
| 2    | .2058     | .0229     |           |           | .1715     | .3086     | .0286     |
| 3    | .2229     |           | .0324     |           | .2229     |           |           |
| 4    | .3429     | .0286     | .3429     |           | .2572     | .3086     | .3258     |
| 5    | .4458     | .4287     | .3772     |           | .2915     |           | .4801     |
| 6    | .5144     | .5316     | .5316     |           | .5658     | .5144     | .5316     |
| 7    | .4115     | .4801     | .4801     |           | .4973     |           | .4458     |
| 8    | .3772     |           | .3258     |           | .4115     | .2401     | .2743     |
| 9    |           | .0229     | .0305     | .2401     |           | .0171     | .2915     |
| 10   | .0267     | .0191     | .2572     | .1543     | .2572     | .0229     | .2058     |
| 11   |           | .0171     | .2572     | .2229     |           | .0267     | .1715     |
| 12   | .0229     |           |           | .2229     | .2915     | .0324     | .2058     |
| 13   | .0248     | .0229     | .2229     | .2401     |           | .0267     | .2058     |
| 14   |           | .0248     | .2572     | .2572     | .2572     |           | .1886     |
| 15   | .0267     | .2134     | .2572     | .2572     |           | .0286     | .2058     |
| 16   |           | .2743     | .3086     | .2572     | .2229     | .0305     | .2058     |
| 17   |           | .3258     | .3601     | .3258     |           | .3258     | .2401     |
| 18   | .3258     | .3601     | .2743     | .2915     | .3086     | .3601     | .2743     |
| 19   |           | .5144     | .4115     | .3944     |           | .463      |           |
| 20   | .463      | .4458     | .4287     | .463      | .4458     | .4409     | .4287     |
| 21   |           | .4287     |           |           |           | .407      |           |
| 22   | .3772     | .3601     |           | .3086     | .3601     |           | .3601     |
| 23   | .2743     | .3429     |           | .2743     |           |           |           |
| 24   | .2229     |           | .3086     |           | .2401     | .2743     | .0343     |
| Max  | .5144     | .5316     | .5316     | .463      | .5658     | .5144     | .5316     |
| Min  | .0229     | .0171     | .0305     | .1543     | .1715     | .0171     | .0286     |
| Avg  | .2631     | .2560     | .2892     | .2793     | .3129     | .2252     | .2686     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124170 / Pimperkhed Substation

Feeder No / Name : 202 / 11 KV Pimperkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2915     |           |           |           |           | .2572     |           |
| 2    | .3772     |           |           |           |           | .2572     | .3222     |
| 3    | .4115     |           |           |           |           | .2572     | .3391     |
| 4    | .4458     |           |           |           |           | .2743     | .3561     |
| 5    | .3944     |           |           |           |           | .3429     | .4239     |
| 6    | .8573     |           |           |           |           | .583      | .4748     |
| 7    | 1.046     |           |           |           |           | .7202     |           |
| 8    | 1.0117    |           |           |           |           | .6859     |           |
| 9    | .78       |           |           |           |           | .6104     | .3429     |
| 11   |           | 1.1022    | .9602     | .9259     | .7202     |           |           |
| 12   |           | 1.1869    | 1.0288    | 1.0288    | .9945     |           |           |
| 13   |           | 1.0343    | 1.0974    | .8916     | .8745     |           |           |
| 14   |           | .9326     | .823      | .823      | .7373     |           |           |
| 15   |           | .8987     | .7888     |           | .703      |           |           |
| 16   |           | .9156     | .823      | .7202     | .7545     |           |           |
| 17   |           | .8817     | .8745     | .6344     | .8573     |           |           |
| 18   |           | .6952     | .7202     | .6173     | .6516     |           |           |
| 24   | .2572     |           |           |           |           | .2401     | .3222     |
| Max  | 1.046     | 1.1869    | 1.0974    | 1.0288    | .9945     | .7202     | .4748     |
| Min  | .2572     | .6952     | .7202     | .6173     | .6516     | .2401     | .3222     |
| Avg  | .5873     | .9559     | .8895     | .8059     | .7866     | .4228     | .3687     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-II[243] BU 8150

Substation No/ Name :- 124170 / Pimperkhed Substation

Feeder No / Name : 203 / 11 kV Beladarwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1543     |           |           |           |           | .1696     | .1696     |
| 2    | .1715     |           |           |           |           |           | .1696     |
| 3    | .1886     |           |           |           |           |           | .1526     |
| 4    | .2058     |           |           |           |           | .1696     | .1696     |
| 5    | .2915     |           |           |           |           |           | .1696     |
| 6    | .4458     |           |           |           |           | .2883     | .1865     |
| 7    | .4801     |           |           |           |           | .407      | .407      |
| 8    | .3772     |           |           |           |           |           | .4239     |
| 9    | .39       |           |           |           |           | .2883     | .2743     |
| 11   |           | .6104     | .5487     | .5316     | .5256     |           |           |
| 12   |           | .5765     |           | .4973     |           |           |           |
| 13   |           | .5087     | .4458     | .4287     | .407      |           |           |
| 14   |           |           | .4115     | .4115     | .3391     |           |           |
| 15   |           | .407      | .3429     | .3944     |           |           |           |
| 16   |           | .4239     | .3944     | .4115     | .2883     |           |           |
| 17   |           | .407      | .4115     | .3772     | .3052     |           |           |
| 18   |           | .3052     |           | .2743     | .2713     |           |           |
| 24   | .1543     |           |           |           |           | .1696     | .1696     |
| Max  | .4801     | .6104     | .5487     | .5316     | .5256     | .407      | .4239     |
| Min  | .1543     | .3052     | .3429     | .2743     | .2713     | .1696     | .1526     |
| Avg  | .2859     | .4627     | .4258     | .4158     | .3561     | .2487     | .2292     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 201 / 11 KV TAKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9374     | 1.0936    | 1.0936    | 1.0936    |           |           |           |
| 2    | .9374     | 1.0936    | 1.0936    | 1.0936    |           |           |           |
| 3    | .9374     | 1.0936    | 1.0936    | .9374     |           |           |           |
| 4    | .9374     | 1.2498    | 1.0936    | .9374     |           |           |           |
| 5    | .9374     | 1.2498    | 1.2498    | .9374     |           |           |           |
| 6    | 1.0936    | 1.2498    | 1.2498    | 1.0936    |           |           |           |
| 7    | 1.2498    | 1.406     | 1.2498    | 1.406     |           |           |           |
| 8    | 1.406     | 1.406     | 1.406     | 1.406     |           |           |           |
| 9    | 1.2498    | 1.2498    | .9374     | 1.2498    |           |           |           |
| 11   |           |           |           |           |           | 1.406     | 1.5623    |
| 12   |           |           |           |           | 1.7185    |           | 1.7185    |
| 13   |           |           |           |           | 1.5623    | 1.7185    | 1.5623    |
| 14   |           |           |           |           | 1.5623    | 1.7185    | 1.406     |
| 15   |           |           |           |           | 1.5623    | 1.7185    | 1.406     |
| 16   |           |           |           |           | 1.406     | 1.406     | 1.2498    |
| 17   |           |           |           |           | 1.406     | 1.406     | 1.406     |
| 18   |           |           |           |           | 1.406     | 1.406     | 1.2498    |
| 24   | .9374     | 1.0936    | 1.0936    | 1.0936    |           |           |           |
| Max  | 1.406     | 1.406     | 1.406     | 1.406     | 1.7185    | 1.7185    | 1.7185    |
| Min  | .9374     | 1.0936    | .9374     | .9374     | 1.406     | 1.406     | 1.2498    |
| Avg  | 1.0624    | 1.2186    | 1.1561    | 1.1248    | 1.5176    | 1.5399    | 1.4451    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 202 / 11 KV ALWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .415      | .4108     | .3881     | .3772     | .3696     | .3658     | .3696     |
| 2    | .415      | .4108     | .3881     | .3772     | .3696     | .3658     | .3696     |
| 3    | .415      | .4108     | .3881     | .3772     | .3696     | .4024     | .3696     |
| 4    | .4527     | .4481     | .4066     | .3772     | .4066     | .439      | .3696     |
| 5    | .6036     | .5228     | 1.7926    | .5658     | .5544     | .5121     | .5544     |
| 6    | .7922     | .6722     | .6468     | .8299     | .7762     | .7316     | .8215     |
| 7    | .7167     | .5975     | .5175     | .5975     | .7762     | .5853     | .5914     |
| 8    | .6036     | .4435     | .462      | .5487     | .5175     | .4755     | .439      |
| 9    | .4904     | .3696     | .3881     | .3734     | .5175     | .4024     | .3734     |
| 10   | .3772     | .3696     | .362      | .3734     | .3696     | .3326     | .4108     |
| 11   | .3395     | .3511     | .3982     | .3582     |           | .3582     | .3734     |
| 12   | .3772     | .3142     | .3258     | .3582     | .3326     | .3224     | .3734     |
| 13   | .3361     | .3142     | .3258     | .3582     | .2957     | .2926     | .3658     |
| 14   | .3361     | .2772     | .3326     | .3582     | .2957     | .2743     | .3658     |
| 15   | .2987     | .2772     | .3326     | .3582     | .2957     | .2743     | .3658     |
| 16   | .2987     | .2957     | .3326     | .362      | .3326     | .3361     | .3658     |
| 17   |           | .3511     | .362      | .3582     | .3696     | .3582     | .3658     |
| 18   | .4481     | .3881     | .362      | .4298     | .4066     | .4207     | .4755     |
| 19   | .5975     | .4435     | .6036     | .6089     | .4435     | .462      | .6413     |
| 20   | .5601     | .499      | .5914     | .6283     | .4435     | .5914     | .6219     |
| 21   | .5601     | .462      | .5658     | .5544     | .4805     | .5487     | .5487     |
| 22   | .5228     | .4435     | .5281     | .5175     | .4066     | .5487     | .5121     |
| 23   | .4854     | .4251     | .4904     | .4854     | .3696     | .3658     | .4805     |
| 24   | .415      | .4108     | .3881     | .3772     | .4435     | .3658     | .4755     |
| Max  | .7922     | .6722     | 1.7926    | .8299     | .7762     | .7316     | .8215     |
| Min  | .2987     | .2772     | .3258     | .3582     | .2957     | .2743     | .3658     |
| Avg  | .4720     | .4129     | .4866     | .4546     | .4323     | .4222     | .4583     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 203 / 11 KV UPKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .439      | .3277     | .2949     | .4715     | 1.6632    | 1.6632    | 1.5261    |
| 2    | .439      | .3277     | .2949     | .4715     | 1.6632    | 1.6632    | 1.5261    |
| 3    | .439      | .3277     | .2949     | .4715     | 1.6632    | 1.7556    | 1.5261    |
| 4    | .5487     | .3277     | .4096     | .4715     | 1.7741    | 1.8111    | 1.5261    |
| 5    | .6401     | .3768     | .4915     | .6602     | 1.848     | 1.885     | 1.6956    |
| 6    | .7682     | .4096     | .6718     | .5658     | 1.9774    | 2.0328    | 1.8652    |
| 7    | .695      | .4424     |           | .3772     | 1.9959    | 2.1253    | 2.2043    |
| 8    |           | .3932     |           | .3772     | 2.0328    | 2.1253    | 1.9719    |
| 9    |           | .3277     | .3277     | .2241     | 1.848     | 2.1253    | 1.8004    |
| 10   | .3658     | .2458     | .3239     | .2241     | .3696     | .3734     | .3086     |
| 11   | 2.0317    | 1.7204    | 1.8652    |           |           | .2987     | .3086     |
| 12   | 2.13      | 2.3102    | 1.95      | 2.5019    | .3326     | .2987     | .1715     |
| 13   | 2.1628    | 2.2611    | 1.8652    | 2.4272    | .2587     | .2987     | .1715     |
| 14   | 2.2119    | 2.2611    | 1.95      | 2.4272    | .2772     | .2987     | .2401     |
| 15   | 2.2611    | 2.1136    | 1.95      | 2.2032    | .2957     | .2987     | .2401     |
| 16   | 2.2447    | 2.1464    | 1.95      | 2.2405    | .3142     | .2987     | .3086     |
| 17   |           | 2.1136    | 1.95      | 2.0538    | .3326     |           | .3429     |
| 18   | 1.9989    | 2.1792    | 1.6956    | 1.8671    | .3696     | .3734     | .3772     |
| 19   | .3932     | .4572     | .4748     | .6535     | .4066     | .4668     | .6173     |
| 20   | .426      | .5735     | .6104     | .7468     | .4251     | .679      | .6173     |
| 21   | .4096     | .4915     | .5426     | .7468     | .4435     | .6602     | .6173     |
| 22   | .3605     | .4588     | .5487     | .6348     | .3696     | .6602     | .6173     |
| 23   | .3277     | .4096     | .5121     | .5041     | .3326     | .4572     | .463      |
| 24   | .439      | .3277     | .2458     | .4572     | 1.6057    | 1.6632    | 1.6598    |
| Max  | 2.2611    | 2.3102    | 1.95      | 2.5019    | 2.0328    | 2.1253    | 2.2043    |
| Min  | .3277     | .2458     | .2458     | .2241     | .2587     | .2987     | .1715     |
| Avg  | 1.0349    | .9721     | .9645     | 1.0339    | .9826     | 1.0571    | .9460     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 204 / 11 KV MANDURNE SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6767     | .7095     | .6908     | .7167     | .5914     | .5914     | .3601     |
| 2    | .6767     | .7095     | .6908     | .7167     | .5914     | .5914     | .3601     |
| 3    | .6767     | .7095     | .6908     | .7167     | .5914     | .6283     | .3601     |
| 4    | .7316     | .7842     | .7282     | .7545     | .6283     | .6283     | .3601     |
| 5    | .823      | .8589     | .8029     | .8488     | .6653     | .6468     | .3601     |
| 6    | 1.0059    | .9896     | 1.0456    | 1.0374    | .7207     | .6653     | .4115     |
| 7    | 1.1203    | 1.0269    | .9149     | .8871     | 1.0164    | .7577     | .2812     |
| 8    | .9335     | .6908     | .8962     | .8316     | .924      | .7023     | .2968     |
| 9    | .7468     | .5788     | .5975     | .8316     | .9055     | .6468     | .25       |
| 10   | .6722     | .5975     | .5788     | .7392     | .5544     | .6099     | .3048     |
| 11   | .6722     | .6161     | .7468     | .924      |           | .5914     | .3582     |
| 12   | 1.0269    | .7095     | .8402     | 1.0719    | .6099     | .5853     | .3403     |
| 13   | .9896     | .6908     | .7468     | 1.0349    | .5914     | .5853     | .3403     |
| 14   | .9522     | .7095     | .9335     | 1.0349    | .5729     | .5853     | .3403     |
| 15   | .9335     | .7655     | .9335     | 1.0534    | .5544     | .5853     | .695      |
| 16   | .9709     | .8029     | .8962     | 1.0349    | .5544     | .5853     | .6733     |
| 17   |           | .8962     | .8962     | 1.0534    | .5914     | .5121     | .695      |
| 18   | .6722     | .8589     | .8413     | .924      | .5729     | .695      | .7133     |
| 19   | .7655     | .8962     | .7682     | .7023     | .7023     | .7316     | .9145     |
| 20   | .8775     | .8962     | .8779     | .8686     | .7392     | .9145     | .8779     |
| 21   | .8589     | .8589     | .823      | .8501     | .8501     | .8596     | .7973     |
| 22   | .8215     | .7655     | .823      | .8501     | .8131     | .9328     | .8048     |
| 23   | .7842     | .7468     | .7865     | .7392     | .7392     | .7499     | .7865     |
| 24   | .6767     | .7095     | .6908     | .7133     | .5729     | .5914     | .5304     |
| Max  | 1.1203    | 1.0269    | 1.0456    | 1.0719    | 1.0164    | .9328     | .9145     |
| Min  | .6722     | .5788     | .5788     | .7023     | .5544     | .5121     | .25       |
| Avg  | .8289     | .7741     | .8017     | .8723     | .6806     | .6655     | .5088     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 205 / 11 KV SAKUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3292     | .3109     | .2926     | .3109     | .7316     | .7682     | .9145     |
| 2    | .3292     | .3109     | .2926     | .3109     | .7316     | .8048     | .9145     |
| 3    | .3292     | .3142     | .2926     | .3109     | .7316     | .8048     | 1.5181    |
| 4    | .4024     | .3658     | .3475     | .3658     | .8962     | .9511     | .9145     |
| 5    | .4755     | .439      | .3658     | .4572     | .9877     | 1.1157    | .9145     |
| 6    | .567      | .4938     | .4755     | .5853     | 1.0059    | 1.2803    | 1.0059    |
| 7    | .4938     | .4572     | .4572     | .4755     | .4755     | 1.5912    | 1.6461    |
| 8    | .3109     | .3292     | .3292     | .3658     | 1.39      | 1.6461    | 1.6461    |
| 9    | .2743     | .2561     | .2743     | .2743     | 1.262     | 1.4449    | 1.4632    |
| 10   | .2378     | .2378     | .2378     | .2561     | .2195     | .2378     | .2195     |
| 11   | 1.6827    | 1.6787    | 1.3717    | 1.4083    |           | .2012     | .128      |
| 12   | 1.7193    | 1.7375    | 1.4815    | 1.6278    | .2195     | .2012     | .1097     |
| 13   | 1.5364    | 1.6461    | 1.4632    | 1.5729    | .2195     | .2012     | .1097     |
| 14   | 1.5546    | 1.4815    | 1.4632    | 1.4083    | .2378     | .2012     | .1097     |
| 15   | 1.5364    | 1.4266    | 1.4632    | 1.3717    | .2378     | .2012     | .128      |
| 16   | 1.4998    | 1.4632    | 1.5546    | 1.3169    | .2378     | .2378     | .1463     |
| 17   |           | 1.39      | 1.3717    | 1.39      | .2561     | .2378     | .1463     |
| 18   | .9145     | 1.2071    | 1.1523    | 1.0608    | .2561     | .2743     | .1829     |
| 19   | .4024     | .3658     | .439      | .4024     | .3841     | .3658     | .2743     |
| 20   | .439      | .4572     | .4572     | .4755     | .4024     | .4572     | .4572     |
| 21   | .4207     | .4024     | .4572     | .4572     | .439      | .4207     | .4572     |
| 22   | .4024     | .3658     | .4024     | .4024     | .4024     | .4207     | .4207     |
| 23   | .3475     | .3292     | .3475     | .3475     | .3658     | .3658     | .3658     |
| 24   | .3292     | .3109     | .3109     | .3109     | .7499     | .7682     | .8596     |
| Max  | 1.7193    | 1.7375    | 1.5546    | 1.6278    | 1.39      | 1.6461    | 1.6461    |
| Min  | .2378     | .2378     | .2378     | .2561     | .2195     | .2012     | .1097     |
| Avg  | .7189     | .7407     | .7125     | .7194     | .5583     | .6333     | .6272     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 206 / 11 KV SAIGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0957    | 2.0005    | .2305     | 2.4196    | .8383     | .8383     | .8573     |
| 2    | 2.0957    | 2.0005    | .2305     | 2.4196    | .8383     | .8383     | .8573     |
| 3    | 2.0957    | 2.0005    | .2305     | 2.4196    | .8383     | .8383     | .8573     |
| 4    | 2.1529    | 2.0767    | .2382     | 2.4768    | .8954     | .9526     | 1.0479    |
| 5    | 2.4768    | 2.1338    | .2629     | 2.572     | 1.105     | 1.0288    | .9526     |
| 6    | 2.572     | 2.572     | .2743     | 2.8578    | 1.3146    | 1.2384    | 1.0479    |
| 7    | 2.6673    | 2.6482    | .2858     | 3.0483    | 1.1812    | 1.1812    | 1.1622    |
| 8    | 2.4196    | .2686     | .2858     | 2.8578    | .9907     | .9907     | .9526     |
| 9    | 2.4006    | .2686     | .2324     | 2.8578    | .8573     | .8192     | .7811     |
| 10   | .7049     | .08       | .6859     | .743      | .7049     | .8383     | .724      |
| 11   | .6668     | .0705     | .8573     | .724      |           | 3.0483    |           |
| 12   | .6668     | .0724     | .7621     | .743      | 3.1817    | 3.0483    | 3.0483    |
| 13   | .6859     | .0724     | .7621     | .743      | 2.9912    | 2.9531    | 3.1055    |
| 14   | .7621     | .0743     | .7621     | .743      | 3.0483    | 3.0483    | 3.0864    |
| 15   | .724      | .0743     | .7621     | .7621     | 2.9721    | 3.0483    | 3.0483    |
| 16   | .7049     | .0743     | .724      | .7621     | 2.9912    | 2.8578    | 2.8959    |
| 17   |           | .0724     | .743      | .7811     | 2.8197    | 2.572     | 2.7435    |
| 18   | .8573     | .0743     |           |           | 2.7054    | 2.4768    | 2.6292    |
| 19   | 1.0288    | .0991     | 1.1622    | 1.0669    | 1.0098    | 1.0479    | 1.1241    |
| 20   | 1.0669    | .1181     | 1.2003    | 1.1622    | 1.105     | 1.2003    | 1.2384    |
| 21   | 1.105     | .1086     | 1.1431    | 1.1241    | 1.086     | 1.1431    | 1.105     |
| 22   | .9526     | .0953     | .9526     | 1.0479    | 1.0669    | 1.086     | 1.0288    |
| 23   | .9145     | .0914     | .9145     | .9145     | .8573     | .9717     | .9526     |
| 24   | 2.0576    | 2.0005    | .221      | 2.2291    | .8383     | .8192     | .8954     |
| Max  | 2.6673    | 2.6482    | 1.2003    | 3.0483    | 3.1817    | 3.0483    | 3.1055    |
| Min  | .6668     | .0705     | .221      | .724      | .7049     | .8192     | .724      |
| Avg  | 1.4728    | .7978     | .6054     | 1.6294    | 1.5755    | 1.6202    | 1.5714    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124003 / 33/11 KV PILKHOD S/STN

Feeder No / Name : 207 / 11 KV KAKADNE SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4842    | 1.448     | 1.647     | 1.8099    | .2172     | .2353     | .2195     |
| 2    | 1.4842    | 1.448     | 1.647     | 1.8099    | .2172     | .2353     | .2195     |
| 3    | 1.4842    | 1.448     | 1.647     | 1.448     | .2172     | .2715     | .2195     |
| 4    | 1.6651    | 1.5565    | 1.7737    | 1.448     | .2353     | .2715     | .2195     |
| 5    | 1.8099    | 1.6289    | 1.8099    | 1.448     | .2896     | .3077     | .2743     |
| 6    | 2.0271    | 1.9728    | 1.8823    | 1.8099    | .3439     | .3439     | .3658     |
| 7    |           | 1.9366    | 1.9185    | 1.8099    | .2896     | .1448     | .2743     |
| 8    | 2.4253    | 1.7556    | 1.9185    | 1.7194    | .1448     | .1086     |           |
| 9    | 2.4253    | 1.6289    | 1.7556    | 1.5384    | .181      | .1086     | .2195     |
| 10   | .181      | .1267     | .1448     | .1267     | .0905     | .0724     | .1829     |
| 11   | .181      | .1097     | .1086     | .1267     |           | 1.8099    | 1.9204    |
| 12   | .1629     | .1086     | .1086     | .1267     | 1.5746    | 2.0814    | 2.0851    |
| 13   | .1448     | .1086     | .1086     | .1448     | 1.7737    | 2.0814    | 1.829     |
| 14   | .1267     | .1086     | .1086     | .1448     | 1.9004    | 2.0814    | 2.0119    |
| 15   | .1267     | .1267     | .1086     | .1267     | 1.8823    | 2.0814    | 1.9753    |
| 16   | .1448     | .1267     | .1267     | .1267     | 1.9004    | 1.9909    | 1.9753    |
| 17   |           | .1086     | .1448     | .1267     | 1.9185    | 1.8099    | 2.0668    |
| 18   | .181      | .1629     | .1448     | .1629     | 1.9366    | 1.7194    | 1.829     |
| 19   | .3077     | .2715     | .2534     | .2896     | .2534     | .2715     | .2743     |
| 20   | .3258     | .3258     | .3258     | .3077     | .2715     | .3658     | .3292     |
| 21   | .2715     | .3077     | .2715     | .2715     | .2353     | .3109     | .2926     |
| 22   | .2534     | .2715     | .2715     | .2534     | .2534     | .2561     | .2561     |
| 23   | .2353     | .2353     | .2172     | .2353     | .2353     | .2378     | .2378     |
| 24   | 1.4661    | 1.448     | 1.4661    | 1.8099    | .2172     | .2353     | .2195     |
| Max  | 2.4253    | 1.9728    | 1.9185    | 1.8099    | 1.9366    | 2.0814    | 2.0851    |
| Min  | .1267     | .1086     | .1086     | .1267     | .0905     | .0724     | .1829     |
| Avg  | .8597     | .7821     | .8295     | .8009     | .7208     | .8097     | .8477     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124004 / 33/11 kV TALEGAON S/STN

Feeder No / Name : 201 / 11 KV TALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3688     | .3086     | .3353     | .4954     | .5258     | .5716     | .5716     |
| 2    | .3856     | .3258     | .3688     | .4954     | .5609     | .5716     | .5716     |
| 3    | .4359     | .3601     | .3856     | .4954     | .5609     | .5716     | .5716     |
| 4    | .4694     | .5144     | .503      | .6478     | .5959     | .6668     | .724      |
| 5    | .5533     | .6687     | .7209     | .7621     | .6859     | .7049     | .9145     |
| 6    | .7042     | 1.1145    | .8383     | .9145     | .7888     | .8954     | .9907     |
| 7    | .8048     | 1.0802    | .9892     | .7621     | .6859     | .7621     | .7621     |
| 8    | .6706     | .8402     | .8718     | .5716     | .5548     | .5335     | .5716     |
| 9    | .4527     | .5868     | .6874     | .4572     | .4382     | .4191     | .5335     |
| 10   | .4191     | .4572     | .4191     | .4382     |           | .4763     | .4207     |
| 11   | .381      | .3048     | .3429     | .823      | .7042     | .6203     | .703      |
| 12   | .381      | .3048     | .3429     | .7545     | .8383     | .5365     | .6859     |
| 13   | .381      | .3429     | .3048     | .7373     | .9389     | .503      | .5316     |
| 14   | .4001     | .381      | .362      | .7545     | .5533     | .3688     | .4458     |
| 15   | .4191     | .4382     | .3429     | .4801     | .5365     | .4191     | .4458     |
| 16   | .4382     | .4191     | .4001     | .6001     | .503      | .503      | .5365     |
| 17   | .4207     | .3429     | .4572     | .7888     | .503      | .6539     | .5868     |
| 18   | .5258     | .4954     | .4954     | .6661     | .57       | .5365     | .5868     |
| 19   | .6836     |           | .6859     | .7011     | .6668     | .7621     | .7811     |
| 20   | .7628     | .8383     | .7621     | .6661     | .8383     | .8383     | .8573     |
| 21   | .7186     | .7811     | .7621     | .631      | .8192     | .7621     | .8002     |
| 22   | .631      | .6668     | .6668     | .5959     | .724      | .6859     | .724      |
| 23   | .5959     | .6097     | .5716     | .5959     | .7049     | .6097     | .6478     |
| 24   | .3018     | .3258     | .503      | .5335     | .5784     | .6097     | .5716     |
| Max  | .8048     | 1.1145    | .9892     | .9145     | .9389     | .8954     | .9907     |
| Min  | .3018     | .3048     | .3048     | .4382     | .4382     | .3688     | .4207     |
| Avg  | .5127     | .5438     | .5466     | .6403     | .6468     | .6076     | .6473     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124004 / 33/11 kV TALEGAON S/STN

Feeder No / Name : 202 / 11 KV HATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5868     | .3258     | .5868     | .5716     | .5144     | .5716     | .6859     |
| 2    | .4191     | .3258     | .503      | .5716     | .5144     | .4763     | .6859     |
| 3    | .4359     | .3258     | .4527     | .5716     |           | .4763     | .6859     |
| 4    | .503      | .3429     | .5533     | .7621     | .5144     | .6097     | .9145     |
| 5    | .5365     | .5144     | .6874     | 1.0669    | .6516     | .8192     | 1.0288    |
| 6    | .6036     | .6859     | .7545     | 1.1812    | .8916     | .9526     | 1.2384    |
| 7    | .6706     | .6001     | .8383     | 1.0669    | .9431     | 1.2384    | 1.1431    |
| 8    | .6706     | .6001     | .7545     | .8002     | .7373     | .9526     | .8002     |
| 9    | .5868     | .5868     | .5868     | .8002     |           | .7621     | .6859     |
| 10   | .6668     |           | .6478     | .4681     |           | .7049     | .5375     |
| 11   |           | .6668     | .4954     | .5144     | .5868     | .5365     | .4801     |
| 12   | .5716     | .6668     | .4954     | .5144     | .503      | .503      |           |
| 13   | .5716     | .5716     | .5144     | .5487     | .503      | .4862     |           |
| 14   | .5716     | .6668     | .4954     | .5144     | .5868     | .4694     |           |
| 15   | .5716     | .6859     | .4954     | .4287     | .503      | .4862     |           |
| 16   | .5906     | .7049     | .5335     | .4801     | .503      | .503      |           |
| 17   | .5721     | .724      |           | .5144     | .503      | .5365     |           |
| 18   | .5548     | .7621     | .5335     | .3772     | .5868     | .4024     |           |
| 19   | .7108     |           | .7621     | .6516     | .8573     | .8383     |           |
| 20   | .8149     | 1.0479    | .9145     | .7716     | 1.0479    | 1.0288    |           |
| 21   | .703      | .8764     | .8383     | .7202     | .9526     | .9145     |           |
| 22   | .6241     | .8192     | .7621     | .6588     | .8764     | .8383     |           |
| 23   | .5721     | .7621     | .6859     | .6068     | .7621     | .7621     |           |
| 24   | .503      | .3814     | .5716     | .5716     | .5548     | .6668     | .7621     |
| Max  | .8149     | 1.0479    | .9145     | 1.1812    | 1.0479    | 1.2384    | 1.2384    |
| Min  | .4191     | .3258     | .4527     | .3772     | .503      | .4024     | .4801     |
| Avg  | .5918     | .6202     | .6288     | .6556     | .6711     | .6890     | .8040     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124004 / 33/11 kV TALEGAON S/STN

Feeder No / Name : 203 / 11 KV PIMPALWAD(ANDHARI) SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5335     | .5716     | .5716     | 1.2689    | 1.085     | 1.4575    | 1.2689    |
| 2    | .4763     | .5906     | .5335     | 1.2407    | 1.085     | 1.5061    | 1.2689    |
| 3    | .4763     | .6287     | .5335     | 1.2407    | 1.085     | 1.2955    | 1.3032    |
| 4    | .7049     | .6287     | .724      | 1.6766    | 1.2146    | 1.3413    | 1.5089    |
| 5    | .8192     | .7621     | .8764     | 1.8107    | 1.6194    | 1.5061    | 1.6766    |
| 6    | .9335     | .9526     | 1.0098    | 2.0119    | 1.8623    | 1.8623    | 1.7772    |
| 7    | 1.0669    | .8764     | 1.0288    | 1.9113    | 1.7814    | 1.8461    | 2.0119    |
| 8    | .8764     | .7621     | .7621     | 1.7604    | 1.749     | 1.6194    | 1.8945    |
| 9    | .5716     | .5906     | .6097     | 1.4419    | 1.4737    | 1.6356    | 1.643     |
| 10   | .6097     | .5144     | .4954     | .4954     |           |           | .4572     |
| 11   | 1.7939    | 1.8623    | 1.7833    | .5525     | .6287     | .5144     | .5335     |
| 12   | 1.9113    | 2.0405    | 1.9547    | .5906     | .5906     | .6287     | .5906     |
| 13   | 1.8778    | 2.1538    | 1.8861    | .6668     | .6287     | .6287     | .6478     |
| 14   | 1.8442    | 1.9433    | 1.8176    | .5906     | .6668     | .6287     | .6097     |
| 15   | 1.8275    | 1.9757    | 1.8004    | .6097     | .6097     | .6668     | .724      |
| 16   | 1.9113    | 1.8947    | 1.7661    | .5906     | .6859     | .6668     | .6668     |
| 17   | 1.8623    | 1.8461    | 1.6644    | .5906     | .724      | .7049     | .7811     |
| 18   | 1.6518    | 1.668     | 1.6476    | .6668     | .6097     | .6097     | .6859     |
| 19   | .7811     | .724      | .6097     | .724      | .6668     | .7049     | .8954     |
| 20   | .9717     | .9526     | .8002     | .7621     | .7811     | .724      | .9717     |
| 21   | .9526     | .8383     | .6859     | .6668     | .6668     | .724      | .8764     |
| 22   | .7621     | .7621     | .5716     | .5906     | .6097     | .6478     | .7621     |
| 23   | .6859     | .6668     | .5335     | .4954     | .4763     | .6097     | .6478     |
| 24   | .5335     | .5716     | .6097     | 1.6476    | 1.0364    | 1.6263    | 1.2689    |
| Max  | 1.9113    | 2.1538    | 1.9547    | 2.0119    | 1.8623    | 1.8623    | 2.0119    |
| Min  | .4763     | .5144     | .4954     | .4954     | .4763     | .5144     | .4572     |
| Avg  | 1.1015    | 1.1157    | 1.0532    | 1.0251    | .9712     | 1.0502    | 1.0613    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124004 / 33/11 kV TALEGAON S/STN

Feeder No / Name : 204 / 11 KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0762     | .1715     | .0953     | .0953     | .1524     | .0953     | .0953     |
| 2    | .0762     | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     |
| 3    | .0762     | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     |
| 4    | .0762     | .1715     | .0953     | .0953     | .1715     | .0953     | .0762     |
| 5    | .0762     | .1715     | .0953     | .0953     | .1334     | .0953     | .0762     |
| 6    | .0762     | .1715     | .0953     | .0953     | .1334     | .0953     | .0762     |
| 7    | .0762     | .1715     | .0953     | .0953     | .1334     | .0953     | .0762     |
| 8    | .0381     | .1524     | .0953     | .0762     | .2477     | .2286     | .0953     |
| 9    | .2858     | .1524     | .0953     | .0953     | .2286     | .0381     | .0953     |
| 10   | .2286     | .1715     | .0953     | .0953     |           | .2286     | .0953     |
| 11   | .2286     | .1524     | .0953     | .1524     | .1524     | .2667     | .0953     |
| 12   | .2286     | .1524     | .1143     | .0953     | .1524     | .2096     | .0953     |
| 13   | .2286     | .1524     | .0953     | .1524     | .1524     | .2096     | .0953     |
| 14   | .2096     | .1524     | .0953     | .0953     | .1524     | .2096     | .0762     |
| 15   | .2096     | .1524     | .0953     | .1524     | .1524     | .2096     | .2286     |
| 16   | .1715     | .0953     | .0953     | .1524     | .2286     | .2096     | .2096     |
| 17   | .1524     | .0953     | .0953     | .1715     | .2286     | .2096     | .2096     |
| 18   | .1715     |           | .0953     | .1524     | .2096     | .1905     | .2096     |
| 19   | .1715     |           | .1143     | .1715     | .2096     | .1715     | .2286     |
| 20   | .1715     | .1143     | .1143     | .1715     | .2286     | .0953     | .2286     |
| 21   | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     | .1715     |
| 22   | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     | .1143     |
| 23   | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     | .0381     |
| 24   | .0953     | .1715     | .0953     | .0953     | .1715     | .0953     | .0953     |
| Max  | .2858     | .1715     | .1143     | .1715     | .2477     | .2667     | .2286     |
| Min  | .0381     | .0953     | .0953     | .0762     | .0953     | .0381     | .0381     |
| Avg  | .1516     | .1455     | .0977     | .1255     | .1682     | .1469     | .1239     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 201 / 11 KV ADGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2957     | .5401     | .2999     |           |           |           |           |
| 2    | .3113     | .5361     | .3018     |           |           |           |           |
| 3    | .3129     | .5435     | .306      |           |           |           |           |
| 4    | .344      | .5448     | .3704     |           |           |           |           |
| 5    | .3631     | .7517     | .4675     |           |           |           |           |
| 6    | .5364     | .893      | .6882     |           |           |           |           |
| 7    |           | .9591     | 1.012     |           |           |           |           |
| 8    |           | .8005     | .8282     |           |           |           |           |
| 9    |           | .7316     | .7225     |           |           |           |           |
| 11   |           |           |           | .9194     | .8223     | .6173     | .6807     |
| 12   |           |           |           | 1.0735    | .8223     | .7195     | .6857     |
| 13   |           |           |           | .9351     | .703      | .6718     | .6874     |
| 14   |           |           |           | .8084     | .5886     | .6234     | .6142     |
| 15   |           |           |           | .6987     | .5195     | .5017     | .463      |
| 16   |           |           |           | .6666     | .6135     | .4853     | .526      |
| 17   |           |           |           | .6188     | .6611     | .5921     | .6036     |
| 18   |           |           |           | .5611     | .5683     | .4603     | .467      |
| 24   | .4067     | .4595     | .2842     |           |           |           |           |
| Max  | .5364     | .9591     | 1.012     | 1.0735    | .8223     | .7195     | .6874     |
| Min  | .2957     | .4595     | .2842     | .5611     | .5195     | .4603     | .463      |
| Avg  | .3672     | .6760     | .5281     | .7852     | .6623     | .5839     | .5910     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 202 / 11 KV BRAHMANSHEVGE  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0709     | .0827     | .0832     | .0689     |
| 2    |           |           |           | .0706     | .0835     | .0838     | .0702     |
| 3    |           |           |           | .0704     | .0864     | .086      | .0843     |
| 4    |           |           |           | .0863     | .1152     | .1043     | .0912     |
| 5    |           |           |           | .092      | .1427     | .1065     | .1467     |
| 6    |           |           |           | .2942     | .3045     | .1496     | .2054     |
| 7    |           |           |           | .489      | .5689     | .6893     | .621      |
| 8    |           |           |           | .4344     | .5959     | .5513     | .5247     |
| 9    |           |           |           | .3152     | .4241     | .1524     | .3347     |
| 11   | .6234     | .6313     | .3141     |           |           |           |           |
| 12   | .8909     | .6296     | .5053     |           |           |           |           |
| 13   | .7907     | .5156     | .5456     |           |           |           |           |
| 14   | .6884     | .3814     | .4633     |           |           |           |           |
| 15   | .6127     | .3981     | .319      |           |           |           |           |
| 16   | .6043     | .4043     | .3544     |           |           |           |           |
| 17   | .5357     | .3915     | .3463     |           |           |           |           |
| 18   | .2042     | .3212     | .3126     |           |           |           |           |
| 24   |           |           |           | .072      | .0882     | .0799     | .0554     |
| Max  | .8909     | .6313     | .5456     | .489      | .5959     | .6893     | .621      |
| Min  | .2042     | .3212     | .3126     | .0704     | .0827     | .0799     | .0554     |
| Avg  | .6188     | .4591     | .3951     | .1995     | .2492     | .2086     | .2203     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 203 / 11 KV UMBERKHED

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1467     | .3185     | .1942     |           |           |           |           |
| 2    | .1616     | .3198     | .1947     |           |           |           |           |
| 3    | .1623     | .3232     | .1958     |           |           |           |           |
| 4    | .1771     | .3244     | .2115     |           |           |           |           |
| 5    | .1783     | .4134     | .2262     |           |           |           |           |
| 6    | .2474     | .5401     | .3118     |           |           |           |           |
| 7    |           | .6241     | .6142     |           |           |           |           |
| 8    |           | .5309     | .5676     |           |           |           |           |
| 9    |           | .5135     | .4418     |           |           |           |           |
| 11   |           |           |           | .6089     | .4538     | .4458     | .414      |
| 12   |           |           |           | .684      | .489      | .513      | .4458     |
| 13   |           |           |           | .6319     | .4578     | .4527     | .4475     |
| 14   |           |           |           | .4961     | .4156     | .4079     | .342      |
| 15   |           |           |           | .4145     | .3539     | .3691     | .348      |
| 16   |           |           |           | .3869     | .4166     | .3567     | .3819     |
| 17   |           |           |           | .375      | .3997     | .4182     | .3765     |
| 18   |           |           |           | .3636     | .372      | .3429     | .3035     |
| 24   | .186      | .2896     | .1931     |           |           |           |           |
| Max  | .2474     | .6241     | .6142     | .684      | .489      | .513      | .4475     |
| Min  | .1467     | .2896     | .1931     | .3636     | .3539     | .3429     | .3035     |
| Avg  | .1799     | .4198     | .3151     | .4951     | .4198     | .4133     | .3824     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 204 / 11 KV ADGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4481     | .3734     | .4108     | .3361     | .3361     | .3547     | .3921     |
| 2    | .4527     | .3734     | .4108     | .3361     | .3361     | .3547     | .3921     |
| 3    | .4527     | .3734     | .4294     | .3361     | .3734     | .3734     | .4294     |
| 4    | .5281     | .4108     | .5228     | .3734     | .4854     | .4481     | .5228     |
| 5    | .5658     | .6036     | .5847     | .6722     | .6908     | .5975     | .6348     |
| 6    | .9149     | .8402     | .7167     | .9054     | .9522     | .8589     | .8589     |
| 7    | .8589     | .8299     | .6413     | .5975     | .7282     | .7167     | .6979     |
| 8    | .6535     | .5228     | .5228     | .5975     | .6283     | .5788     | .4715     |
| 9    | .4435     | .4527     | .3395     | .4715     | .3734     | .4572     | .4435     |
| 10   | .362      | .415      | .3982     | .3772     | .362      | .362      | .4435     |
| 11   | .2896     | .3395     | .3982     | .3772     | .3658     | .362      | .3582     |
| 12   | .362      | .3018     | .3582     | .3018     | .3326     | .362      | .3258     |
| 13   | .2865     | .3206     | .3224     | .3206     | .3696     | .362      | .3292     |
| 14   | .2865     | .3206     | .362      | .3206     | .362      | .362      | .394      |
| 15   | .2926     | .3395     | .3801     | .3395     | .2926     | .3982     | .362      |
| 16   | .362      | .3584     | .3801     | .3772     | .3258     | .3982     | .3258     |
| 17   |           | .3961     | .3544     | .3658     | .4075     | .415      | .3361     |
| 18   |           | .4527     | .4527     | .4207     | .4119     | .4527     | .4207     |
| 19   | .6516     | .6602     | .6516     | .5792     | .5792     | .679      | .5281     |
| 20   | .6401     | .7545     | .695      | .7023     | .5914     | .6224     | .6584     |
| 21   | .462      | .5847     | .5914     | .6219     | .5359     | .6036     | .6401     |
| 22   | .5175     | .5041     | .4668     | .567      | .4435     | .547      | .5853     |
| 23   | .4481     | .4338     | .3734     | .5175     | .4024     | .4338     | .439      |
| 24   | .2218     | .3734     | .4108     | .3361     | .3881     | .3696     | .4108     |
| Max  | .9149     | .8402     | .7167     | .9054     | .9522     | .8589     | .8589     |
| Min  | .2218     | .3018     | .3224     | .3018     | .2926     | .3547     | .3258     |
| Avg  | .4773     | .4723     | .4656     | .4646     | .4614     | .4779     | .475      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 205 / 11 KV SHIRASGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3361     | .2987     | .3361     | .2987     | .3018     | .2829     | .3174     |
| 2    | .3361     | .2987     | .3361     | .2987     | .3018     | .2829     | .3174     |
| 3    | .3734     | .2987     | .3361     | .2987     | .3018     | .2829     | .3361     |
| 4    | .4481     | .3734     | .3734     | .3174     | .3772     | .3772     | .3734     |
| 5    | .4854     | .5281     | .5281     | .4481     | .4527     | .5281     | .547      |
| 6    | .811      | .9054     | .7545     | .8299     | .8299     | .7733     | .7733     |
| 7    | .7733     | .6722     | .679      | .6722     | .6602     | .6979     | .679      |
| 8    | .547      | .462      | .4668     | .4435     | .4854     | .5359     | .4715     |
| 9    | .4481     | .3881     | .3658     | .4066     | .3982     | .4163     | .443      |
| 10   | .3658     | .3292     | .3696     | .3326     | .2865     | .3224     | .4477     |
| 11   | .2926     | .2926     | .3696     | .2987     | .2835     | .2896     | .4344     |
| 12   | .2957     | .2743     | .3292     | .2054     | .2865     | .2715     | .2926     |
| 13   | .2957     | .2561     | .2743     | .2033     |           | .2896     | .2926     |
| 14   | .2957     | .2987     | .2743     | .2218     | .2715     | .2896     | .2715     |
| 15   | .2926     | .2957     | .2743     | .2957     | .2896     | .2926     | .2926     |
| 16   | .2926     | .3142     | .2772     | .2957     | .2926     | .2926     | .2926     |
| 17   |           | .3142     | .2896     | .3109     | .3224     | .2926     | .2865     |
| 18   |           | .3258     | .3429     | .3582     | .3721     | .3258     | .3856     |
| 19   | .5792     | .5973     | .5487     | .4706     | .543      | .5853     | .5792     |
| 20   | .6401     | .5914     | .5853     | .5853     | .5847     | .5175     | .5853     |
| 21   | .5121     | .499      | .4435     | .4755     | .4706     | .4854     | .5487     |
| 22   | .3658     | .3881     | .4108     | .3841     | .3734     | .4251     | .4024     |
| 23   | .3658     | .3326     | .3361     | .3658     | .3511     | .3292     | .3658     |
| 24   | .3292     | .2987     | .3361     | .2987     | .2987     | .3109     | .3142     |
| Max  | .811      | .9054     | .7545     | .8299     | .8299     | .7733     | .7733     |
| Min  | .2926     | .2561     | .2743     | .2033     | .2715     | .2715     | .2715     |
| Avg  | .4310     | .4014     | .4016     | .3798     | .3972     | .3957     | .4187     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124078 / 33/11 KV ADGAON

Feeder No / Name : 206 / 11 KV DEOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1027     | .2258     | .1235     |           |           |           |           |
| 2    | .1055     | .2263     | .1241     |           |           |           |           |
| 3    | .1217     | .2229     | .1253     |           |           |           |           |
| 4    | .1376     | .2692     | .1551     |           |           |           |           |
| 5    | .1532     | .3383     | .2138     |           |           |           |           |
| 6    | .2102     | .5494     | .3165     |           |           |           |           |
| 7    |           |           | .5098     |           |           |           |           |
| 8    |           | .4129     | .4264     |           |           |           |           |
| 9    |           | .3819     | .3361     |           |           |           |           |
| 11   | .2102     |           |           | .4002     | .4073     | .3493     | .3311     |
| 12   |           |           |           | .4979     | .4561     | .4023     | .2907     |
| 13   |           |           |           | .4515     | .4161     | .3567     | .2869     |
| 14   |           |           |           | .3765     | .3457     | .2964     | .2103     |
| 15   |           |           |           | .3139     | .2524     | .2413     | .232      |
| 16   |           |           |           | .3734     | .2789     | .2545     | .2347     |
| 17   |           |           |           | .4304     | .3221     | .3102     | .376      |
| 18   |           |           |           | .3315     | .2293     | .2421     | .2476     |
| 24   | .1103     | .2263     | .1229     |           |           |           |           |
| Max  | .2102     | .5494     | .5098     | .4979     | .4561     | .4023     | .376      |
| Min  | .1027     | .2229     | .1229     | .3139     | .2293     | .2413     | .2103     |
| Avg  | .1439     | .317      | .2454     | .3969     | .3385     | .3066     | .2762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124108 / 33/11 KV UMBERKHED S/STN

Feeder No / Name : 201 / 11 KV GIRNA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 1.0526    | 1.0883    | 1.085     |
| 2    |           |           |           |           | 1.0364    | 1.0911    | 1.0526    |
| 3    |           |           |           |           | 1.0364    | 1.1227    | 1.0688    |
| 4    |           |           |           |           | 1.0526    | 1.1498    | 1.1012    |
| 5    |           |           |           |           | 1.0526    | 1.1822    | 1.1336    |
| 6    |           |           |           |           | 1.1012    | 1.2018    | 1.1822    |
| 7    |           |           |           |           | 1.2308    | 1.2492    | 1.3927    |
| 8    |           |           |           |           | 1.3441    | 1.3443    | 1.3927    |
| 9    |           |           |           |           | 1.3765    | 1.3117    | 1.2955    |
| 11   |           | 1.5223    | 1.4737    | 1.3603    |           |           |           |
| 12   |           | 1.3441    | 1.3279    | 1.3927    |           |           |           |
| 13   |           | 1.4251    | 1.5223    | 1.5223    |           |           |           |
| 14   |           | 1.3765    | 1.4251    | 1.4251    |           |           |           |
| 15   |           | 1.3603    | 1.3603    | 1.4413    |           |           |           |
| 16   |           | 1.3927    | 1.2955    | 1.4089    |           |           |           |
| 17   |           | 1.247     | 1.2631    | 1.2631    |           |           |           |
| 18   | 1.1523    | 1.2146    | 1.1092    | 1.085     |           |           |           |
| 19   | 1.4899    |           |           |           |           |           |           |
| 20   | 1.4243    |           |           |           |           |           |           |
| 21   | 1.3763    |           |           |           |           |           |           |
| 22   | 1.3765    |           |           |           |           |           |           |
| 24   |           |           |           |           | 1.0364    | 1.0202    | 1.085     |
| Max  | 1.4899    | 1.5223    | 1.5223    | 1.5223    | 1.3765    | 1.3443    | 1.3927    |
| Min  | 1.1523    | 1.2146    | 1.1092    | 1.085     | 1.0364    | 1.0202    | 1.0526    |
| Avg  | 1.3639    | 1.3603    | 1.3471    | 1.3623    | 1.1320    | 1.1761    | 1.1789    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124108 / 33/11 KV UMBERKHED S/STN

Feeder No / Name : 202 / 11 KV VERKHEDA BK AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     | .2812     | .2187     |           |           |           |
| 2    | .2743     | .2846     | .2031     |           |           |           |
| 3    | .2846     | .2656     | .2031     |           |           |           |
| 4    | .2743     | .2812     | .2031     |           |           |           |
| 5    | .2688     | .2846     | .2214     |           |           |           |
| 6    | .2688     | .2846     | .2214     |           |           |           |
| 7    | .2846     | .2591     | .2056     |           |           |           |
| 8    | .2743     | .2378     | .2031     |           |           |           |
| 9    | .2656     | .2378     | .2372     |           |           |           |
| 11   |           |           |           | .3077     | .2812     | .2812     |
| 12   |           |           |           | .3277     | .3005     | .2968     |
| 13   |           |           |           | .3125     | .2968     | .2778     |
| 14   |           |           |           | .2968     | .2968     | .2469     |
| 15   |           |           |           | .3163     | .2812     | .25       |
| 16   |           |           |           | .2968     | .2343     | .2343     |
| 17   |           |           |           | .3041     | .2469     | .2439     |
| 18   |           |           |           | .2896     | .253      | .2408     |
| 24   | .2812     | .2812     | .2343     |           |           |           |
| Max  | .2846     | .2846     | .2372     | .3277     | .3005     | .2968     |
| Min  | .2656     | .2378     | .2031     | .2896     | .2343     | .2343     |
| Avg  | .2751     | .2698     | .2151     | .3064     | .2738     | .2590     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124108 / 33/11 KV UMBERKHED S/STN

Feeder No / Name : 203 / 11 KV NAVEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .7116     | .7701     | .6327     |
| 2    |           |           |           |           | .703      | .7701     |           |
| 3    |           |           |           |           | .7186     | .7682     | .6405     |
| 4    |           |           |           |           | .7202     | .7935     | .6718     |
| 5    |           |           |           |           | .759      | .8259     | .6718     |
| 6    |           |           |           |           | .7907     | .7682     | .7099     |
| 7    |           |           |           |           | .9282     | .9175     | .8436     |
| 8    |           |           |           |           | .9602     | .9231     | .8642     |
| 9    |           |           |           |           | .9069     | .9012     | .8124     |
| 11   |           | 1.0467    | .9755     | .9602     |           |           |           |
| 12   |           | 1.0595    | 1.0562    | 1.0364    |           |           |           |
| 13   |           | 1.1248    | 1.1043    | 1.0364    |           |           |           |
| 14   |           | 1.0494    | 1.0883    | 1.0402    |           |           |           |
| 15   |           | .9907     | .9998     | 1.0242    |           |           |           |
| 16   |           | .9877     | .8539     | 1.085     |           |           |           |
| 17   |           | .9907     | .7274     | 1.0402    |           |           |           |
| 18   | .7468     | .9259     | .7842     | .8855     |           |           |           |
| 19   | 1.0648    |           |           |           |           |           |           |
| 20   | .8951     |           |           |           |           |           |           |
| 21   | .7773     |           |           |           |           |           |           |
| 22   | .9414     |           |           |           |           |           |           |
| 24   |           |           |           |           | .6718     | .6642     | .6327     |
| Max  | 1.0648    | 1.1248    | 1.1043    | 1.085     | .9602     | .9231     | .8642     |
| Min  | .7468     | .9259     | .7274     | .8855     | .6718     | .6642     | .6327     |
| Avg  | .8851     | 1.0219    | .9487     | 1.0135    | .7870     | .8102     | .7200     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124108 / 33/11 KV UMBERKHED S/STN

Feeder No / Name : 205 / 11 KV BHAIROBA FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.1714    | 2.0891    | 2.0481    |           |           |           |
| 2    | 2.1548    | 2.0809    | 2.0481    |           |           |           |
| 3    | 2.1051    | 2.13      | 2.1216    |           |           |           |
| 4    | 2.1382    | 2.0729    | 2.1714    |           |           |           |
| 5    | 2.2211    | 2.1464    | 2.2211    |           |           |           |
| 6    | 2.4478    | 2.2211    | 2.2708    |           |           |           |
| 7    | 2.4646    | 2.42      | 2.2283    |           |           |           |
| 8    | 2.2874    | 2.2045    | 2.1548    |           |           |           |
| 9    | 2.17      | 2.1051    | 1.9498    |           |           |           |
| 11   |           |           |           | 2.713     | 2.649     | 2.5484    |
| 12   |           |           |           | 2.2131    | 2.3868    | 2.5316    |
| 13   |           |           |           | 2.3807    | 2.42      | 2.4531    |
| 14   |           |           |           | 2.304     | 2.4006    | 2.2874    |
| 15   |           |           |           | 2.4905    | 2.2634    | 2.5484    |
| 16   |           |           |           | 2.3807    |           | 2.4646    |
| 17   |           |           |           | 2.42      |           | 2.3537    |
| 18   |           |           |           | 2.1216    | 2.304     | 2.2874    |
| 19   |           |           |           |           | 2.1792    |           |
| 24   | 2.2211    | 2.1216    | 2.0317    |           |           |           |
| Max  | 2.4646    | 2.42      | 2.2708    | 2.713     | 2.649     | 2.5484    |
| Min  | 2.1051    | 2.0729    | 1.9498    | 2.1216    | 2.1792    | 2.2874    |
| Avg  | 2.2382    | 2.1592    | 2.1246    | 2.3780    | 2.3719    | 2.4343    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124108 / 33/11 KV UMBERKHED S/STN

Feeder No / Name : 206 / 11 KV UMBERKHED GAOTHAN GAOTHAN FEEDER  
FEEDER Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4075     | .4075     | .4207     | .4382     | .4031     | .4031     | .4031     |
| 2    | .4075     | .394      | .4252     | .4382     | .3988     | .3988     | .3814     |
| 3    | .394      | .3898     | .4075     | .4607     | .4161     | .3988     | .4075     |
| 4    | .4207     | .394      | .4298     | .5014     | .443      | .4557     | .4207     |
| 5    | .4706     | .4298     | .4706     | .5373     | .4887     | .4908     | .4784     |
| 6    | .5359     | .5249     | .6036     | .5552     | .567      | .5895     | .5853     |
| 7    | .567      | .4784     | .543      | .5552     | .5611     | .5201     | .543      |
| 8    | .4477     | .3681     | .4075     | .443      | .4477     | .3856     | .4382     |
| 9    | .4161     | .333      | .4119     | .3944     | .3688     | .3121     | .3521     |
| 10   | .3988     | .3294     | .4477     | .3441     | .373      | .3521     | .3149     |
| 11   | .3641     | .3258     | .3898     | .3772     | .2915     | .333      | .3121     |
| 12   | .3086     | .3294     | .333      | .3988     | .2601     | .3681     | .3467     |
| 13   | .3086     | .3155     | .3121     | .3641     | .3086     | .3856     | .3544     |
| 14   | .3294     | .3155     | .333      | .3681     | .3155     | .3856     | .3544     |
| 15   | .3601     | .3544     | .3189     | .3681     | .3467     | .2658     | .3721     |
| 16   |           | .3155     | .3155     | .3681     | .3506     | .3258     | .3898     |
| 17   | .4031     | .3429     | .3681     | .3772     | .4115     | .373      | .4334     |
| 18   | .4733     | .3481     | .3898     | .3812     | .3814     | .39       | .4578     |
| 19   | .4784     | .4458     | .4525     | .4973     | .4287     | .4961     | .4917     |
| 20   | .4607     | .5138     | .4733     | .4908     | .4681     | .4961     | .4961     |
| 21   | .4607     | .4908     | .4733     | .4854     | .4557     | .4733     | .4854     |
| 22   | .4508     | .4854     | .4508     | .4508     | .4557     | .4733     | .4557     |
| 23   | .4161     | .4508     | .4508     | .4334     | .4334     | .4557     | .4607     |
| 24   | .4115     | .4075     | .443      | .443      | .4207     | .4161     | .4252     |
| Max  | .567      | .5249     | .6036     | .5552     | .567      | .5895     | .5853     |
| Min  | .3086     | .3155     | .3121     | .3441     | .2601     | .2658     | .3121     |
| Avg  | .4214     | .3954     | .4196     | .4363     | .4081     | .4143     | .4233     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124111 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11KV TALONDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1873    | 1.1888    | 1.3765    | 1.1265    |           |           |           |
| 2    | 1.2037    | 1.2342    | 1.4089    | 1.1544    |           |           |           |
| 3    | 1.1717    | 1.2651    | 1.3763    | 1.1717    |           |           |           |
| 4    | 1.1728    | 1.3123    | 1.4083    | 1.2334    |           |           |           |
| 5    | 1.2334    | 1.4575    | 1.4575    | 1.2809    |           |           |           |
| 6    | 1.4089    | 1.6907    | 1.5061    | 1.4575    |           |           |           |
| 7    | 1.9113    | 2.1365    | 2.0119    | 1.8778    |           |           |           |
| 8    | 2.0119    | 2.0119    | 1.9062    | 1.7695    |           |           |           |
| 9    | 1.4883    | 1.8399    | 1.3599    | 1.6324    |           |           |           |
| 11   |           |           |           |           |           | 2.0348    | 1.933     |
| 12   |           |           |           |           | 1.8275    | 2.4446    | 2.1125    |
| 13   |           |           |           |           | 1.9281    | 1.933     | 1.9839    |
| 14   |           |           |           |           | 1.9784    | 2.0119    | 1.9334    |
| 15   |           |           |           |           | 1.9784    | 1.9839    | 1.8679    |
| 16   |           |           |           |           | 2.0119    | 1.9113    | 1.8842    |
| 17   |           |           |           |           | 1.8623    | 1.8623    | 1.8461    |
| 18   |           |           |           |           | 1.6804    | 1.7553    | 1.7341    |
| 24   | 1.1574    | 1.1574    | 1.3765    | 1.1574    |           |           |           |
| Max  | 2.0119    | 2.1365    | 2.0119    | 1.8778    | 2.0119    | 2.4446    | 2.1125    |
| Min  | 1.1574    | 1.1574    | 1.3599    | 1.1265    | 1.6804    | 1.7553    | 1.7341    |
| Avg  | 1.3947    | 1.5294    | 1.5188    | 1.3862    | 1.8953    | 1.9921    | 1.9119    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124111 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11KV SHIRASGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .0533     | .1143     | .092      |
| 2    |           |           |           |           | .0676     | .1286     | .08       |
| 3    |           |           |           |           | .0823     | .1303     | .0657     |
| 4    |           |           |           |           | .0676     | .1448     | .0934     |
| 5    |           |           |           |           | .0667     | .2286     | .1067     |
| 6    |           |           |           |           | .2858     | .3048     | .381      |
| 7    |           |           |           |           | .5525     | .6097     | .6478     |
| 8    |           |           |           |           | .5906     |           | .7621     |
| 9    |           |           |           |           | .5144     | .4344     | .4694     |
| 11   | .3201     | .578      | .3858     | .4064     |           |           |           |
| 12   | .6097     | .5944     | .5575     | .5117     |           |           |           |
| 13   | .5796     | .5944     | .5428     | .4725     |           |           |           |
| 14   | .5001     | .5575     | .4793     | .3858     |           |           |           |
| 15   | .3814     | .5575     | .4371     | .3102     |           |           |           |
| 16   | .5335     | .5428     | .3948     | .3572     |           |           |           |
| 17   |           | .4108     | .3807     | .3292     |           |           |           |
| 18   | .2667     | .3292     | .2921     | .3111     |           |           |           |
| 24   |           |           |           |           | .0686     | .1128     | .0777     |
| Max  | .6097     | .5944     | .5575     | .5117     | .5906     | .6097     | .7621     |
| Min  | .2667     | .3292     | .2921     | .3102     | .0533     | .1128     | .0657     |
| Avg  | .4559     | .5206     | .4338     | .3855     | .2349     | .2454     | .2776     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124111 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11KV DESHMUKHWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .7145     | .8069     | .8036     |
| 2    |           |           |           |           | .7529     | .8215     | .8002     |
| 3    |           |           |           |           | .6859     | .8619     | .8177     |
| 4    |           |           |           |           | .7472     | .873      | .8431     |
| 5    |           |           |           |           | .8002     | .9031     | .8716     |
| 6    |           |           |           |           | 1.0536    | 1.1431    | 1.3904    |
| 7    |           |           |           |           | 1.5242    | 1.6604    | 1.866     |
| 8    |           |           |           |           | 1.6556    | .6287     | 1.8818    |
| 9    |           |           |           |           | 1.3756    | 1.5623    | 1.4661    |
| 11   | 1.9433    | 2.1052    | 1.9845    | 2.0805    |           |           |           |
| 12   | 2.4291    | 2.0485    | 1.9925    | 2.1125    |           |           |           |
| 13   | 2.3205    | 1.9134    | 1.8435    | 1.7711    |           |           |           |
| 14   | 1.8903    | 1.8233    | 1.713     | 1.6975    |           |           |           |
| 15   | 1.7078    | 1.8896    | 1.6156    | 1.5699    |           |           |           |
| 16   | 1.531     | 1.7901    | 1.5546    | 1.5123    |           |           |           |
| 17   |           | 1.6575    | 1.5242    | 1.5051    |           |           |           |
| 18   | 1.247     |           | 1.4784    | 1.4022    |           |           |           |
| 24   |           |           |           |           | .724      | .7964     | .8288     |
| Max  | 2.4291    | 2.1052    | 1.9925    | 2.1125    | 1.6556    | 1.6604    | 1.8818    |
| Min  | 1.247     | 1.6575    | 1.4784    | 1.4022    | .6859     | .6287     | .8002     |
| Avg  | 1.867     | 1.8897    | 1.7133    | 1.7064    | 1.0034    | 1.0057    | 1.1569    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124116 / 33/11 KV GANESHPUR S/STN

Feeder No / Name : 201 / 11 KV PATANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6478     |           |           |           |           | .4515     | .5182     |
| 2    | .6478     |           |           |           |           | .4687     | .5344     |
| 3    | .6964     |           |           |           |           | .463      | .5668     |
| 4    | .7287     |           |           |           |           | .5401     | .663      |
| 5    | 1.0526    |           |           |           |           | .703      | .8288     |
| 6    | 1.166     |           |           |           |           | .9259     | 1.1934    |
| 7    | 1.4575    |           |           |           |           | 1.0669    | 1.4089    |
| 8    | 1.4575    |           |           |           |           | .9374     | 1.1603    |
| 9    | 1.326     |           |           |           |           |           | .9945     |
| 10   |           |           |           | 1.4918    |           |           |           |
| 11   |           | 1.6575    | 1.4403    | 1.5746    | 1.2955    |           |           |
| 12   |           | 1.7814    | 1.1203    | 1.4089    | 1.2955    |           |           |
| 13   |           | 1.5384    | 1.2346    |           | 1.1336    |           |           |
| 14   |           | 1.2955    | 1.0936    | 1.1603    | .9717     |           |           |
| 15   |           | 1.2955    | 1.0802    | 1.1603    | .8097     |           |           |
| 16   |           | 1.326     | 1.0802    | 1.0774    | 1.1336    |           |           |
| 17   |           | 1.166     | 1.3717    | 1.1869    | 1.1069    |           |           |
| 18   |           | 1.0526    | .9717     | .6783     | .8002     |           |           |
| 24   |           |           |           |           |           | .4572     | .5344     |
| Max  | 1.4575    | 1.7814    | 1.4403    | 1.5746    | 1.2955    | 1.0669    | 1.4089    |
| Min  | .6478     | 1.0526    | .9717     | .6783     | .8002     | .4515     | .5182     |
| Avg  | 1.0200    | 1.3891    | 1.1741    | 1.2173    | 1.0683    | .6682     | .8403     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124116 / 33/11 KV GANESHPUR S/STN

Feeder No / Name : 202 / 11 KV PIMPRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0497     | .0486     | .0486     |           |           |           |
| 2    |           | .0663     | .0648     | .0486     |           |           |           |
| 3    |           | .0663     | .0648     | .0648     |           |           |           |
| 4    |           | .0829     | .0972     | .1134     |           |           |           |
| 5    |           | .116      | .1296     | .1457     |           |           |           |
| 6    |           | .1492     | .1457     | .1619     |           |           |           |
| 7    |           | .1658     | .1619     | .2105     |           |           |           |
| 8    |           | .1492     | .2429     | .2105     |           |           |           |
| 9    |           | .116      | .16       | .1134     | .081      |           |           |
| 10   |           |           |           |           | .1943     |           |           |
| 11   | .1326     |           |           |           | .1619     | .2572     | .1526     |
| 12   | .1658     |           |           |           | .1781     | .2374     | .1067     |
| 13   | .116      |           |           |           |           | .1865     | .1017     |
| 14   | .0663     |           |           |           |           | .1526     | .0678     |
| 15   | .0663     |           |           |           |           | .1017     | .0848     |
| 16   | .1492     |           |           |           |           | .1696     | .0848     |
| 17   | .1658     |           |           |           |           | .116      | .1296     |
| 18   | .1326     |           |           |           |           | .116      | .1457     |
| 24   |           | .0497     | .0486     |           |           |           |           |
| Max  | .1658     | .1658     | .2429     | .2105     | .1943     | .2572     | .1526     |
| Min  | .0663     | .0497     | .0486     | .0486     | .081      | .1017     | .0678     |
| Avg  | .1243     | .1011     | .1164     | .1242     | .1538     | .1671     | .1092     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124116 / 33/11 KV GANESHPUR S/STN

Feeder No / Name : 203 / 11 KV TAMBOLA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .5801     | .5801     | .5668     | .5316     |           |           |
| 2    |           | .5801     | .5801     | .5668     | .5316     |           |           |
| 3    |           | .6299     | .6133     | .6154     | .6173     |           |           |
| 4    |           | .6962     | .7127     | .7287     | .7202     |           |           |
| 5    |           | .8951     | .8619     | .9069     |           |           |           |
| 6    |           | 1.0277    | .9945     | 1.004     | .8478     |           |           |
| 7    |           | 1.1105    | 1.0442    | 1.1174    | 1.0343    |           |           |
| 8    |           | .8951     | 1.1105    | 1.085     |           |           |           |
| 9    |           | .779      | .8951     | .8288     | .5668     |           |           |
| 11   | 1.2431    |           |           |           |           | 1.2209    | 1.1271    |
| 12   | 1.1934    |           |           |           |           | 1.2431    | 1.1437    |
| 13   | .9945     |           |           |           |           | 1.0111    |           |
| 14   | .9282     |           |           |           |           | .8551     |           |
| 15   | .8453     |           |           |           |           | .8718     | .8817     |
| 16   | .8619     |           |           |           |           | .8551     | .9116     |
| 17   | .8785     |           |           |           |           | .8785     | .9393     |
| 18   | .7459     |           |           |           |           | .7293     | .8259     |
| 24   |           | .4641     | .5182     |           | .463      |           |           |
| Max  | 1.2431    | 1.1105    | 1.1105    | 1.1174    | 1.0343    | 1.2431    | 1.1437    |
| Min  | .7459     | .4641     | .5182     | .5668     | .463      | .7293     | .8259     |
| Avg  | .9614     | .7658     | .7911     | .8244     | .6641     | .9581     | .9716     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124116 / 33/11 KV GANESHPUR S/STN

Feeder No / Name : 204 / 11 KV GANESHPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5668     | .5144     | .5144     | .4858     | .5487     | .6401     | .6001     |
| 2    | .5668     | .5487     | .5487     | .5182     | .5487     | .6468     | .6001     |
| 3    | .5506     | .5487     | .6001     | .583      | .583      | .6468     | .6344     |
| 4    | .6154     | .6173     | .6344     | .5992     | .6859     | .724      | .6859     |
| 5    | .6802     | .6859     | .7202     | .7287     | .9259     | .9955     | .9602     |
| 6    | .7287     | .8059     | .823      | .7935     |           | 1.0974    | 1.0802    |
| 7    | .8583     | .8916     | .9088     | .8421     | .8573     | .961      | .9602     |
| 8    | .664      | .5967     | .703      | .6154     | .5487     | .6584     | .6859     |
| 9    | .5658     | .6173     | .6201     | .7202     |           |           | .6173     |
| 10   | .5487     | .5487     | .5609     | .6001     | .4372     | .5487     | .5487     |
| 11   | .6859     | .5658     | .443      | .6173     | .4049     | .4458     | .5487     |
| 12   | .583      | .4801     | .4477     | .4801     | .4049     | .4115     | .5144     |
| 13   | .5487     | .5144     | .443      | .4458     | .5182     | .5487     | .5144     |
| 14   | .5144     | .5316     | .4854     | .4801     | .4858     | .5144     | .4801     |
| 15   | .5144     | .5658     | .5316     | .4973     | .4696     | .5144     | .5144     |
| 16   | .583      | .583      | .5316     | .583      | .4696     | .5144     | .5144     |
| 17   | .6173     | .6001     | .5182     | .5487     | .6447     | .6687     | .6316     |
| 18   | .6173     | .6344     | .502      | .6173     | .7011     | .7202     | .664      |
| 19   | .7716     | .7716     | .7347     | .7716     | .6859     | .7716     | .7773     |
| 20   | .8059     | .823      | .7449     | .823      | .8688     | .8402     | .8097     |
| 21   | .7202     | .7202     | .7125     | .7888     | .8048     | .7545     | .6478     |
| 22   | .6687     | .6516     | .6316     | .6859     | .7392     | .703      | .664      |
| 23   | .5658     | .6173     | .5668     | .6173     | .6653     | .6344     | .6154     |
| 24   |           | .5144     | .5344     |           | .5144     | .6468     | .5668     |
| Max  | .8583     | .8916     | .9088     | .8421     | .9259     | 1.0974    | 1.0802    |
| Min  | .5144     | .4801     | .443      | .4458     | .4049     | .4115     | .4801     |
| Avg  | .6322     | .6229     | .6025     | .6279     | .6142     | .6786     | .6598     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124158 / 33/11 KV PIMPALGAON S/Stn

CSN

Feeder No / Name : 201 / 11 KV GANGASHRAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2096     | .1905     | .1715     | .1619     | .1457     | .1134     | .1134     |
| 2    | .1905     | .1905     | .1715     | .2105     | .1619     | .1134     | .1296     |
| 3    | .1905     | .1905     | .1886     | .2267     | .1943     | .1619     | .1619     |
| 4    | .2286     | .1905     | .2229     | .3401     | .1943     | .1781     | .1943     |
| 5    | .2858     | .2286     | .2401     | .3725     | .2267     | .1943     | .3725     |
| 6    | .3239     | .2858     | .2915     | .4049     | .2915     | .3563     | .4696     |
| 7    | .2286     | .1886     | .2229     | .4696     | .5344     | .4696     | .4858     |
| 8    | .1715     | .1715     | .1543     | .3401     | .4372     | .4696     | .4534     |
| 9    | .1334     | .12       | .1334     | .2105     | .3077     | .2591     | .3077     |
| 10   | .1524     | .1372     | .1143     | .1334     |           | .1134     | .1524     |
| 11   | .5182     | .3887     | .3725     | .1143     | .12       | .1334     | .1524     |
| 12   | .4049     | .3563     | .3401     | .1334     | .1372     | .1524     | .1524     |
| 13   | .3239     | .2915     | .2591     | .1334     | .1543     | .1524     | .1524     |
| 14   | .2591     | .2429     | .2591     | .1715     | .1543     | .1334     | .1524     |
| 15   | .2915     | .2267     | .2591     | .1715     | .1543     | .1524     | .1524     |
| 16   | .2753     | .2753     | .2915     | .1715     | .1715     | .1715     | .1524     |
| 17   | .3077     | .3077     | .3077     | .1715     | .1886     | .2096     | .1715     |
| 18   | .2267     | .2058     | .2105     | .2477     | .1886     | .2286     | .2096     |
| 19   | .2286     | .2229     | .2477     | .2858     | .2229     | .2858     | .2477     |
| 20   | .2477     | .2229     | .2477     | .2286     | .2572     | .2858     | .3048     |
| 21   | .2477     | .2401     | .2667     | .1905     | .2401     | .2858     | .2667     |
| 22   | .2286     | .2401     | .2286     | .1905     | .2229     | .2477     | .2667     |
| 23   | .1905     | .2058     | .1905     | .1905     | .1886     | .2096     | .2286     |
| 24   | .1905     | .1905     | .1886     | .1905     | .1134     | .1296     | .1134     |
| Max  | .5182     | .3887     | .3725     | .4696     | .5344     | .4696     | .4858     |
| Min  | .1334     | .12       | .1143     | .1143     | .1134     | .1134     | .1134     |
| Avg  | .2523     | .2296     | .2325     | .2276     | .2177     | .2170     | .2318     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-R-I[242] BU 8141

Substation No/ Name :- 124158 / 33/11 KV PIMPALGAON S/Stn

CSN

Feeder No / Name : 202 / 11 KV KARAJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1781     | .1619     | .1457     | .1715     | .2667     | .2229     | .2477     |
| 2    | .1781     | .1619     | .1296     | .2096     | .2667     | .2229     | .2477     |
| 3    | .1781     | .1619     | .1619     | .2286     | .2667     | .2229     | .2667     |
| 4    | .1943     | .1943     | .1781     | .2286     | .3048     | .2401     | .2858     |
| 5    | .2105     | .2267     | .1943     | .2477     | .3048     | .2572     | .3429     |
| 6    | .2858     | .3077     |           | .2858     | .362      | .3086     | .2858     |
| 7    | .3725     | .6316     | .583      | .2477     | .2858     | .2572     | .2477     |
| 8    | .3887     | .5182     | .5344     | .2096     | .1905     | .2058     | .2096     |
| 9    | .3125     | .2915     | .2105     | .1524     | .1543     | .0762     | .1524     |
| 10   | .1715     | .1457     | .1524     | .1334     |           | .0572     | .1524     |
| 11   | .1715     | .1543     | .1524     | .6154     | .4696     | .421      | .4372     |
| 12   | .1715     | .1372     | .1524     | .4858     | .421      | .3725     | .3239     |
| 13   | .1715     | .1372     | .1524     | .4049     | .3887     | .3239     | .2753     |
| 14   | .1715     | .1372     | .1715     | .3239     | .3563     | .2753     | .2591     |
| 15   | .1524     | .1543     | .1715     | .2753     | .2753     | .2591     | .2591     |
| 16   | .1715     | .1715     | .1334     | .3077     | .2915     | .2915     | .2753     |
| 17   | .1715     | .1715     | .0953     | .3077     | .3401     | .3725     | .3725     |
| 18   | .2096     | .1715     | .1905     | .1943     | .3239     | .3077     | .2656     |
| 19   | .3048     | .2743     | .2667     | .1334     | .2229     | .2858     | .2858     |
| 20   | .3239     | .3086     | .3239     | .1905     |           | .3048     |           |
| 21   | .3429     | .3086     | .3429     | .2667     | .2915     | .3239     |           |
| 22   | .2667     | .2743     | .3048     | .2667     | .2743     | .3048     |           |
| 23   | .2667     | .2229     | .2667     | .2858     | .2572     | .2858     |           |
| 24   | .1781     | .1457     | .1457     | .1457     | .2667     |           | .2667     |
| Max  | .3887     | .6316     | .583      | .6154     | .4696     | .421      | .4372     |
| Min  | .1524     | .1372     | .0953     | .1334     | .1543     | .0572     | .1524     |
| Avg  | .2310     | .2321     | .2243     | .2633     | .2992     | .2695     | .2730     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

CHALISGAON DIVISION[596]

CHALISGAON-U[240]

BU 0240

Substation No/ Name :- 124146 / CTM SUB STATION

Feeder No / Name : 202 / HUDCO COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3817     | .4015     | .4028     | .4207     | .3994     | .4189     | .4176     |
| 2    | .3631     | .3829     | .3829     | .3631     | .4003     | .3999     | .4189     |
| 3    | .3628     | .3639     | .3829     | .3825     | .3994     | .3919     | .4015     |
| 4    | .3639     | .3647     | .3841     | .3837     | .4015     | .402      | .4024     |
| 5    | .4036     | .4246     | .4444     | .422      | .4036     | .4246     | .4032     |
| 6    | .4639     | .4835     | .5212     | .484      | .4251     | .4815     | .4634     |
| 7    | .5036     | .5415     | .5387     | .5233     | .4835     | .5201     | .5005     |
| 8    | .4668     | .4486     | .479      | .449      | .4467     | .484      | .4251     |
| 9    | .4449     | .4277     | .4615     | .4062     | .4572     | .4472     | .4194     |
| 10   | .4041     | .4189     | .3825     | .3999     | .4123     | .4255     | .4011     |
| 11   | .4049     | .4011     | .3853     | .3873     | .4394     | .4426     | .3973     |
| 12   | .4198     | .4215     | .3654     | .4534     | .4367     | .4902     | .402      |
| 13   | .503      | .4229     | .3978     | .3957     | .4015     | .5015     | .3643     |
| 14   | .5396     | .4024     | .3616     | .3468     | .3837     | .3849     | .3793     |
| 15   | .3999     | .3825     | .3635     | .4137     | .3809     | .3471     | .3628     |
| 16   | .3986     | .3666     | .3793     | .4348     | .3845     | .345      | .5761     |
| 17   | .3982     | .3443     | .3432     | .3446     | .3424     | .3432     | .4656     |
| 18   | .3733     | .3403     | .3352     | .3547     | .3179     | .3693     | .4093     |
| 19   | .3885     | .4289     | .443      | .4303     | .4132     | .4592     | .5046     |
| 20   | .4864     | .4696     | .5046     | .4681     | .4731     | .4676     | .5828     |
| 21   | .4506     | .4553     | .4721     | .452      | .4553     | .4691     | .4866     |
| 22   | .433      | .4539     | .4696     | .4496     | .4496     | .4671     | .4671     |
| 23   | .453      | .4544     | .4741     | .4534     | .4711     | .4716     | .4666     |
| 24   | .3994     | .4385     | .4198     | .438      | .4367     | .4371     | .4367     |
| Max  | .5396     | .5415     | .5387     | .5233     | .4835     | .5201     | .5828     |
| Min  | .3628     | .3403     | .3352     | .3446     | .3179     | .3432     | .3628     |
| Avg  | .4253     | .4183     | .4206     | .4190     | .4173     | .4330     | .4398     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124066 / 33/11 KV JANVA

Feeder No / Name : 201 / Dangar feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1966     | .1886     |           | .168      | .1509     | .1981     | .1823     |
| 2    | .1638     | .1663     | .132      | .1509     | .1524     | .1448     | .1658     |
| 3    | .1638     | .2075     | .6154     | .1509     | .1524     | .2006     | .1677     |
| 4    | .2294     | .2353     | .1478     | .168      | .1905     | .2378     | .2155     |
| 5    | .2401     | .2987     | .6241     | .2241     | .2829     | .2317     | .2321     |
| 6    | .2881     | .3258     | .3174     | .2957     | .321      | .286      | .2818     |
| 7    | .3125     | .2402     | .2587     | .2427     | .2452     | .3241     | .3361     |
| 8    | .3749     | .1448     | .2241     | .168      | .1886     | .2606     | .3041     |
| 9    | .132      | .1663     | .132      | .1494     | .1109     | .1867     | .2427     |
| 10   | .0905     | .3239     | .2949     | .2623     | .2606     | .1494     | .1494     |
| 11   | .0934     |           | .3201     | .3125     | .301      | .168      | .1448     |
| 12   | .132      | .3048     | .3041     | .25       | .2606     | .168      | .1478     |
| 13   | .1663     |           | .2591     | .2968     | .2372     | .168      | .1867     |
| 14   | .1629     | .25       | .2458     | .2812     | .1981     | .1867     | .2033     |
| 15   | .1307     |           | .2591     | .2812     | .2462     | .1867     | .1991     |
| 16   | .1629     | .2559     | .2753     | .2812     | .3121     | .1867     | .1663     |
| 17   | .1509     | .25       | .2591     | .2812     | .286      | .1791     | .1698     |
| 18   | .1663     | .168      | .168      | .1867     | .1867     | .1848     | .2054     |
| 19   | .1991     |           | .2427     | .2987     | .2402     | .2801     | .2241     |
| 20   | .2241     | .3292     | .2801     | .2987     | .2715     | .2614     | .2534     |
| 21   | .2534     |           | .2614     | .2614     | .2587     | .2241     | .2402     |
| 22   | .1848     | .2263     | .2054     | .1867     | .2263     | .2054     | .2241     |
| 23   | .1663     | .2075     | .1867     | .168      | .2229     | .2818     | .2134     |
| 24   |           | .1663     | .1698     | .168      |           | .1981     |           |
| Max  | .3749     | .3292     | .6241     | .3125     | .321      | .3241     | .3361     |
| Min  | .0905     | .1448     | .132      | .1494     | .1109     | .1448     | .1448     |
| Avg  | .1906     | .2345     | .2688     | .2305     | .2306     | .2124     | .2111     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124066 / 33/11 KV JANVA

Feeder No / Name : 202 / Ranaiche feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1867     | .4755     |           | .4858     | .503      | .1698     | .1334     |
| 2    | .1886     | .4344     | .6154     | .4696     | .4862     | .1867     | .1334     |
| 3    | .1905     | .5093     | .5735     | .4696     | .4862     | .2172     | .1524     |
| 4    | .2286     | .5418     | .6241     | .4858     | .5121     | .2172     | .1886     |
| 5    | .2829     | .6019     |           | .5281     | .5407     | .2829     | .3018     |
| 6    | .3206     | .6642     | .8124     | .6167     | .6539     | .2987     | .3018     |
| 7    | .1867     | .7977     |           | .7968     | .7362     | .2772     | .1886     |
| 8    | .1307     | .6895     | .8619     | .8429     | .7842     | .2641     | .1509     |
| 9    | .112      |           | .1509     | .1307     | .3439     | .168      | .1698     |
| 10   | .639      | .1905     | .1143     | .1494     | .2427     | .6554     | .5937     |
| 11   | .7562     |           | .1132     | .1494     | .1772     | .6859     | .7562     |
| 12   | .8962     | .2452     | .132      | .1509     | .1663     | .6706     | .7579     |
| 13   | .7526     |           | .1698     | .1509     | .1629     | .7316     | .7095     |
| 14   | .8322     | .2829     | .1886     | .1698     | .1867     | .7316     | .7011     |
| 15   | .8398     |           | .1867     | .168      | .181      | .7468     | .6472     |
| 16   | .9482     | .2477     | .168      | .168      | .1848     | .6923     | .759      |
| 17   | .8333     | .1698     | .168      | .1494     | .1646     | .639      | .602      |
| 18   | .2402     | .1524     | .1867     | .1494     | .2054     | .1307     | .181      |
| 19   | .2715     |           | .2241     | .2614     | .2641     | .2801     | .2614     |
| 20   | .3206     | .3361     | .3361     | .3174     | .2957     | .2987     | .2896     |
| 21   | .2926     |           | .3174     | .3174     | .2715     | .2987     | .2614     |
| 22   | .2587     |           | .2801     | .2987     | .2452     | .2801     | .2402     |
| 23   | .5401     | .7773     | .5281     | .5079     | .2172     | .2241     | .2075     |
| 24   |           | .4344     | .7287     | .5121     |           | .1848     |           |
| Max  | .9482     | .7977     | .8619     | .8429     | .7842     | .7468     | .759      |
| Min  | .112      | .1524     | .1132     | .1307     | .1629     | .1307     | .1334     |
| Avg  | .4456     | .4442     | .3562     | .3519     | .3483     | .3888     | .3778     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124066 / 33/11 KV JANVA

Feeder No / Name : 203 / Londhave Feeder  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7125     | .5973     | .5121     | .5601     | .6224     | .5792     | .6882     |
| 2    | .6316     | .5729     | .4887     | .5415     | .6287     | .6401     | .6554     |
| 3    | .6062     | .6224     | .4755     | .5415     | .6478     | .6325     | .639      |
| 4    | .6316     | .6516     | .5175     | .5975     | .7811     | .6773     | .7701     |
| 5    | .8002     | .7207     | .5601     | .7392     | .8676     | .7282     | 1.0486    |
| 6    | 1.0467    | 1.1203    | .8871     | 1.1157    | 1.1128    | .9267     | 1.1043    |
| 7    | 1.2041    | .7059     | .7842     | .7874     | .8589     | .9031     | 1.0212    |
| 8    | 1.0762    | .4668     | .6468     | .5228     | .5415     | .8253     | .9214     |
| 9    | .5041     |           | .4904     | .4108     | .4525     | .6535     | 1.0164    |
| 10   | .4887     | 1.0155    | .8951     | .7655     | .571      | .5041     | .4887     |
| 11   | .5415     |           | .9511     | .8749     | .9181     | .4481     | .5041     |
| 12   | .5914     | 1.0402    | .9482     | .8436     | 1.012     | .4668     | .543      |
| 13   | .5658     |           | .9482     | .8535     | .9701     | .5975     | .6036     |
| 14   | .5175     | 1.1043    | .9145     | .884      | .9259     | .6348     | .6283     |
| 15   | .5228     |           | .9145     | .8905     | 1.0722    | .6535     | .6154     |
| 16   | .543      | .9659     | .9511     | .9061     | .9659     | .5975     | .6036     |
| 17   | .6036     | .9374     | .9659     | .96       | .9362     | .5552     | .543      |
| 18   | .6535     | .5281     | .6283     | .618      | .5658     | .5373     | .6602     |
| 19   | .7783     |           | .7023     | .8215     | .7095     | .8215     | .8131     |
| 20   | .9242     | .9709     | .8048     | .8775     | .9054     | .8402     | .8326     |
| 21   | .7468     |           | .8413     | .8589     | .7468     | .7842     | .7545     |
| 22   | .7023     | .7577     | .7392     | .7468     | .6335     | .7282     | .6468     |
| 23   | .6602     | .7167     | .6908     | .6348     | .5937     | .6722     | .6483     |
| 24   |           | .5729     | .5975     | .5975     |           | .5792     |           |
| Max  | 1.2041    | 1.1203    | .9659     | 1.1157    | 1.1128    | .9267     | 1.1043    |
| Min  | .4887     | .4668     | .4755     | .4108     | .4525     | .4481     | .4887     |
| Avg  | .6979     | .7815     | .7440     | .7479     | .7843     | .6661     | .7283     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124147 / 33/11 KV AMALNER URBAN S/S

(RA

Feeder No / Name : 201 / 11 KV TADEPURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.9204    | 2.0058    |           |           | 2.0553    |           |
| 3    |           | 1.749     |           |           |           | 1.9448    |           |
| 5    |           | 1.9719    |           |           |           | 2.1523    |           |
| 6    |           |           |           |           | 2.1085    |           |           |
| 7    |           | 2.0919    |           | 1.949     |           | 2.0773    |           |
| 8    |           |           | 1.825     |           | 1.7187    |           |           |
| 9    |           |           | 1.701     | 1.5604    | 1.6461    | 1.7318    | 1.8176    |
| 10   |           | 1.7046    |           |           |           |           |           |
| 11   |           |           |           | 1.6118    | 1.7318    | 1.8519    | 1.8176    |
| 12   |           | 1.8959    |           |           |           |           |           |
| 13   |           |           |           | 1.749     | 1.869     | 1.8519    | 1.9033    |
| 14   |           | 1.9095    |           |           |           |           |           |
| 15   |           |           |           | 1.8004    | 1.9547    | 1.9547    | 2.0405    |
| 16   | 1.9004    | 1.9054    | 1.9095    | 1.8519    |           |           |           |
| 17   | 1.7661    | 1.7833    |           |           |           |           |           |
| 19   | 2.2634    | 2.0062    |           |           |           |           |           |
| 21   | 2.2805    | 2.1776    |           |           |           |           |           |
| Max  | 2.2805    | 2.1776    | 2.0058    | 1.949     | 2.1085    | 2.1523    | 2.0405    |
| Min  | 1.7661    | 1.7046    | 1.701     | 1.5604    | 1.6461    | 1.7318    | 1.8176    |
| Avg  | 2.0526    | 1.9196    | 1.8603    | 1.7538    | 1.8381    | 1.9525    | 1.8948    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124147 / 33/11 KV AMALNER URBAN S/S

(RA

Feeder No / Name : 203 / 11 KV POWER HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.1317    | 1.0631    |           |           | 1.2048    |           |
| 3    |           | 1.0288    |           |           |           | 1.0962    |           |
| 5    |           | .9088     |           |           |           | .988      |           |
| 6    |           |           |           |           | .9745     |           |           |
| 7    |           | .8573     |           |           |           | .9682     |           |
| 8    |           |           | .9114     |           | .8859     |           |           |
| 9    |           |           |           | .9431     | .9088     | 1.0117    | .8745     |
| 10   |           | .8701     |           |           |           |           |           |
| 11   |           |           |           | .8916     | .9431     | .9431     | .9259     |
| 12   |           | .9568     |           |           |           |           |           |
| 13   |           |           |           | 1.0631    | .9945     | 1.046     | 1.0117    |
| 14   |           | 1.0785    |           |           |           |           |           |
| 15   |           |           |           | 1.0974    | 1.1488    | 1.0802    | 1.1145    |
| 16   | .9816     | 1.0585    | 1.2199    | 1.0631    |           |           |           |
| 17   | .9088     | .9774     |           |           |           |           |           |
| 19   | 1.0117    | 1.0117    |           |           |           |           |           |
| 21   | 1.1488    | 1.1488    |           |           |           |           |           |
| Max  | 1.1488    | 1.1488    | 1.2199    | 1.0974    | 1.1488    | 1.2048    | 1.1145    |
| Min  | .9088     | .8573     | .9114     | .8916     | .8859     | .9431     | .8745     |
| Avg  | 1.0127    | 1.0026    | 1.0648    | 1.0117    | .9759     | 1.0423    | .9817     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124147 / 33/11 KV AMALNER URBAN S/S

(RA

Feeder No / Name : 204 / 11 KV SANENAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6001     | .6024     |           |           | .6733     |           |
| 3    |           | .5144     |           |           |           | .6011     |           |
| 5    |           | .6001     |           |           |           | .6704     |           |
| 6    |           |           |           |           | .6805     |           |           |
| 7    |           | .6173     |           |           |           | .6337     |           |
| 8    |           |           | .567      |           | .6379     |           |           |
| 9    |           |           |           | .5487     | .583      | .6173     | .5658     |
| 10   |           | .4972     |           |           |           |           |           |
| 11   |           |           |           | .583      | .6516     | .5658     | .583      |
| 12   |           | .567      |           |           |           |           |           |
| 13   |           |           |           | .6001     | .6516     | .6344     | .583      |
| 14   |           | .5658     |           |           |           |           |           |
| 15   |           |           |           | .6344     | .7373     | .7202     | .6173     |
| 16   | .7164     | .5645     | .6011     | .6344     |           |           |           |
| 17   | .6516     | .5316     |           |           |           |           |           |
| 19   | .6687     | .6001     |           |           |           |           |           |
| 21   | .7202     | .7373     |           |           |           |           |           |
| Max  | .7202     | .7373     | .6024     | .6344     | .7373     | .7202     | .6173     |
| Min  | .6516     | .4972     | .567      | .5487     | .583      | .5658     | .5658     |
| Avg  | .6892     | .5814     | .5902     | .6001     | .6570     | .6395     | .5873     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124147 / 33/11 KV AMALNER URBAN S/S

(RA

Feeder No / Name : 205 / 11 KV PRATAP MILL FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.5432    | 1.5238    |           |           | 1.382     |           |
| 3    |           | 1.4403    |           |           |           | 1.2376    |           |
| 5    |           | 1.3375    |           |           |           | 1.3408    |           |
| 6    |           |           |           |           | 1.382     |           |           |
| 7    |           | 1.3203    |           |           |           | 1.2851    |           |
| 8    |           |           | 1.2536    |           | 1.3289    |           |           |
| 9    |           |           | 1.3466    | 1.3032    | 1.4746    | 1.3889    | 1.3375    |
| 10   |           | 1.4915    |           |           |           |           |           |
| 11   |           |           |           | 1.5261    | 1.5775    | 1.7147    | 1.6118    |
| 12   |           | 1.5947    |           |           |           |           |           |
| 13   |           |           |           | 1.6289    | 1.6975    |           | 1.8519    |
| 14   |           | 1.7503    |           |           |           |           |           |
| 15   |           |           |           | 1.9204    | 1.7833    | 1.8176    | 1.8519    |
| 16   | 1.6124    | 1.7819    | 1.8034    | 1.8861    |           |           |           |
| 17   | 1.5089    | 1.6804    |           |           |           |           |           |
| 19   | 1.6804    | 1.8347    |           |           |           |           |           |
| 21   | 1.6632    | 1.7318    |           |           |           |           |           |
| Max  | 1.6804    | 1.8347    | 1.8034    | 1.9204    | 1.7833    | 1.8176    | 1.8519    |
| Min  | 1.5089    | 1.3203    | 1.2536    | 1.3032    | 1.3289    | 1.2376    | 1.3375    |
| Avg  | 1.6162    | 1.5915    | 1.4819    | 1.6529    | 1.5406    | 1.4524    | 1.6633    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER (U) S/DIVN.[232] BU 5622

Substation No/ Name :- 124147 / 33/11 KV AMALNER URBAN S/S

(RA

Feeder No / Name : 206 / 11 KV WIPRO FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.3032    | 1.1641    |           |           | 1.3466    |           |
| 3    |           | 1.1831    |           |           |           | 1.2023    |           |
| 5    |           | 1.2003    |           |           |           | 1.0938    |           |
| 6    |           |           |           |           | 1.1163    |           |           |
| 7    |           | 1.2003    |           |           |           | 1.1091    |           |
| 8    |           |           | .9922     |           | 1.0277    |           |           |
| 9    |           |           | 1.0277    | 1.1488    | 1.0631    | 1.1488    | 1.0117    |
| 10   |           | 1.1187    |           |           |           |           |           |
| 11   |           |           |           | 1.1488    | 1.166     | 1.2346    | 1.166     |
| 12   |           | 1.1871    |           |           |           |           |           |
| 13   |           |           |           | 1.2003    | 1.2346    | 1.2346    | 1.2346    |
| 14   |           | 1.3083    |           |           |           |           |           |
| 15   |           |           |           | 1.3375    | 1.3203    | 1.3375    | 1.406     |
| 16   | 1.2795    | 1.3408    |           | 1.3889    |           |           |           |
| 17   | 1.2346    | 1.166     |           |           |           |           |           |
| 19   | 1.2346    | 1.2346    |           |           |           |           |           |
| 21   | 1.3203    | 1.286     |           |           |           |           |           |
| Max  | 1.3203    | 1.3408    | 1.1641    | 1.3889    | 1.3203    | 1.3466    | 1.406     |
| Min  | 1.2346    | 1.1187    | .9922     | 1.1488    | 1.0277    | 1.0938    | 1.0117    |
| Avg  | 1.2673    | 1.2299    | 1.0613    | 1.2449    | 1.1547    | 1.2134    | 1.2046    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124068 / 33/11 KV KALAMSARE

Feeder No / Name : 203 / 11 KV SHAHAPUR AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9431     |
| Max  | .9431     |
| Min  | .9431     |
| Avg  | .9431     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124068 / 33/11 KV KALAMSARE

Feeder No / Name : 205 / 11 KV KALALI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 13-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 12   | 1.6095    |
| Max  | 1.6095    |
| Min  | 1.6095    |
| Avg  | 1.6095    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124068 / 33/11 KV KALAMSARE

Feeder No / Name : 207 / 11 Kv NIMB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 13-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 12   | .0377     |
| Max  | .0377     |
| Min  | .0377     |
| Avg  | .0377     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124068 / 33/11 KV KALAMSARE

Feeder No / Name : 208 / 11 Kv SHAHAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 13-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 12   | .2452     |
| Max  | .2452     |
| Min  | .2452     |
| Avg  | .2452     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124068 / 33/11 KV KALAMSARE

Feeder No / Name : 209 / 11 Kv BOHARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 13-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 12   | .679      |
| Max  | .679      |
| Min  | .679      |
| Avg  | .679      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124117 / 33/11KV GANDHALI SUBSTATION

Feeder No / Name : 201 / 11KV AMALGAON PURE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.5089    | 1.4746    | 1.3748    | 1.2587    |           |           |
| 2    |           | 1.5699    | 1.3765    | 1.3603    | 1.2842    |           |           |
| 3    |           | 1.5242    | 1.3763    | 1.3763    | 1.2793    |           |           |
| 4    |           | 1.5935    | 1.4255    | 1.326     | 1.2878    |           |           |
| 5    |           | 1.5851    | 1.4413    | 1.3889    | 1.2995    |           |           |
| 6    |           | 1.6091    | 1.5043    |           | 1.3111    |           |           |
| 7    |           | 1.7185    | 1.6091    | 1.5043    | 1.488     |           |           |
| 8    |           | 1.7185    | 1.5546    | 1.4723    | 1.5158    |           |           |
| 10   | 1.6716    |           |           |           |           | .7621     | 1.4327    |
| 11   |           |           |           |           |           | 1.2193    | 1.4632    |
| 12   | 1.7966    |           |           |           |           | 1.5432    | 1.5242    |
| 13   | 1.7654    |           |           |           |           | 1.5123    | 1.5394    |
| 14   | 1.7654    |           |           |           |           | 1.448     | 1.5242    |
| 15   | 1.8027    |           |           |           |           | 1.4632    | 1.3565    |
| 16   | 1.7654    |           |           |           |           |           | 1.0669    |
| 17   |           |           |           |           |           |           | 1.4815    |
| 23   |           | 1.56      |           |           |           |           |           |
| 24   |           | 1.5592    |           |           | 1.2467    |           |           |
| Max  | 1.8027    | 1.7185    | 1.6091    | 1.5043    | 1.5158    | 1.5432    | 1.5394    |
| Min  | 1.6716    | 1.5089    | 1.3763    | 1.326     | 1.2467    | .7621     | 1.0669    |
| Avg  | 1.7612    | 1.5947    | 1.4703    | 1.4004    | 1.3301    | 1.3247    | 1.4236    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124117 / 33/11KV GANDHALI SUBSTATION

Feeder No / Name : 202 / 11KV AMALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5914     | .5544     | .567      | .5487     | .5853     | .5853     | .5731     |
| 2    | .6316     | .6283     | .543      | .5853     | .6244     | .618      | .6089     |
| 3    | .7095     | .7207     | .6219     | .6089     | .72       | .7074     | .695      |
| 4    | .7858     | .7762     | .6516     | .6805     | .7762     | .7458     | .7316     |
| 5    | .8615     | .8962     | .7023     | .724      | .8545     | .8203     | .7602     |
| 6    | .9364     | 1.0059    | .8326     |           | 1.0072    | .8954     | .788      |
| 7    | .7423     | .6219     | .6401     | .7133     | .823      | .6428     | .6584     |
| 8    | .5865     | .5853     | .4805     | .5373     | .5822     | .543      |           |
| 9    | .5068     | .4525     | .5068     | .5601     | .6335     | .5068     | .543      |
| 10   | .4075     | .4252     | .4477     | .4344     | .543      | .4477     | .5083     |
| 11   | .443      | .443      | .4382     | .4887     | .5611     | .4607     | .5083     |
| 12   | .4961     | .4656     | .4557     | .5249     | .5731     | .5373     | .5316     |
| 13   | .443      | .4887     | .4961     | .5068     | .4477     | .5373     | .5731     |
| 14   | .4835     | .4887     | .5316     | .5487     | .5014     |           | .5552     |
| 15   | .5249     | .5249     | .567      | .5544     | .5373     |           | .5373     |
| 16   | .5249     | .5792     | .5316     | .5487     | .5493     |           | .543      |
| 17   |           | .6036     |           | .5731     |           | .5914     | .6036     |
| 18   |           | .6722     |           | .5508     | .5268     | .6584     | .6722     |
| 19   |           | .8029     |           | .7939     | .6706     | .7343     | .7468     |
| 20   |           | .8775     |           | .7164     | .7291     |           | .8775     |
| 21   |           | .8215     |           | .7007     | .757      |           | .7577     |
| 22   |           | .7356     |           | .6863     | .6626     |           | .7133     |
| 23   |           | .6283     |           |           |           |           | .6516     |
| 24   | .6251     | .6099     |           |           | .6193     | .6232     | .6219     |
| Max  | .9364     | 1.0059    | .8326     | .7939     | 1.0072    | .8954     | .8775     |
| Min  | .4075     | .4252     | .4382     | .4344     | .4477     | .4477     | .5083     |
| Avg  | .6059     | .6420     | .5634     | .5993     | .6493     | .6268     | .6417     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234]

BU 5657

Substation No/ Name :- 124117 / 33/11KV GANDHALI SUBSTATION

Feeder No / Name : 203 / 11KV GANDHALI PURE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3658     |           |           |           |           | .3658     | .3353     |
| 2    | .3958     |           |           |           |           | .3909     | .3658     |
| 3    | .4257     |           |           |           |           | .4389     | .4214     |
| 4    | .4409     |           |           |           |           | .4037     | .4024     |
| 5    | .4555     |           |           |           |           | .4201     | .4024     |
| 6    | .4544     |           |           |           |           | .3879     | .5498     |
| 7    | .5989     |           |           |           |           | .5734     | .5498     |
| 8    | .5386     |           |           |           |           | .5868     |           |
| 10   |           | .4666     | .381      | .4572     | .3048     |           |           |
| 11   |           | .5668     | .5268     | .5182     | .381      |           |           |
| 12   |           | .5182     | .5268     | .5053     | .4967     |           |           |
| 13   |           | .5344     | .4572     | .4607     | .5335     |           |           |
| 14   |           | .5218     | .4967     | .4666     | .4877     |           |           |
| 15   |           | .5247     | .5335     | .4725     | .423      |           |           |
| 16   |           | .5401     | .5428     | .5401     | .4988     |           |           |
| 17   |           | .4096     |           | .4801     | .4936     |           |           |
| 23   |           |           |           |           |           |           | .3479     |
| 24   | .4047     |           |           |           |           | .3529     | .3401     |
| Max  | .5989     | .5668     | .5428     | .5401     | .5335     | .5868     | .5498     |
| Min  | .3658     | .4096     | .381      | .4572     | .3048     | .3529     | .3353     |
| Avg  | .4534     | .5103     | .4950     | .4876     | .4524     | .4356     | .4128     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

AMALNER-II[234] BU 5657

Substation No/ Name :- 124131 / 33/11 KV KURHE

Feeder No / Name : 204 / NATIONAL STONE CRUSHER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 08-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0686     |
| Max  | .0686     |
| Min  | .0686     |
| Avg  | .0686     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 201 / Vatar Agri  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.9004    | 1.6461    |           |
| 10   |           |           | 1.8176    |
| 12   | 3.0178    |           | 1.6289    |
| 17   | 2.8349    | 1.829     |           |
| 23   |           |           | 2.0405    |
| Max  | 3.0178    | 1.829     | 2.0405    |
| Min  | 1.9004    | 1.6461    | 1.6289    |
| Avg  | 2.5844    | 1.7376    | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 202 / 11 KV Shevra  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 2.524     |           |
| 10   | 3.3105    |           | 2.1434    |
| 12   |           |           | 2.4863    |
| 14   |           |           | 2.5206    |
| 17   | 2.7801    |           | 2.4348    |
| 24   |           | 2.652     |           |
| Max  | 3.3105    | 2.652     | 2.5206    |
| Min  | 2.7801    | 2.524     | 2.1434    |
| Avg  | 3.0453    | 2.588     | 2.3963    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 204 / Vatar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .7842     | .9335     |           |           |
| 9    |           |           |           | .5611     |
| 10   | .4294     |           |           |           |
| 12   |           | .3361     | .2652     | .2896     |
| 15   |           |           |           | .3258     |
| 16   | .4108     | .3547     |           |           |
| 18   |           |           |           | .6335     |
| 23   |           | .3361     |           | .3258     |
| 24   | .3174     | .3361     |           |           |
| Max  | .7842     | .9335     | .2652     | .6335     |
| Min  | .3174     | .3361     | .2652     | .2896     |
| Avg  | .4855     | .4593     | .2652     | .4272     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 205 / 11 KV UNAPDEV

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | 2.5339    |           |           |           |
| 8    | 2.4977    |           |           |           |
| 10   |           | 2.4508    |           |           |
| 12   |           |           | 2.2131    |           |
| 17   |           | 2.4874    |           |           |
| 23   |           |           |           | 1.989     |
| 24   | 2.4874    |           |           |           |
| Max  | 2.5339    | 2.4874    | 2.2131    | 1.989     |
| Min  | 2.4874    | 2.4508    | 2.2131    | 1.989     |
| Avg  | 2.5063    | 2.4691    | 2.2131    | 1.989     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 207 / 11KV PIMPRI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

|      |           |
|------|-----------|
| DATE | 11-APR-18 |
| HR   | Load (MW) |
| 12   | 2.2969    |
| Max  | 2.2969    |
| Min  | 2.2969    |
| Avg  | 2.2969    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124073 / 33/11 KV ADAWAD

Feeder No / Name : 208 / 11 KV Khardi

Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 9    |           | .6516     |
| 12   | 1.8107    |           |
| 13   |           | 1.8347    |
| 15   |           | 1.8347    |
| 17   |           | .4706     |
| 18   |           | .6687     |
| 23   |           | .3801     |
| Max  | 1.8107    | 1.8347    |
| Min  | 1.8107    | .3801     |
| Avg  | 1.8107    | .9734     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124074 / 33/11 KV MANGARUL

Feeder No / Name : 202 / 11 KV Mangarul -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .1255     |           | .1267     | .1255     |           | .1086     | .1255     |
| 4    | .1255     |           | .1448     | .1614     |           | .1448     | .1614     |
| 6    | .2868     |           | .2896     | .2881     | .2689     | .2534     | .2331     |
| 7    |           | .2151     |           |           |           |           |           |
| 8    | .1793     | .1793     | .1629     | .18       | .1614     | .1629     | .1436     |
| 10   | .1255     | .1629     | .162      | .1255     | .1448     | .1434     |           |
| 12   | .1076     | .1448     | .1255     | .1255     | .1267     | .126      |           |
| 14   |           | .1448     | .1255     |           | .1448     | .1436     |           |
| 16   | .1614     | .1448     | .1436     | .1434     | .1267     | .1434     |           |
| 18   |           | .1448     | .1254     | .1434     | .1448     | .1791     |           |
| 20   |           | .2172     | .2151     |           | .1991     | .2151     |           |
| 21   | .1793     |           |           | .1793     |           |           |           |
| 22   |           | .1448     | .1434     |           |           | .1434     |           |
| 24   | .1434     |           | .126      | .1255     |           | .1255     |           |
| Max  | .2868     | .2172     | .2896     | .2881     | .2689     | .2534     | .2331     |
| Min  | .1076     | .1448     | .1254     | .1255     | .1267     | .1086     | .1255     |
| Avg  | .1594     | .1665     | .1575     | .1598     | .1647     | .1574     | .1659     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124074 / 33/11 KV MANGARUL

Feeder No / Name : 203 / 11 KV Adawad

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 2.6406    |           | 2.1033    | 2.1403    |           | 2.2862    | 2.3291    |
| 4    | 2.5926    |           | 2.0576    | 2.1091    |           | 2.2862    | 2.3746    |
| 6    | 2.5606    |           | 2.0881    | 2.0807    | 2.0805    | 2.3167    | 2.3912    |
| 7    |           | 2.3045    |           |           |           |           |           |
| 8    | 2.5926    | 2.2725    | 2.1795    | 2.0962    | 2.1925    | 2.3167    | 2.4371    |
| 10   | 2.4166    | 2.5606    | 2.8121    | 2.6886    | 2.5149    | 2.1948    |           |
| 12   | 2.3845    | 2.7435    | 2.8433    | 3.0657    | 2.5911    | 2.2862    |           |
| 14   |           | 2.713     | 2.6086    |           | 2.5911    | 2.3291    |           |
| 16   | 2.3845    | 2.713     | 2.6086    | 2.6406    | 2.5911    | 2.2981    |           |
| 24   | 2.2885    |           | 2.1403    | 2.2405    |           | 2.3602    |           |
| Max  | 2.6406    | 2.7435    | 2.8433    | 3.0657    | 2.5911    | 2.3602    | 2.4371    |
| Min  | 2.2885    | 2.2725    | 2.0576    | 2.0807    | 2.0805    | 2.1948    | 2.3291    |
| Avg  | 2.4826    | 2.5512    | 2.3824    | 2.3827    | 2.4269    | 2.2971    | 2.383     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124074 / 33/11 KV MANGARUL

Feeder No / Name : 204 / 11 KV Khedi Bhokari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | 1.7985    | 1.7654    |           |           |
| 4    |           |           | 1.7985    | 1.7497    |           |           |
| 6    |           |           | 1.8595    | 1.8747    | 1.7966    |           |
| 7    |           | 1.9685    |           |           |           |           |
| 8    |           | 1.9685    | 1.89      | 1.906     | 1.8278    |           |
| 10   | 2.1872    |           |           |           |           | 1.8591    |
| 12   | 2.1715    |           |           |           |           | 1.906     |
| 14   |           |           |           |           |           | 1.8747    |
| 16   | 1.9372    |           |           |           |           | 1.9216    |
| 24   | 1.9685    |           | 1.7497    | 1.781     |           |           |
| Max  | 2.1872    | 1.9685    | 1.89      | 1.906     | 1.8278    | 1.9216    |
| Min  | 1.9372    | 1.9685    | 1.7497    | 1.7497    | 1.7966    | 1.8591    |
| Avg  | 2.0661    | 1.9685    | 1.8192    | 1.8154    | 1.8122    | 1.8904    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124076 / 33/11 KV VIRWADE

Feeder No / Name : 201 / 11 KV Virwade -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1981     | .2134     | .2134     | .1981     | .1981     |           |
| 2    | .1829     | .1981     |           | .1829     | .2134     | .1829     |
| 3    | .2439     | .2439     |           | .2134     | .2591     |           |
| 4    | .3353     | .3353     |           | .2591     | .3048     | .2286     |
| 5    | .4115     | .4115     | .4268     | .3506     | .3506     |           |
| 6    | .4877     | .4877     |           | .4572     | .4115     | .4572     |
| 7    | .3963     | .3506     | .381      | .2439     | .3506     |           |
| 8    | .3201     | .2743     |           | .2896     |           | .3353     |
| 9    | .2743     |           |           |           |           |           |
| 10   | .2591     |           | .2439     | .2591     |           | .2591     |
| 11   | .2591     |           | .2286     |           |           |           |
| 12   | .2134     |           | .2439     | .2439     |           | .2286     |
| 13   | .1829     |           | .2134     | .2286     |           |           |
| 14   | .2134     |           | .2286     | .2134     |           | .2134     |
| 15   | .1981     |           | .2286     | .2286     |           |           |
| 16   | .2286     |           | .2439     | .2439     |           | .1829     |
| 17   | .2591     |           | .2591     | .2591     |           |           |
| 18   | .2896     |           | .3048     | .2743     |           | .2743     |
| 19   | .4115     |           | .3658     | .381      |           |           |
| 20   | .2896     |           | .3048     | .3048     |           | .4115     |
| 21   | .2439     |           | .2591     | .2286     |           |           |
| 22   | .2134     |           | .2286     | .2134     |           |           |
| 23   | .1829     |           | .1981     | .1981     |           |           |
| 24   | .1677     | .1829     |           | .1829     | .1829     |           |
| Max  | .4877     | .4877     | .4268     | .4572     | .4115     | .4572     |
| Min  | .1677     | .1829     | .1981     | .1829     | .1829     | .1829     |
| Avg  | .2693     | .2997     | .2690     | .2570     | .2839     | .2774     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124076 / 33/11 KV VIRWADE

Feeder No / Name : 202 / 11 KV Malapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7926     | 1.5242    | 1.2193    | 1.2498    | .7621     |           |
| 2    | .8078     | 1.6309    |           | 1.2803    | .7926     | .823      |
| 3    | .823      | 1.7223    |           | 1.326     | .8078     |           |
| 4    | .8383     | 1.7833    |           | 1.3717    | .7773     | .8383     |
| 5    | .8078     | 1.829     | 1.4022    | 1.448     | .823      |           |
| 6    | .8383     | 1.8747    |           | 1.7985    | .8383     | .8383     |
| 7    | .8078     | 1.9052    | 1.8747    | 1.9966    | .8078     |           |
| 8    | .7773     | 1.9357    |           | 2.0271    |           | .7621     |
| 9    | .6401     |           | .7164     | .7011     |           |           |
| 10   | 1.9204    |           | .7011     | .6706     |           | 1.7985    |
| 11   | 1.9357    |           | .6706     | .6859     |           |           |
| 12   | 1.8138    |           | .7011     | .7011     |           | 1.7985    |
| 13   |           |           | .6859     | .6859     |           |           |
| 14   |           |           |           | .7316     |           | 1.768     |
| 15   | .4725     |           |           | .7164     |           |           |
| 16   | 1.4632    |           | .7316     | .7468     |           |           |
| 17   | 1.768     |           | .7468     | .7164     |           |           |
| 18   | 1.8595    |           | .7926     | .823      |           |           |
| 19   | .8535     |           |           | .8688     |           |           |
| 20   | .9297     |           | .5525     | .9145     |           |           |
| 21   | 1.0059    |           | .9755     | .945      |           |           |
| 22   | 1.0669    |           | .9145     | .9145     |           |           |
| 23   | 1.2803    |           | 1.3108    | .8688     |           |           |
| 24   | .8383     | 1.387     |           | 1.3565    | .8535     |           |
| Max  | 1.9357    | 1.9357    | 1.8747    | 2.0271    | .8535     | 1.7985    |
| Min  | .4725     | 1.387     | .5525     | .6706     | .7621     | .7621     |
| Avg  | 1.1064    | 1.7325    | .9330     | 1.0644    | .8078     | 1.2324    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124076 / 33/11 KV VIRWADE

Feeder No / Name : 203 / 11 KV Virwade

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3717    |           |           |           |           |           |
| 2    | 1.4022    |           |           |           |           | 1.2955    |
| 3    | 1.4327    |           |           |           |           |           |
| 4    | 1.4175    |           |           |           |           | 1.3108    |
| 5    | 1.4327    |           |           |           |           |           |
| 6    | 1.4632    |           |           |           |           | 1.2955    |
| 7    | 1.5242    |           |           |           |           |           |
| 8    | 1.5394    |           |           |           |           | 1.4327    |
| 10   |           |           | 1.0822    |           |           |           |
| 11   |           |           |           | 1.4937    |           |           |
| 12   |           |           |           | 1.5394    |           |           |
| 13   |           |           |           | 1.4937    |           |           |
| 14   |           |           | 1.3717    | 1.4632    |           |           |
| 15   |           |           | 1.3565    | 1.448     |           |           |
| 16   |           |           | 1.387     | 1.4327    |           |           |
| 17   |           |           | 1.3108    | 1.326     |           |           |
| 24   | 1.4632    | 1.5394    |           |           | 1.326     |           |
| Max  | 1.5394    | 1.5394    | 1.387     | 1.5394    | 1.326     | 1.4327    |
| Min  | 1.3717    | 1.5394    | 1.0822    | 1.326     | 1.326     | 1.2955    |
| Avg  | 1.4496    | 1.5394    | 1.3016    | 1.4567    | 1.326     | 1.3336    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124076 / 33/11 KV VIRWADE

Feeder No / Name : 204 / Adgaon -Gaothan-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1829     | .1829     | .1829     | .1829     | .1829     |           |
| 2    | .2134     | .2134     |           | .1981     | .1981     | .1981     |
| 3    | .2286     | .2286     |           | .2286     | .2286     |           |
| 4    | .2591     | .2743     |           | .2439     | .2439     | .2134     |
| 5    | .3048     | .2439     | .3048     | .2896     | .2896     |           |
| 6    | .3353     | .3048     |           | .3353     | .3201     | .3048     |
| 7    | .2591     | .2439     | .2591     | .2439     | .2286     |           |
| 8    | .2286     | .2134     |           | .2286     |           | .1829     |
| 9    | .2134     |           | .1981     | .2286     |           |           |
| 10   | .1981     |           | .2134     | .2134     |           |           |
| 11   | .1829     |           | .442      | .2134     |           |           |
| 12   | .1829     |           | .1981     | .1829     |           | .2134     |
| 13   | .1677     |           | .1829     | .2134     |           |           |
| 14   | .1981     |           | .1677     | .1981     |           | .1981     |
| 15   | .2134     |           | .1829     | .1981     |           |           |
| 16   | .2286     |           | .1981     | .1829     |           | .1981     |
| 17   | .2134     |           | .2134     | .2286     |           |           |
| 18   | .2439     |           | .2439     | .2439     |           | .1981     |
| 19   | .3048     |           | .2896     | .2896     |           |           |
| 20   | .2439     |           | .1619     | .2743     |           | .2439     |
| 21   | .2743     |           | .2743     | .2591     |           |           |
| 22   | .2439     |           | .2439     | .2286     |           |           |
| 23   | .2134     |           | .2286     | .2134     |           |           |
| 24   | .2134     | .2134     |           | .2134     | .2134     |           |
| Max  | .3353     | .3048     | .442      | .3353     | .3201     | .3048     |
| Min  | .1677     | .1829     | .1619     | .1829     | .1829     | .1829     |
| Avg  | .2312     | .2354     | .2325     | .2305     | .2382     | .2168     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124076 / 33/11 KV VIRWADE

Feeder No / Name : 205 / 11 KV Adgaon Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9145     |           |           |           | .6401     |           |
| 2    | .884      |           |           |           | .6097     | .823      |
| 3    | .8535     |           |           |           | .5792     |           |
| 4    | .8688     |           |           |           | .5944     | .8078     |
| 5    | .884      |           |           |           | .6249     |           |
| 6    | .9297     |           |           |           | .6554     | .7926     |
| 7    | .9145     |           |           |           | .6554     |           |
| 8    | .9602     |           |           |           |           | .9145     |
| 10   |           |           | .9907     | .945      |           |           |
| 11   |           |           | 1.0364    | .9297     |           |           |
| 12   |           |           | 1.0059    | .9297     |           |           |
| 13   |           |           | 1.0059    | .9145     |           |           |
| 14   |           |           | .9755     | .9145     |           |           |
| 15   |           |           | .945      | .7773     |           |           |
| 16   |           |           | .9145     | .6401     |           |           |
| 17   |           |           | .8688     | .6859     |           |           |
| 23   |           |           |           | .6401     |           |           |
| 24   | .9145     | .9602     |           |           | .6401     |           |
| Max  | .9602     | .9602     | 1.0364    | .945      | .6554     | .9145     |
| Min  | .8535     | .9602     | .8688     | .6401     | .5792     | .7926     |
| Avg  | .9026     | .9602     | .9678     | .8196     | .6249     | .8345     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 201 / 11 KV VARGAVHAN GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | .3772     |           |           |
| 10   |           | .3544     | .3353     |           |
| 24   | .4252     | .3086     |           | .3688     |
| Max  | .4252     | .3772     | .3353     | .3688     |
| Min  | .4252     | .3086     | .3353     | .3688     |
| Avg  | .4252     | .3467     | .3353     | .3688     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 202 / 11 KV Moharad

Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 09-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    | 2.5034    |           |           |
| 24   | .5144     | 1.8442    | 2.2131    |
| Max  | 2.5034    | 1.8442    | 2.2131    |
| Min  | .5144     | 1.8442    | 2.2131    |
| Avg  | 1.5089    | 1.8442    | 2.2131    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 203 / 11 KV Bidgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | .3944     |           |           |           |
| 24   | .5493     | 2.2462    | 2.7463    | .3521     | .3429     |
| Max  | .5493     | 2.2462    | 2.7463    | .3521     | .3429     |
| Min  | .5493     | .3944     | 2.7463    | .3521     | .3429     |
| Avg  | .5493     | 1.3203    | 2.7463    | .3521     | .3429     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 204 / Pargaon Agri  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | 2.9012    | 2.6063    | 3.1131    |
| Max  | 2.9012    | 2.6063    | 3.1131    |
| Min  | 2.9012    | 2.6063    | 3.1131    |
| Avg  | 2.9012    | 2.6063    | 3.1131    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 205 / 11 KV Panchak

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 2.1776    |           |           |
| 14   |           | 2.3137    |           |           |
| 15   |           | 2.3663    |           |           |
| 24   | 2.392     | 1.7318    | 2.0119    | 2.2634    |
| Max  | 2.392     | 2.3663    | 2.0119    | 2.2634    |
| Min  | 2.392     | 1.7318    | 2.0119    | 2.2634    |
| Avg  | 2.392     | 2.1474    | 2.0119    | 2.2634    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 206 / 11 KV Vargavhan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 2.9835    |           |           |           |
| 14   |           | 2.758     |           |           |           |
| 16   |           |           | 2.5987    |           |           |
| 24   | 3.1007    |           |           | 2.5149    | 2.6578    |
| Max  | 3.1007    | 2.9835    | 2.5987    | 2.5149    | 2.6578    |
| Min  | 3.1007    | 2.758     | 2.5987    | 2.5149    | 2.6578    |
| Avg  | 3.1007    | 2.8708    | 2.5987    | 2.5149    | 2.6578    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 207 / Dhanora Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 1.046     |           |           |
| 10   | .8764     |           |           |           |
| 14   |           | .7783     |           |           |
| 24   |           | .7545     | .6706     | .7202     |
| Max  | .8764     | 1.046     | .6706     | .7202     |
| Min  | .8764     | .7545     | .6706     | .7202     |
| Avg  | .8764     | .8596     | .6706     | .7202     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124077 / 33/11KV DHANORA

Feeder No / Name : 208 / 11 KV Devgaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 2.7435    |           |           |
| 14   |           | 2.6425    |           |           |
| 24   | 2.8704    |           | 2.2634    | 2.572     |
| Max  | 2.8704    | 2.7435    | 2.2634    | 2.572     |
| Min  | 2.8704    | 2.6425    | 2.2634    | 2.572     |
| Avg  | 2.8704    | 2.693     | 2.2634    | 2.572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124091 / 33/11KV OLD POWER HOUSE

Feeder No / Name : 202 / 11 KV Akulkheda Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .6001     |           |           |           | .2229     |           |           |
| 4    | .6344     |           | .2572     |           | .2058     |           | .5658     |
| 5    |           |           | .2572     |           |           |           | .6173     |
| 6    | .6859     |           | .2401     | .2229     | .2401     |           | .6344     |
| 7    |           |           | .2401     |           |           | .7122     | .6516     |
| 8    |           |           | .2401     |           |           |           | .6859     |
| 9    | .7545     |           |           |           |           | .2572     |           |
| 10   |           |           |           | .7545     |           |           |           |
| 11   |           |           |           |           |           | .2401     |           |
| 12   | .2229     | .8383     | 1.0288    | .8573     | .6783     |           | .2401     |
| 13   |           | .9221     |           |           |           | .2401     |           |
| 14   |           | .9724     | .823      | .7716     |           | .2058     | .2401     |
| 15   |           | .9724     |           |           |           | .1886     |           |
| 16   |           |           |           | .7202     |           | .1715     |           |
| 17   |           | .8718     | .7545     |           |           | .1886     | .1715     |
| 18   |           | .1715     |           | .2401     | .1696     | .2229     |           |
| 20   |           |           |           | .2572     |           |           |           |
| 22   |           |           |           | .2572     |           |           |           |
| 24   |           |           | .2401     | .024      |           |           | .4801     |
| Max  | .7545     | .9724     | 1.0288    | .8573     | .6783     | .7122     | .6859     |
| Min  | .2229     | .1715     | .2401     | .024      | .1696     | .1715     | .1715     |
| Avg  | .5796     | .7914     | .4535     | .4561     | .3033     | .2697     | .4763     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233] BU 0233

Substation No/ Name :- 124091 / 33/11KV OLD POWER HOUSE

Feeder No / Name : 241 / 11 KV Incomer NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 18   | .7888     |           | .4578     | .6001     | .7373     |           |
| 24   |           | 2.0178    | 1.6108    |           |           | .9602     |
| Max  | .7888     | 2.0178    | 1.6108    | .6001     | .7373     | .9602     |
| Min  | .7888     | 2.0178    | .4578     | .6001     | .7373     | .9602     |
| Avg  | .7888     | 2.0178    | 1.0343    | .6001     | .7373     | .9602     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124114 / 33/11 KV VARDI SUBSTATION

Feeder No / Name : 201 / 11 KV VADATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.6461    |           |           |           |           | 1.6766    | 1.5089    |
| 4    | 1.6766    |           |           |           |           | 1.7071    | 1.5242    |
| 6    | 1.6918    |           |           |           |           | 1.6766    | 1.4937    |
| 8    | 1.8747    |           |           |           |           |           | 1.5242    |
| 10   |           | 1.8138    | 1.9357    | 1.9357    | 2.2634    |           |           |
| 12   |           | 1.9662    | 2.0271    | 1.9204    | 2.1434    |           |           |
| 14   |           | 1.9052    | 2.0119    | 1.9662    | 2.0576    |           |           |
| 16   |           | 1.8138    | 1.9509    | 1.9357    | 2.0919    |           |           |
| 17   |           |           |           |           | 2.1434    |           |           |
| 23   |           |           |           |           | 1.7223    |           |           |
| 24   |           |           |           |           |           | 1.7071    | 1.4784    |
| Max  | 1.8747    | 1.9662    | 2.0271    | 1.9662    | 2.2634    | 1.7071    | 1.5242    |
| Min  | 1.6461    | 1.8138    | 1.9357    | 1.9204    | 1.7223    | 1.6766    | 1.4784    |
| Avg  | 1.7223    | 1.8748    | 1.9814    | 1.9395    | 2.0703    | 1.6919    | 1.5059    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124114 / 33/11 KV VARDI SUBSTATION

Feeder No / Name : 202 / 11 KV VISHNAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .0686     | 1.0669    | 1.1317    | 1.0212    | .8993     | .0686     | .0686     |
| 4    | .1029     | 1.0822    | 1.0212    | 1.0669    | .9145     | .1029     | .0857     |
| 6    | .12       | 1.0669    | 1.0059    | .9145     | .9297     | .12       | .1372     |
| 8    | .1029     | 1.0822    | .9907     | .9907     | .9602     | .0857     | .0857     |
| 10   | 1.0364    | .0857     | .0857     | .0686     |           | 1.0059    | .9755     |
| 12   | 1.1431    | .0686     |           | .0514     |           | 1.0212    | .9602     |
| 14   | .9755     | .0514     | .0514     | .0514     | .0514     | 1.0517    | .9907     |
| 16   | 1.0974    | .0686     | .0686     | .0514     | .0686     | 1.0059    | .9907     |
| 18   | .0857     | .0686     | .0857     | .0857     | .0857     | .0762     | .0762     |
| 20   | .0686     | .0857     | .1029     | .0857     |           | .0686     | .0686     |
| 22   | .0686     | .0686     | .0686     | .0514     | .0686     | .0686     | .0514     |
| 23   |           |           |           |           | .0857     |           |           |
| 24   |           | 1.0364    | .9907     | .9145     |           | .0514     | .0514     |
| Max  | 1.1431    | 1.0822    | 1.1317    | 1.0669    | .9602     | 1.0517    | .9907     |
| Min  | .0686     | .0514     | .0514     | .0514     | .0514     | .0514     | .0514     |
| Avg  | .4427     | .4860     | .5094     | .4461     | .4515     | .3939     | .3785     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124114 / 33/11 KV VARDI SUBSTATION

Feeder No / Name : 203 / VARDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .3772     | .3258     | .4458     | .3601     | .3086     | .3601     | .3429     |
| 4    | .5316     | .4458     | .6001     | .463      | .4458     | .4973     | .5144     |
| 6    | .8402     | .8402     | .823      | .823      | .8573     | .8573     | .7545     |
| 8    | .4801     | .5144     | .463      | .4973     | .583      | .5487     | .5658     |
| 10   | .3601     | .4287     | .4458     | .4115     | .4973     | .3944     | .5316     |
| 12   | .3258     | .3258     | .3086     | .3086     | .3086     | .3258     | .3601     |
| 14   | .3086     | .2915     | .3429     | .3258     | .3086     | .3258     | .3601     |
| 16   | .3601     | .3086     | .3772     | .3429     | .3429     | .3258     | .3944     |
| 18   | .4287     | .3601     | .4287     | .3944     | .463      | .4115     | .4458     |
| 20   | .6001     | .6001     | .6001     | .6687     | .6516     | .6516     | .6516     |
| 22   | .3772     | .4287     | .3772     | .4115     | .3772     | .3944     | .4115     |
| 24   |           | .3258     | .3258     | .3258     |           | .3086     | .3086     |
| Max  | .8402     | .8402     | .823      | .823      | .8573     | .8573     | .7545     |
| Min  | .3086     | .2915     | .3086     | .3086     | .3086     | .3086     | .3086     |
| Avg  | .4536     | .4330     | .4615     | .4444     | .4676     | .4501     | .4701     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124149 / 33/11 KV Chopda Urban

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3772     | .3395     | .6036     | .4715     | .5303     | .5658     | .6036     |
| 2    | .3772     | .3018     | .5658     | .3772     | .4166     | .5658     | .5658     |
| 3    | .3395     | .2641     | .4801     | .3395     | .3788     | .415      | .5281     |
| 4    | .3206     | .3018     | .4115     | .3018     | .3977     | .3961     | .3772     |
| 5    | .3018     | .3395     | .4904     | .4527     | .4166     | .3961     | .3584     |
| 6    | .3018     | .4338     | .5658     |           | .3977     | .3961     | .3395     |
| 7    | .3395     | .4715     | .5658     | .4904     | .4734     | .415      | .3395     |
| 8    | .4527     | .5658     | .7733     | .5243     | .606      | .5658     | .8865     |
| 9    | .5093     | .7545     | .8299     | .639      | .8299     | .8488     | .8328     |
| 10   | .547      | .9431     | .9242     | 1.0416    | .8299     | .8676     | 1.0416    |
| 11   |           | .9808     | .8676     | .9658     | .9054     | .9054     | 1.0794    |
| 12   | .4338     | .7922     | .8299     | .9279     | .8676     | .8488     | .9848     |
| 13   |           | .811      | .7922     | .9658     | .8488     | .6036     | .6249     |
| 14   | .3395     | .811      | .7167     | .6445     | .811      | .4904     | .6249     |
| 15   | .2641     | .811      | .6413     | .891      | .811      | .5658     | .606      |
| 16   | .2263     | .6413     | .679      | .9488     | .7922     | .7356     | .7386     |
| 17   | .2641     | .811      | .6036     | .9478     | .7922     | .1886     | .7962     |
| 18   |           | .8299     | .6413     | 1.0816    | .8299     | .6602     | .9658     |
| 19   | .2452     | .7545     |           | .797      | .7733     | .5281     | .7764     |
| 20   | .4904     | .7922     | .6036     | .759      | .679      | .5093     | .6036     |
| 21   | .7167     | .5658     | .7356     | .6831     | .6224     | .5281     | .6628     |
| 22   |           | .6036     | .679      | .6628     | .5847     | .6979     | .5681     |
| 23   | .4527     | .6036     | .5658     | .6439     | .5658     | .6036     | .5308     |
| 24   | .415      | .3772     | .6224     | .5281     | .6249     | .5658     | .5847     |
| Max  | .7167     | .9808     | .9242     | 1.0816    | .9054     | .9054     | 1.0794    |
| Min  | .2263     | .2641     | .4115     | .3018     | .3788     | .1886     | .3395     |
| Avg  | .3857     | .6209     | .6604     | .6994     | .6577     | .5776     | .6675     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124149 / 33/11 KV Chopda Urban

Feeder No / Name : 203 / 11 KV Shere Punjab

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4706     | .3982     | .5068     | .4525     | .4887     | .5068     | .5068     |
| 2    | .4525     | .3258     | .4887     | .4163     | .4344     | .4887     | .5068     |
| 3    | .4525     | .2896     | .4706     | .4525     | .3982     | .4887     | .4887     |
| 4    | .4525     | .362      | .4344     | .362      | .3982     | .5068     | .4887     |
| 5    | .4706     | .3982     | .4525     | .3982     | .4207     | .5249     | .4706     |
| 6    | .4344     | .4163     | .4706     | .4525     | .5068     | .5068     | .4525     |
| 7    | .4525     | .4706     | .4525     | .4344     | .4706     | .4706     | .4525     |
| 8    | .4706     | .4525     | .543      | .4525     | .4525     | .6878     | .4887     |
| 9    | .4344     | .5068     | .543      | .4525     | .5249     | .5249     | .4525     |
| 10   | .5068     | .543      | .543      | .4755     | .5611     | .5611     | .5068     |
| 11   | .543      | .5611     | .5792     | .4938     | .5973     | .5973     | .5249     |
| 12   | .5611     | .5611     | .5792     | .4887     | .543      | .5249     | .543      |
| 13   | .543      | .543      | .543      | .4938     | .543      | .543      | .5068     |
| 14   | .5068     | .5611     | .5792     | .4887     | .543      | .5249     | .543      |
| 15   | .543      | .5792     | .5068     | .4706     | .5249     | .5068     | .543      |
| 16   | .4706     | .5973     | .543      | .4755     | .4887     | .5068     | .543      |
| 17   | .543      | .6697     | .5068     | .4887     | .4525     | .4706     | .543      |
| 18   |           | .5611     | .543      | .4938     | .5611     | .5068     | .5249     |
| 19   | .6697     | .6154     |           | .543      | .6154     | .5611     | .5792     |
| 20   | .6154     | .543      | .5068     | .567      | .5611     | .5792     | .5792     |
| 21   | .543      | .543      | .4887     | .5487     | .5249     | .4887     | .5249     |
| 22   |           | .5068     | .4706     | .5487     | .4887     | .4706     | .543      |
| 23   | .543      | .4887     | .4525     | .6219     | .5068     | .5068     | .5249     |
| 24   | .4525     | .4706     | .5068     | .4706     | .5304     | .5068     | .5068     |
| Max  | .6697     | .6697     | .5792     | .6219     | .6154     | .6878     | .5792     |
| Min  | .4344     | .2896     | .4344     | .362      | .3982     | .4706     | .4525     |
| Avg  | .5060     | .4985     | .5092     | .4809     | .5057     | .5234     | .5143     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124149 / 33/11 KV Chopda Urban

Feeder No / Name : 204 / 11 KV Hareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8099    | 1.7737    | 1.8461    | 1.8461    | 1.829     | 2.0633    | 1.9366    |
| 2    | 1.8099    | 1.7375    | 1.8823    | 1.7737    | 1.7924    | 2.0452    | 1.9547    |
| 3    | 1.7918    | 1.8099    | 1.828     | 1.7737    | 1.7375    | 1.9909    | 1.9185    |
| 4    | 1.7737    | 1.8823    | 1.7013    | 1.8099    | 1.7558    | 1.9547    | 1.9004    |
| 5    | 1.7737    | 1.9185    | 1.7194    | 1.8823    | 1.7193    | 1.9366    | 1.828     |
| 6    | 1.7556    | 2.0814    | 1.9004    | 1.9185    | 1.9204    | 1.9004    | 1.8099    |
| 7    | 1.7556    | 2.0814    | 1.9547    | 1.8461    | 1.701     | 1.7737    | 1.7556    |
| 8    | 1.7013    | 1.7737    | 1.7013    | 1.6108    | 1.5912    | 1.7194    | 1.6108    |
| 9    | 1.6832    | 1.5746    | 1.6651    | 1.6651    | 1.6289    | 1.647     | 1.5565    |
| 10   | 1.5927    | 1.6289    | 1.6108    | 1.7193    | 1.647     | 1.7013    | 1.7194    |
| 11   |           | 1.6832    | 1.6651    | 1.6644    | 1.7556    | 1.8099    | 1.5746    |
| 12   | 1.6832    | 1.8099    | 1.7556    | 1.6461    | 1.8099    | 1.8099    | 1.7918    |
| 13   |           | 1.828     | 1.8099    | 1.7193    | 1.828     | 1.7918    | 1.828     |
| 14   | 1.7013    | 1.8099    | 1.8823    | 1.7924    | 1.8099    | 1.8642    | 1.9185    |
| 15   | 1.6651    | 1.9185    | 1.9185    | 1.8656    | 1.8099    | 1.8823    | 1.9547    |
| 16   | 1.647     | 1.7737    | 1.7737    | 1.829     | 1.8099    | 1.9185    | 1.9728    |
| 17   | 1.7013    | 1.7375    | 1.7375    | .695      | 1.828     | 1.828     | 2.0271    |
| 18   |           | 1.7556    | 1.7194    | 1.4998    | 1.7375    | 1.7556    | 1.7741    |
| 19   | 1.9366    | 2.0814    |           | 1.9022    | 2.0452    | 1.9909    | 2.1719    |
| 20   | 1.8823    | 2.0814    | 1.9909    | 1.9753    | 2.1719    | 2.1538    | 2.1357    |
| 21   | 1.8642    | 1.9909    | 1.9366    | 2.0302    | 2.1538    | 2.0271    | 2.0633    |
| 22   |           | 2.009     | 1.8823    | 2.1033    | 2.1176    | 2.1357    | 2.0814    |
| 23   | 1.8461    | 2.0271    | 1.8823    | 2.0302    | 2.1357    | 2.0814    | 2.1538    |
| 24   | 1.8461    | 1.8099    | 1.9909    | 1.8099    | 1.9204    | 2.1176    | 1.9185    |
| Max  | 1.9366    | 2.0814    | 1.9909    | 2.1033    | 2.1719    | 2.1538    | 2.1719    |
| Min  | 1.5927    | 1.5746    | 1.6108    | .695      | 1.5912    | 1.647     | 1.5565    |
| Avg  | 1.7610    | 1.8574    | 1.8154    | 1.7670    | 1.8440    | 1.9125    | 1.8899    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124149 / 33/11 KV Chopda Urban

Feeder No / Name : 205 / 11 KV KATHORA FEEDER

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0351     | .0362     | .1372     | .2534     | .2515     | .0343     | .0343     |
| 2    | .0351     | .0362     | .1543     | .2534     | .2515     | .0343     | .0343     |
| 3    | .0351     | .0362     | .2229     | .2534     | .2515     | .0343     | .0343     |
| 4    | .0351     | .0362     | .2058     | .2534     | .2515     | .0343     | .0343     |
| 5    | .0351     | .2353     | .2058     | .2534     | .2572     | .0343     | .0343     |
| 6    | .0351     | .2534     | .2058     | .2534     | .2515     | .0343     | .0343     |
| 7    | .0351     | .2353     | .2058     | .2534     | .2515     | .0343     | .0343     |
| 8    | .0362     | .181      | .0343     | .2534     | .2515     | .0343     | .0343     |
| 9    | .0362     | .2572     | .1086     | .1638     | .2629     | .0343     | .0328     |
| 10   | .0362     | .2572     | .2353     | .2297     | .2629     | .0343     | .0335     |
| 11   |           | .1715     | .2534     | .2294     | .298      | .0343     | .0335     |
| 12   | .0362     | .2572     | .2715     | .1715     | .298      | .0343     | .0335     |
| 13   |           | .1886     | .2715     | .2229     | .2629     | .0343     | .0335     |
| 14   | .0362     | .2058     | .2715     | .213      | .2629     | .0343     | .0328     |
| 15   | .1086     | .1372     | .2715     | .2572     | .0351     | .0343     | .0328     |
| 16   | .2172     | .2229     | .2715     | .1543     | .2279     | .0343     | .0328     |
| 17   | .2172     | .2401     | .2715     | .0686     | .2279     | .0343     | .0324     |
| 18   | .2263     | .1715     | .2715     | .1886     | .1886     | .0343     | .0328     |
| 19   | .1629     | .2572     |           | .1715     | .0343     | .0343     | .0328     |
| 20   | .2353     | .2401     | .2353     | .2572     | .2058     | .0343     | .0328     |
| 21   | .2353     | .1715     | .2715     | .2515     | .0343     | .0343     | .0328     |
| 22   |           | .1543     | .2715     | .2515     | .2229     | .0343     | .0328     |
| 23   | .2353     | .1543     | .2715     | .2515     | .0343     | .0343     | .0328     |
| 24   | .0351     | .2353     | .1543     | .2715     | .2515     | .0343     | .0343     |
| Max  | .2353     | .2572     | .2715     | .2715     | .298      | .0343     | .0343     |
| Min  | .0351     | .0362     | .0343     | .0686     | .0343     | .0343     | .0324     |
| Avg  | .1        | .1822     | .2206     | .2242     | .2137     | .0343     | .0335     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA I S/DN[233]

BU 0233

Substation No/ Name :- 124149 / 33/11 KV Chopda Urban

Feeder No / Name : 206 / 11 KV CHOPDA URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.262     | 1.2071    | 1.2986    | 1.3169    | 1.2986    | 1.3169    | 1.3169    |
| 2    | 1.2437    | 1.1888    | 1.3169    | 1.2071    | 1.2437    | 1.2803    | 1.3169    |
| 3    | 1.2437    | 1.2071    | 1.2254    | 1.1706    | 1.1706    | 1.2803    | 1.2803    |
| 4    | 1.2254    | 1.1706    | 1.1523    | 1.2071    | 1.1523    | 1.262     | 1.2437    |
| 5    | 1.2071    | 1.2071    | 1.1706    | 1.2803    | 1.1523    | 1.262     | 1.2071    |
| 6    | 1.1888    | 1.2254    | 1.1888    | 1.2437    | 1.2437    | 1.2437    | 1.1888    |
| 7    |           | 1.1706    | 1.2437    | 1.3352    | 1.1888    | 1.0791    | 1.0974    |
| 8    |           | 1.0974    | 1.0974    | 1.2254    | 1.0425    | .9877     | 1.0425    |
| 9    |           | .9694     | 1.0608    | .3801     | 1.0425    | 1.0059    | .9877     |
| 10   | 1.0608    | 1.0059    | 1.0425    | 1.0425    | 1.0974    | .9877     | 1.0498    |
| 11   | 1.0608    | .9694     | 1.0242    | 1.0791    | 1.0974    | .9694     | 1.1041    |
| 12   | 1.0242    | 1.2254    | 1.0242    | 1.0974    | .9877     | .9511     | 1.0679    |
| 13   | 1.0608    | 1.1706    | 1.0974    | 1.0791    | 1.0608    | .9877     | 1.0679    |
| 14   | 1.134     | 1.0974    | 1.134     | 1.1888    | 1.0791    | 1.0425    | 1.086     |
| 15   | 1.1706    | 1.134     | 1.0974    | 1.2071    | 1.0974    | 1.0242    | 1.1041    |
| 16   | 1.0791    | 1.0974    | 1.0608    | 1.0608    | 1.0974    | 1.0425    | 1.0679    |
| 17   | 1.0974    | 1.0242    | 1.0242    | 1.0791    | 1.0974    | 1.0608    | 1.0136    |
| 18   |           | 1.0242    | 1.0059    | .8869     | .9877     | .9328     | 1.0317    |
| 19   | 1.2071    | 1.2254    |           | 1.1706    | 1.2254    | 1.0059    | 1.2071    |
| 20   | 1.2437    | 1.1523    | 1.2437    | 1.2803    | 1.2071    | 1.2437    | 1.2803    |
| 21   | 1.3169    | 1.3717    | 1.3169    | 1.3352    | 1.2803    | 1.2437    | 1.2803    |
| 22   |           | 1.4083    | 1.2803    | 1.4632    | 1.3535    | 1.2986    | 1.2986    |
| 23   | 1.2437    | 1.3169    | 1.2437    | 1.5364    | 1.3535    | 1.39      | 1.3169    |
| 24   | 1.262     | 1.2437    | 1.3352    | 1.2803    | 1.3535    | 1.3352    | 1.3169    |
| Max  | 1.3169    | 1.4083    | 1.3352    | 1.5364    | 1.3535    | 1.39      | 1.3169    |
| Min  | 1.0242    | .9694     | 1.0059    | .3801     | .9877     | .9328     | .9877     |
| Avg  | 1.1754    | 1.1629    | 1.1602    | 1.1731    | 1.1629    | 1.1347    | 1.1656    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124072 / 33/11 KV GALANGI

Feeder No / Name : 201 / 11 KV Vitner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 14-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 8    | 1.9814    | .4801     |
| 11   | .381      |           |
| 12   |           | 2.0386    |
| 24   | 1.6575    |           |
| Max  | 1.9814    | 2.0386    |
| Min  | .381      | .4801     |
| Avg  | 1.3400    | 1.2594    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124072 / 33/11 KV GALANGI

Feeder No / Name : 203 / 11 KV Ghodgaon-Pure AG-  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 10-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           | 1.4083    |
| 9    | 1.4413    |           |           |
| 12   |           | 1.7718    |           |
| 18   |           | 1.848     |           |
| Max  | 1.4413    | 1.848     | 1.4083    |
| Min  | 1.4413    | 1.7718    | 1.4083    |
| Avg  | 1.4413    | 1.8099    | 1.4083    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124072 / 33/11 KV GALANGI

Feeder No / Name : 204 / 11 KV Bhaver - Pure AG-  
Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    | 1.3908    | 1.5242    |           |
| 12   |           |           | 1.6575    |
| 24   | 1.2955    | 1.3527    |           |
| Max  | 1.3908    | 1.5242    | 1.6575    |
| Min  | 1.2955    | 1.3527    | 1.6575    |
| Avg  | 1.3432    | 1.4385    | 1.6575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124072 / 33/11 KV GALANGI

Feeder No / Name : 206 / 11 Kv Ganpur Gavthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 10-APR-18 | 11-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .3547     | .3429     | .362      | .3361     |
| 11   |           |           |           | .2286     |
| 12   |           | .2667     |           |           |
| 18   |           | .3239     |           | .4001     |
| 24   |           | .2096     | .2286     |           |
| Max  | .3547     | .3429     | .362      | .4001     |
| Min  | .3547     | .2096     | .2286     | .2286     |
| Avg  | .3547     | .2858     | .2953     | .3216     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124072 / 33/11 KV GALANGI

Feeder No / Name : 207 / 11 Kv Veloda Agr

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 10-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    | 2.0233    |           | 1.9376    |
| 12   |           | 2.4196    |           |
| Max  | 2.0233    | 2.4196    | 1.9376    |
| Min  | 2.0233    | 2.4196    | 1.9376    |
| Avg  | 2.0233    | 2.4196    | 1.9376    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124081 / 33/11 KV GORGAWALE

Feeder No / Name : 201 / Gorgawale Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .3696     | .3772     |           | .3841     | .3601     | .3772     |           |
| 4    | .7023     | .5658     | .4458     | .4207     | .6001     | .5487     | .3944     |
| 6    | .961      | .8573     |           | .8596     | .8916     | .823      |           |
| 7    |           |           | .6344     |           |           |           | .6173     |
| 8    | .5729     | .4801     | .4973     | .5121     | .4801     | .4801     | .4801     |
| 10   | .4801     | .4287     | .462      | .4115     | .3772     | .4458     | .463      |
| 12   | .4115     | .4115     | .3881     | .3772     | .3944     | .3944     | .4115     |
| 14   | .4115     | .3601     | .3696     | .3944     | .3601     | .3772     | .3944     |
| 16   | .463      | .3772     | .3696     | .4115     | .3944     | .3772     | .4115     |
| 18   | .4287     | .4458     | .4435     | .4287     | .3944     | .4287     | .4115     |
| 20   | .5316     | .6344     | .5914     | .6173     | .5658     | .6344     | .5658     |
| 22   | .4115     | .4458     | .462      | .4287     | .4458     | .4115     | .4287     |
| 24   | .3881     | .3772     | .3772     | .7796     |           | .3601     | .3772     |
| Max  | .961      | .8573     | .6344     | .8596     | .8916     | .823      | .6173     |
| Min  | .3696     | .3601     | .3696     | .3772     | .3601     | .3601     | .3772     |
| Avg  | .5110     | .4801     | .4583     | .5021     | .4785     | .4715     | .4505     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124081 / 33/11 KV GORGAWALE

Feeder No / Name : 202 / 11 Kv Vadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 1.866     | .2743     |           | .2686     | .2572     | 1.89      |           |
| 4    | 1.9134    | .3429     | .2743     | .3224     | .5487     | 1.9357    | 2.0576    |
| 6    | 1.9292    | .3944     |           | .7343     | .7202     | 1.9814    |           |
| 7    |           |           | .5316     |           |           |           | 2.2291    |
| 8    | 2.0241    | .3601     | .4287     | .4835     | .3944     |           | 2.2462    |
| 10   | .2915     | 2.0062    | 2.4691    | 2.2634    | 1.8747    | .2915     | .3086     |
| 12   | .3086     | 2.2805    | 2.3411    | 2.2291    | 1.8747    | .2401     | .2401     |
| 14   | .2915     | 2.3148    | 1.9936    | 2.2119    | 1.9357    | .2401     | .2401     |
| 16   | .2743     | 1.9547    | 2.4143    | 2.2119    | 1.8747    | .2915     | .2401     |
| 18   | .4287     | .3944     | .4755     | .3772     | .3944     | .3772     | .4287     |
| 20   | .3601     | .3772     | .439      | .4973     | .4287     | .4801     | .463      |
| 22   | .3258     | .2915     | .3292     |           | .3086     | .3086     | .3258     |
| 24   | 1.8185    | .2743     | .2401     | .2743     |           | 1.8747    | 2.0233    |
| Max  | 2.0241    | 2.3148    | 2.4691    | 2.2634    | 1.9357    | 1.9814    | 2.2462    |
| Min  | .2743     | .2743     | .2401     | .2686     | .2572     | .2401     | .2401     |
| Avg  | .9860     | .9388     | 1.0851    | 1.0794    | .9647     | .9010     | .9821     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124081 / 33/11 KV GORGAWALE

Feeder No / Name : 203 / 11 Kv Gorgawale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | 2.1605    |           |           |           |           | 2.0729    |           |
| 4    |           |           |           |           |           | 2.0729    | 1.9814    |
| 6    |           |           |           |           |           | 2.0729    |           |
| 7    |           |           |           |           |           |           | 2.1338    |
| 8    |           |           |           |           |           | 2.1338    | 2.1338    |
| 10   |           | 2.1338    | 2.3205    | 2.1338    | 2.2405    |           |           |
| 12   |           | 2.2862    | 2.4863    | 2.2862    | 2.2405    |           |           |
| 14   |           | 2.2862    | 2.4863    | 2.2862    | 2.2405    |           |           |
| 16   |           | 2.2862    | 2.3205    | 2.2862    | 2.3167    |           |           |
| 24   | 2.1605    |           |           |           |           | 2.0729    | 1.9814    |
| Max  | 2.1605    | 2.2862    | 2.4863    | 2.2862    | 2.3167    | 2.1338    | 2.1338    |
| Min  | 2.1605    | 2.1338    | 2.3205    | 2.1338    | 2.2405    | 2.0729    | 1.9814    |
| Avg  | 2.1605    | 2.2481    | 2.4034    | 2.2481    | 2.2596    | 2.0851    | 2.0576    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124081 / 33/11 KV GORGAWALE

Feeder No / Name : 205 / 11 Kv Khedi Bhokri Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .1829     | .12       |           | .1646     | .1372     | .12       |           |
| 4    | .2743     | .1715     | .1543     | .2743     | .2572     | .2058     | .1543     |
| 6    | .5487     | .5144     |           | .5487     | .5144     | .5144     |           |
| 7    |           |           | .3429     |           |           |           | .3429     |
| 8    | .1829     | .2229     | .1715     | .1829     | .2572     | .2401     | .1715     |
| 10   | .1715     | .1715     | .1663     | .1715     | .1715     | .1715     |           |
| 12   | .1372     | .1372     | .1663     | .1715     | .1372     | .1372     | .703      |
| 14   | .12       | .1372     | .1663     | .1715     | .1543     | .1715     | .1715     |
| 16   | .1715     | .1715     | .1848     | .1715     | .1886     | .1715     | .2058     |
| 18   | .2229     | .1715     | .1848     | .2572     | .2058     | .1715     | .3086     |
| 20   | .3429     | .1715     | .1848     | .2572     | .2058     | .1715     | .3086     |
| 22   | .1372     | .1372     | .1663     | .1715     | .1372     | .1715     | .2572     |
| 23   |           |           |           | .1543     |           |           |           |
| 24   | .1463     | .12       | .1372     | .1463     |           | .12       | .1543     |
| Max  | .5487     | .5144     | .3429     | .5487     | .5144     | .5144     | .703      |
| Min  | .12       | .12       | .1372     | .1463     | .1372     | .12       | .1543     |
| Avg  | .2199     | .1872     | .1841     | .2187     | .2151     | .1972     | .2778     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124081 / 33/11 KV GORGAWALE

Feeder No / Name : 206 / 11 KV Vadgaon Kh Ag Feeder FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           | 2.1338    |           | 1.9766    | 2.2462    |           |           |
| 4    |           | 2.1338    | 2.0424    | 1.9766    |           |           |           |
| 6    |           | 2.1338    |           | 1.9925    |           |           |           |
| 7    |           |           | 2.0881    |           |           |           |           |
| 8    |           | 2.1338    | 2.21      | 2.0557    | 2.332     |           |           |
| 10   | 2.1033    |           |           |           |           | 1.9662    | 2.2634    |
| 12   | 2.0424    |           |           |           |           | 2.0271    | 2.4006    |
| 14   | 2.0424    |           |           |           |           | 2.0424    | 2.4006    |
| 16   | 2.0881    |           |           |           |           | 2.0119    |           |
| 17   |           |           |           |           |           |           | 2.2291    |
| 18   |           |           |           |           |           | 1.9814    |           |
| 23   |           |           |           | 2.2977    |           |           |           |
| 24   |           | 2.1338    | 1.9509    | 2.2634    |           |           |           |
| Max  | 2.1033    | 2.1338    | 2.21      | 2.2977    | 2.332     | 2.0424    | 2.4006    |
| Min  | 2.0424    | 2.1338    | 1.9509    | 1.9766    | 2.2462    | 1.9662    | 2.2291    |
| Avg  | 2.0691    | 2.1338    | 2.0729    | 2.0938    | 2.2891    | 2.0058    | 2.3234    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124092 / 33/11 KV MOHIDA S/STN

Feeder No / Name : 201 / 11 Kv Mohida Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7202     |           |           |           |           | 1.1317    | 1.0802    |
| 2    | .7202     |           |           |           |           | 1.166     | 1.1488    |
| 3    | .7545     |           |           |           |           | 1.2003    |           |
| 4    | .7545     |           |           |           |           | 1.2003    | 1.166     |
| 5    | .7888     |           |           |           |           | 1.2346    |           |
| 6    | .7888     |           |           |           |           | 1.2346    | 1.1488    |
| 7    | .823      |           |           |           |           | 1.2689    |           |
| 8    | 1.2346    |           |           |           |           | 1.2174    | 1.166     |
| 10   |           | 1.2174    | 1.2174    | 1.166     | .9945     |           |           |
| 11   |           |           | 1.2003    |           | 1.0288    |           |           |
| 12   |           | 1.286     | 1.2517    | 1.2517    | 1.0631    |           |           |
| 13   |           |           | 1.2346    |           | 1.0631    |           |           |
| 14   |           | 1.3032    | 1.2346    | 1.2346    | 1.0974    |           |           |
| 15   |           |           | 1.2346    |           | 1.0974    |           |           |
| 16   |           | 1.3375    | 1.2346    | 1.2174    | 1.1145    |           |           |
| 17   |           |           | 1.2689    |           | 1.1317    |           |           |
| 23   |           |           |           |           | 1.0631    |           |           |
| 24   | .6859     |           |           |           |           | 1.0974    | 1.046     |
| Max  | 1.2346    | 1.3375    | 1.2689    | 1.2517    | 1.1317    | 1.2689    | 1.166     |
| Min  | .6859     | 1.2174    | 1.2003    | 1.166     | .9945     | 1.0974    | 1.046     |
| Avg  | .8078     | 1.2860    | 1.2346    | 1.2174    | 1.0726    | 1.1946    | 1.1260    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548] BU 8192

Substation No/ Name :- 124092 / 33/11 KV MOHIDA S/STN

Feeder No / Name : 203 / 11 Kv Ajantisim Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.2689    | 1.286     | 1.1145    |           |           |           |
| 2    |           | 1.2689    |           | 1.0974    | 1.1831    |           |           |
| 3    |           | 1.3032    |           | 1.1145    |           |           |           |
| 4    |           | 1.3375    | 1.3546    | 1.1145    | 1.2003    |           |           |
| 5    |           | 1.3375    |           | 1.0974    |           |           |           |
| 6    |           | 1.3717    |           | 1.2174    | 1.2689    |           |           |
| 7    |           | 1.406     | 1.3889    | 1.3717    |           |           |           |
| 8    |           | 1.4232    | 1.4575    | 1.3546    | 1.3032    |           |           |
| 10   | 1.3546    |           |           |           |           |           | 1.3032    |
| 11   | 1.3375    |           |           |           |           | 1.1488    | 1.406     |
| 12   | 1.3032    |           |           |           |           |           | 1.3375    |
| 13   | 1.3032    |           |           |           |           | 1.166     | 1.3203    |
| 14   | 1.3203    |           |           |           |           |           | 1.3717    |
| 15   | 1.3375    |           |           |           |           |           | 1.4232    |
| 16   | 1.3717    |           |           |           |           | 1.2689    | 1.4232    |
| 17   | 1.3889    |           |           |           |           | 1.2689    | 1.3546    |
| 23   | 1.2346    |           | 1.1145    |           |           |           |           |
| 24   |           | 1.2689    | 1.2174    | 1.0974    | 1.166     |           |           |
| Max  | 1.3889    | 1.4232    | 1.4575    | 1.3717    | 1.3032    | 1.2689    | 1.4232    |
| Min  | 1.2346    | 1.2689    | 1.1145    | 1.0974    | 1.166     | 1.1488    | 1.3032    |
| Avg  | 1.3279    | 1.3318    | 1.3032    | 1.1755    | 1.2243    | 1.2132    | 1.3675    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

CHOPDA-II S/DN[548]

BU 8192

Substation No/ Name :- 124092 / 33/11 KV MOHIDA S/STN

Feeder No / Name : 204 / 11 Kv Vadhoda Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     | .1543     | .12       | .1543     |           | .1372     | .12       |
| 2    | .1715     | .1715     | .1543     |           | .1543     | .1543     | .1372     |
| 3    | .2401     | .3429     |           | .1886     |           |           | .1715     |
| 4    | .5487     | .5487     |           | .3772     | .2743     | .2572     | .2058     |
| 5    | .5144     | .5144     | .3429     | .4973     |           | .4115     | .3429     |
| 6    | .4458     | .4458     | .5316     | .5144     | .5316     | .5487     | .5316     |
| 7    | .4115     | .3429     | .4801     | .3772     |           | .3944     | .4115     |
| 8    | .3086     | .2915     | .3772     | .3429     | .3429     | .2401     | .3601     |
| 9    | .2743     |           | .2915     |           | .2915     |           | .3086     |
| 10   | .2572     | .2743     | .2743     | .2229     | .2743     | .2058     | .3429     |
| 11   | .1886     |           | .2058     |           | .2401     | .1886     | .3086     |
| 12   | .1715     | .1715     | .1715     | .1715     | .1715     |           | .2572     |
| 13   | .1543     | .1372     | .1715     |           | .1543     | .1372     | .1886     |
| 14   | .1372     |           | .1886     | .1715     | .1715     |           | .1715     |
| 15   | .1715     |           | .1886     |           | .1886     |           | .2229     |
| 16   | .1886     | .1715     | .1886     | .1543     | .2058     | .1715     | .2401     |
| 17   | .3429     |           | .2401     |           | .2229     |           | .2743     |
| 18   | .3772     |           | .4801     |           | .3086     |           | .2915     |
| 19   | .3086     |           | .5487     |           | .3429     | .4801     | .4458     |
| 20   | .2743     | .463      | .5144     | .3258     | .4115     |           | .463      |
| 21   | .2743     | .1886     | .2229     |           | .2743     |           | .3772     |
| 22   | .2058     |           | .2058     | .2401     | .1715     | .2058     | .1886     |
| 23   | .1715     |           | .1886     |           | .1543     | .1715     | .1715     |
| 24   | .1715     | .1372     | .12       | .1543     | .1543     | .1372     | .12       |
| Max  | .5487     | .5487     | .5487     | .5144     | .5316     | .5487     | .5316     |
| Min  | .1372     | .1372     | .12       | .1543     | .1543     | .1372     | .12       |
| Avg  | .2686     | .2904     | .2821     | .2780     | .2521     | .2561     | .2772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 201 / 11 KV PALDHI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 1.869     | 1.9033    | 1.9719    |
| 2    |           |           |           |           | 1.9033    | .1886     |           |
| 3    |           |           |           |           | 2.0233    | 1.9547    |           |
| 4    |           |           |           |           | 2.0919    | 2.0405    |           |
| 5    |           |           |           |           | 2.4863    | 2.4006    | 2.4006    |
| 6    |           |           |           |           | 2.572     | 2.572     | 2.572     |
| 7    |           |           |           |           |           |           | 2.4006    |
| 8    |           |           |           |           | 2.2291    | 2.0576    | 2.2291    |
| 9    | 1.7318    | 1.9033    | 1.6804    | 2.1437    | 2.2177    | 2.2177    | 2.2177    |
| 10   | 2.0576    | 1.7147    | 1.7147    | 2.0328    | 2.0328    | 2.2177    | 2.1253    |
| 11   | 1.869     | 1.6118    | 1.6461    | 1.9404    | 1.6263    | 2.0328    | 1.9035    |
| 12   | 1.7147    | 1.5432    | 1.5432    | 1.885     | 1.9404    | 1.7926    | 1.9404    |
| 13   | 1.6804    |           |           | 1.8111    | 1.885     | 1.7741    | 1.9404    |
| 14   | 1.5775    |           |           | 1.7926    | 1.8665    | 1.7926    | 1.8665    |
| 15   | 1.5432    | 1.5089    |           | 1.8296    | 1.9035    | 1.9404    | 1.9589    |
| 16   | 1.5432    | 1.4575    |           | 1.9404    | 1.922     | 1.9035    | 1.885     |
| 17   | 1.9589    | 1.9404    |           |           |           |           |           |
| 18   | 2.1253    | 2.1068    |           |           |           |           |           |
| 19   | 2.4646    | 2.5766    |           |           |           |           |           |
| 20   | 2.3899    | 2.5019    |           |           |           |           |           |
| 21   | 2.3339    | 2.3339    |           |           |           |           |           |
| 22   | 2.1472    | 2.2032    |           |           |           |           |           |
| 24   |           |           |           |           | 1.7147    | 1.7147    | 1.9033    |
| Max  | 2.4646    | 2.5766    | 1.7147    | 2.1437    | 2.572     | 2.572     | 2.572     |
| Min  | 1.5432    | 1.4575    | 1.5432    | 1.7926    | 1.6263    | .1886     | 1.8665    |
| Avg  | 1.9384    | 1.9502    | 1.6461    | 1.9220    | 2.0177    | 1.9065    | 2.0939    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 202 / 11 KV ENGG. COLLEGE  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .5144     | .5144     | .5144     |
| 2    |           |           |           |           | .4973     | .5144     |           |
| 3    |           |           |           |           | .4973     | .4801     |           |
| 4    |           |           |           |           | .4801     | .4801     |           |
| 5    |           |           |           |           | .4801     | .4458     | .4458     |
| 6    |           |           |           |           | .463      | .4287     |           |
| 7    |           |           |           |           |           |           | .4287     |
| 8    |           |           |           |           | .5658     | .6344     | .4973     |
| 9    | .5144     | .6859     | .6516     | .8686     | 1.1088    | .7392     | .3696     |
| 10   | .5658     | .6516     | .9602     | 1.1088    | 1.2567    | 1.2936    | .8316     |
| 11   |           |           | .9431     | 1.2197    | 1.2936    | 1.4784    | .7392     |
| 12   |           | .823      | .8916     | 1.0719    | 1.2012    | 1.2567    | .5544     |
| 13   | .6687     |           |           | 1.1827    | 1.2012    | 1.4045    | .6468     |
| 14   | .6516     |           |           | 1.2382    | 1.2567    | 1.4784    | .7577     |
| 15   | .6516     | .8916     |           | 1.2012    | 1.2936    | 1.2936    | .7392     |
| 16   | .6173     | .8916     |           | 1.2567    | 1.2012    | 1.2382    | .6653     |
| 17   | .7762     | 1.2936    |           |           |           |           |           |
| 18   | .8871     | .924      |           |           |           |           |           |
| 19   | .7468     | .7468     |           |           |           |           |           |
| 20   | .7842     | .8215     |           |           |           |           |           |
| 21   | .7468     | .7468     |           |           |           |           |           |
| 22   | .7468     | .6908     |           |           |           |           |           |
| 24   |           |           |           |           | .5144     | .5144     | .5316     |
| Max  | .8871     | 1.2936    | .9602     | 1.2567    | 1.2936    | 1.4784    | .8316     |
| Min  | .5144     | .6516     | .6516     | .8686     | .463      | .4287     | .3696     |
| Avg  | .6964     | .8334     | .8616     | 1.1435    | .8641     | .8872     | .5940     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 203 / 11 KV EKLAGNA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           | .1543     | .1886     |
| 2    |           |           |           |           | .0343     | .1715     |           |
| 3    |           |           |           |           | .0343     | .2058     |           |
| 4    |           |           |           |           | .0343     | .2058     |           |
| 5    |           |           |           |           | .0343     | .2229     | .2401     |
| 6    |           |           |           |           | .0343     | .2401     | .2572     |
| 7    |           |           |           |           |           |           | .4115     |
| 8    |           |           |           |           | .0343     | .4115     | .4458     |
| 9    | .0343     | .0343     | .0343     | .037      | .0554     | .0554     | .0554     |
| 10   | .0343     |           | .463      | .5544     | .4251     | .0554     | .037      |
| 11   |           | .5487     | .5144     | .5914     | .5914     | .0554     | .0554     |
| 12   |           | .6516     | .6001     | .5914     | .5729     | .0554     | .0554     |
| 13   | .0343     |           |           | .4435     | .7023     | .0554     | .0554     |
| 14   | .0171     |           |           | .4251     | .8871     | .0554     | .0739     |
| 15   | .0171     | .5487     |           | .3881     | .4251     | .0554     | .0739     |
| 16   | .0171     | .5144     |           | .4108     | .4066     | .037      | .0554     |
| 17   | .0739     | .5914     |           |           |           |           |           |
| 18   | .0739     | .0554     |           |           |           |           |           |
| 19   | .0747     | .0747     |           |           |           |           |           |
| 20   | .0747     | .0934     |           |           |           |           |           |
| 21   | .0747     | .0934     |           |           |           |           |           |
| 22   | .056      | .0747     |           |           |           |           |           |
| 24   |           |           |           |           | .0343     | .1543     | .1715     |
| Max  | .0747     | .6516     | .6001     | .5914     | .8871     | .4115     | .4458     |
| Min  | .0171     | .0343     | .0343     | .037      | .0343     | .037      | .037      |
| Avg  | .0485     | .2982     | .4030     | .4302     | .2871     | .1369     | .1555     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 204 / 11 KV EKLAGNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .12       | .1029     |           |
| 2    |           |           |           |           | .1715     | .0857     |           |
| 3    |           |           |           |           | .1715     | .12       |           |
| 4    |           |           |           |           | .1886     | .1543     |           |
| 5    |           |           |           |           | .2058     | .1886     | .1886     |
| 6    |           |           |           |           | .2229     | .2229     | .2058     |
| 7    |           |           |           |           |           |           | .1715     |
| 8    |           |           |           |           | .1543     | .12       | .1372     |
| 9    | .1372     | .12       | .1029     | .1478     | .1478     | .1294     | .1478     |
| 10   | .0857     | .1029     | .0857     | .1109     | .1294     | .1109     | .1294     |
| 11   |           |           | .0686     | .1109     | .0924     | .1109     | .1109     |
| 12   |           | .0686     | .0686     | .0924     | .0739     | .0924     | .1109     |
| 13   | .0686     |           |           | .0924     | .0924     | .0924     | .1109     |
| 14   | .0686     |           |           | .0924     | .0924     | .0739     | .1109     |
| 15   | .0514     | .0857     |           | .1109     | .0739     | .0739     | .0924     |
| 16   | .0686     | .0857     |           | .1109     | .0924     | .0739     | .0924     |
| 17   | .1294     | .1109     |           |           |           |           |           |
| 18   | .1294     | .1109     |           |           |           |           |           |
| 19   | .168      | .1307     |           |           |           |           |           |
| 20   | .168      | .168      |           |           |           |           |           |
| 21   | .1494     | .168      |           |           |           |           |           |
| 22   | .1307     | .1307     |           |           |           |           |           |
| 24   |           |           |           |           | .1029     | .1029     | .1029     |
| Max  | .168      | .168      | .1029     | .1478     | .2229     | .2229     | .2058     |
| Min  | .0514     | .0686     | .0686     | .0924     | .0739     | .0739     | .0924     |
| Avg  | .1129     | .1166     | .0815     | .1086     | .1333     | .1159     | .1317     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 205 / 11 KV EKLAGNA- II  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .3944     | .3944     | .4287     |
| 2    |           |           |           |           | .3601     | .3601     |           |
| 3    |           |           |           |           | .3601     | .3601     |           |
| 4    |           |           |           |           | .3086     | .3429     |           |
| 5    |           |           |           |           | .2915     | .3086     | .3258     |
| 6    |           |           |           |           | .2743     | .2915     | .3086     |
| 8    |           |           |           |           | .2401     | .2743     | .2572     |
| 9    | .4801     | .5144     | .2743     | .6468     | .6468     | .499      | .2218     |
| 10   | .3258     |           | .3258     | .7207     | .4805     | .5914     | .2587     |
| 11   |           | .4801     | .3772     | .7023     | .5359     | .5175     | .2587     |
| 12   |           | .4287     | .4458     | .6653     | .5359     | .5544     | .2772     |
| 13   | .3429     |           |           | .6838     | .5544     | .4066     | .2587     |
| 14   | .3772     |           |           | .6468     | .5914     | .3142     | .2772     |
| 15   | .4115     | .5487     |           | .6653     | .5729     | .3326     | .2587     |
| 16   | .5144     | .6001     |           | .5914     | .5544     | .5729     | .2772     |
| 17   | .5914     | .6468     |           |           |           |           |           |
| 18   | .7023     | .6468     |           |           |           |           |           |
| 19   | .2801     | .3174     |           |           |           |           |           |
| 20   | .2987     | .3734     |           |           |           |           |           |
| 21   | .2987     | .3547     |           |           |           |           |           |
| 22   | .4108     | .4294     |           |           |           |           |           |
| 24   |           |           |           |           | .4458     | .4115     | .4287     |
| Max  | .7023     | .6468     | .4458     | .7207     | .6468     | .5914     | .4287     |
| Min  | .2801     | .3174     | .2743     | .5914     | .2401     | .2743     | .2218     |
| Avg  | .4195     | .4855     | .3558     | .6653     | .4467     | .4083     | .2952     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 206 / 11 KV PATHRAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | 1.0719    |           | 1.1273    | 1.2936    |
| 10   |           |           | 1.6448    | 1.7372    | 1.0349    | 1.2012    |
| 11   |           |           | 1.8665    | 1.848     | .9979     | .9979     |
| 12   |           |           |           | 1.8296    | 1.0349    | 1.1643    |
| 13   |           |           | 1.5524    | 1.7741    | 1.0164    | 1.1458    |
| 14   |           |           | 1.5708    | 1.7372    | 1.0534    | 1.1827    |
| 15   |           |           | 1.5684    | 1.6263    | 1.1273    | 1.1643    |
| 16   |           |           | 1.5893    | 1.6448    | 1.1458    | 1.1273    |
| 17   | 1.1273    | 1.7741    |           |           |           |           |
| 18   | 1.2382    | 1.2012    |           |           |           |           |
| 19   | 1.6617    | 1.6057    |           |           |           |           |
| 20   | 1.643     | 1.6617    |           |           |           |           |
| 21   | 1.587     | 1.6244    |           |           |           |           |
| 22   | 1.419     | 1.4563    |           |           |           |           |
| Max  | 1.6617    | 1.7741    | 1.8665    | 1.848     | 1.1458    | 1.2936    |
| Min  | 1.1273    | 1.2012    | 1.0719    | 1.6263    | .9979     | .9979     |
| Avg  | 1.4460    | 1.5539    | 1.5520    | 1.7425    | 1.0672    | 1.1596    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124062 / 33/11 KV PALDHI

Feeder No / Name : 207 / 11 KV DONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 1.3717    | .5658     | .6859     |
| 2    |           |           |           |           | 1.5089    | .7716     |           |
| 3    |           |           |           |           | 1.5089    | .8573     |           |
| 4    |           |           |           |           | 1.6461    | 1.0117    |           |
| 5    |           |           |           |           | 1.6461    | 1.2003    | 1.2003    |
| 6    |           |           |           |           | 1.6461    | 1.2689    | 1.2517    |
| 7    |           |           |           |           |           |           | 1.1145    |
| 8    |           |           |           |           | 1.7833    | .8916     | .8916     |
| 9    | .6344     | .6516     | .4801     | .7023     | .6838     | .7023     | .7392     |
| 10   | 1.5089    | .5316     | .5658     | .6653     | .5914     | 1.848     | 1.8296    |
| 11   |           | .5144     | .4973     | .462      | .4805     | 1.9774    | 1.8111    |
| 12   |           | .4973     | .4287     | .4435     | .4251     | 1.9404    | 1.6263    |
| 13   | 1.9204    |           |           | .4805     | .462      | 1.8111    | 1.6448    |
| 14   | 1.9204    |           |           | .4805     | .4805     | 1.7187    | 1.5524    |
| 15   | 1.9204    | .3429     |           | .5359     | .5175     | 1.6263    | 1.4969    |
| 16   | 1.7833    | .3086     |           | .5175     | .5544     | 1.5524    | 1.46      |
| 17   | 1.885     | .3326     |           |           |           |           |           |
| 18   | .6283     | .3511     |           |           |           |           |           |
| 19   | 1.0082    | 1.0456    |           |           |           |           |           |
| 20   | .9149     | .9149     |           |           |           |           |           |
| 21   | .8402     | .8402     |           |           |           |           |           |
| 22   | .6908     | .7282     |           |           |           |           |           |
| 24   |           |           |           |           | 1.3717    | .5658     | .6001     |
| Max  | 1.9204    | 1.0456    | .5658     | .7023     | 1.7833    | 1.9774    | 1.8296    |
| Min  | .6283     | .3086     | .4287     | .4435     | .4251     | .5658     | .6001     |
| Avg  | 1.3046    | .5883     | .4930     | .5359     | 1.0424    | 1.2694    | 1.2789    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 201 / 11KV SALWA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           |           |           | .1593     |
| 7    | .6171     |           |           |           |           | .3913     |
| 11   |           |           | .7973     |           | .6622     |           |
| 12   |           |           |           | .8122     |           |           |
| 16   |           |           |           | .5967     |           |           |
| 17   |           | .6979     |           |           |           |           |
| 24   | .2934     |           |           |           |           | .1593     |
| Max  | .6171     | .6979     | .7973     | .8122     | .6622     | .3913     |
| Min  | .2934     | .6979     | .7973     | .5967     | .6622     | .1593     |
| Avg  | .4553     | .6979     | .7973     | .7045     | .6622     | .2366     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 203 / 11 KV ROTWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           | .4525     |           |           |           |           |
| 5    |           | .431      |           |           |           |           |           |
| 6    |           |           | .543      | .4252     |           |           |           |
| 8    |           | .5801     |           |           |           |           |           |
| 11   |           |           |           |           | .5428     |           |           |
| 12   | .6299     |           |           |           |           | .5418     | .6401     |
| 16   | .5801     |           |           |           |           |           |           |
| 24   |           | .4641     | .4755     | .4382     |           |           |           |
| Max  | .6299     | .5801     | .543      | .4382     | .5428     | .5418     | .6401     |
| Min  | .5801     | .431      | .4525     | .4252     | .5428     | .5418     | .6401     |
| Avg  | .605      | .4917     | .4903     | .4317     | .5428     | .5418     | .6401     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 204 / 11 KV SALWA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE       | 10-APR-18    | 11-APR-18    | 12-APR-18    | 13-APR-18    | 14-APR-18    |
|------------|--------------|--------------|--------------|--------------|--------------|
| HR         | Load (MW)    | Load (MW)    | Load (MW)    | Load (MW)    | Load (MW)    |
| 4          |              |              |              | .3841        |              |
| 5          |              |              | .4656        |              |              |
| 6          |              | .5847        |              |              |              |
| 7          |              |              |              | .4435        |              |
| 9          |              |              | .3045        | .3582        | .4119        |
| 11         | .2658        |              | .2454        |              |              |
| 12         |              | .2865        |              | .3045        | .2561        |
| 16         |              | .3582        |              |              |              |
| 19         |              |              | .4344        | .5359        | .415         |
| 20         | .443         | .4477        |              |              |              |
| 24         |              | .3189        | .3224        | .3224        |              |
| <b>Max</b> | <b>.443</b>  | <b>.5847</b> | <b>.4656</b> | <b>.5359</b> | <b>.415</b>  |
| <b>Min</b> | <b>.2658</b> | <b>.2865</b> | <b>.2454</b> | <b>.3045</b> | <b>.2561</b> |
| <b>Avg</b> | <b>.3544</b> | <b>.3992</b> | <b>.3545</b> | <b>.3914</b> | <b>.361</b>  |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 205 / 11KV SAKARE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           | .1294     |           |           | .128      |           |
| 5    |           | .1433     |           |           | .1254     |           |           |
| 6    |           |           | .2195     | .2103     |           |           |           |
| 7    | .2033     |           |           |           |           | .1848     |           |
| 8    |           | .1612     |           |           |           |           |           |
| 9    |           |           |           |           | .1433     | .1075     | .1463     |
| 11   |           |           | .0886     |           | .1029     |           |           |
| 12   | .1075     |           |           | .0895     |           | .1063     | .1097     |
| 16   | .1254     |           |           | .1075     |           |           |           |
| 17   |           | .132      |           |           |           |           |           |
| 19   |           |           |           |           | .197      | .1646     | .1886     |
| 20   | .197      |           | .1595     | .1791     |           |           |           |
| 24   | .128      | .1254     | .128      | .124      | .1254     | .1294     |           |
| Max  | .2033     | .1612     | .2195     | .2103     | .197      | .1848     | .1886     |
| Min  | .1075     | .1254     | .0886     | .0895     | .1029     | .1063     | .1097     |
| Avg  | .1522     | .1405     | .145      | .1421     | .1388     | .1368     | .1482     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 206 / 11KV ROTWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           | .4024     |           |           | .4024     |           |
| 5    |           | .5014     |           |           | .4477     |           |           |
| 6    |           |           | .5853     | .5609     |           |           |           |
| 7    | .5121     |           |           |           |           | .462      |           |
| 8    |           | .3761     |           |           |           |           |           |
| 9    |           |           |           |           | .394      | .3506     | .362      |
| 11   |           |           | .3544     |           | .3506     |           |           |
| 12   | .3761     |           |           | .3582     |           | .3582     | .3475     |
| 16   | .4298     |           |           | .4119     |           |           |           |
| 17   |           | .4715     |           |           |           |           |           |
| 19   |           |           |           |           | .5068     | .5359     | .5093     |
| 20   | .4656     |           | .5138     | .4835     |           |           |           |
| 24   | .3696     | .3761     | .3658     | .3721     | .3582     | .3801     |           |
| Max  | .5121     | .5014     | .5853     | .5609     | .5068     | .5359     | .5093     |
| Min  | .3696     | .3761     | .3544     | .3582     | .3506     | .3506     | .3475     |
| Avg  | .4306     | .4313     | .4443     | .4373     | .4115     | .4149     | .4063     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124063 / 33/11 KV SALVA

Feeder No / Name : 207 / 11KV SAKRE INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 7    |           | .0914     |           |
| 9    | .0886     | .0886     | .0886     |
| 11   | .1372     |           |           |
| 12   |           | .1433     |           |
| 19   | .1063     | .0914     |           |
| 24   |           | .1791     |           |
| Max  | .1372     | .1791     | .0886     |
| Min  | .0886     | .0886     | .0886     |
| Avg  | .1107     | .1188     | .0886     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 201 / 11 KV PIMPRI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     |           | .2715     | .2772     | .2772     |           | .2572     |
| 2    | .1715     |           | .2896     | .2896     | .2926     | .2572     | .2743     |
| 3    | .2229     |           | .3326     | .3403     | .3258     | .2743     | .3086     |
| 4    | .3086     |           | .3547     | .3881     | .3734     | .2915     | .3086     |
| 5    | .4287     |           | .4715     | .4715     | .4904     | .3086     | .4287     |
| 6    | .583      |           | .547      | .5093     | .5847     | .3429     | .4458     |
| 7    | .4287     |           | .4904     | .4715     | .4715     | .4115     | .462      |
| 8    | .3772     | .3658     | .3584     | .3961     |           | .3258     | .3439     |
| 9    | .4115     | .3326     | .3018     | .3142     |           | .2743     | .3258     |
| 10   | .2572     | .2926     | .2801     | .3142     |           | .2743     | .2987     |
| 11   | .2572     | .2772     | .2801     | .2987     |           | .2743     | .2987     |
| 12   | .2401     | .2772     | .2801     | .2801     |           | .2572     | .2801     |
| 13   | .2572     | .2772     | .2926     | .2987     |           | .2572     | .2801     |
| 14   | .2572     | .2772     | .2957     | .2801     |           | .2743     | .2987     |
| 15   | .2772     | .2957     | .2987     | .2987     |           | .2572     | .2987     |
| 16   | .2772     | .2957     | .2957     | .2987     |           | .2572     | .2957     |
| 17   | .2772     |           |           |           |           | .2572     | .2987     |
| 18   | .2743     |           |           |           |           | .2915     | .3292     |
| 19   | .3734     |           |           |           |           | .2915     |           |
| 20   |           |           |           |           |           | .3086     |           |
| 21   |           |           |           |           |           | .3086     |           |
| 22   |           |           |           |           |           | .3086     |           |
| 23   |           |           |           |           |           | .2743     |           |
| 24   |           |           | .2772     | .2987     | .2743     |           |           |
| Max  | .583      | .3658     | .547      | .5093     | .5847     | .4115     | .462      |
| Min  | .1372     | .2772     | .2715     | .2772     | .2743     | .2572     | .2572     |
| Avg  | .3062     | .2990     | .3363     | .3427     | .3862     | .2899     | .3241     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 202 / 11 KV SATKHEDA AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4934     | .4268     | .4268     |
| 2    | .4572     | .4534     | .4534     |
| 3    | .5335     | .4401     | .4401     |
| 4    | .5335     | .4268     | .4268     |
| 5    | .6401     | .6173     | .6344     |
| 6    | .5868     | .6516     | .6173     |
| 7    | 1.0974    | .6859     | .8686     |
| 8    | 1.1317    | .7545     | .9412     |
| 23   |           | .4287     |           |
| 24   | .5639     |           |           |
| Max  | 1.1317    | .7545     | .9412     |
| Min  | .4572     | .4268     | .4268     |
| Avg  | .6708     | .5428     | .6011     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 203 / 11 KV GARKHEDA INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9945     |           | .5835     | .1898     | .6791     | .4115     | .6516     |
| 2    | .7716     |           | .5286     | .3457     | .6075     | .4115     | .6001     |
| 3    | .8916     |           | .6892     | .4261     | .6843     | .4801     | .6097     |
| 4    | 1.0974    |           | .7514     | .4486     | .5426     | .5144     | .4877     |
| 5    | 1.2346    |           | .6843     | .5985     | .6217     | .4801     | .5639     |
| 6    | 1.5242    |           | .6118     | .8309     | .6962     | .5487     | .6097     |
| 7    | 1.3889    |           | .4264     | .669      | .3704     | .7545     | .6859     |
| 8    | 1.9433    | 1.3957    | 1.2574    | 1.1317    |           | .823      | .6935     |
| 9    | 1.848     | 1.4712    | 1.1812    | 1.1694    |           | 1.2955    | .7282     |
| 10   | 1.848     | 1.5466    | 1.1431    | 1.094     |           | 1.3717    | .823      |
| 11   | 1.6632    | 1.5089    | 1.1812    | 1.1317    |           | 1.3336    | .9145     |
| 12   | 1.829     | 1.4712    | 1.1317    | 1.1203    |           | 1.3146    | .9335     |
| 13   |           | 1.5089    | 1.1317    | 1.1694    |           | 1.2765    | .8962     |
| 14   | 1.2955    | 1.4712    | .9431     | 1.2071    |           | 1.1831    | .8779     |
| 15   | 1.3717    | 1.5466    | 1.2826    | 1.2826    |           | 1.1488    | .9145     |
| 16   | 1.3717    | 1.5089    | 1.3203    | 1.2193    |           | 1.1831    | .9709     |
| 17   | 1.3717    |           |           |           |           | 1.0974    | 1.0829    |
| 18   | 1.3336    |           |           |           |           | 1.2193    | 1.0829    |
| 19   | .8688     |           |           |           |           | 1.086     |           |
| 20   |           |           |           |           |           | .9774     |           |
| 21   |           |           |           |           |           | .6859     |           |
| 22   |           |           |           |           |           | .6344     |           |
| 23   |           |           |           |           |           | .6001     |           |
| 24   | .8688     |           | .6698     |           | .7722     |           |           |
| Max  | 1.9433    | 1.5466    | 1.3203    | 1.2826    | .7722     | 1.3717    | 1.0829    |
| Min  | .7716     | 1.3957    | .4264     | .1898     | .3704     | .4115     | .4877     |
| Avg  | 1.3430    | 1.4921    | .9128     | .8771     | .6218     | .9057     | .7848     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 205 / 11 KV MUSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3334     |           | .3206     | .3168     | .2981     | .4268     | .4115     |
| 2    | .4001     |           | .3392     | .3316     | .3378     | .3963     | .4115     |
| 3    | .4001     |           | .3791     | .3529     | .3772     | .3658     | .381      |
| 4    | .4877     |           | .3969     | .3937     | .4158     | .3963     | .4115     |
| 5    | .5335     |           | .4692     | .4725     | .4711     | .3734     | .4268     |
| 6    | .5639     |           | .5981     | .6017     | .5823     | .4001     | .442      |
| 7    | .5335     |           | .5072     | .4316     | .4513     | .4268     | .506      |
| 8    | .6249     | .3547     | .3547     | .3174     |           | .4534     | .4778     |
| 9    | .3772     | .3734     | .3734     | .2587     |           | .2229     | .3696     |
| 10   | .2401     | .7827     | .4633     | .4344     |           | .2401     | .3292     |
| 11   | .2401     | .7526     | .4755     | .4694     |           | .2229     | .2896     |
| 12   | .2058     | .6241     | .5268     | .5201     |           | .2229     | .2926     |
| 13   | .2058     | .5647     | .4816     | .4458     |           | .2058     | .2926     |
| 14   | .2058     | .4755     | .4515     | .4458     |           | .2058     | .2743     |
| 15   | .2353     | .4458     | .4515     | .4344     |           | .2229     | .2743     |
| 16   | .2353     | .4755     | .4515     | .4344     |           | .2058     | .2743     |
| 17   | .2353     |           |           |           |           | .2229     | .2926     |
| 18   | .2534     |           |           |           |           | .2401     | .2926     |
| 19   | .3982     |           |           |           |           | .2915     |           |
| 20   |           |           |           |           |           | .3086     |           |
| 21   |           |           |           |           |           | .3944     |           |
| 22   |           |           |           |           |           | .3944     |           |
| 23   |           |           |           |           |           | .4287     |           |
| 24   | .2401     |           | .3197     | .3148     | .2993     |           |           |
| Max  | .6249     | .7827     | .5981     | .6017     | .5823     | .4534     | .506      |
| Min  | .2058     | .3547     | .3197     | .2587     | .2981     | .2058     | .2743     |
| Avg  | .3475     | .5388     | .4329     | .4104     | .4041     | .3160     | .3583     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 206 / 11 KV BHOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6097     |           | .6084     | .6084     | .6066     | .7316     | .5487     |
| 2    | .6554     |           | .6648     | .6668     | .6595     | .7621     | .6001     |
| 3    | .7164     |           | .6993     | .7035     | .7218     | .7926     | .6344     |
| 4    | .8573     |           | .7906     | .7882     | .7938     | .7316     | .703      |
| 5    | .9259     |           | .8597     | .8668     | .8962     | .6706     | .8916     |
| 6    | .9602     |           | .9307     | .913      | .9679     | .8916     | 1.0631    |
| 7    | 1.0364    |           | .8944     | .8402     | .8944     | .8916     | .9556     |
| 8    | 1.0669    | .8501     | .8589     | .8871     |           | .8916     | .9892     |
| 9    | .8688     | .8871     | .8871     | .7842     |           | .7545     | .7316     |
| 10   | .6516     | 1.0277    | 1.0277    | 1.1469    |           | .6516     | .7468     |
| 11   | .5487     | 1.1603    | 1.1142    | 1.1142    |           | .5487     | .6878     |
| 12   |           | 1.2431    | 1.1203    | 1.065     |           | .5716     | .6878     |
| 13   |           | 1.1271    | 1.0402    | 1.065     |           | .5716     | .6335     |
| 14   | .6097     | 1.0774    | .9922     | .9831     |           | .5716     | .6516     |
| 15   | .5716     | 1.0898    | 1.0402    | .9602     |           | .5144     | .695      |
| 16   | .5658     | 1.0774    | 1.0814    | .9831     |           | .5144     | .695      |
| 17   | .6036     |           |           |           |           | .5716     | .6878     |
| 18   | .6036     |           |           |           |           | .7049     | .6878     |
| 19   | .9335     |           |           |           |           | .7545     |           |
| 20   |           |           |           |           |           | .7545     |           |
| 21   |           |           |           |           |           | .7888     |           |
| 22   |           |           |           |           |           | .6344     |           |
| 23   |           |           |           |           |           | .6001     |           |
| 24   | .7164     |           | .6097     | .6084     | .6078     |           |           |
| Max  | 1.0669    | 1.2431    | 1.1203    | 1.1469    | .9679     | .8916     | 1.0631    |
| Min  | .5487     | .8501     | .6084     | .6084     | .6066     | .5144     | .5487     |
| Avg  | .7501     | 1.06      | .8953     | .8814     | .7685     | .6900     | .7384     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124079 / 33/11 KV BHOD

Feeder No / Name : 207 / 11 KV SATKHEDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4287     | .6475     | .6342     | .6435     | .5487     | .6001     |
| 2    | .5144     | .6944     | .7204     | .6831     | .583      | .6344     |
| 3    | .7202     | .8703     | .8462     | .7658     | .6516     | .7202     |
| 4    | .9945     | 1.1305    | 1.134     | 1.0697    | .6859     | .9945     |
| 5    | 1.3717    | 1.4667    | 1.4697    | 1.4262    | .7202     | 1.3203    |
| 6    | 1.6461    | 1.6254    | 1.6327    | 1.6352    | .8916     | 1.3717    |
| 7    | 1.0974    | 1.3324    | 1.3486    | 1.3649    | 1.0288    | 1.2254    |
| 8    | .8916     |           |           |           | 1.0974    | 1.1827    |
| 9    | .8916     |           |           |           | .8916     | 1.1088    |
| 10   | .823      |           |           |           | .7545     | 1.0082    |
| 11   | .823      |           |           |           | .8059     | .8962     |
| 12   | .7202     |           |           |           | .823      | .7468     |
| 13   | .6344     |           |           |           | .6344     | .7095     |
| 14   | .4801     |           |           |           | .4801     | .6036     |
| 15   |           |           |           |           | .463      | .6036     |
| 16   |           |           |           |           | .6344     |           |
| 17   |           |           |           |           | .7545     | .9054     |
| 18   |           |           |           |           | .8059     | 1.094     |
| 19   |           |           |           |           | .7716     |           |
| 20   |           |           |           |           | .8059     |           |
| 21   |           |           |           |           | .823      |           |
| 22   |           |           |           |           | .8059     |           |
| 23   |           |           |           |           | .6344     |           |
| 24   | .5487     | .6635     | .6635     | .6648     |           |           |
| Max  | 1.6461    | 1.6254    | 1.6327    | 1.6352    | 1.0974    | 1.3717    |
| Min  | .4287     | .6475     | .6342     | .6435     | .463      | .6001     |
| Avg  | .8390     | 1.0538    | 1.0562    | 1.0317    | .7433     | .9250     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124135 / 33/11KV APDRP DHARANGAON S/S

Feeder No / Name : 201 / 11KV GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .362      | .3429     | .2829     | .2477     | .2641     | .362      | .2858     |
| 2    | .3239     | .362      | .2641     | .2667     | .2452     | .3429     | .2667     |
| 3    | .2858     | .3429     | .2829     | .2477     | .2263     | .2858     | .2477     |
| 4    | .2667     | .3239     | .2829     | .2286     | .2452     | .2667     | .3048     |
| 5    | .3048     | .2858     | .3018     | .2286     | .2829     | .2858     | .3239     |
| 6    | .3048     | .2667     | .3206     | .2477     | .3395     | .2858     | .3429     |
| 7    | .3239     | .2858     | .3018     | .2858     | .3206     | .3048     | .3048     |
| 8    | .3048     | .3048     | .2829     | .2477     | .2641     | .3239     | .2858     |
| 9    | .3048     | .2858     | .2667     | .2286     | .2096     | .2858     | .2858     |
| 10   | .2858     | .3048     | .2858     | .2641     | .2286     | .2858     | .2667     |
| 11   | .3048     | .3048     | .2858     | .2452     | .2667     | .2667     | .3048     |
| 12   | .2667     | .2477     | .2667     | .2452     | .3239     | .2667     | .2477     |
| 13   | .2477     | .3239     | .2667     | .2641     | .381      | .2667     | .2667     |
| 14   | .2667     | .2667     | .2858     | .2829     | .2667     | .2858     | .3239     |
| 15   | .2858     | .3048     | .3048     | .3206     | .2858     | .3048     | .2858     |
| 16   | .2667     | .2858     | .2477     | .3018     | .2858     | .2858     | .2858     |
| 17   | .2858     | .2858     | .2667     | .2829     | .2667     | .2858     | .3048     |
| 18   | .3048     | .2477     | .3048     | .3018     | .2858     | .3239     | .2667     |
| 19   | .3239     | .2829     | .362      | .2829     | .3048     | .3239     | .3048     |
| 20   | .3429     | .3018     | .381      | .3395     | .3429     | .362      | .2858     |
| 21   | .3429     | .3395     | .3048     | .3395     | .3584     | .3429     | .3239     |
| 22   | .3048     | .3395     | .3429     | .3206     | .381      | .3048     | .3048     |
| 23   | .362      | .3018     | .3048     | .3018     | .3772     | .2858     | .362      |
| 24   | .381      | .3429     | .2829     | .2667     | .362      | .3584     | .2667     |
| Max  | .381      | .362      | .381      | .3395     | .381      | .362      | .362      |
| Min  | .2477     | .2477     | .2477     | .2286     | .2096     | .2667     | .2477     |
| Avg  | .3064     | .3034     | .2950     | .2745     | .2965     | .3039     | .2937     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 124135 / 33/11KV APDRP DHARANGAON S/S

Feeder No / Name : 202 / 11KV CHINTAMAN MOURYA SHEDDABLE URBAN  
 NAGAR Feeder KV- 11 /  
 OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9134     | .8954     | .9492     | .7164     | .9492     | .9671     | .9671     |
| 2    | .8596     | .9134     | .9313     | .7701     | .9313     | .9313     | .985      |
| 3    | .8059     | .8596     | .9671     | .8059     | .9313     | .9134     | .9492     |
| 4    | .8417     | .8775     | .8954     | .8775     | .9134     | .8954     | .9671     |
| 5    | .8775     | .9313     | .8596     | .8954     | .8954     | 1.5939    | .9134     |
| 6    | .9671     | .985      | .8775     | 1.0387    | .9313     | 2.3461    | .9313     |
| 7    | .9313     | .8954     | .8954     | .9313     | .8954     | 2.2028    | .7343     |
| 8    | .8059     | .7343     | .8059     | 1.0387    | .8417     | 1.9342    | .7701     |
| 9    | .8417     | .8059     | .7701     | .9492     | .8238     | 1.9163    | .7343     |
| 10   | .8954     | .788      | .8596     | .9313     | .8596     |           | .8059     |
| 11   | .9134     | .8238     | .8775     | .8775     | .9492     |           | .8417     |
| 12   | .8775     | .8954     | .8954     | .8954     | .8417     |           | .7701     |
| 13   | .8954     | .8954     | .8417     | .9134     | .9134     | 1.6118    | .7701     |
| 14   | .8596     | .8775     | .9134     | .8954     | .9671     | 1.0387    | .8059     |
| 15   |           | .8954     | .8775     | .9134     |           | .788      | .8417     |
| 16   | .8417     | .8954     | .7522     | .9313     | 1.0387    | .7701     | .8238     |
| 17   | .8417     | .8775     | .7164     | .8775     | .9671     | .7343     | .8059     |
| 18   | .8954     | .8596     | .788      | .8596     | .9134     | .7701     | .8775     |
| 19   | .985      | 1.0208    | .8596     | .985      | 1.0208    | .9134     | .8954     |
| 20   | 1.0387    | 1.0208    | .8954     | 1.0387    | 1.0745    | .9671     | .9492     |
| 21   | 1.0029    | 1.0208    | .9492     | 1.0208    | 1.0387    | 1.0029    | .985      |
| 22   | .9671     | 1.0387    | .7701     | 1.0387    | 1.1104    | 1.0745    | .8596     |
| 23   | .9492     | 1.0029    | .8059     | 1.0029    | 1.0745    | 1.0387    | .7164     |
| 24   | .9492     | .9134     | .9671     | .6805     | 1.0029    | 1.0029    | .985      |
| Max  | 1.0387    | 1.0387    | .9671     | 1.0387    | 1.1104    | 2.3461    | .985      |
| Min  | .8059     | .7343     | .7164     | .6805     | .8238     | .7343     | .7164     |
| Avg  | .9024     | .9051     | .8634     | .9119     | .9515     | 1.2101    | .8619     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125112 / 33/11 KV SONWAD

Feeder No / Name : 201 / 11 KV ANJANVIHIRE AG  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .1753     | .8326     | .8865     | 1.0562    | .7888     | .1267     | .1578     |
| 8    | .2254     | 1.0867    | 1.0374    | 1.3717    | 1.0288    | .2454     | .1928     |
| 12   | 1.2136    | .1052     | .0953     |           | .1307     | 1.1568    | 1.2136    |
| 16   | 1.2483    | .1097     | .1143     | .1029     | .0732     | 1.0229    | 1.1096    |
| 20   | .2279     | .2743     | .2477     | .2229     | .2172     | .1753     | .2279     |
| 24   | .1227     | .8063     | .9431     | .9808     | .7888     | .1063     | .1029     |
| Max  | 1.2483    | 1.0867    | 1.0374    | 1.3717    | 1.0288    | 1.1568    | 1.2136    |
| Min  | .1227     | .1052     | .0953     | .1029     | .0732     | .1063     | .1029     |
| Avg  | .5355     | .5358     | .5541     | .7469     | .5046     | .4722     | .5008     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125112 / 33/11 KV SONWAD

Feeder No / Name : 202 / 11KV BABHULGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .9709     | 1.094     | 1.0185    |           |           |           |
| 8    |           | 1.6297    | 1.5546    | 1.2955    |           |           |           |
| 12   | 1.8176    |           |           |           | 1.8519    | 1.8861    | 1.3032    |
| 16   | 1.6126    |           |           |           | 1.6804    | 1.5565    | 1.2689    |
| 24   |           | .9709     | 1.1506    | 1.0562    |           |           |           |
| Max  | 1.8176    | 1.6297    | 1.5546    | 1.2955    | 1.8519    | 1.8861    | 1.3032    |
| Min  | 1.6126    | .9709     | 1.094     | 1.0185    | 1.6804    | 1.5565    | 1.2689    |
| Avg  | 1.7151    | 1.1905    | 1.2664    | 1.1234    | 1.7662    | 1.7213    | 1.2861    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125112 / 33/11 KV SONWAD

Feeder No / Name : 203 / 11KV SONWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5975     | .5281     | .5144     | .2858     | .6173     | .4108     |           |
| 8    | .6535     | .6036     |           | .381      | .6344     | .5975     |           |
| 12   |           | .3547     | .1905     |           | .4294     | .4668     | .4715     |
| 16   | .4481     | .3734     | .5716     | .4287     | .462      | .4668     | .415      |
| 20   | .6535     | .6722     |           | .703      | .6908     | .6908     |           |
| 24   | .3734     | .3547     | .3239     | .2477     | .3772     | .4108     |           |
| Max  | .6535     | .6722     | .5716     | .703      | .6908     | .6908     | .4715     |
| Min  | .3734     | .3547     | .1905     | .2477     | .3772     | .4108     | .415      |
| Avg  | .5452     | .4811     | .4001     | .4092     | .5352     | .5073     | .4433     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125112 / 33/11 KV SONWAD

Feeder No / Name : 204 / GANGAPURI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .4163     | .4668     | .4191     | .4001     | .3772     | .3921     |           |
| 8    | .4024     | .3921     | .362      |           | .3772     | .3658     | .362      |
| 12   | .2561     | .2801     | .3048     |           | .2987     | .2715     | .2801     |
| 16   | .2743     | .2801     | .3239     | .2743     | .2926     | .3258     | .3239     |
| 20   | .5601     | .5601     | .5716     | .4801     | .5175     | .5249     | .4481     |
| 24   | .3658     | .3734     | .381      | .381      | .3601     | .3921     | .3921     |
| Max  | .5601     | .5601     | .5716     | .4801     | .5175     | .5249     | .4481     |
| Min  | .2561     | .2801     | .3048     | .2743     | .2926     | .2715     | .2801     |
| Avg  | .3792     | .3921     | .3937     | .3839     | .3706     | .3787     | .3612     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125113 / 33/11 KV CHANDSAR

Feeder No / Name : 202 / 11 KV PATHRAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0747     |           |           |           |           | .0343     | .0686     |
| 2    | .0747     |           |           |           |           | .0343     | .0686     |
| 3    | .0747     |           |           |           |           | .0343     | .0686     |
| 4    | .0934     |           |           |           |           | .0343     | .0857     |
| 5    | .0934     |           |           |           |           | .0343     | .1029     |
| 6    | .1294     |           |           |           |           | .0514     | .12       |
| 7    | .2402     |           |           |           |           | .12       | .1886     |
| 8    | .2054     |           |           |           |           | .1372     | .1886     |
| 10   |           | .2058     | .1372     | .1294     | .1029     |           |           |
| 11   |           | .2058     | .1543     | .1463     | .1543     |           |           |
| 12   |           | .2401     | .1886     | .2033     | .1715     |           |           |
| 13   |           | .2401     | .1715     | .1848     | .1715     |           |           |
| 14   |           | .2058     | .1372     | .1109     | .1372     |           |           |
| 15   |           | .1715     | .1372     | .1109     | .1029     |           |           |
| 16   |           | .1372     | .1372     | .1109     | .12       |           |           |
| 17   |           | .1372     | .1543     | .1109     | .1029     |           |           |
| 23   |           |           |           |           | .0343     | .0514     |           |
| 24   | .0747     |           |           |           |           | .0343     | .0686     |
| Max  | .2402     | .2401     | .1886     | .2033     | .1715     | .1372     | .1886     |
| Min  | .0747     | .1372     | .1372     | .1109     | .0343     | .0343     | .0686     |
| Avg  | .1178     | .1929     | .1522     | .1384     | .1219     | .0566     | .1067     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

DHARANGAON DIVISION.[231] BU 5614

Substation No/ Name :- 125113 / 33/11 KV CHANDSAR

Feeder No / Name : 204 / 11 KV CHORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0974    | .1029     | .12       | .1372     | .1848     | 1.0288    | 1.046     |
| 2    | 1.0242    | .12       | .1372     | .1372     | .1848     | 1.0974    | 1.0802    |
| 3    | 1.0608    | .1372     | .1715     | .1715     | .2218     | 1.1317    | 1.0631    |
| 4    | 1.0974    | .1372     | .2058     | .2229     | .2772     | 1.166     | 1.0974    |
| 5    | 1.0974    | .1543     | .1715     | .3086     | .3511     | 1.166     | 1.1317    |
| 6    | 1.2437    | .1029     | .1886     | .2572     | .499      | 1.166     | 1.166     |
| 7    | 1.3535    | .12       | .0686     | .12       | .4251     | 1.1317    | 1.2689    |
| 8    | 1.2254    | .2401     | .0686     | .1029     | .3511     | 1.166     | 1.2689    |
| 9    | .0686     | .2229     | .0343     | .1097     | .2743     | .2401     | .1715     |
| 10   | .0514     | 1.3375    | 1.4575    | 1.6095    | 1.3717    | .2058     | .0514     |
| 11   | .0514     | 1.5775    | 1.4918    |           | 1.4746    | .1715     | .0514     |
| 12   | .1543     | 1.4746    | 1.5604    | 1.6644    | 1.749     | .1543     | .2058     |
| 13   | .1372     | 1.4746    | 1.5947    | 1.6278    | 1.6461    | .1715     | .1886     |
| 14   | .1372     | 1.5775    | 1.5947    | 1.6644    | 1.6804    | .1715     | .1715     |
| 15   | .1543     | 1.6461    | 1.6118    | 1.6461    | 1.6804    |           |           |
| 16   | .1886     | 1.6804    | 1.4403    | 1.6827    | 1.6461    |           |           |
| 17   | .2058     | 1.6461    | 1.3717    | 1.6461    | 1.5432    | .1029     |           |
| 18   | .2229     | .2058     | .1029     | .3142     | .2058     | .0857     | .2572     |
| 19   | .1029     | .2401     |           | .4251     | .3086     | .3429     | .4115     |
| 20   | .1715     | .0686     |           | .2957     | .3086     | .3086     | .3772     |
| 21   | .2058     | .1029     | .2915     | .2033     | .2401     | .2572     | .2743     |
| 22   | .1715     | .2058     | .2401     | .2033     | .2058     | .2229     | .2058     |
| 23   | .1543     | .1715     |           | .1848     | 1.0288    | 1.0631    |           |
| 24   | 1.1888    | .1372     | .1372     | .1715     | .1663     | 1.0288    | 1.0631    |
| Max  | 1.3535    | 1.6804    | 1.6118    | 1.6827    | 1.749     | 1.166     | 1.2689    |
| Min  | .0514     | .0686     | .0343     | .1029     | .1663     | .0857     | .0514     |
| Avg  | .5236     | .6202     | .6696     | .6481     | .7510     | .6173     | .6276     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 201 / 11 KV Pimpalkhotha SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1576    | 1.4003    |           |           |           |           |           |
| 2    | 1.2696    | 1.4003    |           |           |           |           |           |
| 3    | 1.307     | 1.4377    |           |           |           |           |           |
| 4    | 1.475     | 1.643     |           |           |           |           |           |
| 5    | 1.7177    | 1.8298    |           |           |           |           |           |
| 6    | 1.9605    | 1.8671    |           |           | 1.5546    |           |           |
| 7    | 1.9605    | 2.0538    | 2.1365    |           |           | .1696     | .0373     |
| 8    | 1.6655    | 1.8671    |           |           |           |           |           |
| 9    | 1.5043    |           |           | 1.1949    |           |           | .0187     |
| 10   | 1.1584    |           |           |           |           |           |           |
| 11   |           |           |           |           |           |           | .2427     |
| 14   |           |           |           |           |           |           | .2427     |
| 15   |           |           |           | .7842     |           |           |           |
| 17   |           |           |           | 1.2136    |           |           | .2054     |
| 18   |           |           |           | 1.1576    |           |           |           |
| 19   | 1.5592    |           | 1.2483    | 1.4937    |           |           | .0373     |
| 20   |           |           |           | 1.7177    |           |           |           |
| 21   |           |           |           | 1.643     |           |           |           |
| 22   | 1.382     |           |           | 1.5123    |           |           |           |
| 24   | 1.2136    | 1.3611    | 1.1462    |           | .0335     |           |           |
| Max  | 1.9605    | 2.0538    | 2.1365    | 1.7177    | 1.5546    | .1696     | .2427     |
| Min  | 1.1576    | 1.3611    | 1.1462    | .7842     | .0335     | .1696     | .0187     |
| Avg  | 1.4870    | 1.6511    | 1.5103    | 1.3396    | .7941     | .1696     | .1307     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 202 / 11 KV Nagduli SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5228     | .2801     |           |           |           |           |
| 2    | .5228     | .3361     |           |           |           |           |
| 3    |           | .4108     |           |           | .2427     |           |
| 4    | .5041     | .4668     |           |           |           |           |
| 5    | .499      | .5601     |           |           |           |           |
| 6    | .499      | .6161     |           |           | .3696     |           |
| 7    | .8402     | .5788     | .3881     |           |           | .7701     |
| 8    |           | .4668     |           |           |           |           |
| 9    |           |           |           | .1867     |           | .2241     |
| 11   |           |           |           | .7468     |           | .2241     |
| 12   |           |           |           |           | .7133     |           |
| 13   |           |           |           | .7392     |           |           |
| 14   |           |           |           |           | .7602     | .2587     |
| 15   |           |           |           | .6722     |           |           |
| 17   |           |           |           | .6908     |           | .2241     |
| 18   |           |           |           | .1867     |           |           |
| 19   | .2614     |           |           | .2241     |           | .2614     |
| 20   |           |           |           | .2987     |           |           |
| 21   |           |           |           | .3361     |           |           |
| 22   | .2801     |           |           | .2614     |           |           |
| 24   | .4668     | .2743     | .2218     |           | .2427     | .3841     |
| Max  | .8402     | .6161     | .3881     | .7468     | .7602     | .7701     |
| Min  | .2614     | .2743     | .2218     | .1867     | .2427     | .2241     |
| Avg  | .4885     | .4433     | .3050     | .4343     | .4657     | .3352     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 203 / 11 KV Erandol SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1694    |           |           |           |           |           |           |
| 2    | 1.1576    | 1.3443    |           |           |           |           |           |
| 3    | 1.1389    | 1.307     |           |           | 1.1273    |           |           |
| 4    | 1.1576    | 1.2936    |           |           |           |           |           |
| 5    | 1.1458    | 1.3169    |           |           |           |           |           |
| 6    | 1.2012    | 1.39      |           |           | 1.1888    |           |           |
| 7    | 1.251     | 1.3491    | 1.3253    |           |           | 1.1736    | 1.1283    |
| 8    |           | 1.0456    |           |           |           |           |           |
| 9    |           |           |           | .9335     |           |           |           |
| 10   |           |           |           |           | .9389     |           |           |
| 11   |           |           |           | .9709     |           |           |           |
| 13   |           |           |           | .9709     |           |           |           |
| 14   |           |           |           |           | .9955     |           |           |
| 15   |           |           |           | 1.0829    |           |           |           |
| 17   |           |           |           | 1.0269    |           |           |           |
| 18   |           |           |           | 1.0829    |           |           |           |
| 19   | 1.1462    |           | 1.0682    | 1.1389    |           |           |           |
| 20   |           |           |           | 1.2696    |           |           |           |
| 21   |           |           |           | 1.3817    |           |           |           |
| 22   | 1.2934    |           |           | 1.3817    |           |           |           |
| 23   |           | 1.3443    |           |           |           |           |           |
| 24   | 1.2323    | 1.2757    | 1.2357    |           | 1.2887    |           | 1.3169    |
| Max  | 1.2934    | 1.39      | 1.3253    | 1.3817    | 1.2887    | 1.1736    | 1.3169    |
| Min  | 1.1389    | 1.0456    | 1.0682    | .9335     | .9389     | 1.1736    | 1.1283    |
| Avg  | 1.1893    | 1.2963    | 1.2097    | 1.1240    | 1.1078    | 1.1736    | 1.2226    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 204 / 11 KV Kasoda FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6161     | .6161     |           |           |           |           |           |
| 2    | .5975     | .6348     |           |           |           |           |           |
| 3    | .5975     | .6722     |           |           | .5041     |           |           |
| 4    | .7095     | .7095     |           |           |           |           |           |
| 5    | .7095     | .7282     |           |           |           |           |           |
| 6    | .7842     | .7468     |           |           | .8962     |           |           |
| 7    | .924      | .6908     | .7865     |           |           | .6874     |           |
| 8    | .8145     | .6161     |           |           |           |           |           |
| 9    | .5175     |           |           | .5041     |           |           |           |
| 10   | .4805     |           |           |           | .6722     |           |           |
| 11   | .8145     |           |           | .8402     |           |           |           |
| 12   |           |           |           |           | .7602     |           |           |
| 13   |           |           |           | .6838     |           |           |           |
| 14   |           |           |           |           | .7602     |           | .4251     |
| 15   |           |           |           | .6722     |           |           |           |
| 17   |           |           |           | .7468     |           |           | .4066     |
| 18   |           |           |           | .3921     |           |           |           |
| 19   | .6767     |           | .6104     | .6535     |           |           | .6219     |
| 20   |           |           |           | .7468     |           |           |           |
| 21   |           |           |           | .7095     |           |           |           |
| 22   | .567      |           |           | .6161     |           |           |           |
| 24   | .6348     | .5792     | .5175     |           | .503      |           | .5792     |
| Max  | .924      | .7468     | .7865     | .8402     | .8962     | .6874     | .6219     |
| Min  | .4805     | .5792     | .5175     | .3921     | .503      | .6874     | .4066     |
| Avg  | .6746     | .6660     | .6381     | .6565     | .6827     | .6874     | .5082     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 205 / 11 KV VIKHARAN AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7842     | .8962     |           |           |           |           |           |
| 2    | .8402     | .8962     |           |           |           |           |           |
| 3    | .8402     | .8775     |           |           | 1.2437    |           |           |
| 4    | .8962     | .7842     |           |           |           |           |           |
| 5    | 1.0082    | .7468     |           |           |           |           |           |
| 6    | 1.1203    | .7468     |           |           | 1.2803    |           |           |
| 7    | 1.0534    | .7842     | 1.7353    |           |           | 1.2378    | .7701     |
| 8    | .6584     | .7095     |           |           |           |           |           |
| 9    | .6401     |           |           | .5601     |           |           | .6036     |
| 10   | 1.3466    |           |           |           | .3561     |           |           |
| 11   |           |           |           | .5975     |           |           | 1.5223    |
| 12   |           |           |           |           | .2987     |           |           |
| 13   |           |           |           | .6161     |           |           |           |
| 14   |           |           |           |           | .6767     |           | 1.5043    |
| 15   |           |           |           | .6535     |           |           |           |
| 17   |           |           |           | .5975     |           |           | .6767     |
| 18   |           |           |           | .5975     |           |           |           |
| 19   | .7783     |           | .7122     | .7468     |           |           |           |
| 20   |           |           |           | .8215     |           |           |           |
| 21   |           |           |           | .8962     |           |           |           |
| 22   | .8779     |           |           | .8775     |           |           |           |
| 24   | .8775     | .8688     | 1.1641    |           | 1.1643    |           | .7316     |
| Max  | 1.3466    | .8962     | 1.7353    | .8962     | 1.2803    | 1.2378    | 1.5223    |
| Min  | .6401     | .7095     | .7122     | .5601     | .2987     | 1.2378    | .6036     |
| Avg  | .9017     | .8122     | 1.2039    | .6964     | .8366     | 1.2378    | .9681     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4481     | .3734     |           |           |           |           |           |
| 2    | .4108     | .3734     |           |           |           |           |           |
| 3    | .3921     | .3921     |           |           | .4066     |           |           |
| 4    | .3921     | .3921     |           |           |           |           |           |
| 5    | .3734     | .4108     |           |           |           |           |           |
| 6    | .3734     | .4294     |           |           | .3696     |           |           |
| 7    | .4294     | .4108     | .5304     |           |           | .3521     | .567      |
| 8    |           | .3361     |           |           |           | .4359     |           |
| 9    |           |           |           | .4108     |           |           | .5175     |
| 10   |           |           |           |           | .407      |           |           |
| 11   |           |           |           | .3734     |           |           | .5853     |
| 12   |           |           |           |           | .1867     |           |           |
| 13   |           |           |           | .4668     |           |           | .5487     |
| 14   |           |           |           |           | .3696     |           |           |
| 15   |           |           |           | .4108     |           |           |           |
| 17   |           |           |           | .5415     |           |           |           |
| 18   |           |           |           | .4294     |           |           |           |
| 19   | .3696     |           | .3561     | .5415     |           |           |           |
| 20   |           |           |           | .5228     |           |           |           |
| 21   |           |           |           | .5228     |           |           |           |
| 22   | .3696     |           |           | .5228     |           |           |           |
| 24   | .4668     | .3696     | .5853     |           | .462      |           | .7059     |
| Max  | .4668     | .4294     | .5853     | .5415     | .462      | .4359     | .7059     |
| Min  | .3696     | .3361     | .3561     | .3734     | .1867     | .3521     | .5175     |
| Avg  | .4025     | .3875     | .4906     | .4743     | .3669     | .394      | .5849     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 207 / 11 KV Gandhipura SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0829    | 1.1576    |           |           |           |           |           |
| 2    | 1.0829    | 1.1576    |           |           |           |           |           |
| 3    | 1.1576    | 1.1203    |           |           | 1.1643    |           |           |
| 4    | 1.1458    | 1.1458    |           |           |           |           |           |
| 5    | 1.2197    | 1.1458    |           |           |           |           |           |
| 6    | 1.3121    | 1.1643    |           |           | 1.3717    |           |           |
| 7    | 1.2136    | .9795     | 1.2178    |           |           | 1.1869    | 1.1999    |
| 8    |           | .8589     |           |           |           |           |           |
| 9    |           | 1.1104    |           | .9709     |           |           | 1.0498    |
| 10   |           |           |           |           | 1.0174    |           |           |
| 11   |           |           |           | 1.1203    |           |           | 1.0745    |
| 12   |           |           |           |           | 1.0745    |           |           |
| 13   |           |           |           | 1.1949    |           |           |           |
| 14   |           |           |           |           | 1.5402    |           | 1.1641    |
| 15   |           |           |           | 1.2323    |           |           |           |
| 17   |           |           |           | 1.2136    |           |           |           |
| 18   |           |           |           | 1.1576    |           |           |           |
| 19   | 1.2178    |           |           | 1.1389    |           |           |           |
| 20   |           |           |           | 1.2323    |           |           |           |
| 21   |           |           | .9496     | 1.307     |           |           |           |
| 22   | 1.1163    |           |           | 1.307     |           |           |           |
| 24   | 1.1763    |           | 1.0974    |           | 1.1736    |           | 1.2178    |
| Max  | 1.3121    | 1.1643    | 1.2178    | 1.307     | 1.5402    | 1.1869    | 1.2178    |
| Min  | 1.0829    | .8589     | .9496     | .9709     | 1.0174    | 1.1869    | 1.0498    |
| Avg  | 1.1725    | 1.0934    | 1.0883    | 1.1875    | 1.2236    | 1.1869    | 1.1412    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 208 / 11 KV VARKHEDI AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 10-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    |           |           | .037      |           |
| 6    |           |           | .0554     |           |
| 7    |           | .128      |           | .0671     |
| 10   | .056      |           |           |           |
| 17   |           |           |           | .1109     |
| 24   |           | .0554     | .0671     |           |
| Max  | .056      | .128      | .0671     | .1109     |
| Min  | .056      | .0554     | .037      | .0671     |
| Avg  | .056      | .0917     | .0532     | .089      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 209 / 11 KV Filter Plant NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0373     | .056      |           |           |           |           |           |
| 2    | .0373     | .056      |           |           |           |           |           |
| 3    | .0373     | .056      |           |           | .037      |           |           |
| 4    | .037      | .056      |           |           |           |           |           |
| 5    | .0554     | .0739     |           |           |           |           |           |
| 6    | .0554     | .0739     |           |           | .0554     |           |           |
| 7    | .0924     | .0747     | .0554     |           |           | .056      | .037      |
| 8    | .0934     | .0739     |           |           |           |           |           |
| 9    | .0934     |           |           | .0554     |           |           | .0934     |
| 10   | .0934     |           |           |           | .0671     |           |           |
| 11   |           |           |           | .0554     |           |           | .0934     |
| 12   |           |           |           |           | .0747     |           |           |
| 13   |           |           |           | .037      |           |           |           |
| 14   |           |           |           |           | .0747     |           | .0747     |
| 15   |           |           |           | .037      |           |           |           |
| 17   |           |           |           | .037      |           |           | .0747     |
| 18   |           |           |           | .0373     |           |           |           |
| 19   | .0934     |           | .0566     | .0373     |           |           | .0747     |
| 20   |           |           |           | .0373     |           |           |           |
| 21   |           |           |           | .056      |           |           |           |
| 22   | .056      |           |           | .0554     |           |           |           |
| 24   | .0554     | .056      | .037      |           | .0503     |           | .0373     |
| Max  | .0934     | .0747     | .0566     | .056      | .0747     | .056      | .0934     |
| Min  | .037      | .056      | .037      | .037      | .037      | .056      | .037      |
| Avg  | .0644     | .0640     | .0497     | .0445     | .0599     | .056      | .0693     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 210 / 11 KV TOLI FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           | .3856     |
| 10   |           | .5256     |           |
| 19   | .2374     |           |           |
| Max  | .2374     | .5256     | .3856     |
| Min  | .2374     | .5256     | .3856     |
| Avg  | .2374     | .5256     | .3856     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 211 / 11 KV Mahajan Nagar SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1494     | .1494     |           |           |           |           |           |
| 2    | .1307     | .1494     |           |           |           |           |           |
| 3    | .1307     | .1494     |           |           | .0924     |           |           |
| 4    | .1494     | .1494     |           |           |           |           |           |
| 5    | .168      | .1867     |           |           |           |           |           |
| 6    | .1867     | .1867     |           |           | .128      |           |           |
| 7    | .168      | .1663     | .1478     |           |           | .1357     | .1478     |
| 8    |           | .1307     |           |           |           |           |           |
| 9    |           |           |           | .1494     |           |           |           |
| 10   |           |           |           |           | .1698     |           |           |
| 11   |           |           |           | .168      |           |           |           |
| 13   |           |           |           | .2033     |           |           |           |
| 17   |           |           |           | .2241     |           |           |           |
| 18   |           |           |           | .2241     |           |           |           |
| 19   |           |           |           | .1494     |           |           |           |
| 20   |           |           |           | .1494     |           |           |           |
| 21   |           |           | .1696     | .112      |           |           |           |
| 22   |           |           |           | .112      |           |           |           |
| 24   | .1867     |           | .1478     |           | .1341     |           | .1478     |
| Max  | .1867     | .1867     | .1696     | .2241     | .1698     | .1357     | .1478     |
| Min  | .1307     | .1307     | .1478     | .112      | .0924     | .1357     | .1478     |
| Avg  | .1587     | .1585     | .1551     | .1657     | .1311     | .1357     | .1478     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124064 / 33/11 KV ERANDOL SUB-STATION

Feeder No / Name : 401 / 33 KV Erandol Incomer  
Feeder KV- 33 / INCOMING

| DATE | 12-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4024     |
| Max  | .4024     |
| Min  | .4024     |
| Avg  | .4024     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 201 / 11 KV Kasoda Town Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1568    | 1.1317    | 1.1568    | 1.166     | 1.1744    | 1.2127    | 1.2445    |
| 2    | 1.1218    | 1.0974    | 1.1218    | 1.1317    | 1.1568    | 1.2127    | 1.1919    |
| 3    | 1.1218    | 1.0974    | 1.134     | 1.1317    | 1.1568    | 1.1946    | 1.1744    |
| 4    | 1.1269    | 1.1317    | 1.1393    | 1.1488    | 1.1789    | 1.2308    | 1.1616    |
| 5    | 1.2483    | 1.2517    | 1.2309    | 1.2517    | 1.283     | 1.3575    | 1.2309    |
| 6    | 1.595     | 1.6632    | 1.5775    | 1.6289    | 1.595     | 1.6651    | 1.5604    |
| 7    | 1.543     | 1.5604    | 1.6632    | 1.4575    | 1.4575    | 1.5565    | 1.491     |
| 8    | 1.3321    | 1.3717    | 1.2689    | 1.3032    | 1.3176    | 1.3575    | 1.335     |
| 9    | 1.3937    | 1.4175    | 1.262     | 1.4083    | 1.3289    | 1.3203    | 1.382     |
| 10   | 1.448     | 1.3998    | 1.262     | 1.4266    | 1.4266    | 1.3032    | 1.4815    |
| 11   | 1.3937    | 1.258     | 1.2803    | 1.3352    | 1.3496    | 1.3203    | 1.3321    |
| 12   | 1.267     | 1.134     | 1.2803    | 1.2403    | 1.3256    | 1.2346    | 1.4377    |
| 13   | 1.267     | 1.2071    | 1.2934    | 1.262     | 1.1871    | 1.2517    | 1.2715    |
| 14   | 1.1946    | 1.1706    | 1.2803    | 1.1871    | 1.2226    | 1.166     |           |
| 15   | 1.2127    | 1.1888    | 1.2437    | 1.134     | 1.1517    | 1.166     | 1.2269    |
| 16   | 1.1946    | 1.1517    | 1.1831    | 1.2071    | 1.2048    | 1.166     | 1.2174    |
| 17   | 1.2517    | 1.2094    | 1.2517    | 1.2094    | 1.2489    | 1.2269    | 1.2517    |
| 18   | 1.286     | 1.3146    | 1.3203    | 1.2795    | 1.3394    | 1.1517    | 1.2517    |
| 19   | 1.4575    | 1.5083    | 1.5089    | 1.4737    | 1.5565    | 1.543     | 1.5261    |
| 20   | 1.5089    | 1.5424    | 1.5604    | 1.543     | 1.6108    | 1.56      | 1.5775    |
| 21   | 1.3375    | 1.4022    | 1.4232    | 1.3847    | 1.3937    | 1.4548    | 1.4403    |
| 22   | 1.3717    | 1.3496    | 1.3889    | 1.3672    | 1.4118    | 1.4198    | 1.406     |
| 23   | 1.2346    | 1.262     | 1.2517    | 1.2971    | 1.3213    | 1.3321    | 1.3032    |
| 24   | 1.2094    | 1.166     | 1.1919    | 1.2174    | 1.2269    | 1.267     | 1.2971    |
| Max  | 1.595     | 1.6632    | 1.6632    | 1.6289    | 1.6108    | 1.6651    | 1.5775    |
| Min  | 1.1218    | 1.0974    | 1.1218    | 1.1317    | 1.1517    | 1.1517    | 1.1616    |
| Avg  | 1.3031    | 1.2911    | 1.3031    | 1.2997    | 1.3178    | 1.3196    | 1.3388    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 202 / 11 KV V S S K -Pure AG- FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1562     |           |           |           |           | .2534     | .2721     |
| 2    | .3005     |           |           |           |           | .2715     | .2214     |
| 3    | .3005     |           |           |           |           | .2715     | .2056     |
| 4    | .2968     |           |           |           |           | .2896     | .2056     |
| 5    | .2968     |           |           |           |           | .3258     | .1875     |
| 6    | .3086     |           |           |           |           | .5068     | .25       |
| 7    | .5864     |           |           |           |           | .5611     | .4999     |
| 8    | .6249     |           |           |           |           |           | .578      |
| 10   |           | .5853     | .503      | .5316     | .5487     |           |           |
| 11   |           | .7973     | .5533     | .5493     | .567      |           |           |
| 12   |           | .7377     | .6687     | .5426     | .6767     |           |           |
| 13   |           | .823      | .5895     | .6219     | .6722     |           |           |
| 14   |           | .7087     | .5201     | .4908     | .4961     |           |           |
| 15   |           | .6173     | .5304     | .4607     | .5316     |           |           |
| 16   |           | .6344     | .5316     | .5493     | .463      |           |           |
| 17   |           | .6562     | .6001     | .5304     | .4887     |           |           |
| 23   |           |           |           |           | .2715     | .2155     |           |
| 24   | .2968     |           |           |           |           | .2715     | .2241     |
| Max  | .6249     | .823      | .6687     | .6219     | .6767     | .5611     | .578      |
| Min  | .1562     | .5853     | .503      | .4607     | .2715     | .2155     | .1875     |
| Avg  | .3519     | .6950     | .5621     | .5346     | .5239     | .3296     | .2938     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 203 / 11 KV FARKANDE pure Agr. FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2401     | .2753     | .2915     | .2652     |           |           |
| 2    |           | .2401     | .2429     | .2915     | .2652     |           |           |
| 3    |           | .2401     | .2105     | .2915     | .2652     |           |           |
| 4    |           | .2572     | .2105     | .2743     | .2622     |           |           |
| 5    |           | .2401     | .2241     | .2743     | .2753     |           |           |
| 6    |           | .3258     | .3163     | .3258     | .3749     |           |           |
| 7    |           | .6344     | .6636     | .823      | .6944     |           |           |
| 8    |           | .6859     | .4062     | 1.3032    | .7253     |           |           |
| 10   | .4706     |           |           |           |           | .4458     | 4.481     |
| 11   | .6335     |           |           |           |           | .6001     | .6588     |
| 12   | .6154     |           |           |           |           | .6859     | .6219     |
| 13   | .7059     |           |           |           |           |           | .5729     |
| 14   | .543      |           |           |           |           | .6516     | .5487     |
| 15   | .543      |           |           |           |           | .6001     | .4075     |
| 16   | .6878     |           |           |           |           | .5658     | .4801     |
| 17   | .8059     |           |           |           |           | .5155     | .6001     |
| 23   | .1886     | .2753     | .2743     |           |           |           |           |
| 24   |           | .2401     | .2753     | .2915     | .2515     |           |           |
| Max  | .8059     | .6859     | .6636     | 1.3032    | .7253     | .6859     | 4.481     |
| Min  | .1886     | .2401     | .2105     | .2743     | .2515     | .4458     | .4075     |
| Avg  | .5771     | .3379     | .3099     | .4630     | .3755     | .5807     | 1.0464    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 204 / 11 KV Talai -Pure Ag-  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0617     |           |           |           |           | .1448     | .0625     |
| 2    | .064      |           |           |           |           | .1629     | .0625     |
| 3    | .064      |           |           |           |           | .1448     | .0625     |
| 4    | .064      |           |           |           |           | .1629     | .0772     |
| 5    | .0633     |           |           |           |           | .181      | .0617     |
| 6    | .1134     |           |           |           |           | .181      | .1235     |
| 7    | .1875     |           |           |           |           | .181      | .2315     |
| 8    | .2372     |           |           |           |           | .2172     | .2031     |
| 10   |           | .128      | .1463     | .1829     | .1646     |           |           |
| 11   |           | .2378     | .2103     | .2012     | .1772     |           |           |
| 12   |           | .2195     | .2195     | .2012     | .1829     |           |           |
| 13   |           | .1646     | .2715     | .1867     | .2012     |           |           |
| 14   |           | .1595     | .2303     | .1772     | .1463     |           |           |
| 15   |           | .1646     | .1829     | .1646     | .1829     |           |           |
| 16   |           | .2195     | .1715     | .168      | .1753     |           |           |
| 17   |           | .2507     |           | .1372     |           |           |           |
| 23   |           |           |           |           | .1086     |           | .0686     |
| 24   | .0617     |           |           |           |           | .1448     | .0633     |
| Max  | .2372     | .2507     | .2715     | .2012     | .2012     | .2172     | .2315     |
| Min  | .0617     | .128      | .1463     | .1372     | .1086     | .1448     | .0617     |
| Avg  | .1019     | .1930     | .2046     | .1774     | .1674     | .1689     | .1016     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 206 / 11 KV Express Feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 09-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 16   | .2195     |
| Max  | .2195     |
| Min  | .2195     |
| Avg  | .2195     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 207 / 11 KV Nipane Pure Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1029     | .1781     | .2229     | .1829     |           |           |
| 2    |           | .1029     | .1781     | .2229     | .1677     |           |           |
| 3    |           | .1029     | .1781     | .2401     | .1677     |           |           |
| 4    |           | .1029     | .1781     | .2058     | .1829     |           |           |
| 5    |           | .1029     | .1966     | .2229     | .1981     |           |           |
| 6    |           | .2401     | .3048     | .3601     | .3353     |           |           |
| 7    |           | .5316     | .5182     | .8402     |           |           |           |
| 8    |           | .7545     | .7164     | 1.046     |           |           |           |
| 10   | .5792     |           |           |           |           | .583      | .567      |
| 11   | .9231     |           |           |           |           | .7888     | .7865     |
| 12   | .905      |           |           |           |           | .8573     | .7362     |
| 13   | .7059     |           |           |           |           | .7888     | .724      |
| 14   | .5973     |           |           |           |           | .6516     | .6836     |
| 15   | .5973     |           |           |           |           | .3772     |           |
| 16   | .5611     |           |           |           |           | .6001     | .4115     |
| 17   | .703      |           |           |           |           | .7099     | .5658     |
| 23   | .1029     | .2321     | .2229     | .2155     |           |           |           |
| 24   |           | .12       | .213      | .2229     | .2006     |           |           |
| Max  | .9231     | .7545     | .7164     | 1.046     | .3353     | .8573     | .7865     |
| Min  | .1029     | .1029     | .1781     | .2058     | .1677     | .3772     | .4115     |
| Avg  | .6305     | .2393     | .2884     | .3799     | .2050     | .6696     | .6392     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 208 / 11 KV Ginning Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1052     | .1029     | .1052     | .1029     | .1227     | .0543     | .1227     |
| 2    | .1052     | .1029     | .1052     | .1029     | .1052     | .0543     | .1402     |
| 3    | .0876     | .1029     |           | .1029     | .1227     | .0543     | .1227     |
| 4    | .0876     | .1029     | .1052     | .1029     | .1214     | .0724     | .1214     |
| 5    | .104      | .1029     | .1052     | .0857     | .1214     | .0543     | .104      |
| 6    | .104      | .1029     | .1214     | .0857     | .104      | .0526     | .1052     |
| 7    | .104      | .1029     | .104      | .0857     | .1214     | .1267     | .1052     |
| 8    | .0876     | .1029     | .1052     | .0857     | .104      | .1086     | .1402     |
| 9    | .1086     | .0914     | .0886     | .0886     | .0914     | .0857     | .1402     |
| 10   | .1448     | .0732     | .1063     | .1063     | .112      | .0857     | .124      |
| 11   | .1448     | .0914     | .1097     | .1097     | .1097     | .0857     | .128      |
| 12   | .1267     | .1063     | .128      | .0914     | .1086     | .0857     | .128      |
| 13   | .0905     | .128      | .1463     | .0732     | .1086     | .0857     | .1307     |
| 14   | .1086     |           | .1463     |           | .0724     | .12       | .1267     |
| 15   | .1086     | .124      | .124      | .0709     | .0914     | .1886     | .1595     |
| 16   | .0905     |           | .1372     | .1417     | .1227     | .12       | .1886     |
| 17   | .0857     |           | .12       | .1402     | .1267     | .1402     | .12       |
| 18   | .12       |           | .0857     | .1402     | .1448     | .1227     | .1715     |
| 19   | .0857     | .1227     | .1029     | .1578     | .0543     | .124      | .12       |
| 20   | .12       | .1227     | .12       | .1402     | .0526     | .1402     | .12       |
| 21   | .12       | .124      | .12       | .1417     | .1448     | .1052     | .1029     |
| 22   | .12       | .1227     | .1029     | .1417     | .1448     | .1052     | .1029     |
| 23   | .12       | .1063     | .12       | .1402     | .1086     | .1402     | .1029     |
| 24   | .0876     | .1029     | .1227     | .12       | .1578     | .1086     | .1402     |
| Max  | .1448     | .128      | .1463     | .1578     | .1578     | .1886     | .1886     |
| Min  | .0857     | .0732     | .0857     | .0709     | .0526     | .0526     | .1029     |
| Avg  | .1070     | .1069     | .1144     | .1112     | .1114     | .1009     | .1278     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 209 / 11 KV Adgaon -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3506     | .3429     | .3506     | .3601     | .3641     | .3801     | .3506     |
| 2    | .3506     | .3429     | .3506     | .3601     | .3506     | .362      | .3506     |
| 3    | .3681     | .3601     | .3681     | .3772     | .3506     |           | .3506     |
| 4    | .4031     | .3944     | .4031     | .3944     | .3988     | .4344     | .3467     |
| 5    | .5721     | .5487     | .5548     | .5144     | .5375     | .5792     | .5201     |
| 6    | .7455     | .7716     | .703      | .7373     | .703      | .7421     | .5028     |
| 7    | .5721     | .5487     | .5316     | .5144     | .4854     | .5792     | .3155     |
| 8    | .3856     | .3944     | .3814     | .3944     | .3988     | .3982     | .2454     |
| 9    | .4163     | .3109     |           | .3189     | .3772     | .3258     |           |
| 10   | .3258     | .2926     |           | .3109     | .3174     | .2915     | .2303     |
| 11   | .3077     | .2658     | .2926     | .2926     | .2743     | .2743     | .0732     |
| 12   | .3077     | .2926     |           | .2926     | .2195     | .2915     | .0732     |
| 13   | .2896     | .3109     |           | .2926     |           | .2915     | .4207     |
| 14   | .3258     | .2835     |           | .3012     | .3366     | .2915     | .3506     |
| 15   | .3258     | .3189     | .3012     | .3012     | .3658     | .3086     | .3506     |
| 16   | .3258     | .3109     | .3258     | .3292     | .3544     | .3086     | .3601     |
| 17   | .3086     | .3086     | .3258     | .3121     | .362      | .3121     | .3601     |
| 18   | .3601     | .3681     | .3944     | .3506     | .362      | .3506     | .3429     |
| 19   | .4801     | .4681     | .4801     | .4854     | .4887     |           | .4973     |
| 20   | .5144     | .5028     | .5144     | .5434     | .5611     | .5258     | .5316     |
| 21   | .4458     | .4508     | .4458     | .4557     | .4525     | .4557     | .4458     |
| 22   | .3944     | .4207     | .4115     | .4207     | .4344     | .3856     | .3944     |
| 23   | .3601     | .3681     | .3601     | .3681     | .3982     | .3506     | .3601     |
| 24   | .3506     | .3429     | .3681     | .3601     | .3641     | .3801     | .3506     |
| Max  | .7455     | .7716     | .703      | .7373     | .703      | .7421     | .5316     |
| Min  | .2896     | .2658     | .2926     | .2926     | .2195     | .2743     | .0732     |
| Avg  | .3994     | .3883     | .4138     | .3912     | .4025     | .3918     | .3532     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124065 / 33 KV KASODA

Feeder No / Name : 213 / 11 KV Nipane Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6379     | .6173     | .6089     | .6173     | .5959     | .6154     | .567      |
| 2    | .6268     | .6001     | .6268     | .6173     | .6024     | .6154     | .5792     |
| 3    | .6447     | .6173     | .6447     | .6344     | .5959     | .6335     | .6154     |
| 4    | .7087     | .6859     | .7343     | .6687     | .691      | .6836     | .6626     |
| 5    | 1.0277    | 1.0288    | 1.0745    | .9602     | .9745     | .964      | .8859     |
| 6    | 1.5043    | 1.4575    | 1.5074    | 1.4403    | 1.4022    | 1.4043    | 1.2757    |
| 7    | 1.2536    | 1.2003    | 1.1568    | .703      | 1.1641    | 1.1919    | 1.0277    |
| 8    | .9593     | .8916     | .8505     | .4801     |           |           | .788      |
| 9    | .7602     | .7682     | .811      | .6584     | .691      | .3944     | .8596     |
| 10   | .6878     | .6584     | .6024     | .5304     | .6584     | .3601     | .6767     |
| 11   | .6516     | .5487     | .5853     | .5304     | .5304     | .5316     | .4755     |
| 12   | .6335     | .5304     | .5316     | .5121     | .5304     | .4973     |           |
| 13   | .5068     | .5121     |           | .5121     | .5304     | .5487     | .4755     |
| 14   | .5249     | .443      | .443      | .5121     | .5121     | .4801     | .4607     |
| 15   | .5249     | .4961     | .4755     | .5304     | .5487     | .4801     | .443      |
| 16   | .5611     | .5316     | .4801     | .567      | .5083     | .4801     | .4973     |
| 17   | .6001     | .5611     | .5487     | .5434     | .5249     | .5316     | .4801     |
| 18   | .5658     | .6379     | .6173     | .5935     | .6878     | .6024     | .5316     |
| 19   | .9259     | .9465     | .8573     | .929      |           | .8589     | .8402     |
| 20   | .9774     | .9991     | .9774     | .9991     | 1.0317    | .9745     | .9602     |
| 21   | .7716     | .7796     | .7545     | .7796     | .724      | .7783     | .7545     |
| 22   | .6687     | .6805     | .703      | .691      | .6516     | .6733     | .6687     |
| 23   | .6001     | .6626     | .6516     | .6626     | .6335     | .6024     | .5658     |
| 24   | .6556     | .6001     | .6447     | .6173     | .6135     | .6335     | .5731     |
| Max  | 1.5043    | 1.4575    | 1.5074    | 1.4403    | 1.4022    | 1.4043    | 1.2757    |
| Min  | .5068     | .443      | .443      | .4801     | .5083     | .3601     | .443      |
| Avg  | .7491     | .7273     | .7342     | .6787     | .7001     | .6755     | .6810     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124100 / 33/11KV UTRAN SUBSTATION

Feeder No / Name : 202 / 11 KV BAMHNE AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .9259     | 1.1389    | 1.2536    | 1.3443    |           |
| 2    |           |           | .8916     | 1.1576    | 1.2178    | 1.363     |           |
| 3    |           |           | .8573     | 1.1576    | 1.1999    | 1.3817    |           |
| 4    |           |           | .8916     | 1.1763    | 1.182     | 1.363     |           |
| 5    |           |           | .9259     | 1.1949    | 1.1641    | 1.3817    |           |
| 6    |           |           | .9431     | 1.2696    | ***       | 1.4003    |           |
| 7    |           |           | 1.3375    | 1.1389    | 1.5402    | 1.6804    |           |
| 8    |           |           | 1.286     | 1.7924    | 1.6297    | 1.7177    |           |
| 10   | 1.7194    | 1.7318    |           |           |           |           | 1.7318    |
| 11   | 2.009     | 2.0405    |           |           |           |           | 1.9719    |
| 12   | 2.0995    | 1.8519    |           |           |           |           | 2.0405    |
| 13   | 2.1719    | 1.7318    |           |           |           |           | 2.0405    |
| 14   | 1.828     | 1.7147    |           |           |           |           | 2.0405    |
| 15   | 1.7375    | 1.5089    |           |           |           |           | 1.989     |
| 16   | 1.6651    | 1.5775    |           |           |           |           | 1.9033    |
| 17   | 1.6289    | 1.5432    |           |           |           |           | 1.8519    |
| 23   |           | 1.1317    | 1.1949    | 1.3032    | 1.475     |           |           |
| 24   |           |           | 1.1145    | 1.1949    | 1.286     | 1.3957    |           |
| Max  | 2.1719    | 2.0405    | 1.3375    | 1.7924    | 12.9481   | 1.7177    | 2.0405    |
| Min  | 1.6289    | 1.1317    | .8573     | 1.1389    | 1.1641    | 1.3443    | 1.7318    |
| Avg  | 1.8574    | 1.648     | 1.0368    | 1.2524    | 2.4896    | 1.4475    | 1.9462    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124100 / 33/11KV UTRAN SUBSTATION

Feeder No / Name : 203 / 11 KV TALAI AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8775     | .8145     |           |           |           |           | 1.4842    |
| 2    | .8954     | .8145     |           |           |           |           | 1.4118    |
| 3    | .8596     | .8688     |           |           |           |           | 1.3575    |
| 4    | .8775     | .8145     |           |           |           |           | 1.448     |
| 5    | .8954     | .8507     |           |           |           |           | 1.5023    |
| 6    | .8596     | .905      |           |           |           |           | 1.5565    |
| 7    | 1.0924    | 1.1765    |           |           |           |           | 1.7918    |
| 8    | 1.0745    | 1.2308    |           |           |           |           | 1.8823    |
| 10   |           |           | 1.4937    | 1.7551    | 2.0538    | 2.0633    | 1.7318    |
| 11   |           |           | 1.6617    | 2.167     | 2.2592    | 2.3167    |           |
| 12   |           |           | 1.9605    | 2.0595    | 2.2032    | 2.3529    |           |
| 13   |           |           | 1.9231    | 2.0774    | 2.2405    | 2.2986    |           |
| 14   |           |           | 1.9418    | 2.0237    | 2.2592    | 2.1357    |           |
| 15   |           |           | 1.9231    | 2.0058    | 2.2779    | 2.2443    |           |
| 16   |           |           | 1.7177    | 2.0774    | 2.2405    | 2.0814    |           |
| 17   |           |           | 1.8671    | 2.0595    |           | 2.0814    |           |
| 23   | .8145     |           |           |           |           | 1.4842    | 1.4232    |
| 24   | .8954     | .8869     |           |           |           |           | 1.5746    |
| Max  | 1.0924    | 1.2308    | 1.9605    | 2.167     | 2.2779    | 2.3529    | 1.8823    |
| Min  | .8145     | .8145     | 1.4937    | 1.7551    | 2.0538    | 1.4842    | 1.3575    |
| Avg  | .9142     | .9291     | 1.8111    | 2.0282    | 2.2192    | 2.1176    | 1.5604    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 201 / 11KV RINGANGAON AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3517     |           |           |           |           | .3048     | .2521     |
| 3    | .3652     |           |           |           |           | .3048     | .2724     |
| 5    | .4115     |           |           |           |           | .3048     | .3024     |
| 6    | .439      |           |           |           |           | .3353     | .3024     |
| 7    | .6203     |           |           |           |           | .5182     | .4668     |
| 8    | .6676     |           |           |           |           | .5792     | .5258     |
| 10   |           | .5121     | .4572     | .6706     | .4755     |           |           |
| 11   |           | .884      | .6811     |           | .6859     |           |           |
| 12   |           | .884      | .6401     | .7042     | .7468     |           |           |
| 13   |           | .8993     | .6268     |           | .7468     |           |           |
| 14   |           | .823      | .583      | .7099     | .6554     |           |           |
| 15   |           | .6401     | .5697     |           | .5944     |           |           |
| 16   |           | .6401     | .5449     | .6706     | .5639     |           |           |
| 17   |           | .6249     | .5573     |           | .6554     |           |           |
| 23   |           |           |           |           | .2896     | .217      |           |
| 24   | .3652     |           |           |           |           | .2896     | .2401     |
| Max  | .6676     | .8993     | .6811     | .7099     | .7468     | .5792     | .5258     |
| Min  | .3517     | .5121     | .4572     | .6706     | .2896     | .217      | .2401     |
| Avg  | .4601     | .7384     | .5825     | .6888     | .6015     | .3567     | .3374     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 202 / 11KV RINGANGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6722     |           | .7316     |           |           | .7316     | .7324     |
| 3    | .8162     | .7082     | .9755     | .7082     | 1.0242    | .7926     | .8402     |
| 5    | 1.2803    | 1.0364    | 1.0974    | 1.0486    |           | 1.1584    | 1.2193    |
| 6    | 1.6347    | 1.5356    | 1.5364    | 1.5108    | 1.8982    | 1.4998    | 1.4754    |
| 7    | 1.2574    | 1.0852    | 1.2437    | 1.1706    | 1.5154    | 1.2681    | 1.226     |
| 8    | .8291     | .8642     | .9023     | .8402     | 1.1523    | .9633     | .9362     |
| 9    | .7082     | .8413     | .8042     |           | .8291     |           | .7682     |
| 10   | .7082     | .6828     | .7082     | .9122     | .756      | .7682     | .6962     |
| 11   | .6481     | .6706     | .6361     |           | .6584     | .6615     | .6602     |
| 12   | .5881     | .6219     | .6481     | .8162     | .6462     |           | .6121     |
| 13   | .5881     | .6219     | .6241     |           | .6097     | .6481     | .6241     |
| 14   | .6121     | .6097     | .6602     | .8065     | .6584     | .6722     | .6481     |
| 15   | .6241     | .6462     | .6722     |           | .695      | .6842     | .6842     |
| 16   |           | .6828     | .7082     | .8962     | .7072     | .7202     | .7322     |
| 17   |           | .695      | .7322     |           | .756      | .5817     | .7562     |
| 18   | .7922     | .7682     | .8042     | 1.1012    | .8291     | .8162     | .8402     |
| 19   | .9602     | .9998     | 1.0242    |           | 1.2437    | 1.1403    | 1.0442    |
| 20   | 1.0974    | 1.1949    | 1.134     | 1.4327    | 1.1218    | 1.1584    | 1.1706    |
| 21   | .8642     | .9389     | .8882     |           | .9267     | .9122     | .9002     |
| 22   | .8162     | .8413     | .8042     | 1.1174    | .8291     | .8042     | .8402     |
| 23   |           | .756      |           | .9878     | .7438     | .7082     |           |
| 24   | .6962     | .7082     | .7316     | .7082     | 1.0059    | .7316     | .7087     |
| Max  | 1.6347    | 1.5356    | 1.5364    | 1.5108    | 1.8982    | 1.4998    | 1.4754    |
| Min  | .5881     | .6097     | .6241     | .7082     | .6097     | .5817     | .6121     |
| Avg  | .8523     | .8338     | .8603     | 1.0041    | .9303     | .8711     | .8626     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 203 / 11KV Kharchi Agr  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .3963     |           |           |           |           |
| 3    |           | .1928     | .3963     | .2789     | .4268     |           |           |
| 5    |           | .2477     | .4572     | .4734     |           |           |           |
| 6    |           | .3429     | .5182     | .5681     | .4999     |           |           |
| 7    |           | .6268     | .7011     | .6802     | .7253     |           |           |
| 8    |           | .5921     | .7164     | .7331     | .6836     |           |           |
| 10   | .4344     |           |           |           |           | .5944     | .3877     |
| 11   | .4954     |           |           |           |           | .8482     | .3877     |
| 12   | .4801     |           |           |           |           | .6241     | .4458     |
| 13   | .4458     |           |           |           |           | .6859     | .4201     |
| 14   | .423      |           |           |           |           | .6097     | .3144     |
| 15   | .4081     |           |           |           |           | .5569     | .2953     |
| 16   |           |           |           |           |           | .6097     | .3144     |
| 17   |           |           |           |           |           | .5817     | .4344     |
| 23   |           | .3201     |           | .3353     |           |           |           |
| 24   |           | .1715     | .3506     | .2789     | .3506     |           |           |
| Max  | .4954     | .6268     | .7164     | .7331     | .7253     | .8482     | .4458     |
| Min  | .4081     | .1715     | .3506     | .2789     | .3506     | .5569     | .2953     |
| Avg  | .4478     | .3563     | .5052     | .4783     | .5372     | .6388     | .3750     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 204 / 11 KV KADHOLI AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .945      |           |           |           |           |
| 3    |           | 1.0002    | .945      | .8669     | .8935     |           |           |
| 5    |           | 1.0288    | .945      | .8269     |           |           |           |
| 6    |           | 1.0574    | .9602     | .8669     | .9431     |           |           |
| 7    |           | 1.1288    | .9297     | .8535     | 1.1126    |           |           |
| 8    |           | 1.186     | 1.0974    | 1.0002    | .9602     |           |           |
| 10   | 1.1574    |           |           |           |           | 1.1248    | .9869     |
| 11   | 1.2574    |           |           |           |           | 1.2809    | 1.0431    |
| 12   | 1.3146    |           |           |           |           | 1.3603    | 1.0574    |
| 13   | 1.1469    |           |           |           |           | 1.2967    | 1.3575    |
| 14   | 1.2431    |           |           |           |           | 1.2498    | 1.1717    |
| 15   | 1.2574    |           |           |           |           | 1.1888    | 1.0802    |
| 16   |           |           |           |           |           | 1.0822    | 1.0936    |
| 17   |           |           |           |           |           | 1.1092    | 1.0669    |
| 23   |           | .9755     |           | .9191     |           |           |           |
| 24   |           | .9859     | .945      | .9069     | .9191     |           |           |
| Max  | 1.3146    | 1.186     | 1.0974    | 1.0002    | 1.1126    | 1.3603    | 1.3575    |
| Min  | 1.1469    | .9755     | .9297     | .8269     | .8935     | 1.0822    | .9869     |
| Avg  | 1.2295    | 1.0518    | .9668     | .8915     | .9657     | 1.2116    | 1.1072    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 205 / 11 KV RINGANGAON IND  
FEEDER Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1875     |           | .2801     |           |           | .2241     | .1562     |
| 3    | .2031     | .1991     | .2614     | .181      | .156      | .2241     | .1718     |
| 5    | .2187     | .2353     | .2614     | .1629     |           | .2614     | .1718     |
| 6    | .2343     | .2715     | .2614     | .1629     | .1543     | .2427     | .1875     |
| 7    | .2187     | .2715     | .2054     | .1629     | .1387     | .2427     | .1718     |
| 8    | .2031     | .2715     | .3361     | .2715     | .1543     | .2987     | .1875     |
| 9    | .362      | .3547     | .4163     |           | .2614     |           | .2534     |
| 10   | .4344     | .7842     | .6335     | .463      | .4108     |           | .1991     |
| 11   | .543      | .8589     | .2896     |           | .3734     | .4531     | .2715     |
| 12   | .5611     | .6348     | .5792     | .4973     | .4294     | .4374     | .3258     |
| 13   | .5068     | .5601     | .3982     |           | .3734     | .3795     | .362      |
| 14   | .5611     | .6535     | .4344     | .4382     | .6161     | .3125     | .3982     |
| 15   | .4525     | .5975     | .4706     |           |           | .2031     | .3439     |
| 16   |           | .5788     | .3982     |           |           | .2812     | .2715     |
| 17   |           | .2054     | .3982     |           |           | .25       | .3439     |
| 18   | .4706     | .168      | .3439     | .2915     |           | .1067     | .2715     |
| 19   | .4706     | .2801     | .2534     |           | .3174     | .2187     | .2534     |
| 20   | .2896     | .3547     | .181      | .2279     | .2987     | .1562     | .2172     |
| 21   | .2534     | .3174     | .181      |           | .2801     | .1524     | .181      |
| 22   | .2534     | .2801     | .1629     | .1734     | .2614     | .1677     | .1991     |
| 23   |           | .2987     |           | .1928     | .2054     | .1718     |           |
| 24   | .2031     | .2534     | .2801     | .1991     | .2058     | .2241     | .1562     |
| Max  | .5611     | .8589     | .6335     | .4973     | .6161     | .4531     | .3982     |
| Min  | .1875     | .168      | .1629     | .1629     | .1387     | .1067     | .1562     |
| Avg  | .3488     | .4014     | .3346     | .2634     | .2898     | .2504     | .2426     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

DHARANGAON DIVISION[593]

ERANDOL S/DIVN.[235] BU 0235

Substation No/ Name :- 124102 / 33/11KV RINGANGAON

Feeder No / Name : 206 / 11 Kv Ravanje Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3443    |           |           |           |           | 1.1431    | 1.3123    |
| 3    | 1.2651    |           |           |           |           | 1.1431    | 1.3123    |
| 5    | 1.1873    |           |           |           |           | 1.0974    | 1.3283    |
| 6    | 1.1561    |           |           |           |           | 1.1431    | 1.3443    |
| 7    | 1.5203    |           |           |           |           | 1.4022    | 1.6194    |
| 8    | 1.6356    |           |           |           |           | 1.4937    | 1.6518    |
| 10   |           | 1.387     | 1.5242    | 1.4003    |           |           |           |
| 11   |           | 1.6918    | 1.1469    |           |           |           |           |
| 12   |           | 1.768     | 1.8362    | 1.5203    |           |           |           |
| 13   |           | 1.7528    |           |           |           |           |           |
| 14   |           | 1.6461    |           |           |           |           |           |
| 15   |           | 1.5546    | 1.5718    |           |           |           |           |
| 16   |           | 1.4784    | 1.5432    |           |           |           |           |
| 17   |           | 1.5394    | 1.5003    |           |           |           |           |
| 19   |           |           |           |           | 1.3565    |           |           |
| 20   |           |           |           |           | 1.3108    |           |           |
| 21   |           |           |           |           | 1.326     |           |           |
| 22   |           |           |           |           | 1.326     |           |           |
| 23   |           |           |           |           | .9877     | 1.2483    |           |
| 24   | 1.3603    |           |           |           |           | 1.1736    | 1.3283    |
| Max  | 1.6356    | 1.768     | 1.8362    | 1.5203    | 1.3565    | 1.4937    | 1.6518    |
| Min  | 1.1561    | 1.387     | 1.1469    | 1.4003    | .9877     | 1.0974    | 1.3123    |
| Avg  | 1.3527    | 1.6023    | 1.5204    | 1.4603    | 1.2614    | 1.2306    | 1.4138    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 201 / 11 KV Lokmat  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .1257     | .3688     | .4508     |           |           |           |           |
| 7    |           |           |           | .4755     | .4024     | .4024     |           |
| 8    | .192      |           |           |           |           |           |           |
| 11   |           | .6584     | .6859     |           | .724      | .6859     |           |
| 12   | .6584     |           |           | .724      |           |           |           |
| 13   |           | .6036     |           |           |           |           |           |
| 14   |           | .6219     |           |           |           |           |           |
| 15   | .5853     |           | .8383     | .724      |           | .724      |           |
| 17   |           |           | .7545     |           |           | .5658     |           |
| 18   | .6859     | .6287     |           |           |           |           |           |
| 19   |           |           |           |           | .5658     |           |           |
| 20   | .5601     |           |           | .547      |           |           |           |
| 22   |           |           |           |           |           |           | .2526     |
| 24   | .3125     | .679      | .679      | .5487     | .5487     | .6219     | .6036     |
| Max  | .6859     | .679      | .8383     | .724      | .724      | .724      | .6036     |
| Min  | .1257     | .3688     | .4508     | .4755     | .4024     | .4024     | .2526     |
| Avg  | .4457     | .5934     | .6817     | .6038     | .5602     | .6        | .4281     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 202 / 11 KV Rasoi  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.307     | 1.3491    | 1.475     |           |           |           |           |
| 7    |           |           |           | 1.7528    | 1.6766    | 1.9433    |           |
| 8    | .7455     |           |           |           |           |           |           |
| 11   |           | 2.4768    | 2.7054    |           | 2.7816    | 2.5911    |           |
| 12   | 2.6292    |           |           | 4.382     |           |           |           |
| 13   |           | 2.0576    |           |           |           |           |           |
| 14   |           | 2.2862    |           |           |           |           |           |
| 15   | 2.5149    |           | 2.4006    | 2.5149    |           | 2.7816    |           |
| 17   |           |           | 2.6783    |           |           | 2.5339    |           |
| 18   | 2.0957    | 2.21      |           |           |           |           |           |
| 19   |           |           |           |           | 2.4387    |           |           |
| 20   | 1.3817    |           |           | 1.6409    |           |           |           |
| 22   |           |           |           |           |           |           | .8505     |
| 23   |           |           |           |           | 1.9433    |           |           |
| 24   | .9259     | 1.6975    | 1.7918    | 1.8099    | 1.7909    | 1.9433    | 1.8671    |
| Max  | 2.6292    | 2.4768    | 2.7054    | 4.382     | 2.7816    | 2.7816    | 1.8671    |
| Min  | .7455     | 1.3491    | 1.475     | 1.6409    | 1.6766    | 1.9433    | .8505     |
| Avg  | 1.6571    | 2.0129    | 2.2102    | 2.4201    | 2.1262    | 2.3586    | 1.3588    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 203 / 11 KV Trident  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .3401     | .985      | 1.0808    |           |           |           |           |
| 7    |           |           |           | 1.5242    | 1.4098    | 1.2574    |           |
| 8    | .5127     |           |           |           |           |           |           |
| 11   |           | 1.8099    | 1.7909    |           | 1.9814    | 1.9052    |           |
| 12   | 1.4289    |           |           | 1.9052    |           |           |           |
| 13   |           | 1.829     |           |           |           |           |           |
| 14   |           | 1.5242    |           |           |           |           |           |
| 15   | 1.3717    |           | 1.9052    | 1.9052    |           | 2.0957    |           |
| 17   |           |           | 1.8099    |           |           | 1.6956    |           |
| 18   | 1.2955    | 1.5432    |           |           |           |           |           |
| 19   |           |           |           |           | 1.6032    |           |           |
| 20   | .9511     |           |           | .547      |           |           |           |
| 22   |           |           |           |           |           |           | .4338     |
| 24   | .3081     | 1.0317    | 1.2197    | 1.2384    | 1.2955    | 1.4861    | 1.4861    |
| Max  | 1.4289    | 1.829     | 1.9052    | 1.9052    | 1.9814    | 2.0957    | 1.4861    |
| Min  | .3081     | .985      | 1.0808    | .547      | 1.2955    | 1.2574    | .4338     |
| Avg  | .8869     | 1.4538    | 1.5613    | 1.424     | 1.5725    | 1.688     | .9600     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 204 / 11 KV Bharat Forge  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.0669    | 1.358     | 1.448     |           |           |           |           |
| 7    |           |           |           | 1.6804    | 1.7737    | 1.8671    |           |
| 8    | 1.3769    |           |           |           |           |           |           |
| 11   |           | 1.7551    | 1.829     |           | 2.1338    | 1.6004    |           |
| 12   | 1.419     |           |           | 1.7147    |           |           |           |
| 13   |           | 1.363     |           |           |           |           |           |
| 14   |           | 1.419     |           |           |           |           |           |
| 15   | 1.307     |           | 1.5242    | 2.3243    |           | 2.0195    |           |
| 17   |           |           | 1.9044    |           |           | 1.8861    |           |
| 18   | 1.3336    | 1.6078    |           |           |           |           |           |
| 19   |           |           |           |           | 1.7551    |           |           |
| 20   | 1.4098    |           |           | 1.4377    |           |           |           |
| 22   |           |           |           |           |           |           | .0754     |
| 24   | .2507     | 1.3957    | 1.448     | 1.419     | 1.419     | 1.5242    | 1.8671    |
| Max  | 1.419     | 1.7551    | 1.9044    | 2.3243    | 2.1338    | 2.0195    | 1.8671    |
| Min  | .2507     | 1.358     | 1.448     | 1.419     | 1.419     | 1.5242    | .0754     |
| Avg  | 1.1663    | 1.4831    | 1.6307    | 1.7152    | 1.7704    | 1.7795    | .9713     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 205 / 11 KV BHARAT PETROLIUM  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .8368     | 2.6783    | 2.9531    |           |           |           |           |
| 7    |           |           |           | 3.1626    | 3.0864    | 3.0483    |           |
| 8    | 1.2803    |           |           |           |           |           |           |
| 11   |           | 3.2769    | 4.1914    |           | 4.6487    | 3.9628    |           |
| 12   |           |           |           | 4.039     |           |           |           |
| 13   |           | 3.3532    |           |           |           |           |           |
| 14   |           | 3.7151    |           |           |           |           |           |
| 15   | 3.8866    |           | 4.2295    | 4.5344    |           | 4.1533    |           |
| 17   |           |           | 4.2816    |           |           | 3.8676    |           |
| 18   | 3.2388    | 3.5837    |           |           |           |           |           |
| 19   |           |           |           |           | 3.4294    |           |           |
| 20   | 2.6673    |           |           | 2.9613    |           |           |           |
| 22   |           |           |           |           |           |           | .6173     |
| 23   |           |           |           |           | 3.2007    |           |           |
| 24   | .6563     | 2.999     | 3.1626    | 3.4294    | 3.315     | 3.0483    | 3.2388    |
| Max  | 3.8866    | 3.7151    | 4.2816    | 4.5344    | 4.6487    | 4.1533    | 3.2388    |
| Min  | .6563     | 2.6783    | 2.9531    | 2.9613    | 3.0864    | 3.0483    | .6173     |
| Avg  | 2.0944    | 3.2677    | 3.7636    | 3.6253    | 3.5360    | 3.6161    | 1.9281    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 206 / 11 KV Gitanjali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 2.0178    | 2.8166    | 3.1741    |           |           |           |           |
| 7    |           |           |           | 2.8578    | 3.5437    | 3.315     |           |
| 8    | 2.2085    |           |           |           |           |           |           |
| 11   |           | 4.3058    | 4.4963    |           | 4.6106    | 4.5725    |           |
| 12   | 3.9247    |           |           | 4.039     |           |           |           |
| 13   |           | 4.1914    |           |           |           |           |           |
| 14   |           | 4.2295    |           |           |           |           |           |
| 15   | 3.9247    |           | 4.5725    | 4.382     |           | 4.763     |           |
| 17   |           |           | 4.3381    |           |           | 4.6106    |           |
| 18   | 3.8485    | 3.9609    |           |           |           |           |           |
| 19   |           |           |           |           | 4.2061    |           |           |
| 20   | 3.2217    |           |           | 3.3008    |           |           |           |
| 22   |           |           |           |           |           |           | 2.1807    |
| 24   | 2.0157    | 3.1181    | 3.2819    | 3.4294    | 3.3532    |           | 3.658     |
| Max  | 3.9247    | 4.3058    | 4.5725    | 4.382     | 4.6106    | 4.763     | 3.658     |
| Min  | 2.0157    | 2.8166    | 3.1741    | 2.8578    | 3.3532    | 3.315     | 2.1807    |
| Avg  | 3.0231    | 3.7704    | 3.9726    | 3.6018    | 3.9284    | 4.3153    | 2.9194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 207 / 11 KV Supreme Colony  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.3817    | 1.3817    | 1.419     |           |           |           |           |
| 7    |           |           |           | 1.4045    | 1.4045    | 1.6632    |           |
| 8    | 1.3256    |           |           |           |           |           |           |
| 11   |           | .8871     | 1.1088    |           | 1.1458    | 1.2323    |           |
| 12   | 1.1088    |           |           | 1.1088    |           |           |           |
| 13   |           | .924      |           |           |           |           |           |
| 14   |           | .8871     |           |           |           |           |           |
| 15   | .961      |           | .9877     | 1.0349    |           | 1.0349    |           |
| 17   |           |           | 1.0059    |           |           | .9694     |           |
| 18   | 1.0829    | .8869     |           |           |           |           |           |
| 19   |           |           |           |           | 1.3535    |           |           |
| 20   | 1.4937    |           |           | 1.2071    |           |           |           |
| 22   |           |           |           |           |           |           | 1.2382    |
| 24   | 1.1827    |           | 1.0903    | 1.2197    | 1.0719    | 1.1088    | 1.1827    |
| Max  | 1.4937    | 1.3817    | 1.419     | 1.4045    | 1.4045    | 1.6632    | 1.2382    |
| Min  | .961      | .8869     | .9877     | 1.0349    | 1.0719    | .9694     | 1.1827    |
| Avg  | 1.2195    | .9934     | 1.1223    | 1.195     | 1.2439    | 1.2017    | 1.2105    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124014 / 33 / 11 KV New MIDC S/S

Feeder No / Name : 208 / 11 KV STREAM FLOW FEEDER SHEDDABLE FEEDER MIDC EQUIVALENT  
 Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .3071     | 1.1694    | 1.094     |           |           |           |           |
| 7    |           |           |           | 1.0974    | 1.2071    | 1.0608    |           |
| 8    | .5127     |           |           |           |           |           |           |
| 11   |           | 1.39      | 1.3336    |           | 1.3336    | 1.0288    |           |
| 12   | 1.2437    |           |           | 1.4861    |           |           |           |
| 13   |           | 1.1706    |           |           |           |           |           |
| 14   |           | 1.2071    |           |           |           |           |           |
| 15   | 1.3717    |           | 1.3717    | 1.4098    |           | 1.0288    |           |
| 17   |           |           | 1.3203    |           |           | .9054     |           |
| 18   | 1.4861    | 1.2197    |           |           |           |           |           |
| 19   |           |           |           |           | 1.2574    |           |           |
| 20   | 1.1812    |           |           | 1.1317    |           |           |           |
| 22   |           |           |           |           |           |           | .1448     |
| 24   | .2507     | 1.2384    | 1.1812    | 1.0608    | 1.1888    | 1.0669    | .7682     |
| Max  | 1.4861    | 1.39      | 1.3717    | 1.4861    | 1.3336    | 1.0669    | .7682     |
| Min  | .2507     | 1.1694    | 1.094     | 1.0608    | 1.1888    | .9054     | .1448     |
| Avg  | .9076     | 1.2325    | 1.2602    | 1.2372    | 1.2467    | 1.0181    | .4565     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124015 / 33/11 KV OLD MIDC

Feeder No / Name : 202 / 11KV Ruby Surgical  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .6668     | .5487     | .583      | .5487     |
| 2    |           |           |           |           |           |           | .583      |
| 4    | .4382     |           |           |           |           |           |           |
| 5    |           |           |           |           | .5144     | .4801     | .5144     |
| 6    |           | .6287     | .5716     | .6097     | .5144     |           | .4801     |
| 7    | .4001     | .6097     | .5525     | .6287     | .5144     |           | .4287     |
| 8    | .4572     | .6097     | .5144     | .5144     | .4801     |           | .2743     |
| 9    |           |           | .6668     |           | .8383     | .6516     |           |
| 10   |           | .9945     |           | 1.0479    | 1.1241    |           |           |
| 11   |           | 1.046     | 1.3717    |           |           |           |           |
| 12   | .8764     | .9945     |           | 1.2193    |           |           |           |
| 13   |           | .9602     | .8916     |           |           |           |           |
| 14   |           | .9774     | .8573     |           | 1.1812    |           |           |
| 15   | .9907     | 1.1488    | 1.0288    | 1.2765    |           | 1.086     | .381      |
| 16   | .9907     | 1.2574    | 1.1317    |           | 1.1812    |           | .724      |
| 17   | .9717     | 1.105     | 1.3146    |           |           |           |           |
| 18   | .9145     |           | 1.1812    | 1.105     | 1.105     | 1.105     | .6668     |
| 19   |           | 1.105     |           |           |           |           |           |
| 20   | .6478     |           |           | .7202     |           | .8002     | .4954     |
| 21   |           | .743      | .7049     |           | .6859     |           | .4287     |
| 22   | .6478     | .6668     | .743      | .6516     | .6516     | .724      | .4458     |
| 23   |           |           |           | .5487     | .583      | .6687     | .463      |
| 24   | .4382     | .6668     | .6668     | .7621     | .583      | .6001     | .6516     |
| Max  | .9907     | 1.2574    | 1.3717    | 1.2765    | 1.1812    | 1.105     | .724      |
| Min  | .4001     | .6097     | .5144     | .5144     | .4801     | .4801     | .2743     |
| Avg  | .7067     | .9009     | .8712     | .8126     | .7504     | .7443     | .5061     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124015 / 33/11 KV OLD MIDC

Feeder No / Name : 203 / 11 KV Mehrun

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 2.0386    | 1.7661    | 1.8347    | 1.8519    |
| 2    |           |           |           |           |           |           | 1.8176    |
| 4    | 1.7147    |           |           |           |           |           |           |
| 5    |           |           |           |           | 1.7661    | 1.8519    | 1.6461    |
| 6    |           | 2.0767    | 2.0957    | 2.0005    | 1.8519    | 1.989     | 1.8004    |
| 7    | 2.0386    | 2.1148    | 2.1338    | 1.9814    | 1.9547    | 1.9376    | 1.7318    |
| 8    | 1.9433    | 1.9624    | 2.0576    | 1.9052    | 1.7833    | 1.8176    | 1.749     |
| 9    |           | 1.6118    | 1.8671    |           | 1.848     | 1.7661    | 1.8099    |
| 10   |           | 1.5432    |           | 1.6004    | 1.8099    |           |           |
| 11   |           | 1.6632    | 1.7147    |           |           |           |           |
| 12   | 1.8671    | 1.6461    |           | 1.7528    |           | 1.8671    | 1.9243    |
| 13   |           | 1.5947    | 1.7147    |           |           |           |           |
| 14   |           | 1.4575    | 1.6632    |           | 1.7718    |           | 1.9052    |
| 15   | 1.7909    | 1.7147    | 1.6289    | 1.829     |           | 1.9052    | 1.9052    |
| 16   | 1.7909    | 1.829     | 1.6289    | 1.6118    | 1.8671    |           | 1.9052    |
| 17   | 1.7528    | 1.8671    |           |           |           |           |           |
| 18   | 1.6385    |           | 1.7337    | 1.5775    | 1.848     | 1.8099    | 1.8671    |
| 19   |           | 2.0576    |           |           |           |           |           |
| 20   | 1.9814    |           |           | 1.8861    |           | 2.1529    | 2.21      |
| 21   |           | 2.0576    | 2.1529    |           | 2.1719    |           | 1.9547    |
| 22   | 2.0767    | 2.1719    | 2.1719    | 1.8861    | 2.0233    | 2.1338    | 1.989     |
| 23   |           |           |           | 1.989     | 2.0576    | 2.1262    | 2.0576    |
| 24   | 2.0195    | 2.0386    | 2.0386    | 2.1719    | 1.8861    | 1.8861    | 1.9719    |
| Max  | 2.0767    | 2.1719    | 2.1719    | 2.1719    | 2.1719    | 2.1529    | 2.21      |
| Min  | 1.6385    | 1.4575    | 1.6289    | 1.5775    | 1.7661    | 1.7661    | 1.6461    |
| Avg  | 1.8740    | 1.8379    | 1.8924    | 1.8639    | 1.8861    | 1.9291    | 1.8881    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124015 / 33/11 KV OLD MIDC

Feeder No / Name : 204 / 11 kV Civil Hospital  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0953     | .1029     | .0857     |           |
| 2    |           |           |           |           |           |           | .0857     |
| 4    | .0953     |           |           |           |           |           |           |
| 5    |           |           |           |           | .0857     | .1029     | .0857     |
| 6    |           | .0953     | .0953     | .1334     | .0686     | .1029     | .1029     |
| 7    | .1715     | .0953     | .1334     | .1334     | .0857     | .1029     | .12       |
| 8    | .1334     | .1143     | .1334     | .1524     | .1029     | .12       | .1029     |
| 9    |           | .1886     | .1524     |           | .2667     | .1715     |           |
| 10   |           | .1372     |           | .1905     | .2477     |           | .1715     |
| 11   |           | .2401     | .3048     |           |           |           |           |
| 12   | .0762     | .2229     |           | .1905     |           | .1905     |           |
| 13   |           | .3086     | .2286     |           |           |           |           |
| 14   |           | .1715     | .2058     |           | .1334     |           | .1715     |
| 15   | .0762     | .1372     | .1715     | .1143     |           | .1143     | .1143     |
| 16   | .0572     | .1524     | .1029     | .12       | .1334     |           | .1334     |
| 17   | .0953     | .1905     |           |           |           |           |           |
| 18   | .1143     |           | .2096     | .1029     | .1143     | .1715     | .1334     |
| 19   |           | .1334     |           |           |           |           |           |
| 20   | .0953     |           |           | .0686     |           | .1143     | .1334     |
| 21   |           | .1143     | .1334     |           | .1143     |           | .1029     |
| 22   | .0953     | .0953     | .1143     | .0857     | .0857     | .0953     | .12       |
| 23   |           |           |           | .0857     | .0857     | .1029     | .0857     |
| 24   | .0953     | .0953     | .0953     | .0953     | .1029     | .1029     | .0857     |
| Max  | .1715     | .3086     | .3048     | .1905     | .2667     | .1905     | .1715     |
| Min  | .0572     | .0953     | .0953     | .0686     | .0686     | .0857     | .0857     |
| Avg  | .1005     | .1558     | .1601     | .1206     | .1236     | .1214     | .1166     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124015 / 33/11 KV OLD MIDC

Feeder No / Name : 205 / 11 kV Khedi Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.2193    | 1.0631    | 1.0802    | 1.0974    |
| 2    |           |           |           |           |           |           | 1.0802    |
| 4    | 1.0669    |           |           |           |           |           |           |
| 5    |           |           |           |           | 1.0631    | 1.0974    | 1.0631    |
| 6    |           | 1.2384    | 1.3146    | 1.2765    | 1.2003    | 1.166     | 1.0974    |
| 7    | 1.2574    | 1.3146    | 1.2765    | 1.2955    | 1.1831    | 1.2174    | 1.1488    |
| 8    | 1.1241    | 1.1622    | 1.1812    | 1.0669    | .9945     | 1.0974    | .9602     |
| 9    |           | .823      | .9526     |           | .9335     | .8916     | .9145     |
| 10   |           | .7202     |           | .8764     | .9145     |           |           |
| 11   |           | .703      | .8383     |           |           |           |           |
| 12   | 1.0288    | .7373     |           | .7621     |           | .8002     | .9145     |
| 13   |           | .7545     | .8383     |           |           |           |           |
| 14   |           | .7716     | .8059     |           | 1.0288    |           | .9907     |
| 15   | 1.0479    | .8059     | .823      | .8573     |           | .9145     | .9717     |
| 16   | 1.086     | .1715     | .7888     | .7888     | .9526     |           | 1.0098    |
| 17   | .9526     | .9145     | .9145     |           |           |           |           |
| 18   | .9717     |           | .9145     | .8059     | .8764     | .9717     | .9526     |
| 19   |           | 1.0669    |           |           |           |           |           |
| 20   | 1.2384    |           |           | 1.0974    | 1.0288    | 1.2193    | 1.2384    |
| 21   |           | 1.2193    | 1.3336    |           | 1.2574    |           | 1.1831    |
| 22   | 1.3336    | 1.3146    | 1.3527    | 1.0631    | 1.2689    | 1.4098    | 1.2174    |
| 23   |           |           |           | 1.166     | 1.2346    | 1.3032    | 1.2689    |
| 24   | 1.2384    | 1.2384    | 1.2384    | 1.2765    | 1.0974    | 1.1145    | 1.1145    |
| Max  | 1.3336    | 1.3146    | 1.3527    | 1.2955    | 1.2689    | 1.4098    | 1.2689    |
| Min  | .9526     | .1715     | .7888     | .7621     | .8764     | .8002     | .9145     |
| Avg  | 1.1223    | .9347     | 1.0409    | 1.0424    | 1.0731    | 1.0987    | 1.0720    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124016 / 33/11 KV MAHABAL

Feeder No / Name : 201 / 11 KV Ganpati Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .9259     |           | 1.0175    |           |           |           |
| 2    | .8273     |           | .8981     |           |           |           |           |
| 4    |           | .7096     |           | .7354     | .7316     |           | .7331     |
| 5    | .6428     |           |           |           | .7118     | .6936     | .6979     |
| 6    |           | .5758     | .6092     | .6687     | .6296     | .6277     |           |
| 7    |           | .5584     | .5196     |           | .5578     | .5533     | .5533     |
| 8    | .6653     | .5148     |           | .6207     | .564      | .578      | .6991     |
| 9    | .6904     |           |           | .6538     | .5232     |           | .5475     |
| 10   |           | .5464     | .5014     |           |           | .543      |           |
| 11   | .5418     | .5036     |           | .5713     | .4721     | .5299     | .4348     |
| 12   | .5786     | .521      | .535      |           |           |           |           |
| 13   |           |           |           |           | .5221     | .5828     | .5447     |
| 14   | .6048     | .6167     | .5646     | .6335     |           |           |           |
| 15   | .7569     | .676      |           | .753      | .6852     | .7008     | .7369     |
| 16   | .8106     | .7023     | .6428     | .7369     | .6455     | .666      |           |
| 17   |           |           | .6335     | .6238     |           | .6206     |           |
| 18   | .6128     | .5384     | .4982     | .591      | .5743     | .591      | .6175     |
| 19   |           |           | .5897     | .6241     | .5522     | .5749     | .6161     |
| 20   | .5916     | .5872     | .6669     |           | .642      | .7029     | .6427     |
| 21   |           | .7179     | .7202     | .7186     | .7358     | .7955     | .7855     |
| 22   | .7278     | .7972     | .9164     |           | .7666     | .8387     | .8887     |
| 23   | .9259     |           |           |           |           |           |           |
| 24   | .9415     | 1.0021    | 1.0512    | 1.0926    | 1.0392    | 1.0545    | 1.0556    |
| Max  | .9415     | 1.0021    | 1.0512    | 1.0926    | 1.0392    | 1.0545    | 1.0556    |
| Min  | .5418     | .5036     | .4982     | .5713     | .4721     | .5299     | .4348     |
| Avg  | .7084     | .6558     | .6676     | .7172     | .6471     | .6658     | .6824     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124016 / 33/11 KV MAHABAL

Feeder No / Name : 202 / 11 KV Sharada Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.3741    |           | 2.5162    |           |           |           |
| 2    | 2.1925    |           | 2.3093    |           |           |           |           |
| 4    |           | 2.0056    |           | 2.0442    | 2.1902    |           | 2.524     |
| 5    | 1.9957    |           |           |           | 2.1582    | 2.2426    | 2.0894    |
| 6    |           | 2.3901    | 2.3213    | 2.1459    | 2.5293    | 2.411     |           |
| 7    |           | 2.2453    | 2.1762    |           | 2.2727    | 2.2246    | 1.9061    |
| 8    | 1.9631    | 1.9506    |           | 1.963     | 2.0027    | 2.0357    | 1.9589    |
| 9    | 1.8642    |           |           | 1.7947    | 1.8784    |           | 1.7833    |
| 10   |           | 1.6424    | 1.6459    |           |           | 1.662     |           |
| 11   | 1.6797    | 1.5174    |           | 1.6101    | 1.7156    | 1.599     | 1.7588    |
| 12   | 1.6832    | 1.5352    | 1.5418    |           |           |           |           |
| 13   |           |           |           |           | 1.742     | 1.7446    | 1.8485    |
| 14   | 1.9832    | 1.9125    | 1.8099    | 1.9346    |           |           |           |
| 15   | 2.0711    | 1.965     |           | 1.9993    | 1.9004    | 1.9671    | 2.2085    |
| 16   | 2.0506    | 1.8917    | 1.874     | 1.963     | 1.8744    | 1.9468    |           |
| 17   |           |           | 1.7501    | 1.7409    |           | 1.8242    |           |
| 18   | 1.8724    | 1.6424    | 1.6742    | 1.715     | 1.701     | 1.715     | 1.8544    |
| 19   |           |           | 2.1155    | 1.9342    | 1.9562    | 1.9562    | 2.0775    |
| 20   | 2.2467    | 2.2174    | 2.3216    |           | 2.3422    | 2.324     | 2.2529    |
| 21   |           | 2.3204    | 2.4381    | 2.3422    | 2.4797    | 2.4042    | 2.4151    |
| 22   | 2.5659    | 2.6787    | 2.7704    |           | 2.6998    | 2.7309    | 2.7013    |
| 23   | 2.7479    |           |           |           |           |           |           |
| 24   | 2.6107    | 2.6161    | 2.687     | 2.7606    | 2.6714    | 2.7422    | 2.8343    |
| Max  | 2.7479    | 2.6787    | 2.7704    | 2.7606    | 2.6998    | 2.7422    | 2.8343    |
| Min  | 1.6797    | 1.5174    | 1.5418    | 1.6101    | 1.701     | 1.599     | 1.7588    |
| Avg  | 2.1091    | 2.0566    | 2.1025    | 2.0331    | 2.1321    | 2.0956    | 2.1581    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124016 / 33/11 KV MAHABAL

Feeder No / Name : 204 / 11 KV Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.2046    |           | 1.1693    |           |           |           |
| 2    | 1.052     |           | 1.0575    |           |           |           |           |
| 4    |           | .904      |           | .9372     | .9432     |           | .9774     |
| 5    | .8822     |           |           |           | 1.0136    | .9902     | 1.0082    |
| 6    |           | .9231     | .9422     | .9012     | 1.0262    | .9603     |           |
| 7    |           | .8569     |           |           | .9097     | .924      | .8299     |
| 8    | .7905     | .7947     |           | .788      | .8264     | .8624     | .8133     |
| 9    | .928      |           |           | .8477     | .7442     |           | .823      |
| 10   |           | .7217     | .7156     |           |           | .7652     |           |
| 11   | .8551     | .7382     |           | .8274     | .7036     | .7522     | .8157     |
| 12   | .7734     | .7922     | .788      |           |           |           |           |
| 13   |           |           |           |           | .7506     | .8291     | .7771     |
| 14   | .9402     | .8706     | .856      | .8945     |           |           |           |
| 15   | 1.0264    | .9877     |           | .9116     | 1.0028    | 1.0038    | .9684     |
| 16   |           | 1.0905    | .9511     | .9135     | .9126     | .9135     |           |
| 17   |           |           | .8352     | .8964     |           | .9583     |           |
| 18   | .8194     | .93       | .8283     | .7956     | .8098     | .8256     | .8166     |
| 19   |           |           | .9672     | .9095     | .9486     | .9124     | .8707     |
| 20   | .9214     | .8897     | 1.0808    |           | 1.0132    | 1.0665    | 1.0517    |
| 21   |           | .9871     | 1.1413    | 1.0866    | 1.07      | 1.0745    | 1.0985    |
| 22   | 1.0814    | 1.1415    | 1.3032    |           | 1.2891    | 1.2656    | 1.241     |
| 23   | 1.2816    |           |           |           |           |           |           |
| 24   | 1.2059    | 1.2816    | 1.2646    | 1.3013    | 1.3871    | 1.4251    | 1.3549    |
| Max  | 1.2816    | 1.2816    | 1.3032    | 1.3013    | 1.3871    | 1.4251    | 1.3549    |
| Min  | .7734     | .7217     | .7156     | .788      | .7036     | .7522     | .7771     |
| Avg  | .9660     | .9446     | .9793     | .9414     | .9594     | .9705     | .9605     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124016 / 33/11 KV MAHABAL

Feeder No / Name : 205 / 11 kV Gayatri Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.1547    |           | 1.2607    |           |           |           |
| 2    | 1.0769    |           | 1.1523    |           |           |           |           |
| 4    |           | .9318     |           | .9653     | 1.1198    |           | .9511     |
| 5    | .9145     |           |           |           | 1.0745    | 1.0971    | .9684     |
| 6    |           | .9212     | .9928     | .96       | .9684     | 1.0242    |           |
| 7    |           | .9154     | .8704     |           | .9116     | .9154     | .8807     |
| 8    | .8668     | .8841     |           | .823      | .8587     | .9021     | .7725     |
| 9    | .7709     |           |           | .7684     | .7721     |           | .7426     |
| 10   |           | .7652     | .7796     |           |           | .7712     |           |
| 11   | .7171     | .674      |           | .7057     | .6413     | .7225     | .6704     |
| 12   | .7141     | .6502     | .7512     |           |           |           |           |
| 13   |           |           |           |           | .7482     | .7788     | .793      |
| 14   | .8706     | .8162     | .8642     | .811      |           |           |           |
| 15   | .9663     | .8925     |           | .9088     | .8934     | .9279     | 1.0136    |
| 16   | .9328     | .9183     | .9069     | .9107     | .924      | .9461     |           |
| 17   |           |           | .7775     | .8651     |           | .8803     |           |
| 18   | .8831     | .788      | .7746     | .748      | .7578     | .7879     | .8395     |
| 19   |           |           | .8569     | .856      | .8514     | .8523     | .8328     |
| 20   | .9382     | .9623     | .9902     |           | .9774     | 1.0114    | .9753     |
| 21   |           | 1.0232    | 1.0883    | 1.0531    | 1.0553    | 1.1029    | 1.1186    |
| 22   | 1.1316    | 1.2398    | 1.262     |           | 1.2084    | 1.2607    | 1.3478    |
| 23   | 1.304     |           |           |           |           |           |           |
| 24   | 1.2476    | 1.321     | 1.3944    | 1.3535    | 1.3407    | 1.3929    | 1.3182    |
| Max  | 1.304     | 1.321     | 1.3944    | 1.3535    | 1.3407    | 1.3929    | 1.3478    |
| Min  | .7141     | .6502     | .7512     | .7057     | .6413     | .7225     | .6704     |
| Avg  | .9525     | .9286     | .9615     | .9278     | .9439     | .9609     | .9446     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124016 / 33/11 KV MAHABAL

Feeder No / Name : 206 / 11 kV D-Mart

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0338     |           | .038      |           |           |           |
| 2    | .0379     |           | .038      |           |           |           |           |
| 4    |           | .0354     |           | .0379     | .0345     |           | .0362     |
| 5    | .0379     |           |           |           | .0346     | .0367     | .0363     |
| 6    |           | .0268     | .0379     | .0379     | .0328     | .0341     |           |
| 7    |           | .0262     | .0379     |           | .0333     | .0352     | .0362     |
| 8    | .038      | .1331     |           | .0379     | .0378     | .0379     | .038      |
| 9    | .1142     |           |           | .133      | .095      |           | .1331     |
| 10   |           | .1886     | .1334     |           |           | .1331     |           |
| 11   | .1135     | .1713     |           | .1332     | .133      | .1331     | .1706     |
| 12   | .1715     | .1524     | .1326     |           |           |           |           |
| 13   |           |           |           |           | .1517     | .1523     | .1699     |
| 14   | .171      | .1524     | .1331     | .1524     |           |           |           |
| 15   | .1524     | .1521     |           | .1524     | .1517     | .1713     | .1713     |
| 16   | .1711     | .1509     | .1334     | .1518     | .1523     | .1523     |           |
| 17   |           |           | .1715     | .1521     |           | .1524     |           |
| 18   | .1704     | .1711     | .1523     | .1523     | .1334     | .1701     | .1124     |
| 19   |           |           | .1521     | .1515     | .1701     | .1694     | .1842     |
| 20   | .1859     | .1698     | .1515     |           | .1518     | .1677     | .1854     |
| 21   |           | .1711     | .1518     | .1509     | .151      | .1691     | .1835     |
| 22   | .152      | .1128     | .0558     |           | .1518     | .0569     | .0762     |
| 23   | .0569     |           |           |           |           |           |           |
| 24   | .0381     | .0348     | .038      | .0379     | .0292     | .0352     | .0352     |
| Max  | .1859     | .1886     | .1715     | .1524     | .1701     | .1713     | .1854     |
| Min  | .0379     | .0262     | .0379     | .0379     | .0292     | .0341     | .0352     |
| Avg  | .1151     | .1177     | .1085     | .1085     | .1028     | .1129     | .1120     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124017 / 33 / 11 KV GIRANA PUMPING

S/S

Feeder No / Name : 201 / 11 KV Prabhat Colony (Pre.

SHEDDABLE URBAN

Shi Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2936    | 1.182     | 1.4118    | 1.386     | 1.3121    | 1.4784    | 1.3676    |
| 2    | 1.2936    | 1.1888    | 1.3575    | 1.3306    | 1.2567    | 1.4045    | 1.2936    |
| 3    | 1.2071    | 1.1706    |           | 1.2437    | 1.0974    | 1.2567    | 1.2696    |
| 4    | .9877     | 1.0974    |           | 1.1706    | 1.0608    | 1.2071    | 1.2696    |
| 5    | 1.0136    | 1.0029    | 1.0029    | 1.0974    | 1.0719    | 1.134     | 1.1827    |
| 6    | 1.0242    | 1.0029    | 1.0745    | 1.0719    | 1.0903    | 1.1157    | 1.1643    |
| 7    | 1.0534    | .8954     | 1.0387    | 1.0534    | 1.0534    | 1.0608    | 1.0719    |
| 8    | .9511     | 1.0029    | .985      | 1.0136    | 1.0317    | 1.086     | 1.0679    |
| 9    | 1.0059    | 1.0745    | 1.0745    | 1.086     | 1.1765    | 1.1765    | 1.086     |
| 10   | .9145     |           | 1.1641    | 1.086     | 1.086     | 1.1765    | 1.086     |
| 11   | .9145     | 1.1641    | 1.0002    | 1.2536    | 1.1765    | 1.267     | 1.086     |
| 12   | 1.0059    | 1.1641    | 1.2254    | 1.267     | 1.0974    | 1.267     | 1.086     |
| 13   | 1.0059    | 1.2536    | 1.1222    | 1.1765    | 1.0974    | 1.3575    | 1.086     |
| 14   | 1.1088    | 1.2536    | 1.1888    | 1.1765    | 1.1888    | 1.267     | .905      |
| 15   | 1.2012    | 1.3432    | 1.3306    | 1.3575    | 1.1888    | 1.267     | 1.3535    |
| 16   | 1.2012    | 1.4327    | 1.3121    | 1.3575    | 1.2803    | 1.267     | 1.3169    |
| 17   | 1.0402    | 1.3432    | 1.3306    | 1.4118    | 1.2437    | 1.4266    | 1.1694    |
| 18   | 1.0136    | 1.3213    | 1.2936    | 1.267     | 1.2437    | 1.3535    |           |
| 19   | 1.1462    | 1.3352    | 1.2986    | 1.3394    | 1.2803    | 1.3169    |           |
| 20   | 1.1946    | 1.3169    | 1.3169    | 1.4083    | 1.3717    | 1.2986    | 1.4706    |
| 21   | 1.2127    | 1.39      | 1.3535    | 1.3717    | 1.4449    | 1.3717    | 1.4632    |
| 22   | 1.3169    | 1.448     | 1.3717    |           | 1.4632    | 1.4449    | 1.4998    |
| 23   | 1.2536    | 1.4327    | 1.5893    | 1.6244    | 1.6263    | 1.6617    | 1.6632    |
| 24   | 1.423     | 1.2178    | 1.3969    | 1.5708    | 1.46      | 1.5708    | 1.5154    |
| Max  | 1.423     | 1.448     | 1.5893    | 1.6244    | 1.6263    | 1.6617    | 1.6632    |
| Min  | .9145     | .8954     | .985      | 1.0136    | 1.0317    | 1.0608    | .905      |
| Avg  | 1.1160    | 1.2189    | 1.2382    | 1.2661    | 1.2250    | 1.3014    | 1.2488    |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124017 / 33 / 11 KV GIRANA PUMPING

S/S

Feeder No / Name : 202 / 11KV Bhagwan Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5927    | 1.6126    | 1.7718    | 1.7194    | 1.6461    | 1.7924    | 1.7194    |
| 2    | 1.448     | 1.5775    | 1.7364    | 1.647     | 1.6095    | 1.7924    | 1.6289    |
| 3    | 1.448     | 1.5947    | 1.701     | 1.5927    | 1.5729    | 1.6289    | 1.5203    |
| 4    | 1.3756    | 1.5238    | 1.6655    | 1.4327    | 1.4842    | 1.6118    | 1.4327    |
| 5    | 1.3756    | 1.5061    | 1.5592    | 1.3756    | 1.5203    | 1.6126    | 1.4327    |
| 6    | 1.3756    | 1.4706    | 1.5592    | 1.4449    | 1.5203    | 1.4575    | 1.4118    |
| 7    | 1.423     | 1.3112    | 1.3998    | 1.3717    | 1.3756    | 1.3432    | 1.3575    |
| 8    | 1.2308    | 1.1694    | 1.2403    | 1.2437    | 1.2757    | 1.2934    | 1.2048    |
| 9    | 1.1517    | 1.1641    | 1.0867    | 1.0974    | 1.1517    | 1.1517    | 1.1517    |
| 10   | 1.0631    |           | 1.0749    | 1.0974    | 1.0631    | 1.1517    | 1.1517    |
| 11   | 1.0631    | .985      | .9745     | 1.0974    | 1.0631    | 1.1517    | 1.0631    |
| 12   | .9745     | .9745     | 1.0166    | 1.0974    | 1.0631    | 1.1517    | 1.0745    |
| 13   | 1.0745    | 1.0631    | 1.1694    | 1.0974    | 1.0631    | 1.1517    | 1.0745    |
| 14   | 1.1641    | 1.0631    | 1.1517    | 1.1888    | 1.1517    | 1.2403    | 1.3432    |
| 15   | 1.1641    | 1.1517    | 1.2254    | 1.307     | 1.1517    | 1.3289    | 1.3466    |
| 16   | 1.1641    | 1.1517    | 1.0745    | 1.307     | 1.2403    | 1.3289    | 1.3253    |
| 17   | 1.1946    | 1.1694    |           | 1.262     | 1.2403    | 1.0277    | 1.2226    |
| 18   | 1.1568    | 1.1393    | 1.0802    | 1.2269    | 1.2437    | 1.134     |           |
| 19   | 1.387     | 1.3466    | 1.4022    | 1.262     | 1.3611    | 1.3466    |           |
| 20   | 1.5061    | 1.5592    | 1.6124    | 1.5947    | 1.5061    | 1.5415    | 1.8604    |
| 21   | 1.5947    | 1.7528    | 1.7909    | 1.7918    | 1.7364    | 1.6832    | 1.7718    |
| 22   | 1.7737    | 1.8446    | 1.8804    |           | 1.7718    | 1.7718    | 1.8427    |
| 23   | 1.7703    | 1.8427    | 2.0851    | 1.9753    | 2.0668    | 2.0668    | 2.1216    |
| 24   | 1.7194    | 1.6651    | 1.8073    | 1.9022    | 1.7558    | 1.8656    | 1.9022    |
| Max  | 1.7737    | 1.8446    | 2.0851    | 1.9753    | 2.0668    | 2.0668    | 2.1216    |
| Min  | .9745     | .9745     | .9745     | 1.0974    | 1.0631    | 1.0277    | 1.0631    |
| Avg  | 1.3413    | 1.3756    | 1.4376    | 1.3971    | 1.4014    | 1.4428    | 1.4527    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124017 / 33 / 11 KV GIRANA PUMPING

S/S

Feeder No / Name : 203 / 11 KV Girna Pumping  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .0914     | .0709     | .0709     | .1017     |           |
| 2    |           |           | .0914     | .0709     | .0709     | .1017     |           |
| 3    |           | .0709     | .0914     | .0701     | .0709     | .0995     |           |
| 4    | .0934     | .0914     | .0914     | .0693     | .0876     | .1134     | .1063     |
| 5    | .0934     | .0914     | .0914     | .0693     | .104      | .1134     | .1052     |
| 6    | .0934     | .1097     | .0914     | .1063     | .1214     | .1187     | .1029     |
| 7    | .1109     | .1463     | 1.7375    | .1052     | .1387     | .1187     | .1017     |
| 8    | .1097     | .1402     | .985      | .0686     | .116      |           | .112      |
| 9    | .0914     | .0876     | .0972     | .0867     | .116      | .0943     | .08       |
| 10   | .0914     |           |           | .0867     | .0867     | .0857     | .0895     |
| 11   | .0914     | .0876     | .1097     | .0867     | .0819     | .0857     | .0857     |
| 12   | .0914     | .0876     | .1017     | .0867     | .0819     | .0857     | .0819     |
| 13   | .0914     |           | .0914     | .0867     | .0819     | .0857     | .0819     |
| 14   | .0914     |           |           | .0867     | .0819     | .0857     |           |
| 15   |           |           |           | .0867     | .0819     | .0857     |           |
| 16   |           |           |           | .0867     | .0819     | .0857     |           |
| 17   |           |           |           | .0686     |           |           |           |
| 18   | 1.3032    |           |           |           |           |           |           |
| 19   |           | .0895     | .1134     |           | .1086     | .1086     |           |
| 20   |           | .1086     | .1134     |           | .1086     | .1086     |           |
| 21   |           | .1097     | .1134     | .1147     | .1267     | .1086     |           |
| 22   |           | .0905     | .1147     |           | .1267     | .1086     |           |
| 23   |           | .0914     | .1029     | .0724     |           | .1052     |           |
| 24   |           |           | .0914     | .1017     | .0716     | .1017     |           |
| Max  | 1.3032    | .1463     | 1.7375    | .1147     | .1387     | .1187     | .112      |
| Min  | .0914     | .0709     | .0914     | .0686     | .0709     | .0857     | .08       |
| Avg  | .1960     | .1002     | .2400     | .0841     | .0960     | .1001     | .0947     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124017 / 33 / 11 KV GIRANA PUMPING

S/S

Feeder No / Name : 205 / 11 KV Telephone Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.957     | 1.9404    | 2.0485    | 2.1765    | 2.0851    | 2.0851    | 2.1033    |
| 2    | 1.8473    | 1.885     | 2.0119    | 2.0119    | 1.9366    | 1.9753    | 2.0119    |
| 3    | 1.6461    | 1.8656    | 1.9753    | 2.0119    | 1.8099    | 1.9547    | 1.8099    |
| 4    | 1.448     | 1.7193    | 1.7909    | 1.829     | 1.8099    | 1.828     | 1.8099    |
| 5    | 1.5565    | 1.6632    | 1.0208    | 1.7924    | 1.7924    | 1.8473    | 1.7924    |
| 6    | 1.6644    | 1.4784    | 1.8461    | 1.9022    | 1.7741    | 1.7924    | 1.7375    |
| 7    | 1.701     | 1.5524    | 1.7013    | 1.7375    | 1.6461    | 1.7375    | 1.701     |
| 8    | 1.5912    | 1.4998    | 1.5565    | 1.5546    | 1.5181    | 1.4998    | 1.6095    |
| 9    | 1.3717    | 1.4632    | 1.4118    | 1.3717    | 1.1888    | 1.3717    | 1.4632    |
| 10   | 1.2803    |           | 1.4118    | 1.2803    | 1.2803    | 1.2803    | 1.2803    |
| 11   | 1.1888    | 1.0059    | 1.267     | 1.2803    | 1.0974    | 1.2803    | 1.1888    |
| 12   | 1.1203    | 1.1888    |           | 1.2803    | 1.1888    | 1.2803    | 1.2803    |
| 13   | 1.307     | 1.2803    | 1.1765    | 1.2803    | 1.2803    | 1.3717    | 1.3717    |
| 14   | 1.4003    | 1.3717    | 1.448     | 1.3717    | 1.2803    | 1.3717    | 1.6461    |
| 15   | 1.4003    | 1.4632    | 1.5364    | 1.3717    | 1.2803    | 1.3717    | 1.6827    |
| 16   | 1.4003    | 1.3717    | 1.4083    | 1.3717    | 1.3717    | 1.3717    | 1.6461    |
| 17   | 1.3575    | 1.5154    | 1.4632    | 1.4632    | 1.3717    | 1.0808    | 1.4998    |
| 18   | 1.3032    | 1.4045    | 1.4083    | 1.4632    | 1.3176    | 1.3496    |           |
| 19   | 1.5364    | 1.5364    | 1.6827    | 1.4632    | 1.5223    | 1.5074    |           |
| 20   | 1.7375    | 1.7741    | 1.829     | 1.829     | 1.7551    | 1.7896    | 2.0595    |
| 21   | 1.9022    | 1.9204    | 2.0119    | 2.0119    | 1.8642    | 1.8804    | 1.8461    |
| 22   | 2.0851    | 2.2314    | 2.1948    |           | 1.8461    | 1.9342    | 1.8823    |
| 23   | 2.1437    | 2.2131    | 2.4874    | 2.4326    | 2.5423    | 2.4691    | 1.3169    |
| 24   | 2.1216    | 2.0328    | 2.1033    | 2.268     | 2.19      | 2.3228    | 2.2131    |
| Max  | 2.1437    | 2.2314    | 2.4874    | 2.4326    | 2.5423    | 2.4691    | 2.2131    |
| Min  | 1.1203    | 1.0059    | 1.0208    | 1.2803    | 1.0974    | 1.0808    | 1.1888    |
| Avg  | 1.5862    | 1.6251    | 1.6866    | 1.6763    | 1.6146    | 1.6564    | 1.6797    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124095 / 33/11 KV V SECTOR

Feeder No / Name : 201 / 11 KV Balaji Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | 1.3306    | 1.6975    | 1.358     | 1.5089    | 1.262     | 1.3756    |
| 5    | .2401     |           |           |           |           |           |           |
| 7    |           | 1.2936    | 1.5089    | 1.2936    | 1.5089    | 1.6057    | 1.2696    |
| 8    | .5544     |           |           |           |           |           |           |
| 10   |           |           |           |           | 1.7353    | 1.307     | .543      |
| 11   |           |           | 1.643     |           |           |           |           |
| 12   | 1.3203    | 1.3203    |           | 1.8298    | 1.4937    | 1.358     | .4085     |
| 14   |           |           |           |           | 1.6804    | 1.8861    | .1158     |
| 15   | 1.2437    | 1.307     | 1.7551    | 1.6804    | 1.8671    |           |           |
| 16   |           |           |           |           | 1.7551    | 1.7164    | .0545     |
| 18   | .9145     | 1.3443    | 1.7177    | 1.4937    |           |           |           |
| 20   | 1.1203    | .9877     | .9145     | 1.2071    | 1.39      |           | .4687     |
| 24   | .4572     | 1.5089    | 1.3203    | 1.4118    |           | 1.3203    | 1.4998    |
| Max  | 1.3203    | 1.5089    | 1.7551    | 1.8298    | 1.8671    | 1.8861    | 1.4998    |
| Min  | .2401     | .9877     | .9145     | 1.2071    | 1.39      | 1.262     | .0545     |
| Avg  | .8358     | 1.2989    | 1.5081    | 1.4678    | 1.6174    | 1.4936    | .7169     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124095 / 33/11 KV V SECTOR

Feeder No / Name : 202 / 11 KV Satyam Feeder.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .8299     | .8299     | .7545     | .9054     | .8299     | .8059     |
| 5    | .1412     |           |           |           |           |           |           |
| 7    |           | .8775     | .9431     | .9896     | .9054     | .7545     | .6722     |
| 8    | .3163     |           |           |           |           |           |           |
| 10   | .3163     |           |           |           | 1.3203    | 1.1317    | .1509     |
| 11   |           |           | 1.358     |           | 1.3203    |           |           |
| 12   | 1.094     | 1.1694    |           | 1.0562    | 1.2826    | 1.1812    | .1463     |
| 14   |           |           |           |           | 1.358     | 1.2071    | .1532     |
| 15   | 1.0562    | 1.3203    | 1.2826    | 1.358     | 1.3203    |           |           |
| 16   |           |           |           |           | 1.2071    | 1.2449    | .0876     |
| 18   | .9526     | 1.094     | 1.0669    | 1.1317    |           |           |           |
| 20   | .9145     | .8215     | .9054     | .8962     | .8962     |           | .2126     |
| 24   | .1067     | .7545     | .7545     | .811      | .9526     | .7545     | .7545     |
| Max  | 1.094     | 1.3203    | 1.358     | 1.358     | 1.358     | 1.2449    | .8059     |
| Min  | .1067     | .7545     | .7545     | .7545     | .8962     | .7545     | .0876     |
| Avg  | .6122     | .9810     | 1.0201    | .9996     | 1.1468    | 1.0148    | .3729     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124095 / 33/11 KV V SECTOR

Feeder No / Name : 203 / 11 KV Alpha Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | 3.4705    | 3.5818    | 3.131     | 3.3573    | 3.2442    | 3.2065    |
| 5    | .6455     |           |           |           |           |           |           |
| 7    |           | 3.3951    | 3.6591    | 3.3265    | 3.3951    | 3.2065    | 2.4646    |
| 8    | 1.5947    |           |           |           |           |           |           |
| 10   |           |           |           |           | 4.0329    | 4.1914    | .4877     |
| 11   |           |           | 4.4063    |           |           |           |           |
| 12   | 3.5082    | 4.0741    |           | 3.6969    | 3.7723    | 3.5082    | .3414     |
| 14   |           |           |           |           | 4.1076    | 4.1118    | .1829     |
| 15   | 4.0741    | 4.2943    | 4.225     | 4.1076    | 4.3317    |           |           |
| 16   |           |           |           |           | 4.1076    | 4.1495    |           |
| 18   | 3.8855    | 3.8855    | 4.039     | 3.9582    |           |           |           |
| 20   | 3.131     | 3.0178    | 3.0178    | 3.2388    | 2.8292    |           | .4119     |
| 24   | .3544     | 3.1626    | 3.4328    | 3.1741    | 3.3951    | 3.2065    | 3.0864    |
| Max  | 4.0741    | 4.2943    | 4.4063    | 4.1076    | 4.3317    | 4.1914    | 3.2065    |
| Min  | .3544     | 3.0178    | 3.0178    | 3.131     | 2.8292    | 3.2065    | .1829     |
| Avg  | 2.4562    | 3.6143    | 3.7660    | 3.5190    | 3.7032    | 3.6597    | 1.4545    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124095 / 33/11 KV V SECTOR

Feeder No / Name : 401 / 33 KV TULASI FEEDER

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .1406     | .0189     | .12       | .0343     | .0206     | .208      |
| 5    | .0377     |           |           |           |           |           |           |
| 7    |           | .0652     | .0206     | .1217     | .0274     | .0206     | .1943     |
| 8    | .0189     |           |           |           |           |           |           |
| 10   |           |           |           |           | .0686     | .0412     | .1829     |
| 11   |           |           | .0149     |           |           |           |           |
| 12   | .0274     | .0892     |           | .1063     | .0566     | .1943     | .1806     |
| 14   |           |           |           |           | .0412     | .1943     | .1806     |
| 15   | .1852     | .0532     | .0572     | .1303     | .0223     |           |           |
| 16   |           |           |           |           | .0189     | .2058     | .1829     |
| 18   | .176      | .0686     | .1286     | .1355     |           |           |           |
| 20   | .2629     | .2035     | .1132     | .1355     | .0207     |           | .1235     |
| 24   | .0446     | .0846     | .16       | .1235     | .1406     | .0377     | .064      |
| Max  | .2629     | .2035     | .16       | .1355     | .1406     | .2058     | .208      |
| Min  | .0189     | .0532     | .0149     | .1063     | .0189     | .0206     | .064      |
| Avg  | .1075     | .1007     | .0733     | .1247     | .0478     | .1021     | .1646     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124096 / 33/11 KV M SECTOR

Feeder No / Name : 201 / 11 KV Kiran Pipes Feeder.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3429     | .9431     | 1.0669    | 1.1241    | 1.0269    | .6344     | .9145     |
| 8    | .7545     | 1.2174    | 1.3336    | 1.2765    | 1.4563    | 1.2689    | .5525     |
| 12   | 1.3032    | 1.6385    | 1.7528    | 1.7177    | 1.0802    | 1.9433    | .4382     |
| 16   | 1.5947    | 2.0576    | 1.9624    | 2.0165    | 1.8519    | 2.0767    | .4191     |
| 20   | 1.0117    | 1.3908    | 1.3336    | 1.2883    | 1.1488    | 1.1431    | .381      |
| 24   | .4191     | .9945     | 1.1812    | 1.0479    | 1.1949    | .9945     | 1.0098    |
| Max  | 1.5947    | 2.0576    | 1.9624    | 2.0165    | 1.8519    | 2.0767    | 1.0098    |
| Min  | .3429     | .9431     | 1.0669    | 1.0479    | 1.0269    | .6344     | .381      |
| Avg  | .9044     | 1.3737    | 1.4384    | 1.4118    | 1.2932    | 1.3435    | .6192     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124096 / 33/11 KV M SECTOR

Feeder No / Name : 202 / 11 KV Mahalaxmi Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3048     | .7716     | .8002     | .9335     | .8488     | .6516     | .6668     |
| 8    | .5658     | .7888     | .7621     | .9145     | .8029     | .6173     | .3429     |
| 12   | 1.1317    | 1.1812    | 1.2003    | 1.226     | 1.1831    | .9907     | .2286     |
| 16   | 1.0802    | 1.4289    | 1.3336    | 1.307     | 1.1488    | 1.1622    | .2286     |
| 20   | .7716     | .9907     | 1.0098    | .9808     | .6859     | .8383     | .2172     |
| 24   | .2667     | .7373     | .8764     | 1.0288    | .9431     | .6687     | .7621     |
| Max  | 1.1317    | 1.4289    | 1.3336    | 1.307     | 1.1831    | 1.1622    | .7621     |
| Min  | .2667     | .7373     | .7621     | .9145     | .6859     | .6173     | .2172     |
| Avg  | .6868     | .9831     | .9971     | 1.0651    | .9354     | .8215     | .4077     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124096 / 33/11 KV M SECTOR

Feeder No / Name : 203 / 11 KV Winley Feeder.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .2477     | .4801     | .4001     | .4572     | .4904     | .463      | .4382     |
| 7    | .2477     |           |           |           |           |           | .381      |
| 8    | .3772     | .7373     | .8002     | .724      | .7545     | .6859     | .2858     |
| 12   | .7545     | .9907     | .9526     | .7733     | .8059     | .8764     | .1143     |
| 16   | .5658     | .9717     | .9526     | .8299     | .5487     | .9907     | .0857     |
| 20   | .4287     | .7621     | .7811     | .6602     | .6344     | .7621     | .1143     |
| 23   |           | .6668     |           |           |           |           |           |
| 24   | .2667     | .4287     | .4763     | .4763     | .4904     | .5487     | .4954     |
| Max  | .7545     | .9907     | .9526     | .8299     | .8059     | .9907     | .4954     |
| Min  | .2477     | .4287     | .4001     | .4572     | .4904     | .463      | .0857     |
| Avg  | .4126     | .7196     | .7272     | .6535     | .6207     | .7211     | .2735     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124121 / 33/11 KV Jilha Peth S/S

Feeder No / Name : 201 / 11 KV SWANTANTRA CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8107    | 1.848     | 1.8656    |           |           |           |           |
| 2    |           |           |           | 1.701     |           | 1.7375    |           |
| 3    |           |           |           |           |           | 1.6461    |           |
| 4    | 1.7013    | 1.4045    | 1.3756    |           | 1.5524    |           | 1.8099    |
| 5    | 1.6289    | 1.5339    | 1.3937    | 1.7013    | 1.5339    | 1.6461    |           |
| 6    | 1.5927    | 1.5181    | 1.4998    | 1.6095    | 1.5524    | 1.6461    | 1.5729    |
| 7    | 1.4842    | 1.4784    |           | 1.5927    | 1.5154    | 1.5546    | 1.5364    |
| 8    | 1.576     | 1.4842    | 1.4327    | 1.5565    | 1.4842    | 1.5203    |           |
| 9    | 1.5746    | 1.4661    | 1.5223    | 1.6118    | 1.5203    | 1.5384    | 1.6651    |
| 10   | 1.4661    | 1.6651    | 1.6651    | 1.773     | 1.7194    | 1.7737    |           |
| 11   | 1.5238    |           | 1.7918    |           | 1.829     | 1.829     | 1.7918    |
| 12   | 1.5384    |           | 1.829     | 1.9547    | 1.829     | 1.9204    | 1.7737    |
| 13   | 1.5565    | 1.8839    |           | 1.9366    | 1.9387    | 2.0119    | 1.7013    |
| 14   | 1.5927    |           | 1.9204    | 2.0452    | 1.9753    | 2.0485    |           |
| 15   | 1.6651    | 1.9753    | 1.9936    | 2.0668    | 1.9909    | 2.0485    |           |
| 16   | 1.6289    |           |           | 2.0851    | 2.1068    | 2.1068    | 1.9728    |
| 17   | 1.647     |           | 1.9022    | 1.9753    | 1.9753    | 2.0485    | 1.8473    |
| 18   | 1.5546    | 1.9366    | 1.885     | 1.829     | 1.8473    | 1.9387    | 1.647     |
| 19   | 1.6832    |           | 1.9366    | 1.8823    | 1.9753    | 1.9204    | 1.7909    |
| 20   | 1.7013    | 1.828     | 1.9022    | 1.8823    | 1.9547    | 1.9022    | 1.7918    |
| 21   |           |           |           | 1.9022    | 1.9387    | 1.9728    | 1.848     |
| 22   | 1.8107    | 1.8823    | 1.9753    | 1.9022    | 2.0119    | 1.957     | 1.9185    |
| 23   |           |           |           | 1.922     | 2.0119    | 2.0668    | 1.9204    |
| 24   | 1.8656    | 1.8665    | 1.9387    | 1.9204    | 1.885     | 1.9204    | 1.9589    |
| Max  | 1.8656    | 1.9753    | 1.9936    | 2.0851    | 2.1068    | 2.1068    | 1.9728    |
| Min  | 1.4661    | 1.4045    | 1.3756    | 1.5565    | 1.4842    | 1.5203    | 1.5364    |
| Avg  | 1.6301    | 1.6979    | 1.7547    | 1.8425    | 1.8166    | 1.8525    | 1.7842    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124121 / 33/11 KV Jilha Peth S/S

Feeder No / Name : 202 / 11 KV G. S. GROUND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .823      | .8238     | .8939     |           |           |           |           |
| 2    |           |           |           | .8063     |           | .8507     |           |
| 3    |           |           |           |           |           | .8507     |           |
| 4    | .6952     | .6952     | .7455     |           | .7545     |           | .7888     |
| 5    | .6952     | .7202     | .7455     | .7537     | .7455     | .8688     | .7712     |
| 6    | .7461     | .8669     | .7716     | .7545     | .7282     | .8869     | .7888     |
| 7    | .703      | .8573     |           | .7802     | .7362     | .8869     | .7373     |
| 8    | .8764     | .703      | .7291     | .7042     | .7042     | .7373     |           |
| 9    | .8413     | .7122     | .763      | .7461     | .7377     | .7628     | .7202     |
| 10   | .9955     | .9015     | .9816     | 1.0402    | .9536     | 1.0341    |           |
| 11   | .9391     |           | 1.2403    |           | .8059     | 1.3253    | 1.1694    |
| 12   | .8413     | 1.267     | 1.4118    | 1.4327    | 1.3756    | 1.448     | 1.3073    |
| 13   | .7888     | 1.2851    |           | 1.3432    | 1.3432    | 1.3937    | 1.2715    |
| 14   | .7712     |           | 1.448     | 1.3575    |           | 1.4661    |           |
| 15   | .8413     | 1.2308    | 1.4299    | 1.4266    | 1.39      | 1.4661    |           |
| 16   | .8328     |           |           | 1.39      | 1.5364    | 1.4998    | 1.3937    |
| 17   | .7545     | 1.3575    | 1.4661    | 1.3937    | 1.448     | 1.4299    | 1.1765    |
| 18   | .7537     | 1.379     | 1.4083    | 1.3432    | 1.448     | 1.3575    | 1.2357    |
| 19   | .8322     |           | 1.3969    | 1.3611    | 1.4148    | 1.4148    | 1.2971    |
| 20   | .8573     | 1.2403    | 1.1999    | 1.1517    | 1.2894    | 1.262     | 1.1163    |
| 21   | .823      |           |           | 1.0517    | 1.1041    | 1.0517    | .9602     |
| 22   | .8745     | 1.0166    |           | .9991     | 1.0679    | 1.0056    | .9816     |
| 23   |           |           | 1.0056    | .9745     | 1.086     | .9991     | .9214     |
| 24   | .8573     | .8413     | .929      | .8939     | .9391     | .9774     | .9391     |
| Max  | .9955     | 1.379     | 1.4661    | 1.4327    | 1.5364    | 1.4998    | 1.3937    |
| Min  | .6952     | .6952     | .7291     | .7042     | .7042     | .7373     | .7202     |
| Avg  | .8163     | .9936     | 1.0921    | 1.0852    | 1.0804    | 1.1352    | 1.0339    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-I S/DN.[236] BU 4236

Substation No/ Name :- 124121 / 33/11 KV Jilha Peth S/S

Feeder No / Name : 203 / 11 kV The Collector Exp. NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0187     | .0187     | .0189     |           |           |           |           |
| 2    |           |           |           | .0373     |           | .0377     |           |
| 3    |           |           |           |           |           | .0189     |           |
| 4    | .0377     | .0185     | .0183     |           | .0377     |           | .0373     |
| 5    | .0373     | .0183     | .0183     | .0373     | .0373     | .0189     | .0373     |
| 6    | .0187     | .0181     | .0185     | .0377     | .0179     | .0189     | .0373     |
| 7    | .0189     | .0181     |           | .0347     | .0171     | .0189     | .0177     |
| 8    | .0179     | .0183     | .0187     | .0183     | .0181     | .0187     |           |
| 9    | .0177     | .0549     | .0358     | .0381     | .0377     | .0381     | .0358     |
| 10   | .037      | .0747     | .0754     | .0762     | .0754     | .0754     |           |
| 11   | .037      |           | .132      |           | .1132     | .0377     | .0716     |
| 12   | .0373     | .132      | .132      | .0943     | .132      | .1509     | .0924     |
| 13   | .0377     | .132      |           | .1132     | .1132     | .1509     | .0566     |
| 14   | .0373     |           | .132      | .1132     |           | .1509     |           |
| 15   | .037      | .1848     | .132      | .1663     | .1132     | .1509     |           |
| 16   | .0373     |           |           | .1132     | .1132     | .132      | .037      |
| 17   | .0181     | .1663     | .132      | .1132     | .1143     | .132      | .0362     |
| 18   | .0183     | .1448     | .1143     | .0943     | .0754     | .0943     | .0175     |
| 19   | .0181     |           | .0566     | .0572     | .0377     | .0377     | .0189     |
| 20   | .0185     | .0572     | .0377     | .0377     | .0373     | .0377     | .0189     |
| 21   | .0187     |           |           | .0377     | .0377     | .0377     | .0189     |
| 22   | .0373     | .0189     |           | .0377     | .0377     | .0373     | .0189     |
| 23   |           |           | .0377     | .0377     | .0377     | .0373     | .0189     |
| 24   | .0189     | .0187     | .0377     | .0377     | .0381     | .0377     | .0373     |
| Max  | .0377     | .1848     | .132      | .1663     | .132      | .1509     | .0924     |
| Min  | .0177     | .0181     | .0183     | .0183     | .0171     | .0187     | .0175     |
| Avg  | .0274     | .0684     | .0675     | .0667     | .0621     | .0668     | .0358     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124018 / 33/11 KV NIMKHEDI S/S

Feeder No / Name : 202 / 11 KV SILK MILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6827    | 1.6827    | 1.7193    | 1.8088    | 1.8473    | 1.8099    | 1.6476    |
| 2    | 1.6461    | 1.6461    | 1.6476    | 1.6289    | 1.7013    | 1.828     | 1.6118    |
| 3    | 1.5912    | 1.5546    | 1.6118    | 1.4864    | 1.6289    | 1.7556    | 1.576     |
| 4    | 1.4632    | 1.4632    | 1.5927    | 1.4327    | 1.5927    | 1.6651    | 1.5581    |
| 5    | 1.3575    | 1.4998    | 1.6289    | 1.4327    | 1.4842    | 1.5746    | 1.4685    |
| 6    | 1.3535    | 1.6827    | 1.6289    | 1.4685    | 1.5203    | 1.647     | 1.3969    |
| 7    | 1.5154    | 1.5524    | 1.6461    | 1.4118    | 1.5729    | 1.6289    | 1.3432    |
| 8    | 1.3169    | 1.3394    | 1.4632    | 1.267     | 1.3575    | 1.3575    | 1.2536    |
| 9    | 1.2536    | 1.2894    | 1.2357    | 1.1584    | 1.2894    | 1.3253    | 1.3032    |
| 10   | 1.1584    | 1.2403    | 1.1694    | 1.1641    | 1.2048    | 1.2403    | 1.2403    |
| 11   | 1.1641    | 1.1462    | 1.1163    | 1.134     | 1.182     | 1.1999    | 1.1999    |
| 12   | 1.1888    | 1.1222    | 1.1517    | 1.1283    | 1.182     | 1.2308    | 1.267     |
| 13   | 1.3032    | 1.2127    | 1.2715    | 1.2536    | 1.2803    | 1.2536    | 1.3213    |
| 14   | 1.39      | 1.2308    | 1.3611    | 1.3394    | 1.3756    | 1.3575    | 1.3575    |
| 15   | 1.4118    | 1.4299    | 1.4661    | 1.3432    | 1.3717    | 1.4327    | 1.4632    |
| 16   | 1.3717    | 1.3169    | 1.4842    | 1.3394    | 1.3394    | 1.5023    | 1.5181    |
| 17   | 1.4266    | 1.1641    | 1.3253    |           | 1.3432    |           | 1.382     |
| 18   | 1.448     | 1.1694    | 1.2269    | 1.1919    | 1.2757    | 1.3253    | 1.2757    |
| 19   | 1.4506    | 1.6118    | 1.5223    | 1.5043    | 1.5223    | 1.5402    | 1.5238    |
| 20   | 1.7013    | 1.7737    | 1.7013    | 1.7737    | 1.7013    | 1.7375    | 1.2178    |
| 21   | 1.7737    | 1.8461    | 1.8642    | 1.8099    | 1.9366    | 1.8823    | 1.8642    |
| 22   | 1.9753    | 1.97      | 1.9366    | 2.1719    | 1.9909    |           | 1.9909    |
| 23   | 2.0485    | 1.8267    | 1.9909    | 1.9909    | 1.9547    |           | 2.0633    |
| 24   |           | 1.957     | 1.7193    | 1.9909    | 1.8823    | 1.9185    | 1.9547    |
| Max  | 2.0485    | 1.97      | 1.9909    | 2.1719    | 1.9909    | 1.9185    | 2.0633    |
| Min  | 1.1584    | 1.1222    | 1.1163    | 1.1283    | 1.182     | 1.1999    | 1.1999    |
| Avg  | 1.4779    | 1.4887    | 1.5201    | 1.4883    | 1.5224    | 1.5339    | 1.4916    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124018 / 33/11 KV NIMKHEDI S/S

Feeder No / Name : 203 / 11 KV SMIT ( Pre. Ganesh SHEDDABLE URBAN  
Colon Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7924    | 1.829     | 1.9163    | 1.8642    | 1.9004    | 1.9366    | 1.9342    |
| 2    | 1.6827    | 1.6461    | 1.8267    |           | 1.8099    | 1.8823    | 1.7909    |
| 3    | 1.6095    | 1.6095    | 1.773     | 1.6651    | 1.7194    | 1.8099    | 1.6476    |
| 4    | 1.4998    | 1.5729    | 1.7193    | 1.5384    | 1.6289    | 1.7194    | 1.5939    |
| 5    | 1.3756    | 1.4632    | 1.6476    | 1.5023    | 1.5912    | 1.6289    | 1.4506    |
| 6    | 1.3535    | 1.5364    | 1.5581    | 1.4842    | 1.4998    | 1.5203    | 1.4327    |
| 7    | 1.4449    | 1.4083    | 1.4327    | 1.448     | 1.4266    | 1.4842    | 1.3432    |
| 8    | 1.3032    | 1.3253    | 1.2894    | 1.3213    | 1.3937    | 1.3032    | 1.3073    |
| 9    | 1.267     | 1.2048    | 1.1517    | 1.2178    | 1.2178    | 1.1641    | 1.2757    |
| 10   | 1.1462    | 1.1517    | 1.1517    | 1.1393    | 1.1218    | 1.134     | 1.2269    |
| 11   | 1.0985    | 1.1163    | 1.1222    | 1.1218    | 1.1919    | 1.1871    | 1.2403    |
| 12   | 1.1283    | 1.134     | 1.1584    | 1.0985    | 1.2226    | 1.2536    | 1.3432    |
| 13   | 1.2803    | 1.2757    | 1.2403    | 1.2226    | 1.2136    | 1.2715    | 1.379     |
| 14   | 1.3756    | 1.4148    | 1.3611    | 1.3394    | 1.1203    | 1.4685    | 1.4842    |
| 15   | 1.3937    | 1.448     | 1.4842    | 1.3253    | 1.3717    | 1.5203    | 1.448     |
| 16   | 1.3717    | 1.5203    | 1.4118    | 1.3394    | 1.5402    | 1.5565    | 1.5546    |
| 17   | 1.39      | 1.5203    | 1.2178    | 1.2048    | 1.3672    | 1.379     | 1.2894    |
| 18   | 1.3432    | 1.2269    | 1.1919    |           | 1.283     |           | 1.2269    |
| 19   | 1.3112    | 1.576     | 1.3575    | 1.3998    | 1.5061    | 1.3466    | 1.4706    |
| 20   | 1.4842    | 1.6651    | 1.5402    | 1.5927    | 1.7013    | 1.5939    | 1.6118    |
| 21   | 1.647     | 1.8099    | 1.7556    | 1.7737    | 1.9004    | 1.7375    | 1.7193    |
| 22   | 1.9936    | 2.0774    | 1.8461    | 2.1582    | 1.9909    |           | 1.97      |
| 23   | 2.1437    | 2.0416    | 1.9909    | 2.0814    | 2.0814    |           | 2.1491    |
| 24   |           | 2.0851    | 2.0058    | 2.1357    | 2.0271    | 2.1176    | 2.1719    |
| Max  | 2.1437    | 2.0851    | 2.0058    | 2.1582    | 2.0814    | 2.1176    | 2.1719    |
| Min  | 1.0985    | 1.1163    | 1.1222    | 1.0985    | 1.1203    | 1.134     | 1.2269    |
| Avg  | 1.4537    | 1.5274    | 1.5063    | 1.4988    | 1.5345    | 1.5245    | 1.5442    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124018 / 33/11 KV NIMKHEDI S/S

Feeder No / Name : 204 / 11 KV SAVKHEDA VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7164     | .7316     | .724      | .6268     | .6335     | .6335     | .724      |
| 2    | .7164     | .724      | .724      | .7164     | .724      | .724      | .724      |
| 3    | .8145     | .7602     | .724      | .8059     | .8145     | .724      | .724      |
| 4    | .9511     | .9145     | .724      | .8059     | .8145     | .8145     | .8145     |
| 5    | 1.1888    | 1.0974    | .905      | .8954     | .905      | .905      | .905      |
| 6    | 1.386     | 1.3306    | 1.267     | 1.2536    | 1.2803    | 1.267     | 1.086     |
| 7    | 1.1888    | .924      | 1.1888    | 1.0745    | 1.134     | 1.086     | .905      |
| 8    | 1.086     |           | .9145     | .8954     | .9145     | .905      | .905      |
| 9    | .8059     | .9145     | .9145     | .8871     | .905      | .8145     | .823      |
| 10   | .724      | .7316     | .7964     | .788      | .8059     | .7164     | .724      |
| 11   | .7522     | .7316     | .6878     | .7164     | .724      | .7316     | .7164     |
| 12   | .8059     | .724      | .6805     | .5792     | .7164     | .6516     | .6878     |
| 13   | .7164     | .6154     | .6447     | .6154     | .5792     | .6447     | .724      |
| 14   | .6379     | .6516     | .6805     | .6733     | .6516     | .6024     | .7522     |
| 15   | .6805     | .6516     | .724      | .7442     | .7011     |           | .8145     |
| 16   | .724      | .6584     | .7602     | .7964     | .7164     |           | .8059     |
| 17   | .7164     | .7164     | .8145     | .6859     | .7628     | .8059     | .8596     |
| 18   | .9412     | .8145     | .788      | .7712     | .8413     | .8688     | .9465     |
| 19   | .9412     | .9774     | 1.0745    | 1.1088    | 1.1222    | 1.086     | 1.2178    |
| 20   | 1.0608    | 1.0974    | 1.1584    |           | 1.0608    | 1.0498    | 1.086     |
| 21   | .9955     | .9955     | 1.0059    | 1.0136    | 1.0608    | .905      | .985      |
| 22   | .905      | .905      | .7316     | .929      | .9145     |           |           |
| 23   | .7392     | .724      | .6401     | .7602     | .8145     |           | .8059     |
| 24   | .7522     | .724      | .724      | .6401     | .5792     | .6335     | .724      |
| Max  | 1.386     | 1.3306    | 1.267     | 1.2536    | 1.2803    | 1.267     | 1.2178    |
| Min  | .6379     | .6154     | .6401     | .5792     | .5792     | .6024     | .6878     |
| Avg  | .8728     | .8311     | .8332     | .8166     | .8407     | .8285     | .8461     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124018 / 33/11 KV NIMKHEDI S/S

Feeder No / Name : 205 / 11 KV SAVKHEDA EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0333     | .0352     | .0943     | .0943     | .0943     | .1886     | .1886     |
| 2    | .0213     | .0282     | .0943     | .0943     | .0943     | .1886     | .1886     |
| 3    | .0213     | .0305     | .0943     | .0943     | .0914     | .1886     | .1886     |
| 4    | .029      | .0286     | .0943     | .0943     | .0943     | .1886     | .1886     |
| 5    | .0293     | .0297     | .0943     | .0943     | .0943     | .1886     | .1886     |
| 6    | .0373     | .0343     | .0943     | .0943     | .0943     | .1886     | .1886     |
| 7    | .04       | .0343     | .0943     | .0943     | .1509     | .1886     | .1886     |
| 8    | .128      |           | .0943     | .0943     | .1463     | .1886     | .1886     |
| 9    | .1372     | .0572     | .0714     | .0524     | .2641     | .2667     | .2263     |
| 10   | .1372     | .1341     | .1448     | .0972     | .2641     | .3048     | .2641     |
| 11   | .1402     | .1715     | .0914     | .1029     | .2641     | .2829     | .2641     |
| 12   | .1372     | .1886     | .12       | .0972     | .3018     | .2641     | .3048     |
| 13   | .1086     | .0591     | .08       | .08       | .3048     | .2641     | .3048     |
| 14   | .1109     | .1296     | .08       | .0972     | .3018     | .3048     | .3018     |
| 15   | .1086     | .1219     | .0914     | .0914     | .3048     | .3018     | .2641     |
| 16   | .1109     | .0914     | .0972     | .0972     | .3018     | .3018     | .2641     |
| 17   | .1132     | .1132     | .0857     | .1027     | .2641     | .2452     | .2263     |
| 18   | .1132     | .1132     | .0812     | .0537     | .2263     | .2667     | .1886     |
| 19   | .1132     | .1029     | .0892     | .0434     | .2263     | .2286     | .1698     |
| 20   | .0453     | .1372     | .1132     | .0467     | .1886     | .1905     | .1698     |
| 21   | .0507     | .1132     | .1132     | .0448     | .2263     | .1886     | .2829     |
| 22   | .04       | .0943     | .0943     | .0613     | .1886     |           | .1886     |
| 23   |           | .0943     | .0943     | .0952     | .1886     |           | .1886     |
| 24   |           | .0533     | .0943     | .0943     | .0943     | .1886     | .2641     |
| Max  | .1402     | .1886     | .1448     | .1029     | .3048     | .3048     | .3048     |
| Min  | .0213     | .0282     | .0714     | .0434     | .0914     | .1886     | .1698     |
| Avg  | .0821     | .0868     | .0957     | .0838     | .1988     | .2322     | .2242     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124018 / 33/11 KV NIMKHEDI S/S

Feeder No / Name : 206 / 11 KV NIMKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2172     | .2218     | .181      | .2149     | .2172     | .2195     | .2172     |
| 2    | .2172     | .2195     | .181      | .1791     | .181      | .1829     | .181      |
| 3    | .2172     | .2195     | .181      | .1791     | .181      | .181      | .181      |
| 4    | .2172     | .2195     | .181      | .2149     | .181      | .181      | .2172     |
| 5    | .2378     | .2427     | .1791     | .2172     | .2172     | .2172     | .2195     |
| 6    | .2641     | .2641     | .2149     | .2172     | .2195     | .2715     | .2561     |
| 7    | .2641     | .2641     | .2686     | .2172     | .2263     | .2743     | .2195     |
| 8    | .2218     | .2241     | .1791     | .181      | .181      | .2195     | .2195     |
| 9    | .1791     | .1629     | .1829     | .1829     | .1715     | .181      | .1734     |
| 10   | .1753     | .1772     | .1433     | .1612     | .1734     | .1829     | .1696     |
| 11   | .1734     | .1417     | .2195     | .1448     | .1715     | .1658     | .1753     |
| 12   | .1791     | .1402     | .181      | .1433     | .1629     | .1734     | .1734     |
| 13   | .1448     | .1402     | .1772     | .1402     | .1417     | .2103     | .1734     |
| 14   | .1433     | .1646     | .1791     | .1753     | .1402     | .1715     | .1753     |
| 15   | .1448     | .181      | .1753     | .1772     | .1772     | .1715     | .1772     |
| 16   | .1372     | .197      | .2126     | .1578     | .1753     | .1734     | .1791     |
| 17   | .1029     | .181      | .1715     | .181      | .1907     | .2218     | .1848     |
| 18   | .1734     | .1791     | .1989     | .1753     | .1696     | .2195     | .2126     |
| 19   | .2058     | .1753     | .2058     | .2103     | .2172     | .2587     | .2481     |
| 20   | .2303     | .2103     | .2172     | .2149     | .2507     | .2534     | .2534     |
| 21   | .2303     | .2149     | .2058     | .2454     | .2715     | .2507     | .2658     |
| 22   | .2353     | .2172     | .2058     | .2126     | .2715     |           | .2658     |
| 23   | .2218     | .2172     | .2058     | .2172     | .2172     |           |           |
| 24   | .2534     | .2218     | .181      | .2401     | .2172     | .2172     | .2149     |
| Max  | .2641     | .2641     | .2686     | .2454     | .2715     | .2743     | .2658     |
| Min  | .1029     | .1402     | .1433     | .1402     | .1402     | .1658     | .1696     |
| Avg  | .1995     | .1999     | .1929     | .1917     | .1968     | .209      | .2067     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpra

Feeder No / Name : 202 / 11 KV PRAJAPAT NAGAR (Pre.

SHEDDABLE URBAN

Mam Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8573     | .9362     | .9214     | .823      | .823      | .8916     | .8573     |
| 2    | .823      | .9015     | .8954     | .7888     | .7888     | .8916     | .823      |
| 3    | .7888     | .9536     | .8413     | .7202     | .7545     | .8573     | .9259     |
| 4    | .9259     | 1.0402    | 1.0277    | .8916     | .8573     | .823      | .9602     |
| 5    | .9602     | 1.1269    | 1.0745    | .9945     | .8916     | .8916     | 1.0288    |
| 6    | .9945     | 1.1789    | 1.1222    | 1.046     | 1.0288    | 1.166     | 1.0974    |
| 7    | 1.1145    | 1.2483    | 1.3756    | 1.166     | 1.1317    | 1.2346    | 1.1145    |
| 8    | .9088     | 1.283     | 1.3073    | 1.1317    | 1.1145    | 1.0288    | 1.1317    |
| 9    | 1.1831    | 1.1963    | 1.2308    | 1.0974    | 1.1145    | .9259     | 1.166     |
| 10   | 1.0974    | 1.1317    | 1.1576    | .8573     | .9259     | 1.0117    | 1.0288    |
| 11   | 1.0117    | 1.0867    | 1.1576    | 1.0288    | 1.0117    | 1.0974    | 1.0631    |
| 12   | 1.1831    | 1.0974    | 1.0985    | 1.0631    | 1.046     | 1.1145    | 1.0802    |
| 13   | 1.0631    | 1.0631    | 1.0808    | 1.0631    | 1.0631    | 1.0974    | 1.0802    |
| 14   | .9602     | 1.0288    | .8859     | 1.0099    | .9602     | .9259     | .9431     |
| 15   | .9774     | 1.0117    | .9568     | .9088     | .8745     | .8745     | .9259     |
| 16   | 1.0117    | .9774     | .8954     | .8745     | .9259     | .8916     | .9259     |
| 17   | .9945     | .9088     | .8869     | .8745     | .8916     | .823      | .9088     |
| 18   | 1.0117    | .9088     | .9425     | .9088     | .8745     | .8916     | .9088     |
| 19   | 1.2003    | 1.0974    | 1.0498    |           | 1.1145    | 1.0631    | .9945     |
| 20   | 1.1831    | 1.2174    | 1.2489    | 1.166     | 1.1488    | 1.1831    | 1.1831    |
| 21   | 1.0802    | 1.1488    | 1.1041    | 1.0802    | 1.1488    | 1.0631    | 1.0117    |
| 22   | 1.046     | 1.1145    | 1.0974    | 1.0631    | 1.046     | 1.0288    | 1.0117    |
| 23   | .9774     | 1.0802    | .985      | .9745     | 1.0608    | 1.0425    | 1.0059    |
| 24   | .9088     | .9015     | .9991     | .8916     | .8573     | .9602     | .8916     |
| Max  | 1.2003    | 1.283     | 1.3756    | 1.166     | 1.1488    | 1.2346    | 1.1831    |
| Min  | .7888     | .9015     | .8413     | .7202     | .7545     | .823      | .823      |
| Avg  | 1.0109    | 1.0683    | 1.0559    | .9749     | .9773     | .9908     | 1.0028    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpra

Feeder No / Name : 203 / 11 KV SHIVAJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | .7373     |           |           |
| 7    | .7202     | .8299     | .7682     | .7373     |           |           |           |
| 8    |           | .7356     |           |           |           | .6173     |           |
| 9    |           |           |           |           |           | .6001     |           |
| 16   |           |           |           | .6173     |           |           |           |
| 17   |           | .5658     |           |           |           |           |           |
| 18   | .5144     |           |           | .5316     | .583      | .5487     | .6173     |
| 19   |           |           | .6268     |           |           |           |           |
| 24   | .7545     | .7522     | .8238     | .7888     | .6859     | .7888     | .7716     |
| Max  | .7545     | .8299     | .8238     | .7888     | .7373     | .7888     | .7716     |
| Min  | .5144     | .5658     | .6268     | .5316     | .583      | .5487     | .6173     |
| Avg  | .6630     | .7209     | .7396     | .6688     | .6687     | .6387     | .6945     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpra

Feeder No / Name : 204 / 11 KV Dudh Federation Exp. SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | .6516     |           |           |
| 7    | .6344     | .5853     | .6584     | .5316     |           |           | .4115     |
| 8    |           | .583      |           |           |           | .5144     |           |
| 9    |           |           |           |           |           | .5144     |           |
| 10   |           |           | .7701     |           |           |           |           |
| 11   |           |           |           |           |           | .6687     |           |
| 13   |           |           |           |           | .7373     |           |           |
| 15   |           | .6859     |           |           |           |           |           |
| 17   | .7545     | .7373     |           |           |           |           |           |
| 18   |           |           |           | .6859     | .7373     | .7202     | .6344     |
| 19   |           |           | .8505     |           |           |           |           |
| 22   | .6859     |           |           |           |           |           |           |
| 24   | .6516     | .8048     | .7619     | .703      | .7545     | .6516     | .7716     |
| Max  | .7545     | .8048     | .8505     | .703      | .7545     | .7202     | .7716     |
| Min  | .6344     | .583      | .6584     | .5316     | .6516     | .5144     | .4115     |
| Avg  | .6816     | .6793     | .7602     | .6402     | .7202     | .6139     | .6058     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpri)

Feeder No / Name : 205 / 11 KV LAKUDPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | 1.3375    |           |           |
| 7    | 1.166     | 1.4327    | 1.2936    | 1.166     |           |           |           |
| 8    |           | 1.4083    |           |           |           | 1.1145    |           |
| 9    |           |           |           |           |           | 1.1488    |           |
| 10   |           |           |           |           |           |           | 1.2003    |
| 11   |           |           |           | 1.1157    |           |           |           |
| 12   |           |           |           |           |           | .9431     |           |
| 14   |           |           |           |           | .9945     |           |           |
| 16   |           |           |           | 1.1317    |           |           |           |
| 17   | .9088     | 1.0288    |           |           |           |           |           |
| 18   |           |           |           | .9774     | 1.0288    | 1.0117    | .9774     |
| 19   |           |           | 1.2197    |           |           |           |           |
| 20   | 1.1488    |           |           |           |           |           |           |
| 24   | 1.1831    | 1.2048    | 1.2226    | 1.2174    | 1.2003    | 1.2346    | 1.2517    |
| Max  | 1.1831    | 1.4327    | 1.2936    | 1.2174    | 1.3375    | 1.2346    | 1.2517    |
| Min  | .9088     | 1.0288    | 1.2197    | .9774     | .9945     | .9431     | .9774     |
| Avg  | 1.1017    | 1.2687    | 1.2453    | 1.1216    | 1.1403    | 1.0905    | 1.1431    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpri)

Feeder No / Name : 206 / 11 KV Railway Exp.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | .1029     |           |           |
| 7    | .0857     | .0943     | .0924     | .0857     |           |           | .0686     |
| 8    |           | .0943     |           |           |           | .1029     |           |
| 9    |           |           |           |           |           | .1029     |           |
| 10   |           |           | .1086     |           |           |           |           |
| 17   | .1029     |           |           |           |           |           |           |
| 18   |           |           |           | .1029     | .12       | .1029     | .12       |
| 19   |           | .1029     | .1227     |           |           |           |           |
| 24   | .1029     | .132      | .1075     | .1029     | .1029     | .12       | .12       |
| Max  | .1029     | .132      | .1227     | .1029     | .12       | .12       | .12       |
| Min  | .0857     | .0943     | .0924     | .0857     | .1029     | .1029     | .0686     |
| Avg  | .0972     | .1059     | .1078     | .0972     | .1086     | .1072     | .1029     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpri)

Feeder No / Name : 209 / 11 KV S. K. Oil Mill

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0343     | .0175     | .0362     | .0171     | .0171     | .0171     | .0171     |
| 2    | .0343     | .0175     | .0347     | .0171     | .0171     | .0171     | .0343     |
| 3    | .0171     | .0175     | .0351     | .0171     | .0171     | .0171     | .0343     |
| 4    | .0171     | .0351     | .0354     | .0171     | .0171     | .0171     | .0343     |
| 5    | .0171     | .0351     | .0354     | .0171     | .0171     | .0171     | .0171     |
| 6    | .0171     | .0351     | .0347     | .0171     | .0171     | .0171     | .0171     |
| 7    | .0171     | .0175     | .0358     | .0171     | .0171     | .0171     | .0171     |
| 8    | .0171     | .0171     | .0173     | .0171     | .0171     | .0171     | .0343     |
| 9    | .0171     | .0343     | .0351     | .0171     | .0343     | .0343     | .0343     |
| 10   | .0171     | .0343     | .0373     | .0343     | .0343     | .0171     | .0343     |
| 11   | .0171     | .0373     | .0187     | .0514     | .0343     | .0171     |           |
| 12   | .0171     | .0343     | .0183     | .0187     | .0171     | .0171     | .0514     |
| 13   | .0171     | 1.406     | .0366     | .0187     | .0343     | .0171     | .0514     |
| 14   | .0171     | .0514     | .0549     | .0187     | .0343     | .0343     | .0343     |
| 15   | .0171     | .0514     | .0732     | .0373     | .0171     | .0686     | .0514     |
| 16   | .0171     | .0514     | .0724     | .0171     |           | .0514     | .0514     |
| 17   | .0171     | .0686     | .0354     | .0171     | .0171     | .0343     | .0514     |
| 18   | .0171     | .0343     | .0181     |           | .0171     | .0171     | .0514     |
| 19   | .0343     |           | .0131     |           | .0171     | .0171     | .0171     |
| 20   | .0343     |           | .0128     | .0171     | .0171     |           | .0171     |
| 21   | .0343     | .0343     | .012      | .0171     | .0171     | .0171     | .0343     |
| 22   | .0343     | .0343     | .0124     | .0171     | .0171     | .0171     | .0343     |
| 23   | .0171     | .0343     | .012      | .0131     | .0181     | .0358     | .0343     |
| 24   | .0343     | .0351     | .0358     | .0171     | .0171     | .0171     | .0343     |
| Max  | .0343     | 1.406     | .0732     | .0514     | .0343     | .0686     | .0514     |
| Min  | .0171     | .0171     | .012      | .0131     | .0171     | .0171     | .0171     |
| Avg  | .0221     | .0970     | .0318     | .0204     | .0209     | .0239     | .0343     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124019 / 33/11 KV SHIVAJI NAGAR

(Pimpra

Feeder No / Name : 210 / 11 kV Gendalal Mill

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | 1.2174    |           |           |
| 7    | 1.5604    | 1.5893    | 1.5893    | 1.5432    |           |           | 1.5775    |
| 8    |           | 1.3889    |           |           |           | 1.4232    |           |
| 9    |           |           |           |           |           | 1.3203    |           |
| 11   |           | 1.0349    |           | 1.2254    |           |           |           |
| 12   |           |           |           | 1.2437    |           | 1.166     |           |
| 14   |           |           |           |           | .9088     |           |           |
| 16   |           |           |           | .9431     |           |           |           |
| 17   | .9431     |           |           |           |           |           |           |
| 18   |           |           |           | .9431     | .9774     | .6859     | 1.0288    |
| 19   |           | .8745     | 1.1706    |           |           |           |           |
| 24   | .9088     | .9602     | 1.0029    | .9431     | .9602     | .9774     | .9945     |
| Max  | 1.5604    | 1.5893    | 1.5893    | 1.5432    | 1.2174    | 1.4232    | 1.5775    |
| Min  | .9088     | .8745     | 1.0029    | .9431     | .9088     | .6859     | .9945     |
| Avg  | 1.1374    | 1.1696    | 1.2543    | 1.1403    | 1.0160    | 1.1146    | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124089 / 33/11 KV RING ROAD S/S

Feeder No / Name : 201 / 11 kV Ring Road Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .8859     | .905      | .9412     | .8954     | .9412     | .9955     | 1.0029    |
| 8    | .9313     | .9412     | .9036     | .7973     | .8682     | .9774     | .8589     |
| 12   | 1.0517    | 1.1946    | 1.1584    | 1.382     | 1.1888    | 1.1765    | 1.2715    |
| 16   | 1.0608    | 1.3169    | 1.262     | 1.39      | 1.3169    | 1.1462    | 1.262     |
| 20   | 1.0608    | 1.1462    | 1.1041    | 1.1283    | 1.1706    | 1.0745    | 1.1104    |
| 24   | 1.1222    | 1.134     | 1.2254    | 1.1222    | 1.2254    | 1.2437    | 1.1706    |
| Max  | 1.1222    | 1.3169    | 1.262     | 1.39      | 1.3169    | 1.2437    | 1.2715    |
| Min  | .8859     | .905      | .9036     | .7973     | .8682     | .9774     | .8589     |
| Avg  | 1.0188    | 1.1063    | 1.0991    | 1.1192    | 1.1185    | 1.1023    | 1.1127    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124089 / 33/11 KV RING ROAD S/S

Feeder No / Name : 202 / 11 kV Ganesh Colony feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .9671     | 1.1088    | 1.1765    | 1.2178    | 1.1765    | 1.1222    | 1.1222    |
| 8    | .8328     | .905      | .8328     | .8589     | .8417     | .905      | .8413     |
| 12   | 1.0745    | .9671     | .9955     | 1.1919    | .9774     | .9492     | 1.0387    |
| 16   | 1.0974    | 1.2071    | 1.2254    | 1.3937    | 1.1888    | 1.1157    | 1.2308    |
| 20   | 1.2071    | 1.1104    | 1.1462    | 1.182     | 1.2071    | 1.2071    | 1.1641    |
| 24   | 1.2986    | 1.4784    | 1.5364    | 1.4632    | 1.4998    | 1.5729    | 1.4266    |
| Max  | 1.2986    | 1.4784    | 1.5364    | 1.4632    | 1.4998    | 1.5729    | 1.4266    |
| Min  | .8328     | .905      | .8328     | .8589     | .8417     | .905      | .8413     |
| Avg  | 1.0796    | 1.1295    | 1.1521    | 1.2179    | 1.1486    | 1.1454    | 1.1373    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124089 / 33/11 KV RING ROAD S/S

Feeder No / Name : 203 / 11 kV Forest Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.0808    | 1.0498    |           | 1.1946    | 1.1104    | 1.2489    | 1.2127    |
| 7    |           |           | 1.1283    |           |           |           |           |
| 8    | 1.0692    | 1.0608    | 1.1104    | 1.182     | 1.1222    | 1.1041    | 1.1517    |
| 12   | 1.2127    | 1.4449    | 1.4299    | 1.5043    | 1.3352    | 1.5203    | 1.3575    |
| 16   | 1.1706    | 1.5912    | 1.5912    | 1.5912    | 1.5729    | 1.5565    | 1.4998    |
| 20   | 1.3535    | 1.5203    | 1.6651    | 1.6289    | 1.6644    | 1.5912    |           |
| 24   | 1.2308    | 1.4266    | 1.3756    | 1.4299    | 1.4118    | 1.4632    | 1.3394    |
| Max  | 1.3535    | 1.5912    | 1.6651    | 1.6289    | 1.6644    | 1.5912    | 1.4998    |
| Min  | 1.0692    | 1.0498    | 1.1104    | 1.182     | 1.1104    | 1.1041    | 1.1517    |
| Avg  | 1.1863    | 1.3489    | 1.3834    | 1.4218    | 1.3695    | 1.4140    | 1.3122    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124089 / 33/11 KV RING ROAD S/S

Feeder No / Name : 204 / 11 kV Shiv Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.1523    | 1.262     | 1.3575    | 1.4842    | 1.448     | 1.3032    | 1.3575    |
| 8    | 1.2308    | 1.267     | 1.2178    | 1.2357    | 1.3432    | 1.2986    | 1.2536    |
| 12   | 1.0608    | 1.0277    | .985      | 1.0454    | 1.086     | 1.0631    | 1.1104    |
| 16   | 1.1706    | 1.2357    | 1.2308    | 1.2127    | 1.3717    | 1.2178    | 1.3213    |
| 20   | 1.4266    | 1.5043    | 1.576     | 1.5402    | 1.5729    | 1.6095    | 1.5043    |
| 24   | 1.5746    | 1.6078    | 1.6827    | 1.7737    | 1.7193    | 1.7375    | 1.7558    |
| Max  | 1.5746    | 1.6078    | 1.6827    | 1.7737    | 1.7193    | 1.7375    | 1.7558    |
| Min  | 1.0608    | 1.0277    | .985      | 1.0454    | 1.086     | 1.0631    | 1.1104    |
| Avg  | 1.2693    | 1.3174    | 1.3416    | 1.3820    | 1.4235    | 1.3716    | 1.3838    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124089 / 33/11 KV RING ROAD S/S

Feeder No / Name : 205 / 11 kV Bhaskar Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .6068     | .5731     | .6201     | .6268     | .591      | .567      | .6068     |
| 8    | .5201     | .5548     | .5548     | .5493     | .6556     | .5609     | .5548     |
| 12   | .5258     | .8145     | .7964     | .7522     | .8238     | .7796     | .7164     |
| 16   | .567      | .9145     | .9145     | .8048     | .905      | .7522     | .8326     |
| 20   | .7164     | .9412     | .9412     | .905      | .7964     | .8779     | .9671     |
| 24   | .6805     | .7602     | .7164     | .7522     | .7421     | .7602     | .7164     |
| Max  | .7164     | .9412     | .9412     | .905      | .905      | .8779     | .9671     |
| Min  | .5201     | .5548     | .5548     | .5493     | .591      | .5609     | .5548     |
| Avg  | .6028     | .7597     | .7572     | .7317     | .7523     | .7163     | .7324     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124122 / 33/11 KV HUDCO (Pimprala)

S/S

Feeder No / Name : 201 / 11 KV SANT MIRABAI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0288    | 1.0288    |           | 1.0117    | 1.1641    |           | 1.0631    |
| 2    | 1.046     | .9431     | .0257     |           | 1.1641    | .0257     | 1.0117    |
| 3    | 1.0631    | .9602     |           | 1.0117    | 1.1999    |           | 1.0117    |
| 4    | 1.0631    | .9602     | .024      | 1.0288    | 1.2178    | .0257     | .9602     |
| 5    | 1.0802    | 1.0631    |           | 1.0288    | 1.2536    |           | 1.0117    |
| 6    | 1.1145    | 1.2517    | .0274     | 1.046     | 1.182     | .0257     | 1.046     |
| 7    | 1.1317    | 1.0974    | .0257     | 1.0288    | 1.1403    | .0257     | 1.0117    |
| 8    | .9431     | .9088     | .0223     | .823      | .9492     | .024      | .9088     |
| 9    | .8059     | .8059     | .0189     | .7888     | .8238     | .0189     | .8573     |
| 10   | .7888     | .0189     | .7716     | .7522     | .0171     | .7545     | .0206     |
| 11   | .7545     | .0189     | .7373     | .7343     | .0223     | .7888     | .0189     |
| 12   | .7716     | .0223     | .7716     | .7701     | .0223     | .823      | .0189     |
| 13   | .7716     | .0223     | .823      | .8238     | .0206     | .823      | .0223     |
| 14   | .8916     | .0223     | .8573     | .8954     | .0223     | .9259     | .0223     |
| 15   | .8916     | .0223     | .8573     | .8954     | .0223     | .9088     | .0223     |
| 16   | .8745     | .0223     | .8573     | .8417     | .0223     | .9259     | .024      |
| 17   | .8916     | .0223     | .8573     | .8417     | .0223     | .9431     | .024      |
| 18   | .8745     | .0223     | .823      | .8238     | .0189     | .8916     |           |
| 19   | .9945     | .024      | 1.0288    | .9134     | .0257     | .9945     |           |
| 20   | 1.0974    | .0274     | 1.1145    | 1.1641    | .0274     | 1.166     | .0291     |
| 21   | 1.1317    | .0291     | 1.1317    | 1.2178    | .0291     | 1.2003    | .0291     |
| 22   | 1.166     | .0309     | 1.1488    | 1.2715    | .0291     | 1.2174    | .0291     |
| 23   | 1.1317    |           | 1.1831    | 1.2357    |           | 1.2174    |           |
| 24   | 1.0631    | 1.046     | .0257     | 1.1641    |           | .0274     | 1.0974    |
| Max  | 1.166     | 1.2517    | 1.1831    | 1.2715    | 1.2536    | 1.2174    | 1.0974    |
| Min  | .7545     | .0189     | .0189     | .7343     | .0171     | .0189     | .0189     |
| Avg  | .9738     | .4509     | .6253     | .9614     | .4726     | .6549     | .4876     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124122 / 33/11 KV HUDCO (Pimprala)

S/S

Feeder No / Name : 202 / 11 KV BHAVANI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.2003    |           | 1.2174    | 1.3575    |           | 1.1488    |
| 2    |           | 1.1488    | .0274     |           | 1.3575    | .0291     | 1.1488    |
| 3    | 1.0802    | 1.0288    |           | 1.1831    | 1.3213    |           | 1.0974    |
| 4    | 1.0802    | .9602     | .0257     | 1.166     | 1.267     | .0291     | 1.0631    |
| 5    | 1.0631    | 1.0288    |           | 1.1488    | 1.2308    |           | 1.0631    |
| 6    | 1.0631    | 1.1317    | .0343     | 1.166     | 1.1765    | .0343     | 1.0802    |
| 7    | 1.0631    | .9945     | .0326     | 1.0802    | 1.1403    | .0291     | 1.0631    |
| 8    | .9259     | .9259     | .0291     | .4973     | 1.0317    | .0291     | .9774     |
| 9    | .823      | .9088     | .0257     | .4287     | .9231     | .0257     | .8573     |
| 10   | .9088     | .0206     | .9431     | .8507     | 7.7161    | .8916     | .0223     |
| 11   | .823      | .0189     | 1.0631    | .8688     | 6.8587    | .9945     | .0206     |
| 12   | .8402     | .0206     | .8573     | .8869     | 7.2874    | .9945     | .0223     |
| 13   | .8745     | .0223     | .9774     | .9231     | 7.2874    | .9945     | .0223     |
| 14   | .9088     | .0223     | .9602     | .9774     | .024      | .9945     | .0257     |
| 15   | .9945     | .024      | 1.0631    | 1.086     | .0257     | 1.0802    | .0257     |
| 16   | .9945     | .0223     | .9774     | 1.0679    | 7.2874    | 1.0631    | .0257     |
| 17   | .9259     | .024      | .3086     | .9593     | .0257     | .9602     | .0274     |
| 18   | .8916     | .0223     | .9088     | .905      | .024      | .8745     |           |
| 19   | 1.0631    | .0257     | 1.1145    | 1.0498    | .0257     | 1.0117    |           |
| 20   | 1.1488    | .0291     | 1.2003    | 1.267     | .0291     | 1.2346    | .036      |
| 21   | 1.166     | .0309     | .4115     | 1.3575    | .0291     | 1.2689    | .0291     |
| 22   | 1.2689    | .0291     | 1.406     | 1.4299    | .0326     | 1.3546    | .0343     |
| 23   |           |           | 1.3375    | 1.4842    |           | 1.406     |           |
| 24   | 1.2003    | 1.3032    | .0309     | 1.3756    |           | .0309     | 1.2689    |
| Max  | 1.2689    | 1.3032    | 1.406     | 1.4842    | 7.7161    | 1.406     | 1.2689    |
| Min  | .823      | .0189     | .0257     | .4287     | .024      | .0257     | .0206     |
| Avg  | 1.0051    | .4758     | .6540     | 1.0599    | 2.1572    | .7300     | .5266     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124122 / 33/11 KV HUDCO (Pimprala)

S/S

Feeder No / Name : 203 / 11 KV HUDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .703      | .6859     |           | .6859     | .7762     |           | .6859     |
| 2    | .7202     | .6516     | ***       |           | .8131     | .0171     | .6173     |
| 3    | .7373     | .6516     |           | .7373     | .8871     |           | .6859     |
| 4    | .7373     | .6516     | .0171     | .7545     | .9795     |           | .6859     |
| 5    | .823      | .6859     |           | .823      | 1.0164    |           | .7202     |
| 6    | .823      | .9088     | .0206     | .8916     | 1.0903    | .0223     | .823      |
| 7    | .9088     | 1.0288    | .024      | 1.0288    | 1.1458    | .024      | .9431     |
| 8    | 1.0288    | .9259     | .0223     | .8916     | .961      | .0223     | .823      |
| 9    | .823      | .703      | ***       | .7888     | .8686     | .0223     | .8059     |
| 10   | .7716     | .0171     | .6687     | .7762     | .0171     | .7545     | .0189     |
| 11   | .7202     | .0171     | .6859     | .6838     | .0189     | .7716     | .0171     |
| 12   | .8059     | .0189     | .6859     | .6838     | .0171     | .8059     | .0171     |
| 13   | .7202     | .0171     | .6859     | .6838     | ***       | .6516     | .0171     |
| 14   | .6516     | .0171     | .823      | .6838     | ***       | .6173     | .0171     |
| 15   | .6173     | .0206     | .6173     | .6653     | ***       | .6173     | ***       |
| 16   | .6687     | .0206     | .583      | .6838     | ***       | .6173     | ***       |
| 17   | .6344     | .0189     | .6173     | .6838     | ***       | .6173     | ***       |
| 18   | .6859     | .0171     | .6859     | .6838     | .0171     | .7545     |           |
| 19   | .8573     | .0206     | .9088     | .8686     | .0206     | .8745     |           |
| 20   | .8916     | .0223     | .8573     | .961      | .0223     | .9088     | .024      |
| 21   | .8059     | .0189     | .823      | .8686     | .0206     | .823      | .0223     |
| 22   | .7716     | .0206     | .7716     | .8507     | .0189     | .7716     | .0171     |
| 23   | .7373     |           | .7373     | .8501     |           | .7545     |           |
| 24   | .7202     | .6859     | .0171     | .7762     |           | .0171     | .703      |
| Max  | 1.0288    | 1.0288    | 16.2895   | 1.0288    | 15.4321   | .9088     | 16.2895   |
| Min  | .6173     | .0171     | .0171     | .6653     | .0171     | .0171     | .0171     |
| Avg  | .7652     | .3403     | 2.0396    | .7828     | 3.7659    | .5232     | 2.6707    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON U-II S/DN.[237] BU 4237

Substation No/ Name :- 124122 / 33/11 KV HUDCO (Pimprala)

S/S

Feeder No / Name : 204 / 11 kV Khanderao Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3772     | .3944     |           |           |           | .4115     |
| 2    | .3772     | .3772     | 8.5734    |           | 9.4307    | .3944     |
| 3    |           | .3944     |           |           |           | .4115     |
| 4    | .4458     | .3944     | 8.5734    |           | ***       | .4115     |
| 5    |           | .463      |           |           |           | .4801     |
| 6    | .5487     | .6516     | ***       |           | ***       | .5487     |
| 7    | .6001     | .6516     | ***       |           | ***       | .5658     |
| 8    | .4973     | .5316     | ***       |           | ***       | .5658     |
| 9    | .4115     | .3772     | 9.4307    |           | 9.4307    | .4115     |
| 10   | .4115     | 6.0014    | .3429     |           | .4115     | 9.4307    |
| 11   | .3944     | 5.5727    | .3429     |           | .3944     | 7.2874    |
| 12   | .3429     | 6.0014    |           |           | .3601     | 7.2874    |
| 13   | .3086     | 6.8587    |           |           | .3601     | 6.4301    |
| 14   | .3086     | 6.8587    |           |           | .3086     | 6.8587    |
| 15   | .3086     | 6.0014    |           |           | .3086     | 7.2874    |
| 16   | .3086     | 6.4301    |           |           | .3086     | 7.2874    |
| 17   | .3086     | 6.4301    |           | 8.1447    | .3258     | 7.2874    |
| 18   | .2743     | 8.1447    |           | 6.8587    | .3258     |           |
| 19   | .3944     | ***       |           | ***       | .4287     |           |
| 20   | .4973     | ***       |           | 9.4307    | .4801     | ***       |
| 21   | .4458     | 9.8594    |           | 9.8594    | .4973     | 9.8594    |
| 22   | .4458     | ***       |           | ***       | .4801     | ***       |
| 23   | .4115     |           |           |           | .463      |           |
| 24   | .3772     | .3944     | 9.8594    |           | ***       | .4115     |
| Max  | .6001     | 11.1454   | 16.2895   | 11.1454   | 15.0035   | 11.1454   |
| Min  | .2743     | .3772     | .3429     | 6.8587    | .3086     | .3944     |
| Avg  | .3998     | 4.5812    | 8.9354    | 9.2878    | 4.1177    | 4.5267    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124020 / 33/11 KV VIDGAON

Feeder No / Name : 201 / 11 KV Vidgaon Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 10-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5944     |           |           |           |
| 5    |           |           | .6865     |           |
| 8    | .7011     |           | .8633     | .7011     |
| 12   |           | .8535     |           |           |
| 16   |           | .884      |           |           |
| 24   | .5792     |           | .628      | .6401     |
| Max  | .7011     | .884      | .8633     | .7011     |
| Min  | .5792     | .8535     | .628      | .6401     |
| Avg  | .6249     | .8688     | .7259     | .6706     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124020 / 33/11 KV VIDGAON

Feeder No / Name : 203 / 11 KV Ridhur AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 10-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .945      |           |           |           |
| 5    |           |           | .5089     |           |
| 8    | 1.0974    |           | 1.3492    | .9755     |
| 12   |           | 1.0974    |           |           |
| 16   |           | 1.1888    |           |           |
| 24   | .9145     |           | 1.05      | .9145     |
| Max  | 1.0974    | 1.1888    | 1.3492    | .9755     |
| Min  | .9145     | 1.0974    | .5089     | .9145     |
| Avg  | .9856     | 1.1431    | .9694     | .945      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124020 / 33/11 KV VIDGAON

Feeder No / Name : 204 / 11 KV Vidgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.0317    |           |           |           |           |           |           |
| 5    |           |           |           |           |           | 1.5556    |           |
| 8    | 1.6289    |           |           | 1.4299    | 1.4661    | 1.5556    | 1.3394    |
| 9    |           | 1.1134    | 1.5746    |           |           |           |           |
| 11   | .8978     |           |           |           |           |           |           |
| 12   |           |           | .8688     |           |           | .7964     |           |
| 16   |           |           | .9774     |           |           | .9231     |           |
| 20   |           |           | 1.647     |           |           | 1.448     |           |
| 24   | .7964     | .7721     | .8326     | .8326     | .8688     | .8308     | .8145     |
| Max  | 1.6289    | 1.1134    | 1.647     | 1.4299    | 1.4661    | 1.5556    | 1.3394    |
| Min  | .7964     | .7721     | .8326     | .8326     | .8688     | .7964     | .8145     |
| Avg  | 1.0887    | .9428     | 1.1801    | 1.1313    | 1.1675    | 1.1849    | 1.0770    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124020 / 33/11 KV VIDGAON

Feeder No / Name : 205 / 11 KV Diksai Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           |           |           |           |           | .5149     |           |
| 8    | .5359     |           |           | .4805     | .499      | .4938     | .499      |
| 9    |           | .3782     | .4066     |           |           |           |           |
| 11   | .2071     |           |           |           |           |           |           |
| 12   |           |           | .1663     |           |           | .1478     |           |
| 16   |           |           | .1848     |           |           | .2033     |           |
| 20   |           |           | .462      |           |           | .4435     |           |
| 24   | .2402     | .2033     | .2218     | .2218     | .2402     | .2259     | .2218     |
| Max  | .5359     | .3782     | .462      | .4805     | .499      | .5149     | .499      |
| Min  | .2071     | .2033     | .1663     | .2218     | .2402     | .1478     | .2218     |
| Avg  | .3277     | .2908     | .2883     | .3512     | .3696     | .3382     | .3604     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124020 / 33/11 KV VIDGAON

Feeder No / Name : 208 / 11 kV Bhagirath Gening  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5093     |           |           |           |           |           |           |
| 5    |           |           |           |           |           | .6005     |           |
| 8    | .5658     |           |           | .5658     | .5093     | .629      | .547      |
| 9    |           | .5823     | .5658     |           |           |           |           |
| 11   | .6111     |           |           |           |           |           |           |
| 12   |           |           | .6036     |           |           | .6413     |           |
| 16   |           |           | .6413     |           |           | .5658     |           |
| 20   |           |           | .5281     |           |           | .5175     |           |
| 24   | .5093     | .563      | .5281     | .4715     | .5093     | .6296     | .6224     |
| Max  | .6111     | .5823     | .6413     | .5658     | .5093     | .6413     | .6224     |
| Min  | .5093     | .563      | .5281     | .4715     | .5093     | .5175     | .547      |
| Avg  | .5489     | .5727     | .5734     | .5187     | .5093     | .5973     | .5847     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238]

BU 5665

Substation No/ Name :- 124021 / 33/11 KV MASAWAD

Feeder No / Name : 202 / 11 KV Wawlada Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5601     | .567      | .5729     |           | .5975     | .567      |           |
| 2    | .5601     |           |           |           | .5975     | .6099     | .5544     |
| 3    | .6722     | .7023     | .6584     |           | .7023     | .7392     |           |
| 4    | .9709     |           |           | .7762     | .8962     | .9522     | .924      |
| 5    | 1.1949    | 1.2637    | 1.2449    |           | 1.1827    | 1.2826    | 1.1949    |
| 6    | 1.3306    |           | 1.4712    |           | 1.5154    | 1.6409    | 1.4377    |
| 7    | 1.1827    | 1.1203    | 1.2449    |           | 1.2567    | 1.3256    | 1.1763    |
| 8    | .8871     | .8962     |           | 1.0269    | .924      | .8215     | .961      |
| 9    |           | .7842     |           | .7095     | .7392     | .7392     |           |
| 10   |           | .5914     |           | .6283     | .6036     | .5792     |           |
| 11   | .5914     | .5175     |           | .5544     | .4344     | .5249     |           |
| 12   |           |           | .4755     | .4854     | .4938     | .4755     | .4477     |
| 13   |           |           |           | .4805     | .439      | .4755     |           |
| 14   | .6516     |           |           | .5175     | .5068     | .5068     |           |
| 15   |           | .4755     |           | .5729     | .5304     |           |           |
| 16   | .7499     | .6283     | .3881     | .6653     | .5853     | .5304     | .5729     |
| 17   | .8131     | .8131     |           | .6653     | .6767     | .6584     |           |
| 18   | .8501     | .8871     |           |           | .8686     | .8048     |           |
| 19   | 1.2449    | 1.2826    |           | 1.1458    | 1.2826    | 1.1088    |           |
| 20   |           | 1.0185    | 1.0751    | .961      | 1.0082    | .9335     |           |
| 21   |           |           |           | .7842     | .8501     | .8775     |           |
| 22   | .6908     |           |           | .6722     | .7207     |           |           |
| 23   | .5914     |           |           | .5914     | .6099     | .6219     |           |
| 24   | .5544     | .5729     |           | .567      | .5914     | .567      |           |
| Max  | 1.3306    | 1.2826    | 1.4712    | 1.1458    | 1.5154    | 1.6409    | 1.4377    |
| Min  | .5544     | .4755     | .3881     | .4805     | .4344     | .4755     | .4477     |
| Avg  | .8292     | .8080     | .8914     | .6943     | .7755     | .7883     | .9086     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124021 / 33/11 KV MASAWAD

Feeder No / Name : 204 / 11 KV Wavadada PURE AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4329     |           |           |           |           | .4978     |           |
| 2    | .4329     |           |           |           |           | .4864     | .4405     |
| 3    | .4801     |           |           |           |           | .4534     |           |
| 4    | .5487     |           |           |           |           | .4405     | .4212     |
| 5    | .5952     |           |           |           |           | .4527     | .4468     |
| 6    | .6584     |           |           |           |           | .4904     | .4652     |
| 7    | .7545     |           |           |           |           | .5784     | .6127     |
| 8    | .7034     |           |           |           |           | .6341     | .6967     |
| 9    | .6348     |           |           |           |           | .5365     |           |
| 11   |           | .8431     |           | .7956     | .719      |           |           |
| 12   |           |           | 1.0227    | .7846     | .7472     |           |           |
| 13   |           |           |           | .8657     | .6584     |           |           |
| 14   |           | .9259     |           | .7472     | .5653     |           |           |
| 15   |           | .8215     |           | .6493     | .5468     |           |           |
| 16   |           | .7305     | .8718     | .6087     | .6036     |           |           |
| 17   |           | .651      |           | .6493     | .6222     |           |           |
| 18   |           | .5944     |           | .6493     | .4371     |           |           |
| 24   | .439      |           |           |           |           | .5312     | .514      |
| Max  | .7545     | .9259     | 1.0227    | .8657     | .7472     | .6341     | .6967     |
| Min  | .4329     | .5944     | .8718     | .6087     | .4371     | .4405     | .4212     |
| Avg  | .5680     | .7611     | .9473     | .7187     | .6125     | .5101     | .5139     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238]

BU 5665

Substation No/ Name :- 124021 / 33/11 KV MASAWAD

Feeder No / Name : 205 / 11 kV Lamanjan Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.3226    | 1.2986    |           | .9739     |           |           |
| 2    |           |           |           |           | .9877     |           |           |
| 3    |           | 1.4723    | 1.423     |           | .9877     |           |           |
| 4    |           |           |           | .9574     | 1.07      |           |           |
| 5    |           | 1.3969    | 1.3256    |           | 1.0822    |           |           |
| 6    |           |           | 1.358     |           | 1.0957    |           |           |
| 7    |           | 1.5091    | 1.448     | 1.3256    | 1.1092    |           |           |
| 8    |           | 1.6263    |           | 1.1498    | 1.0562    |           |           |
| 9    |           | 1.576     |           | 1.028     | 1.1092    |           |           |
| 11   | 1.8665    |           |           |           |           | 1.6832    | 1.2483    |
| 12   |           |           |           |           |           | 1.7741    | 1.2127    |
| 13   |           |           |           |           |           | 1.7741    |           |
| 14   | 1.7194    |           |           |           |           | 1.6834    |           |
| 15   |           |           |           |           |           | 1.5775    |           |
| 16   | 1.4217    |           |           |           |           | 1.5947    | 2.5064    |
| 17   | 1.2929    |           |           |           |           | 1.3923    |           |
| 18   | 1.1883    |           |           |           |           | 1.2403    | 1.1385    |
| 24   |           | 1.3375    |           | 1.2483    | .9739     |           |           |
| Max  | 1.8665    | 1.6263    | 1.448     | 1.3256    | 1.1092    | 1.7741    | 2.5064    |
| Min  | 1.1883    | 1.3226    | 1.2986    | .9574     | .9739     | 1.2403    | 1.1385    |
| Avg  | 1.4978    | 1.4630    | 1.3706    | 1.1418    | 1.0446    | 1.5900    | 1.5265    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238]

BU 5665

Substation No/ Name :- 124021 / 33/11 KV MASAWAD

Feeder No / Name : 206 / 11 kV OM GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0185     | .0838     | .0714     |           | .1086     | .0191     |           |
| 2    | .0175     |           |           |           | .1448     | .0191     | .0669     |
| 3    | .0181     | .072      | .0734     |           | .1448     | .0191     |           |
| 4    | .0181     |           |           | .0714     | .0886     | .0191     | .0857     |
| 5    | .0183     | .0732     | .0829     |           | .0701     | .0191     | .0945     |
| 6    | .0183     |           | .0943     |           | .0716     | .0191     | .1036     |
| 7    | .0183     | .0019     | .0819     |           | .0724     | .0191     | .0907     |
| 8    | .0181     | .0019     |           | .0781     | .0701     | .0191     | .0743     |
| 9    | .0705     | .0019     |           | .0362     | .0633     | .0191     |           |
| 10   |           | .0019     |           | .0183     | .0572     | .0633     |           |
| 11   |           | .0019     |           | .0181     | .0495     | .0617     |           |
| 12   |           |           | .116      | .0183     | .0572     | .0633     | .0497     |
| 13   |           |           |           | .0181     |           | .0191     |           |
| 14   | .0734     |           |           | .0905     |           | .0191     |           |
| 15   |           | .0019     |           | .0876     |           | .0191     |           |
| 16   | .08       | .0019     | .0838     | .0895     | .0695     | .0191     | .0509     |
| 17   | .0829     | .0724     |           | .1097     | .0714     | .0191     |           |
| 18   | .0943     | .0753     |           | .0724     | .0705     | .0191     |           |
| 19   | .1162     | .0619     |           | .0876     | .0191     | .0549     |           |
| 20   |           | .0743     | .0857     | .0724     | .0191     | .0518     |           |
| 21   |           |           |           | .0701     | .0191     | .0514     |           |
| 22   | .0838     |           |           | .0724     | .0191     |           |           |
| 23   | .0781     |           |           | .0724     | .0191     | .032      |           |
| 24   | .0185     | .0772     |           | .1658     | .0701     | .0191     | .0566     |
| Max  | .1162     | .0838     | .116      | .1658     | .1448     | .0633     | .1036     |
| Min  | .0175     | .0019     | .0714     | .0181     | .0191     | .0191     | .0497     |
| Avg  | .0496     | .0402     | .0862     | .0694     | .0655     | .0297     | .0748     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124106 / 33 / 11 KV Kanalda S/S

Feeder No / Name : 201 / 11 Kv Nandra Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.1022    |           |           |           |           | .9602     | 1.419     |
| 8    | 1.2887    |           |           |           |           | 1.1736    | 1.419     |
| 12   |           | 1.7924    | 1.6956    | 1.587     | 1.4327    |           |           |
| 16   |           | 1.8298    | 1.6956    | 1.4937    | 1.326     |           |           |
| 24   | 1.1869    |           |           |           |           | 1.1431    | 1.2696    |
| Max  | 1.2887    | 1.8298    | 1.6956    | 1.587     | 1.4327    | 1.1736    | 1.419     |
| Min  | 1.1022    | 1.7924    | 1.6956    | 1.4937    | 1.326     | .9602     | 1.2696    |
| Avg  | 1.1926    | 1.8111    | 1.6956    | 1.5404    | 1.3794    | 1.0923    | 1.3692    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124106 / 33 / 11 KV Kanalda S/S

Feeder No / Name : 202 / 11 Kv Vadnagari AG Feeder FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .9755     | 1.1203    | 1.1869    |           |           |           |
| 8    |           | 1.0517    | 1.2696    | 1.3904    | 1.587     |           |           |
| 12   | 1.0822    |           |           |           |           | 1.643     |           |
| 16   | .945      |           |           |           |           | 1.5684    | 1.4413    |
| 21   |           |           |           |           |           |           | 1.4922    |
| 24   |           | .9602     | .9335     | 1.153     | 1.307     |           |           |
| Max  | 1.0822    | 1.0517    | 1.2696    | 1.3904    | 1.587     | 1.643     | 1.4922    |
| Min  | .945      | .9602     | .9335     | 1.153     | 1.307     | 1.5684    | 1.4413    |
| Avg  | 1.0136    | .9958     | 1.1078    | 1.2434    | 1.447     | 1.6057    | 1.4668    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124106 / 33 / 11 KV Kanalda S/S

Feeder No / Name : 203 / 11 kV Kanalda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.7528    | 1.1145    | 1.4937    | 1.0517    |           | 1.2517    | 1.5684    |
| 8    | 1.8404    | 1.4403    | 1.6804    | 1.4899    | 1.5604    | 1.5604    | 1.6804    |
| 12   | .9431     | .7468     | .964      | .8669     |           | .9335     | .7888     |
| 16   | 1.0974    | 1.0456    | .964      | .8322     | 1.1317    | .8215     | 1.2269    |
| 20   | 2.0062    | 1.8671    | 1.7528    |           | 2.1091    | 2.0538    |           |
| 21   |           |           |           |           |           |           | 1.7528    |
| 24   | .8764     | .8745     | .9335     | 1.0166    | .8669     | .9774     | 1.0456    |
| Max  | 2.0062    | 1.8671    | 1.7528    | 1.4899    | 2.1091    | 2.0538    | 1.7528    |
| Min  | .8764     | .7468     | .9335     | .8322     | .8669     | .8215     | .7888     |
| Avg  | 1.4194    | 1.1815    | 1.2981    | 1.0515    | 1.4170    | 1.2664    | 1.3438    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124123 / 33/11 KV VASANTWADI WAWADADA

Feeder No / Name : 201 / 11 KV Jalke Mix

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .5316     | .5552     | .4557     | .6154     | .4961     | .5316     | .4733     |
| 8    | .8145     | .7701     | .7164     | .7087     | .7522     | .8063     | .8322     |
| 12   | .5256     | .506      | .4641     | .57       | .663      | .4858     | .4801     |
| 16   | .5533     | .5281     | .5243     | .5533     | .5304     | .5243     | .4854     |
| 20   | .7628     | .6935     | .724      | .7537     | .7545     | .6859     | .7316     |
| 24   | .4161     | .4784     | .4458     | .4161     | .4607     | .407      | .4409     |
| Max  | .8145     | .7701     | .724      | .7537     | .7545     | .8063     | .8322     |
| Min  | .4161     | .4784     | .4458     | .4161     | .4607     | .407      | .4409     |
| Avg  | .6007     | .5886     | .5551     | .6029     | .6095     | .5735     | .5739     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124123 / 33/11 KV VASANTWADI WAWADADA

Feeder No / Name : 202 / 11 KV Vitner Mix SHEDDABLE RURAL  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3437     | .4607     | .8048     | .5426     | .4588     | .4578     | .4534     |
| 8    | .763      | .6009     | 1.2928    | .6783     | .6882     | .7045     | .7209     |
| 12   | .4167     | .8024     | .4877     | .3658     | .68       | .5441     | .5182     |
| 16   | .5155     | .9374     | .5693     | .4062     | .4744     | .5535     | .4481     |
| 20   | .5967     | 1.3078    | .6443     | .6554     | .6642     | .6443     | .6859     |
| 24   | .3841     | .3963     | .8322     | .4321     |           | .4481     | .4428     |
| Max  | .763      | 1.3078    | 1.2928    | .6783     | .6882     | .7045     | .7209     |
| Min  | .3437     | .3963     | .4877     | .3658     | .4588     | .4481     | .4428     |
| Avg  | .5033     | .7509     | .7719     | .5134     | .5931     | .5587     | .5449     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

JALGAON-R[238] BU 5665

Substation No/ Name :- 124123 / 33/11 KV VASANTWADI WAWADADA

Feeder No / Name : 203 / SHIRSOLI GFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .0754     | .0377     | .0554     | .0351     | .0566     | .0554     | .0554     |
| 8    | .0566     | .0554     | .0566     | .0377     | .0566     | .0754     | .0532     |
| 12   | .0377     | .0377     | .0373     | .0377     | .0373     | .0377     | .0377     |
| 16   | .056      | .0373     | .0566     | .0366     | .0739     | .0377     | .0366     |
| 20   | .0362     | .0572     | .0566     | .0566     | .0754     | .0754     | .0566     |
| 24   | .0377     | .0566     | .0362     | .0377     | .0381     | .0377     | .0373     |
| Max  | .0754     | .0572     | .0566     | .0566     | .0754     | .0754     | .0566     |
| Min  | .0362     | .0373     | .0362     | .0351     | .0373     | .0377     | .0366     |
| Avg  | .0499     | .0470     | .0498     | .0402     | .0563     | .0532     | .0461     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124023 / 33/11 KV NASHIRABAD

Feeder No / Name : 201 / 11 kV Nashirabad AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0919    | 1.7833    | .8402     | .6859     | .7202     | 1.9376    | 1.8652    |
| 2    | 2.0919    | 1.8004    | .8402     | .7202     | .7202     | 1.9376    | 1.8652    |
| 3    | 2.0576    | 1.8004    | .8059     | .6859     | .7545     | 1.9719    | 1.8482    |
| 4    | 2.0233    | 1.8347    | .8059     | .6687     | .7888     | 1.9719    | 1.8519    |
| 5    | 2.0062    | 1.8347    | .8402     | .6687     | .8059     | 2.0233    | 1.8519    |
| 6    | 2.0748    | 1.8652    | .8059     | .8059     | .8059     | 2.0576    | 1.9376    |
| 7    | 2.2462    | 2.0062    | .8745     | .8402     | .8059     | 2.1091    | 1.9719    |
| 8    | 2.0062    | 2.1434    | .9259     | .9088     | .9156     | 2.2291    | 2.1605    |
| 9    |           | 2.1776    | .9088     | 1.1317    | .823      | 2.0919    | 2.1434    |
| 11   | 1.0802    | 1.1145    | 2.1948    |           | 2.2291    | 1.0802    | 1.0631    |
| 12   | 1.046     | 1.0802    | 2.2805    | 2.0748    | 2.452     | 1.0802    | 1.0631    |
| 13   | .9088     | 1.0631    | 2.2977    | 2.1776    | 2.3834    | 1.0483    | 1.0117    |
| 14   | .9088     | 1.046     | 2.1605    | 2.2291    | 2.332     | .9431     | .9774     |
| 15   | .8916     | .9945     | 2.2291    | 2.1948    | 2.2634    | .9431     | .9774     |
| 16   | .9259     | .9945     | 2.1776    | 2.1091    | 2.2634    | .9259     | .9536     |
| 17   | .9945     | .9088     | 2.1091    | 2.0405    | 2.1026    | .9259     | .985      |
| 18   | .9362     | .9602     | 2.0687    | 1.989     | 2.3663    | .9431     | .9431     |
| 20   |           |           | 1.8107    |           |           |           |           |
| 23   | 1.989     |           |           |           |           |           |           |
| 24   | 2.0919    |           | .8402     | .7545     | .7888     | 1.9719    | 2.0405    |
| Max  | 2.2462    | 2.1776    | 2.2977    | 2.2291    | 2.452     | 2.2291    | 2.1605    |
| Min  | .8916     | .9088     | .8059     | .6687     | .7202     | .9259     | .9431     |
| Avg  | 1.5762    | 1.4946    | 1.4640    | 1.3344    | 1.4623    | 1.5662    | 1.5284    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124023 / 33/11 KV NASHIRABAD

Feeder No / Name : 202 / 11 KV Nashirabad

INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4563    | 1.8671    | 1.9993    | 1.8861    | 1.8111    | 2.0936    | 1.9616    |
| 2    | 1.5466    | 1.8484    | 1.9239    | 1.9239    | 1.6598    | 2.0748    | 2.0748    |
| 3    | 1.6409    | 1.7924    | 1.8484    | 1.9616    | 1.4998    | 1.8484    | 2.0748    |
| 4    | 1.6598    | 1.7177    | 1.8484    | 1.9993    | 1.423     | 1.8484    | 1.8484    |
| 5    | 1.6221    | 1.6263    | 1.8107    | 1.773     | 1.363     | 1.8861    | 1.6975    |
| 6    | 1.386     | 1.6617    | 2.0748    | 1.8298    | 1.2696    | 1.8861    | 1.8673    |
| 7    | 1.9805    | 1.7551    | 2.037     | 1.9978    | 2.037     | 1.8861    | 1.5684    |
| 8    | 1.6598    | 1.8107    | 1.773     | 2.0182    | 1.8673    | 1.8861    | 1.5466    |
| 9    | 1.9993    | 2.037     | 1.8088    | 2.4331    | 2.1691    | 2.0748    | 1.3392    |
| 10   | 1.9993    |           | 2.2634    | 2.3388    | 2.452     | 2.1502    | 1.4146    |
| 11   | 2.2068    | 2.1502    | 2.2257    |           | 3.0556    | 2.5463    | 1.1949    |
| 12   | 1.2936    | 1.5089    |           | 2.5652    | 2.8292    | 2.2257    | 1.3256    |
| 13   | 1.267     | 2.0748    | 1.4632    | 2.5274    | 2.3011    | 2.3577    | 1.363     |
| 14   | 1.2851    | 1.9616    | 1.6263    | 2.4897    | 2.6406    | 2.6029    | 1.4146    |
| 15   | 1.2536    | 2.4143    | 1.5684    | 2.5652    | 2.6595    | 2.5463    | .7712     |
| 16   | 1.2536    | 2.452     | 1.6804    | 1.8111    | 1.7164    | 2.4143    | .5058     |
| 17   | 1.3491    | 2.2965    | 1.7924    | 2.4897    | 2.6029    | 2.2634    | 1.4523    |
| 18   | 2.3577    | 2.1285    | 2.5652    | 2.5274    | 2.1313    | 2.2257    | 1.3203    |
| 19   | 1.905     | 2.2405    | 2.0936    | 2.2822    | 1.1401    | 1.9239    | 1.2449    |
| 20   | 1.39      | 1.6975    | 1.8107    | 1.9993    | 1.1233    | 1.6787    | 1.1088    |
| 21   | 1.9239    | 1.905     | 1.9805    | 1.8673    | 1.8861    | 2.037     | 1.5278    |
| 22   | 1.9239    | 1.9616    | 2.0182    | 1.9616    | 1.9993    | 1.7918    | 1.4712    |
| 23   | 1.9239    | 2.037     | 1.7558    | 2.037     | 1.8296    | 1.7918    | 1.4146    |
| 24   | 1.7353    | 1.905     | 1.9616    | 1.905     | 1.8673    | 1.8296    | 1.905     |
| Max  | 2.3577    | 2.452     | 2.5652    | 2.5652    | 3.0556    | 2.6029    | 2.0748    |
| Min  | 1.2536    | 1.5089    | 1.4632    | 1.773     | 1.1233    | 1.6787    | .5058     |
| Avg  | 1.6675    | 1.9500    | 1.9100    | 2.1387    | 1.9723    | 2.0779    | 1.4756    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124023 / 33/11 KV NASHIRABAD

Feeder No / Name : 204 / 11 kV Nashirabad URBAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7918    | 1.8673    | 1.7918    | 1.9909    | 1.7918    | 1.8099    | 1.8461    |
| 2    | 1.7741    | 1.8111    | 1.8461    | 1.9004    | 1.828     | 1.7375    | 1.8823    |
| 3    | 1.7924    | 1.8656    | 1.9022    | 1.8642    | 1.8656    | 1.7551    | 1.9547    |
| 4    | 1.9022    | 2.0119    | 1.9163    | 1.828     | 1.9022    | 1.9387    | 2.0119    |
| 5    | 2.1582    | 2.1399    | 2.2314    | 2.1033    | 2.1253    | 2.1033    | 2.1582    |
| 6    | 2.5503    | 2.4949    | 2.5503    | 2.4025    | 2.4025    | 2.3411    | 2.396     |
| 7    | 2.3655    | 2.1765    | 2.268     | 2.2131    | 2.1357    | 2.0119    | 2.0995    |
| 8    | 1.9547    | 1.7918    | 2.0416    | 1.9163    | 1.8625    | 1.9547    | 1.9521    |
| 9    | 1.8088    | 1.6476    | 1.7364    | 1.6476    | 1.6834    | 1.8446    | 1.7551    |
| 10   | 1.701     |           |           | 1.6301    | 1.6476    | 1.6827    | 1.7002    |
| 11   | 1.6655    | 1.5592    |           |           |           | 1.7718    | 1.6297    |
| 12   | 1.6478    | 1.5947    | 1.8427    | 1.5592    |           | 1.6476    | 1.6126    |
| 13   | 1.5775    | 1.5947    | 1.7878    | 1.5775    | 1.6297    | 1.701     | 1.5424    |
| 14   | 1.56      | 1.5769    | 1.7353    | 1.5769    | 1.6476    | 1.6476    | 1.5775    |
| 15   | 1.6817    | 1.7187    | 1.7703    | 1.7541    | 1.6991    | 1.6476    | 1.7002    |
| 16   |           | 1.7193    | 1.8229    | 1.7187    | 1.6126    | 1.6817    | 1.6827    |
| 17   | 1.6632    | 1.6827    | 1.7528    | 1.491     | 1.7718    | 1.6991    | 1.8267    |
| 18   | 1.6651    | 1.7164    | 1.6476    | 1.5775    | 1.5947    | 1.6804    | 1.858     |
| 19   | 2.1491    | 2.1491    | 2.2207    | 1.8054    | 2.2325    | 2.1559    | 2.167     |
| 20   | 2.2207    | 2.2923    | 2.2624    | 2.1085    | 2.2028    | 2.2565    | 2.2986    |
| 21   | 2.1491    | 2.1719    | 2.1719    | 2.1216    | 2.1616    | 2.167     | 2.1132    |
| 22   | 2.0995    | 2.0995    | 2.1719    | 2.0633    | 2.1538    | 2.1849    | 2.0416    |
| 23   | 2.0452    | 2.0452    | 2.0633    | 1.9909    | 2.0058    | 2.0595    | 1.9909    |
| 24   | 1.8823    | 1.8823    | 1.9004    | 2.009     | 1.7318    | 1.8446    | 1.9185    |
| Max  | 2.5503    | 2.4949    | 2.5503    | 2.4025    | 2.4025    | 2.3411    | 2.396     |
| Min  | 1.56      | 1.5592    | 1.6476    | 1.491     | 1.5947    | 1.6476    | 1.5424    |
| Avg  | 1.9046    | 1.8961    | 1.9743    | 1.8630    | 1.8949    | 1.8885    | 1.9048    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124023 / 33/11 KV NASHIRABAD

Feeder No / Name : 206 / 11 KV Godavari MEDICAL

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5175     | .5175     | .5175     | .5175     | .5121     | .4805     | .4805     |
| 2    | .4805     | .5175     | .5175     | .4938     | .5121     | .4805     | .4805     |
| 3    | .462      | .462      | .4854     | .4755     | .4805     | .4805     | .4805     |
| 4    | .462      | .462      | .4481     | .4805     | .4805     | .5121     | .5175     |
| 5    | .462      | .4435     | .4854     | .4805     | .499      | .5487     | .5175     |
| 6    | .4066     | .5175     | .5175     | .5175     | .5175     | .5487     | .5121     |
| 7    | .5175     | .5175     | .5853     | .5487     | .5121     | .5853     | .5121     |
| 8    | .5121     | .5121     | .5731     | .5792     | .543      | .6516     | .4755     |
| 9    | .5792     | .6283     | .6089     | .6805     | .7164     | .6584     | .5853     |
| 10   | .5121     | .7133     | .8145     | .7964     | .5853     | .4755     | .6584     |
| 11   | .695      | .7316     | .8145     |           | .7282     | .6722     | .6722     |
| 12   | .4435     | .7316     | .8326     | .7947     | .7059     | .7468     | .7207     |
| 13   | .543      | .7316     | .8413     | .8316     | .695      | .7468     | .6468     |
| 14   | .6219     | .7682     | .823      | .7947     | .7682     | .7468     | .695      |
| 15   | .6219     | .7865     | .8048     | .8029     | .7682     | .7468     | .695      |
| 16   | .5487     | .7577     | .7682     | .7842     | .7499     | .7468     | .6697     |
| 17   | .6584     | .6584     | .724      | .5792     | .6219     | .7316     | .6584     |
| 18   | .5853     | .6335     | .695      | .5853     | .6584     | .6283     | .5853     |
| 19   | .567      | .6219     | .6584     | .6089     | .5853     | .6516     | .6283     |
| 20   | .5792     | .6036     | .6584     | .6219     | .6154     | .5792     | .6154     |
| 21   | .567      | .5853     | .6401     | .6219     | .6219     | .5544     | .5487     |
| 22   | .6219     | .6219     | .6219     | .5853     | .5487     | .5914     | .5853     |
| 23   | .6154     | .6283     | .5792     | .5601     | .6036     | .5121     | .5487     |
| 24   | .5121     | .5487     | .5175     | .5175     | .5487     | .5601     | .5175     |
| Max  | .695      | .7865     | .8413     | .8316     | .7682     | .7468     | .7207     |
| Min  | .4066     | .4435     | .4481     | .4755     | .4805     | .4755     | .4755     |
| Avg  | .5455     | .6125     | .6472     | .6199     | .6074     | .6099     | .5836     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 201 / 11 KV Bhadli GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7202     | .7545     | .724      | .724      | .6878     | .7545     | .7964     |
| 2    | .6859     | .7545     | .724      | .724      | .6878     | .7545     | .7964     |
| 3    | .7202     | .823      | .8505     | .7602     | .7011     | .823      | .7964     |
| 4    | .9259     | .9259     | .9412     | 8.4886    | .8413     | .9602     | .9955     |
| 5    | 1.5089    | 1.3032    | 1.3575    | 1.4327    | 1.262     | 1.5089    | 1.448     |
| 6    | 1.6461    | 1.5432    | 1.7002    | 1.576     | 1.643     | 1.4746    | 1.5524    |
| 7    | 1.2308    | 1.406     | 1.448     | 1.3003    | 1.3306    | 1.406     | 1.4045    |
| 8    | 1.3394    | 1.166     | 1.086     | 1.086     | 1.1458    | 1.2689    | 1.1765    |
| 9    | 1.1222    | .9602     | .788      | .9412     | 1.0719    | 1.0631    | 1.0517    |
| 10   | .823      | .9114     | .7164     | .8764     | .7202     | .8505     | .9114     |
| 11   | .823      | .7802     | .788      |           | .7202     | .7973     | .8413     |
| 12   | .7545     | .724      | .7164     | .5249     | .6173     | .7796     | .7796     |
| 13   | .7545     | .7468     | .7522     | .724      | .6516     | .7087     | .7619     |
| 14   | .7545     | .724      | .788      | .724      | .6516     | .7087     | .7537     |
| 15   | .823      | .724      | .788      | .724      | .6516     | .7087     | .7796     |
| 16   | .8573     | .8145     |           | .7421     | .6859     | .7087     | .7796     |
| 17   | .9259     | .8688     | .8596     | .8063     | .823      | .8505     | .9214     |
| 18   | 1.0288    | .9412     | .9313     | 1.086     | .8916     | 1.0136    | 1.0608    |
| 19   | 1.2346    | 1.3032    |           | 1.2308    | 1.3032    | 1.4335    | 1.2567    |
| 20   | 1.1145    | 1.086     | 1.1462    | 1.086     | 1.166     | 1.1517    | .9877     |
| 21   | .9602     | .9054     |           | .905      | .9602     | .9412     | .8413     |
| 22   | .8573     | .8145     | .788      | .7964     | .823      | .8688     | .8764     |
| 23   | .823      | .724      | .7522     | .724      | .7888     | .8145     | .8413     |
| 24   | .7362     | .7545     | .724      | .7164     | .6733     | .7545     | .7964     |
| Max  | 1.6461    | 1.5432    | 1.7002    | 8.4886    | 1.643     | 1.5089    | 1.5524    |
| Min  | .6859     | .724      | .7164     | .5249     | .6173     | .7087     | .7537     |
| Avg  | .9654     | .9358     | .9224     | 1.2478    | .8958     | .9627     | .9670     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 202 / 11 KV Asoda AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .639      | .6173     | .5144     |
| 2    |           |           |           |           | .639      | .6173     | .5716     |
| 3    |           |           |           |           | .6554     | .6344     | .5716     |
| 4    |           |           |           |           | .6554     | .6516     | .5716     |
| 5    |           |           |           |           | .6554     | .6516     | .5716     |
| 6    |           |           |           |           | .6882     | .7545     | .5716     |
| 7    |           |           |           |           | .8192     | .8916     | .6287     |
| 8    |           |           |           |           | .8848     | .9945     | .852      |
| 9    |           |           |           |           | .9175     | .9602     | .6554     |
| 10   |           |           |           |           |           | .7145     |           |
| 11   | .8916     | .8573     | .9602     |           |           |           |           |
| 12   | .9945     |           | 1.0288    | .724      |           |           |           |
| 13   | 1.0288    | .8573     | .8916     | .7964     |           |           |           |
| 14   | 1.0288    | .8573     | 1.1088    | .7865     |           |           |           |
| 15   | .9259     | .8573     | .9313     | .7865     |           |           |           |
| 16   | .8916     | .8573     |           | .7209     |           |           |           |
| 17   | .8916     | .7859     | .823      | .7537     |           |           |           |
| 18   | .8573     | .743      | .7888     | .8192     |           |           |           |
| 24   |           |           |           |           | .6554     | .6173     |           |
| Max  | 1.0288    | .8573     | 1.1088    | .8192     | .9175     | .9945     | .852      |
| Min  | .8573     | .743      | .7888     | .7209     | .639      | .6173     | .5144     |
| Avg  | .9388     | .8308     | .9332     | .7696     | .7209     | .7368     | .6121     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239] BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 203 / 11 KV Bhadli AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6062     | .6173     | .5487     | .6001     |           |           |           |
| 2    | .6062     | .6173     | .5487     | .6001     |           |           |           |
| 3    | .6226     | .6001     | .6516     | .6173     |           |           |           |
| 4    | .6226     | .5487     | .6516     | .6516     |           |           |           |
| 5    | .5898     | .5487     | .724      | .6173     |           |           |           |
| 6    | .6226     | .5487     | .724      | .6173     |           |           |           |
| 7    | .7209     | .6173     | .6097     | .6516     |           |           |           |
| 8    | .7209     | .6516     | .6097     | .6859     |           |           |           |
| 9    | .7209     | .7545     | .6859     | .6226     |           |           |           |
| 10   |           | .6097     |           |           |           |           |           |
| 11   |           |           |           |           | .8573     | .6859     | .7865     |
| 12   |           |           |           |           | .7545     | .7316     | .8192     |
| 13   |           |           |           |           | .8573     | .7316     | .7865     |
| 14   |           |           |           |           | .7888     | .7316     | .7865     |
| 15   |           |           |           |           | .7888     | .6859     | .6554     |
| 16   |           |           |           |           | .8573     | .6706     | .6226     |
| 17   |           |           |           |           | .7888     | .6097     | .7209     |
| 18   |           |           |           |           | .7888     | .6097     | .6882     |
| 24   | .6226     | .6516     | .5944     | .6001     |           |           |           |
| Max  | .7209     | .7545     | .724      | .6859     | .8573     | .7316     | .8192     |
| Min  | .5898     | .5487     | .5487     | .6001     | .7545     | .6097     | .6226     |
| Avg  | .6455     | .6150     | .6348     | .6264     | .8102     | .6821     | .7332     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 204 / 11 KV Asoda GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7796     | .7545     | .7796     | .788      | .7619     | .823      | .7796     |
| 2    | .7442     | .7545     | .078      | .788      | .7619     | .7888     | .7796     |
| 3    | .815      | .7888     | .8859     | .8059     | .7796     | .823      | .7796     |
| 4    | .8505     | .8573     | .8505     | .8954     | .8505     | .9259     | .9955     |
| 5    | 1.2403    | 1.1317    | 1.2403    | 1.0745    | 1.1163    | 1.1317    | 1.1765    |
| 6    | 1.5238    | 1.3717    | 1.5524    |           | 1.4563    | 1.406     | 1.39      |
| 7    | 1.4784    | 1.3375    | 1.2403    | 1.3432    | 1.2403    | 1.286     | 1.3306    |
| 8    | 1.134     | 1.0631    | 1.0631    | 1.086     | 1.0631    | 1.1317    | 1.0631    |
| 9    | 1.0277    | .9259     | .9313     | .9568     | .9036     | .9259     | .9922     |
| 10   | .9602     | .7796     | .6447     | .8859     | .7888     | .7545     | .8505     |
| 11   | .7888     | .7442     | .788      |           | .7202     | .7202     | .8505     |
| 12   | .7545     | .7087     | .7164     | .7087     | .6859     | .6935     | .815      |
| 13   | .7545     | .7087     | .788      | .7087     | .6859     | .6935     | .7087     |
| 14   | .7545     | .6379     | .9313     | .7087     | .6516     | .7087     | .7442     |
| 15   | .7545     | .7087     | .7164     | .7087     | .6516     | .7442     | .7796     |
| 16   | .823      | .7973     |           | .7796     | .6859     | .7796     | .815      |
| 17   | .823      | .7973     | .7522     | .7796     |           | .7973     | .8505     |
| 18   | .8916     | .9214     | .8596     | .8328     |           | .8505     | 1.1218    |
| 19   | 1.0974    | 1.2048    |           | 1.134     | 1.2689    | 1.134     | 1.1218    |
| 20   | 1.0631    | 1.086     | 1.2178    | 1.0631    | 1.2689    | 1.086     | 1.2048    |
| 21   | .9602     | .9568     |           | .9922     | 1.1145    | .9412     | 1.0277    |
| 22   | .9259     | .8859     | .9313     | .9568     | .9602     | .8505     | .9568     |
| 23   | .823      | .7973     | .8596     | .8859     | .823      | .7973     | .8859     |
| 24   | .7796     | .7545     | .7796     | .8059     | .7796     | .823      | .7796     |
| Max  | 1.5238    | 1.3717    | 1.5524    | 1.3432    | 1.4563    | 1.406     | 1.39      |
| Min  | .7442     | .6379     | .078      | .7087     | .6516     | .6935     | .7087     |
| Avg  | .9395     | .8948     | .8860     | .8949     | .9099     | .9007     | .9500     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 205 / 11 kV Bholane GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     | .1372     | .1387     | .1478     | .1267     | .1372     | .1387     |
| 2    | .1311     | .1372     | .1387     | .1478     | .124      | .12       | .1387     |
| 3    | .1543     | .1372     | .1387     | .1848     | .1417     | .1372     | .1402     |
| 4    | .1886     | .1715     | .208      | .2218     | .1595     | .2058     | .1772     |
| 5    | .3772     | .2743     | .3696     | .2772     | .2481     | .2743     | .3696     |
| 6    | .4973     | .4801     | .5068     |           | .4108     | .4801     | .4435     |
| 7    | .4163     | .4801     | .3544     | .4805     | .3734     | .4458     | .3696     |
| 8    | .3801     | .3772     | .3467     | .2772     | .3361     | .3772     | .3544     |
| 9    | .3544     | .3086     | .2865     | .2804     | .2949     | .3086     | .2835     |
| 10   | .1715     | .2774     | .2149     | .1753     | .2401     | .1715     | .2835     |
| 11   | .0857     | .1734     | .1433     |           | .2058     |           | .1991     |
| 12   | .1372     | .1387     | .1478     | .6554     | .1372     | .1372     | .1402     |
| 13   | .1372     | .1387     | .1478     | .1448     | .1029     | .1372     | .1578     |
| 14   | .1372     | .1387     | .1663     | .1448     | .1372     | .1372     | .1402     |
| 15   | .1372     | .1387     | .1478     | .1402     | .1372     | .1372     | .1402     |
| 16   | .1715     | .1387     |           | .1578     | .1715     | .1372     | .1578     |
| 17   | .1715     | .1734     | .2033     | .1753     | .1715     | .1772     | .2103     |
| 18   | .2401     | .3018     | .2686     | .2481     | .2401     | .2126     | .3109     |
| 19   | .4115     | .3734     |           | .3898     | .3429     | .3696     | .4066     |
| 20   | .3429     | .1867     | .2957     | .3189     | .2743     | .3544     | .3292     |
| 21   | .2058     | .1494     |           | .1772     | .2058     | .2218     | .2126     |
| 22   | .1715     | .1387     | .1663     | .1417     | .1715     | .1734     | .1753     |
| 23   | .1372     | .1387     | .1478     | .1448     | .1715     | .1387     | .1402     |
| 24   | .1372     | .1372     | .1387     | .1478     | .124      | .1372     | .1387     |
| Max  | .4973     | .4801     | .5068     | .6554     | .4108     | .4801     | .4435     |
| Min  | .0857     | .1372     | .1387     | .1402     | .1029     | .12       | .1387     |
| Avg  | .2263     | .2186     | .2227     | .2354     | .2104     | .2230     | .2316     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

JALGAON URBAN DIVISION[594]

NASHIRABAD[239]

BU 5690

Substation No/ Name :- 124086 / 33/11 KV BHADLI BK

Feeder No / Name : 206 / SUMAN HOMTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3601     | .3584     | .3224     | .3361     | .3772     | .3921     |
| 2    |           | .3429     | .3511     | .3403     | .3734     | .3429     | .3734     |
| 3    | .3921     | .3601     | .3696     | .3582     | .3734     | .3601     | .3547     |
| 4    | .3921     | .3506     | .3961     |           | .3921     | .3429     | .3547     |
| 5    | .3734     | .3258     | .3696     | .3761     | .3921     | .3601     | .3734     |
| 6    | .3921     | .3772     | .3772     | .3582     | .3921     | .3601     | .3921     |
| 7    | .4108     | .3429     | .3326     | .3224     | .3921     | .3429     | .4108     |
| 8    | .3921     | .3258     | .3326     | .3582     | .3174     | .3601     | .3921     |
| 9    | .3189     | .3601     | .2865     | .3734     | .3734     | .3429     | .3921     |
| 10   | .3429     | .3326     | .3582     | .3547     | .3258     | .2987     | .3361     |
| 11   | .3258     | .3361     | .3582     |           | .3258     | .2957     | .3921     |
| 12   | .3601     | .3734     | .3224     | .2987     | .2915     | .2987     | .3921     |
| 13   | .3601     | .3881     | .3582     | .3734     | .3429     | .3361     | .3921     |
| 14   | .3429     | .3961     | .3403     | .3361     | .3429     | .3734     | .3734     |
| 15   | .3601     | .3734     | .3582     | .3734     | .3429     | .3772     | .3921     |
| 16   | .3601     | .3734     |           | .3361     | .3429     | .3961     | .3921     |
| 17   | .3601     | .3734     | .3045     | .3734     | .3601     | .3961     | .3921     |
| 18   | .3601     | .3734     | .3045     | .3174     | .3601     | .3961     | .3734     |
| 19   | .3429     | .3696     |           | .8589     | .3601     | .3961     | .3734     |
| 20   | .3506     | .3326     | .3224     | .3734     | .3429     | .3734     | .3921     |
| 21   | .3601     | .3361     |           | .3174     | .3601     | .2957     | .3734     |
| 22   | .3601     | .3326     | .3224     |           | .3429     | .3361     | .3361     |
| 23   | .3601     | .3547     | .3224     | .3734     | .3429     | .3734     | .8775     |
| 24   | .3921     | .3601     | .3961     | .3224     | .3174     | .3772     | .3921     |
| Max  | .4108     | .3961     | .3961     | .8589     | .3921     | .3961     | .8775     |
| Min  | .3189     | .3258     | .2865     | .2987     | .2915     | .2957     | .3361     |
| Avg  | .3641     | .3563     | .3448     | .3723     | .3518     | .3546     | .4006     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124007 / 33 KV BHADGAON

Feeder No / Name : 203 / 11 KV BHADGAON UII AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6554     |           |           |           |           |
| 2    |           | .4687     |           |           |           |
| 6    |           | .5487     |           |           |           |
| 7    | .8383     |           |           |           |           |
| 10   |           |           | .8002     | .743      | .8145     |
| 13   |           |           | .9511     | .7859     | .7002     |
| Max  | .8383     | .5487     | .9511     | .7859     | .8145     |
| Min  | .6554     | .4687     | .8002     | .743      | .7002     |
| Avg  | .7469     | .5087     | .8757     | .7645     | .7574     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124007 / 33 KV BHADGAON

Feeder No / Name : 204 / 11 KV WALWADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .506      |           | 1.0364    | .9755     | .9602     |
| 2    |           |           |           | .4001     |           |           |           |
| 6    |           |           |           | .7087     | 1.2803    |           | .9907     |
| 7    |           |           | .828      |           |           | 1.3565    |           |
| 10   |           | 1.4784    |           |           | .442      | .4531     | .4999     |
| 11   | 1.6613    |           | 1.4861    |           |           |           |           |
| 12   |           | 1.3375    |           | 1.4118    |           |           |           |
| 13   |           |           |           |           | .4744     | .4268     | .4531     |
| 14   |           | 1.5242    | 1.5384    | 1.2651    |           |           |           |
| 15   | 1.4937    |           |           |           |           |           |           |
| 18   | .4999     | .4531     | .3315     |           |           |           |           |
| 20   | 1.0364    | .8078     | .5716     |           |           |           |           |
| Max  | 1.6613    | 1.5242    | 1.5384    | 1.4118    | 1.2803    | 1.3565    | .9907     |
| Min  | .4999     | .4531     | .3315     | .4001     | .442      | .4268     | .4531     |
| Avg  | 1.1728    | 1.1202    | .8769     | .9464     | .8083     | .8030     | .7260     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124007 / 33 KV BHADGAON

Feeder No / Name : 206 / 11 KV NIMBHORA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 1.4022    |           | .6093     | .5144     | .5716     |
| 2    |           |           |           | 1.4937    |           |           |           |
| 6    |           |           |           | 1.829     | 1.1883    |           | 1.0974    |
| 7    |           |           | 2.0271    |           |           | .7202     |           |
| 10   |           | .3544     |           |           | 1.6861    | 1.7147    | 1.5003    |
| 11   | .4001     |           | .2439     |           |           |           |           |
| 12   |           | .2389     |           | .378      |           |           |           |
| 13   |           |           |           |           | 1.6861    | 1.8004    | 1.5003    |
| 14   |           | .2267     | .2801     |           |           |           |           |
| 15   | .4001     |           |           |           |           |           |           |
| 18   | .5693     | .5639     | .503      |           |           |           |           |
| 20   | .7773     | .9755     | .743      |           |           |           |           |
| Max  | .7773     | .9755     | 2.0271    | 1.829     | 1.6861    | 1.8004    | 1.5003    |
| Min  | .4001     | .2267     | .2439     | .378      | .6093     | .5144     | .5716     |
| Avg  | .5367     | .4719     | .8666     | 1.2336    | 1.2925    | 1.1874    | 1.1674    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124007 / 33 KV BHADGAON

Feeder No / Name : 207 / 11 KV INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .0857     |           | .0857     | .0857     | .0857     |
| 2    |           |           |           | .0857     |           |           |           |
| 6    |           |           |           | .1543     | .1372     |           | .0857     |
| 7    |           |           | .1715     |           |           | .2572     |           |
| 10   |           | .2915     |           |           | .4115     | .3086     | .2229     |
| 11   | .3772     |           | .3887     |           |           |           |           |
| 12   | .3258     | .2429     |           | .3887     |           |           |           |
| 13   |           |           |           |           | .2743     | .1543     | .3086     |
| 14   |           | .2429     | .2267     | .3239     |           |           |           |
| 15   | .3086     |           |           |           |           |           |           |
| 18   | .2743     | .2743     | .2915     |           |           |           |           |
| 20   | .1886     | .1886     | .3086     |           |           |           |           |
| Max  | .3772     | .2915     | .3887     | .3887     | .4115     | .3086     | .3086     |
| Min  | .1886     | .1886     | .0857     | .0857     | .0857     | .0857     | .0857     |
| Avg  | .2949     | .2480     | .2455     | .2382     | .2272     | .2015     | .1757     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124007 / 33 KV BHADGAON

Feeder No / Name : 211 / 11 KV VADGAON BALAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .2315     |           | .2591     | .2591     | .2286     |
| 2    |           |           |           | .2134     |           |           |           |
| 6    |           |           |           | .3334     | .3658     |           | .3048     |
| 7    |           |           | .4374     |           |           | .4572     |           |
| 10   |           | .4161     |           |           | .2056     | .2372     | .1898     |
| 11   | .5487     |           | .4458     |           |           |           |           |
| 12   |           | .4572     |           | .3429     |           |           |           |
| 13   |           |           |           |           | .1875     | .2056     | .2214     |
| 14   |           | .3715     | .3658     | .2429     |           |           |           |
| 15   | .4115     |           |           |           |           |           |           |
| 18   | .2031     | .2031     | .16       |           |           |           |           |
| 20   | .25       | .3906     | .3334     |           |           |           |           |
| Max  | .5487     | .4572     | .4458     | .3429     | .3658     | .4572     | .3048     |
| Min  | .2031     | .2031     | .16       | .2134     | .1875     | .2056     | .1898     |
| Avg  | .3533     | .3677     | .3290     | .2832     | .2545     | .2898     | .2362     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124012 / 33 KV KOLGAON

Feeder No / Name : 202 / 11 KV GUDHE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.2818    |           |           | 1.1031    | 1.5588    | 1.5588    | 1.5773    |
| 7    | 1.3584    | 1.4712    | 1.5064    | 1.4224    |           |           |           |
| 8    | 1.3628    | 1.2058    | 1.3878    | 1.2211    |           |           |           |
| 9    | 1.0101    |           | .8757     | .7545     |           |           |           |
| 10   | .9278     | .8545     |           | 1.0168    |           |           |           |
| 12   |           | .8871     | .8325     | .9183     | 1.5039    | 1.684     | 1.8716    |
| 14   |           |           |           | .9511     |           |           |           |
| 15   |           |           | .8222     |           | 1.6567    | 1.5931    | 1.6082    |
| 16   | .8797     | .8131     | .8807     |           | 1.6948    | 1.6714    | 1.7298    |
| 17   |           | .8413     |           |           |           |           |           |
| 20   | 1.6495    | 1.5015    | 1.4274    | 1.5708    | 1.5355    | 1.6482    | 1.4985    |
| 22   |           | 1.295     |           |           |           |           |           |
| 23   |           |           |           | 1.2923    | 1.2567    | 1.3973    | 1.3749    |
| 24   | 1.1026    | 1.1531    | 1.4227    | 1.1754    | 1.2752    | 1.2025    | 1.2541    |
| Max  | 1.6495    | 1.5015    | 1.5064    | 1.5708    | 1.6948    | 1.684     | 1.8716    |
| Min  | .8797     | .8131     | .8222     | .7545     | 1.2567    | 1.2025    | 1.2541    |
| Avg  | 1.1966    | 1.1136    | 1.1444    | 1.1426    | 1.4974    | 1.5365    | 1.5592    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124012 / 33 KV KOLGAON

Feeder No / Name : 203 / 11 KV KOLGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .9835     | 1.0634    |           | 1.0117    | .8072     | .7454     | .8072     |
| 7    | .9691     | .996      | .8708     | 1.0502    | 1.1623    | 1.0631    | 1.1083    |
| 8    | .8075     | .7293     | .6921     | .8093     | .9105     | .8922     | .955      |
| 9    | .6676     |           | .8505     | .8081     |           |           |           |
| 10   | 1.1036    | 1.1772    |           | 1.0898    |           |           |           |
| 12   | 1.0218    | 1.0905    | 1.0927    | 1.0865    | .5872     | .6337     | .5804     |
| 14   | .8241     |           |           | 1.0002    |           |           |           |
| 15   |           |           | .7546     |           | .6115     | .6168     | .6866     |
| 16   | .8699     | .9189     | .7875     | .9588     | .5849     | .6063     | .6443     |
| 17   |           | .5878     |           |           |           |           |           |
| 20   |           | .9602     | 1.0678    | 1.0737    | .9861     | 1.1455    | 1.0049    |
| 22   |           | 1.0082    |           |           |           |           |           |
| 23   | .956      |           | .8967     | .8634     | .8781     | .9129     | .8718     |
| 24   | .8526     | .8728     | .8619     | .8431     | .8383     | .7979     | .8507     |
| Max  | 1.1036    | 1.1772    | 1.0927    | 1.0898    | 1.1623    | 1.1455    | 1.1083    |
| Min  | .6676     | .5878     | .6921     | .8081     | .5849     | .6063     | .5804     |
| Avg  | .9056     | .9404     | .8750     | .9632     | .8185     | .8238     | .8344     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124012 / 33 KV KOLGAON

Feeder No / Name : 204 / 11 KV PIMPRIHAT FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3499     | 1.0553    |           | .3082     | .5249     |           | .6167     |
| 7    | .4328     | .4494     | .4657     | .473      | .8359     | .6013     | .8025     |
| 8    | .3361     | .325      | .3025     | .3313     | .696      | .6587     | .6561     |
| 9    | .5514     |           | .5625     | .6056     |           |           |           |
| 10   | .7811     | .7339     |           | .779      |           |           |           |
| 12   | .7486     | .8291     | .7645     | .8114     | .1625     | .1864     | .1694     |
| 14   | .7064     |           |           | .7148     |           |           |           |
| 15   | .7486     |           | .5882     |           | .15       | .1866     | .1552     |
| 16   | .7119     | .1938     | .5977     | .7125     | .1744     | .1889     | .1664     |
| 20   | .3126     | .3585     | .3298     | .3572     | .3366     | .2883     | .3051     |
| 22   |           | .2561     |           |           |           |           |           |
| 23   | .2418     |           | .2236     | .5887     | .6791     | .6966     | .25       |
| 24   | .2222     | .2112     | .2226     | .2243     | .5869     | .6413     | .6433     |
| Max  | .7811     | 1.0553    | .7645     | .8114     | .8359     | .6966     | .8025     |
| Min  | .2222     | .1938     | .2226     | .2243     | .15       | .1864     | .1552     |
| Avg  | .5120     | .4903     | .4508     | .5369     | .4607     | .4310     | .4183     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124120 / 33 KV GIRAD

Feeder No / Name : 201 / 11 KV PIMPALGAON G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .333      | .3601     |           | .4119     | .3561     |           |           |
| 5    |           |           |           |           |           |           | .5316     |
| 7    |           |           |           |           |           |           | .6344     |
| 8    | .4075     |           |           | .4681     | .4239     | .4801     |           |
| 10   |           |           |           |           |           | .463      |           |
| 12   | .2743     |           | .4119     | .3315     | .3391     | .2915     | .3361     |
| 16   | .2743     |           | .3561     | .4382     | .39       | .3944     | .3725     |
| 20   | .4287     |           | .6335     | .583      |           |           | .5731     |
| 24   | .298      |           |           | .4163     | .463      | .4409     |           |
| Max  | .4287     | .3601     | .6335     | .583      | .463      | .4801     | .6344     |
| Min  | .2743     | .3601     | .3561     | .3315     | .3391     | .2915     | .3361     |
| Avg  | .3360     | .3601     | .4672     | .4415     | .3944     | .4140     | .4895     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124120 / 33 KV GIRAD

Feeder No / Name : 202 / 11 KV PIMPALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3477     | .6173     | .6706     |           |           |           |
| 8    | .4801     |           | .8949     |           |           |           |
| 12   |           |           |           | 1.3203    | 1.166     | .9511     |
| 16   |           |           |           | 1.0631    |           | .9332     |
| 24   | .3382     |           | .7727     |           |           |           |
| Max  | .4801     | .6173     | .8949     | 1.3203    | 1.166     | .9511     |
| Min  | .3382     | .6173     | .6706     | 1.0631    | 1.166     | .9332     |
| Avg  | .3887     | .6173     | .7794     | 1.1917    | 1.166     | .9422     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124120 / 33 KV GIRAD

Feeder No / Name : 203 / 11 KV BHATKHANDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE       | 08-APR-18     | 09-APR-18     | 10-APR-18     | 11-APR-18     | 12-APR-18     | 13-APR-18     | 14-APR-18     |
|------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| HR         | Load (MW)     | Load (MW)     | Load (MW)     | Load (MW)     | Load (MW)     | Load (MW)     | Load (MW)     |
| 4          | 1.6956        | 1.7147        |               | 1.6632        | 1.7364        | 1.5089        |               |
| 5          |               |               |               |               |               |               | 1.4575        |
| 7          |               |               |               |               |               |               | 1.749         |
| 8          | 1.4922        |               |               | 1.4074        | 1.7126        | 1.7147        |               |
| 12         | 1.3546        |               | 1.6617        | 1.8482        | .9156         |               | 1.2851        |
| 13         |               |               |               |               |               | 1.1831        |               |
| 16         | 1.166         |               | 1.656         | 1.8482        | 1.1288        | 1.286         | 1.2717        |
| 20         | 2.0919        |               | 2.0348        | 2.1622        |               | 2.1262        | 2.2965        |
| 23         |               |               |               |               |               | 1.5604        |               |
| 24         | 1.3056        |               |               | 1.3226        | 1.6263        | 1.4918        |               |
| <b>Max</b> | <b>2.0919</b> | <b>1.7147</b> | <b>2.0348</b> | <b>2.1622</b> | <b>1.7364</b> | <b>2.1262</b> | <b>2.2965</b> |
| <b>Min</b> | <b>1.166</b>  | <b>1.7147</b> | <b>1.656</b>  | <b>1.3226</b> | <b>.9156</b>  | <b>1.1831</b> | <b>1.2717</b> |
| <b>Avg</b> | <b>1.5177</b> | <b>1.7147</b> | <b>1.7842</b> | <b>1.7086</b> | <b>1.4239</b> | <b>1.5530</b> | <b>1.6120</b> |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124132 / 33 KV AMADADA

Feeder No / Name : 201 / 11 KV AMADAD GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.3817    | 1.3756    | 1.3717    | 1.2567    |           |           |
| 8    | .8962     | .8686     | .8688     | 1.5432    | .8501     | .8962     |           |
| 12   | .499      | .6154     | .5716     |           | .462      | .6697     | .7049     |
| 14   |           |           |           | .5415     |           |           |           |
| 16   | .6161     | .5973     | .6668     | .6099     |           | .6697     | .6478     |
| 18   | .7468     |           | .7621     | .7023     | .8029     |           | .9145     |
| 20   |           | 1.0317    |           |           |           | 1.1403    |           |
| 24   | .6161     |           | .6516     | 1.2803    |           |           |           |
| Max  | .8962     | 1.3817    | 1.3756    | 1.5432    | 1.2567    | 1.1403    | .9145     |
| Min  | .499      | .5973     | .5716     | .5415     | .462      | .6697     | .6478     |
| Avg  | .6748     | .8989     | .8161     | 1.0082    | .8429     | .8440     | .7557     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124151 / 33 KV VADJI

Feeder No / Name : 201 / 11 KV Pandhrad feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .0016     | .0016     | .0016     | .0014     | .002      | .0017     |           |
| 8    | .0011     | .001      | .0013     | .0016     | .0021     | .0022     | .002      |
| 12   | .0027     | .0027     | .0025     | .0025     |           | .0006     | .0009     |
| 16   | .0025     | .0025     | .0023     | .0022     | .0008     |           | .0009     |
| 20   | .0018     | .0017     | .0017     | .0017     | .0015     | .0016     | .0016     |
| 24   | .0012     | .001      | .0011     | .0011     | .0017     | .0015     | .0014     |
| Max  | .0027     | .0027     | .0025     | .0025     | .0021     | .0022     | .002      |
| Min  | .0011     | .001      | .0011     | .0011     | .0008     | .0006     | .0009     |
| Avg  | .0018     | .0018     | .0018     | .0018     | .0016     | .0015     | .0014     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124151 / 33 KV VADJI

Feeder No / Name : 202 / 11 KV Mahindale feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .0012     | .0012     | .0011     | .001      | .0009     | .0009     | .0009     |
| 8    | .0009     | .001      | .001      | .0009     | .0007     | .0007     |           |
| 12   | .0005     | .0005     | .0005     |           | .0013     |           | .0012     |
| 16   | .0005     | .0005     | .0005     | .0005     |           |           | .0011     |
| 20   | .001      | .001      | .001      | .001      | .001      | .001      | .001      |
| 24   | .0011     | .0011     | .0009     | .0009     | .0006     | .0008     |           |
| Max  | .0012     | .0012     | .0011     | .001      | .0013     | .001      | .0012     |
| Min  | .0005     | .0005     | .0005     | .0005     | .0006     | .0007     | .0009     |
| Avg  | .0009     | .0009     | .0008     | .0009     | .0009     | .0009     | .0011     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124151 / 33 KV VADJI

Feeder No / Name : 203 / 11 KV Kothali-Nimbhora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .0002     | .0002     | .0002     | .0002     |           |           |
| 8    | .0003     | .0002     | .0002     | .0002     |           |           |
| 12   |           |           |           |           | .0003     | .0003     |
| 16   |           |           |           |           | .0003     | .0003     |
| 24   | .0002     | .0002     | .0002     | .0002     |           |           |
| Max  | .0003     | .0002     | .0002     | .0002     | .0003     | .0003     |
| Min  | .0002     | .0002     | .0002     | .0002     | .0003     | .0003     |
| Avg  | .0002     | .0002     | .0002     | .0002     | .0003     | .0003     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124153 / 33 KV LON PIRACHE

Feeder No / Name : 201 / 11 KV GONDGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.3756    | 1.0498    | 1.0317    | .9955     |           | 1.7194    | 1.9547    |
| 6    |           |           |           |           | 1.8461    |           |           |
| 7    |           | 1.5384    |           |           |           |           |           |
| 8    | 1.3213    | 1.3032    | 1.267     | 1.2851    | 1.2308    | 1.2489    | 1.1403    |
| 12   | 1.7013    | 1.8099    | 1.6289    | 1.8461    | .7059     | .724      | .724      |
| 16   | 1.7375    | 1.6108    | 1.7918    | 1.7194    | .7421     | 1.7918    | .8145     |
| 18   |           |           |           | .905      |           |           | .905      |
| 20   | 1.4842    | 1.4299    | 1.3032    | 1.3937    | 1.4118    | 1.448     | 1.3032    |
| 24   | .8326     | .8145     | .7783     | .7964     | 1.7737    | 1.8461    | 1.4842    |
| Max  | 1.7375    | 1.8099    | 1.7918    | 1.8461    | 1.8461    | 1.8461    | 1.9547    |
| Min  | .8326     | .8145     | .7783     | .7964     | .7059     | .724      | .724      |
| Avg  | 1.4088    | 1.3652    | 1.3002    | 1.2773    | 1.2851    | 1.4630    | 1.1894    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124153 / 33 KV LON PIRACHE

Feeder No / Name : 202 / 11 KV GHUSARDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           |           | .5335     | .5487     | .5944     |
| 6    |           |           |           |           | .6554     |           |           |
| 8    |           |           |           |           | .5944     | .7011     | .6401     |
| 12   | .9602     | .823      | .884      | .823      |           |           |           |
| 16   | .8383     | .7621     | .8688     | .7926     |           |           |           |
| 24   |           |           |           |           | .5487     | .5944     | .5639     |
| Max  | .9602     | .823      | .884      | .823      | .6554     | .7011     | .6401     |
| Min  | .8383     | .7621     | .8688     | .7926     | .5335     | .5487     | .5639     |
| Avg  | .8993     | .7926     | .8764     | .8078     | .583      | .6147     | .5995     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

BHADGAON[549]

BU 8125

Substation No/ Name :- 124153 / 33 KV LON PIRACHE

Feeder No / Name : 203 / 11 KV LON P. SINGLE PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.4255    | .9945     | 1.0111    | 1.0442    | 1.21      | 1.21      | 1.5083    |
| 7    |           | 1.5912    |           |           |           |           |           |
| 8    | 1.2763    | 1.326     | 1.4089    | 1.2763    | 1.1603    | 1.0608    | 1.2763    |
| 12   | .663      | .6464     | .663      | .6133     | 1.4255    | 1.21      | 1.1603    |
| 16   | .663      | .663      | .7127     | .6962     | 1.1603    | 1.0277    | 1.1105    |
| 18   |           |           |           | .7459     |           |           | .7625     |
| 20   | 1.3923    | 1.442     | 1.4255    | 1.326     | 1.4089    | 1.3923    | 1.4586    |
| 24   | .9116     | .9779     | 1.0442    | 1.0774    | 1.0111    | .9614     | 1.1603    |
| Max  | 1.4255    | 1.5912    | 1.4255    | 1.326     | 1.4255    | 1.3923    | 1.5083    |
| Min  | .663      | .6464     | .663      | .6133     | 1.0111    | .9614     | .7625     |
| Avg  | 1.0553    | 1.0916    | 1.0442    | .9685     | 1.2294    | 1.1437    | 1.2053    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 202 / 11 KV PASARDI GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .5144     | .5144     | .4801     | .5144     | .4973     | .4115     | .5316     |
| 7    | .5144     | .463      | .4801     | .3944     | .4801     | .4287     | .463      |
| 8    | .3944     | .3429     | .3601     | .3429     | .3601     | .3258     | .3429     |
| 9    |           |           |           | .2915     | .2743     |           |           |
| 10   | .2058     | .2229     | .2058     | .2401     | .2229     | .1543     |           |
| 11   | .1543     |           | .1372     | .1543     |           |           |           |
| 12   |           |           | .12       |           |           | .12       | .1372     |
| 13   |           | .1372     |           |           |           |           |           |
| 14   | .1543     |           |           |           | .12       |           |           |
| 15   |           |           | .1372     |           |           |           |           |
| 16   | .1715     | .1543     |           | .1543     | .1886     | .1543     | .1715     |
| 17   | .1715     |           | .1372     | .1715     |           |           | .1543     |
| 18   | .2401     | .2915     |           | .2058     | .2229     | .2915     | .2915     |
| 19   |           |           |           | .3772     |           |           |           |
| 20   |           |           |           |           |           | .3772     |           |
| 21   |           |           |           |           |           |           | .2743     |
| 22   |           | .2058     | .2229     | .2401     |           |           | .2401     |
| Max  | .5144     | .5144     | .4801     | .5144     | .4973     | .4287     | .5316     |
| Min  | .1543     | .1372     | .12       | .1543     | .12       | .12       | .1372     |
| Avg  | .2801     | .2915     | .2534     | .2806     | .2958     | .2829     | .2896     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 203 / 11 KV GALAN FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .2401     | .2401     | .2401     | .2401     | .6173     | .7888     | .7716     |
| 7    | .2401     | .2401     | .2058     | .2401     | .6859     | .7373     | .5658     |
| 8    | .1715     | .2229     | .1886     | .1886     | .3772     | .6001     | .5487     |
| 9    |           |           |           | .3429     | .1372     |           |           |
| 10   | .7888     | .7545     | .6516     | .6173     | .12       | .12       |           |
| 11   | .9774     |           | .8916     | .6516     |           |           |           |
| 12   |           |           | .7545     |           |           | .1029     | .12       |
| 13   |           | .6173     |           |           |           |           |           |
| 14   | .6687     |           |           |           | .1029     |           |           |
| 15   |           |           | .4458     |           |           |           |           |
| 16   | .6859     | .5487     |           | .4801     | .1029     | .12       | .1372     |
| 17   | .0857     |           | .12       | .12       |           |           | .12       |
| 18   | .1372     | .1372     |           | .12       | .1543     | .1029     | .1372     |
| 19   |           |           |           | .2058     |           |           |           |
| 20   |           |           |           |           |           | .1886     |           |
| 21   |           |           |           |           |           |           | .1715     |
| 22   |           | .1543     | .12       | .1372     |           |           | .1372     |
| Max  | .9774     | .7545     | .8916     | .6516     | .6859     | .7888     | .7716     |
| Min  | .0857     | .1372     | .12       | .12       | .1029     | .1029     | .12       |
| Avg  | .4439     | .3644     | .402      | .3040     | .2872     | .3451     | .3010     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 204 / 11 KV PASARDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           | .2401     | .3772     | .5144     | .4973     |
| 7    |           |           |           | .3601     | .583      | .4973     | .5487     |
| 8    |           |           |           | .3086     | .463      | .3772     | .2401     |
| 10   | .5487     | .4801     | .4801     |           |           |           |           |
| 11   | .6001     |           | .5487     |           |           |           |           |
| 12   | .7545     |           | .463      |           |           |           |           |
| 13   |           | .3258     |           |           |           |           |           |
| 14   | .3944     |           |           |           |           |           |           |
| 15   |           |           | .2572     |           |           |           |           |
| 16   | .3772     | .3601     |           |           |           |           |           |
| Max  | .7545     | .4801     | .5487     | .3601     | .583      | .5144     | .5487     |
| Min  | .3772     | .3258     | .2572     | .2401     | .3772     | .3772     | .2401     |
| Avg  | .5350     | .3887     | .4373     | .3029     | .4744     | .4630     | .4287     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 206 / 11 KV KAJGAON AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           | .5316     | .703      | .3944     |
| 7    |           |           |           |           | .583      | .7373     | .6687     |
| 8    |           |           |           |           | .5144     | .4115     | .703      |
| 9    |           |           |           | .8573     |           |           |           |
| 10   | .7545     | .5487     | .6859     | .6859     |           |           |           |
| 11   | .7716     |           | .7202     | .7373     |           |           |           |
| 12   |           |           | .6687     |           |           |           |           |
| 13   |           | .3429     |           |           |           |           |           |
| 14   | .5658     |           |           |           |           |           |           |
| 15   |           |           | .3944     |           |           |           |           |
| 16   | .4801     | .7202     |           | .6516     |           |           |           |
| Max  | .7716     | .7202     | .7202     | .8573     | .583      | .7373     | .703      |
| Min  | .4801     | .3429     | .3944     | .6516     | .5144     | .4115     | .3944     |
| Avg  | .643      | .5373     | .6173     | .7330     | .543      | .6173     | .5887     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 207 / 11 KV KAJGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.3889    | 1.3889    | 1.406     | 1.3546    | 1.3203    | 1.4232    | 1.3375    |
| 7    | 1.2689    | 1.166     | .3086     | 1.1831    | 1.2517    | 1.1145    | 1.2174    |
| 8    | 1.0802    | .9945     | .9774     | .9431     | 1.0117    | .9259     | .9774     |
| 9    |           |           |           | .823      | .7716     |           |           |
| 10   | .7716     | .8573     | .7545     | .8573     | .7716     | .9088     |           |
| 11   | .7202     |           | .6687     | .6859     |           |           |           |
| 12   |           |           | .6516     |           |           | .6344     | .6516     |
| 13   |           | .703      |           |           |           |           |           |
| 14   | .6173     |           |           |           | .6687     |           |           |
| 15   |           |           | .6001     |           |           |           |           |
| 16   | .6516     | .7202     |           | .6859     | .6344     | .6344     | .6344     |
| 17   | .6516     |           | .6344     | .7716     |           |           | .703      |
| 18   | .8059     | .8573     |           | .6859     | .7545     | .7373     | .8402     |
| 19   |           |           |           | 1.0117    |           |           |           |
| 21   |           |           |           |           |           |           | .9088     |
| 22   |           | .8402     | .8402     | .823      |           |           | .7545     |
| Max  | 1.3889    | 1.3889    | 1.406     | 1.3546    | 1.3203    | 1.4232    | 1.3375    |
| Min  | .6173     | .703      | .3086     | .6859     | .6344     | .6344     | .6344     |
| Avg  | .8840     | .9409     | .7602     | .8932     | .8981     | .9112     | .8916     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 208 / 11 KV GONDGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .3772     | .5658     | .5487     | .6173     | .6001     | .703      | .5316     |
| 7    | .4973     | .4973     | .3086     | .4801     | .463      | .4973     | .463      |
| 8    | .3772     | .3772     | .2743     | .463      | .3429     | .4287     | .4458     |
| 9    |           |           |           | .4458     | .4115     |           |           |
| 10   | .3772     | .1886     | .4287     | .3429     | .2401     | .3944     |           |
| 11   | .3258     |           | .3601     | .3429     |           |           |           |
| 12   |           |           | .3601     |           |           |           | .3429     |
| 13   |           | .1886     | .2543     |           |           | .2572     |           |
| 14   | .2743     |           |           |           | .3258     |           |           |
| 15   |           |           | .3258     |           |           |           |           |
| 16   | .3429     | .2058     |           | .2229     | .3772     | .3944     | .3601     |
| 17   | .2401     |           | .4973     | .2743     |           |           | .3429     |
| 18   | .3944     | .2058     |           | .3601     | .2915     | .3086     | .3772     |
| 19   |           |           |           | .4973     |           |           |           |
| 20   |           |           |           |           |           | .6516     |           |
| 21   |           |           |           |           |           |           | .3429     |
| 22   |           | .2572     | .4115     | .2743     |           |           | .2401     |
| Max  | .4973     | .5658     | .5487     | .6173     | .6001     | .703      | .5316     |
| Min  | .2401     | .1886     | .2543     | .2229     | .2401     | .2572     | .2401     |
| Avg  | .3563     | .3108     | .3769     | .3928     | .3815     | .4544     | .3829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 209 / 11 KV GONDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.0631    | 1.3546    | 1.1317    | .7888     |           |           |           |
| 7    | 1.1317    | 1.2003    | 1.1145    | .9602     |           |           |           |
| 8    | .8916     | .7716     | .9259     | .9602     |           |           |           |
| 9    |           |           |           |           | .823      |           |           |
| 10   |           |           |           |           | 1.3546    | 1.2174    |           |
| 12   |           |           |           |           |           | 1.3717    | 1.3032    |
| 14   |           |           |           |           | 1.3203    |           |           |
| 16   |           |           |           |           | 1.3032    | 1.2689    | 1.1831    |
| Max  | 1.1317    | 1.3546    | 1.1317    | .9602     | 1.3546    | 1.3717    | 1.3032    |
| Min  | .8916     | .7716     | .9259     | .7888     | .823      | 1.2174    | 1.1831    |
| Avg  | 1.0288    | 1.1088    | 1.0574    | .9031     | 1.2003    | 1.286     | 1.2432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124008 / 33 KV KAJGAON

Feeder No / Name : 210 / 11 KV GHUSARDI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .1372     | .1715     |           |           |           |           | .1029     |
| 7    | .1372     | .1543     |           |           |           |           | .1372     |
| 8    |           | .1372     |           |           |           |           | .0857     |
| 9    |           |           |           | .0686     |           |           |           |
| 10   |           |           | .12       | .1714     | .0857     | .0514     |           |
| 11   |           |           | .1543     | .2058     |           |           |           |
| 12   |           |           | .1715     |           |           | .0857     |           |
| 14   |           |           |           |           | .3258     |           |           |
| 15   |           |           | .0857     |           |           |           |           |
| 16   |           |           |           | .2058     | .1029     | .0686     |           |
| Max  | .1372     | .1715     | .1715     | .2058     | .3258     | .0857     | .1372     |
| Min  | .1372     | .1372     | .0857     | .0686     | .0857     | .0514     | .0857     |
| Avg  | .1372     | .1543     | .1329     | .1629     | .1715     | .0686     | .1086     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 201 / 11 KV NAGARDEOLA URBAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .7621     | .8383     | .7621     | .7621     | .7621     | .8383     | .8383     |
| 8    | .9145     | .8383     | .8383     | .8383     | .8383     | .9145     | .9145     |
| 12   | .6097     | .6097     | .5335     | .6097     | .6097     | .6859     | .6097     |
| 16   | .5335     | .6097     | .5335     | .5335     | .6097     | .6097     | .6097     |
| 20   | .9907     | .9907     | .9907     | .9907     | .9907     |           | .9907     |
| 24   | .6859     | .6097     | .6097     | .5335     | .6097     | .5335     | .6859     |
| Max  | .9907     | .9907     | .9907     | .9907     | .9907     | .9145     | .9907     |
| Min  | .5335     | .6097     | .5335     | .5335     | .6097     | .5335     | .6097     |
| Avg  | .7494     | .7494     | .7113     | .7113     | .7367     | .7164     | .7748     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 202 / 11 KV NIPANE FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .8383     | 1.2955    | 1.3718    | 1.3718    | .6097     | .6097     | .6097     |
| 8    | .9145     | 2.2862    | 1.1431    | .7621     | .6097     | .6097     | .6097     |
| 12   | .3048     | .6096     | .6096     | .2286     | 1.1431    | .9145     | 1.1431    |
| 16   | .3048     | .6096     | .6096     | .2286     | .9145     | .9145     | .9145     |
| 20   | .6859     | 1.3718    | 1.3718    | .7621     | .7621     |           | .7621     |
| 24   | .6859     | .9145     | .9144     | .9144     | .4572     | .3048     | .381      |
| Max  | .9145     | 2.2862    | 1.3718    | 1.3718    | 1.1431    | .9145     | 1.1431    |
| Min  | .3048     | .6096     | .6096     | .2286     | .4572     | .3048     | .381      |
| Avg  | .6224     | 1.1812    | 1.0034    | .7113     | .7494     | .6706     | .7367     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 203 / 11 KV PIMPALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           |           |           |           | .1524     | .3048     | .1524     |
| 8    |           |           |           |           | .2286     | .381      | .2286     |
| 12   | .4572     | .3048     | .381      | .3048     |           |           |           |
| 16   | .2286     | .2286     | .2286     | .2286     |           |           |           |
| 24   |           |           |           |           | .0762     | .1524     | .1524     |
| Max  | .4572     | .3048     | .381      | .3048     | .2286     | .381      | .2286     |
| Min  | .2286     | .2286     | .2286     | .2286     | .0762     | .1524     | .1524     |
| Avg  | .3429     | .2667     | .3048     | .2667     | .1524     | .2794     | .1778     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 204 / 11 KV VISHNU NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .6859     | .9145     | .6097     | .9145     | .9145     | .7621     | .9145     |
| 8    | .7621     | .6097     | .6859     | .6859     | .6859     | .7621     | .7621     |
| 12   | .4572     | .4572     | .4572     | .7621     | .7621     | .6859     | .6097     |
| 16   |           | .4572     | .5335     | .7621     | .6097     | .6097     | .6097     |
| 20   | .9145     | .8383     | .5239     | .8383     | .8383     |           | .8383     |
| 24   | .6097     | .8383     | .7621     | .6097     | .6859     | .6097     | .6859     |
| Max  | .9145     | .9145     | .7621     | .9145     | .9145     | .7621     | .9145     |
| Min  | .4572     | .4572     | .4572     | .6097     | .6097     | .6097     | .6097     |
| Avg  | .6859     | .6859     | .5954     | .7621     | .7494     | .6859     | .7367     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 205 / 11 KV INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 8    | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 12   | .0762     | .0762     | .0762     | .0762     | .0762     |           | .0762     |
| 16   | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 20   | .0762     | .0762     | .0762     | .0762     | .0762     |           | .0762     |
| 24   | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Max  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Min  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Avg  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124090 / 33/11 KV NAGARDEOLA

Feeder No / Name : 206 / 11 KV PIMPALGAON GAV.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 8    | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 12   | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 16   | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| 20   | .0762     | .0762     | .0762     | .0762     | .0762     |           | .0762     |
| 24   | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Max  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Min  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |
| Avg  | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124160 / 33/11 KV TARKHEDA S/S

Feeder No / Name : 201 / 11 KV TARKHEDA GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .2987     | .2774     | .2743     | .2804     | .2804     | .2987     | .3174     |
| 4    | .3547     | .3506     | .3658     | .3641     | .362      | .3921     | .3734     |
| 6    | .6283     | .6024     | .6036     | .5847     | .5959     | .6099     | .5788     |
| 8    | .3142     | .3467     | .3109     | .2774     | .3077     | .3142     | .3174     |
| 10   | .208      | .3326     | .2254     | .2378     | .2772     | .2402     | .2378     |
| 12   | .1886     | .2402     | .2229     | .2353     | .2218     | .2587     | .2743     |
| 13   |           |           |           |           |           | .2402     |           |
| 14   | .2103     | .2402     | .2454     | .2103     | .2587     | .2587     | .2561     |
| 16   | .2601     | .2587     | .2254     | .2427     | .2772     | .2587     | .2743     |
| 17   |           |           |           |           | .2801     | .2772     |           |
| 18   | .2427     | .2772     | .2427     | .2454     | .2614     |           | .2743     |
| 20   | .3814     | .3881     | .3467     | .3982     | .4108     | .4294     | .4207     |
| 22   | .3681     | .3696     | .333      | .3439     | .3696     | .3921     | .3658     |
| 23   |           |           |           | .3155     | .3326     |           |           |
| 24   | .3142     | .2835     | .3109     | .2804     | .3109     | .3174     | .3361     |
| Max  | .6283     | .6024     | .6036     | .5847     | .5959     | .6099     | .5788     |
| Min  | .1886     | .2402     | .2229     | .2103     | .2218     | .2402     | .2378     |
| Avg  | .3141     | .3306     | .3089     | .3089     | .3247     | .3298     | .3355     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124160 / 33/11 KV TARKHEDA S/S

Feeder No / Name : 202 / 11 KV TARKHEDA AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .0154     | .0255     | .0154     |           |           |           |
| 4    | .0156     | .0128     | .0156     |           |           |           |
| 6    | .0469     | .0248     | .0309     |           |           |           |
| 8    | .0926     | .0732     | .0617     |           |           |           |
| 10   |           |           | .0743     | .061      | .0305     | .0389     |
| 12   |           |           | .0714     | .0762     | .061      | .0777     |
| 13   |           |           |           |           | .0457     |           |
| 14   |           |           | .0412     | .0762     | .0457     | .2561     |
| 16   |           |           | .0549     | .061      | .061      | .1684     |
| 24   | .0154     | .0248     | .0156     |           |           |           |
| Max  | .0926     | .0732     | .0743     | .0762     | .061      | .2561     |
| Min  | .0154     | .0128     | .0154     | .061      | .0305     | .0389     |
| Avg  | .0372     | .0322     | .0423     | .0686     | .0488     | .1353     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

NAGAR DEOLA S/DN.[590] BU 0590

Substation No/ Name :- 124160 / 33/11 KV TARKHEDA S/S

Feeder No / Name : 203 / 11 KV HANUMAN NAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    | .1406     | .1189     | .1235     | .1829     |           |           |
| 4    | .1581     | .1067     | .125      | .2134     |           |           |
| 6    | .2031     | .1219     | .1581     | .2393     |           |           |
| 8    | .1562     | .1337     | .1543     | .2148     |           |           |
| 9    |           |           |           | .0714     |           |           |
| 10   |           |           |           | .1781     | .2105     | .1337     |
| 12   |           |           |           | .2267     | .2105     | .1656     |
| 13   |           |           |           |           | .2105     |           |
| 14   |           |           |           | .1943     | .1619     | .1486     |
| 16   |           |           |           | .1457     | .1457     | .1635     |
| 23   |           |           | .081      |           |           |           |
| 24   | .1406     | .104      | .1094     | .1524     |           |           |
| Max  | .2031     | .1337     | .1581     | .2393     | .2105     | .1656     |
| Min  | .1406     | .104      | .081      | .0714     | .1457     | .1337     |
| Avg  | .1597     | .1170     | .1252     | .1819     | .1878     | .1529     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124010 / 33/11 KV WADI SHEWALE

Feeder No / Name : 201 / 11 KV WADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .3353     | .208      | .1738     |
| 2    |           |           |           |           | .3353     | .208      | .2027     |
| 3    |           |           |           |           | .3963     | .208      | .2317     |
| 4    |           |           |           |           | .4268     | .2172     | .2572     |
| 5    |           |           |           |           | .4877     | .2526     | .2606     |
| 6    |           |           |           |           | .5792     | .3715     | .2896     |
| 7    |           |           |           |           | .5182     | .543      | .5502     |
| 8    |           |           |           |           | .4268     |           | .5053     |
| 9    | .2675     | .1646     | .2378     | .2743     |           |           |           |
| 10   | .4755     |           | .4572     | .3353     |           |           |           |
| 11   | .5944     | .4664     | .535      | .5487     |           |           |           |
| 12   | .6241     | .4572     | .4904     | .6401     |           |           |           |
| 13   | .5944     | .4755     | .4344     | .5792     |           |           |           |
| 14   | .5053     | .4458     | .4344     | .5182     |           |           |           |
| 15   | .4161     | .4572     | .4161     | .4877     |           |           |           |
| 16   | .4755     | .3734     | .2896     | .5182     |           |           |           |
| 23   |           |           |           | .2439     | .2229     | .1715     |           |
| 24   |           |           |           |           | .2134     | .208      | .2        |
| Max  | .6241     | .4755     | .535      | .6401     | .5792     | .543      | .5502     |
| Min  | .2675     | .1646     | .2378     | .2439     | .2134     | .1715     | .1738     |
| Avg  | .4941     | .4057     | .4119     | .4606     | .3942     | .2653     | .2968     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124010 / 33/11 KV WADI SHEWALE

Feeder No / Name : 202 / 11 KV SATGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0059    | 1.1576    | 1.1203    | .9877     | .6706     | .6706     | .7042     |
| 2    | 1.0059    | 1.1949    | 1.1576    | .9979     | .7011     | .6706     | .6802     |
| 3    | 1.0974    | 1.2696    | 1.2323    | 1.0349    | .7621     | .6706     | .8048     |
| 4    | 1.3306    | 1.419     | 1.2696    | 1.1458    | .884      | .7499     | .9069     |
| 5    | 1.5729    | 1.6804    | 1.419     | 1.39      | 1.0059    | .9717     | 1.0364    |
| 6    |           | 2.0911    |           | 2.0119    | 1.1888    | 1.1012    | 1.1736    |
| 7    | 1.8839    | 1.7924    | 1.9418    | 1.7741    | 1.1279    | 1.2193    | 1.3927    |
| 8    | 1.3717    | 1.3443    | 1.39      | 1.3352    | 1.0364    | 1.1069    | 1.07      |
| 9    | .8916     | .6706     | .8745     | .4877     | 1.0242    | 1.1222    | 1.1203    |
| 10   | 1.0402    | .9808     | 1.0978    | .4572     | .9511     | .9412     | 1.0082    |
| 11   | 1.0997    | .9808     | 1.0974    | .945      | .8413     | .8326     | .9335     |
| 12   | 1.1294    | .9686     | 1.0669    | 1.0059    | .8048     | .724      | .7842     |
| 13   | 1.1888    | .9374     | 1.0084    | 1.0364    | .7682     |           | .8215     |
| 14   | 1.0997    | .7926     | .9511     | .945      | .8413     |           | .8589     |
| 15   | .9808     | .7926     | .7926     | .8535     | .8413     | .724      | .8215     |
| 16   | 1.0105    | .8535     | .8535     | .945      | .8413     | .8326     | .8962     |
| 17   | .8215     | .8326     | .7316     | .9259     | .8779     | .724      | .8962     |
| 18   | .9335     | .905      | 1.0059    | .9259     | .9511     | .9335     | .9709     |
| 19   | 1.643     | 1.4563    | 1.5154    | 1.3717    | 1.4784    |           | 1.643     |
| 20   | 1.531     | 1.643     | 1.5893    | 1.4746    | 1.5729    |           | 1.7177    |
| 21   | 1.307     | 1.307     | 1.39      | 1.2689    | 1.3352    |           | 1.6804    |
| 22   | 1.1576    | 1.1576    | 1.2567    | 1.1317    | 1.1706    | 1.1576    | 1.1949    |
| 23   | 1.0829    | 1.1203    | 1.0974    | .7011     | .6706     | .6478     | 1.1203    |
| 24   | 1.0059    | 1.1203    | 1.1088    | 1.0242    | .6706     | .6706     | .6478     |
| Max  | 1.8839    | 2.0911    | 1.9418    | 2.0119    | 1.5729    | 1.2193    | 1.7177    |
| Min  | .8215     | .6706     | .7316     | .4572     | .6706     | .6478     | .6478     |
| Avg  | 1.1822    | 1.1862    | 1.1725    | 1.0907    | .9591     | .8669     | 1.0368    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124010 / 33/11 KV WADI SHEWALE

Feeder No / Name : 203 / 11 KV MONDHALE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .208      | .4161     | .2134     | .2561     | .4458     | .4938     | .5228     |
| 2    | .208      | .4161     | .2439     | .2587     | .4115     | .4938     |           |
| 3    | .208      | .4458     | .2439     | .2561     | .4801     | .4938     | .5975     |
| 4    | .2675     | .4755     | .25       | .2439     | .583      | .5853     | .7468     |
| 5    | .3269     | .4755     | .2743     | .3048     | .7202     | .8501     | .8589     |
| 6    |           | .5053     |           | .3864     | .8573     | 1.0242    | 1.0456    |
| 7    | .4904     | .4458     | .421      | .4458     | .7545     | .8131     | .9335     |
| 8    | .4458     | .2972     | .3269     | .4111     | .6173     | .7392     | .7468     |
| 9    | .5228     | .5144     | .543      | .5487     | .2378     | .2561     | .208      |
| 10   | .4854     | .3982     | .4805     | .4458     | .2896     | .2591     | .2675     |
| 11   | .4108     | .362      | .4066     | .3429     | .3269     | .2439     | .2972     |
| 12   | .3734     | .362      | .3658     | .3429     | .2675     | .2187     | .2134     |
| 13   | .3734     | .3982     | .3658     | .3086     | .2743     |           | .2675     |
| 14   | .2972     | .3982     | .3841     | .3429     | .2439     |           | .208      |
| 15   | .4481     | .3982     | .4066     | .4115     | .2378     | .1829     | .2378     |
| 16   | .4108     | .3982     | .3881     | .4458     | .2378     | .2439     | .2378     |
| 17   | .3734     | .362      | .3696     | .4458     | .4024     | .362      | .3734     |
| 18   | .5228     | .3982     | .3841     | .4458     | .3841     | .3982     | .4481     |
| 19   | .8589     | .7468     | .6283     | .6859     | .6722     |           | .8589     |
| 20   | .7468     | .8215     | .7023     | .7545     | .7865     |           | .8589     |
| 21   | .5975     | .6348     | .6283     | .6516     | .6036     |           | .8962     |
| 22   | .5601     | .543      | .5121     | .5487     | .543      | .5144     | .5975     |
| 23   | .4755     | .2286     | .2286     | .4801     | .4938     | .5068     | .5053     |
| 24   | .208      | .4458     | .2        | .2378     | .4801     | .4938     | .5228     |
| Max  | .8589     | .8215     | .7023     | .7545     | .8573     | 1.0242    | 1.0456    |
| Min  | .208      | .2286     | .2        | .2378     | .2378     | .1829     | .208      |
| Avg  | .4269     | .4536     | .3899     | .4168     | .4730     | .4828     | .5413     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124010 / 33/11 KV WADI SHEWALE

Feeder No / Name : 204 / 11 KV DONGERGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8749     | .743      | .8097     | .8749     | .6516     | .6767     | .7468     |
| 2    | .8749     | .8025     | .8745     | .8749     | .6859     | .6767     | .7842     |
| 3    | .8749     | .8916     | .9069     | .8855     | .7202     | .7316     | .8589     |
| 4    | .9172     | .9511     | .9717     | 1.0753    | .7888     | .8779     | .9709     |
| 5    | .9145     | 1.0402    | 1.004     | 1.0364    | .9259     | 1.0719    | 1.0829    |
| 6    |           | 1.1294    | 1.1736    | 1.1702    | 1.1317    | 1.134     | 1.2323    |
| 7    | 1.1888    | 1.1888    | 1.3279    | 1.3599    | 1.0288    | .961      | 1.1576    |
| 8    | 1.0936    | .9808     | 1.1279    | 1.3603    | .8916     | .7577     | .8962     |
| 9    | .7095     | .6516     | .5639     | .6859     | .9755     | .8745     | .9808     |
| 10   | .6722     |           | .5487     | .5487     | 1.1584    | 1.004     | 1.0105    |
| 11   | .5228     | .5068     | .5304     | .4458     | 1.2193    | 1.1336    | 1.0997    |
| 12   | .5228     | .4706     | .5121     | .4115     | 1.2803    | 1.2308    | 1.1294    |
| 13   | .5601     | .543      | .5175     | .4458     | 1.2967    |           | 1.1591    |
| 14   | .5228     | .5068     | .5729     | .4458     | 1.2651    |           | 1.1591    |
| 15   | .5601     | .5068     | .5853     | .4801     | 1.2308    | .9717     | 1.1888    |
| 16   | .5975     | .5068     | .5487     | .5144     | 1.1385    | 1.0688    | 1.0402    |
| 17   | .5228     | .543      | .5487     | .5487     | .5304     | .543      | .5601     |
| 18   | .7095     | .6219     | .6036     | .6173     | .0914     | .4854     | .5975     |
| 19   | 1.531     | .7468     | .8048     | .7545     | .7865     |           | 1.0082    |
| 20   | 1.4937    | .7095     | .9979     | .9259     | .9877     |           | 1.0829    |
| 21   | .8589     | .8215     | .924      | .823      | .695      |           | .8962     |
| 22   | .8215     | .7842     | .823      | .7888     | .6767     | .7842     | .8962     |
| 23   | .6836     | .7621     | .7926     | .7202     | .6767     | .7468     | .7133     |
| 24   | .884      | .7133     | .7499     | .8535     | .6859     | .6767     | .7468     |
| Max  | 1.531     | 1.1888    | 1.3279    | 1.3603    | 1.2967    | 1.2308    | 1.2323    |
| Min  | .5228     | .4706     | .5121     | .4115     | .0914     | .4854     | .5601     |
| Avg  | .8222     | .7444     | .7842     | .7770     | .8966     | .8635     | .9583     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124010 / 33/11 KV WADI SHEWALE

Feeder No / Name : 205 / 11 KV SHINDAD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4706     | .4161     | .421      | .4477     | .3658     | .4961     | .3887     |
| 2    | .4706     | .4458     | .4534     | .4525     | .3353     | .4908     | .421      |
| 3    | .5014     | .4755     | .4374     | .443      | .3963     | .4961     | .421      |
| 4    | .567      | .5944     | .4687     | .5609     | .4572     | .5316     | .5182     |
| 5    | .6733     | .6836     | .4999     | .567      | .5487     | .724      | .6154     |
| 6    |           | .743      | .6874     | .7577     | .6401     | .8238     | .7125     |
| 7    | .8413     | .535      | .7449     | .7392     | .5792     | .695      | .6802     |
| 8    | .5493     | .4755     | .5316     | .5068     | .5487     | .6161     | .4458     |
| 9    | .3864     | .3715     | .4607     | .3353     | .4706     | .3658     | .4458     |
| 10   | .3567     |           | .4207     | .3048     | .3189     | .421      | .3567     |
| 11   | .3269     | .2743     | .3841     | .3658     | .3012     | .2591     | .3567     |
| 12   | .2972     | .2591     | .3366     | .3353     |           | .25       | .2972     |
| 13   | .3269     | .25       | .3681     | .3658     | .4207     |           | .3269     |
| 14   | .2972     | .2743     | .3898     | .3963     | .4607     |           | .3269     |
| 15   | .3269     | .3048     | .4252     |           | .4607     | .3239     | .2972     |
| 16   | .3567     | .3048     | .3898     | .3963     | .4252     | .2743     | .3269     |
| 17   | .3864     | .3437     | .3898     | .4268     | .443      | .3239     | .3864     |
| 18   | .3864     | .3353     | .4458     | .4268     | .4706     | .3887     | .3864     |
| 19   | .5053     | .5975     | .6099     | .5182     | .6154     |           | .5944     |
| 20   | .6722     | .5601     | .6697     | .6401     | .7619     |           | .6241     |
| 21   | .6348     | .421      | .6154     | .5487     | .6024     |           | .5944     |
| 22   | .4458     | .421      | .4961     | .4268     | .5316     | .3772     | .4161     |
| 23   | .4161     | .4062     | .4607     | .3963     | .4961     | .3563     | .3864     |
| 24   | .4607     | .4161     | .3887     | .443      | .3658     | .4961     | .3749     |
| Max  | .8413     | .743      | .7449     | .7577     | .7619     | .8238     | .7125     |
| Min  | .2972     | .25       | .3366     | .3048     | .3012     | .25       | .2972     |
| Avg  | .4633     | .4308     | .4790     | .4696     | .4790     | .4584     | .4458     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124110 / 33/11 KV NIRMAL SUBSTATION

Feeder No / Name : 201 / 11 KV INDUSTRIAL NIRMAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .1524     | .1143     | .1543     | .1715     | .1715     | .1715     |           |
| 8    | .1334     |           |           | .1372     |           | .1715     |           |
| 12   | .0762     |           |           |           |           |           |           |
| 16   |           |           |           | .3239     | .3239     | .1524     | .2229     |
| 20   |           |           |           | .2096     | .2667     | .1715     | .1715     |
| 24   | .1372     | .1143     | .1715     | .1715     | .2058     | .2058     |           |
| Max  | .1524     | .1143     | .1715     | .3239     | .3239     | .2058     | .2229     |
| Min  | .0762     | .1143     | .1543     | .1372     | .1715     | .1524     | .1715     |
| Avg  | .1248     | .1143     | .1629     | .2027     | .2420     | .1745     | .1972     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244] BU 8168

Substation No/ Name :- 124110 / 33/11 KV NIRMAL SUBSTATION

Feeder No / Name : 203 / 11 KV PUNGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .3086     | .1905     | .12       | .1715     | .1715     | .2743     |           |
| 8    | .6668     |           |           | .2915     | .2401     |           |           |
| 12   | .2286     |           |           |           |           |           |           |
| 16   |           |           |           | .2286     | .2477     | .1524     | .1886     |
| 20   |           |           |           | .5335     | .5335     | .5335     | .5144     |
| 24   | .2401     | .1143     | .1372     | .1543     | .1372     | .2401     |           |
| Max  | .6668     | .1905     | .1372     | .5335     | .5335     | .5335     | .5144     |
| Min  | .2286     | .1143     | .12       | .1543     | .1372     | .1524     | .1886     |
| Avg  | .3610     | .1524     | .1286     | .2759     | .266      | .3001     | .3515     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124125 / 33/11 KV MIDC SUBSTATION

Feeder No / Name : 201 / 11 Kv KRUSHNAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.259     | 1.2576    | 1.2742    | 1.2922    | 1.2576    | 1.3475    | 1.3295    |
| 2    | 1.151     | 1.1498    | 1.2397    | 1.1845    | 1.2217    | 1.3115    | 1.3295    |
| 3    | 1.1151    | 1.1678    | 1.2204    | 1.0768    | 1.1858    | 1.2936    | 1.3115    |
| 4    | 1.1331    | 1.1319    | 1.2383    | 1.1127    | 1.1498    | 1.2576    | 1.2576    |
| 5    | 1.169     | 1.1858    | 1.2742    | 1.1486    | 1.2576    | 1.2397    | 1.2936    |
| 6    | 1.223     | 1.2936    | 1.3999    | 1.364     | 1.3115    | 1.4014    | 1.3654    |
| 7    | 1.259     | 1.2397    | 1.3101    | 1.4178    | 1.3834    | 1.2576    | 1.3295    |
| 8    | 1.0611    | 1.0959    | 1.0948    | 1.1845    | 1.1858    | 1.078     | 1.1678    |
| 9    | 1.8684    | .9702     | 1.023     | 1.2037    | 1.0061    | 1.0061    | 1.042     |
| 10   | .9342     | .9702     | .9871     | 1.0241    | .9342     | .9163     | 1.06      |
| 11   | 1.042     | 1.042     | .9163     | 1.0061    | .9702     | .9342     | 1.042     |
| 12   | 1.0241    | 1.042     | .964      | 1.0241    | 1.0061    | 1.042     | 1.06      |
| 13   | 1.0959    | 1.1498    | 1.0196    | 1.042     | 1.0241    | 1.0959    | 1.06      |
| 14   | 1.078     | 1.1858    | 1.0959    | 1.0959    | 1.06      | 1.0959    | 1.078     |
| 15   | 1.078     | 1.1858    | 1.078     | 1.0959    | 1.1139    | 1.0959    | 1.0959    |
| 16   | 1.1139    | 1.1319    | 1.1139    | 1.0959    | 1.0959    | 1.0959    | 1.1139    |
| 17   | 1.0791    | 1.0061    | 1.06      | 1.078     | 1.0241    | 1.042     | 1.0959    |
| 18   | 1.0252    | 1.06      | 1.2383    | 1.2217    | 1.0061    | 1.0959    | 1.0948    |
| 19   | 1.2756    | 1.2576    | 1.2922    | 1.2936    | 1.2936    | 1.3295    | 1.2742    |
| 20   | 1.3115    | 1.3295    | 1.364     | 1.3475    | 1.3115    | 1.3654    | 1.3281    |
| 21   | 1.2936    | 1.3475    | 1.364     | 1.4193    | 1.2936    | 1.4373    | 1.3819    |
| 22   | 1.3295    | 1.3295    | 1.3999    | 1.3475    | .521      | 1.3475    | 1.364     |
| 23   | 1.3475    | 1.3295    | 1.3999    | 1.3834    | 1.3475    | 1.3295    | 1.3819    |
| 24   | 1.3129    | 1.2936    | 1.3101    | 1.3999    | 1.3475    | 1.3295    | 1.3475    |
| Max  | 1.8684    | 1.3475    | 1.3999    | 1.4193    | 1.3834    | 1.4373    | 1.3819    |
| Min  | .9342     | .9702     | .9163     | 1.0061    | .521      | .9163     | 1.042     |
| Avg  | 1.1908    | 1.1730    | 1.1949    | 1.2025    | 1.1379    | 1.1977    | 1.2169    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124125 / 33/11 KV MIDC SUBSTATION

Feeder No / Name : 202 / 11 Kv VASAHAT INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2858     | .5906     | .5906     | .5716     | .5335     | .6097     |           |
| 2    | .3048     | .5716     | .5716     | .5906     | .5525     | .5906     | .4001     |
| 3    | .2858     | .5525     | .5525     | .6097     | .5335     | .6097     | .4191     |
| 4    | .2667     | .5906     | .5716     | .5716     | .5716     | .5906     | .381      |
| 5    | .2477     | .5716     | .5906     | .5906     | .5906     | .5716     | .4382     |
| 6    | .2858     | .5335     | .6097     | .5716     | .5716     | .5906     | .4954     |
| 7    | .2667     | .5525     | .5716     | .6097     | .5716     | .5906     | .5144     |
| 8    | .2858     | .4954     | .5716     | .6097     | .6097     | .6478     | .4382     |
| 9    | .5525     | .8192     | .8192     | 1.3718    | .8002     | .9526     | .4132     |
| 10   | .6287     | .8954     | .9907     | .8192     | .8383     | .9335     | .4382     |
| 11   | .6859     | .9907     | .9526     | .8383     | .8954     | .9526     | .4572     |
| 12   | .9335     | 1.0288    | .9907     | .8192     | .8383     | .8573     | .4382     |
| 13   | .8383     | .9717     | .9717     | .7811     | .8192     | .7621     | .4382     |
| 14   | .6478     | .8764     | .8954     | .7811     | .7811     | .724      | .4572     |
| 15   | .7621     | .9145     | .8764     | .724      | .8383     | .8764     | .4382     |
| 16   | .6287     | .9526     | .9717     | .7621     | .8954     | .8764     | .4572     |
| 17   | .8002     | .8192     | .8954     | .6668     | .7049     | .8192     | .4382     |
| 18   | .7811     | .6287     | .724      | .6668     | .724      | .724      | .4382     |
| 19   | .743      | .724      | .6287     | .6097     | .743      | .724      | .4191     |
| 20   | .4763     | .5906     | .6097     | .5716     | .5906     | .5144     | .4001     |
| 21   | .5335     | .5716     | .5525     | .5335     | .6097     | .5144     | .4001     |
| 22   | .5525     | .5335     | .6097     | .5144     | .5525     | .5144     | .4001     |
| 23   | .5525     | .5906     | .6097     | .5525     | .5906     | .4763     | .4191     |
| 24   | .2858     | .5716     | .6097     | .6097     | .1524     | .6287     | .5335     |
| Max  | .9335     | 1.0288    | .9907     | 1.3718    | .8954     | .9526     | .5335     |
| Min  | .2477     | .4954     | .5525     | .5144     | .1524     | .4763     | .381      |
| Avg  | .5263     | .7057     | .7224     | .6811     | .6629     | .6938     | .4379     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124125 / 33/11 KV MIDC SUBSTATION

Feeder No / Name : 203 / 11 Kv SHIVAR

FEEDER SEPERATION/PURE AG

(AGRICULTURE) Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2386     | .2227     | .1595     |           |           |           |
| 2    |           | .2386     | .2227     | .1914     |           |           |           |
| 3    |           | .2545     | .2386     | .1754     |           |           |           |
| 4    |           | .2864     | .2386     | .1914     |           |           |           |
| 5    |           | .3023     | .2704     | .2073     |           |           |           |
| 6    |           | .3023     | .3023     | .4306     |           |           |           |
| 7    |           | .4932     | .4613     | .4784     |           |           |           |
| 8    |           | .4613     | .2545     | .3987     |           |           |           |
| 9    | .35       |           |           |           | .2711     | .4943     | .3197     |
| 10   | .35       |           |           |           | .3987     | .5103     | .5115     |
| 11   | .6841     |           |           |           | .5262     | .5422     | .5914     |
| 12   | .6204     |           |           |           | .59       | .606      | .5435     |
| 13   | .5727     |           |           |           | .5741     | .5103     | .5115     |
| 14   | .5091     |           |           |           | .5601     | .5262     | .4955     |
| 15   | .525      |           |           |           | .5441     | .5103     | .4316     |
| 16   | .4932     |           |           |           | .5921     | .4784     | .5115     |
| 23   | .2386     | .2227     | .1909     |           |           |           |           |
| 24   |           | .2386     | .2227     | .1754     |           |           |           |
| Max  | .6841     | .4932     | .4613     | .4784     | .5921     | .606      | .5914     |
| Min  | .2386     | .2227     | .1909     | .1595     | .2711     | .4784     | .3197     |
| Avg  | .4826     | .3039     | .2625     | .2676     | .5071     | .5223     | .4895     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124125 / 33/11 KV MIDC SUBSTATION

Feeder No / Name : 204 / 11 KV GAYTRI FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1143     | .1524     | .1524     | .1524     | .1143     | .1715     | .1524     |
| 2    | .1143     | .1524     | .1524     | .1524     | .1143     | .1524     | .1524     |
| 3    | .1334     | .1524     | .1524     | .1524     | .1524     | .1524     | .1524     |
| 4    | .1334     | .1715     | .1715     | .1715     | .1715     | .1715     | .1524     |
| 5    | .1524     | .1715     | .1715     | .1715     | .1905     | .1905     | .1524     |
| 6    | .1524     | .1905     | .1905     | .1715     | .1905     | .1905     | .1715     |
| 7    |           | .1905     | .1715     | .1905     | .1715     | .1715     | .1524     |
| 8    | .1715     | .1715     | .1715     | .1715     | .1715     | .1715     | .1524     |
| 9    | .1715     | .1524     | .1715     | .1715     | .1715     | .1715     |           |
| 10   | .1715     | .1524     | .1715     | .1715     | .1524     | .1715     | .1143     |
| 11   | .1143     | .1524     | .1715     | .1715     | .1524     | .1715     | .1143     |
| 12   | .1143     | .1524     | .1524     | .1524     | .1524     | .1715     | .1143     |
| 13   | .1524     | .1524     | .1524     | .1715     | .1715     | .1715     | .1143     |
| 14   | .1524     | .1524     | .1524     | .1715     | .1715     | .1715     | .1143     |
| 15   | .1524     | .1524     | .1524     | .1715     | .1715     | .1524     | .1143     |
| 16   | .1524     | .1524     | .1524     | .1143     | .1715     | .1524     | .1143     |
| 17   | .1524     | .1524     | .1715     |           | .1715     | .1334     | .1143     |
| 18   | .1524     | .1524     | .1715     | .1334     | .1715     | .1334     | .1143     |
| 19   | .1524     | .1524     | .1524     | .1143     | .1715     | .1143     | .1143     |
| 20   | .1715     | .1524     | .1524     | .1143     | .0171     | .1143     | .1143     |
| 21   | .1715     | .1524     | .1715     | .1143     | .0191     | .1143     | .1143     |
| 22   | .1715     | .1524     | .1524     | .1143     | .1715     | .1143     | .1143     |
| 23   | .1524     | .1524     | .1524     | .1143     | .1715     | .1143     | .1143     |
| 24   | .1143     | .1524     | .1524     | .1524     | .1143     | .1715     | .1143     |
| Max  | .1715     | .1905     | .1905     | .1905     | .1905     | .1905     | .1715     |
| Min  | .1143     | .1524     | .1524     | .1143     | .0171     | .1143     | .1143     |
| Avg  | .1474     | .1580     | .1619     | .1516     | .1500     | .1548     | .1284     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124148 / 33/11 KV PACHORA (RAPDRP)

SUBS

Feeder No / Name : 201 / 11 KV CHATRAPATI SHIVAJI

SHEDDABLE URBAN

NAGA Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6827    | 1.6827    | 1.7013    | 1.7194    | 1.7013    | 1.7194    | 1.8099    |
| 2    | 1.5565    | 1.6108    | 1.6651    | 1.6651    | 1.647     | 1.6118    | 1.7193    |
| 3    |           | 1.5565    | 1.6289    | 1.647     | 1.6108    |           | 1.6655    |
| 4    | 1.5203    | 1.5565    | 1.6108    | 1.5927    | 1.5565    | 1.6289    | 1.6289    |
| 5    |           | 1.5384    | 1.6289    | 1.5746    | 1.5746    |           | 1.6651    |
| 6    | 1.6108    | 1.6461    | 1.8656    | 1.6832    | 1.7193    | 1.7375    | 1.6827    |
| 7    | 1.6108    | 1.6278    | 1.8656    | 1.7918    | 1.7558    |           | 1.7558    |
| 8    | 1.576     | 1.5043    | 1.647     | 1.6108    | 1.5939    | 1.5912    | 1.6118    |
| 9    | 1.4864    | 1.5402    | 1.6644    | 1.5947    | 1.5043    | 1.6289    | 1.5415    |
| 10   | 1.5043    | 1.6289    | 1.6832    | 1.6651    | 1.5746    | 1.7193    | 1.6124    |
| 11   | 1.576     | 1.7375    | 1.7918    | 1.7541    | 1.7375    | 1.8983    | 1.7187    |
| 12   | 1.7551    | 1.9366    | 1.8461    | 1.8427    | 1.828     | 2.1312    | 1.8446    |
| 13   | 1.8625    | 1.9366    | 1.8461    | 1.8983    | 1.8461    | 2.0595    | 1.9163    |
| 14   | 1.6655    | 1.9163    | 1.9004    | 1.9163    |           | 1.9521    | 1.9342    |
| 15   | 1.6655    | 1.9879    | 1.9909    | 2.0237    | 1.9728    | 1.9342    | 1.97      |
| 16   | 1.6651    | 2.0416    | 1.9547    | 1.8983    |           | 2.0271    | 1.9909    |
| 17   | 1.647     | 1.9667    | 1.8823    | 1.8959    |           | 1.9342    | 1.8604    |
| 18   | 1.5565    | 1.8054    | 1.7737    | 1.8427    |           | 1.825     | 1.7896    |
| 19   | 1.8642    | 2.2565    | 2.0814    | 2.0595    |           | 2.1312    | 2.1132    |
| 20   | 1.8625    | 2.2986    | 2.1357    | 2.1538    | 2.0814    | 2.19      | 2.1176    |
| 21   | 1.828     | 2.0995    | 1.9909    | 1.9728    |           | 2.0271    | 1.9163    |
| 22   | 1.828     | 1.9366    | 1.9547    | 1.9185    | 1.9547    | 1.9936    | 1.9185    |
| 23   | 1.8461    | 1.9185    | 1.9366    | 1.9185    | 1.9366    | 1.9936    | 1.9022    |
| 24   |           | 1.7375    | 1.8099    | 1.8642    | 1.8107    |           | 1.8099    |
| Max  | 1.8642    | 2.2986    | 2.1357    | 2.1538    | 2.0814    | 2.19      | 2.1176    |
| Min  | 1.4864    | 1.5043    | 1.6108    | 1.5746    | 1.5043    | 1.5912    | 1.5415    |
| Avg  | 1.6748    | 1.8112    | 1.8273    | 1.8127    | 1.7448    | 1.8867    | 1.8123    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-II[244]

BU 8168

Substation No/ Name :- 124148 / 33/11 KV PACHORA (RAPDRP)

SUBS

Feeder No / Name : 203 / 11 KV PANDAV NAGARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7372    | 1.829     | 1.9387    | 1.9366    | 1.9387    | 1.9879    | 2.0668    |
| 2    | 1.6118    | 1.7741    | 1.829     | 1.8461    | 1.8099    | 1.8267    | 1.9728    |
| 3    |           | 1.6644    | 1.7558    | 1.7737    | 1.6832    |           | 1.8823    |
| 4    | 1.5203    | 1.6095    | 1.701     | 1.7013    | 1.6108    | 1.6651    | 1.7918    |
| 5    |           | 1.5729    | 1.6827    | 1.6289    | 1.5565    |           | 1.7375    |
| 6    | 1.5384    | 1.701     | 1.7741    | 1.8642    | 1.7372    | 2.009     | 1.6817    |
| 7    | 1.6644    | 1.6263    | 1.7558    | 1.8099    | 1.7002    |           | 1.6817    |
| 8    | 1.4864    | 1.3432    | 1.4118    | 1.647     | 1.5402    | 1.6095    | 1.4148    |
| 9    | 1.3432    | 1.267     | 1.2489    | 1.3466    |           | 1.39      | 1.2757    |
| 10   | 1.2894    | 1.2308    | 1.1584    | 1.2445    |           | 1.1999    | 1.2445    |
| 11   | 1.3073    | 1.2536    | 1.2127    | 1.2403    |           | 1.2048    | 1.2403    |
| 12   | 1.3969    | 1.267     | 1.1765    | 1.2403    | 1.3969    | 1.2536    | 1.3073    |
| 13   | 1.3253    | 1.3213    | 1.3575    | 1.3611    |           | 1.4327    | 1.3969    |
| 14   | 1.5223    | 1.448     | 1.7013    | 1.4842    | 1.5402    | 1.6108    | 1.6476    |
| 15   | 1.5581    | 1.5223    | 1.5384    | 1.5203    | 1.5746    | 1.647     | 1.7556    |
| 16   | 1.5043    | 1.5565    | 1.6108    | 1.5223    |           | 1.5565    | 1.6651    |
| 17   | 1.5043    | 1.3998    | 1.5746    | 1.5238    |           | 1.5402    | 1.5415    |
| 18   | 1.3756    | 1.3321    | 1.5927    | 1.5061    | 1.4506    | 1.3998    | 1.4175    |
| 19   | 1.6108    | 1.6476    | 1.7918    | 1.6655    |           | 1.576     | 1.5402    |
| 20   | 1.7194    | 1.7918    | 1.8823    | 1.8823    |           | 1.8099    | 1.8099    |
| 21   | 1.9004    | 1.9753    | 2.0633    | 1.9366    |           | 1.9185    | 1.9547    |
| 22   | 2.1216    | 2.2131    | 2.2081    | 2.1719    | 2.371     | 2.2497    | 2.1719    |
| 23   | 2.1582    | 2.3045    | 2.2986    | 2.2862    | 2.371     | 2.396     | 2.3348    |
| 24   |           | 1.9936    | 2.1033    | 2.1176    | 2.009     |           | 2.1538    |
| Max  | 2.1582    | 2.3045    | 2.2986    | 2.2862    | 2.371     | 2.396     | 2.3348    |
| Min  | 1.2894    | 1.2308    | 1.1584    | 1.2403    | 1.3969    | 1.1999    | 1.2403    |
| Avg  | 1.5807    | 1.6102    | 1.6820    | 1.6774    | 1.7527    | 1.6642    | 1.6953    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124009 / 33/11 KV LASGAON

Feeder No / Name : 201 / 11 KV LASGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9717     | .5609     | .4359     | .8954     | .8954     |
| 2    | .9907     | .4908     | .4694     | .8954     | .8954     |
| 3    | 1.0288    | .4908     | .4862     | .8383     | .8383     |
| 4    |           | .7265     | .5365     | .9335     | .9335     |
| 5    |           | .8238     | .7377     | 1.0669    | 1.2193    |
| 6    | 1.2193    | .8775     | .9556     | 1.2765    | 1.448     |
| 7    | 1.4289    | .8954     | .9054     | 1.5623    | 1.3717    |
| 8    | 1.1241    | .6485     | .8817     | 1.2003    | 1.0288    |
| 9    | .5721     |           | 1.105     | .5375     | .5973     |
| 10   | .6415     |           | .4191     | .6415     | .6878     |
| 11   | .5609     |           | .3429     | .6241     | .5731     |
| 12   | .5243     |           | .5525     | .5731     | .5249     |
| 13   | .5316     |           | .7621     | .5194     | .5068     |
| 14   | .4801     |           | .8002     | .5068     | .4475     |
| 15   | .4578     |           | .8192     | .4887     | .4424     |
| 16   | .5197     |           | .7811     | .5611     |           |
| 17   | .8309     |           | .743      | .8002     | .5138     |
| 18   | 1.1694    |           | .8383     | .8954     | .9335     |
| 19   | 1.4146    |           | 1.086     | 1.3908    | 1.467     |
| 20   | 1.5278    |           | 1.4861    | 1.3527    | 1.5623    |
| 21   | 1.358     |           | 1.3146    | 1.3146    | 1.3717    |
| 22   | 1.2071    |           | 1.086     | 1.2574    | 1.2003    |
| 23   | .6661     |           | .9335     | .9335     | 1.0669    |
| 24   | .6661     |           |           | .9335     | .9335     |
| Max  | 1.5278    | .8954     | 1.4861    | 1.5623    | 1.5623    |
| Min  | .4578     | .4908     | .3429     | .4887     | .4424     |
| Avg  | .9042     | .6893     | .8034     | .9166     | .9330     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124009 / 33/11 KV LASGAON

Feeder No / Name : 202 / 11 KV BAMBRUD GAOTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0479    | .8817     | .9709     | .6554     | 1.1241    | 1.1241    |
| 2    | 1.0669    | .8939     | .9522     | .6882     | 1.1241    | 1.1241    |
| 3    | 1.105     | .8149     | .8775     | .7209     | 1.0288    | 1.0288    |
| 4    | 1.1812    | .7888     | .8589     | .852      | 1.1622    | 1.2765    |
| 5    | 1.2765    | .8589     | 1.1576    | 1.0486    | 1.2765    | 1.7147    |
| 6    | 1.7528    | 1.2094    | 1.3256    | 1.1633    | 1.7147    | 2.0576    |
| 7    | 1.6766    | 1.3717    | 1.5497    | 1.278     | 1.6766    | 1.7909    |
| 8    | 1.3146    | 1.1616    | 1.2323    | .9339     | 1.6766    | 1.448     |
| 9    | .8453     | 1.1694    | .8954     | 1.3527    | 1.1812    | .9522     |
| 10   | .9448     | 1.086     | .8192     | 1.0288    | 1.1763    | 1.0829    |
| 11   | .9945     | .8192     | .6668     | .8954     | 1.1389    | 1.0608    |
| 12   | .8951     | .8192     | .743      | .8383     |           | .8785     |
| 13   | .9175     | .7811     | .8002     | .8573     | 1.1203    | .8951     |
| 14   | .8029     | .743      | .8383     | .8573     | 1.0082    | .8453     |
| 15   | .7545     |           | .7811     | .8764     | .9335     |           |
| 16   | .8551     | .8573     | .8192     | .8383     | 1.0456    | .8718     |
| 17   | .9991     | .9145     | .8383     | .8192     | 1.0269    | .8573     |
| 18   | 1.1694    | 1.1241    | 1.1431    | 1.0479    | .8954     | 1.1431    |
| 19   | 1.6598    | 1.5242    | 1.6766    | 1.448     | 1.467     | 1.6385    |
| 20   | 1.7164    | 1.7147    | 1.6956    | 1.6385    | 1.6766    |           |
| 21   | 1.2637    | 1.448     | 1.3527    | 1.5623    | 1.448     | 1.4289    |
| 22   | 1.3203    | 1.3336    | 1.3146    | 1.2574    | 1.3527    | 1.3717    |
| 23   | .9991     | 1.251     | .7293     | 1.2193    | 1.2193    | 1.0669    |
| 24   | .9465     |           | 1.0082    | .6796     | 1.1241    | 1.1241    |
| Max  | 1.7528    | 1.7147    | 1.6956    | 1.6385    | 1.7147    | 2.0576    |
| Min  | .7545     | .743      | .6668     | .6554     | .8954     | .8453     |
| Avg  | 1.1461    | 1.0712    | 1.0436    | 1.0232    | 1.2434    | 1.2174    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124009 / 33/11 KV LASGAON

Feeder No / Name : 204 / 11 KV VARSADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7811     | 1.0978    | 1.6032    | .6478     | .6478     |
| 2    | .8192     | .9667     | 1.6409    | .6478     | .6478     |
| 3    | .8954     | 1.0608    | 1.6975    | .5525     | .5525     |
| 4    | 1.0669    | 1.1401    | 1.8296    | .743      | .743      |
| 5    | 1.1812    | 1.1437    | 1.8484    | 1.1241    | 1.2955    |
| 6    | 1.467     | 1.5074    | 1.9427    | 1.2955    | 1.6575    |
| 7    | 1.3336    | 1.5708    | 2.0182    | 1.3336    | 1.3527    |
| 8    | .8383     | 1.3272    | 1.8107    | .8383     | .9335     |
| 9    | 1.8378    |           | .6287     | 1.7924    | .2452     |
| 10   | 2.1209    |           | .7049     | 2.2028    | 2.2916    |
| 11   | 1.9938    |           | .5716     | 2.3577    | 2.1719    |
| 12   | 1.9839    |           | .5335     | 2.2916    | 2.3348    |
| 13   | 1.989     |           | .6097     | 2.268     | 2.1176    |
| 14   | 1.7684    |           | .5525     | 2.1582    | 2.0332    |
| 15   | 1.6632    |           | .5716     | 2.0165    | 1.9938    |
| 16   | 1.6278    |           | .5335     | 2.0165    | 1.7857    |
| 17   | .6613     |           | .4191     | 1.9774    | .6859     |
| 18   | .7922     |           | .6478     | .5335     | .5906     |
| 19   | 1.0669    |           | 1.2765    | .6668     | 1.0479    |
| 20   | 1.0288    |           | 1.086     | .9335     | 1.105     |
| 21   | .9145     |           | 1.0288    | .9335     | .9145     |
| 22   | .8764     |           | .8192     | .8383     | .8764     |
| 23   | 1.1797    |           | .743      | .743      | .7811     |
| 24   | 1.1105    |           |           | .7049     | .7049     |
| Max  | 2.1209    | 1.5708    | 2.0182    | 2.3577    | 2.3348    |
| Min  | .6613     | .9667     | .4191     | .5335     | .2452     |
| Avg  | 1.2916    | 1.2268    | 1.0921    | 1.3174    | 1.2296    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124009 / 33/11 KV LASGAON

Feeder No / Name : 205 / 11 KV BAMBRUD AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 12-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           | .1991     |
| 2    | .1715     |           | .2534     |
| 3    | .1907     |           | .2715     |
| 4    | .208      |           | .3045     |
| 5    | .2629     |           | .3403     |
| 6    | .298      |           | .3582     |
| 7    | .3155     |           | .333      |
| 8    | .2572     |           | .3086     |
| 9    |           | .1214     |           |
| 10   |           | .1526     |           |
| 11   |           | .2652     |           |
| 12   |           | .1966     |           |
| 13   |           | .2347     |           |
| 14   |           | .1989     |           |
| 15   |           | .1677     |           |
| 16   |           | .1802     |           |
| 23   |           | .1227     | .1886     |
| 24   |           |           | .1612     |
| Max  | .3155     | .2652     | .3582     |
| Min  | .1715     | .1214     | .1612     |
| Avg  | .2344     | .1822     | .2718     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 201 / 11 KV VADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0762     | .0762     | .0625     | .0076     |           |           |           |
| 2    | .0762     | .0762     | .0625     | .0076     |           |           |           |
| 3    | .0762     | .0762     | .0625     | .0076     |           |           |           |
| 4    | .0762     | .0762     | .0625     | .0076     |           |           |           |
| 5    | .0762     | .0762     | .061      | .0076     |           |           |           |
| 6    | .0762     | .1334     | .0781     | .0076     |           |           |           |
| 7    | .0762     | .0762     | .0625     | .0114     |           |           |           |
| 8    | .0762     | .0762     | .0625     | .0953     |           |           |           |
| 9    |           |           |           |           | .0762     | .0076     | .0762     |
| 10   |           |           |           |           | .0762     | .0095     | .0762     |
| 11   |           |           |           |           | .1143     | .0114     | .0762     |
| 12   |           |           |           |           | .1524     | .0076     | .0762     |
| 13   |           |           |           |           | .0762     | .0076     | .0762     |
| 14   |           |           |           |           | .0762     | .0057     | .0572     |
| 15   |           |           |           |           | .0762     | .0006     | .0191     |
| 16   |           |           |           |           | .0762     | .0057     | .0762     |
| 23   | .0762     | .0625     | .0076     |           |           |           | .0762     |
| 24   | .0762     | .0762     | .0625     | .0076     |           |           |           |
| Max  | .0762     | .1334     | .0781     | .0953     | .1524     | .0114     | .0762     |
| Min  | .0762     | .0625     | .0076     | .0076     | .0762     | .0006     | .0191     |
| Avg  | .0762     | .0806     | .0584     | .0178     | .0905     | .0070     | .0677     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 202 / 11 KV LOHARA-MHASAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .0572     | .0572     | .0057     |
| 2    |           |           |           |           | .0572     |           | .0057     |
| 3    |           |           |           |           | .0572     | .0572     | .0057     |
| 4    |           |           |           |           | .0572     | .0572     | .0572     |
| 5    |           |           |           |           | .0572     | .0572     | .0057     |
| 6    |           |           |           |           | .0572     | .1334     |           |
| 7    |           |           |           |           | .0762     | .0572     | .0095     |
| 8    |           |           |           |           | .0762     | .1143     | .0095     |
| 9    | .0381     | .0381     | .064      | .0953     |           |           |           |
| 10   | .0762     | .032      | .08       | .0953     |           |           |           |
| 11   |           |           | .064      | .0953     |           |           |           |
| 12   | .0762     | .0617     | .048      | .0953     |           |           |           |
| 13   | .0381     | .0892     | .064      | .0762     |           |           |           |
| 14   |           | .0594     | .064      | .0762     |           |           |           |
| 15   | .0381     | .0579     | .064      | .0762     |           |           |           |
| 16   | .0381     | .0714     | .08       | .0762     |           |           |           |
| 22   |           |           |           |           |           |           | .0191     |
| 23   |           |           |           | .0381     | .0572     | .0076     |           |
| 24   |           |           |           |           | .0572     | .0572     | .0076     |
| Max  | .0762     | .0892     | .08       | .0953     | .0762     | .1334     | .0572     |
| Min  | .0381     | .032      | .048      | .0381     | .0572     | .0076     | .0057     |
| Avg  | .0508     | .0585     | .066      | .0805     | .061      | .0665     | .0140     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 203 / 11 KV KURHAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1524     | .1524     | .1875     | .0267     |           |           |           |
| 2    | .1524     | .1524     | .1943     | .0267     |           |           |           |
| 3    | .1524     | .2286     | .192      | .0248     |           |           |           |
| 4    | .1524     | .2096     | .192      | .0267     |           |           |           |
| 5    | .1524     | .2096     | .2881     | .0305     |           |           |           |
| 6    | .1905     | .3429     | .3749     | .0381     |           |           |           |
| 7    | .3429     | .4191     | .4049     | .0533     |           |           |           |
| 8    | .2667     | .4572     | .3239     | .3048     |           |           |           |
| 9    |           |           |           |           |           | .125      | .3048     |
| 10   |           |           |           |           | .4191     | .3125     | .381      |
| 11   |           |           |           |           | .4382     | .3437     | .381      |
| 12   |           | .1524     |           |           | .381      | .25       | .381      |
| 13   |           |           |           |           | .4191     | .2187     | .381      |
| 14   |           |           |           |           | .381      | .25       | .3048     |
| 15   |           |           |           |           | .3239     | .253      | .3048     |
| 16   |           |           |           |           | .3429     | .3163     | .3048     |
| 23   | .1524     | .1875     | .3125     |           |           |           | .1143     |
| 24   | .1524     | .1524     | .1875     | .0343     |           |           |           |
| Max  | .3429     | .4572     | .4049     | .3048     | .4382     | .3437     | .381      |
| Min  | .1524     | .1524     | .1875     | .0248     | .3239     | .125      | .1143     |
| Avg  | .1867     | .2422     | .2658     | .0629     | .3865     | .2587     | .3175     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 204 / 11 KV KURHAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0136    | 1.0136    | 1.1222    | 1.0498    | 1.0498    | 1.086     | 1.0498    |
| 2    | 1.0136    | 1.0136    | 1.1222    | 1.0498    | 1.0498    | 1.086     | 1.0498    |
| 3    | 1.0136    | 1.086     | 1.1765    | 1.086     | 1.0498    | 1.086     | 1.0498    |
| 4    | 1.1706    | 1.1584    | 1.2308    | 1.1765    | 1.1765    | 1.1584    | .7678     |
| 5    | 1.3756    | 1.5203    | 1.448     | 1.448     | 1.4118    | 1.5203    | 1.448     |
| 6    | 1.9185    | 2.1719    | 2.1719    | 2.1357    | 2.0271    | 2.1719    | 2.1357    |
| 7    | 1.7558    | 1.8099    | 1.6651    |           | 1.6651    | 1.6651    | 1.8099    |
| 8    | 1.39      | 1.448     | 1.4118    | 1.448     | 1.2308    | 1.448     | 1.448     |
| 9    | 1.1706    | 1.2308    | 1.2308    | 1.2308    | 1.1584    | 1.2308    | 1.2308    |
| 10   | 1.086     | .9955     | 1.0136    | .9412     | 1.0136    | .905      | .9412     |
| 11   |           | .905      | .8688     | .8326     | .8688     | .8326     | .8688     |
| 12   | .8688     | .8688     | .7964     | .7964     | .8688     | .8688     |           |
| 13   | .8688     | .8869     | .7964     | .8326     | .8688     | .8688     | .905      |
| 14   | .8688     | .905      | .8688     | .8326     | .8688     | .8688     | .9412     |
| 15   | .8688     | .9231     | .8688     | .8688     |           | .905      | .9774     |
| 16   | .7964     | .9593     | 1.0136    | .905      |           | .905      | 1.0136    |
| 17   | 1.0136    | 1.0136    | 1.0498    | .9412     |           | .9412     | 1.086     |
| 18   | 1.0136    | 1.1765    | 1.086     | .9511     | 1.3756    |           | 1.2308    |
| 19   | 1.5203    | 1.448     | 1.5203    | 1.4118    | 1.8823    | 1.5927    | 1.5364    |
| 20   | 1.3756    | 1.4118    | 1.3756    | 1.5203    | 1.5927    | 1.448     | 1.448     |
| 21   | 1.2308    | 1.267     | 1.3032    | 1.1584    | 1.3756    | 1.3032    | 1.3032    |
| 22   | 1.1584    | 1.2308    | 1.2308    | 1.1584    | 1.2308    | 1.2308    | 1.3032    |
| 23   | 1.086     | 1.1584    | 1.1584    | 1.086     | 1.1584    | 1.1584    |           |
| 24   | 1.086     | 1.0136    | 1.086     | 1.0498    | 1.0498    | 1.086     | 1.086     |
| Max  | 1.9185    | 2.1719    | 2.1719    | 2.1357    | 2.0271    | 2.1719    | 2.1357    |
| Min  | .7964     | .8688     | .7964     | .7964     | .8688     | .8326     | .7678     |
| Avg  | 1.1593    | 1.1923    | 1.1923    | 1.1266    | 1.2368    | 1.1899    | 1.2105    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 205 / 11 KV AMBE VADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2012     | .2012     | .2172     | .2012     | .1991     | .2012     | .2012     |
| 2    | .2012     | .2012     | .1991     | .2012     | .1991     | .2012     | .2012     |
| 3    | .2012     | .2012     | .1991     | .2012     | .2012     | .2012     | .2012     |
| 4    | .2378     | .2195     | .2353     | .2561     | .2561     | .2012     | .2561     |
| 5    | .2926     | .2378     | .2715     | .2926     | .2926     | .2378     | .2926     |
| 6    | .4207     | .439      | .4706     | .3658     | .4525     | .3475     | .3658     |
| 7    | .4207     | .4024     | .4344     | .3658     | .4024     | .3292     | .4024     |
| 8    | .3658     | .2926     | .2172     | .2926     | .2926     | .2378     | .2926     |
| 9    | .2835     | .2378     | .2534     | .2172     | .3109     | .1829     | .2378     |
| 10   | .2012     | .1829     | .2172     | .2096     | .1991     | .1646     | .2195     |
| 11   |           | .1463     | .181      | .1829     | .1448     | .1097     | .1829     |
| 12   | .1463     | .1463     | .1448     | .1646     | .1646     | .128      | .1829     |
| 13   | .1646     | .1646     | .1267     | .1646     | .1448     | .128      | .1829     |
| 14   | .1646     | .1646     | .1448     | .1646     | .1463     | .1463     | .1991     |
| 15   | .1646     | .1829     | .1448     | .1646     | .1646     | .1463     | .2012     |
| 16   | .2012     | .1829     | .1629     | .1829     | .1829     | .1463     | .1991     |
| 17   | .2012     | .2195     | .181      | .2012     | .2012     | .1829     | .2172     |
| 18   | .2378     | .2378     | .2172     | .2126     | .2378     | .2195     | .2195     |
| 19   | .2561     | .2926     | .2534     | .2957     | .1829     | .2743     | .3109     |
| 20   | .2561     | .2926     | .2896     | .2743     | .2896     | .2561     | .2926     |
| 21   | .2378     | .2561     | .2534     | .2481     | .2353     | .2561     | .2896     |
| 22   | .2378     | .2195     | .2353     | .2378     | .2195     | .2378     | .2926     |
| 23   | .2012     | .2195     | .1991     | .1991     | .2012     | .2195     | .2172     |
| 24   | .2195     | .2012     | .2172     | .2195     | .2172     | .2012     | .2012     |
| Max  | .4207     | .439      | .4706     | .3658     | .4525     | .3475     | .4024     |
| Min  | .1463     | .1463     | .1267     | .1646     | .1448     | .1097     | .1829     |
| Avg  | .2398     | .2309     | .2278     | .2298     | .2308     | .2065     | .2441     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 206 / 11 KV LOHARA-MHASAS

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 2    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 3    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 4    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 5    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 6    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 7    | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| 8    | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     | .0038     |
| 9    | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 10   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 11   |           |           | .0019     | .0191     | .0191     | .0019     | .0191     |
| 12   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 13   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 14   |           | .0191     | .0019     | .0191     | .0762     | .0019     | .0191     |
| 15   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 16   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 17   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 18   | .0191     | .0381     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 19   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 20   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 21   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 22   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 23   | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     | .0191     |
| 24   | .0191     | .0191     | .0191     | .0019     | .0191     | .0191     | .0019     |
| Max  | .0191     | .0381     | .0191     | .0191     | .0762     | .0191     | .0191     |
| Min  | .0191     | .0191     | .0019     | .0019     | .0191     | .0019     | .0019     |
| Avg  | .0191     | .0199     | .0084     | .0134     | .0215     | .0084     | .0127     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124013 / 33/11 KV KURHAD

Feeder No / Name : 207 / 11 KV PCK INDUSTRIAL  
FEEDER Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .381      | .381      | .381      | .0381     | .2286     | .4001     | .0305     |
| 2    | .381      | .2096     | .381      | .0381     | .2286     | .381      | .0305     |
| 3    | .381      | .2096     | .2286     | .0343     | .2286     | .381      | .0305     |
| 4    | .3429     | .2096     | .2667     | .0343     | .2286     | .2286     | .0267     |
| 5    | .4001     | .2096     | .2667     | .0305     | .2286     | .2286     | .0267     |
| 6    | .2286     | .2096     | .2286     | .0267     | .2286     | .2286     | .0267     |
| 7    | .2286     | .2286     | .2096     | .0267     | .2286     | .2286     | .0267     |
| 8    | .1905     | .2096     | .2096     | .2286     | .2286     | .2286     | .0191     |
| 9    | .2286     | .2667     | .0229     | .2286     | .2286     | .021      | .2286     |
| 10   | .2096     | .2477     | .0229     | .2286     | .2096     | .0267     | .2286     |
| 11   |           | .2286     | .0229     | .2286     | .2286     | .0267     | .2286     |
| 12   | .2286     | .2096     | .0229     | .2286     | .381      | .0305     | .2286     |
| 13   | .2286     | .2667     | .0229     | .2286     | .2286     | .0267     | .2286     |
| 14   |           | .2477     | .0229     | .2286     | .3048     | .0267     | .2286     |
| 15   | .2286     | .2286     | .0229     | .2286     | .2477     | .0267     | .2286     |
| 16   | .3048     | .381      | .0229     | .2286     | .2477     | .0381     | .2286     |
| 17   | .2667     | .381      | .0267     | .2286     | .2286     | .0457     | .2286     |
| 18   | .3239     | .362      | .0267     | .2286     | .3429     | .0381     | .2286     |
| 19   | .362      | .381      | .0229     | .2286     | .4382     | .0343     | .2286     |
| 20   | .4382     | .362      | .0229     | .2286     | .381      | .0381     | .2286     |
| 21   | .381      | .4001     | .0191     | .2286     | .362      | .0381     | .2286     |
| 22   | .4191     | .362      | .0191     | .2286     | .4001     | .0381     | .2286     |
| 23   | .362      | .381      | .0229     | .2286     | .362      | .0381     | .2286     |
| 24   | .3429     | .4572     | .4001     | .0381     | .2286     | .4001     | .0381     |
| Max  | .4382     | .4572     | .4001     | .2286     | .4382     | .4001     | .2286     |
| Min  | .1905     | .2096     | .0191     | .0267     | .2096     | .021      | .0191     |
| Avg  | .3117     | .2929     | .1215     | .1635     | .2770     | .1333     | .1535     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124088 / 33/11 KV PIMPALGAON

HARESHWAR

Feeder No / Name : 201 / 11 KV PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.4327    |           |           | 1.4299    |
| 8    | 1.6476    | 1.4419    |           | 1.4864    |
| 12   | 1.0029    |           |           |           |
| 16   | 1.0974    |           | .9745     |           |
| 20   | 1.6651    |           | 1.6832    | 1.6655    |
| 24   | 1.3394    | 1.1946    |           | 1.3756    |
| Max  | 1.6651    | 1.4419    | 1.6832    | 1.6655    |
| Min  | 1.0029    | 1.1946    | .9745     | 1.3756    |
| Avg  | 1.3642    | 1.3183    | 1.3289    | 1.4894    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124088 / 33/11 KV PIMPALGAON

HARESHWAR

Feeder No / Name : 202 / 11 KV VARSADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .1543     | .12       | .1387     | .2286     |           |           |           |
| 8    | .2458     | .2214     | .3391     | .3048     |           |           |           |
| 12   | .2572     |           |           |           | .4805     | .0848     | .4763     |
| 16   | .2458     |           |           |           |           |           | .2858     |
| 24   | .1753     | 1.3717    | .1417     | .2286     |           |           |           |
| Max  | .2572     | 1.3717    | .3391     | .3048     | .4805     | .0848     | .4763     |
| Min  | .1543     | .12       | .1387     | .2286     | .4805     | .0848     | .2858     |
| Avg  | .2157     | .5710     | .2065     | .254      | .4805     | .0848     | .3811     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124088 / 33/11 KV PIMPALGAON

HARESHWAR

Feeder No / Name : 203 / 11 KV PIMPALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           |           | .1227     | .1402     | .2058     |
| 8    |           |           |           |           | .5609     | .4287     | .4748     |
| 12   | .6274     | .3222     | .4049     | .5487     |           |           |           |
| 16   |           | .5426     | .362      | .3856     |           |           |           |
| 24   |           |           |           |           | .1254     | .1612     | .2058     |
| Max  | .6274     | .5426     | .4049     | .5487     | .5609     | .4287     | .4748     |
| Min  | .6274     | .3222     | .362      | .3856     | .1227     | .1402     | .2058     |
| Avg  | .6274     | .4324     | .3835     | .4672     | .2697     | .2434     | .2955     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124088 / 33/11 KV PIMPALGAON

HARESHWAR

Feeder No / Name : 204 / NEW VARSADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .0686     | .2058     | .0514     | .0762     |           |           |           |
| 8    | .1174     | .1296     | .1781     | .1524     |           |           |           |
| 12   | .1147     |           |           |           | .3121     | .2155     | .3239     |
| 16   |           |           |           |           | .1848     | .1781     | .1905     |
| 24   | .0701     | .12       | .0514     | .0953     |           |           |           |
| Max  | .1174     | .2058     | .1781     | .1524     | .3121     | .2155     | .3239     |
| Min  | .0686     | .12       | .0514     | .0762     | .1848     | .1781     | .1905     |
| Avg  | .0927     | .1518     | .0936     | .1080     | .2485     | .1968     | .2572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124134 / 33/11 KV LOHARA

Feeder No / Name : 201 / 11 KV NEW LOHARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8596     | .8596     | .7964     | .8059     | .823      | .7537     | .7682     |
| 2    | .8596     | .8596     | .7964     | .8059     | .8779     | .7973     | .7421     |
| 3    | .8779     | .8954     | .9145     | .8596     | .8779     | .8238     | .7865     |
| 4    | .9979     | 1.0387    | .9055     | .4298     | .9795     | .8682     | .8686     |
| 5    | 1.2936    | 1.2536    | 1.1643    | 1.1283    | 1.2752    | 1.1919    | 1.1088    |
| 6    | 1.6804    | 1.576     | 1.6057    | 1.4148    | 1.6991    | 1.3998    | 1.4937    |
| 8    | 1.307     | 1.0808    | 1.0534    | 1.0924    | 1.1576    | 1.0692    | 1.0719    |
| 9    | 1.1043    | .929      | .8764     | .924      | .7973     | .9795     | .9492     |
| 10   | .6935     | .7947     | .5316     | .8962     | .8413     | .8686     | .8596     |
| 11   | .6935     |           | .5258     | .695      | .6661     | .7947     | .7796     |
| 12   | .7282     | .7947     | .5784     | .7499     | .6733     | .7133     | .7343     |
| 13   | .6935     | .7316     | .6661     | .7316     | .6836     | .695      | .691      |
| 14   | .6935     | .815      | .7362     | .7059     | .7186     | .7577     |           |
| 15   | .7108     | .7186     | .7712     | .7522     | .7265     |           | .8764     |
| 16   | .7628     | .7619     | .815      | .7011     | .7186     | .5359     | .8417     |
| 17   | .7975     | .7537     | .7973     | .7282     | .7888     | .6283     | .815      |
| 18   |           |           |           |           |           | .8131     | .7164     |
| 19   | 1.3112    | 1.3256    | 1.2536    | 1.2752    | 1.2757    | 1.0829    | .9671     |
| 20   | 1.1104    | 1.2136    | 1.2178    | 1.3121    | 1.3321    | 1.2136    | 1.267     |
| 21   | 1.0387    | 1.0719    | 1.0208    | 1.0719    | .9922     | .961      | 1.0277    |
| 22   | .9313     | .924      | .8775     | .961      | .8939     | .8316     | .8954     |
| 23   | .8954     | .8686     | .8238     | .8413     | .815      | .8131     | .8328     |
| 24   | .8596     | .8596     | .823      | .8059     | .823      | .7712     | .8048     |
| Max  | 1.6804    | 1.576     | 1.6057    | 1.4148    | 1.6991    | 1.3998    | 1.4937    |
| Min  | .6935     | .7186     | .5258     | .4298     | .6661     | .5359     | .691      |
| Avg  | .9500     | .9584     | .8887     | .8949     | .9289     | .8802     | .9044     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124134 / 33/11 KV LOHARA

Feeder No / Name : 202 / 11 KV NEW LOHARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1214     | .061      | .0693     | .0655     |           |           |
| 2    |           | .104      | .061      | .0693     | .0655     |           |           |
| 3    |           | .1214     | .061      | .1214     | .0663     |           |           |
| 4    |           | .1029     | .0791     | .1214     | .0829     |           |           |
| 5    |           | .0343     | .1134     | .1387     | .0848     |           |           |
| 6    |           | .0343     | .1543     | .1734     | .12       |           |           |
| 7    |           | .1562     | .2401     | .208      | .2947     |           |           |
| 8    |           | .1562     | .1341     | .1907     | .2481     |           |           |
| 9    | .1886     |           |           |           |           | .1372     |           |
| 10   | .1715     |           |           |           |           | .2658     | .1898     |
| 11   | .1715     |           |           |           |           | .2149     | .1739     |
| 12   | .1886     |           |           |           |           | .2303     | .112      |
| 13   | .2058     |           |           |           |           | .2126     | .1875     |
| 14   | .2229     |           |           |           |           | .1753     | .16       |
| 15   | .2572     |           |           |           |           | .1509     | .1423     |
| 16   | .2229     |           |           |           |           | .1677     | .1739     |
| 23   | .1387     | .128      | .1214     | .1341     |           |           |           |
| 24   |           | .1734     | .1107     | .1052     | .1174     |           |           |
| Max  | .2572     | .1734     | .2401     | .208      | .2947     | .2658     | .1898     |
| Min  | .1387     | .0343     | .061      | .0693     | .0655     | .1372     | .112      |
| Avg  | .1964     | .1132     | .1136     | .1332     | .1272     | .1943     | .1628     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PACHORA-I[241]

BU 8184

Substation No/ Name :- 124134 / 33/11 KV LOHARA

Feeder No / Name : 203 / 11 KV KALAMSARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1174     |           |           |           |           | .0781     | .12       |
| 2    |           |           |           |           |           | .0791     | .1174     |
| 3    | .1174     |           |           |           |           | .0791     | .12       |
| 4    | .1174     |           |           |           |           | .0781     | .12       |
| 5    | .1357     |           |           |           |           | .0781     | .1715     |
| 6    | .2279     |           |           |           |           | .1562     | .2658     |
| 7    | .3582     |           |           |           |           | .2372     | .3841     |
| 8    | .2658     |           |           |           |           | .2187     | .3439     |
| 9    |           | .1406     |           | .1174     | .1739     |           |           |
| 10   |           | .362      | .2343     | .1696     | .25       |           |           |
| 11   |           |           | .2401     | .2865     | .3281     |           |           |
| 12   |           | .3292     | .2401     | .1949     | .2656     |           |           |
| 13   |           | .2743     | .2401     | .1772     | .2343     |           |           |
| 14   |           | .2056     | .2058     | .197      | .1718     |           |           |
| 15   |           | .1875     | .2058     | .1753     | .2214     |           |           |
| 16   |           | .253      | .2401     | .2774     | .2056     |           |           |
| 23   |           |           |           |           | .1423     | .1886     | .1423     |
| 24   | .1715     |           |           |           |           | .125      | .1543     |
| Max  | .3582     | .362      | .2401     | .2865     | .3281     | .2372     | .3841     |
| Min  | .1174     | .1406     | .2058     | .1174     | .1423     | .0781     | .1174     |
| Avg  | .1889     | .2503     | .2295     | .1994     | .2214     | .1318     | .1939     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 201 / 11 KV PAROLA URBAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8573     | .823      | .823      | .8059     | .8573     | .823      |           |
| 2    | .823      | .7888     | .823      | .7716     | .8059     | .7888     | .823      |
| 3    |           | .7545     | .7888     | .7545     |           | .7545     |           |
| 4    | .6859     | .7202     | .7888     | .7545     | .6859     | .7202     | .7888     |
| 5    | .7545     | .7888     | .7545     | .7545     | .7202     | .7716     |           |
| 6    | .823      | .823      | .7545     | .8573     | .7545     | .823      | .7545     |
| 7    | .7888     | .7716     | .7545     | .6859     | .6859     | .6859     | .703      |
| 8    | .7545     |           | .6173     | .6859     | .6344     | .6516     | .703      |
| 9    | .7202     | .6859     | .6001     | .6516     | .6516     | .6859     | .7202     |
| 10   | .703      | .6859     | .6344     | .6859     | .6859     | .7545     | .7545     |
| 11   | .7545     | .6859     | .6859     | .7202     | .7716     |           | .823      |
| 12   | .7716     | .7545     | .6859     | .7545     | .823      | .7888     | .7888     |
| 13   | .8573     | .7888     | .7888     | .823      | .8573     | .7888     | .823      |
| 14   | .8573     | .7545     | .7716     | .823      | .8402     |           | .8573     |
| 15   | .8573     | .8573     | .7545     | .8573     | .8573     | .8916     | .823      |
| 16   | .8573     | .823      | .823      | .8402     | .823      | .8573     | .8573     |
| 17   | .7888     | .7545     | .823      | .8916     | .8573     | .823      | .823      |
| 18   | .7888     | .7202     | .8402     | .8916     | .823      | .7888     | .823      |
| 19   | .9259     | .7888     | .9602     | .8916     | .823      | .823      | .8916     |
| 20   | .9602     | .7888     | 1.0288    | .9602     | .8573     | .9602     | .9259     |
| 21   | .8916     | .823      | 1.0631    | .8916     | .9088     | .8916     | .8916     |
| 22   | .8916     | .8573     | .9602     | .8916     | .9602     | .9602     | .9259     |
| 23   | .8916     | .8745     | .9259     | .9259     | .9259     | .9945     | .9259     |
| 24   | .8916     | .8573     | .8573     | .8916     | .8916     | .8573     | .8916     |
| Max  | .9602     | .8745     | 1.0631    | .9602     | .9602     | .9945     | .9259     |
| Min  | .6859     | .6859     | .6001     | .6516     | .6344     | .6516     | .703      |
| Avg  | .8215     | .7813     | .8045     | .8109     | .8044     | .8129     | .8247     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 202 / 11 KV INDUSTRIAL FEEDER - SHEDDABLE FEEDER HAVING WEEKLY  
I Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2229     | .2743     | .2058     | .2401     | .0686     | .12       |           |
| 2    | .2058     | .2401     | .1715     | .0686     | .0514     | .1372     | .2058     |
| 3    |           | .2229     | .1715     | .0686     | .0514     | .1543     |           |
| 4    | .2229     | .2058     | .2058     | .1886     | .0514     | .1715     | .1715     |
| 5    | .2058     | .1886     | .2058     | .1886     | .12       | .1715     |           |
| 6    | .2058     | .1886     | .2058     | .2058     | .1715     | .1715     | .1715     |
| 7    | .2058     | .1886     | .2058     | .2401     | .0514     | .1886     | .1715     |
| 8    | .2229     |           | .2058     | .2058     | .2058     | .1715     | .1886     |
| 9    |           | .2915     | .2915     | .1715     | .1886     | .2915     | .2401     |
| 10   |           | .3086     | .2743     | .1886     | .2743     | .3429     | .2743     |
| 11   | .2743     | .3086     | .3429     |           | .2743     |           | .2058     |
| 12   | .3429     | .3429     | .3086     | .1886     | .2401     | .3086     | .1029     |
| 13   | .3086     | .3429     | .2743     | .1715     | .2401     | .2229     | .1029     |
| 14   | .3086     | .2401     | .2743     | .1886     | .1543     |           | .1886     |
| 15   | .3429     | .2401     | .2743     | .0857     | .0686     | .3258     | .1715     |
| 16   | .3086     | .2743     | .2572     | .1543     | .0686     | .3086     | .0857     |
| 17   | .12       | .2743     | .3086     | .2058     | .0857     | .2743     | .2229     |
| 18   | .1886     | .2743     | .2743     | .2058     | .1886     | .2058     | .2058     |
| 19   | .2229     | .2401     | .2572     | .2058     | .2058     | .1715     | .2401     |
| 20   | .2401     | .2915     | .2743     | .2058     | .2401     | .2401     | .3086     |
| 21   | .2743     | .2743     | .2743     | .0686     | .2401     | .2401     | .1715     |
| 22   | .2915     | .2915     | .2915     | .0857     | .12       | .2401     | .2058     |
| 23   | .2915     | .2401     | .2915     | .0857     | .12       | .2401     | .3258     |
| 24   | .2058     | .3086     | .2058     | .2915     | .0686     | .12       | .2401     |
| Max  | .3429     | .3429     | .3429     | .2915     | .2743     | .3429     | .3258     |
| Min  | .12       | .1886     | .1715     | .0686     | .0514     | .12       | .0857     |
| Avg  | .2482     | .2632     | .2522     | .1700     | .1479     | .2190     | .2001     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 203 / 11 KV VICHKHEDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5487     | .3086     | .3429     | .3086     | .3258     | .583      | .583      |
| 2    | .583      | .3086     | .3429     | .3086     | .3086     | .6001     | .583      |
| 3    | .6344     | .3086     | .3429     | .3086     | .3086     | .6173     | .6173     |
| 4    | .6687     | .3086     | .4801     | .3429     | .3086     | .6687     | .7545     |
| 5    |           | .5487     | .6173     | .4458     | .5144     | .9602     | .9259     |
| 6    |           | .7716     | .703      | .823      | .6859     |           |           |
| 7    |           | .7545     | .7888     | .7373     | .7716     |           |           |
| 8    |           |           | .4801     | .6344     | .6001     |           |           |
| 9    | .5144     | .4801     | .4973     | .5487     | .463      | .3772     | .3772     |
| 10   | .4801     | .463      | .4458     | .463      | .463      | .583      | .5144     |
| 11   | .4801     | .4115     | .4115     | .4115     | .463      |           | .4801     |
| 12   | .4801     | .4115     |           | .4458     | .463      | .6001     | .5144     |
| 13   | .4115     | .4458     | .4801     | .4287     | .463      | .6001     | .5144     |
| 14   | .3772     |           | .463      | .4458     | .4801     |           | .4115     |
| 15   | .4115     | .3944     | .4458     | .5144     | .4973     | .463      | .4801     |
| 16   | .4801     | .4287     | .4801     | .4801     | .5144     | .6173     | .5144     |
| 17   | .463      | .4801     | .463      | .4801     | .5144     | .4801     | .463      |
| 18   | .5144     | .5316     | .4973     | .3601     | .4973     | .6516     | .5316     |
| 19   | .7373     | .6859     | .6859     | .7545     | .7202     | .7545     | .7545     |
| 20   | .8402     | .7202     | .8916     | .8745     | .8402     | .8916     | .8573     |
| 21   | .7716     | .7202     | .8573     | .7545     | .7716     | .7545     | .7716     |
| 22   | .7202     | .6859     | .703      | .6859     | .7202     | .6516     | .7373     |
| 23   | .3429     | .4801     | .4115     | .3772     | .6516     | .583      | .6173     |
| 24   | .5487     | .3086     | .3429     | .3258     | .3429     | .583      | .583      |
| Max  | .8402     | .7716     | .8916     | .8745     | .8402     | .9602     | .9259     |
| Min  | .3429     | .3086     | .3429     | .3086     | .3086     | .3772     | .3772     |
| Avg  | .5504     | .4980     | .5293     | .5108     | .5287     | .6326     | .5993     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 204 / 11KV SHEWGE BK 1PH FDR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5144     | .3429     | .3086     | .3601     | .3429     | .5144     | .5144     |
| 2    | .583      | .3429     | .3086     | .3429     | .3258     | .5487     | .5144     |
| 3    | .6001     | .3429     | .3086     | .3086     | .3429     | .5658     | .5144     |
| 4    | .6516     | .3429     | .3772     | .3086     | .3601     | .5658     | .6173     |
| 5    | .7716     | .4287     | .4115     | .3944     | .4801     |           | .7545     |
| 6    |           | .5144     | .4115     | .6001     | .6001     |           | .8573     |
| 7    |           | .583      | .5487     | .5658     | .4458     |           | .7888     |
| 8    |           |           | .4801     | .4801     | .4458     |           | .6516     |
| 9    | .4458     | .4973     | .4115     | .5487     | .5144     | .3944     | .3772     |
| 10   | .3772     | .463      | .4458     | .4458     | .4801     | .5487     | .4801     |
| 11   | .3772     | .4458     | .4115     | .3772     | .4458     |           | .4801     |
| 12   | .3772     | .4458     | .3772     | .3429     | .4458     | .5658     | .4458     |
| 13   | .3429     | .3772     | .3258     | .3601     | .3944     | .4973     | .4115     |
| 14   | .3086     | .4115     | .3429     | .4115     | .3944     |           | .4458     |
| 15   | .3086     |           | .3944     | .3944     | .4287     | .5316     | .4115     |
| 16   | .3429     | .4287     | .4458     | .4115     | .4287     | .463      | .4458     |
| 17   | .3258     | .4287     | .3772     | .4115     | .4115     | .4458     | .4115     |
| 18   | .4458     | .4287     | .4115     | .4287     |           | .583      | .4287     |
| 19   | .6516     | .7202     | .6516     | .7545     | .6516     | .6516     | .703      |
| 20   | .7545     | .6344     | .7716     | .8402     | .703      | .8573     | .8059     |
| 21   | .6859     | .583      | .6859     | .6859     | .6173     | .6687     | .6516     |
| 22   | .6173     | .5144     | .583      | .6516     | .5487     | .6173     | .6001     |
| 23   | .3086     | .3429     | .4115     | .3258     | .5144     | .5487     | .5487     |
| 24   | .5144     | .3429     | .3086     | .3944     | .3601     | .4801     | .5144     |
| Max  | .7716     | .7202     | .7716     | .8402     | .703      | .8573     | .8573     |
| Min  | .3086     | .3429     | .3086     | .3086     | .3258     | .3944     | .3772     |
| Avg  | .4907     | .4528     | .4379     | .4644     | .4645     | .5582     | .5573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 205 / 11 KV BHILALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6344     | .9431     | .8916     | .9088     | .9088     | .583      | .6516     |
| 2    | .6516     | 1.0288    | .8916     | .9088     | .9259     | .6001     | .6516     |
| 3    | .6859     | 1.1145    | .9602     | .9431     | 1.0117    | .6173     | .6859     |
| 4    | .7202     | 1.2346    | 1.166     | 1.2003    | 1.1317    | .6516     | .6859     |
| 5    | .9088     |           | 1.3032    | 1.3717    | 1.3717    | .8573     | .8916     |
| 6    | 1.1488    |           |           |           |           | 1.046     | 1.3889    |
| 7    | 1.0974    |           |           |           |           | .8745     | 1.0288    |
| 8    | .9431     |           |           |           |           | .7202     | .8573     |
| 9    | .9259     | .8573     | .703      | .7545     | .7202     | 1.0117    | 1.0288    |
| 10   | .8745     | .9259     | .823      | .7545     | .8573     | .8745     | .9774     |
| 11   | .7888     | .8916     | .7716     | .7716     | .7716     |           | .3086     |
| 12   | .7373     | .3772     | .7888     | .7716     | .7202     | .8059     | .8573     |
| 13   | .7545     | .3086     | .703      | .703      | .6859     | .3429     | .8745     |
| 14   | .7545     | .8059     | .7202     | .6516     | .6173     |           | .8573     |
| 15   | .7545     | .8402     | .7373     | .6859     | .6001     | .8745     | .8745     |
| 16   | .8059     | .7888     | .7888     | .8059     | .7545     | .8402     | .8573     |
| 17   | .8402     | .8573     | .7888     | .7202     | .7373     | .8402     | .823      |
| 18   | .9431     | .9259     | .9259     | .7716     | .8916     | 1.0288    | .8916     |
| 19   | 1.3032    | 1.3375    | 1.4232    | 1.3375    | 1.3032    | 1.3717    | 1.286     |
| 20   | 1.3717    | 1.4746    | 1.4746    | 1.4575    | 1.3717    | 1.5089    | 1.3717    |
| 21   | 1.3032    | 1.2346    | 1.3717    | 1.2689    | 1.2346    | 1.166     | 1.2174    |
| 22   | 1.1145    | 1.1317    | 1.0974    | 1.0974    | 1.0288    | 1.0974    | 1.0631    |
| 23   | .9602     | .9602     | .9431     | .9602     | .6001     | .6516     | .6859     |
| 24   | .6344     | .9088     | .9088     | .9259     | .9088     | .583      | .6516     |
| Max  | 1.3717    | 1.4746    | 1.4746    | 1.4575    | 1.3717    | 1.5089    | 1.3889    |
| Min  | .6344     | .3086     | .703      | .6516     | .6001     | .3429     | .3086     |
| Avg  | .9024     | .9474     | .9610     | .9415     | .9120     | .8612     | .8945     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 206 / 11 KV MEHU TEHU AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     |           |           |           |           | .2229     | .6516     |
| 2    | .2743     |           |           |           |           | .2229     | .3429     |
| 3    | .2572     |           |           |           |           | .2229     | .3429     |
| 4    | .2572     |           |           |           |           | .2229     | .4115     |
| 5    |           |           |           |           |           | .3429     | .4458     |
| 6    | .4115     |           |           |           |           | .4287     | .4801     |
| 7    | .4801     |           |           |           |           | .3772     | .4115     |
| 8    | .583      |           |           |           |           | .3772     | .4115     |
| 9    |           | .3429     | .3086     | .2401     | .2743     |           |           |
| 10   |           | .4801     | .4458     | .3944     | .3601     |           |           |
| 11   |           | .4973     | .4801     |           | .4115     |           |           |
| 12   |           | .4801     | .4115     | .3258     | .3944     |           |           |
| 13   |           | .4801     | .703      | .2572     | .3429     |           |           |
| 14   |           |           | .3429     | .2058     | .2915     |           |           |
| 15   |           |           | .3429     | .2401     | .2229     |           |           |
| 16   |           | .5487     | .3429     | .2743     | .3086     |           |           |
| 23   |           |           |           |           | .2229     | .3429     | .2058     |
| 24   | .3086     |           |           |           |           | .2229     | .3429     |
| Max  | .583      | .5487     | .703      | .3944     | .4115     | .4287     | .6516     |
| Min  | .2572     | .3429     | .3086     | .2058     | .2229     | .2229     | .2058     |
| Avg  | .3558     | .4715     | .4222     | .2768     | .3143     | .2983     | .4047     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 207 / 11KV MEHUTEHU GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6344     | .5658     | .583      | .6173     | .5316     | .5658     |           |
| 2    |           | .6001     | .583      | .6344     | .583      | .583      | .583      |
| 3    | .6516     | .6516     | .6173     | .6516     | .6344     | .6001     |           |
| 4    | .6859     | .6687     | .7202     | .6859     | .6687     | .6173     | .6516     |
| 5    |           | .8916     | .9602     | .8573     | .823      | .7716     |           |
| 6    | 1.0802    | 1.0288    | 1.0974    | 1.0288    | 1.0288    | .9259     | .9774     |
| 7    | .8916     |           | .9602     | .7888     | .8059     | .8059     | .7545     |
| 8    | .8402     |           | .6859     | .6859     | .6516     | .7202     | .7202     |
| 9    | .5487     | .6516     | .6001     | .4973     | .6001     | .6001     | .5487     |
| 10   | .4973     | .5487     | .4801     | .4801     | .6001     | .463      | .4801     |
| 11   | .4458     | .5144     | .4287     | .3772     | .4458     |           | .4458     |
| 12   | .4801     | .463      | .4458     | .4115     | .4458     | .4458     | .4458     |
| 13   | .4458     | .4287     | .463      | .4115     | .4458     | .463      | .4115     |
| 14   | .4115     | .5144     | .4801     | .4287     | .4801     |           | .4458     |
| 15   | .4115     | .5144     | .4973     | .4458     | .4801     | .4801     | .463      |
| 16   | .463      | .5144     | .5144     | .3734     | .4801     | .4973     | .5144     |
| 17   | .4973     | .583      | .5144     | .4973     | .4801     | .5144     | .5487     |
| 18   | .5144     | .6173     | .583      | .5144     | .583      | .6516     | .4115     |
| 19   | .7716     | .8745     | .8745     | .7202     | .7888     | .823      | .8573     |
| 20   | .823      | .823      | .9431     | .823      | .7716     | .8573     | .8573     |
| 21   | .7202     | .7202     | .7716     | .7202     | .6687     | .7202     | .7888     |
| 22   | .6687     | .6516     | .7202     | .7202     | .703      | .6516     | .703      |
| 23   | .583      | .6173     | .6173     | .6001     | .583      | .6516     | .5658     |
| 24   | .6344     | .5658     | .583      | .6173     | .5487     | .5658     | .583      |
| Max  | 1.0802    | 1.0288    | 1.0974    | 1.0288    | 1.0288    | .9259     | .9774     |
| Min  | .4115     | .4287     | .4287     | .3734     | .4458     | .4458     | .4115     |
| Avg  | .6227     | .6368     | .6552     | .6078     | .6180     | .6352     | .6075     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 208 / 11 KV UNDIRKHEDA 1P FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8573     | .6173     | .6173     | .4801     | .6516     | .9259     | .8916     |
| 2    |           | .6173     | .6173     | .4801     | .6516     | .9602     | .8916     |
| 3    | 1.0631    | .6344     | .6516     | .5144     | .6859     | 1.0288    | .9945     |
| 4    | 1.1831    | .6516     | .7545     | .6173     | .6859     | 1.0631    | 1.2003    |
| 5    | 1.2346    | .7716     | .8573     | .823      | .823      | 1.3717    | 1.3032    |
| 6    |           | .9431     | .9259     | 1.0802    | 1.0631    |           |           |
| 7    |           | 1.0631    | 1.2003    | 1.166     | 1.1317    |           |           |
| 8    |           |           | .9602     | 1.1145    | .9602     |           |           |
| 9    | .823      | .7716     | .9431     | .9945     | 1.0117    | .6859     | .7202     |
| 10   | .8916     | .8059     | .7888     | .7716     | .8573     | .8916     | 1.0288    |
| 11   | .8573     | .7716     | .6687     | .7716     | .8059     |           | .9602     |
| 12   | .8573     | .6173     | .6516     | .6001     | .7716     | .9602     | .8916     |
| 13   | .823      |           | .6344     | .703      | .8059     | .9088     | .7888     |
| 14   | .7888     | .703      | .6859     | .6859     | .823      |           | .7716     |
| 15   | .7888     | .8059     | .7716     | .7202     | .7716     | .7888     | .7202     |
| 16   | .823      | .7888     | .7716     | .8059     | .8059     | .8745     | .7716     |
| 17   | .7202     | .7888     | .7716     | .7202     | .7545     | .7888     | .8059     |
| 18   | .703      | .823      | .7716     | .7888     | .6859     | 1.0631    | .7888     |
| 19   | 1.2517    | 1.166     | 1.3203    | 1.2174    | 1.1488    | 1.3203    | 1.2689    |
| 20   | 1.3717    | 1.1317    | 1.3546    | 1.3717    | 1.3717    | 1.4403    | 1.3717    |
| 21   | 1.2346    | 1.0974    | 1.406     | 1.2174    | 1.1831    | 1.2346    | 1.2689    |
| 22   | 1.1488    | 1.0802    |           |           | 1.0802    | 1.0974    | 1.0631    |
| 23   | .6516     | .6859     |           | .7716     | .9431     | .9602     | .9774     |
| 24   | .9088     | .6173     | .6173     |           | .703      | .9259     | .8916     |
| Max  | 1.3717    | 1.166     | 1.406     | 1.3717    | 1.3717    | 1.4403    | 1.3717    |
| Min  | .6516     | .6173     | .6173     | .4801     | .6516     | .6859     | .7202     |
| Avg  | .9491     | .8160     | .8519     | .8371     | .8823     | 1.0153    | .9700     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 209 / 11KV JHAPATBHAWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.6118    |           |           |           | 1.6118    |           |
| 2    |           | 1.5775    |           |           |           | 1.5775    |           |
| 3    |           | 1.5432    |           |           |           | 1.5432    |           |
| 4    | 1.4403    | 1.4403    | 1.8176    | 1.4232    | 1.4918    | 1.5089    | 1.5432    |
| 5    |           | 1.4746    |           |           |           | 1.5775    |           |
| 6    | 1.5775    | 1.5432    |           |           | 1.6975    | 1.6804    |           |
| 7    |           | 1.3717    |           |           | 1.4918    | 1.5947    |           |
| 8    | 1.3375    |           | 1.2689    | 1.3375    | 1.3717    | 1.4746    | 1.4575    |
| 9    |           | 1.3203    |           | 1.3375    | 1.3375    | 1.4575    | 1.3546    |
| 10   | 1.4575    |           | 1.2517    | 1.3717    | 1.4575    |           | 1.406     |
| 11   | 1.4746    |           |           | 1.4403    | 1.5089    |           | 1.5432    |
| 12   | 1.5089    |           | 1.4403    | 1.4918    | 1.5432    | 1.4575    | 1.4918    |
| 13   |           |           |           | 1.5089    | 1.5604    | 1.6118    | 1.5775    |
| 14   | 1.4746    |           |           | 1.5432    | 1.5432    |           | 1.5432    |
| 15   |           |           | 1.5432    | 1.5432    | 1.5604    |           | 1.5432    |
| 16   | 1.4575    | 1.3717    | 1.5089    | 1.4746    | 1.5089    | 1.5775    | 1.5432    |
| 17   | 1.406     |           |           | 1.4575    | 1.4403    |           | 1.5432    |
| 18   | 1.4403    | 1.5432    | 1.4918    | 1.3889    | 1.3717    | 1.6461    | 1.5089    |
| 19   | 1.5432    |           |           |           | 1.5432    |           | 1.6632    |
| 20   | 1.6461    |           | 1.6804    | 1.7833    | 1.7318    | 1.8176    | 1.8004    |
| 21   | 1.7147    |           |           |           | 1.8176    |           |           |
| 22   | 1.8347    | 1.8861    | 1.8347    | 1.8519    | 1.8861    | 1.8861    |           |
| 23   | 1.749     | 1.7833    | 1.7833    | 1.8519    | 1.7318    |           | 1.8347    |
| 24   | 1.6289    | 1.6632    | 1.749     | 1.7147    | 1.7318    | 1.6804    | 1.8004    |
| Max  | 1.8347    | 1.8861    | 1.8347    | 1.8519    | 1.8861    | 1.8861    | 1.8347    |
| Min  | 1.3375    | 1.3203    | 1.2517    | 1.3375    | 1.3375    | 1.4575    | 1.3546    |
| Avg  | 1.5432    | 1.5485    | 1.5791    | 1.5325    | 1.5664    | 1.6064    | 1.5721    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124006 / 33 KV PAROLA

Feeder No / Name : 210 / 11 KV INDUSTRIAL - II  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5487     | .3429     | .3086     | .4287     | .2058     | .5487     | .0686     |
| 2    |           | .3086     | .3086     | .463      | .1886     | .5487     | .0686     |
| 3    |           | .3086     | .3086     | .463      | .1715     | .5487     | .0686     |
| 4    | .583      | .2743     | .3086     | .4973     | .1715     | .5487     | .0686     |
| 5    | .583      | .2743     | .3086     | .5658     | .1715     | .5487     | .0686     |
| 6    | .6516     | .2743     | .3086     | .6516     | .1886     | .5658     | .0686     |
| 7    | .5487     | .2743     | .3086     | .5658     | .1886     | .583      | .0686     |
| 8    | .3258     |           | .1715     | .2401     | .2915     | .5144     | .2743     |
| 9    | .4801     | .2229     | .2572     | .5487     | .3086     | .5144     | .5144     |
| 10   | .6687     | .2915     | .3086     | .5658     | .3429     | .7373     | .3429     |
| 11   | .583      | .2915     | .3258     | .5487     | .3429     |           | .5144     |
| 12   | .5316     | .2572     | .2572     | .5144     | .3086     | .6344     | .4458     |
| 13   | .5487     | .2401     | .2572     | .5144     | .3429     | .6001     | .4458     |
| 14   | .6173     | .1886     | .2743     | .5144     | .2915     |           | .4115     |
| 15   | .4115     | .2058     | .2743     | .5487     | .3086     | .5658     | .6516     |
| 16   | .3601     | .2229     | .2401     | .5487     | .5144     | .6001     | .6516     |
| 17   | .3429     | .1715     | .2743     | .4801     | .5487     | .6173     | .6001     |
| 18   | .3601     | .1715     | .2229     | .463      | .5144     | .5144     | .583      |
| 19   | .3772     | .0686     | .2915     | .2401     | .4801     | .3772     | .5144     |
| 20   | .2401     | .0686     | .1715     |           | .4287     | .2401     | .3601     |
| 21   | .3601     | .2743     | .4115     | .0857     | .5487     | .0686     | .3258     |
| 22   | .3944     | .3601     | .583      | .0857     | .583      | .0686     | .5487     |
| 23   | .4115     | .3429     | .6516     | .2058     | .5487     | .0686     | .5658     |
| 24   | .6173     | .3772     | .3086     | .5487     | .2401     | .5487     | .0686     |
| Max  | .6687     | .3772     | .6516     | .6516     | .583      | .7373     | .6516     |
| Min  | .2401     | .0686     | .1715     | .0857     | .1715     | .0686     | .0686     |
| Avg  | .4793     | .2527     | .3101     | .4473     | .3429     | .4801     | .3458     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 201 / 11 KV MUNDANE AG FDR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2258     | .1957     | .2401     |           | .1619     | .1505     | .2058     |
| 2    | .2286     | .1957     | .2229     | .1882     | .1619     | .1505     | .1886     |
| 3    | .2559     | .1957     | .2229     |           | .1619     | .1355     | .1715     |
| 4    | .2572     | .2107     | .2058     | .1715     | .1457     | .1355     | .1543     |
| 5    | .286      | .2408     | .2058     |           | .1296     | .1355     | .1715     |
| 6    | .2715     | .3311     | .4287     | .3001     | .2429     | .301      |           |
| 7    | .4515     | .587      | .7716     |           | .3401     | .3763     | .1715     |
| 8    | .3286     | .4666     | .6516     | .4144     | .2753     | .301      |           |
| 9    | .1715     | .2408     | .2572     | .2143     | .2709     | .2107     |           |
| 10   | .3763     | .3429     | .2858     | .2915     | .4967     | .4801     | .3572     |
| 11   | .4365     | .3944     |           | .4049     | .6171     | .5487     |           |
| 12   | .4365     | .3429     | .3286     | .3239     | .602      | .4973     | .4287     |
| 13   | .3913     | .3429     |           | .2591     | .4515     | .3944     |           |
| 14   | .286      | .3258     | .2572     | .2753     | .3913     | .3086     | .3001     |
| 15   | .301      | .2743     |           | .2753     | .3612     | .3944     |           |
| 16   | .3161     | .2915     | .2858     | .3239     | .4365     | .3429     | .3572     |
| 23   | .286      | .2401     |           | .1619     | .1957     |           |           |
| 24   | .2        | .2258     | .2401     | .1858     | .1619     | .1656     | .2229     |
| Max  | .4515     | .587      | .7716     | .4144     | .6171     | .5487     | .4287     |
| Min  | .1715     | .1957     | .2058     | .1619     | .1296     | .1355     | .1543     |
| Avg  | .3059     | .3025     | .3289     | .2707     | .3113     | .2958     | .2481     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 203 / 11 KV KARMAD AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1858     | .2286     | .2858     |           |           |           |           |
| 2    | .2        | .2143     | .2715     | .2286     |           |           |           |
| 3    | .2286     | .2286     | .2572     |           |           |           |           |
| 4    | .2429     | .2286     | .2429     | .2        |           |           |           |
| 5    | .3144     | .2715     | .2143     |           |           |           |           |
| 6    | .4287     | .4572     | .3572     | .4001     |           |           |           |
| 7    | .643      | .7573     | .7002     |           |           |           |           |
| 8    | .4572     | .5716     | .5287     | .4572     |           |           |           |
| 9    |           |           |           |           | .3429     | .3001     |           |
| 10   |           |           |           |           | .5716     | .4715     | .4715     |
| 11   |           |           |           |           | .7573     | .5287     |           |
| 12   |           |           |           |           | .6859     | .543      |           |
| 13   |           |           |           |           | .6144     | .4858     |           |
| 14   |           |           |           |           | .4715     | .4715     | .3858     |
| 15   |           |           |           |           | .4287     | .4715     |           |
| 16   |           |           |           |           | .4144     | .443      | .4144     |
| 23   | .3001     | .3001     |           |           |           |           |           |
| 24   | .1715     | .2429     | .3001     | .2572     |           |           |           |
| Max  | .643      | .7573     | .7002     | .4572     | .7573     | .543      | .4715     |
| Min  | .1715     | .2143     | .2143     | .2        | .3429     | .3001     | .3858     |
| Avg  | .3172     | .3501     | .3509     | .3086     | .5358     | .4644     | .4239     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 204 / 11 KV TAMASWADI GFSS

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     | .2378     | .2427     |           | .2195     | .2195     | .2427     |
| 2    | .2926     | .2195     | .2614     | .2561     | .2195     | .2195     | .2427     |
| 3    | .3292     | .2378     | .2801     |           | .2378     | .2378     | .2427     |
| 4    | .3658     | .2561     | .2801     | .3109     | .2561     | .2561     | .2427     |
| 5    | .4207     | .3292     | .2987     |           | .2743     | .2926     | .3174     |
| 6    | .4755     | .5121     | .4668     | .4938     | .4938     | .4755     | .4854     |
| 7    | .4207     | .4572     | .4481     |           | .3475     | .4938     | .4294     |
| 8    | .3292     | .3109     |           | .3109     | .2926     | .3292     | .3547     |
| 9    | .2561     | .2012     | .2614     | .2743     | .2561     | .2561     |           |
| 10   | .2378     | .2587     | .2561     | .2378     | .2561     | .2957     | .2561     |
| 11   | .2561     | .2587     |           | .2195     | .2378     | .2587     |           |
| 12   | .2378     | .2218     | .2195     | .2195     | .2378     | .2587     | .2561     |
| 13   | .2378     | .2402     |           | .2195     | .2378     | .2427     |           |
| 14   | .2195     | .1478     | .2195     | .2195     | .2561     | .1867     | .2561     |
| 15   | .2378     | .2402     |           | .2561     | .2561     | .1867     |           |
| 16   | .2378     | .2587     | .2378     | .2561     | .2378     | .1867     | .2561     |
| 17   | .2378     | .2402     |           | .2561     | .2561     | .2054     |           |
| 18   | .2743     | .2987     | .2743     | .3109     | .2926     | .3174     | .2743     |
| 19   | .3292     | .4108     |           | .3475     | .3292     | .3547     |           |
| 20   | .3841     | .4251     | .4024     | .4024     | .3841     | .4294     | .4024     |
| 21   | .2926     | .3361     |           | .3109     | .3109     | .3361     |           |
| 22   | .2743     | .2987     | .2926     | .2561     | .2926     | .2987     | .2926     |
| 23   | .2561     | .2614     |           | .2561     | .2561     |           |           |
| 24   | .2561     | .2378     | .2427     | .1858     | .2378     | .2378     | .2427     |
| Max  | .4755     | .5121     | .4668     | .4938     | .4938     | .4938     | .4854     |
| Min  | .2195     | .1478     | .2195     | .1858     | .2195     | .1867     | .2427     |
| Avg  | .2972     | .2874     | .2928     | .2800     | .2782     | .2859     | .2996     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 205 / 11 KV KARMAD GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8962     | .6401     | .7282     |           | .695      | .695      | .7167     |
| 2    | 1.0242    | .6401     | .7468     | .8413     | .695      | .7133     | .7356     |
| 3    | 1.262     | .6767     | .8215     |           | .7133     | .7682     | .7922     |
| 4    | 1.4266    | .7682     | .8962     | 1.0608    | .9511     | .9328     | .8488     |
| 5    | 1.5546    | 1.262     | 1.251     |           | 1.2254    | 1.2071    | 1.1694    |
| 6    | 1.7741    | 1.4266    | 1.8111    | 1.7558    | 1.7741    | 1.7558    | 1.6221    |
| 7    | 1.4815    | 1.262     | 1.531     |           | 1.3169    | 1.4815    | 1.3392    |
| 8    | 1.2986    | 1.0791    | 1.2883    | 1.1523    | 1.1888    | 1.2254    | 1.1883    |
| 9    | 1.134     | 1.0059    | 1.0903    | .9511     | 1.0974    | 1.0974    |           |
| 10   | .905      | .8215     | .9511     | .8413     | .8326     | .8775     | .7682     |
| 11   | .8326     | .6722     |           | .6219     | .7602     | .7842     |           |
| 12   | .7783     | .6161     | .7133     | .6767     | .6878     | .6908     | .7865     |
| 13   | .6516     | .6161     |           | .5487     | .6878     | .7468     |           |
| 14   |           | .6348     | .7133     | .5853     | .6516     | .7468     | .7316     |
| 15   | .4163     | .7468     |           | .6767     | .6697     | .7468     |           |
| 16   | .6697     | .5228     | .7499     | .7316     | .6878     | .8215     | .8779     |
| 17   |           | .5601     |           | .7865     | .7783     | .8589     |           |
| 18   |           | 1.0349    | .9145     | 1.134     | .9877     | 1.0269    | .8413     |
| 19   | 1.5546    | 1.4937    |           | 1.39      | 1.4449    | 1.5684    |           |
| 20   | .8962     | 1.587     | 1.4632    | 1.2986    | 1.3717    | 1.5497    | 1.4815    |
| 21   | .9877     | 1.1389    |           | 1.0059    | 1.0608    | .9522     |           |
| 22   | .8779     | .9149     | .9145     | .9145     | .8596     | .8215     | .9145     |
| 23   | .7133     | .7842     |           | .7499     | .7316     |           |           |
| 24   | .8779     | .6584     | .3921     | .7499     | .695      | .695      | .679      |
| Max  | 1.7741    | 1.587     | 1.8111    | 1.7558    | 1.7741    | 1.7558    | 1.6221    |
| Min  | .4163     | .5228     | .3921     | .5487     | .6516     | .6908     | .679      |
| Avg  | 1.0482    | .8985     | .9986     | .9236     | .9402     | .9897     | .9683     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 207 / 11 KV EXPRESS PWW  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0358     | .0358     | .0358     |           | .0366     |           | .0358     |
| 2    | .0358     |           | .0358     | .0358     |           | .0358     | .0358     |
| 3    |           | .0358     | .0358     |           | .0366     |           | .0358     |
| 4    | .0358     |           | .0358     |           | .0366     | .0358     | .0358     |
| 5    | .0358     | .0358     |           |           | .0366     | .0358     | .0358     |
| 6    |           | .0358     | .0358     | .0358     | .0366     | .0358     |           |
| 7    | .0358     | .0358     |           |           |           | .0358     | .0358     |
| 8    | .0358     | .0358     | .0358     |           | .0366     |           | .0358     |
| 9    |           | .0358     | .0358     | .0358     | .0358     | .0358     |           |
| 10   | .0358     |           | .0358     | .0366     |           | .0358     |           |
| 11   |           | .0358     |           | .0366     |           |           |           |
| 12   | .0358     |           |           |           | .0358     |           | .0358     |
| 13   |           |           |           | .0366     |           | .0358     |           |
| 14   |           |           | .0358     |           | .0358     |           | .0358     |
| 16   |           |           |           | .0366     |           | .0358     |           |
| 17   | .0358     | .0358     |           |           | .0358     |           |           |
| 18   | .0358     |           |           | .0366     |           |           | .0358     |
| 19   |           | .0358     |           | .0366     | .0358     | .0358     |           |
| 20   | .0358     | .0358     | .0358     | .0366     |           | .0358     | .0358     |
| 21   | .0358     |           |           | .0366     | .0358     | .0358     |           |
| 22   |           | .0358     |           | .0366     | .0358     |           |           |
| 23   | .0358     | .0358     |           | .0366     | .0358     |           |           |
| 24   | .0358     | .0358     |           | .0358     |           | .0358     | .0358     |
| Max  | .0358     | .0358     | .0358     | .0366     | .0366     | .0358     | .0358     |
| Min  | .0358     | .0358     | .0358     | .0358     | .0358     | .0358     | .0358     |
| Avg  | .0358     | .0358     | .0358     | .0364     | .0361     | .0358     | .0358     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124011 / 33 KV TAMASWADI

Feeder No / Name : 208 / 11 KV RATALE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .2012     | .2149     |
| 2    |           |           |           |           | .2195     | .2328     |
| 3    |           |           |           |           | .2195     | .2328     |
| 4    |           |           |           |           | .2195     | .2328     |
| 5    |           |           |           |           | .2195     | .2686     |
| 6    |           |           |           |           | .2743     | .3761     |
| 7    |           |           |           |           | .3658     | .5014     |
| 8    |           |           |           |           | .2743     | .4477     |
| 9    | .2896     | .2429     |           | .2572     |           |           |
| 10   | .3429     | .3045     | .3144     | .3658     |           |           |
| 11   | .4287     | .4298     |           | .3292     |           |           |
| 12   | .4144     | .5014     | .3286     | .3292     |           |           |
| 13   | .4144     | .4477     |           | .3292     |           |           |
| 14   | .3715     | .394      | .2858     | .3292     |           |           |
| 15   | .3572     | .2865     |           | .2926     |           |           |
| 16   | .3144     | .4298     | .2715     | .3292     |           |           |
| 23   |           |           |           | .1829     |           |           |
| 24   |           |           |           |           | .2012     | .2149     |
| Max  | .4287     | .5014     | .3286     | .3658     | .3658     | .5014     |
| Min  | .2896     | .2429     | .2715     | .1829     | .2012     | .2149     |
| Avg  | .3666     | .3796     | .3001     | .3049     | .2439     | .3024     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124085 / 33 KV SAVKHEDA

Feeder No / Name : 201 / 11 KV SARVE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8488     | .9035     | .898      | .8548     | .8115     | .7049     | .6577     |
| 2    | .9081     | .959      | .9431     | .8729     | .8387     | .7426     | .674      |
| 3    | 1.0616    | 1.0353    | 1.0445    | .9877     | .8733     | .7619     | .6733     |
| 4    | 1.2145    | 1.1506    | 1.1294    | 1.1753    | .8869     | .7838     | .739      |
| 5    | 1.4175    | 1.3041    | 1.2499    | 1.3243    | .8993     | .8221     | .7897     |
| 6    | 1.4407    | 1.6081    | 1.5498    | 1.5513    | 1.1628    | 1.169     | 1.1883    |
| 7    |           |           |           |           | 1.0866    | 1.0574    | 1.0365    |
| 8    |           |           |           |           | 1.1468    | .822      | .8386     |
| 9    | .4368     | .7553     | .822      | .7676     | 1.0321    | 1.2436    | 1.0851    |
| 10   | .5201     | .8086     | .8847     | .7087     | .9261     | .8299     | .8479     |
| 11   | .7202     | .8521     | .7699     | .6921     | .8094     | .7882     | .8436     |
| 12   | .7934     | .7952     | .7682     | .6921     | .8368     | .7491     | .7858     |
| 13   | .8269     | .7394     | .7607     | .6798     | .8316     | .7468     | .8606     |
| 14   | .7493     | .7712     | .6584     | .734      | .8668     | .8029     | .8589     |
| 15   | .7916     | .7394     | .7385     | .7266     | .9037     | .785      | .8802     |
| 16   | .8483     | .7324     | .7651     | .7298     | .8614     | .8571     | .8428     |
| 17   | .7252     | .6756     | .6887     | .8239     | .8179     | .8148     | .743      |
| 18   | .8492     | .8186     | .925      | .8669     | .9021     | .8343     | .8852     |
| 19   | 1.2761    | 1.1635    | 1.3498    | 1.3043    | 1.2361    | 1.2161    | 1.1925    |
| 20   | 1.4623    | 1.4653    | 1.4998    | 1.4032    | 1.4638    | 1.4638    | 1.4118    |
| 21   | 1.2936    | 1.2722    | 1.311     | 1.2696    | 1.2561    | 1.2735    | 1.2548    |
| 22   | 1.1424    | 1.1974    | 1.1588    | 1.1079    | 1.1237    | 1.1225    | 1.1225    |
| 23   | 1.0353    | 1.0185    | .9808     | .7386     | .7712     | .7442     |           |
| 24   | .9044     | .9402     | .9639     | .927      | .7064     | .737      | .711      |
| Max  | 1.4623    | 1.6081    | 1.5498    | 1.5513    | 1.4638    | 1.4638    | 1.4118    |
| Min  | .4368     | .6756     | .6584     | .6798     | .7064     | .7049     | .6577     |
| Avg  | .9667     | .9866     | .9936     | .9517     | .9605     | .9114     | .9097     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124085 / 33 KV SAVKHEDA

Feeder No / Name : 202 / 11 KV KANHERE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3582     | .4646     | .4468     | .4463     | .2859     | .2683     | .2149     |
| 2    | .4477     | .5004     | .5004     | .4641     | .3217     | .2862     | .2507     |
| 3    | .4835     | .554      | .5713     | .554      | .3574     | .2862     | .2686     |
| 4    | .6805     | .6255     | .6784     | .7148     | .3932     | .322      | .2686     |
| 5    | .9323     | .7506     | .8221     | .8747     | .4468     | .3578     | .3403     |
| 6    | 1.2204    | 1.2165    | 1.2688    | 1.3046    | .6255     | .6083     | .6089     |
| 7    | 1.1666    | 1.1449    | 1.1449    | 1.0734    | .5719     | .6083     | .6268     |
| 8    | 1.005     | .9661     | 1.0913    | .9839     | .3395     | .5188     | .5014     |
| 9    | .4666     | .3761     | .3936     | .3399     | .8757     | .7872     | .9681     |
| 10   | .4307     | .4298     | .4294     | .2862     | .4497     | .7156     | .7709     |
| 11   | .3765     | .3757     | .322      | .322      | .5719     | .5009     | .5737     |
| 12   | .4303     | .3578     | .2862     | .2683     | .5004     | .5009     | .502      |
| 13   | .4472     | .3395     | .3041     | .2862     | .483      | .4472     | .4841     |
| 14   | .5361     | .3385     | .2862     | .3038     | .5188     | .4835     | .502      |
| 15   | .357      | .3035     | .2862     | .2681     | .5009     | .5014     | .5199     |
| 16   | .357      | .357      | .322      | .2502     | .5188     | .5014     | .5378     |
| 17   | .4993     | .3567     | .483      | .3932     | .5009     | .5014     | .502      |
| 18   | .642      | .6063     | .644      | .5719     | .6619     | .591      | .6275     |
| 19   | 1.1068    | .9997     | 1.1425    | 1.108     | .9839     | 1.0387    | .986      |
| 20   | 1.1068    | 1.1068    | .5713     | .8757     | .9482     | 1.1462    | 1.1295    |
| 21   | .7498     | .6784     | .7498     | .7506     | .7335     | .7522     | .7171     |
| 22   | .6076     | .5891     | .5713     | .6433     | .5725     | .5731     | .5558     |
| 23   | .5183     | .5004     | .4998     | .2859     | .3041     | .2507     |           |
| 24   | .4298     | .5004     | .4825     | .4641     | .2681     | .2862     | .2686     |
| Max  | 1.2204    | 1.2165    | 1.2688    | 1.3046    | .9839     | 1.1462    | 1.1295    |
| Min  | .357      | .3035     | .2862     | .2502     | .2681     | .2507     | .2149     |
| Avg  | .6398     | .6016     | .5957     | .5764     | .5306     | .5347     | .5533     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124085 / 33 KV SAVKHEDA

Feeder No / Name : 203 / 11KV PALASHKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6813     | .8431     | .7042     | .7756     | .8889     | .7842     | .7274     |
| 2    | .8112     | .8648     | .7579     | .8309     | .9659     | .8445     | .7842     |
| 3    | .8817     | .9037     | .8953     | .9378     | 1.0424    | .9522     | .8224     |
| 4    | .9007     | .9431     | .8745     | 1.0254    | 1.2247    | 1.1191    | .898      |
| 5    | .9208     | 1.0311    | .9709     | 1.138     | 1.3946    | 1.3229    | 1.1576    |
| 6    | 1.2236    | 1.322     | 1.2283    | 1.2712    |           | 1.5232    | 1.4504    |
| 7    | 1.1909    | 1.3531    | 1.1738    | 1.3232    |           |           |           |
| 8    | 1.0059    | 1.1958    | 1.1108    | 1.0242    |           |           |           |
| 9    | .9699     | 1.0653    | 1.0227    | .9522     | 1.0053    | .8728     | .9197     |
| 10   | .8224     | .7813     | .7484     | .7866     | 1.1877    | 1.0749    | 1.0596    |
| 11   | .618      | .7095     | .6915     | .7059     | .9934     | .9802     | .9981     |
| 12   | .6521     | .6701     | .6708     | .6852     | 1.0374    | .9694     | .9371     |
| 13   | .6859     | .6667     | .6845     | .7073     | .9816     | .9216     | .8342     |
| 14   | .7044     | .6873     | .7215     | .668      | .8179     | .9111     | .7842     |
| 15   | .7237     | .7052     | .7446     | .743      | .8906     | .9015     | .8317     |
| 16   | .7608     | .7802     | .7778     | .7778     | .9191     | .9101     | .849      |
| 17   | .6667     | .7423     | .7407     | .7392     | .7561     | .7178     | .6011     |
| 18   | .8925     | .777      | .9193     | .8361     | .823      | .8889     | .9093     |
| 19   | 1.307     | 1.303     | 1.3243    | 1.3774    | 1.3443    | 1.2857    | 1.3788    |
| 20   | 1.3616    | 1.2197    | 1.3429    | 1.1065    | 1.363     | 1.3402    | 1.3416    |
| 21   | 1.0829    | 1.118     | 1.0829    | 1.0164    | 1.0642    | 1.0982    | 1.118     |
| 22   | .9503     | .9316     | .8944     | .9815     | .9335     | .9503     | .9503     |
| 23   | .8825     | .7665     | .8066     | .8571     | .8376     | .8562     |           |
| 24   | .8029     | .8551     | .7419     | .7587     | .8207     | .8012     | .802      |
| Max  | 1.3616    | 1.3531    | 1.3429    | 1.3774    | 1.3946    | 1.5232    | 1.4504    |
| Min  | .618      | .6667     | .6708     | .668      | .7561     | .7178     | .6011     |
| Avg  | .8958     | .9265     | .9013     | .9177     | 1.0139    | 1.0012    | .9597     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124104 / 33 KV BAHADARPUR

Feeder No / Name : 201 / 11 KV BADRINARAYAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5083     | .961      | .9522     | .9709     | .9328     | .4477     | .4835     |
| 2    | .4908     | .961      | .924      | 1.0269    | .9145     | .4525     | .4656     |
| 3    | .5083     | 1.0719    | .924      | 1.1203    | .9694     | .4656     | .4835     |
| 4    | .5258     | 1.2012    | 1.3256    | 1.1576    | 1.0974    | .4525     | .4835     |
| 5    | .5373     | 1.2803    | 1.4377    | 1.2696    | 1.2437    | .4525     | .5014     |
| 6    | .6201     |           |           |           |           | .5973     | .5138     |
| 7    | .691      |           |           |           |           | .591      | .5258     |
| 8    | .5258     |           |           |           |           | .5083     | .5083     |
| 9    | .9425     | .4207     | .4917     | .5138     | .4409     | .8871     | .8962     |
| 10   | .9145     | .5596     | .5281     | .567      | .6443     | .924      | .8871     |
| 11   | .8215     | .5596     | .4973     | .5087     | .6203     | .9425     | .8871     |
| 12   | .8402     | .4915     | .4854     | .407      | .5596     | .9328     | .8686     |
| 13   | .823      | .547      | .4801     | .3768     | .5256     | .9511     | .8962     |
| 14   | .8596     | .426      | .4694     | .407      | .5487     | .9328     | .8871     |
| 15   | .9055     | .4973     | .4807     | .407      | .5316     | .9328     | .9425     |
| 16   | .9055     | .4748     | .4973     | .4917     | .5304     | .9328     | .9425     |
| 17   | .8962     | .8688     | .8413     | 1.0059    | .7343     | .905      | .9145     |
| 18   | .924      | .9896     | .7802     | .9328     | 1.0136    | .8859     | .8596     |
| 19   | 1.2437    | 1.1888    | 1.2012    | 1.2254    | .961      | 1.2071    | 1.0719    |
| 20   | 1.423     | 1.4415    | 1.46      | 1.4449    | 1.4563    | 1.4415    | 1.419     |
| 21   | 1.3306    | 1.3491    | 1.363     | 1.3169    | 1.2696    | 1.2752    | 1.307     |
| 22   | 1.2197    | 1.1458    | 1.2012    | 1.2437    | 1.1827    | 1.1458    | 1.2136    |
| 23   | 1.0719    | 1.0349    | 1.0534    | 1.0425    | .4961     | .4961     | .4908     |
| 24   | .5258     | 1.0349    | .9709     | .9896     | 1.0059    | .443      | .4961     |
| Max  | 1.423     | 1.4415    | 1.46      | 1.4449    | 1.4563    | 1.4415    | 1.419     |
| Min  | .4908     | .4207     | .4694     | .3768     | .4409     | .443      | .4656     |
| Avg  | .8356     | .8812     | .8745     | .8774     | .8418     | .8001     | .7894     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124104 / 33 KV BAHADARPUR

Feeder No / Name : 202 / 11 KV MONDHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7373     | 1.0174    | 1.0513    | 1.0985    | 1.0682    | .7468     | .7577     |
| 2    | .7545     | 1.0174    | 1.0631    | 1.1919    | 1.0682    | .7655     | .7577     |
| 3    | .8059     | 1.1022    | 1.1389    | 1.2136    | 1.1022    | .8402     | .7842     |
| 4    | .9945     | 1.1401    | 1.2003    | 1.2689    | 1.0174    | .9335     | .9335     |
| 5    | 1.0974    | 1.1904    | 1.3032    | 1.3077    | 1.2548    | 1.1763    | 1.0425    |
| 6    |           | 1.5089    | 1.4074    | 1.6385    | 1.643     |           |           |
| 7    |           | 1.3916    | 1.5947    | 1.6356    | 1.7436    |           |           |
| 8    |           | 1.0174    | 1.4413    | 1.4243    | 1.4419    |           |           |
| 9    | .8478     | .8779     | .8596     | .8413     | 1.0456    | .7888     | 1.1869    |
| 10   | 1.4251    | .7682     | .7865     | .8048     | .8029     | 1.4575    | 1.5927    |
| 11   | 1.4922    | .6219     | .6036     | .695      | .7468     | 1.5089    | 1.2717    |
| 12   | 1.4586    | .6283     | .6653     | .6767     | .6348     | 1.2955    | 1.3916    |
| 13   | 1.291     | .6401     | .6653     | .6767     | .6099     | 1.2498    | 1.3748    |
| 14   | 1.291     | .6036     |           | .6767     | .7468     | 1.2498    | 1.2887    |
| 15   | 1.3413    | .6099     | .6036     |           | .7762     | 1.2803    | 1.1126    |
| 16   | 1.3748    | .6219     | .6584     | .695      | .7842     | 1.2955    | 1.2193    |
| 17   | .695      | .7059     | .6767     | .7133     | .7947     | .6001     | .583      |
| 18   | .823      | .7392     | .7577     | .8413     | .8048     | .8059     | .6859     |
| 19   | 1.2012    | 1.0719    | 1.1763    | 1.2437    | .9979     | 1.1488    | .9602     |
| 20   | 1.3491    | 1.3306    | 1.3256    | 1.39      | 1.1458    | 1.2689    | 1.1145    |
| 21   | 1.2012    | 1.0719    | 1.1016    | 1.1157    | 1.1949    | 1.1488    | .9945     |
| 22   | .924      | .9335     | .924      | .9694     | 1.0082    | .9259     | .8916     |
| 23   | 1.0174    | 1.0852    | 1.1283    | 1.0852    | .8402     | .7202     | .703      |
| 24   | .7373     | 1.0513    |           | 1.0985    | 1.1191    | .7842     | .7842     |
| Max  | 1.4922    | 1.5089    | 1.5947    | 1.6385    | 1.7436    | 1.5089    | 1.5927    |
| Min  | .695      | .6036     | .6036     | .6767     | .6099     | .6001     | .583      |
| Avg  | 1.0886    | .9478     | 1.0060    | 1.0566    | 1.0163    | 1.0472    | 1.0205    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124104 / 33 KV BAHADARPUR

Feeder No / Name : 203 / 11 KV BHOLANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8356     | .7762     | .8215     | .7842     | .7865     | .7459     | .8139     |
| 2    | .8383     | .7762     | .8316     | .8402     | 1.0242    | .7625     | .823      |
| 3    | .8718     | 1.0349    | .8589     | .9335     | 1.0608    | .8048     | .8573     |
| 4    | .9156     | 1.2437    | .9709     | 1.0456    | 1.0974    | .8383     | .8916     |
| 5    | .9496     | 1.2803    |           | 1.2323    | 1.2254    | .8718     | .9259     |
| 6    | 1.17      |           |           |           |           | .9602     | 1.1145    |
| 7    | 1.2887    |           | 1.2696    |           |           | 1.0513    | 1.2174    |
| 8    | 1.0898    |           |           |           |           | .9116     | .9156     |
| 9    | 1.1016    | .6104     | .8817     | .9156     | .6443     | .8402     | 1.0456    |
| 10   | .924      | 1.0898    | .9389     | 1.065     | 1.0513    | .7282     | .9709     |
| 11   | .7655     | 1.2125    | .9503     | 1.0159    | 1.1305    | .8402     | .8402     |
| 12   | .7207     | 1.085     | .8848     | .9556     | 1.0242    | .8215     | .8402     |
| 13   | .7577     | 1.1012    | .9503     | .9995     | 1.0364    | .7762     | .7842     |
| 14   | .7762     | .9012     | .9069     | .9835     | 1.0159    | .7947     | .8029     |
| 15   | .8402     | .9717     | .8482     | 1.0004    | .9878     | .8316     | .9425     |
| 16   | .8316     | 1.065     | 1.0562    | 1.0852    | .9722     | .8316     | .9055     |
| 17   | .8413     | .7468     | .7316     | .7316     | .6697     | .8316     | .9145     |
| 18   | .8316     | .8869     | .8596     | .9328     | .8954     | .9511     | .9877     |
| 19   | 1.2936    | 1.3443    | 1.1949    | 1.3535    | 1.1827    | 1.1389    | 1.2696    |
| 20   | 1.3491    | 1.3121    | 1.3256    | 1.2803    | 1.419     | 1.3817    | 1.1763    |
| 21   | 1.251     | 1.1458    | 1.1949    | 1.1523    | 1.1203    | 1.2012    |           |
| 22   | 1.1827    | .9795     | .9425     | .9979     | .9709     | .924      | .9979     |
| 23   | .8413     | .8589     | .8316     | .8413     | .7209     | .8215     | .9389     |
| 24   | .8356     | .8131     | .8215     | .7842     | .8048     | .7459     | .8215     |
| Max  | 1.3491    | 1.3443    | 1.3256    | 1.3535    | 1.419     | 1.3817    | 1.2696    |
| Min  | .7207     | .6104     | .7316     | .7316     | .6443     | .7282     | .7842     |
| Avg  | .9626     | 1.0112    | .9558     | .9967     | .9924     | .8919     | .9477     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124105 / 33 KV MANGRUL

Feeder No / Name : 201 / 11 KV MANGRUL- GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5144     | .4862     | .4588     | .4694     | .4801     | .4096     | .4694     |
| 2    | .5144     | .4694     | .4752     | .4862     | .4801     | .4096     | .4694     |
| 3    | .5316     | .503      | .4915     | .503      | .4973     | .426      | .4862     |
| 4    | .6344     | .6203     | .5898     | .6203     | .6173     | .4915     | .6036     |
| 5    | .823      | .788      | .7865     | .8048     | .703      | .6062     | .6874     |
| 6    | 1.046     | 1.0227    | .9995     | 1.0395    | .9774     | .9339     | .9054     |
| 7    | .7888     | .788      | .8029     | .7209     |           | .7045     | .7209     |
| 8    | .5658     | .6706     | .6718     | .6001     | .6173     | .4915     | .6203     |
| 9    | .6036     | .5735     | .5868     | .5487     | .5407     | .4862     | .5487     |
| 10   |           | .4096     | .4359     | .463      | .426      | .4527     | .5316     |
| 11   | .4527     | .4096     | .4024     | .4115     | .4096     | .4694     | .4973     |
| 12   | .4191     | .3932     | .407      | .4115     | .4096     | .4191     | .4801     |
| 13   | .4191     | .3932     | .4287     | .4115     | .426      | .4359     | .4458     |
| 14   | .4024     | .3932     | .4409     | .4287     | .3932     | .4359     | .4115     |
| 15   | .4115     | .4096     | .4527     | .463      | .426      |           | .4801     |
| 16   | .4694     | .4424     | .4527     | .4458     | .4424     |           | .463      |
| 17   | .503      | .4915     | .5533     | .5144     | .426      | .57       | .4801     |
| 18   | .5533     | .5571     | .6371     | .5658     | .5898     | .57       |           |
| 19   | .7545     | .8029     | .9389     | .8745     | .7209     | .8383     | .8402     |
| 20   | .7545     | .7701     | .8215     | .7545     | .6554     | .7042     | .823      |
| 21   | .6539     | .6226     | .6371     | .6001     | .5571     | .6371     | .6344     |
| 22   | .5365     | .5571     | .57       | .5316     | .5243     | .5533     | .6001     |
| 23   | .4862     |           | .4862     | .4973     | .4588     | .503      | .5316     |
| 24   | .5144     | .4862     | .4588     | .4527     | .4801     | .426      | .4862     |
| Max  | 1.046     | 1.0227    | .9995     | 1.0395    | .9774     | .9339     | .9054     |
| Min  | .4024     | .3932     | .4024     | .4115     | .3932     | .4096     | .4115     |
| Avg  | .5805     | .5678     | .5828     | .5675     | .5330     | .5443     | .5746     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124105 / 33 KV MANGRUL

Feeder No / Name : 202 / 11 KV DHULPIMPRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .2439     | .2294     | .2743     |
| 2    |           |           |           |           | .2439     | .2294     | .2743     |
| 3    |           |           |           |           | .2439     | .2294     | .2743     |
| 4    |           |           |           |           | .2439     | .2294     | .2743     |
| 5    |           |           |           |           | .2439     | .2294     | .2743     |
| 6    |           |           |           |           | .3963     | .4096     | .6036     |
| 7    |           |           |           |           | .4877     | .3932     | .6203     |
| 8    |           |           |           |           | .381      | .4096     | .57       |
| 9    | .4191     | .4715     | .3561     | .381      | .3906     |           |           |
| 10   | .5533     | .4374     | .4359     | .4268     |           |           |           |
| 11   | .2898     | .5312     | .5868     | .4268     |           |           |           |
| 12   | .6371     | .5937     | .57       | .381      |           |           |           |
| 13   | .6036     | .5937     | .6036     | .3506     |           |           |           |
| 14   | .57       | .4687     | .4862     | .381      |           |           |           |
| 15   | .57       | .4999     | .4694     | .3658     |           |           |           |
| 16   | .503      | .5155     | .5365     | .503      |           |           |           |
| 23   |           |           |           | .2439     |           | .4191     |           |
| 24   |           |           |           |           | .2439     | .2622     | .3856     |
| Max  | .6371     | .5937     | .6036     | .503      | .4877     | .4191     | .6203     |
| Min  | .2898     | .4374     | .3561     | .2439     | .2439     | .2294     | .2743     |
| Avg  | .5182     | .5140     | .5056     | .3844     | .3119     | .3041     | .3946     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124105 / 33 KV MANGRUL

Feeder No / Name : 203 / 11 KV CHORWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4268     | .4694     | .3113     | .4409     | .2915     | .2622     | .3174     |
| 2    | .4268     | .4694     | .3277     | .4527     | .2915     | .2622     | .2801     |
| 3    | .4268     | .4694     | .3277     | .4694     | .3086     | .2949     | .2957     |
| 4    | .4572     | .503      | .3277     | .503      | .3258     | .2949     | .3361     |
| 5    | .503      | .5533     | .3113     | .57       | .3429     | .2949     | .3696     |
| 6    | .5792     | .788      | .4424     | .7042     | .4458     | .3277     | .4572     |
| 7    | .7011     | .8215     | .5079     | .8215     | .3429     | .2458     | .3696     |
| 8    | .6249     | .6036     | .3768     | .5197     | .3086     | .2622     | .3174     |
| 9    | .2241     | .1638     |           | .2401     | .3125     | .503      | .5182     |
| 10   | .2054     | .2458     |           | .2401     | .6718     | .7377     | .5792     |
| 11   | .1848     | .2458     | .1867     | .2058     | .6706     |           | .503      |
| 12   | .1867     | .213      | .1886     | .2229     | .7621     | .7712     | .5182     |
| 13   | .1867     | .213      | .373      | .2401     | .7343     | .6874     | .5335     |
| 14   | .1848     |           | .4359     | .2401     | .6562     | .6539     | .5182     |
| 15   | .1867     |           | .4239     | .2401     | .578      | .6371     | .4572     |
| 16   | .2427     |           | .2241     | .2401     | .6562     | .5868     | .4877     |
| 17   | .2987     |           | .1867     | .2572     | .2622     | .2801     | .2401     |
| 18   | .3696     | .3605     | .3734     | .2572     | .2949     | .3511     |           |
| 19   | .3921     | .426      | .5228     | .3772     | .3932     | .5121     | .3506     |
| 20   | .462      | .4588     | .4854     | .3258     | .426      | .4435     | .381      |
| 21   | .4251     | .426      | .4066     | .3944     | .3605     | .4481     | .381      |
| 22   | .4294     | .3605     | .3734     | .3772     | .3605     | .3734     | .3353     |
| 23   | .5197     |           | .4239     | .3086     |           | .3696     | .4268     |
| 24   | .4877     | .503      | .3239     | .4409     | .2915     | .2785     | .2987     |
| Max  | .7011     | .8215     | .5228     | .8215     | .7621     | .7712     | .5792     |
| Min  | .1848     | .1638     | .1867     | .2058     | .2622     | .2458     | .2401     |
| Avg  | .3805     | .4365     | .3573     | .3787     | .4386     | .4295     | .4031     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124109 / 33/11 KV RATNAPIMPRI

Feeder No / Name : 201 / 11KV RATNAPIMPRI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2896     | .2689     | .2862     | .2507     | .2534     | .2715     | .2865     |
| 2    | .2896     | .2689     | .2868     | .2507     | .2534     | .2715     | .2686     |
| 3    | .3077     | .2689     | .2868     | .2686     | .2715     |           | .2865     |
| 4    | .362      | .2868     | .3048     | .3224     | .3439     | .3439     | .3224     |
| 5    | .6516     | .4487     | .4477     | .5014     | .5249     | .5068     | .4656     |
| 6    | .4525     | .4846     | .6984     | .394      | .6335     | .6516     | .3761     |
| 7    | .362      | .3765     | .4841     | .2865     | .3258     | .5068     | .3224     |
| 8    | .2896     | .3586     | .3765     | .2328     | .2507     | .3761     | .2686     |
| 9    | .3439     | .3224     | .3258     | .2151     | .4119     | .3403     | .4303     |
| 10   |           | .3224     | .2896     | .251      | .3582     | .2686     | .3761     |
| 11   |           | .3045     | .2715     | .2868     | .3045     | .2686     | .3227     |
| 12   | .2149     | .2686     | .2534     | .2868     | .3045     | .2686     | .2868     |
| 13   | .2689     | .2686     | .2172     | .2689     | .3045     | .2686     | .2689     |
| 14   | .3045     | .2686     | .2172     | .2689     | .3224     | .2507     | .2689     |
| 15   | .2692     | .2686     | .2172     | .251      | .3403     | .2865     | .2868     |
| 16   | .2515     | .197      | .2149     | .251      | .3582     | .2686     | .2689     |
| 17   | .2875     | .1791     | .3224     | .2172     | .3227     | .3045     | .2353     |
| 18   | .3414     | .3224     | .3761     | .2715     | .3765     | .3761     | .2534     |
| 19   | .3953     | .3761     | .4477     | .4656     | .4123     | .4477     | .3982     |
| 20   | .3948     | .4477     | .4835     | .4163     | .3582     | .4656     | .4344     |
| 21   | .3769     | .3765     | .394      | .3801     |           | .3761     | .362      |
| 22   | .3403     | .3227     | .3224     | .3077     | .3224     | .3224     | .3077     |
| 23   | .2868     | .2868     |           | .2715     | .2715     | .2865     | .2896     |
| 24   | .2896     | .2689     | .2686     | .2507     | .2534     | .2715     | .2865     |
| Max  | .6516     | .4846     | .6984     | .5014     | .6335     | .6516     | .4656     |
| Min  | .2149     | .1791     | .2149     | .2151     | .2507     | .2507     | .2353     |
| Avg  | .3350     | .3151     | .3388     | .2986     | .3425     | .3478     | .3197     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124109 / 33/11 KV RATNAPIMPRI

Feeder No / Name : 202 / 11KV RATNAPIMPRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3018     | .3014     | .3582     | .301      |           |           |
| 2    |           | .3018     | .3014     | .301      | .3311     |           |           |
| 3    |           | .3018     | .3018     | .3161     | .3311     |           |           |
| 4    |           | .3169     | .3165     | .3161     | .3612     |           |           |
| 5    |           | .3617     | .3315     | .3311     | .3913     |           |           |
| 6    |           | .3923     | .3617     | .3612     | .4515     |           |           |
| 7    |           | .422      | .437      | .4365     | .5268     |           |           |
| 8    |           | .3923     | .4521     | .4515     | .4515     |           |           |
| 9    |           |           |           |           |           | .4064     | .422      |
| 10   | .3324     |           |           |           |           | .4816     | .4515     |
| 11   | .3777     |           |           |           |           | .5268     | .4967     |
| 12   | .4387     |           |           |           |           | .5418     | .4816     |
| 13   | .4532     |           |           |           |           | .4967     | .4515     |
| 14   | .4835     |           |           |           |           | .4967     | .437      |
| 15   | .4986     |           |           |           |           | .4515     | .4214     |
| 16   | .5137     |           |           |           |           | .4666     | .4973     |
| 23   | .3018     | .2414     |           | .3913     |           |           |           |
| 24   |           | .3014     | .3018     | .301      | .301      |           |           |
| Max  | .5137     | .422      | .4521     | .4515     | .5268     | .5418     | .4973     |
| Min  | .3018     | .2414     | .3014     | .301      | .301      | .4064     | .4214     |
| Avg  | .4250     | .3333     | .3450     | .3564     | .3829     | .4835     | .4574     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 124109 / 33/11 KV RATNAPIMPRI

Feeder No / Name : 203 / 11KV KOLPIMPRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7373     | .2321     | .2321     | .2294     | .1966     | .7373     | .7209     |
| 2    | .7373     | .2321     | .2321     | .2294     | .1966     | .7373     | .7209     |
| 3    | .7865     | .2321     | .2321     | .2458     | .2458     | .7865     | .7209     |
| 4    | .7865     | .2323     | .2486     | .2949     | .3113     | .7865     | .7373     |
| 5    | .8192     | .2987     | .3153     | .3605     | .3605     | .852      | .7373     |
| 6    | .9012     | .4144     | .448      | .3932     | .426      | .9175     | .8848     |
| 7    | 1.0159    | .3485     | .3481     | .3113     |           | .9503     | .9012     |
| 8    | .852      | .2483     | .2818     | .213      | .2294     | .7842     | .8684     |
| 9    | .1475     | .5898     | .6554     | .6299     | .5079     | .176      | .2483     |
| 10   | .1654     | .8356     | .9069     | .7956     | .7537     | .176      | .2486     |
| 11   | .215      | .9831     | .9555     | .9293     | .8848     | .16       | .2321     |
| 12   | .1817     | .9831     | .9393     | .9127     | .9175     | .16       | .2321     |
| 13   | .1819     | .9503     | .9069     | .8795     | .9012     | .1619     | .2321     |
| 14   | .1982     | .9339     | .8907     | .8795     | .9175     | .1943     | .2323     |
| 15   | .1982     | .8356     | .8421     | .8795     | .9293     | .1943     | .2321     |
| 16   | .1984     | .8029     | .8097     | .9293     | 1.0545    |           | .2157     |
| 17   | .1984     | .1147     | .1311     | .1311     | .1493     | .2105     | .213      |
| 18   | .215      | .2294     | .3441     | .213      | .2155     | .1802     | .2294     |
| 19   | .2481     | .2785     | .2785     | .3041     | .3153     | .213      | .2915     |
| 20   | .2483     | .3113     | .3113     | .3277     | .2987     | .2949     | .2785     |
| 21   | .2649     | .2818     | .2622     | .2785     | .2821     | .2785     | .2622     |
| 22   | .2483     | .2486     | .2294     | .2458     | .2323     | .2294     | .2458     |
| 23   | .2321     | .2321     |           | .1966     | .7373     | .7373     | .7125     |
| 24   | .7373     | .2321     | .2318     | .2294     | .1966     | .7373     | .7209     |
| Max  | 1.0159    | .9831     | .9555     | .9293     | 1.0545    | .9503     | .9012     |
| Min  | .1475     | .1147     | .1311     | .1311     | .1493     | .16       | .213      |
| Avg  | .4381     | .4617     | .4797     | .4600     | .4896     | .4633     | .4633     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

PACHORA DIVISION[595]

PAROLA[245]

BU 8133

Substation No/ Name :- 127019 / 132/33 kV Parola Substation

Feeder No / Name : 401 / 33 kV Parola

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 5.0412    | 5.3498    | 4.9383    | 5.2984    | 4.8354    | 5.2652    | 4.784     |
| 2    | 4.9383    | 5.2469    | 4.8868    | 5.1955    | 4.7325    | 4.8354    | 4.6296    |
| 3    |           | 5.1955    | 4.9897    | 5.1955    | 4.7325    | 4.8868    | 4.7325    |
| 4    | 5.0412    | 5.0412    | 5.2984    | 5.4012    | 4.8354    | 5.3772    | 4.8354    |
| 5    | 5.7613    | 5.5556    | 5.8642    | 5.7613    | 5.6584    | 5.4012    | 4.9383    |
| 6    | 5.5556    | 6.0185    | 6.2757    | 6.9445    | 5.8642    | 5.607     | 4.9383    |
| 7    | 5.3498    | 5.9156    | 6.1214    | 6.3786    | 5.4527    | 5.2469    |           |
| 8    | 4.6811    |           | 5.0926    | 5.0926    | 5.2469    | 4.5782    | 4.5268    |
| 9    | 5.144     | 4.6811    | 4.9383    | 4.1152    | 4.6811    | 5.3498    | 5.2469    |
| 10   | 5.5041    | 4.784     | 5.144     | 4.784     | 4.9383    | 6.07      | 5.6584    |
| 11   | 5.6584    | 4.7325    | 5.144     | 4.784     | 5.0412    |           | 5.4527    |
| 12   | 5.5041    | 4.4239    | 5.144     | 4.7325    | 4.9383    | 6.07      | 5.4527    |
| 13   | 5.3498    | 4.0124    | 5.2469    | 4.6811    | 4.8868    | 5.7613    | 5.6584    |
| 14   | 5.144     | 4.2696    | 4.7325    | 4.6296    | 4.6811    |           | 5.4012    |
| 15   | 5.3498    | 4.4753    | 4.6296    | 4.784     | 4.6811    | 5.8642    | 5.7099    |
| 16   | 5.3498    | 4.7325    | 4.8868    | 4.9383    | 4.9383    | 5.7613    | 5.7613    |
| 17   | 4.5931    | 4.6296    | 4.2181    | 4.1152    | 4.2181    | 4.5268    | 4.5268    |
| 18   | 4.4239    | 4.2696    | 4.4753    | 4.2181    | 4.6296    | 4.9383    | 4.5268    |
| 19   | 5.2469    | 5.0412    | 5.3498    | 4.9383    | 5.144     | 5.144     | 5.3498    |
| 20   | 5.607     | 5.4012    | 5.8642    | 5.3498    | 5.7099    | 5.3498    | 5.6584    |
| 21   | 5.4012    | 5.144     | 5.6584    | 4.9383    | 5.607     | 4.9383    | 5.2469    |
| 22   | 5.4527    | 5.0926    | 4.9897    | 4.7325    | 5.607     | 4.9383    | 5.3498    |
| 23   | 5.7099    | 4.9383    | 5.1955    | 5.4527    | 5.2469    | 4.9897    | 5.5556    |
| 24   | 5.2469    | 5.4012    | 4.9897    | 5.0926    | 5.144     | 4.9383    | 4.784     |
| Max  | 5.7613    | 6.0185    | 6.2757    | 6.9445    | 5.8642    | 6.07      | 5.7613    |
| Min  | 4.4239    | 4.0124    | 4.2181    | 4.1152    | 4.2181    | 4.5268    | 4.5268    |
| Avg  | 5.2632    | 4.9718    | 5.1697    | 5.0647    | 5.0604    | 5.2654    | 5.1619    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 201 / 11 KV BHAMALWADI-AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10   |           |           |           |           | 1.3672    |           |
| 11   |           |           | 1.5051    | 1.3717    |           | 1.2795    |
| 13   |           | 1.5954    |           |           |           |           |
| 14   |           |           |           | 1.4022    | 1.3672    |           |
| 15   |           |           |           |           |           | 1.4407    |
| 16   |           |           | 1.4901    |           |           |           |
| 18   | 1.2934    |           | 1.4047    | 1.3998    |           |           |
| Max  | 1.2934    | 1.5954    | 1.5051    | 1.4022    | 1.3672    | 1.4407    |
| Min  | 1.2934    | 1.5954    | 1.4047    | 1.3717    | 1.3672    | 1.2795    |
| Avg  | 1.2934    | 1.5954    | 1.4666    | 1.3912    | 1.3672    | 1.3601    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 202 / 11 KV KANDWEL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.278     | 1.2631    | 1.1174    | 1.2289    |
| 13   |           | 1.278     |           |           |           |           |
| 14   |           |           |           | 1.1336    | 1.1498    |           |
| 15   |           |           |           |           |           | 1.3279    |
| 18   | 1.085     |           | 1.0814    | 1.1797    |           |           |
| Max  | 1.085     | 1.278     | 1.278     | 1.2631    | 1.1498    | 1.3279    |
| Min  | 1.085     | 1.278     | 1.0814    | 1.1336    | 1.1174    | 1.2289    |
| Avg  | 1.085     | 1.278     | 1.1797    | 1.1921    | 1.1336    | 1.2784    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 203 / 11 KV VITWA- AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0232     |           |           |           |           |
| 2    |           |           |           | 2.21      | 2.2862    |
| 3    |           | 2.3624    |           |           |           |
| 4    |           |           | 2.3624    |           |           |
| 6    | .0236     |           |           | 2.2862    | 2.5149    |
| 7    |           | 2.2862    | 2.4387    |           |           |
| 10   | 2.6673    |           |           |           |           |
| Max  | 2.6673    | 2.3624    | 2.4387    | 2.2862    | 2.5149    |
| Min  | .0232     | 2.2862    | 2.3624    | 2.21      | 2.2862    |
| Avg  | .9047     | 2.3243    | 2.4006    | 2.2481    | 2.4006    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 204 / 11 KV AINPUR -AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.7147    | 1.7147    | 1.9814    | 1.9052    |
| 13   |           | 1.9814    |           |           |           |           |
| 14   |           |           |           | 1.829     | 2.0957    |           |
| 15   |           |           |           |           |           | 1.7179    |
| 16   |           |           | 1.8671    |           |           |           |
| 17   |           |           | 1.829     |           |           |           |
| 18   | .021      |           | 1.9052    | 1.9052    |           |           |
| Max  | .021      | 1.9814    | 1.9052    | 1.9052    | 2.0957    | 1.9052    |
| Min  | .021      | 1.9814    | 1.7147    | 1.7147    | 1.9814    | 1.7179    |
| Avg  | .021      | 1.9814    | 1.829     | 1.8163    | 2.0386    | 1.8116    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 205 / 11 KV DHAMODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.2191    |           |           |           |           |
| 2    |           |           |           |           | 1.1069    | 1.1561    |
| 3    |           |           | 1.2193    |           |           |           |
| 4    |           |           |           | 1.2334    |           |           |
| 6    |           | 1.2191    |           |           | 1.1385    | 1.2029    |
| 7    |           |           | 1.3717    | 1.3125    |           |           |
| 10   |           | 1.3125    |           |           |           |           |
| 11   |           |           | .0791     | .0762     | .061      | .0791     |
| 13   |           | .0633     |           |           |           |           |
| 14   |           |           |           | .061      | .061      |           |
| 15   |           |           |           |           |           | .0781     |
| 16   |           |           | .0949     |           |           |           |
| 18   | .0926     |           | .1423     | .1581     |           |           |
| 19   |           |           |           |           | .1718     | .1875     |
| 22   | .1235     | .1372     | .1265     |           |           | .125      |
| 23   |           |           |           | .1107     | .1094     |           |
| Max  | .1235     | 1.3125    | 1.3717    | 1.3125    | 1.1385    | 1.2029    |
| Min  | .0926     | .0633     | .0791     | .061      | .061      | .0781     |
| Avg  | .1081     | .7902     | .5056     | .4920     | .4414     | .4715     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124053 / 33/11 KV AINPUR

Feeder No / Name : 207 / 11 KV KHIRDI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0625     |           |           |           |           |
| 2    |           |           |           |           | .8131     | .7762     |
| 3    |           |           | 1.1458    |           |           |           |
| 6    |           | .16       |           |           | 1.885     | 1.885     |
| 7    |           |           | 1.6632    |           |           |           |
| 10   |           | .9979     |           |           |           |           |
| 11   |           |           | .8871     | .8962     | .8596     |           |
| 12   |           |           |           |           |           | .8501     |
| 13   |           | .7023     |           |           |           |           |
| 14   |           |           |           | .6584     | .6584     |           |
| 15   |           |           |           |           |           | .8686     |
| 16   |           |           | .8501     |           |           |           |
| 18   | .1097     |           | 1.4415    | 1.3676    |           |           |
| 19   |           | 1.6817    |           |           | 1.6817    | 1.4969    |
| 22   | .0762     | .9795     | 1.0164    |           |           | .961      |
| 23   |           |           |           | .8686     | .8501     |           |
| Max  | .1097     | 1.6817    | 1.6632    | 1.3676    | 1.885     | 1.885     |
| Min  | .0762     | .0625     | .8501     | .6584     | .6584     | .7762     |
| Avg  | .0930     | .7640     | 1.1674    | .9477     | 1.1247    | 1.1396    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 201 / 11 KV KIRWAD-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 2.4417    |           | 2.1348    |           |
| 9    |           |           | 2.2382    |           | 2.3739    |
| 10   | 2.0972    |           |           |           | 2.0424    |
| Max  | 2.0972    | 2.4417    | 2.2382    | 2.1348    | 2.3739    |
| Min  | 2.0972    | 2.4417    | 2.2382    | 2.1348    | 2.0424    |
| Avg  | 2.0972    | 2.4417    | 2.2382    | 2.1348    | 2.2082    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 202 / 11KV KHANAPUR- AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 2.4417    |           | 2.1792    |           |
| 9    |           |           | 2.13      |           | 2.5095    |
| 10   |           |           |           |           | 2.3663    |
| 12   | 1.9006    | 2.3061    |           | 2.13      |           |
| 16   | 2.0317    | 2.3061    | 2.3752    |           | 2.3663    |
| 18   |           |           |           |           | 2.1605    |
| 19   | 1.0174    |           |           |           |           |
| 24   |           |           |           | .5243     |           |
| Max  | 2.0317    | 2.4417    | 2.3752    | 2.1792    | 2.5095    |
| Min  | 1.0174    | 2.3061    | 2.13      | .5243     | 2.1605    |
| Avg  | 1.6499    | 2.3513    | 2.2526    | 1.6112    | 2.3507    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 203 / 11 KV MORGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | .8421     | .7865     |           | .8478     |           |
| 16   | .8436     | .8848     | .9015     |           | .7926     |
| 18   |           |           |           |           | .823      |
| Max  | .8436     | .8848     | .9015     | .8478     | .823      |
| Min  | .8421     | .7865     | .9015     | .8478     | .7926     |
| Avg  | .8429     | .8357     | .9015     | .8478     | .8078     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 205 / 11KV PADALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .5426     |           | .4748     |           |
| 9    |           |           | .4588     |           | .6783     |
| 10   |           |           |           |           | .5144     |
| 12   | 1.7368    | 1.6872    |           | 1.7465    |           |
| 16   | 1.1797    | 1.3904    | 1.2146    |           | 1.3375    |
| 18   |           |           |           |           | 1.5775    |
| 19   | .7773     |           |           |           |           |
| 24   |           |           |           | .4694     |           |
| Max  | 1.7368    | 1.6872    | 1.2146    | 1.7465    | 1.5775    |
| Min  | .7773     | .5426     | .4588     | .4694     | .5144     |
| Avg  | 1.2313    | 1.2067    | .8367     | .8969     | 1.0269    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 206 / 11 KV DHURKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 2.5888    |           | 2.6526    |           |
| 9    |           |           | 2.5587    |           | 2.5911    |
| 10   | 2.5724    |           |           |           | 2.2558    |
| Max  | 2.5724    | 2.5888    | 2.5587    | 2.6526    | 2.5911    |
| Min  | 2.5724    | 2.5888    | 2.5587    | 2.6526    | 2.2558    |
| Avg  | 2.5724    | 2.5888    | 2.5587    | 2.6526    | 2.4235    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124054 / 33KV MORGAON

Feeder No / Name : 207 / 11 KV KIRWAD-GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .7682     |           | .7122     |           |
| 9    |           |           | .5487     |           | .5792     |
| 10   |           |           |           |           | .5144     |
| 12   | .3258     | .362      |           | .2896     |           |
| 16   | .3277     | .3982     | .4252     |           | .4115     |
| 18   |           |           |           |           | .6173     |
| 19   | .724      |           |           |           |           |
| 24   |           |           |           | .3605     |           |
| Max  | .724      | .7682     | .5487     | .7122     | .6173     |
| Min  | .3258     | .362      | .4252     | .2896     | .4115     |
| Avg  | .4592     | .5095     | .4870     | .4541     | .5306     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124055 / 33/11 KV KERHALE

Feeder No / Name : 202 / 11 KV KERHALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .9945     |           | 1.0288    | .9945     | 1.0288    |
| 9    |           |           | .9088     |           |           |           |
| 10   |           |           |           |           |           | .7545     |
| 12   |           | .5487     | .5316     |           |           | .5144     |
| 16   | .6516     | .5335     | .583      | .5658     |           | .6516     |
| 20   | 1.0631    | .9602     | 1.0288    | .9945     |           |           |
| 24   |           | .6859     | .6859     | .6859     | .6859     | .6516     |
| Max  | 1.0631    | .9945     | 1.0288    | 1.0288    | .9945     | 1.0288    |
| Min  | .6516     | .5335     | .5316     | .5658     | .6859     | .5144     |
| Avg  | .8574     | .7446     | .7476     | .8188     | .8402     | .7202     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124055 / 33/11 KV KERHALE

Feeder No / Name : 204 / 11 KV GINING INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
 FEEDER Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .0305     |           | .0305     | .0305     | .0457     |
| 9    |           |           | .0305     |           |           |           |
| 10   |           |           |           |           |           | .0305     |
| 12   |           | .0305     | .0305     | .0457     |           | .061      |
| 16   | .0305     | .0305     | .0305     | .061      |           | .0305     |
| 20   | .0305     | .0305     | .0305     | .0305     |           |           |
| 24   |           | .0305     | .0305     | .0305     | .0305     | .0305     |
| Max  | .0305     | .0305     | .0305     | .061      | .0305     | .061      |
| Min  | .0305     | .0305     | .0305     | .0305     | .0305     | .0305     |
| Avg  | .0305     | .0305     | .0305     | .0396     | .0305     | .0396     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124056 / 33/11 KV PAL

Feeder No / Name : 201 / 11 KV PAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           |           | 1.7859    | 1.6057    |           |
| 12   |           |           | 1.704     |           |           |           |
| 13   |           | 1.704     |           |           |           | 1.8351    |
| 14   |           |           |           | 1.704     |           |           |
| 16   | 1.3927    |           | 1.6057    |           | 1.8023    | 1.8351    |
| 18   | 1.4091    | 1.6221    |           | 1.3599    | 1.6876    |           |
| 19   |           |           |           |           | 1.6876    |           |
| Max  | 1.4091    | 1.704     | 1.704     | 1.7859    | 1.8023    | 1.8351    |
| Min  | 1.3927    | 1.6221    | 1.6057    | 1.3599    | 1.6057    | 1.8351    |
| Avg  | 1.4009    | 1.6631    | 1.6549    | 1.6166    | 1.6958    | 1.8351    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124056 / 33/11 KV PAL

Feeder No / Name : 202 / 11 KV PAL GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .4424     | .426      | .4588     | .4424     |
| 7    |           | .7701     |           |           |           |           |
| 8    |           | .6226     | .5243     | .5898     | .6718     | .5898     |
| 10   |           | .5407     |           |           |           | .5079     |
| 11   |           |           |           | .4752     | .4096     |           |
| 12   |           |           | .4424     |           |           |           |
| 13   |           | .4424     |           |           |           | .3932     |
| 14   |           |           |           | .3932     |           |           |
| 16   | .4915     |           | .4915     |           | .4588     | .4424     |
| 18   | .6226     | .5407     |           | .5571     | .4096     |           |
| 19   |           |           |           |           |           | .639      |
| 20   |           |           | .5898     |           |           |           |
| 21   | .5407     |           |           |           |           |           |
| 22   |           |           |           | .5407     |           |           |
| 23   | .5079     |           |           |           |           |           |
| 24   |           | .4915     | .4915     | .4752     | .5079     | .4752     |
| Max  | .6226     | .7701     | .5898     | .5898     | .6718     | .639      |
| Min  | .4915     | .4424     | .4424     | .3932     | .4096     | .3932     |
| Avg  | .5407     | .568      | .4970     | .4939     | .4861     | .4986     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124056 / 33/11 KV PAL

Feeder No / Name : 203 / 11 KV MOHARAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.9006    | 1.8515    | 1.8023    | 1.9006    |
| 7    | 2.6543    |           |           |           |           |
| 8    | 2.4577    | 2.13      | 2.3266    | 2.2447    | 2.2283    |
| 10   | 1.7368    |           |           |           | 2.0317    |
| Max  | 2.6543    | 2.13      | 2.3266    | 2.2447    | 2.2283    |
| Min  | 1.7368    | 1.9006    | 1.8515    | 1.8023    | 1.9006    |
| Avg  | 2.2829    | 2.0153    | 2.0891    | 2.0235    | 2.0535    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124057 / 33/11 KV VIVARA

Feeder No / Name : 201 / 11 KV VIVARA-I-PARASE-  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   |           | 1.6804    | 1.406     | 1.531     | 1.7177    | 1.6617    |
| 16   | 1.5089    | 1.4937    | 1.4746    | 1.587     | 1.6409    | 1.643     |
| Max  | 1.5089    | 1.6804    | 1.4746    | 1.587     | 1.7177    | 1.6617    |
| Min  | 1.5089    | 1.4937    | 1.406     | 1.531     | 1.6409    | 1.643     |
| Avg  | 1.5089    | 1.5871    | 1.4403    | 1.559     | 1.6793    | 1.6524    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124057 / 33/11 KV VIVARA

Feeder No / Name : 202 / 11 KV VIVARA-II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | .8688     | .8749     | .884      | .823      | .8383     |
| 8    |           | .8535     | .823      | .884      | .8383     | .9145     |
| 12   |           | 1.9204    | 1.7071    | 1.8623    | 1.7394    | 1.8343    |
| 16   | 1.7985    | 1.8138    | 1.7375    | 1.8185    | 1.7394    | 1.8976    |
| Max  | 1.7985    | 1.9204    | 1.7375    | 1.8623    | 1.7394    | 1.8976    |
| Min  | 1.7985    | .8535     | .823      | .884      | .823      | .8383     |
| Avg  | 1.7985    | 1.3641    | 1.2856    | 1.3622    | 1.2850    | 1.3712    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124057 / 33/11 KV VIVARA

Feeder No / Name : 204 / 11 KV VIVRA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.4403    | 1.5339    | 1.3717    | 1.531     | 1.5684    |
| 12   |           | .695      | .6173     | .6984     | .6984     | .724      |
| 16   | .6344     | .6878     | .6859     | .724      | .7522     | .7865     |
| 19   | .9259     | 1.0791    | 1.0631    | 1.1643    |           | 1.1157    |
| 24   |           | .7202     | .7602     | .6859     | .7522     | .7602     |
| Max  | .9259     | 1.4403    | 1.5339    | 1.3717    | 1.531     | 1.5684    |
| Min  | .6344     | .6878     | .6173     | .6859     | .6984     | .724      |
| Avg  | .7802     | .9245     | .9321     | .9289     | .9335     | .9910     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124057 / 33/11 KV VIVARA

Feeder No / Name : 205 / 11 KV UTKHEDA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.5432    | 1.6461    |           | 1.4937    | 1.587     |
| 8    |           | 1.2003    | 1.3717    | 1.166     | 1.1088    | 1.307     |
| 12   |           |           | .6344     | .7316     | .7316     | .7682     |
| 16   | .7888     | .7682     | .7202     | .7602     | .7316     | .8779     |
| 19   | 1.166     | 1.4563    | 1.3717    |           |           | 1.307     |
| 24   |           | .6859     | .7545     | .6859     | .7316     | 1.2803    |
| Max  | 1.166     | 1.5432    | 1.6461    | 1.166     | 1.4937    | 1.587     |
| Min  | .7888     | .6859     | .6344     | .6859     | .7316     | .7682     |
| Avg  | .9774     | 1.1308    | 1.0831    | .8359     | .9595     | 1.1879    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124057 / 33/11 KV VIVARA

Feeder No / Name : 206 / 11 KV KUSUMBE FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.3717    | 1.2811    | 1.4784    | 1.6288    | 1.6129    |
| 8    | 1.4175    | 1.4706    | 1.448     | 1.6129    | 1.4937    |
| Max  | 1.4175    | 1.4706    | 1.4784    | 1.6288    | 1.6129    |
| Min  | 1.3717    | 1.2811    | 1.448     | 1.6129    | 1.4937    |
| Avg  | 1.3946    | 1.3759    | 1.4632    | 1.6209    | 1.5533    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124058 / 33/11 KV NIMBOL

Feeder No / Name : 201 / 11 KV SANGAVA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.7193    |           |           | 1.9753    |
| 12   |           | 1.9033    |           |           |           |           |
| 14   |           | 1.9376    | 1.9204    |           | 1.9547    | 2.1033    |
| 16   | 2.0851    | 1.9204    | 2.0119    | 1.8519    | 1.989     | 2.1948    |
| 18   | 2.0851    |           | 2.0485    |           |           | 2.2314    |
| Max  | 2.0851    | 1.9376    | 2.0485    | 1.8519    | 1.989     | 2.2314    |
| Min  | 2.0851    | 1.9033    | 1.7193    | 1.8519    | 1.9547    | 1.9753    |
| Avg  | 2.0851    | 1.9204    | 1.9250    | 1.8519    | 1.9719    | 2.1262    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124058 / 33/11 KV NIMBOL

Feeder No / Name : 202 / 11 KV NANDURKHEDA- AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.5729    | 1.3889    | 1.2803    |           |           |
| 7    |           | 1.4746    |           | 1.5604    | 1.4575    |
| 8    | 1.6461    | 1.5089    | 1.4998    | 1.5604    | 1.4575    |
| Max  | 1.6461    | 1.5089    | 1.4998    | 1.5604    | 1.4575    |
| Min  | 1.5729    | 1.3889    | 1.2803    | 1.5604    | 1.4575    |
| Avg  | 1.6095    | 1.4575    | 1.3901    | 1.5604    | 1.4575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124058 / 33/11 KV NIMBOL

Feeder No / Name : 203 / 11 KV NIMBOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.307     | 1.2003    | 1.307     |           |           |
| 7    |           |           | 1.0631    |           | 1.0288    | 1.0288    |
| 8    |           | .8686     | .8402     | .7762     | .7888     | .8059     |
| 11   |           |           | .4435     |           |           | .3326     |
| 12   |           | .3086     |           |           |           |           |
| 14   |           | .3429     | .3696     |           | .3772     | .3361     |
| 16   | .4108     | .4115     | .4435     | .3944     | .4287     | .4805     |
| 18   | .7468     |           | .7468     |           |           | .7392     |
| 20   |           | .703      |           |           |           |           |
| 21   | .6283     |           | .6653     |           | .6516     | .7023     |
| 23   |           |           |           | .5144     |           |           |
| 24   |           | .4805     | .5144     | .5175     | .5144     | .5144     |
| Max  | .7468     | 1.307     | 1.2003    | 1.307     | 1.0288    | 1.0288    |
| Min  | .4108     | .3086     | .3696     | .3944     | .3772     | .3326     |
| Avg  | .5953     | .6317     | .6985     | .7019     | .6316     | .6175     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124058 / 33/11 KV NIMBOL

Feeder No / Name : 204 / 11 KV SANGVA GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           | 1.0802    | 1.1088    |           |           |
| 7    |           |           | .9945     |           | 1.0288    | 1.046     |
| 8    |           | .8686     | .7202     |           | .9602     | .9259     |
| 11   |           |           | .4805     |           |           | .3696     |
| 14   |           | .6859     | .4066     |           | .6687     | .3696     |
| 16   | .4435     | .7545     | .4805     | .7716     | .8402     | .5175     |
| 18   | .7762     |           | .7392     |           |           | .7762     |
| 20   |           | .6687     |           |           |           |           |
| 21   | .6283     |           | .6283     |           | .6173     | .6653     |
| 23   |           |           |           | .4287     |           |           |
| 24   |           | .4435     | .4115     | .462      | .4115     | .463      |
| Max  | .7762     | .8686     | 1.0802    | 1.1088    | 1.0288    | 1.046     |
| Min  | .4435     | .4435     | .4066     | .4287     | .4115     | .3696     |
| Avg  | .616      | .6842     | .6602     | .6928     | .7545     | .6416     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124058 / 33/11 KV NIMBOL

Feeder No / Name : 205 / 11 KV PATONDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.2071    |           | 1.0059    |           |           |
| 7    |           | 1.0974    |           | 1.0288    | 1.0117    |
| 8    | 1.2437    | 1.1145    | 1.0974    | 1.0974    | 1.0802    |
| Max  | 1.2437    | 1.1145    | 1.0974    | 1.0974    | 1.0802    |
| Min  | 1.2071    | 1.0974    | 1.0059    | 1.0288    | 1.0117    |
| Avg  | 1.2254    | 1.1060    | 1.0517    | 1.0631    | 1.0460    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124094 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV AJNAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .6653     | .6516     | .7066     | .785      | .6173     |
| 16   | .4582     | .463      | .4362     | .4721     | .4287     | .4458     |
| 24   |           | .3982     | .4115     | .3973     | .4503     | .4115     |
| Max  | .4582     | .6653     | .6516     | .7066     | .785      | .6173     |
| Min  | .4582     | .3982     | .4115     | .3973     | .4287     | .4115     |
| Avg  | .4582     | .5088     | .4998     | .5253     | .5547     | .4915     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124094 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV KHANAPUR AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .9945     | .8718     | .8154     | .8593     | .788      |
| Max  | .9945     | .8718     | .8154     | .8593     | .788      |
| Min  | .9945     | .8718     | .8154     | .8593     | .788      |
| Avg  | .9945     | .8718     | .8154     | .8593     | .788      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

RAVER S/DIVISION.[248] BU 0655

Substation No/ Name :- 124094 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV AJNAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 1.7304    | 2.0119    | 1.9004    | 1.8254    | 1.8945    | 1.8107    |
| Max  | 1.7304    | 2.0119    | 1.9004    | 1.8254    | 1.8945    | 1.8107    |
| Min  | 1.7304    | 2.0119    | 1.9004    | 1.8254    | 1.8945    | 1.8107    |
| Avg  | 1.7304    | 2.0119    | 1.9004    | 1.8254    | 1.8945    | 1.8107    |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124059 / 33/11 KV CHINAWAL

Feeder No / Name : 201 / 11 KV SAWKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.2862    | 2.1948    | 2.0424    | 2.4577    | 2.4082    | 2.4577    | 2.332     |
| 2    | 2.572     | 2.1948    | 1.9814    | 2.4577    | 2.4082    | 2.4577    | 2.3167    |
| 3    | 2.572     | 2.1795    | 1.9662    | 2.4577    | 2.2862    | 2.4577    | 2.3167    |
| 4    | 2.2558    | 2.1795    | 1.9509    | 2.3922    | 2.2862    | 2.4577    | 2.3167    |
| 5    | 2.271     | 2.21      | 1.9357    | 2.3922    | 2.21      | 2.4577    | 2.3167    |
| 6    | 2.2558    | 2.2862    | 2.0271    | 2.4249    | 2.2253    | 2.5232    | 2.332     |
| 7    | 2.2862    | 2.2405    | 1.9966    | 2.4577    | 2.3167    | 2.5396    | 2.3929    |
| 8    | 2.1491    | 2.2558    | 2.5789    | 2.4577    | 2.1948    | 2.5724    | 2.271     |
| 9    | 2.1643    | 2.271     | 2.3594    | 2.4577    | 2.3758    | 2.4387    | 2.271     |
| 10   | 2.1643    | 2.2405    | 2.2939    | 2.2862    | 2.4249    | 2.3624    | 2.2558    |
| 11   |           | 2.2405    |           |           |           |           |           |
| Max  | 2.572     | 2.2862    | 2.5789    | 2.4577    | 2.4249    | 2.5724    | 2.3929    |
| Min  | 2.1491    | 2.1795    | 1.9357    | 2.2862    | 2.1948    | 2.3624    | 2.2558    |
| Avg  | 2.2977    | 2.2266    | 2.1133    | 2.4242    | 2.3136    | 2.4725    | 2.3122    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124059 / 33/11 KV CHINAWAL

Feeder No / Name : 202 / 11 KV WAGHODA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   | 1.4327    | 1.4632    | 1.4746    | 1.5851    | 1.5074    | 1.5242    | 1.4327    |
| 12   | 1.5242    | 1.3717    | 1.4746    | 1.7833    | 1.7368    | 1.4632    | 1.4327    |
| 13   | 1.5242    | 1.2498    | 1.5074    | 1.8176    | 1.6057    | 1.5394    | 1.5242    |
| 14   | 1.4632    | 1.3108    | 1.5074    | 1.8176    | 1.7695    | 1.5242    | 1.4327    |
| 15   | 1.4632    |           | 1.4746    | 1.7147    | 1.704     | 1.5394    | 1.3717    |
| 16   | 1.4937    |           |           | 1.4022    | 1.5402    | 1.5394    | 1.4327    |
| 17   | 1.4784    |           | 1.5402    | 1.3717    |           | 1.5089    | 1.4327    |
| 18   | 1.4022    |           | 1.5074    | 1.3717    | 1.5402    | 1.448     | 1.4937    |
| 19   |           |           |           |           |           |           | 1.4937    |
| Max  | 1.5242    | 1.4632    | 1.5402    | 1.8176    | 1.7695    | 1.5394    | 1.5242    |
| Min  | 1.4022    | 1.2498    | 1.4746    | 1.3717    | 1.5074    | 1.448     | 1.3717    |
| Avg  | 1.4727    | 1.3489    | 1.4980    | 1.6080    | 1.6291    | 1.5108    | 1.4496    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124059 / 33/11 KV CHINAWAL

Feeder No / Name : 204 / 11 KV CHINAWAL II Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .823      | .7888     | .823      | .8779     | .823      | .8779     | .8745     |
| 2    | .823      | .7888     | .823      | .8779     | .823      | .8779     | .8745     |
| 3    | .8573     | .8573     | .9145     | .9145     | .8573     | .9145     | .9431     |
| 4    | 1.0631    | 1.0288    | 1.0791    | 1.134     | 1.0631    | 1.134     | 1.0288    |
| 5    | 1.2517    | 1.2003    | 1.3717    | 1.39      | 1.286     | 1.3352    | 1.2346    |
| 6    | 1.4918    | 1.4575    | 1.4998    | 1.701     | 1.5261    | 1.5729    | 1.4746    |
| 7    | 1.286     | 1.2517    | 1.2437    | 1.267     | 1.2346    | 1.39      | 1.2517    |
| 8    | 1.0802    | .9431     | 1.0608    | 1.0974    | .9774     | 1.0802    | 1.046     |
| 9    | 1.046     | 1.0059    | 1.0425    | 1.0059    | .9511     | .9602     | 1.0608    |
| 10   | .9602     | .9511     | 1.0242    | .8745     | .9877     | 1.0288    | 1.0242    |
| 11   | .823      | .8962     | .9145     | .7716     | .8779     | .8916     | .9145     |
| 12   | .7716     | .7682     | .8413     | .7545     | .823      | .8402     | .823      |
| 13   | .7545     | .7682     | .8413     | .7373     | .7499     | .7888     | .7865     |
| 14   | .7716     | .7682     | .8048     | .7716     | .8048     | .7716     | .7865     |
| 15   | .8402     | .8048     | .9145     | .823      | .8413     | .8059     | .8779     |
| 16   | .8402     | .8596     | .9511     | .8059     | .8779     | .9431     | .9145     |
| 17   | .9431     |           | .9511     | 1.0631    |           | .9945     | .9877     |
| 18   | 1.0974    | 1.39      | 1.0242    | 1.1145    | 1.134     | 1.1145    | .945      |
| 19   | 1.166     | 1.4632    | 1.4266    | 1.2174    | 1.3352    | 1.3032    | 1.2986    |
| 20   | 1.0288    | 1.2071    | 1.2071    | 1.1317    | 1.2437    | 1.166     | 1.1523    |
| 21   | .9945     | 1.0791    | 1.0974    | 1.0802    | 1.134     | 1.0974    | 1.0608    |
| 22   | .9602     | 1.0059    | 1.0974    | 1.0117    |           |           | 1.0242    |
| 23   |           | .9328     |           | .9259     | 1.0059    |           | .9877     |
| 24   | .8745     | .8402     | .8962     | .9511     | .8745     | .9511     | .9259     |
| Max  | 1.4918    | 1.4632    | 1.4998    | 1.701     | 1.5261    | 1.5729    | 1.4746    |
| Min  | .7545     | .7682     | .8048     | .7373     | .7499     | .7716     | .7865     |
| Avg  | .9803     | 1.0025    | 1.0369    | 1.0125    | 1.0105    | 1.0382    | 1.0124    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124059 / 33/11 KV CHINAWAL

Feeder No / Name : 207 / 11 kv Waghoda village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6001     | .6173     | .6584     | .6584     | .6344     | .695      | .6173     |
| 2    | .6001     | .6173     | 3.7677    | .6584     | .6344     | .695      | .6173     |
| 3    | .6516     | .6859     | .7316     | .695      | .6859     | .7316     | .6859     |
| 4    | .7716     | .7716     | .823      | .8048     | .9602     | 1.0242    | .9431     |
| 5    | .9602     | .9431     | 1.1523    | .9877     | 1.0974    | 1.1706    | 1.0802    |
| 6    | 1.2003    | 1.2003    | 1.3535    | 1.2254    | 1.2003    | 1.3352    | 1.2003    |
| 7    | 1.1488    | 1.0631    | 1.1706    | 1.0242    | 1.0974    | 1.1706    | 1.0288    |
| 8    | .9088     | .9088     | .8779     | .8779     | .8059     | .9145     | .8059     |
| 9    | .8402     | .8048     | .823      | .7682     | .7133     | .7545     | .7499     |
| 10   | .6516     | .7316     | .7316     | .7373     | .695      | .6859     | .7316     |
| 11   | .6001     | .695      | .6401     | .5316     | .6401     |           | .6584     |
| 12   | .5658     | .695      | .5571     | .6001     | .5487     |           | .5853     |
| 13   | .4973     | .6036     | .5853     | .5487     | .5853     | .6516     | .5853     |
| 14   | .4973     | .6584     |           | .4973     | .6036     | .5487     | .6036     |
| 15   | .5487     | .6584     | .5853     | .583      | .6401     | .5316     | .6036     |
| 16   | .5144     | .6584     | .6219     | .6173     | .6401     | .5658     | .6584     |
| 17   | .5658     |           | .6584     | .6859     |           | .5658     | .695      |
| 18   | .6344     | .8413     | .7682     | .8059     | .8048     | .6859     | .6554     |
| 19   | .9259     | 1.0242    | .9511     | .8916     | .9511     | .9431     | .9694     |
| 20   | .8573     | .9328     | .8779     | .823      | .9145     | .8745     | .8962     |
| 21   | .823      | .8779     | .8779     | .8059     | .8413     | .8059     | .8779     |
| 22   | .7888     | .823      | .8048     | .7716     |           |           | .8596     |
| 23   |           | .7682     |           | .703      | .7682     |           | .7682     |
| 24   | .6516     | .6516     | .695      | .7682     | .6516     | .695      | .6687     |
| Max  | 1.2003    | 1.2003    | 3.7677    | 1.2254    | 1.2003    | 1.3352    | 1.2003    |
| Min  | .4973     | .6036     | .5571     | .4973     | .5487     | .5316     | .5853     |
| Avg  | .7306     | .7927     | .9415     | .7529     | .7779     | .8023     | .7727     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124059 / 33/11 KV CHINAWAL

Feeder No / Name : 209 / 11 KV CHINAWAL-III

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 13-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 11   | 1.2955    |
| 12   | 1.2955    |
| 13   | 1.4022    |
| 14   | 1.4175    |
| 15   | 1.387     |
| 16   | 1.4175    |
| 17   | 1.4327    |
| 18   | 1.4327    |
| Max  | 1.4327    |
| Min  | 1.2955    |
| Avg  | 1.3851    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 201 / 11 KV SAWKHEDA AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.7892    | 2.9721    |           |           | 2.8349    | 3.0178    |
| 5    | 2.713     |           |           | 2.8045    | 2.5606    |           |           |
| 6    |           |           |           |           |           | 2.713     |           |
| 7    |           | 2.7587    | 2.7892    |           | 2.6063    |           | 2.8807    |
| 8    | 2.9111    |           |           | 2.6825    |           |           |           |
| 9    |           |           |           | 2.6825    |           |           | 2.9111    |
| 10   | 2.6673    | 2.8959    | 2.713     |           | 2.9416    | 2.9874    |           |
| Max  | 2.9111    | 2.8959    | 2.9721    | 2.8045    | 2.9416    | 2.9874    | 3.0178    |
| Min  | 2.6673    | 2.7587    | 2.713     | 2.6825    | 2.5606    | 2.713     | 2.8807    |
| Avg  | 2.7638    | 2.8146    | 2.8248    | 2.7232    | 2.7028    | 2.8451    | 2.9365    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 202 / 11 KV Chinchati-Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | 2.3167    | 2.3777    |           | 2.2862    | 2.4234    | 2.2862    | 2.2558    |
| 13   |           |           | 2.1491    |           |           |           |           |
| 14   |           | 1.9966    |           |           |           | 1.8442    |           |
| 15   | 1.8747    |           |           | 1.8595    | 1.7528    |           | 1.6461    |
| 16   |           |           | 1.7223    |           |           |           |           |
| 17   | 1.7071    | 1.9052    | 1.7833    | 1.9662    | 2.0271    | 1.9052    | 1.7071    |
| Max  | 2.3167    | 2.3777    | 2.1491    | 2.2862    | 2.4234    | 2.2862    | 2.2558    |
| Min  | 1.7071    | 1.9052    | 1.7223    | 1.8595    | 1.7528    | 1.8442    | 1.6461    |
| Avg  | 1.9662    | 2.0932    | 1.8849    | 2.0373    | 2.0678    | 2.0119    | 1.8697    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 203 / 11 KV KALMODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.768     | 1.5699    |           |           | 1.7833    | 1.6613    |
| 5    | 1.1888    |           |           | 1.1888    | 1.2041    |           |           |
| 6    |           |           |           |           |           | 1.2651    |           |
| 7    |           | 1.3717    | 1.326     |           | 1.2803    |           | 1.3565    |
| 8    | 1.387     |           |           | 1.4784    |           |           |           |
| 9    |           |           |           | 1.4022    |           |           | 1.448     |
| 10   | 1.2955    | 1.0669    | 1.5699    |           | 1.2803    | 1.3717    |           |
| 12   | .3601     | .3086     |           | .4115     | .3772     | .3258     | .3429     |
| 13   |           |           | .3601     |           |           |           |           |
| 14   |           | .3258     |           |           |           | .3429     |           |
| 15   | .3601     |           |           | .3772     | .3944     |           | .3429     |
| 16   |           |           | .3772     |           |           |           |           |
| 17   | .4115     | .3601     | .463      | .3944     | .3944     | .4115     | .3772     |
| 19   | .6687     | .6344     | .5144     | .6516     | .6001     | .583      | .6173     |
| 21   | .4458     | .4973     | .4287     | .4458     | .4801     | .463      |           |
| 23   |           |           |           |           |           |           | .4287     |
| 24   | .3944     | .3944     | .3944     | .6344     | .3944     | .4115     | .3944     |
| Max  | 1.387     | 1.768     | 1.5699    | 1.4784    | 1.2803    | 1.7833    | 1.6613    |
| Min  | .3601     | .3086     | .3601     | .3772     | .3772     | .3258     | .3429     |
| Avg  | .7235     | .7475     | .7782     | .7760     | .7117     | .7731     | .7744     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 204 / 11 kv ROZODA -AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | 1.7375    | 2.0271    |           | 1.89      | 2.1033    | 2.0729    | 1.9509    |
| 13   |           |           | 1.9204    |           |           |           |           |
| 14   |           |           |           |           |           | 1.8595    |           |
| 15   | 1.6613    |           |           | 1.829     | 1.9052    |           | 1.7375    |
| 16   |           | 1.7528    | 1.8442    |           |           |           |           |
| 17   | 1.768     | 1.7528    | 1.8595    | 1.8595    | 1.9357    | 1.6461    | 1.7985    |
| Max  | 1.768     | 2.0271    | 1.9204    | 1.89      | 2.1033    | 2.0729    | 1.9509    |
| Min  | 1.6613    | 1.7528    | 1.8442    | 1.829     | 1.9052    | 1.6461    | 1.7375    |
| Avg  | 1.7223    | 1.8442    | 1.8747    | 1.8595    | 1.9814    | 1.8595    | 1.8290    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 205 / 11 KV SAWKHEDA-I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.326     | 1.3108    |           |           | 1.3108    | 1.3413    |
| 5    | 1.448     |           |           | 1.4784    | 1.2193    |           |           |
| 6    |           |           |           |           |           | 1.4937    |           |
| 7    |           | 1.6975    | 1.5546    |           | 1.3717    |           | 1.3565    |
| 8    | 1.5089    |           |           | 1.326     |           |           |           |
| 9    |           |           |           | 1.3108    |           |           | 1.2651    |
| 10   | 1.2498    | 1.2651    | 1.2803    |           | 1.2498    | 1.2803    |           |
| 12   | .4115     | .3601     |           | .4458     | .5144     | .463      | .4973     |
| 14   |           | .4287     |           |           |           | .4801     |           |
| 15   | .4801     |           |           | .4115     | .4973     |           | .4801     |
| 16   |           |           | .5144     |           |           |           |           |
| 17   | .5658     | .5316     | .6001     | .7888     | .5658     | .583      | .5487     |
| 19   | .9945     | .8745     | .9259     | 1.0288    | .9945     | .9259     | .9602     |
| 21   | .7888     | .7716     | .6344     | .7888     | .7716     | .7373     |           |
| 23   |           |           |           |           |           |           | .6001     |
| 24   | .583      | .5658     | .5487     | .583      | .583      | .5658     | .583      |
| Max  | 1.5089    | 1.6975    | 1.5546    | 1.4784    | 1.3717    | 1.4937    | 1.3565    |
| Min  | .4115     | .3601     | .5144     | .4115     | .4973     | .463      | .4801     |
| Avg  | .8923     | .8690     | .9212     | .9069     | .8630     | .8711     | .8480     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 206 / 11 KV ROZODA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6001     | .5487     |           |           | .5316     | .5144     |
| 5    | 1.2174    |           |           | 1.2346    | 1.2174    |           |           |
| 6    |           |           |           |           |           | 1.3203    |           |
| 7    |           | 1.1145    | 1.1317    |           | 1.0631    |           | .9602     |
| 8    | .9259     |           |           | .8402     |           |           |           |
| 9    |           |           |           | .6859     |           |           | .7545     |
| 10   | .6516     | .5316     | .6001     |           | .5487     | .6001     |           |
| 12   | .463      | .4973     |           | .463      | .4458     | .5144     | .2229     |
| 13   |           |           | .4973     |           |           |           |           |
| 14   |           | .4801     |           |           |           | .4973     |           |
| 15   | .5316     |           |           | .4801     | .4801     |           | .583      |
| 16   |           |           | .583      |           |           |           |           |
| 17   | .6001     | .6173     |           | .6173     | .6001     | .6173     | .583      |
| 19   | .9431     | .8916     | .9259     | .8916     | .8916     | .8745     | .9431     |
| 21   | .7202     | .703      | .6859     | .7202     | .7716     | .7202     |           |
| 23   |           |           |           |           |           |           | .6173     |
| 24   | .5487     | .5487     | .5658     | .5487     | .5316     | .5658     | .5658     |
| Max  | 1.2174    | 1.1145    | 1.1317    | 1.2346    | 1.2174    | 1.3203    | .9602     |
| Min  | .463      | .4801     | .4973     | .463      | .4458     | .4973     | .2229     |
| Avg  | .7335     | .6649     | .6923     | .7202     | .7278     | .6935     | .6382     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124060 / 33/11 KV KHIRODA

Feeder No / Name : 208 / 11 KV KHIRODA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3086     | .2743     |           |           | .2743     | .2743     |
| 5    | .5316     |           |           | .5316     | .5316     |           |           |
| 6    |           |           |           |           |           | .583      |           |
| 7    |           | .4973     | .4801     |           | .4801     |           | .4801     |
| 8    | .3944     |           |           | .3601     |           |           |           |
| 9    |           |           |           | .3086     |           |           | .3086     |
| 10   | .3086     | .2572     |           |           | .2572     | .2572     |           |
| 12   | .1715     | .1886     |           | .2572     | .1886     | .2058     | .2401     |
| 13   |           |           | .2401     |           |           |           |           |
| 14   |           | .2229     |           |           |           | .2229     |           |
| 15   | .2401     |           |           | .2401     | .2572     |           | .2229     |
| 16   |           |           | .2401     |           |           |           |           |
| 17   | .2915     | .2915     | .2743     | .2915     | .2743     | .2915     | .2743     |
| 19   | .4115     | .4115     | .4115     | .463      | .3944     | .3944     | .4115     |
| 21   | .3429     | .3601     | .5144     | .3772     | .3944     | .3601     |           |
| 22   |           | .3258     |           |           |           |           |           |
| 23   |           |           |           |           |           |           | .3258     |
| 24   | .2915     | .2743     | .2915     | .3258     | .2915     | .3086     | .2915     |
| Max  | .5316     | .4973     | .5144     | .5316     | .5316     | .583      | .4801     |
| Min  | .1715     | .1886     | .2401     | .2401     | .1886     | .2058     | .2229     |
| Avg  | .3315     | .3138     | .3408     | .3506     | .3410     | .3220     | .3143     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124107 / 33/11 KV GAURKHEDA

Feeder No / Name : 203 / 11 KV LOHARA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6173     | .6001     |           | .6173     | .6344     |           | .6344     |
| 2    |           | .6348     | .5658     |           | .6722     | .583      |           |
| 3    | .7202     |           |           | .6859     |           |           | .703      |
| 4    | .7888     |           | .7716     | .7545     |           | .7202     | .7888     |
| 5    | .9945     | .9602     |           | .9945     | 1.0269    |           | .9259     |
| 6    | 1.0802    | 1.1888    | 1.0288    | 1.0974    | 1.1088    | .9945     | 1.0974    |
| 7    | .8573     | .9774     | .9088     | .8402     | .961      | .9431     | .8916     |
| 8    | .8059     | .8215     | .7373     | .7888     | .7947     | .7888     | .8402     |
| 9    |           |           |           |           | .6859     |           |           |
| 10   | .7282     | .583      | .6344     | .6722     |           | .6859     | .6516     |
| 11   | .6173     | .5144     | .5487     | .6161     | .6001     | .583      | .6173     |
| 12   | .5487     |           | .4973     | .5788     |           | .5144     | .5359     |
| 13   | .5658     | .4458     | 2.9835    | .5487     | .4287     | .5316     | .543      |
| 14   | .5914     |           |           | .5658     | .5487     |           | .6036     |
| 15   | .6154     | .4973     | .6001     | .6173     | .6001     | .5487     | .6219     |
| 16   | .6722     |           | .6344     | .7023     | .6173     | .6344     | .6584     |
| 17   | .695      |           | .6173     | .7202     |           | .6516     | .6878     |
| 18   | .7499     |           | .7373     | .8501     |           | .6859     | .7265     |
| 19   | .8402     | .8916     | .8402     |           | .8573     | .8402     | .8326     |
| 20   | .8402     |           | .7545     | .7762     | .7716     | .703      | .8215     |
| 21   | .7202     | .7373     |           |           |           |           |           |
| 22   |           | .7202     | .6516     | .7133     | .703      |           | .7602     |
| 23   | .6001     |           |           | .695      |           |           |           |
| 24   | .5658     |           | .6516     | .6584     |           | .6173     | .6516     |
| Max  | 1.0802    | 1.1888    | 2.9835    | 1.0974    | 1.1088    | .9945     | 1.0974    |
| Min  | .5487     | .4458     | .4973     | .5487     | .4287     | .5144     | .5359     |
| Avg  | .7245     | .7363     | .8331     | .7247     | .7340     | .6891     | .7297     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124107 / 33/11 KV GAURKHEDA

Feeder No / Name : 204 / 11 KV FAIZPUR WATER SUPPLY NON SHEDDABLE WATER SUPPLY AND  
EX Feeder KV- 11 / OUTGOING UTILITY

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     | .0762     |           | .0857     | .0762     |           | .0857     |
| 2    |           | .0848     | .0857     |           | .0848     | .0857     |           |
| 3    | .0857     |           |           | .0857     |           |           | .0857     |
| 4    | .0857     |           | .0857     | .0857     |           | .0857     | .0857     |
| 5    | .0857     | .0819     |           | .0857     | .0848     |           | .0857     |
| 6    | .0857     | .0819     | .0857     | .0857     | .0819     | .0857     | .0857     |
| 7    | .0857     | .0819     | .0857     | .0857     | .0819     |           | .0857     |
| 8    | .0857     | .0819     | .0857     | .0857     | .0791     | .0857     | .0857     |
| 9    |           |           |           |           | .0857     |           |           |
| 10   | .0762     | .0857     | .0857     | .0762     |           | .0857     | .0762     |
| 11   | .0848     | .0857     | .0857     | .0762     | .0857     | .0857     | .0848     |
| 12   |           |           | .0857     | .0819     |           | .0857     | .0819     |
| 13   |           | .0857     | .0857     | .0848     | .0857     | .0857     | .0848     |
| 14   |           |           |           | .0819     | .0857     |           | .0829     |
| 15   |           | .0857     | .0857     | .0819     | .0857     | .0857     | .081      |
| 16   |           |           | .0857     | .0848     | .0857     | .0857     | .0819     |
| 17   |           |           | .0857     | .0819     |           | .0857     | .0829     |
| 18   |           |           | .0857     | .0819     |           | .0857     | .0819     |
| 19   | .0848     | .0857     | .0857     | .0819     | .0857     | .0857     | .0819     |
| 20   | .0762     |           | .0857     | .0829     | .0857     | .0857     | .0762     |
| 21   | .0762     | .0857     |           |           |           |           |           |
| 22   |           | .0857     | .0857     | .0848     | .0857     | .0857     | .0762     |
| 23   | .0762     |           |           | .0848     |           |           | .0762     |
| 24   | .0848     |           | .0857     | .0848     |           | .0857     | .0848     |
| Max  | .0857     | .0857     | .0857     | .0857     | .0857     | .0857     | .0857     |
| Min  | .0762     | .0762     | .0857     | .0762     | .0762     | .0857     | .0762     |
| Avg  | .0828     | .0837     | .0857     | .0834     | .084      | .0857     | .0825     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124115 / 33/11 KV SINGAT

Feeder No / Name : 201 / 11 KV SINGAT VILLAGE  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           | .882      |
| 7    | .6852     |           | .6415     | .7778     |
| 10   |           |           | .4371     |           |
| 14   |           |           | .2798     |           |
| 15   |           | .3145     |           |           |
| 16   |           | .3889     |           |           |
| 18   |           |           | .6626     |           |
| 21   |           | .4412     | .4316     |           |
| 22   |           | .3677     |           |           |
| Max  | .6852     | .4412     | .6626     | .882      |
| Min  | .6852     | .3145     | .2798     | .7778     |
| Avg  | .6852     | .3781     | .4905     | .8299     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

SAVADA SUB DIVISION.[249] BU 0663

Substation No/ Name :- 124115 / 33/11 KV SINGAT

Feeder No / Name : 202 / 11 KV PURI-GOLWADE -AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 08-APR-18 | 11-APR-18 | 12-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.2003    |           | 1.3373    |
| 7    | 1.2323    |           | 1.4155    |
| 10   |           | 1.3117    |           |
| Max  | 1.2323    | 1.3117    | 1.4155    |
| Min  | 1.2003    | 1.3117    | 1.3373    |
| Avg  | 1.2163    | 1.3117    | 1.3764    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 201 / 11 KV SAKLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.5692    | 2.6968    | 2.4577    | 1.9185    | 1.9313    |           | 2.0995    |
| 2    | 2.5692    | 2.7149    | 2.4577    | 1.9004    | 1.8959    |           | 1.9909    |
| 3    | 2.5337    | 2.7149    | 2.4741    | 1.8099    | 1.825     |           | 1.9909    |
| 4    | 2.516     | 2.7149    | 2.4905    | 1.8099    | 1.7718    |           | 1.9004    |
| 5    | 2.4983    | 2.7511    | 2.5069    | 1.7737    | 1.7541    |           | 1.8099    |
| 6    | 2.4629    | 2.7692    | 2.5232    | 1.7375    | 1.7896    |           | 1.647     |
| 7    | 2.5514    | 2.7873    | 2.5396    | 1.9909    | 1.9136    |           | 1.8099    |
| 8    | 2.7995    | 2.7692    | 2.3922    | 2.0271    | 2.0553    | 2.0271    | 2.0452    |
| 9    | 2.6787    | 2.5069    | 2.6968    | 2.0022    |           | 2.0633    | 1.9845    |
| 10   | 2.6606    | 2.5069    | 2.6606    | 2.0022    |           | 1.9909    | 1.8781    |
| 11   |           | 2.1136    | 2.2986    | 2.7995    | 3.0045    | 3.1131    | 3.0298    |
| 12   |           | 2.1628    | 2.3348    | 2.7641    | 2.9864    | 3.0588    | 3.0298    |
| 13   |           | 2.1956    | 2.1357    | 2.9767    | 3.0226    | 3.0588    | 2.959     |
| 14   |           | 2.1464    | 2.1176    | 2.9058    | 3.0769    | 2.9502    | 2.9058    |
| 15   |           | 2.0972    | 1.9909    | 2.7818    | 3.0769    | 2.9864    | 2.8881    |
| 16   |           | 2.0317    |           | 2.9944    | 3.0407    | 2.9321    | 2.7286    |
| 17   |           | 1.9498    | 2.0271    | 2.9412    | 2.9864    | 2.9683    | 2.7641    |
| 18   |           | 1.8842    | 2.0452    | 2.9412    | 2.8235    | 2.9321    | 2.6932    |
| Max  | 2.7995    | 2.7873    | 2.6968    | 2.9944    | 3.0769    | 3.1131    | 3.0298    |
| Min  | 2.4629    | 1.8842    | 1.9909    | 1.7375    | 1.7541    | 1.9909    | 1.647     |
| Avg  | 2.5840    | 2.4174    | 2.3617    | 2.3376    | 2.4347    | 2.7346    | 2.3419    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 202 / 11 KV MUNJOBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.8099    | 2.0022    | 1.8823    | 1.8099    |
| 2    |           |           |           | 1.6289    | 1.9667    | 1.8099    | 1.8099    |
| 3    |           |           |           | 1.6289    | 1.825     | 1.8099    | 1.8099    |
| 4    |           |           |           | 1.6651    | 1.6478    | 1.7556    | 1.6289    |
| 5    |           |           |           | 1.5927    | 1.6124    | 1.7556    | 1.6289    |
| 6    |           |           |           | 1.5927    | 1.5592    | 1.7375    | 1.6289    |
| 7    |           |           |           | 1.7013    | 1.6832    | 1.7194    | 1.6289    |
| 8    |           |           |           | 1.8099    | 1.7718    | 3.5112    | 1.6651    |
| 9    |           |           |           | 1.7364    | 1.828     | 1.6651    | 1.6478    |
| 10   |           |           |           | 1.8604    | 1.8099    |           | 1.701     |
| 11   | 1.9909    | 1.7368    | 2.0814    |           |           |           |           |
| 12   | 2.0452    | 1.5729    | 2.0452    |           |           |           |           |
| 13   | 2.009     | 1.5402    | 1.9909    |           |           |           |           |
| 14   | 1.9185    | 1.5074    | 1.9909    |           |           |           |           |
| 15   | 1.828     | 1.4746    | 1.8099    |           |           |           |           |
| 16   | 1.7375    | 1.4746    | 1.8099    |           |           |           |           |
| 17   |           | 1.5074    | 1.8099    |           |           |           |           |
| 18   | 1.7375    | 1.5565    | 1.8099    |           |           |           |           |
| Max  | 2.0452    | 1.7368    | 2.0814    | 1.8604    | 2.0022    | 3.5112    | 1.8099    |
| Min  | 1.7375    | 1.4746    | 1.8099    | 1.5927    | 1.5592    | 1.6651    | 1.6289    |
| Avg  | 1.8952    | 1.5463    | 1.9185    | 1.7026    | 1.7706    | 1.9607    | 1.6959    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 203 / 11 KV CHUNCHALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.2425    | 3.1493    | 2.8673    |           |           |           |           |
| 2    | 3.207     | 3.1493    | 2.8346    |           |           |           |           |
| 3    | 2.0645    | 3.1493    | 2.8018    |           |           |           |           |
| 4    | 2.9944    | 3.1312    | 2.7526    |           |           |           |           |
| 5    | 2.8172    | 3.1493    | 2.7199    |           |           |           |           |
| 6    | 3.0298    | 3.1674    | 2.769     |           |           |           |           |
| 7    | 2.9412    |           | 2.769     |           |           |           |           |
| 8    | 2.7995    |           | 2.5724    |           |           |           |           |
| 9    | 3.0226    |           | 2.7149    |           |           |           |           |
| 10   | 2.9321    |           | 2.7149    |           |           |           |           |
| 11   |           |           |           | 3.3311    | 3.3484    | 3.4389    | 3.3665    |
| 12   |           |           |           | 3.207     | 3.3484    | 3.4389    | 3.5082    |
| 13   |           |           |           | 3.2779    | 3.3665    | 3.2579    | 3.4196    |
| 14   |           |           |           | 3.1893    | 3.3303    | 3.2579    | 3.3842    |
| 15   |           |           |           |           | 3.3665    | 3.2579    | 3.3665    |
| 16   |           |           |           | 3.2779    | 3.276     | 2.9864    | 3.2779    |
| 17   |           |           |           | 3.1361    | 3.2579    | 2.9683    | 3.3488    |
| 18   |           |           |           | 3.2779    | 3.2579    | 2.9321    | 3.1539    |
| 19   |           |           |           | 3.0476    |           |           |           |
| 23   |           | 2.8509    |           |           |           |           |           |
| 24   |           |           | 2.8673    |           |           |           |           |
| Max  | 3.2425    | 3.1674    | 2.8673    | 3.3311    | 3.3665    | 3.4389    | 3.5082    |
| Min  | 2.0645    | 2.8509    | 2.5724    | 3.0476    | 3.2579    | 2.9321    | 3.1539    |
| Avg  | 2.9051    | 3.1067    | 2.7622    | 3.2181    | 3.3190    | 3.1923    | 3.3532    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 204 / 11 KV SAKALI GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5847     | .5792     | .5571     | .6154     | .6556     | .6335     | .6335     |
| 2    | .5847     | .5973     | .5571     | .6154     | .6556     | .6335     | .6335     |
| 3    | .691      | .6335     | .5898     | .6335     | .7087     | .7059     | .6878     |
| 4    | .8328     | .8688     | .6882     | .8507     | .8328     | .8145     | .8326     |
| 5    | .9036     | 1.0317    | .7865     | 1.0136    | .9922     | 1.0498    | .8869     |
| 6    | 1.134     | 1.1584    | .9667     | 1.1765    | 1.134     | 1.1584    | .9955     |
| 7    | 1.0277    | 1.0136    | .9012     | 1.0498    | .9214     | .9412     | .8688     |
| 8    | .7973     | .7964     | .6718     | .7964     | .7442     | .7602     | .7602     |
| 9    | .7783     | .6882     | .6697     | .6733     | .6697     | .6878     | .6201     |
| 10   | .724      | .6554     | .724      | .691      |           | .7602     | .6733     |
| 11   | .6697     | .6226     | .6154     | .6201     | .7059     | .6697     | .7087     |
| 12   | .6154     | .5735     | .6154     | .567      | .6516     | .6516     | .7087     |
| 13   | .5792     | .5407     | .5792     | .567      | .5792     | .6154     | .6556     |
| 14   | .5973     | .5571     | .543      | .5493     | .5973     | .5973     | .6556     |
| 15   | .6154     | .5898     |           | .5493     | .6335     | .6154     | .6379     |
| 16   | .6335     | .6226     | .6154     | .567      | .6335     | .5973     | .6379     |
| 17   | .6154     | .6882     | .6335     | .6201     | .6516     | .6697     | .6733     |
| 18   | .6335     | .7701     | 1.0317    | .691      | .7964     | .7059     | .7442     |
| 19   | .8145     | .8848     | .905      | 1.0099    | .905      | .9774     | 1.0277    |
| 20   | .9593     | .8356     | .8145     | .8859     | .9955     | .8507     | .9391     |
| 21   | .8145     | .7865     | .8145     | .7973     | .8688     | .8688     | .8328     |
| 22   | .7602     | .7537     | .7964     | .7973     | .7964     | .7783     | .7442     |
| 23   | .7602     | .6718     | .7059     | .7619     | .7602     | .724      | .8505     |
| 24   | .567      | .7059     | .5898     | .6335     | .7087     | .6878     | .6516     |
| Max  | 1.134     | 1.1584    | 1.0317    | 1.1765    | 1.134     | 1.1584    | 1.0277    |
| Min  | .567      | .5407     | .543      | .5493     | .5792     | .5973     | .6201     |
| Avg  | .7372     | .7344     | .7118     | .7388     | .7651     | .7564     | .7525     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 205 / 11 KV CHUNCHALE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1949     | .2172     | .213      | .1991     | .2481     | .2534     | .1991     |
| 2    | .1949     | .2172     | .213      | .1991     | .2481     | .2534     | .1991     |
| 3    | .3189     | .2534     | .2458     | .2896     | .3189     | .2896     | .2534     |
| 4    | .4607     | .3801     | .3441     | .4163     | .4784     | .4887     | .4163     |
| 5    | .6733     | .6516     | .4424     | .6154     | .567      | .6154     | .5792     |
| 6    | .691      | .6154     | .5735     | .6878     | .691      | .6878     | .6154     |
| 7    | .7265     | .6335     | .5243     | .543      | .5316     | .5611     | .5249     |
| 8    | .6733     | .4096     | .4588     | .4163     | .4252     | .4344     | .3801     |
| 9    | .362      | .3277     | .3077     | .3012     | .3439     | .362      | .3721     |
| 10   | .2715     | .2622     | .2534     | .2658     | .2715     | .2896     | .3012     |
| 11   | .2172     | .213      | .2172     | .2303     | .2172     | .2715     | .2658     |
| 12   | .181      | .213      | .1991     | .2303     | .2353     | .2353     | .2126     |
| 13   | .1629     | .213      | .181      | .2303     | .2172     | .2172     | .1949     |
| 14   | .1629     | .213      | .181      | .2303     | .2172     | .1991     | .1949     |
| 15   | .181      | .213      | .1991     | .2126     | .2172     | .1991     | .1949     |
| 16   | .2172     | .213      | .181      | .2303     | .2172     | .2534     | .1949     |
| 17   |           | .2294     | .3258     | .2303     | .2353     | .2896     | .1949     |
| 18   | .3258     | .2785     | .3982     | .3012     | .2896     | .2896     | .3012     |
| 19   | .4887     | .3768     | .4887     | .443      | .4887     | .4344     | .4961     |
| 20   | .3982     | .3277     | .3439     | .3012     | .3982     | .4344     | .4252     |
| 21   | .3258     | .2949     | .9231     | .3012     | .3258     | .3439     | .3721     |
| 22   | .2715     | .2458     | .2715     | .2835     | .2715     | .3077     | .3012     |
| 23   | .2534     | .2294     | .2534     | .2658     | .2534     | .2534     | .2658     |
| 24   | .1949     | .2353     | .213      | .2353     | .2658     | .2534     | .2172     |
| Max  | .7265     | .6516     | .9231     | .6878     | .691      | .6878     | .6154     |
| Min  | .1629     | .213      | .181      | .1991     | .2172     | .1991     | .1949     |
| Avg  | .3455     | .3110     | .3313     | .3191     | .3322     | .3424     | .3197     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124049 / 33/11 KV SAKALI

Feeder No / Name : 207 / 11 KV SAIRAM GINNERS IND SHEDDABLE FEEDER HAVING WEEKLY  
FDR Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0181     |           |           | .0181     |
| 2    |           | .0181     | .0164     |           | .0181     |
| 3    |           | .0181     |           |           | .0181     |
| 4    |           | .0181     | .0164     |           |           |
| 5    |           | .0181     |           |           | .0181     |
| 6    |           | .0181     | .0164     |           | .0181     |
| 7    |           | .0181     | .0164     |           | .0181     |
| 8    |           | .0181     | .0164     |           | .0181     |
| 9    | .0181     |           |           | .0181     |           |
| 10   | .0181     | .0164     |           | .0181     |           |
| 11   | .0181     |           |           | .0181     |           |
| 12   | .0181     | .0164     |           | .0181     |           |
| 13   |           |           |           | .0181     |           |
| 14   | .0181     | .0164     |           | .0124     |           |
| 15   | .0181     |           |           | .0181     |           |
| 16   | .0181     | .0164     |           |           |           |
| 17   | .0181     |           |           |           |           |
| 18   | .0181     | .0164     |           | .0181     |           |
| 19   | .0181     |           |           | .0181     |           |
| 20   | .0181     | .0164     |           | .0181     |           |
| 21   | .0181     |           |           | .0181     |           |
| 22   | .0181     | .0164     |           | .0181     |           |
| 23   | .0187     | .0164     |           | .0181     |           |
| 24   |           |           | .0164     |           | .0181     |
| Max  | .0187     | .0181     | .0164     | .0181     | .0181     |
| Min  | .0181     | .0164     | .0164     | .0124     | .0181     |
| Avg  | .0181     | .0173     | .0164     | .0177     | .0181     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124050 / 33/11 KV KINGAON

Feeder No / Name : 201 / 11 KV DAMBHURNI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 10-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6461    | 1.6804    |           |
| 2    | 1.6804    | 1.6804    |           |
| 3    | 1.7147    | 1.6804    |           |
| 4    | 1.7147    | 1.749     |           |
| 5    | 1.749     | 1.7833    |           |
| 6    | 1.7833    | 1.9204    |           |
| 7    | 1.6804    | 2.0233    |           |
| 8    | 1.8176    |           |           |
| 9    | 1.8347    |           |           |
| 10   | 1.7147    |           |           |
| 11   |           |           | 2.8292    |
| 12   |           |           | 2.7092    |
| 13   |           |           | 2.5549    |
| 14   |           |           | 2.332     |
| 15   |           |           | 2.1948    |
| 16   |           |           | 1.9547    |
| 17   |           |           | 1.9547    |
| 18   |           |           | 1.9719    |
| Max  | 1.8347    | 2.0233    | 2.8292    |
| Min  | 1.6461    | 1.6804    | 1.9547    |
| Avg  | 1.7336    | 1.7882    | 2.3127    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124050 / 33/11 KV KINGAON

Feeder No / Name : 204 / 11 KV WAGHZIRA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 13-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    |           | 1.5432    |
| 2    |           | 1.5432    |
| 3    |           | 1.5775    |
| 4    |           | 1.6289    |
| 5    |           | 1.7147    |
| 6    |           | 1.9204    |
| 7    |           | 2.2291    |
| 8    |           | 2.3148    |
| 9    |           | 2.2977    |
| 10   |           | 2.2291    |
| 11   | 3.1722    |           |
| 12   | 3.0178    |           |
| 13   | 2.8121    |           |
| 14   | 2.572     |           |
| 15   | 2.4006    |           |
| 16   | 2.4863    |           |
| 17   | 2.5549    |           |
| 18   | 2.2291    |           |
| Max  | 3.1722    | 2.3148    |
| Min  | 2.2291    | 1.5432    |
| Avg  | 2.6556    | 1.8999    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124050 / 33/11 KV KINGAON

Feeder No / Name : 209 / 11 KV DAMBHURNI SHIVAR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 09-APR-18 | 10-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8861    | 1.9226    |           |
| 2    | 1.9204    | 1.9204    |           |
| 3    | 1.989     | 1.9547    |           |
| 4    | 2.0576    | 2.0233    |           |
| 5    | 2.0919    | 2.1481    |           |
| 6    | 2.1091    | 2.1434    |           |
| 7    | 2.0233    | 2.1776    |           |
| 8    | 2.0748    |           |           |
| 9    | 2.1091    |           |           |
| 10   | 2.1605    |           |           |
| 11   |           |           | 2.4691    |
| 12   |           |           | 2.4006    |
| 13   |           |           | 2.2462    |
| 14   |           |           | 2.1434    |
| 15   |           |           | 2.1948    |
| 16   |           |           | 2.2119    |
| 17   |           |           | 2.2291    |
| 18   |           |           | 2.2119    |
| Max  | 2.1605    | 2.1776    | 2.4691    |
| Min  | 1.8861    | 1.9204    | 2.1434    |
| Avg  | 2.0422    | 2.0414    | 2.2634    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124051 / 33/11 KV RAJORA

Feeder No / Name : 201 / 11 KV PIMPRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 2.0508    | 2.1338    | 2.0805    | 2.1643    |
| 2    |           |           |           | 2.1548    | 2.1643    | 2.0805    | 2.1491    |
| 3    |           |           |           | 2.1548    | 2.21      | 2.0805    | 2.1948    |
| 4    |           |           |           | 2.1399    | 2.2253    | 2.0805    | 2.1795    |
| 5    |           |           |           | 2.1399    | 2.2405    | 2.1102    | 2.1795    |
| 6    |           |           |           | 2.1399    | 2.2253    | 2.029     | 2.1948    |
| 7    |           |           |           | 2.1548    | 2.2558    | 2.4478    | 2.1948    |
| 8    |           |           |           | 2.3331    | 2.3015    | 2.4478    | 2.2253    |
| 9    |           |           |           | 2.1491    | 2.0576    | 2.3015    | 2.1845    |
| 10   |           |           |           | 2.1795    | 2.1102    | 2.3472    | 2.1845    |
| 11   | 2.2862    |           | 2.2588    |           |           |           |           |
| 12   | 2.4996    | 2.2291    | 2.2291    |           |           |           |           |
| 13   |           | 2.3777    | 2.2588    |           |           |           |           |
| 14   | 2.4996    | 2.4371    | 2.3034    |           |           |           |           |
| 15   | 2.4691    | 2.3777    | 2.3034    |           |           |           |           |
| 16   | 2.4371    | 2.7161    | 2.3182    |           |           |           |           |
| 17   | 2.4371    | 2.4074    | 2.3034    |           |           |           |           |
| 18   | 2.4074    | 2.4074    | 2.3034    |           |           |           |           |
| Max  | 2.4996    | 2.7161    | 2.3182    | 2.3331    | 2.3015    | 2.4478    | 2.2253    |
| Min  | 2.2862    | 2.2291    | 2.2291    | 2.0508    | 2.0576    | 2.029     | 2.1491    |
| Avg  | 2.4337    | 2.4218    | 2.2848    | 2.1597    | 2.1924    | 2.2006    | 2.1851    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124051 / 33/11 KV RAJORA

Feeder No / Name : 202 / 11 KV RAJORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6004    | 1.7375    | 1.8107    |           |           |           |           |
| 2    | 1.5851    | 1.768     | 1.749     |           |           |           |           |
| 3    | 1.6156    | 1.7071    | 1.7368    |           |           |           |           |
| 4    | 1.6309    | 1.6766    | 1.8107    |           |           |           |           |
| 5    | 1.6004    | 1.6766    | 1.7436    |           |           |           |           |
| 6    | 1.6156    | 1.6918    | 1.643     |           |           |           |           |
| 7    | 1.7528    | 1.7223    | 1.7101    |           |           |           |           |
| 8    | 1.89      | 1.8138    | 1.7101    |           |           |           |           |
| 9    | 1.8138    | 2.0119    | 1.5752    |           |           |           |           |
| 10   | 1.7223    | 2.0348    | 1.5901    |           |           |           |           |
| 11   |           |           |           | 1.9052    | 1.8138    |           | 1.6347    |
| 12   |           |           |           | 1.8442    | 1.8138    | 1.8442    | 1.6644    |
| 13   |           |           |           | 1.8138    | 1.9113    | 1.829     | 1.709     |
| 14   |           |           |           | 1.89      | 1.6049    | 1.6918    | 1.709     |
| 15   |           |           |           | 1.8747    | 1.7772    | 1.8138    | 1.709     |
| 16   |           |           |           | 1.9052    | 1.7101    | 1.829     | 1.7535    |
| 17   |           |           |           | 1.768     | 1.7101    | 1.8595    | 1.7535    |
| 18   |           |           |           | 1.7528    | 1.7772    | 1.7985    | 1.7684    |
| Max  | 1.89      | 2.0348    | 1.8107    | 1.9052    | 1.9113    | 1.8595    | 1.7684    |
| Min  | 1.5851    | 1.6766    | 1.5752    | 1.7528    | 1.6049    | 1.6918    | 1.6347    |
| Avg  | 1.6827    | 1.7840    | 1.7079    | 1.8442    | 1.7648    | 1.8094    | 1.7127    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124051 / 33/11 KV RAJORA

Feeder No / Name : 203 / 11 KV ANJALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3413    | 1.3108    | 1.4083    |           |           |           |           |
| 2    | 1.3108    | 1.2498    | 1.4083    |           |           |           |           |
| 3    | 1.2803    | 1.2346    | 1.4083    |           |           |           |           |
| 4    | 1.2955    | 1.2498    | 1.4083    |           |           |           |           |
| 5    | 1.2955    | 1.2193    | 1.3748    |           |           |           |           |
| 6    | 1.3108    | 1.2193    | 1.3748    |           |           |           |           |
| 7    | 1.3108    | 1.2498    | 1.3279    |           |           |           |           |
| 8    | 1.3413    | 1.3108    | 1.3748    |           |           |           |           |
| 9    | 1.3108    | 1.4419    | 1.2483    |           |           |           |           |
| 10   | 1.2803    | 1.4419    | 1.2483    |           |           |           |           |
| 11   |           |           |           | 1.387     | 1.643     |           | 1.5009    |
| 12   |           |           |           | 1.3717    | 1.6766    | 1.5089    | 1.5158    |
| 13   |           |           |           | 1.4632    | 1.6766    | 1.5851    | 1.5158    |
| 14   |           |           |           | 1.4937    | 1.6766    | 1.5242    | 1.5158    |
| 15   |           |           |           | 1.4632    | 1.6766    | 1.5242    | 1.4861    |
| 16   |           |           |           | 1.4784    | 1.576     | 1.5242    | 1.4266    |
| 17   |           |           |           | 1.4327    | 1.576     | 1.4632    | 1.3375    |
| 18   |           |           |           | 1.448     | 1.576     | 1.5089    | 1.3969    |
| Max  | 1.3413    | 1.4419    | 1.4083    | 1.4937    | 1.6766    | 1.5851    | 1.5158    |
| Min  | 1.2803    | 1.2193    | 1.2483    | 1.3717    | 1.576     | 1.4632    | 1.3375    |
| Avg  | 1.3077    | 1.2928    | 1.3582    | 1.4422    | 1.6347    | 1.5198    | 1.4619    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124051 / 33/11 KV RAJORA

Feeder No / Name : 204 / 11 KV RAJORA GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2439     | .2439     | .2591     | .2675     | .2743     | .3353     | .2896     |
| 2    | .2439     | .2439     | .2591     | .2675     | .2743     | .3353     | .2896     |
| 3    | .2743     | .2439     | .3018     | .3864     | .2743     | .3353     | .3048     |
| 4    | .381      | .3048     | .373      | .4458     | .3353     | .4024     | .4877     |
| 5    | .5639     | .5792     | .6154     | .6836     | .5792     | .6371     | .5792     |
| 6    | .7316     | .7773     | .8097     | .7727     | .7926     | .8383     | .7621     |
| 7    | .6401     | .6706     | .7209     | .6687     | .6859     | .7209     | .6401     |
| 8    | .5335     | .5182     | .5365     | .5201     | .5335     | .583      | .5944     |
| 9    | .3506     | .3688     | .3418     | .381      | .3506     | .3658     | .4161     |
| 10   | .3201     | .3353     | .3121     | .3353     | .3353     | .3506     | .3567     |
| 11   | .3048     |           | .2675     | .2743     | .3018     |           | .3121     |
| 12   | .2896     | .285      | .2675     | .2591     | .285      | .2743     | .2675     |
| 13   | .2591     | .2683     | .2675     | .2591     |           | .2743     | .2675     |
| 14   | .2591     | .2683     | .2526     | .2286     | .3239     | .2591     | .2526     |
| 15   | .3048     | .3185     | .2972     | .2743     |           | .2743     | .2972     |
| 16   | .3567     | .3353     | .3567     | .3048     | .4191     | .2743     | .3567     |
| 17   | .3864     | .4359     | .4161     | .381      | .4359     | .3506     | .3864     |
| 18   | .5053     | .5365     | .4755     | .4572     |           |           | .4755     |
| 19   | .639      | .6783     | .431      | .6401     |           | .5944     | .639      |
| 20   | .5639     | .5087     | .3864     | .5792     | .6371     | .5335     | .5647     |
| 21   | .4268     | .4239     | .3715     | .4268     | .503      | .503      | .4607     |
| 22   | .3353     | .3856     | .3864     | .381      | .4862     | .442      | .3715     |
| 23   | .3048     | .3239     | .3567     | .3048     | .3688     | .381      | .3269     |
| 24   | .3048     | .2743     | .3018     | .2675     | .2743     | .3353     | .3048     |
| Max  | .7316     | .7773     | .8097     | .7727     | .7926     | .8383     | .7621     |
| Min  | .2439     | .2439     | .2526     | .2286     | .2743     | .2591     | .2526     |
| Avg  | .3968     | .4056     | .3902     | .4069     | .4235     | .4273     | .4168     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124051 / 33/11 KV RAJORA

Feeder No / Name : 205 / 11 KV ANJALE GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3506     | .381      | .4024     | .3269     | .3658     | .4024     | .381      |
| 2    | .3658     | .3963     | .4024     | .3567     | .3658     | .4024     | .381      |
| 3    | .3506     | .3353     | .4024     | .3715     | .381      | .4359     | .4115     |
| 4    | .5182     | .5335     | .4694     | .4161     | .4268     | .4694     | .442      |
| 5    | .5944     | .6249     | .5441     | .535      | .5182     | .6036     | .5335     |
| 6    | .6401     | .6097     | .7042     | .639      | .6401     | .7042     | .6706     |
| 7    | .5487     | .4725     | .57       | .4607     | .503      | .5868     | .5335     |
| 8    | .4572     | .4268     | .4359     | .4012     | .4268     | .4024     | .4115     |
| 9    | .381      | .3521     | .3418     | .3201     | .3658     | .3658     | .3269     |
| 10   | .3201     | .3353     | .2675     | .3353     | .3185     | .3048     | .2824     |
| 11   | .3048     | .3353     | .3121     | .3048     | .3185     |           | .2972     |
| 12   | .3048     | .3353     | .2824     | .3201     | .285      | .1829     | .2972     |
| 13   | .3048     | .3353     | .3121     | .3048     | .2347     | .3048     | .3121     |
| 14   | .3201     | .3688     | .3418     | .3201     | .3185     | .3201     | .3121     |
| 15   | .3353     |           | .3567     | .3506     | .3688     | .3506     | .3567     |
| 16   | .3864     | .3725     | .3715     | .3201     | .3353     | .3353     | .3715     |
| 17   | .4161     | .4049     | .3864     | .3658     | .4024     | .381      | .3715     |
| 18   | .5201     | .4527     | .3864     | .4115     | .4359     |           | .4012     |
| 19   | .535      | .6203     | .4161     | .5335     | .57       | .5792     | .535      |
| 20   | .5639     | .5533     | .431      | .4572     | .57       | .4877     | .4755     |
| 21   | .4877     | .4862     | .4458     |           | .503      | .4725     | .4458     |
| 22   | .4572     | .4694     | .4458     | .4268     | .4694     | .4572     | .4458     |
| 23   | .4115     | .4359     | .4161     | .4115     | .4359     | .4572     | .431      |
| 24   | .3658     | .4115     | .4359     | .3269     | .4268     | .4024     | .4268     |
| Max  | .6401     | .6249     | .7042     | .639      | .6401     | .7042     | .6706     |
| Min  | .3048     | .3353     | .2675     | .3048     | .2347     | .1829     | .2824     |
| Avg  | .4267     | .4369     | .4117     | .3920     | .4161     | .4277     | .4106     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 201 / 11 KV DAHIGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.4196    |           |           |           |           |
| 6    |           | 2.0957    |           |           |           |           |
| 8    |           | 2.3815    | 2.3815    |           |           |           |
| 10   | 2.2862    | 2.3815    |           |           |           |           |
| 11   |           |           |           | 2.9531    | 2.8578    | 2.9531    |
| 12   |           |           |           |           |           | 2.8578    |
| 13   |           |           |           |           | 2.572     |           |
| 15   |           |           |           |           | 2.191     |           |
| 16   |           |           |           | 2.1719    |           |           |
| 18   |           |           |           | 2.2862    | 2.191     | 2.2862    |
| Max  | 2.2862    | 2.4196    | 2.3815    | 2.9531    | 2.8578    | 2.9531    |
| Min  | 2.2862    | 2.0957    | 2.3815    | 2.1719    | 2.191     | 2.2862    |
| Avg  | 2.2862    | 2.3196    | 2.3815    | 2.4704    | 2.4530    | 2.6990    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 202 / 11 KV SAVKHEDA ( 1 PHASING SINGLE PHASING  
) Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.1812    |           | 1.1812    | 1.1622    | 1.2193    |           |
| 7    |           |           |           | .9526     |           |           | .9526     |
| 8    |           | 1.4861    | 1.2384    |           | .743      |           | .7621     |
| 10   |           | 1.1431    |           |           |           |           | .6097     |
| 11   |           |           | .4572     |           | 1.7718    | 1.5242    |           |
| 12   |           |           |           |           |           | 1.3908    |           |
| 13   |           |           |           |           | 1.5051    |           |           |
| 15   | .5716     |           |           |           | 1.105     |           |           |
| 16   |           |           |           | 1.2574    |           |           |           |
| 17   |           |           | .6668     |           |           |           |           |
| 18   | .743      |           | .7621     |           | 1.2955    |           |           |
| 19   |           | .9526     |           |           |           | .8573     |           |
| 20   |           |           |           | .9907     | .9717     | 1.0479    |           |
| 22   | .8192     |           |           |           |           |           |           |
| 24   |           | .724      |           |           | .724      | .6859     |           |
| Max  | .8192     | 1.4861    | 1.2384    | 1.2574    | 1.7718    | 1.5242    | .9526     |
| Min  | .5716     | .724      | .4572     | .9526     | .724      | .6859     | .6097     |
| Avg  | .7113     | 1.0974    | .7811     | 1.0955    | 1.1598    | 1.1209    | .7748     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 203 / 11 KV HARIPURA ( 1 PHASING SINGLE PHASING  
) Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 1.3908    | 1.3336    |           |
| 6    |           |           |           | 1.3336    | 1.3146    | 1.4098    |           |
| 7    |           |           |           | 1.3336    |           |           | 1.5242    |
| 8    |           |           |           |           | 1.5813    |           | 1.4289    |
| 10   |           |           |           | 1.4289    | 1.4098    |           | 1.3527    |
| 11   | 1.5813    |           | 1.4861    |           |           |           |           |
| 12   |           |           | 1.3908    |           |           |           |           |
| 15   | 1.5051    |           |           |           |           |           |           |
| 17   |           |           | 1.4861    |           |           |           |           |
| 18   | 1.467     | 1.3336    | 1.4289    |           |           |           |           |
| Max  | 1.5813    | 1.3336    | 1.4861    | 1.4289    | 1.5813    | 1.4098    | 1.5242    |
| Min  | 1.467     | 1.3336    | 1.3908    | 1.3336    | 1.3146    | 1.3336    | 1.3527    |
| Avg  | 1.5178    | 1.3336    | 1.4480    | 1.3654    | 1.4241    | 1.3717    | 1.4353    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 205 / 11 KV KORPAWALI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | .8002     |           | .8383     | .6859     | .8192     |           |
| 7    |           |           |           | .6668     |           |           |           |
| 8    |           | .5716     | .5716     |           | .4382     |           | .5335     |
| 10   |           | .4382     |           | .4191     |           |           | .4001     |
| 11   | .4191     |           | .4191     |           | .381      | .4382     |           |
| 12   |           |           | .381      | .381      |           | .381      |           |
| 13   |           |           |           |           | .381      |           |           |
| 15   | .3239     |           |           |           | .362      |           |           |
| 16   |           |           |           | .4191     |           |           |           |
| 17   |           |           | .4572     |           |           |           |           |
| 18   | .4001     | .5716     | .5906     |           |           |           |           |
| 19   |           | .6668     |           |           |           | .6287     |           |
| 20   |           |           |           | .5716     | .5525     | .6097     |           |
| 22   | .4382     |           |           |           |           |           |           |
| 23   |           |           |           | .4191     |           |           |           |
| 24   |           | .4001     |           |           | .4001     | .4001     |           |
| Max  | .4382     | .8002     | .5906     | .8383     | .6859     | .8192     | .5335     |
| Min  | .3239     | .4001     | .381      | .381      | .362      | .381      | .4001     |
| Avg  | .3953     | .5748     | .4839     | .5307     | .4572     | .5462     | .4668     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 206 / 11 KV NAGADEVI 1 PH SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.448     |           |           |           |           |
| 6    |           | 1.2003    |           |           |           |           |
| 8    |           | 1.4289    | 1.2384    |           |           |           |
| 10   | 1.3717    | 1.3717    |           |           |           |           |
| 11   |           |           |           | 1.7528    | 1.6004    | 1.7147    |
| 12   |           |           |           |           |           | 1.7147    |
| 13   |           |           |           |           | 1.5242    |           |
| 15   |           |           |           |           | 1.3146    |           |
| 16   |           |           |           | 1.3146    |           |           |
| 18   |           |           |           | 1.4289    | 1.3527    |           |
| Max  | 1.3717    | 1.448     | 1.2384    | 1.7528    | 1.6004    | 1.7147    |
| Min  | 1.3717    | 1.2003    | 1.2384    | 1.3146    | 1.3146    | 1.7147    |
| Avg  | 1.3717    | 1.3622    | 1.2384    | 1.4988    | 1.4480    | 1.7147    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124052 / 33/11 KV DAHIGAON

Feeder No / Name : 207 / 11 kV Moharale 1 Ph SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | .8764     |           | 1.2193    | 1.2193    | 1.1812    |           |
| 7    |           |           |           | 1.3336    |           | 1.1812    |           |
| 8    |           | .6097     | .6097     |           | 1.1812    |           | 1.2384    |
| 10   |           | .3429     |           | 1.1431    |           |           | 1.105     |
| 11   | 1.2574    |           | 1.2955    |           | .4572     | .4191     |           |
| 12   |           |           | 1.2193    | .3048     |           | .2858     |           |
| 13   |           |           |           |           | .3048     |           |           |
| 15   |           |           |           |           | .3429     |           |           |
| 16   |           |           |           | .3429     |           |           |           |
| 17   |           |           | 1.1431    |           |           |           |           |
| 18   | 1.2193    | 1.2384    | 1.2955    |           | .5335     |           |           |
| 19   |           | .6668     |           |           |           | .7621     |           |
| 20   |           |           |           | .6097     | .6478     | .6668     |           |
| 22   | .381      |           |           |           |           |           |           |
| 23   |           |           |           | .3429     |           |           |           |
| 24   |           | .3429     |           |           | .3429     | .3429     |           |
| Max  | 1.2574    | 1.2384    | 1.2955    | 1.3336    | 1.2193    | 1.1812    | 1.2384    |
| Min  | .381      | .3429     | .6097     | .3048     | .3048     | .2858     | 1.105     |
| Avg  | .9526     | .6795     | 1.1126    | .7566     | .6287     | .6913     | 1.1717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 201 / 11 KV CHINCHOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4062     | .4854     | .3982     | .3593     | .3963     | .4668     | .4344     |
| 2    | .3906     | .4668     | .3982     | .3637     | .381      | .5041     | .4344     |
| 3    | .3658     | .5041     | .439      | .427      | .3658     | .5041     | .4755     |
| 4    | .4801     | .5788     |           | .5079     | .4115     | .5601     | .5175     |
| 5    | .5937     | .6535     | .7468     | .6036     | .5937     | .6838     | .7468     |
| 6    | .7042     | .8962     | .8589     | .7545     | .7362     | .8048     | .8589     |
| 7    | .6882     | .7468     | .7842     | .6274     | .5937     | .6722     | .7468     |
| 8    | .4999     | .6161     | .5228     | .4752     | .4115     | .5788     |           |
| 9    | .4572     | .5121     | .4424     |           | .4294     | .4755     | .4115     |
| 10   | .3475     | .4024     | .3906     | .3201     | .3734     | .7682     | .3658     |
| 11   | .3292     | .2926     | .2656     | .3048     | .3547     | .3982     | .3201     |
| 12   | .3109     | .2896     | .2656     | .2896     | .3361     | .362      | .3201     |
| 13   | .2772     | .2896     | .2623     | .3201     | .3361     | .3258     | .3048     |
| 14   | .2987     | .3292     | .2591     | .3048     | .2987     | .362      | .3048     |
| 15   | .2614     | .362      | .2846     | .3048     | .3361     | .3982     | .3201     |
| 16   | .3547     |           | .3401     | .3658     | .3734     | .4344     | .3321     |
| 17   | .3921     | .4024     | .3647     | .3353     | .3734     | .3982     | .3725     |
| 18   | .4481     | .5601     | .3812     | .4062     | .4108     | .4755     | .431      |
| 19   | .7095     | .6653     | .57       | .5937     | .7095     | .6722     | .6104     |
| 20   | .7282     | .7392     | .5935     | .5312     | .6722     | .5601     | .5571     |
| 21   | .6722     | .6584     | .5138     | .4843     | .5601     | .5175     | .4858     |
| 22   | .5788     | .5487     | .4481     | .4531     | .5601     | .4805     | .4428     |
| 23   | .5601     | .4706     | .426      | .4374     | .5415     | .4755     | .4062     |
| 24   | .4531     | .5228     |           | .4049     | .4218     | .5041     | .4344     |
| Max  | .7282     | .8962     | .8589     | .7545     | .7362     | .8048     | .8589     |
| Min  | .2614     | .2896     | .2591     | .2896     | .2987     | .3258     | .3048     |
| Avg  | .4712     | .5214     | .4525     | .4337     | .4574     | .5159     | .4623     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 202 / 11 KV UNTAWAD AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0669    | .7701     | 1.1873    |           |           |           |           |
| 2    | 1.0936    | .8402     | 1.0974    |           |           |           |           |
| 3    | 1.0623    | .8356     |           |           |           |           |           |
| 4    | 1.0623    | .8356     | 1.0623    |           |           |           |           |
| 5    | 1.0212    | .8356     | 1.0623    |           |           |           |           |
| 6    | 1.0311    | .8848     | 1.0623    |           |           |           |           |
| 7    | .9998     | 1.0486    | 1.0623    |           |           |           |           |
| 8    | 1.0212    | 1.065     | 1.1248    |           |           |           |           |
| 9    | 1.0227    |           | 1.0936    |           |           |           |           |
| 10   | .8848     |           | 1.1702    |           |           |           |           |
| 11   |           |           |           | 1.1888    | 1.1568    | 1.1203    | .9783     |
| 12   |           |           |           | 1.1888    | 1.2071    | 1.1203    | .9907     |
| 13   |           |           |           | 1.1279    | 1.1904    | .9998     | .9145     |
| 14   |           |           |           | 1.0974    | 1.2239    | 1.012     | .9031     |
| 15   |           |           |           | 1.0974    | 1.1736    | .9998     | .9659     |
| 16   |           |           |           | 1.0669    | 1.1401    | .9686     | .9536     |
| 17   |           |           |           | 1.0974    | 1.0898    | .9998     | .9907     |
| 18   |           |           |           | 1.0059    | 1.0395    | .9374     | .9907     |
| Max  | 1.0936    | 1.065     | 1.1873    | 1.1888    | 1.2239    | 1.1203    | .9907     |
| Min  | .8848     | .7701     | 1.0623    | 1.0059    | 1.0395    | .9374     | .9031     |
| Avg  | 1.0266    | .8894     | 1.1025    | 1.1088    | 1.1527    | 1.0198    | .9609     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 203 / 11 KV ADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0623    | .7865     | .8916     |           |           |           |           |
| 2    | 1.0623    | .8192     | .8322     |           |           |           |           |
| 3    | 1.0155    | .8192     | .7526     |           |           |           |           |
| 4    | .9907     | .8356     | .8025     |           |           |           |           |
| 5    | .9145     | .8356     | .8322     |           |           |           |           |
| 6    | .9755     | .852      | .8322     |           |           |           |           |
| 7    | 1.0936    | .8848     | .9031     |           |           |           |           |
| 8    | 1.1248    | .9175     | 1.0623    |           |           |           |           |
| 9    | 1.1961    |           | .9389     |           |           |           |           |
| 10   | 1.1633    |           | .8916     |           |           |           |           |
| 11   |           |           |           | 1.4373    | 1.4251    | 1.326     | 1.3094    |
| 12   |           |           |           | 1.406     | 1.4419    | 1.2186    | 1.1288    |
| 13   |           |           |           | 1.2498    | 1.2574    | 1.1248    | 1.0536    |
| 14   |           |           |           | 1.1584    | 1.1736    | 1.0936    | .9362     |
| 15   |           |           |           | .9998     | 1.0898    | .8916     | .8322     |
| 16   |           |           |           | .9686     | .9724     | .8322     | .8173     |
| 17   |           |           |           | 1.0936    | .9221     | .9957     | .743      |
| 18   |           |           |           | 1.1248    | 1.0059    | 1.0105    | .9602     |
| 19   |           |           |           |           |           | 1.326     |           |
| Max  | 1.1961    | .9175     | 1.0623    | 1.4373    | 1.4419    | 1.326     | 1.3094    |
| Min  | .9145     | .7865     | .7526     | .9686     | .9221     | .8322     | .743      |
| Avg  | 1.0599    | .8438     | .8739     | 1.1798    | 1.1610    | 1.091     | .9726     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 204 / 11 KV CHINCHOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.2498    | 1.5203    | 1.2174    | 1.3717    |
| 2    |           |           |           | 1.2955    | 1.5203    | .3944     | 1.3717    |
| 3    |           |           |           | 1.2498    | 1.5203    | 1.2517    | 1.278     |
| 4    |           |           |           | 1.2651    | 1.4403    | 1.286     | 1.1888    |
| 5    |           |           |           | 1.2498    | 1.406     | 1.3375    | 1.1888    |
| 6    |           |           |           | 1.3279    | 1.3279    | 1.3717    | 1.1584    |
| 7    |           |           |           | 1.406     | 1.406     | 1.5775    | 1.1888    |
| 8    |           |           |           | 1.4232    | 1.406     | 1.5947    |           |
| 9    |           |           |           | 1.4403    | 1.7147    |           | 1.4918    |
| 10   |           |           |           | 1.4403    | 1.6461    |           | 1.3717    |
| 11   | 1.989     | 1.9433    | 1.829     |           |           |           |           |
| 12   | 2.0576    | 1.7394    | 1.9062    |           |           |           |           |
| 13   | 1.8861    | 1.7394    | 1.7394    |           |           |           |           |
| 14   | 1.7147    | 1.5623    | 1.6766    |           |           |           |           |
| 15   | 1.7318    | 1.5623    | 1.5242    |           |           |           |           |
| 16   | 1.749     | 1.5623    | 1.3375    |           |           |           |           |
| 17   | 1.7147    | 1.5623    | 1.3717    |           |           |           |           |
| 18   | 1.6804    |           | 1.3717    |           |           |           |           |
| Max  | 2.0576    | 1.9433    | 1.9062    | 1.4403    | 1.7147    | 1.5947    | 1.4918    |
| Min  | 1.6804    | 1.5623    | 1.3375    | 1.2498    | 1.3279    | .3944     | 1.1584    |
| Avg  | 1.8154    | 1.6673    | 1.5945    | 1.3348    | 1.4908    | 1.2539    | 1.2900    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 205 / 11 KV MANUDEVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .743      | .6859     | .6706     | .543      |
| 2    |           |           |           | .743      | .6859     | .7042     | .5502     |
| 3    |           |           |           | .743      | .6859     | .7042     | .5792     |
| 4    |           |           |           | .743      | .6401     | .7377     | .6622     |
| 5    |           |           |           | .743      | .6401     | .7545     | .7011     |
| 6    |           |           |           | .7526     | .7011     | .7712     | .7316     |
| 7    |           |           |           | .8278     | .884      | .8718     | .8025     |
| 8    |           |           |           | .8579     | .9145     | .9221     |           |
| 9    |           |           |           | .8383     | .9724     |           | .8173     |
| 10   |           |           |           | .823      | .8886     |           | .7876     |
| 11   | .9339     | 1.012     | .6836     |           |           |           |           |
| 12   | .9831     | .9488     | .6836     |           |           |           |           |
| 13   | .9012     | .8749     | .8688     |           |           |           |           |
| 14   | .8684     | .7811     | .8535     |           |           |           |           |
| 15   | .852      |           | .8383     |           |           |           |           |
| 16   | .8356     | .2934     | .7926     |           |           |           |           |
| 17   | .8684     | .4001     | .7621     |           |           |           |           |
| 18   | .9012     | .2705     | .743      |           |           |           |           |
| Max  | .9831     | 1.012     | .8688     | .8579     | .9724     | .9221     | .8173     |
| Min  | .8356     | .2705     | .6836     | .743      | .6401     | .6706     | .543      |
| Avg  | .8930     | .6544     | .7782     | .7815     | .7699     | .7670     | .6861     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124084 / 33/11 KV CHINCHOLI

Feeder No / Name : 206 / 11 KV SHEVADE AG SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9204    | 1.6289    | 1.8233    | .1143     | .1067     | .1524     | .1143     |
| 2    | 1.9204    | 1.6632    | 1.7901    | .1143     | .1067     | .1334     | .1143     |
| 3    | 1.9204    | 1.6632    | 1.7901    | .1905     | .1372     | .1524     | .1524     |
| 4    | 1.9528    | 1.7147    | 1.8233    | .2858     | .1829     | .2096     | .2286     |
| 5    | 2.0805    | 1.7147    | 1.9227    | .381      | .2812     | .3429     | .3429     |
| 6    | 2.1605    | 1.749     | 1.989     | .5716     | .3521     | .4763     | .5716     |
| 7    | 2.2405    | 1.6632    | 1.7814    | .381      | .3048     | .3429     | .3429     |
| 8    | 2.0805    | 1.6289    | 1.8233    | .2858     | .1829     | .1905     |           |
| 9    | 2.1091    | 1.4918    | 1.8896    | .1562     | .1905     | .1905     | .1715     |
| 10   | 1.9719    | 1.326     | 2.2291    | .1524     | .1524     | 1.8233    | .1905     |
| 11   | .1524     | .1905     | .1524     | 2.0805    | 2.1948    | 1.6575    | 2.1338    |
| 12   | .1334     | .1524     | .1334     | 2.0805    | 2.1605    | 1.5912    | 2.1872    |
| 13   | .1334     | .1143     | .1143     | 1.9204    | 2.1434    | 1.5912    | 2.2929    |
| 14   | .1143     | .1524     | .1143     | 1.9204    | 2.0919    | 1.5912    | 2.2929    |
| 15   | .0953     | .1905     | .1143     | 1.9204    | 1.989     |           | 2.2929    |
| 16   | .1334     | .1905     | .1715     | 2.0005    | 1.9204    |           | 2.2405    |
| 17   | .1715     | .2286     | .1905     | 2.0805    | 1.9719    | 1.989     | 2.2672    |
| 18   | .2477     | .1905     | .1905     | 2.1091    | 2.0233    | 1.5912    | 2.2672    |
| 19   | .3429     | .2667     | .3048     | .3125     | .4001     | .3429     | .381      |
| 20   | .1715     | .2286     | .2286     | .2591     | .4191     | .2667     | .2286     |
| 21   | .3239     | .1905     | .1905     | .1981     | .2858     | .1905     | .2096     |
| 22   | .1905     | .1905     | .1524     | .1524     | .2096     | .1524     | .1905     |
| 23   | .1715     | .1905     | .1524     | .1219     | .1715     | .1524     | .1905     |
| 24   | .1524     | .1524     |           | .1334     | .1219     | .1524     | .1334     |
| Max  | 2.2405    | 1.749     | 2.2291    | 2.1091    | 2.1948    | 1.989     | 2.2929    |
| Min  | .0953     | .1143     | .1143     | .1143     | .1067     | .1334     | .1143     |
| Avg  | .9538     | .7864     | .9162     | .8301     | .8375     | .6947     | .9364     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124097 / 33/11 KV DAMBHURNI

Feeder No / Name : 201 / 11 KV DONGAON AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4619    | 2.5072    | 2.2539    |           |           |           |           |
| 2    | 2.0805    | 2.4806    | 2.2539    |           |           |           |           |
| 3    | 2.0805    | 2.4806    | 2.2539    |           |           |           |           |
| 4    | 2.0631    | 2.5072    | 2.2539    |           |           |           |           |
| 5    | 2.0458    | 2.4177    | 2.2885    |           |           |           |           |
| 6    | 2.0458    | 2.4806    | 2.3752    |           |           |           |           |
| 7    | 2.0458    | 2.4806    | 2.3752    |           |           |           |           |
| 8    | 2.0458    | 2.392     | 2.5139    |           |           |           |           |
| 9    | 2.1491    | 2.3061    | 2.5941    |           |           |           |           |
| 10   | 2.1491    | 2.2721    | 2.489     |           |           |           |           |
| 11   |           |           |           | 2.572     | 2.524     | 2.6006    |           |
| 12   |           |           |           | 2.8921    | 2.4272    | 2.6006    |           |
| 13   |           |           |           | 2.9127    | 2.3926    | 2.6006    |           |
| 14   |           |           |           | 2.7463    | 2.5312    | 2.6292    |           |
| 15   |           |           |           | 2.6755    | 2.5486    | 2.6006    |           |
| 16   |           |           |           | 2.7873    | 2.5139    | 2.572     |           |
| 17   |           |           |           | 2.6467    | 2.5415    |           |           |
| 18   |           |           |           | 2.3565    | 2.4619    | 2.6006    | 2.572     |
| Max  | 2.4619    | 2.5072    | 2.5941    | 2.9127    | 2.5486    | 2.6292    | 2.572     |
| Min  | 2.0458    | 2.2721    | 2.2539    | 2.3565    | 2.3926    | 2.572     | 2.572     |
| Avg  | 2.1167    | 2.4325    | 2.3652    | 2.6986    | 2.4926    | 2.6006    | 2.572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124097 / 33/11 KV DAMBHURNI

Feeder No / Name : 202 / 11 KV DAMBHURNI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .394      | .3856     | .3801     | .4024     | .4207     | .3761     | .3856     |
| 2    | .3982     | .3856     | .3801     | .4024     | .4252     | .3761     | .3898     |
| 3    | .4344     | .4298     | .3982     | .4435     | .4607     | .4119     | .4298     |
| 4    | .5121     | .5487     | .4755     | .4668     | .4656     | .4887     | .5068     |
| 5    | .5914     | .5975     | .5853     | .5601     | .6379     | .5914     | .6348     |
| 6    | .8215     | .8215     | .8215     | .8215     | .7964     | .8215     | .8215     |
| 7    | .6722     | .6348     | .6535     | .6348     | .6154     | .6535     | .5853     |
| 8    | .5228     | .5228     | .5544     | .5228     | .4784     | .5415     | .5304     |
| 9    | .4207     | .3898     | .3506     | .3856     | .3801     | .4298     |           |
| 10   | .3856     | .3155     |           | .3856     | .3294     | .3898     |           |
| 11   | .3856     | .2947     | .2774     | .3258     | .2947     | .3506     |           |
| 12   | .3429     | .2947     | .2629     | .2804     | .2947     | .3506     |           |
| 13   | .3391     | .3121     | .2835     | .3086     | .2947     | .3506     |           |
| 14   | .3391     | .3155     | .2804     | .333      | .3294     | .3467     |           |
| 15   | .3544     | .333      | .3155     |           | .3506     | .3681     |           |
| 16   | .394      | .3681     | .3189     |           | .3681     | .3641     |           |
| 17   | .4115     | .3814     | .3898     | .3772     | .3898     | .3982     |           |
| 18   | .4961     | .4161     | .4252     | .4607     | .443      | .4755     | .4854     |
| 19   | .6722     | .567      | .567      | .5658     | .6268     | .6348     |           |
| 20   | .5373     | .4961     | .567      | .5609     | .591      | .5853     |           |
| 21   | .4755     | .4784     | .4961     | .443      | .4656     | .5121     |           |
| 22   | .4298     | .443      | .443      | .4525     | .4477     | .4477     |           |
| 23   | .3898     | .4075     |           |           | .4252     | .4207     |           |
| 24   | .3982     | .3898     | .3898     | .4207     |           | .3898     | .3856     |
| Max  | .8215     | .8215     | .8215     | .8215     | .7964     | .8215     | .8215     |
| Min  | .3391     | .2947     | .2629     | .2804     | .2947     | .3467     | .3856     |
| Avg  | .4633     | .4387     | .4371     | .4550     | .4492     | .4615     | .5155     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124097 / 33/11 KV DAMBHURNI

Feeder No / Name : 203 / 11 KV KOLNHA VI II AGR FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 3.65      | 2.915     | 3.6355    | 3.5437    |
| 2    |           |           |           | 3.65      | 3.0498    | 3.6355    | 3.5437    |
| 3    |           |           |           | 3.65      | 3.1893    | 3.6176    | 3.5818    |
| 4    |           |           |           | 3.6323    | 3.2427    | 3.5818    | 3.5818    |
| 5    |           |           |           | 3.65      | 3.2779    | 3.6355    | 3.7609    |
| 6    |           |           |           | 3.65      | 3.2779    | 3.6892    | 3.7609    |
| 7    |           |           |           | 3.8272    | 3.4932    | 3.7609    | 3.7609    |
| 8    |           |           |           | 3.526     | 3.5791    | 3.8504    | 3.5818    |
| 9    |           |           |           | 3.7037    | 3.5997    | 3.7275    |           |
| 10   |           |           |           | 3.6145    | 3.6713    | 3.7275    |           |
| 11   | 3.9963    | 3.9758    | 4.1461    |           |           |           |           |
| 12   | 3.9963    | 3.9758    | 4.1993    |           |           |           |           |
| 13   | 4.0314    | 4.0474    | 4.0398    |           |           |           |           |
| 14   | 4.0314    | 4.2086    | 3.9689    |           |           |           |           |
| 15   | 4.0752    | 4.2265    | 4.0043    |           |           |           |           |
| 16   | 4.119     | 1.7185    | 3.9866    |           |           |           |           |
| 17   | 3.9335    | 3.9041    | 3.898     |           |           |           |           |
| 18   | 3.9335    | 3.8094    | 3.9335    |           |           |           |           |
| Max  | 4.119     | 4.2265    | 4.1993    | 3.8272    | 3.6713    | 3.8504    | 3.7609    |
| Min  | 3.9335    | 1.7185    | 3.898     | 3.526     | 2.915     | 3.5818    | 3.5437    |
| Avg  | 4.0146    | 3.7333    | 4.0221    | 3.6554    | 3.3296    | 3.6861    | 3.6394    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124097 / 33/11 KV DAMBHURNI

Feeder No / Name : 204 / 11 KV SANGHAVI FOOD  
EXPRESS FE Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1402     | .1595     | .1543     | .1578     | .1029     | .1543     | .1417     |
| 2    | .1578     | .1417     | .1372     | .1578     | .12       | .1372     | .1595     |
| 3    | .1402     | .1433     | .1372     | .1402     |           | .1372     | .1612     |
| 4    | .1753     | .1612     | .1543     | .1578     | .1372     | .1543     | .1612     |
| 5    | .1753     | .124      | .1372     | .1402     | .12       | .1372     | .1433     |
| 6    | .1753     | .1254     | .1543     | .1402     | .1372     | .1543     | .1612     |
| 7    | .1227     | .1063     | .1372     | .1402     | .1543     | .1715     | .1417     |
| 8    | .1402     | .1063     | .12       | .1402     | .1029     | .1372     | .1433     |
| 9    | .1753     | .1543     | .1402     | .12       | .12       | .1578     |           |
| 10   | .1928     | .1715     | .1928     | .1543     | .1715     | .1772     |           |
| 11   | .1949     | .2058     | .2279     | .1029     | .2058     | .1772     |           |
| 12   | .1772     | .1543     | .1753     | .12       | .1886     | .1595     |           |
| 13   | .1753     | .1715     | .1772     | .1372     | .1543     | .1578     |           |
| 14   | .1417     |           | .1753     | .1543     | .2229     | .1753     |           |
| 15   | .1595     |           | .1753     | .12       | .2058     | .1772     |           |
| 16   | .1612     |           | .1928     | .1886     | .2058     | .1772     |           |
| 17   | .1417     | .1886     | .1753     | .1543     | .1715     | .1612     |           |
| 18   | .1612     | .1543     | .1402     | .1372     | .1372     | .1612     | .12       |
| 19   | .1612     | .1372     | .1402     | .12       | .1372     | .1772     |           |
| 20   | .1612     | .1543     | .1227     | .12       | .1543     | .1595     |           |
| 21   | .1791     | .1715     | .1052     | .1029     | .1886     | .1772     |           |
| 22   | .1629     | .12       | .1402     | .0857     | .1372     | .1402     |           |
| 23   | .1595     | .12       |           |           | .1372     | .1417     |           |
| 24   | .1402     | .1595     | .1543     | .1402     |           | .1543     | .1402     |
| Max  | .1949     | .2058     | .2279     | .1886     | .2229     | .1772     | .1612     |
| Min  | .1227     | .1063     | .1052     | .0857     | .1029     | .1372     | .12       |
| Avg  | .1613     | .1491     | .1551     | .1362     | .1551     | .1590     | .1473     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124099 / 33/11 KV SATOD

Feeder No / Name : 201 / 11 KV SATOD GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3544     | .3547     | .3544     | .3544     | .3734     | .3506     | .3544     |
| 2    | .3544     | .3547     | .3544     | .3544     | .3734     | .3544     | .3544     |
| 3    | .443      | .4854     | .4477     | .4252     | .4805     | .4298     | .443      |
| 4    | .6201     | .6099     | .6154     | .567      | .5729     | .5792     | .5493     |
| 5    | .7442     | .7023     | .7947     | .7265     | .7682     | .7762     | .7619     |
| 6    | .8682     | .9511     | .924      | .9214     | .8962     | .961      | .8859     |
| 7    | .7619     | .7499     | .7522     | .7442     | .695      | .6335     | .691      |
| 8    | .5611     | .5373     | .5316     | .6584     | .4835     | .5316     | .5014     |
| 9    | .5068     | .443      |           | .4938     | .443      | .4607     | .4477     |
| 10   | .4525     | .3506     | .4252     | .4207     | .4075     | .4075     | .4298     |
| 11   | .3821     | .3506     | .3544     | .4207     | .3681     | .3898     | .3366     |
| 12   | .3457     | .3506     | .3544     | .4024     | .3681     | .3544     | .3366     |
| 13   | .3439     | .3366     | .3189     | .4066     | .3544     | .3544     | .3506     |
| 14   | .3439     | .3155     | .3012     | .4066     | .3366     | .3189     | .3366     |
| 15   | .362      | .3155     | .3544     | .4066     | .3224     | .3012     | .3544     |
| 16   | .362      | .3544     | .3898     | .4066     | .3155     | .3012     | .3681     |
| 17   | .4163     | .3761     | .4252     | .439      | .3814     |           | .3641     |
| 18   | .5068     | .4887     | .5138     | .4755     | .543      | .5138     | .5731     |
| 19   | .6516     | .6401     | .5847     | .5487     | .6584     | .6024     | .6661     |
| 20   | .543      | .5249     | .4961     | .6154     | .5552     | .5316     | .5552     |
| 21   | .5068     | .4477     | .4252     | .5304     | .5014     | .4961     | .4784     |
| 22   | .4572     | .4075     | .4075     | .4572     | .443      | .4607     | .4161     |
| 23   | .3841     | .3856     | .3721     | .4024     | .3856     | .3898     | .4031     |
| 24   | .3721     | .3547     | .3681     | .3721     | .4108     | .3761     | .3721     |
| Max  | .8682     | .9511     | .924      | .9214     | .8962     | .961      | .8859     |
| Min  | .3439     | .3155     | .3012     | .3544     | .3155     | .3012     | .3366     |
| Avg  | .4852     | .4661     | .4724     | .4982     | .4766     | .4728     | .4721     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124099 / 33/11 KV SATOD

Feeder No / Name : 202 / 11 KV KOLWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.134     | 1.1022    | .9536     |           |           |           |           |
| 2    | 1.1163    | 1.1145    | .9511     |           |           |           |           |
| 3    | 1.1163    | 1.0802    | .9214     |           |           |           |           |
| 4    | 1.0985    | 1.0117    | .9065     |           |           |           |           |
| 5    | 1.0985    | .9602     | .8655     |           |           |           |           |
| 6    | 1.0631    | 1.0631    | .8509     |           |           |           |           |
| 7    | 1.0631    | 1.0974    | .9065     |           |           |           |           |
| 8    | 1.0442    | .9957     | 1.0808    |           |           |           |           |
| 9    | 1.0277    | .9536     | 1.0631    |           |           |           |           |
| 10   | 1.0395    | .9332     | 1.0631    |           |           |           |           |
| 11   |           |           |           | 1.1145    | 1.0105    | 1.0985    | 1.0235    |
| 12   |           |           |           | 1.1145    | .9682     | 1.1517    | 1.0235    |
| 13   |           |           |           | 1.1145    | .9976     | 1.1694    | 1.0402    |
| 14   |           |           |           | 1.0802    | .9536     | 1.1517    | 1.0385    |
| 15   |           |           |           | 1.0923    | .9659     | 1.134     | 1.0235    |
| 16   |           |           |           | 1.0682    | .9482     | 1.0985    | .9934     |
| 17   |           |           |           | 1.0852    | .9783     | 1.134     | .9934     |
| 18   |           |           |           | 1.0852    | .9031     | 1.134     | 1.0235    |
| Max  | 1.134     | 1.1145    | 1.0808    | 1.1145    | 1.0105    | 1.1694    | 1.0402    |
| Min  | 1.0277    | .9332     | .8509     | 1.0682    | .9031     | 1.0985    | .9934     |
| Avg  | 1.0801    | 1.0312    | .9563     | 1.0943    | .9657     | 1.1340    | 1.0199    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124099 / 33/11 KV SATOD

Feeder No / Name : 203 / 11 KV PARSALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 2.5869    | 2.3579    | 2.2712    | 2.3743    |
| 2    |           |           |           | 2.5692    | 2.3579    | 2.2539    | 2.3211    |
| 3    |           |           |           | 2.516     | 2.2885    | 2.2539    | 2.3034    |
| 4    |           |           |           | 2.516     | 2.2885    | 2.2192    | 2.3034    |
| 5    |           |           |           | 2.5337    | 2.2885    | 2.2192    | 2.3388    |
| 6    |           |           |           | 2.516     | 2.3232    | 2.2291    | 2.3211    |
| 7    |           |           |           | 2.4983    | 2.4966    | 2.3579    | 2.3565    |
| 8    |           |           |           | 2.4446    | 2.4966    | 2.3211    | 2.3405    |
| 9    |           |           |           | 2.4272    | 2.4272    | 2.3743    | 2.3926    |
| 10   |           |           |           | 2.4272    | 2.3405    | 2.4097    | 2.3405    |
| 11   | 2.4446    | 2.6873    | 2.8349    |           |           |           |           |
| 12   | 2.6006    | 2.6526    | 2.8349    |           |           |           |           |
| 13   | 2.6006    | 2.6006    | 2.7463    |           |           |           |           |
| 14   | 2.6006    | 2.5312    | 2.5692    |           |           |           |           |
| 15   | 2.5659    | 2.5139    | 2.4806    |           |           |           |           |
| 16   | 2.5659    | 2.4792    | 2.4806    |           |           |           |           |
| 17   | 2.5659    | 2.4792    | 2.516     |           |           |           |           |
| 18   | 2.5833    | 2.4348    | 2.4983    |           |           |           |           |
| 24   |           |           |           | 2.5869    |           |           |           |
| Max  | 2.6006    | 2.6873    | 2.8349    | 2.5869    | 2.4966    | 2.4097    | 2.3926    |
| Min  | 2.4446    | 2.4348    | 2.4806    | 2.4272    | 2.2885    | 2.2192    | 2.3034    |
| Avg  | 2.5659    | 2.5474    | 2.6201    | 2.5111    | 2.3665    | 2.2910    | 2.3392    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124124 / 33/11 KV THORGAVAN

Feeder No / Name : 201 / 11 KV SHIRAGAD GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3048     | .3429     | .3052     | .3429     |           |           | .3086     |
| 2    | .3429     | .3048     | .3222     | .381      |           |           | .2713     |
| 3    | .381      | .3239     | .3086     | .381      |           |           | .3429     |
| 4    | .6097     | .6478     | .4748     | .6097     |           |           | .4458     |
| 5    | .8383     | .8764     | .763      | .8383     |           |           | .7122     |
| 6    | 1.0098    | 1.0288    | .7461     | .9907     | .9145     |           | .8215     |
| 7    | .8002     | .7049     | .5365     | .724      | .7811     |           | .6783     |
| 8    | .6478     | .6478     | .5087     | .6668     | .7621     |           | .6274     |
| 9    | .6097     | .4917     | .5335     | .5335     | .724      | .6097     | .503      |
| 10   | .4954     | .39       | .4572     | .4191     | .4763     | .4572     | .4409     |
| 11   | .381      | .2683     | .362      | .4191     | .4001     |           | .3521     |
| 12   | .381      | .2683     | .3239     | .362      | .3429     |           | .3185     |
| 13   | .362      | .2515     | .3048     | .362      | .3239     |           | .2543     |
| 14   | .3429     | .2515     | .2858     | .381      | .362      | .4191     | .3391     |
| 15   | .3429     | .2683     | .3048     | .4001     | .4382     | .4382     | .3185     |
| 16   | .4001     | .3222     | .4191     | .4382     | .4572     | .4572     | .3521     |
| 17   | .4763     | .39       | .4954     | .4763     | .4763     | .4954     | .407      |
| 18   | .6859     | .5765     | .6668     |           | .6287     | .6668     | .5087     |
| 19   | .8192     | .6516     | .7621     |           |           | .8383     |           |
| 20   | .6668     |           | .6097     |           |           | .6097     | .5658     |
| 21   | .6097     |           | .5335     |           |           | .4954     |           |
| 22   | .4572     |           | .4763     |           |           | .4572     | .3429     |
| 23   | .4191     |           | .4191     |           |           | .381      | .3086     |
| 24   | .3048     | .362      |           | .381      |           |           | .362      |
| Max  | 1.0098    | 1.0288    | .763      | .9907     | .9145     | .8383     | .8215     |
| Min  | .3048     | .2515     | .2858     | .3429     | .3239     | .381      | .2543     |
| Avg  | .5287     | .4685     | .4747     | .5059     | .5452     | .5271     | .4355     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124124 / 33/11 KV THORGAVAN

Feeder No / Name : 203 / 11 KV SAPTASHRUNGI DEVI AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6766    | 1.7147    | 1.3565    |           |           |           |           |
| 2    | 1.6194    | 1.6956    | 1.2717    |           |           |           |           |
| 3    | 1.6385    | 1.4098    | 1.2717    |           |           |           |           |
| 4    | 1.6766    | 1.3908    | 1.2209    |           |           |           |           |
| 5    | 1.6766    | 1.3717    | 1.2209    |           |           |           |           |
| 6    | 1.7147    | 1.3717    | 1.1869    |           |           |           |           |
| 7    | 1.7528    | 1.6956    | 1.3916    |           |           |           |           |
| 8    | 1.7528    | 1.7147    | 1.3565    |           |           |           |           |
| 9    | 1.7909    | 1.3748    | 1.5623    |           |           |           |           |
| 10   | 1.829     | 1.3413    | 1.6194    |           |           |           |           |
| 11   |           |           |           | 1.6385    | 1.6194    |           | 1.1233    |
| 12   |           |           |           | 1.6194    | 1.6575    |           | 1.2071    |
| 13   |           |           |           | 1.6194    | 1.6766    |           | 1.2209    |
| 14   |           |           |           | 1.6766    | 1.7337    | 1.5623    | 1.3565    |
| 15   |           |           |           | 1.6575    | 1.7718    | 1.6194    | 1.3748    |
| 16   |           |           |           | 1.6385    | 1.7528    | 1.6766    | 1.3565    |
| 17   |           |           |           | 1.5242    | 1.7718    | 1.6766    | 1.3565    |
| 18   |           |           |           |           | 1.7718    | 1.6194    | 1.3226    |
| 19   |           |           |           |           |           | 1.6194    |           |
| Max  | 1.829     | 1.7147    | 1.6194    | 1.6766    | 1.7718    | 1.6766    | 1.3748    |
| Min  | 1.6194    | 1.3413    | 1.1869    | 1.5242    | 1.6194    | 1.5623    | 1.1233    |
| Avg  | 1.7128    | 1.5081    | 1.3458    | 1.6249    | 1.7194    | 1.6290    | 1.2898    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124138 / 33/11 KV YAWAL

Feeder No / Name : 201 / 11 KV YAWAL URBAN -1  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.267     | 1.267     | 1.3032    | 1.267     | 1.2851    | 1.3032    | 1.3032    |
| 2    | 1.2308    | 1.2308    | 1.1946    | 1.2127    | 1.2308    | 1.2308    | 1.3032    |
| 3    | 1.1946    | 1.267     | 1.2308    | 1.2127    | 1.2308    | 1.267     | 1.3394    |
| 4    | 1.1765    | 1.267     | 1.2308    | 1.1584    | 1.267     | 1.267     | 1.3756    |
| 5    | 1.2127    | 1.3032    | 1.2308    | 1.3032    | 1.267     | 1.3575    | 1.3756    |
| 6    | 1.3032    | 1.3213    | 1.448     | 1.4299    | 1.3213    | 1.4299    | 1.4118    |
| 7    | 1.3575    | 1.3756    | 1.448     | 1.4299    | 1.3032    | 1.4118    | 1.3756    |
| 8    | 1.2489    | 1.2127    | 1.3756    | 1.2308    | 1.2489    | 1.2851    | 1.3394    |
| 9    | 1.1765    | 1.086     | 1.267     | 1.1946    | 1.2127    | 1.3032    | 1.2308    |
| 10   | 1.267     | 1.1946    | 1.1946    | 1.267     | 1.267     | 1.3756    | 1.2308    |
| 11   | 1.267     | 1.2308    | 1.3213    | 1.3032    | 1.3394    | 1.448     | 1.2308    |
| 12   | 1.1222    | 1.3032    | 1.1946    | 1.2308    | 1.1584    | 1.3394    | 1.3213    |
| 13   | 1.086     | 1.2308    | 1.2489    | 1.2127    | 1.2308    | 1.3032    | 1.2308    |
| 14   | 1.1222    | 1.1946    | 1.3032    | 1.2308    | 1.3032    | 1.3032    | 1.2308    |
| 15   | 1.1222    | 1.267     | 1.3575    | 1.2851    | 1.267     | 1.3394    | 1.267     |
| 16   | 1.1765    | 1.2308    | 1.2308    | 1.267     | 1.2851    | 1.3032    | 1.267     |
| 17   | 1.1584    | 1.3032    | 1.1946    | 1.1765    | 1.267     | 1.267     | 1.267     |
| 18   | 1.1765    | 1.267     | 1.2489    | 1.267     | 1.3213    | 1.267     | 1.2489    |
| 19   | 1.4299    | 1.4842    | 1.5384    | 1.4661    | 1.5927    | 1.5203    | 1.5203    |
| 20   | 1.448     | 1.4842    | 1.4299    | 1.4842    | 1.6108    | 1.5203    | 1.5565    |
| 21   | 1.448     | 1.448     | 1.5023    | 1.4842    | 1.5023    | 1.5565    | 1.5203    |
| 22   | 1.4299    | 1.448     | 1.5023    | 1.5023    | 1.5565    | 1.5565    | 1.5023    |
| 23   | 1.3937    | 1.4118    | 1.4118    | 1.4118    | 1.4661    | 1.5203    | 1.4842    |
| 24   | 1.3394    | 1.3213    | 1.3756    | 1.3394    | 1.3575    | 1.4118    | 1.448     |
| Max  | 1.448     | 1.4842    | 1.5384    | 1.5023    | 1.6108    | 1.5565    | 1.5565    |
| Min  | 1.086     | 1.086     | 1.1946    | 1.1584    | 1.1584    | 1.2308    | 1.2308    |
| Avg  | 1.2564    | 1.2979    | 1.3243    | 1.3070    | 1.3288    | 1.3703    | 1.3492    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124138 / 33/11 KV YAWAL

Feeder No / Name : 202 / 11 KV VYAS MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8326     | .8326     | .8326     | .8688     | .8507     | .8507     | .8326     |
| 2    | .7964     | .8145     | .7964     | .8145     | .8145     | .7964     | .8326     |
| 3    | .7783     | .8688     | .8326     | .8145     | .8145     | .8145     | .905      |
| 4    | .7964     | .8507     | .8688     | .8869     | .8507     | .8145     | .905      |
| 5    | .8145     | .8869     | .905      | .8507     | .8688     | .8688     | .9412     |
| 6    | .905      | .905      | .8688     | .8869     | .905      | .9231     | .9412     |
| 7    | .7602     | .7783     | .8326     | .8145     | .8326     | .8869     | .8688     |
| 8    | .7602     | .7602     | .7964     | .7059     | .8145     | .8145     | .8326     |
| 9    | .724      | .724      | .7602     | .7421     | .724      | .724      | .7602     |
| 10   | .6154     | .724      | .6697     | .7059     | .724      | .7602     | .724      |
| 11   | .6335     | .6516     | .6516     | .6878     | .6516     | .724      | .6697     |
| 12   | .6154     | .6516     | .6516     | .6335     | .7059     | .724      | .6697     |
| 13   | .6516     | .6516     | .6516     | .6516     | .7059     | .7602     | .7059     |
| 14   | .6878     | .6878     | .6878     | .6516     | .6878     | .7602     | .724      |
| 15   | .7602     | .724      | .724      | .724      | .724      | .7602     | .7602     |
| 16   | .724      | .724      | .7964     | .7783     | .724      | .7602     | .7602     |
| 17   | .724      | .724      | .724      | .7602     | .7059     | .6516     | .7421     |
| 18   | .7059     | .724      | .6516     | .7059     | .6516     | .6878     | .724      |
| 19   | .7964     | .8326     | .8145     | .8145     | .905      | .8326     | .8688     |
| 20   | .8507     | .905      | .9412     | .8688     | .9412     | .905      | .9593     |
| 21   | .9593     | .9412     | .9412     | .9593     | .9955     | .9774     | .8688     |
| 22   | .9412     | .905      | .9774     | .9774     | .9774     | 1.0136    | .905      |
| 23   | .9412     | .905      | .9593     | .9412     | .9412     | .9774     | .9955     |
| 24   | .8688     | .905      | .8688     | .905      | .8869     | .905      | .905      |
| Max  | .9593     | .9412     | .9774     | .9774     | .9955     | 1.0136    | .9955     |
| Min  | .6154     | .6516     | .6516     | .6335     | .6516     | .6516     | .6697     |
| Avg  | .7768     | .7949     | .8002     | .7979     | .8085     | .8205     | .8251     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL II SUBDN.[247] BU 0647

Substation No/ Name :- 124138 / 33/11 KV YAWAL

Feeder No / Name : 203 / 11 KV Industrial Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3    |           | .0181     |           |           | .1448     |           | .0181     |
| 4    | .0181     | .0181     |           | .0181     |           | .0181     | .0181     |
| 5    | .0181     | .0181     | .0181     |           |           | .0181     | .0181     |
| 6    |           | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| 7    | .0181     |           | .0181     |           | .0181     |           | .0181     |
| 8    | .0181     |           | .0181     | .1086     | .0362     |           | .0181     |
| 9    | .0181     |           | .0181     | .0181     | .0181     |           | .0362     |
| 10   | .0543     | .0181     | .0181     | .0181     | .0543     | .0362     | .0362     |
| 11   | .0543     | .0181     | .0181     | .0362     | .0543     | .0543     | .0362     |
| 12   | .0543     | .0181     | .0181     |           | .0543     | .0362     | .0181     |
| 13   | .0543     | .0181     | .0181     | .0362     | .0181     | .0543     | .0362     |
| 14   | .0362     | .0181     | .0181     | .0181     | .0181     | .0181     |           |
| 15   | .0362     | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| 16   | .0362     | .0181     |           | .0181     | .0181     | .0181     | .0181     |
| 17   | .0362     | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| 18   | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| 19   | .0181     |           |           | .0181     |           |           |           |
| Max  | .0543     | .0181     | .0181     | .1086     | .1448     | .0543     | .0362     |
| Min  | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| Avg  | .0326     | .0181     | .0181     | .0278     | .0362     | .0272     | .0229     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 201 / 11 KV VANOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .6097     | .5335     |           | .5716     | .5335     |           | .4191     |
| 8    | .3048     | .4572     |           | .4572     |           | .4572     | .381      |
| 12   | 1.0486    | 1.1142    |           | 1.3763    | 1.2452    | 1.1797    | 1.3108    |
| 16   | 1.1142    | 1.2452    | 1.2452    | 1.3108    | 1.2452    | 1.3108    | 1.1797    |
| 20   | .6097     | .5335     | .4572     | .4572     | .4572     | .5335     | .5335     |
| 23   |           |           |           |           | .4572     |           |           |
| 24   | .2286     | .3048     |           | .2286     | .3048     | .2286     | .2667     |
| Max  | 1.1142    | 1.2452    | 1.2452    | 1.3763    | 1.2452    | 1.3108    | 1.3108    |
| Min  | .2286     | .3048     | .4572     | .2286     | .3048     | .2286     | .2667     |
| Avg  | .6526     | .6981     | .8512     | .7336     | .7072     | .7420     | .6818     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 202 / 11 KV PILODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .4954     | .5716     |           |           | .6097     | .5335     |
| 8    | .5335     |           |           |           | .4954     | .5335     |
| 12   | 2.1956    |           |           |           | 2.3594    | 2.3967    |
| 16   | 2.2283    | 2.1628    | 2.3266    | 2.2611    | 2.3365    | 2.2996    |
| 18   |           |           |           |           |           | .381      |
| 20   | .6859     | .6478     | .5716     | .6097     | .6097     | .5716     |
| 24   | .381      | .3429     |           |           | .381      | .381      |
| Max  | 2.2283    | 2.1628    | 2.3266    | 2.2611    | 2.3594    | 2.3967    |
| Min  | .381      | .3429     | .5716     | .6097     | .381      | .381      |
| Avg  | 1.0866    | .9313     | 1.4491    | 1.4354    | 1.1320    | 1.0138    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 205 / 11 KV AMODA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.9662    | 1.7695    | 1.6057    | 1.6712    | 1.6385    |
| 8    | 1.7695    |           | 1.6712    | 1.7695    | 1.7368    |
| Max  | 1.9662    | 1.7695    | 1.6712    | 1.7695    | 1.7368    |
| Min  | 1.7695    | 1.7695    | 1.6057    | 1.6712    | 1.6385    |
| Avg  | 1.8679    | 1.7695    | 1.6385    | 1.7204    | 1.6877    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 206 / 11 KV BAMNOD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .7602     | .7964     |           |           | .8688     | .7602     | .8688     |
| 8    | .7602     |           |           |           | .7164     | .6805     | .6805     |
| 12   | .6447     |           |           |           | .6984     | .6089     | .5068     |
| 16   | .6805     | .6089     | .6089     | .6805     | .6447     | .6697     | .6697     |
| 20   | .724      | .7964     | .7964     | .7602     | .7164     | .7602     | .788      |
| 24   | .6447     | .6447     |           |           |           | .6805     | .6805     |
| Max  | .7602     | .7964     | .7964     | .7602     | .8688     | .7602     | .8688     |
| Min  | .6447     | .6089     | .6089     | .6805     | .6447     | .6089     | .5068     |
| Avg  | .7024     | .7116     | .7027     | .7204     | .7289     | .6933     | .6991     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 207 / 11KV Padalse Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .7964     | .905      |           |           | .7964     | .7964     | .788      |
| 8    | .6447     |           |           |           | .6805     | .724      | .7164     |
| 12   | .567      |           |           |           | .5316     | .4706     | .5068     |
| 16   | .5316     | .4961     | .5014     |           | .5316     | .543      | .5853     |
| 20   | .7964     | .724      | .7522     | .724      | .7602     | .7602     | .6805     |
| 24   | .5731     | .5731     |           |           | .5731     | .5373     | .5731     |
| Max  | .7964     | .905      | .7522     | .724      | .7964     | .7964     | .788      |
| Min  | .5316     | .4961     | .5014     | .724      | .5316     | .4706     | .5068     |
| Avg  | .6515     | .6746     | .6268     | .724      | .6456     | .6386     | .6417     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 209 / 11KV. Kosgaon Agr.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | 1.2193    |           |           |           |           |           |           |
| 12   | 1.2193    |           |           |           | 1.0669    | 1.0669    | .8573     |
| 16   | 1.105     | 1.1431    | .9907     | 1.1431    | 1.0669    | 1.1431    | .9907     |
| Max  | 1.2193    | 1.1431    | .9907     | 1.1431    | 1.0669    | 1.1431    | .9907     |
| Min  | 1.105     | 1.1431    | .9907     | 1.1431    | 1.0669    | 1.0669    | .8573     |
| Avg  | 1.1812    | 1.1431    | .9907     | 1.1431    | 1.0669    | 1.105     | .924      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124046 / 33/11KV.BAMNOD

Feeder No / Name : 210 / 11 KV BHALOD AGR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .8124     | .7907     | .7499     | .8192     | .8002     |
| 8    | .8223     |           | .8124     | .852      | .8322     |
| 12   | .8539     |           |           |           |           |
| Max  | .8539     | .7907     | .8124     | .852      | .8322     |
| Min  | .8124     | .7907     | .7499     | .8192     | .8002     |
| Avg  | .8295     | .7907     | .7812     | .8356     | .8162     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 201 / 11 KV DONGARKATHORA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.475     | 1.5653    |           |           |           |
| 12   |           |           |           |           | 1.4577    | 1.3998    |           |
| 14   | .9511     | .7579     |           | .8128     |           | .7977     | .8962     |
| 15   |           |           | .7676     |           |           |           |           |
| 16   | .8768     | .8471     |           | .7827     | .8993     |           |           |
| 18   | .9659     | 1.0254    | .9332     |           | .945      | .9934     | 1.1043    |
| Max  | .9659     | 1.0254    | 1.475     | 1.5653    | 1.4577    | 1.3998    | 1.1043    |
| Min  | .8768     | .7579     | .7676     | .7827     | .8993     | .7977     | .8962     |
| Avg  | .9313     | .8768     | 1.0586    | 1.0536    | 1.1007    | 1.0636    | 1.0003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 202 / 11 KV M S S K

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0754     | .0739     | .0762     | .0762     | .0762     | .0761     | .0762     |
| 4    |           |           |           |           |           | .0761     |           |
| 6    | .0754     | .0739     | .0953     | .0762     | .0762     |           |           |
| 7    |           |           | .0762     |           |           | .0951     | .0762     |
| 9    |           | .0953     |           | .0953     | .1141     | .1143     |           |
| 10   | .0924     |           |           |           |           |           | .0739     |
| 11   |           |           | .1905     | .0762     |           |           |           |
| 12   |           |           |           |           | .1711     | .1715     |           |
| 14   | .0739     | .1715     |           | .1905     |           | .1715     | .0739     |
| 15   |           |           | .1334     |           |           |           |           |
| 16   | .0739     | .1334     |           | .1524     | .1521     |           |           |
| 18   | .0924     | .0762     | .0762     |           |           |           | .0739     |
| 19   |           |           |           |           | .0951     |           |           |
| 20   | .0739     | .0953     | .0762     | .0953     |           | .0762     | .0739     |
| 21   |           | .1143     |           |           | .0951     | .0762     |           |
| 24   | .0754     | .0739     |           | .0953     | .0953     |           |           |
| Max  | .0924     | .1715     | .1905     | .1905     | .1711     | .1715     | .0762     |
| Min  | .0739     | .0739     | .0762     | .0762     | .0762     | .0761     | .0739     |
| Avg  | .0791     | .1009     | .1034     | .1072     | .1094     | .1071     | .0747     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 203 / 11 KV MARUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.848     | 1.9004    | 1.9814    | 2.0767    | 1.9052    | 1.9433    | 1.9243    |
| 4    |           |           |           |           |           | 1.7147    |           |
| 6    | 1.848     | 1.9547    | 1.8861    | 1.9624    | 2.1148    |           | 1.829     |
| 7    |           |           | 2.1529    |           |           | 2.1338    | 2.0767    |
| 9    |           | 2.0767    |           | 1.8861    | 2.0576    | 1.9814    |           |
| 10   | 1.6651    |           |           |           |           |           | 1.6975    |
| 11   |           |           | 1.3336    |           |           |           |           |
| 12   |           |           |           |           | 1.1241    | 1.3146    |           |
| 14   | 1.2489    | 1.2574    |           | 1.3336    |           | 1.3336    | 1.3014    |
| 15   |           |           | 1.2765    |           |           |           |           |
| 16   | 1.1946    | 1.2955    |           | 1.2765    | 1.2359    |           |           |
| 18   | 1.3032    | 1.3527    | 1.3146    |           |           | 1.3717    | 1.358     |
| 19   |           |           |           |           | 1.3908    |           |           |
| 20   | 1.2851    | 1.4289    | 1.4098    | 1.3527    |           | 1.4289    | 1.4523    |
| 21   |           | 1.4861    |           |           | 1.467     | 1.4289    |           |
| 24   | 1.3717    | 1.267     |           | 1.1241    | 1.3336    |           |           |
| Max  | 1.848     | 2.0767    | 2.1529    | 2.0767    | 2.1148    | 2.1338    | 2.0767    |
| Min  | 1.1946    | 1.2574    | 1.2765    | 1.1241    | 1.1241    | 1.3146    | 1.3014    |
| Avg  | 1.4706    | 1.5577    | 1.6221    | 1.5732    | 1.5786    | 1.6279    | 1.6627    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 204 / 11 KV Hingona Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .362      | .4338     | .3761     | .3801     | .362      | .3654     | .4024     |
| 4    |           |           |           |           |           | .4568     |           |
| 6    | .6154     | .7545     | .6626     | .6154     | .6516     |           | .5487     |
| 7    |           |           | .5373     |           |           | .5664     | .5304     |
| 9    |           | .3658     |           | .4887     | .4568     | .4572     |           |
| 10   | .3206     |           |           |           |           |           | .4024     |
| 11   |           |           | .4207     | .3077     |           |           |           |
| 12   |           |           |           |           | .2741     | .3475     |           |
| 14   | .3206     | .3224     |           | .3077     |           | .3658     | .3292     |
| 15   |           |           | .4525     |           |           |           |           |
| 16   | .3395     | .3582     |           | .3258     | .3654     |           |           |
| 18   | .415      | .4119     | .5068     |           | .475      | .3658     | .4207     |
| 19   |           |           |           |           | .4338     |           |           |
| 20   | .5658     | .3582     | .4887     | .4706     |           | .4938     | .4938     |
| 21   |           | .4298     |           |           | .4385     | .4755     |           |
| 24   | .362      | .3395     |           | .3982     | .3982     |           |           |
| Max  | .6154     | .7545     | .6626     | .6154     | .6516     | .5664     | .5487     |
| Min  | .3206     | .3224     | .3761     | .3077     | .2741     | .3475     | .3292     |
| Avg  | .4126     | .4193     | .4921     | .4118     | .4284     | .4327     | .4468     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 205 / 11 KV HINGONA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.5402    | 1.6057    |           |           |           |
| 12   |           |           |           |           | 1.278     | 1.1888    |           |
| 14   | .9717     | .8383     |           | .8356     |           | .7716     | .8383     |
| 15   |           |           | .7701     |           |           |           |           |
| 16   | .8259     | .8025     |           | .7701     | .8383     |           |           |
| 18   | .8097     | .9755     | 1.0159    |           | 1.0202    | 1.1227    | .7209     |
| Max  | .9717     | .9755     | 1.5402    | 1.6057    | 1.278     | 1.1888    | .8383     |
| Min  | .8097     | .8025     | .7701     | .7701     | .8383     | .7716     | .7209     |
| Avg  | .8691     | .8721     | 1.1087    | 1.0705    | 1.0455    | 1.0277    | .7796     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 206 / 11 KV NHA VI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 2.0881    | 2.1186    |           |           |           |
| 12   |           |           |           |           | 1.9656    | 1.8595    |           |
| 14   | 1.326     | 1.3413    |           | 1.3717    |           | 1.3108    | 1.3757    |
| 15   |           |           | 1.2266    |           |           |           |           |
| 16   | 1.2498    | 1.3565    |           | 1.3108    | 1.336     |           |           |
| 18   | 1.4632    | 1.5242    | 1.4784    |           | 1.4127    | 1.4632    | 1.5023    |
| Max  | 1.4632    | 1.5242    | 2.0881    | 2.1186    | 1.9656    | 1.8595    | 1.5023    |
| Min  | 1.2498    | 1.3413    | 1.2266    | 1.3108    | 1.336     | 1.3108    | 1.3757    |
| Avg  | 1.3463    | 1.4073    | 1.5977    | 1.6004    | 1.5714    | 1.5445    | 1.439     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 207 / 11 KV BORKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0623    | 1.2269    | 1.142     | 1.0974    | 1.2334    | 1.142     | 1.0957    |
| 4    |           |           |           |           |           | .9259     |           |
| 6    | .9172     | .964      | .8333     | .8383     | .8855     |           | .7407     |
| 7    |           |           | .8482     |           |           | .8025     | .8179     |
| 9    |           | .9568     |           | .9907     | .9877     | .9877     |           |
| 10   | .964      |           |           |           |           |           | 1.0031    |
| Max  | 1.0623    | 1.2269    | 1.142     | 1.0974    | 1.2334    | 1.142     | 1.0957    |
| Min  | .9172     | .9568     | .8333     | .8383     | .8855     | .8025     | .7407     |
| Avg  | .9812     | 1.0492    | .9412     | .9755     | 1.0355    | .9645     | .9144     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 208 / 11 KV Khable Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0339     | .0335     | .0492     | .0343     | .0343     | .0343     | .0343     |
| 4    |           |           |           |           |           | .0168     |           |
| 6    | .0168     | .0168     | .0164     | .0171     | .0168     |           | .0347     |
| 7    |           |           | .0177     |           |           | .0335     | .0332     |
| 9    |           | .0328     |           | .048      | .0492     | .0332     |           |
| 10   | .0339     |           |           |           |           |           | .0343     |
| Max  | .0339     | .0335     | .0492     | .048      | .0492     | .0343     | .0347     |
| Min  | .0168     | .0168     | .0164     | .0171     | .0168     | .0168     | .0332     |
| Avg  | .0282     | .0277     | .0278     | .0331     | .0334     | .0295     | .0341     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 209 / 11 KV HAMBARDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6644    | 1.6324    | 1.7124    | 1.5851    | 1.6288    | 1.6004    | 1.692     |
| 4    |           |           |           |           |           | 1.2955    |           |
| 6    | 1.4083    | 1.3123    | 1.3603    | 1.2346    | 1.2967    |           | 1.3283    |
| 7    |           |           | 1.4403    |           |           | 1.3108    | 1.439     |
| 9    |           | 1.4403    |           | 1.3413    | 1.3763    | 1.4074    |           |
| 10   | 1.3603    |           |           |           |           |           | 1.5181    |
| Max  | 1.6644    | 1.6324    | 1.7124    | 1.5851    | 1.6288    | 1.6004    | 1.692     |
| Min  | 1.3603    | 1.3123    | 1.3603    | 1.2346    | 1.2967    | 1.2955    | 1.3283    |
| Avg  | 1.4777    | 1.4617    | 1.5043    | 1.387     | 1.4339    | 1.4035    | 1.4944    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124047 / 33/11 KV HAMBARDI

Feeder No / Name : 210 / 11KV Mor Dam

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11   |           |           | 1.5581    | 1.873     |           |           |           |
| 12   |           |           |           |           | 1.4255    | 1.5746    |           |
| 14   | 1.186     | 1.2492    |           | 1.326     |           | 1.2597    | 1.4089    |
| 15   |           |           | 1.2266    |           |           |           |           |
| 16   | 1.1544    | 1.2176    |           | 1.2431    | 1.3757    |           |           |
| 18   | 1.2651    |           | 1.2597    |           | 1.5154    | 1.5083    | 1.1603    |
| Max  | 1.2651    | 1.2492    | 1.5581    | 1.873     | 1.5154    | 1.5746    | 1.4089    |
| Min  | 1.1544    | 1.2176    | 1.2266    | 1.2431    | 1.3757    | 1.2597    | 1.1603    |
| Avg  | 1.2018    | 1.2334    | 1.3481    | 1.4807    | 1.4389    | 1.4475    | 1.2846    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124048 / 33/11 KV NHA VI

Feeder No / Name : 201 / 11 KV NHA VI - I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | 1.0753    | 1.0753    | 1.0722    | 1.0562    | 1.1385    | 1.2357    | 1.0242    |
| 16   | .8855     | .8855     | .9282     | .8962     | .9488     | 1.0745    | .8962     |
| Max  | 1.0753    | 1.0753    | 1.0722    | 1.0562    | 1.1385    | 1.2357    | 1.0242    |
| Min  | .8855     | .8855     | .9282     | .8962     | .9488     | 1.0745    | .8962     |
| Avg  | .9804     | .9804     | 1.0002    | .9762     | 1.0437    | 1.1551    | .9602     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124048 / 33/11 KV NHA VI

Feeder No / Name : 202 / 11 NHA VI II Gavathan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .9313     | .8596     | .9671     | .9671     | .9774     | .9671     | 1.0029    |
| 8    | .6805     | .7164     | .788      | .788      | .8238     | .8238     | .8238     |
| 12   | .5373     | .7164     |           |           | .6447     | .6805     | .6805     |
| 16   | .6447     | .6805     | .8059     | .8596     | .6447     | .7522     | .788      |
| 20   | .8775     | 1.0029    | .9671     | 1.0208    | .9313     | 1.0029    |           |
| 21   |           |           |           |           |           |           | .8954     |
| 23   | .788      |           | .8596     | .8954     | .8238     | .8954     | .8238     |
| 24   | .7164     | .7522     | .8238     | .8238     | .8596     | .788      | .8596     |
| Max  | .9313     | 1.0029    | .9671     | 1.0208    | .9774     | 1.0029    | 1.0029    |
| Min  | .5373     | .6805     | .788      | .788      | .6447     | .6805     | .6805     |
| Avg  | .7394     | .788      | .8686     | .8925     | .8150     | .8443     | .8391     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124048 / 33/11 KV NHA VI

Feeder No / Name : 203 / 11 KV JTM Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.3592    | 1.3765    | 1.4548    | 1.3413    | 1.2955    | 1.2967    | 1.3916    |
| 8    | 1.4373    | 1.4899    | 1.5023    | 1.3108    | 1.3927    | 1.3916    | 1.4232    |
| Max  | 1.4373    | 1.4899    | 1.5023    | 1.3413    | 1.3927    | 1.3916    | 1.4232    |
| Min  | 1.3592    | 1.3765    | 1.4548    | 1.3108    | 1.2955    | 1.2967    | 1.3916    |
| Avg  | 1.3983    | 1.4332    | 1.4786    | 1.3261    | 1.3441    | 1.3442    | 1.4074    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124048 / 33/11 KV NHA VI

Feeder No / Name : 204 / 11 KV KHARAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | 1.8061    | 1.6255    | 1.6347    | 1.5851    | 1.6872    | 1.5901    | 1.6156    |
| 16   | 1.0837    | 1.1439    | 1.1443    | 1.1584    | .5624     | 1.0105    | 1.0669    |
| Max  | 1.8061    | 1.6255    | 1.6347    | 1.5851    | 1.6872    | 1.5901    | 1.6156    |
| Min  | 1.0837    | 1.1439    | 1.1443    | 1.1584    | .5624     | 1.0105    | 1.0669    |
| Avg  | 1.4449    | 1.3847    | 1.3895    | 1.3718    | 1.1248    | 1.3003    | 1.3413    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124048 / 33/11 KV NHA VI

Feeder No / Name : 205 / 11 KV Shevadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | 2.1664    | 2.0805    | 1.9271    | 1.8724    | 2.1792    | 2.0405    | 2.0485    |
| 16   | 1.6762    | 1.5203    | 1.3765    | 1.5364    | 1.6385    | 1.5061    | 1.4563    |
| Max  | 2.1664    | 2.0805    | 1.9271    | 1.8724    | 2.1792    | 2.0405    | 2.0485    |
| Min  | 1.6762    | 1.5203    | 1.3765    | 1.5364    | 1.6385    | 1.5061    | 1.4563    |
| Avg  | 1.9213    | 1.8004    | 1.6518    | 1.7044    | 1.9089    | 1.7733    | 1.7524    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124098 / 33/ 11 KV SANGAVI BK

Feeder No / Name : 201 / 11 KV DHULE AGR .

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 2.7092    | 2.452     | 2.572     | .2915     | .3086     | .2572     | .3086     |
| 8    | 2.7949    | 2.7092    | 2.6749    | .1372     | .1886     | .12       | .2058     |
| 9    |           |           |           |           |           |           | .2058     |
| 12   | .1372     | .1543     | .12       | 3.1036    | 2.9664    | 3.0864    | 3.0178    |
| 16   | .1543     | .12       | .1543     | 2.6063    | 2.692     | 2.6578    | 2.6063    |
| 18   |           | .1715     | .1715     | 2.8121    | 2.5892    |           | 2.7263    |
| 20   | .2229     | .2058     | .2058     | .2229     | .1886     |           | .1886     |
| 21   |           |           |           |           |           | .2058     |           |
| 24   | .1715     | .1715     | .1715     | .1715     | .1715     | .1715     | .2058     |
| Max  | 2.7949    | 2.7092    | 2.6749    | 3.1036    | 2.9664    | 3.0864    | 3.0178    |
| Min  | .1372     | .12       | .12       | .1372     | .1715     | .12       | .1886     |
| Avg  | 1.0317    | .8549     | .8671     | 1.3350    | 1.3007    | 1.0831    | 1.1831    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124098 / 33/ 11 KV SANGAVI BK

Feeder No / Name : 202 / 11 KV SANGAVI BK GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.0631    | 1.0288    | 1.0802    | 1.166     | 1.0802    | 1.1317    | 1.2517    |
| 8    | .7545     | .6173     | .7202     | .7716     | .6859     | .6516     | .8573     |
| 10   |           |           |           |           |           |           | .8573     |
| 12   | .4801     | .4973     | .6001     | .5487     | .4801     | .5144     | .4801     |
| 16   | .6173     | .7202     | .6516     | .6173     | .6516     | .7716     | .6516     |
| 18   |           | .7716     | .7888     | .7716     | .703      |           | .7716     |
| 20   | .823      | .823      | .823      | .8402     | .823      |           | .823      |
| 21   |           |           |           |           |           | .7716     |           |
| 24   | .5487     | .6173     | .5316     | .6516     | .5487     | .6173     | .7716     |
| Max  | 1.0631    | 1.0288    | 1.0802    | 1.166     | 1.0802    | 1.1317    | 1.2517    |
| Min  | .4801     | .4973     | .5316     | .5487     | .4801     | .5144     | .4801     |
| Avg  | .7145     | .7251     | .7422     | .7667     | .7104     | .7430     | .8080     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124098 / 33/ 11 KV SANGAVI BK

Feeder No / Name : 203 / 11 KV MUNJOBA AGR.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           | 2.4348    | 2.3663    | 2.1091    | 2.2977    |
| 8    |           |           |           | 2.4177    | 2.4177    | 2.4691    | 2.4006    |
| 12   | 2.6235    | 2.7435    | 2.692     |           |           |           |           |
| 16   | 2.572     | 2.5206    | 2.4863    |           |           |           |           |
| 18   |           | 2.3663    | 2.5034    |           |           |           |           |
| Max  | 2.6235    | 2.7435    | 2.692     | 2.4348    | 2.4177    | 2.4691    | 2.4006    |
| Min  | 2.572     | 2.3663    | 2.4863    | 2.4177    | 2.3663    | 2.1091    | 2.2977    |
| Avg  | 2.5978    | 2.5435    | 2.5606    | 2.4263    | 2.392     | 2.2891    | 2.3492    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124133 / 33/11kv BHORTEK SBSTATION

Feeder No / Name : 201 / 11 KV DUSKHEDA Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .499      |           | .6283     | .4805     |           |           |
| 5    | .6283     |           | .6722     |           |           | .7095     | .6767     |
| 8    | .8029     | .8402     | .8215     | .8402     | .8316     | .7733     | .8215     |
| 12   | .4294     | .5544     | .4854     | .5601     | .5544     | .5415     | .5914     |
| 16   | .4706     | .499      | .6283     | .5544     | .5975     | .5601     | .5975     |
| 17   |           | .5359     |           |           |           |           |           |
| 19   |           |           | .8589     |           |           |           |           |
| 20   | .5611     | .6838     |           | .7207     | .6767     | .6219     | .6584     |
| 23   | .4298     | .4119     | .4252     | .4119     | .4298     | .4477     | .4252     |
| 24   | .4075     | .4119     | .394      | .3982     | .4119     | .4119     | .4075     |
| Max  | .8029     | .8402     | .8589     | .8402     | .8316     | .7733     | .8215     |
| Min  | .4075     | .4119     | .394      | .3982     | .4119     | .4119     | .4075     |
| Avg  | .5328     | .5545     | .6122     | .5877     | .5689     | .5808     | .5969     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124133 / 33/11kv BHORTEK SBSTATION

Feeder No / Name : 202 / 11kv TAPI kathora Agr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   | .503      | .5801     | .5121     | .5668     | .6203     | .6344     | .6133     |
| 16   | .5596     | .4915     | .5735     | .583      | .6371     | .5801     | .6133     |
| 17   |           | .4696     |           |           |           |           |           |
| Max  | .5596     | .5801     | .5735     | .583      | .6371     | .6344     | .6133     |
| Min  | .503      | .4696     | .5121     | .5668     | .6203     | .5801     | .6133     |
| Avg  | .5313     | .5137     | .5428     | .5749     | .6287     | .6073     | .6133     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124155 / 33/11 kv Pimprude  
substation.Feeder No / Name : 201 / 11 KV BANANA VALLEY  
FEEDER. Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 09-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 22   | 1.182     |
| Max  | 1.182     |
| Min  | 1.182     |
| Avg  | 1.182     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124155 / 33/11 kv Pimprude  
substation.Feeder No / Name : 202 / 11 KV Rajbag Faizpur  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | 1.0387    | 1.0848    |           |           |           |
| 3    |           |           |           |           |           |           | 1.0387    |
| 4    |           |           |           | 1.1391    |           | 1.0848    |           |
| 5    |           |           | 1.1765    |           |           |           |           |
| 6    | 1.1584    | 1.1596    |           | 1.1752    |           |           | 1.1999    |
| 7    |           |           | 1.1222    | 1.1946    |           |           |           |
| 8    | 1.0498    | 1.0146    | .9955     | 1.086     | 1.0487    | 1.1571    | 1.0566    |
| 9    |           |           | .9593     |           |           |           |           |
| 10   |           |           | .9955     |           |           | 1.182     | 1.0487    |
| 11   | .9774     |           | .9593     |           |           |           | .9763     |
| 12   |           |           | .9593     | 1.0136    | .9944     | 1.0745    | .9583     |
| 13   |           |           | .905      |           |           |           | .9763     |
| 15   |           |           |           |           |           | 1.0387    |           |
| 16   | .9774     | .9955     | 1.0317    |           | 1.0667    |           | 1.0848    |
| 17   |           |           | 1.0136    | 1.1752    |           |           | 1.0487    |
| 18   |           |           | .9221     |           |           | 1.1999    | 1.0667    |
| 19   |           | 1.2851    | 1.4103    |           |           |           |           |
| 20   | 1.2308    |           | 1.4103    | 1.2462    | 1.3018    |           | 1.3741    |
| 21   |           |           | 1.3199    |           |           |           | 1.3379    |
| 24   | 1.0667    | 1.1403    | 1.1104    | 1.1933    | 1.1379    | 1.2114    | 1.182     |
| Max  | 1.2308    | 1.2851    | 1.4103    | 1.2462    | 1.3018    | 1.2114    | 1.3741    |
| Min  | .9774     | .9955     | .905      | 1.0136    | .9944     | 1.0387    | .9583     |
| Avg  | 1.0768    | 1.1190    | 1.0831    | 1.1453    | 1.1099    | 1.1355    | 1.1038    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124155 / 33/11 kv Pimprude  
substation.

Feeder No / Name : 203 / 11 KV VIRODA SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | 1.7404    | 1.9018    |           |           |           |
| 3    |           |           |           |           |           |           | .5243     |
| 4    |           |           |           | 1.8852    |           | .6291     |           |
| 5    |           |           | 1.7532    |           |           |           |           |
| 6    | .8961     | 2.0861    |           | 2.001     |           |           | .7865     |
| 7    |           |           | 1.7859    | 2.1168    |           |           |           |
| 8    | .4818     | 2.1523    | 2.0481    | 2.1143    | 2.0978    | .4636     | .4588     |
| 9    |           |           | 2.0648    |           |           |           |           |
| 10   |           |           | 1.85      |           |           | .3605     | .3642     |
| 11   | 2.1597    |           | .3469     |           |           |           | 2.202     |
| 12   |           |           | .3634     | .3304     | .3304     | 2.2611    | 2.2516    |
| 13   |           |           | .3634     |           |           |           | 2.2682    |
| 15   |           |           |           |           |           | 2.2775    |           |
| 16   | 2.2045    | .3113     | .3799     |           | .413      | 2.13      |           |
| 17   |           |           | .3964     | .3964     |           |           | 2.1498    |
| 18   |           |           | .5121     |           |           | 2.1136    | 2.0837    |
| 19   |           | .639      | .6615     |           |           |           |           |
| 20   | .6291     |           | .6083     | .6607     | .6277     |           | .6615     |
| 21   |           |           | .6119     |           |           |           | .6449     |
| 22   |           | .6062     |           |           |           |           |           |
| 24   | .5127     | .5304     | .5304     | .4961     | .5457     | .5457     | .5407     |
| Max  | 2.2045    | 2.1523    | 2.0648    | 2.1168    | 2.0978    | 2.2775    | 2.2682    |
| Min  | .4818     | .3113     | .3469     | .3304     | .3304     | .3605     | .3642     |
| Avg  | 1.1473    | 1.0542    | 1.0010    | 1.3225    | .8029     | 1.3476    | 1.2447    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124165 / 33/11 KV Dongarkathora

Feeder No / Name : 201 / 11 kv Dongarkathora  
gaothan fe Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1448     | .1219     | .2172     | .1448     | .181      | .2172     | .2172     |
| 2    | .1448     |           | .2172     | .1448     | .181      | .181      | .181      |
| 3    |           | .12       | .1991     |           | .181      | .181      | .181      |
| 4    | .181      |           | .1991     | .181      | .1991     | .181      | .1991     |
| 5    |           | .16       | .2715     |           | .1991     |           | .2353     |
| 6    | .2172     | .1867     | .2534     | .2896     | .2172     | .1991     | .2715     |
| 7    | .2534     | .16       | .2534     | .2667     | .2353     | .2353     | .2353     |
| 8    | .1991     | .181      | .1991     | .1991     | .181      | .1991     | .1991     |
| 9    |           | .2715     |           |           |           | .3077     |           |
| 10   | .2        | .2715     |           | .181      | .2896     | .2715     | .1905     |
| 11   |           | .2715     |           |           |           | .2896     |           |
| 12   | .1334     | .181      |           | .1991     | .2896     | .1991     | .1905     |
| 13   |           | .2172     |           |           |           | .2172     |           |
| 14   | .1067     | .2715     |           | .1629     | .2896     | .1991     |           |
| 15   |           | .2534     |           |           |           | .181      |           |
| 16   | .1867     | .181      |           | .181      | .2896     | .2172     | .2286     |
| 17   |           | .2172     |           |           |           | .2172     |           |
| 18   | .2534     | .2353     | .3429     | .2172     | .3439     | .2715     | .1905     |
| 19   | .2534     | .2715     |           |           |           | .2353     |           |
| 20   | .3429     | .3258     |           |           | .3439     | .362      |           |
| 21   |           | .2715     |           | .2172     | .3258     | .3258     |           |
| 22   |           | .2715     |           |           | .3439     | .2715     |           |
| 23   |           | .2353     | .1905     |           | .3439     | .2715     |           |
| 24   | .1629     | .12       | .2534     |           | .181      | .3439     | .2715     |
| Max  | .3429     | .3258     | .3429     | .2896     | .3439     | .362      | .2715     |
| Min  | .1067     | .12       | .1905     | .1448     | .181      | .181      | .181      |
| Avg  | .1986     | .2180     | .2361     | .1987     | .2564     | .2424     | .2147     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124165 / 33/11 KV Dongarkathora

Feeder No / Name : 202 / 11 KV Dattamandir Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 2.1451    |           | 2.1605    | 2.1125    |           |
| 2    |           |           | 2.1914    |           | 2.1605    | 2.1605    |           |
| 3    |           |           | 2.1914    |           | 2.1451    |           |           |
| 4    |           |           |           |           | 2.1296    | 2.1125    |           |
| 5    |           |           |           |           | 2.1296    |           |           |
| 6    |           |           | 2.2377    |           | 2.0988    | 2.1605    |           |
| 7    |           |           | 2.1759    |           | 2.0988    | 2.0525    |           |
| 8    |           |           | 2.2068    |           | 2.2685    | 2.1605    |           |
| 9    |           |           |           |           |           | 2.1914    |           |
| 10   |           |           | 2.42      |           | 2.6092    | 2.2068    |           |
| 11   | 2.6406    | 2.2222    |           |           |           |           | 2.4905    |
| 12   | 2.692     | 2.2685    |           |           |           |           |           |
| 13   |           | 2.2377    |           |           |           |           |           |
| 14   |           | 2.2222    |           |           |           |           |           |
| 15   |           | 2.2222    |           |           |           |           |           |
| 16   | 2.6578    | 2.2531    |           |           |           |           | 2.42      |
| 17   |           | 2.2222    |           |           |           |           |           |
| 18   | 2.6063    | 2.2068    |           |           |           |           | 2.4417    |
| 19   |           |           |           | 2.3148    |           |           |           |
| 20   |           |           |           | 2.3148    |           |           |           |
| 21   |           |           |           | 2.284     |           |           |           |
| 24   |           |           |           | 2.5265    | 2.2222    |           |           |
| Max  | 2.692     | 2.2685    | 2.42      | 2.5265    | 2.6092    | 2.2068    | 2.4905    |
| Min  | 2.6063    | 2.2068    | 2.1451    | 2.284     | 2.0988    | 2.0525    | 2.42      |
| Avg  | 2.6492    | 2.2319    | 2.2240    | 2.3600    | 2.2023    | 2.1447    | 2.4507    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

JALGAON ZONE[058]

JALGAON CIRCLE[590]

SAVADA DIVISION[592]

YAWAL I[246]

BU 0639

Substation No/ Name :- 124165 / 33/11 KV Dongarkathora

Feeder No / Name : 203 / 11 KV Swaminarayan

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 08-APR-18 | 09-APR-18 | 10-APR-18 | 11-APR-18 | 12-APR-18 | 13-APR-18 | 14-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.6289    |           |           |           |           | 1.5384    |
| 2    | 1.4403    | 1.6289    |           |           |           |           | 1.5384    |
| 3    |           |           |           |           |           |           | 1.5384    |
| 4    | 1.5203    |           |           |           |           |           | 1.7375    |
| 5    |           |           |           |           |           |           | 1.7194    |
| 6    | 1.5524    | 1.6632    |           |           |           |           | 1.5384    |
| 7    | 1.5524    | 1.6975    |           |           |           |           | 1.5546    |
| 8    | 1.5844    | 1.7004    |           |           |           |           | 1.6194    |
| 9    |           | 1.668     |           |           |           |           |           |
| 10   | 1.8004    | 1.668     |           |           |           |           | 1.7101    |
| 11   |           |           | .2054     | 1.6164    | 1.5497    | 1.7166    |           |
| 12   |           |           |           | 1.6644    | 1.5432    | 1.7328    |           |
| 13   |           |           |           |           |           | 1.7328    |           |
| 14   |           |           |           | 1.6324    | 1.5813    | 1.7328    |           |
| 15   |           |           |           |           |           | 1.7004    |           |
| 16   |           |           | 1.8442    | 1.6004    | 1.4706    | 1.7004    |           |
| 17   |           |           |           |           |           | 1.6842    |           |
| 18   |           |           | 1.7695    | 1.5524    | 1.4232    | 1.668     |           |
| Max  | 1.8004    | 1.7004    | 1.8442    | 1.6644    | 1.5813    | 1.7328    | 1.7375    |
| Min  | 1.4403    | 1.6289    | .2054     | 1.5524    | 1.4232    | 1.668     | 1.5384    |
| Avg  | 1.5750    | 1.6650    | 1.2730    | 1.6132    | 1.5136    | 1.7085    | 1.6105    |