

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1029	.1029	.12	.1543	.1029
2	.12	.1543	.1029	.1029	.12	.1543	.1029
3	.12	.1543	.1029	.1029	.12	.1543	.1029
4	.12	.1543	.1029	.1029	.12	.1543	.1029
5	.12	.1543	.1029	.1029	.12	.1543	.1029
6	.08	.1029	.0343	.0343	.04	.1029	.0343
7	.04	.0514	.0343	.0343	.04	.0514	.0343
8	.04	.0514	.0343	.0343	.04	.0514	.0343
9	.04	.04	.0343	.0343	.04	.0514	.0343
10	.0343	.04	.04	.0514	.0343	.04	.04
11	.0343	.04	.04	.0514	.0343	.04	.04
12	.0343	.04	.04	.0514	.0343	.04	.04
13	.0343	.04	.04	.0514	.0343	.04	.04
14	.0343	.04	.04	.0514	.0343	.04	.04
15	.0343	.04	.04	.0514	.0343	.04	.04
16	.0343	.04	.04	.0514	.0343	.04	.04
17	.0343	.04	.04	.04	.0343	.04	.04
18	.0514	.0343	.0343	.04	.0514	.0343	.04
19	.0514	.0343	.0343	.04	.0514	.0343	.08
20	.1543	.1029	.1029	.1543	.1543	.1029	.12
21	.1543	.1029	.1029	.12	.1543	.1029	.12
22	.1543	.1029	.1029	.12	.1543	.1029	.12
23	.1543	.1029	.1029	.12	.1543	.1029	.12
24	.12	.1543	.1029	.1029	.12	.1543	.1029
Max	.1543	.1543	.1029	.1543	.1543	.1543	.12
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0798	.0822	.0648	.0729	.0781	.0826	.0698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 202 / 11 KV BULDANA - II
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.439	.4458	.4801	.439	.3658	.4115
2	.4287	.439	.4458	.4801	.3658	.3658	.4115
3	.4287	.439	.4115	.4458	.3658	.3658	.3772
4	.4115	.439	.4115	.4115	.3658	.3658	.3429
5	.4115	.3841	.3772	.3772	.3658	.3292	.3086
6	.3772	.3658	.3772	.3772	.3292	.3292	.3086
7	.3601	.3658	.3772	.3429	.2926	.3109	.3429
8	.3772	.3658	.3429	.3429	.2926	.3109	.3772
9	.4287	.4115	.3772	.3944	.3292	.3109	.4115
10	.5487	.5487	.4755	.567	.5487	.3429	.5487
11	.583	.6859	.6584	.7133	.6516	.4115	.6584
12	.6859	.7202	.6584	.7133	.6516	.4287	.7316
13	.7888	.6859	.695	.7865	.6173	.4115	.7316
14	.6859	.6859	.6584		.6516	.3772	.7316
15	.6859	.6859	.5853	.7316	.6516	.4115	.7316
16	.6859	.6859	.7316	.8048	.6173	.3772	.7316
17	.6859	.6859	.7316	.7316	.6516	.4287	.7316
18	.5853	.6173	.6173	.6584	.5853	.4115	.6516
19	.5487	.5487	.583	.5487	.5121	.4801	.5487
20	.5853	.5487	.5487	.5853	.5487	.4458	.5144
21	.4938	.4801	.5487	.5281	.439	.4458	.4801
22	.4755	.4801	.4458	.439	.4024	.4115	.4115
23	.4755	.4801	.4287	.4755	.4024	.4115	.4458
24	.4801	.4572	.4458	.4801	.4755	.3841	.4115
Max	.7888	.7202	.7316	.8048	.6516	.4801	.7316
Min	.3601	.3658	.3429	.3429	.2926	.3109	.3086
Avg	.5291	.5269	.5158	.5398	.4814	.3847	.5147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 203 / 11 KV Town-III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.695	.6401	.6097	.7316	.6219	.5487
2	.6097	.6584	.6097	.5792	.6584	.6219	.5487
3	.6516	.6401	.6097	.5792	.6584	.5853	.5182
4	.6516	.6401	.5792	.5487	.6584	.5487	.4877
5	.5487	.5853	.5487	.5182	.6219	.5121	.4572
6	.5487	.6219	.5487	.5182	.5853	.5121	.4268
7	.5335	.6036	.5487	.5487	.5487	.5121	.4268
8	.583	.5853	.5487	.5487	.5853	.4938	.4268
9		.5144	.4877	.4268	.5487	.4755	.4268
10	.4877	.4801	.5853	.567	.4572	.3963	.5121
11	.5182	.4268	.5853	.5487	.4572	.4287	.439
12	.4877	.5487	.6219	.6219	.4572	.4268	.5121
13	.5182	.5487	.5487	.5853	.4877	.4458	.4755
14	.5182	.5144	.6584	.695	.5487	.4115	.5121
15	.6371	.4877	.695	.7316	.5487	.3772	.5121
16	.5792	.5487	.6584	.6584	.4877	.3658	.5487
17	.5487	.5487	.6584	.6219	.5182	.463	.5121
18	.6584	.503	.5487	.6584	.5853	.4268	.4877
19	.6219	.5792	.5792	.6584	.5853	.4572	.5487
20	.695	.6097	.6401	.695	.695	.4877	.6173
21	.695	.6097	.6097	.7316	.6584	.5182	.5487
22	.7316	.6097	.6401	.5335	.695	.5487	.6516
23	.7316	.6097	.7011	.7316	.695	.5792	.6516
24	.6554	.7316	.6401	.6097	.7316	.6584	.5487
Max	.7316	.7316	.7011	.7316	.7316	.6584	.6516
Min	.4877	.4268	.4877	.4268	.4572	.3658	.4268
Avg	.6009	.5792	.6038	.6052	.5919	.4948	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 204 / 11 KV KOLWAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.4435	1.2346	1.3032		1.1458	1.0288
2	1.2346	1.3306	1.166	1.2003	.6653	1.1088	.9945
3	1.0974	1.3306	1.0974	1.0974	1.2567	1.0534	.9259
4	1.0288	1.2012	1.0288	1.0288	1.1088	.9979	.8573
5	1.0288	1.1643	.9602	.9602	1.0349	.961	.823
6	.9602	1.0164	.9259	.9259	.9979	.8686	.7888
7	.9259	.9425	.8916	.8916	.924	.8501	.7202
8	.8059	.9055	.8916	.8916	1.1273	.8131	.7545
9		.8745	.8916	.8916	1.1458	.7762	.7545
10	.9259	1.0117	1.0164	1.0719	1.0631	.7545	.924
11	.9431	1.1145	1.1273	1.1888	1.0974	.6859	1.1088
12	1.2003	1.1317	1.2936	1.2567	1.0974	.8573	1.1088
13	1.2689	1.2346	1.2752	1.4415	1.2003	.8745	1.1827
14	.4458	1.286	1.4045	1.46	1.2346	.8573	1.2567
15	1.4403		1.6078	1.5708	1.3032	.8745	1.3306
16	1.3717	1.3546	1.46	1.5708	1.2346	.9088	1.386
17	1.3032	1.2689	1.4045	1.4784	1.2003	.8916	1.2197
18	1.3121	1.166	1.2003	1.3491	1.1273	.8916	1.0802
19	1.3306	1.2346	1.2346	1.3306	1.2012	.9431	1.1488
20	1.3306	1.2689	1.286	1.423	1.2382	.9945	1.2003
21	1.2936	1.2346	1.3032	1.2936	1.1827	1.0288	1.166
22	1.386	1.2689	1.3375	1.3491	1.2752	1.0288	1.166
23	1.46	1.3375	1.406	1.423	1.2936	1.0974	1.286
24	1.3546	1.4415	1.286		1.4045	1.2012	1.0974
Max	1.46	1.4415	1.6078	1.5708	1.4045	1.2012	1.386
Min	.4458	.4435	.8916	.8916	.6653	.6859	.7202
Avg	1.1601	1.1549	1.1971	1.2347	1.1484	.9360	1.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 209 / 11 KV Ekta Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.4632	1.406	1.406	1.4632	1.6827	1.5089
2	1.3032	1.3535	1.3032	1.3375	1.3717	1.6095	1.4746
3	1.2346	1.3169	1.2346	1.2689	1.7193	1.5546	1.4403
4	1.1145	1.2803	1.2003	1.2003	1.6095	1.4815	1.3717
5	1.1145	1.2437	1.166	1.166	1.4998	1.3306	1.3032
6	1.0288	1.1157	1.1145	1.1317	1.4266	1.3169	1.2346
7	.9945	1.0608		1.0974	1.4266	1.3535	1.2689
8	.9259	1.0974	1.0288	.9945	1.3352	1.2437	1.2346
9		.0514	.9602	1.0288	1.3352	1.262	1.2003
10	.9259	.0514	1.4266	1.1157	1.286	1.046	1.1888
11	.9602	.0686	1.4266	1.0974	1.3032	1.0288	.9877
12	.9945	.0686	1.4815	1.0425	1.286	1.1145	1.134
13	1.0631	.0514	1.5181	1.134	1.3375	1.0802	1.1888
14	1.166	1.4232	1.6095	1.2254	1.3717	1.0974	1.2803
15	1.2003	1.3375	1.829	1.2986	1.4575	1.1317	1.4266
16	1.166	1.3889	1.7193	1.2803	1.4403	1.1145	1.4449
17	1.166	1.2174	1.5729	1.2071	1.3717	1.2003	1.3535
18	1.0791	1.0974	1.4403	1.1706	1.3535	1.2003	1.2517
19	1.2071	1.2003	1.0974	1.2071	1.4815	1.2689	1.3717
20	1.3717	1.3375	1.2689	1.4083	1.6278	1.406	1.5604
21	1.4449	1.3375	1.3375	1.4083	1.6278	1.4746	1.6118
22	1.5181	1.4403	1.4746	1.5364	1.7741	1.5432	1.749
23	1.6095	1.5432		1.6095	1.8107	1.6461	1.8347
24	1.5432	1.5364	1.4746	1.4746	1.5181	1.7558	1.5432
Max	1.6095	1.5432	1.829	1.6095	1.8107	1.7558	1.8347
Min	.9259	.0514	.9602	.9945	1.286	1.0288	.9877
Avg	1.1988	1.0451	1.3677	1.2436	1.4681	1.3310	1.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 200 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	29-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
6		.1143	
8	.1143		
9			.1097
24		.1143	
Max	.1143	.1143	.1097
Min	.1143	.1143	.1097
Avg	.1143	.1143	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 201 / 11KV DONGAR SHEOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0305	.0351	.0762	.0351	.0648	.1783
2	.0762	.0305	.0354	.0762	.0347	.0648	.1677
3	.0762	.0305	.0347	.0762	.0347	.0648	.1619
4	.0762	.0305	.0351	.0762	.0343	.0648	.1341
5	.0762	.0305	.0347	.0762	.0343	.0671	.1341
6	.0762	.0305	.0351	.0762	.0347	.0648	
7	.0762	.0343	.0351	.0762		.0648	.2286
8	.0762		.0351	.1143		.0648	.2012
9	.0762	.0305	.0351	.0762	.1715	.1943	.0671
10	.2058		.3048	.2713		.2267	.0648
11	.3429	.1696	.2858	.2401		.2591	.0648
12	.3048	.1715	.2858	.2035		.1943	.0648
13	.4287	.1865	.3048	.2543		.1943	.0648
14	.3429	.2058	.3048			.1296	.0648
15		.2035	.2667			.1943	.0648
16	.1524	.2012	.2286	.2572		.1943	.0671
17	.1524	.2713	.3048	.2743		.0648	.0671
18	.0305	.0526	.0762	.0351	.0648	.0648	.0671
19	.0305	.0351	.0762	.0526	.0648	.0972	.0671
20	.0305	.0347	.0762	.0347	.0648	.0648	.0648
21	.0343	.0351	.0762	.0351	.0648	.0671	.0648
22	.0457	.0351	.0762	.0351	.0648	.0671	.0648
23	.061	.0343	.0762	.0351		.1341	.1296
24	.0762	.0305	.0351	.1829	.0351	.0648	.1619
Max	.4287	.2713	.3048	.2743	.1715	.2591	.2286
Min	.0305	.0305	.0347	.0347	.0343	.0648	.0648
Avg	.1271	.0870	.1289	.1198	.0568	.1138	.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 202 / 11KV KINHOLA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0305		.0381	.0347	.0324	.1677
2	.0381	.0305		.0381	.0347	.0335	.1619
3	.0381	.0343		.0381	.0343		.1619
4	.0381	.0343		.0381	.0351		.1943
5	.0381	.0305		.0381	.0351		.1619
6	.0381	.0305			.0351		.1619
7	.0381	.0343		.0381			.1619
8	.0381	.0343		.0381			.1677
9	.0381	.0305		.0762	.0526		.0324
10	.1524		.1905	.2035	.0335	.1619	.0335
11	.1715		.2286	.2035	.1943	.1619	.0335
12	.2058		.2286	.2401	.2429	.1619	.0324
13	.1715		.2286	.2543	.2429	.2012	.0648
14	.1829		.2286	.2374	.2515	.1943	.0648
15	.1524		.2286	.2401	.2429	.2429	.0324
16	.2286		.2286	.2572	.1619	.1619	.0324
17	.1715		.2286	.2572	.0335	.0324	.0335
18	.0343		.0381	.0351	.0324	.0335	.0335
19			.0381	.0351	.0335	.0324	.0381
20	.0305		.0381	.052	.0324	.0324	.0335
21	.0343		.0381	.0526	.0324	.0335	.0324
22	.0305		.0381	.0526	.0324	.0335	.0324
23	.0305		.0381	.0526	.0324	.1619	.1581
24	.0381	.0305		.1524	.0351	.0324	.1619
Max	.2286	.0343	.2286	.2572	.2515	.2429	.1943
Min	.0305	.0305	.0381	.0351	.0324	.0324	.0324
Avg	.0860	.0320	.1442	.1160	.0862	.1026	.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 203 / 11KV SHELSUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2286	.285	.1905	.2915	.2915	.1619
2	.3048	.3429	.3052	.1905	.3222	.3239	.1677
3	.3048	.3048	.3086	.1905	.3086	.2591	.2012
4	.3048	.3048	.3391	.1905	.373	.2915	.1677
5	.381	.4268	.3688	.3429	.4458	.2591	.1781
6	.381	.4572	.4527	.381	.57	.4372	.1619
7	.5716	.6859	.503	.1143		.5992	.1341
8	.4191	.3048	.373	.6668		.6478	.1509
9	.381	.3353	.3258	.6668	.0867	.1619	.2347
10	.0686	.2103	.1905	.1928	.1943	.1619	.3887
11	.061	.2103	.0381	.1227	.1943	.1486	.4694
12	.0514	.1907	.0381	.0876		.1677	.3353
13	.0305	.1734	.0762				.4024
14	.0305	.1715	.0762	.1886	.1341	.1677	.2096
15	.0305	.1715	.1524	.1928	.1457	.1943	.2429
16	.0343	.2103	.1524	.1928	.1677	.1943	.2753
17	.0686	.2103	.1524	.156		.1619	.1457
18	.061	.2103	.1524	.1715		.1677	.3725
19	.0514	.1928	.1905	.1734	.0671	.1619	.4862
20	.0305	.1928	.1905	.1928	.1296	.1457	.1619
21	.0339	.208	.1905	.1928	.1457	.1296	.1619
22	.0305	.2058	.1905	.156	.1619	.1509	.1619
23	.0305	.2103	.1905	.2543	.2591	.1619	.1677
24	.381	.2572	.2543	.0762	.3052	.3239	.1677
Max	.5716	.6859	.503	.6668	.57	.6478	.4862
Min	.0305	.1715	.0381	.0762	.0671	.1296	.1341
Avg	.1811	.2674	.2290	.2297	.2390	.2482	.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 204 / 11 KV D SHEWALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5144	.5373	.5335	.3761	.4858	
2	.5716	.4268	.5731	.5335	.3982	.4858	.4858
3	.5716	.4572	.6154	.5335	.4835	.4725	.4858
4	.5716	.6516	.6697	.7621	.6268	.5365	.6154
5	.7621	.7202	.7059	.7621	.7421	.6478	.5182
6	.7621	.7716	.788	.8002	.8238	.7935	.7287
7		.6859		.724		.0648	.7449
8	.8002	.5639	.7164	.7049		.5796	.664
9	.6478	.5316	.5792	.6287	.6089		.5182
10	.6036		.5716			.583	.4534
11	.4973	.394	.5716			.4858	.3856
12	.4268	.362	.4763			.3563	.3887
13	.4115	.3045	.4763			.3353	.3688
14	.4801	.3258	.4763			.3563	.3401
15	.4801	.3045	.4763			.4024	.4049
16	.4973	.4706	.5335			.4359	.3887
17	.4973	.5068	.5716			.503	.3887
18	.4877	.5792	.8573		.7449	.6203	.6036
19	.6401	.5373	.8573		.7125	.6154	.6539
20	.7164	.4887	.8002		.7125	.7125	.7377
21	.6401	.394	.743		.6478	.6371	.6154
22	.5792	.5014	.6478			.5344	.5506
23	.5316	.4477	.5716		.502	.5182	.5182
24	.5716	.4268	.4344		.362	.4858	.4858
Max	.8002	.7716	.8573	.8002	.8238	.7935	.7449
Min	.4115	.3045	.4344	.5335	.362	.0648	.3401
Avg	.5791	.4942	.6196	.6647	.5955	.5064	.5237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 206 / SHELSUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2035	.3403	.3239	.3582	.2591	.3018
2	.3048	.1981	.3439	.3239	.394	.2915	.2267
3	.3048	.2134	.3582	.3239	.4344	.3239	.1677
4	.4763	.2743	.3761	.4763	.4656	.3239	.3018
5	.5716	.3048	.394	.5335	.5373	.3563	.3353
6	.6097	.463	.3898	.5716	.5792	.4049	.3725
7	.5335	.4458	.4344	.4954		.3401	.4534
8		.3658	.4298	.4572		.3401	.3725
9	.3048	.3048	.3982	.4191	.3582	.3018	.2429
10	.3086	.2896	.362	.362	.1781	.2753	.2429
11	.2743	.2507	.2858	.3224	.1783	.1943	.2105
12	.2439	.2507	.2858	.2865	.1677	.1943	.2012
13	.2915	.2353	.2858	.2715	.1619	.1943	.2347
14	.2401	.2149	.2858	.2507	.1619	.2267	.2347
15	.2743	.2507	.3048	.2353	.285	.2347	.2429
16	.3086	.2713	.3429	.2715	.1943	.2591	.2591
17	.2401	.3189	.381	.3224	.2915	.3239	.2915
18	.3429	.394	.4572	.4298	.3239	.2753	.3401
19	.3772	.543	.4954	.394	.4191	.3018	.3239
20	.463	.5068	.4954	.3982	.3563	.4024	.3887
21	.3353	.4477	.4001	.3366	.3239	.3563	.3563
22	.2743	.4298	.381	.3582	.3239	.2591	.2591
23	.2058	.3801	.3429	.3258	.1619	.2429	.2429
24	.3429	.2229	.3258	.1829	.3258	.2915	.3239
Max	.6097	.543	.4954	.5716	.5792	.4049	.4534
Min	.2058	.1981	.2858	.1829	.1619	.1943	.1677
Avg	.3449	.3242	.3707	.3614	.3173	.2906	.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 201 / 11KV NANDRAKOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.3772	.415	.415	.3391	.3429	.4024
2	.3561	.3944	.4527	.4527	.3391	.3429	.4938
3	.373	.4115	.4527	.4904	.373	.3772	.4755
4	.4239	.5487	.5658	.6036	.4239	.6516	.695
5	.5087	.823	.6413	.7545	.5087	.8402	.9145
6	.9496	.9431	1.0185	1.0185	.8139	.9431	.9877
7	.78	.8402	.9054	.8299	.7461	.7716	1.0059
8	.6783	.6516	.7545	.7167	.6274	.703	
9	.5087	.4973	.5658	.5658	.4409	.463	.5121
10	.3222	.3772	.415	.3772	.3391	.3772	.4024
11	.4588	.3647	.431	.3605	.3441	.3086	.4115
12	.426	.3647	.4641	.4096	.3605	.3429	.3315
13	.4527	.2984	.3978	.3605	.426	.3772	.3353
14	.3353	.3315	.3647	.3277	.3277	.3429	.3277
15	.4024	.3647	.3647	.3605	.3605	.3772	.2949
16	.4527	.3978	.3647	.3932	.3605	.4458	.2949
17	.4694	.431	.431	.4096	.3441	.4458	.3605
18	.4862	.4973	.4641	.4915	.4096	.5487	.4915
19	.7545	.7762	.6722	.6274	.6001	.6859	.7762
20	.7373	.8299	.7842	.6952	.6516	.6173	.6722
21	.5144	.6036	.5658	.4748	.463	.5121	.5658
22	.4458	.4904	.4527	.407	.4115	.4755	.4527
23	.3944	.4527	.415	.373	.3772	.4024	.415
24	.373	.3772	.415	.415	.3561	.3601	.3841
Max	.9496	.9431	1.0185	1.0185	.8139	.9431	1.0059
Min	.3222	.2984	.3647	.3277	.3277	.3086	.2949
Avg	.4983	.5185	.5322	.5137	.4477	.5023	.5219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 203 / 11KV KOLWAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6952	.703	.7545	.7922	.7122	.703	.7316
2	.6952	.7373	.7922	.8299	.7122	.6859	.7682
3	.7122	.7716	.7922	.8299	.7291	.7202	.8779
4	.78	.8573	.8676	.8299	.78	.9259	.9877
5	.8817	1.0288	1.0185	1.0185	.8309	1.0288	1.0974
6	1.1869	1.1145	1.3169	1.2449	1.1361	1.1317	1.1706
7	.8817	.823	1.0829	1.1317	.9326	.9945	1.0425
8	.8139	.7545	1.0185	.9431	.8309	.8916	.9511
9	.3391	.7202	.415	.7167	.6952	.6687	.7499
10	.2713	.3395	.2641	.6413	.5935	.2401	.5121
11		.2984	.431	.6226	.5407	.4801	.4801
12		.2984	.4641	.6226	.4915	.3772	.4024
13	.57	.2652	.4641	.5735	.4752	.4115	.4694
14	.6539	.5636	.4973	.5243	.4588	.3772	.4588
15	.6539	.4641	.5304	.5243	.4752	.3772	.3932
16		.5967	.5636	.5735	.4915	.4801	.3932
17	.6036	.663	.5636	.6554	.5571	.4458	.5243
18	.6203	.5967	.5304	.5735	.4588	.4115	.5243
19	.9602	.9979	.8589	.763	.8916	.9511	.924
20	.9431	1.1694	1.0082	.9835	.7716	.9877	1.0082
21	.823	.9808	.9808	.8478	.8573	.8779	.9808
22	.7545	.9054	.9054	.78	.823	.8048	.9054
23	.7545	.8299	.8299	.7291	.7373	.7499	.7922
24	.7122	.703	.7545	.7922	.7291	.703	.7499
Max	1.1869	1.1694	1.3169	1.2449	1.1361	1.1317	1.1706
Min	.2713	.2652	.2641	.5243	.4588	.2401	.3932
Avg	.7289	.7159	.7377	.7726	.6963	.6844	.7456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 205 / AMBHODA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.2915	.3395	.6036	.2883	.2915	.3109
2	.2713	.3086	.3772	.679	.2883	.3086	.3658
3	.3052	.3086	.415	.7545	.3052	.3429	.3658
4	.3391	.4801	.4527	1.0562	.373	.5316	.567
5	.39	.6516	.5658	1.3203	.4409	.6859	.7316
6	.763	.7545	.8048	1.5089	.763	.7545	.8413
7	.6952	.6859	.7316	1.358	.6443	.6001	.8048
8	.5596	.5487	.6036	1.2071	.5426	.6001	.695
9	.4578	.4973	.4904	.9808	.407	.4973	.5121
10	.3391	.3772	.3395	.679	.373	.3772	.4024
11	.4424	.431	.3978	.8192	.3768	.4115	.3772
12	.4096	.4641	.3647	.3605	.3605	.3429	.3018
13	.4862	.3978	.3647	.3768	.3441	.3086	.2683
14	.3688	.3315	.3978	.3768	.3277	.3086	.0983
15	.3353	.3315	.2984	.1638	.2949	.2743	.1638
16		.3315	.3315	.2458	.3277	.3429	.3277
17		.4641	.3978	.5735	.3441	.4115	.3605
18	.4862	.5304	.431	.4915	.3768	.3772	.3932
19	.6173	.6283	1.1949	.5935	.5658	.5853	.5914
20	.6344	.5281	1.1203	.5935	.463	.5853	.5601
21	.4458	.415	.8676	.407	.3944	.439	.4904
22	.3429	.3772	.7167	.3391	.3772	.3658	.3772
23	.3086	.3395	.6036	.3052	.3086	.2926	.3395
24	.2883	.2915	.3395	.6036	.3052	.2915	.2926
Max	.763	.7545	1.1949	1.5089	.763	.7545	.8413
Min	.2713	.2915	.2984	.1638	.2883	.2743	.0983
Avg	.4344	.4486	.5394	.6832	.3997	.4303	.4391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 201 / 11KV PADALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.394	.3429	.3429	.2915	.2915	.1886
2	.3086	.394	.3086	.3696	.2915	.2915	.1715
3	.3086	.394	.3086	.3506	.2915	.2915	.1543
4	.3429	.394	.3601	.3772	.3258	.3429	.1715
5	.4115	.4298	.4287	.4115	.3944	.4115	.1886
6	.5487	.6089	.5144	.5144	.5144	.5144	
7	.6859	.7522	.6859	.6516	.6173	.7202	
8	.6859	.7164	.6173	.583	.6344	.5487	
9	.5658	.6447	.5959	.5544			.4801
10							.4973
11							.3944
12							.5316
13							.463
14							.463
15							.4458
16							.4458
17		.1372					
19	.2149	.1886	.2058	.1886	.2149	.1886	.2058
20	.2149	.2058	.2103	.1886	.2149	.2058	.2058
21	.2149	.2058	.2172	.1715	.197	.2058	.1886
22	.2149	.2229	.2058	.2058	.1886	.2058	.1886
23	.2149	.1886	.1753	.3086	.3086	.2058	.1886
24	.3258	.394	.3429	.1524	.3086	.3086	.1886
Max	.6859	.7522	.6859	.6516	.6344	.7202	.5316
Min	.2149	.1372	.1753	.1524	.1886	.1886	.1543
Avg	.3723	.3919	.3680	.3580	.3424	.3380	.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 202 / 11KV DAHID AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2865	.2401	.2401	.1886	.2149	.0343
2	.2401	.2865	.2229	.2401	.1886	.2149	.0343
3	.2401	.2865	.2229	.2401	.1886	.2172	.0343
4	.2572	.3224	.2401	.2743	.2401	.2507	.0343
5	.2743	.3582	.2572	.3086	.2743	.3045	.0343
6	.3086	.394	.3086	.3429	.3429	.3582	.0343
7	.4115	.4656	.4115	.3429	.2743	.3403	
8	.4458	.4656	.3772	.3429	.3944	.3086	
9	.3944	.4298	.3086	.3086		.3429	.3086
10							.3772
11							.3258
12							.3258
13							.2572
14							.2401
15							.2401
16							.2743
18				.0343			
19	.0358	.0343	.0351	.0343	.0358	.0343	.0343
20	.0362	.0343	.0343	.0343	.0358	.0343	.0351
21	.0358	.0343	.0343	.0343	.0358	.0343	.0343
22	.0358	.0343	.0343	.0343	.0358	.0343	.0343
23	.0358	.0343	.0343	.2401	.2507	.0343	.0343
24	.2401	.2865	.2401	.1829	.2401	.2507	.0343
Max	.4458	.4656	.4115	.3429	.3944	.3582	.3772
Min	.0358	.0343	.0343	.0343	.0358	.0343	.0343
Avg	.2154	.2502	.2001	.2022	.1947	.1983	.1381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 204 / 11 KV DAHID GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686			.0701			
2	.0686						
3	.0686						
4	.1029		.0857				
5	.1372			.1267			
6	.2229						
7	.1715	.1629	.1543	.1402			
8	.1372					.1448	.1543
9	.1029	.1086				.1029	
12	.2172	.0686	.1097		.0724	.0857	
13			.0701				
14			.0701				
15		.0686	.0701				
16	.0724				.0724	.0686	.0686
17			.1097				
18		.1029	.1097				
19			.1052				
20	.1267		.128		.1433		
21		.12	.1227				
22			.1097				
23		.0857				.0857	
24	.0686	.0724	.0686			.0716	.0686
Max	.2229	.1629	.1543	.1402	.1433	.1448	.1543
Min	.0686	.0686	.0686	.0701	.0724	.0686	.0686
Avg	.1204	.0987	.1010	.1123	.0960	.0932	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 205 / 11KV DEULGHAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5611	.5316	.5975	.5487	.543	.5316
2	.5144	.543	.5144	.5914	.5487	.543	.5144
3	.5144	.543	.5144	.5914	.5316	.543	.4801
4	.5658	.5611	.5487	.6283	.5487	.5792	.4801
5	.583	.5792	.583	.6283	.5658	.5973	.5144
6	.6173	.6335	.583	.6653	.583	.6154	.5487
7	.6173	.5792	.583	.6283	.583	.6154	.5487
8	.5487	.543	.5144	.5914	.5487	.5487	.5144
9	.5487	.543	.5304	.5175	.4801	.5144	.5175
10	.543	.5144	.5175	.5144	.4973	.4973	.4854
11	.5068	.5144	.5601	.5316	.4887	.4973	.4854
12	.543	.5487		.6173	.543	.463	.5304
13	.543	.5144	.5601	.4973	.543	.4287	.5041
14	.5068	.463	.5975	.4973	.543	.4287	.5041
15	.5068	.5144	.5975	.4973	.543	.4458	.5228
16	.5611	.4973	.5975	.4973	.543	.463	.5601
17	.5792	.5316	.6348	.5316	.5792	.5144	.5601
18	.6516	.6001	.5975	.5658	.6154	.5658	.5487
19	.6697	.6344	.7095	.6344	.6516	.6001	.7095
20	.6516	.5658	.5914	.6516	.6697	.5658	.6348
21	.6516	.6173	.6653	.583	.6154	.5658	.6001
22	.5973	.583	.5601	.5487	.5792	.5487	.6001
23	.5792	.5487	.5914	.5487	.5792	.5487	.5658
24	.5487	.5792	.5487	.5914	.5487	.543	.5316
Max	.6697	.6344	.7095	.6653	.6697	.6154	.7095
Min	.5068	.463	.5144	.4973	.4801	.4287	.4801
Avg	.5707	.5547	.5753	.5728	.5616	.5323	.5414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 206 / 11 KV PADALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2172	.2058	.2587	.1886	.2229	.2058
2	.2229	.2172	.2401	.2218	.1886	.2229	.2058
3	.2401	.2172	.2743	.2218	.2058	.2229	.1886
4	.3086	.3258	.3258	.2957	.2572	.2743	.2572
5	.3944	.4344	.3944	.3658	.3258	.3601	.3772
6	.5144	.5792	.5487	.5914	.5487	.5658	.583
7	.4458	.543	.4973	.5175	.4287	.4458	.4973
8	.4287	.4706	.3429	.4435	.4115	.4115	.463
9	.4115	.4344	.2801	.2957	.3258	.3429	.3326
10	.362	.3429	.2715	.2401	.2229	.3086	.2772
11	.2534	.2572	.2587	.1886	.2058	.2572	.2801
12	.2172	.2229	.2614	.1715	.2058	.2229	.2241
13	.2172	.2572	.2241	.1543	.2058	.2058	.2241
14	.2172	.2229	.2587	.1543	.2058	.2058	.2614
15	.2172	.2572	.2587	.1886	.2058	.2058	.2614
16	.2353	.2229		.1886	.2058	.2401	.2987
17	.2715	.2572	.2987	.2401	.2401	.3086	.2614
18	.3439	.2743	.4108	.2572	.2743	.3601	.3326
19	.5249	.3429	.4481	.4287	.4458	.3944	.4854
20	.4525	.4458	.4108	.4287	.4458	.3772	.4938
21	.362	.3772	.3696	.3258	.3429	.3258	.3086
22	.2715	.3086	.3326	.2401	.2743	.3086	.2572
23	.2534	.2058	.2801	.2229	.2572	.2572	.2401
24	.2229	.2172	.2058	.2587	.2229	.2401	.2058
Max	.5249	.5792	.5487	.5914	.5487	.5658	.583
Min	.2172	.2058	.2058	.1543	.1886	.2058	.1886
Avg	.3171	.3188	.3217	.2875	.2851	.3036	.3134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 201 / 11 KV Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3169	1.3032	1.2346	1.4299	1.2003	1.1888
2	1.3032	1.2803	1.267	1.166	1.4118	1.1145	1.134
3	1.2689	1.2803	1.2489	1.166	1.3756	1.0802	1.134
4	1.2689	1.2437	1.1946	1.1317	1.3394	1.0631	1.0974
5	1.1831	1.1888	1.1584	1.1145	1.3032	1.0631	1.0974
6	1.1488	1.0608	1.1403	1.0802	1.267	1.0631	1.0974
7	1.166		1.086	1.0288	1.1584	1.0288	
8	1.166	1.0974	1.2308	1.0802	1.3032	1.046	1.0791
9	1.1888			1.046	1.2489	1.0288	.9877
10	1.2071		1.0679	1.1488	.9774	1.0288	.9694
11	1.2803		1.0117	1.2489	1.0631	1.0608	.9412
12	1.1888		1.0631	1.267	1.0974	1.0608	.905
13	1.262		1.0802	1.2127	1.1317	.9511	1.0317
14	1.3169	1.448	1.0631	1.1946	1.1831	.9877	1.0317
15	1.3535	1.448		1.267	1.2003	1.0059	1.1403
16	1.3717	1.448	1.3032	1.3756	1.2346	1.0425	1.1403
17	1.2803	1.4118	1.2689	1.3756	1.2003	1.0974	1.1584
18	1.3169	1.4118	1.2346	1.3032	1.2346	1.1706	1.1765
19	1.1888	1.2851	1.2346	1.3032		1.1888	1.3032
20	1.3169	1.3032	1.2689	1.4661		1.2437	1.3213
21	1.2254	1.2489	1.286	1.3032	1.2517		1.267
22	1.2803	1.267	1.286	1.3575	1.2689	1.2071	1.2851
23	1.2803	1.3032	1.2689	1.3937	1.2689	1.2437	1.3213
24	1.3546	1.3169	1.3394	1.2517		1.2174	1.1888
Max	1.3717	1.448	1.3394	1.4661	1.4299	1.2437	1.3213
Min	1.1488	1.0608	1.0117	1.0288	.9774	.9511	.905
Avg	1.2592	1.2978	1.2003	1.2299	1.2357	1.0954	1.1303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 202 / 11 KV Ganesh Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4632	1.4842	1.4403	1.5746	1.2689	1.1888
2	1.3032	1.39	1.448	1.3717	1.2851	1.2003	1.1888
3	1.2689	1.2803	1.3756	1.2689	1.267	1.1317	1.0974
4	1.2689	1.2803	1.3032	1.2346	1.267	1.0631	1.0974
5	1.2346	1.2437	1.3032	1.1831	1.2489	1.046	1.0974
6	1.2003	1.2437	1.2127	1.0631	1.1946	.9945	1.0608
7	1.1317	1.1706	1.1584	1.046	1.1041	.9602	1.0242
8	1.0631	1.0608	1.4118	.9945	1.1765	.9259	1.0608
9	1.1706	1.0791		.9945	1.086	.9602	.9511
10	1.1706	1.1946	1.1584	1.0631	.9593	.9602	1.0425
11	1.262	1.3394	1.1488	1.2308	1.046	1.0608	1.086
12	1.1706	1.3756	1.1488	1.1765	1.1317	1.0608	1.1222
13	1.3169	1.3756	1.2517	1.2851	1.2346	1.0242	1.1946
14	1.3169	1.3756	1.3546	1.3937	1.3203	1.0425	1.2127
15	1.4632	1.3756		1.4661	1.3032	1.0425	1.267
16	1.4632	1.3756	1.5261	1.4661	1.3032	1.0608	1.267
17	1.4632	1.3756	1.3889	1.3575	1.2689	1.0608	1.2489
18	1.4632	1.3756	1.286	1.1584	1.1145	1.0608	1.1222
19	1.39	1.3213	1.3546	1.267	1.166	1.2437	1.3394
20	1.5729	1.5927	1.5089	1.5565	1.2517	1.3352	1.3937
21	1.5729	1.5203	1.4232	1.4842	1.3375	1.3169	1.4842
22	1.6644	1.5927	1.5261	1.5927	1.3717	1.3169	
23	1.6278	1.5565	1.5775	1.6289	1.3717	1.3352	1.5023
24	1.4746	1.6278	1.5203	1.4575	1.6289	1.3032	1.2803
Max	1.6644	1.6278	1.5775	1.6289	1.6289	1.3352	1.5023
Min	1.0631	1.0608	1.1488	.9945	.9593	.9259	.9511
Avg	1.3502	1.3578	1.3578	1.2992	1.2505	1.1156	1.1882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 203 / 11 KV JAISTAMB-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4207	.4163	.3944	.4344	.3772	.3658
2	.3772	.4207	.4163	.3772	.3982	.3772	.3658
3	.3772	.4207	.4163	.3772	.3982	.3429	.3658
4	.3601	.4207	.3982	.3601	.362	.3429	.3658
5	.3429	.4207	.3982		.362	.3258	.3658
6	.3429	.439	.3801	.3601	.362	.3258	.3658
7	.3601	.4207	.3801	.3601	.3439	.3086	.3658
8	.3429	.3841	.3982	.2915	.3982	.2915	.2743
9	.3292	.3475		.2743	.3734	.3429	.2561
10	.3658	.3439	.3801	.3429	.3439	.2915	.3292
11	.3658	.362	.3772	.362	.3429	.3292	.362
12	.4024	.362	.463	.362	.3429	.3292	.362
13	.439	.3801	.4287	.3801	.3429	.3109	.362
14	.4572	.3801	.3601	.3801	.3772	.3292	.362
15	.439	.3801		.3982	.3772	.3475	.362
16	.4024	.3921	.3944	.3982	.3429	.3658	.362
17	.4024	.3801	.3772	.3982	.3429	.3292	.362
18	.3658	.3801	.3429	.2353	.3258	.3292	.3258
19	.3841	.3982	.3772	.362	.3601	.4024	.3982
20	.439	.4525	.4287	.4525	.3944	.4207	.4163
21	.4572	.4344	.4287	.4344	.4115	.439	.4344
22	.4572	.4344	.4458	.4706	.4115	.439	.4344
23	.439	.4344	.4287	.4706	.3944	.4207	.4163
24	.4115	.4207	.4163	.3944	.4525	.3772	.3841
Max	.4572	.4525	.463	.4706	.4525	.439	.4344
Min	.3292	.3439	.3429	.2353	.3258	.2915	.2561
Avg	.3932	.4012	.4024	.3755	.3748	.3540	.3652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 204 / 11 kv Hanwatkhed Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
11	.0343	
12	.0343	
13	.0343	
14	.0343	
15	.0343	
16	.0343	
24		.061
Max	.0343	.061
Min	.0343	.061
Avg	.0343	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 205 / 11 kv Balaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1646		.1372	.1448	.1029	.1463
2	.1543	.1646	.1448	.1372	.1267	.1029	.1463
3	.1543	.1646	.1448	.1372	.1267	.1029	.1463
4	.1543	.1463	.1267	.12	.1267	.0857	.1097
5	.1372	.1463	.1267	.1029	.1267	.0857	.1097
6	.12	.128	.0905	.1029	.1267	.0857	.0914
7	.12	.128	.0905	.1029	.1267	.1029	.0732
8	.12	.1097	.1448	.1029	.1029	.12	.0732
9	.1463	.1463		.1029	.1267	.12	.0732
10	.128	.181	.1086	.12	.1448	.1029	.0914
11	.1463	.1448	.12	.1086	.12	.1097	.1267
12	.1829	.1448	.1372	.0905	.12	.128	.1267
13	.1646	.1448	.1715	.1448	.12	.128	.1267
14	.1646	.1448	.1372	.1629	.1372	.1463	.1448
15	.1829	.1448		.181	.1543	.1646	.1629
16	.1829	.1448	.2058	.2172	.1543	.1646	.181
17	.2012	.181	.1715	.181	.1543	.1646	.181
18	.1829	.181	.1715	.1629	.1543	.1463	.1629
19	.1646	.181	.1715	.1886	.12	.1646	.1629
20	.2012	.1629	.2058	.1715	.12	.1646	.1629
21	.1646	.181	.1886	.1543	.1372	.1463	.1543
22	.1829	.1629	.1715	.1372	.1372	.1463	.1543
23	.1646	.1448	.1715	.1372	.12	.1463	.1448
24	.1543	.1646	.1448	.1543	.1448	.12	.1463
Max	.2012	.181	.2058	.2172	.1543	.1646	.181
Min	.12	.1097	.0905	.0905	.1029	.0857	.0732
Avg	.1596	.1545	.1498	.1399	.1322	.1272	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 201 / 11 KV Sakhali GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6173	.6173	.6173		.6173	.6173
2	.6173	.6173	.6173	.6173		.6173	.6173
3	.6173	.6516	.6173	.6173		.6173	.6173
4	.6173	.6516	.6173	.6516		.7888	.6516
5	.6859	.6859	.7545	.6859		.9602	.7202
6	1.0288	.9945	1.0288	.9945	1.0631	1.1317	1.0802
7	.9259	.9259	.9259	.8916	.8573	.9602	1.0288
8	.8573	.823	.8573	.8402	.823	.8573	.8916
9	.7888	.6859	.7545	.703	.7545	.7888	.7888
10	.6344	.6516	.6173	.6173	.6859	.583	.6173
11	.5487	.5487	.5487	.583	.6516	.5487	.5487
12	.583	.5487	.5487	.583	.583		.5144
13	.583	.583	.5487	.5487	.583		.5144
14	.5487	.583	.583	.6173	.6173		.5487
15	.583	.6173	.583	.6173	.6173		.4801
16	.6173	.6173	.6173	.6173	.6173		.583
17	.6516	.6859	.6859	.6516	.823		.6859
18	.823	.823	.7888	.8573	.8916	1.0288	.7545
19	.9774	.9945	.9602	1.0288	1.0288	1.0974	.9602
20	.9431	1.0288	1.0288	1.0974	.9945	1.0631	1.0631
21	.8573	.8573	.8916	.7202	.823	.9945	.8573
22	.7545	.6859	.7888	.7202	.7202	.823	.7202
23	.6516	.6516	.6516	.6516	.6516	.6516	.6859
24	.6173	.6173	.6173		.6516	.6173	.6516
Max	1.0288	1.0288	1.0288	1.0974	1.0631	1.1317	1.0802
Min	.5487	.5487	.5487	.5487	.583	.5487	.4801
Avg	.7137	.7145	.7187	.7187	.7599	.8192	.7166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 202 / Sakhali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0686	.0343		.0343	.2401
2	.0343	.0343	.0343	.0343		.0343	.2401
3	.0343	.0343	.0343	.0343		.0343	.2572
4	.0343	.0343	.0343	.0343		.0343	.2572
5	.0343	.0343	.0343	.0343		.0343	.2572
6	.0343	.0686	.0686	.0343		.0343	.3601
7	.0343	.0686	.0686	.0343		.0343	.3601
8		.0686					.3772
9				.1029	.1029	.3086	
10	.2743	.2401	.2401	.3086	.2058	.1715	
11	.3429	.2743	.3429	.3772	.2058		
12	.2401	.3429	.2743	.5144	.2743		
13	.2058	.3086	.2743	.2058	.2401		
14	.2401	.2743	.2401	.2058	.1715		
15	.2401	.2401	.2401	.1715	.2058		
16	.2743	.2401	.2743	.2743	.2401		
17	.3429	.3429	.3086				
19	.0686	.0686	.0343	.0343	.0343	.0343	.0686
20	.0686	.0686	.0686	.0343	.0343		.0343
21	.0686	.0686	.0343	.0343	.0343	.0343	.0343
22	.0343	.0686	.0343	.0343	.0343	.0343	.0343
23	.0343	.0686	.0343	.0343	.0343	.2401	.1029
24	.0343	.0343	.0686	.1829	.0343	.0343	.2401
Max	.3429	.3429	.3429	.5144	.2743	.3086	.3772
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.1290	.1372	.1339	.1312	.1323	.0784	.2046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 203 / SHIRPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3086	***		.3086	.0686
2	.3086	.3086	.3429	.3429		.3086	.0686
3	.3086	.3086	.3429	.3086	.3086	.3086	.0686
4	.3086	.3086	.3429	.3429	.3086	.3429	.0686
5	.4458	.4287	.4115		.3086	.4458	.0686
6	.4801	.583	.5487	.1886	.4115	.5144	.1029
7	.6859	.6687	.6859	.1886	.5144	.6173	.1029
8	.583	.6516	.6516	.2915	.5487	.6173	
9	.583	.5144	.5487				.3429
10							.5144
11							.5144
12							.4801
13							.3429
14							.2743
15							.3772
16							.4801
19	.1029	.1029	.1029	.1029	.1029	.1029	.1029
20	.1029	.1029	.0686	.1029	.1029	.1029	.1029
21	.1029	.1029	.0686	.1029	.0686	.1029	.1029
22	.1029	.1029		.1029	.0686		.1029
23	.1029	.1029	.0686	.3086	.3086	.0686	.1029
24	.3086	.2743	.3086	.1524	.3086	.3086	.0686
Max	.6859	.6687	.6859	72.2223	.5487	.6173	.5144
Min	.1029	.1029	.0686	.1029	.0686	.0686	.0686
Avg	.3224	.3246	.3429	5.7506	.2801	.3192	.2123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 201 / Bhadola gaathan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3395	.2926	.3018	.3018	.2926	.2926
2	.2926	.3398	.2926	.3018	.3018	.2926	.2926
3	.2926	.3395	.2926	.3021	.3018	.2926	.2926
4	.2926	.3395	.3109	.3018	.3018	.3292	.2743
5	.3361	.3395	.3475	.3398	.3395	.3658	.3224
6	.5487	.5847	.4656	.4338	.4338	.4572	.4656
7	.567	.5658	.4477	.5287	.4904	.4938	.4298
8	.5487	.4715	.4656	.547	.5121	.5228	.4119
9	.4854	.394	.4835	.5658		.567	.4119
10	.4338	.4298	.3224	.415		.3761	.4338
11	.415	.394	.3961	.3395		.4119	.4527
12	.3772	.4298		.3961		.3403	.3395
13	.3395	.394	.3961	.3961		.3582	.3395
14	.3395	.394	.3961	.3776		.2149	.3587
15	.3395	.394	.3961	.3961		.2149	.3395
16	.3961	.394	.3395	.3961	.4755	.2507	.3395
17	.3961	.3582	.3395	.3961	.4207	.3224	.3772
18	.415	.3582	.4715	.4338	.4755	.394	.3772
19	.4715	.4119	.4715	.5664	.439	.4298	.4338
20	.415	.4656	.472	.4338	.4207	.4477	.4527
21	.3772	.4298	.4338	.415	.3658	.4119	.3961
22	.3584	.3475	.3961	.3584	.3475	.3582	.3018
23	.3395		.3395	.3395	.3109	.3292	.3018
24	.3109	.3398	.2926	.3021	.3018	.2987	.2926
Max	.567	.5847	.4835	.5664	.5121	.567	.4656
Min	.2926	.3395	.2926	.3018	.3018	.2149	.2743
Avg	.3909	.4024	.3853	.3993	.3847	.3655	.3638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 202 / Bhadola Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1509	.1753			.1097	.0514
2	.1829	.1509	.1578	.132		.1097	.0514
3	.1829	.1509	.1578	.1509		.128	.0514
4	.2195	.1509	.1578	.132		.1463	.0514
5	.2195	.1886	.1928	.132	.132	.1494	.0514
6	.2378	.2829	.2454	.2452	.1888	.1829	.0686
7	.2561	.3206	.298	.3018	.2829	.2378	.0686
8	.2012	.2829	.2804	.3395	.2195	.2561	.0686
9	.168	.2454	.2058	.132		.0914	.0686
10	.0566	.0514	.0343	.0566		.0857	.1886
11	.0377	.0514	.0377	.0566		.0343	.2075
12	.0377	.0686	.0566	.0377		.0514	.2452
13	.0377	.0514	.0566	.0377		.0343	.2075
14	.0377	.0514	.0566	.0377		.0514	
15		.0514	.0566	.0377		.0514	.1886
16	.0566	.0514	.0377	.0566		.0514	.2075
17	.0566	.0514	.0566	.0566		.0514	.0566
18	.0754	.0686	.0566	.0566		.0514	.0566
19	.0754	.0686	.0566	.0943	.0549	.0686	.0566
20	.0754	.1029	.0566	.0754	.056	.0686	.0754
21	.0566	.0857	.0566	.0566	.0549	.0514	.0754
22	.0566		.0566	.0566	.0549	.0514	.0566
23	.0566	.0686	.0566	.132	.0732	.0514	.0566
24	.1463	.1132	.1753	.132	.132	.0914	.0514
Max	.2561	.3206	.298	.3395	.2829	.2561	.2452
Min	.0377	.0514	.0343	.0377	.0549	.0343	.0514
Avg	.1172	.1243	.1158	.1107	.1249	.0940	.0983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 201 / Shivshankar Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.0288	1.3443	1.2826	1.2003	1.2696	.985
2	1.2012	1.0288	1.3256	1.226	1.1831	1.1949	.985
3	1.1088	1.0288	1.2936	1.1317	1.1145	1.1949	1.0164
4	1.1088	1.046	1.2883	1.1883	1.0288	1.1576	1.0029
5	1.1104	1.0631	1.2696	1.226	.9945	1.1203	1.0349
6	1.1104	1.0631	1.1949	1.1506	.9945	1.0829	1.0719
7	1.1283	1.0631	1.1576	1.1145	.9774	1.0269	1.0387
8	1.0566	1.0631	1.1576	1.046	.9602	1.1203	.9671
9	.9602	1.0288	1.0829	1.0288	1.0456	1.0029	.9808
10	.9602	1.0829	1.0269	.9774	1.0456	.9313	.9431
11	.9431	1.0456	.9709	.9259	1.0269	.8954	.7907
12	.9602	.9896	1.0269	.9088	.9896	.8417	.9619
13	.9945	1.0082	1.0456	.9259	1.0082	.8596	1.0374
14	.9945	1.0456	1.1203	1.0631	1.0456	.8954	1.0374
15	1.0117	1.0642		1.0631	1.0829	.8954	.9431
16	1.0117	1.0456	1.0269	1.0631	1.1389	.8954	.9431
17	1.0288	1.0642	1.0456	1.0288	1.0829	.9313	.9709
18	1.0288	1.0642	1.1389	1.0288	1.0456	.9671	1.0269
19	1.0288	1.1949	1.2637	1.0802	1.1203	1.0029	1.0829
20	.9774	1.307	1.3203	1.166	1.1576	1.0387	1.2136
21	.9945	1.3256	1.358	1.2346	1.1576	1.0745	1.2696
22	1.0974	1.3443	1.4146	1.286	1.1949	1.1641	1.2826
23	1.0974	1.419	.1509	1.2003	1.2696	1.1641	1.226
24	1.2936	1.0631	1.3817	1.358	1.2003	1.307	1.1458
Max	1.2936	1.419	1.4146	1.358	1.2696	1.307	1.2826
Min	.9431	.9896	.1509	.9088	.9602	.8417	.7907
Avg	1.0587	1.1032	1.1481	1.1127	1.0861	1.0431	1.0399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 202 / Bhagirath SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1029	.1109	.0934	.1029	.1109	.1109
2	.1109	.12	.1109	.0934	.0857	.1109	.1109
3	.1075	.12	.1109	.0934	.0857	.1109	.1075
4	.1075	.12	.1109		.0857	.1109	.1109
5	.1075	.1372	.1109	.112		.1109	.1109
6	.1109	.1372	.1109	.1307	.1029	.1109	.1433
7	.1075	.1372	.1294	.1029	.12	.1109	.1791
8			.1294	.1029	.12	.1109	.0924
9	.1372		.1075	.12	.1294	.1075	.112
10	.1543		.2149	.1372	.1294	.1254	.112
11	.1886		.2328	.1372	.1294	.1433	.1132
12	.2229	.1294	.2149	.1543	.1294	.1433	.112
13	.2058	.1478	.1791	.1372	.1294	.1433	.1307
14	.2058	.2402	.1791	.1543	.1663	.1433	.1307
15	.1372	.2218	.1433	.1543	.2033	.1433	.1307
16	.12	.2033	.1433	.1372	.2218	.1848	.1307
17	.12	.1848	.1433	.1543	.1848	.1791	.1063
18	.1372	.2218	.1433	.1543	.1294	.1478	.1063
19	.1372	.2218		.1543	.1478	.1478	.112
20	.1372	.1848	.2054	.1372	.1663	.1848	.124
21	.12	.1478	.1867	.1372	.1478	.1848	.124
22	.0857	.1478	.1494	.1372	.1294	.1109	.112
23	.1029	.1294	.112	.12	.1109	.1109	.112
24	.1109	.1029	.1294	.112	.1029	.1109	.1109
Max	.2229	.2402	.2328	.1543	.2218	.1848	.1791
Min	.0857	.1029	.1075	.0934	.0857	.1075	.0924
Avg	.1340	.1579	.1482	.1290	.1331	.1333	.1186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 205 / SAV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1029	.0914	.0772	.1029	.0914	.2686
2	.1075	.1029	.0914	.0772	.0914	.0914	.2865
3	.1075	.0914	.0914	.0772	.0914	.0914	.2865
4	.1075	.0914	.0914	.0926	.0914	.1067	.3224
5	.1254	.1067	.0914	.108	.0914	.1067	3.349
6		.1372	.0914	.108	.0914	.1067	.3582
7	.1254	.1372	.0914		.0914	.1067	.4119
8	.1254		.0762		.0914	.0914	.3704
9	.1067		.0791		.3353		.0926
10	.3429		.3163		.3353		.0926
11	.4268		.5376		.3658		.0949
12	.5316	.4572	.5535		.3048	.5731	.0926
13	.5316	.4877			.3048		.0926
14	.5487	.4572			.3048		.0926
15	.4572	.4877			.2743	.5014	.0926
16	.4268	.5182			.2743	.4656	.0926
17	.463	.4572		.0857	.1067	.1109	.1107
18	.0914	.0914	.1265	.0857	.0914	.1109	.1107
19	.1029	.1219		.1029	.0914	.1109	.1107
20	.1029	.1219	.1235	.1029	.0914	.1109	.1107
21	.1029	.1067	.108	.12	.0914	.1109	.1107
22	.1029	.0914	.108	.12	.0914	.0924	.108
23	.1029	.0914	.0926	.12	.0914	.2686	.2469
24	.1075	.1029	.0914	.0926	.1029	.0914	.2772
Max	.5487	.5182	.5535	.12	.3658	.5731	3.349
Min	.0914	.0914	.0762	.0772	.0914	.0914	.0926
Avg	.2328	.2181	.1585	.0979	.1667	.1758	.3159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 206 / Yelgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2058	.1802	.1581	.2058	.1802	.1791
2	.1791	.2058	.1802	.1581	.1715	.1966	.1791
3	.1791	.2401	.1638	.1581	.1715	.1802	.2149
4	.2149	.2743	.1966	.1898	.1886	.1966	.2149
5	.2149	.2743	.1966	.2214	.2058	.213	.2507
6	.2328	.2401	.213	.253	.2401	.2294	.2507
7	.2328	.2401	.2622	.2401	.2401	.2294	.2686
8	.1791		.2294	.2058	.2401	.213	.2507
9	.1543		.1844	.2058	.1966		.2056
10	.1543		.2012	.1715	.1802		.1898
11	.1715		.2012	.1715	.1638	.1254	.1898
12	.1886	.1311	.1677	.1543	.1638		.1581
13	.1886	.1311	.1677	.1715	.1475	.1433	.1581
14	.1886	.1311	.1677	.2058	.1475	.1433	.1739
15	.1715	.1475	.1677	.2229	.1475	.1848	.1739
16	.1715	.1475	.2012	.2058	.1638	.2033	.1898
17	.1715	.1638	.2012	.1715	.1966	.2033	.2012
18	.1715	.1966	.2347	.1715	.213	.2149	.1898
19	.1715	.2622		.1715	.2294	.2218	.218
20	.1886	.2785	.2846	.1715	.2458	.2328	.2515
21	.1886	.1966	.253	.1886	.213	.2587	.2515
22	.2058	.1638	.1898	.2058	.1966	.2587	.2372
23	.2058	.213	.1898	.2058	.1966	.2149	.2214
24	.2149	.2058	.1966	.1898	.2058	.1966	.197
Max	.2328	.2785	.2846	.253	.2458	.2587	.2686
Min	.1543	.1311	.1638	.1543	.1475	.1254	.1581
Avg	.1883	.2025	.2013	.1904	.1946	.2019	.2090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1595
Max	.1595
Min	.1595
Avg	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 201 / 11 kv Indira Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4706	.4706	.4938	
2	.4706	.4525	.4656	.4706	
3	.4706	.4344	.4477	.4755	
4	.4525	.4344	.4525	.4572	
5	.4525	.4163	.4525	.439	
6	.4344	.4163	.4344	.4344	
7	.4344	.4344	.4344	.4344	
8	.362	.3898	.362	.4207	
9	.362	.3544		.3982	
10	.3801	.3898		.4207	
11	.362	.3898		.4344	
12	.3077	.3898		.4298	
13	.3439	.3544		.5316	
14	.3982	.4252		.4607	
15	.4525	.4252		.4607	
16	.4706	.4024		.4961	
17	.4344	.4024		.4961	
18	.4344	.4344		.4961	
19	.4525	.4525	.4163	.4961	
20	.4706	.4477	.4887	.4961	
21	.4706	.5014	.5194	.4607	
22	.5068	.5014	.543	.4961	
23	.5068	.5068	.5194	.4961	
24	.5068	.4706	.4706	.4887	.4607
Max	.5068	.5068	.543	.5316	.4607
Min	.3077	.3544	.362	.3982	.4607
Avg	.4352	.4290	.4627	.4660	.4607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 202 / 11 kv Ram Nagar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0543	.0543	.0549		.0543	.0354
2	.0362	.0543	.0549	.0549	.0532	.0543	.0354
3	.0362	.0543	.0549	.0366	.0532	.0543	.0354
4	.0362	.0543	.0543	.0543	.0549	.0543	.0532
5	.0543	.0543	.0543	.0543	.0532	.0543	.0532
6	.0724	.0543	.0543	.0537	.0532	.0543	.0532
7	.0724	.0543	.0543	.0537	.0532	.0543	.0532
8	.0543	.0709	.0366	.0543	.0532	.0362	.0709
9	.0724	.0709		.0366	.0532	.0354	.0543
10	.0362	.0532		.0366		.0532	.0362
11	.0543	.0532		.0537		.0549	.0362
12	.0543	.0532		.0543		.0354	.0543
13	.0543	.0532		.0532		.0354	.0543
14	.0543	.0532		.0532		.0354	.0543
15	.0543	.0532		.0532	.0724	.0354	.0724
16	.0543	.0543	.0724	.0532	.0543	.0354	.0543
17	.0543	.0543	.0724	.0532	.0543	.4961	.0701
18	.0543	.0537	.0724	.0532	.0543	.0354	.0701
19	.0543	.0537	.0543	.0532	.0543	.0354	.0543
20	.0543	.0537	.0724	.0532	.0724	.0354	.0543
21	.0543	.0532	.0724	.0532	.0543	.0354	.0543
22	.0724	.0543	.0366	.0532	.0543	.0532	.0543
23	.0543	.0543	.0543	.0532	.0543	.0532	.0362
24	.0543	.0543	.0549	.0537	.0532	.0543	.0354
Max	.0724	.0709	.0724	.0549	.0724	.4961	.0724
Min	.0362	.0532	.0366	.0366	.0532	.0354	.0354
Avg	.0535	.0553	.0576	.0515	.0559	.0640	.0515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 203 / 11 KV SAGWAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.543	.5121	.5068		.4887	.4607
2	.5068	.543	.4938	.4887	.5316	.4525	.4607
3	.543	.543	.4887	.4938	.5316	.4706	.4607
4	.5792	.5611	.5249	.543	.5316	.4706	.4607
5	.6154	.5792	.5792	.591	.5316	.5068	.5316
6	.6335	.724	.6984	.7522	.5316	.6154	.6379
7	.6516	.6335	.6878	.7522	.6024	.6516	.7087
8	.5792	.6024	.6154	.724	.6379	.6154	.6379
9	.5792	.567		.7059	.567	.5316	.5792
10	.5068	.4961		.5853	.4607	.4961	.4887
11	.4115	.4607			.4252	.4252	.4525
12	.4163	.4607			.3898	.443	.3982
13	.4344	.4607		.3544	.4344	.3898	.4344
14	.4525	.4252		.3189	.4887	.4252	.4344
15	.4706	.4252		.2835	.4706	.443	.4344
16	.4706	.4706		.2835	.4706	.4961	.4706
17	.4887	.5014		.5316	.3077	.4961	.4887
18	.5068	.5731	.5973	.6379	.543	.567	.5611
19	.6154	.5792	.6516	.7087	.724	.567	.6335
20	.7421	.7164	.7964	.7442	.6516	.6379	.5973
21	.6516	.6268	.6805	.7087	.6154	.567	.5792
22	.6154	.5731	.6626	.6379	.5068	.5316	.543
23	.5611	.5068	.6154	.6024	.5068	.5316	.5068
24	.543	.5611	.5068	.5611	.5493	.4887	.4961
Max	.7421	.724	.7964	.7522	.724	.6516	.7087
Min	.4115	.4252	.4887	.2835	.3077	.3898	.3982
Avg	.5451	.5472	.6074	.5689	.5222	.5129	.5190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 205 / JAMBHRUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0514	.064	.0648		.0514	.0177
2	.1086	.0514	.064	.0648	.0709	.0514	.0177
3	.1267	.0543	.081	.064	.0886	.0514	.0177
4	.1267	.0686	.0648	.08	.1063	.0514	.0177
5	.1448	.0686	.096	.08	.1097	.0686	.0354
6	.1629	.1372	.1265	.096	.1063	.0857	.0354
7	.181	.1715	.1423	.1265	.124	.0514	.0177
8		.1772	.112	.128	.1063	.0343	.0354
9		.1063		.0164		.0177	.0724
10		.0354		.0164		.0177	.0857
11		.0177					.1543
12	.0343	.0177				.0177	
13	.0171	.0354				.0177	
14	.0343	.0177				.0177	
15	.0343	.0177				.0177	
16	.0171	.0166	.0343			.0177	
17	.0171	.0332	.0343	.0354	.0686	.0177	.0362
18	.0343	.0328	.0343	.0354	.0686	.0177	.0181
19	.0343	.0328	.0343	.0354	.0362	.0354	.0362
20	.0343	.0328	.0343	.0354	.0343	.0354	.0181
21	.0343	.0166	.0332	.0177	.0343	.0177	.0181
22	.0343	.0164	.0164	.0177	.0171	.0177	.0181
23	.0343	.0164	.0164	.0709	.0514	.0177	.0181
24	.0905	.0514	.064	.1829	.0709	.0514	.0177
Max	.181	.1772	.1423	.1829	.124	.0857	.1543
Min	.0171	.0164	.0164	.0164	.0171	.0177	.0177
Avg	.0705	.0532	.0619	.0649	.0729	.0339	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 206 / 11 kv Ajijpur AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1029	.0819	.0995		.1029	.9214
2	.1448	.1086	.0663	.0995	.1417	.1029	.8505
3	.1448	.1029	.0829	.0838	.1417	.1029	.8505
4	.1629	.1029	.0819	.1147	.1417	.12	.8505
5	.1629	.12	.1147	.1147	.1417	.12	.9214
6	.2172	.2058	.1457	.1475	.1417	.1372	1.0631
7	.2534	.2058	.1781	.1943	.1595	.1543	1.2403
8	.181	.1772	.1802	.1966	.1417	.1715	1.0631
9	.1629	.128		1.1203	.8859	.9922	.1543
10	1.4918	1.5061		1.4548	.9922	1.0631	.1543
11	1.5261	1.5238		1.5023	.9568	1.0631	.12
12	1.7013	1.5947		1.4251	.9214	1.134	.12
13	1.6118	1.4175		1.4175	.8573	1.0631	.12
14	1.3717	1.4529		.4001	.9431	1.134	.1372
15	1.1317	1.2048		1.2048	.9431	.9922	.1372
16	1.2346	1.012	1.7318	1.2048	.9431	.9922	.12
17	1.2346	1.1069	1.9719	.1417	.1372	.124	.1448
18	.1029	.1475	.1543	.1417	.1543	.124	.2172
19	.1372	.1619	1.0974	.1417	.1372	.1417	.2353
20	.1372	.1406	1.0974	.1417	.12	.1417	.2172
21	.1543	.1147	.9488	.1417	.12	.124	.181
22	.1372	.1147	.1134	.1417	.12	.1063	.1629
23	.12	.116	.1134	.1417	.1029	.8505	.9412
24	.1267	.1029	.081		.1417	.1029	.9214
Max	1.7013	1.5947	1.9719	1.5023	.9922	1.134	1.2403
Min	.1029	.1029	.0663	.0838	.1029	.1029	.12
Avg	.5740	.5405	.4848	.5118	.4124	.4650	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 400 / Station Transformer
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 402 / 33 KV Buldhana NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 403 / 33 KV PADALI

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 404 / 33 KV DONGARSHIVALI

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 405 / 33 KV GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.6132
Max	7.6132
Min	7.6132
Avg	7.6132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 406 / 33kv Yelgaon WW

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	6.9445
Max	6.9445
Min	6.9445
Avg	6.9445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 407 / 33 KV Maintenance Unit

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 077007 / 132/33kv Substn. Buldana

Feeder No / Name : 409 / 33 Kv Raipur

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	7.4589
Max	7.4589
Min	7.4589
Avg	7.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
9	.0747	
24		.1905
Max	.0747	.1905
Min	.0747	.1905
Avg	.0747	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 201 / 11 KV AMDAPUR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.3429
2			.3429
3			.3429
4			.3429
5			.4287
10	.6859	.6859	
11	.8573	.8573	
12	.6859	.6859	
13	.3429	.5144	
14	.3429	.3429	
15	.3429	.3429	
16	.3429	.3429	.3048
17	.5144	.3429	
24			.3048
Max	.8573	.8573	.4287
Min	.3429	.3429	.3048
Avg	.5144	.5144	.3443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 202 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.1715
2			.1715
3			.1715
4			.1715
5			.1715
6			.1715
7			.1715
8			.1715
10	.1715	.1715	
11	.1715	.1715	
12	.1715	.1715	
13	.1715	.1715	
14	.1715	.1715	
15	.1715	.1715	
16	.1715	.1715	
17	.1715	.1715	
23			.1715
24			.1905
Max	.1715	.1715	.1905
Min	.1715	.1715	.1715
Avg	.1715	.1715	.1734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 203 / 11 KV UNDRI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.3429
2	.6859	.5144	.3429
3	.6859	.5144	.3429
4	.6859	.6001	.3429
5	.8573	.6859	.5144
6	.8573	.8573	1.0288
7	1.3717	1.2003	1.3032
8	1.3717	1.286	
9	1.0288	1.0288	
24	.6859	.5144	.3429
Max	1.3717	1.286	1.3032
Min	.6859	.5144	.3429
Avg	.8916	.7716	.5701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 204 / 11 KV AMDAPUR GFFS

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 205 / 11 KV MANGRUL GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0288	.9431
2	.9431	1.0288	.9431
3	.9431	1.0288	.9431
4	1.0288	1.1145	.9431
5	1.1145	1.1145	1.0288
6	1.286	1.2003	1.2003
7	1.2003	1.1145	1.0631
8	1.0288	.9431	
9	.8573	.9431	
10	.8573	.8573	
11	.7716	.7716	
12	.7716	.7716	
13	.7716	.7716	
14	.7716	.7716	
15	.7716	.7716	
16	.7716	.8573	
17	.8573	.8573	
18	.9431	1.2003	
19	1.1145	1.2003	
20	1.2003	1.286	
21	1.0288	1.0288	
22	1.0288	1.0288	
23	1.0288	.9431	
24	1.0288	1.0288	.9431
Max	1.286	1.286	1.2003
Min	.7716	.7716	.9431
Avg	.9609	.9859	1.0010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 206 / 11 KV UNDRI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.2003	1.286	
2	1.1145	1.1145	1.2003	
3	1.1145	1.1145	1.2003	
4	1.1145	1.2003	1.2003	
5	1.1145	1.2003	1.286	
6	1.3717	1.286	1.3717	
7	1.3717	1.2003	1.2003	
8	1.286	1.2003		
9	1.286	1.0288		
10	1.2003	1.0288		
11	1.1145	1.1145		
12	1.0288	1.1145		
13	1.1145	1.1145		
14	1.1145	1.1145		
15	1.1145	1.1145		
16	1.1145	1.2003		
17	1.2003	1.3717		
18	1.2003	1.3717		
19	1.4575	1.3717		
20	1.5432	1.5432		
21	1.5432	1.3717		
22	1.3717	1.3717		
23	1.2003	1.0288		
24	1.2003	1.2003	1.3717	1.2384
Max	1.5432	1.5432	1.3717	1.2384
Min	1.0288	1.0288	1.2003	1.2384
Avg	1.2288	1.2074	1.2646	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 201 / 11 KV BORGAON 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.3772	.3772	.4115	.3395	.415
2	.415	.3772	.3772	.3772	.415	.3395	.3772
3	.4527	.4115	.3772	.3772	.415	.3772	.3772
4	.4904	.4115	.415	.415	.4458	.4527	.3772
5	.5658	.4458	.5281	.5281	.4801	.5658	.4458
6	.679	.6173	.679	.6413	.6173	.679	.5144
7	.6036	.5658	.5658	.5658	.5658	.8676	.7545
8	.4904	.5281	.5281	.5281	.5281	.6036	.4801
9	.4527		.3772	.5487	.583	.2401	.3772
10		.8573	.6859	.679	.5487	.2058	.3018
11		.823	.7202	.7545	.6516	.4801	.2263
12		.7202	.6859	.7202	.5487	.6173	.2641
13		.6859	.6859	.6516	.5487	.5144	.2641
14		.6859	.6173	.6173	.6173	.4801	.3018
15		.6516	.5144	.6173	.6173	.4458	.3395
16		.6859		.5487	.583	.5144	.3395
17		.6859		.4527	.4527	.3772	.3772
18		.4527	.4458		.5658	.5281	.4527
19		.6036	.5281	.6036	.6036	.5658	.6224
20		.6036	.5658	.5281	.5658	.5658	.679
21		.4527	.4904	.4904	.4527	.4527	.7167
22		.4527	.4527	.3772	.3772	.415	.7545
23		.415	.3772	.415	.3772	.415	.6516
24	.415	.3772	.415	.3772	.4115	.3395	.415
Max	.679	.8573	.7202	.7545	.6516	.8676	.7545
Min	.415	.3772	.3772	.3772	.3772	.2058	.2263
Avg	.4980	.5603	.5186	.5301	.5160	.4743	.4510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 202 / 11 KV BHORSHI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2401	.2401	.2401	.2401	.2641
2	.2572	.2401	.2401	.2401	.2401	.2058	.2641
3	.2572	.2743	.2401	.2743	.2058		.3018
4	.2572	.2743	.2401	.2743	.2058		.3018
5	.2915	.3086	.3086	.3086	.2058		.3772
6	.3429	.3429	.4115	.3429	.2058		.7167
7	.3429	.3772	.4458	.3429	.4801		
8	.3772	.4115	.4115	.3772	.4115		
9	.2743	.4115	.3429	.3018	.2263		
10		.2641	.2641	.2641	.2641	.1509	
11		.2263	.2263	.2263	.2263	.2263	.2401
12		.2641	.2263	.2263	.2263	.2263	.2401
13		.2263	.2641	.2263	.2263	.2263	.2743
14		.2641	.2641	.2263	.2263	.3018	.3018
15		.3018	.2641	.2263	.2263	.2641	.3395
16		.2641	.2641	.2263	.2263	.2641	.3086
17		.3018	.1886	.2263	.2641	.3018	.3018
18		.3395	.3395	.3018	.3206	.1509	.3395
19		.415	.4527	.1509	.3772	.4527	.4527
20		.4527	.415	.2263	.3395	.3772	.4527
21		.3772	.3395	.3395	.3018	.3772	.4527
22		.3018	.3018	.2263	.3018	.3018	.4527
23		.2641	.2641	.2263	.2401	.3018	.415
24	.2572	.2401	.2401	.2134	.2401	.2401	.2641
Max	.3772	.4527	.4527	.3772	.4801	.4527	.7167
Min	.2572	.2263	.1886	.1509	.2058	.1509	.2401
Avg	.2915	.3076	.2998	.2598	.2679	.2711	.3531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 203 / 11 KV EKLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5487	.6413	.6036	.583	.5658
2	.6036	.5487	.6413	.6036	.5487	.5658
3	.6413	.583	.6036	.6413	.5487	.5281
4	.679	.6173	.6413	.7545	.6516	.5281
5	.7545	.7716	.7167	.7545	.6859	.6602
6	.9054	.823	.9054	.8676	.9054	.8299
7		.6859	.7545	.7545	.7545	.7545
8	.679	.6173	.7167	.679	.6036	.5281
9	.5281	.5487	.6036		.2058	.2743
10		.3018	.3086		.2401	
11		.3018	.2743		.2401	
12		.3018	.2743		.2058	
13		.3018	.2743		.2229	
14		.3018	.2743		.2743	
15		.2641	.2572		.2743	
16		.3395	.3086		.1372	
17		.3772	.3086		.5658	
18		.6413	.5281		.6036	
19		.7545	.679		.679	
20		.7545	.7167		.7545	
21		.7545	.679		.679	
22		.679	.679		.6036	
23		.679	.6036		.6036	
24	.6036	.5487	.6413	.6036	***	.5658
Max	.9054	.823	.9054	.8676	94.2045	.8299
Min	.5281	.2641	.2572	.6036	.1372	.2743
Avg	.6665	.5436	.5430	.6958	4.4073	.5801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 204 / 11 kV KOLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5144	.5487	.3772	.4115
2	.5487	.5487	.5487	.5487	.3772	.3429
3	.5487		.5487	.5487	.4115	.3601
4	.5487	.5658	.583	.583	.3772	
5	.5658	.583	.583	.583	.3429	
6	.5658	.583	.6001	.6173	.5487	
7	.6173	.5487	.8299	.583	.6173	
8	.5487	.5487	.6859	.6001	.4801	.5144
9	.5144	.4115	.5487	.5281	.5658	.5281
10		.5658	.5658	.5281		
11		.5281	.4904	.4904		
12		.5281	.5281	.5281	.5658	
13		.5658	.5658	.5658	.5658	
14		.5281	.6036	.6036	.6036	
15		.5281	.6036	.5658	.4904	
16		.5658	.6036	.5281	.4527	
17		.5658	.5658	.5281	.4715	
18		.5658	.4527		.5658	
19		.7922	.7545	.7545	.679	
20		.9431	.8299	.8299	.7922	
21		.8299	.8299	.8676	.8299	
22		.7545	.7545	.679	.7545	
23		.7167	.679	.4115	.4458	
24	.5487	.5144	.5144	.4572	.3944	.4458
Max	.6173	.9431	.8299	.8676	.8299	.5281
Min	.5144	.4115	.4527	.4115	.3429	.3429
Avg	.5556	.6013	.616	.5860	.5322	.4338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 207 / 11 KV INCOMER-I

Feeder KV- 11 / INCOMING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 201 / 11 KV ANDHERA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1417	.1052	
2		.1417	.124	
3	.2241	.1417	.1417	
4	.2241	.1772	.1402	
5	.2987	.1949	.1595	
6	.3361	.1949	.1949	
7	.2614	.2303	.1949	
8		.2303	.1578	
9		.1772		
13				.1772
14				.1949
15				.1595
16				.1578
24	.1867	.1417	.0914	
Max	.3361	.2303	.1949	.1949
Min	.1867	.1417	.0914	.1578
Avg	.2454	.1772	.1455	.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 202 / 11 KV ANTRI KH. AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.2481			
10		.3189		.3012			
11	.3544	.443		.2658		.1595	
12	.3366	.3189		.2835		.1772	
13	.3189	.2658		.2658			.1753
14	.3189	.2658		.2126		.2126	.1949
15	.3012	.2126	.3366			.2303	.1578
16	.2658	.0354	.3506		.1509	.2481	.1595
17	.2481	.0354	.4075			.2303	
18	.3544						
Max	.3544	.443	.4075	.3012	.1509	.2481	.1949
Min	.2481	.0354	.3366	.2126	.1509	.1595	.1578
Avg	.3123	.2370	.3649	.2628	.1509	.2097	.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 203 / 11 KV BHAROSA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.0354		
10			.0886	.0354	.0373	
11	.0709		.1063		.0373	.0532
12	.0876	.0354	.0886		.0373	.0354
13	.0709	.1063	.0532		.0373	.0354
14	.0709	.0886	.0532		.0377	.0354
15	.0532	.0532	.0354		.0747	.0532
16	.0532	.0532	.0532		.0747	.0532
17	.0526	.0709	.0532			
Max	.0876	.1063	.1063	.0354	.0747	.0532
Min	.0526	.0354	.0354	.0354	.0373	.0354
Avg	.0656	.0679	.0665	.0354	.0480	.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 204 / 11 KV ANTRI KH GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5316	.567	.5316	.4961	.4854	
2	.5658	.567	.6024	.567	.4961	.4854	
3	.6722	.567	.6379	.6201	.567		
4	.7842	.7087	.7442	.7011	.7087		
5	1.0829	1.0454	.8505	.8328	.7796		
6	1.1203	1.0631	.9568	.9036	.9214		
7	1.0456	1.0631	.9214	1.0277	.9922		
8			.9214				
9			.7087	.8505			
10		.567	.6379	.6379	.679		
11	.4784	.4961	.4961	.567	.5975	.5316	.4252
12	.5316	.4961	.5316	.5316	.5228	.4961	.4557
13	.6379	.4961	.567	.5316	.4904	.567	.4961
14	.5847	.6379	.5083	.4961	.5281	.567	.4382
15	.5609	.4961	.4961		.5658	.6379	.4557
16	.7265	.4961	.6201	.4252	.6036	.6379	.4961
17	.7796	.567	.6379	.6379	.6348	.6379	.7011
18		.9568	.8505		.7095	.7796	.8413
19		.9922	.9214	.7796	.7842	.9214	
20		.9214	.8505	.8505	.6722	.8859	
21		.7796	.691	.6379	.5975	.6201	
22		.6379	.567	.6379	.5601	.5316	
23		.567	.567	.567	.5228	.4961	
24	.5601	.5493	.567	.7621	.4961	.4854	
Max	1.1203	1.0631	.9568	1.0277	.9922	.9214	.8413
Min	.4784	.4961	.4961	.4252	.4904	.4854	.4252
Avg	.7131	.6910	.6842	.6713	.6330	.6104	.5387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 205 / 11 KV BHAROSA GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4607	.4252	.4031	.1595	.4481	
2	.5281	.4908	.4961	.4207	.1595	.4481	
3	.5601	.5493	.6024	.5609	.1772	.5093	
4	.7167	.6836	.7087	.7362	.1772	.7167	
5	.9709	.8764	.8413	.8682	.5138	1.0456	
6	1.2696	1.1218	.9114	.9465	.5493	1.1506	
7	1.1694	1.1694	1.1218	1.1871	.6024		
8	1.094	.9745	1.0166	1.0341		1.3443	
9		.8764	.8328	.9036		1.2826	
10		.5316	.567	.6201	.2614	1.1506	
11		.567	.4607	.5316	.3395	1.0631	.4252
12	.6201	.5493	.4961	.5316	.3734	1.0631	.4075
13	.5609	.4784	.5138	.567			.3721
14	.5847	.4961	.5316	.4961		1.0985	.4207
15	.6201	.5138	.567	.6556	.6722	.6733	.4557
16	.6556	.6024	.6379	.691	.8775	.6556	.5083
17	.6836	.6201	.6661	.7087	.3395	.8589	.815
18		.9214	.9214		.9149	.9214	.9391
19		.8859	.9922		.7842	1.0277	
20		.7796	.7442	.3366	.6722	.9568	
21		.6379	.6661	.2303	.5601	.8682	
22		.5316	.4607	.1772	.4854	.6201	
23		.4252	.4382	.1772	.4481	.4075	
24	.5281	.443	.4252	.4572	.1595	.4481	
Max	1.2696	1.1694	1.1218	1.1871	.9149	1.3443	.9391
Min	.5281	.4252	.4252	.1772	.1595	.4075	.3721
Avg	.7393	.6744	.6685	.6018	.4613	.8526	.5430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 206 / 11 KV DEULGAON GHUBE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.124	.124	.124		.112	
2	.112	.1052	.124	.1063		.112	
3	.112	.1052	.124	.1063		.112	
4	.112	.124	.1772	.124			
5	.1494	.1417	.1772	.1417			
6	.1867	.1772	.1949	.1595			
7		.1949	.1949	.1772			
8		.1417	.2303	.2454		.0754	
9		.0886	.1949				
11							.0532
12							.0532
13							.0701
14							.0709
15							.0886
16							.0886
22					.112		
23					.112		
24	.1509	.124	.124	.1524		.112	
Max	.1867	.1949	.2303	.2454	.112	.112	.0886
Min	.112	.0886	.124	.1063	.112	.0754	.0532
Avg	.1389	.1327	.1665	.1485	.112	.1047	.0708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 209 / 11 KV MANUBAI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18
HR	Load (MW)
7	.1886
Max	.1886
Min	.1886
Avg	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 201 / 11 KV RAUT WADI (TOWN)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.924		.7621
2		.9145	.9149		.7621
3		.8764	.8962		.724
4		.8764	.7392		.6859
5		.8192	.695		.6287
6		.7811	.6468		.5906
7		.724	.6036		.6097
8		.6287	.5729		.5716
9		.5906	.5487	.5335	.5144
10	.5906	.6097		.4954	.4954
11	.6097	.567		.5144	.4572
12	.6478	.5914		.5525	.4854
13	.6859			.4954	
14	.6668			.5335	.5121
15	.724			.5144	.567
16	.743			.5525	.5975
17	.7049			.5525	.5544
18	.6859			.5906	.5601
19	.7811			.6097	.6283
20	.7811			.743	.7499
21	.8764			.6859	.823
22	.9335			.743	.8686
23	.9717			.8573	.8501
24		.9526	.9328		.8002
Max	.9717	.9526	.9328	.8573	.8686
Min	.5906	.567	.5487	.4954	.4572
Avg	.7430	.7574	.7474	.5982	.6434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 202 / 11 KV RAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4382
2				.4191
3				.4191
4				.4572
5				.4954
6				.5335
7				.6478
8				.6478
9			.4382	
10	.7811	.7811	.5144	
11	.9907	.7701	.5716	
12	.9526	.7459	.5144	
13	.9335		.6478	
14	.8383		.6668	
15	.8192		.5716	
16	.8192		.5716	
17	.9335			
23			.4001	
24				.4763
Max	.9907	.7811	.6668	.6478
Min	.7811	.7459	.4001	.4191
Avg	.8835	.7657	.5441	.5038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 203 / 11 KV SHELLOOR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.4572		.6287
2		.5906	.4572		.6668
3		.6478	.5175		.743
4		.724	.5853		.8383
5		.8002	.6722		.9145
6		.8954	.8215		.9907
7		.8764	.8048		.9145
8		.6478	.7947		.8573
9		.6478	.6584	.6478	.5525
10	.5716	.5906		.5525	
11	.5144	.4572		.4954	.426
12	.5716	.4854		.4954	.3481
13	.5335			.4382	.2195
14	.5716			.4572	.5975
15	.6097			.4954	.5544
16	.5906			.4954	.5121
17	.5906			.6097	.5853
18	.6287			.6859	.6219
19	.8002			.724	.7577
20	.8383			.7811	.7865
21	.8383			.6859	.7392
22	.743			.6478	.6219
23	.6287			.6097	.6401
24		.5906	.2858		.5906
Max	.8383	.8954	.8215	.7811	.9907
Min	.5144	.4572	.2858	.4382	.2195
Avg	.6451	.6558	.6055	.5881	.6568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 204 / 11 KV SAKEGAON GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.2743		.3239
2		.3429	.2801		.381
3		.4001	.3361		.4382
4		.4763	.3841		.5335
5		.5335	.5228		.5906
6		.5906	.6036		.6478
7		.4954			.4572
8		.4763			.4382
9		.2858		.3239	.362
10	.2858	.3048		.3048	.2667
11	.2858	.2772		.1905	.1646
12	.2858	.2561		.2096	.2012
13	.2858			.2858	.1829
14	.2858			.2477	.2218
15	.2858			.2858	.2378
16	.2858			.2858	.2587
17	.362			.3429	.3109
18	.4001			.381	.4207
19	.5335			.4763	.499
20	.5144			.4001	.4572
21	.4001			.3429	.3841
22	.362			.3048	.3109
23	.3239			.3048	.3361
24		.2858	.2858		.2858
Max	.5335	.5906	.6036	.4763	.6478
Min	.2858	.2561	.2743	.1905	.1646
Avg	.3498	.3854	.3838	.3124	.3630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 206 / 11 KV SHEL SOOR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	31-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	.4572	
2	.4763	
3	.5144	
4	.5525	
5	.5906	
6	.6287	
7	.724	
8	.7621	
9	.743	.4954
10		.6097
12		.426
13		.3605
14		.3978
15		.4424
16		.4752
24	.4572	
Max	.7621	.6097
Min	.4572	.3605
Avg	.5906	.4581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286] BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 201 / 11 KV MURADPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4334	
3					.4694
4					.4915
5					.7712
6					.823
7					.8383
8			.5548	.6935	
9			.4161		
10			.5144		
11			.3988		
12			.3988	.4359	
13			.3988		
14			.3814		
15			.3814		
16		.4161	.4161		
17	.4359	.4681			
18		.7373			
19		.7455			
20		.6762			
21		.5316			
22		.5028			
23		.4508			
24			.9145	.4382	
Max	.4359	.7455	.9145	.6935	.8383
Min	.4359	.4161	.3814	.4334	.4694
Avg	.4359	.5661	.4775	.5003	.6787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 202 / 11 KV YEOTA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.1214
10			.1715
14			.1734
15			.1214
16		.1886	.1578
17	.1806	.1543	
Max	.1806	.1886	.1734
Min	.1806	.1543	.1214
Avg	.1806	.1715	.1491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 203 / 11 KV BHALGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2774	
3			.0151
6			.0301
7	.2601		
8		.0347	
24		.2572	
Max	.2601	.2774	.0301
Min	.2601	.0347	.0151
Avg	.2601	.1898	.0226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 204 / 11 KV RAMNAGAR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
9		.1372
10		.2103
11		.2601
12		.2254
13		.1734
14		.156
15		.1734
16	.1715	.1372
17	.1543	
Max	.1715	.2601
Min	.1543	.1372
Avg	.1629	.1841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 205 / 11 KV GANGALGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
8		.0347
24	.0572	
Max	.0572	.0347
Min	.0572	.0347
Avg	.0572	.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 206 / 11 KV CHANDANPUR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
2		.1907
3		.1907
4		.2427
5		.2774
6		.3814
7		.3121
8		.3121
9	.1715	
10	.2601	
11	.2254	
12	.2572	
13	.2774	
14	.208	
15	.208	
24	.1981	.1387
Max	.2774	.3814
Min	.1715	.1387
Avg	.2257	.2557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 201 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.2229			.12
2	.2743		.2229			.12
3	.2743		.2401			.12
4	.2743		.2401			.1372
5	.2743		.2401			.1372
6	.2743		.2743			.1372
7		.3772		.3601		
8		.3772		.3772		
9		.3429		.3601		
10		.2743		.3258	.0686	
11		.2743		.2915	.2401	
12		.2229		.3086	.2401	
13		.2058		.2915	.2058	
14		.2058		.2572	.1715	
15					.1372	
16					.1372	
23		.2401		.2401	.12	
24	.2743		.2229			.12
Max	.2743	.3772	.2743	.3772	.2401	.1372
Min	.2743	.2058	.2229	.2401	.0686	.12
Avg	.2743	.2801	.2376	.3125	.1651	.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 202 / 11 KV MANGRUL GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6687	.6859	.6516	.7373	.6516	.6516
2	.7202	.6687	.7202	.6516	.7373	.6516	.6516
3	.7888	.6687	.7545	.6859			.6859
4	.8402	.7202	.8059	.6859			.9259
5	.9088	.7888	.8573	.9602	.8916		1.046
6	1.1831	1.1488	1.2003	1.166	1.1317		1.2346
7	1.0288	1.0117	1.1145	.9602	1.046		1.1145
8	.9088		.9088	.9431			1.0288
9	.9259	.8573	.8745	.8745	.8916	.8916	.8573
10	.6516	.703	.8573	.6516	.703	.7716	.6687
11	.6173	.6173	.703	.5316	.6001	.5144	.6001
12	.583	.6344	.6516	.583	.5316	.5487	
13	.6173	.6687	.6859	.5316	.5658	.5144	.5487
14	.6344	.6859	.6859	.6344	.6173	.5316	.6344
15	.703	.6859	.6173	.6344	.6516	.5487	.6001
16	.6859	.6687	.5144	.6344	.6859	.5487	.6001
17	.7716	.7202	.7202	.6687	.703	.5658	.6344
18	.8745	.8916	.6859	.823	.9088	.583	.7888
19	1.046	1.2517		.9602	.8573	.6344	1.0974
20	1.0802	1.166	.6001	.9431	.9945	.6344	1.2003
21	.8745	.8745		.8573	.8059	.6859	.9774
22	.7716	.8573	.5144	.7716	.7373	.7545	.7888
23	.7202	.7373	.6859	.7202	.6859	.6687	.7373
24	.7373	.6687	.703	.4382	.7373	.6687	.6516
Max	1.1831	1.2517	1.2003	1.166	1.1317	.8916	1.2346
Min	.583	.6173	.5144	.4382	.5316	.5144	.5487
Avg	.8081	.7984	.7521	.7484	.7724	.6316	.8141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 203 / 11 KV DONGERGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145			.8916	
2		1.0288			.8916	
3		.9602				
4		.9088				
5		.9088				
6		1.0117				
7	1.3375		1.286			.8573
8	1.3203		1.166			.8573
9	1.286		1.3032	.1886		.9259
10	1.3889		1.286	1.0288		1.0669
11	1.3889		1.286	1.2346		.9774
12	1.2346		1.1317	1.286		.9088
13	1.046		1.166	1.2346		.9088
14	1.0288		1.2003	1.1145		.8059
15				.9945		
16				.9259		
17				1.0288		
23	1.1488			.8916		.8916
24		1.1831			.9259	
Max	1.3889	1.1831	1.3032	1.286	.9259	1.0669
Min	1.0288	.9088	1.1317	.1886	.8916	.8059
Avg	1.2422	1.0166	1.2282	.9928	.9030	.9111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 204 / 11 KV ISOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229			.0343	
2		.2229				
3		.2229				
4		.2572				
5		.2743				
6		.2915				
7	.3772		.3429			.2401
8	.463		.3772			.2401
9	.3601					.2401
10	.3601			.3429		.2401
11	.3258			.3772		.2743
12	.3086		.2401	.3086		.2743
13	.3086		.3086	.3429		.3086
14	.3429		.2401	.2401		.2743
15			.2401			
16			.2401	.1715		
17				.1715		
23	.3086			.0343		.2058
24		.2229			.0343	
Max	.463	.2915	.3772	.3772	.0343	.3086
Min	.3086	.2229	.2401	.0343	.0343	.2058
Avg	.3505	.2449	.2842	.2486	.0343	.2553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 205 / 11 KV DAHIGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1372		.0514		.0686
2	.1372		.1372		.0514		.0686
3	.1372		.1372				.0686
4	.1372		.1372				.0686
5	.1715		.1372				.0686
6	.2058		.2058				.0686
7		.2743		.2058		.1029	
8		.1715		.2401		.1029	
9		.2743		.3429		.0686	
10		.2401		.2572		.0686	
11		.2058		.2229		.2401	
12		.2058		.2058		.2401	
13		.1715		.1886		.2229	
14		.1886		.1715		.1029	
23		.2058		.0686		.0857	
24	.1372		.1372		.0686		.0686
Max	.2058	.2743	.2058	.3429	.0686	.2401	.0686
Min	.1372	.1715	.1372	.0686	.0514	.0686	.0686
Avg	.1519	.2153	.147	.2115	.0571	.1372	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 206 / 11 KV NAIGON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2915	.2743	.3086	.2915	.2743	.3086
2	.3258	.2915	.3086	.3086	.2915	.2743	.3086
3	.3601	.2915	.3429	.3429		.2743	.3772
4	.4115	.3429	.4458	.4115			.4115
5	.4458	.4458	.4801	.4458			.4801
6		.463					
11				.2915	.2401	.2401	.2401
12					.2401	.2401	.2058
13		.2401			.2401	.2401	.2058
14		.2743		.2743	.2058	.2058	.2058
15	.8573	.7202		1.1317	.9259	.5144	.6516
16	.9602	.823	1.0288	.8916	.9259	.6001	.7202
17	.9431	.8916	1.0288	1.0974	.9774	.7202	.7545
18	1.0631	.6859		.9945	.9259	.7202	.7202
19	1.0631	1.0802	1.0288	1.0288	.9602	.6344	.7545
20	1.0288	1.0631	1.0631	1.0288	.9088	.6173	.7202
21	.9088	1.0117	1.0288	.9945	.823	.583	.7202
22	.8916	.9088	.9602	.9259	.7716	.5658	.7202
23	.3086	.3086	.2743	.3086	.3086	.3086	.3086
24	.3086	.2915	.2743	.4267	.583	.2915	.3086
Max	1.0631	1.0802	1.0631	1.1317	.9774	.7202	.7545
Min	.2915	.2401	.2743	.2743	.2058	.2058	.2058
Avg	.6779	.5792	.6568	.6595	.6012	.4297	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5914		.2957	.2402	.4435	
2		.5729	.4805	.2772	.2218	.4435	.3881
3	.3326	.5729	.2957	.2587	.2218	.4251	.3881
4	.3142	.5544	.2957	.2772	.2218		.3326
5	.3142	.5544	.4805	.2587	.2033	.1294	.2772
6	.3326	.5359	.5914	.2402	.2033		.2772
7	.3326	.2957	.6838	.2587	.2772		.2957
8	.3326	.4805		.2772	.2402		.2652
9	.499	.5175	.6838	.3326	.4251		
10	.5544	.7577	.7762	.5544		.2218	.3881
11	.6283	.8131	.9979	.8316	.5359	.4435	.499
12	.9795	.5914	.9425	.9979	.6283	.8871	.4435
13	.9979	.8871	.8871	.8501	.5914	.6653	.4805
14	.7762	.924	.9055	.8131	.6283	.6653	.5359
15	.7577	.8316	.924	.924	.6099	.6838	.4251
16	.7207	.6653	.9425	.7762	.6099	.8316	.4066
17	.961	.6099	.7762	.6283	.5914	.6283	.3326
18	.7207	.5359	.6099	.499	.8131	.6468	.2218
19	.7947	.462	.7207	.5175	.7392	.5544	.2772
20	.5729	.8316	.4805	.6468	.2772	.5175	.3326
21	.6099	.6468		.4251	.5914	.6283	.3326
22	.6838	.5544	.3326	.5914	.5914	.6283	.3511
23	.6468	.4805	.3326	.3142	.6283	.4835	.3326
24		.5914	.3511	.3429	.2772	.462	.5914
Max	.9979	.924	.9979	.9979	.8131	.8871	.5914
Min	.3142	.2957	.2957	.2402	.2033	.1294	.2218
Avg	.6125	.6191	.6424	.5079	.4508	.5468	.3716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 202 / 11 KV SAILANINAGAR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6263	1.5729	1.5708	1.5339	1.3717	1.386	1.2197
2	1.5708	1.5364	1.5339	1.4969	1.3169	1.3676	1.2197
3	1.4784	1.5364	1.3491	1.46	1.2803	1.386	1.1458
4	1.423	1.4998	1.3491	1.4415	1.2254	1.2012	1.1458
5	1.386	1.4815	1.386	1.4045	1.1706	1.1273	1.1088
6	1.386	1.4449	1.4415	1.3491	1.1157	1.0903	1.1273
7	1.3306	1.3535	1.386	1.3121	1.0974	1.1273	1.1458
8	1.2567	1.2803	1.1827	1.2752	1.1157	1.1088	1.0719
9	1.2752	1.2437	1.1827	1.3306	1.1706	1.1088	
10	1.4266	1.3352	1.3306	1.2752		1.0719	1.2197
11	1.4998	1.5708	1.386	1.4998	1.6632	1.2197	1.3352
12	1.5546	1.5708	1.6078	1.5364	1.6632	1.2752	1.4083
13	1.6644	1.7372	1.7741	1.6644	1.6817	1.2752	1.4083
14	1.7193	1.6448	1.7556	1.701	1.6632	1.2752	1.5181
15	1.701	1.7741	1.7741	1.701	1.6632	1.2752	1.5364
16	1.829	1.7556	1.7741	1.7558	1.4784	1.2567	1.4632
17	1.8107	1.7372	1.7741	1.7193	1.4415	1.2197	1.5181
18	1.5546	1.6263		1.3717	1.4784	1.2382	1.2986
19	1.701	1.7372		1.5364	1.6263	1.3306	1.5546
20	1.7741	1.8111	1.848	1.6644	1.6263	1.4415	1.6644
21	1.7193	1.7002	1.8111	1.6095	1.4784	1.386	1.5546
22	1.6827	1.7372	1.7002	1.6644	1.4784	1.3491	1.5729
23	1.6827	1.7187	1.6448	1.5729	1.5154	1.3306	1.4998
24	1.7556	1.6461	1.6263	1.6575	1.4449	1.4045	1.3121
Max	1.829	1.8111	1.848	1.7558	1.6817	1.4415	1.6644
Min	1.2567	1.2437	1.1827	1.2752	1.0974	1.0719	1.0719
Avg	1.5754	1.5855	1.5540	1.5222	1.4246	1.2605	1.3500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 203 / 11 KV KHANDALA AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.2881		.2984	.2721	.2652	.2984
2	.2984	.2721	.2652	.2984	.2721	.2652	.2984
3	.3149	.2721	.2652	.2984	.2721	.2652	.2652
4	.3315	.3041	.2652	.3481	.2881	.2652	.2652
5	.3647	.3681	.2984	.3978	.3041	.2321	.3481
6	.3978	.4641	.3647	.4144	.3361	.3978	.431
7	.4973	.3841	.4144	.3978	.3361	.3812	.4475
8	.4144	.3681	.3978	.3978	.3361	.3647	.4144
9	.3481	.3361	.3812	.3481	.2561	.2984	.3481
10	.3361	.3201	.3647	.3978		.2818	.2984
11	.3201	.2984	.3481	.2915	.2652	.3326	.112
12	.3041	.2652	.2984	.3041	.2818	.2486	.2721
13	.2881	.2652	.2984	.3041	.3315	.2486	.2881
14	.2881	.2652	.2984	.3041	.2984	.2486	.208
15	.2721	.3812	.3149	.2881	.1658	.2652	.2721
16	.3041	.3647	.3481	.3201	.2155	.3647	.2721
17	.3841	.3149	.3978	.3681	.1658	.431	.3361
18	.4481	.3978	.2486	.3521	.2818	.4475	.3361
19	.4481	.4144	.2984	.3681	.3315	.4475	.4641
20	.4161	.3978	.3978	.3681		.3812	.4001
21	.3681	.3481	.3647	.3361	.2984	.3315	.3521
22	.3041	.3315	.3149	.3361	.2984	.3149	.3521
23	.3041	.3149	.3149	.2881	.2652	.3481	.3201
24	.3149	.3041	.3149	.1829	.2721	.2652	.2818
Max	.4973	.4641	.4144	.4144	.3361	.4475	.4641
Min	.2721	.2652	.2486	.1829	.1658	.2321	.112
Avg	.3486	.3350	.3294	.3337	.2793	.3205	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 201 / 11 KV SAWANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0668	.0534	.0681	.0452	.046	
2	.0657	.0676	.0536	.0674	.0443	.0511	
3	.0667	.0681	.0537	.0672	.0438	.0524	
4	.0676	.0691	.0674	.064	.0434	.0667	
5	.098	.1128	.0812	.0616	.0509	.0804	
6	.168	.245	.1085	.1417	.0835	.0922	
7	.3009	.2222	.2473	.2138	.2023	.2377	
8	.2885	.2521	.2545	.1808	.2204	.2364	
9	.1758	.221	.2129				.1334
10							.1696
11							.1646
12							.1778
13							.1273
14	.1758						.0887
15							.12
16							.0934
23				.0473	.0527		
24	.0624	.072	.0533	.0672	.0476	.0457	
Max	.3009	.2521	.2545	.2138	.2204	.2377	.1778
Min	.0624	.0668	.0533	.0473	.0434	.0457	.0887
Avg	.1395	.1397	.1186	.0979	.0834	.1010	.1344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 202 / 11 KV WALTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0648
2							.0665
3							.0668
4							.0674
5							.0812
6							.1233
7							.2364
8							.2201
9					.1389	.1264	
10	.2804	.2877	.2942		.1825	.107	
11	.3548	.3582	.2705		.168	.1758	
12	.3418	.316	.2588		.1534	.1872	
13	.2801	.2715	.2503		.1664	.1379	
14	.2241	.228	.2521		.1125	.1496	
15	.2503	.2697	.2782	.0932	.1105	.1262	
16	.2555	.2277	.3026	.1715	.1113	.1379	
17	.2843	.2436	.303				
23						.0519	.12
Max	.3548	.3582	.303	.1715	.1825	.1872	.2364
Min	.2241	.2277	.2503	.0932	.1105	.0519	.0648
Avg	.2839	.2753	.2762	.1324	.1429	.1333	.1163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 203 / 11 KV SAWANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5072	.5067	.4899	.5239	.5239	.5082	.5072
2	.5082	.5067	.4904	.5249	.5233	.5087	.5082
3	.5087	.5077	.5287	.5271	.5244	.5658	.5093
4	.5281	.5082	.6054	.5475	.5249	.6042	.5292
5	.5464	.5653	.7167	.5624	.5823	.6413	.5676
6	.6413	.6406	.6986	.6797	.679	.6615	.7
7	.603	.6143	.5859	.6023	.6212	.6042	.6231
8	.4869	.563	.6161	.5999	.5046	.5847	.5636
9	.9336	.449	.5067	.5041	.5201	.5276	.3067
10	.7438	.4312	.4099	.3889	.2949	.4099	.3909
11	.7706	.3742	.4259	.3861	.3901	.3493	.3493
12	.7722	.3921	.4087	.3685	.3708	.3129	.3132
13	.7722	.3746	.4207	.4003	.3889	.37	.3116
14	.7743	.4141	.4229	.3841	.4099	.333	.3677
15	.422	.3566	.4596	.4045	.3929	.3519	.3708
16	.4229	.4706	.4036	.4057	.3941	.3913	.3696
17	.4185	.4518	.4062	.3282	.4518	.4172	.3985
18	.5041	.5442		.2695	.526	.5516	.5132
19	.6515	.6212		.4251	.6742	.6124	.6264
20	.708	.7334	.5975	.7202	.6174	.6387	.7267
21	.6528	.6588	.6174	.6495	.5613	.5448	.618
22	.5601	.5601	.6168	.595	.5618	.5442	.5618
23	.5404	.5459	.5613	.5601	.5067	.5244	.5255
24	.5046	.5228	.4894	.5335	.5249	.5093	
Max	.9336	.7334	.7167	.7202	.679	.6615	.7267
Min	.4185	.3566	.4036	.2695	.2949	.3129	.3067
Avg	.6034	.5130	.5217	.4955	.5029	.5028	.4895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 201 / 11 KV GODHARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	31-MAY-18
HR	Load (MW)
16	.2561
Max	.2561
Min	.2561
Avg	.2561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 202 / 11 KV CHANGHI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.3174	.3174	.2987	.2987	.3174
2	.3361	.3361	.3174	.3142	.2987	.2987	.3734
3	.4108	.3361	.3174	.3174	.2987	.3326	.4108
4	.3734	.3734	.3361	.4108	.3361	.3361	.4481
5	.3734	.4854	.4854	.4938	.4668		.5228
6	.3734	.5601	.6161	.5544	.5975		.5601
7	.5068	.4854	.4854	.5041	.5228		.5601
8	.4706	.4108	.4108	.4066	.4481	.2614	.4435
9	.4344	.3696	.4066	.3547	.4294	.2241	.3696
10	.2896	.2743	.2926	.2378	.3361	.168	.2587
11	.2195	.2	.2402	.2054	.2402	.2218	.2402
12	.2534	.2	.2561	.2957	.2195	.2402	
13	.2534	.2715	.2218	.2587	.2427	.1848	.2561
14	.2534	.2134	.2561	.2743	.2402	.2402	.2561
15	.2172	.2896	.2402	.3109	.2561	.2402	.2743
16	.2926	.3258		.3475	.2987		.2715
17	.3292	.3292	.3142	.3841	.3326	.3361	.3658
18	.4024	.3696	.3881	.3841	.4481	.4207	.3658
19	.5041	.4854	.4435	.5041	.462	.4481	.4481
20	.5228	.4854	.4668	.4668	.4108	.4668	.5041
21	.4108	.4108	.3881	.4108	.3734	.3734	.4481
22	.3734	.3734	.3361	.3734	.3547	.3547	.3734
23	.3547	.3361	.3174	.3174	.3174	.3174	.3361
24	.2987	.3361	.3361	.3109	.2987	.2957	.3174
Max	.5228	.5601	.6161	.5544	.5975	.4668	.5601
Min	.2172	.2	.2218	.2054	.2195	.168	.2402
Avg	.3579	.3581	.3561	.3648	.3553	.3030	.3792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 203 / 11 KV BHOKER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.1097	.1082	.112	.0869	.0791	.2115
2	.2054	.1097	.1082	.1107		.0791	.2538
3	.2201	.1082	.0947	.112		.08	.2782
4	.2641	.1353	.1082	.1107	.0869		.3338
5	.2934	.1623	.1353	.125	.0724		.3894
6	.3081	.2705	.2435	.1898	.1448		.3894
7	.2606	.2667	.2164	.3479	.2896		
8	.2462	.2934	.2667	.2846	.2606	.2056	
9	.2317	.2134	.2134	.3637	.1907	.3521	.1235
10	.4287	.4599	.439	.4218	.242	.3475	.2469
11	.2029	.4801	.4428	.4311		.333	.1623
12	.0549	.4934	.4902		.4744	.3475	
13	.0549	.4268	.4531		.4218	.3475	.2134
14	.0412	.3868	.4062		.3906	.333	.16
15	.4664	.4001	.427	.153	.3637	.3765	.2
16	.487	.4001	.4586	.1947	.4531	.3475	.1623
17	.4664	.4268	.4687				
23				.0869	.0937	.2058	.3243
24	.176	.1097	.1235	.1067	.0869	.096	.2115
Max	.487	.4934	.4902	.4311	.4744	.3765	.3894
Min	.0412	.1082	.0947	.0869	.0724	.0791	.1235
Avg	.2547	.2918	.2891	.2100	.2439	.2522	.2440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 201 / 11 KV CHIKHALI TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	3.0484
Max	3.0484
Min	3.0484
Avg	3.0484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 203 / 11 KV (Kelwad) TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 205 / 11 KV SOOTGIRANI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 207 / 11 KV ROHADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286] BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 401 / 33 KV Jafrabad

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	11.4312
Max	11.4312
Min	11.4312
Avg	11.4312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 402 / 33 KV Dhad

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	10.8596
Max	10.8596
Min	10.8596
Avg	10.8596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 403 / 33 KV BULDHANA

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 405 / 33 KV AMDAPUR

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	6.2872
Max	6.2872
Min	6.2872
Avg	6.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 406 / 33 KV DUSARBID

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	9.4307
Max	9.4307
Min	9.4307
Avg	9.4307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 078002 / 220 KV CHIKHALI EHV S/S

Feeder No / Name : 407 / 33 KV MIDC

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
6		.1677
19	.2347	
24	.0848	
Max	.2347	.1677
Min	.0848	.1677
Avg	.1598	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 201 / 11 KV ANDERA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.2572	.3429
2	.3429	.3429	.3429	.3429	.2572	.1715
3	.3429	.3429	.3429	.3429	.2572	.1715
4	.4287	.3429	.3429	.4287	.2572	.1715
5	.5144	.4287	.5144	.5144	.3429	.2572
6	.6001	.5144	.6001	.6001	.5144	.3429
7	.5144	.5144	.6001	.6001	.6001	.3429
8	.5144	.5144	.5144	.6001	.6001	.2572
9	.4287	.5144	.5144	.5144	.4287	.2572
10	.4287	.3429	.3429	.3429	.4287	.1715
11	.4287	.3429	.3429	.3429	.3429	.1715
12	.3429	.3429	.3429	.3429	.3429	.3429
13		.3429	.3429	.3429	.3429	.3429
14		.4287	.3429	.3429	.3429	.3429
15	.3429	.3429	.3429		.3429	.3429
16	.3429	.3429	.3429		.3429	.3429
17	.3429	.4287			.4287	.4287
18	.4287	.5144	.3429		.4287	.5144
19	.5144	.6001	.5144		.6001	.5144
20	.5144	.5144	.4287		.5144	.5144
21	.4287	.3429	.4287		.4287	.5144
22	.3429	.3429	.3429		.3429	.4287
23	.3429	.3429			.3429	.3429
24	.3429	.3429	.3429	.1357		.3429
Max	.6001	.6001	.6001	.6001	.6001	.5144
Min	.3429	.3429	.3429	.1357	.2572	.1715
Avg	.4170	.4072	.4053	.4091	.3951	.3322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 202 / 11 KV Mendgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.2572	.2572		.1715
2	.4287	.4287	.2572	.2572		.1715
3	.4287	.4287	.2572	.2572		.1715
4	.5144	.4287	.3429	.3429		.1715
5	.6001	.5144	.5144	.4287		.2572
6	.6859	.6001	.6859	.6001		.3429
7	.6001	.5144	.6001	.5144		.3429
8	.5144	.5144	.6001	.5144		.2572
9	.4287	.4287	.5144	.3429		.1715
10	.2572	.2572	.2572	.2572		
11	.2572	.1715	.2572	.2572		.1715
12	.2572	.1715	.2572	.2572		.1715
13	.2801	.1715	.1715	.2572		.1715
14	.2572	.1715	.1715	.2572		
15	.2572	.1715	.1715			.1715
16	.2572	.1715	.2572			.1715
17	.3429	.2572			.0857	.2572
18	.4287	.3429	.4287		.1715	.3429
19		.3429	.4287		.2572	.3429
20	.3429	.3429	.3429		.1715	.3429
21	.2572	.2572	.3429		.1715	.2572
22	.2572	.2572	.2572		.1715	.2572
23	.2572	.1715	.2572	.2543	.1715	.2572
24	.4287	.4287	.2572	.1696		.1715
Max	.6859	.6001	.6859	.6001	.2572	.3429
Min	.2572	.1715	.1715	.1696	.0857	.1715
Avg	.3812	.3322	.3429	.3266	.1715	.2338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 203 / 11 KV MANGRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1357
Max	.1357
Min	.1357
Avg	.1357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2204
Max	.2204
Min	.2204
Avg	.2204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 201 / 11 KV DRAJA TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5935
Max	.5935
Min	.5935
Avg	.5935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 202 / 11 KV SRAJA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.298	.2477	.3841	.285	.2267	.3437
2	.4024	.298	.2286	.3841	.298	.1989	.3041
3	.5121	.3109	.2601	.3841	.298	.1677	.3048
4	.439	.3368	.2972	.4024	.298	.1638	.2984
5	.5853	.4146	.3715	.4024	.3715	.192	.3277
6	.6401	.4923	.4458		.4534	.2204	.4239
7	.6767	.5053	.695		.4405	.2713	.5487
8	.4489	.443	.6767		.3902	.2343	.503
9	.4199	.4161	.5853	.6036	.4252	.2713	.4586
10	.4344	.3765	.4207	.3772	.3418	.2458	.4001
11	.3567	.3765	.439	.2462	.2892	.2429	.415
12	.3475	.362	.4715	.2705	.2606	.2622	.3109
13	.3429	.3311	.439	.306	.2606	.3315	.2846
14	.3185	.3185	.4207			.3688	.3475
15	.3269	.3475	.4207	.3812		.4115	.3163
16	.4214	.3475		.3812			.3841
17	.3887	.4344				.3277	.3041
18	.4087	.4515			.0781	.4049	.3024
19	.483	.4755	.6767		.0983	.4641	.3155
20	.5201	.4755	.6401		.0678	.5087	.3418
21	.4706		.5487		.0914	.4801	
22	.3096		.439		.3563	.4973	.3155
23			.4024		.3353	.426	.3024
24	.4207	.298	.2477	.4287	.2724	.2458	.4001
Max	.6767	.5053	.695	.6036	.4534	.5087	.5487
Min	.3096	.298	.2286	.2462	.0678	.1638	.2846
Avg	.4381	.3862	.4464	.3809	.2856	.3115	.3588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 203 / 11 KV DRJA TOWN-2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.5573	.583	.7796	.3887	.5601	.5304
2	.9328	.5573	.57	.7796	.3757	.4807	.4801
3	.8962	.5697	.57	.7682	.3368	.3437	.4748
4	.8779	.582	.5571	.7682	.3239	.3681	.3763
5	.8779	.6068	.583	.7087	.298	.4144	.4424
6	.8962	.6068	.6219		.298	.5761	.5144
7	.9054	.8383	.9145		.3757		.6344
8	.6923	.6805	.9145		.3094	.5243	.5487
9	.6622	.6805	.7865	.961	.4199	.5138	.5487
10	.6241	.6241	.7316	.7095	.5647	.3441	
11	.5792	.5792	.7499	.5546	.5792		.5304
12	.602	.5792	.7682		.5937	.4687	.5487
13	.602	.5502	.7682		.5792	.5243	.5487
14	.5937	.5502	.7499				.5853
15		.587	.7316	.6371		.6706	.6219
16		.6805		.6226		.6203	.2115
17	.582	.7074				.5668	
18	.5944	.6836	.8048		.4572	.6036	.5502
19	.6192	.7095	.8596		.5182	.6554	.5792
20	.6687	.724	.8596		.5868	.7377	.5792
21	.6563		.8779		.6249	.6802	
22	.6192		.9145		.6882	.6097	.7375
23			.7611	.2715	.6783	.5937	.823
24	.8962	.5573	.583	.8482	.3887	.6299	.5735
Max	.9328	.8383	.9145	.961	.6882	.7377	.823
Min	.5792	.5502	.5571	.2715	.298	.3437	.2115
Avg	.7282	.6291	.7391	.7007	.4693	.5470	.5447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 204 / 11 KV JUMDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1115	.1029	.1646	.1238	.0914	.0937
2	.1463	.1115	.1029	.1646	.1115	.0625	.08
3	.128	.1115	.1029	.1646	.1115	.0655	.0995
4	.128	.1238	.1029	.1646	.1115	.0838	.1017
5	.128	.1115	.1029	.1463	.1115	.0857	.1029
6	.1463	.1115	.1029		.0991	.0972	.116
7	.128	.1115	.1646		.0867	.1214	.1372
8	.092	.1132	.1646		.0907	.1341	.1357
9	.0789	.1166	.1646	.1646	.092	.0625	.0983
10	.0789	.1315	.128	.1183	.0789	.0633	.1107
11	.0789	.1448	.128	.0867	.0789	.061	.0937
12	.0789	.1315	.1646	.096	.0526	.081	.0106
13	.0789	.1296	.1463	.1036	.0526	.0671	.128
14	.0777	.1315	.1646	.1036			.1097
15	.0903	.1296	.1646	.1006		.048	.0949
16	.1204	.1257		.1052		.1341	.1097
17	.1029	.1166	.1646			.116	.0754
18	.1143	.1132			.0633	.1219	.0754
19	.1257	.1296	.1646		.08	.128	.0754
20	.1257	.1467	.1646		.1187	.1526	.088
21	.1257		.1646		.1296	.1341	
22	.1257		.1646		.1457	.1296	.1132
23			.1646		.1341	.1107	.088
24	.1646	.1115	.1029	.3982	.1143	.0937	.1067
Max	.1646	.1467	.1646	.3982	.1457	.1526	.1372
Min	.0777	.1115	.1029	.0867	.0526	.048	.0106
Avg	.1135	.1221	.1408	.1487	.0994	.0976	.0976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 201 / 11 KV DMAHI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
23	.2204
24	.2035
Max	.2204
Min	.2035
Avg	.2120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 202 / 11 KV TAKARKHED
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2374
Max	.2374
Min	.2374
Avg	.2374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 203 / 11 KV DIGRAS AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2543
Max	.2543
Min	.2543
Avg	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 204 / 11 KV DMAHI GAONTHAN-
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2353
Max	.2353
Min	.2353
Avg	.2353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 205 / 11 KV TAKARKHED GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2172
Max	.2172
Min	.2172
Avg	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074009 / 33 KV D MAHI

Feeder No / Name : 206 / 11 KV DIGRAS GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2534
Max	.2534
Min	.2534
Avg	.2534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1187
Max	.1187
Min	.1187
Avg	.1187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 201 / 11 KV GIROLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2883
Max	.2883
Min	.2883
Avg	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Girola

Feeder No / Name : 202 / 11 kv JUMDA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2204
Max	.2204
Min	.2204
Avg	.2204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 203 / 11 KV SRAJA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2543
Max	.2543
Min	.2543
Avg	.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074055 / 33 KV Giroli

Feeder No / Name : 204 / 11 kv GIROLI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.2172
Max	.2172
Min	.2172
Avg	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1696
Max	.1696
Min	.1696
Avg	.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 201 / 11 KV SINGAON JAHANGIR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	2.0586
Max	2.0586
Min	2.0586
Avg	2.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 202 / 11KV PANGRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.7539
Max	.7539
Min	.7539
Avg	.7539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 203 / 11KVMEHUNARAJA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.2229
24	.7818
Max	.7818
Min	.2229
Avg	.5024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 204 / Water work D RAJA
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1865
Max	.1865
Min	.1865
Avg	.1865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 205 / Khalyal Gawhan Ag SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2035
Max	.2035
Min	.2035
Avg	.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074075 / SINGAONJAHAGIR (RU)

Feeder No / Name : 206 / Gargondi AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.2204
24	.2374
Max	.2374
Min	.2204
Avg	.2289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0848
Max	.0848
Min	.0848
Avg	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 201 / 11KV SHELGAON ATOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1341	.1372	.1886	.1677	.1174	.12
2	.2012	.1341	.1372	.1715	.1677	.1174	.12
3	.2012	.1341	.1372	.1715	.1677	.1174	.12
4	.2012	.1341	.1372	.2058	.2012	.1174	.2058
5	.2012	.1677	.3429	.2572	.2515	.1677	.2058
6	.2683	.2347	.3429	.3772	.3018	.2515	.3086
7	.1341	.2683	.2572	.3429	.2683	.3018	.2915
8	.1341	.2515	.2572	.2401	.2683	.218	.2401
9	.1006	.2515	.1543	.1372	.1677	.1677	.2229
10	.1006	.2012	.1543	.1844	.1509	.12	.2058
11	.1006	.1715	.1543	.1844	.1341		.1677
12	.1341	.1543	.1372	.1844	.1341	.1029	.1006
13	.1341	.1543	.1372	.1509	.1341		.1006
14	.1341	.1543	.1543	.1509	.1341		.1006
15	.1341	.1715	.1715		.1677	.12	.1174
16	.1341	.1715	.2058		.1844	.1886	.1174
17	.2012	.3086			.2012	.2058	.218
18	.2515	.3086	.2401		.218	.2058	.218
19	.3353	.3086		.3185	.285	.2058	.2347
20	.3018	.3086	.3429	.3185	.2515	.1715	.2347
21	.2012	.1715	.2743	.3018	.2012	.1543	.2012
22	.1509	.1715	.2401	.3018	.1677	.1543	.2012
23	.1341	.1372	.2058	.2515	.1341	.1372	.2012
24	.1677	.1341	.1372	.1696	.2515	.1174	.12
Max	.3353	.3086	.3429	.3772	.3018	.3018	.3086
Min	.1006	.1341	.1372	.1372	.1341	.1029	.1006
Avg	.1774	.1974	.2027	.2304	.1963	.1648	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 202 / 11KV AMONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1341	.1715	.2058	.2515	.1341	.1715
2	.2012	.1341	.1715	.1886	.2515	.1341	.1543
3	.2012	.1341	.1715	.1886	.2347	.1341	.1543
4	.2012	.1341	.1715	.2229	.2515		.1543
5	.2515	.1341	.3429	.2572	.3018		.2401
6	.3185		.3429	.3601	.3521	.2012	.3772
7	.3353		.2915	.2572	.3185	.2347	.3429
8	.3521		.2915		.3185	.2347	.3086
9	.2347		.1886	.1543	.1677	.2347	.3944
10	.2347		.1886	.1509	.1677	.1372	.2915
11	.2012				.1677		.2743
12	.1677				.1844	.12	.2743
13	.1677	.1372			.2012		.2743
14	.1677	.1372		.1341	.218	.1029	.2915
15	.1677	.1372	.2058		.2012	.1372	.2915
16	.1677	.1372	.2229		.2012	.2058	
17	.2012	.1543			.2012	.2229	.2915
18	.2515	.2572	.3772		.1844	.2743	.2915
19	.3185	.3086	.3944	.1341	.2012	.2743	.2401
20	.2515	.3086	.3772	.3856	.1677	.2572	.3086
21	.2012	.2572	.3429	.3688	.1677	.2401	.2058
22	.1509	.2572	.2743	.3688	.1509	.2229	.2058
23	.1341	.1715	.2401	.3353	.1341	.2058	
24	.1677	.1341	.1715	.2204	.3353	.1341	.2058
Max	.3521	.3086	.3944	.3856	.3521	.2743	.3944
Min	.1341	.1341	.1715	.1341	.1341	.1029	.1543
Avg	.2187	.1805	.2599	.2458	.2222	.1921	.2611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 203 / 11 KV ISRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1341	.12	.1543	.1677	.1174	.12
2	.2012	.1341	.12	.1543	.1677	.1174	
3	.218	.1341	.12	.1543	.1677	.1174	.12
4	.218	.1341	.12	.1543	.2012		.1715
5	.2515	.1677	.3086	.2229	.2012		.1715
6	.2515	.2012	.3086	.2572	.2347		.2572
7	.2515	.2683	.2572	.2743	.2347	.218	.2572
8	.2515	.2515	.2572	.2572	.2347	.2012	.2401
9	.2012	.2347	.1886	.2572	.1677	.1677	.1715
10	.2012	.218	.1886	.2347	.1677	.12	.1543
11	.2012	.2058	.1715	.2012	.1677	.1372	.1509
12	.2012	.2058	.1372		.1677	.1543	.1006
13	.2012	.2058	.1543	.1677	.1341	.1543	.1677
14	.2012	.2058	.1543	.1844	.1341	.1543	.1677
15	.2012	.2572	.2058		.1341	.1715	.1677
16	.2347	.2572	.2572		.1341	.2229	.1677
17	.2683	.2915			.1341	.2229	.2347
18	.2683	.2915	.2058		.1844	.2401	.2347
19	.3018	.2915		.2347	.1844	.2229	.2347
20	.2515	.2915	.2229	.2347	.1677	.2058	.218
21	.2012	.2915	.2058	.2347	.1677	.1372	.2012
22	.1509	.1715	.1715	.2347	.1174	.1372	.2012
23	.1341	.12	.1715	.218	.1174	.1372	.2012
24	.1677	.1341	.12	.2543	.218	.1174	.12
Max	.3018	.2915	.3086	.2743	.2347	.2401	.2572
Min	.1341	.12	.12	.1543	.1174	.1174	.1006
Avg	.2180	.2124	.1894	.2150	.1712	.1654	.1840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 204 / 11 KV ANCHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2347	.1715	.1543	.1677	.2012	.1715
2	.2012	.2347	.1715	.1543	.1677	.2012	.1715
3	.218	.2347	.1715		.1677	.2012	.1886
4	.218	.2347	.1715		.1677	.2012	.1886
5	.2515	.3018	.3429		.2012	.2012	.2058
6	.3018	.3688	.3429			.2347	.2401
7	.3018	.4024	.3429			.2683	.2743
8	.3018	.4191	.3429			.2683	.2915
9	.3018	.4191	.2915			.3018	.2401
10	.3018	.4191	.2915			.1715	.2229
11	.2683	.3429	.2915		.1174	.1715	.218
12	.2515	.2572	.3086		.1341	.1715	.1844
13	.2515	.2572	.3086	.0671	.1677	.1715	.4359
14	.2515	.2572		.0671	.2683	.1715	.4527
15	.2515	.2058	.2743		.2515	.2058	.4527
16	.3018	.2058	.2915		.2515		.1677
17	.3353	.2401			.2515		.218
18	.4191	.3429		.2012	.2515	.2572	.218
19	.4527	.3601		.2012	.285	.2401	.5365
20	.4024	.3772	.2401	.2012	.2515	.2058	.5197
21	.3688	.3086	.2058	.2012	.2515	.1886	.4191
22	.3353	.2915	.1715	.2012	.2515	.1715	.4191
23	.3018	.1715	.1715	.1677	.2012	.1715	.4024
24	.1677	.2683	.1715	.2374	.1677	.2012	.1715
Max	.4527	.4191	.3429	.2374	.285	.3018	.5365
Min	.1677	.1715	.1715	.0671	.1174	.1715	.1677
Avg	.2899	.2981	.2538	.1685	.2092	.2081	.2921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074095 / 33 kv Isrul

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1017
Max	.1017
Min	.1017
Avg	.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 201 / Naryankhed Gawthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2402	.2587	.2587	.2402	.3142	.2957
2	.2402	.2402	.2587	.2587	.2427	.2957	.2772
3	.2587	.2402	.2587	.2614		.2987	.2801
4	.2987	.2614	.2987	.2987	.1307	.3174	.2987
5	.3361	.3734	.3734	.3361	.132	.415	.4108
6	.7545	.7095	.7468	.7922	.2452	.7922	.8589
7	.8215	.7468	.6722	.8215	.3395	.8775	.4108
8	.7468	.7282	.6908	.7468	.2801	.8589	.8402
9	.6535	.5601	.5788	.5788	.1886	.6908	.6535
10	.3511	.3734	.3696	.3326	.3395	.4294	.4294
11	.2743	.2957	.2402	.2402		.3734	.2987
12	.2378	.2561	.2743	.2534		.3475	.2772
13	.2561	.2561	.2743	.2561		.2743	.3109
14	.2378	.2587	.2926			.3077	.2801
15	.2614	.2743	.2926			.2957	.3361
16	.2801	.3142	.3696		.5914	.3511	.3174
17	.3881	.462	.5175		.7762	.462	.4294
18	.5975	.6535	.6468		.5914	.6722	.5975
19	.7207	.6722	.5544		.499	.7095	.6908
20	.5914	.5544	.4854	.4066	.4294	.6161	.5601
21	.3326	.3511	.3361	.3292	.3841	.3921	.3881
22	.2987	.3142	.3142	.2772	.3326	.3361	.3547
23	.2587	.2772	.2743	.2587	.3142	.3142	.3174
24	.2614	.2587	.2587	.2587	.2402	.3142	.2957
Max	.8215	.7468	.7468	.8215	.7762	.8775	.8589
Min	.2378	.2402	.2402	.2402	.1307	.2743	.2772
Avg	.4042	.4030	.4016	.3870	.3498	.4607	.4254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 202 / Nimgaon Guru Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0293	.0297	.0312	.0293	.0267		.0297
2	.0305	.0305	.0316	.0297	.0274		.0312
3	.0312	.0297	.0328	.0305	.0278		.032
4	.032	.029	.0328	.0312	.0286		.0328
5	.0324	.0343	.0343	.048	.029		.0343
6	.0554	.0549	.0543	.0543	.0532		.0537
7							.3185
8							.3765
9							.4458
10							.4694
11							.3807
12							.3666
13							.3807
14							.4089
15	.7164	.6097	.6401			.5201	
16	.679	.3948	.6622		.439	.602	
17	.7407	.6472	.5281			.5792	
18	.7621	.6226	.5937			.5575	
19	.6836	.6241	.5216			.4633	.0564
20	.5575	.5213	.459	.3567		.4033	.0533
21	.5144	.4729	.3567	.3368		.3978	.0297
22	.5001	.4729	.3155	.3191		.3734	.0301
23	.0282	.0297	.0434	.0255		.0282	.0293
24	.0286	.0286	.0305	.029	.0259		.029
Max	.7621	.6472	.6622	.3567	.439	.602	.4694
Min	.0282	.0286	.0305	.0255	.0259	.0282	.029
Avg	.3388	.2895	.2730	.1173	.0822	.4361	.1794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 203 / 11 kv Digras Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2526	.2606	.257	.2534		
8	.2896	.3001	.2503	.3155		
9	.3814	.3374	.3269	.3517		
10	.3841	.3384	.3144	.3384		
11	.2976	.3311	.3121	.3475		
12	.3521	.3269	.3567	.362		
13	.3121	.2675	.3475	.3521	.2195	
14	.286	.2286	.3041		.1783	
15						.2881
16						.2462
17						.2751
18						.2705
19						.2841
20						.1669
21						.1623
22						.16
23		.0297				
Max	.3841	.3384	.3567	.362	.2195	.2881
Min	.2526	.0297	.2503	.2534	.1783	.16
Avg	.3194	.2689	.3086	.3315	.1989	.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.Feeder No / Name : 400 / 33/0.4 ,Stn T/F
Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 401 / 33 KV NIMGAON

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.2717
Max	1.2717
Min	1.2717
Avg	1.2717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.Feeder No / Name : 403 / 33 KV MANDAPGAON-DAGADWADI
Feeder KV- 33 / INCOMING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	6.6301
Max	6.6301
Min	6.6301
Avg	6.6301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 404 / VASANTNAGAR-BHAROSA

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 077010 / 132 KV DEOULGAON MAHI(WAKI
KD.

Feeder No / Name : 405 / 33 KV WAKI BK

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.3226
Max	1.3226
Min	1.3226
Avg	1.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
8		.0747
15	.009	
21	.0543	
24		.0373
Max	.0543	.0747
Min	.009	.0373
Avg	.0317	.056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 201 / 11 KV PANGRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.4115	.4344	.4706	.0362
2	.3429	.3944	.4115	.4344	.4706	.0362
3	.3429	.3944	.4115	.4344	.4887	.0362
4	.3772	.3944	.4115	.4525		.0362
5	.3772	.4115	.4115	.4706		.0362
6	.6516	.7202	.6859	.543		.0362
7	.7888	.7545	.7716	.6878	.4525	.0362
8	.4115	.4287	.6687	.3982	.724	.0362
9	.4115	.3086	.3601	.0343	.6335	.4458
10	.0171	.0171	.0181	.0343	.0362	.6001
11	.0171		.0181	.0343		
12	.0171	.0171	.0181	.0343		.6001
13	.0171		.0181	.0343		.5487
14		.0171	.0181	.0343	.0362	.4973
15		.0171	.0181	.0343	.0362	.463
16		.0171	.0181	.0343	.0362	.5487
17	.0171	.0171	.0181	.0343	.0362	.0514
18	.0514	.0686			.0362	.0686
19	.0514	.0857		.0343	.0362	.0686
20	.0343	.0686	.0724	.0343	.0362	.0686
21	.0343	.0514	.0724	.0343	.0362	.0514
22	.0171	.0514	.0543	.0343	.0362	.0514
23	.0171	.0514	.4344	.3429	.0362	.0343
24	.3772	.3601	.4115	.4344	.4525	.0362
Max	.7888	.7545	.7716	.6878	.724	.6001
Min	.0171	.0171	.0181	.0343	.0362	.0343
Avg	.2245	.2284	.2606	.2208	.2273	.1923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 202 / 11KV RAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0362	.0362	.3077
2	.0343	.0343	.0343	.0362	.0362	.2534
3	.0343	.0343	.0343	.0362	.0362	.2534
4	.0343	.0514	.0343	.0362	.0362	.3258
5	.0343	.0686	.0343	.0362	.0362	.5068
6	.0343	.0686	.0343	.0362	.0362	.6335
7	.0343	.0686	.0343	.0362	.0362	.6335
8	.0343	.0514	.0343	.0362	.0362	.6516
9		.0343	.0514	.3086	.181	.6173
10		.4287	.4525	.4115	.362	.0343
11		.6001	.5792	.5144	.362	
12	.6001	.7202	.6154	.5144		
13	.6859	.6001	.6154			
14	.6001	.6001	.4525			
15	.6001	.6001	.4525	.3429	.6335	.0343
16	.6001	.6001	.6219	.5144	.6335	.0343
17	.6001	.7202	.6219	.0343	.0181	.0343
18	.0343	.0343	.0362	.0343	.0181	.0343
19	.0343	.0514	.0362	.0343	.0181	.0514
20	.0514	.0343	.0362	.0343	.0181	.0343
21	.0514	.0343	.0362	.0343	.0181	.0343
22	.0514	.0514	.0362	.0343	.0181	.0514
23	.0343	.0343	.0362	.0343	.181	.3086
24	.0343	.0343	.0343	.0366	.0362	.2534
Max	.6859	.7202	.6219	.5144	.6335	.6516
Min	.0343	.0343	.0343	.0343	.0181	.0343
Avg	.2025	.2329	.2079	.1442	.1327	.2544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 203 / 11KV SAILANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857	.0686	.0724	.0857	.0724	.4344
2	.0686	.0857	.0686	.0724	.0686	.0724	.4344
3	.0686	.0857	.0686	.0724	.0686	.0724	.4706
4	.0857	.0857	.0857	.0724	.0857	.0724	.4706
5	.1029	.0857	.0857	.0905	.0686	.0724	.543
6	.1029	.12	.12	.1086	.1029	.1086	.5973
7	.0857	.1029	.1029	.1086	.0857	.0724	.6335
8	.0857	.1029	.0857	.0905	.0686	.1267	.7059
9	.0857	.0686	.0686	.3601	.4287	.4163	.0686
10	.0514	.6173	.5792	.5487	.5316	.543	.0686
11	.0514	.703	.5792	.583	.5144	.5792	.0514
12	.6173	.583	.5792	.5487		.0724	
13	.6516	.5658	.5792		.5487		.0686
14	.583	.5658	.5249	.5487	.5487		
15	.5658	.5144	.5068	.4801	.5487		.0514
16	.5144	.5487	.5249	.5316	.463	.724	.1372
17	.5487	.583	.5973	.1029	.0514		.1372
18	.1029	.0686	.0724	.1372	.0857	.0905	.1372
19	.0857	.1029	.0905	.1543	.0857	.1267	.0686
20	.1029	.0857	.0905	.0857		.0905	.1372
21	.1029	.0857	.0905	.0857	.0686	.0905	.1543
22	.1029	.0857	.0905	.0686	.0686	.0724	.0857
23	.0857	.0857	.0724	.0686	.0686	.4344	.5144
24	.0686	.0857	.0686	.0724	.0686	.0724	.4344
Max	.6516	.703	.5973	.583	.5487	.724	.7059
Min	.0514	.0686	.0686	.0686	.0514	.0724	.0514
Avg	.2079	.2543	.2417	.2202	.2143	.1991	.2911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 204 / 11 KV RAIPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3944	.3944	.4294	.4344	.4024
2	.4115	.3772	.3772	.4294	.4344	.4338
3	.4115	.3772	.3944	.4338	.4525	.462
4	.4458	.4115	.3944	.4527	.4344	.4572
5	.4458	.4115	.4115	.4715	.4525	.5121
6	.4801	.4973	.583	.5175	.5792	.6335
7	.5144	.5144	.4973	.5415	.5792	.5847
8	.4801	.463	.4801	.5175	.543	.5658
9	.3772	.4287	.3601	.4458	.362	.4115
10	.4115	.4458	.3439	.3772	.4163	.3601
11	.3429	.3601	.362	.3601	.362	.3086
12	.3086	.3429	.3982	.3772	.362	.2743
13	.3601	.3429	.362	.3258	.3439	.2915
14	.3258	.3429	.3982	.3601	.3258	.3258
15	.3429	.3601	.3801	.3429	.362	.3601
16	.3429	.3944	.3982	.3601	.3801	.3772
17	.3601	.4115	.4163	.3944	.4706	.4458
18	.4287	.4973	.543	.4801	.5249	.4458
19	.5658	.5487	.543	.6001	.5068	.5144
20	.5658	.583	.5792		.5611	.6001
21	.4801	.4973	.5068	.4973	.4525	.4973
22	.4458	.4458	.4525	.463	.4525	.4458
23	.4115	.3944	.4344	.4287	.4338	.4115
24	.4115	.3944	.3944	.4294	.4525	.4338
Max	.5658	.583	.583	.6001	.5792	.6335
Min	.3086	.3429	.3439	.3258	.3258	.2743
Avg	.4201	.4265	.4335	.4363	.4449	.4398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 205 / 11 KV SAILANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4287	.4287	.4706	.4344	.4344
2	.4801	.4458	.4287	.4525	.4706	.4344
3	.5144	.463	.4801	.4706	.5249	.4344
4	.583	.4973	.5487	.5068	.6335	.5068
5	.9088	.6344	.6344	.5792	.724	.6154
6	1.0974	1.0117	.9774	1.0136	.9412	1.0317
7	1.166	.8916	.8916	.9774	1.0136	1.0498
8	1.1317	.8573	.8402	.8688	.8688	.8688
9	.4801	.7716	.6859	.6859	.7059	.583
10	.9088	.5658	.6335	.6173	.6697	.583
11	.8402	.4801	.5792	.4973	.5249	.4801
12	.7716	.4801	.3439	.4973	.4344	.4287
13	.7716	.463	.362			.4458
14	.7545	.3944	.3077	.463	.4344	
15	.7545	.4458	.5068	.463	.4706	.5144
16	.8402	.4801	.5792	.4973	.5611	.5316
17	.8916	.5658	.5973	.6001	.7059	.5658
18		.7373	.905	.7373	.7964	.7888
19	.7545	.8916	.8869	.8059	.7964	.9259
20	.7716	.7716	.7964	.7888	.7421	.7545
21	.583	.583	.5792	.5658	.5973	.5658
22	.5144	.5144	.5611	.4973	.543	.5316
23	.463	.4801	.5068	.4458	.4887	.463
24	.4801	.4458	.4458	.4887	.4525	.4525
Max	1.166	1.0117	.9774	1.0136	1.0136	1.0498
Min	.463	.3944	.3077	.4458	.4344	.4287
Avg	.7366	.5958	.6044	.6083	.6319	.6083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 206 / Pangri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.12	.1372	.1433	.1448	.1448
2	.1372	.12		.1417	.1448	.1448
3	.1543	.1372	.1372	.1433	.1629	.1629
4	.1715	.1715	.1715	.1772	.2715	.2534
5	.2401	.2229	.2572	.2103	.3077	.3258
6	.4115	.2743	.3429	.2401	.2896	.4344
7	.3601	.3429	.3086	.2572	.362	.333
8	.2401	.2572	.2743	.2572	.2715	.2743
9	.1715	.2401	.1886	.2401	.2172	.1715
10	.1029	.1715	.1629	.1715	.2172	.1715
11	.1372	.1372	.1267	.1543	.1267	.1372
12	.1029	.12	.1267	.1543	.1267	.1372
13	.12	.12	.1267	.1543	.1448	.12
14	.12	.12	.1448	.1372	.1448	.1372
15	.1372	.1543		.1543	.181	.1715
16	.1372	.1372	.1595		.181	.1715
17	.1886	.1886	.1949	.1715	.181	.2229
18	.2743	.2915			.2715	.2743
19	.3429	.3429		.3429		.3258
20	.2743	.3086	.2629	.2572	.2534	.2743
21	.1715	.2058	.2172	.2229	.1629	.2058
22	.1372	.1543	.1448	.1543	.1629	.1543
23	.1372	.1372	.1448	.1543	.1372	.1372
24	.1372	.1372	.1372	.1417	.1448	.1448
Max	.4115	.3429	.3429	.3429	.362	.4344
Min	.1029	.12	.1267	.1372	.1267	.12
Avg	.1893	.1922	.1883	.1901	.2003	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 202 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	1.2574	1.2071
2	1.3077	1.2574
3	1.3413	1.3413
4	1.3413	1.4251
5	1.3748	1.5089
6	1.4251	1.5089
7	1.5089	1.5592
8	1.5089	1.3077
9	1.5257	
24	1.0898	1.1401
Max	1.5257	1.5592
Min	1.0898	1.1401
Avg	1.3681	1.3617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 203 / 11 KV MASRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	.3125	.0324
2	.2812	.0486
3	.2812	.0486
4	.2812	.0486
5	.3125	
6	.3437	.0648
7	.3437	.0648
8	.3125	
9	.3125	
24	.3125	.0324
Max	.3437	.0648
Min	.2812	.0324
Avg	.3094	.0486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 204 / 11 KV DOMRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	.2343	.2343
2	.2812	.25
3	.3125	.2812
4	.3437	.3125
5	.4374	.3125
6	.4374	.3125
7	.4687	.3125
8	.4687	.3125
9	.3125	
24	.1562	.1875
Max	.4687	.3125
Min	.1562	.1875
Avg	.3453	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 205 / 11 KV JANUNA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	.0686	.0686
2	.0686	.0686
3	.0686	.0857
4	.0857	.0857
5	.0857	.0857
6	.0857	.1029
7	.0857	.1029
24	.0686	.0686
Max	.0857	.1029
Min	.0686	.0686
Avg	.0772	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 201 / GFSS CHANDOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3658	.3658	.3012	.3326	.3511	.3361
2		.362	.3696	.3045	.3696	.3511	.3361
3		.3982	.3841	.3189	.4251	.4251	.3361
4		.4024	.4024	.3403	.4805	.4805	.3734
5		.4525	.4572	.3761	.5175	.5544	.5601
6		.6767	.6878	.5731	.5544	.6283	.7023
7	.6468	.591	.6516	.5014	.5914	.5544	.6653
8	.6283	.6154	.6767	.4835	.5359	.5175	.5544
9	.5544	.5258	.362	.4298	.5544	.4066	.5175
10	.5544	.4075	.394		.4435	.3326	.4435
11	.439	.333	.3721		.4066	.3326	.4066
12	.3439	.3258	.3944		.3881	.3696	.3696
13		.3292	.4119		.3881	.2957	.3696
14	.333	.3224	.3224		.3881	.2957	.3326
15	.3258	.3439	.3403		.4066	.2957	.3326
16	.3658	.3761	.3544		.4435	.3326	.3326
17	.439	.4344			.4805	.4066	.3696
18	.5544	.5487		.4805	.5175	.4805	.4805
19	.6099	.5914		.5914	.499	.5601	.5601
20	.567	.6099	.4477	.462	.5359	.5601	.5601
21	.4938	.4435	.394	.4066	.4435		.5601
22	.4251	.3841	.4119	.4066	.3881		.4854
23	.3841	.3658		.3696	.3696	.3361	.3921
24		.362	.3658	.3077	.3326	.3511	.3361
Max	.6468	.6767	.6878	.5914	.5914	.6283	.7023
Min	.3258	.3224	.3224	.3012	.3326	.2957	.3326
Avg	.4790	.4403	.4283	.4158	.4497	.419	.4464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 202 / Chandol AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.2429	.2458	.1638	.037	.2218	.2987
2	.5601	.2429	.2458	.1311	.0554	.2587	.2987
3	.5601	.2401	.2591	.1147	.0739	.3696	.2987
4	.7468	.2881	.2915	.116	.0739	.4066	.2987
5	.9335	.3239	.3401	.116	.0739	.4435	.3696
6	1.1088	.578	.5468	.1989	.0924	.4805	.4805
7	.5175	.5401	.4167	.2267	.0924	.4435	.462
8	.6283	.4687	.4167	.1802	.0739	.4251	.4066
9	.5175	.3953	.381		.0924	.4251	.2587
10	.3887	.2343	.3048		.1478	.3696	.3696
11	.3932	.3125	.3201		.1663	.3696	.3696
12	.3725	.0701	.3353		.1478	.5175	.3696
13		.0709	.253		.1848	.4066	.3696
14	.3401	.1875	.2294		.1848	.3696	.3696
15	.3401	.2286	.2241	.1663	.2033		.3326
16	.3239	.2743	.2294		.2218	.4066	.3696
17	.3201	.2968		.1294	.2218	.1478	.1848
18	.2254	.1886		.1109	.2402	.2218	.1848
19	.2454	.2743	.1543	.3326	.2587	.2614	.2614
20	.2507	.2601	.12	.1848	.3326	.2614	.2614
21	.208	.2012	.0857	.1478	.2587		.1867
22	.1928	.1734	.1029	.1109	.1663		.1867
23	.1612	.1578	.1029	.0554	.1848	.2614	.3361
24	.5601	.2294	.2321	.1823	.037	.2218	.2987
Max	1.1088	.578	.5468	.3326	.3326	.5175	.4805
Min	.1612	.0701	.0857	.0554	.037	.1478	.1848
Avg	.4546	.2700	.2653	.1569	.1509	.3471	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 203 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	03-JUN-18
HR	Load (MW)
11	.3696
12	.5175
Max	.5175
Min	.3696
Avg	.4436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 204 / Saoli GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.056	.0549	.0554	.0554	.056
2	.056	.056	.056	.0549	.0554	.0554	.056
3	.056	.056	.056	.0549	.1109	.0739	.056
4	.0747	.0747	.0747	.0549	.0739	.1109	.0747
5	.112	.0934	.0934	.0724	.1294	.1478	.1109
6	.1663	.1307	.1478	.1463	.1663	.1663	.1663
7	.0924	.0747	.0924	.1097	.1109	.1109	.1109
8	.0739	.0747	.0934	.0549	.0924	.0934	.0924
9	.0739	.056	.056	.0716	.0554	.0739	.0554
10	.0554	.0747	.0373	.0537	.037	.037	.0554
11	.056	.0373	.0724	.056	.037	.037	.0554
12	.056	.0373	.0358	.037	.037	.0554	.0554
13		.0373	.0362	.037	.037	.0554	.0554
14	.056	.0554	.0362	.0554	.037	.0554	.0554
15	.0373	.0554	.0543	.0739	.037	.0554	.0554
16	.0373	.0373	.0358	.0739	.037	.0739	.0554
17	.0373	.0747		.0739	.037	.0739	.0924
18	.0747	.0747		.0739	.0739	.0739	.0924
19	.0747	.112	.0709	.1109	.0924	.0934	.0934
20	.0934	.0934	.0362	.0739	.0739	.0934	.0747
21	.0747	.0747	.0724	.0739	.0739		.0747
22	.056	.056	.0724	.0739	.0739		.0747
23	.0554	.056	.0537	.0554	.0739	.056	.056
24	.056	.0554	.056	.0537	.0554	.0554	.056
Max	.1663	.1307	.1478	.1463	.1663	.1663	.1663
Min	.0373	.0373	.0358	.037	.037	.037	.0554
Avg	.0688	.0668	.0634	.0688	.0693	.0774	.0742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 205 / 11 KV SAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0526	.0693	.0514	.0739	.0747	.1494
2	.056	.0526	.0701	.0514	.0739	.0739	.1494
3	.056	.0716	.0701	.0514	.0739	.0747	.1494
4	.056	.0709	.0701	.0514	.1109	.0924	.1494
5	.112	.0895	.0693	.0686	.1294	.1294	.1848
6	.1478	.1254	.1214	.12	.1294	.1494	.2957
7	.1478	.124	.1227	.1029	.1109	.1294	.2957
8	.1478	.1063	.1214	.1029	.1109	.1109	.2957
9	.1109	.1063	.0693	.1372	.1478	.1848	.0924
10	.3326	.2372	.25	.1372	.3142	.168	.0924
11	.3201	.2187	.3201	.1848	.3696	.2218	.0739
12	.3725	.3005	.2743	.2218	.3696	.2218	.0739
13		.2401	.213	.1663	.3326	.2218	.0739
14	.2372	.1943	.1966	.1848	.2587	.2218	.0739
15	.3005	.2561	.1966	.1848	.1294		.0739
16	.3401	.2656	.1966	.2033	.0739		.0554
17	.3163	.2688		.0924	.0554	.1109	.0739
18	.1227	.0905		.1109	.0554	.1109	.0739
19	.0876	.1267	.0857	.1109	.0554	.112	.0934
20	.0905	.0914		.0924	.1109	.0934	.0934
21	.0867	.0905		.0739	.0924		.0747
22	.0701	.0709	.0857	.056	.0934		.1307
23	.0724	.0701	.0686	.0554	.0924	.1494	.1307
24	.056	.052	.0686	.0514	.0554	.0739	.1494
Max	.3725	.3005	.3201	.2218	.3696	.2218	.2957
Min	.056	.052	.0686	.0514	.0554	.0739	.0554
Avg	.1607	.1405	.1370	.1110	.1425	.1363	.1291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 206 / 11 KV DHANGARPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1006	.1006	.0332	.0554	.0739	.0373
2	.112	.0995	.0995	.0332	.0554	.0739	.0373
3	.112	.0983	.0995	.0332	.0739	.0924	.0373
4	.1867	.1134	.1147	.0332	.1109	.0924	.0747
5	.112	.1254	.1311		.1478	.0739	.0739
6	.3696	.2949	.3239	.0829	.1294	.0924	.1294
7	.4066	.253	.3953		.1478	.1478	.1109
8	.3696	.3125	.3521		.1663	.1848	.0739
9	.2587	.216	.2401		.037	.0554	.1294
10	.0554	.0343	.052		.0185	.037	.1848
11	.0716	.0366	.0514		.0185	.037	.2587
12	.0709	.0347	.0343			.037	.2587
13		.0532	.0354	.0924	.037	.037	.2587
14	.0526	.037	.0514		.037		.2587
15	.0354	.0362	.0532	.037	.0185		.2218
16	.0351	.0358	.0514		.037	.037	.2587
17	.0526	.0724			.037	.037	.0924
18	.0886	.0543		.2033	.037	.0924	.0924
19	.1075	.128		.037	.037	.0934	.0934
20	.0732	.0905		.037	.037	.0934	.0934
21	.0709	.0724	.0343	.037	.037		.056
22	.0709	.0526	.0343	.037	.037		.056
23	.0549	.0532	.0343	.037	.0739	.0373	.056
24	.112	.1075	.1006	.0328	.037	.0739	.0373
Max	.4066	.3125	.3953	.2033	.1663	.1848	.2587
Min	.0351	.0343	.0343	.0328	.0185	.037	.0373
Avg	.1300	.1047	.1195	.0547	.0619	.0750	.1242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 201 / 11KV SAKHARKHERDA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.1829
9				.1524		
10	.1829			.2896		
11	.4725		.4572			
12	.3658	.0914	.4725			
13	.3048		.3963			
14	.2743	.1067	.2896	.2439		
15	.2439	.0762	.2743			
16			.2743		.0914	
17	.3353		.2591			
23						.0914
Max	.4725	.1067	.4725	.2896	.0914	.1829
Min	.1829	.0762	.2591	.1524	.0914	.0914
Avg	.3114	.0914	.3462	.2286	.0914	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 202 / 11KV SHENDURJAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							.1219
9				.061		.0457	
10	.0914	.0914	.0762	.0914		.061	
11	.1829		.1829				
12	.1829	.1829	.1219		.0914		
13	.1524		.1219		.0762		
14	.1219	.1677	.1219	.1524			
15	.1219	.1524	.1524				
16	.0914		.1219				
17	.0914		.1219				
23							.061
24				.0762			
Max	.1829	.1829	.1829	.1524	.0914	.061	.1219
Min	.0914	.0914	.0762	.061	.0762	.0457	.061
Avg	.1295	.1486	.1276	.0953	.0838	.0534	.0915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 203 / 11KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0305		.061		
2		.0305	.061	.061		
3		.0305				
4		.0305	.0762		.061	
5		.0305				
6		.061	.061			
7		.1029				
8	.061	.1219				
9		.1219	.0762			.061
10						.061
11						.0914
12						.0914
13						.061
14						.061
24		.0457	.0914	.0457	.0457	
Max	.061	.1219	.0914	.061	.061	.0914
Min	.061	.0305	.061	.0457	.0457	.061
Avg	.061	.0606	.0732	.0559	.0534	.0711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 204 / 11 KV DAREGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219		.1219	
2		.0914	.1067	.1219	
3		.0914		.1067	
4		.0914	.0914	.1219	
5		.1219		.1524	
6		.2134	.2439	.1677	
7		.1981		.1829	
8	.2439	.1829		.1219	
9		.1524	.1677		
12					.1524
13					.1219
14					.1524
19					.1524
24		.1219	.1829	.1219	
Max	.2439	.2134	.2439	.1829	.1524
Min	.2439	.0914	.0914	.1067	.1219
Avg	.2439	.1387	.1585	.1355	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 206 / 11KV SHENDURJAN GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058		.2058			
2		.2058	.1829				
3		.2058		.2058			
4		.2401	.2134	.2401		.2134	
5		.3429		.3601			
6	.4572	.4458	.4268	.5144		.4115	
9		.3086	.3048	.3601			.3658
10	.3429	.2401	.2134	.2229	.2134	.1981	.2743
11	.2572		.1886				.1886
12	.2229	.1677	.2229		.1524		.1886
13	.2058		.2058				.1886
14	.2058	.1524	.1829	.1829	.1372		.2058
15	.2058		.2401				
16	.2401		.3086		.1829		
17	.3086		.3086				
18	.3429						
19	.4287	.442			.3048		.4287
20	.3258	.3658					.4115
21	.2915		.2915				.2915
22	.2401	.2439	.2401		.2134		.2401
23	.2229		.2229				.2229
24		.2058	.1829	.2058		.1829	
Max	.4572	.4458	.4268	.5144	.3048	.4115	.4287
Min	.2058	.1524	.1829	.1829	.1372	.1829	.1886
Avg	.2865	.2695	.2460	.2775	.2007	.2515	.2733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 207 / 11 KV SAKHARKHERDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3032		1.2689			
2		1.3032	1.1279	1.2689			
3		1.3032		1.286			
4		1.406	1.0974	1.4403		1.2193	
5		1.6118		1.7833			
6	1.7375	2.0062	1.8138	2.1091	1.89	2.1338	
9		.1524	1.4175	1.7318			1.6766
10	1.5775	1.5089	1.2803	1.5604	1.0974	1.2193	1.4327
11	1.4746		1.2689				1.166
12	1.3032	1.2041	1.1831		1.1126		1.0631
13	1.2689		1.2689				1.1145
14	1.3032	1.1279	1.3032	1.0974	1.0669		1.1317
15	1.286	1.1279	1.3203				
16	1.3375		1.406		1.2803		
17	1.4232		1.4918				
18	1.6118						
19	1.9204	1.9966			1.6004		1.9547
20	1.6804	1.8138					1.869
21	1.5604		1.6289				1.6118
22	1.406	1.3413	1.5775		1.1888		1.4575
23	1.286		1.3375				1.3546
24		1.3032	1.1888	1.286		1.1279	
Max	1.9204	2.0062	1.8138	2.1091	1.89	2.1338	1.9547
Min	1.2689	.1524	1.0974	1.0974	1.0669	1.1279	1.0631
Avg	1.4784	1.3673	1.3570	1.4832	1.3195	1.4251	1.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 201 / 11KV SINDAKHEDRAJA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566		.0566		.0566	
2		.0566		.0566		.0566	
3		.0566		.0566		.0566	
4		.0566		.0566		.0566	
5		.0566		.1132		.0566	
6		.0566		.1132		.0566	
7		.1132		.1132		.0566	
8		.1698		.1132			
9		.1132			.0762		.0953
10	.0983		.1132		.1132		.0953
11	.1475		.1132		.1132		.1143
12	.1475		.1132		.1698		.0953
13	.0983		.1132		.3395		.1143
14	.1132		.1132		.1132		.0953
15	.1132		.0566				.0953
16	.1132				.0566		.1143
17	.1132		.0566				
23			.0566		.0566		.0381
24		.0566		.1328		.0566	
Max	.1475	.1698	.1132	.1328	.3395	.0566	.1143
Min	.0983	.0566	.0566	.0566	.0566	.0566	.0381
Avg	.1181	.0792	.0920	.0902	.1298	.0566	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 202 / 11KV BAMKHED AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 203 / 11KV BAMKHED GFSS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3395	.3429	.2829	.3429		.3048
2	.381	.3395	.3429	.2829	.3429		.3048
3	.381	.3395	.381	.2829	.3429		.3048
4	.5335	.3961	.4572	.3961	.4191		.381
5	.6859	.5658	.5716	.5658	.5335		.4572
6	.8002	.679		.679	.7621		.6478
7	.8383		.1524		.8002		
8			.1905		.6478		
9	.6859		.1715				
10	.3961	.6287	.5093				.4001
11	.3961	.5716	.3395	.3429	.3395		.3429
12	.3395	.5716	.3395	.5716	.3395		
13	.3395	.5144	.3395		.3395		.1905
14	.2829	.4572	.3395	.6478	.3395	.2667	.1715
15	.3395		.3395	.6478		.3048	
16	.3292	.3429	.3395	.5335		.381	
17	.3395	.6287	.4527			.4572	
18	.5093	.5716	.5658	.4572		.5335	
19	.5658	.6859	.5658			.6097	
20	.5093	.5716	.5093	.4572		.5335	.2477
21	.4527	.4572	.4527	.4191	.2829	.4191	.2477
22	.3961	.381	.3961	.3429	.2829	.3429	.1905
23	.3395	.3429	.2829	.3429	.2829	.3048	.1905
24	.4191	.3395		.2829	.3429	.2829	.3048
Max	.8383	.6859	.5716	.679	.8002	.6097	.6478
Min	.2829	.3395	.1524	.2829	.2829	.2667	.1715
Avg	.4626	.4862	.3810	.4433	.4213	.4033	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 204 / 11KV SINDKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.5278	1.4289	1.4146	1.3336	1.0751	1.1431
2	1.4098	1.5278	1.3717	1.4146	1.3336	1.0751	1.1431
3	1.4098	1.5278	1.3717	1.4146	1.3336	1.0751	1.1431
4	1.5623	1.5278	1.4289	1.4146	1.3717	1.0751	1.2193
5	1.6385	1.5278	1.5242	1.4146	1.4098	1.1317	1.4098
6	1.7147	1.7541	1.6004	1.6409	1.448	1.358	1.5242
7	1.7909	1.8107	1.7147	1.6975	1.5242	1.358	1.5623
8	1.7528	1.7541	1.6004	1.5278	1.4098	1.3014	1.448
9	1.6004	1.6975	1.6575	1.5278	1.4861	1.1883	1.3717
10	1.5844	1.7147	1.5844	1.448	1.4712	1.105	1.1622
11	1.5278	1.6004	1.5844	1.5242	1.4712		1.086
12	1.5844	1.7147	1.6409	1.4098	1.4146		1.086
13	1.5278	1.6575	1.6409	1.5242	1.5278		1.2003
14	1.0751	1.7147	1.6409	1.448	1.6975	1.2574	1.1622
15	1.4712	1.6575	1.6409			1.1431	1.2193
16	1.7541	1.6004	1.6409	1.7909	1.2449	1.2193	1.3146
17	1.8673	1.829	1.8673		1.3014	1.2955	1.3717
18	1.9239	1.829	1.8107	1.5242	1.1883	1.4861	1.3146
19	1.6409	1.9433	1.7541		1.1883	1.448	1.5432
20	1.8673	1.8861	1.7541	1.7147	1.2449	1.4098	1.4861
21	1.5844	1.829	1.6975	1.6004	1.1883	1.3717	1.448
22	1.5844	1.7147	1.6409		1.1883	1.2955	1.4861
23	1.5278	1.5432	1.5844	1.3717	1.1317	1.2193	1.4289
24	1.448	1.5278		.4286	1.3336	1.0751	1.1431
Max	1.9239	1.9433	1.8673	1.7909	1.6975	1.4861	1.5623
Min	1.0751	1.5278	1.3717	.4286	1.1317	1.0751	1.086
Avg	1.5941	1.6841	1.6166	1.4626	1.3584	1.2364	1.3090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 201 / 11KV SONOSHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)
10	.6381	
11	.518	.526
12	.4358	
13	.438	
Max	.6381	.526
Min	.4358	.526
Avg	.5075	.526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 202 / 11KV WARDADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 203 / 11KV SONOSHI GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 204 / 11KV WARDADI GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 205 / 11 KV JAMBHORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0857
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 206 / 11 KV BUTTA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074039 / 33KV SONOSI

Feeder No / Name : 207 / 11 KV KHAIRKHED AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 201 / 11KV MALKAPUR PANGRA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0857	.0857	.1029	.0857	.0686
2	.0857	.0686	.1029	.0857	.12	.0857	.0686
3	.12	.0857	.12	.1029	.1372	.12	.0857
4	.1372	.0857	.1372	.1372	.1543	.1543	.0857
5	.1543	.1029	.1715	.1543	.1715	.1715	.1029
6	.1715	.12	.1886	.1715		.1886	.12
9				.1886	.2401	.2401	
10	.2743	.3601	.3429	.2058	.3086	.2401	
11	.4115	.3429	.2572		.3086		
12	.3944	.3772	.2401		.2743		
13	.3086	.3086	.2401	.2572	.2401	.3086	
14	.2743	.2401	.2058	.1886		.2915	
15	.2743	.2572	.1715			.2915	
16	.2915	.3086	.2572			.2915	
17	.3086	.3429	.3944				
20	.12	.1543		.1372	.12	.1029	.1543
21	.1029	.1372	.1029	.12	.12	.0857	.1543
22	.1029	.12	.1029	.12	.1029	.0686	.12
23	.0857	.1029	.0857	.1372	.1029	.0686	.2229
24	.0857	.0686	.0857	.0857	.1029	.1029	.0686
Max	.4115	.3772	.3944	.2572	.3086	.3086	.2229
Min	.0857	.0686	.0857	.0857	.1029	.0686	.0686
Avg	.1994	.1922	.1829	.1452	.1738	.1705	.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 202 / 11 KV MALKAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.463	.463	.4287	.3772
2	.3772	.3772	.3944	.463	.4801	.4287	.3772
3	.4287	.3944	.4287	.4973	.5144	.4801	.3944
4	.4801	.4458	.4801	.6516	.6001	.6344	.4973
5	.5487	.5316	.5487	.703	.703	.7545	.6687
6	.6001	.6173	.6344	.823	.8059	.8573	.823
7	.5316	.5316	.6344	.703	.7202	.8745	.7716
8	.5487	.4973	.583	.6687	.6001	.8059	.6344
9	.4973	.463	.5658	.5658	.5144	.6516	.5658
10	.4458	.463	.4973	.4801	.4801	.5487	.463
11	.3944	.4115	.3601	.463	.4458	.3429	.3258
12	.3944	.4115	.4458	.4287	.4458	.3601	.3258
13	.3772	.3944	.463	.4115	.4458	.3772	.2915
14	.3772	.3772	.4287	.3772		.3601	.2915
15	.3944	.4115	.4458			.3772	.3258
16	.4287	.4287	.5144		.4287	.4287	.3772
17	.463	.463	.6516	.6516	.5658	.5487	.463
18		.6516	.8402	.7716	.6001	.6687	.5658
19	.7202	.7545	.8916	.6516	.7716	.6344	.6516
20	.7545	.6344	.7373	.6173	.7202	.6173	.6859
21	.5144		.6173	.583	.583	.463	.4973
22	.4287	.4458	.583	.5144	.5144	.4115	.4801
23	.3944	.4115	.4973	.4801	.4801	.3944	.4115
24	.3772	.3772	.3772	.4801	.463	.4458	.3772
Max	.7545	.7545	.8916	.823	.8059	.8745	.823
Min	.3772	.3772	.3601	.3772	.4287	.3429	.2915
Avg	.4719	.4727	.5416	.5658	.5612	.5373	.4851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 203 / 11 KV WAGHALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1715	.1372	.1372	.1372
2	.1372	.1372	.1543	.1543	.1543	.1372	.1372
3	.1715	.1543	.1715	.2058	.1715	.1543	.1543
4	.2401	.2229	.2401	.2743	.2401	.2058	.2058
5	.2915	.2572	.2915	.3429	.3086	.2572	.2572
6	.3258	.3086	.3258	.3601	.3601	.2915	.3772
10	.2058	.2743	.2401	.2058	.2572	.1543	.1886
11	.1372	.1886	.1715	.12	.1886	.1372	.12
12	.1372	.1886	.1886		.1715	.1372	.12
13	.1372	.1715	.1715		.1543	.1372	.1372
14	.1372	.1543	.1543	.1372		.1372	.1372
15	.1543	.1715	.1543			.1372	.1543
16	.1715	.1886	.2229				.2572
17	.2229	.2401	.2743			.2572	.2915
18	.3086	.3429	.4115			.3258	.3429
19	.3944	.3772	.3772			.2915	.4287
20	.2743	.3086	.2743	.2572		.2743	.3601
21	.2058	.2229	.2229	.2229	.1886	.2058	.2743
22	.1543	.1886	.1886	.1886	.1715	.1886	.2058
23	.1372	.1543	.1715	.1543	.1715	.1715	.1886
24	.1372	.1372	.1372	.1715	.1372	.1372	.1372
Max	.3944	.3772	.4115	.3601	.3601	.3258	.4287
Min	.1372	.1372	.1372	.12	.1372	.1372	.12
Avg	.2009	.2156	.2229	.2119	.2009	.1938	.2196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 204 / 11 KV WAGHALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0343	.0343	.0343	.0343
2	.0171	.0343	.0343	.0171	.0343	.0343	.0343
3	.0343	.0514	.0514	.0343	.0514	.0343	
4	.0686	.0686	.0857	.0514	.0514	.0514	
5	.1543	.1029	.1029	.0686		.0514	.0343
6	.2058	.1372	.1372	.1029	.0514	.0857	.0514
7	.1372	.1029	.1029	.12	.0514	.0857	.0686
8	.12	.0857	.0686	.0857	.0686	.0857	.0686
9	.12	.0343	.0514				.0857
10							.0514
11							.0857
12							.1029
13							.0857
14							.0857
15							.1543
23				.0343	.0343	.0343	
24	.0171	.0343	.0343	.7621	.0343	.0343	.0343
Max	.2058	.1372	.1372	.7621	.0686	.0857	.1543
Min	.0171	.0343	.0343	.0171	.0343	.0343	.0343
Avg	.0892	.0686	.0703	.1311	.0457	.0531	.0698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 201 / 11 KV SHIVANI TAKA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0343		
4		.0343		
6		.0297		
7		.0446		
8		.0594		
9		.0446		
10	.0594		.0594	
11	.0743		.0743	
12	.0596			
13	.0446		.0446	
14	.0594			.0446
15	.0297			.0446
16	.0594			
17	.0446			
18			.0446	
24		.0343		
Max	.0743	.0594	.0743	.0446
Min	.0297	.0297	.0446	.0446
Avg	.0539	.0402	.0557	.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 202 / 11 KV ANCHALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0298		
2		.0706		
3		.1059		
4		.1192		
5		.1639		
6		.2235		
7		.2682		
8		.2384		
9		.1192		
10	.149		.1788	
11	.2533		.2831	
12	.2682		.2682	
13	.2384		.2235	
14	.2086		.1788	
15	.1788			
16	.2384			
17	.2682			.2533
18			.1788	.1937
24		.0298		
Max	.2682	.2682	.2831	.2533
Min	.149	.0298	.1788	.1937
Avg	.2254	.1369	.2185	.2235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 203 / 11 KV DAWARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0745		.0745			.0298
2	.0745		.0745			.0298
3	.0894		.0745			.0298
4	.1639		.1341			.0298
5	.2235		.1937			.0298
6	.2831		.2682			.0447
7	.3576		.3129			.0745
8	.3129					.0894
9	.2533					
10		.2682				
11		.3576				
12		.4023		.3278		
13		.298				
14		.2235		.3278		
15		.2235		.2831		
16		.2235				
17		.2086				
23					.0298	
24	.0745		.0745	1.2193		.0298
Max	.3576	.4023	.3129	1.2193	.0298	.0894
Min	.0745	.2086	.0745	.2831	.0298	.0298
Avg	.1907	.2757	.1509	.5395	.0298	.0430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 204 / 11 KV ANCHALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.206	.1717	.206			.206	.2575
2	.2403	.206	.206			.206	.2747
3	.2747	.2747	.2403			.206	.309
4	.3605	.309	.309			.2575	.412
5	.412	.3776	.3433			.4291	.4635
6							.4635
7							.4463
8							.4463
9	.3262	.3262					.4291
10	.2403	.2403	.2575	.2403			
11	.206	.2403	.1545	.1888			
12	.1717	.1888	.1888	.1717			.4291
13	.1888	.1888	.1888	.1717			.4806
14	.1717	.1888	.1717	.1888			.3433
15	.1717	.1888	.1717	.1888			.4978
16	.1717	.206	.1717				.4806
17	.2232	.206	.2575				.5321
18	.2918	.309	.309			.2747	.515
19	.3605	.3948	.3262			.412	
20		.309			.1717	.4635	
21		.2575				.3948	
22		.2232				.2918	
23	.1888	.206				.2918	
24	.206	.1717	.206			.206	.2747
Max	.412	.3948	.3433	.2403	.1717	.4635	.5321
Min	.1717	.1717	.1545	.1717	.1717	.206	.2575
Avg	.2451	.2469	.2318	.1917	.1717	.3033	.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074065 / 33 KV DAWARGAON S/S

Feeder No / Name : 205 / 11 KV DAWARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.247	.2823	.247			.2999	.247
2	.2823	.3176	.247			.2999	.247
3	.3528	.4234	.3176			.2999	.3176
4	.4587	.4587	.4763			.4411	.4587
5	.5469	.494	.5822			.6704	.6528
9	.3176	.3528	.3705			.3705	
10	.2646	.247	.3176				
11	.2293		.2293				
12	.2117	.2117	.2117				.2117
13	.2293	.2117	.2117				.2117
14	.2293	.2293	.2117	.2646			.2117
15	.2117	.2117	.2117	.2823			.2117
16	.247	.2117	.2117			.247	.2117
17	.3176	.247	.2117			.4058	.3352
18	.494	.3176	.4763		.3528	.4058	.4234
19	.4763	.4411	.4587		.4058	.3881	.4587
20		.3705			.3881	.3705	
21		.3176				.3352	
22		.2646				.2823	
23	.247	.247				.247	
24	.247	.247	.247			.2999	.247
Max	.5469	.494	.5822	.2823	.4058	.6704	.6528
Min	.2117	.2117	.2117	.2646	.3528	.247	.2117
Avg	.3117	.3052	.3082	.2735	.3822	.3576	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 201 / 11 KV KINGAON RAJA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0667	.0274	.0412	
2	.0667	.0667	.0274	.0412	
3	.0667	.0667	.0412	.0412	
4	.0667	.0667	.0549	.0549	
5	.0667	.0934	.0869	.0412	
6	.1734	.1467	.1738	.0823	
7	.2	.1334	.208	.1448	
8	.16	.1334	.1783		
9	.1334	.1067	.1128		.08
10					.0667
11					.1128
12					.141
13					.1692
14					.1738
15					.1738
16					.1738
24	.0667	.0667	.0549	.0412	
Max	.2	.1467	.208	.1448	.1738
Min	.0667	.0667	.0274	.0412	.0667
Avg	.1080	.0947	.0966	.061	.1364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 202 / 11 KV HIVARKHED PURNA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4001
2						.4001
3						.4268
4						.4668
5						.4668
6						.4668
7						.4801
8						.5068
9				.8688		
10	.8802	.8002	.8535	.9686	.5601	
11	1.0002	.9998		.9998		
12	1.0002	1.0936		.9998		
13	1.0002	1.1248		1.0311		
14	1.0136	1.0623		.9374	.5735	
15	1.0269	1.0311		1.004	.5335	
16	1.0002	1.0623			.5335	
17	.9736	1.0936				
23						.4877
24						.4001
Max	1.0269	1.1248	.8535	1.0311	.5735	.5068
Min	.8802	.8002	.8535	.8688	.5335	.4001
Avg	.9869	1.0335	.8535	.9728	.5502	.4502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 203 / 11KV KINGAONRAJA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4458	.4024	.4755		.4801
2	.4458	.4458	.3658	.4755		.4458
3	.4801	.4801	.439	.5121		.4801
4	.6001	.5487	.5487	.5487		.6001
5	.9431	.9259	.5914	.7762		.9431
6	.8573	.8916	1.0082	.9335		.9602
7	.8573	.8573	.8501	.8962		.8573
8	.6859	.7716	.7762	.8131		.8059
9	.6001	.6516	.7095	.5729		.6516
10	.5658	.5316	.6283	.567	.6001	.6001
11		.5544		.5175		.5544
12	.4287	.5121		.4755		.3658
13	.4287	.4755		.4755		.2926
14		.439		.439	.3944	.3658
15		.439		.439	.4287	.4024
16	.4458	.4755		.4755	.463	.4755
17	.4973	.5853		.5544	.583	.5487
18	.6859	.6653		.7316	.823	.7023
19	.8402				.8573	.9522
20	.8916				.7716	.7577
21	.6859				.5658	.6283
22	.5487				.4973	.5121
23	.463				.4801	.4755
24	.4458	.4458	.439	.0857		.4458
Max	.9431	.9259	1.0082	.9335	.8573	.9602
Min	.4287	.439	.3658	.0857	.3944	.2926
Avg	.6116	.5864	.6144	.5665	.5877	.5960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 204 / 11 KV PANGRI UGALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0667	.04		.0412		.04
2	.0667	.0667		.0412		.0667
3	.0667	.0667		.0412		.0667
4	.0667	.0667		.0412		
5	.0667	.0667		.0412		
6	.0934	.0667		.096		.04
7	.1734	.1334		.1158		.0667
8	.1334	.1334		.1097		.0667
9	.0667	.0667	.1448	.0423		.0667
10			.0549	.0412		.0667
11	.0533	.0274		.0274		.0564
12	.0533	.0549		.0274		.0564
13	.0533	.0549		.0274		.0846
14	.0533	.0549		.0564	.0667	.0846
15	.0533	.0549		.0846	.0934	.1128
16	.04	.0549		.0549	.0934	.1128
17	.04	.0549			.0934	
18					.0667	
19					.0667	
20					.0667	
23					.04	.0549
24	.0667	.04	.0274	.0274		.0667
Max	.1734	.1334	.1448	.1158	.0934	.1128
Min	.04	.0274	.0274	.0274	.04	.04
Avg	.0714	.0649	.0757	.0539	.0734	.0693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 205 / 11 KV HIVARKHED PURNA GFSS GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.3658	.4207		.4287
2	.4287	.4287	.439	.4207		.4287
3	.4801	.4458	.4755	.4207		
4	.5144	.5144	.5914	.5544		
5	.8573	.8573	.8871	.8048		
6	.9088	.9088	1.0829	.9709		1.1317
7	.8573	.8573	.8871	.8962		1.0288
8	.7716	.8573	.8501	.8402		.8916
9	.6859	.7716	.695	.695		.6859
10	.5658	.6001	.5853	.6036	.5658	.6001
11	.5144	.5487		.5487		.5487
12	.4115	.5487		.439		.5121
13	.4115	.5121		.4024		.4755
14	.4287	.4755		.4755	.3429	.4755
15	.4287	.439		.5121	.4287	.4755
16	.4458	.4755		.4755	.4115	.4755
17	.4801	.5487		.5853		.5487
18	.7716	.7392		.7762	.6001	.7842
19	.8573				.7716	
20	.8573				.8573	.8501
21	.7373				.6516	.5853
22	.5487				.4458	.4755
23	.4287				.4287	.5121
24	.4458	.4287	.4024	.4207		.4287
Max	.9088	.9088	1.0829	.9709	.8573	1.1317
Min	.4115	.4287	.3658	.4024	.3429	.4287
Avg	.5944	.5993	.6601	.5928	.5504	.6171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074068 / 33 KV KINGAON RAJA S/S

Feeder No / Name : 206 / 11 KV PIMPALGAON

FEEDER SEPERATION/PURE AG

LENDI(SHELGAO Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 201 / 11KV RUMHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 202 / 11KV CHANGEFAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.216	.2469	.2469	.2315
2	.2006	.2006	.2469	.1852
3	.2469	.2315	.2315	.2315
4	.2778	.2315	.216	.2006
5	.3241	.2778	.2778	.2778
6	.3858	.3549	.4475	.463
7	.4321	.4012	.4321	
8	.463	.4321	.463	
9	.4938	.463	.5401	.2932
24	.2315	.216	.2315	.7621
Max	.4938	.463	.5401	.7621
Min	.2006	.2006	.216	.1852
Avg	.3272	.3056	.3333	.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 201 / 11KV JAGDARI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4161	.4668	.4115	.6859	.4108	.4115
2	.463	.4508	.4854	.4115	.703	.4668	.4458
3	.5144	.4801	.5228	.5144	.7202	.4854	.5144
4	.7202	.6344	.7095	.7202	.8817	.5601	.7716
5	.9774	.9602	1.0829	.8745	1.2039	.8962	.9774
6	1.2517	1.2548	1.3443	1.0288	1.643	1.1949	1.1831
7	1.2517	1.2548	1.2883	.823	1.4754	1.1576	1.1488
8	1.0802	1.0852	1.251	.8916	1.2039	1.2696	.9774
9	.9945	.9602	.9709	.703	.8745	.9522	.823
10	.6516	.6687	.7095	.6687	.6344	.7655	.6001
11	.583	.6161	.5658	.6344	.5975	.5316	.4334
12	.5375	.5415	.463	.5658	.3921	.4973	.3814
13	.5201	.5228	.4973	.5028	.4854	.4115	.3988
14	.5028	.5228		.5548		.4973	.4161
15	.5028	.8589		.5658		.5144	.4508
16	.5548	2.0911	.6173			.5316	.5028
17	.6516	2.4832	.8916	.8745	.8402	.7545	2.4417
18	.9088		1.046		.8215	.8916	2.6825
19	1.1361		.9945	1.0004	1.1576	.9431	1.1191
20	1.0682	1.1203	2.4863	.7202	.9709	.7888	.8648
21	.6344	.7842	.6001	.5487	.8589	.5658	.6001
22	.5028	.5601	.4801	.7716	.5788	.4973	.4854
23	.4681	.5228	.4458	.7202	.4854	.4458	.4334
24	.4973	.4508	.4854	.4287	.6859	.4854	.4287
Max	1.2517	2.4832	2.4863	1.0288	1.643	1.2696	2.6825
Min	.4458	.4161	.4458	.4115	.3921	.4108	.3814
Avg	.7258	.8745	.8366	.6789	.8524	.6881	.8122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 202 / 11KV JAGDARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0457
2							.0457
3							.0457
4							.0457
5							.0762
6							.0457
7							.0762
8							.0457
9				.1524	.1341		
10	.1844	.1844	.1494	.1524	.1509		
11	.2347	.2801	.2286	.2012	.1494		
12	.2012	.2427	.1981	.1844		.061	
13	.2012	.2054	.1981	.1509		.0762	
14	.1341	.2427				.061	
15	.1353	.168		.1677		.0457	
16	.1509	.2241	.2439				
17	.1844	.2241	.2286				
23							.1526
24							.0457
Max	.2347	.2801	.2439	.2012	.1509	.0762	.1526
Min	.1341	.168	.1494	.1509	.1341	.0457	.0457
Avg	.1783	.2214	.2078	.1682	.1448	.0610	.0625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 203 / 11KV NAGZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1341	.112	.1219	.0848	
2	.1067	.1187	.112	.1219	.0848	
3	.1219	.1187	.112	.1372	.0848	
4	.1219	.1341	.1494	.1372	.0848	
5	.1219	.1509	.168	.1524	.1017	
6	.1677	.1844	.2241	.1829	.1017	
7	.2743	.218	.3547	.2134	.1844	
8	.2439	.1844	.3361	.2134	.2347	
9	.2134	.218	.3361			
10						.0305
11						.12
12						.0857
13						.1029
15						.1526
16						.2035
23				.0848		
24	.12	.1341	.0747	.1219	.0848	
Max	.2743	.218	.3547	.2134	.2347	.2035
Min	.1067	.1187	.0747	.0848	.0848	.0305
Avg	.1598	.1595	.1979	.1487	.1163	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 201 / 11 KV SAOKHED TEJAN AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 202 / 11 KV WAGHORA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074102 / 33/11 KV MAHARKHED

Feeder No / Name : 203 / 11 KV SAOKHED TEJAN GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 201 / 11KV RAHERI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 202 / 11KV BIBI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 203 / 11KV JAMBHORA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 204 / 11KV JAMBHORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 205 / 11KV RAHERI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 077005 / 132KV S/S DUSARBID

Feeder No / Name : 206 / 11 KV BIBI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 201 / 11 KV SHIRLA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
7		.4031	
17	.1463		
24			.2058
Max	.1463	.4031	.2058
Min	.1463	.4031	.2058
Avg	.1463	.4031	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 202 / 11 KV BORIADGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 203 / 11 KV LAKHANWADA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3929
Max	.3929
Min	.3929
Avg	.3929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 204 / 11 KV P DHANGAR WW EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 205 / 11 KV LAKHANWADA GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4972
Max	.4972
Min	.4972
Avg	.4972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074003 / 33/11KV ATALI

Feeder No / Name : 206 / 11 KV BORIADGAON GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	1.2345
Max	1.2345
Min	1.2345
Avg	1.2345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 201 / 11KV GERU MATARGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3292	.3086	.2896		
2			.3258	.3086	.2926		
3			.3258	.3429	.2896		
4			.3658	.3429	.2896		
5			.4344	.4287	.3258		
6			.5487	.4801	.3982		
7			.5487	.5144	.4344		
8				.5487	.4706		
9	.4801	.5144		.4801	.3772		
10	.5144	.543		.5068	.3772		
11	.5487	.5731				.7712	.6516
12	.583	.5792				.7377	.6859
13	.6001	.5068				.6516	.7716
14	.6001	.4344				.6859	.5487
15	.583	.3982				.57	.6001
16	.6001	.3982				.503	.6001
17						.4694	.4287
18						.3688	.3944
22		.3189					
23		.3258					
24			.3258	.3086			
Max	.6001	.5792	.5487	.5487	.4706	.7712	.7716
Min	.4801	.3189	.3258	.3086	.2896	.3688	.3944
Avg	.5637	.4592	.4005	.4155	.3545	.5947	.5851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 202 / 11 KV ATALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0152				.0343	.0286
2	.0171	.0152				.0343	.0297
3	.0171	.0152				.0343	.0297
4	.0171	.0152				.0343	.0297
5	.0343	.0152				.0343	.0297
6	.0343	.0305				.0343	.0446
7	.0343	.0305				.0343	.0446
8						.0171	.0434
9			.0305			.0171	.0457
10			.0305			.0297	.0305
11			.0305	.0724	.0343		
12			.0305	.0362	.0343		
13			.0305	.0362	.0343		
14			.0305	.0354	.0343		
15			.0305	.0175	.0343		
16			.0305	.0175	.0343		
17				.0175			
18				.0362	.0343		
22	.0305						
23	.0305						
24	.0171	.0305		.1372			
Max	.0343	.0305	.0305	.1372	.0343	.0343	.0457
Min	.0171	.0152	.0305	.0175	.0343	.0171	.0286
Avg	.0249	.0209	.0305	.0451	.0343	.0304	.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 203 / 11KV LOKHANDA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715	.0362	.0305		.1715	.0747
2	.1372	.1715	.0362	.0305		.1715	.112
3	.1715	.1715	.0362	.0343		.1715	.112
4	.1715	.1715	.0362	.0343		.1715	.112
5	.1715	.2058	.0362	.0305		.1715	.1494
6	.1715	.2058	.0362	.0305		.2058	.1867
7	.1715	.1715	.0362	.0305		.2401	.2614
8	.0343	.0305	.0305	.0305		.2401	.1867
9	.0305	.0305	.2058	.0305		.2401	.1494
10	.0305	.0362	.2058	.0343		.112	.1372
11	.0305	.0362	.2401	.2172		.0747	.0305
12	.0305	.0366	.2058	.2172	.2058	.0373	.0305
13	.0305	.0362	.2401	.2172	.1715	.0373	.0305
14	.0305	.0362	.2058	.1829	.1372	.0373	.0305
15	.0305	.0362	.2058	.1772	.1372	.0373	.0305
16	.0305	.0358	.2401	.2172	.1372	.0747	.0305
17		.0362	.0305	.2534	.1029	.0747	.0457
18	.0305	.0362	.0305	.2534	.1029	.0747	.0457
19	.0305	.0732	.0305	.0362	.0686		.0457
20	.061	.0724	.0305	.0354	.0686	.0747	.061
21	.061	.0724	.0305	.0351	.0686	.0747	.061
22	.1715	.0362	.0305	.0362	.0686	.0747	.061
23	.2058	.0362	.0305	.0351	.0686	.0747	.061
24	.1372	.2058	.0366	.0305	.0362	.0686	.0747
Max	.2058	.2058	.2401	.2534	.2058	.2401	.2614
Min	.0305	.0305	.0305	.0305	.0362	.0373	.0305
Avg	.0916	.0897	.0951	.0942	.1057	.1179	.0883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 204 / 11KV LOKHANDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.4805	.4115		.3772	.4108
2	.3772	.3772	.4706	.4115	.4344	.3772	.4108
3	.3772	.3772	.4755	.4115	.4344	.3772	.4108
4	.4115	.3772	.4755	.4115	.4344	.4115	.4108
5	.4115	.4287	.5121	.4801	.4706	.4115	.4481
6	.4458	.4287	.5121	.4801	.543	.4115	.4481
7	.4458	.4458	.4706	.4115	.4706	.4115	.4854
8	.4115	.4115	.4115	.4115	.4344	.4115	.4854
9	.4458	.3658	.4115	.4458	.4115	.4115	.4481
10	.4115	.4344	.3772	.439	.4115	.3734	.3429
11		.3982	.3429	.4344	.4115	.3734	.3086
12	.4115	.4024	.4115	.4024	.3772	.3734	.4115
13	.3772	.3982	.4115	.3982	.3772	.4108	.4115
14	.3429	.4344	.4115	.394	.3772	.3734	.3429
15	.3772	.4344	.4801	.4298	.3772	.4481	.3772
16	.3429	.3982	.3772	.4344	.3772	.4108	.3772
17	.4115	.3982	.4115	.3982	.4115	.4108	.4115
18	.4115	.4755	.4801	.4706	.4115	.4854	.4801
19	.4115	.4755	.4115	.543	.4115		.4458
20	.4115	.6584	.4115	.6154	.4115	.6722	.4115
21	.4801		.4287	.5792	.4115	.5975	.4115
22	.4801	.5792	.4115	.543	.4115	.5975	.4801
23	.4115	.543	.4115	.4706	.3772	.5601	.4801
24	.4115	.4115	.5121	.4115	.4755	.3772	.4854
Max	.4801	.6584	.5121	.6154	.543	.6722	.4854
Min	.3429	.3658	.3429	.394	.3772	.3734	.3086
Avg	.4085	.4361	.4379	.4516	.4202	.4376	.4223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 205 / 11 KV GERU MATARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3258	.3086	.3292	.3086	.3361
2	.3086	.3086	.3258	.3086	.3258	.3086	.3361
3	.3086	.3086	.3292	.3086	.3258	.2743	.3361
4	.3086	.3086	.3292	.3086	.3292	.2743	.3361
5	.3429	.3429	.362	.3429	.3292	.2743	.3361
6	.3429	.3429	.3292	.3086	.3292	.2743	.3361
7	.3429	.3429	.3292	.2743	.2926	.2743	.2987
8	.3429	.3086	.3086	.2401	.2926	.2743	.2987
9	.3086	.3086	.2743	.2743	.2743	.2743	.2987
10	.3086	.3258	.3086	.2896	.2743	.2614	.2743
11	.2743	.2896	.2743	.3292	.2743	.2614	.3086
12	.3086	.2926	.3086	.3258	.2743	.2614	.2401
13	.2743	.3258	.2743	.3258	.2743	.2987	.2401
14	.2743	.3292	.2743	.3292	.2743	.2987	.2743
15	.2743	.3292	.3086	.3326	.2743	.2987	.2743
16	.2743	.3258	.3086	.3292	.2743	.2987	.2401
17	.3086	.2926	.3429	.2926	.2743	.2987	.2743
18	.3086	.2896	.2743	.3292	.3086	.2614	.3086
19	.3429	.3982	.3086	.3658	.3429	.3361	.3086
20	.3772	.4755	.3429	.4344	.3772	.4108	.3429
21	.4287	.4755	.4458	.4066	.3772	.4481	.4115
22	.4115	.4344	.4287	.4024	.3772	.4108	.3772
23	.4458	.4024	.4115	.3658	.3429	.4108	.3429
24	.3429	.3429	.3658	.3429	.3658	.3429	.3734
Max	.4458	.4755	.4458	.4344	.3772	.4481	.4115
Min	.2743	.2896	.2743	.2401	.2743	.2614	.2401
Avg	.3293	.3421	.3288	.3282	.3131	.3098	.3127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 201 / 11 KV KOLORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2915	.2229	.2572	.2401	.2229	.2058
2	.2915	.2743	.2058	.2572	.2401	.2058	.2058
3	.2743	.2743	.2058	.2401	.2401	.2058	.2058
4	.2743	.2915	.2058	.2401	.2058	.1886	.2229
5	.3086	.3086	.2058	.2229	.2058	.2058	.2401
6	.3429	.3429	.1886	.2229	.2058	.2058	.2401
7	.3086		.1543	.2058	.1715	.2229	.2058
8	.1715	.1715	.1372	.2058	.1543	.1715	.1886
9	.1543	.1543	.2743	.1543	.1372	.1543	.1543
10	.1715	.1372	.3086	.1715	.1543	.12	.1543
11	.1886	.1543	.3086	.3772	.2229	.1372	.1543
12	.2058	.1715	.3086	.3429	.2572	.1715	.1543
13	.2058	.2058	.2743	.2915	.2229	.1715	.2058
14	.2229	.2229	.2743	.2572	.2401	.1715	.2229
15	.2058	.2401	.2915	.2743	.2743	.2058	.2229
16	.2058	.2401		.3429	.2915	.1886	.2229
17	.2058	.2229	.1886	.3429	.1543	.1715	.2058
18	.1886	.2058	.1886	.2743		.1886	.1715
19	.2058	.2229	.2401	.2058	.2401	.2572	.2401
20	.2743	.2743	.2743	.2743	.2058	.2743	.2743
21	.2743	.2743	.3086	.2743	.2229	.2743	.3086
22	.4115	.2743	.3086	.2743	.2229	.2743	.2743
23	.3429	.2572	.2915	.2743	.2058	.2401	.2401
24	.3086	.3086	.2401	.2572	.2743	.2229	.2058
Max	.4115	.3429	.3086	.3772	.2915	.2743	.3086
Min	.1543	.1372	.1372	.1543	.1372	.12	.1543
Avg	.2515	.2400	.2438	.2601	.2170	.2022	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 202 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5316	.6516	.5144	.4115	.5144
2	.5487	.5144	.5144	.6173		.4115	.5144
3	.5144	.5144	.5144	.6173	.4801	.3944	.4801
4	.5144	.4801	.5144	.583	.5144	.4115	.4458
5	.4801	.4801	.5316	.6516	.5144	.4287	.4458
6	.4458	.3772	.5487		.4801	.463	.4115
7	.3772	.3258	.5144	.6173	.5487	.3772	.3772
8	.3601	.3429		.583	.583	.3944	.3086
9	.5487	.6344		.5487	.6173	.3429	.2915
10	.6001	.6859		.463	.5487	.2915	
11	.6173	.6001		.4287		.2743	.583
12	.6173	.5487	.6001	.5144		.2743	.6173
13	.6001		.6173	.5487		.3086	.6516
14	.6173	.5144	.6173	.5487	.6001	.3429	.6344
15	.583	.4801	.6001	.5487	.6173	.4115	.6516
16	.6516	.4801	.6001	.5487	.6001	.3944	
17	.4801	.3601	.4801	.4801		.3772	.4801
18	.3772	.3772	.4115	.3772	.4287	.4115	.4801
19	.6173	.4458	.6173	.3772	.4287	.5144	.6001
20	.6173	.6173	.6516	.6173	.1543	.6001	.6516
21	.6516	.6516	.6687	.6173	.5487	.6001	.6173
22	.6516	.5487	.6687	.6516	.4801	.6173	.6173
23	.583	.5487	.6173	.6173	.4458	.583	.583
24	.5658	.5487	.5316		.583	.4115	.5487
Max	.6516	.6859	.6687	.6516	.6173	.6173	.6516
Min	.3601	.3258	.4115	.3772	.1543	.2743	.2915
Avg	.5487	.5055	.5676	.5549	.5099	.4187	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 203 / 11 KV CHITODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.3601	.5144	.2743	.1886	.2058
2	.2401	.2401	.3429	.4801	.2743	.1715	.2058
3	.2401	.2401	.3429	.4458	.2915	.1715	.2058
4	.2229	.2229	.3429	.4458	.2915	.1715	.2229
5	.2229	.2229	.3772	.4801	.3086	.1886	.2229
6	.2401	.2229	.4115	.583	.3086	.1886	.2401
7	.2058	.2058	.3772	.5144	.2915	.2058	.2229
8	.2058	.2058	.2058	.4801	.2915	.1886	.2058
9	.4287	.4115	.2229	.4115	.2743	.1886	.1886
10	.4458	.4115	.2401	.3429	.4115	.2229	.1886
11	.4115		.2401	.2572	.2229	.1886	.4458
12	.4115	.3601	.2572	.2743	.2229	.2229	.4115
13	.3772	.3601	.2743	.2743	.2572	.2229	.3086
14	.4115	.3429	.2743		.2743	.3601	.3086
15	.3772	.4287	.2743		.2743	.4115	.3429
16	.4115	.4115	.2743		.2058	.4115	.3429
17	.2058	.1886	.2401	.2058		.3944	.3086
18	.2058	.2058	.2058	.2058		.3772	.2743
19	.2743	.2743	.3086	.2743		.2743	.3086
20	.3429	.3086	.3429	.3429	.2915	.3258	.3429
21	.3429	.3429	.3086	.3429	.2743	.2915	.3429
22	.2915	.3429	.3086	.2915	.2572	.2572	.3258
23	.2743	.4115	.3086	.2743	.2058	.2401	.2915
24	.2743	.2572	.3944		.2743	.1886	.2401
Max	.4458	.4287	.4115	.583	.4115	.4115	.4458
Min	.2058	.1886	.2058	.2058	.2058	.1715	.1886
Avg	.3051	.2989	.3015	.3721	.2751	.2522	.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 204 / 11 KV SHAHEEN FROZON NON SHEDDABLE EXPRESS HV FEEDERS
EXPRESS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8		.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.3086	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343	.0343	.0343			.0343
17	.0343	.0343	.0343	.0343		.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343		.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.3086	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0457	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 205 / 11 KV TEMBHURNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3258	.3429	.2058	.3086	.3086
2	.3086	.2915	.3086	.3429	.2058	.3086	.3086
3	.3086	.3086	.3086	.3086	.1886	.2915	.2915
4	.2915	.3086	.2915	.3086	.1886	.2915	.2915
5	.2915		.2915	.2743	.2058	.2915	.2915
6	.3086	.2058	.2743	.2572	.2058	.2915	.3086
7	.2743	.3429	.2401	.2401	.1715	.2743	.2743
8		.1543	.2058	.2229	.2058	.2058	.2572
9		.2058	.2743		.2058	.2058	.2401
10		.2401	.3086		.2401	.2229	.2401
11	.2743	.2229	.3086	.1372	.3601	.2229	.2058
12	.2915	.2058		.1372	.3429	.2401	.2058
13	.3258	.2058	.3601	.4287	.3601	.2401	.1715
14	.3258	.2229	.3429	.3772	.3258	.2572	.2915
15	.3086	.2915	.3601	.4287	.3258	.2743	.3086
16	.3086	.2743	.3429	.3772	.3258	.2572	.2229
17	.2743	.2572	.2743	.3429	.2229	.2572	
18	.2401	.2401	.2743	.3086	.2915	.2401	
19	.3086	.2743	.3772		.2915	.3086	.3429
20	.3772	.3601	.4115	.3772	.3772	.3772	.3772
21	.3772	.3944	.4115	.3772	.2743	.3772	.3944
22	.463	.3772	.0343	.3772	.2915	.3429	.3944
23	.4115	.3772	.3772	.3772	.3086	.3429	.3772
24	.3772	.3429	.3601	.3429	.3429	.3258	.3258
Max	.463	.3944	.4115	.4287	.3772	.3772	.3944
Min	.2401	.1543	.0343	.1372	.1715	.2058	.1715
Avg	.3233	.2788	.3071	.3184	.2694	.2815	.2923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 201 / 11 KV MATARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.6535	.0343	.0343	.0724		.9088
2	.6161	.6161	.0343	.0343	.0934		.8916
3	.6036	.6348	.0343	.0343	.0905		.8916
4	.6219	.7095	.0343	.0343	.112		.8745
5	.7316	.7468	.0343	.1029	.1086		.9431
6	.7421	.7783	.0514	.1029	.1307		1.0117
7	.823	1.0082	.0514	.1029	.0934		1.2003
8			.0686	.1029	.1307		1.2003
9			.8745	.1494	.168		1.166
10			.8916	.1629	.1097		1.0117
11			.8916	1.0082	1.0974		
12			.9259	1.0829	1.2437		
13			.8916	1.0642	1.1523		
14	.0747	.0343	.8916	1.0456	1.134		
15	.0724	.0343	.8916	1.0829	1.1157		
16	.0905	.0343	.8916	1.0185			
17	.0934	.0343		.9709			
18	.0934	.0343		.9522		1.0288	
19	.112	.0343				1.0288	.0343
20	.112	.0343				1.046	.0343
21	.112	.0343				1.0288	.1029
22	.6722	.0343				1.0288	.1029
23	.6154	.0343				.9774	.1372
24	.5853	.6348	.0343	.4031			.9431
Max	.823	1.0082	.9259	1.0829	1.2437	1.046	1.2003
Min	.0724	.0343	.0343	.0343	.0724	.9774	.0343
Avg	.4087	.3403	.4428	.4995	.4568	1.0231	.7159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 202 / 11 KV JALAMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.112	.1715	.1715			.0686
2	.0914	.0934	.1715	.2058			.0686
3	.0905	.112	.1715	.2401			.0686
4	.0914	.0934	.1715	.2743			.0686
5	.1097	.0905	.2401	.2743			.0343
6	.1097	.0747	.2743	.3772			.0343
7	.1097	.0724	.4115	.4458			.0514
8	.1097	.0905		.3086	.4481		.0514
9	.439	.3944		.2715	.3734		.12
10	.3734	.3601		.1494	.3801		
11	.2534	.3429					.3429
12	.3361	.3086					.3086
13	.2987	.2401					.3086
14	.2715	.3429	.1029				.2915
15	.2534	.4287	.1029				.2915
16	.2353	.2572	.1029				.3258
17			.12	.1307			.3258
18			.1372	.1494			.2915
19			.1372	.1307			
20			.1372	.112		.0514	
21			.12	.1307		.0857	
22	.112	.2058	.0857	.112		.0857	
23	.0934	.2058	.1029	.112		.0686	
24	.1097	.112	.1715	.3856	.1307		.0686
Max	.439	.4287	.4115	.4458	.4481	.0857	.3429
Min	.0905	.0724	.0857	.112	.1307	.0514	.0343
Avg	.1884	.2072	.1629	.2212	.3331	.0729	.1734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 203 / 11 KV JALAMB GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.8402	.6859	.6859	.8029	.5853	.6859
2	.7133	.7468	.6859	.6859	.7655	.567	.6859
3	.7316	.7095	.6859	.6859	.7842	.5853	.6859
4	.7133	.6878	.6516	.6516	.8029	.5788	.6516
5	.7282	.724	.6001	.6001	.7468	.5975	.6001
6	.6401	.6161	.5144	.6173	.6516	.6283	.5658
7	.5228	.5041	.5144	.463	.5788	.6036	.4973
8	.5041	.5041	.5316	.5316	.5601	.5973	.463
9	.567	.5316	.4801	.5228	.5792	.5487	.4801
10	.5975	.5316	.4801		.5611	.4973	
11	.6154	.5487	.4973		.5975		.5144
12	.724	.6516	.4973		.6283		.5487
13	.724	.7373	.5144		.7282	.5316	.5144
14	.7095	.7373	.6173		.7577	.5658	.6516
15	.6878	.7373	.6516		.7316	.583	.6687
16	.7468	.703	.6516	.8962			.6859
17	.7316	.6859	.6344	.7842		.4973	.6173
18	.8688	.6344	.5658	.7095		.5144	.5487
19	1.0082	.7373	.7373	.8962			.7716
20	.9709	.823	.8916	.8962		.8059	.8059
21	.905	.8402	.9088	.9522		.8059	.8059
22	.8326	.7888	.823	.9709		.7888	.7888
23	.7964	.7373	.7373	.8215		.7202	.703
24	.7316	.8402	.703	.703	.8029		.6859
Max	1.0082	.8402	.9088	.9709	.8029	.8059	.8059
Min	.5041	.5041	.4801	.463	.5601	.4973	.463
Avg	.7296	.6916	.6359	.7263	.6925	.6106	.6359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 204 / 11 KV MATARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.4481	.3258	.3772	.3734	.2743	.3429
2	.4024	.4108	.3258	.3429	.3734	.2926	.3429
3	.3921	.3734	.3258	.3429	.3361	.2772	.3429
4	.3658	.3361	.3258	.3429	.3361	.2926	.3429
5	.3658	.3361	.3258	.3429	.3174	.2743	.3086
6	.3475	.3174	.3258	.3086	.3361	.2957	.2743
7	.3361	.2801	.2743	.2743	.2801	.2926	.2572
8	.2957	.2614	.2572	.2743	.2987	.2743	.2401
9	.3142	.2058	.2572	.2801	.2801	.3109	.2401
10	.3174	.2229	.2743	.3361	.3174	.2743	.2743
11	.3361	.2401	.3086	.3361	.3361	.2743	.2743
12	.3734	.2915	.3601	.3174	.3292	.2743	.2743
13	.3361	.3429	.3601	.2987	.3511	.2915	.2915
14	.3439	.3772	.3772	.3361	.3696	.3258	.3086
15	.3734	.3944	.3772	.3547	.3475	.3429	.3086
16	.3547	.3772	.3601	.3734			.3429
17	.3734	.3601	.3429	.3361		.3086	.3086
18	.4344	.2915	.3086	.3547		.3258	.2915
19	.4481	.3601	.3429	.3734		.3772	.3429
20	.4668	.4458	.4287	.4108		.4115	.3772
21	.4668	.4458	.4287	.4294		.4115	.3944
22	.4525	.4287	.4287	.4481		.3944	.3944
23	.4481	.3944	.4115	.4481		.3601	.3429
24	.4024	.4481	.3258	.4115	.4108		.3429
Max	.4668	.4481	.4287	.4481	.4108	.4115	.3944
Min	.2957	.2058	.2572	.2743	.2801	.2743	.2401
Avg	.3805	.3496	.3408	.3521	.3371	.3162	.3151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 205 / 11 KV BHASTAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2614	.2058	.2229	.2614	.1829	.2058
2	.2801	.2427	.2058	.2058	.2427	.1848	.2058
3	.2772	.2172	.2058	.2058	.2241	.1829	.2058
4	.2614	.2427	.2058	.2058	.2427	.1991	.2058
5	.2587	.2614	.2058	.2058	.2241	.2218	.1886
6	.2587	.1867	.1886	.1886	.2241	.2195	.1886
7	.2241	.1867	.1886	.1543	.1867	.2561	.1715
8	.2012	.168	.2058	.1886	.2241	.2195	.1715
9	.2195	.2743	.2058	.1867	.2614	.2195	.2058
10	.181	.2572	.2058	.1867	.1848	.2058	.2058
11	.2172	.2401	.2058	.1867	.2402	.2058	.2058
12	.2534	.2401	.2229	.2054	.2561	.2058	.2058
13	.2353	.2572	.2229	.2241	.2587	.2058	.2229
14	.2172	.2401	.2401		.2772	.2743	.2229
15	.2614	.2401	.2572	.2427	.2743	.2743	.2229
16	.2427	.2572	.2572	.2801			.2401
17	.2241	.2401	.2401	.2427		.1886	.2058
18	.2987	.2229	.2229	.2614		.2743	.1543
19	.3174	.2572	.2572	.2614		.3086	.2401
20	.3361	.3258	.3258	.2987		.3429	.3086
21	.2987	.3086	.3086	.3361		.3086	.2743
22	.2614	.2915	.2743	.3361		.2915	.2401
23	.2614	.2401	.2572	.2801		.2401	.2058
24	.2561	.2427	.2229	.2401	.2614		.2058
Max	.3361	.3258	.3258	.3361	.2772	.3429	.3086
Min	.181	.168	.1886	.1543	.1848	.1829	.1543
Avg	.2549	.2459	.2308	.2325	.2403	.2369	.2129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 200 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.4191	.724	.6097	.0381	.1524
2	.1524	.1524	.4191	.7621	.6097	.0381	.1524
3	.1524	.1143	.4191	.7621	.6478	.0381	.1524
4	.1524	.1143	.4572	.7621	.6859	.0381	.1524
5	.1524	.1143	.5716	.7621	.7621	.0381	.1524
6	.1524	.1143	.8764	.9526	.8002	.0381	.1524
7	.1524	.1143		1.0669	1.1431	.0381	.1524
8	.1524	.1143	.1524	.7621	.9526	.0381	.1524
9	.9145	.8383		.724	.8383		.1524
10	1.1431	.7621	.1524	.6097	.6478		.1143
11	.9526	1.0288	.1524	.1524	.1143		.3429
12	.8002	.9526	.1524	.1524	.1143	.2667	1.1431
13	.6097	.8383	.1524	.1524	.1143	.5716	1.2193
14	.5335	.7621	.1524	.1524	.1143	.8383	.9145
15		.724	.1524	.1524	.1143	.7621	.8383
16	.5335	.6859	.1524	.1524	.1143	.724	.8002
17	.1905	.1524	.1524	.1524	.0762	.5716	.8383
18	.1905	.1524	.1524	.1905	.0762	.4572	.4954
19	.1524	.1524	.1524	.1524	.0762	.1524	.1524
20	.1524	.1524	.1524	.1905	.0762	.1524	.1524
21	.1524	.1524	.1524	.1905	.0762	.1524	.1524
22	.1524	.6097	.1524	.1524	.0381	.1524	.1524
23	.1524	.4954	.1524	.1524	.0381	.1524	.1524
24	.1524	.1524	.4191	.4287	.1524	.0381	.1524
Max	1.1431	1.0288	.8764	1.0669	1.1431	.8383	1.2193
Min	.1524	.1143	.1524	.1524	.0381	.0381	.1143
Avg	.3479	.4001	.2667	.4338	.3747	.2522	.3747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 201 / 11 KV BHALEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.1524	.1524	.1143	.0381	.0381
2	.0381	.0381	.1524	.1524	.1143	.0381	.0381
3	.0381	.0381	.1524	.1524	.1143	.0381	.0381
4	.0381	.0381	.1524	.1524	.1524	.0381	.0381
5	.0381	.0381	.1905	.1524	.1905	.0381	.0381
6	.0381	.0381	.3048	.2286	.2667	.0381	.0953
7	.0381	.0381		.381	.4572	.0381	.0381
8	.0381	.0381		.381	.4191	.0381	.0381
9		.4572		.2667	.381	.0381	
10	.4954	.4572	.0381	.2667	.381	.0381	
11	.4191	.4954	.0381	.0381	.0381	.2667	
12	.3048	.4191	.0381	.0381	.0381	.3429	
13	.2667	.381	.0381	.0381	.0381	.3429	
14	.1905	.3048	.0381	.0381	.0381	.3048	.2667
15	.1524	.3048	.0381	.0381	.0381	.3048	.4572
16	.1524		.0381	.0381	.0381	.2667	.4191
17	.0381	.0381	.0381	.0381	.0381	.2667	.5716
18	.0381	.0381	.0381	.0381	.0381	.2667	.381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.1524	.0381	.0381	.0381	.0381	.0381
23	.0381	.1524	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.1524	.0381	.0381	.0381	.0381
Max	.4954	.4954	.3048	.381	.4572	.3429	.5716
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1126	.1590	.0853	.1175	.1302	.1238	.1414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 202 / 11 KV PIMPALGAON RAJA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.1143	.0762
2	.2286	.1905	.1143	.0762
3	.2286	.2286	.1143	.0762
4	.2286	.3048	.1143	.0762
5	.2667	.381	.1143	.0762
6	.3429	.4191	.1143	.0762
7	.4954	.4572		.0762
8	.0762	.1143	.1143	
9			.1524	
10			.381	
11			.3048	
12			.2286	
13			.2286	
14	.0762		.2286	
15	.0762	.1143	.2286	
16	.0762	.1143	.2286	
17	.0762	.1143	.0762	
18	.0762	.1143	.0762	
19	.1143	.1143	.0762	
20	.1143	.1143	.0762	
21	.1143	.1143		
22	.1905	.1143		
23	.1905	.1143	.0762	
24	.2286	.1905	.1143	.0762
Max	.4954	.4572	.381	.0762
Min	.0762	.1143	.0762	.0762
Avg	.1805	.1947	.1560	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 204 / 11 KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.1143	.1524	.1524	.4572	.4572
2	.4954	.4572	.1143	.1524	.1524	.4572	.4572
3	.4954	.4954	.1143	.1524	.1524	.4572	.4572
4	.5335	.5716	.1143	.1524	.1524	.0381	.4572
5	.6478	.6097	.1143	.1524	.1524		.5716
6	.8002	.6859	.1143	.1524	.1524	.4572	.8002
7	.8383	.8764		.3048	.1524	.6859	1.0288
8	.1143	.1143	.1143	.3048	.1524	.6859	1.0288
9	.1524	.1524	.1143	.1524	.1143	.7621	.8002
10	.1524	.1143	1.1431	.1524	.0762	.6097	.724
11	.1524	.1143	.8002	1.105	1.1431	.0762	.1524
12	.1524		.7621	.9145	.9526	.0762	.1905
13		.1143	.5716	.7621	.7621	.0762	.1905
14	.1524	.1143	.5716	.6859	.6859	.0762	.1905
15			.381	.6859	.6859	.0762	.1905
16		.1143	.381	.5716	.5716	.0762	.1905
17	.1524	.1143	.1524	.6859	.5716	.0762	.1905
18	.1143	.381	.1524	.5716	.381	.0762	.1524
19	.1524	.1143	.1524	.1524	.1143		.1524
20	.1524	.1143	.1524	.1524	.1143	.1143	.1524
21	.1143	.1143	.1524	.1524	.0762	.1143	.1524
22	.4572	.1143	.1524	.1524	.0762	.1143	.1524
23	.4954	.1143	.1524	.1524	.0762	.1143	.1524
24	.4954	.4191	.1143	.1524	.1524	.0762	.1143
Max	.8383	.8764	1.1431	1.105	1.1431	.7621	1.0288
Min	.1143	.1143	.1143	.1524	.0762	.0381	.1143
Avg	.3484	.2944	.2916	.3636	.3239	.2615	.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 205 / 11 KV PIMPALGAON RAJA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8383	.8383	.8764	.8383		.8002
2	.8764	.8383	.8002	.8764	.7621		.8002
3	.8383	.7621	.7621	.8764	.7621	.724	.7621
4	.8002	.724	.7621	.8764	.7621	.6478	.7621
5	.7621	.724	.724	.7621	.724	.6478	.724
6	.7621	.6859	.6859	.6859	.6859	.6478	.724
7	.6859	.6097		.6478	.6097	.5716	.6097
8	.6478	.5716	.6097	.6478	.6097	.4954	.5716
9		.4954	.6097	.6859	.5716	.4954	.6097
10		.5335	.6478	.724	.6097	.5335	.6097
11		.6478	.6859	.7621		.6097	.6097
12		.7621	.7621	.8002	.7621	.6478	.724
13	.6859	.8002	.7621	.8764	.8002	.6859	.7621
14	.9907	.8002	.7621	.8764	.8002	.6859	.8383
15	.9907	.8383	.7621	.9145	.8383	.724	.8383
16	.9526	.8383	.7621	.8764	.8383	.724	.8383
17	.8764	.8764	.6859	.8383	.8764	.6859	.7621
18	.8002	.7621	.6859	.8383	.8383	.6859	.6859
19	.8764	.8383	.7621	.8383	.8764	.7621	.8383
20	.9907	.9526	.8764	.9526	.9526	.8383	.9526
21	1.0288	.9907	.8764	1.0288	.9526	.8764	.9907
22	.9526	.9526	.8383	.9526	.9145	.8764	.9145
23	.9145	.9145	.8764	.9145	.9145	.8383	.8764
24	.9145	.8764	.8383	.9145	.8383	.9145	.8383
Max	1.0288	.9907	.8764	1.0288	.9526	.9145	.9907
Min	.6478	.4954	.6097	.6478	.5716	.4954	.5716
Avg	.8612	.7764	.7555	.8351	.7886	.6963	.7685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 206 / 11 KV BHALEGAON GFSS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18
HR	Load (MW)
1	.5335
2	.4954
3	.4954
4	.4572
5	.4572
6	.4572
7	.381
8	.381
24	.5335
Max	.5335
Min	.381
Avg	.4657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 207 / 11 KV WASADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.3429	.381
2	.381	.3429	.3429	.381	.381	.3429	.3429
3	.3429	.3429	.3429	.381	.3429	.3429	.3429
4		.3429	.3429	.381	.3429	.3048	.3429
5	.3048	.3048	.3048	.2667	.3429	.3048	.3048
6	.3048	.3048	.3048	.2667	.3048	.3048	.3048
7	.2667	.2667		.2667	.2286	.2286	.2286
8	.2286	.2286	.2667		.2286	.2286	.2286
9	.2286	.2286	.2667	.2667	.2286	.2286	.2286
10	.2286	.2667	.2667	.2667	.2667	.2286	.2286
11	.3048	.2667	.3048	.3048	.3048	.2286	.2667
12	.3429	.2667	.3429	.3429	.3429	.2667	.2667
13	.3429	.3048	.3429	.381	.3429	.2667	.3429
14	.381	.3429	.3429	.381	.381	.3048	.3429
15	.381	.381	.3048	.381	.381	.3048	.3429
16	.381	.381	.3048	.3429	.3048	.3048	.381
17	.3429	.381	.3048	.3429	.2286	.3048	.3429
18	.3429	.3048	.3048		.3429	.3048	.3048
19	.381	.381	.381	.2667	.381	.3429	.381
20	.4572	.5335	.381	.5335	.4954	.4572	.4954
21	.4572	.4954	.381	.5335	.4572	.4572	.4954
22	.4191	.4572		.4572	.4191	.4191	.4572
23	.4191	.4191	.4191	.4191	.4191	.381	.4191
24	.381	.381	.381	.4191	.381	.381	.381
Max	.4572	.5335	.4191	.5335	.4954	.4572	.4954
Min	.2286	.2286	.2667	.2667	.2286	.2286	.2286
Avg	.3479	.3461	.3325	.3620	.3429	.3159	.3397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 209 / 11 KV TANDULWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2286	.3048	.4191	.2286	.3048	.2667
2	.2667	.2286	.2667	.4191	.2286	.3048	.2667
3	.2667	.1905	.2667	.4191	.2286		.2667
4	.2667	.1905	.2667	.4572	.1905		.2286
5	.2667	.1905	.2667	.4954	.1905	.3048	.2286
6	.3048	.1905	.3048	.4954	.1905	.3048	.2286
7	.2667	.1905		.1905	.2286	.2286	.2286
8	.2286	.1524	.2286		.2286	.2286	.1905
9	.1905	.1524	.1905	.1905	.2286	.1905	.1905
10	.1905	.1905	.3048	.2286	.2667	.1524	.1905
11	.1905	.1905	.381	.1905	.3048	.1905	.1524
12	.1905	.1905		.2286	.3429	.2667	.1905
13	.2667	.2286	.381	.2286	.3429	.2667	.2286
14	.2667	.2286	.381	.2286	.381	.2667	.2286
15	.2667		.381	.2286	.381	.2667	.2286
16	.2667	.3048	.381	.2286	.3048	.2667	.2286
17	.1905	.3048	.2286	.2286		.2667	.2286
18	.1905	.2667	.2286	.1905		.2667	.2286
19	.2286	.3429	.2667	.2667	.2667	.3429	.2667
20	.3048	.4191	.3048	.381	.3048	.4191	.3048
21	.3048	.4191	.3048	.3429	.3429	.4191	.3048
22	.2667	.3429	.3048	.3048	.3429	.381	.2667
23	.2286	.3429	.2667	.2667	.3429	.3429	.2667
24	.3048	.2286	.3048	.2667	.2286	.3048	.3048
Max	.3048	.4191	.381	.4954	.381	.4191	.3048
Min	.1905	.1524	.1905	.1905	.1905	.1524	.1524
Avg	.2508	.2485	.2961	.2998	.2771	.2858	.2381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 201 / 11 KV ROHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9995	1.1812	1.1431				.9717
2	.9995	1.1431	1.1431				.9717
3	.9995	1.1431	1.1431				.9526
4	1.0159	1.1431	1.1431				.9526
5	1.0159	1.1812	1.1812				.9907
6	1.0486	1.448	1.2955				1.2574
7	1.1984	1.467					1.3527
8							1.3527
9							1.0562
10							1.0059
11				1.9624	1.8671	1.4575	
12				1.7337	1.6956	1.3765	
13				1.6575	1.5242	1.2955	
14				1.3908	1.3146	.0695	
15				1.2384	1.2384	1.1174	
16				1.1812	1.2003	1.0688	
17				1.3336		1.2193	
18				.9892	.7625	1.1431	
22	1.5623	1.5432					
23	1.3717	1.3717					
24	1.0322	1.2384	1.1622				
Max	1.5623	1.5432	1.2955	1.9624	1.8671	1.4575	1.3527
Min	.9995	1.1431	1.1431	.9892	.7625	.0695	.9526
Avg	1.1244	1.286	1.1730	1.4359	1.3718	1.0935	1.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 202 / 11 KV WARNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4191	.3561	.3185	.3222
2	.3601	.3429	.4191	.3391	.3185	.3052
3	.3601	.3429	.4191	.3561	.3185	.3052
4	.3772	.3429	.4191	.4748	.3521	.4578
5	.4458	.381	.4191	.4917	.4024	.4973
6	.4801	.5525	.6097	.5087	.4694	.5304
7	.4801	.5906	.6478		.5533	
8	.5533	.6478	.6859	.5765	.6036	
9	.5533	.6478	.7621	.724	.6722	
10	.6668	.5967	.57	.743	.7049	
11		.547	.6203	.724	.6668	
12	.6478	.663	.6539	.724	.6859	
13	.7049	.663	.6036	.724	.724	
14	.7049	.663	.6203	.724	.5335	
15	.7049	.5087	.6203	.6668	.6478	
16	.6859	.4748	.6203	.7049	.6668	
17	.5906	.6783	.6706	.7811		
18	.6097	.7811	.6783	.6203	.2883	
19	.724	.7049	.6443	.4527	.5801	
20	.6859	.6859	.6104	.4191	.4239	
21	.6097	.6478	.5596	.4191	.373	
22	.5335	.4572	.5256	.4191	.3561	
23	.362	.4191	.5087	.3521	.3391	
24		.362	.4191	.3561	.3185	.3222
Max	.724	.7811	.7621	.7811	.724	.5304
Min	.3429	.3429	.4191	.3391	.2883	.3052
Avg	.5538	.5435	.5719	.5503	.4921	.3915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 203 / 11 KV DIWTHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1524	.2096				.6287
2	.125	.1524	.1905				.6287
3	.1406	.1524	.1905				.6097
4	.1372	.1524	.1905				.6097
5	.1635	.1715	.2096				.6668
6	.208	.1905	.2667				.8383
7	.2526	.2477	.3239			.5304	.9145
8						.5365	.9054
9						.6464	.4694
10						.5636	.5868
11				.4382	.3429	.7773	.57
12				.4191		.7773	.6036
13				.362		.7926	.6036
14				.3048		.7926	.7042
15				.2667	.3429	.7621	.7545
16				.2667	.3429	.6859	.6036
17				.2667		.9717	.6036
18				.1677	.2058	.9907	.6036
19						.7049	.7459
20						.6859	.663
21						.4954	.6464
22	.1715	.1905				.4763	.57
23	.1905	.2096				.4572	.5144
24	.1372	.1905	.2096				.4191
Max	.2526	.2477	.3239	.4382	.3429	.9907	.9145
Min	.1219	.1524	.1905	.1677	.2058	.4572	.4191
Avg	.1648	.1810	.2239	.3115	.3086	.6851	.6443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 204 / 11 KV NIMKAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1029	.1715	
2				.1715	.1132	.1715	
3				.1715		.1543	
4				.1543	.1543	.1372	
5				.1886	.0309	.1543	
6				.2713	.3688	.2229	
7					.4024	.3391	
8				.3086	.4115	.3772	
9	.285	.3239	.381	.2858	.3772	.3086	
10	.381	.373	.4024	.2858	.381	.3086	
11	.4191	.373	.4359				.6478
12	.4001	.373	.4024				.4694
13	.3429	.3391	.3353				.503
14	.3429	.2883	.3353				.3658
15	.3429	.3391	.3018				.4359
16	.3429	.2883	.3185				.4359
17							.503
18							.5144
24				.4031			
Max	.4191	.373	.4359	.4031	.4115	.3772	.6478
Min	.285	.2883	.3018	.1543	.0309	.1372	.3658
Avg	.3571	.3372	.3641	.2412	.2602	.2345	.4844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 205 / 11 KV ROHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1905	.1791	.2058	.1791	.2096
2	.1991	.1524	.1715	.1791	.2058	.1791	.2096
3	.1991	.1524	.1715	.1791	.2058	.1791	.1905
4	.2172	.1524	.1715	.1612	.1886	.1791	.1905
5	.2172	.1715	.1715	.1791	.1715	.1791	.1905
6	.1991	.2096	.2096	.1612	.1543	.197	
7	.181	.1715	.1905		.1543	.1612	.2096
8	.1991	.2096	.2096	.1433	.1543	.1629	.1886
9	.181	.1715	.1905	.1334	.012	.1629	
10	.1524	.1267	.1715	.1334	.1524	.1463	
11	.1715	.1448	.1715	.1905	.1905	.1629	
12	.1715	.1629	.1543	.1905	.1905	.1463	
13	.2096	.1629	.1677	.2096	.1905	.1646	
14	.1715	.1629	.1677	.2096	.2096	.181	
15	.1524	.1448	.1677	.2096	.2096	.181	
16	.1905	.1629	.1509	.2096	.2096	.1629	.2229
17	.1905	.181	.1543	.2096		.1524	.2012
18	.2096	.2096	.197	.2058	.181	.2096	.3258
19	.2477	.2477	.2328	.2058	.2507	.2667	.2715
20	.2667	.2858	.2686	.2683	.3045	.3048	.2534
21	.2667	.2667	.2328	.2401	.2534	.2667	.2715
22	.2286	.2667	.2149	.218	.2353	.2477	.2534
23	.2096	.2286	.2149	.2058	.2172	.2286	.2172
24	.1991	.2096	.2096	.197	.2012	.1991	.2096
Max	.2667	.2858	.2686	.2683	.3045	.3048	.3258
Min	.1524	.1267	.1509	.1334	.012	.1463	.1886
Avg	.2005	.1886	.1897	.1921	.1934	.1917	.2260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 201 / 11 KV KALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1829	.2126	.2972		
2			.1829	.2126	.2972		
3			.1829	.2126	.3567		
4			.2012	.2126	.3612		
5			.2743	.2835	.3612		
6			.4572	.5138	.3612		
7			.6335	.631	.4755		
8				.4075	.5312		
9		.463		.4252	.4012		
10	.5601	.5853		.3121	.5249		
11	.5729	.4938				.7116	
12	.5853	.439				.6405	
13	.4668	.3841				.4458	
14	.4481	.3658				.4012	.1543
15	.415	.3475				.4458	.6173
16	.3961	.3658				.4816	.7116
17						.4489	.7621
18						.3429	.5357
22		.2012					
23		.2195					
24			.1829	.373			
Max	.5853	.5853	.6335	.631	.5312	.7116	.7621
Min	.3961	.2012	.1829	.2126	.2972	.3429	.1543
Avg	.4920	.3865	.2872	.3451	.3968	.4898	.5562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 203 / 11 KV DHORAPGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281	.547	.5847	.547	.5415	.5281
2		.5281	.547	.5847	.547	.5415	.5093
3		.5281	.547	.5847	.547	.5415	.5093
4		.4904	.547	.5847	.5093	.5415	.5093
5		.4904	.5281	.5658	.5093	.5415	
6		.4904	.5093	.5281	.5093	.4904	.4904
7		.4251	.3961	.4668	.4527	.3961	.3961
8		.3801		.4527	.3734	.3395	
9		.3982		.4527	.3734	.3584	
10	.415	.3772	.3961	.4805	.3395	.3734	
11	.4481	.3206	.4527	.4481	.3772	.3018	
12	.3772	.3772	.4904	.5041	.415	.3584	
13	.4854	.4527	.5093	.5041	.4338	.3206	
14	.499	.4527	.4904	.5041	.4715	.4108	.3547
15	.4854	.4527	.4904	.5041	.4715	.4024	.499
16	.4854	.4904	.4904	.4481	.4527	.4435	.499
17	.4481	.415	.415	.4481	.3772	.4024	.4435
18	.4656	.4527	.4527	.4477	.3961	.4024	.439
19	.5853	.5093	.547	.5975	.4338	.499	.5729
20	.6348	.6348	.6979	.6722	.6348	.5658	.6602
21	.5975	.5975	.6602	.6722	.6161	.6036	.6602
22	.5658	.5975	.6602	.6161	.5975	.6036	.6413
23	.5658	.5415	.6224	.5847	.5658	.5658	.5847
24		.5281	.5415	.5847	.547	.5415	.5281
Max	.6348	.6348	.6979	.6722	.6348	.6036	.6602
Min	.3772	.3206	.3961	.4477	.3395	.3018	.3547
Avg	.5042	.4775	.5245	.5342	.4791	.4620	.5191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 201 / 11 KV AMBIKAPUR

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
10	.567	
11	.5304	
12	.5121	
13	.5121	
14	.5121	
15	.1646	
16	.1463	
17	.6401	
24		.6661
Max	.6401	.6661
Min	.1463	.6661
Avg	.4481	.6661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5068	.2534	.4024	.2743	.4887	.5068
2	.4801		.2534	.362	.2572	.4887	.5068
3	.4801	.5068	.2534	.3734	.2572	.4706	.5068
4	.4801	.5068	.2534	.3921	.2572	.4706	.5068
5	.4973	.4706	.2353	.2772	.2572	.4887	.4706
6	.3601	.3801	.3077	.2561	.2743	.3801	.362
7	.2401	.2896	.2896	.2054	.2743	.3077	.2896
8	.2743	.3077	.2353	.2172	.2401	.2896	.2172
9	.2915	.3439	.2896	.2587	.2229	.2896	.2353
10	.2715	.2896	.3258	.2058	.2229	.2896	.2715
11	.2926	.2896	.4024		.3658	.2353	.2743
12	.2715	.3077	.5041		.4207	.3077	.2801
13	.2715	.3077	.5121	.3944	.4938	.2896	.2743
14	.2715	.3258	.5359	.4973	.4075	.2534	.2614
15	.2896	.3258	.5304	.4973	.2926	.2715	.2743
16	.2715	.3439	.5228	.4973	.2561	.2534	.3174
17	.3982	.4163	.4024	.3772		.2534	.2715
18	.362	.3258	.3142	.3086	.362	.181	.2427
19	.4163	.4525	.4024	.3429	.4525	.3439	.4755
20	.5611	.5973	.5729	.5144	.5973	.543	.6099
21	.5973	.6154	.5487	.5487	.6154	.543	.543
22	.5611	.3258	.5729	.5316	.5792	.5611	.5975
23	.543	.3077	.5487	.5144	.543	.543	.567
24	.4801	.5249	.2715	.5304	.5487	.5068	.5068
Max	.5973	.6154	.5729	.5487	.6154	.5611	.6099
Min	.2401	.2896	.2353	.2054	.2229	.181	.2172
Avg	.3934	.3943	.3891	.3866	.3684	.3771	.3904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 203 / 11 KV KADMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3982	.181	.3841	.1886	.3982	.4163
2	.3772	.3982	.181	.3361	.1543	.3982	.3982
3	.3772	.3982	.181	.2896	.1543	.3801	.3982
4	.3772	.3982	.1629	.2743	.1543	.3856	.3982
5	.3772	.3801	.181	.1867	.1543	.3982	.3801
6	.3086	.3077	.1991	.1848	.1886	.2896	.2896
7	.2229	.2172	.1991	.1629	.1543	.2534	.3077
8	.2229	.2172	.2353	.1267	.1543	.1991	.1991
9	.1543	.1448	.2534	.1494	.12	.1991	.2172
10	.1629	.1991	.2715	.1029	.1372	.2172	.2353
11	.181	.181	.3258		.2835	.181	.2172
12	.1629	.1991	.4066		.3475	.1991	.2054
13	.1629	.181	.4024	.3429	.3721	.181	.1848
14	.1629	.2172	.4163	.4287	.3658	.1629	.1867
15	.1629	.2172	.4024	.4287	.3292	.1629	.181
16	.1448	.1991	.4251	.4115	.2926	.181	.1848
17	.1448	.362	.3258		.2561	.1629	.181
18	.2896	.1991	.2987		.2715	.1267	.1307
19	.362	.3439	.3475	.3258	.3439	.2896	.3258
20	.4525	.4525	.4805	.4801	.4706	.3982	.4668
21	.4887	.4706	.4572	.4973	.4887	.4344	.4435
22	.4706	.1991	.4668	.4458	.4525	.4525	.4668
23	.4344	.1991	.4163	.4115	.4344	.4344	.4344
24	.3772	.4163	.1991	.4163	.4287	.4163	.4163
Max	.4887	.4706	.4805	.4973	.4887	.4525	.4668
Min	.1448	.1448	.1629	.1029	.12	.1267	.1307
Avg	.2898	.2873	.3090	.3193	.2791	.2876	.3027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 201 / 11 kv Vardhan
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6859	.6478	.6859	.6478	.6097	.6478
2	.6097	.6859	.6478	.6859	.6478	.6097	.6478
3	.6097	.6478	.6097	.6859	.6478	.6097	.6478
4	.5716	.6478	.6097	.6859	.6478	.5906	.6478
5	.6097	.6478	.6478	.6859	.6478	.5906	.6478
6	.6097	.6478	.6478	.6859	.6478	.5906	.6478
7	.5716	.6478	.6097	.6097	.6097	.5716	.6478
8	.4954	.5716	.5716	.6097	.6478	.5335	.6287
9	.4999	.6036	.4085	.6478	.7621	.5335	.724
10	.3894	.5312	.4401	.724	.6859	.724	.7621
11	.5441	.5117	.4915	.7621	.6478	.724	.7621
12	.4816	.631	.5792	.7621	.6859	.7621	.7621
13	.4001	.4458	.4744	.7621	.6859	.6706	.7621
14	.5441	.6036	.463	.7621	.724	.6443	.7621
15	.5441	.5636	.4915	.7621	.724	.6733	.724
16	.583	.6173	.4687	.7621	.724	.6443	.6859
17	.6859	.6668	.5716	.724	.2378	.6554	.5213
18	.6097	.6097	.6097	.5906	.4108	.4999	.4329
19	.6097	.5525	.6097	.6287	.3944	.5117	.3254
20	.6287	.6287	.6668	.6478	.3841	.4858	.3429
21	.6668	.6097	.6668	.6478	.4287	.4816	.4115
22	.6668	.6668	.6478	.6668	.4058	.4451	.3894
23	.6478	.6478	.6287	.6668	.6097	.6668	.4001
24	.5716	.6478	.6097	.6097	.6478	.6097	.6478
Max	.6859	.6859	.6668	.7621	.7621	.7621	.7621
Min	.3894	.4458	.4085	.5906	.2378	.4451	.3254
Avg	.5718	.6133	.5758	.6859	.5960	.6016	.6075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3429	.3429	.381	.3429	.3429	.2858
2	.2286	.3429	.3429	.381	.3429	.3048	.2858
3	.2667	.3429	.3429	.381	.3429	.3048	.2667
4	.2667	.3048	.3048	.381	.3429	.3048	.2667
5	.2286	.3048	.3048	.381	.3429	.2858	.2667
6	.2286	.3429	.3429	.381	.3429	.2858	.2477
7	.2286	.3048	.3048	.381	.3429	.3048	.2667
8	.2286	.3429	.3048	.381	.381	.3048	.2286
9	.1715	.3353	.3429	.4191	.381	.3429	.2286
10	.2774		.3696	.4191	.4572	.381	.2286
11	.2865	.4854	.4108	.4572	.5335	.3429	.2286
12	.3696	.4435	.4024	.4572	.5335	.3048	.2286
13	.3189	.4066	.4108	.4954	.5335	.2804	.2286
14	.3361	.4805	.4359	.4954	.4954	.3544	.2286
15	.3734	.4904	.4481	.5335	.4572	.3018	.2286
16	.4108	.4904	.5281	.5335	.4954	.3224	.2286
17	.381	.5716	.4763	.5525	.2454	.3086	.1898
18	.3429	.4763	.4572	.4954	.3189	.2561	.1875
19	.3048	.4191	.4001	.4763	.2454	.2214	.1898
20	.3048	.4191	.4001	.4191	.2804	.2561	.1578
21	.2858	.4001	.381	.381	.2713	.2469	.16
22	.2858	.381	.4001	.362	.3086	.2187	.1463
23	.3048	.381	.381	.381	.3048	.2858	.1372
24	.2667	.2667	.381	.381	.3429	.3048	.2858
Max	.4108	.5716	.5281	.5525	.5335	.381	.2858
Min	.1715	.2667	.3048	.362	.2454	.2187	.1372
Avg	.2886	.3946	.3840	.4294	.3744	.2986	.2249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 203 / 11 kv Khamgaon Syntex NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4954	.4382	.4954	.4954	.4763	.5144
2	.4954	.4954	.4382	.4954	.4954	.4572	.4954
3	.4763	.4572	.4572	.4954	.4954	.4954	.4954
4	.4763	.4572	.4572	.4954	.4954	.4954	.4954
5	.4954	.4572	.4954	.4954	.4954	.4954	.4954
6	.5144	.4954	.5525	.4954	.4954	.5144	.4954
7	.4954	.4954	.5335	.4572	.5335	.5144	.5144
8	.4954	.4572	.5335	.4572	.5716	.5144	.5144
9	.4748	.427	.5121	.4191	.5335	.5144	.5335
10	.3961		.4001	.4191	.5335	.5525	
11	.591	.4784	.2824	.4572	.4954	.6097	.5716
12	.583	.4961	.5373	.4954	.5335	.6668	.5716
13	.5636	.5914	.4801	.4572	.5335	.6268	.5716
14	.4988	.4641	.4515	.4572	.5335	.5365	.5335
15	.4988	.6099	.5853	.4191	.5335	.5596	.5335
16	.4512	.6979	.591	.4191	.5335	.5784	.4954
17	.6097	.6478	.5144	.4572	.3549	.4877	.1395
18	.6287	.6668	.5335	.4382	.5731	.442	.1509
19	.6097	.5716	.5716	.4763	.4816	.4666	.4641
20	.5716	.4572	.4191	.4572	.503	.3715	.3814
21	.5525	.5335	.4763	.4572	.4578	.4527	.4268
22	.4954	.5335	.4572	.4572	.4733	.4917	.4365
23	.4763	.5144	.4191	.4572	.4954	.4954	.4049
24	.5144	.4572	.4763	.4191	.4954	.4954	.4954
Max	.6287	.6979	.591	.4954	.5731	.6668	.5716
Min	.3961	.427	.2824	.4191	.3549	.3715	.1395
Avg	.5192	.5199	.4839	.4604	.5059	.5129	.4665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 204 / 11 kv Federation

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.2765	1.2384	1.1431	1.1431	1.0288	1.0479
2	.9526	1.2574	1.2384	1.1431	1.1431	1.0288	1.0479
3	.9335	1.2384	1.2193	1.1431	1.1431	1.0479	1.0669
4	.9145	1.2193	1.2193	1.1431	1.1431	1.0288	1.0669
5	.9335	1.2193	1.2193	1.1431	1.1431	1.0669	1.0479
6	1.0098	1.2574	1.2384	1.2574	1.1431	1.105	1.105
7	1.086	1.2765	1.2193	1.1812	1.1431	1.2193	1.1241
8	1.1622	1.448	1.448	1.1812	1.2193	1.4098	.9907
9	1.6787	1.5893	1.6301	1.6385	1.6385	1.5623	.9907
10	1.8861		1.6057	1.5623	1.7909	1.7147	.9907
11	1.9814	1.9805	2.0195	1.5623	1.9052	1.6766	1.0288
12	1.9814	1.9814	1.5497	1.448	1.9814	1.9052	1.0669
13	1.5497	1.3756	1.5123	1.6385	1.9814	1.7353	1.0669
14	1.9814	1.6057	1.6598	1.7147	2.0195	1.8861	1.105
15	1.9814	1.6617	1.5655	1.7528	1.9433	1.6975	1.105
16	1.8861	1.5844	1.8484	1.829	1.9052	1.773	1.105
17	2.0576	1.5242	1.7337	1.5623	.9412	1.9433	1.0387
18	1.7909	1.6385	1.448	1.5623	1.2936	1.4563	.8356
19	1.5813	1.3527	1.2765	1.2384	1.1827	1.39	.8288
20	1.3146	1.1812	1.105	1.2193	.985	.9945	.7343
21	1.2955	1.2003	1.2003	1.1812	.964	.9882	.7316
22	1.2574	1.2003	1.2384	1.1241	.9362	.9389	.7099
23	1.2574	1.2765	1.1241	1.1431	1.0669	1.0479	.4049
24	.8954	1.2574	1.2574	1.1812	1.1431	1.0669	1.0288
Max	2.0576	1.9814	2.0195	1.829	2.0195	1.9433	1.1241
Min	.8954	1.1812	1.105	1.1241	.9362	.9389	.4049
Avg	1.4300	1.4175	1.4090	1.3622	1.3708	1.363	.9695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 205 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1905	.1905	.1524	.1905	.1905	.1524
2	.3048	.1905	.1905	.1524	.1905	.1905	.1524
3	.2477	.1905	.1524	.1524	.1905	.1905	.1524
4	.2477	.1524	.1524	.1524	.1905	.1524	.1524
5	.2286	.1524	.1524	.1524	.1905	.1524	.1905
6	.3048	.1905	.1524	.1905	.1905	.1524	.1905
7	.2477	.1524	.1143	.2667	.1524	.1905	.1143
8	.724	.1524	.1143	.2667	.1524	.2286	.1143
9	.2774	.1433	.2241	.3429	.2667	.2286	.2667
10	.3696	.2126	.2263	.3429	.3048	.2286	.3048
11	.3734	.3018	.2263	.3429	.3429	.3048	.2667
12	.3734	.2263	.2172	.381	.3429	.3048	.2286
13	.3155	.3018	.1372	.3429	.3429	.3018	.2286
14	.2241	.3018	.2263	.3429	.3429	.3772	.2286
15	.2241	.2987	.2263	.3048	.3429	.3018	.2286
16	.2865	.2218	.2263	.3048	.2667	.2263	.2286
17	.381	.3048	.1905	.3429	.2263	.1886	.1524
18		.2667	.2286	.2667	.2149	.1509	.1524
19	.2667	.3048	.2286	.3429	.2957	.1509	.1692
20	.1905	.1715	.1905	.2667	.1848	.1509	.144
21	.1524	.1524	.1524	.2286	.1132	.0148	.1578
22	.1905	.1905	.1905	.1905	.1478	.1494	.1623
23	.1905	.1905	.1905	.1905	.1524	.1524	.1783
24	.3048	.1905	.1905	.1905	.1905	.1524	.1524
Max	.724	.3048	.2286	.381	.3429	.3772	.3048
Min	.1524	.1433	.1143	.1524	.1132	.0148	.1143
Avg	.2926	.2146	.1871	.2588	.2303	.2013	.1862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 206 / 11 KV SUTALA BK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9145	.8954	.8002	.7621	.8192	.8002
2	.9526	.9145	.8764	.8002	.7621	.7621	.7621
3	.9145	.8764	.8383	.8002	.7621	.724	.724
4	.8002	.7621	.8002	.8002	.7621	.6859	.724
5	.7621	.7621	.724	.8002	.7621	.6097	.6478
6	.743	.6859	.6859	.724	.7621	.5716	.6097
7	.6859	.7621	.6668	.6097	.6097	.5335	.5335
8	.724	.6478	.6097	.6097	.5716	.4954	.5144
9	.6089	.5731	.5731	.6478	.5716	.4763	.4954
10		.5316	.5792	.6478	.5716	.4572	.4954
11	.6697	.5973	.5792	.6478	.5716	.5335	.5335
12	.7964	.6697	.6584	.6478	.6478	.4954	.5716
13	.7602	.7602	.7133	.724	.6859	.5611	.6097
14	.8048	.7682	.7922	.7621	.6859	.5611	.6097
15	.8413	.8048	.8596	.8383	.8002	.6697	.6859
16	.8596	.8326	.8048	.8383	.8383	.6697	.7621
17	.8383	.8192	.8002	.8002	.394	.591	.6697
18	.7811	.6668	.7621	.8192	.5316	.6024	.6626
19	.8192	.7621	.7621	.7811	.5731	.6335	.7164
20	.8954	.8764	.8954	.8383	.8596	.7133	.8507
21	.8573	.8383	.9907	.8764	.9055	.7577	.8779
22	.9526	.9717	1.0098	.9526	.924	.8131	.9055
23	.9717	.9907	.9717	.9526	.8764	.8573	.961
24	.9717	.9335	.9145	.9717	.7621	.8383	.8383
Max	.9717	.9907	1.0098	.9717	.924	.8573	.961
Min	.6089	.5316	.5731	.6097	.394	.4572	.4954
Avg	.8245	.7801	.7818	.7788	.7064	.643	.6900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 401 / 33 kv HLL Stand by NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.829	1.9433	1.829	2.0576	2.1148	1.829
2	2.2862	1.9433	1.9433	1.829	2.0576	2.0576	1.829
3	2.1719	1.829	1.9433	1.829	2.0576	4.9154	1.829
4	2.0576	1.829	1.829	1.829	2.0576	2.0576	1.829
5	2.1719	1.8861	2.0576	1.829	2.0576	2.0005	1.8861
6	2.1719	1.9433	2.1148	1.829	1.829	1.9433	1.9433
7	1.7718	1.7718	1.8861	1.829	1.829	1.829	1.4861
8	1.829	1.7147	2.0576	1.829	2.1719	1.829	1.829
9	1.829	2.0005	2.2862	1.9433	2.0576	1.8861	1.9433
10	2.0576	1.7147	1.8861	2.0576	2.1719	2.1719	1.9433
11	2.1719	2.0576	2.2291	2.0576	2.2862	2.0005	2.0576
12	2.2291	2.0576	2.3434	2.1719	2.1719	2.0005	2.1719
13	1.9433	2.0005	1.9433	1.9433	2.1719	2.0005	2.1719
14	2.0576	2.2291	1.9433	1.9433	2.1719	1.8861	2.1719
15	2.1719	2.0576	1.829	1.9433	2.1719	1.8861	2.1719
16	2.1148	2.1148	1.9433	2.1719	1.9433	1.7718	2.1719
17	2.1148	2.2291	2.0005	2.1719	2.1148	1.829	2.0576
18	1.829	2.0576	2.0576	2.1719	2.0576	1.7718	2.0576
19	1.829	2.2862	2.0576	2.1719	1.9433	1.9433	2.3434
20	2.0005	2.0005	2.0576	2.1719	2.0005	1.9433	2.2291
21	1.9433	1.9433	2.0005	2.1719	1.9433	1.8861	2.2291
22	2.0005	2.0005	2.0005	2.1719	1.9433	1.9433	2.0005
23	1.8861	1.8861	2.0005	2.1719	1.829	1.829	2.0005
24	2.2862	1.9433	2.1148	2.1148	2.0576	1.9433	1.829
Max	2.2862	2.2862	2.3434	2.1719	2.2862	4.9154	2.3434
Min	1.7718	1.7147	1.829	1.829	1.829	1.7718	1.4861
Avg	2.0505	1.9719	2.0195	2.0076	2.0481	2.0600	2.0005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajjanpuri s/s

Feeder No / Name : 201 / 11 kv Ghatpuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7545		.703	.703		
2	.6687	.7545		.6859	.6516	.6859	
3	.6687	.7202	.8383	.6687	.6516	.6859	
4	.6516	.6859		.6687	.6344	.6516	
5	.6516	.6516	.7621	.6344	.6173	.6173	
6	.6001	.583	.7049	.5658	.6001	.5487	
7	.6344	.583	.6287	.5487	.5658	.5144	
8	.5144	.5487	.7049	.5316	.6173	.5487	
9	.5487		.6173	.5487		.583	
10	.5487		.6344	.5487	.5487		
11	.6173		.6516	.6001	.583		
12	.6516	.6859	.6859	.6344	.7202		
13	.6859		.703	.703	.7545		
14	.7545		.7373	.8059	.7545		
15	.7545		.7373	.4973	.7545		
16	.7888	.6478	.7545	.823			
17	.7545		.7202	.7373			
18	.6859		.6859	.583			
19	.7202		.6516	.6344			
20	.7545	.8002	.7373	.7373		.7811	
21	.7545		.8059	.7545			
22	.7888		.8402	.703			
23	.7545	.8764	.8402	.8059		.7621	.8764
24	.7716	.7545	.8383	.7716	.7545	.7202	.7621
Max	.7888	.8764	.8402	.823	.7545	.7811	.8764
Min	.5144	.5487	.6173	.4973	.5487	.5144	.7621
Avg	.6852	.6959	.7276	.6623	.6607	.6454	.8193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajanpuri s/s

Feeder No / Name : 203 / 11 kv Sajanpuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086		.3086	.3429	.3429
2	.3429	.3086		.3086	.3258	.3429
3	.3258	.3086	.3429	.3086	.3258	.3429
4	.3258	.3086		.2915	.3086	.3429
5	.3258	.3086		.2915	.2915	.3086
6	.3086	.2743	.2667	.2743	.2915	.2743
7	.2743	.2743	.3048	.2743	.2743	.2743
8	.3086	.3086	.2667	.2743	.2743	.2743
9	.3258		.2743	.2915		.2743
10	.3429		.2915	.2915	.2743	
11	.3429		.3258	.2915	.2743	
12	.3429	.381	.3429	.3086	.3429	
13	.3429		.3429	.3429	.3429	
14	.3772		.3601	.3258	.3429	
15	.3772		.3601	.3258	.3086	
16	.3429	.381	.3772	.2915		
17	.3429		.3772	.3086		
18	.3772		.3601	.3258		.3429
19	.3429		.3429	.3086		
20	.3429	.381	.3772	.3429		
21	.3429		.3601	.3429		
22	.3429		.3601	.3429		
23	.3086	.3429	.3601	.3429		.3429
24	.3429	.3086	.3429	.3086	.3429	.3429
Max	.3772	.381	.3772	.3429	.3429	.3429
Min	.2743	.2743	.2667	.2743	.2743	.2743
Avg	.3372	.3227	.3368	.3093	.3109	.3172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 201 / 11 kv Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.5242	1.5623	1.0669	1.2193	1.0288	1.448
2	1.1812	1.5623	1.4861	1.0669	1.1812	.9907	1.448
3	1.2003	1.5623	1.2574	1.105	1.1812	1.0288	1.5242
4	1.1812	1.4098	1.2574	1.105	1.1431	.9907	1.5242
5	1.2384	1.2955	1.2955	1.105	1.1431	.9526	1.5242
6	1.2193	1.2193	1.2955	1.2193	.9907	.9526	1.448
7	1.1812	1.1812	1.2955	1.105	1.105	.8002	1.2574
8	1.0479	1.0669	.9717	.9526	1.0288	.9145	1.2574
9	1.1812	1.2955	1.086	1.1431	1.4098	.8764	1.5623
10	1.105	1.2574	1.1128	1.2193	1.4098	1.105	1.448
11	1.2193	1.2574		1.2955	1.3717	1.4861	1.1431
12	1.1812	1.5242	.8764	1.2955	1.6766	1.448	1.2955
13	1.2193	1.6385	1.105	1.4098	1.6385	1.3717	1.2193
14	1.2574	1.5242	1.1812	1.2955	1.6385	1.3336	1.3717
15	1.2955	1.5242	1.0669	1.2193	1.7147	1.3336	1.6004
16	1.1812	1.5242	1.105	1.2574	1.7528	1.5242	1.6385
17	1.1431	1.6004	1.105	1.2193		1.3336	1.5242
18	1.1431	1.5813	1.1431	1.1431		1.3717	1.4861
19	1.0288	1.1812	1.105	1.1812		1.2574	1.3336
20	.9907	1.1431	1.0669	1.0669		1.2574	1.1431
21	1.2574	1.6004	1.105	1.3336	.8002	1.4098	1.4098
22	1.2955	1.448	1.0669	1.3336	1.1431	1.4098	1.3717
23	1.3336	1.4861	1.0288	1.4098	1.1431	1.5242	1.3336
24	1.0669	1.4098	1.5051	1.0669	1.2955	1.105	1.4098
Max	1.3336	1.6385	1.5623	1.4098	1.7528	1.5242	1.6385
Min	.9907	1.0669	.8764	.9526	.8002	.8002	1.1431
Avg	1.1788	1.4091	1.1774	1.1923	1.2993	1.2003	1.4051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 202 / 11 kv Januna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.1254	.3052	.2401	.2401	.1254	.1372
2	.3222	.1433	.3086	.2743	.2229	.1254	.1372
3	.3018	.1433	.2915	.2743	.2229	.1254	.1372
4	.2818	.1254	.2883	.2743	.2401	.1254	.1372
5	.2713	.1612	.3086	.2743	.2401	.1254	.1372
6	.12	.2507	.1865	.2401	.1372	.1075	.12
7	.1187	.2507	.1187	.1372	.12	.1075	.12
8	.116	.1254	.12	.12	.12	.0895	.1372
9	.1029	.1372	.1029		.12	.0857	.1612
10	.1372	.1715	.1372	.1254	.1372	.1543	.1075
11	.1696	.2058		.1254	.1715	.1886	.1612
12	.1696	.2058	.1372	.1612	.1886	.1372	.1612
13	.1791	.1715	.1372	.1791	.1715		.1433
14	.1433	.1715	.1543	.1433	.1372	.1029	.1254
15	.1433	.1372	.1372	.1433	.1372	.1715	.1254
16	.1612	.1543	.1372	.1254	.1886	.1372	.1254
17	.197	.1696	.1372	.1543		.1372	.1372
18	.197	.1715	.1372	.1886	.1433	.1543	.1543
19	.1791	.1526	.2572	.2058	.1433	.1372	.1543
20	.1791	.1543	.1886	.1715	.1433	.1372	.2058
21	.1791	.2713	.1886	.1715	.1791	.1543	.2058
22	.2865	.2543	.1886	.2572	.1433	.1543	.2058
23	.2507	.2743	.1543	.2401	.1433	.1372	.1715
24	.2818	.2328	.2743	.1801	.2572	.1254	.1372
Max	.3222	.2743	.3086	.2743	.2572	.1886	.2058
Min	.1029	.1254	.1029	.12	.12	.0857	.1075
Avg	.1997	.1817	.1912	.1916	.1716	.1324	.1477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 203 / 11 kv Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8775	.8962	.8871	.8962	.8589	.8871
2	.8775	.8775	.8962	.8501	.7888	.8402	.8501
3	.8316	.8775	.9055	.8131	.8573	.8402	.8501
4	.8501	.8589	.8501	.7545	.8573	.8402	.8501
5	.8686	.8215	.8316	.8131	.8589	.7842	.8501
6	.7947	.7282	.6859	.7577	.8002	.6908	.7207
7	.7392	.7282	.7468	.7392	.7655	.6535	.6283
8	.7392	.6908	.7282	.7343	.7095	.6535	.7023
9	.6535	.6283	.7282	.6535	.6653	.6097	.6161
10	.6468	.6099	.6161	.7095	.6653	.5525	.5975
11	.6838	.6653		.7468	.6653	.5601	.6348
12	.6908	.6838	.6838	.7655	.6838	.5975	.5601
13	.6908	.7207	.7207	.7842	.6838	.5788	.6348
14	.7842	.7392	.7392	.8029	.7207	.6348	.7282
15	.7842	.7392	.7762	.8215	.7762	.6348	.8215
16	.8215	.7577	.7762	.8029	.7392	.6344	.8029
17	.8402	.7947	.7762	.8402		.7577	.7468
18	.8215	.7577	.7392	.7282	.7282	.6838	.7095
19	.7468	.7023	.7762	.7282	.7655	.7207	.7655
20	.8402	.8501	.8686	.8764	.8589	.7392	.8402
21	.8775	.8686	.924	.8775	.8215	.7947	.8775
22	.9335	.924	.9795	.9335	.8962	.8316	.8962
23	.9149	.9335	.9425	.9709	.8962	.8871	.9149
24	.8871	.9149	.9055	.9425	.9149	.8589	.8871
Max	.9335	.9335	.9795	.9709	.9149	.8871	.9149
Min	.6468	.6099	.6161	.6535	.6653	.5525	.5601
Avg	.7987	.7813	.8040	.8056	.7832	.7182	.7655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 407 / 33 KV HIVARKHED NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5252	3.2773	2.4714	1.773	1.9342	2.6863	2.1491
2	2.5789	3.1699	2.4177	1.8804	2.1491	2.5252	2.0953
3	2.4714	3.0624	2.364	1.8804	2.2565	2.4177	2.0416
4	2.5252	3.0087	2.4714	2.0416	2.2565	.8059	2.0416
5	2.6326	3.0087	2.6863	2.0953	2.2862	.7522	2.2565
6	3.0624	2.955	3.2773	2.6326	2.7938	1.1283	2.7401
7	3.9758	3.0087	4.4593	3.2236	2.4177	1.0745	3.3848
8	3.6534	2.6326	3.546	2.955	2.2565	1.7193	3.0624
9	4.0832	2.9012	3.3311	2.8475	2.3102	1.7193	3.0087
10	4.2444	2.8475	3.2236	1.9879	2.955	1.4506	2.6326
11	3.8146	2.5252		2.2028	3.1699	2.5789	3.3848
12	3.4385	2.2565	3.4385	2.0953	3.2773	2.5252	3.3311
13	3.3848	2.4177	3.2773	2.0416	3.3311	2.5252	3.3311
14	3.3848	2.1491	3.3311	2.0953	2.364	2.5252	2.3102
15	2.9012	2.7401	2.955	2.7938	3.1699	2.5252	2.5789
16	3.1161	2.9012	2.955	1.7193	3.9758	2.7401	2.6863
17	2.7938	2.7401	2.9012	2.8475	2.1491	2.7401	2.6326
18	3.0087	2.8275	.8596	2.955	2.2565	2.0953	2.7401
19	3.4385	3.5997	2.0416	3.1699	2.7401	2.4177	2.9012
20	3.546	3.8146	3.0624	3.4385	3.2236	2.6326	3.1161
21	3.1161	3.2773	2.5252	3.0624	2.9012	2.5252	2.7401
22	3.4922	2.6326	1.0745	2.7938	2.7938	2.1491	2.7938
23	3.4385	2.5252		2.1491	2.7938	2.364	2.8292
24	2.4714	3.4922	2.4177	1.6655	1.8804	2.7938	2.1491
Max	4.2444	3.8146	4.4593	3.4385	3.9758	2.7938	3.3848
Min	2.4714	2.1491	.8596	1.6655	1.8804	.7522	2.0416
Avg	3.2124	2.9071	2.7767	2.4311	2.6518	2.1424	2.7057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 202 / 11 kv Cotton Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0109
Max	.0109
Min	.0109
Avg	.0109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 204 / 11 kv Polytechnic
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	.0085
Max	.0085
Min	.0085
Avg	.0085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 205 / 11 kv Town- II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0325
Max	.0325
Min	.0325
Avg	.0325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 404 / 33 kv MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.144	5.144	5.2584	5.5441	5.7156	5.6584	5.3155
2	5.144	5.144	5.3727	5.5441	5.7156	5.487	5.2584
3	5.0297	5.0297	5.144	5.5441	5.7156	5.487	5.2584
4	5.0297	5.0297	5.144	5.5441	5.7156	5.3727	5.2584
5	4.9154	5.0297	5.0297	5.5441	5.7156	5.2584	5.2584
6	4.9154	5.144	5.2584	5.6013	5.487	5.2012	5.3155
7	4.6868	4.2295	5.0297	5.3727	5.3155	5.2012	4.7439
8	4.6868		5.144	5.3727	5.7728	5.3727	4.8583
9	5.6013		5.8299	5.9442	5.9442	5.6013	4.8011
10	6.2872	5.7156	5.7156	5.9442	6.4015	6.2872	5.0297
11	6.6301	6.4015	6.4015	5.9442	6.6301	6.23	5.2584
12	6.4015	6.2872	6.4015	6.1728	6.7444	6.5158	5.3727
13	6.1728	6.5158	6.1728	6.5158	6.8587	5.7156	5.3727
14	6.4015	6.5158	6.4015	6.6301	6.973	6.4015	5.2584
15	6.4015	6.4015	5.8299	6.6301	6.8587	6.4015	5.2584
16	6.6301	6.6301	6.5158	6.6301	6.8587	6.1728	5.3727
17	7.1445	6.8016	6.3443	6.6873	4.5725	5.8299	5.0297
18	6.0585	6.4586	6.1728	6.4015	5.3727	5.2584	4.3439
19	6.0585	6.2872	5.9442	6.1728	6.6301	5.487	4.8011
20	5.9442	5.7728	5.7728	6.1728	7.4303	5.0297	4.9154
21	5.8299	5.7156	5.9442	6.0014	7.316	4.9154	5.0297
22	5.8871	6.0014	6.0014	6.0014	4.9154	5.0297	4.9154
23	5.144	5.2584	5.7728	6.2872	5.3727	5.3727	5.0297
24		5.144	5.6013	5.6013	5.7156	5.487	5.3155
Max	7.1445	6.8016	6.5158	6.6873	7.4303	6.5158	5.3727
Min	4.6868	4.2295	5.0297	5.3727	4.5725	4.9154	4.3439
Avg	5.7454	5.7572	5.7585	5.9919	6.0728	5.6156	5.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 407 / 33 kv Chikhali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8234	5.7716	4.9383	3.7346	4.3439	4.6399	4.4136
2	4.9897	5.715	4.9343	3.9043	4.6868	4.4702	4.4702
3	4.8788	5.6584	4.8234	3.9043	4.5153	4.357	4.4136
4	4.8234	5.4321	4.9343	4.0741	4.4582	2.6029	4.4136
5	4.8234	5.0926	4.9897	4.0741	4.2295	2.4897	4.6965
6	4.9343	5.036		4.8663	4.8011	2.7161	5.2058
7	5.8213	5.2058	6.4866	5.3755	4.401	2.4897	5.6019
8	5.3778	4.4702	5.2115	4.8097	4.2867	3.3385	5.2624
9	4.2135	4.9794	5.0452	4.8663	4.5268	3.0293	5.4321
10	5.9877	4.9228	4.5268	4.0741	5.2058	3.2579	4.9228
11	5.7659			4.4702	5.4887	4.8583	5.4321
12	5.3778	4.6965	5.0452	4.4136	5.998	4.8583	5.3755
13	5.4321	4.9228	5.1492	4.357	5.8848	4.7439	5.4321
14	5.5453	4.5268	5.2058	4.3004	4.8663	4.8011	4.5268
15	5.036	5.1492	4.8097	5.0926	5.3755	4.8011	5.2624
16	5.2624	5.4321	4.7531	3.9609	6.8467	5.2584	5.3189
17	4.9228	5.2126	4.6965	5.2012	2.2634	5.036	5.144
18	5.036	4.9897	2.4897	5.2584	3.2819	4.4136	5.2584
19		5.5418	3.678	5.3155	3.7912	4.6399	5.3155
20	5.4887	5.695	4.9228	5.6584	4.357	4.9228	5.487
21	5.3189	5.7065	4.5268	5.4298	4.7531	4.9794	5.4298
22	5.998	5.0452	3.0556	5.4298	5.036	4.4702	5.487
23	5.998	5.0452	1.8673	4.6868	5.036	4.5833	5.5441
24	4.7051	5.998	4.9897	.0504	4.3439	4.9228	4.4702
Max	5.998	5.998	6.4866	5.6584	6.8467	5.2584	5.6019
Min	4.2135	4.4702	1.8673	.0504	2.2634	2.4897	4.4136
Avg	5.2418	5.2281	4.5945	4.4712	4.6991	4.1950	5.0965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 408 / 33 kv Sajjanpuri
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0463	.0617		.036	.036	.0412	
2	.0463	.0617		.036	.036	.0412	
3	.0463	.0617	.0629	.036	.036	.0412	
4	.0463	.0617		.036	.036	.036	
5	.0566	.0617	.0686	.036	.036	.036	
6	.0772	.0617	.0686	.036	.036	.036	
7	.0617	.0617	.0572	.036	.036	.036	
8	.036	.036	.04	.036	.0412	.036	
9	.036		.0412	.036		.0309	
10	.0412		.0463	.0412	.0566		
11	.0309		.0463	.0772	.072		
12	.0412	.0457	.0463	.0772	.0669		
13	.0412		.0463	.072			
14	.0463		.0463	.0669	.0566		
15	.0463		.0463	.0617	.0566		
16	.0412	.04	.0412	.0669			
17	.0412		.0412	.0617			
18	.036		.0412	.036			
19	.0412		.0412	.0412			
20	.0412	.0514	.0463	.0412			
21	.0412		.0412	.0412			
22	.0669		.0412	.0412			
23	.0617	.0686	.0412	.036			.0457
24	.0514	.0617	.0629	.036	.036	.0412	.0343
Max	.0772	.0686	.0686	.0772	.072	.0412	.0457
Min	.0309	.036	.04	.036	.036	.0309	.0343
Avg	.0467	.0566	.0483	.0467	.0456	.0376	.04

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	02-JUN-18
HR	Load (MW)	Load (MW)
10	.0191	
11	.0191	.0191
12	.0191	.0191
13	.0191	.0191
14	.0191	.0191
15	.0191	.0191
16	.0191	.0191
17	.0191	.0191
18		.0191
19		.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 201 / 11KV Lonar Water Supply SHEDDABLE URBAN
Feeder Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	.9717	.9145	.9907	.8573	.7621	.8002
2	1.0288	.9717	.8764	.9526	.8383	.7621	.8002
3	1.0288	.9907	.8383	.9145	.8192	.8002	.7621
4	1.0098	1.0098	.8002	.8954	.8764	.8002	.7621
5	.9907	1.0098	.8764	.9145	.8954	.8192	.8383
6	1.0098	.9907	.9145	.9526	.9335	.8383	.8573
7	1.0098	.9335	.9526	.9907	.9145	.8573	.8954
8	1.0288	.9907	.9907	.9526	.8954	.8573	.8764
9	1.0098	1.0098	.9907	.9526	.8383	.9145	.8764
10	1.0098	.9526	.9526	1.0288	.8192	.8383	.8954
11	1.0098	.9526	.9145	1.1241	.8954	.8954	.8954
12	.9907	.9526	.8764	1.0479	.8954	.8573	.8573
13	.9526	.9335	.9145	.9526		.8002	.8383
14	.9145	.9335	.9526	.9717		.7621	.8192
15	.9335	.9335	.9907	.9145	.9526	.6859	.8192
16		.9907	1.0288		.8383	.8002	.8383
17	1.0669	1.0288	1.0669		.7621	.8764	.8764
18	1.0669	1.105	1.105		.7621	.9145	.9526
19	1.105	1.105	1.1812	1.0288	.8192	.8192	.9717
20	1.1812	1.0288	1.1812	1.0479	.9717	.8383	.9526
21	1.086	1.0669	1.1431	1.0098	.8954	.8383	.9335
22	1.0479	1.0288	1.0669	.9717	.8573	.8192	.9335
23	.9717	.9907	1.0669	.9526	.8002	.8192	.9145
24	1.0098	.9907	.9526	1.0288	.9145	.7621	.8002
Max	1.1812	1.105	1.1812	1.1241	.9717	.9145	.9717
Min	.9145	.9335	.8002	.8954	.7621	.6859	.7621
Avg	1.0205	.9947	.9812	.9807	.8660	.8224	.8653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 202 / 11KV Shara AG Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6478	
8	1.3717	1.2003				.5716
9	1.3146	1.3146				.9907
10	1.3336	1.2955				1.0098
11	1.2003	1.2765				1.0098
12	1.2955	1.2574				1.0288
13	1.2193	1.2193				.9907
14	1.1431	1.2193				.9526
15	1.1431					.8954
16				.0191	.7811	
17			1.3336		.7621	
18			1.3717	.9526	.743	
19			1.4098	1.0288	.6859	
20			1.3336	.8573	.6097	
21			1.2955	.8192	.5716	
22			1.2574	.7621	.5335	
23		1.2193	1.105	.724	.4954	
24			1.2193		.6668	
Max	1.3717	1.3146	1.4098	1.0288	.7811	1.0288
Min	1.1431	1.2003	1.105	.0191	.4954	.5716
Avg	1.2527	1.2503	1.2907	.7376	.6497	.9312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 203 / 11 KV Hirdav AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0191	.0191	
9				.0191	.0191	
10				.0191	.0191	
11				.0191	.0191	
12			.0191	.0191	.0191	
13			.0191		.0191	
14			.0191		.0191	
15			.0191		.0191	
16						.0191
17	.0191	.0191				.0381
18	.0191	.0191				.0191
19	.0191					.0191
20	.0191					.0191
21	.0191					.0191
22	.0191					.0191
23	.0191					.0191
Max	.0191	.0191	.0191	.0191	.0191	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 204 / 11Kv Shara GFSS Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4572	.4572	.381	.4382	.4191
2	.4763	.4763	.4954	.4763	.3429	.4191	.4191
3	.5335	.5144	.5335	.4954	.3429	.4191	.4763
4	.724	.6668	.5335		.362	.5716	.6668
5	.9145	.8954	.6097	.6097	.4954	.8573	.8573
6	1.105	.9717	.724	.7621	.8573	1.0288	1.0288
7					.6668		
10	.5716	.6097	.5716	.4954	.5335	.4382	.4572
11	.4382	.4191	.5335	.4382	.4191		.3048
12	.4191	.4382	.4572	.4191	.4001	.3239	.3239
13	.4191	.4382	.4191	.4572		.3239	.3429
14	.4382	.4572		.4572		.3429	.3429
15	.4572	.4763		.4954		.3429	.362
16		.5335	.5716	.4954	.5335	.4763	.362
17	.5335	.6097	.6097			.5335	.4191
18	.6478	.724	.6097		.5716	.5906	.5716
19	.7621	.724	.6478	.6859	.6287	.6287	.724
20	.8002	.7049	.6478	.6478	.5906	.5716	.6668
21	.6097	.6097	.6097	.6668	.5335	.5335	.5906
22	.5716	.5716	.5716	.5716	.4954	.4763	.5716
23	.4954	.5335	.5335	.4382	.4763	.4382	.4191
24	.4954	.4954	.4572	.4572	.4191	.4382	.4191
Max	1.105	.9717	.724	.7621	.8573	1.0288	1.0288
Min	.4191	.4191	.4191	.4191	.3429	.3239	.3048
Avg	.5944	.5879	.5575	.5292	.5028	.5096	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 205 / 11 kv Pangra AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4382	.4191	.4572	.3048	
9			.4382	.4191	.4191	.3048	
10			.4191	.4191	.381	.3429	
11			.4191	.4382	.3429	.381	
12			.4191	.4191		.381	
13			.4191	.4191		.3429	
14			.4191	.4382		.362	
15			.4191	.4572		.3429	
16		.4763					
17	.381	.4572					
18	.4191	.4382					
19	.3429	.4191					.381
20	.2858	.4191					.362
21	.2667	.4001					.3429
22	.2667	.381					.2858
23	.2667	.381					.2858
Max	.4191	.4763	.4382	.4572	.4572	.381	.381
Min	.2667	.381	.4191	.4191	.3429	.3048	.2858
Avg	.3184	.4215	.4239	.4286	.4001	.3453	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 206 / 11 kv Lonar Bus Stand

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2003	1.105	1.0669	1.105	.9717	.9526
2	1.2193	1.2003	1.0669	1.0288	1.0479	.9526	.9907
3	1.2193	1.1812	1.0288	1.0288	1.0479	.9907	.9907
4	1.1812	1.2003	1.0669	1.0669	1.0669	1.0288	1.0479
5	1.2003	1.2193	1.105	1.105	1.105	1.0479	1.0669
6	1.2003	1.2384	1.1431	1.1431	1.2765	1.086	1.105
7	1.2574	1.2384	1.1812	1.2193	1.2765	1.1812	1.105
8	1.2574	1.2574	1.2193	1.1812	1.3336	1.1622	1.086
9	1.2955	1.2384	1.2193	1.1431	1.2955	1.1812	1.0669
10	1.2955	1.3336	1.1431	1.1812	1.2955	1.105	1.086
11	1.2574	1.3336	1.105	1.2193	1.1812	.9526	1.086
12	1.2003	1.3336	1.0669	1.2384	1.2955	1.0669	1.0669
13	1.2193	1.3146	1.105	1.2765		1.1431	1.0669
14	1.2955	1.3146	1.1431	1.2955		1.1812	1.086
15	1.2765	1.3146	1.2193	1.3146	1.3527	1.2003	1.105
16		1.3336	1.2574		1.2384	1.2384	1.1431
17			1.3336		1.0479	1.2955	1.1812
18	1.5432	1.4289	1.3717		1.1431	1.3146	1.3336
19	1.5432	1.3336	1.3336	1.448	1.2193	1.2574	1.3146
20	1.5242	1.3336	1.3336	1.3717	1.2384	1.1812	1.2003
21	1.467	1.2955	1.2955	1.3146	1.105	1.105	1.1431
22	1.3336	1.2574	1.2193	1.2384	1.0669	1.0479	1.105
23	1.2574	1.2574	1.1431	1.1622	1.0288		1.0479
24	1.2384	1.2193	1.105	1.105	1.1431	.9907	.9526
Max	1.5432	1.4289	1.3717	1.448	1.3527	1.3146	1.3336
Min	1.1812	1.1812	1.0288	1.0288	1.0288	.9526	.9526
Avg	1.2964	1.2773	1.1796	1.1975	1.1778	1.1166	1.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 201 / BIBI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.583	.583	.583	.6001		.5144
2	.5144	.583	.583	.583	.6001		.5144
3	.5144	.583	.583	.583	.6001		.5144
4	.5144	.6859	.6859		.6173		.5144
5	.6859	.7545	.7545		.6859		.6859
6	1.0288	.8573	.8916		1.0288		.7545
7	1.0288	.9602	1.0288		1.0631		.7202
8	.9602	.9259	.9602		.9602		
9	.8573	.7545	.7716	1.0288	.8573		.6859
10	.6859	.823	.6516	.6859	.7202		.5144
11	.583	.583	.6173	.5144			.463
12	.5487	.5487	.5487		.5487		.4115
13	.5144	.5144	.5144				.4115
14	.5144	.5487	.4801				.3601
15	.5487	.583	.583				
16	.5487	.6173	.583				.4287
17	.6859	.6516	.7545				
18	.7888	.823	1.0288				
19	1.0974	.8916	1.0288	.9431			
20	1.0288	.9602	.8573	.9431		.7202	1.0288
21	.7888	.7202	.6859	.7716		.583	.583
22	.6859	.6859	.5144	.6859		.5144	.583
23		.6173		.6859		.5144	
24	.5144	.583	.6173	.583	.6001		.5144
Max	1.0974	.9602	1.0288	1.0288	1.0631	.7202	1.0288
Min	.5144	.5144	.4801	.5144	.5487	.5144	.3601
Avg	.7023	.7016	.7090	.7159	.7402	.583	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 202 / 11 KV MALKAPUR PANGRA

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0171		
2		.0171	.0171	.0171		
3	.0171	.0171	.0171	.0171	.0171	
4		.0171	.0171	.0171		
5		.0171	.0171	.0171		
6	.0171	.0171	.0171	.0171	.0171	
7				.0171		
10	.2743	.1715		.1715		
11	.2743	.1715	.2058	.1715		
12	.2743	.1886	.2401			
13	.1715	.2229	.1886			
14	.1715	.1715	.1543			
15		.1543	.2229			
16	.1715	.1543	.2401			
17	.1715	.12	.2229			
19	.1715					
20	.0171	.0171	.0171	.0171		.0171
21		.0171	.0171	.0171		.0171
22	.0171	.0171	.0171	.0171		.0171
23		.0171	.0171	.4287		
24	.0171	.0171	.0171	.3773	.0171	
Max	.2743	.2229	.2401	.4287	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.1358	.0812	.0924	.0943	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 203 / 11 KV ANJANI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
10		.2058
23	.2401	
24	.4972	
Max	.4972	.2058
Min	.2401	.2058
Avg	.3687	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 204 / 11 kv Anjani GFSS feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5487	.5487	.5487	.5144
2	.5144	.5144	.5144	.5487	.5487	.5487	.5144
3	.5144	.5144	.5144	.5487	.5487	.5487	.5144
4	.6001	.583	.583	.5487	.6001	.6859	.583
5	.7716	.6859	.7202	.5487	.8573	.7888	.8916
6	1.0288	1.0974	1.166	1.0288		1.2346	1.3375
7	1.0288	.9259		1.0631	1.1145	1.166	1.1317
8	.9431	.9945	.823	.8573	1.0288	.9259	
9	.7202	.7545	.7545	.7716		1.0288	.5144
10		.5144	.6173	.5658	.6859	.583	
11	.4801	.4458	.4801	.4801		.5487	.463
12	.4458	.4801	.4458		.4458		.4458
13	.4115	.5487	.4801				.4458
14	.4458	.4801	.4801				.3429
15		.5144	.5144				.4287
16	.5487	.583	.583			.7202	.5144
17	.6173	.6859	.7888			.9259	.463
18	.8916	.8916	1.0288		.6173	.8916	
19	1.0631	1.0288	1.0288	.9431		1.0288	
20	1.0288	.9602	.8573	.8573	.8916	.8916	
21	.7202	.7202	.6859	.7888	.7202	.7202	.6859
22	.6173	.6173	.5658	.6001	.6516	1.3032	.6344
23		.583		.6001		.583	
24	.5144	.5144	.5144	.7887	.5487	.5487	.5144
Max	1.0631	1.0974	1.166	1.0631	1.1145	1.3032	1.3375
Min	.4115	.4458	.4458	.4801	.4458	.5487	.3429
Avg	.6867	.6730	.6664	.7111	.7006	.8111	.6078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551]

BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 205 / 11 kv M.Pangra GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.703	.1029	.2743	.0514	.0686	.1029
2	.12	.1372	.1029	.1029	.0514	.0686	.1029
3	.12	.1372	.1029	.1029	.0514	.0686	.1029
4	.1543	.2058	.1029	.1029	.0514	.0686	.1029
5	.2058	.3086	.3086	.1029	.0514	.0686	.1029
6	.4287	.4115	.3772	.3429	.0857	.0686	.2743
7	.4287	.4458	.3772	.4115	.0857	.0686	.2743
8	.4287	.3772	.3429	.3944		.0686	
9	.3086	.3086	.3429	.3086		.0686	.1715
10	.1715	.1715	.3086	.2058		.0686	.1029
11	.1372	.1029	.1372	.1715		.0686	.1029
12	.1029	.1029	.1372				.1029
13	.1029	.1029	.1029				.1029
14	.1029	.1372	.1372				.1372
15	.1372	.1372	.1372				.1715
16	.1372	.1372	.1715				.2058
17	.1715	.2401	.2743				
18	.2743	.3429	.3429		.0686		
19	.3429	.3429	.3772	.0686	.0686	.1029	
20	.3086	.3429	.3429	.0514	.0686	.1715	.2058
21	.1715	.2058	.1715	.0514	.0686	.2743	.1886
22	.1715	.1715	.1543	.0514	.0686	.1372	.1715
23		.1372	.1715	.0514		.1029	
24	.12	.1372	.1029	.1543	.0514	.0686	.1029
Max	.4287	.703	.3772	.4115	.0857	.2743	.2743
Min	.1029	.1029	.1029	.0514	.0514	.0686	.1029
Avg	.2073	.2436	.2179	.1735	.0633	.0948	.1489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 206 / 11 KV BIBI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171		
2	.0171	.0171	.0171	.0171	.0171	
3	.0171	.0171	.0171	.0171		
4	.0171	.0171	.0171	.0171		
5	.0171	.0171	.0171	.0171	.0171	
6	.0171	.0171	.0171	.0171	.0171	
7				.0171		
10	.1715	.1715	.1886	.2572	.1372	
11	.1715	.1715	.2058	.2058		
12	.1543	.2058	.1886		.1543	
13	.2058	.12	.12			
14	.1372	.1543	.1543			
15	.1029	.12	.1715			
16	.1715	.1543	.1886			
17		.12	.1715			
20	.0171	.0171	.0171	.0171		
21	.0171	.0171	.0171	.0171		.0686
22	.0171	.0171	.0171	.0171		.0171
23		.0171		.0171		
24	.0171	.0171	.0171	.0171	.0171	
Max	.2058	.2058	.2058	.2572	.1543	.0686
Min	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0756	.0740	.0867	.0477	.0600	.0429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187			.0187	.0187
2		.0187			.0187	.0187
3		.0187			.0187	.0187
4		.0187			.0187	.0187
5		.0187			.0187	.0187
6		.0187			.0187	.0187
7		.0187				.0187
8		.0187			.0189	.0187
9	.0187	.0187	.0187	.0187	.0187	
10	.0187		.0187	.0187	.0187	
11	.0187		.0187	.0187	.0187	
12	.0187		.0187	.0187	.0187	
13	.0187		.0187	.0187	.0187	
14	.0187		.0187	.0187	.0187	
15	.0187		.0187	.0187	.0187	
16	.0187		.0187	.0187	.0187	
17	.0187		.0187	.0187	.0187	
18	.0187		.0187	.0187	.0187	
19	.0187		.0187	.0187	.0187	
20	.0187		.0187	.0187	.0187	
21	.0187		.0187	.0187	.0187	
22	.0187		.0187	.0187	.0187	
23	.0187			.0187	.0187	
24		.0187			.0187	.0187
Max	.0187	.0187	.0187	.0187	.0189	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 201 / 11 KV PANGRA TITVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0187				.0187
2	.0343	.0187				.0187
3	.0343	.0187				.0187
4	.0343	.0187				.0187
5	.0343	.0187				
6	.0171	.0373				
7			.0343			
8			.0514			
9			.056			
10			.0373			
11			.0373	.0187		
12			.0373	.0187		
13			.056	.0187		
14			.0373	.0187		
15		.12				
16		.0857				
17		.0514				
18		.0343				
19		.0343				
20		.0343				
21		.0343				
22		.0343				
23	.0187				.0187	.0171
24	.0171	.0187				.0187
Max	.0343	.12	.056	.0187	.0187	.0187
Min	.0171	.0187	.0343	.0187	.0187	.0171
Avg	.0259	.0385	.0434	.0187	.0187	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 202 / 11 KV DHAD GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3921	.3258		.2987	.3174
2	.3429	.4108	.3429		.3206	.3547
3	.3601	.4854	.3429		.3361	
4	.4287	.5228	.4115		.3734	
5	.4801	.5601	.4458		.4108	
6	.5144	.6722	.4458		.4481	
10		.4801	.5228	.112	.2241	.2743
11		.3772	.4854	.112	.2987	.2572
12	.4481	.3429	.4481	.112	.2241	.2572
13	.4108	.3258	.4481	.112	.2241	.1886
14	.3734	.2915	.4481		.2801	.1715
15	.3921	.3429	.4668	.3361	.2427	.1886
16	.4108	.2858	.5041	.3547	.3174	.1715
17	.4854	.5144	.5415	.3734	.3547	.2572
18	.5415	.6344	.6348	.3921	.4481	.463
19	.6348	.6859	.6722	.3921	.4481	.5144
20	.5601	.6001		.3734	.5041	.4801
21	.4668	.5144		.3361	.4481	.4458
22	.3921	.4115	.4481	.2987	.4108	.1886
23	.3734	.3429		.3584	.3547	.1715
24	.3258	.3921	.3258		.2987	.2987
Max	.6348	.6859	.6722	.3921	.5041	.5144
Min	.3258	.2858	.3258	.112	.2241	.1715
Avg	.4360	.4564	.4589	.2818	.3460	.2941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 203 / 11 KV PANGRA GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1867	.1715		.1715	.168	.1307
2	.1715	.1867	.1715		.1886	.1867	.1494
3	.2058	.1867	.1886		.2058	.2054	.168
4	.2401	.2241	.1886		.2401	.2427	.168
5	.2915	.2614	.2058		.2743	.2614	.1867
6	.3086	.2987	.2058		.2743	.2987	.2054
10	.1867	.1543	.1867		.1867	.1494	.1715
11	.1867	.1886	.168		.168	.1867	.1372
12	.168	.1715	.168		.168	.112	.1372
13	.1867	.1715	.1494		.1494	.112	.12
14	.1867	.1715	.1494		.1867	.1307	.12
15	.168	.1543	.1494		.168	.1494	.12
16	.1494	.1715	.168		.168	.1494	.12
17	.1867	.2058	.1867	.2401	.168	.168	.1372
18	.2241	.2229	.2241	.2401	.1867	.2241	.1715
19	.2614	.2572	.2614	.2229	.2241	.2614	.2401
20	.2427	.2058	.2241	.2743	.1867	.1867	.2058
21	.2054	.2058	.1867	.2058	.1867	.1494	.1886
22	.168	.2058	.1867		.1867	.1494	.1543
23	.168	.1886		.1715	.1698	.1494	.1543
24	.1372	.168	.1715		.1715	.1494	.1307
Max	.3086	.2987	.2614	.2743	.2743	.2987	.2401
Min	.1372	.1543	.1494	.1715	.1494	.112	.12
Avg	.1991	.1994	.1856	.2258	.1919	.1805	.1579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 204 / 11 KV DHAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058		
2			.1886		
3			.2058		
4			.2058		
5			.2229		
6			.2229		
7	.2058				
8	.2058				
9	.2427				
10	.2427				
11	.2427			.0187	
12	.2427			.0187	
13	.2427			.0187	
14	.2241			.0187	
15					.0171
16					.0171
17					.0171
19					.0171
23		.2229			
24			.2229		
Max	.2427	.2229	.2229	.0187	.0171
Min	.2058	.2229	.1886	.0187	.0171
Avg	.2312	.2229	.2107	.0187	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 205 / 11 KV GOTHRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.168	
7		.168				.1867
8		.168				.2054
9		.1543				.1886
10		.1543				.1543
11		.1543				.2058
12						.1715
13		.1543				.1715
14		.1372				.1715
15	.1867		.1867			
16	.1867		.1867		.1867	
17	.2054		.168		.1867	
18			.168		.1867	
19			.168		.2054	
20	.168		.1886		.2054	
21	.168				.2054	
22	.168				.1867	
23				.1867		
24					.1867	
Max	.2054	.168	.1886	.1867	.2054	.2058
Min	.168	.1372	.168	.1867	.168	.1543
Avg	.1805	.1558	.1777	.1867	.1909	.1819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 206 / 11 KV GOTHRA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1867	.1543		.1715	.168	.168
2	.1543	.1867	.1715		.1886	.1867	.1867
3	.2058	.1867	.2229		.2401	.2054	.2241
4	.2229	.2054	.2572		.2915	.2427	.2801
5	.3086	.2241	.2915		.3258	.2614	.3361
6	.3086	.2614	.3086		.3429	.2987	.3921
10	.1867	.1886	.1867		.168	.1867	.1372
11	.168	.1543	.1494		.168	.1494	.1372
12	.1494	.1372	.1307		.168	.1307	.0686
13	.1307	.1372	.1307		.1494	.1494	.0857
14	.1307	.1543	.1494		.2054	.168	.0857
15	.1494	.1372	.168		.2054	.168	.1029
16	.1494	.1372	.1867		.2427	.168	.1029
17	.2054	.1372	.2241		.2241	.1867	.12
18	.2241	.1886	.2241		.2614	.2614	.12
19	.2801	.2401	.2427		.2987	.2801	.2401
20	.2614	.2229	.2241	.2743	.2614	.2614	.2572
21	.2241	.2229	.2054	.2572	.2241		.2229
22	.2054	.1715	.168		.2054	.2054	.2058
23	.1867	.1543		.2572	.1867	.168	
24	.1372	.1867	.1372		.1715	.168	.1494
Max	.3086	.2614	.3086	.2743	.3429	.2987	.3921
Min	.1307	.1372	.1307	.2572	.1494	.1307	.0686
Avg	.1965	.1820	.1967	.2629	.2238	.2007	.1811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 200 / Station Transformer
Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17				.0171	
18				.0171	
19				.0171	
20				.0171	
21				.0171	
23				.0171	
24	.0191	.0191	.0171		.0171
Max	.0191	.0191	.0171	.0171	.0171
Min	.0191	.0191	.0171	.0171	.0171
Avg	.0191	.0191	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 201 / 11 KV Chincholi AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0762	.0543			.0914	.0686
2	.0701	.0762	.0724			.0914	.0514
3	.0724	.0762	.0543			.1097	.0514
4						.1097	
5						.1267	
6						.1905	
7						.1543	
8				.5144	.0343	.2058	
9				.4954		.2058	
10		.4525				.2401	.2858
11	.3429	.4163				.3086	.2667
12	.381	.4207				.3258	.2477
13	.3048	.3982				.2743	.2096
14	.2858					.2401	.2096
15	.2667	.4163				.2229	.2477
16	.3048	.362					.2667
17	.362	.362				.2058	.3239
18	.0762	.0754	.0762		.0724	.0343	.0572
19	.0762	.0724	.0762	.0686	.5792	.0343	.0762
20	.0762	.0724	.0762	.0686	.0724	.0343	.0762
21	.0762	.0762	.0762	.0686	.0724	.0514	.0762
22	.0762	.0543	.0762		.0724	.0514	
23	.0762	.0724	.0762		.0724	.0514	.0762
24	.0724	.0762	.0543	.12		.0914	.0514
Max	.381	.4525	.0762	.5144	.5792	.3258	.3239
Min	.0701	.0543	.0543	.0686	.0343	.0343	.0514
Avg	.1760	.2092	.0693	.2226	.1394	.1501	.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 202 / 11 KV RAJEGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.2096	.2534			.3429
2	.1578	.2096	.2378			.3429
3	.181	.2286	.2561			.3429
4	.1753	.2667	.2715			.3601
5	.1457	.3048	.2829			.4115
6	.1578	.3429	.3258			.4115
7	.2715	.4001				.4572
8	.3292	.4191	.4024			.4763
9	.3982	.4572	.4706			.4954
10			.4191	.1905	.3429	
11			.4382		.3439	
12			.4572	.2401	.3258	
13			.4382	.3429	.362	
14			.381	.3772	.181	
15				.3429	.0905	
16			.2286		.0724	
17			.2667		.0724	
24	.1267	.2286	.1267			.3772
Max	.3982	.4572	.4706	.3772	.362	.4954
Min	.1267	.2096	.1267	.1905	.0724	.3429
Avg	.2088	.3067	.3285	.2987	.2239	.4018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 203 / 11 KV WENI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2401		
2				.2401		
3				.2401		
5				.3772		
6				.3772		
7				.4115		
8			.2667	.4458		
9			.3048	.4458		
10	.439	.3439			.2058	.3239
11	.4763	.362			.2058	.362
12	.4954	.3801			.2401	.362
13	.4191	.362			.2401	.3429
14	.4001	.4191				.362
15	.381	.362			.2572	.3429
16	.4191	.362			.3772	.3429
17	.4572	.3982			.1715	.381
24				.2572		
Max	.4954	.4191	.3048	.4458	.3772	.381
Min	.381	.3439	.2667	.2401	.1715	.3239
Avg	.4359	.3737	.2858	.3372	.2425	.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551]

BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 204 / 11kv ChincholiBore GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7421	.8192	.8192	.8192	.6859	.7621	.6859
2	.7602	.8383	.7783	.8383	.7202	.7811	.7545
3	.8002	.8573	.8383	.8573	.7545	.7621	.7545
4	.8383	.9907	.9145	.9145		.8383	.8916
5	1.1812	1.2955	1.105	1.0669	.9431	1.1812	1.0631
6	1.3717	1.4861	1.3717	1.3717	1.2689	1.4861	1.448
7	1.3336	1.5432		1.5051	1.3032	1.406	1.5432
8	1.1812	1.2574	1.2955	1.2955	1.0631	1.166	1.3717
9	.9907	1.105	1.0288	1.105	.9259	1.0117	1.1241
10	.9145	.9145	.8192	.9145	.8916		.9907
11	.743	.8002	.724		.8002	.7888	.8764
12	.6859	.7621	.6859	.823	.724	.6859	.724
13	.6478	.7421	.6668	.7545	.7621	.7545	.6859
14	.6478	.7621	.6478	.9259	.7621		.6478
15	.6668	.8002	.6859	.7888	.724	.7545	.6478
16	.6859	.8002	.724		1.0669	.823	.6859
17	.8383	.8192	.8002		1.0669	.9259	.8002
18	1.105	1.1431	1.0288		1.1812	1.0631	1.0669
19	1.2003	1.4098	1.1812		1.3717		1.1812
20	1.0669	.8764	1.0479	1.0631	.8413	1.1317	1.1241
21	.9717	.8002	.9907		.724	.9259	.9907
22	.9145	.8383	.9145	.7545	.7733	.8916	.9335
23	.8573	.8192	.8573		.7621	.7888	.8573
24	.724	.8383	.8002	.8192	.6859	.7421	.7545
Max	1.3717	1.5432	1.3717	1.5051	1.3717	1.4861	1.5432
Min	.6478	.7421	.6478	.7545	.6859	.6859	.6478
Avg	.9112	.9716	.9011	.9775	.9044	.9367	.9418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 205 / 11 kv Rajegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.2401
3				.2743
4				.3429
5				.583
7				.6859
16			.2572	
17			.3601	
24	.1905	.2572		.2572
Max	.1905	.2572	.3601	.6859
Min	.1905	.2572	.2572	.2401
Avg	.1905	.2572	.3087	.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 206 / 11 kv Weni GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.4763	.3772	.4954		.4191	.3086
2	.381	.4954	.4191	.4763		.4001	.3429
3	.4001	.5144	.4382	.4954		.4191	.4458
4	.4191	.5335	.4572	.5335		.4572	.4458
5	.5335	.724	.5716	.6859		.724	.7545
6	.7621	.9335		.8383		.8192	.9602
7	.724	.8573		.8573		.6516	1.0288
8	.5716	.8192	.7621	.6859		.6516	.9526
9	.4763	.6859	.6859	.6668		.6344	.7811
10	.4191	.5335	.381	.5716		.4458	.5144
11	.4572	.4382	.4954			.3772	.4191
12	.4382	.4191	.5144	.4458		.3429	.4191
13	.4382	.4001	.4954	.3772		.4115	.4001
14	.4572	.4191	.4954	.4115		.4115	.4572
15	.4954	.4001	.5335	.4115		.4115	.4763
16	.5335	.4191	.5525			.4801	.4954
17	.5525	.4382	.6478			.4801	.5716
18	.6668	.5335				.583	.6668
19	.9335	.6859	.8002	.6173	.4954	.7202	.8192
20	.8383	.4763	.7811	.6173	.4191	.6173	.8573
21	.6859	.4191	.6097		.4191	.5144	.7621
22	.6097	.4191	.5335		.4001		.6097
23	.5335	.4191	.4954		.4001	.4801	.5335
24	.4001	.4954	.4382	.4572		.3658	.4458
Max	.9335	.9335	.8002	.8573	.4954	.8192	1.0288
Min	.3439	.4001	.3772	.3772	.4001	.3429	.3086
Avg	.5446	.5398	.5469	.5673	.4268	.5138	.6028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 207 / 11 KV DAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0572	.0549		
2	.0543	.0572	.0543		
3	.0762	.0572	.0724		
4	.0762	.0762	.0543		
5	.0762	.0762	.0543		
6	.0724	.0762	.0724		
7	.0543	.1524			
8	.0549	.1334	.0724		
9	.0572	.1143	.0914		
10			.0762	.0953	.0514
11			.0572		.0183
12			.0572	.0686	.0181
13			.0572	.1029	.0183
14			.0572	.0514	.0191
15			.0572	.0514	
16			.0762		
17			.0953		
24	.0543	.0762	.0549		
Max	.0762	.1524	.0953	.1029	.0514
Min	.0543	.0572	.0543	.0514	.0181
Avg	.0648	.0877	.0656	.0739	.0250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 208 / 11 KV BORKHEDI DHARAN NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0171
2				.0171
3				.0171
4				.0171
5				.0171
6				.0171
7			.0171	.0191
8			.0171	.0191
9			.0171	.0191
10			.0171	.0191
11			.0171	.0191
12		.0171	.0171	
13			.0171	
14		.0171	.0171	
15			.0171	
17			.0171	
18	.0191		.0171	
19		.0171	.0171	
20			.0171	
21			.0171	
22			.0171	
23			.0171	
24				.0171
Max	.0191	.0171	.0171	.0191
Min	.0191	.0171	.0171	.0171
Avg	.0191	.0171	.0171	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 201 / 11 kv Gaikhed AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.1715	.1524	.1334
Max	.1715	.1524	.1334
Min	.1715	.1524	.1334
Avg	.1715	.1524	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 202 / 11 Kv Gundha Gfss Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1905	.2096	.2096	.1715	.1524	.1905
Max	.1905	.2096	.2096	.1715	.1524	.1905
Min	.1905	.2096	.2096	.1715	.1524	.1905
Avg	.1905	.2096	.2096	.1715	.1524	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 203 / 11 kv Wadhav AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.1334	.1334	.1715
Max	.1334	.1334	.1715
Min	.1334	.1334	.1715
Avg	.1334	.1334	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 205 / 11 KV GAYKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6097	.5906	.6097	.5144	.5335	.5716
Max	.6097	.5906	.6097	.5144	.5335	.5716
Min	.6097	.5906	.6097	.5144	.5335	.5716
Avg	.6097	.5906	.6097	.5144	.5335	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 206 / 11 KV DABHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381	.1143	.0381	
2			.0381	.0762	.0381	
3			.0381	.0762	.0381	
4			.0381	.1143	.0381	
5			.0381	.1143	.0381	
6			.0381	.1524	.0381	
7			.0762	.1524	.0762	
8	.1715	.2286				.0762
9	.1524					.0762
10	.1524					.1143
11	.1143					.1334
12	.1334					.0953
13	.1143					.1143
14	.1143					.1143
15	.1334					.0762
16					.0953	
17					.1524	
18					.1905	
19					.1905	
20					.1524	
21					.1143	
22					.0762	
23					.0762	
24			.0381	.1143	.0381	
Max	.1715	.2286	.0762	.1524	.1905	.1334
Min	.1143	.2286	.0381	.0762	.0381	.0762
Avg	.1358	.2286	.0429	.1143	.0869	.1000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 201 / 11 KV Kingaon Jattu Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.2667	.1524	.1715	.1334	.1334
2	.1715	.1334	.2667	.1905	.1524	.1334	.1334
3	.1715	.1334	.2667	.1715	.1334	.1334	.1334
4	.1905	.1334	.2667	.2477	.1524	.1334	.1524
5	.2286	.1524	.2858	.2096	.1905	.1905	.1905
6	.2667	.1715	.1715	.1905	.2858	.2096	.2096
10	.4382	.1715	.5525	.4763	.1715	.2286	.2286
11	.381	.1524	.2858	.4572	.1715	.4191	.3048
12	.1715	.1524	.3429	.4001	.4001	.4382	.1334
13	.1905	.1524	.2667		.2858	.4001	.1905
14	.4763	.1334	.4191			.4001	.2667
15	.2858	.1334	.2667		.2096	.3048	.362
16	.3429	.1524	.2477			.2858	.2477
17	.4191	.1524	.4572			.2477	.3429
18	.362	.1524	.4763			.2477	.3429
19	.3239	.1715	.2477		.1715	.3048	.4001
20	.381	.2096	.4382	.2286	.1715	.2667	.2667
21	.381	.1905	.2858	.2477	.1524	.2477	.3048
22	.381	.1715	.1905	.2286	.1524	.1524	.3429
23	.1334	.2477	.1905	.1905	.1524	.1524	.1905
24	.1715	.1334	.1715	.1715	.1905	.1524	.1524
Max	.4763	.2477	.5525	.4763	.4001	.4382	.4001
Min	.1334	.1334	.1715	.1524	.1334	.1334	.1334
Avg	.2867	.1588	.3030	.2545	.1950	.2468	.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 202 / 11 kv Bhumrala feeder

SHEDDABLE RURAL

(Mix) Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2286	.2858	.2286		.1905	.1905
2	.3048	.2286	.2858	.1905		.1905	.1905
3	.3429	.2286	.2858	.2286		.1905	.1905
4	.3239	.2286	.3239	.2667		.1905	.2286
5	.4572	.381	.4001	.3048		.1905	.3429
6	.5335	.4191	.4763	.3239		.4763	.381
10		.4191		.4382		.2858	
11		.381		.381		.3239	
12		.362		.381		.3429	
13		.3429				.2667	
14		.3239				.3048	.3048
15	.2858		.381				.3048
16	.4763		.4001				.3429
17	.4763		.4763				.381
18	.4382		.4382				.4382
19	.5144	.4572	.4763		.4191	.4763	.5144
20	.4001	.4382	.4191	.1524	.362	.4001	.4572
21	.3429	.381	.362	.1905	.2858	.3429	.381
22	.3239	.3239	.3048		.2667	.2858	.3429
23	.3048	.3048	.2667		.2286	.2286	.2286
24	.3429	.2858	.3048	.2477		.2286	.2096
Max	.5335	.4572	.4763	.4382	.4191	.4763	.5144
Min	.2858	.2286	.2667	.1524	.2286	.1905	.1905
Avg	.3870	.3373	.3679	.2778	.3124	.2891	.3194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 203 / 11 KV Kingaon Jattu AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1715	.1334	.0191	.1334	.1334
2	.1524	.1905	.1524	.0953	.0191	.1334	
3	.1524	.1905	.1524	.0762	.0191	.4572	.1334
4	.1715	.1905	.1524	.1715	.0191	.1334	.1524
5	.2667	.2286	.2286	.1905	.0191	.1905	.2286
6	.3429	.381	.3239	.2477	.0191	.2858	.2858
10	.2096		.3048		.1334		.1524
11	.2477		.2858	.1905	.1143		.1905
12	.2096		.3048	.1715	.1143		
13	.2096		.2477		.1143		
14	.1905		.1334		.1143		.1905
15		.2096					
16		.2286					
17		.2667					
18		.3239				.2858	
19	.1905	.3239	.381	.0191	.1715	.3239	.362
20	.3429	.3429	.3048	.0191	.1905	.2858	.3048
21	.3048	.2858	.2477	.0191	.1715	.2286	.2667
22	.2286	.2096	.2096	.0381	.1715	.1524	.2096
23	.2096	.1715	.1715	.0572	.1524	.1334	.1715
24	.1905	.1905	.1715	.1524	.0381	.1524	.1334
Max	.3429	.381	.381	.2477	.1905	.4572	.362
Min	.1524	.1715	.1334	.0191	.0191	.1334	.1334
Avg	.2230	.2453	.2320	.1130	.0942	.2228	.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 201 / 11 kv Deulgaon AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3121	.2774			
2	.2774	.2774			
3	.2774	.2947			
4	.2947	.2947			
5	.3429	.3294			
6	.3944	.3814			
7	.4287	.4458			
11			.2096	.2858	
12					.1905
13					.2096
14			.2286		
15			.2667		
16			.2858		
22	.2804				
23	.3121				
24	.2947	.3086			
Max	.4287	.4458	.2858	.2858	.2096
Min	.2774	.2774	.2096	.2858	.1905
Avg	.3215	.3262	.2477	.2858	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 202 / 11 KV AJISPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6858	
2				.6478	
3				.6858	
4				.6858	
5				.6478	
6				.6858	
7			.1715	.6096	
8				.6858	
9	.5087	.5144		.4572	
10	.5316	.4161		.6096	
11		.5716		.3048	.1334
12	.5533	.5525			.1524
13	.5197	.4954		.3429	.381
14	.4239	.4954		.3429	.3429
15	.4409	.5525		.3429	.2667
16	.3944	.5716		.3048	.2667
17	.5316			.3429	.3048
18				.2667	.381
19	.5533				
Max	.5533	.5716	.1715	.6858	.381
Min	.3944	.4161	.1715	.2667	.1334
Avg	.4953	.5212	.1715	.5088	.2786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 203 / 11 KV DEULGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.499	.362	.381		.4954	.4572
2	.4755	.499	.3429			.4954	.4191
3	.4755	.4805	.3429			.5144	.381
4	.6516	.695	.4572			.6859	.6668
5	.9214	1.0029	.7621			.8573	.8383
6	.9922	.9671	.9145			.8954	.9907
10		.439				.6097	.6859
11	.462	.4001		.5716		.4191	.5716
12	.4251	.4191	.2667				.4382
13	.4066	.4191	.362			.3429	.381
14	.4066	.4001	.4191				.3429
15	.4066	.4382	.4572			.3429	.3429
16	.4259	.4954	.6097				.4382
17	.4755	.5716	.6478			.5335	.6478
18	.6767	.6478	.743			.9145	.8002
19	.7964		.8383		.8954	.8002	.7621
20	.8145		.7621		.8573	.724	.724
21	.6335		.6287		.6668	.6478	.6478
22	.5487	.4572	.5525		.5716	.6287	.5906
23	.5175	.381	.4954		.5335	.5716	.4954
24	.4887	.499	.381	.4572		.5144	.5716
Max	.9922	1.0029	.9145	.5716	.8954	.9145	.9907
Min	.4066	.381	.2667	.381	.5335	.3429	.3429
Avg	.5738	.5395	.5445	.4699	.7049	.6107	.5806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 200 / Dongaon Substation Xmer
Feeder Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0243	.028	.0183	.0191
2	.0183	.0299	.0261	.0183	.0191
3	.0183		.0261	.0183	.0191
4	.0183	.0299	.0261	.0183	.0191
5	.0183	.0317	.0317	.0183	
6	.0183		.0336	.0183	.0191
7	.0183	.028	.028	.0183	.0191
8	.0183		.0238	.0183	.0191
9	.0183	.0261	.0219	.0183	.0191
10	.0191	.0224	.0219	.0183	.0191
11	.0191		.0183	.0183	.0191
12	.0191	.0222	.0183	.0183	.0191
13	.0191		.0183	.0183	.0191
14	.0191	.024	.0183	.0183	.0191
15	.0191		.0183	.0183	.0191
16		.024	.0183	.0183	
17	.0191	.0205		.0183	.0191
18	.0191	.0243		.0183	.0191
19	.0191			.0183	.0191
20	.0191	.0299		.0183	.0191
21	.0191			.0183	.0191
22	.0191	.028		.0183	.0191
23	.0191	.028		.0183	.0191
24	.0183	.0224	.0243	.0183	.0191
Max	.0191	.0317	.0336	.0183	.0191
Min	.0183	.0205	.0183	.0183	.0191
Avg	.0188	.0260	.0236	.0183	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1966	.1492	
2	.1463	.2321	.1658	
3	.1646	.2591	.1802	
4	.1829	.2785	.2321	
5	.2561	.3113	.2949	
6	.3475	.2949	.3441	
7	.3292	.3113	.3277	
12				.3734
13				.3361
14				.3361
16				.3429
17				.3921
18				.3547
22	.2427	.1989		
23	.2241	.1638		
24	.1829	.1966	.1638	
Max	.3475	.3113	.3441	.3921
Min	.1463	.1638	.1492	.3361
Avg	.2241	.2443	.2322	.3559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV PANGARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.3647		
2	.4207	.3647		
3	.4024	.3812		
4	.4024	.4144		
5	.5487	.4641		
6	.8779	.5304		
7	.695	.5636	.426	
12				.6161
13				.6535
14				.5601
15				.5601
18				.5415
22	.5041	.3768		
23	.4668	.3978		
24	.4572	.3812		
Max	.8779	.5636	.426	.6535
Min	.4024	.3647	.426	.5415
Avg	.5214	.4239	.426	.5863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV MADANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.4755	.4096	.4144	
10	.5601	.4641	.4641	
11	.5788		.6036	
12	.4481	.5304	.5487	
13	.6722	.4641	.5121	
14	.5093	.426	.439	.3292
15	.4294	.3978	.4755	.2561
16	.3734	.3812	.5121	.2743
17				.2926
18				.2926
Max	.6722	.5304	.6036	.3292
Min	.3734	.3812	.4144	.2561
Avg	.5059	.4390	.4962	.2890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV DONGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7737	1.6278	1.7558	1.5912	1.5123
2	1.7364	1.6095	1.7002	1.6095	1.4937
3	1.7177	1.7375	1.7556	1.5912	1.4563
4		1.8107	1.8839	1.7924	1.643
5	2.0165	2.1068	2.0119	1.957	1.9044
6	2.2218	2.1719	2.1719	2.1948	2.2068
7	2.1285	1.828	2.0119	1.9204	2.1285
8	1.8298	1.7741	1.9204	1.7558	1.7364
9	1.6617	1.647	1.8107	1.6461	1.5497
10	1.4563	1.5729	1.5364	1.4266	1.531
11	1.419		1.3535	1.39	1.4563
12	1.475	1.8099	1.4998	1.4266	1.251
13	1.419	1.6832	1.5181	1.3717	1.2136
14	1.4937	1.6827	1.5546	1.39	1.2323
15	1.475	1.7194	1.5364	1.4266	
16	1.6804	1.7556	1.5546	1.4083	1.251
17	1.6617	1.7193		1.4449	1.3443
18	1.8298	1.7926		1.5181	1.6244
19	1.9605	2.0851		1.7558	1.8298
20	2.0165	2.2177		1.7924	1.8111
21	1.9605	2.0485		1.701	1.8111
22	1.9044	1.9959		1.6278	1.7737
23	1.8298	1.9022		1.5181	1.7177
24	1.8111	1.701	1.7924	1.6461	1.531
Max	2.2218	2.2177	2.1719	2.1948	2.2068
Min	1.419	1.5729	1.3535	1.3717	1.2136
Avg	1.7599	1.8261	1.7275	1.6209	1.6091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV PANGARKHED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8779	.8779		.8402
2	.8779	.8962	.8596		.8215
3	.8962	.9231	.8779		.7842
4	.8779	.9694	1.0242		.8962
5	1.0425	1.0425	1.0974		1.0642
6	1.1706	1.1157	1.2437		1.1576
7	1.1523	.9877	1.0242		1.0269
8	.9877	.9694	.8871		
9	.8779	.9593	.7762		
10	.8775		.7023		
11	.8402		.7865		
12	.8029	.8413	.7682		.8589
13	.8215	.8048	.823		.8029
14	.8215	.823	.8596	.9877	.7842
15	.8402	.823	.8048	.9511	.7655
16	.8029	.8048	.7682	.9145	
17	.7842	.8589		.8596	
18	.9522	.8871		.8048	.9335
19	1.0456	1.0534		.9877	1.1203
20	1.1203	1.2567		1.0974	1.1576
21	1.1576	1.134		.9145	1.1763
22	1.0642	1.0534		.9694	1.0829
23	.9522	.9795		.9328	1.0456
24	.9511	.9231	.924		.8962
Max	1.1706	1.2567	1.2437	1.0974	1.1763
Min	.7842	.8048	.7023	.8048	.7655
Avg	.9430	.9538	.8885	.9420	.9564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 201 / 11KV Deulgaon Mali AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
9	.3688	.2462	.282
10	.3185	.2462	.3521
11	.3227	.2494	.2934
12	.3353	.2397	.2934
13	.2107	.2256	.2572
14	.2107	.2256	.2606
15	.2107	.2195	.2572
16	.2107	.2195	.1867
Max	.3688	.2494	.3521
Min	.2107	.2195	.1867
Avg	.2735	.2340	.2728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 202 / 11 KV LAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2881	.2841	.0442	
2	.2606	.2881	.2841	.0686	
3	.2469	.2881	.2705	.0686	
4	.2397	.3001	.2705		
5	.2896	.3121	.2705		
6	.3227	.3269	.3704		
7	.3715	.3475	.4054		
8				.0503	
9				.0754	
10				.1372	
11					.2896
12					.3311
13					.3521
14					.3521
22	.3292	.3292			
23	.3292	.3292			
24	.2606	.3292			
Max	.3715	.3475	.4054	.1372	.3521
Min	.2397	.2881	.2705	.0442	.2896
Avg	.2911	.3139	.3079	.0741	.3312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 203 / 11 KV PENTAKALI EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3121	.2915	.2743		.4294	.1463	.2743
2	.3121	.2915	.2743		.4294	.1463	.2743
3	.3121	.2915	.2743		.4294	.1448	.2743
4	.3155	.3052	.2743		.4294	.1448	.2401
5	.5028	.4973	.2743		.4294	.3582	.3429
6	.5548	.4973	.5201		.3944	.5201	.4801
7	.5201	.5144	.5375		.4334	.5201	.4801
8	.1214	.5487	.4801		.4854	.2713	.4854
9	.4854	.5487	.5201		.4854	.1227	.4801
10	.5201	.5487	.5316		.1448	.1402	.5201
11	.5487	.5548	.5487		.285	.5201	.5144
12	.5487	.5316	.5144		.5144	.5144	.2652
13	.506	.5487	.5201		.4854	.5144	.5201
14	.5426	.5548	.5375			.5144	.5201
15	.5487	.5487	.4854		.4854	.5658	
16	.5548	.5201	.5201		.1097	.5487	
17	.5487	.5609	.5375		.4706	.5487	
18	.439				.5548	.5144	
19	.4784	.5201			.5201	.5548	.5144
20	.4382	.3077			.3467	.5548	.5144
21	.2947	.2896			.3467	.5201	.5487
22	.2915				.2915	.2743	.5792
23	.2915	.2743		.1048	.2743	.2743	.285
24	.3121	.2743			.5975	.1372	.3353
Max	.5548	.5609	.5487	.1048	.5975	.5658	.5792
Min	.1214	.2743	.2743	.1048	.1097	.1227	.2401
Avg	.4292	.4464	.4485	.1048	.4075	.3780	.4224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 204 / 11 KV LAVALA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.5228	.5601	.2353	.5068	.4805
2	.5228	.5228	.5487	.2353	.5068	.4755
3	.5228	.5228	.5544	.2353		.4805
4	.5847	.5601	.5601	.2353		.4805
5	.8299	.7545	.6653	.2715		.5544
6	.9149	.8589	.8215	.3292		.8962
7	.7842	.8676	.7842	.2926		.9054
8	.6722	.7392	.6653	.2835	.5068	.7468
9	.5975	.6979	.7468	.2896	.5068	.6584
10	.5601	.5544	.6283	.2896	.4287	.5175
11	.5601	.5304	.543	.4161	.4334	.4755
12	.5121	.5249	.5014	.4334	.3155	.4344
13	.5304	.5121	.5068	.4115	.5014	.4252
14	.5304	.5175	.5487		.5373	.4607
15	.5601	.5487	.7316		.5373	
16	.5788	.5914	.543	.3429	.567	
17	.5853	.5731	.6219	.6588	.6878	
18	.6722			.9511	.7316	
19	.7842	.7964		.8596	.7392	.8145
20	.7282	.8326		.7783	.7023	.7316
21	.6653	.6722		.724	.5914	.6584
22	.6161	.6283		.6447	.3658	.6219
23	.5601	.5487		.6268	.3109	.5792
24	.5415	.5601			.543	.543
Max	.9149	.8676	.8215	.9511	.7392	.9054
Min	.5121	.5121	.5014	.2353	.3109	.4252
Avg	.6231	.6277	.6195	.4545	.5274	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 201 / 11 KV HIWARA KD. AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0554
3						.056
4						.0549
5						.0549
6	.2743		.2096			.0549
7	.3109					.0732
8						.0914
9			.3048			.1478
11				.1715		
12				.1715		
14		.1143				
15					.1109	
16				.1334	.1097	
17					.1097	
18					.1097	
24	.128		.0953			
Max	.3109	.1143	.3048	.1715	.1109	.1478
Min	.128	.1143	.0953	.1334	.1097	.0549
Avg	.2377	.1143	.2032	.1588	.11	.0736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 202 / 11 KV DEULGAON SAKARSHA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4024		.2926
2							.2561
3							.2561
4							.2195
5							.2195
6	.4435		.4572				.3292
7					.4024		.2561
8					.3292		
9					.3658		
10					.3658		
11		.7621		.439	.381	.3658	.4024
12		.6859		.439	.4572	.4024	.3658
13		.4572		.4755		.4024	.3658
14			.5544			.3658	
15			.5121	.4755		.4024	
16			.439			.3658	
17						.2926	
19				.5121			.4755
20				.5121			.4755
21				.4755			.439
22				.4755			.3658
23				.439			.3658
24	.3696		.3048	.6618	.3658		.3292
Max	.4435	.7621	.5544	.6618	.4572	.4024	.4755
Min	.3696	.4572	.3048	.439	.3292	.2926	.2195
Avg	.4066	.6351	.4535	.4905	.3837	.3710	.3384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 203 / 11 KV NAIGAON DATTAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.1097		
9	.6584			.1463		
10	.6219			.1829		
11		.6859		.1334		
12		.6668		.2096		.3658
13		.724				.4024
14		.6668	.695		.1463	.439
15					.1463	.4207
16			.695	.3048	.1829	.4207
17					.1829	.4024
18						.3658
Max	.6584	.724	.695	.3048	.1829	.439
Min	.6219	.6668	.695	.1097	.1463	.3658
Avg	.6402	.6859	.695	.1811	.1646	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 204 / 11 KV DEULGAON SAKARSHA

GAOTHAN FEEDER

GAOTHA Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4024		.6036
2					.439		.5853
3					.439		.5853
4					.4755		.6219
5					.5487		.695
6	.7762				.5853		.9511
7	.695				.5853		.7682
8	.6219		.2096		.5487		.5487
9	.6219		.724		.5487		.439
10	.4755				.5121		.4024
11		.9145		.439	.5335	.5175	.5487
12		.9145		.4755	.4572	.4024	.4755
13		.9145		.4755		.4572	.4755
14		.9145	.5175	.4572		.439	.5121
15			.5914	.439		.4024	.5121
16			.6219		.5335	.4024	.5487
17						.4755	.5487
18							.6219
19				.8779			.7316
20			.8048	.8413			.8413
21			.7316	.8048			.8779
22			.695	.7682			.7682
23				.7316			.7682
24	.6219		.6097	.6219	.6584		.6219
Max	.7762	.9145	.8048	.8779	.6584	.5175	.9511
Min	.4755	.9145	.2096	.439	.4024	.4024	.4024
Avg	.6354	.9145	.6117	.6302	.5191	.4423	.6272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 205 / 11 KV NAIGAON DATTAPUR

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4755		.4024
2					.5121		.4024
3					.5487		.439
4					.6219		.4755
5					.6584		.6219
6	.8779		.6668		.7316		.9511
7	.7316		.7621		.695		.8048
8	.695				.6584		.6584
9	.6653		.6097		.6219		.6584
10					.5487	.439	.4572
11		.7621		.4755	.4001		.439
12		.4191		.4755	.6097	.4024	.4024
13		.6668		.439		.4024	.3658
14		.7621	.5121	.439		.3658	.4024
15			.5487	.4755		.4024	.4024
16			.5487			.4435	.439
17						.4755	.4755
18							.5487
19				.5853			.695
20			.6584	.6219			.7316
21			.5853	.5487			.6584
22			.5121	.5487			.5853
23				.5121			.5487
24	.4755		.4001	.4435	.4755		.439
Max	.8779	.7621	.7621	.6219	.7316	.4755	.9511
Min	.4755	.4191	.4001	.439	.4001	.3658	.3658
Avg	.6891	.6525	.5804	.5059	.5813	.4187	.5418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 206 / 11 KV HIWARA KD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584				.6219		.6219
2					.6219		.6219
3					.6584		.5853
4					.6584		.6584
5					.695		.695
6	.8779		.6859		.7682		.9145
7	.8048		.9145		.7682		.8779
8	.7316		.9145		.5853		.7316
9	.695				.5487		.6584
10	.6653				.5121		.5853
11		.5335		.439	.5335		.5487
12		.4572		.439	.5335		.5121
13		.5144		.4755			.4755
14		.5335	.7392	.4755		.439	.4755
15			.7392	.439		.4066	.439
16			.6653		.6097		.439
17						.7023	.4755
18						.7316	.5487
19				.8048			.695
20			.6653	.7682			.7682
21			.5487	.7316			.8413
22			.5544	.695			.7682
23		.6859		.6584			.7316
24	.7023			.6219	.6584		.6584
Max	.8779	.6859	.9145	.8048	.7682	.7316	.9145
Min	.6584	.4572	.5487	.439	.5121	.4066	.439
Avg	.7336	.5449	.7141	.5953	.6267	.5699	.6386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 201 / 11 KV ANDHURD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3467	.2427		.1734	.2774	
2		.3467	.2601			.2774	
3		.3467	.3121			.2774	
4		.3814	.3467			.3121	
5		.4161	.4161			.3467	
6		.4508	.4161			.3467	
7		.4161	.4508			.3467	
8	.2427	.1387	.3467			.3467	
9	.2774	.1387	.4161			.3467	
10	.3467	.1734		.2601		.3467	
11	.3467	.3467		.3814		.3467	.3467
12	.8322	.3467		.3467		.3467	.5201
13	.7802	.3121	.3814	.3467		.3467	.5548
14	.7975	.2774	.4854	.5548	.2427	.3467	.6068
15	.6588	.3121	.5201	.6241	.2427	.3467	.5201
16	.3467	.3467	.6068		.2427	.3467	.5201
17		.3121	.5201		.2427	.4161	
18			.4508	.6935	.2427	.3467	.4161
19					.2601		.5201
20					.2601		
21					.2601		
22	.2427	.1734			.2427		
23	.2774	.208			.2601		
24		.3121	.2427			.2601	
Max	.8322	.4508	.6068	.6935	.2601	.4161	.6068
Min	.2427	.1387	.2427	.2601	.1734	.2601	.3467
Avg	.4681	.3051	.4009	.4582	.2427	.3330	.5006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 203 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1387			.3121	.2601
2			.1387			.3467	.2774
3			.1734				.2774
4			.1734				.3121
5			.2601				.3467
6			.3467				.3467
7			.3121	.1387		.3467	.4161
8	.1734	.3467		.1734		.3467	.4334
9	.2774	.4854		.2601		.3467	.3467
10	.3467	.4508		.3467		.3467	.3467
11	.3467	.4508		.4508			
12	.3467	.4161		.3814	.3467		
13	.3467	.4161		.3467	.3121		
14	.3467	.3467		.2774	.2774		
15	.3467	.3467			.2774		
16	.3467	.3467					
22		.0867					
23		.104					
24			.1387			.1734	.1734
Max	.3467	.4854	.3467	.4508	.3467	.3467	.4334
Min	.1734	.0867	.1387	.1387	.2774	.1734	.1734
Avg	.3197	.3452	.2102	.2969	.3034	.317	.3215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 204 / 11 KV BHIVAPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7802	.6935	.8322	.7802
2			.6935	.6935
3	.6935		.7802	.6588
4	.6935		.6935	
5	.8322		1.387	
6	1.2136		1.647	1.387
7	1.387		1.3003	1.647
8	1.1269		1.1269	1.3003
9	.9709		.9709	1.1443
10	.7975		.8322	.9709
11	.7975		.7975	.8669
12	.7975	.7975	.7975	.8322
13	.7975	.5201	.6935	.6935
14	.8322	.6935	.6935	.6935
15	.8322	.6935	.7975	.7282
16		.9536	.8669	.8322
17		1.1269	.9015	.9709
18	1.0402	1.2136	1.0402	1.0402
19	1.2136	1.3523	1.2136	1.1789
20	1.1789	1.2136	1.387	1.2136
21	1.0402	1.1269	1.2136	1.1789
22	.9015	1.0402	.9709	1.1269
23	.7975	.9709	.8669	1.0402
24	.8322	.7802	.8669	.8322
Max	1.387	1.3523	1.647	1.647
Min	.6935	.5201	.6935	.6588
Avg	.9313	.9412	.9738	.9914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 205 / 11 KV ANDHRUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6588	.6935	.7802	.6935
2	.6068		.6935	.6588
3	.5548		.6588	.6241
4	.6588		.6935	.6588
5	.7282		.6935	.6935
6			1.2136	1.1269
7			1.1269	1.2656
8			.8669	1.0402
9	.2601		.8322	.7975
10	.3121		.6068	.6935
11	.6762	.5548	.6241	.6068
12	.5201	.5201	.5548	.5201
13	.6241	.5548		.4854
14	.6935	.6588	.5548	.4508
15	.8322	.6588	.5548	.5201
16		.6588	.6241	.6588
17	.1734	.7975	.6762	.7282
18	.1734	.9709	.7802	.8322
19	.6935	1.0402	1.0402	.8669
20	1.0402	.7554	1.2136	1.0402
21	1.1443	1.0402	1.0402	.9709
22	.8669	.9709	.7975	.8669
23	.7628	.8669	.7802	.8322
24	.6935	.7282	.8322	.7282
Max	1.1443	1.0402	1.2136	1.2656
Min	.1734	.5201	.5548	.4508
Avg	.6337	.7647	.7930	.7650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 206 / 11 KV GHATBORI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5895	.5548	.5201	.4854	.5548	.6068	.4854
2	.5201	.5201	.4854	.4508		.5548	
3	.4854	.4854	.5201	.4854			.4854
4	.5201	.5201	.6068	.8669			.5201
5	.6588	.6068	.7802	.6935			.6935
6	.8669	.9709	.9015	.8669			1.0402
7	.8322	.7975	1.0402	.6241		.7802	.7975
8	.6935	.7282	.8669	.5201		.6588	.7282
9	.6588	.6241	.6935	.4854		.6068	.5201
10	.6588			.4508		.4854	.4854
11	.6241	.3467		.4508		.4854	.4854
12	.5548	.4161		.4854		.4508	.4854
13	.4508	.4508	.4854	.4854		.4161	.4854
14	.4508	.4854	.4854	.4854		.4161	.4854
15	.4854	.5201	.4854	.4854	.5201	.4508	.4854
16	.5201	.5548	.5201		.6068	.5201	.5201
17	.5548	.6935	.6935	.6935	.6935	.5548	.5548
18	.6935	.6935	.7802	.6935	.8322	.6935	.6935
19	.8669	1.0402		.8322	1.0402	.8669	.7802
20	.8322	.9709		.9015	.9709	1.0402	.8669
21	.7802	.8669			.8669	.8669	.8322
22	.6935	.8322		.8322	.7802	.6241	.7802
23	.5895	.6935	.6588	.6935	.6935	.5548	.6935
24	.6241	.6068	.5548	.5201	.6241	.6241	.5201
Max	.8669	1.0402	1.0402	.9015	1.0402	1.0402	1.0402
Min	.4508	.3467	.4854	.4508	.5201	.4161	.4854
Avg	.6335	.6513	.6517	.6131	.7439	.6129	.6271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 207 / SJS INFRA TECH EXPRESS

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0347	.0347	.0347	.3467
2	.0347		.0347	.3467
3	.0347		.0347	.3467
4	.0347		.0347	.3467
5	.0347		.0347	.3467
6	.0347		.0347	.3467
7	.0347		.1214	.2601
8	.0347		.1734	.0347
9	.0347		.1734	.0347
10	.0347		.0347	.1734
11	.0347	.0347	.0347	.1734
12	.0347	.0347	.0347	.1734
13	.0347	.0347	.0347	.1734
14	.0347	.0347	.0347	.1734
15	.0347	.0867	.1734	.1734
16	.0347	.1214	.2774	.3467
17	.0347	.1214	.3467	.5201
18	.0347	.2427	.3467	.3467
19	.0347	.2427	.3467	.3467
20	.0347	.2427	.3467	.3467
21	.0347	.0347	.2601	.3467
22	.0347	.0347	.1734	.3467
23	.0347	.0347	.1734	.3467
24	.0347	.0347	.0347	.1734
Max	.0347	.2427	.3467	.5201
Min	.0347	.0347	.0347	.0347
Avg	.0347	.0913	.1387	.2738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 201 / 11 KV NAGZARI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.5144	.6413		
2	.7762	.5144	.5975		
3	.7762	.5144			
4	.8316	.6173	.6348		
5	.8871	.7202	.7167		
6	.9425	.823	.7282		
7	.9425	.8745	.7922		
9			.5975		
10			.8215		
11			.8029	.8316	.4481
12			.7655	.8871	.4481
13			.7282	.7762	.4108
14			.6908	.7762	.3921
15			.7095		.3921
16			.7842		.2987
17					.2614
18					.2614
22	.5658	.6722			
23	.5658	.6722			
24	.8488	.5144	.6224		
Max	.9425	.8745	.8215	.8871	.4481
Min	.5658	.5144	.5975	.7762	.2614
Avg	.7968	.6437	.7089	.8178	.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 202 / 11 KV NAGZARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395		.2987	.1867	.1509	.1494	.2054
2	.3395	.2987	.2801	.2241	.1509	.1494	.2054
3	.3206	.2987	.2801	.3361	.132	.1494	.2054
4	.3206	.3361	.3361	.3361	.1509	.168	.2241
5	.3772	.3921	.4108		.2263	.2614	.2614
6	.4715	.4294	.5041		.2829	.3547	
7	.4904	.4294	.5041	.2614	.2641	.3734	
8	.4715	.3734	.4294	.2641	.2075	.3174	
9	.3772	.3734	.3734	.2452		.1886	
10	.3395	.2801	.3547	.2075		.1867	
11	.2801	.2427	.2427	.1886		.168	
12	.2614	.2427	.2241	.2075		.1307	
13	.2801	.2427	.2241	.2263		.1494	
14	.2614	.2614	.2241	.2241			
15	.2241	.2614	.2614	.2241			
16	.2614		.2614		.1494		
17	.2614		.2614		.168		
18	.2987				.168	.3361	
19	.4481	.5601			.2614		
20	.4854	.4854			.2427	.4294	
21	.3734	.4108	.2614		.168	.4108	
22	.3547	.3547	.2614	.1509	.1867	.3734	
23	.3361	.3547	.2241	.1132	.1494	.3361	
24	.3395	.3174	.2801	.2054	.132	.1494	.2427
Max	.4904	.5601	.5041	.3361	.2829	.4294	.2614
Min	.2241	.2427	.2241	.1132	.132	.1307	.2054
Avg	.3464	.3473	.3094	.2251	.1877	.2517	.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 203 / 11 KV WARUDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5228	.5228	.4108	.415	.4108	.4108
2	.5093	.5415	.5228	.4481	.415	.4108	.415
3	.4715	.5415	.5041	.5601	.3772	.4108	.415
4	.4715	.5601	.5975	.5601	.415	.4481	.4527
5	.5281	.6036	.7468	.7468	.5658	.6535	.5228
6	.7922	.7865	.7655	.8215	.6602	.7095	.6535
7	.7922	.7316	.6908	.7468	.8488	.6908	.7468
8	.6602	.6219	.6535	.7167	.7545	.7468	.5975
9	.6224	.5788	.5975	.5093	.5658	.5415	.5041
10	.4904		.7095	.415	.4904	.4668	.3361
11	.4481	.3734	.3734	.4338	.3921	.3361	.3547
12	.4108	.4108	.4108	.415	.4481	.3361	.3734
13	.4481	.3921	.4481	.3961	.3921	.4108	.3734
14	.4668	.4294	.4481	.4527	.3361	.4294	.3547
15	.5041	.4668	.4668	.415	.3921	.3921	
16	.5228		.4854		.4108	.4481	
17	.5228		.5228		.4481	.6535	
18	.5975				.5601	.6535	
19	.6722	.8402			.5788	.6535	.8215
20	.8029	.7655			.5415	.5975	.8589
21	.6908	.7655	.5415		.5041	.5975	.8215
22	.5975	.5228	.5228	.5281	.4854	.5228	.7468
23	.5601	.5228	.4854	.5093	.4668	.4481	.679
24	.5093	.5228	.5041	.4294	.4715	.4108	.4108
Max	.8029	.8402	.7655	.8215	.8488	.7468	.8589
Min	.4108	.3734	.3734	.3961	.3361	.3361	.3361
Avg	.5667	.5750	.5486	.5286	.4973	.5158	.5425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 204 / 11 KV WARUDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2801	.1029	.2263
2				.3361	.1029	.1698
3				.3361	.1543	.1698
4				.3921	.2058	.168
5				.3921	.2058	.168
6				.4481	.2058	.2241
7				.4481	.2572	.2801
8	.3326				.2572	.2241
9	.3326	.3601			.2058	.2801
10	.3881					.2801
11	.3772	.3921				.2614
12	.3921	.3921				.2427
13	.3772	.3361				.2241
14	.3086	.3361				.2241
15	.3086	.3361				
16	.3601					
22			.2801			
23			.2801			
24				.2801		
Max	.3921	.3921	.2801	.4481	.2572	.2801
Min	.3086	.3361	.2801	.2801	.1029	.168
Avg	.3530	.3588	.2801	.3641	.1886	.2245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 201 / 11 KV UKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2286	.2			.1166
2	.3109	.2229	.2			.1446
3	.3109	.2229	.2286			.1425
4	.3109	.2526	.2572			.1555
5	.3292	.2591	.2572			.1814
6	.4024	.2526	.2572			.1814
7	.3475	.2526	.2858			.1814
8						.1814
9			.2366			.1814
10			.2498			.1943
11			.3292		.2743	
12			.2926	.3841	.3125	
13			.3475	.3658		
14			.3292	.3658		
15			.3292			
16			.3475			
17				.2743		
18				.2195	.0171	
22	.2753	.2				
23	.2591	.2				
24	.2926	.2286	.2			
Max	.4024	.2591	.3475	.3841	.3125	.1943
Min	.2591	.2	.2	.2195	.0171	.1166
Avg	.3131	.2320	.2717	.3219	.2013	.1661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 202 / 11 KV BORI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.168		
2				.168		
3				.168		
4				.1663		
5				.1848		
6				.2402		
7			.2378	.2772		
8	.2195		.3109	.2772		
9	.3292		.3109	.2218		
10	.3109			.1848		
11	.2622					.1858
12	.2429					.1715
13	.2035					.1429
14	.1638	.3001				.1429
15	.1619	.3001			.1143	.1429
16	.1619	.3001			.1858	.1572
17		.3144			.1572	.1572
18		.2572			.1572	.1429
19		.2286				
Max	.3292	.3144	.3109	.2772	.1858	.1858
Min	.1619	.2286	.2378	.1663	.1143	.1429
Avg	.2284	.2834	.2865	.2056	.1536	.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 203 / 11 KV UKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.8383	.9335	.9328	.8215	.8097	.9431
2	.9511	.8697	.9619	.8779	.8131	.7373	.9431
3	.9694	.8124	1.0269	.8779	.8962	.7373	1.0185
4	1.0242	.9145	1.1576	.8779	.924	.9374	1.094
5	1.134	1.1431	1.4969	1.134	1.2012	1.186	1.1694
6	1.7193	1.2631	1.6632	1.6461	1.8111	1.448	1.6448
7	1.6461	1.247	1.6598	1.4266	1.7926	1.448	1.8858
8	1.6095	1.1145	1.5524	1.3169	1.6632	1.0402	1.5708
9	1.3717		1.3392	1.2986	1.4045	.9145	1.3443
10	1.0974		1.1317		.8316	.7621	1.2696
11	.8573		.7682		.7716	.8962	1.0374
12	.7116		.695	1.0974	.7888	.4904	.8962
13	.8139		.7316	1.0059		.4904	.8402
14	.8192	1.0269	.9877	.9694			.8299
15	.8192	1.0751	.9511			.8488	.9335
16	.8097	.8859	.8779			.9619	.9997
17	.9145	1.2826	1.0974	1.4998		1.1458	1.1088
18	.9907	1.4045	1.4632	1.3535		1.386	1.2936
19	1.0402	1.5524		1.4937	1.3375	1.4784	1.4969
20	1.1294	1.4784	1.4632	1.4003	1.0669	1.4415	1.2012
21	.9907	1.2012		1.1203	.9907	1.3203	.9425
22	.9145	1.094		.9709	.8478	1.2071	.9425
23	.9488	.961	.9816	.9335	.8478	.0191	.8962
24	1.0059	.8383	.9335	.9145	.8402	.8192	.9619
Max	1.7193	1.5524	1.6632	1.6461	1.8111	1.4784	1.8858
Min	.7116	.8124	.695	.8779	.7716	.0191	.8299
Avg	1.0516	1.1054	1.1368	1.1574	1.0917	.9794	1.1360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 204 / 11 KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0183	.0191	.0366	.0187	.0181	.0191
2	.0183	.0179	.0191	.0366	.0373	.0181	.0191
3	.0183	.0181	.0191	.0366	.0373	.0183	.0191
4	.0183	.0181	.0191	.0366	.0373		.0191
5	.0183	.0181	.0191	.0366	.0373	.0179	.0191
6	.0183	.0183	.0191	.0366	.037	.0181	.0191
7	.0183	.0183	.0191	.0366	.037	.0183	.0191
8	.0183	.0181	.0191	.0183	.037	.0181	.0191
9	.0183		.0191	.0183	.037	.0183	.0191
10	.0183		.0191		.037	.0181	.0191
11	.0181		.0183		.0181	.0191	.0191
12	.0183		.0183	.0183	.0181	.0191	.0191
13	.0181		.0183	.0183		.0191	.0191
14	.0181	.0191	.0183	.0183		.0191	.0191
15	.0183	.0191	.0183			.0191	.0191
16	.0181	.0191	.0183			.0191	.0191
17	.0183	.0191	.0183	.0366		.0191	.0191
18	.0181	.0191	.0183	.0366		.0191	.0191
19	.0183	.0191	.0366	.056		.0191	.0191
20	.0183	.0191	.0549	.056	.0171	.0191	.0191
21	.0181	.0191		.0373	.0171	.0191	.0191
22	.0181	.0191		.0373	.0177	.0191	.0191
23	.0181	.0191	.0351	.0373	.0171	.0191	.0191
24	.0183	.0181	.0191	.0366	.0373	.0181	.0191
Max	.0183	.0191	.0549	.056	.0373	.0191	.0191
Min	.0181	.0179	.0183	.0183	.0171	.0179	.0191
Avg	.0182	.0186	.0220	.0341	.0291	.0187	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 201 / 11 KV KALAMBESHWAR
GAONTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.4144	.4656	.3315	.3647	.4938	.4374
2	.9259	.4096	.4656	.3315	.3647	.4938	.4374
3	1.0082	.4096	.4706	.3315		.4938	.4374
4	.9945	.4858	.4607	.3353	.3688		.6001
5	1.0288	.5281	.5258	.3647	.3688		.7164
6	1.0288	.6009	.6154	.4096	.3978		.7133
7	1.0117	.5959		.4588	.3978	.6626	.6154
8	.8573			.4588	.3978	.5014	.4298
9	.8573			.3978	.3353	.4656	.3582
10	.8573			.3772	.3353	.394	.3475
11				.3429	.3315		.3086
12				.3429	.3315		.2743
13	.3688			.3429	.3315		.2401
14	.3353	.4607	.426	.3772	.2715	.3801	.3086
15	.3647	.4908	.4588	.3429	.3292	.3801	.3086
16	.3978	.5014	.4588			.439	.3086
17	.4096	.5373	.4801		.3658	.543	.3258
18	.4534	.5316			.543	.5731	.463
19	.5376	.6154		.4115	.5014	.6154	.4801
20	.6249	.6201		.4115	.4835	.591	.4801
21	.5535	.543		.4115	.4835	.567	.4458
22	.4858	.5068		.3772	.4938	.5487	.4458
23	.4534	.5068		.3772	.4938	.5121	.4458
24	.9156	.426	.4706		.3772	.4938	.5121
Max	1.0288	.6201	.6154	.4588	.543	.6626	.7164
Min	.3353	.4096	.426	.3315	.2715	.3801	.2401
Avg	.6998	.5102	.4816	.3767	.3940	.5082	.4350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 202 / 11 KV KALAMBESHWAR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1638	.2187
2				.1562	.2214
3				.1619	.2187
4				.1562	.2343
5					.2429
6				.0949	.253
7				.2187	.2622
8				.2656	.2591
9	.4161				
10	.4161			.1718	.1638
11	.4801				.2675
12	.4801				.2824
13	.506				
14	.4096		.7225		.2675
15	.5121	.5281	.743		.2675
16	.4801		.6836		.2675
17					.2378
18					.1783
24				.16	
Max	.5121	.5281	.743	.2656	.2824
Min	.4096	.5281	.6836	.0949	.1638
Avg	.4625	.5281	.7164	.1721	.2402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 203 / 11 KV KASARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4858	.6539			
2		.4801	.6539			
3		.4588	.6622	.4588		
4		.4534	.6622	.4588		
5		.4801	.6622	.4588		
6		.4801	.6171	.4858		
7		.4401	.679	.4858		
9				.5601		
10				.6516		
11				.6241	.4801	
12				.6241	.6173	
13				.6241	.6009	
14				.6241	.4999	.4218
15				.6241		.4801
16						.5693
17						.5624
18						.5247
22		.6161				
23	.3932	.6455				
24		.4858	.6539			
Max	.3932	.6455	.679	.6516	.6173	.5693
Min	.3932	.4401	.6171	.4588	.4801	.4218
Avg	.3932	.5026	.6556	.5567	.5496	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074097 / 33/11 KV PIMPALGAON UNDA

Feeder No / Name : 203 / 11 KV PIMPALGAON UNDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4542	.5139	.3429	.3246	
2	.3772	.4547	.5139	.3429	.3288	
3	.3772	.4964		.3429	.3403	
4	.3429	.5067	.5139	.3429	.3262	
5	.3429	.5067		.3258	.3254	
6	.3772	.4736	.5329	.3086	.3743	
7	.4115	.5137	.4949	.3429	.3441	
8				.3429	.3756	
9				.3429	.3288	
10				.3429	.3453	
11						.3734
12						.4108
13						.4481
14						.4668
22		.4949				
23		.5329				
24	.4115	.4537	.5093			
Max	.4115	.5329	.5329	.3429	.3756	.4668
Min	.3429	.4537	.4949	.3086	.3246	.3734
Avg	.3772	.4888	.5131	.3378	.3413	.4248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 202 / 11 KV MEHKAR TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	1.5851
Max	1.5851
Min	1.5851
Avg	1.5851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 203 / 11 KV SONATI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 204 / 11 KV MEHKAR TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 205 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 077004 / 132/33/11 KV MEHKAR

Feeder No / Name : 206 / 11 KV CHAIGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 202 / 11 KV TUNKI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9	1.9814	2.3243	
10	1.7909	2.191	
11	1.9243	2.0957	
12	1.6385	1.6385	
13	1.448	1.6194	
14	1.4289		
15	1.448		
16	1.5813		
24			1.0288
Max	1.9814	2.3243	1.0288
Min	1.4289	1.6194	1.0288
Avg	1.6552	1.9738	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 203 / 11 KV BAWANBIR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9	.724	.6478	
10	.7621	.6668	
11	.4954	.7621	
12	.4954	.7621	
13	.4763		
14	.4572		
15		.6668	
16	.7621		
24			1.0288
Max	.7621	.7621	1.0288
Min	.4572	.6478	1.0288
Avg	.5961	.7011	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 204 / 11 KV WASADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6766				2.6292	2.6863
2		1.6766				2.553	2.6673
3		1.6575				2.553	2.6673
4		1.6194				2.6292	2.6292
5		1.8671				2.8578	2.934
6		2.0005				3.0674	3.1626
7		1.3717				2.8959	3.0864
8						2.7054	2.8959
9			2.1719			2.4768	
10			2.6482			2.3624	2.4768
11			2.7054	3.4294			
12	1.9814			2.553	3.5246		
13	2.0576		2.7054	3.5818	3.5246		
14	1.9433		2.6482	3.3532	3.2198		
15	1.9052		2.6101	3.3722	3.1245		
16			2.7054	3.2769	3.3532		
17				2.7816			
18				2.5149	2.7244		
22	1.6575						
24	1.1812	1.7147					
Max	2.0576	2.0005	2.7054	3.5818	3.5246	3.0674	3.1626
Min	1.1812	1.3717	2.1719	2.5149	2.7244	2.3624	2.4768
Avg	1.7877	1.6980	2.5992	3.1079	3.2452	2.6730	2.8006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 205 / 11 KV TUNKI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764	.9145	.8192	.8764	.9145
2		.8764	.8383	.8002	.8573	.8954
3		.8764	.8383	.8002	.8573	.8764
4		.8954	.8002	.8002	.8573	.9145
5		.8954	.8383	.8002	.8383	.9526
6		.9145	.8764	.8383	.8764	1.0479
7		.8573	.8002	.8002	.8573	1.0288
8		.8002	.7811	.724	.8573	1.0098
9		.8383	.7621	.724	.8383	.9335
10		.8573	.9145	.7621		
11		.8383	.8002			.9335
12			.8002	.6859		.9145
13		.743	.7621	.5906		.9145
14	.8573	.7621	.8002	.743		.9907
15	.8573	.7621	.8002	.8383	.9907	.9526
16	.7811	.8002	.8383	.8573	.8764	.9717
17	.8002	.7811	.7621		.8573	.9526
18	.7811		.8383	.8764	.8383	.9907
19	.9145	.8954	.9145	.9526	.9526	1.0288
20	1.1431	1.0098	1.0669	1.086	1.105	1.105
21	1.105	.9335			1.0288	1.2574
22	1.0098	1.0288	.9145	.9335	.9907	
23	.9526	.9907	.9145	.9335	.9526	
24		.9145	.9526	.7621	.8954	.9145
Max	1.1431	1.0288	1.0669	1.086	1.105	1.2574
Min	.7811	.743	.7621	.5906	.8383	.8764
Avg	.9202	.8703	.8491	.8156	.9055	.9762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 201 / 11 kv Warwat Bakal AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058	.1715	.1715		
2			.2572	.1715	.1715		
3			.2572	.1372	.1372		
4			.3429	.1372	.1543		
5			.3429	.1715	.1372		
6			.4287	.3429	.2058		
7			.3429	.463	.3086		
8	.2401			.3429	.3772		
9	.3601	.3601		.2743	.3429		
10	.2743	.3429		.2401	.2058		
11	.2743	.2401				.4287	.3772
12	.2058	.2401				.2229	.3086
13	.1715	.1543				.2058	.1886
14	.1715	.1715				.2229	.1715
15	.1715	.1886				.2401	.1372
16		.2572				.2401	.1715
17						.3086	.2743
18						.2572	.2915
22		.2229					
23		.1715					
24			.1543	.2058			
Max	.3601	.3601	.4287	.463	.3772	.4287	.3772
Min	.1715	.1543	.1543	.1372	.1372	.2058	.1372
Avg	.2336	.2349	.2915	.2416	.2212	.2658	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 202 / 11kv wankhed ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717						1.2689
2	1.4575						1.2689
3	1.4575						1.2003
4	1.5432						1.2003
5	1.5432						1.2003
6	1.5432						1.166
7	1.5089						1.3375
8			1.5432				1.3375
9		1.5432	1.5775				1.3717
10		1.6289	1.5775				
11			1.6461	1.8861			
12			1.6804	1.9033		1.2689	
13		1.6804	1.6461	1.8347			
14		1.5432	1.6461	1.8004			
15		1.5775	1.6118	1.8004	1.8004		
16		1.5432	1.6461	1.8004	1.8004	1.7661	
17		1.6289		1.7661		1.8519	
18						1.5089	
19						1.3717	
20						1.3717	
21						1.3717	
22					1.286	1.3375	
23					1.3889		
24	1.4918						
Max	1.5432	1.6804	1.6804	1.9033	1.8004	1.8519	1.3717
Min	1.3717	1.5432	1.5432	1.7661	1.286	1.2689	1.166
Avg	1.4896	1.5922	1.6194	1.8273	1.5689	1.4811	1.2613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 203 / 11kv KAKANWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	1.286	2.2805	1.2689	2.0576	.6516	1.4403
2	2.2291	1.2346	2.2805	1.2689	2.0919	.6516	1.4403
3	2.0576	1.2346	2.2291	1.2689	2.0576	.6516	1.4403
4	2.1948	1.2003	2.1434	1.2689	2.0576	.6516	1.406
5	2.0576	1.2003	2.1434	1.2689	2.0233	.6516	1.406
6	2.1948		2.1262	1.3717	2.0748	.6516	1.4403
7		1.4575	2.1434	1.5089	2.1605	.823	1.5089
8	2.1605		2.2291	1.5432	2.1262	.9431	
9	2.0748	1.3717	2.1776	1.5432	2.0576	.9431	
10	2.0576		2.3491	1.5089	2.1262	.8573	
11	2.2291		2.3663		2.0576	1.2003	
12	2.2462	.6859	2.2634		2.1262	1.1317	2.3148
13	2.2805	.703	2.2291		2.1262	1.2346	2.3491
14	2.2805	.6859	2.2291	1.3375	2.1091	1.2174	2.2291
15	2.2291	1.4746	2.1948	1.2003	2.1434	1.286	2.4006
16			2.1605	1.4232	1.8004	1.2346	2.4006
17		1.4575		1.3717		1.4403	2.4006
18						1.2346	2.2291
22	1.3889	1.1145					
23	1.406	1.2174					
24	2.1262	1.286	2.2634	1.2689			
Max	2.2805	1.4746	2.3663	1.5432	2.1605	1.4403	2.4006
Min	1.3889	.6859	2.1262	1.2003	1.8004	.6516	1.406
Avg	2.0848	1.1740	2.2241	1.3615	2.0748	.9698	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 205 / 11 kv Warwat bakal GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.1488	1.2003	1.166	1.0974	1.2003	1.0631
2	1.1145	1.1145	1.0288	1.166	1.1145	1.1145	1.0631
3	1.1145	1.1145	1.0288	1.1317	1.1145	1.1488	1.0288
4	1.0288	1.0631	.9431	1.1317	1.0117	1.1488	1.0288
5	.8573	1.0631	.9431	1.0288	1.1145	1.046	.9602
6	.8573	.9945	.9259	1.0288	.9602	.9431	.2743
7	.8573	.823	.8573	.8745	.8573	.8573	.2401
8	.8059	.8573	.823	.8573	.8573	.7716	.2401
9	.8573	.823	.9259	.8573	.8745	.6859	.3086
10		.8059	.9259	.8573	.8573	.7202	
11	.8573	.8573	1.0288	.8573	.8745	.6859	.9259
12	.9431	.823	1.0631	.9431	1.0288	.8573	.9259
13	.9945	.8573	1.0631	1.0288	1.0288	.8916	1.0631
14	.9431	1.0288	1.0974	1.0631	1.046	.8916	1.0631
15	.7202	1.1145	1.0974	1.0631	1.0802	.9259	1.1317
16	.6859	1.0802	1.0631	1.0288	1.0631	.8573	1.0631
17		.9602	1.0288	.9945		.8916	.9945
18	.9431	.9945	1.0288	.9431		.823	.8573
19	1.0288	1.0288	1.3375			.9259	1.0974
20	1.286	1.1145	1.3375	1.3032	1.286	1.0974	1.0974
21	1.2517	1.2003	1.3375	1.2346	1.286	1.0974	1.1317
22	1.1831	1.1145	1.3032	1.2689		1.0974	1.1145
23	1.2174	1.2174	1.2346	1.2346	1.2346	1.1317	1.166
24	1.1317	1.1488	1.1831	1.166	1.166	1.2003	1.0974
Max	1.286	1.2174	1.3375	1.3032	1.286	1.2003	1.166
Min	.6859	.8059	.823	.8573	.8573	.6859	.2401
Avg	.9929	1.0145	1.0753	1.0534	1.0477	.9588	.9103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 206 / 11 kv WANKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6001	.583	.583	.5487	.5487	.5144
2	.5144	.5658	.5144	.583	.5144	.5487	.5144
3	.5144	.5487	.5144	.5487	.5144	.5144	.4801
4	.4287	.5487	.4801	.5487	.5144	.5144	.4801
5	.4115	.4801	.4287	.5144	.5144	.4801	.4458
6	.4115	.4287	.4115	.4458	.4115	.463	.4115
7	.3258	.3258	.3601	.3429	.3429	.4287	.3772
8	.3258	.3601	.3258	.3429		.3258	.3429
9	.3429	.3772	.3772	.3429		.3086	.3258
10	.3601	.4287	.3772	.3772		.3258	.3429
11	.4287	.4115	.4115	.4458		.3601	.4115
12	.4458	.3944	.4801	.4801		.3944	.4115
13	.463	.4115	.5144	.5144		.3772	.4801
14	.4801	.4801	.5144	.5144		.463	.4801
15	.4801	.4801	.5144	.5316	.6001	.4458	.4801
16	.463	.463	.4801	.4458	.6001	.4287	.463
17	.4287	.4287	.5144	.4115		.4115	.4115
18	.4287	.4115		.3772	.4458	.4115	.4287
19	.4458	.4801	.583	.5487	.4801	.4458	.5144
20	.5658	.5144	.6173	.5658	.583	.583	.5144
21	.6001	.583	.6344	.583	.583	.583	.4801
22	.5487	.6001	.6173		.6344	.583	.4973
23	.5658	.583	.6173	.583	.583	.5316	.4973
24	.5487		.5658	.583	.5487	.5658	.5144
Max	.6173	.6001	.6344	.583	.6344	.583	.5144
Min	.3258	.3258	.3258	.3429	.3429	.3086	.3258
Avg	.4644	.4741	.4973	.4876	.5262	.4601	.4508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 201 / 11 kV PALSHI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.0082	.9335	.9412	1.0456	.9335	.9149
2	.9335	1.0185	.8962	.9709	1.0829	.8505	.8775
3	.9335	.9795	.8589	1.0082	1.1203		.8775
4	1.0082	.9511	.8962	1.0082	1.1203	.8131	.8962
5	1.0456	.9391	.9709	1.0082	1.1389	.7522	.9149
6	1.0456		1.307	.9774	1.1763	.811	.8775
7	1.0456	.7392	1.2696	1.1949	1.1576	.6979	.7842
8	1.0082	.6767	.8215	1.2437	1.1576	.4938	.8215
9	1.2071	1.1203	.7468	1.1203	1.1203	.3361	.7468
10	1.1584	1.0317	.6161	.9709	1.1016	.4572	.7655
11	1.1584	.9955	.7682	.5975		1.0164	1.3256
12	.9745	.9896	.7842	.6161	.8596	1.1763	1.3443
13	.9328	.9335	.7964	.6535	.8962	1.2696	1.307
14	.9214	.8775	.6878	.6535	.7783	1.3256	1.251
15	.929	.8962	.8779	.7095	.691	1.307	1.2136
16	.9745	.9335	.8589	.7468	.6767	1.2696	
17	.7499	.8962	.8326	.7842			
18	.7701	.8962	.8688	.8402	.2481	.168	
19	.8596	.9149	.9709	.8962		1.0269	
20	1.0791	1.0829	1.0829	1.0642	.7133	.8962	
21	1.0608	1.1203		1.0642	.7316	.9896	
22	1.0534	1.0082		1.0829	.8596	.9896	
23	1.0242	1.0082		1.0642	.9795	.9896	
24	.9709	1.0059	.9335	1.1203	1.0269	.9412	.9335
Max	1.2071	1.1203	1.307	1.2437	1.1763	1.3256	1.3443
Min	.7499	.6767	.6161	.5975	.2481	.168	.7468
Avg	.9923	.9575	.8942	.9307	.9372	.8869	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 202 / 11 KV BODKHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.6219	.3361	.3734	.4854	.5601	.5041
2	.5068	.5853	.2987	.362	.4854	.4784	.4854
3	.5068	.543	.2987	.2896	.4108	.4668	.4854
4	.5121	.5258	.3361	.2926	.4294	.4294	.4854
5	.4344	.5138	.3361	.2561	.4294	.4108	.4668
6	.439		.3921	.2926	.3734	.3721	.4108
7	.3658	.4572	.4108	.3734	.3361	.3361	.5228
8	.3734	.439	.4481	.3361	.2987	.4668	.4481
9	.3326	.3734	.4481	.4108	.3361	.3841	.4854
10	.3696	.3189	.5788	.4344	.3547	.3174	.4854
11	.3982	.3109	.6535	.6348		.4784	.4668
12	.3326	.3174	.5601	.7095	.6348	.3734	.3547
13	.2865	.3921	.543	.7282	.5975	.3547	.3734
14	.2896	.2801	.7468	.7468	.6447	.3361	.3734
15	.2896	.3547	.7468	.7655	.7186	.3361	.3921
16	.3012	.3174	.7095	.7468	.6219	.3734	1.587
17	.5249	.6535	.5792	.7095	.3721	.3361	1.7551
18	.567	.5415	.5792	.6722	.4075	.2241	1.4563
19	.6036	.4108	.5487	.5975	.4572	.3547	1.4003
20	.5731	.5415	.5601	.5415	.4887	.4854	1.3443
21	.6348	.5788		.5601	.5304	.5228	1.307
22	.6584	.3921		.5788	.5853	.5228	1.307
23	.6908	.3734		.5601	.6161	.5228	1.2696
24	.5601	.6722	.3547	.439	.5415	.5975	.5228
Max	.6908	.6722	.7468	.7655	.7186	.5975	1.7551
Min	.2865	.2801	.2987	.2561	.2987	.2241	.3547
Avg	.4630	.4572	.4983	.5171	.4850	.4183	.7787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 203 / 11 KV NIWANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9795	.6535	.7964	.8962	.9328	.8589
2	.905	.8954	.6161	.8215	.8402	.8962	.8402
3	.9335	.8779	.6348	.7842	.8402	.8413	.8215
4	.7964		.6535	.7842	.8775	.7796	.8402
5	.7964		.6722	.5975	.8589		.8589
6	.7964	.8596	.8589	.8215	.8402	.8402	.7282
7	.6154	.8596	.9149	.8962	.8402	.6161	.8402
8	.5914	.7602	.6535	.7468	.8215		.6535
9	.6584	.9745	.8775	.5975	.8402		.6908
10	.7023	.7701	.9896	.4344	.8589	.6401	.6348
11	.6154	.7059	1.0242	1.0456		.9709	1.1203
12	.6099	.6161	.695	1.1576	1.0425	.8775	.9149
13	.5434	.5788		1.1576	1.0288	.7468	.8402
14	.5138	.5601	1.267	1.1949	1.1888	.5601	.7842
15	.5316	.6722	1.1203	1.2323	1.1888	.7095	.7095
16	.5731	.5975	1.1888	1.1576	.9774	.7095	.6722
17	.8328	1.1203	1.1706	1.0829	.7602	.7468	.7468
18		.9335		1.0642	.3189	.5415	.6348
19	.924	.8029	1.0498	1.0829	.7947	.7282	.8402
20	.9896	.9709	1.0829	1.0829	1.0456	.8589	.7842
21	1.0059	1.0082		1.0456	1.0425	.9522	.7468
22	1.0349	.7468		1.0456	1.0242	.9335	.7095
23	1.0425	.6908		.9709	1.0269	.8962	.8589
24	.9511	1.0269	.6535	1.1203	.9335	.9694	.8962
Max	1.0425	1.1203	1.267	1.2323	1.1888	.9709	1.1203
Min	.5138	.5601	.6161	.4344	.3189	.5415	.6348
Avg	.7789	.8185	.8830	.9467	.9081	.7975	.7927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 204 / 11KV SANGRAPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5792	.6535	.6348	.7095	.5601	.5975
2	.5792	.5975	.6161	.6219	.6722	.5415	.5601
3	.5975	.567	.6161	.5975	.6348	.5121	.5601
4	.5601	.543	.5975	.5975	.5975	.499	.5415
5	.5068	.6036	.6161	.5975	.5228		.5601
6	.5228		.5228	.5975	.4854	.5093	.4668
7	.4252	.4668	.4294	.4108	.4294	.3961	.3734
8	.5544	.3801	.4294	.3734	.3921	.3292	.3921
9	.5914	.4031	.4108	.3734	.3361	.3547	.3547
10	.5853	.5041	.4481	.4108	.3921	.3258	.3921
11	.4805	.4784	.5121	.3734		.3326	.4108
12	.5415	.5041	.6348	.5601	.4887	.4108	.4668
13	.4887	.6348	.6348	.5975	.4854	.4481	.5228
14	.4784	.6161	.6348	.6535	.5138	.4854	.5228
15	.5138	.6348	.6154	.6722	.591	.5041	.5601
16	.5373	.6161	.6516	.6722	.5316	.4668	.5788
17	.5434	.6161	.5228	.6535	.4525	.4481	.5415
18	.5853	.5041	.5228	.6535	.4294	.4481	.4854
19	.5847	.5788	.7468	.5975	.5914	.4481	.5228
20	.6036	.6348	.7392	.5788	.6401	.5601	.5228
21	.6468	.6348		.6535	.6068	.5975	.5228
22	.6722	.6722		.6722	.6283	.6161	.6722
23	.6335	.7095		.6908	.6036	.6348	.7095
24	.6348	.6219	.6722	.6348	.6722	.5853	.6348
Max	.6722	.7095	.7468	.6908	.7095	.6348	.7095
Min	.4252	.3801	.4108	.3734	.3361	.3258	.3547
Avg	.5594	.5696	.5822	.5783	.5394	.4789	.5197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 201 / 11 KV SONALA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2936	1.3676	1.3443	1.3443	1.3306	1.3306
2	1.2803	1.2936	1.307	1.3306	1.307	1.2936	1.2936
3	1.2308	1.2696	1.2696	1.2567	1.2136	1.2197	1.2437
4	1.1765	1.2136	1.2012	1.2567	1.2696	1.2567	1.2696
5	1.1222	1.1458	1.1827	1.2197	1.1203	1.1088	1.1949
6	1.1888	1.1273	1.1576	1.0349	1.1576	1.1458	1.1389
7	1.0242	1.1088	1.1088	.9979	1.0059	.9979	1.1827
8	.9511	1.0349	.9979	.9055	.9328	1.0082	1.1827
9	.9328	.961	.924	.924	.9511	1.0082	1.0719
10	.9511	.9979	.9979	1.0164	.9694	.924	1.086
11	.9145	1.0349	1.0903	.9979	1.0082	.924	1.0608
12	1.0349	1.0534	1.0349	1.0974		.9425	1.0425
13	1.1088	1.0534	1.0719	1.1706	.961	.961	
14	1.1827	1.0349	1.1643	1.2071	.961	.961	1.1157
15	1.1458	1.1088	1.1643	1.2254	1.1088	.9979	1.1576
16	1.1458	1.1643	1.1827	1.134	1.2382	1.0903	1.1523
17	1.1827	1.1827	1.0903	1.0974		1.1088	1.0608
18	1.2936	1.2567	1.1949	.9145	1.0974	1.1706	.9877
19	1.3306	1.2936	1.419	1.134	1.2254	1.1888	
20	1.3676	1.3676	1.4563		1.386	1.2254	1.3817
21	1.423	1.423	1.4563		1.475	1.3676	1.4998
22	1.4045	1.4045	1.4563		1.46	1.46	1.5364
23	1.3676	1.3676	1.419		1.4415	1.46	
24	1.2986	1.2936	1.3491	1.3817	1.4377	1.423	1.4415
Max	1.423	1.423	1.4563	1.3817	1.475	1.46	1.5364
Min	.9145	.961	.924	.9055	.9328	.924	.9877
Avg	1.1808	1.1869	1.2110	1.1323	1.1851	1.1489	1.2110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 202 / 11 KV SONALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.7209		.0509		.0497	.0332
2	.6478	.7209		.0509		.0503	.0358
3	.6154	.6706	.9061	.0509		.0503	.0373
4	.6706	.6836	.9374	.0509		.0497	.037
5	.6802	.6836	.9374	.0503		.0497	.037
6	.7125	.6836	.9145	.0503		.0497	.0381
7	.7865	.7133	.9145				
9			.8916				
10			1.0242				
11			1.0437	1.1934		1.1561	
12			1.0753	1.1984		1.1561	
13			1.0437	1.2308	1.3923	1.1561	
14			1.0437	1.2071	1.3923	1.1248	
15			1.0437	1.2146	1.2498	1.1111	
16			1.0437	1.2308	1.2346	1.0802	
17			1.1065	.9717		1.0802	
18					1.0936	1.0802	
19					1.0936		
20	.0663	.0671	.0503		.0503	.0503	
21	.0663	.0671	.0503		.0497	.0503	
22	.8215	.8718	.0503		.0503	.0332	
23	.779	.9054	.0503		.0497	.0332	
24	.7045	.7127	.9145	.0503	.0503	.0497	.0332
Max	.8215	.9054	1.1065	1.2308	1.3923	1.1561	.0381
Min	.0663	.0671	.0503	.0503	.0497	.0332	.0332
Avg	.6046	.6251	.7917	.6144	.7006	.4979	.0359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 203 / 11 KV SAGODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7712	.7712	.7712	.0503		.0503	.0537
2	.7377	.7682	.7625	.0503		.0497	.056
3	.7377	.7682	.6796	.0503		.0492	.056
4	.7287	.7621	.7773	.0503		.0497	.056
5	.7537	.7621	.7773	.0503		.0503	.0572
6	.7449	.7773	.7811	.0503		.0509	.0572
7	.7773	.7621	.8097				
9			1.0623				
10			1.1203				
11			1.1363	1.5249		1.4403	
12			1.1843	1.5223	1.3245	1.4563	
13			1.2483	1.643	1.3245	1.4563	
14			1.2651	1.4575	1.3413	1.4232	
15			1.2651	1.3603	1.4754	1.406	
16			1.2018	1.2955	1.4723	1.3592	
17				1.0898		1.3123	
18				1.1336	.9998	1.2811	
19					.9998		
20	.0503	.0503	.0503		.0503	.0503	
21	.0503	.0497	.0503		.0503	.0503	
22	.8048	.8048	.0503		.0497	.0497	
23	.8048	.7956	.0503		.0503	.0503	
24	.7611	.7712	.828	.0503	.0486	.0503	.0503
Max	.8048	.8048	1.2651	1.643	1.4754	1.4563	.0572
Min	.0503	.0497	.0503	.0503	.0486	.0492	.0503
Avg	.6435	.6536	.7936	.7586	.7656	.6150	.0552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 204 / 11 KV PALSODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0339	.0377	.2652	.3605	.3315	.362
2		.0339	.0377	.2683	.3353	.3353	.3658
3		.0381	.0381	.2683	.3018	.3353	.3696
4		.0381	.0381	.3018	.2949	.3688	.3326
5		.0381	.0381	.3353	.3353	.3647	.3395
6		.0381	.0381	.3688	.3932		.3018
7				.4024	.4862	.3978	.3772
8				.4694	.503	.4641	.4527
9	.5182	.6224		.3688	.4694	.4641	.5281
10	.5407	.5658		.2984	.3768	.4973	.4527
11	.5243	.4527					.4527
12	.4024	.3772					.4424
13	.3506	.3772					.4191
14	.3206	.3772					.285
15	.3395	.3772					.3185
16	.415	.3395					.4024
17							.4359
18							.4359
20	.0332	.0339	.0335		.0343	.0343	
21	.0332	.0343	.0335		.0339	.0343	
22	.0332	.0343	.0335		.0335	.0358	
23	.0328	.0343	.0335		.0332	.0358	
24		.0332	.0381	.0335	.0335	.0332	.0362
Max	.5407	.6224	.0381	.4694	.503	.4973	.5281
Min	.0328	.0332	.0335	.0335	.0332	.0332	.0362
Avg	.2953	.2042	.0364	.3073	.2683	.2666	.3742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 205 / 11 KV PINGLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3315	.2984		1.6385	1.4918	1.3592
2		.3315	.2984		1.7695	1.5089	1.326
3		.3277	.3018		1.643	1.5249	1.3413
4		.3353	.3018		1.6095	1.576	1.3413
5		.3353	.2683		1.6766	1.5581	1.2407
6		.3315	.2652		1.7859	1.6278	1.1603
7					1.8023	1.6095	1.1574
8					1.7328	1.643	1.1431
9	1.9334	1.9204			1.6766	1.6766	1.1443
10	1.8785	1.989			1.5223	1.6575	1.4754
11	1.9498	1.9559					1.5089
12	2.0388	1.8233					1.576
13	1.8233	1.8233					
14	1.704	1.7901					
15	1.8233	1.7901					1.5089
16	2.0119	1.8351					
18							1.4251
20	.3315	.3315			.285	.285	
21	.3277	.3277			.285	.2818	
22	.3315	.3315			.3018	.2652	
23	.3315	.3315			.2883	.2622	
24	.3277	.3315	.3315	1.0288	.2267	.285	.2515
Max	2.0388	1.989	.3315	1.0288	1.8023	1.6766	1.576
Min	.3277	.3277	.2652	1.0288	.2267	.2622	.2515
Avg	1.2933	.9776	.2951	1.0288	1.2163	1.1502	1.2640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 206 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.6299	.6554	.0335		.0339	.0358
2	.5571	.6299	.6325	.0335		.0335	.0373
3	.5571	.583	.6958	.0335		.0332	.0373
4	.5735	.5556	.7186	.0335		.0335	.0377
5	.5898	.5556	.7499	.0335		.0339	.0377
6	.5898	.5556	.7811	.0335		.0339	
7	.6226	.5247	.7811				
9			.8749				
10			1.012				
11			1.1069	1.3923		1.5813	
12			1.1385	.9831	1.5089	1.5813	
13			1.1385	.7773	1.4918	1.5813	
14			1.1203	1.2125	1.4918	1.5623	
15			1.1069	1.2308	1.4918	1.5432	
16			1.1069	1.2289	1.4575		
17				1.1984		1.5123	
18				1.2955	1.2967	1.4506	
19					1.2967		
20	.0332	.0332	.0335		.0339	.0335	
21	.0332	.0335	.0335		.0339	.0335	
22	.547	.5868			.0335	.0335	
23	.5967	.5967	.0335		.0339	.0332	
24	.6371	.6299	.8539	.0335	.0335	.0339	.0332
Max	.6371	.6299	1.1385	1.3923	1.5089	1.5813	.0377
Min	.0332	.0332	.0335	.0335	.0335	.0332	.0332
Avg	.4939	.4929	.7670	.6369	.8503	.6212	.0365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 201 / 11 KV DEULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3081	.3391	.2429	.2286	
2			.3041	.3467	.2429	.2286	
3				.3391	.2267	.2286	
4			.2961	.3467	.2267	.2286	
5			.2961	.3506	.2267	.2286	
6			.3521	.3467	.2267	.1677	
7			.3521	.3467	.3077	.1677	
8				.3506	.3239	.1677	
9	.3077			.3391	.3239	.1677	
10	.3239			.362	.3077	.2134	
11	.3239						.2896
12	.2591					.2286	.2934
13	.3077					.2709	.2713
14	.3563					.2258	.3052
15	.3048					.2408	.3391
16	.3048					.2408	.2774
17						.2591	.2774
18						.2743	.2774
22		.2972					
23		.3269					
24			.3081				
Max	.3563	.3269	.3521	.362	.3239	.2743	.3391
Min	.2591	.2972	.2961	.3391	.2267	.1677	.2713
Avg	.3110	.3121	.3167	.3467	.2656	.2216	.2914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 202 / 11KV PATURDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.7316		.7682	.7602	.7682	.724
2	.8145	.7316		.7186	.724	.7316	.724
3	.7783	.6584		.7316	.724	.695	.724
4	.7783	.6283	.7164	.7316	.6878	.6584	.6878
5	.7602	.5914	.7164	.724	.6697	.6219	.6805
6	.724	.5914	.6447	.6516	.6335	.6036	.5731
7	.5973	.5175	.5194	.5611	.5249	.5487	.4835
8	.4887	.4938	.5249	.4887	.543	.4755	.4344
9	.5611	.5121	.567	.6154	.5068	.439	.5014
10	.6516	.5249	.6024	.6516	.5792	.5121	.5068
11	.6516	.6401	.6379	.6584	.5973	.547	.591
12	.6878	.6516	.6733	.6878	.6516	.5729	.5973
13	.7059	.6984	.695	.7783	.7316	.5973	.6584
14	.724	.6984	.7316	.7602	.724	.6335	.6516
15	.724	.6447	.695	.724	.724	.6697	.6767
16	.724	.6268	.7133	.7059	.7059	.6335	.6767
17		.6447	.7133	.6335		.5973	.6154
18	.6219	.6516	.7133	.543	.6219	.5611	.6219
19	.7133	.6516	.7133	.6697	.7316	.5792	.7316
20	.8596	.8326	.8962	.724	.8596	.7602	.8413
21	.8596	.8326	.8688	.8145	.8596	.7783	.8413
22	.8596	.8326	.8326	.724	.8413	.7783	.8507
23	.823	.7964	.7865	.7964	.8048	.7602	
24	.8326	.7682		.7682	.7964	.7682	.724
Max	.8596	.8326	.8962	.8145	.8596	.7783	.8507
Min	.4887	.4938	.5194	.4887	.5068	.439	.4344
Avg	.7285	.6646	.6981	.6929	.6958	.6371	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 203 / 11 KV KODRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2286				
2	.2267	.2286				
3	.2267	.1981				
4	.2267	.1981				
5	.2267	.1981				
6	.2267	.1829				
7	.1619	.1677				
8						.0743
9		.2134	.2397			.1355
10		.2591	.2641			.1337
11		.3201	.2641	.2543	.3401	
12		.3506	.2934	.2543	.3077	
13		.3243	.3467	.2429	.3201	
14		.2961	.3391	.2429	.3201	
15		.2538	.39	.2429	.3201	
16		.2679	.373	.2753		
17				.2429		
18				.2429	.1372	
22	.2134					
23	.2286					
24	.2429	.2286				
Max	.2429	.3506	.39	.2753	.3401	.1355
Min	.1619	.1677	.2397	.2429	.1372	.0743
Avg	.2223	.2448	.3138	.2498	.2909	.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 204 / 11 KV KAVTHAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2134				
2		.2134				
3		.2134				
4		.2286	.1269			
5		.2286	.141			
6		.2286	.1448			
7		.2286	.2027			.0312
8						.1054
9			.2172			.1656
10			.2751			.1614
11			.2172	.2374	.3239	.1448
12			.2172	.2713	.2753	.176
13			.2713	.2753	.2743	
14			.2774	.2591	.2743	
15			.2774	.2267	.2743	
16			.2947	.2267	.2743	
17				.2267		
18				.2105		
22	.2286	.208				
23	.2134	.1783				
24		.2134				
Max	.2286	.2286	.2947	.2753	.3239	.176
Min	.2134	.1783	.1269	.2105	.2743	.0312
Avg	.221	.2154	.2219	.2417	.2827	.1307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 205 / 11KV KAWTHAL GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.5359	.5373	.5611	.5544	.5175
2		.5544	.5304	.5487	.5611	.5544	.5175
3		.5544	.5304	.5373	.543	.5544	.5175
4		.5175	.5304	.5068	.5068	.5544	.5175
5		.4435	.5121	.5121	.4887	.5544	.5304
6		.4435	.567	.4887	.4344	.5729	.5121
7		.4435	.499	.4938	.5249	.5175	.4755
8		.5175	.462	.4938	.4706	.4805	.3696
9		.4755	.4207	.4656	.4344	.5175	.3881
10		.5121	.4572	.5373	.5068	.3511	.3511
11		.4938		.5068	.5249	.4251	.4251
12		.4938		.5068	.4344		.4435
13		.4938		.543	.4572		.4477
14		.4938	.4298	.543	.4572		.4755
15	.5121		.5373	.543	.4755	.5359	.5068
16	.5121	.5121	.5373	.543	.4755	.5729	.4887
17	.5304	.5304	.543	.5249		.5729	.4706
18	.5487	.5175	.5611	.4887	.4805	.5359	.4525
19	.6584	.5729	.5792	.543	.5359	.6099	.5068
20	.7316	.695	.7602	.6335	.6468	.6767	.5792
21	.7207	.6767	.7059	.543	.6838	.6584	.6516
22	.6468	.6283	.6584	.5973	.6283	.5853	.6036
23	.5729	.5544	.5853	.5792	.5729	.5544	
24		.5544	.5359	.5487	.5611	.5544	.5359
Max	.7316	.695	.7602	.6335	.6838	.6767	.6516
Min	.5121	.4435	.4207	.4656	.4344	.3511	.3511
Avg	.6037	.5319	.5466	.5319	.5203	.5473	.4906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 201 / 11KV TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.419	1.419	1.2696	1.2696	1.3443	1.2323
2	1.2323	1.3443	1.419	1.2323	1.2696	1.307	1.2323
3	1.2323	1.3443	1.3443	1.1949	1.2696	1.2696	1.2323
4	1.2323	1.307	1.3443	1.1949	1.2323	1.2323	1.2323
5	1.2323	1.2323	1.2323	1.1949	1.2323	1.1203	1.2323
6	1.1949	1.0829	1.1203	1.1203	1.0456	1.0456	.9709
7	1.0456	1.0082	1.0082		1.0456	.9335	.8962
8	1.0456	.9335	.9709	.9709	.9709		.7468
9	.9335	.9335	.8962	1.0082	.9709	.8215	.8589
10	1.0456	1.0082		1.0456	1.0456	.8215	1.0082
11	1.1203	1.0082	1.1949	1.1203	1.0829	.8962	1.0082
12	1.1949	1.1949	1.1949	1.1949	1.1203	.8962	1.0829
13	1.3443	1.2696	1.2696	1.2696	1.2323	1.0456	1.307
14	1.307	1.307	1.3443	1.3817	1.307	1.1203	1.307
15	1.4563	1.3443	1.419	1.4563	1.4563	1.1949	1.3817
16	1.419	1.3817	1.419	1.4563		1.1949	1.3817
17	1.419	1.307	1.3443	1.3817		1.1203	1.3817
18	1.3443	1.2323	1.1949	1.2696	1.3443	1.0456	1.2696
19	1.3443	1.2323	1.3443	1.2696	1.3443	1.1949	1.2696
20	1.419	1.3443	1.3817	1.2696	1.3443	1.2696	1.3443
21	1.419	1.3817	1.419	1.3443	1.419	1.1949	1.4937
22	1.4563	1.4563	1.4563	1.419	1.4563	1.3443	1.419
23	1.4937	1.2696	1.531	1.4937	1.419	1.3443	1.419
24	1.4937	1.4563	1.2696	1.4937	1.419	1.3443	1.3443
Max	1.4937	1.4563	1.531	1.4937	1.4563	1.3443	1.4937
Min	.9335	.9335	.8962	.9709	.9709	.8215	.7468
Avg	1.2790	1.2416	1.2842	1.2631	1.2408	1.1349	1.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 202 / 11KV TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0829	1.2323	1.1949	1.1949	1.2323	1.0456
2	1.0082	1.0456	1.1949	1.1576	1.1576	1.1949	1.0456
3	1.0082	1.0456	1.1576	1.1576	1.1576	1.1576	1.0456
4	.9709	1.0082	1.1576	1.1576	1.1576	1.0829	1.0456
5	.8962	.8589	1.0456	1.1203	1.1576	.9709	1.0456
6	.7468	.7468	.9335	.8962	.8215	.8215	.8215
7		.5975	.8215	.7468	.7468	.7468	.7468
8	.6722		.7468	.7468	.7468		
9	.5975	.5975	.7095	.7468	.7468	.5601	.5975
10	.5975	.5975	.6722	.7468	.7095	.5975	.6348
11	.6722	.6348	.7468	.7842	.7842	.7095	.7468
12	.7468	.7468	.8962	.8589	.8589	.7095	.7468
13	.8215	.8215	.8962	.9709	.9709	.6348	.8589
14	.8962	.8589	1.0456	1.0456	1.0082	.8215	.9335
15	.9709	.8589	1.1203	1.1203	1.0456	.8962	1.0082
16	.8962	.9335	1.1203	1.1949		.9335	1.0829
17	.9335	.8962	1.0456	1.1203		.8962	.9335
18	.8962	.7842	.8962	.9335	1.1203	.7468	.9335
19	.8215	.8962	.9709	.9709	.9709	.8215	.8962
20	.8962	1.0456	1.0829	1.0456	1.1203	.8962	1.1949
21	.9709	1.0829	1.0829	1.0456	1.1949	.8962	1.1203
22	1.0082	1.1949	1.1949	1.1203	1.1949	1.0456	1.1949
23	1.0829	1.2696	1.307	1.2696	1.2696	1.1203	1.3443
24	1.1949	1.0829	1.2696	1.2696	1.3443	1.2696	1.1203
Max	1.1949	1.2696	1.307	1.2696	1.3443	1.2696	1.3443
Min	.5975	.5975	.6722	.7468	.7095	.5601	.5975
Avg	.8848	.8995	1.0145	1.0176	1.0218	.9027	.9628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 203 / 11 KV ALASNA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.0166	.0332	.0663	.0332	.0166	.0166
2	.0166	.0166	.0332	.0663	.0332	.0166	.0166
3	.0166	.0166	.0332	.0663	.0663	.0166	.0166
4	.0166	.0166	.0332	.0663	.0663	.0166	.0166
5	.0166	.0166	.0663	.0663	.0663	.0166	.0166
6	.0166	.0166	.0663	.0663	.0663	.0166	.0166
7			.0663	.0663	.0663		
8				.0995	.0663		
9	.0995	.0995		.0663	.0663		
10	.112	.0995		.0332	.0663		
11	.0747	.0995				.0663	.0995
12	.112	.0663				.0663	.0663
13	.0663	.0663				.0995	.0663
14	.0663	.0332				.0663	.0663
15	.0663	.0663				.0663	.0663
16	.0663	.0332				.0663	.0663
17						.0663	.0663
18						.0663	.0663
20	.0166	.0166	.0166		.0166	.0166	.0166
21	.0166	.0166	.0166	.0187	.0187	.0166	.0166
22	.0166	.0332	.0166	.0166	.0166	.0166	.0166
23	.0166	.0373		.0166	.0332	.0166	.0166
24	.0166	.0166	.0663	.0166	.0166	.0166	.0166
Max	.112	.0995	.0663	.0995	.0663	.0995	.0995
Min	.0166	.0166	.0166	.0166	.0166	.0166	.0166
Avg	.0445	.0412	.0407	.0523	.0466	.0393	.0393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.3315	.4641	.3647	.4481	.3315	.431
2	.4108	.3315	.3647	.3647	.3978	.3978	.431
3	.3647	.2984	.3647	.3647	.3978	.3978	.3978
4	.3647	.2652	.3647	.3647	.3978	.3647	.3978
5	.3647	.3315	.3978	.3315	.3647	.3978	.3978
6	.3647	.2984	.3647	.3315	.3647	.3647	.3978
7	.1326	.1658	.2652	.1989	.2321	.2984	.2321
8	.1989	.2321	.2652	.1989	.2652		.1989
9	.1658	.3978	.2321	.3315	.431	.3315	.2321
10	.2321	.4641	.2652	.2984	.3978	.2652	.2987
11	.2321	.3978	.431	.3647	.3978	.3315	.3647
12	.2652	.2984	.3315	.3647	.3647	.3978	.3315
13	.2652	.2321	.2984	.2984	.431	.3647	.2652
14	.0995	.2321	.1989	.2984	.2984	.2984	.2652
15	.2984	.3647	.2652	.2984	.2984	.431	.3315
16	.2984	.431	.4641	.3978		.5304	.3647
17	.1989	.3647	.4641	.4481		.4641	.431
18	.0995	.4641	.3647	.3315	.2984	.5304	.4854
19	.0995	.3647	.3647	.3647	.3315	.431	.3315
20	.0995	.4973	.3978	.3315	.2652	.431	.4641
21	.2321	.3315	.3315	.3315	.2984	.2984	.2321
22	.3647	.4973	.3978	.431	.2652	.2652	.2652
23	.2984	.4641	.3315	.3978	.2984	.2984	.3315
24	.1989	.2652	.3978	.3647		.1989	.3647
Max	.4108	.4973	.4641	.4481	.4481	.5304	.4854
Min	.0995	.1658	.1989	.1989	.2321	.1989	.1989
Avg	.2506	.3467	.3495	.3405	.3450	.3661	.3435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 205 / ALASNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3734	.4481	.4481	.4481	.4108	.9709
2	.4481	.4108	.3734	.4481	.4481	.4108	.4108
3	.4481	.3734	.4108	.4108	.4481	.4108	.4108
4	.4108	.4108	.4481	.4108	.4481	.3734	.4108
5	.4108	.4108	.4481	.4108	.4481	.4108	.4108
6	.4108	.3734	.4108	.4108	.4108	.4108	.4108
7	.2987	.2987	.2987	.2987	.3361	.3361	.3361
8	.3361	.2987	.2987	.3361	.2614		.2987
9	.3361	.3361	.3361	.3361	.3361	.2614	.2987
10	.2614	.3361	.3361	.2987	.3361	.2987	.2614
11	.3361	.2987		.2987	.2987	.2614	.3361
12	.2987	.2614		.3361	.2987	.3361	.3734
13	.4481	.4108	.3361	.3734	.4481	.2987	.3361
14	.3734	.3734	.4108	.4108	.4108	.2241	.4108
15	.4108	.4108	.3734	.4108	.3361	.3361	.4108
16	.4481	.4108	.4854	.4108		.3734	.4108
17	.3734	.3734	.3361	.3734		.3361	.3734
18	.3734	.3734	.3734	.3734	.0373	.3734	.3734
19	.3734	.3734	.3734	.4108	.3361	.3361	.3361
20	.4854	.5601	.5228	.4481	.4481	.4854	.5228
21	.5601	.5228	.4854	.4854	.5228	.4481	.4854
22	.4481	.5228	.5601	.5601	.5228	.5228	.4481
23	.4854	.4481	.4481	.4854	.5228	.4481	.4854
24	.4108	.4108	.4854	.5228	.4481	.4481	.4481
Max	.5601	.5601	.5601	.5601	.5228	.5228	.9709
Min	.2614	.2614	.2987	.2987	.0373	.2241	.2614
Avg	.4014	.3905	.4091	.4045	.3887	.3718	.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/Stn

Feeder No / Name : 206 / 11 KV ENGG COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3443	1.3203	1.2323
2		1.3443	1.3203	1.2323
3		1.307	1.2826	1.1576
4		1.307	1.2071	1.1576
5		1.307	1.1317	1.1576
6		1.0456	1.0562	.8962
7		.8962	.9054	.7468
8		.7468	.9054	
9	.9431	.8676	.8215	.7842
10	.9808	.9808	.8215	.7842
11	.9808	1.0185	.8215	.8215
12	1.0185	1.0562	.8962	.8589
13	1.1694	1.1317	.8962	1.0082
14	1.3203	1.3203	.8215	1.0829
15	1.3957	1.3203		1.1576
16	1.358		1.1694	1.2323
17	1.3817		1.1317	1.2323
18	1.2826		.9808	1.0829
19	1.1949	1.1949	1.0456	1.1203
20	1.2696	1.1949	1.1203	1.1949
21	1.2696	1.2071	1.1203	1.3443
22	1.4937	1.4335	1.2323	1.3443
23	1.5684	1.5089	1.2696	1.4937
24		1.419	1.4335	1.2696
Max	1.5684	1.5089	1.4335	1.4937
Min	.9431	.7468	.8215	.7468
Avg	1.2418	1.1882	1.0744	1.1040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M
S/StnFeeder No / Name : 400 / 33/0.4Kv Station Xmer
Feeder KV- 33 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2241	.2241	.3361	.2241	.2241	.2241
2	.2241	.2241	.2241	.2241	.2241	.2241	.2241
3	.2241	.2241	.2241	.2241	.2241	.2241	.2241
4	.2241	.2241	.2241	.2241	.2241	.2241	.2241
5	.2241	.2241	.2241	.2241	.2241	.2241	.2241
6	.2241	.2241	.2241	.2241	.2241	.2241	.2241
7	.2241	.2241	.112	.2241	.112	.112	.112
8	.2241	.2241	.112	.112			.112
9	.2241	.2241		.112	.2241	.2241	.2241
10	.112	.112		.2241	.2241	.112	.112
11	.112	.2241		.2241	.2241	.2241	.2241
12	.2241	.2241	.2241	.2241	.2241	.2241	.2241
13	.2241	.2241	.2241	.2241	.2241	.2241	.2241
14	.2241	.2241	.2241	.2241	.2241	.112	.3361
15	.2241	.2241	.3361	.2241	.2241	.112	.3361
16	.2241	.2241	.2241	.2241		.2241	.3361
17	.2241	.2241	.2241	.2241		.112	.3361
18	.2241	.2241	.2241	.2241	.2241	.2241	.2241
19	.3361	.2241	.2241		.2241	.112	
20	.2241	.2241	.2241	.2241	.2241	.2241	
21	.2241	.2241	.2241	.2241	.2241	.2241	.2241
22	.2241	.2241	.3361	.2241	.2241	.2241	.2241
23	.2241	.2241	.3361	.2241	.2241	.2241	.2241
24	.2241	.2241	.2241	.2241	.2241	.2241	.2241
Max	.3361	.2241	.3361	.3361	.2241	.2241	.3361
Min	.112	.112	.112	.112	.112	.112	.112
Avg	.2241	.2194	.2294	.2192	.2188	.1949	.2292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 200 / STATION T/F

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0293	.0309	.0328	.0293	.0309	.0328	.0271
2	.0293	.0305	.0259	.0293	.0309	.0328	.0271
3	.0293	.0305	.0328	.0293	.0309	.0328	.0271
4	.0293	.0305	.0328	.0293	.0309	.0328	.0271
5	.0293	.0305	.0328	.0293	.0309	.0328	.0271
6	.0293	.0305	.0328	.0293	.0309	.0328	.0271
7	.0293	.0305	.0328	.0293	.0309	.0328	.0271
8	.0293	.0305	.0328	.0293	.0305	.0328	.0271
9	.0293	.0305	.0328	.0293	.0305	.0328	.0271
10	.0293	.0293	.0328	.0293	.0305	.0293	.0305
11	.0328	.0293	.0328	.0328	.0271	.0293	.0305
12	.0328	.0293	.0259	.0328	.0271	.0293	.0305
13	.0328	.0293	.0328	.0328	.0271	.0293	.0305
14	.0328	.0293	.0328	.0328	.0271	.0293	.0305
15	.0328	.0293	.0328	.0328	.0271	.0293	.0305
16	.0339	.0293	.0328	.0328		.0293	.0305
17	.0328	.0293	.0328	.0328		.0293	
18	.0373	.0293	.0328	.0328	.0328	.0293	.0293
19	.0312	.0328	.0297	.0305	.0328	.0271	.0293
20	.0309	.0328	.0293	.0305		.0271	.0293
21	.0309		.0293	.0762	.0328	.0271	.0293
22	.0312	.0328	.0293	.0305	.0328	.0271	.0293
23	.0309	.0328	.0293	.0305	.0328	.0271	.0293
24	.0293	.0309	.0328	.0293	.0309	.0328	.0271
Max	.0373	.0328	.0328	.0762	.0328	.0328	.0305
Min	.0293	.0293	.0259	.0293	.0271	.0271	.0271
Avg	.0311	.0305	.0315	.0326	.0304	.0303	.0287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 201 / 11 KV ANAND SAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.1888	1.251	1.2012	1.2437	1.307	1.1203
2	1.2012	1.1706	1.251	1.1643	1.1888	1.2696	1.1203
3	1.1643	1.1523	1.2136	1.1088	1.1706	1.2323	1.1203
4	1.1088	1.134	1.1949	1.0719	1.0608	1.1576	1.0829
5	1.0903	1.0059	1.0456	1.0349	1.0059	1.1203	1.0456
6	.9979	.8413	.8775	.961	.9145	1.0082	.8962
7	.961	.8413	.8402	.9425	.9694	.9335	.9335
8	.9979	.9511	1.0082	.9795	.9145	.7468	.8962
9	.961	.9511	1.0456	.9979	.9511	.8402	.9335
10	1.0164	.961	.8589	.961	.9511	.924	.9511
11	1.0456	1.0164	.9335	1.0082	1.0269	.924	.9145
12	.9709	1.0164	.8962	1.0456	.9709	.9425	.9328
13	1.0456	1.0534	.8962	1.0456	.9709	1.0164	.9511
14	1.0456	1.0903	1.0082	1.1576	1.1949	1.0164	.9877
15	1.1763	1.1273	1.0456	1.2323	1.2136	1.0719	1.0242
16	1.2136	1.1643	1.0456	1.2696		1.0349	1.0242
17	1.1203	1.1088	1.1203	1.0082		1.0349	.9877
18	1.1203	1.0164	.8962	.9709	1.1203	.924	.8316
19	.9511	1.1203	1.0164	.9877	1.1203	.9335	.924
20	1.0425	1.1203	1.0164	1.0608	1.1203	1.0269	1.0349
21	1.0608		1.0903	1.0974	1.1576	1.0269	1.1088
22	1.2071	1.2136	1.1273	1.2437	1.2696	1.1203	1.1643
23	1.2437	1.2696	1.2382	1.3169	1.419	1.1576	1.2752
24	1.2936	1.2071	1.2323	1.2752	1.2803	1.3443	1.1949
Max	1.2936	1.2696	1.251	1.3169	1.419	1.3443	1.2752
Min	.9511	.8413	.8402	.9425	.9145	.7468	.8316
Avg	1.0940	1.0749	1.0479	1.0893	1.1016	1.0464	1.0190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 202 / 11KV Nagzari AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3361	.2429	.1928		.0747
2	.0663	.0739	.2785	.2105	.2103		.0747
3	.0829	.0739	.2949	.2267	.2103		.0747
4	.0829	.0739	.2883	.2105	.2279		.0747
5	.0663		.2883	.2105	.2454		.0747
6			.4096	.421	.3561		
7			.4096	.3725	.4359		
8				.421	.3521		
9	.4858	.4694		.3401	.3121		
10	.4534	.4372		.3725	.298		
11	.426	.4049				.3563	.5365
12	.407	.3725				.4534	.4862
13	.3768	.3563				.3887	
14	.3605	.3563	.0655			.3401	.208
15	.373	.3725	.0819			.3887	
16	.3561	.3725	.0819			.3887	.2427
17			.0819	.0819		.3887	.4858
18			.0983	.0819		.3239	.4858
19			.0995	.2033			.4049
20	.0739	.0819	.116			.0747	.0995
21	.0739		.0995			.0747	.0829
22	.0739	.3734	.116	.0739	.0655	.0747	.2486
23	.0739	.2949	.116	.0739	.0678	.0747	.0995
24		.0739	.2949	.0995	.0739	.0655	
Max	.4858	.4694	.4096	.421	.4359	.4534	.5365
Min	.0663	.0739	.0655	.0739	.0655	.0655	.0747
Avg	.2395	.2792	.1976	.2277	.2345	.2610	.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 203 / 11 KV GM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9774	1.9387	1.7924	1.8296	1.7558	1.8298	1.6617
2	1.9404	1.9022	1.7737	1.7556	1.7375	1.8298	1.643
3	1.848	1.8473	1.7551	1.7002	1.701	1.7924	1.643
4	1.8296	1.829	1.7177	1.6632	1.6095	1.7177	1.587
5	1.7556	1.7558	1.7177	1.6263	1.5546	1.6804	1.5497
6	1.7187	1.6644	1.6057	1.5708	1.4632	1.531	1.3817
7	1.4415	1.4083	1.4937	1.3676	1.4266	1.3817	1.2136
8	1.4045	1.39	1.3443	1.386	1.2986	1.3443	1.1949
9	1.423	1.4632	1.307	1.2752	1.2803		1.1389
10	1.4045	1.5893	1.4937	1.4784	1.4632	1.4784	1.2071
11	1.531	1.6263	1.531	1.4937	1.587	1.4969	1.3717
12	1.4937	1.6448	1.643	1.6057	1.6244	1.4045	1.4449
13	1.7924	1.8111	1.6804	1.7924	1.6804	1.4969	1.4632
14	1.8671	1.848	1.8671	1.8484	1.8298	1.5154	1.6461
15	1.9044	1.8665	1.8298	1.7924	1.8484	1.5524	1.6644
16	1.8298	1.7556	1.7924	1.7177		1.5154	1.6644
17	1.6804	1.6448	1.6804	1.643		1.386	1.4632
18	1.6057	1.5524	1.0456	1.4937	1.531	1.3121	1.4045
19	1.7551	1.531	1.6817	1.4815	1.5684	1.4937	1.4415
20	1.8656	1.6804	1.848	1.6827	1.6804	1.6057	1.6448
21	1.9387		1.8665	1.7193	1.9791	1.6244	1.7741
22	2.0119	1.7924	1.9589	1.7741	1.9418	1.6804	1.7741
23	2.0485	1.7737	1.922	1.829	1.9044	1.643	1.8111
24	2.0513	1.9753	1.8298	1.848	1.7741	1.8671	1.6057
Max	2.0513	1.9753	1.9589	1.8484	1.9791	1.8671	1.8111
Min	1.4045	1.39	1.0456	1.2752	1.2803	1.3121	1.1389
Avg	1.7550	1.7083	1.6741	1.6406	1.6473	1.5730	1.5164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 204 / 11KV CHINCHOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.3052	.1147	.0995	.1848	.0655	.2134
2	.2591	.2947	.0983	.0829	.2033	.0655	.2214
3	.2753	.2947	.112	.0829	.1848	.0819	.2187
4	.2591	.2713	.0983	.116	.1848	.0655	.216
5	.3077	.3467	.0983	.0995	.1663	.0655	.2315
6	.4372	.4409	.1638	.1326	.1663	.0655	.4012
7	.4696	.5533		.1478	.1663	.0819	.4321
8	.4534			.1492	.1478	.0819	.4012
9			.4915			.0819	.3241
10	.1326	.116	.5243			.081	.4527
11	.1187	.116	.5087	.5735	.3953		
12	.0983	.0829	.4096	.4096	.3163		
13	.0983	.0829	.3932	.3605	.3005	.1492	.1109
14	.1017	.0995	.3768	.3768	.3163	.2915	.1109
15	.1187	.0995	.3768		.3086	.2652	.1109
16	.1017	.0829	.3605	.3932		.1326	.1109
17	.112	.116		.4096		.1326	.1663
18				.3932			
19	.3605		.1326		.0492		
20	.3688	.1475	.1326		.0328	.1494	.116
21	.1478		.1326	.2033	.0351	.1494	.116
22	.3688	.1494	.0995	.2195	.0187	.1307	.116
23	.3391	.1147	.0995	.1848	.0164	.1307	.116
24	.2753	.3391	.0983	.0995	.1848	.0164	.1307
Max	.4696	.5533	.5243	.5735	.3953	.2915	.4527
Min	.0983	.0829	.0983	.0829	.0164	.0164	.1109
Avg	.2483	.2133	.2411	.2386	.1778	.1142	.2158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR
S

Feeder No / Name : 205 / 11KV NAGZRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2427	.168	.2033	.2054	.2054	.2054
2	.2402	.2427	.1867	.2218	.2241	.1867	.2054
3	.2587	.2241	.168	.2033	.2054	.1494	.2054
4	.2155	.2054	.168	.1848	.2241	.168	.2054
5	.2218	.1867	.1867	.2033	.2054	.1867	.2054
6	.2218	.168	.168	.1848	.1867	.168	
7	.2033	.1494	.1494	.1663	.1494	.1494	
8	.2033	.1307	.1494	.1663	.1494	.1307	
9	.1848	.1494	.168	.1478	.1494	.0934	
10	.1848	.1478	.168	.1848	.1494	.0924	
11	.2054	.1294	.1867	.2054	.168	.1109	.168
12	.2054	.1663	.1494	.2054	.1867	.1109	.2241
13		.1848	.1867	.2241	.2054	.2218	.2427
14	.2263	.2033	.2054	.2241	.2054	.2033	.2241
15	.2241	.1848	.2054	.2054	.2054	.2218	.2241
16	.2427	.1663	.2241	.2054		.2033	.2241
17	.2241	.1663	.2241	.2241		.2033	.2241
18	.2614	.1848	.1494	.2241	.1867	.1663	.2218
19	.2801	.2241	.2218	.2241	.2241	.2427	.2218
20	.3361	.2427	.3142	.2987	.2614	.2427	.2957
21	.2987	.2427	.2772	.2801	.2427	.2614	.2587
22	.2801	.2241	.2587	.2427	.2427	.2427	.2402
23	.2614	.1867	.2218	.2427	.2054	.2241	.2033
24	.2218	.2427	.168	.2033	.2241	.2054	.2054
Max	.3361	.2427	.3142	.2987	.2614	.2614	.2957
Min	.1848	.1294	.1494	.1478	.1494	.0924	.168
Avg	.2366	.1915	.1947	.2115	.2003	.1829	.2213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.Feeder No / Name : 200 / STSTION T/F
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4504	.3391	.4752	.5068	.4692	.4424
2	.4887	.4504	.3391	.4862	.5068	.4692	.4424
3	.4887	.4504	.3391	.4531	.4887	.4692	.4424
4	.5068	.4129	.3391	.4694	.4887	.4692	.4527
5	.4887	.4129	.3391	.4801	.5068	.4692	.4527
6					.4706		
19		.3391				.0655	
20	.4129	.3391	.4752	.5068		.4938	.4706
21	.4129	.3391	.4588	.5068	.4692	.4588	.4706
22	.5067	.3391	.4694	.4887	.4692	.4424	.4706
23	.4504	.3391	.4588	.4887	.4692	.4527	.4525
24	.5068	.4504	.3391	.4862	.4887	.4879	.4424
Max	.5068	.4504	.4752	.5068	.5068	.4938	.4706
Min	.4129	.3391	.3391	.4531	.4692	.0655	.4424
Avg	.4769	.3930	.3897	.4841	.4865	.4316	.4539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.

Feeder No / Name : 201 / 11KV TOWN RLY GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.7694	.8029	.9145	.924	.882	.9149
2	.9335	.7882	.7762	.8962	.924	.8632	.8402
3	.8962	.7882	.7842	.8962	.8871	.8257	.8402
4	.8962	.7906	.7842	.8962	.8871	.8445	.7842
5	.8589	.7694	.7842	.8402	.8501	.7882	.7468
6	.7468	.7319	.7577	.8029	.7762	.6944	.6722
7	.6584	.6756	.6535	.7282	.5544	.6381	.6722
8	.6036	.6944	.7842	.7655	.695	.6005	.6756
9	.6401	.7655	.7762	.6756	.7319	.6653	.6944
10	.7316	.8589	.8131	.8069	.8215	.7865	.7694
11	.823	.8215	.8871	.8445	.8257	.7316	.7694
12	.695	.7842	.823	.7882	.8632	.7499	.7694
13	.7499	.9335	.8029	.8471	.9195	.7499	.7319
14	.7316	.9709		.8632	.9758	.8413	.8069
15		.9896		.9946	.9571	.8962	.9571
16	.9145	1.0425	1.0082	.9758		.961	.7882
17	.9383	.9145	.9145	.8869		.7842	.815
18	.7319	.7577	.7682	.724	.6193	.7282	.6268
19	.7131	.6838	.8413	.823	.7694	.7842	.7682
20	.7506	.8871	.9335	.823	.7882	.8775	.8413
21	.7694	.7392	.9149	.8501	.9195	.8402	.823
22	.8445	.7762	1.0082	.924	.9195	.8962	.924
23	.8632	.8131	.9522	.9979	.9195	.9149	.9425
24	.924	.8632	.8029	.9709	.9425	.9008	.9149
Max	.9383	1.0425	1.0082	.9979	.9758	.961	.9571
Min	.6036	.6756	.6535	.6756	.5544	.6005	.6268
Avg	.7977	.8170	.8352	.8557	.8396	.8019	.7954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.

Feeder No / Name : 202 / LOHARA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3352	1.445	1.3443	1.419	1.3676	1.3136	.9149
2	1.3169	1.4262	1.3306	1.3535	1.3676	1.3136	1.2803
3	1.3169	1.4262	1.3443	1.3817	1.3306	1.2949	1.2803
4	1.2803	1.3136	1.307	1.3817	1.3306	1.2761	1.2696
5	1.2437	1.2386	1.307	1.307	1.2936	1.2761	1.2136
6	1.1706	1.1823	1.1643	1.1763	1.2197	1.201	1.0829
7	.9877	1.0509	1.0082	1.1016	1.0719	1.126	1.0642
8	.9694	1.0697	.9335	.8775	.9955	1.126	1.0321
9	1.0242	1.0269	.9425	1.126	1.0608		1.0884
10	1.0242	1.0059	.961	1.1072	1.0829	.9328	1.0697
11	1.0608	1.1203	1.0974	1.201	1.0884	.9877	1.126
12	1.1523	1.2136	1.1888	1.3136	1.126	1.0242	1.126
13	1.262	1.2803	1.3169	1.3699	1.201	1.1888	.9195
14	1.39	1.2803		1.4075	1.3136	1.1888	1.0697
15	1.2986	1.2986		1.4825	1.2949	1.1888	
16	1.2803	1.307	1.3352	1.4638		1.1706	1.2198
17	1.3136	1.1706	1.2803	1.2178		.4024	1.2071
18	1.3136	1.1458	1.1706	1.1393	.32	1.1888	1.1946
19	1.4825	1.2567	1.4632	1.2851	.4879	1.3443	1.3121
20	1.764	1.6078	1.7177	1.5893	.5067	1.5546	1.6095
21	1.764	1.6078	1.643	1.6057	1.7828	1.5546	1.6057
22	1.5764	1.5524	1.587	1.5339	.5255	1.4632	1.5154
23	1.5576	1.4045	1.4563	1.4784	1.4825	.8962	1.4415
24	1.386	1.4825	1.363	1.419	1.4045	1.3699	1.3169
Max	1.764	1.6078	1.7177	1.6057	1.7828	1.5546	1.6095
Min	.9694	1.0059	.9335	.8775	.32	.4024	.9149
Avg	1.3030	1.2881	1.2846	1.3224	1.1207	1.1906	1.2156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP
S/STN.Feeder No / Name : 203 / 11KV Janori Ag fdr
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3864	.4504					
2	.4012	.4504					
3	.4012	.4316					
4	.3864	.4504					
5	.4161	.4504					
6	.4199	.5255					
7	.4012	.5067					
9			.4572				
10			.5853				.4504
11			.5487	.7319	.6588		.4879
12			.567	.6756	.6568		.4879
13			.5487	.6193	.6005		.5255
14				.563	.563		.5442
15				.5818	.563		.5067
16			.5249	.5442			.5067
17				.5847		.4572	.547
18				.4481			.5228
19						.4572	
20						.4706	
22	.5255						
23	.4692						
24	.421	.4879					
Max	.5255	.5255	.5853	.7319	.6588	.4706	.547
Min	.3864	.4316	.4572	.4481	.563	.4572	.4504
Avg	.4228	.4692	.5386	.5936	.6084	.4617	.5088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 201 / 11 KV JALGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097				.1715		
2	.1075		.1029		.1543		
3	.1075		.1372		.1715		
4	.1075		.1543		.2058		
5	.1433		.2058		.2743		
6	.2507		.2572		.3429		
7	.3292		.3601				
8	.4801		.4287				
9	.4458		.5068	.4887		.5068	.6335
10		.2715		.0549		.4525	.543
11		.7602		.4525		.4344	.3982
12		.6335		.5792		.3258	.3077
13		.362		.543		.3077	.3258
14		.3258		.3077		.2715	.362
15		.3224		.2926		.3582	.3258
16		.3292		.2865		.3582	.3258
17		.3582				.3582	
21				.1463			.1029
22							.1029
23							.1372
24	.1075				.1372		
Max	.4801	.7602	.5068	.5792	.3429	.5068	.6335
Min	.1075	.2715	.1029	.0549	.1372	.2715	.1029
Avg	.2189	.4204	.2691	.3502	.2082	.3748	.3241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 202 / 11 KV SOOTGIRNI EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
 FEEDER Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.2801	.4668	.4481	.4481	.4294	.394
2	.4024	.2801	.4668	.4481	.4668	.4294	.4024
3	.4024	.2801	.4668	.4481	.4668	.4108	.4024
4	.4024	.2801	.4481	.4481	.4668	.4294	.4024
5	.394	.2801	.4481	.4668	.4481	.4481	.394
6	.394	.2801	.4854	.4854	.4668	.4481	.4024
7	.394	.2801	.4481	.5228	.4108	.4108	.4024
8	.4108	.4108	.4481	.5601	.4294		.4032
9	.4481	.4108	.4481	.3734	.4294	.4108	.3734
10	.4481		.4481	.3734	.4294	.4481	.3921
11	.2801	.4294	.4481	.3734	.4294	.4481	.4108
12	.2801	.4481	.4481	.3734	.4294	.4294	.4108
13	.2801	.4481	.4481	.3734	.4668	.4481	.4108
14	.2801	.4481		.3734	.4668	.4481	.4108
15	.2801	.439	.439	.2865	.4668	.4298	.4108
16	.2801	.439	.439	.2865	.4668	.4298	.4108
17	.2801	.439	.439	.394		.394	.4108
18	.2801	.439	.439	.394	.4481	.394	.4108
19	.2801	.439	.439	.4024	.4481	.4024	.4108
20	.2801	.439	.439	.4024	.4481	.4024	.4481
21	.2801	.439	.439	.4024	.4481		.4108
22	.2801	.439	.439			.4024	.4108
23						.4024	.4108
24	.4024	.2801	.4481	.4668	.4481	.4294	.4024
Max	.4481	.4481	.4854	.5601	.4668	.4481	.4481
Min	.2801	.2801	.439	.2865	.4108	.394	.3734
Avg	.3418	.3795	.4490	.4138	.4490	.4239	.4062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 203 / 11 KV JALGAON SUNGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.5384
Max	1.5384
Min	1.5384
Avg	1.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 204 / 11 KV ASALGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686		.0686		.0857	.2149
2		.0686		.0686		.0857	.2149
3		.0686		.0686		.0857	.2149
4		.0686		.1029		.1543	.2149
5		.0857		.12		.2229	.2507
6		.1029		.3772		.4287	.3582
7		.2915					
8		.2229					
9		.2715			.543		
10	.2058		.2715		.5792		
11	.5144		.362		.4525		
12	.4115		.362		.3982		
13	.3429		.3077		.2715		
14	.2572				.2172		
15	.2172		.2926		.2172		
16	.181		.2926		.181		
17	.2172		.2926				
21			.0732		.1086	.1463	
22			.0732			.2195	
24		.0857		.0857		.0857	.2149
Max	.5144	.2915	.362	.3772	.5792	.4287	.3582
Min	.181	.0686	.0732	.0686	.1086	.0857	.2149
Avg	.2934	.1335	.2586	.1274	.3298	.1683	.2405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 205 / 11 KV JALGAON TOWN-2

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2136	1.2136	1.2696	1.1576	1.1949	.9313
2	1.2071	1.1949	1.2136	1.2136	1.1576	1.1949	.9511
3	1.2071	1.1576	1.1576	1.2136	1.1203	1.1389	.9511
4	1.182	1.1576	1.1576	1.1763	1.1203	1.1203	.9511
5	1.1706	1.1203	1.1203	1.1203	1.0829	1.0829	.9511
6	1.0974	1.1203	1.0642	1.1203	1.0642	1.0269	.9511
7	.9671	.9335	1.0269	1.0082	1.0456	1.0082	.9145
8	.9335	.9896	.9335	.9335	.9149		.8413
9	.9335	1.0164	.961	.924	.8316	.8686	.7762
10	.9335	.961	.961	.961	.8871	.8316	.7392
11	.9709	1.0164	.961	1.0164	.961	.8316	.8316
12	1.0082	1.0719	1.0719	1.0164	1.0164	.8316	.924
13	1.0829	1.1088	1.1088	1.0534	1.0719	.924	.9795
14	1.1203	1.1458		1.1458	1.0719	.961	1.1088
15	1.2012	1.134	1.134		1.1088	.9313	1.1458
16	1.1458	1.134	1.0974	1.0745	1.0349	.9511	1.1088
17	1.1088	1.0974	1.0242	1.0745		.9511	1.0719
18	1.0719	.9877	.9511	.9145	.961	.9511	.961
19	1.1088	1.134	1.0974	.9145	1.0719	1.0242	1.0642
20	1.2012	1.1706	1.1706	.9145	1.1088	1.0608	1.1576
21	1.2567	1.2071	1.3535	1.2437	1.1088	1.182	1.4563
22	1.2936	1.2803	1.4632			1.182	1.4003
23						1.2071	1.3443
24	1.2437	1.2696	1.251	1.2883	1.2136	1.2136	.9511
Max	1.2936	1.2803	1.4632	1.2883	1.2136	1.2136	1.4563
Min	.9335	.9335	.9335	.9145	.8316	.8316	.7392
Avg	1.1153	1.1140	1.1133	1.0760	1.0529	1.0291	1.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 206 / 11 KV JALGAON TOWN-1

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9387	1.9044	1.8671	2.0538	1.9605	1.9791	1.829
2	1.829	1.8298	1.8298	2.0538	1.9044	1.9044	1.829
3	1.7909	1.8111	1.7924	1.8298	1.8298	1.8671	1.7558
4	1.7924	1.8298	1.7924	1.7737	1.8671	1.7924	1.6827
5	1.7551	1.7737	1.6991	1.7737	1.8298	1.6804	1.6095
6	1.6834	1.7924	1.6804	1.6804	1.8298	1.643	1.5364
7	1.5729	1.6057	1.643	1.5497	1.643	1.4937	1.4327
8	1.5684	1.4937	1.587	1.4003	1.4937		1.3253
9	1.5497	1.5339	1.5339	1.3306	1.3306	1.2567	1.2567
10	1.4937	1.2936	1.5708	1.386	1.4045	1.2936	1.2936
11	1.7177	1.5893	1.6632	1.6632	1.4784	1.3306	1.4415
12	1.7551	1.6263	1.7556	1.7002	1.5708	1.3491	1.5154
13	1.9044	1.6632	1.7926	1.7556	1.7556	1.4784	1.6632
14	1.9791	1.7372		1.8111	1.7926	1.5154	1.7556
15	1.848	1.8983	1.7924	1.9022	1.7556	1.5364	1.7741
16	1.8111		1.7924	1.8625	1.6632	1.5364	1.7556
17	1.8111	1.9022	1.7924	1.7193		1.4685	1.7002
18	1.7556	1.6461	1.6095	1.5364	1.5708	1.4685	1.6632
19	1.7556	1.9387	1.7924	1.6461	1.7002		1.8858
20	1.9959	2.0119	1.9753	1.9022	1.9404	1.7558	2.0538
21	2.0328	2.0119	2.0119	1.9022	1.9774	1.9022	2.2032
22	2.0328	2.0119	2.0119			1.9022	2.2032
23							2.1472
24	1.9022	2.0351	1.9791	3.7591	2.0165	1.9978	1.829
Max	2.0328	2.0351	2.0119	3.7591	2.0165	1.9978	2.2032
Min	1.4937	1.2936	1.5339	1.3306	1.3306	1.2567	1.2567
Avg	1.7946	1.7700	1.7711	1.8178	1.7293	1.6263	1.7142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 207 / 11 KV UMAPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.12	.2149	.2401	.3086	.2229	
2	.1829	.12	.2149	.2229	.2743	.2058	
3	.1829	.12	.2229	.2058	.3429	.2058	
4	.1791	.1715	.2328	.2058	.3601	.2572	
5	.1791	.2058	.3045	.2572	.4115	.2401	
6	.2149	.2229	.3045	.2915	.6001	.2915	
7	.5014	.3429	.4119				
8	.5487		.5731				
9	.4115	.2715	.5373		.4525		.8145
10	.1543	.3982	.2686		.4163		.724
11	.3772	.905	.4298		.362	.8145	.6335
12	.3258	.7783	.3582		.3258	1.086	.6335
13	.3077	.4344	.2865	.6335	.3077	.8145	.905
14	.2896	.362	.2865	.724	.2715	.543	.724
15	.2172	.2561	.2865	.5373	.3258	.5014	.6878
16	.2172	.2507	.2865	.439	.362	.5121	.6335
17	.3258	.4656	.3292				
21				.2926	.2172		.3086
22			.1829				.2743
23							.2743
24	.1829	.1372	.2743	.2058	.3429	.2058	
Max	.5487	.905	.5731	.724	.6001	1.086	.905
Min	.1543	.12	.1829	.2058	.2172	.2058	.2743
Avg	.2765	.3272	.3161	.3546	.3551	.4539	.6012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 208 / 11 KV MAIN INCOMER JJ-I

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						2.4272
8	1.9791	1.9044	2.0351	1.9605	1.9231	
12	2.0351					
24		2.3152	2.4272	2.5579	2.4646	
Max	2.0351	2.3152	2.4272	2.5579	2.4646	2.4272
Min	1.9791	1.9044	2.0351	1.9605	1.9231	2.4272
Avg	2.0071	2.1098	2.2312	2.2592	2.1939	2.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 201 / 11 KV JAMOD AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	1.1069	.7202	.6154	.6104	.9326	1.2651
2	1.4737	1.0802	.7045	.5281	.6104	.9326	1.3123
3	1.3889	1.2308	.6718	.5281	.6104	.9326	1.3763
4	1.4419	1.4074	.7209	.5121	.7122	1.0513	1.4582
5	1.3763	1.5203	.8436	.5344	.9156	1.2548	1.4746
6	1.4723	1.5893	.9602	.5668	1.1022	1.4922	1.4403
7	1.7859	1.5813	1.0082	.5735			
8	1.6004	1.2483	.9602	.6081			
9	1.6617	1.0852	.9448	.6653	2.5692	1.7238	1.6244
10	.8139	1.4582	1.8067	.6653	2.4531	1.6741	1.5083
11	.9156	2.0348	2.1879	.6468	2.2045	1.3094	1.1934
12	1.0004	1.9669	1.9393		1.6741	1.1271	.9945
13	.9496	1.7295	1.7238		1.5912	1.1271	.9945
14	.7122	1.6956	1.4918		1.5912	.9448	.8785
15	.7969	1.7974	1.442		1.6907	1.0774	1.0608
16	.8309	1.8821	1.4255	1.1603	1.873	.9945	1.1437
17	.9448		1.3904				
18	1.7404		.5407				
19	2.2045		.6401				
20	1.7404		.7287				
21	1.5083		.7042	.7122	.9496		.407
22	1.4586		.7045	.9156	1.0343		.5426
23	1.2176		.6882	.78	.9835		.6783
24	1.6194	1.0957	.7116	2.2919	.6104	.9326	1.2963
Max	2.2045	2.0348	2.1879	2.2919	2.5692	1.7238	1.6244
Min	.7122	1.0802	.5407	.5121	.6104	.9326	.407
Avg	1.3414	1.5006	1.0692	.7690	1.3214	1.1671	1.1472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 202 / 11 KV SUNGAON AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943		.1966		.407		
2	.192		.192		.407		
3	.1966		.192		.407		
4	.3605		.2267		.5426		
5	.3041		.2294		.6104		
6	.5079		.5761		.7291		
7	.7459		.8002				
8	.6464		.7202				
9	.6443		.6299	.7956		1.0111	1.0774
10		.7122		.8785		1.094	1.0277
11		.9835		.779		.9448	.8951
12		.78				.9779	.6962
13		.5087				.779	.6464
14		.4748				.779	
15		.4409				.6299	.6133
16		.407		.6464		.6133	.6962
21				.3391			.3052
22				.407			.373
23				.407			.4409
24	.1875		.1638	1.3927	.407		
Max	.7459	.9835	.8002	1.3927	.7291	1.094	1.0774
Min	.1875	.407	.1638	.3391	.407	.6133	.3052
Avg	.3980	.6153	.3927	.7057	.5014	.8536	.6771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 203 / 11 KV KARMODA AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
1		1.7814
2		1.7814
3		1.7204
4		1.6004
5		1.6194
6		1.5203
18	.7373	
19	1.0402	
20	1.5384	
21	1.7814	
22	1.8138	
23	1.8623	
24		2.732
Max	1.8623	2.732
Min	.7373	1.5203
Avg	1.4622	1.8222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 204 / 11 KV JAMOD GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7282	.6762	.5735
2		.7282	.6762	.5281
3			.6762	.5601
4		.7282	.6241	.5735
5		.6935	.6241	.6133
6		.6935	.6068	.6554
7		.6241	.5895	.6401
8		.5721	.5721	.6722
9		.6099	.6099	.5914
10		.6468	.6468	.6099
11		.6283	.6283	.5914
12		.6283	.5914	.6099
13		.6653	.5914	.6468
14		.7023	.6283	.6838
15		.6838	.6283	.6653
16	.6838	.7207	.6283	.6838
17	.5548			
18	.5895	.7802		
19	.6588	.8149		
20	.7282	.7975		
21	.7628	.7802		.7282
22	.7975	.763		.7455
23	.7455	.7455		.7455
24	.9088	.7282	.6762	.664
Max	.9088	.8149	.6762	.7455
Min	.5548	.5721	.5721	.5281
Avg	.7144	.7029	.6279	.6391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 205 / 11 KV KARMODA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2012	.192	.1966	.2601	.2774	.1989
2	.192	.1989	.1619	.1989	.2601	.2774	.192
3	.1638	.1966	.1619	.1638	.2601	.2774	.1638
4	.1638	.1943	.1638	.1966	.2601	.2774	.16
5	.2012	.1966	.1989	.192	.2427	.2427	.2012
6	.192	.2515	.2515	.2401	.2427	.208	.2515
7	.2515	.2486	.2401		.208	.208	.2515
8	.1989	.2401	.2515	.2429	.208	.208	.1943
9	.208	.2427	.1478	.1848	.2033	.1848	.1848
10	.2427	.2427	.1663	.1478	.2402	.1294	.1478
11	.2427	.2427	.2402	.1294	.1848	.0924	.1848
12	.2427	.2427			.1848	.2033	.2033
13	.2427	.2427			.2402	.1848	.1663
14	.2374	.2427	.2957		.2772	.1848	.1848
15	.2427	.2427	.2772		.2033	.1848	.2033
16	.2427	.2427	.2402	.1848	.2587	.2033	.2033
17	.2587		.2427	.208			
18	.2218		.2267	.208	.2601	.1848	
19	.2587		.2458	.2427	.2601	.2402	
20	.3142		.2486	.2601	.2774		
21	.3142		.2458	.2601	.2774		.2601
22	.3142		.2401	.2774	.2774		.2774
23	.2458		.1943	.4161	.2774		.2774
24	.2035	.2012	.2012	.8745	.2601	.2774	.2012
Max	.3142	.2515	.2957	.8745	.2774	.2774	.2774
Min	.1638	.1943	.1478	.1294	.1848	.0924	.1478
Avg	.2330	.2277	.2197	.2539	.2445	.2130	.2054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 206 / 11 KV USARA CHALTHANA AG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4858		.5765	.6325
2		.4424		.4801		.5765	.6554
3		.5441		.6722		.5765	.7287
4		.5668		.8322		.78	.8322
5		.6562		.9282		.9835	.9393
6		.7842		.9602		1.2209	.8697
7		1.0155					
8		.9922					
9		.9835			1.5746		
10	.78		1.1105		1.5746		
11	.9156				1.1768		
12	1.0174		1.2431		1.1768		
13	.9496		1.0442		.9945		
14	.8139		.8619		.8288		
15	.7122		.7625		.8288		
16	.7291		.8288		.8951		
17	.7956		.8139				
21			.3277				
22			.5601		.0848		
23			.5601		.2035		
24		.2881		.4801		.5765	.6401
Max	1.0174	1.0155	1.2431	.9602	1.5746	1.2209	.9393
Min	.7122	.2881	.3277	.4801	.0848	.5765	.6325
Avg	.8392	.697	.8113	.6913	.9338	.7558	.7568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 201 / 11 KV PIMPALGAON KALE AG FEEDER SEPERATION/PURE AG
FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.0242
Max	1.0242
Min	1.0242
Avg	1.0242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 202 / 11 KV ADOL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4481		
10			.0285	.4024
11			.3688	.4024
12			.4191	.4024
13				.4694
14				.503
15	.4108			.4191
16				.3688
21				.2572
22				.3086
23				.3429
Max	.4108	.4481	.4191	.503
Min	.4108	.4481	.0285	.2572
Avg	.4108	.4481	.2721	.3876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 203 / 11 KV PALASHI SUPO AG FEEDER SEPERATION/PURE AG
FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 204 / 11 KV ADOL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
10		.4191	.4191
11		.381	.4191
12		.3963	.4024
13			.4191
15	.4108		
16			.4578
17			.503
18			.57
19			.6203
20			.6706
21			.6344
22			.6001
23			.5487
24		.5312	
Max	.4108	.5312	.6706
Min	.4108	.381	.4024
Avg	.4108	.4319	.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 205 / 11 KV PIMPALGAON KALE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.1203		
10			.9221	.9724
11			.8383	.9389
12			.788	.9054
13				.9221
14				.9724
15	1.307			1.0059
16				1.0395
17				1.2346
18				1.3546
19				1.4746
20				1.5432
21				1.4403
22				1.3375
23				1.2346
24			1.5364	
Max	1.307	1.1203	1.5364	1.5432
Min	1.307	1.1203	.788	.9054
Avg	1.307	1.1203	1.0212	1.1697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 206 / 11 KV JIGAON (PROJECT) EXP NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0934		
10			.0914	.0838
11			.1006	.1006
12			.0914	.1006
13				.1006
14				.1006
15	.0934			.1006
16				.1006
17				.1029
18				.0686
19				.0343
20				.0171
21				.0171
22				.0171
23				.0171
24			.064	
Max	.0934	.0934	.1006	.1029
Min	.0934	.0934	.064	.0171
Avg	.0934	.0934	.0869	.0687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074031 / 33 KV PIMPALGAON KALE S/S

Feeder No / Name : 207 / 11 KV Tiwadi AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9335		
10			.9389	.8383
11			.884	.9724
12			.9297	1.073
13				1.1401
14				1.1736
15	.7842			1.2574
16				1.0898
21				.6859
22				.6859
23				.7716
Max	.7842	.9335	.9389	1.2574
Min	.7842	.9335	.884	.6859
Avg	.7842	.9335	.9175	.9688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 201 / 11 KV RUDHANA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5525	.5975	.2743	.4854	.2801	.4668
2	.5487	.4954	.5847	.2743	.4854	.2987	.4481
3	.5487	.4572	.6036	.3109	.4481	.3174	.4481
4	.5121	.4572	.5658	.3292	.4294	.3361	.4854
5	.4938	.4572	.5658	.3475	.4294	.3734	.5041
6	.4755	.4763	.5658	.3475	.4294	.3547	.5415
7	.3292	.381	.5228	.2195	.4108	.2987	.2614
8	.2561	.3429		.1829	.3547	.2427	.2427
9	.6096	.3048		.3048	.4251	.2427	.3174
10	.6096	.4108	.3326	.2858	.4805	.2801	.3048
11	.5716	.4108	.4066	.3239	.4668	.2987	.2858
12	.6096	.4294	.4435	.3429	.4066	.2614	.3048
13	.6478	.4668	.4066	.2858	.3511	.2614	.2858
14	.6096	.4854	.3696	.3048	.3326	.2801	.3048
15	.6478	.4854	.2587	.2858	.3326	.2801	.3239
16	.3429	.4854	.2957	.3429	.3142	.2801	.3429
17	.3429	.4668	.2987	.4572		.2614	.3239
18	.8001	.5041	.2402	.4001	.3511	.2614	.3429
19	.8001	.5415	.2587	.4954	.4854	.2614	.4001
20	.8763	.5788	.2957	.5041		.2801	.4191
21	.8001	.5975	.3326	.5601	.6161	.4854	.4572
22	.762	.6161	.2957	.5601	.2801	.5041	
23	.8382	.5975	.2772	.5415	.2614	.4854	.4001
24	.5853	.5716	.6161	1.2189	.5788	.2614	.4668
Max	.8763	.6161	.6161	1.2189	.6161	.5041	.5415
Min	.2561	.3048	.2402	.1829	.2614	.2427	.2427
Avg	.5918	.4822	.4152	.3958	.4161	.3120	.3773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 202 / 11 KV WADSINGHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4415		1.1088	
2	1.386		1.0164	
3	1.3676		1.0164	
4	1.3306		.961	
5	1.3306		.9795	
6	1.2752		1.0349	
7	.9425		.924	
8			.8871	
9			1.0479	
10		.924	1.0669	.8573
11		1.0719	1.086	.8764
12		1.1088	1.0479	.9145
13		1.0719	1.0669	.8954
14		1.0534	1.0479	.9335
15		1.0349	1.0669	.9526
16		1.1088	1.105	.9907
17		1.0745	1.086	1.1431
18		.961	.9526	1.2193
19		.9979	1.1812	1.2384
20		1.1088		1.2003
21		1.1088		1.1431
22		1.1088		1.105
23		1.1643		1.0669
24	1.46		1.1088	
Max	1.46	1.1643	1.1812	1.2384
Min	.9425	.924	.8871	.8573
Avg	1.3168	1.0641	1.0396	1.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 203 / 11 KV BHENDWAD FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0162
Max	.0162
Min	.0162
Avg	.0162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 201 / 11 KV DHANORA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.8029	.7545	.8316	.8501	.7716	.8131
2	.823	.7842	.7545	.7762	.8501	.7545	.7947
3	.7964	.7682	.7373	.7392	.823	.7373	.7762
4		.7468	.7202	.7023	.8145	.703	.7392
5	.7392	.6805	.7202	.6653	.7392	.6859	.7207
6	.695	.6878	.6344	.7392	.695	.6344	.6838
7	.5914	.5304	.5316	.5729	.5853	.5487	.5359
8	.5068	.5121	.4973	.5121	.5415	.4801	
9	.4973	.5788	.5487	.543	.5487	.4458	.5068
10	.5487	.5611	.5487	.5316	.5487	.4805	.4973
11	.583	.6036	.6401	.583	.6036	.5249	.5316
12	.6173	.6401	.6584	.6516	.6584	.5487	.5658
13	.6516	.7133	.7133	.6859	.7577	.5973	.583
14	.703	.7499	.7316	.7202	.7682	.6219	.6687
15	.6859	.7316	.7682	.7202		.6584	.6859
16	.6687	.6584	.724	.703	.7682	.6584	.6516
17	.6173	.6173	.6697	.6173		.6447	.6173
18	.7095	.6001	.6201	.6135	.5144	.6135	.6201
19	.8029	.703	.788	.724	.6859	.6805	.788
20	.9335	.8745	.9694	.9425	.8573	.8316	.9511
21	.961	.8573	.961	.961	.8916	.9055	.961
22	.9335	.8916	.9425	.961	.8745	.8871	.9795
23	.8962	.823	.8871	.9055	.823		.924
24	.8316	.8402	.7716	.8501	.8686	.7888	.8131
Max	.961	.8916	.9694	.961	.8916	.9055	.9795
Min	.4973	.5121	.4973	.5121	.5144	.4458	.4973
Avg	.7228	.7065	.7205	.7188	.7303	.6610	.7134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 202 / 11 KV DHANORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274		.061		.0417		
2	.0263		.061		.0412		
3	.0412		.061		.0526		
4	.0389		.0457		.0446		
5	.1128		.0457		.1372		
6	.1646		.1372		.282		
7	.2881		.3353				
8	.2841		.3963				
9	.1981		.2743	.2435		.5182	
10		.2027		.3353		.3909	
11		.4199		.3658		.2435	.5792
12		.2054		.2134		.2086	.442
13		.1448		.1372		.1833	.2134
14		.0686		.0762		.1286	.2134
15		.0823		.061		.0977	.1829
16		.0867		.1219		.192	.2743
17		.1677					.2439
18		.1677					
21				.0406			.0337
22				.0541			.0619
23				.0417			.0526
24	.0248		.061		.0417		
Max	.2881	.4199	.3963	.3658	.282	.5182	.5792
Min	.0248	.0686	.0457	.0406	.0412	.0977	.0337
Avg	.1206	.1718	.1479	.1537	.0916	.2454	.2297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 203 / 11 KV MAHULI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.12	.1132	.1132	.12	.1132
2	.1132	.1132	.12	.1132	.1132	.1029	.1132
3	.1132	.1132	.12	.1132	.0934	.1029	.0943
4	.112	.0943	.12	.0943	.1132	.1029	.0943
5	.0943	.0943	.1029	.0943	.1132	.1029	.0943
6	.0754	.0943	.0857	.0943	.0934	.1029	.0943
7	.0754	.0594	.0686	.0754	.0754	.0857	.0566
8	.0754	.0754	.0686	.0566	.0754	.0686	
9	.0686	.0754	.0686	.0754	.0754	.0686	.0377
10	.0686	.0754	.0572	.0686	.0566	.0377	.0514
11	.0686	.0754	.0754	.0686	.0566	.0754	.0686
12	.0857	.0754	.0754	.1029	.0943	.0754	.0686
13	.0857	.0754	.0754	.1029	.0943	.0754	
14	.0857	.0943	.0943	.1029	.3763	.0943	.1029
15	.1029	.0943	.0943	.1029	.3311	.0754	.1029
16	.0857	.0754	.0934	.1029	.1132	.0754	.0857
17	.0686	.0857	.0934	.0857		.0747	.0857
18	.0943	.0857	.0754	.0747	.0857	.0566	.0747
19	.1132	.1029	.1132	.0754	.0857	.0943	.0754
20	.132	.12	.132	.132	.12	.1307	.1132
21	.1509	.12	.132	.132	.12	.1132	.1334
22	.132	.12	.132	.132	.1372	.1132	.132
23	.132	.12	.132	.1132	.12		.1132
24	.1132	.1132	.12	.715	.1132	.12	.1132
Max	.1509	.12	.132	.715	.3763	.1307	.1334
Min	.0686	.0594	.0572	.0566	.0566	.0377	.0377
Avg	.0983	.0944	.0987	.1226	.1204	.0900	.0918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 204 / 11 KV MAHULI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229		.2462		.1829	.2606
2		.2641		.1572		.1829	.2606
3		.2107		.1572		.1829	.2229
4		.2143		.1738		.2134	.2115
5		.2526		.2258		.2439	.3418
6		.2675		.2968		.2896	.4268
7		.3567					
8		.3572					
9		.4161			.5281		
10	.4115		.4687		.6718		
11	.3963		.5921		.4428		
12	.3048		.4167		.381		
13	.3048		.2743		.381		
14	.2896		.2029				
15	.2591		.1635				
16	.3048		.2932		.3382		
17	.3048		.301				
21						.2286	
22						.2824	
23						.2751	
24		.2462		.94		.2134	
Max	.4115	.4161	.5921	.94	.6718	.2896	.4268
Min	.2591	.2107	.1635	.1572	.3382	.1829	.2115
Avg	.3220	.2808	.3391	.3139	.4572	.2295	.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 205 / 11 KV MAIN I/C ASALGAON-I

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9795	1.0974	.9431	1.1946	1.0349	1.0974	1.2308
2	.9694	1.1104	.9431	1.0679	1.0059	1.0631	1.2127
3	.9593	1.0985	.9259	1.0317	.9774	1.046	1.1222
4	.9896	1.086	.8916	.9955	.9877	1.046	1.086
5	.9593	1.0745	.8745	1.0136	1.0349	1.0631	1.2127
6	.9671	1.0808	.8745	1.1584	1.1643	1.0631	1.2536
7	.9774	1.0099	.9774	.6335	.6516	.6344	.5914
8	.8648	.9991	1.0117	.567	.5973	.5487	
9	.7888	1.1043	.9259	.8817	1.1616	1.0974	.5729
10	1.0802	.8495	1.1043	.9774	1.2689	.9221	.5487
11	1.0974	1.1317	1.3321	1.0631	1.1218	.8648	1.2517
12	1.046	.9391	1.1744	.9945	1.1568	.8495	1.1317
13	1.0802	.9391	1.0808	.9431	1.2269	.9145	.9088
14	1.1145	.9328	1.0745	.9088	1.262	.8505	1.0117
15	1.0802	.9313	1.0631	.8916	1.2403	.8669	.9945
16	1.0974	.8596	1.1218	.9431	1.2934	.9877	1.046
17	1.0288	.8916	1.0749	.703		.7164	.9774
18	.7537	.6859	.691	.6836	.6001	.6661	.6836
19	.8402	.8059	.905	.7964	.7716	.7701	.8596
20	1.0208	.9945	1.1088	1.0719	.9774	.961	1.0719
21	1.0974	.9774	1.0903	1.1458	1.0117	1.267	1.134
22	.9774	1.0117	1.0719	1.1643	1.0117	1.3213	1.1888
23	.964	.9431	1.0164	1.0719	.9431		
24	1.0164	1.2178	.9602	1.2127	1.0534	1.1488	1.2489
Max	1.1145	1.2178	1.3321	1.2127	1.2934	1.3213	1.2536
Min	.7537	.6859	.691	.567	.5973	.5487	.5487
Avg	.9896	.9905	1.0099	.9631	1.0241	.9463	1.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 201 / 11 KV UMAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372		.3612		.1829	.583
2		.1219		.3612		.1677	.583
3		.1219		.381		.1524	.6173
4		.1143		.3963		.1753	.6516
5		.1524		.4115		.2286	.7202
6		.2134		.4877		.3429	.8573
7		.2743					
8		.3048					
9		.2743			.8589		
10	.6413		.7202		1.0185		
11	.3201		.8402		.3963		
12	.3201		.7316		.381		
13	.3353		.6773		.3506		
14	.3048		.6622		.3429		
15	.2743		.6321		.3582		
16	.2591		.587		.381		
17	.2743		.6554				
21			.4268		.2286	.5487	
22			.3963		.2134	.583	
23			.3963		.2058	.583	
24		.1372		.3963		.1905	.583
Max	.6413	.3048	.8402	.4877	1.0185	.583	.8573
Min	.2591	.1143	.3963	.3612	.2058	.1524	.583
Avg	.3412	.1852	.6114	.3993	.4305	.3155	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 202 / 11 KV KAHUPATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0533		.1505		.0914	.3086
2		.0457		.1505		.0762	.3086
3		.0457		.1505		.0762	.3086
4		.0533		.1505		.0914	.3086
5		.0686		.1524		.1067	.3429
6		.0991		.2439		.1372	.3429
7		.1219					
8		.1296					
9		.0991			.3734		
10	.1494		.2572		.3772		
11	.061		.3429		.16		
12	.0914		.3048		.1524		
13	.0838		.2896		.1372		
14	.0838		.2743		.1296		
15	.0914		.2439		.1296		
16	.0914		.2743		.1372		
17	.0991		.3048				
21			.1505		.0914	.2401	
22			.1505		.1067	.2743	
23			.1505		.1067	.3086	
24		.0533		.1505		.0991	.3086
Max	.1494	.1296	.3429	.2439	.3772	.3086	.3429
Min	.061	.0457	.1505	.1505	.0914	.0762	.3086
Avg	.0939	.0770	.2494	.1641	.1729	.1501	.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 203 / 11 KV HANWATKHED AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481		.4115		.4854		
2	.415		.4115		.5329		
3			.4287		.5228		
4	.4527		.4458		.5544		
5	.7167		.5487		.7095		
6	.7762		.6859		.9431		
7	.7842		.8745				
8	.9335		.8059				
9	.7468		.7716	.4877		.503	1.0631
10		.3506		.9374		.5182	1.1488
11		1.046		1.1203		1.0974	.8905
12		.8573		1.0082		1.0802	.8592
13		.7545		.7922		1.0288	.8436
14		.7716		.7095		.9945	.8488
15		.7545		.7095		.9431	.8488
16		.7716		.8215		.9431	.9804
17		.8059					
21				.4854			.4268
22				.4481			.5792
23				.4805			.6097
24	.4481		.4115		.4854		
Max	.9335	1.046	.8745	1.1203	.9431	1.0974	1.1488
Min	.415	.3506	.4115	.4481	.4854	.503	.4268
Avg	.6357	.764	.5796	.7273	.6048	.8885	.8272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 204 / 11 KV UMAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.282	.5487	.6733	.6722	.2058	.583
2	.679	.2743	.5487	.6201	.6722	.1677	.583
3	.6653	.2591	.5144	.6024	.6722	.1524	.5487
4	.6283	.2439	.5144	.5847	.6722	.1448	.5144
5	.6348	.2286	.4801	.567	.6653	.1677	.5144
6	.7023	.2439	.4801	.543	.6602		.5487
7	.4668	.221	.463	.4706	.5228	.2286	.4973
8	.5281	.1905		.4607	.5601	.2286	.4801
9	.5175	.2134	.463	.4784	.5601	.2134	
10	.5601	.221	.4801	.5249	.4854	.2058	.463
11	.2286	.463	.5316	.5601	.2439	.5144	.5138
12	.2439	.5144		.5228	.2591		.543
13	.2515	.5487		.5975	.2591	.5144	.5493
14	.2515	.5487	.567	.5975	.2515	.5316	.5792
15		.5487	.6154	.5914	.2439	.5487	
16	.2591	.5487	.6379	.5975	.2591	.5487	.5792
17	.2439	.5658	.6878	.6036		.6001	.6697
18	.2667	.6001	.5611	.6348	.2591	.6344	.6878
19	.2591	.6516	.5914	.6722	.282	.6516	.7059
20	.3048	.6859	.7392	.7095	.3048	.6344	.7947
21		.703	.7316	.7392	.3048	.6516	.7762
22	.3048	.6859	.7392	.7468	.2896	.6516	.7392
23	.2743	.6687	.7059	.7545	.2743	.6173	.7059
24	.7095	.282	.6173	.6878	.6722	.2743	.583
Max	.7095	.703	.7392	.7545	.6722	.6516	.7947
Min	.2286	.1905	.463	.4607	.2439	.1448	.463
Avg	.4387	.4330	.5818	.6058	.4368	.4131	.5982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 201 / 11 KV DATALA (SINGLE PHASE) Feeder KV- 11 / OUTGOING SINGLE PHASING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3527	.5716	1.3146	.6097	1.3527	.6859	.7049
2	1.2955	.5716	1.2574	.6097	1.2955	.6859	.7049
3	1.2574	.5335	1.2003	.6097	1.2384	.6859	.724
4	1.2193	.5335	1.1812	.6287	1.2003	.6859	.8383
5	1.1812	.5525	1.1431	.6478	1.1431	.724	1.0669
6	1.1812	.5525	1.105	.7049	1.086	.7621	1.1812
7	1.0288	.6668	.9526	.9717	.9526	1.0288	.9526
8	.9526	.7621	.8954	.9526	.9145	.9526	.8383
9	.8954	.7049	.9335	.9717	.9907	.9526	.9335
10	.724	.6478	.6287	1.0288	.9526	.8573	.9335
11	.8573	1.0098	.8573	1.0669	.9526	.8954	.9145
12	.9335	1.1812	.9907	1.105	.8764	.9335	1.0479
13	.8573	1.2384	.9526	1.2955	.8573	1.0479	1.2003
14	.724	1.2955	.9526	1.3336	.8573	1.1622	1.2384
15	.724	1.2574	.7621	1.0479	.8954	1.1241	1.2574
16	.7049	1.2574	.724	1.0669	.8764	1.0669	1.2765
17	.724	1.2003	.724	1.2384	1.1812	1.086	1.2193
18	.9526	1.086	.9717	1.2003	1.0669	1.105	1.1431
19	1.2003	1.467	1.1241	1.2193	1.1812	1.1241	1.2003
20	1.3336	1.5432	1.6385	1.6004	1.4098	1.4098	1.5813
21	1.5242	1.5813	.743	1.6956	.7621	.8002	1.6575
22	1.5813	1.6004	.6859	1.6004	.7621	.7621	1.5623
23	1.4289	1.5242	.6287	1.448	.724	.743	1.4289
24	1.4098	.5716	1.3908	.964	1.4098	.7049	.724
Max	1.5813	1.6004	1.6385	1.6956	1.4098	1.4098	1.6575
Min	.7049	.5335	.6287	.6097	.724	.6859	.7049
Avg	1.0852	.9963	.9899	1.0674	1.0391	.9161	1.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 202 / 11 KV UMALI (SINGAL PHASING) Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	1.0479	.5335	1.1431	.6478	1.105	1.105
2	.5525	1.0479	.5335	1.1431	.6478	1.0288	1.086
3	.5716	.9526	.4954	1.105	.6668	1.0288	1.0479
4	.5716	.9526	.5525	1.0669	.743	1.0288	1.0288
5	.6287	.9526	.5906	1.0479	.8002	1.0288	1.0098
6	.7049	.9526	.7049	.9907	.9526	1.0669	.9717
7	.8192	.8383	.7811	.8954	.9145	.8383	.8383
8	1.0288	.724	1.0098	.8764	.8002	.743	.7621
9	.9717	.7811	.8002	.9526	.8383	.9907	1.0098
10	.7811	.9526	.7621	1.0288	.9526	1.1812	1.2574
11	.8573	1.2193		1.1431	.9526	1.1431	1.2384
12	.9335	1.1431		1.1431	.9717	1.1812	1.2003
13	.9907	1.086		1.1431	1.0479	1.0479	.9145
14	1.086	.9717		1.0098	1.086	.9526	1.0479
15	1.0479	.8764	1.2765	.9526	1.1431	1.0288	1.0288
16	1.086	.8383	1.2193	.9335	1.1431	.9145	1.0479
17	1.0288	.8573	1.2003	1.105	1.0669	.8764	1.0288
18	1.0479	.8192	1.0098	1.105	.9145	.9526	1.0288
19	1.0288	1.2955	1.0669	1.086	1.1431	.9907	1.0288
20	1.1431	1.3717	1.4861	1.4098	1.4289	1.2003	1.4098
21	1.3146	1.3717	1.467	.724	1.4098	1.3336	.8383
22	1.3146	1.3527	1.3336	.7049	1.3146	1.2574	.7811
23	1.2003	1.2765	1.7909	.724	1.2003	1.1812	.7049
24	.5144	1.105	.5144	1.1812	.6859	1.1431	1.1431
Max	1.3146	1.3717	1.7909	1.4098	1.4289	1.3336	1.4098
Min	.5144	.724	.4954	.7049	.6478	.743	.7049
Avg	.9066	1.0328	.9564	1.0256	.9780	1.0518	1.0233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 203 / 11 KV NIMBARI (SINGAL PHASING) Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.6668	.2286	.7621	.2286	.8002	.9526
2	.2286	.6668	.2286	.7621	.2286	.8002	.9335
3	.2096	.7621	.2286	.7621	.2096	.8002	.9145
4	.2096	.8573	.2096	.8002	.2096	.8573	1.0479
5	.2096	.8573	.2096	.8573	.2096	.8954	1.1812
6	.2096	.8764	.2096	.9526	.2096	.9145	1.2955
7	.1524	.9526	.1905	.1524	.1524	.1715	.1334
8	.1524	1.086	.1524	.1524	.1524	.0762	
9	.1334	1.105	.1524	.1715	1.2193	.0762	
10	.7049	.1715	.9145	.1905	1.2384	.0953	
11	.9526	.1143	1.0479	.2096	1.2384	.0953	
12	1.1431	.0953	1.1431	.2286	1.2955	.1905	
13	1.0479	.1143	1.0479		1.1431	.2096	
14	.8954	.2286	1.0479		1.1431	.2286	.2286
15	.9526	.2286	.9526	.2667	.9907	.2096	.2477
16	.9526	.2286	.9526	.2477	.9526	.1905	.2477
17	.9526	.1905	.9717	.2286	.2286	.1905	.2286
18	.2858	.1524	.1524	.2096	.1905	.2096	.2096
19	.2096	.2286	.2096	.2096		.2286	.2286
20	.2286	.2667	.2667	.3048		.2477	.2667
21	.2477	.2667	.7621	.3048		.8954	.3048
22	.2477	.2667	.7621	.2667	.7621	.9335	.2667
23	.2477	.2477	.7621	.2477	.8383	.9907	.2477
24	.2477	.6478	.2477	.7621	.2477	.8192	.9717
Max	1.1431	1.105	1.1431	.9526	1.2955	.9907	1.2955
Min	.1334	.0953	.1524	.1524	.1524	.0762	.1334
Avg	.4604	.4699	.5438	.4114	.6233	.4636	.5504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 204 / 11 KV AKSHAY (EXPRESS) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.2096	.2477	.1334	.1905	.1334	.1334
2	.1334	.2286	.2286	.1334	.1905	.1334	.1334
3	.1524	.2477	.2286	.1334	.2096	.1334	.1524
4	.1524	.2667	.1905	.1334	.2286	.1334	.1715
5	.1524	.2858	.2096	.1524	.2286	.1334	.1715
6	.1524	.2858	.2096	.1715	.2477	.1334	.1715
7	.1524	.2096	.2286	.1715	.2096	.1524	.2286
8	.1905	.2667	.2286	.1905	.1334	.1905	.1715
9	.5906	.5906	.5335	.5716	.3239	.4954	.5335
10	.6478	.6668	.6859	.5716	.381	.5144	.6097
11	.6097	.6097	.6668	.5335	.381	.4763	.5144
12	.6287	.6097	.5906	.5144	.5525	.4191	.5335
13	.6287	.6097	.6097	.5335	.4763	.4763	.5525
14	.6097	.6097	.6668	.5525	.4382	.5335	.5144
15	.5716	.5906	.724	.2667	.4763	.5525	.4572
16	.4763	.5906	.5716	.2477	.4001	.5144	.4191
17	.362	.5335	.4191	.2286	.1715	.4001	.362
18	.3429	.4572	.3429	.1524	.0953	.362	.2286
19	.3239	.4001	.2286	.1334	.0953	.2286	.1524
20	.3239	.362	.1905	.1334	.0953	.1905	.1524
21	.3429	.2858	.1524	.1524	.1143	.1715	.1905
22	.3429	.2477	.1524	.1524	.1143	.1524	.1715
23	.1715	.2286	.1334	.1905	.0953	.1524	.1715
24	.1334	.2096	.2477	.1524	.1905	.1334	.1524
Max	.6478	.6668	.724	.5716	.5525	.5525	.6097
Min	.1334	.2096	.1334	.1334	.0953	.1334	.1334
Avg	.3469	.4001	.3620	.2628	.2517	.2882	.2937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 205 / 11 KV JAMBHULDHABA (SINGAL SINGLE PHASING
PHA Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.4382	.6287	.4572	.6668	.4191	.5716
2	.6287	.4382	.5906	.4572	.6668	.4191	.5906
3	.6097	.4572	.5716	.4572	.6478	.4191	.5716
4	.5716	.4763	.5716	.4763	.6287	.4191	.6097
5	.5906	.4763	.5525	.4954	.6478	.4382	.6287
6	.5906	.4954	.5525	.6097	.6287	.4572	.6287
7	.4954	.5716	.4954	.5335	.5525	.4001	.4382
8	.4191	.5716	.4572	.4954	.4572	.4382	.4191
9	.5144	.4382	.5335	.4954	.6287	.4001	.4572
10	.4763	.5144	.5525		.724	.4382	.4572
11	.5716	.5906	.5716		.6668	.4763	.5525
12	.5906	.6859	.6668		.6859	.5144	.6097
13	.5906	.724	.5716	.7621	.6859	.5716	.6668
14	.5906	.743	.5716	.8002	.7049	.5906	.6668
15	.5716	.6859	.5525	.8002	.6478	.5906	.6668
16	.5335	.6859	.5144	.7621	.6478	.5906	.6859
17	.5144	.5525	.5335	.6478	.6287	.4763	.6097
18	.5716	.5335	.5906	.6668	.5716	.4763	.5716
19	.6097	.6287	.6287	.6287	.6097	.5144	.6097
20	.6668	.8002	.8002	.8954	.724	.6287	.7049
21	.743	.7621	.4763	.8573	.5335	.5906	.743
22	.743	.724	.4763	.7811	.4954	.5716	.7049
23	.6668	.6859	.4763	.743	.4572	.5335	.6668
24	.6668	.4382	.6478	.4572	.7049	.4382	.5525
Max	.743	.8002	.8002	.8954	.724	.6287	.743
Min	.4191	.4382	.4572	.4572	.4572	.4001	.4191
Avg	.5898	.5882	.5660	.6323	.6255	.4922	.5993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 401 / 33 KV INCOMER I (1)

Feeder KV- 33 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3717	1.2003	1.4289	1.3146	1.4861	1.6575
2	1.2003	1.3717	1.1431	1.4289	1.3146	1.4289	1.6575
3	1.2003	1.3146	1.086	1.4289	1.3146	1.4289	1.6575
4	1.1431	1.3146	1.1431	1.4861	1.3717	1.4289	1.7718
5	1.2003	1.3717	1.1431	1.4861	1.3717	1.4861	2.0005
6	1.3146	1.3717	1.2574	1.6575	1.5432	1.6004	2.1148
7	1.3146	1.5432	1.2574	.8002	.8002	.743	.743
8	1.4861	1.6004	1.4861	.8002	.743	.6859	.6859
9	1.4289	1.4289	1.3146	1.4289	1.8861	1.4289	1.4289
10	1.4861	1.7718	1.4289	1.3717	1.9433	1.6004	1.7147
11	1.7147	1.7718	1.4289	1.4861	1.9433	1.6004	1.7147
12	1.6575	1.7718	1.6575	1.4861	1.8861	1.6575	1.7718
13	1.7718	1.7147	1.5432	1.829	1.8861	1.6004	1.5432
14	1.6575	1.7718	1.5432	1.7147	1.9433	1.5432	1.6575
15	1.6575		1.7147	1.5432	1.9433	1.6004	1.6575
16	1.6004	1.4861	1.6575	1.5432	1.8861	1.4861	1.7147
17	1.6004	1.4289	1.6575	.9717	.9717	.8002	.9717
18	.8573	.8002	.8573	.9717	.8573	.8573	.9145
19	.9717	1.1431	.9145	.9717	.9717	.8573	.9717
20	1.0288	1.2574	1.3146	1.3146	1.2003	1.086	1.2574
21	1.2003	1.2574	1.7147	1.6004	1.7718	1.829	1.6575
22	1.2003	1.2003	1.6004	1.4861	1.7147	1.7718	1.5432
23	1.086	1.1431	1.4861	1.4289	1.6004	1.6575	1.4289
24	1.2003	1.3717	1.2003	1.4861	1.3717	1.5432	1.6575
Max	1.7718	1.7718	1.7147	1.829	1.9433	1.829	2.1148
Min	.8573	.8002	.8573	.8002	.743	.6859	.6859
Avg	1.3408	1.4165	1.3646	1.3813	1.4813	1.3837	1.4956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 402 / 33 KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.8573	.3429	.9145	.2858	.9145	1.086
2	.2286	.9145	.2858	.9145	.2858	.9145	1.086
3	.2286	.8573	.2858	.9145	.2858	.9145	1.086
4	.2286	1.0288	.2858	.9145	.2858	.9717	1.2003
5	.2286	1.1431	.2858	1.0288	.2858	1.0288	1.3717
6	.2286	1.1431	.2858	1.1431	.3429	1.0288	1.4861
7	.2286	1.2003	.2858	.2286	.2858	.2286	.2858
8	.2286	1.3717	.2858	.2286	.1715	.2286	.1715
9	.6287	1.7147	.5716		1.3717	.5144	.5144
10	1.3717	.743	1.6004		1.6004	.5716	.6287
11	1.5432	.6287	1.7147		1.6004	.5144	.5144
12	1.7718	.6287	1.7147		1.829	.4572	.5144
13	1.6575	.6287	1.6575	.5144	1.6004	.5716	.5716
14	1.4861	.6859	1.7147	.5716	1.5432	.6287	.5716
15	1.3146		1.6004	.3429	1.4861	.6287	.5144
16	1.4289	.6859	1.5432	.3429	1.3717	.5716	.5144
17	1.3146	.5716	1.3717	.2858	.2286	.4572	.4572
18	.4572	.5144	.4001	.2286	.1715	.4572	.2858
19	.4001	.4572	.2858	.2286	.1143	.2858	.2286
20	.4001	.4572	.2858	.2286	.1143	.2858	.2286
21	.4001	.4001	.9145	.2286	.1143	1.086	.2858
22	.4001	.3429	.9145	.2286	.8573	1.086	.2858
23	.2286	.2858	.9145	.2858	.9145	1.1431	.2286
24	.2286	.8573	.3429	.9145	.2858	.9717	1.1431
Max	1.7718	1.7147	1.7147	1.1431	1.829	1.1431	1.4861
Min	.2286	.2858	.2858	.2286	.1143	.2286	.1715
Avg	.7025	.7877	.8288	.5344	.7264	.6859	.6359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 201 / 11 KV RAMTHAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6316	.2572		.2753		.9602
2		.6154	.2572		.2915		.9602
3		.6316	.2743		.2753		.9602
4		.6316	.2743		.2915	.4287	.9602
5		.6478	.2915		.3239	.6687	.9945
6		.7125	.2915		.421	.7545	1.0288
7		.7773	.3772				
8		.7888	.4458				
9	.7611	.9259	.4115	.7773			.7716
10	.2429	.3429	.823	.9717		.703	.7888
11	.2753	.4801	.8993	1.0202		.7202	
12	.2753	.4973	1.0059	1.0526	.8688	.703	
13	.2753	.4115	1.0669	1.085	.8078	.703	
14	.2429	.3772	1.0974	1.0526	1.0802	.703	
15	.2105	.3258	1.0669	1.0688	1.0517	.703	
16	.2429	.3429	1.0059	1.0364	.9755	.7545	.7888
17	.2753	.3258	.9297				.823
18							.703
21				.3239	.7373	.9431	1.0288
22				.3239		.9602	1.1145
23				.2915	.7545	.9431	1.046
24		.6154	.2572	.2743	.2915	.5658	.9431
Max	.7611	.9259	1.0974	1.085	1.0802	.9602	1.1145
Min	.2105	.3258	.2572	.2743	.2753	.4287	.703
Avg	.3113	.5601	.6129	.7732	.6033	.7324	.9248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 202 / 11 KV NERVAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.7545		.8421	.0686	.1372
2		.0972	.7545		.8421	.0686	.1372
3		.0972	.7716		.8259	.0686	.1372
4		.0972	.7716		.8421	.0686	.12
5		.1296	.7888		.8907	.0686	.12
6		.1781	.8059		.9555	.0686	.12
7		.1619	.9088		.1619	.0686	.12
8		.1029	.9431		.1781	.0686	.1372
9	.1943	.1029	.9431	.1943	.1677	1.166	1.286
10	.8097	1.0631	.0857	.1619	.1829	1.2689	1.286
11	.8259	1.0288	.0762	.1619	.1829	1.3717	
12	.8097	.9774	.0762	.1781	.1829	1.3717	
13	.7935	.823	.0914	.1781	.1829	1.3375	
14	.7773	.823	.0914	.1781	.1677	1.3032	
15	.7449	.8402	.0914	.1619	.1677	1.2346	
16	.7449	.8745	.0914	.1619	.1677	1.286	1.2517
17	.7611	.823	.0914	.1781	.1524	.1372	1.0288
18	.0972	.2058	.0914	.1781	.1524	.12	1.046
19	.0972	.1715	.0914	.1781	.1524	.12	.1372
20	.1296	.1715	.0914	.1619		.1372	.12
21	.1134	.1715	.0914	.8907		.12	.1372
22		.1715		.9069		.1372	.1543
23	.0972	.1543		.8745		.12	.1372
24		.0972	.7716	.5944	.8421	.0686	.12
Max	.8259	1.0631	.9431	.9069	.9555	1.3717	1.286
Min	.0972	.0972	.0762	.1619	.1524	.0686	.12
Avg	.4997	.3942	.4216	.3337	.4120	.4937	.4070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 203 / 11 KV JAKWEL INDISTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7164	1.286		1.8484	1.6289	1.2003
2		1.6975	1.2346		1.8107	1.6461	1.1145
3		1.6032	1.1831		1.773	1.6461	1.0974
4		1.6221	1.1831		1.7918	1.6975	1.0974
5		1.5844	1.1317		1.8484	1.7147	1.046
6		1.6221	1.1317		1.8673	1.9719	1.0288
7		1.7918	1.6461		1.8107	1.5261	.7545
8		1.8004	2.0062		1.8673	1.5775	.703
9	1.3765	1.8004	2.3148	2.3954	1.9966	1.5775	.703
10	1.905	1.9547	2.572	2.4143	2.21	1.7318	.6173
11	1.7166	2.0576	2.1948	2.6595	2.1948	1.8861	
12	1.8861	2.1091	2.21	2.6783	2.21	1.6804	
13	1.8484	2.1605	2.0729	2.8292	2.1338	1.6804	
14	2.2445	2.4006	2.1033	2.7349	1.829	1.6804	
15	2.6029	2.4177	2.0576	2.6783	1.7528	1.6804	
16	2.6406	2.4177	2.0576	2.6029	1.7071	1.8347	.7202
17	2.6595	2.3148	2.0576	2.7726	1.7528	1.7318	.6687
18	2.4897	2.2634	2.0119	2.4897	1.3717	1.7147	.6687
19	2.3011	2.5206	1.9814	2.3765	1.2955	1.6289	.6173
20	2.2257	2.452	1.9509	2.4331		1.4918	.6173
21	2.1879	2.4177	1.829	2.3011		1.5775	.6173
22	1.905	2.0576		2.32		1.5432	.703
23	1.8296	2.0062		1.8673		1.4232	.703
24		1.8107	1.6461	1.6004	1.8673	1.6289	1.2346
Max	2.6595	2.5206	2.572	2.8292	2.21	1.9719	1.2346
Min	1.3765	1.5844	1.1317	1.6004	1.2955	1.4232	.6173
Avg	2.1213	2.0250	1.8119	2.4471	1.8470	1.6625	.8375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 204 / 11 KV NARVEL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5973	.4801		.5792	.4287	.4801
2		.6154	.4801		.5792	.3772	.463
3		.5973	.4801		.5792	.3944	.4458
4		.6154	.5144		.5792	.3944	.4458
5		.5973	.5316		.5792	.4287	.4973
6		.5792	.5316		.5973	.4801	.5144
7		.5249	.5144		.5249	.4458	.463
8		.4287	.4801		.5068	.4115	.4458
9	.4887	.4458	.463	.5068		.4115	.4115
10	.421	.4287	.4458	.547		.3944	.4115
11	.5068	.4801	.381	.543		.3772	
12	.543	.5144	.3963	.5792		.4458	
13	.5973	.5658	.4725	.6335		.4973	
14	.5792	.583	.4572	.6154		.5144	
15	.6154	.583	.4572	.6335		.5658	
16	.6335	.6001	.4725	.6516		.5316	.6859
17	.6697	.583	.4725	.6516		.5487	.6173
18	.724	.5658	.5182	.6697		.583	.6344
19	.7783	.6516	.5944	.6878		.5658	.6859
20	.7602	.7202	.4572	.7964		.6687	.7373
21	.7421	.703	.5487	.724		.6344	.6859
22	.6878	.6859		.6697		.6001	.6173
23	.6335	.6001		.6335		.5144	.5487
24		.6154	.6516	.4572	.5792	.2743	.4801
Max	.7783	.7202	.6516	.7964	.5973	.6687	.7373
Min	.421	.4287	.381	.4572	.5068	.2743	.4115
Avg	.6254	.5784	.4909	.6250	.5671	.4787	.5406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 205 / 11 KV RANTHAM GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362	.3429		.4344	.3772	.3944
2		.3439	.3086		.4344	.3429	.3772
3		.362	.3086		.4344	.3429	.3772
4		.3439	.3772		.4344		.4115
5		.362	.3429		.4706	.4115	.4287
6		.3982	.3086		.5249	.4801	.4801
7		.3258	.4458		.4887	.4973	.5144
8		.2915	.4115		.4706	.4458	.4458
9			.3944	.5068	.4287	.3601	.4458
10	.3887		.4115	.4706	.4287	.4115	.3772
11	.2896	.2915	.3658	.4887	.2743	.4287	
12	.3258	.4115	.381	.4525	.3086	.4287	
13	.362	.4287	.381	.4706	.463	.4287	
14	.4525	.4458	.3963	.4887	.463	.4287	
15	.4887	.463	.3963	.5068	.463	.4287	
16	.5068	.5144	.3963	.4887	.4801	.3429	.5316
17	.4706	.5144	.4115	.5249	.463	.3086	.4287
18	.543	.5316	.442	.5792	.5658	.2058	.4973
19	.6154	.5487	.4877	.6154	.5487	.5144	.5144
20	.543	.5658	.5335	.6335	.583	.5487	.583
21	.4706	.4801	.4572	.5792	.4801	.463	.5487
22	.4344	.3429		.4887	.4287	.4801	.5316
23	.3982	.5487		.4706	.3944	.4115	.463
24		.3801	.3772	.3506	.4527	.3944	.3944
Max	.6154	.5658	.5335	.6335	.583	.5487	.583
Min	.2896	.2915	.3086	.3506	.2743	.2058	.3772
Avg	.4492	.4208	.3944	.5072	.4549	.4123	.4603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 206 / 11 KV WAGHOLA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5487	.8573
2				.5487	.8573
3				.5487	.8745
4				.5487	.8745
5				.6001	.9259
6					.9945
9		.6173	.6687		
10	.2743	.7716	.823		
11	.4268	.8573	.823		
12	.5335	.8402	.823		
13	.6706	.8402	.7202		
14	.6859	.823	.7716		
15	.6706	.8059	.823		
16	.6401	.7888			
17	.6401				
21					1.0288
22				.8916	1.0974
23			.5144	.823	1.0631
24				.5487	.8573
Max	.6859	.8573	.823	.8916	1.0974
Min	.2743	.6173	.5144	.5487	.8573
Avg	.5677	.7930	.7459	.6323	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 207 / 11 KV DUPESHWAR W/S NON SHEDDABLE WATER SUPPLY AND
EXPRESS. Feeder KV- 11 / UTILITY
OUTGOING

DATE	29-MAY-18	30-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0648	.0514	.0514
2		.0648	.0514	.0514
3		.0648	.0514	.0514
4		.0648	.0514	.0514
5		.0648	.0514	.0514
6		.0648	.0514	.0514
7		.0648	.0686	.0686
8			.0686	.0686
9	.081		.0686	.0686
10	.081		.0514	.0686
11	.0648		.0686	
12	.081		.0686	
13	.0648		.0686	
14	.0754		.0686	
15	.0486		.0686	
16	.0648		.0686	
17	.0486		.0514	
18	.0486		.0686	.0514
19	.0648		.0686	.0514
20	.0648		.0686	.0686
21	.0724		.0686	.0686
22	.0648		.0686	.0686
23	.0648		.0514	.0686
24		.0648	.0686	.0514
Max	.081	.0648	.0686	.0686
Min	.0486	.0648	.0514	.0514
Avg	.0660	.0648	.0622	.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 408 / 33 KV KARTICK PAPER EXP

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.0514		.1132	.1029	.1029
2		.1132	.0514		.1132	.1029	.1029
3		.1132	.0514		.1132	.1029	.1029
4		.1132	.0514		.1132	.1029	.1029
5		.1132	.0514		.1132	.1029	.1029
6		.1132	.1029		.1132	.1029	.1029
7		.1132	.1029		.1132	.1029	.1029
8		.1029	.1029		.1132	.1029	
9	.1086	.1029	.1029	.1132	.1029	.1029	
10	.2263	.2572	.1029	.1132	.1029	.1029	
11	.2715	.2572	.1829	.2263	.1029	.1029	
12	.2829	.2572	.1372	.2263	.1029	.1029	.1029
13	.2829	.1543	.1372	.2263	.1029	.1029	
14		.1543	.1372	.2263	.1029	.1029	.1029
15	.2829	.2058	.1372	.2829	.1029	.1029	
16	.2829	.2058	.1829	.2829	.1029	.1029	
17	.2829	.2058	.1372	.1698	.1029	.1029	.1029
18	.2429	.2058	.1829	.2263	.1029		.1029
19	.2829	.1543		.1698	.1029	.1029	.1029
20	.2715	.1543		.1698	.1029	.1029	.1029
21	.2829	.1543		.1132	.1029	.1029	.1029
22	.2829	.2058		.1132	.1029	.1029	.1029
23	.2263	.1029		.1132	.1029	.1029	.1029
24		.1943	.1029	.1029	.1132	.1029	.1029
Max	.2829	.2572	.1829	.2829	.1132	.1029	.1029
Min	.1086	.1029	.0514	.1029	.1029	.1029	.1029
Avg	.2579	.1611	.1110	.1797	.1068	.1029	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 409 / 33 KV BIRLA COTSAN EXP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2068	2.0576		2.2805	1.8519	1.9547
2		2.32	2.0576		2.2634	1.8519	2.0576
3		2.3765	2.1091		2.32	1.8004	2.0576
4		2.32	2.0576		2.4331	1.8519	2.1091
5		2.2068	2.1091		2.3765	2.0576	2.1091
6		2.2634	2.1091		2.32	2.1605	2.0576
7		2.4897	2.2634		2.3765	2.0062	2.3663
8		1.9033	2.0576		1.8673	1.9033	2.0576
9	2.0633	1.9547	1.9033	1.7541	2.0062	2.0062	1.6975
10	2.1719	1.9547	2.1091	2.2634	2.0576	2.1605	1.9547
11	2.32	2.0576	1.9204	2.3765	2.0576	2.3148	
12	2.3765	2.2119	2.0119	2.3765	2.3663	2.3148	
13	2.4897	1.8519	1.9662	2.4331	2.2119	2.2634	
14	2.32	1.9547	2.0119	2.3765	2.2634	2.3148	
15	2.2805	2.1091	2.0576	2.2634	2.3663	2.3148	
16	2.32	2.3148	2.0576	2.32	2.1605	2.4177	1.9033
17	2.2634	2.1091	2.2862	2.1502	2.3148	2.3663	2.3148
18	2.3765	1.8004	1.9662	2.2068	2.2634	2.3148	2.1091
19	2.6595	2.2119	1.8747	2.2634	2.3148	2.3148	2.3148
20	2.2634	1.5432	1.829	2.2634	2.0576	2.2119	2.2119
21	2.1502	1.5432	1.6004	2.32	1.9547		2.0576
22	2.0936	1.8004		2.3765	1.749	2.1091	1.6975
23	2.037	1.8519		2.32	1.8004	1.8004	1.5947
24		2.2634	1.8519	1.6461	2.4331		1.9547
Max	2.6595	2.4897	2.2862	2.4331	2.4331	2.4177	2.3663
Min	2.037	1.5432	1.6004	1.6461	1.749	1.8004	1.5947
Avg	2.2790	2.0675	2.0122	2.2319	2.1923	2.1231	2.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 201 / 11 KV HARIKIRAN MLK SHEDDABLE URBAN
SDN(2887) Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9959	1.8665	1.922	1.9589	2.0698	1.587	1.6632
2	1.9022	1.7556	1.848	1.848	1.9959	1.4937	1.5708
3	1.7558	1.6617	1.7741	1.5524	1.6632	1.3817	1.4784
4	1.6827	1.5684	1.6632	1.4784	1.5893	1.307	1.423
5	1.5729	1.4784	1.5524	1.4784	1.5524	1.2136	1.3491
6	1.4784	1.3535	1.39	1.4045	1.2936	1.1576	1.2752
7	1.3676	1.3213	1.3535		1.3676	1.1157	1.1946
8	1.3306	1.267	1.2986	1.3032	1.3306	1.0317	1.1946
9	1.4045	1.3032	1.3394	1.307	1.2936	1.1641	1.2803
10		1.448	1.5927	1.4784	1.2936	1.2308	1.3937
11	1.7558	1.4842	1.7375	1.6263	1.6827	1.3032	1.5565
12	1.848	1.8823	1.8099	1.8111	1.7924	1.3535	1.7193
13	1.9774	1.9909	1.829	1.848	1.9035	1.4632	1.8656
14	2.0698	2.0633	2.0485	1.9959	1.9959	1.4632	1.8656
15	2.0328	2.0633	2.0485	2.0698	2.1253	1.5364	1.9022
16	2.0144	2.0271	1.9959	2.0328	2.0144	1.5364	1.9022
17	1.922	1.9204	1.922	1.9753	1.9035	1.4299	1.9387
18	1.7187	1.7558	1.5927	1.829	1.6095	1.2803	1.6827
19	1.7002	1.7556	1.6827	1.6461	1.5893	1.262	1.7002
20	1.8111	1.8111	1.7924	1.6461	1.7372	1.423	1.7741
21	1.8296	1.8296	1.922	1.9022	1.7372	1.5893	1.922
22	1.9589	1.9774	1.9589	1.9959	1.7924	1.7556	2.0328
23	2.0328	2.0698	2.0698	2.1068	1.8298	1.7741	1.9959
24	2.0698	1.9959	2.0144	2.0698	2.0911	1.6804	1.8111
Max	2.0698	2.0698	2.0698	2.1068	2.1253	1.7741	2.0328
Min	1.3306	1.267	1.2986	1.3032	1.2936	1.0317	1.1946
Avg	1.7927	1.7354	1.7566	1.7550	1.7189	1.3972	1.6455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 202 / 11 KV PRASHANT NAGAR MLK
SDN(2 Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6827	1.848	1.848	1.8099	1.8656	1.6057	1.7187
2	1.6461	1.7187	1.7741	1.8099	1.829	1.531	1.6632
3	1.5729	1.6244	1.6817	1.7375	1.7558	1.4563	1.6078
4	1.39	1.531	1.6078	1.7375	1.7558	1.363	1.5524
5	1.2803	1.4045	1.4969	1.448	1.4632	1.3256	1.4415
6	1.1584	1.3169	1.3535	1.3756	1.2803	1.2437	1.2936
7	1.2308	1.262	1.1888	1.1584	1.2012	1.2437	1.1157
8	1.1584	1.1222	1.1283	1.0498	1.1458	1.1584	.8686
9	1.0136	1.086	1.1104	1.134	1.1458	.9412	.8316
10		1.086	1.0745	1.1643	1.1088	.9774	.8316
11	1.5023	1.086	1.0136	1.2012	1.262	.8688	.8316
12	1.448	1.448	1.2308	1.1888	1.3717	1.0029	.8686
13	1.5546	1.5565	1.3756	1.2936	1.4449	1.0029	.9145
14	1.7002	1.6289	1.5203	1.4784	1.5181	.9671	.9145
15	1.701	1.7013	1.5203	1.5524	1.5524	1.0029	.9145
16	1.8473	1.7013		1.4784	1.4449	1.0029	1.0059
17	1.6095	1.3121	1.448	1.4998	1.3717	.9694	1.134
18	1.262	1.2012	1.086	1.1888	1.086	.9328	1.0059
19	1.2567	1.262	1.086	1.1888	1.3169	1.0059	1.2308
20	1.2936	1.3676	1.2308	1.2803	1.3676	1.1576	1.3169
21	1.7002	1.6278	1.6651	1.3169	1.5893	1.5339	1.3535
22	1.885	1.8665	1.8111	1.6461	1.848	1.7741	1.6095
23	1.9589	2.0328	1.9791	1.7924	1.9605	1.7741	1.6461
24	1.7558	1.9204	1.9035	1.8823	1.885	1.7177	1.7187
Max	1.9589	2.0328	1.9791	1.8823	1.9605	1.7741	1.7187
Min	1.0136	1.086	1.0136	1.0498	1.086	.8688	.8316
Avg	1.5047	1.4880	1.4406	1.4339	1.4821	1.2316	1.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 203 / 11 KV WATER FILTTER EXP NON SHEDDABLE WATER SUPPLY AND
MLK S Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.112	.0924	.1294	.0747	.0381	.0381
2	.037	.0381	.0381	.1294	.0747	.0381	.0381
3	.037	.0381	.0381	.1294	.0747	.112	.0381
4	.037	.112	.0191	.037	.112	.112	.0381
5	.037	.0381	.0191	.0185	.112	.0934	.0381
6	.0366	.1109	.0191	.0185	.112	.0747	.0381
7	.1086	.0924	.1109	.0183	.112	.0924	.0914
8	.0181	.0381	.0381	.128	.112	.0381	.0191
9	.1267	.0381	.0377	.0366	.112	.1086	.1097
10		.056	.128	.0914	.112	.0185	.0381
11	.112	.056	.0362	.0381	.056	.1294	.128
12	.112	.0739	.1463	.0381	.1307	.1294	.0381
13	.0381	.0739	.1267	.0381	.0381	.037	.1097
14	.1307	.0739	.128	.0381	.1109	.0185	.0183
15	.0381	.056	1.1999	.056	.0381	.1109	.0183
16	.112	.056		.056	.0191	.0189	.0366
17	.0381	.0381	.1294	.0373	.1109	.0381	.1294
18	.0381	.0381	.0183	.0747	.0381	.0191	.1294
19	.1109	.0381	.0377	.0747	.0381	.1109	.037
20	.0381	.0381	.1267	.0747	.112	.0914	.1267
21	.1109	.128	.0366	.0747	.0381	.0191	.0358
22	.0381	.0381	.1478	.0747	.112	.0924	.1294
23	.0381	.0381	.0373	.0747	.0381	.0381	.0362
24	.0185	.1109	.1109	.1294	.0747	.112	.0924
Max	.1307	.128	1.1999	.1294	.1307	.1294	.1294
Min	.0181	.0381	.0183	.0183	.0191	.0185	.0183
Avg	.0622	.0638	.1227	.0673	.0818	.0705	.0647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 401 / 33 kv incommer APDRP
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7311	3.786	3.8409	3.8552	4.0181	3.3471	3.4568
2	3.6763	3.5665	3.6763	3.7466	4.0181	3.1276	3.2922
3	3.4568	3.4928	3.5117	3.3665	3.9095	3.0493	3.1276
4	3.2922	3.3265	3.2922	3.2579	3.8009	2.8829	3.0178
5	2.9081	3.0178	3.0727	2.9321	3.5837	2.6337	2.8532
6	2.6063	2.7938	2.7692	2.8235	3.4751	2.3891	2.5789
7	2.6063	2.6326	2.5789	2.6063	3.0407	2.3388	2.4177
8	2.5514	2.392	2.4714	2.6063	2.9321	2.1794	2.1176
9	2.5514	2.3388	2.4714	2.4451	2.7149	2.1262	2.2262
10		3.0087	2.7343	2.5789	2.6063	2.3137	2.3348
11	3.3848	2.9321	3.0087	2.8235	3.0087	2.4394	2.6063
12	3.3848	3.9095	3.1893	3.0407	3.2773	2.4451	2.6063
13	3.638	4.0181	3.3665	3.2579	3.3665	2.5514	2.7692
14	3.8552	4.0181	3.6923	3.3665	3.638	2.6337	2.9321
15	3.8009	4.1267	3.6923	3.5294	3.7466	2.6337	2.8778
16	3.9095	4.1267	3.7146	3.6923	3.5837	2.6337	5.9728
17	3.6534	3.3122	3.4019	3.5837	3.4385	2.4714	6.5158
18	3.0624	3.0407	2.7641	2.9321	2.7641	2.3102	5.647
19	3.0407	3.0407	2.7343	2.9321	2.9012	2.3891	3.1161
20	3.2922	3.2922	3.2579	3.2579	3.1493	2.7435	3.2579
21	3.4751	3.5837	3.6923	3.4019	3.2579	3.1824	3.4751
22	3.8009	3.8009	3.9095	3.7311	3.5837	3.5837	3.6923
23	4.1267	4.1152	4.0181	4.0604	3.6923	3.6214	3.8089
24	3.9506	3.9095	3.9506	3.9095	4.0604	3.5665	3.5294
Max	4.1267	4.1267	4.0181	4.0604	4.0604	3.6214	6.5158
Min	2.5514	2.3388	2.4714	2.4451	2.6063	2.1262	2.1176
Avg	3.3807	3.3992	3.2838	3.2391	3.3987	2.7330	3.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 201 / 11 KV ANKUR INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.8002	.6859	.8573	.8059	.9145	.8916
2	.5144	.8002	.6859	.8573	.7888	.9145	.7888
3	.4973	.7811	.6173	.9259	.7373	.9145	.6859
4	.4458	.7811	.583	1.0288	.7202	.9145	.6173
5	.4115	.7811	.5658	1.0479	.7202	.9335	.5144
6	.4458	.8002	.5487	1.0479	.703	.9717	.5487
7	.4287	.4001	.5316	.5144	.4973	.743	.4801
8	.6859	.9145	.6859	.5487	.7202	.8383	.3944
9	.7202	.8573	.8573	1.0802	.8764	.8745	.4572
10	.7716	.9945		1.0974	1.0669	.9259	.5335
11	.8573	1.0288	1.0098	.5144	.9259	.9431	.5144
12	.9088	1.046	1.1431	1.046	1.0669	.9602	.5144
13	.9431	1.0288	1.105	1.0288	1.105	1.0288	
14	1.0288	1.046	1.086	1.046	1.0479	.9602	.5144
15	1.0098	1.0288	1.0669	1.0288	1.0098	.8573	
16	1.0098	.3772	1.3717	1.0631	1.0669	.7888	
17	1.1431	1.0288	1.1431	1.0288	1.0098	.8573	
18	1.2955	.7202	.9526	1.0974	.6287	.9088	.4458
19	.8573	.5658	.8002	1.0631	.8764	.8916	.463
20	.8764	.6001	.6859	1.0288	.8954	.8573	.3944
21	.8954	.6344	.8002	.9431	.9717	.8916	.4115
22	.8573	.6859	.9431	.8573	.9526	.9602	.4287
23	.8383	.7202	.9907	.8745	.9145	.9602	.4458
24	.463	.8002	.703	.9717	.823	.9145	.9259
Max	1.2955	1.046	1.3717	1.0974	1.105	1.0288	.9259
Min	.4115	.3772	.5316	.5144	.4973	.743	.3944
Avg	.7661	.8009	.8506	.9416	.8721	.9052	.5485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 202 / 11 KV GHIRNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.0953	.3086	.1029	.3601	.0953	.0762
2	.2896	.0953	.3048	.1029	.3772	.0953	.061
3	.3506	.0953	.4287	.1029	.4287	.0953	.061
4	.4115	.0953	.4268		.3963	.0953	.061
5	.4268	.0953	.442	.1029	.4572	.0953	.0762
6	.4572	.0953	.442	.1029	.4877	.0762	.1372
7	.4572	.0762	.4572	.0857		.0762	
8	.4725	.0762	.5487	.0857		.0762	
9	.442	.0762	.4877	.381		.5182	.5335
10		.3772		.5144		.4877	.5335
11		.5144		.3429		.4572	.5335
12		.4725		.5316		.381	.5335
13		.4877		.4572		.3658	
14		.4572		.442	.0762	.4115	.4115
15		.442		.4268	.0762	.4572	
16	.0762	.4115	.0953	.442	.0953	.4268	
17	.0762	.4973	.0953	.0857	.0953	.0686	
18	.0953	.0686	.1143	.0857	.0762	.2743	.0857
19	.0953	.0857	.1524	.0857	.1143	.0762	.1029
20	.1143	.0857	.1524	.0857	.1143	.0762	.12
21	.1143	.0857	.12	.1715	.1143	.0914	.3086
22	.1143	.0857	.1372	.2058	.1143	.0914	.3601
23	.0953	.0857	.1524	.2743	.0953	.0762	.3353
24	.2286	.0953	.2572	.1029	.3429	.0953	.0762
Max	.4725	.5144	.5487	.5316	.4877	.5182	.5335
Min	.0762	.0686	.0953	.0857	.0762	.0686	.061
Avg	.2542	.2105	.2846	.2314	.2248	.2108	.2448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 203 / 11 KV GHIRNI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3258	.3258	.3429	.3258	.3048	.3601
2	.3772	.3258	.3086	.3429	.3086	.2858	.3772
3	.3772	.3086	.2591	.3086	.3258	.2858	.3601
4	.3429	.3239	.3086	.3086	.3086	.2858	.3429
5	.3086	.3048	.3086	.3086	.2915	.3048	.3429
6	.3258	.3048	.3258	.3429	.2572	.2743	.3258
7	.2915	.2667	.3258	.2477	.2743	.2743	.2743
8	.3258	.3048	.3258	.0857	.3258	.3048	.3086
9	.3086	.2743	.3429	.2572	.3429	.2572	.3086
10	.3086	.2572		.3086	.3429	.2743	.3086
11	.3258	.2915	.3258	.2401	.3086	.3086	.2743
12	.3086	.3086	.3429	.3429	.2915	.2915	.2743
13	.3086	.3429	.3429	.3258	.2915	.3429	
14	.3086		.3429	.3086	.3086	.3601	.3429
15	.3429		.3429	.3258	.3258	.3429	
16	.3258		.3429	.3258	.2743	.3258	
17	.3429	.3601	.381	.3086	.2915	.3258	
18	.3429	.3601	.4001	.3258	.1905	.3086	.3772
19	.3429	.3772	.4191	.3429	.3086	.3429	.3944
20	.3772	.3601	.3772	.3429	.3601	.3353	.4287
21	.3944	.3429	.4382	.3258	.3601	.3601	.3944
22	.3601	.3601	.4382	.3086	.3258	.3601	.3772
23	.3258	.3601	.381	.3258	.3086	.3258	.3601
24	.3258	.3429	.3258	.381	.3258	.3048	.3429
Max	.3944	.3772	.4382	.381	.3601	.3601	.4287
Min	.2915	.2572	.2591	.0857	.1905	.2572	.2743
Avg	.3351	.3240	.3492	.3077	.3073	.3120	.3438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 204 / 11 KV Waghul Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.3658	.0857	.3772	.0857	.3201	.4115
2	.061	.3658	.0857	.4191	.0686	.3048	.4458
3	.061	.3506	.0686	.4115	.0686	.3048	.5144
4	.061	.3658	.0762	.5144	.0686	.3048	.5487
5	.0762	.381	.0762	.5144	.0686	.3353	.4572
6	.0762	.4268	.0762	.5658	.0686	.5487	.4268
7	.061	.5792	.0686		.0686		
8		.7316	.0857		.0686		
9	.061	.6859	.0762		1.1431		
10	.823				1.046		
11	.7011		.8078		1.0288		
12	.6859		.7316		1.0288		
13	.6859		.5944	.0686	.6516	.0457	
14	.5792		.5487	.0686	.5944	.0457	.0381
15	.503		.442	.0686	.6097	.061	
16	.5182	.0762	.4725	.0857	.5792	.061	
17	.5487	.0686	.6287	.0857		.061	
18		.0857		.0857		.061	.0857
19		.0857		.0857		.061	.1029
20		.1029		.0857		.061	.1029
21		.1029		.0857	.2743	.3506	.1029
22		.1029		.0857	.3048	.3963	.1029
23		.0857		.0857	.3201	.381	.0857
24	.0762	.3201	.0857	.3429	.0857	.3201	.4458
Max	.823	.7316	.8078	.5658	1.1431	.5487	.5487
Min	.061	.0686	.0686	.0686	.0686	.0457	.0381
Avg	.3326	.2935	.2947	.2243	.4116	.2236	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 211 / 11 KV INCOMER I

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.1431	1.3203	1.2003	1.5261	1.3336	1.3717
2	1.0288	1.1431	1.3032	1.2003	1.4918	1.3336	1.3375
3	1.0802	1.1431	1.286	1.2003	1.5089	1.2955	1.2003
4	1.1488	1.0288	1.3032	1.166	1.4918	1.2574	1.2346
5	1.1317	1.0098	1.3203	1.1317	1.5432	1.2574	1.2003
6	1.166	.9907	1.3203	1.1317	1.4232	1.2765	1.1317
7	1.1488	.6287	1.1888	.8002	.7888	1.0669	.7545
8		1.2574	1.6118	.8764	1.0802	1.1812	.6344
9	1.5089	1.1488	1.8004	1.7147	1.3336	1.8004	1.166
10	1.3717	1.6289		1.8861		1.749	1.2003
11	1.2346	1.7147	1.5242	1.0288	1.3032	1.7147	1.1831
12	1.2174	1.8004	1.3717	1.8861	1.286	1.6975	1.2003
13	1.1831	1.869	1.3717	1.8861	1.3032	1.8347	
14	1.2003	1.7318	1.448	1.869	1.3032	1.6461	1.1145
15	1.0974	1.7147	1.448	1.8519	1.3032	1.5947	
16	1.2003	1.2003	1.5604	1.8861	1.2517	1.5604	
17	1.2346	1.7147	1.6956	1.4575	1.2346	1.4746	
18	1.4232	1.166	1.3146	1.3717	.8764	1.286	.7373
19	1.1431	1.0288	1.1431	1.5432	1.1431	1.3375	.7373
20	1.3336	1.0631	1.3336	1.5089	1.2346	1.2689	.7545
21	1.3336	1.0974	1.3717	1.4918	1.2517	1.2346	.9431
22	1.2384	1.1145	1.5432	1.4232	1.4289	1.3203	1.0288
23	1.1431	1.166	1.2689	1.5089	1.3908	1.2689	1.0802
24	.9259	1.1431	1.286	1.3527	1.5432	1.3336	1.3032
Max	1.5089	1.869	1.8004	1.8861	1.5432	1.8347	1.3717
Min	.9259	.6287	1.1431	.8002	.7888	1.0669	.6344
Avg	1.1944	1.2770	1.3972	1.4322	1.3061	1.4218	1.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 212 / 11 KV INCOMER II

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.3658	.0953	.3429	.0686	.3201	.4115
2	.0686	.3658	.0953	.381	.0686	.3048	.4458
3	.0686	.3506	.0857	.4572	.0686	.3048	.5144
4	.0686	.3658	.0686	.5716	.0686	.3048	.5487
5	.0857	.381	.0762	.5716	.0686	.3353	.5144
6	.0857	.4268	.0762	.5658	.0686	.5487	.4801
7	.0857	.5792	.0762		.0686		
8		.7316	.0857		.0686		
9	.0686	.6859	.0762		1.0288		
10	.823				1.1622		
11	.7888		.8078		1.0288		
12	.7716		.7316		.8573		
13	.7716		.5944	.0762	.6344		
14	.5792		.5487	.0953	.5944	.0514	.0381
15	.503		.442	.0953	.6097	.0686	
16	.5182	.0762	.4725	.0857	.5792	.0686	
17	.5487	.0686	.6287	.0857		.0686	
18		.0857		.0857		.0686	.1029
19		.1029		.0857		.0686	.1029
20		.1029		.0857		.0686	.12
21		.1029		.0857	.2743	.3506	.0953
22		.1029		.0857	.3048	.4458	.0857
23		.0857		.0857	.3201	.4287	.1029
24	.0762	.3201	.0857	.3429	.0686	.3201	.463
Max	.823	.7316	.8078	.5716	1.1622	.5487	.5487
Min	.0686	.0686	.0686	.0762	.0686	.0514	.0381
Avg	.3528	.2945	.2969	.2325	.4006	.2427	.2876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 401 / 33 KV INCOMER I

Feeder KV- 33 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	1.2003	1.2346	1.3717	1.4918	1.3717	1.3889
2	1.0288	1.2003	1.1831	1.2574	1.4403	1.3717	1.3375
3	1.2346	1.2003	1.1317	1.2574	1.3889	1.3146	1.1831
4	1.1831	1.1431	1.0517	1.2574	1.4403	1.2574	1.2346
5	1.286	1.1431	1.2346	1.2574	1.3889		1.1831
6	1.3375	1.1431	1.286	1.3146	1.4403	1.4289	1.1317
7	1.2346	.743	1.286	.8573	.7716	1.086	.7716
8	1.6461	1.3146	1.6975	1.1317	1.0288	1.2003	.6687
9	1.5947	1.286	1.6975	1.8004	1.2574	1.6975	1.1831
10	1.5432	1.5947		1.6975	1.3146	1.6461	1.2346
11	1.4403	1.6461	1.4861	1.1317	1.286	1.5947	1.1831
12	1.3375	1.749	1.5432	1.9033	1.3375	1.6975	1.1831
13	1.286	1.9033	1.3889	1.8519	1.3889	1.6975	
14	1.3717	1.8519	1.3717	1.8519	1.286	1.6461	1.2574
15	1.2574	1.8004	1.3717	1.8004	1.3889	1.5947	
16	1.3375	1.4403	1.5947	1.749	1.286	1.5432	
17	1.5432	1.6461	1.5432	1.5432	1.2346	1.3889	
18	1.4918	1.1831	1.4403	1.4403	.9145	1.3375	.823
19	1.2574	1.0288	1.1317	1.3889	1.2003	1.4403	.7716
20	1.4289	1.1317	1.2346	1.3375	1.286	1.3375	.823
21	1.4289	1.1831	1.2346	1.3889	1.286	1.286	1.0288
22	1.3146	1.1831	1.4861	1.3375	1.5432	1.3375	1.0802
23	1.2574	1.1831	1.286	1.3375	1.4289	1.286	1.0802
24	.9774	1.2003	1.286	1.2346	1.4918	1.3717	1.2346
Max	1.6461	1.9033	1.6975	1.9033	1.5432	1.6975	1.3889
Min	.9774	.743	1.0517	.8573	.7716	1.086	.6687
Avg	1.3291	1.3375	1.3566	1.4375	1.3051	1.4319	1.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 402 / 33 KV INCOMER II

Feeder KV- 33 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.3658				.3201	.4115
2	.1029	.3658				.3201	.463
3	.1029	.3658				.3201	.5144
4	.1543	.3658				.3201	.5658
5		.3658				.3658	.5144
6		.4115				.5487	.463
7		.5944					
8		.7316					
9		.7716					
10	.823						
11	.823		.823				
12	.7202		.7773				
13	.7716		.6401				
14	.5944		.5487				
15	.503		.4572		.5944		
16	.5487		.503		.5944		
17	.5944						
18				.1715			.1543
19		.1543					.1543
20		.1543					.1715
21		.1543			.2743	.3601	
22		.1543			.3201	.463	
23		.1543			.3658	.463	
24	.1543	.3201	.1543	.3201		.3658	.463
Max	.823	.7716	.823	.3201	.5944	.5487	.5658
Min	.1029	.1543	.1543	.1715	.2743	.3201	.1543
Avg	.4652	.3620	.5577	.2458	.4298	.3847	.3875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 201 / 11KV SHIVAJI NAGAR MLK SHEDDABLE URBAN
SDN(288 Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3937	1.386	1.262	1.448	1.4449	1.3676	1.2803
2	1.39	1.3676	1.1888	1.448	1.39	1.3306	1.2437
3	1.3717	1.3306	1.134	1.3575	1.3535	1.2936	1.1888
4	1.3535	1.2936	1.0974	1.267	1.3169	1.2567	1.134
5	1.3169	1.2567	1.0608	1.2308	1.3169	1.1827	1.0608
6	1.267	1.2197	1.0974	1.2197	1.2986	1.1458	.9877
7	1.1765	1.1458	1.134	1.1827	1.2071	1.0903	1.0059
8	1.1222	1.0719	1.134	1.1273	1.1827	1.0534	1.0242
9	1.1088	1.0974	1.1458	1.0608	1.1458	1.0425	1.0317
10	1.0349	1.134	1.1157	1.086	1.1088	1.0059	1.0059
11	1.1088	1.1523	1.1273	1.0679	1.1273	.9877	1.0242
12	1.1458	1.1706	1.1827	1.1584	1.1458	.9511	1.0059
13	1.1827	1.2071	1.2012	1.1584	1.1827	.9877	1.0242
14	1.2936	1.2437	1.1765	1.1523	1.2197	1.0242	1.086
15	1.3676	1.2437	1.1946	1.2437	1.2936	1.0608	1.1946
16	1.3676	1.262	1.1946	1.386	1.3306		1.1584
17	1.3306	1.262	1.2127	1.3121	1.2936		1.1706
18	1.2197	1.2803	1.2127	1.2803	1.2197	1.0608	1.1706
19	1.2936	1.3169	1.2382	1.3169	1.2936	1.0791	1.2012
20	1.3676	1.3352	1.3717	1.4449	1.386	1.134	1.3535
21	1.4415	1.3717	1.4415	1.4815	1.4045	1.1888	1.3756
22	1.4784	1.3535	1.5154	1.4083	1.4045	1.2071	1.4118
23	1.4784	1.3169	1.4969	1.4449	1.4415	1.2437	1.448
24	1.3756	1.46	1.4083	1.4784	1.4815	1.386	1.3717
Max	1.4784	1.46	1.5154	1.4815	1.4815	1.386	1.448
Min	1.0349	1.0719	1.0608	1.0608	1.1088	.9511	.9877
Avg	1.2911	1.2616	1.2227	1.2817	1.2912	1.1400	1.1650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288]

BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 202 / 11 KV MANGAL GATE MLK

SHEDDABLE URBAN

SDN(2887 Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5203	1.6651	1.2437	1.7013	1.5927	1.448	1.2803
2	1.3575	1.5927	1.1706	1.7013	1.4842	1.3756	1.2437
3	1.3394	1.5203	1.134	1.6289	1.448	1.3394	1.1888
4	1.267	1.448	1.0974	1.448	1.3394	1.3032	1.134
5	1.267	1.4118	1.0242	1.267	1.267	1.2308	1.0974
6	1.2489	1.3394	.9877	1.1584	1.2489	1.1946	1.0608
7	1.086	1.1222	1.0242	1.1222	1.1403	1.086	.9877
8	1.0136	1.0498	1.0791	1.1403	1.1041	.9412	1.0242
9	1.0317	1.0791	1.0498	.9774	1.0136	.9877	1.0059
10	1.0498	1.0791	1.0498	1.0136	.9412	1.0974	.9593
11	1.086	1.0974	1.0498	1.0387	1.0136	1.134	.905
12	1.1222	1.134	1.1584	1.0745	1.086	1.1523	.9231
13	1.1584	1.1523	1.1946	1.182	1.1584	1.134	.9412
14	1.267	1.1523	1.1946	1.267	1.1946	1.0974	1.1765
15	1.3756	1.1706	1.1584	1.1765	1.2308		1.2851
16	1.3756	1.1888	1.1584	1.1222	1.2308		1.2308
17	1.3394	1.1888	1.1403	1.086	1.1946		1.1765
18	1.1222	1.1888	1.1403	1.1041	1.1222	1.0608	1.1222
19	1.1584	1.2254	1.1222	1.1403	1.1946	1.0974	1.1222
20	1.3032	1.2803	1.2851	1.3937	1.2851	1.0974	1.2308
21	1.4118	1.3169	1.3937	1.448	1.3575	1.134	1.3032
22	1.4661	1.3535	1.5565	1.5565	1.4118	1.1706	1.4661
23	1.6832	1.3169	1.7375	1.6651	1.5023	1.2437	1.5927
24	1.6289	1.7375	1.7193	1.7013	1.7013	1.5023	1.4083
Max	1.6832	1.7375	1.7375	1.7013	1.7013	1.5023	1.5927
Min	1.0136	1.0498	.9877	.9774	.9412	.9412	.905
Avg	1.2783	1.2838	1.2029	1.2964	1.2610	1.1823	1.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 203 / 11 KV YASHODHAM MLK SHEDDABLE URBAN
 SDN(2887) Feeder KV- 11 /
 OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.182	1.0387	.8962	1.1403	1.1222	.4656	.823
2	1.1584	1.0029	.8413	1.1403	1.0498	.4477	.7682
3	1.1222	.9671	.7316	1.1584	1.0136	.8596	.7316
4	1.0498	.9313	.695	1.1222	.9774	.9313	.695
5	.9774	.8954	.6584	1.086	.9412	.9134	.7316
6	.8596	.8596	.695	1.0136	.905	.8954	.7682
7	.8059	.8238	.7682	.9593	.8507	.8954	.7682
8	.7701		.8413	.8507	.8145	.8238	.7865
9	.788	.7164	.8688	.8869	.8596		.7701
10	.8238		.905	.8596	.8954		.7602
11	.8954		.9231	.8417	.9134		.7602
12	.9671		.9774	.9313	.9313		.7602
13	1.0029	.7682	.9955	.985	.9313		.8145
14	1.0387	.8048	.9774	1.0317	1.0029		.8954
15	1.0745	.8962	.9593	1.086	1.0745		1.0029
16	1.0745	.9694	.9412	1.1765	1.0745		.9955
17	.8775	.9877	.9231	1.086	1.0387		.9231
18	.8954	.9694	.905	.9231		.8962	.8688
19	1.0029	.9877	.9231	.9593		.8779	.8688
20	1.0208	1.0242	.905	1.0498		.8962	.9412
21	1.0387	1.0242	1.0679	1.086		.8962	.985
22	1.0387	.9877	1.1946	1.1765		.9145	1.1104
23	1.1641	.9511	1.2127	1.1765	.4835	.8779	1.1104
24	1.1462	1.0924	1.1523	1.1403	1.1584	.4656	.7133
Max	1.182	1.0924	1.2127	1.1765	1.1584	.9313	1.1104
Min	.7701	.7164	.6584	.8417	.4835	.4477	.695
Avg	.9906	.9349	.9149	1.0361	.9494	.8038	.8480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 211 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9276	4.0238	3.9872	4.3347	4.0787	3.1824	3.0178
2	3.7494	3.914	3.8409	4.3347	3.8592	3.0727	2.9264
3	3.6946	3.7677		4.1884	3.8043	3.219	2.7801
4	3.4751	3.5482	3.3836	3.8775	3.5848	3.1459	2.7435
5	3.3484	3.3653	3.219	3.6214	3.4751	3.0727	2.652
6	3.2217	3.219	3.2556	3.4019	3.3105	3.0361	2.5606
7	2.9502	2.8898	3.2922	3.1093	3.1093	2.8898	2.5972
8	2.7873	2.7435	3.3288	2.9995	3.0308	2.6337	2.6337
9	2.8166	2.1948	3.0727	2.7618	2.8532	2.652	2.5882
10	2.7435	2.1765	3.091	2.8416	2.7801	2.6886	2.5057
11	2.963	2.2314	2.9081	2.8235	2.8898	2.7069	2.5606
12	3.1093	2.2497	3.3288	3.0588	2.9995	2.7069	2.5423
13	3.2556	2.8166	3.2739	3.1855	3.1093	2.7069	2.6244
14	3.2556	2.8532	3.3836	3.3288	1.39	2.6703	3.0769
15	3.3288	2.9995	3.3471	3.4385	3.3288	2.7252	3.3484
16	3.3288	3.1093	3.3288	3.6961	3.3288	2.7801	3.2941
17	3.2556	3.1459	3.3105	3.5113	3.219	2.8349	3.219
18	3.0361	3.1824	3.1093	3.219	2.1582	2.9264	3.1093
19	3.219	3.2556	3.2373	3.3288	2.4143	3.0178	3.1602
20	3.3653	3.2922	3.4934	3.7129	2.5606	3.0727	3.3653
21	3.6214	3.3288	3.7129	3.8226	2.7435	3.1459	3.4932
22	3.8409	3.5117	4.0787	4.0055	2.963	3.219	3.8371
23	4.1701	3.658	4.2798	4.0969	3.4385	3.2556	4.0181
24	4.0905	4.1335	4.0787	4.1518	4.1884	3.2922	3.7129
Max	4.1701	4.1335	4.2798	4.3347	4.1884	3.2922	4.0181
Min	2.7435	2.1765	2.9081	2.7618	1.39	2.6337	2.5057
Avg	3.3564	3.1504	3.4496	3.5355	3.1091	2.9439	3.0153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 401 / 33 kv Incomer Salipura MLK NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2896	4.2353	3.8409	4.3896	4.3347	3.4751	3.5665
2	4.1152	4.0181	3.2922	4.3896	4.1152	3.3665	3.2922
3	4.0604	3.9095	3.2922	4.0604	4.0604	3.4751	3.0727
4	3.8409	3.8009	3.1824	3.8409	3.8409	3.3665	2.8532
5	3.7311	3.6923	2.963	3.7311	3.7311	3.2579	2.7435
6	3.4751	3.4751	2.7435	3.5117	3.5665	3.2036	2.6337
7	3.2036	3.1493	2.8532	3.2922	3.2922	3.0407	2.6886
8	3.0407	2.9864	2.963	3.1824	3.2156	2.8778	2.7435
9	3.0407	2.1948	3.0727	2.963	2.9864	2.963	2.7149
10	2.9864	2.3045	2.963	3.0407	2.9321	3.0727	2.6886
11	3.1493	2.3045	3.0727	3.0407	3.0407	2.963	2.7435
12	3.3122	2.4143	3.2922	3.2579	3.1493	2.7435	2.7435
13	3.4208	2.963	3.5117	3.3665	3.3122	2.8532	2.8532
14	3.5837	3.0727	3.5117	3.5117	3.4208	3.7311	3.2579
15	3.6923	3.2373	3.4019	3.6214	3.5294	3.2922	3.5294
16	3.6923	3.2922	3.4019	3.8809	3.5294	3.4019	3.4751
17	3.5837	3.4019	3.3471	3.7146	3.4751	3.5117	3.4019
18	3.2579	3.4019	3.2922	3.4019	2.4434	3.4019	3.2922
19	3.4208	3.5117	3.4019	3.5117	2.6063	3.4019	3.3265
20	3.5837	3.6214	3.6214	3.9506	2.7692	3.5117	3.6214
21	3.8009	3.8409	3.9506	4.0604	2.9321	3.5117	3.7466
22		4.1152	4.2798	4.3896	3.0407	3.7311	4.0724
23	4.3439	4.3896	4.4993	4.3896	3.638	3.786	4.2896
24	4.3439	4.3439	4.2798	4.3896	4.4445	3.5294	3.9506
Max	4.3439	4.3896	4.4993	4.3896	4.4445	3.786	4.2896
Min	2.9864	2.1948	2.7435	2.963	2.4434	2.7435	2.6337
Avg	3.6074	3.4032	3.4179	3.7037	3.3919	3.3112	3.2209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 201 / 11 KV GOULKHED SINGLE PHASING

FEEDER(SINGLE P Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1509	.2241	.1715	.2286	.1509	.1715
2	.2058	.1509	.2241	.1715	.2286	.1509	.1715
3	.1886	.1509	.2241	.1715	.2286	.1509	.1715
4	.1886	.1509	.2241	.1715	.2286	.1509	.1715
5	.2058	.1509	.2241	.1715	.2477	.1509	.1886
6	.2229	.1134	.2241	.1886	.2286	.1677	.2515
7	.2229	.1781	.2427	.1867	.2096	.2033	.2241
8	.2229	.2591	.2218	.2427	.1905	.2427	.2054
9	.2058	.3239	.2033	.2054	.2286	.2033	.2054
10	.1619	.1715	.1981	.2054	.2267	.2096	.2033
11	.2753	.2477	.2743	.2614	.2915		.2195
12	.2915	.2667	.2896	.2427	.2949		.2561
13	.3077	.2858	.2896	.2987	.2785		.2743
14	.3077	.3048	.2591	.3326	.2785		.2743
15	.2915	.3048	.2591	.3511	.285		.2896
16	.2753	.3239	.2439	.2957	.285		.3142
17	.2753	.2801	.2591	.2858	.2587	.2801	.3239
18	.2241	.2587	.2054	.2667	.2614	.3361	.3048
19	.3547	.3361	.2614	.3239	.2957	.3174	.362
20	.3921	.3734	.3921	.362	.3734	.3547	.381
21	.3361	.3361	.1459	.381	.1715	.2401	.362
22	.2801	.2987	.2058	.3239	.1844	.2229	.3239
23	.2427	.2427	.1886	.2667	.1475	.1886	.3048
24	.2229	.1341	.2241	.381	.2477	.1509	.1715
Max	.3921	.3734	.3921	.381	.3734	.3547	.381
Min	.1619	.1134	.1459	.1715	.1475	.1509	.1715
Avg	.2545	.2414	.2379	.2608	.2458	.2151	.2553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 202 / 11 KV LONWADI SINGLE PHASING

FEEDER(SINGLE PH Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1509	.1867	.1543	.2286	.1715	.1886
2	.1715	.1509	.1867	.1543	.1905	.1715	.1886
3	.1715	.1509	.1867	.1543	.1905	.1715	.1886
4	.1715	.1509	.1867	.1543	.2096	.1715	.1886
5	.1886	.1677	.1867	.1715	.2477	.1715	.2058
6	.2058	.1943	.1867	.2572	.2096	.2229	.3521
7	.1715	.2429	.168	.132	.1524	.1494	.168
8	.1543	.2846	.1307	.1307	.1524	.112	.168
9	.1543		.1494	.112	.381	.112	.1307
10	.1943	.0191	.1372	.1494	.2753	.1524	.1494
11	.3077	.0191	.2286	.1867	.2429		.1307
12	.2591	.1334	.2439	.1867	.2458		.168
13	.2267	.1524	.2439	.2054	.2294		.168
14	.2267	.2286	.2134	.2241	.2294		.168
15	.2105	.2477	.2134	.2241	.2347		.1848
16	.2105	.2477	.1981	.2241	.218		.2054
17	.1943	.2054	.2105	.2096	.1867	.2241	.1905
18	.1494	.1867	.1494	.2096	.1867	.2241	.1905
19	.2054	.2241	.2614	.2096	.2241	.2427	.2286
20	.3174	.2987	.3547	.3048	.2987	.3174	.3429
21	.2987	.3174	.2103	.3429	.1928	.2915	.3429
22	.2801	.2801	.1886	.3048	.1715	.2743	.3048
23	.2241	.2427	.1715	.2667	.1677	.2229	.2667
24	.2229	.1677	.1867	.1543	.2286	.1715	.1886
Max	.3174	.3174	.3547	.3429	.381	.3174	.3521
Min	.1494	.0191	.1307	.112	.1524	.112	.1307
Avg	.2134	.1941	.1992	.2010	.2206	.1986	.2087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 203 / 11 KV KHAMKHED SINGLE PHASING

FEEDER(SINGLE P Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0671	.1334	.0514	.1524	.0526	.0686
2	.12	.0671	.1334	.0514	.1334	.0566	.0686
3	.12	.0671	.1334	.0514	.1334	.0566	.0686
4	.12	.0671	.1334	.0514	.1334	.0526	.0686
5	.12	.0671	.1334	.0514	.1715	.0526	.0686
6	.1372	.081	.1334	.0686	.1334	.0701	.1006
7	.12	.081	.1524	.1307	.1334	.132	.1307
8	.12	.0949	.1132	.1494	.1334	.1132	.1307
9	.1029	.0762	.1132	.1307	.1143	.1132	.1307
10	.0648	.0953	.061	.1509	.0972	.1143	.1132
11	.0648	.1524	.0762	.1509	.081		.1494
12	.0648	.1905	.0762	.1698	.0819		.1494
13	.0648	.1905	.0762	.1698	.0819		.168
14	.0648	.1905	.061	.1698	.0819		.168
15	.0648	.1905	.061	.1886	.0838		.1494
16	.081	.1905	.0762	.1886	.0838		.1494
17	.081	.1509	.081	.1905	.1698	.168	.1524
18	.1307	.1509	.1307	.1524	.1524	.168	.1334
19	.168	.1715	.168	.1524	.1698	.2241	.2096
20	.2241	.2096	.2427	.2286	.2096	.2427	.2286
21	.1867	.1905	.0701	.2286	.0716	.0857	.2286
22	.168	.1715	.0686	.1905	.0526	.0686	.1905
23	.1307	.1524	.0686	.1524	.0514	.0686	.1524
24	.1372	.0671	.1334	.0514	.1524	.0526	.0686
Max	.2241	.2096	.2427	.2286	.2096	.2427	.2286
Min	.0648	.0671	.061	.0514	.0514	.0526	.0686
Avg	.1157	.1306	.1096	.1363	.1192	.1051	.1353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 211 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
20		.8954	.9896				
21	.8215						
23					.3772		
24	.583	.3688	.5525	.3772	.6287	.3856	.4287
Max	.8215	.8954	.9896	.3772	.6287	.3856	.4287
Min	.583	.3688	.5525	.3772	.3772	.3856	.4287
Avg	.7023	.6321	.7711	.3772	.5030	.3856	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 401 / 33 KV INCOMER TO NON SHEDDABLE WATER SUPPLY AND
 JAMBHULDHABA Feeder KV- 33 / UTILITY
 INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.18	.3498	.1885	.3923	.1943	.3736	.4227
2	.1749	.3498	.1885	.3973	.1715	.3736	.4227
3	.1749	.3498	.194	.3973	.1715	.3687	.4177
4	.1646	.3547	.1885	.3923	.1829	.3834	.4177
5	.1749	.3692	.183	.4074	.2115	.4276	.4525
6	.18	.4178	.1885	.4829	.1943	.5309	.6996
7	.1646	.6404	.194	.1738	.1772	.1846	.1683
8	.1646	.6493	.1846	.2009	.1658	.1811	.1738
9	.1595	.4801	.1738	.1683	.7716	.1629	.1629
10	.4317	.1429	.5396	.1866	.6452	.1715	.1629
11	.6689	.1886	.6584	.2085	.6689		.1846
12	.6421	.2115	.6767	.214	.6452		1.6832
13	.6167	.2229	.5807	.2359	.5977		.2172
14	.5977	.2401	.5716	.2552	.5713		.2281
15	.574	.2458	.5213	.2715	.6024		.2281
16	.5456	.2686	.5396	.2606	.6073		.2335
17	.555	.2359	.5598	.2629	.2226	.2226	.2401
18	.1738	.2063	.1683	.2401	.1996	.2552	.2343
19	.2606	.255	.2226	.2515	.2359	.2552	.2743
20	.3204	.3049	.3366	.3144	.3049	.3204	.3315
21	.2769	.2938	.4376	.3258	.4575	.5122	.3258
22	.2335	.2495	.4275	.2743	.3981	.4873	.2629
23	.1846	.1996	.4124	.2172	.3692	.4575	.2172
24	.18	.3547	.194	.3834	.2	.3687	.4227
Max	.6689	.6493	.6767	.4829	.7716	.5309	1.6832
Min	.1595	.1429	.1683	.1683	.1658	.1629	.1629
Avg	.3250	.3159	.3554	.2881	.3736	.3354	.3577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 201 / 11KV ZODGA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.4877
Max	.4877
Min	.4877
Avg	.4877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 204 / 11 KV DAND EXPRESS MLK
SDN(288 Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-JUN-18
HR	Load (MW)
24	.3601
Max	.3601
Min	.3601
Avg	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 205 / 11 KV DEODHABA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 206 / 11 KV MALKAPUR TOWN (MLK SHEDDABLE URBAN
SDN 2 Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.442
Max	.442
Min	.442
Avg	.442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 207 / 11 KV INDISTRIAL MLK
SDN(2887) Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	.3258
Max	.3258
Min	.3258
Avg	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 209 / 11 KV DEODHABA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4725
Max	.4725
Min	.4725
Avg	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 210 / 11 KV ZODGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 403 / 33 KV NANDURA INOUT LINE NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.8519
Max	1.8519
Min	1.8519
Avg	1.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 077001 / 132 KV MALKAPUR S/S

Feeder No / Name : 405 / 33 KV MALKAPUR INPUT TO NON SHEDDABLE WATER SUPPLY AND
TOWN Feeder KV- 33 / INCOMING UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 201 / 11 KV TAPOWAN AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0497		.0663		.0663	.112
2		.0497		.0663		.0663	.112
3		.0829		.0663		.0995	.112
4		.0829		.0829		.0995	.1494
5		.0829		.0829		.1326	.1867
6		.0995		.116		.1658	.2218
7		.116					
8		.1989					
9		.1326			.1326		
10	.1326		.1326		.1989		
11	.1989		.1989		.1989		
12	.1658		.2321		.1989		
13	.1989		.2321		.1658		
14	.1658		.1989		.1658		
15	.1658		.1989		.1326		
16	.1658		.1326		.1326		
17	.1326		.1326				
21			.0497		.0497	.0934	
22			.0663		.0663	.0934	
23			.0663		.0663	.0934	
24		.0497		.0663		.0663	.0934
Max	.1989	.1989	.2321	.116	.1989	.1658	.2218
Min	.1326	.0497	.0497	.0663	.0497	.0663	.0934
Avg	.1658	.0945	.1492	.0781	.1371	.0977	.1410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 202 / 11 kv panhera ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.0663	.3052	.3258	.3258	.0995	.0934
2	.2218	.0663	.3052	.3086	.3086	.0995	.0747
3	.2587	.0663	.3052	.3086	.2915	.0995	.0739
4	.2587	.0663	.3391	.2915	.3086	.0995	.0747
5	.2957	.0663	.3391	.3086	.2915	.0995	.0739
6	.3174		.3391	.3086	.3258		.0747
7	.3696		.3391				
8	.5175		.3052				
9	.3696		.3052	.2652		.431	
10		.3391		.3601		.4805	
11		.373		.3086			
12		.407		.3601			.6443
13		.407		.3772			.6783
14		.373		.3944			.6443
15		.373		.4115		.0924	.5087
16		.373		.4287		.7392	.4748
17		.3391					
19		.0857					
20	.0663	.0848	.0663	.0857	.0663	.0924	.0086
21	.0663	.0848	.0663	.1715	.0663	.112	.2543
22	.0663	.0848	.0663	.1715	.0663	.112	.2543
23	.0663	.0509	.116	.1715	.0732	.0924	.2543
24	.1848	.0663	.3052	.3429	.3429	.0663	.0934
Max	.5175	.407	.3391	.4287	.3429	.7392	.6783
Min	.0663	.0509	.0663	.0857	.0663	.0663	.0086
Avg	.2317	.1986	.2502	.3000	.2243	.1940	.2675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 203 / 11 kv D,badhe ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.0663	.9156	.0663	.9259		.0739
2	.5544	.0663	.9835	.0663	.9602		.0739
3	.5544	.0663	1.0513	.0663	.9945		.0739
4	.5175	.0663	1.1869	.0663	.9602		.0739
5	.5544	.0663	1.1869	.0663	.9774		.0739
6	.5914		1.1869		.9602		.0739
7	1.1458		1.2209				
8	1.3306		1.1869				
9	1.643		1.153	.7956		1.5249	1.4243
10		1.1869		1.2346		1.5524	1.3565
11		1.1869		1.2689		1.6263	1.2887
12		1.2209		1.2346		1.4937	1.2887
13		1.2209		1.2003		1.5154	1.1869
14		1.2003		1.166		1.3443	1.0174
15		1.153		1.0288		1.4415	.8817
16		1.0174		.8916		.1294	1.0174
17		.8817					
20	.0663	.0848	.0663	.0686		.0924	.0848
21	.0663	.0848	.0663	.823		.0934	.6104
22	.0663	.0848	.0663	.8059		.0924	.7461
23	.0663	.0848	.0663	.7888		.0924	.6783
24	.4435	.0663	.8478	.0663	.8573		.0924
Max	1.643	1.2209	1.2209	1.2689	.9945	1.6263	1.4243
Min	.0663	.0663	.0663	.0663	.8573	.0924	.0739
Avg	.5798	.5447	.7989	.6503	.9480	.9165	.6377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 204 / 11 kv D,Badhe GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9877	.8817	.9877	.8916	.8413	.924
2	.9979	.9877	.8478	.9511	.9259	.8413	.924
3	1.0349	.9877	.8817	.9511	.9431	.8413	.9425
4	1.0829	1.0242	.9156	.9877	.9602	.8779	.961
5	1.1576	1.0242	.9835	1.0242	.9945	.9511	.9979
6	1.2136	1.134	1.0174	1.134	1.0288	1.0242	1.1016
7	1.0829	1.0608	1.0174	1.0608	.9602	.9145	.9896
8	.961	.9877	.8478	.9877	.7888	.8779	.8478
9	.9335	.9511	.8139	.9145	.7716	.7682	.7461
10	.8413	.8817	.8413	.8402	.8048	.7282	.6783
11	.8413	.8817	.8413	.8573	.8048		.6783
12	.7865	.8817	.8596	.8745	.8413	.7468	.7122
13	.8048	.9156	.9145	.8573	.8413	.7468	.7122
14	.8413	.8478	.9511	.8402	.8413	.7842	.7122
15	.8413	.9835	.9511	.823	.8413	.8962	.7122
16	.8779	.9156	.9511	.8573	.8779	1.0082	.9496
17	.9511	.8987	1.0242	.9088	.9877	1.0829	1.0174
18	.9511	.9835	1.0608	.9602	.9877	1.1949	1.0513
19	1.0608	1.0513	1.1706	1.0288	1.0242	1.2136	1.1191
20	1.3169	1.0513	1.3169	1.2003	1.134	1.251	1.153
21	1.2071	1.0174	1.2071	1.1145		1.1949	1.0852
22	1.0974	.9835	1.134	.9945	.9877	1.1576	.9326
23	1.0608	.9496	1.0608	.9259	.9511	.9979	.7888
24	1.0456	1.0242	.9496	.9568	.8573	.9145	.9709
Max	1.3169	1.134	1.3169	1.2003	1.134	1.251	1.153
Min	.7865	.8478	.8139	.823	.7716	.7282	.6783
Avg	.9999	.9755	.9767	.9599	.9151	.9502	.9045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 205 / 11 KV PANHERA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3658	.3052	.3658	.3258	.2926	.3734
2	.4108	.3658	.3052	.3658	.3086	.2926	.3881
3	.4294	.4024	.3391	.4024	.2915	.3292	.3734
4	.4854	.439	.373	.439	.3429	.4024	.4066
5	.5228	.4755	.4409	.4755	.3772	.439	.5228
6	.5975	.5853	.5087	.5853	.4458	.4755	.5975
7	.5601	.5487	.5087	.5487	.5144	.5487	.5601
8	.5041	.5121	.4748	.5121	.4801	.4755	.048
9	.4481	.439	.4409	.439	.439	.3658	.4409
10	.3658	.407	.4024	.2915	.3658	.2987	.3391
11	.3292	.373		.2572	.3292	.2987	.2713
12	.2926	.3391	.0183	.2743	.3292	.2987	.2713
13	.2926	.3391	.2926	.2915	.2926	.3174	.3052
14	.2926	.3052	.2926	.3086	.2926	.3174	.3353
15	.2926	.3052	.2926	.2915	.3292	.3361	.373
16	.3292	.3052	.3292	.2743	.3658	.5175	.373
17	.3658	.3052	.3658	.3429	.439	.5601	.373
18	.4024	.3052	.439	.3429	.5121	.5601	
19	.4755	.3391	.5121	.4801		.5601	.5596
20	.5487	.407	.5853	.5316	.5487	.5788	.5087
21	.5121	.4409	.4755	.463	.4755	.5601	.4748
22	.4755	.4748	.439	.4287	.439	.4481	.3768
23	.439	.3391	.4024	.3772	.3658	.3696	.373
24	.4108	.3658	.3391	.3658	.3429	.3292	.3734
Max	.5975	.5853	.5853	.5853	.5487	.5788	.5975
Min	.2926	.3052	.0183	.2572	.2915	.2926	.048
Avg	.4247	.3952	.3862	.3939	.3892	.4155	.3921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 206 / 11 Kv Tapowan Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2195	.1357	.2195	.2058	.1829	.1886
2	.2241	.2195	.1696	.2195	.2058	.1829	.1867
3	.2614	.2195	.2035	.2263	.2058	.1829	.1867
4	.2614	.2561	.2374	.2561	.2401	.2195	.2241
5	.2801	.2926	.2713	.2926	.2401	.2561	.2801
6	.2987	.3292	.3052	.2926	.2572	.2926	.8775
7	.3361	.2926	.2543	.3292	.2058	.2926	.3174
8	.2614	.2561	.2035	.2926	.1715	.2561	.2374
9	.2241	.2195	.1696	.2561	.1543	.2195	.2374
10	.1829	.2035	.2195	.2058	.2195	.1867	.2374
11	.1829	.1696	.1829	.1543	.1829	.1867	.2035
12	.1829	.1696	.1829	.12	.1829	.1867	.2035
13	.1829	.2035	.1829	.1029	.1829	.2241	.2035
14	.1829	.2035	.1829	.12	.1829	.2054	.2035
15	.1829	.2035	.1829	.1372	.1829	.1867	.2035
16	.2195	.1696	.2195	.1543	.2195	.2218	.2035
17	.2195	.1696	.2195	.2401	.2195	.2427	.2035
18	.2561	.1696	.2561	.2401	.2743	.2801	.2374
19	.2926	.1696	.3292	.2743	.3109	.3361	.2713
20	.3292	.2035	.3292	.3258	.3292	.3547	.0309
21	.2926	.2035	.2926	.2572	.2926	.3734	.3391
22	.2926	.2035	.2926	.3086	.2561	.2614	.2374
23	.2561	.1696	.2561	.2572	.2195	.2614	.2035
24	.2241	.2195	.1696	.2195	.2058	.1829	.2241
Max	.3361	.3292	.3292	.3292	.3292	.3734	.8775
Min	.1829	.1696	.1357	.1029	.1543	.1829	.0309
Avg	.2438	.2140	.2270	.2292	.2228	.2407	.2476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 201 / 11 KV NALGANAGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.0343	.6001	.0343	.6516	.0373	.0377
2	.4973	.0343	.583	.0343	.6516	.0373	.0377
3	.5316	.0343	.583	.0343	.6516	.0373	.0343
4	.5658	.0343	.6173	.0343	.7716	.0373	.0343
5	.5658	.0343	.6516	.0343	.823	.0373	.0343
6	.6687	.0343	.7202	.0343	.8916	.0373	.0343
7	.7716		.8402	.0343			
8			.9088	.0343			
9	.8916		1.046	.0343		1.3203	1.4575
10		1.0288		1.1145		1.3032	1.6289
11		1.1145		1.2003		1.286	1.406
12		1.0288		1.1145		1.2003	1.4575
13		.9431		1.0288		1.2003	1.3717
14		.8059		.9431		1.166	1.2003
15		.7716		.9431		1.0288	1.286
16		.8573		.9259		1.1145	1.3032
17		.8916					
19	.0171	.0373	.0343	.0343	.0373	.0343	.0343
20	.0171	.0373	.0343	.0343	.0373	.0343	.0343
21	.0171	.0343	.0343	.6859	.0373	.0343	.3429
22	.0171	.0373	.0343	.6859	.0373	.0343	.3772
23	.0171	.0373	.0343	.6859	.0373	.0343	.3772
24	.4801	.0171	.6001	.0343	.6687	.0373	.0343
Max	.8916	1.1145	1.046	1.2003	.8916	1.3203	1.6289
Min	.0171	.0171	.0343	.0343	.0373	.0343	.0343
Avg	.3980	.3924	.4881	.4427	.4414	.5026	.6262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 202 / 11 KV TARAPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0171	.056	.0343	.0686	.0373	.0171
2	.0514	.0171	.056	.0343	.0686	.0373	.0171
3	.0514	.0171	.056	.0343	.0686	.0373	.0171
4	.0514	.0171	.0739	.0343	.1029	.0373	.0171
5	.0686	.0171	.0739	.0343	.1029	.0373	.0171
6	.1029	.0171	.0914	.0343	.1372	.0373	.0171
7	.1372	.0171	.1578	.0343			
8	.1715	.0171	.2058				
9	.1886		.1907	.1372		.2401	.1886
10		.1715		.1543		.2401	.2401
11		.1372		.2058		.2401	.2229
12		.1372		.1227		.1715	.1886
13		.1543		.1578		.1715	.1715
14		.1029		.1578		.1715	.08
15		.12		.1402		.1715	.1029
16		.1372		.1227		.1715	.1372
17		.1029					
19	.0171	.0373	.0171	.0171	.0373	.0171	.0343
20	.0171	.0373	.0171	.0171	.0373	.0171	.0343
21	.0171	.0373	.0171	.0343	.0373	.0171	.1372
22	.0171	.0373	.0171	.0514	.0373	.0171	.1372
23	.0171	.0373	.0171	.0686	.0373	.0171	.1715
24	.0343	.0171	.056	.3048	.0857	.0373	.0171
Max	.1886	.1715	.2058	.3048	.1372	.2401	.2401
Min	.0171	.0171	.0171	.0171	.0373	.0171	.0171
Avg	.0663	.0638	.0735	.0920	.0684	.0962	.0983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 203 / 11 KV RAJUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.1372	.056	.1715	.0343	.1578	.1886
2	.0171	.1372	.056	.1715	.0343	.1578	.1886
3	.0171	.1715	.056	.1715	.0343	.1402	.1886
4		.2058	.056	.1715	.0343	.1753	.3429
5	.0171	.2401	.056	.2058	.0343	.2058	.3772
6	.0171	.2743	.056	.2058	.0343	.3429	.4458
7		.3086					
8		.2401					
9		.1715			.2572		
10	.3086		.3429		.2915		
11	.4115		.4115		.2743		
12	.463						
13	.3772		.3086		.2743		
14	.3086		.3086		.3601		
15	.2743		.2401		.3429		
16	.2401		.2743		.2915		
17	.2743		.3086				
19	.0171	.056	.0343	.0343	.056	.0343	.0343
20	.0171	.056	.0343	.0343	.056	.0343	.0343
21	.0171	.0373	.0686	.0343	.1753	.1886	
22	.0171	.056	.1029	.0343	.1753	.2401	
23	.0171	.056	.1372	.0343	.1753	.1886	
24	.0171	.1372	.056	.1715	.0343	.1578	.1886
Max	.463	.3086	.4115	.2058	.3601	.3429	.4458
Min	.0171	.0373	.0343	.0343	.0343	.0343	.0343
Avg	.1498	.1523	.1560	.1201	.1563	.1686	.2210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 204 / 11 KV TARAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0373	.0343	.0171	.0373	.0171
2	.0343	.0343	.0373	.0343	.0171	.0373	.0171
3	.0343	.0343	.0373	.0343	.0171	.0373	.0171
4	.0343	.0343	.0187	.0343	.0171	.0373	.0171
5	.0343	.0343	.0187	.0343	.0171	.0187	.0171
6	.0514	.0343	.0187	.0343	.0171	.0187	.0171
7	.0343	.0343	.0187	.0171	.0171	.0187	.0171
8	.0343	.0343	.0373	.0171	.0171	.0373	.0171
9	.0171	.0171	.0187	.0171	.0171	.0187	.0171
10	.0187	.0343	.0343	.0187	.0171	.0171	.0343
11	.0187	.0343	.0171	.0187	.0171	.0171	.0171
12	.0187	.0343	.0171	.0187	.0171	.0171	.0171
13	.0373	.0343	.0171	.0373	.0171	.0171	.0171
14	.0373	.0343	.0171	.0373	.0171	.0171	.0343
15	.0373	.0343	.0171	.0377		.0171	.0171
16	.0373	.0171	.0171	.0187	.0343	.0171	
17	.0373	.0373	.0171	.0187	.0343	.0171	.0514
18	.0171	.0373	.0343	.0171	.0373	.0343	.0343
19	.0171	.0373	.0343	.0343	.056	.0343	.0343
20	.0171	.056	.0343	.0343	.0373	.0343	.0343
21	.0343	.0373	.0343	.0343	.0373	.0343	.0343
22	.0343	.0373	.0343	.0343	.0343	.0343	.0343
23	.0343	.0373	.0343	.0171	.0373	.0189	.0343
24	.0343	.0343	.0373	.0343	.0171	.0373	.0171
Max	.0514	.056	.0373	.0377	.056	.0373	.0514
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0308	.0345	.0267	.0279	.0245	.0261	.0246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 205 / 11 KV NALGANGAPUR GAOTHAN

GAOTHAN FEEDER

FEED Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5144	.6584	.5144	.6173	.6584	.6001
2	.5658	.5144	.6219	.5144	.6001	.6219	.6001
3	.5658	.5487	.5853	.5144	.6602	.5853	.6001
4	.5316	.5487	.5487	.5144	.583	.5853	.5658
5	.5144	.583	.5853	.5144	.583	.6219	.5658
6	.4801	.583	.6219	.5144	.583	.6878	.5487
7	.463	.583	.6878	.2743	.4973	.6401	.5487
8	.5144	.3086	.7164		.4801	.6219	.5487
9	.4973	.5144	.7164		.5487	.6036	.5487
10	.4755	.463	.6173		.4801	.583	.5658
11	.567	.6001	.6173		.5487	.583	.5144
12	.6036	.5316		.7343	.6516	.5144	.5658
13	.6219	.6344	.4801	.7164	.5144	.5487	.5144
14	.5853	.6344	.4115	.6878	.5658	.583	.6001
15	.6219	.6516		.6584		.6173	.5487
16	.6036	.6173	.5144	.6584	.6001	.6516	.6173
17	.6584	.6878	.5487	.6219	.583	.583	.6516
18	.3086	.8059	.5144	.6173	.7164	.6687	.3772
19	.6516	.7164	.5144	.6173	.6878	.7202	.6173
20	.6516	.7164	.5144	.6173	.6878	.7202	.6516
21	.6516	.7343	.5144	.5658	.6584	.6687	.6516
22	.583	.6878	.5144	.6001	.6767	.6516	.6173
23	.5487	.6401	.5144	.6344	.6697	.6344	.583
24	.6344	.5144	.6584	.5144	.6173	.6584	.6344
Max	.6584	.8059	.7164	.7343	.7164	.7202	.6516
Min	.3086	.3086	.4115	.2743	.4801	.5144	.3772
Avg	.5618	.5972	.5762	.5802	.6005	.6255	.5766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 206 / 11 KV RAJUR GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1829	.1715	.1715	.1829	.1543
2	.1715	.1715	.1829	.1715	.1715	.1829	.1543
3	.1543	.1715	.1646	.1715	.1715	.1646	.1543
4	.1715	.1715	.1829	.1715	.2058	.1829	.1715
5	.1886	.1715	.2012	.1715	.2058	.2195	.1715
6	.2229	.1715	.2378	.1715	.2229	.2378	.1886
7	.1886	.1715	.2012	.1886	.1886	.1829	.1715
8	.1886	.1715	.1829	.1715	.1543	.1646	.1715
9	.1372	.1543	.2012	.1715	.1543	.1463	.1372
10	.1463	.1543	.1372	.1829	.12	.1372	.12
11	.1463	.1886	.1886	.1829	.2058	.1372	.1372
12	.1829	.1543	.1543	.2012	.1715	.1715	.1372
13	.1829	.2229	.1715	.1829	.2229	.1715	.1715
14	.1829	.1715	.1715	.1829	.1715	.1715	.1543
15	.2195	.1715	.1543	.2195	.2058	.1715	.1715
16	.2378	.2058	.1543	.2195	.1715	.1715	.1715
17	.2195	.2378	.1543	.2012	.2058	.2229	.1886
18	.2229		.1886	.1715	.2561	.1886	.1543
19	.2058	.2378	.2058	.2915	.2378	.2401	.2743
20	.1715	.2743	.583	.2743	.2561	.2401	.2743
21	.1715	.2561	.1886	.2401	.2378	.1886	.2743
22	.1715	.2378	.1715	.2058	.2195	.1886	.2401
23	.1715	.2195	.1715	.1886	.2012	.1886	.2058
24	.1886	.1715	.2012	.1715	.1715	.2012	.1715
Max	.2378	.2743	.583	.2915	.2561	.2401	.2743
Min	.1372	.1543	.1372	.1715	.12	.1372	.12
Avg	.1840	.1926	.1972	.1949	.1959	.1856	.1800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 208 / 11 KV MOTALA TOWN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.0288	.9465	.9259	.8916	.9465	.8916
2	.9259	1.0288	.9465	.8916	.8916	.9465	.8916
3	.9431	.9259	.9114	.8573	.8916	.9114	.8573
4	.9088	.9259	.8764	.8573	.8573	.8764	.823
5	.8573	.8573	.8505	.823	.7888	.8238	.7888
6	.8059	.7888	.815	.7545	.7716	.788	.7888
7	.7545	.7888	.788	.7202	.6859	.8328	.703
8	.7202	.7545	.7164	.7202	.6173	.7164	.703
9		.7716	.7522	.7202	.6859	.7164	
10		.8573	.7888	.788	.6859	.6859	.7545
11	1.1096	.8573	.8916	.8505	.8402	.7202	.7373
12	1.046	.8573	.9259	.9114	.9259	.7545	.703
13	1.046	.9431	.9774	.9465	.9088	.7545	.9088
14	1.0288	.9774	1.0288	.9465	1.046	.7888	.9945
15	1.0288	1.0117	1.0288	.964	1.0288	.7888	.9945
16	1.0288	.9774	.9945	.9114	.8745	.7888	.9602
17	1.0288	.964	.9774	1.0402	.7888	.7888	.9088
18	1.0117	.8764	.9602	1.0117	.7522	.7888	.8573
19	.9945	.9465	.9945	.9431	.6878	.9259	.9259
20	1.0288	1.1145	1.0288	.9602	.6878	.9259	.9945
21	1.0974	1.0802	1.0288	.9774	.6584	.9431	.9945
22	1.0974	1.046	.9945	.9774	1.0288	.9945	1.0288
23	1.0631	.9882	.9602	.9774	1.0056	.9602	1.0288
24	.9945	1.0288	.9816	.9259	.9088	.9816	.9602
Max	1.1096	1.1145	1.0288	1.0402	1.046	.9945	1.0288
Min	.7202	.7545	.7164	.7202	.6173	.6859	.703
Avg	.9748	.9332	.9235	.8917	.8296	.8395	.8782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 201 / 11 KV MAKODI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.1372	.0343	.0343
2	.0343	.12	.0343	.0343
3	.0343	.1715	.0343	.0343
4	.0343	.2401	.0343	.0343
5	.0343	.2572	.0343	.0343
6	.0343	.3086	.0343	.0343
7		.3429		
8		.4115		
9	.2572		.3429	.6687
10	.4287		.6001	.6687
11	.3429		.5144	.583
12	.3086		.4801	.5144
13	.3601		.463	.3258
14	.4115		.5144	.3086
15	.3772		.5144	.3601
16	.3429		.4801	.3429
19	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343
21	.12	.0343	.0343	.1372
22	.1372	.0343	.0343	.2401
23	.1715	.0343	.0343	.2572
24	.3048	.1543	.0343	.0343
Max	.4287	.4115	.6001	.6687
Min	.0343	.0343	.0343	.0343
Avg	.1919	.1653	.2161	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 202 / 11 KV P. DEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 203 / 11 KV S.BAZAR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.0343	.8573	1.046
2	.7716	.0343	1.0288	1.2346
3	.8573	.0343	1.2003	1.2346
4	1.0288	.0343	1.3717	1.286
5	1.1145	.0343	1.406	1.3375
6	1.2003	.0343	1.4575	1.6461
9		.6516		
10		.8916		
11		1.1145		
12		1.286		
13		1.5432		
14		1.2003		
15		1.0288		
16		.8573		
18			.1372	
19	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343
21	.0343	.5144	.7716	.0343
22	.0343	.6001	.823	.0343
23	.0343	.6859	.8573	.0343
24	.6001	.0343	.7716	.8573
Max	1.2003	1.5432	1.4575	1.6461
Min	.0343	.0343	.0343	.0343
Avg	.5358	.5341	.8270	.7345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 204 / 11 KV Nipana Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 205 / 11 kv Nipana GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1543	.1543	.1543
2	.2401	.1715	.1715	.1543
3	.2229	.1543	.1543	.1715
4	.2572	.1715	.1715	.1715
5	.2229	.2229	.2229	.1715
6	.2058	.2058	.2058	.1886
7	.1886	.1543	.1715	.1715
8	.1715	.1372	.1543	.1543
9	.1543	.12	.1372	.1372
10	.1372	.1029	.12	.1372
11	.1715	.12	.12	.1543
12	.1372	.1372	.12	.1543
13	.1543	.1715	.1372	.1886
14	.1715	.1715	.1372	.1715
15	.1886	.1886	.1543	.1886
16	.1715	.1886	.1715	.2058
17	.2401	.1886	.1715	.1715
18	.2058	.2058	.1886	.2058
19	.2229	.2058	.2058	.2401
20	.2572	.2229	.2058	.2572
21	.2915	.2229	.1886	.2229
22	.2401	.2058	.1886	.2058
23	.2058	.2058	.1715	.1886
24	.3429	.1715	.1715	.1715
Max	.3429	.2229	.2229	.2572
Min	.1372	.1029	.12	.1372
Avg	.2086	.1751	.1665	.1808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 206 / 11 kv P.Devi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2572	.2572
2	.2915	.2401	.2743	.2572
3	.3429	.2572	.2915	.2572
4	.3086	.2915	.2743	.2743
5	.2743	.3258	.2572	.2743
6	.2915	.3601	.2572	.2915
7	.2572	.3258	.2915	.2743
8	.2401	.2915		.2572
9	.2229	.2229		.2058
10	.2058	.2058		.2401
11	.2229	.2401	.2572	.2229
12	.2401	.2743	.2401	.2401
13	.2229	.2229	.2401	.2229
14	.2058	.2401	.2229	.2401
15	.2572	.2572	.2229	.2572
16	.2743	.2915	.2229	.2401
17	.3086	.2572	.2229	.2915
18	.3601	.2401	.2401	.3429
19	.3429	.2743	.2572	.3772
20	.4115	.2915	.2743	.3601
21	.3429	.3086	.3086	.2915
22	.2915	.2743	.3086	.3086
23	.2743	.2572	.2743	.2572
24	.3429	.2572	.2401	.2572
Max	.4115	.3601	.3086	.3772
Min	.2058	.2058	.2229	.2058
Avg	.2836	.2701	.2588	.2708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 207 / 11 kv S.Bazar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2743	.2229
2	.2401	.2572	.2572	.2229
3	.2743	.2915	.2915	.2229
4	.2572	.3086	.3086	.2572
5	.2229	.3429	.3429	
6	.2572	.3601	.3601	.2401
7	.2401	.3258	.4973	.2058
8	.2401	.2915	.3086	.1886
9	.2058	.2058	.2743	.1886
10	.2058	.1715	.2401	.1715
11	.1715	.2229	.2401	.2058
12	.2229	.2401	.2401	.2401
13	.2058	.2572	.2401	.2572
14	.2401	.2058	.2229	.2743
15	.2743	.2401	.2229	.2572
16	.2572	.1715	.2401	.2058
17	.2915	.1886	.2401	.1886
18	.3258	.2058	.2572	.0171
19	.3429	.2229	.2572	.3258
20	.3772	.2401	.2915	.3429
21	.3429	.3086	.2743	.2915
22	.3258	.2915	.2743	.3086
23	.2915	.2743	.2572	.2915
24	.3429	.2572	.2572	.2401
Max	.3772	.3601	.4973	.3429
Min	.1715	.1715	.2229	.0171
Avg	.2665	.2565	.2779	.2333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 208 / 11 kv makodi gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1372	.1543
2	.1543	.1715	.1715	.1543
3	.1715	.2058	.1543	.1543
4	.1886	.1715	.1715	.1715
5	.1715	.2229	.1886	.1372
6	.1715	.2058	.2058	.12
7	.1543	.1715	.1372	.12
8	.1372	.1372	.1029	.12
9	.12	.1029	.1029	
10	.1029	.12	.0686	
11	.12	.1715	.0686	
12	.1029	.1886	.0857	
13	.1372	.2058	.1029	
14	.1543	.1715	.1029	
15	.1715	.1715	.12	.1372
16	.1543	.1543	.1543	.1543
17	.1372	.1715	.1543	.1543
18	.1543	.1715	.1543	.1715
19	.1715	.1886	.1715	.1886
20	.2058	.2058	.1886	.1715
21	.2229	.2058	.1886	.1886
22	.2058	.1715	.1715	.1543
23	.1715	.1715	.1715	.1372
24	.3429	.1543	.1715	.1543
Max	.3429	.2229	.2058	.1886
Min	.1029	.1029	.0686	.12
Avg	.1658	.1729	.1436	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 201 / 11 KV Pophli AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7373		.7449			1.1065
2		.6859		.7865			1.1065
3		.6859		.8745			1.1191
4		.7202		.8421			1.1191
5		.7716		.8002			1.278
6		.8573		.8482			1.3603
7		.9602					
8		1.0631					
9		1.1145			1.3927	1.5089	
10	.8551		1.0395		1.5729	1.4403	
11	1.094		1.0395		1.5061	1.4737	
12			1.073		1.5074	1.5061	
13			1.0059		1.4582	1.4575	
14	.8951		1.004		1.4091	1.3117	
15	.9054		1.0059		1.4255	1.3603	
16	.9116		.9724		1.3763	1.3599	
17	.9259		.9393				
21			.6802			1.1065	
22			.6802			1.1401	
23			.7377			1.1233	
24		.7373		.7125			1.1065
Max	1.094	1.1145	1.073	.8745	1.5729	1.5089	1.3603
Min	.8551	.6859	.6802	.7125	1.3763	1.1065	1.1065
Avg	.9312	.8333	.9252	.8013	1.4560	1.3444	1.1709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 202 / wadi ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.0366	
6	.037		.0343	.0549	
7	.037				
8	.0549				
9	.0732				.0924
10		.0366			.1075
11		.0366			.1254
12		.0537			.1075
13		.0362			.1075
14		.0362			.0716
15		.0362			.0716
16		.0362			.0537
21		.0343	.0362		.0187
22		.0343	.0362		
23			.0185		
Max	.0732	.0537	.0362	.0549	.1254
Min	.037	.0343	.0185	.0366	.0187
Avg	.0505	.0378	.0313	.0458	.0840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 203 / 11 kv Pophli Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.4163	.4294	.4115	.3647	.4163	.4066
2	.4163	.4163	.415	.3856	.3647	.4163	.4066
3	.4344	.4163	.415	.3429	.3812	.3982	.3921
4	.4525	.4344	.3961	.4252	.3812	.4344	.3921
5	.4887	.4525	.439	.4458	.3978	.4525	.462
6	.5068	.4706	.4805	.4607	.431	.4887	.5121
7	.4163	.4887	.4435	.4298	.3481	.4163	.462
8	.4163	.4525	.4251	.3856	.3521	.3439	.3395
9	.3982	.4163	.3511	.3086	.2984	.2926	.3326
10	.3696	.3086	.3506	.3439	.3475	.285	.3258
11	.3511	.3658	.3467	.3439	.3658	.2652	
12		.394	.3467		.3696	.3018	
13		.394	.3814	.3801	.3881	.2984	.1097
14	.4251	.362	.3772	.3982	.4066	.3149	.1097
15	.462	.3898	.394	.4163	.439	.3481	.128
16	.4805	.3898	.3637	.4525	.462	.3841	.128
17	.4525	.2957	.4298	.3978	.4525	.4191	.4706
18	.4525	.4715	.4656	.431	.4525	.4338	.5249
19	.4887	.5847	.4801	.4641	.4525	.4715	.6154
20	.5611	.7023	.6379	.5668	.5973	.5914	.6516
21	.5068	.5788	.543	.4858	.5068	.4854	.5249
22	.4887	.5041	.5121	.426	.4525	.3921	.4525
23	.4344	.4715	.3944	.3978	.4344	.4108	.4344
24	.4163	.4163	.4294	.3856	.3647	.4344	.4108
Max	.5611	.7023	.6379	.5668	.5973	.5914	.6516
Min	.3511	.2957	.3467	.3086	.2984	.2652	.1097
Avg	.4471	.4414	.4270	.4124	.4088	.3956	.3905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 204 / 11 Kv Ghoogali Ag Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0686		
2					.0514		
3					.0514		
4					.0514		
5	.0554		.0914		.0686	.0185	
6	.0739		.1086		.1029	.0549	
7	.0732		.1478				
8	.0914		.1294				
9	.1448		.1294	.144			
10				.1433			.0716
11				.1075			.0895
12				.0895			.0895
13				.0537			.0716
14				.0543			.0537
15				.0543			.0537
16				.0362			.0358
17		.1463					
21				.12			.037
22				.0686	.0543		.037
23				.0686	.037		.037
24					.0686		
Max	.1448	.1463	.1478	.144	.1029	.0549	.0895
Min	.0554	.1463	.0914	.0362	.037	.0185	.0358
Avg	.0877	.1463	.1213	.0855	.0616	.0367	.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 201 / 11 kv Kothali Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.7545	.0762	.5792		.362	.426
2	.1086	.7545	.0762	.5792		.362	.4096
3	.1086	.7716	.0762	.5792		.362	.4096
4	.1086	.7716	.0953	.724		.3982	.4096
5	.1086	.7888		.8145		.4706	.4915
6	.1086	.8059	.0953	1.1765		.5068	1.0364
7		.9259					
8		1.0802					
9		1.1317			.6859		
10	1.2174		.9955		1.2127		
11	1.3717		1.267		1.2308		
12	1.4403		1.4299		1.1222		
13	1.3413		1.1765		1.0679		
14	1.2163		.905		.9412		
15	.9831		.905		.905		
16	.8453		.9412		.8326		
17	1.0288		.9955				
19	.0686	.0762	.1086	.0514	.1086	.1143	.0857
20	.0686	.0762	.1086	.0686	.1086	.0953	.0857
21	.0686	.0762	.5792	.0514	.3258	.4424	.0857
22	.0686	.0762	.5792	.0686	.3439	.4424	.0686
23	.0686	.0762	.5792	.0686	.3439	.4424	.0857
24	.1086	.7545	.0762	.5249	.0686	.3439	.4424
Max	1.4403	1.1317	1.4299	1.1765	1.2308	.5068	1.0364
Min	.0686	.0762	.0762	.0514	.0686	.0953	.0686
Avg	.5274	.5947	.5824	.4405	.6641	.3619	.3364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 202 / 11 kv Kothali GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5658	.5525	.5792		.5973	.5716
2	.5792	.5487	.5525	.5792	.2915	.5973	.5716
3	.5792	.5658	.5525	.5792	.2915	.5973	.5716
4	.5792	.5487	.5525	.5792	.2743	.5973	.5716
5	.5792	.583	.5716	.5792	.3086	.5973	.5906
6	.6516	.5144		.6335	.3429	.6335	.5716
7	.6154	.3429	.4954	.4706	.3429	.4706	.5335
8	.5068	.4801	.4706	.4706	.4458	.4525	
9	.4887	.4115	.4706	.4344	.4115	.4763	.3944
10	.4287	.439	.4706	.4287	.4525	.4382	.3772
11	.4458	.439	.4706	.4458	.4706	.4191	.3601
12	.463	.439	.4706	.4458	.4706	.4382	.3601
13	.4706	.4572	.4706	.4287	.4706	.4572	.3772
14	.4908	.4572	.4706	.4458	.4706	.4382	.4115
15	.4908	.4572	.4706	.4458	.5068	.4572	.4287
16	.5028	.4954	.4887	.4801	.5973	.5144	.4458
17	.5144	.5716	.5068	.5487	.6335	.6097	.4458
18	.5658	.5906	.6335	.6001		.6097	.5658
19	.583	.6287	.6878	.6516	.4163	.6668	.6516
20	.6173	.6859	.724	.703	.6516	.724	.6516
21	.6173	.6859	.7059	.6859	.6335	.6859	.6344
22	.6516	.6478	.6878	.6516	.6335	.6478	.6173
23	.583	.6097	.6335	.583	.5973	.6097	.5487
24	.5792	.5658	.5716	.5792	.5487	.5973	.5906
Max	.6516	.6859	.724	.703	.6516	.724	.6516
Min	.4287	.3429	.4706	.4287	.2743	.4191	.3601
Avg	.5484	.5305	.5514	.5429	.4665	.5555	.5149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 203 / 11 kv ramgaon ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0514	.0655				.0572
2	.181	.0514	.0819		.12		.0572
3	.181	.0514	.0819		.12		.0572
4	.181	.0514	.0819		.12		.0572
5	.181	.0514	.0819		.1715		.0572
6		.0514			.2915		.0572
7	.4344		.3506		.2915		
8	.3982		.362				
9	.3801		.2715	.3258		.3239	.3772
10		.4481		.5144		.2591	.4801
11		.5182		.5487		.4801	.4458
12		.2187		.5487		.4161	.3772
13		.3361		.4287		.3521	.3429
14		.25		.4458		.208	.3429
15		.2241		.3601		.2561	.2743
16		.2622		.3429		.3201	.3429
17		.3113					
19	.0514	.0381	.0543	.0514	.0543	.0572	.0686
20	.0514	.0381	.0543	.0514	.0543	.0572	.0857
21	.0514	.0381	.0543	.12	.0543	.0572	.12
22	.0514	.0381		.1372	.0543	.0572	.12
23	.0514	.0381		.12		.0572	.1372
24	.0724	.0514	.0492		.12		.0572
Max	.4344	.5182	.362	.5487	.2915	.4801	.4801
Min	.0514	.0381	.0492	.0514	.0543	.0572	.0572
Avg	.1670	.1560	.1324	.3073	.1320	.2232	.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 204 / 11 Kv Shirva AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0686	.0572	.0543		.0724
2	.0543	.0686	.0572	.0543	.0514	.0724
3	.0543	.0686	.0572	.0543	.0514	.0724
4	.0543	.0686	.0381	.0724	.0514	.0724
5	.0543	.1029	.0381	.0905	.0514	.1267
6	.0543	.12		.1267		.1448
7		.1372				
8		.1715				
9		.1715			.1543	
10	.1715		.1448		.1629	
11	.1372		.1448		.1629	
12	.1372		.181		.168	
13	.1296		.1448		.1448	
14	.1147		.0724		.1448	
15	.0972		.0724		.1448	
16	.0972		.0905		.1448	
17	.1372		.1267			
19	.0514	.0762	.0543	.0514	.0543	.0572
20	.0514	.0762	.0543	.0514	.0543	
21	.0514	.0762	.0543	.0514	.0543	
22	.0514	.0762	.0543	.0514	.0543	
23	.0514	.0762	.0543	.0514	.0543	
24	.0566	.0686	.0762	.0362	.0514	.0543
Max	.1715	.1715	.181	.1267	.168	.1448
Min	.0514	.0686	.0381	.0362	.0514	.0543
Avg	.0831	.0951	.0828	.0621	.0975	.0841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 205 / 11 KV Shirwa GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	30-MAY-18
HR	Load (MW)
10	.0381
Max	.0381
Min	.0381
Avg	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 201 / 11 KV Harankhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.0343	.1753	.0305	.1829	.0362	.0362
2	.1238	.0362	.1753	.0305	.2134	.0344	.0362
3	.181	.0362	.1928	.0305	.1981	.0344	.0362
4	.1715	.0362	.2058	.0305	.2286	.0362	.0362
5	.2172	.0362	.2058	.0305	.2134	.0344	.0362
6	.2534	.0362	.2572	.0305	.2743	.0373	.0362
7	.2896		.2915				
8	.3258		.3155				
9	.3258		.3048	.2286		.362	.3258
10				.3353		.4706	.3258
11				.3201		.4344	.3258
12				.3353		.4344	.362
13				.3048		.3982	.3258
14		.2915		.3201		.3982	.3258
15		.2743		.2743		.3865	.3258
16		.2572		.2743		.3865	.362
17		.3601					
20	.0343	.0351	.0305	.0305	.0362	.0362	.0351
21	.0362	.0351	.0305	.1524	.0362	.0362	.2229
22	.0362	.0351	.0305	.1524	.0363	.0344	.2401
23	.0362	.0351	.0305	.1829	.0362	.0362	.2058
24	.181	.0343	.1578	.0305	.1829	.0362	.0362
Max	.3258	.3601	.3155	.3353	.2743	.4706	.362
Min	.0343	.0343	.0305	.0305	.0362	.0344	.0351
Avg	.1709	.1049	.1717	.1644	.1490	.1928	.1914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 202 / 11 KV Wadji GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1349	.2172	.2103	.1981	.1829	.2172	.2172
2	.2172	.2172	.2279	.2134	.1677		.2172
3	.2172	.2172	.2229	.2134	.1981	.2172	.2172
4	.2172	.2172	.2401	.2286	.2286	.2172	.2172
5	.2534	.2534	.2401	.2286	.2591	.2172	.2172
6	.2896	.2715	.2743	.2439	.2134	.2896	.2715
7	.2401	.2715	.2915	.2286	.2439	.2534	.2715
8	.2534		.298	.2591	.2134	.2534	.2534
9	.2534		.2134	.1829	.2172	.1486	.2401
10	.2172		.1981	.1677	.2172	.181	.181
11	.2172		.1829	.1524	.2172	.1715	.181
12	.2172		.1829	.1829	.2058	.1867	.2172
13	.2172		.1981	.1677	.2172	.2172	.2172
14	.2172	.2572	.1829	.1829	.2058	.2263	.2172
15	.2172	.2915	.2134	.2134	.2534	.2241	.2058
16	.2172	.2743	.1981	.1981	.2715	.2353	.2534
17	.2172	.2572	.2286	.2134		.2534	.2534
18	.2715	.3155	.2591	.2439	.362	.2715	.298
19	.2715	.3155	.2591	.2591	.3258	.2715	.3155
20	.3258	.3155	.2286	.2286	.2715	.2534	.3155
21	.2534	.2629	.2286	.2286	.2534	.2534	.2743
22	.2534	.2279	.1981	.1981	.2241	.2534	.2401
23	.2534	.2454	.1829	.1829	.2172	.2172	.2229
24	.2172	.2172	.2279	.1981	.1677	.2172	.2172
Max	.3258	.3155	.298	.2591	.362	.2896	.3155
Min	.1349	.2172	.1829	.1524	.1677	.1486	.181
Avg	.2358	.2581	.2245	.2089	.2319	.2281	.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 203 / 11 KV Malegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.362	.0351	.381	.0305	.724	.5792
2	.0362	.362	.0351	.3963	.0305	.724	.5792
3	.0362	.362	.0351	.4268	.0305	.7164	.5792
4	.0362	.362	.0343	.442	.0305	.6859	.5792
5	.0362	.4706	.0343	.4268	.0305	.724	.724
6	.0362	.5068	.0343	.4572	.0305	.7888	.905
7		.5792					
8	.0362						
9					.7602		
10	.5068		.1829		.7554		
11	.543		.7316		.7964		
12	.4344		.7621		.8326		
13			.5944		.8145		
14			.5335		.7602		
15			.442		.7602		
16			.4572		.7602		
17			.4877				
20	.0362	.0351	.0305	.0305	.0362	.0362	.0351
21	.0362	.0351	.3185	.0305	.5068	.6154	.0343
22	.0362	.0351	.3048	.0305	.543	.6154	.0343
23	.0373	.0351	.2896	.0305	.724	.6154	.0343
24	.0362	.3258	.0351	.3048	.0305	.724	.5792
Max	.543	.5792	.7621	.4572	.8326	.7888	.905
Min	.0362	.0351	.0305	.0305	.0305	.0362	.0343
Avg	.1280	.2892	.2831	.2688	.4349	.6336	.4239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
Sta

Feeder No / Name : 201 / 11 KV Takali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0343		.1715	.0671
2		.0686		.0343		.1715	.0671
3		.0686		.0343		.1715	.0671
4		.1029		.0343		.2058	.0671
5		.1029		.0686		.2058	.1341
6		.1372		.1715		.2401	.2683
7		.1715		.2058			
8		.1715					
9		.1372			.1677		
10	.3429		.1715		.2347		
11	.2683		.2058		.3353		
12	.2683		.2058		.2683		
13	.2347		.1372		.2683		
14	.1341		.1372		.2012		
15	.1341		.1372		.2012		
16	.1006		.1372		.1341		
17	.2012		.1715				
21			.0343		.0686	.0671	
22			.0343		.0686	.0671	
23			.0343		.0686	.0671	
24		.0686		.0343		.1715	.0671
Max	.3429	.1715	.2058	.2058	.3353	.2401	.2683
Min	.1006	.0686	.0343	.0343	.0686	.0671	.0671
Avg	.2105	.1143	.1278	.0772	.1833	.1539	.1054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
Sta

Feeder No / Name : 202 / 11 KV Rohinkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		.0671		.0686		
2	.0686		.0671		.1029		
3	.0686		.0671		.1715		
4	.0686		.0671		.1715		
5	.1029		.0671		.2058		
6	.1372		.1006		.2058		
7	.2058		.1341				
8	.2058		.2012				
9	.1715		.2012	.2401		.3772	.3018
10		.1715		.3086		.3086	
11		.3086		.3086		.3772	.3086
12		.3086		.3429		.3772	.3086
13		.2743		.2058		.3429	.2743
14		.2743		.2058		.2743	.2743
15		.2401		.1715		.2743	.2743
16		.2401		.1715		.2058	.2743
17		.2058					
21				.0686			.1372
22				.0686			.1372
23				.0686			.1029
24	.0686		.0671		.0686		
Max	.2058	.3086	.2012	.3429	.2058	.3772	.3086
Min	.0686	.1715	.0671	.0686	.0686	.2058	.1029
Avg	.1166	.2529	.1040	.1964	.1421	.3172	.2394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 203 / 11 KV Rohinkhed Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.4481	.3772	.3086	.3429	.4108
2	.3772	.3086	.4481	.3772	.3086	.3429	.4108
3	.3772	.3086	.4481	.3772	.3429	.3429	.4108
4	.4115	.3429	.4481	.4115	.3429	.3772	.4108
5	.4801	.3429	.4481	.4458	.3772	.3772	.4481
6	.5144	.3429	.5228	.5144	.4115	.4115	.5601
7	.4458	.3772	.4854	.4458	.3429	.4115	.4854
8	.3772	.4115	.4854	.3772	.2743	.3772	.4481
9	.3772	.3772	.4108	.3429	.3361	.3429	.3734
10	.3429	.3086	.3429	.3429	.3734	.3086	.3429
11	.3734	.3429	.3429	.3429	.3734	.3086	.3429
12	.3734	.3429	.3086	.3429	.3361	.3086	.3429
13	.3734	.3429	.3429	.3429	.3361	.3086	.3429
14	.3734	.3429	.3429	.3429	.3361	.3086	.3772
15	.3734	.3429	.3429	.3772	.3734	.3086	.3772
16	.4108	.3429	.3429	.3772	.4108	.3772	.3772
17	.3734	.3772	.3429	.4287	.4854	.4115	.4115
18	.3429	.4458	.4458	.4115	.4801	.4458	.4458
19	.3429	.5975	.4801	.4115	.4801	.4854	.5144
20	.3429	.5601	.4801	.4115	.4458	.4854	.5487
21	.3429	.4854	.4458	.3772	.4115	.4481	.4801
22	.3429	.4481	.4115	.3086	.3772	.4481	.4458
23	.3086	.4481	.4115	.3086	.3772	.4108	.4458
24	.3772	.3086	.4481	.3772	.3086	.3429	.4108
Max	.5144	.5975	.5228	.5144	.4854	.4854	.5601
Min	.3086	.3086	.3086	.3086	.2743	.3086	.3429
Avg	.3805	.3816	.4157	.3822	.3729	.3764	.4235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 204 / 11 KV Takali Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3429	.4481	.4458	.3429	.3772	.4854
2	.4458	.3429	.4481	.4458	.3429	.3772	.4854
3	.4458	.3772	.4481	.4458	.3772	.4115	.4854
4	.4801	.4115		.4458	.4115	.4115	.4854
5	.5144	.4115		.4801	.4458	.4115	.5228
6	.5487	.4115	.5228	.5487	.4801	.4458	.5975
7	.4458	.4115	.5228	.5144	.4458	.4458	.5601
8	.4801	.4115	.4481	.4801	.4458	.4115	.5228
9	.3429	.3772	.3734	.4115	.4481	.3772	.4108
10	.3772	.3772	.3086	.3772	.4108	.2401	.3086
11	.4108	.3086	.3429	.3772	.4108	.2401	.3086
12	.4108	.3429	.3429	.3772	.4108	.2743	.3086
13	.4108	.3429	.3429	.3772	.4108	.2743	.3429
14	.4108	.3429	.3429	.4115	.4108	.3086	.3772
15	.4108	.3772	.3772	.4458	.4481	.3086	.4115
16	.4481	.3772	.3772	.4458	.4481	.3772	.4458
17	.4854	.3772	.3772	.4458	.5228	.4115	.4801
18	.4458	.4801	.5144	.4801	.5487	.5144	.4801
19	.4801	.6722	.5487	.5144		.5975	.5487
20	.5144	.6348	.6173	.5487	.5487	.5975	.5487
21	.5144	.5601	.5487	.5487	.5144	.5601	.5144
22	.4801	.5228	.5144	.5144	.4801	.5228	.4801
23	.3429	.4481	.4458	.4115	.4458	.4854	.4458
24	.4458	.3429	.4481	.4458	.3429	.3772	.4854
Max	.5487	.6722	.6173	.5487	.5487	.5975	.5975
Min	.3429	.3086	.3086	.3772	.3429	.2401	.3086
Avg	.4474	.4169	.4391	.4558	.4389	.4066	.4601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 201 / 11 kv Wadner Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1082	.1158	.0747	.0747	.0747	.176
2	.1143	.1082	.1158	.0747	.0747	.0747	.176
3	.1143	.1067	.1158	.0747	.0747	.0732	.176
4	.1143	.1067	.1158	.0747	.0747	.0747	.2054
5	.1429	.1113	.1448	.0747	.0747	.0747	.2347
6	.1829	.1353	.1829	.0747	.0747	.0747	.2641
7	.1829	.1692	.2134				
8	.2134	.2027	.2134				
9	.1738	.1715	.1829	.1486	.1219	.2378	
10				.2347	.3567	.2972	
11					.3269	.3311	
12				.2378	.2972	.282	
13				.208	.2439	.2606	
14					.2134	.2286	
15				.1783	.2439	.2	
16	.0747	.0747	.0754	.1189	.2439		
17	.0716	.0747	.0747				
18	.0693	.0747	.0747				
19	.0747	.0747	.0747	.0747	.0739	.0747	.0709
20	.0747	.0747	.0747	.0747	.0739	.0747	.0716
21	.0754	.0747	.0747	.0663	.0686	.1448	.2347
22	.0754	.0747	.0747	.0747	.0701	.1486	.2408
23	.0747	.0747		.0747	.0724	.1486	.2107
24	.1097	.1082	.1158	.0747	.0724	.0747	.1467
Max	.2134	.2027	.2134	.2378	.3567	.3311	.2641
Min	.0693	.0747	.0747	.0663	.0686	.0732	.0709
Avg	.1141	.1070	.12	.1119	.1464	.1553	.1840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 202 / 11 kv Chandur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0587	.0293	.5281	.6401	.5487	.0293
2	.029	.0587	.0293	.5281	.6401	.5487	.0293
3	.029	.0587	.0293	.5281	.6401	.5487	.0293
4	.029	.0587	.0293	.5868	.6401	.5487	
5	.029	.0587	.0293	.6161	.6706	.5487	
6				.6455	.7621	.7011	
9							.823
10	.6802	.6371					.8535
11	.6802	.6661	.7335				.7621
12	.6802	.6371	.6455				.823
13	.6802	.6081	.6161				
14	.6802	.5792	.6161				.8535
15	.6478	.5792	.6161				
16	.6154	.6081	.5868				
17	.6161	.6081	.6748				
18		.029					
19				.0602	.061	.0293	.0305
20	.0587	.029	.0293	.0602	.061	.0293	.0305
21	.0587	.029	.0293	.5719	.5792	.0293	.0305
22	.0587	.029	.0293	.6706	.6097	.0293	.0305
23	.0587	.029	.0293		.6097	.0293	.0305
24	.029	.0587	.0293	.6401	.6401	.5487	.0293
Max	.6802	.6661	.7335	.6706	.7621	.7011	.8535
Min	.029	.029	.0293	.0602	.061	.0293	.0293
Avg	.3165	.2853	.2813	.4942	.5462	.3450	.3132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 203 / 11 kv Chandur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8131	.8048	.8048	.7762	.7392	.7316
2	.8413	.7762	.8048	.8048	.7762	.7392	.7316
3	.8413	.7762	.8048	.8048	.7762	.7392	.7316
4	.8413	.7762	.8048	.8596	.7762	.7392	.7316
5	.8048	.7762	.7682	.7682	.7762	.7392	.7316
6	.7316	.7392	.7316	.7682	.7392	.7762	.7316
7	.6584	.7023	.695	.695	.6584	.6584	.695
8	.695	.5544	.695	.7762	.6584	.6653	.6584
9	.695	.5487	.7316	.7316	.695	.6154	.6878
10	.695	.6219		.7682	.695	.6516	.6516
11	.7316	.695	.7602		.7316	.6516	.5792
12	.7682	.8048	.8501	.8779	.7682	.6878	.724
13	.8048	.8413	.7762	.9145	.8048	.724	
14	.8048	.8779	.7682	.8413	.8413	.7316	.7602
15	.8413	.8413	.8048	.8048	.8413	.8048	.724
16	.8413	.8413	.7682	.8048	.8413		.8326
17	.7964	.8413	.7682	.7602	.7964	.7682	.8413
18	.7796	.8779	.8413	.7964	.7602	.7682	.788
19	.905	.8779	.9145	.905	.9145	.7682	.8688
20	.9979	1.0242	.9511	1.0719	1.0719	.8048	1.0719
21	.961	.9877	.9511	1.0349	.924	.8779	.9979
22	.924	.9511	.9511	.961	.8871	.8779	.924
23	.8501	.8413	.8779		.8131	.8048	.8501
24	.8413	.8131	.8413	.8413	.8131	.7762	.7682
Max	.9979	1.0242	.9511	1.0719	1.0719	.8779	1.0719
Min	.6584	.5487	.695	.695	.6584	.6154	.5792
Avg	.8122	.8000	.8115	.8362	.7973	.7439	.7745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 204 / 11 kv Wadner Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8871	.9145	.9145	.924	.8501	.8413
2	.8779	.8871	.9145	.9145	.924	.8501	.8413
3	.8779	.8871	.9145	.9145	.924	.8501	.8413
4	.8779	.8871	.9145	.8779	.924	.8501	.8048
5	.8413	.8871	.8779	.8048	.924	.8501	.7316
6	.7682	.7392	.8048	.7682	.7762	.7023	.695
7	.695	.7023	.695	.695	.6584	.6219	.6584
8	.6584		.695	.7392	.6584	.6653	.6584
9	.7316		.7762	.7682	.695	.6516	.724
10	.8413			.8779	.7316	.6878	.7602
11			.924		.7316	.724	.7602
12			.8871	.8779	.7316	.5853	.7316
13	.9877	.9877	.9145	.8779	.7682	.6516	
14	.9877	1.0608	.8501	.8779	.8413	.7023	.7964
15	.9511	1.0608	.8131	.9145	.8413	.8326	.905
16	.9511	1.0242	.9511	.9877	.8413		.905
17	.8688	.9877	.9511	.8688	.7964	.8413	.8779
18	.815	.9511	.8413	.7964	.7682	.8048	.8238
19	.924	.9511	.8779	.9412	.8326	.8048	.905
20	1.0349	1.0974	.9877	1.0719	1.0349	.9145	1.0349
21	1.0242	1.0974	1.0242	1.1088	1.0349	.9511	1.0719
22	.9979	1.0974	1.0608	1.0719	.9979	.9511	1.0349
23	.961	.9877	.9511		.924	.9145	.961
24	.9145	.924	.9511	1.7909	.961	.8501	.8413
Max	1.0349	1.0974	1.0608	1.7909	1.0349	.9511	1.0719
Min	.6584	.7023	.695	.695	.6584	.5853	.6584
Avg	.8848	.9529	.8910	.9300	.8435	.7873	.8350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 205 / 11 KV JEEGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1974	.2675				.3048
2	.2134	.1947	.2675				.3048
3	.2134	.1974	.2709				.3048
4	.2134	.1974	.2709				.3048
5	.2743	.1947	.2709				.2972
6	.3048	.2164	.2709				.2972
7	.3048	.2782	.2408				
8	.3048	.3338	.3353				
9	.3048	.3429	.3144	.2858	.3567	.4161	
10				.3144	.3864	.4161	
11					.3963	.3765	
12				.3353	.3658	.3338	
13				.3567	.3704	.3475	
14				.3269	.3704	.3429	
15				.3269	.3395	.3429	
16				.3567	.3395		
21						.2378	.2934
22						.2675	.3269
23						.3048	.3269
24	.2134	.1974	.2675				.3048
Max	.3048	.3429	.3353	.3567	.3963	.4161	.3269
Min	.2134	.1947	.2408	.2858	.3395	.2378	.2934
Avg	.2561	.2350	.2777	.3290	.3656	.3386	.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 206 / 11 KV INCOMER NO1

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945		.9945	.9259	.9877	.9145	.9945
2	.9602	1.0242	1.0608	.9259	.9877	.9145	.9945
3	.9602	1.0242	.9945	.9259	1.0082	.9145	.9945
4	.9602	1.0242	.9945	.8916	.9877	.9145	.9945
5	.9602	1.0242	.9945	.823	.9877	.9145	.9602
6	.9259	.924	.9602	.7888	.8413	.7682	.9602
7	.8573	.9145	.8916	.6516	.6584	.6219	.6173
8	.8573	.2641	.8916	.7392	.6584	.6241	
9	.8916	.2058	.9774	.9511	.8413	.9808	.7468
10	.7888			1.1706	1.1584	1.094	.7842
11			.924		1.134	1.1694	.7682
12			.8779	1.1706	1.086	.9808	.7316
13	1.0185	.9259	.9145	1.134	1.0498	1.0185	
14	.9259	.9145	.8413	.8779	1.086	1.0082	.8048
15	.8916	.9945	.8048	1.134	1.1222	1.0974	.9335
16	.9602	1.0288	1.0242	1.134	1.1222		.9145
17	.9511	.9945	.9602	.8962	.8131	.7888	.8871
18	.9431	.9602	.8573	.8215	.7682	.7545	.8501
19	.9877	.9602	.8916	1.0456	.9145	.823	1.0082
20	1.0974	1.0974	.9945	1.1576	1.0608	.9259	1.1088
21	1.1317	1.0974	1.0288	1.1706	1.0974	1.0631	1.3676
22	1.0719	1.0974	1.0631	1.134	1.0608	1.0631	1.3443
23	1.0242	.9945	.9602		.9877	1.0288	1.2323
24	.9945	1.0608	1.0288	.9259	1.0242	.9145	.9602
Max	1.1317	1.0974	1.0631	1.1706	1.1584	1.1694	1.3676
Min	.7888	.2058	.8048	.6516	.6584	.6219	.6173
Avg	.9615	.9266	.9535	.9725	.9768	.9260	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 207 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0749	1.0974	1.3717	1.4563	1.3321	1.0974
2	1.0631	1.0402	1.0974	1.3717	1.4563	1.3321	1.0631
3	1.0631	1.0402	1.0974	1.3717	1.4563	1.3176	1.0631
4	1.0631	1.0402	1.0974	1.4403	1.4563	1.3176	1.0288
5	1.0974	1.0402	1.0631	1.5364	1.491	1.3176	1.0288
6	1.0288	.9709	.9945	1.5729	1.5604	1.5257	1.0288
7	.9602	1.0056	1.0974	.6516	.6241	.6241	.6516
8	.9945	.9362	1.0288	.7762	.6516	.6241	.6173
9	.8573	.9259	1.1222	1.086	1.0867	1.0513	1.595
10	1.3717	1.3375		1.1584	1.1218	1.0852	1.595
11	1.406	1.4403	1.6126		1.1568	1.0513	1.4563
12	1.4403	1.5089	1.5775	1.2269	1.1568	1.0513	1.6297
13	1.4746	1.5089	1.4723	1.2971	1.1919	1.0852	
14	1.4746	1.5089	1.4723	1.2308	1.2269	1.0974	1.6991
15	1.4746	1.4746	1.5074	1.1568	1.1919	1.1789	.6935
16	1.4403	1.5089	1.4373	1.1919	1.1919		.7975
17	1.491	1.5089	1.5089	.7282	.7628	.7202	.7975
18	.7628	.823	.7888	.7628	.7282	.7682	.7628
19	.8669	.823	.8573	.9362	.9362	.7545	.8954
20	1.0056	.9945	.9259	1.0749	.9362	.7888	1.0745
21	.9709	.9602	.9259	1.6297	1.5257	.8573	1.3466
22	.9362	.9259	.9259	1.6644	1.5257	.8573	1.2971
23	.8669	.823	.8573			1.1317	1.2269
24	1.0631	1.0749	1.1317	1.3032	1.491	1.3672	1.0974
Max	1.491	1.5089	1.6126	1.6644	1.5604	1.5257	1.6991
Min	.7628	.823	.7888	.6516	.6241	.6241	.6173
Avg	1.1348	1.1373	1.1607	1.2064	1.1906	1.0538	1.1106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 201 / 11 kv Takarkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.3591	.128	.0343	.0648		.6516
2	.0486	.3405	.1097	.0343	.0648		.6379
3	.0486	.3784	.1109	.0343	.0648		.695
4	.0648		.1097	.0343	.0648		.6878
5	.0648		.1097	.0343	.0648	.4711	.8413
6		.3216		.0343		.9709	1.1218
8		.4573			.4696		
9		.5108			.9069		
10	.5497		.8048		.9335		
11	.6413		.9054		.802		
12	.679		.7377		.7529		
13	.603		.6706		.6965		
14	.5653		.5197		.6212		
15	.5653		.5365		.6413		
16	.603		.57		.6602		
17	.4894		.6371	.8097		.0914	.1327
18				.8583		.0886	.1517
19		.1463		.0648		.0886	.1706
20	.1896	.1463		.0648		.0914	.0189
21	.1706	.1463	.0343	.0648	.4527	.5304	.0758
22	.1894	.1267	.0343	.0648	.4715	.5853	.0758
23		.1086		.0648		.6219	.0758
24	.0486	.3602	.1075	.0343	.0648		.6135
Max	.679	.5108	.9054	.8583	.9335	.9709	1.1218
Min	.0486	.1086	.0343	.0343	.0648	.0886	.0189
Avg	.3276	.2835	.3829	.1594	.4587	.3933	.4250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 202 / 11 kv Fuly Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.056	.2195	.0514	.1619	.0747	.0526
2	.1943	.0566	.2195	.0514	.1619	.0747	.0526
3	.1943	.0566	.2172	.0514	.2267	.0747	.0526
4	.1943	.0754	.2353	.0514	.3077	.0747	.0526
5	.1943	.0761	.3258	.0514	.4534	.0934	.0526
6	.3077		.362		.502		
7	.3887		.3982				
8	.4696		.4252				
9	.3258		.4706	.3688		.8383	.5847
10		.6201		.4696		.8688	.5344
11		.6584		.6154		.7133	.5182
12		.6219		.4696		.5121	.4858
13		.5792		.3725		.4163	.4696
14		.5373		.2915		.439	.4534
15		.5068		.2429		.4755	.3887
16		.4656		.2429		.5121	.3725
17		.4525			.056		
18					.0905		
19		.0549		.0324	.1086	.0549	
20	.0747	.0543	.0514	.0324	.0905	.0549	.0747
21	.0747	.0543	.0514	.1619	.0732	.056	.1267
22	.0747	.0549	.0514	.1619	.0732	.0549	.1629
23	.056	.0549		.1619	.0747	.0549	.1829
24	.1943	.0747	.2195	.0514	.1619	.0747	.0532
Max	.4696	.6584	.4706	.6154	.502	.8688	.5847
Min	.056	.0543	.0514	.0324	.056	.0549	.0526
Avg	.2098	.2690	.2498	.2070	.1816	.2904	.2595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 203 / 11 kv Shemba Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3174	.3658	.2915	.3077	.3109	.2835
2	.3077	.3174	.3658	.2915	.3077	.3292	.2686
3	.2915	.2987	.3658	.2915	.3077	.3109	.2743
4	.2753	.3174	.3841	.2915	.421	.2926	.2686
5	.2753	.2987	.3841	.2915	.421	.2926	.2587
6	.3077	.3018	.4024	.2743	.4696	.2561	.2715
7	.4534	.2926	.4938	.285	.2915	.2743	.3045
8	.4858	.2926	.5068	.2683	.2753	.2926	.2804
9	.3982	.2452	.5249	.4024	.2591	.6104	.6135
10	.1494	.5194	.2743	.2915		.5792	.5182
11	.2743	.567	.2401	.1781	.2801	.543	.4534
12	.3109	.5121	.2713	.3725	.2743	.4706	.4696
13	.2926	.4656	.2713	.421	.3174	.4344	.4534
14	.3109	.4656	.2683	.4049	.3361	.4344	.3563
15	.3109	.4435	.2683	.421	.3326	.4163	.3887
16	.2926	.5175	.2683	.4049	.3142	.4163	.4372
17	.2743	.5544	.2683	.2915	.3881	.3109	.2801
18	.2926	.4207	.2883	.3077	.4163	.3292	.3142
19	.3658	.3856	.3052	.2915	.4344	.4024	.3511
20	.4572	.3856	.4115	.3239	.4525	.4207	.3944
21	.4294	.362	.3772	.3239	.4207	.3841	.4115
22	.4024	.362	.3429	.3401	.3841	.3658	.4115
23	.3658	.333	.3086	.3563	.3292	.3292	.4207
24	.2753	.3361	.3544	.3086	.3725	.3109	.2926
Max	.4858	.567	.5249	.421	.4696	.6104	.6135
Min	.1494	.2452	.2401	.1781	.2591	.2561	.2587
Avg	.3295	.3880	.3463	.3219	.3527	.3799	.3657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 205 / 11 kv Fuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1327	.112	.1753	.1267	.1512	.1307
2	.1448	.1327	.112	.1753	.1267	.1517	.112
3	.1448	.1327	.1307	.1753	.1267	.1323	.112
4	.1629	.1517	.1307	.1753	.1267	.1327	.1307
5	.1629	.1517	.1494	.1753	.1448	.1327	.1494
6	.1267	.1327	.1494	.181	.1448	.1517	.1494
7	.1267	.1518	.1307	.1543	.1448	.1517	.1494
8	.1086	.0943	.0747	.1372	.1448	.1137	.1307
9	.1139	.1137	.0747	.12	.1629	.1137	.112
10	.1137	.112		.1267	.1137	.112	.1086
11	.1136	.112		.1267	.0948	.112	.1267
12	.1324	.112	.12	.1267	.1137	.112	.1267
13	.1326	.112	.1543	.1448	.1327	.112	.1267
14	.1513	.112	.1543	.1448	.1515	.112	.1267
15	.1517	.112	.1543	.1448	.1517	.112	.1448
16	.1327	.1307	.1543	.1448	.1517	.112	.1448
17	.1326	.1494	.1543	.1448	.1517	.112	.1327
18	.1327	.1494	.1715	.1448	.1896	.1307	.1327
19	.1894	.168	.1753	.1448	.1894	.1448	.1137
20	.2268	.2054	.2103	.1629	.2083	.2054	.1706
21	.1896	.1867	.2279	.1629	.1706	.1867	.1896
22	.1896	.168	.2103	.1629	.1896	.168	.1517
23	.1706	.1494	.1928	.1629	.189	.1494	.1517
24	.1629	.1517	.1307	.1753	.1629	.1512	.1307
Max	.2268	.2054	.2279	.181	.2083	.2054	.1896
Min	.1086	.0943	.0747	.12	.0948	.112	.1086
Avg	.1483	.1385	.1488	.1537	.1504	.1360	.1356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 206 / 11 kv Shemba Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2614	.298	.2353	.2743	.2614
2		.168	.2614	.298	.2353	.2743	.2241
3		.1829	.2241	.298	.2534	.2561	.2241
4		.1886	.2427	.2804	.2353	.2561	.2427
5		.1698	.2427	.2804	.2172	.2378	.2614
6	.2353	.1886	.2241	.2454	.2172	.2241	.2427
7	.2353	.1698	.2054	.1886	.1991	.2054	.2054
8	.2172	.168	.1949	.1886	.2172	.1867	.2054
9	.2195		.2195	.2204	.1991	.1509	.2054
10	.2507	.1867	.2058	.2353	.2195	.168	.1629
11	.2743	.2241	.2229	.2105	.2353	.168	.1991
12	.2926	.2427	.2743	.2715	.2427	.1867	.2353
13	.2743	.2241	.2572	.3077	.2772	.2427	.2534
14	.2804	.2241	.2401	.3077	.3142	.2427	.2715
15	.2926	.2427	.2572	.3258	.3174	.2427	.2896
16	.2743	.2427	.2915	.3258	.3174	.2427	.3077
17	.2743	.2614	.2572	.3077	.2614	.2614	.2987
18	.2926	.3174	.2572	.2896	.3292	.2987	.3174
19	.3109	.3921	.298	.3077	.3292	.3361	.2957
20	.3841	.3734	.3856	.3077	.3658	.3734	.333
21	.3734	.3547	.4207	.3258	.3475	.3547	.3155
22	.3292	.3547	.3429	.3439	.3292	.3174	.333
23	.3109	.3361	.298	.2896	.2926	.2987	.3174
24		.2987	.3174	.298	.3077	.2801	.2801
Max	.3841	.3921	.4207	.3439	.3658	.3734	.333
Min	.2172	.168	.1949	.1886	.1991	.1509	.1629
Avg	.2846	.2505	.2668	.2813	.2706	.2533	.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 207 / 11 KV INCOMER NO1

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.6584	.7186	.6173	.583	.5487	1.1694
2	.3258	.7796	.7316	.6173	.583	.5658	1.1163
3	.3077	.815	.695	.6173	.5992	.5316	1.1517
4	.2896	.4938	.7316	.6001	.6964	.5144	1.1694
5	.5992	.4572	.7316	.6001	.6802	.9054	1.3466
6	.5182	.7619	.6219	.5487	.664	1.2334	1.701
7	.664	.4572	.695	.4694	.4696	.4359	.4961
8	.6802	.9214	.6836	.4527	.9393	.4458	.4733
9	.5959	.6859	.7186	.6203	1.3441	.7461	.815
10	.8745	.7207	1.2742	.502	1.3375	.7343	.664
11	1.1218	.7947	1.358	.3887	1.2174	.7133	.6316
12	1.1831	.7577	1.2742	.6154	1.153	.6447	.6802
13	1.0974	.7023	1.1904	.6964	1.1568	.6697	.6802
14	1.0802	.7023	1.0227	.6802	1.153	.6767	.5992
15	1.1043	.6838	1.0562	.7125	1.1831	.6516	.6478
16	1.0802	.7577	1.1233	.6964	1.1831	.6516	.7125
17	.9602	.8131	1.1568	1.3765	.6201	.6516	.6516
18	.5853	.7011	.5365	1.4251	.6952	.691	.7202
19	.6697	.8939	.5868	.6316	.7122	.823	.7545
20	.9922	.8764	.78	.664	.763	.8779	.7783
21	.9114	.8238	.823	.6802	1.1317	1.262	.8413
22	.8764	.8063	.7202	.7125	1.0852	1.262	.8507
23	.8059	.7537	.6687	.6964	.583	1.2437	.7545
24	.2896	.929	.7619	.6344	.7125	.5487	1.1568
Max	1.1831	.929	1.358	1.4251	1.3441	1.262	1.701
Min	.2896	.4572	.5365	.3887	.4696	.4359	.4733
Avg	.7474	.7395	.8609	.6773	.8852	.7512	.8568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 208 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.1896	.3189	.2229	.2753	.2263	.1753
2	.3239	.1896	.3155	.2229	.2753	.2263	.1578
3	.3239	.1894	.333	.2229	.3401	.2075	.1578
4	.3401	.2273	.362	.2229	.421	.2075	.1753
5	.3401	.2275	.4557	.2229	.583	.2263	.1928
6	.421	.1328	.5121	.1715	.6316	.1517	.1402
7	.502	.1517	.5304	.1509	.1296	.1518	.1402
8	.5668	.0943	.5493	.1341	.1296	.1132	.1227
9	.1132	.1139	.5609	.4862	.1457	1.0456	.7059
10	.1132	.7265		.583	.1131	.9568	.6316
11	.1134	.7682		.7287	.0943	.8145	.6316
12	.1324	.7316	.1174	.583	.1129	.6219	.5992
13	.1323	.6661	.1509	.502	.1318	.5304	.583
14	.1512	.6447	.1509	.421	.1494	.543	
15	.1517	.6283	.1509	.3725	.1517	.5792	.5182
16	.1327	.591	.1509	.3725	.1517	.6219	.502
17	.1327	.6099	.1509	.1296	.2085	.1109	.132
18	.1327	.1448	.1696	.1296	.2844	.1227	.1323
19	.1896	.2172	.1677	.1619	.3033	.2012	.1134
20	.303	.2454	.2543	.1781	.3033	.2561	.2452
21	.2657	.2378	.2743	.3077	.2452	.2378	.3206
22	.2651	.2195	.2572	.3077	.2641	.2195	.3206
23	.2273	.1991	.2401	.3077	.2452	.2012	.3395
24	.3401	.2085	.333	.2229	.2915	.2263	.1753
Max	.5668	.7682	.5609	.7287	.6316	1.0456	.7059
Min	.1132	.0943	.1174	.1296	.0943	.1109	.1134
Avg	.2516	.3481	.2957	.3069	.2492	.3667	.3136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 201 / 11 kv Kolasar Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3772		.061		.061
2	.3048	.3601		.061		.061
3	.3048	.3429		.061		.061
4	.3353	.3429		.061		.061
5	.3506	.4115				
6	.5182	.5144				
7	.6554	.6173				
8	.7316	.7373				
9	.7164	.8916				.6249
10			.5487		.8535	
11			.7773		.6706	
12			.6554		.6401	
13			.6401		.6401	
14			.5335		.6401	
15			.5335		.7316	
16					.7164	
17			.6401			
19	.1029	.0857	.061		.1372	
20	.12	.0686	.0457		.0457	
21	.1029	.0686	.061		.061	
22	.1029	.0686	.0457		.061	
23	.1029	.0686	.061		.0686	
24	.7621	.3944		.061		.061
Max	.7621	.8916	.7773	.061	.8535	.6249
Min	.1029	.0686	.0457	.061	.0457	.061
Avg	.3677	.3566	.3836	.061	.4388	.1550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 202 / 11 kv Naigaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0343		.1219		.061
2	.0457	.0343		.1219		.061
3	.0457	.0343		.1067		.061
4	.0457	.0343		.1067		.061
5				.1067		.0914
6				.2286		
7						.1219
8						.0762
10	.2401	.3086				
11	.2229	.2915				
12	.1886	.2229				
13	.1715	.1886				
14	.1543	.1715				
15	.1543	.1715				
16	.1715	.1886				
17	.2058	.2058				
19	.0686	.0514	.061			
20	.0686	.0686	.061		.0152	
21	.0686	.0686	.1067		.0305	
22	.0514	.0686	.1067		.061	
23	.0514		.1219		.061	
24	.0457	.0343		.1219		.1067
Max	.2401	.3086	.1219	.2286	.061	.1219
Min	.0457	.0343	.061	.1067	.0152	.061
Avg	.1137	.1281	.0915	.1306	.0419	.0800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 203 / 11 kv Naigaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029		.1372		.1372
2	.1372	.1029		.1372		.12
3	.1372	.1029		.1372		.12
4	.12	.1029		.1372		.12
5	.12	.1029		.1372		.12
6	.1029	.0857		.1029		.1029
7	.0686	.0686		.0857		.0762
8	.1219	.0857		.1029		.0686
9	.0762	.0857				.0686
10	.0686	.0514	.0686		.1029	
11	.0857	.0857	.0762		.12	
12	.1029	.1029	.0686		.12	
13	.0857	.12	.1029		.1372	
14	.1029	.12	.12		.1372	
15	.1029	.12	.12		.12	
16	.12	.12	.12		.1067	
17	.12	.1029	.12		.1067	
18	.1029	.1029	.1029		.1219	
19	.12	.1029	.1372		.1543	
20	.1372	.1372	.1715		.1524	
21	.1372	.1715	.1715		.1715	
22	.1372	.1543	.1543		.1715	
23	.12	.1372	.1372		.1543	
24	.1372	.1029		.1372		.1543
Max	.1372	.1715	.1715	.1372	.1715	.1543
Min	.0686	.0514	.0686	.0857	.1029	.0686
Avg	.1126	.1072	.1194	.1239	.1340	.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 204 / 11 kv Kolasar Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.4268		.4458
2	.5175		.4287
3	.5175		.4287
4	.499		.4287
5	.499		.4287
6	.3881		.3601
7	.3881		.3258
8	.3511		.2591
9	.3696		.2439
10		.3601	
11		.3772	
12		.3944	
13		.4115	
14		.4458	
15		.4287	
16		.4287	
17		.3772	
18		.3944	
19		.5658	
20		.6687	
21		.6344	
22		.5487	
23		.5144	
24	.4973		.4801
Max	.5175	.6687	.4801
Min	.3511	.3601	.2439
Avg	.4454	.4679	.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 205 / 11 KV SHELGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.12		.3353		.3048
2	.1067	.12		.3353		.3048
3	.1067	.12		.3048		.3048
4	.1067	.12		.3048		.3048
5				.3048		.3048
6				.5792		.7621
10	.7545	.8573				
11	.703	.8059				
12	.6687	.703				
13	.6001	.583				
14	.4973	.5316				
15	.463	.5144				
16	.4973	.4973				
17	.5144	.583				
19	.12	.12	.1372		.1067	
20	.1372	.12	.1219		.1067	
21	.12	.12	.3048		.381	
22	.12	.12	.2743		.3048	
23	.12	.12	.3353		.3048	
24	.1067	.12		.6401		.3048
Max	.7545	.8573	.3353	.6401	.381	.7621
Min	.1067	.12	.1219	.3048	.1067	.3048
Avg	.3249	.3486	.2347	.4006	.2408	.3701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 201 / 11 kv Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.6263	1.829	1.8099	1.5432	1.4784	1.6461
2	1.7147	1.5524	1.7924	1.7375	1.5089	1.4045	1.6804
3	1.6804	1.5364	1.7924	1.6827	1.5089	1.4045	1.643
4	1.6804		1.7924	1.6095	1.4403	1.2567	1.6057
5	1.6118	1.3676	1.7177	1.4784	1.4403	1.2197	1.6221
6	1.3717	1.2803	1.4632	1.4632	1.3375	1.2197	1.4003
7	1.3717	1.2567	1.531	1.4632	1.166	1.1827	1.3169
8	1.166	1.2012	1.4998	1.2894	1.0631	1.1827	1.1949
9	1.267	1.166	1.4045	1.3535	1.3169	1.0631	1.1827
10	1.3443	1.2346	1.2936	1.39	1.3756	1.0631	1.1827
11	1.4632	1.3375	1.39	1.4632	1.4327	1.0288	1.2567
12	1.4632	1.3717	1.4998	1.5364	1.5203	1.0288	1.3306
13	1.643	1.5203	1.6263	1.6461	1.5927	1.0631	1.4045
14	1.6289	1.5043	1.6632	1.7551	1.6095	1.0631	1.5893
15	1.7924	1.6827	1.6632	1.7924	1.7375	1.1576	1.6263
16	1.6827	1.6651	1.6632	1.8107	1.7558	1.0631	1.6632
17	1.6263	1.6461	1.6476	1.6118		1.2936	1.4403
18	1.4784	1.5684	1.5927	1.5775		1.39	1.643
19	1.5893	1.6461	1.6476	1.5775	1.848	1.531	1.6804
20	1.6263	1.7558	1.8099	1.6461	1.848	1.643	1.5775
21	1.6632	1.8298	1.848	1.6461	1.7002	1.6975	1.7551
22	1.6632	1.8861	1.829	1.7147	1.6263	1.6804	1.6804
23	1.6461	1.829	1.9547	1.7147	1.5893		1.5432
24	1.5432	1.7002	1.8671	1.9022	1.7147	1.5524	1.7177
Max	1.7924	1.8861	1.9547	1.9022	1.848	1.6975	1.7551
Min	1.166	1.166	1.2936	1.2894	1.0631	1.0288	1.1827
Avg	1.5597	1.5289	1.6591	1.6113	1.5307	1.2899	1.5160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 202 / 11 kv Dairy

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.1658			1.9753
2			2.2218			1.9791
3			2.1502			1.9791
4			2.1068			1.9239
5			2.0328			1.9044
6			1.6221			1.4937
7			1.5844			1.3817
8			1.5364			1.3443
9	1.5364			1.5844		
10	1.5729			1.587		
11	1.6804			1.6804		
12	1.8861			1.7353		
13	1.9418			2.0911		
14	2.0538			2.1658		
15	2.1658			2.1879		
16	2.1658			2.1658		
17		1.8671			1.531	
18		1.7924			1.5364	
19		2.0748			1.6975	
20		2.1658			1.7924	
21		2.1879			1.8484	
22		2.1879			1.8861	
23		2.1582				
24			2.2032			2.0165
Max	2.1658	2.1879	2.2218	2.1879	1.8861	2.0165
Min	1.5364	1.7924	1.5364	1.5844	1.531	1.3443
Avg	1.8754	2.0620	1.9582	1.8997	1.7153	1.7776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 203 / 11 kv Rural Ag Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.016		.0156		.0156		
2	.016		.016		.0156		
3	.016		.0164		.016		
4	.032		.0168		.0158		
5	.032		.0162		.0158		
6	.0332		.0156		.0312		
7	.0312		.0183				
8	.032		.0183				
9	.0339		.0145	.0164		.0156	.0145
10		.016		.0335		.0312	.0145
11		.0312		.0324		.0312	.0145
12		.0312		.0324		.0312	.0145
13		.0111		.0332		.032	.0145
14		.0114		.0328		.0309	
15		.0149		.0328		.0373	.0145
16		.0111		.0373		.032	.0145
17		.0183					
21				.0156			
22				.0312			.0312
23				.0309			.0312
24	.0154		.0156		.016		
Max	.0339	.0312	.0183	.0373	.0312	.0373	.0312
Min	.0154	.0111	.0145	.0156	.0156	.0156	.0145
Avg	.0258	.0182	.0163	.0299	.018	.0302	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 205 / JALAGAON ROAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.4805	.439	.4435	.5228	.2957	.439
2	.6348	.4755	.4527	.4066	.5228	.2957	.4481
3	.5975	.4024	.4481	.3734	.4481	.2957	.4108
4	.5975	.4024	.439	.3734	.4481	.2957	.4024
5	.5975	.3696	.3658	.3696	.3734	.2957	.415
6	.4481	.3326	.2926	.3696	.3734	.2957	.3734
7	.4481	.2926	.2987	.3696	.3361	.2957	.2987
8	.2987	.2926	.2926	.3696	.2614		.2614
9	.2926	.2987	.2926	.3292	.1109	.2614	.2587
10	.112	.3734	.2926	.3292	.3696	.2614	.2957
11	.2926	.4108	.3292	.3658	.2957	.2614	.2957
12	.3734	.4481	.439	.3658	.3696	.2614	.2957
13	.4481	.3734	.4805	.439	.3696	.2987	.2957
14	.4854	.3734	.4755	.4481	.3772	.3361	.3326
15	.5228	.3734	.4755	.439	.4435	.3361	.3326
16	.4481	.3734	.4755	.4481	.439	.3361	.3292
17	.439	.2926	.362	.4481		.2926	.3361
18	.4435	.2926	.4435	.4108		.2926	.3734
19	.4805	.3361	.5014	.4108	.2926		.4108
20	.5544	.3361	.4344	.4481	.4066	.3658	.4481
21	.5544	.4527	.439	.5228	.4805	.4527	.4481
22	.5914	.4527	.4435	.5228	.4066	.4527	.5228
23	.5658	.4481	.5175	.5975	.3326		.5228
24	.5228	.5487	.4481	.5175	.5975	.3326	.4481
Max	.6348	.5487	.5175	.5975	.5975	.4527	.5228
Min	.112	.2926	.2926	.3292	.1109	.2614	.2587
Avg	.4743	.3847	.4116	.4216	.3899	.3148	.3748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 401 / 33KV MAIN INCOMMER FEEDER NON SHEDDABLE WATER SUPPLY AND
TO N Feeder KV- 33 / INCOMING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.7298		7.6818	8.2305	8.1219		8.2305
2	7.2817		7.8418	8.0361	7.8418		8.2899
3	7.1696		7.572	8.011	7.7298		8.1779
4	7.1696		7.6178	7.9836	7.2817		8.011
5	7.0016		7.6178	7.8418	6.7215		7.7298
6	6.7215		6.3397	7.5823	6.4415		7.1331
7	6.8336		6.5295	5.2669	6.4415		4.4993
8	6.6095	6.5844	7.0731	5.048	5.0412	4.269	4.4445
9	6.1357	6.1054		7.1879	7.5617	4.8171	
10	6.7901	6.1728		7.1331	6.2574	5.3212	
11	7.5172	7.2817		7.5172	8.514	5.6013	
12	8.1219	7.8978		8.1779	8.738	5.8253	
13	8.3459	6.7833		8.5597	8.794	7.8418	
14	8.2899	7.9201		8.4888	9.0741	7.7298	
15	7.6389	7.9201		9.0181	9.5222	7.1696	
16	8.3459	7.9201	8.2305	8.9621	9.4662	8.3459	8.7792
17		8.3459	8.626	8.85		7.5057	6.6655
18		5.4092	6.0471	6.7215		6.5535	6.7215
19		6.2174	6.166	6.8896		5.2126	6.7215
20		6.5844	7.1131	6.7215		6.2552	7.2817
21		6.6244	5.4801	7.0016		8.1207	9.1861
22		6.9685	7.2428	7.2817		8.714	7.8418
23		7.6818	7.2428	7.5617			8.1219
24	7.4932		7.6818	8.6008			8.2305
Max	8.3459	8.3459	8.626	9.0181	9.5222	8.714	9.1861
Min	6.1357	5.4092	5.4801	5.048	5.0412	4.269	4.4445
Avg	7.3644	7.0261	7.1826	7.6114	7.7218	6.6188	7.4156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 402 / 33 KV Outgoing fdr
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646		2.8532	3.2922	3.2487		3.5231
2	2.4646		2.6818	3.2922	2.9127		3.6214
3	2.3525		2.7343	3.2373	2.8006		3.6763
4	2.8006		2.6292	3.3265	2.2405		3.5665
5	2.9127		2.6818	3.3608	2.2405		3.6408
6	2.9687		2.6006	3.3385	1.8461		3.5848
7	2.9687		2.7263	1.3717	1.6804		1.1043
8	2.6326	3.1047	2.7869	1.3169	1.4563	1.1088	1.1523
9	2.572	2.2405		2.8487	4.0175	1.7924	
10	3.5803	2.3525		3.0498	2.7978	1.7364	
11	3.5848	2.6886		3.5117	4.6965	1.8461	
12	3.8477	3.3608		3.8409	4.5268	2.1285	
13	3.6763	2.3137		4.0604	4.6296	2.7446	
14	3.4568	3.3128		3.8009	4.5833	2.6886	
15	2.4394	3.2602		3.6408	4.6965	2.8006	
16	3.3951	3.3808	3.4568	3.5368	4.6399	4.145	2.0302
17		3.5997	3.9438	2.8006		3.2373	2.6886
18		1.5364	1.7353	2.3525		2.8292	2.5206
19		2.7343	1.7193	2.1845		1.7924	2.2405
20		2.1948	2.3594	2.2405		1.9204	2.4646
21		2.3045	2.0199	2.8006		3.9209	4.201
22		2.3045	2.2405	2.9127		4.1872	2.9127
23		2.0856	2.0725	3.2487			3.3608
24	2.3891		2.8532	3.4168	3.1493		3.6763
Max	3.8477	3.5997	3.9438	4.0604	4.6965	4.1872	4.201
Min	2.3525	1.5364	1.7193	1.3169	1.4563	1.1088	1.1043
Avg	2.9710	2.6734	2.5938	3.0326	3.3037	2.5919	2.9391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 201 / 11 kv Chikhali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.1311	.0248	.1372	.0373	.1097	.0133
2	.0343	.1296	.0251	.1372	.0373	.1257	.0133
3	.0343	.1311	.0248	.1372	.0373	.1257	.0171
4	.0343	.116	.0255	.1372	.0373	.1238	.0191
5	.0343	.1457	.0248	.1543	.0373	.1238	.0229
6		.192	.0248	.1696	.0373	.1257	.0229
7		.2241					
8		.2561					
9		.1781			.2915		
10	.3361		.3561		.2105		
11	.2881		.3185		.1486		
12	.2622		.3018		.1486		
13	.2241		.2683		.1362		
14	.2267		.3018		.1383		
15	.1966		.2743		.1362		
16	.192		.2572		.1219		
17	.2241		.3944				
19						.0038	
20	.056			.056		.0038	.0514
21	.056	.0248	.0514	.056		.0152	.0514
22	.056	.0248	.0514	.056	.1006	.0152	.0514
23	.0373	.0248	.0514	.056	.0975	.0152	
24	.0343	.1475	.0251	.12	.0373	.1021	.0152
Max	.3361	.2561	.3944	.1696	.2915	.1257	.0514
Min	.0343	.0248	.0248	.056	.0373	.0038	.0133
Avg	.1312	.1327	.1556	.1106	.1054	.0741	.0278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 202 / 11 kv Amboda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1115		.176		
2	.1715		.1132		.1638		
3	.1715		.1257		.1638		
4	.1715		.1362		.2267		
5	.1886		.1341		.2561		
6	.2229		.161		.3841		
7	.3185		.2515				
8	.3521		.2848				.3772
9	.3772			.4115		.4527	.3772
10		.2477		.4161		.0629	.4694
11		.2724		.4641		.0629	.6133
12		.2477		.3681		.0629	.5487
13		.2601		.3401		.0514	.4694
14		.2724		.2753		.0533	.3086
15		.2553		.2561		.0533	.3944
16		.2477		.2881		.0572	.4801
17		.2683					
21				.213			.3601
22				.2267			.3429
23				.213			.3429
24	.1715		.1006		.1781		
Max	.3772	.2724	.2848	.4641	.3841	.4527	.6133
Min	.1715	.2477	.1006	.213	.1638	.0514	.3086
Avg	.2317	.2590	.1576	.3156	.2212	.1071	.4237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 203 / 11 kv Amboda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1734	.2378	.2229	.1463	.0286
2		.1734	.2218	.208	.1238	.0286
3		.1734	.2033	.208	.1238	.0305
4		.161	.2012	.2035	.1257	.0343
5		.1486	.2012	.1734	.1257	.0343
6		.1463	.1829	.1696	.1238	.0381
7		.1115	.1646	.1753	.1115	.0381
8		.1276	.1829	.1372	.1132	.0549
9		.1238	.1463	.1677	.0991	.0543
10		.2149	.1844	.0854	.0133	.1463
11		.1772	.213	.1362	.0133	.0716
12	.1532	.2149	.2321	.1509	.0152	.2507
13	.161	.2328	.2321	.161	.0191	.2686
14	.161	.2507	.2347	.161	.021	.2686
15	.1635	.2507	.2374	.1734	.021	.3012
16	.1707	.2378	.2155	.1734	.021	.2865
17	.1814	.2328	.2204		.021	.2743
18	.161	.197	.2058		.021	.2926
19	.1486	.2303	.2204		.0229	.3077
20	.2229	.2835	.1734	.2515	.0286	.3761
21	.2353	.3475	.2254	.2105	.0286	.3761
22	.2263	.2865	.2204	.2042	.0229	.3658
23	.1981	.2926	.2204	.176	.0229	.3292
24		.1981	.2378	.2229	.1734	.0229
Max	.2353	.3475	.2378	.2515	.1734	.3761
Min	.1486	.1115	.1463	.0854	.0133	.0229
Avg	.1819	.2078	.2090	.1796	.0649	.1783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 204 / 11 kv Industrial feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.3077	.0383	.0537	.1147	.0629	.0114
2	.298	.2949	.0372	.0543	.0949	.0619	.0114
3	.298	.2949	.0511	.0537	.0949	.0754	.0095
4	.2629	.2915	.0495	.0532	.096	.0743	.0095
5	.2279	.2622	.0495	.0537	.0949	.0619	.0095
6	.2303	.2561	.0503	.0532	.1107	.061	.0095
7	.1928	.1802	.0126	.0709	.0949	.0629	.0095
8	.1949	.1781	.0124	.0716	.064	.0619	.0886
9	.1949	.208	.0124	.0709			.0886
10	.1943	.1509	.0354	.064			.0876
11	.213	.1383		.0648			
12	.2429	.0377	.0532	.0655			.0532
13	.3113	.0495	.0532	.0819	.0495	.0114	.0532
14	.3277	.0503	.0532	.0819	.0619	.0114	.0526
15	.3239	.061	.0886	.0633	.0638	.0114	.0709
16	.3077	.0638	.0709	.0791	.0732	.0095	.0709
17	.2753	.0619	.0895	.064		.0095	.0701
18	.3077	.0377	.0716	.0655		.0095	.0709
19	.3401	.0124	.0549	.08	.0619	.0095	.0716
20	.3521	.0251	.0366	.1107	.0754	.0095	.0886
21	.3563	.0251	.0358	.1107	.0743	.0095	.0895
22	.3361	.0248	.0358	.1134	.0629	.0133	.0895
23	.3361	.0251	.0358	.112	.0629	.0133	.1063
24	.3544	.3441	.0248	.0537	.1134	.0619	.0133
Max	.3563	.3441	.0895	.1134	.1147	.0754	.1063
Min	.1928	.0124	.0124	.0532	.0495	.0095	.0095
Avg	.2834	.1409	.0458	.0727	.0813	.0351	.0537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 205 / 11 kv Chikhali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1014	.0867	.1433	.1014	.088	.0133
2	.1254	.1014	.0743	.1254	.1014	.0894	.0133
3	.124	.0869	.0743	.124	.0823	.0743	.0114
4	.124	.0869	.0743	.1254	.0823	.0754	.0114
5	.124	.0846	.0732	.1254	.0823	.0743	.0095
6	.124	.0823	.0867	.1417	.0869	.0743	.0095
7	.1227	.0724	.0743	.1063	.0724	.0777	.0095
8	.1075	.0549	.0743	.1612	.096	.0743	.0895
9	.1417	.0869	.1132	.2303	.1158	.0619	.0886
10	.1646	.0867	.2865	.192	.2012	.0191	.0895
11	.1974	.088	.3366	.2134	.1486	.0191	.1791
12	.2267		.2658	.1974	.2073		.1772
13	.2469	.2012	.2835	.192	.1886	.021	.1772
14	.16	.2263	.2865	.2195	.1886	.0324	.1772
15	.096	.2477	.3012	.2195	.1734	.0324	.1791
16	.1097	.2477	.3045	.2134	.176	.0286	.1772
17	.096	.1734	.2835	.2195		.0286	.1402
18	.1235	.1486	.2658	.1372		.0248	.1417
19	.1269	.1238	.2149	.1391	.1115	.0286	.1254
20	.1158	.1383	.1753	.1448	.1383	.0191	.1772
21	.1128	.1238	.1772	.1448	.1257	.0191	.197
22	.1269	.0991	.197	.1158	.1115	.0171	.1772
23	.1235	.0991	.1791	.1158	.0991	.0171	.1433
24	.1463	.1235	.0991	.1433	.1128	.1006	.0095
Max	.2469	.2477	.3366	.2303	.2073	.1006	.197
Min	.096	.0549	.0732	.1063	.0724	.0171	.0095
Avg	.1379	.1254	.1828	.1621	.1274	.0477	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 206 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.583	.6335	.5914	.6706	.5973	.0667
2	.6653	.5596	.6154	.5601	.6203	.5731	.0667
3	.6584	.5426	.6516	.5415	.6036	.5792	.0686
4	.6154	.5256	.6516	.5415	.6859	.5853	.0743
5	.6036	.5375	.6335	.5601	.6783	.5611	.0762
6	.6036	.5765	.6089	.5729	.8029	.5611	.08
7	.6697	.5087	.6516	.3511	.3681	.362	.0572
8	.695	.5087	.6335	.4251	.3506	.2715	.6335
9	.7499	.503	.7783	.8962	.6104	.8869	.6468
10	.7459	.7059		.9012	.724	.0953	.8326
11	.7545	.724	.8688	1.0159	.6335	.0953	.9231
12	.8048	.7783	.8596	.9012	.7164	.0781	1.0679
13	.8356	.9774	.8688	.8951	.7865	.1029	1.0029
14	.7625	1.0208	.9134	.8619	.788	.1181	.8238
15	.6464	1.0498	.9412	.8192	.788	.1181	.9774
16	.6613	1.0566	.8962	.8619	.788	.1162	1.0387
17	.6443	.9955	1.0317	.5721		.0591	.5853
18	.4908	.5068	.5487	.4557		.0553	.5175
19	.5258	.4207	.5121	.4908	.2534	.0648	.5175
20	.5847	.5973	.5175	.5201	.6767	.061	.7207
21	.5721	.5973	.6283	.7712	.5973	.2896	.7164
22	.5609	.543	.5914	.7459	.6878	.0686	1.0498
23	.5609	.5068	.5729	.7293	.6335	.0686	1.0059
24	.7316	.6613	.6154	.5729	.6796	.6335	.061
Max	.8356	1.0566	1.0317	1.0159	.8029	.8869	1.0679
Min	.4908	.4207	.5121	.3511	.2534	.0553	.0572
Avg	.6599	.6661	.7054	.6731	.6429	.2918	.5671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 401 / 33KV Gajanan Solvex

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18
HR	Load (MW)
21	1.7164
22	1.6827
23	1.6827
Max	1.7164
Min	1.6827
Avg	1.6939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 201 / 11 kv Maha Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2614	.2686	.0274	.2614	.2561	.2507
2	.2829	.2614	.2686	.0274	.2614	.2378	.2507
3	.2829	.2427	.2686	.0274	.2427	.2378	.2328
4	.2641	.2614	.2686	.0274	.2427	.2195	.2328
5	.2641	.2801	.2328	.0274	.2054	.2195	.2328
6	.2263	.2054	.2149	.0219	.1867	.1829	.197
7	.2012	.1867	.1791	.0183	.1867	.1829	.1612
8	.1848	.1867	.1791	.0183	.168	.1646	.1612
9	.1646	.1494	.197	.0183	.1867	.1829	.0165
10	.2054	.2149	.0201	.2054	.1991	.1612	.0183
11	.1867	.2507	.0238	.2427	.2172	.197	.0201
12	.2241	.2507	.0256	.2801	.2427	.2149	.0183
13	.2801	.2686	.0274	.2801	.2587	.2328	.0219
14	.2614	.2865	.0293	.2987	.2926	.2507	.0274
15	.2801	.2865	.0293	.2801	.3109	.2507	.0293
16	.2987	.2865	.0293	.3174	.3475	.2507	.0293
17	.2801	.2507	.0274	.2801		.2328	.0256
18	.2427	.2328	.0238	.2614		.2507	.0238
19	.2801	.2686	.0274	.2801	.3361	.2686	.0311
20	.3734	.2865	.0754	.4108	.3841	.3045	.0384
21	.4108	.3224	.3961	.3547	.3292	.3224	.0348
22	.3734	.3045	.0329		.3292	.2865	.3073
23	.2987	.2686	.0274	.2987	.2926	.2507	
24	.2801	.2801	.2686	.0274	.2614	.2561	.2507
Max	.4108	.3224	.3961	.4108	.3841	.3224	.3073
Min	.1646	.1494	.0201	.0183	.168	.1612	.0165
Avg	.2679	.2539	.1309	.1753	.2610	.2339	.1136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 202 / 11 kv Maha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0339	.0876	.0055	.0671	.0423	.0526
2	.0754	.0339	.0876	.0055	.0686	.0423	.052
3	.0754	.0343	.0876	.0055	.0686	.0412	.0526
4	.0754	.0343	.0867	.0055	.0514	.0423	.052
5	.0754	.0509	.0876	.0055	.1174	.0564	.052
6	.1132		.1402		.2012		
7	.1858		.1753				
8	.2256		.2454				
9	.1974		.1753	.0165		.08	.0293
10		.2629		.285		.3155	.0274
11		.2629		.2515		.2804	.0073
12		.2629		.2155		.208	.0165
13		.208		.1658		.1753	.0146
14		.1753		.1326		.2103	.0128
15		.1402		.116		.208	.0146
16		.1227		.1677		.208	.0128
17		.1578					
19	.0509	.1052	.0073	.0514	.0423	.052	.0055
20	.0509	.2804	.0754	.0514	.0423	.052	.0073
21	.0509	.0526	.0566	.0671	.04	.052	.0073
22	.0509	.0526	.0055	.0503	.04	.0526	.0091
23	.0503	.0526	.0055	.0671	.04	.0526	.0754
24	.0446	.0339	.0876	.0055	.0671	.0429	.0526
Max	.2256	.2804	.2454	.285	.2012	.3155	.0754
Min	.0446	.0339	.0055	.0055	.04	.0412	.0055
Avg	.0919	.1241	.0941	.0879	.0705	.1165	.0291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 203 / 11 kv Tarw Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2801	.2835	.0293	.2987	.3361	.3582
2	.3395	.2614	.2658	.0293	.2801	.3361	.3403
3	.3395	.2614	.2658	.0293	.2801	.3174	.3403
4	.2829	.2801	.2658	.0293	.2614	.3142	.3403
5		.2801	.2481	.0293	.2614	.2772	.3403
6	.2452	.2241	.2126	.0238	.2427	.2614	.3224
7	.2218	.2054	.1949	.0201	.2054	.2614	.2328
8	.2033	.2427	.1791	.0201	.2054	.2195	.2328
9	.2012	.1867	.197	.0165	.2054	.1829	.0274
10	.2427	.2149	.0274	.2614	.2172	.1612	.0274
11	.2241	.2865	.0293	.2801	.3224	.2149	.0402
12	.2614	.2865	.0293	.2987	.3361	.2686	.0384
13	.3921	.3045	.0329	.3361	.2987	.3045	.0402
14	.3734	.3045	.0384	.3361	.3174	.3224	.0366
15	.3547	.3045	.0348	.3174	.3174	.3582	.0366
16	.3361	.3045	.0311	.2987	.3547	.3582	.0329
17	.3174	.3045	.0293	.2801		.3761	.0439
18	.3361	.3761	.0293	.2987		.3045	.0311
19	.3174	.2865	.0311	.3361	.3547	.3224	.0348
20	.4294	.3224	.3772	.4294	.4294	.4119	.0476
21	.4481	.3403	.3961	.3921	.4108	.4298	.0421
22	.3921	.3224	.0348	.3547	.3921	.394	.3961
23	.2987	.3045	.0311	.3361	.3547	.3761	.3395
24	.3174		.2865	.0293	.2987	.3584	.3582
Max	.4481	.3761	.3961	.4294	.4294	.4298	.3961
Min	.2012	.1867	.0274	.0165	.2054	.1612	.0274
Avg	.3137	.2819	.1480	.2005	.3020	.3111	.1700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 204 / 11 kv Tarwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0838	.0686	.0128	.0848	.0406	.1734
2	.0754	.0829	.0693	.0128	.0678	.0406	.1734
3	.0754	.0838	.0693	.0128	.0678	.04	.1753
4	.0754	.0829	.0701	.0128	.0678	.04	.1753
5	.0754	.1006		.0165	.0838	.0533	.1753
6		.1966		.0201		.0934	.4508
7		.2486					
8		.2486	***				
9		.2012			.3856		
10	.1341		.0402		.2743		
11	.3149		.0457		.2397		
12	.2949		.0366		.1974		
13	.2515		.0293		.1783		
14	.1696		.0219		.1829		
15	.12		.0183		.1467		
16	.1029		.0219		.1334		
17	.12		.0238				
19	.0848	.0857	.0073	.1017		.104	.0091
20	.0848	.0857	.0754	.1006		.1075	.0091
21	.0848	.0867	.0073	.1017	.04	.1734	.0073
22	.0848	.0693	.0073	.1006	.04	.1753	.0091
23	.0848	.0693	.0073	.0838	.04	.156	.0754
24	.0714	.0678	.0686	.0128	.0848	.0412	.156
Max	.3149	.2486	66.3753	.1017	.3856	.1753	.4508
Min	.0714	.0678	.0073	.0128	.04	.04	.0073
Avg	.1253	.1196	3.5297	.0491	.1362	.0888	.1325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 206 / 11 KV INCOMER

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.6447	.724	.0205	.6984	.6371	.8507
2	.7733	.6268	.6984	.0207	.6626	.6344	.8326
3	.7733	.6154	.6984	.0209	.6335	.4801	.8145
4	.6979	.6447	.6984	.0207	.6154	.583	.8145
5	.6979	.6626	.6447	.0205	.6626	.5959	.8145
6	.5847	.6268	.5731	.0201	.6268	.583	.9955
7	.6173	.6447	.5552	.0209	.3841	.4161	.3982
8	.6203	.6805	.6089	.021	.3658	.463	.3982
9	.583	.5373	.5731	.0203	.788	.4458	.0205
10	.5731	.7059	.0201	.7522	.7449	.6516	.0209
11	.7343	.8145	.0207	.7701	.7522	.7059	.0201
12	.7712	.8059	.0205	.788	.7373	.6984	.0201
13	.8939	.7964	.0205	.7602	.7373	.724	.0201
14	.8059	.7783	.0207	.7522	.7716	.788	.0203
15	.7343	.7343	.0205	.7701	.7888	.8238	.0203
16	.7164	.7164	.0205	.7701	.8573	.8238	.0203
17	.6984	.7164	.0207	.5487		.6089	.0205
18	.5611	.788	.021	.5487	.2572	.5552	.0209
19	.7164	.2865	.0207	.7602	.6859	.7522	.0207
20	.9231	.7522	.9431	.9671	.8059	.8775	
21	.9671	.8059	.0207	.8775	.823	.9955	.0201
22	.8775	.7522	.0205	.8238	.7716	.9134	.0201
23	.7164	.7059	.0205	.788	.703	.8507	
24	.6344	.6268	.6335	.0203	.591	.6371	.724
Max	.9671	.8145	.9431	.9671	.8573	.9955	.9955
Min	.5611	.2865	.0201	.0201	.2572	.4161	.0201
Avg	.7253	.6862	.3174	.4535	.6724	.6769	.3140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 201 / 11 kv Alampur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.2667	.8749	.3658	.5868	.5506	.6706
2	.543	.2934	.8421	.3658	.5868	.5506	.6706
3	.543	.2934	.8097	.3658	.5868	.4999	.6706
4	.543	.2934	.7773	.3658	.5868	.5624	.6706
5	.5973	.2934	.7209	.3963	.6401	.6154	.6706
6	.7783	.2934	.7537	.3963	.6935	.6802	.6706
7	1.086	.3734	.8421				
8	.8326	.5068	1.0364				
9	.7621	.6478	.5601	1.004	.884		1.2955
10	.4572	1.1336	.5601	1.1336	.945		1.3927
11	.5792	1.1797	.5068	1.166	.8535		1.4575
12	.5182	1.1336	.5068	1.1248	.1524	.2934	1.4419
13	.5182	1.0688	.4801	1.0936	.7011	.6401	1.3123
14	.3963	.9717	.4534	1.1469	.7316	.9602	1.3108
15	.3963	.8848	.5068	1.1012	.7621	1.1203	1.2631
16	.3963	.9717	.4572	1.0364	.7621	1.3203	1.2803
17	.3734	1.004	.4877			1.1888	
18						1.1584	
21				.5601		.5792	.9755
22				.5601	.5182	.7316	1.0856
23				.5868	.583	.7011	1.0669
24	.4706	.2934	.9717	.3353	.5868	.5506	.7011
Max	1.086	1.1797	1.0364	1.166	.945	1.3203	1.4575
Min	.3734	.2667	.4534	.3353	.1524	.2934	.6706
Avg	.5741	.6613	.6749	.7280	.6565	.7472	1.0337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 202 / 11 kv Yerali Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18
HR	Load (MW)
13	.6478
14	.4954
15	.4954
Max	.6478
Min	.4954
Avg	.5462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 203 / 11 kv Nimgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	1.0185	.8749	1.0498	.9808	.9175	.905
2	.9877	.9431	.8745	1.0029	.9431	.8421	.8688
3	.9877	.9431	.8421	1.0136	.9431	.8192	.8688
4	.9145	.8676	.7449	.9774	.9431	.7537	.8326
5	.8688	.8676	.6154	.9313	.9808	.7209	.788
6	.7783	.8299	.6478	.905	.7922	.7865	.7522
7	.7421	.7167	.6554	.7602	.7545	.6554	.6516
8	.724	.7167	.6154	.6805	.724	.5937	.5731
9	.6878	.3887	.7922	.6802	.6805	.7545	.6226
10	.7602	.6154	.8299	.7125	.724	.7922	.6478
11	.7602	.6802	.9054	.7865	.7964	.8299	.6802
12	.8413	.8421	.9431	.8421	.8688	.8299	
13	.8688	.7773	.9808	.8848	.9145	.8299	.4534
14	.8688	.8097	1.0185	.9175	.9877	.8676	.4858
15	.7164	.8097	.9808	.9069	.9671	.9054	.6154
16	.8238	.8421	.905	.8745	.9313	.8688	.9412
17	.9431	.8097	.905	.9808		.8688	.9313
18	1.0185	.8745	.8326	1.0562		.8238	
19	1.0562	.9069	.9774	1.1694	.7773	.8596	1.0745
20	1.2449	1.0364	1.2308	1.2449	1.1012	1.0029	1.3032
21	1.1694	1.1012	1.2308	1.2071	1.0688	1.0608	1.2308
22	1.1317	1.1012	1.2178	1.094	1.0364	.9671	1.1706
23	1.0562	1.0364	1.1104	1.0185	1.004	.9412	1.0387
24	1.0608	1.0185	.9717	1.0498	.9431	.9717	.905
Max	1.2449	1.1012	1.2308	1.2449	1.1012	1.0608	1.3032
Min	.6878	.3887	.6154	.6802	.6805	.5937	.4534
Avg	.9166	.8564	.9043	.9478	.9029	.8443	.8337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 204 / 11 kv Nimgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202		1.0059		1.2125	1.2803
2		.7468		.9755		1.2125	1.2803
3		.7468		.9511		1.1984	1.3108
4		.7468		1.0402		1.3108	1.3413
5		.8002		1.0997		1.3763	1.3717
6		.8002		1.1584		1.4419	1.4022
7		.8802					
8		1.2269					
9		1.4899			1.5242		
10	1.3108		1.3336				
11	1.2803		1.467		1.6766		
12	1.3717		1.387		1.6766		
13	1.2803		1.3603		1.5546		
14	1.0974		1.1736		1.7909		
15	1.0402		.5601		1.4327		
16	1.0402		1.0364		1.4937		
17	.9602		1.1888				
21						1.2186	
22					1.0688	1.576	
23					1.2308	1.2803	
24		.7202		1.0059		1.1984	1.2803
Max	1.3717	1.4899	1.467	1.1584	1.7909	1.576	1.4022
Min	.9602	.7202	.5601	.9511	1.0688	1.1984	1.2803
Avg	1.1726	.8878	1.1884	1.0338	1.4943	1.3026	1.3238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 205 / 11 kv Alampur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2263	.2267	.2926	.2641	.2591	.2561
2	.3109	.2263	.2267	.2926	.2263	.2267	.2561
3	.3077	.2263	.2187	.2926	.2263	.2187	.2561
4	.2896	.2263	.1943	.2926	.2263	.2294	.2561
5	.2896	.2263	.2267	.2926	.2263	.2294	.2561
6	.2715	.2641	.2294	.2561	.2641	.2294	.2561
7	.2172	.2641	.1966	.1829	.2263	.1966	.2195
8	.2172	.1886	.1875	.2195	.2263		.1829
9	.1829	.1562	.2263	.1875	.1463		.1619
10	.1829	.1619	.2263	.2294	.2195		.1875
11	.2195	.1875	.2641	.2267	.2195		
12	.2195	.2591	.3018	.25	.2926		.2267
13	.2926	.25	.3018	.2915	.2926		.2591
14	.2561	.2591	.3018	.2915	.2926		.25
15	.2926	.2622	.3018	.2915	.2926		.25
16	.2507	.25	.2926	.2591	.2926	.3292	.2926
17	.2641	.2591	.2561	.2641		.2926	.2926
18	.2641	.2267	.2561	.3018		.2926	
19	.2641	.25	.2561	.3395	.2591	.2926	.2926
20	.3772	.2915	.3658	.3395	.3563	.2926	.3658
21	.3395	.2915	.362	.3772	.3239	.3292	.3292
22	.2641	.2915	.3658	.3395	.2915	.2926	.3292
23	.2263	.2915	.2926	.3018	.2591	.2926	.2926
24	.3109	.2263	.2591	.2926	.3018	.2591	.2926
Max	.3772	.2915	.3658	.3772	.3563	.3292	.3658
Min	.1829	.1562	.1875	.1829	.1463	.1966	.1619
Avg	.2676	.2401	.2640	.2794	.2603	.2664	.2619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 207 / 11 KV INCOMER NO2

Feeder KV- 11 / INCOMING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.381	1.0669	.4572	.5868	.6478	.8383
2	.543	.2934	.9907	.4572	.5868	.6478	.8383
3	.543	.2934	.9526	.4572	.5868	.6097	.8383
4	.543	.2934	.9145	.4572	.5868	.6859	.8383
5	.5973	.2934	.8383	.4954	.6401	.724	.8383
6	.7783	.2934	.8764	.4954	.6935	.8002	.8383
7	1.086	.3734	.9907				
8	.8326	.5068	1.2193				
9	.9526	.7621	.5601	1.1812	1.105		1.5242
10	.5716	1.3336	.5601	1.3336	1.1812		1.6385
11	.724	1.166	.5068	1.3717	1.0669		1.7147
12	.6478	1.3336	.5068	1.3717	.1905	.2934	1.6766
13	.6478	1.2574	.4801	1.3336	.8764	.6401	1.6004
14	.4954	1.1431	.4534	1.3336	.9145	.9602	1.5242
15	.4954	1.0288	.5068	1.2955	.9526	1.1203	1.4861
16	.4954	1.1431	.5716	1.2193	.9526	1.2003	1.6004
17	.3734	1.1812	.6097			1.4861	
18						1.448	
21				.5601		.724	1.2193
22				.5335	.6097	.9145	1.4098
23				.5868	.6859	.8764	1.3336
24	.4706	.2667	1.1431	.4191	.5868	.6478	.8764
Max	1.086	1.3336	1.2193	1.3717	1.1812	1.4861	1.7147
Min	.3734	.2667	.4534	.4191	.1905	.2934	.8383
Avg	.6300	.7413	.7638	.8533	.7531	.8486	1.2574