

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 201 / 11 kv Aurangapura Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6095    | 1.6827    | 1.6991    | 1.4003    | 1.7737    | 1.4937    | 1.7177    |
| 2    | 1.5546    | 1.6827    | 1.643     | 1.307     |           | 1.4937    | 1.6057    |
| 3    | 1.4299    | 1.5708    | 1.587     | 1.4784    | 1.6057    | 1.5708    | 1.5089    |
| 4    | 1.3575    | 1.3306    | 1.4632    | 1.4784    | 1.5123    | 1.6804    | 1.4003    |
| 5    | 1.3213    | 1.3756    | 1.531     | 1.6804    | 1.587     | 1.6804    | 1.4563    |
| 6    | 1.4415    | 1.4969    | 1.5497    | 1.6804    | 1.6244    | 1.7556    | 1.4815    |
| 7    | 1.5524    | 1.6817    | 1.643     | 1.7737    | 1.9239    | 1.7177    | 1.6461    |
| 8    | 1.6598    | 1.7558    | 1.7177    | 1.7737    | 1.8111    | 1.7737    | 1.6975    |
| 9    | 1.6057    | 1.7375    | 1.7551    | 1.8298    | 1.7364    | 1.7924    | 1.6804    |
| 10   | 1.6804    | 1.773     | 1.8673    | 1.5655    | 1.922     | 1.7556    | 1.7556    |
| 11   | 2.1098    | 2.4331    | 3.0178    | 2.4143    | 2.4764    | 2.3339    | 2.2731    |
| 12   | 2.5393    | 2.6972    | 2.6783    | 2.7349    | 2.838     | 2.7446    | 2.5133    |
| 13   | 2.4646    | 2.6406    | 2.6406    | 2.7538    | 2.894     | 2.6886    | 2.6139    |
| 14   | 2.5019    | 2.6217    | 2.6406    | 2.7726    | 2.7721    | 2.7633    | 2.6699    |
| 15   | 2.4691    | 2.6783    | 2.8858    | 2.9047    | 2.9313    | 2.8006    | 2.8006    |
| 16   | 2.7073    | 2.7446    | 2.8292    | 3.0933    | 2.9874    | 2.9313    | 2.8753    |
| 17   | 2.6797    | 2.8669    | 2.9569    | 2.9874    | 3.0807    | 2.9687    | 2.894     |
| 18   | 2.7721    | 2.6155    | 2.9569    | 2.9014    | 2.9874    | 2.838     | 2.9874    |
| 19   | 2.7905    | 3.2301    | 3.2341    | 3.2895    | 3.2341    | 3.2301    | 2.9938    |
| 20   | 3.1232    | 3.0727    | 3.2922    | 3.2895    |           | 3.4541    |           |
| 21   | 2.9384    | 2.9127    | 3.1093    | 3.0123    | 2.4272    | 3.0994    | .9522     |
| 22   | 2.4209    | 2.3954    | 2.6139    | 2.4579    | 2.7446    | 2.6886    | 2.4272    |
| 23   | 1.9387    | 2.0538    | 2.1845    | 2.0538    | 2.0911    | 1.9044    | 2.2405    |
| 24   | 1.7193    | 1.7741    | 1.7737    | 1.6804    | 1.8298    | 1.7556    | 1.8861    |
| Max  | 3.1232    | 3.2301    | 3.2922    | 3.2895    | 3.2341    | 3.4541    | 2.9938    |
| Min  | 1.3213    | 1.3306    | 1.4632    | 1.307     | 1.5123    | 1.4937    | .9522     |
| Avg  | 2.0995    | 2.201     | 2.3029    | 2.2631    | 2.3087    | 2.2881    | 2.0903    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0911    | 2.2218    | 2.1098    | 1.6804    | 2.2481    | 1.848     | 2.2634    |
| 2    | 1.9044    | 1.989     | 2.0725    | 1.6632    | 2.0911    | 1.848     | 1.8858    |
| 3    | 1.8484    | 2.0538    | 1.8296    | 1.848     | 2.0538    | 1.9605    | 1.7737    |
| 4    | 1.8484    | 1.8671    | 1.7737    | 1.8671    | 2.1125    | 1.9404    | 1.8671    |
| 5    | 1.8111    | 1.8858    | 1.8298    | 2.0538    | 2.1502    | 2.2177    | 1.9418    |
| 6    | 1.9239    | 2.8292    | 1.8858    | 2.0538    | 2.2032    | 2.2405    | 1.9753    |
| 7    | 1.9993    | 2.2634    | 1.9605    | 2.1472    | 2.2032    | 2.0911    | 2.0485    |
| 8    | 1.9993    | 2.2779    | 2.0725    | 2.2405    | 2.4272    | 2.2177    | 2.0668    |
| 9    | 1.957     | 2.3712    | 2.0725    | 2.2405    | 2.5206    | 2.2361    | 2.2592    |
| 10   | 2.1582    | 2.7726    | 2.5274    | 2.6783    | 2.8753    | 2.6513    | 2.5206    |
| 11   | 2.3339    | 3.0744    | 3.0178    | 3.131     | 3.3421    | 3.0994    | 2.8567    |
| 12   | 2.4086    | 3.1687    | 3.263     | 3.2253    | 3.4915    | 3.1927    | 2.8645    |
| 13   | 2.4646    | 3.131     | 3.1876    | 3.263     | 3.3794    | 3.006     | 2.9874    |
| 14   | 2.3712    | 3.0556    | 3.131     | 3.263     | 3.2487    | 3.0807    | 3.0807    |
| 15   | 2.3899    | 2.999     | 3.131     | 3.2442    | 3.2301    | 3.1741    | 3.2861    |
| 16   | 2.3954    | 2.963     | 3.2819    | 3.3196    | 3.2674    | 3.1927    |           |
| 17   | 2.4272    | 3.0556    | 3.1741    | 3.3196    | 3.3608    | 3.3048    | 2.6139    |
| 18   | 2.6513    | 2.9687    | 3.1741    | 3.2895    | 3.2674    | 3.0247    | 2.2405    |
| 19   | 2.8193    | 3.3105    | 3.3634    | 3.5475    | 3.3265    | 3.4705    | 1.7364    |
| 20   | 2.9313    | 3.3608    | 3.5482    | 3.5101    | 3.5101    | 3.4915    | 2.7905    |
| 21   | 2.7633    | 3.1121    | 3.5113    | 3.0807    | 3.1741    | 3.1741    | 2.8829    |
| 22   | 2.5206    | 2.5463    | 3.1417    | 2.7633    | 2.7446    | 2.8006    | 2.6139    |
| 23   | 2.4459    | 2.4272    | 2.6699    | 2.5393    | 2.5393    | 2.5766    | 2.4272    |
| 24   | 3.4662    | 2.2218    | 2.2032    | 1.9605    | 2.452     | 2.3339    | 2.3152    |
| Max  | 3.4662    | 3.3608    | 3.5482    | 3.5475    | 3.5101    | 3.4915    | 3.2861    |
| Min  | 1.8111    | 1.8671    | 1.7737    | 1.6632    | 2.0538    | 1.848     | 1.7364    |
| Avg  | 2.3304    | 2.6636    | 2.6638    | 2.6637    | 2.8008    | 2.6739    | 2.4043    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 203 / 11 kv city chowk feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2323    | 1.4045    | 1.307     | 1.1203    | 1.2696    | 1.1203    | 1.2696    |
| 2    | 1.1523    | 1.2936    | 1.1888    | 1.0269    | 1.2384    | 1.1203    | 1.1389    |
| 3    | 1.0974    | 1.1088    | 1.2696    | 1.0269    | 1.1389    | 1.1203    | 1.0829    |
| 4    | 1.0974    | 1.1088    | 1.2696    | 1.1203    | 1.1203    | 1.2012    | .9808     |
| 5    | 1.0791    | 1.1157    | 1.3443    | 1.1088    | 1.1694    | 1.2136    | 1.0829    |
| 6    | 1.1273    | 1.1643    | 1.3676    | 1.307     | 1.1949    | 1.307     | 1.251     |
| 7    | 1.2136    | 1.2883    | 1.3817    | 1.4003    | 1.3817    | 1.4377    | 1.4003    |
| 8    | 1.3014    | 1.3817    |           | 1.4937    | 1.3817    | 1.4937    | 1.419     |
| 9    | 1.531     | 1.4563    | 1.4937    | 1.4969    | 1.4937    | 1.5684    | 1.475     |
| 10   | 1.5466    | 1.6032    | 1.5278    | 1.6598    | 1.5089    | 1.7737    | 1.587     |
| 11   | 1.5497    | 1.6598    | 1.6598    | 1.6409    | 1.6221    | 1.7177    | 1.6244    |
| 12   | 1.587     | 1.5466    | 1.6598    | 1.7541    | 1.6804    | 1.8107    | 1.6617    |
| 13   | 1.4632    | 1.6221    | 1.6221    | 1.7541    | 1.5844    | 1.8107    | 1.6057    |
| 14   | 1.3817    | 1.5089    | 1.4712    | 1.5655    | 1.4523    | 1.6598    | 1.587     |
| 15   | 1.2003    | 1.4146    | 1.4146    | 1.4901    | 1.3014    | 1.3957    | 1.4563    |
| 16   | 1.2449    | 1.3169    | 1.3392    | 1.4901    | 1.2136    | 1.307     |           |
| 17   | 1.6461    | 1.4632    | 1.386     | 1.5497    | 1.307     | 1.4901    | 1.6804    |
| 18   | 1.6461    | 1.4998    | 1.4937    | 1.5089    | 1.587     | 1.4523    | 1.6632    |
| 19   | 1.7741    | 1.6095    | 1.6632    | 1.7541    | 1.7556    | 1.6409    | 1.6991    |
| 20   | 1.7741    | 1.829     | 1.7556    | 1.8671    | 1.8111    | 1.7737    | .9335     |
| 21   | 1.5893    | 1.7353    | 1.6804    |           | 1.7737    | 1.6461    | 1.6632    |
| 22   | 1.5339    | 1.7353    | 1.4937    | 1.5524    | 1.7551    | 1.5684    | 1.6804    |
| 23   | 1.4784    | 1.587     | 1.4377    | 1.4563    | 1.5123    | 1.4901    | 1.5123    |
| 24   | 1.307     | 1.4045    | 1.3717    | 1.307     | 1.3392    | 1.307     | 1.3443    |
| Max  | 1.7741    | 1.829     | 1.7556    | 1.8671    | 1.8111    | 1.8107    | 1.6991    |
| Min  | 1.0791    | 1.1088    | 1.1888    | 1.0269    | 1.1203    | 1.1203    | .9335     |
| Avg  | 1.3981    | 1.4524    | 1.4608    | 1.4544    | 1.4414    | 1.4761    | 1.4260    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 204 / 11 KV bus stand Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3392    | 1.4146    | 1.307     | 1.307     | 1.4335    | 1.307     | 1.3717    |
| 2    | 1.2449    | 1.3203    | 1.2136    | 1.2012    | 2.1125    | 1.307     | 1.307     |
| 3    | 1.1883    | 1.3203    | 1.1317    | 1.2136    | 1.2826    | 1.4003    | 1.2323    |
| 4    | 1.1763    | 1.226     | 1.1203    | 1.307     | 1.3717    | 1.4003    | 1.2696    |
| 5    | 1.1949    | 1.226     | 1.1949    | 1.307     | 1.3817    | 1.4937    | 1.2696    |
| 6    | 1.2883    | 1.358     | 1.2883    | 1.4003    | 1.5089    | 1.4784    | 1.4003    |
| 7    | 1.2449    | 1.4901    | 1.307     | 1.4377    |           | 1.4045    | 1.2986    |
| 8    | 1.2696    | 1.5123    | 1.3256    | 1.4937    | 1.5655    | 1.4937    | 1.2803    |
| 9    | 1.3203    | 1.6057    | 1.4563    | 1.5684    | 1.6221    | 1.5708    | 1.4523    |
| 10   | 1.4003    | 1.905     | ***       | 1.8107    |           | 1.7364    | 1.7551    |
| 11   | 1.4563    | 1.9427    | 1.8107    | 1.9993    | 2.0165    | 1.9044    | 1.8111    |
| 12   | 1.5123    | 2.0936    | 1.8673    | 1.9616    | 2.0165    | 1.9418    | 1.7177    |
| 13   | 1.4377    | 1.773     | 1.8107    | 1.8673    | 1.9231    | 1.8671    | 1.7918    |
| 14   | 1.363     | 1.7541    | 1.8484    | 1.8861    | 1.8861    | 1.9044    | 1.8296    |
| 15   | 1.3256    | 1.8296    | 1.8673    | 1.8861    | 1.8671    | 1.9022    | 1.8673    |
| 16   | 1.3203    | 1.7741    | 1.9993    | 1.9805    | 1.848     | 1.9044    | 1.7924    |
| 17   | 1.4937    | 1.829     | 1.848     | 1.9231    | 1.7364    | 1.8861    | 1.6632    |
| 18   | 1.4937    | 1.829     | 1.848     |           | 1.8298    | 1.8484    | 1.4937    |
| 19   | 1.6244    | 1.9022    | 1.848     | 1.9959    | 1.848     | 1.8861    | 1.4377    |
| 20   | 1.6244    | 1.8839    | 1.9035    | 2.0165    | 1.885     | 1.8858    | 1.7364    |
| 21   | 1.587     | 1.7737    | 1.848     | 1.8671    | 1.8671    | 1.8298    | 1.6804    |
| 22   | 1.6057    | 1.6804    | 1.8671    | 1.7364    | 1.7551    | 1.8111    | 1.6804    |
| 23   | 1.5278    | 1.6057    | 1.6817    | 1.6244    | 1.6057    | 1.6804    | 1.587     |
| 24   | 1.4563    | 1.4146    | 1.3769    | 1.587     | 1.4712    | 1.4937    | 1.4937    |
| Max  | 1.6244    | 2.0936    | 17.56     | 2.0165    | 2.1125    | 1.9418    | 1.8673    |
| Min  | 1.1763    | 1.226     | 1.1203    | 1.2012    | 1.2826    | 1.307     | 1.2323    |
| Avg  | 1.3956    | 1.6443    | 2.2637    | 1.6686    | 1.7197    | 1.6807    | 1.5508    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 205 / 11 KV VASANT BHUVAN FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.448     | 1.448     | 1.531     | 1.4003    | 1.4937    | 1.386     | 1.5684    |
| 2    | 1.3756    | 1.3575    | 1.4712    | 1.4003    | 1.419     | 1.4003    | 1.4937    |
| 3    | 1.267     | 1.2437    | 1.4003    | 1.4003    | 1.307     | 1.307     | 1.4003    |
| 4    | 1.267     | 1.2803    | 1.2696    | 1.4937    | 1.3527    | 1.307     | 1.2826    |
| 5    | 1.2489    | 1.267     | 1.307     | 1.4784    | 1.3957    | 1.4937    | 1.307     |
| 6    | 1.262     | 1.3535    | 1.3817    | 1.587     | 1.475     | 1.4937    | 1.3256    |
| 7    | 1.3491    | 1.5524    | 1.5466    | 1.587     | 1.5684    | 1.5123    | 1.3256    |
| 8    | 1.5123    | 1.5339    | 1.419     | 1.6804    | 1.5089    | 1.587     | 1.4377    |
| 9    | 1.5364    | 1.5154    | 1.5123    | 1.7177    | 1.531     | 1.5893    | 1.5497    |
| 10   | 1.643     | 1.5844    | 1.5089    | 1.6409    | 1.5339    | 1.5708    | 1.4415    |
| 11   | 1.6461    | 1.5278    | 1.5844    | 1.6032    | 1.6632    | 1.7002    | 1.5708    |
| 12   | 1.7177    | 1.5089    | 1.7353    | 1.7353    | 1.7187    | 1.8296    | 1.5708    |
| 13   | 1.6975    | 1.773     | 1.5844    | 1.7541    | 1.701     | 1.6461    | 1.6632    |
| 14   | 1.587     | 1.7541    | 1.7353    | 1.7918    | 1.6817    | 1.5912    | 1.7556    |
| 15   | 1.643     |           | 1.6598    | 1.773     | 1.7187    | 1.5546    | 1.6632    |
| 16   | 1.6057    | 1.6095    | 1.7164    | 1.773     | 1.6461    | 1.6617    |           |
| 17   | 1.6461    | 1.6095    | 1.7556    | 1.7375    | 1.7741    | 1.6804    | 1.8671    |
| 18   | 1.848     | 1.7375    | 1.848     | 1.828     | 1.9231    | 1.7918    | 1.8671    |
| 19   | 1.9909    | 1.957     | 2.0328    | 2.0271    | 1.9404    | 2.0538    | 1.9959    |
| 20   | 1.9004    | 2.1472    | 2.0883    | 2.0851    | 2.1472    | 2.0538    | 1.9231    |
| 21   | 1.8461    | 2.0538    | 2.0328    | 1.9728    | 2.1472    | 1.9791    | 2.0165    |
| 22   | 1.6289    | 1.8839    | 1.8671    | 1.7918    | 2.0538    | 1.773     | 1.7737    |
| 23   | 1.6095    | 1.9044    | 1.6804    | 1.7177    | 1.8111    | 1.6644    | 1.643     |
| 24   | 1.5729    | 1.5384    | 1.6244    | 1.4937    | 1.6244    | 1.587     | 1.6221    |
| Max  | 1.9909    | 2.1472    | 2.0883    | 2.0851    | 2.1472    | 2.0538    | 2.0165    |
| Min  | 1.2489    | 1.2437    | 1.2696    | 1.4003    | 1.307     | 1.307     | 1.2826    |
| Avg  | 1.5770    | 1.6148    | 1.6372    | 1.6863    | 1.6723    | 1.6339    | 1.6115    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 207 / ATM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0067     | .0065     | .0114     | .0133     | .0114     | .0111     | .0189     |
| 2    | .0069     | .0069     | .0187     | .013      | .0171     | .012      | .0187     |
| 3    | .0124     | .0069     | .0133     | .0107     | .0133     | .0135     | .0183     |
| 4    | .0131     | .0093     | .0171     | .0111     | .0095     | .0124     | .0114     |
| 5    | .0069     | .0059     | .0181     | .0131     | .0133     | .0118     | .0114     |
| 6    | .0124     | .0053     | .0191     | .0154     | .0171     | .0126     | .0133     |
| 7    | .0152     | .0086     | .0114     | .0124     | .0133     | .012      | .0095     |
| 8    | .0114     | .013      | .0187     | .0162     | .0133     | .0107     | .0152     |
| 9    | .0133     | .0133     | .0187     | .0124     | .0114     | .0124     | .0114     |
| 10   | .0187     | .0377     | .0189     | .0189     | .0332     | .0128     | .0151     |
| 11   | .0187     | .0377     | .0189     | .0189     | .0137     | .0168     | .0362     |
| 12   | .0175     | .0377     | .0566     | .0377     | .0377     | .0137     | .0139     |
| 13   | .0152     | .0189     | .0189     | .0189     | .0116     | .0069     | .037      |
| 14   | .0171     | .0189     | .0189     | .0377     | .0373     | .0133     | .037      |
| 15   | .0171     | .0377     | .0189     | .0377     | .0189     | .0143     | .0366     |
| 16   | .0171     | .0183     | .0189     | .0189     | .0377     | .0187     | .0139     |
| 17   | .0143     | .0183     | .0124     | .0354     | .0145     | .0189     | .0164     |
| 18   | .013      | .0183     | .0137     | .0377     | .0141     | .0189     | .0131     |
| 19   | .0107     | .0183     | .0131     | .0131     | .0135     | .0114     | .0107     |
| 20   | .0124     | .0183     | .0124     | .0103     | .0149     | .0187     | .0137     |
| 21   | .0111     | .0171     | .0124     | .009      | .0124     | .0187     | .0131     |
| 22   | .0164     | .0183     | .0131     | .012      | .0124     | .0114     | .0141     |
| 23   | .0051     | .0133     | .0145     | .0187     | .012      | .0189     | .0124     |
| 24   | .0067     | .0065     | .0171     | .0137     | .0189     | .0124     | .0171     |
| Max  | .0187     | .0377     | .0566     | .0377     | .0377     | .0189     | .037      |
| Min  | .0051     | .0053     | .0114     | .009      | .0095     | .0069     | .0095     |
| Avg  | .0129     | .0171     | .0177     | .0190     | .0176     | .0139     | .0179     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 208 / Medical(jublipark water  
works) Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0263     | .0343     | .0343     | .037      | .0343     | .0373     | .0343     |
| 2    | .0263     | .0339     | .0267     | .0373     | .0162     | .0377     | .0377     |
| 3    | .0259     | .0343     | .0351     | .0373     | .0373     | .0373     | .0373     |
| 4    | .0263     | .0351     | .0343     | .0377     | .0351     | .0373     | .0343     |
| 5    | .0566     | .0566     | .0343     | .0377     | .0566     | .0377     | .0351     |
| 6    | .0566     | .0339     | .0362     | .0373     | .0566     | .0377     | .0566     |
| 7    | .0566     | .0343     | .056      | .0377     | .056      | .0377     | .056      |
| 8    | .056      | .0347     | .0566     | .0377     | .056      | .0566     | .0549     |
| 9    | .0373     | .0351     |           | .0373     | .056      | .0566     | .056      |
| 10   | .0366     |           | .0377     | .0377     | .0351     | .0347     | .0351     |
| 11   | .056      | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     |
| 12   | .056      | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     |
| 13   | .056      | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     |
| 14   | .056      | .0566     | .0566     | .0189     | .0566     | .0566     | .0566     |
| 15   | .056      | .0566     | .0566     | .0377     | .0566     | .0566     | .0566     |
| 16   | .056      | .056      | .0566     | .0566     | .0566     | .056      |           |
| 17   | .0566     | .056      | .056      | .0566     | .0566     | .0566     | .056      |
| 18   | .0566     | .056      | .0566     | .0566     | .056      | .0566     | .0566     |
| 19   | .0566     | .056      | .0566     | .0566     | .0566     | .0343     | .056      |
| 20   | .056      | .056      | .0566     | .0566     | .0566     | .0566     | .0377     |
| 21   | .056      | .056      | .0566     | .0566     | .0566     | .0566     | .0377     |
| 22   | .0566     | .056      | .0554     | .0566     | .056      | .056      | .0373     |
| 23   | .0255     | .056      | .0566     | .056      | .0373     | .056      | .0377     |
| 24   | .0259     | .0566     | .0514     | .0373     | .056      | .0373     | .0373     |
| Max  | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     |
| Min  | .0255     | .0339     | .0267     | .0189     | .0162     | .0343     | .0343     |
| Avg  | .0471     | .0487     | .0494     | .0454     | .0504     | .0483     | .0468     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 201 / UNIVERSITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .037      | .037      | .0381     | .037      | .0187     | .037      | .0373     |
| 2    | .037      | .037      | .0191     | .0185     | .0187     | .037      | .0373     |
| 3    | .037      | .037      | .0191     | .0185     | .0187     | .0185     | .0187     |
| 4    | .0185     | .0185     | .0191     | .0185     | .0187     | .0185     | .0187     |
| 5    | .0185     | .0185     | .0191     | .0185     | .0373     | .0185     | .0187     |
| 6    | .0185     | .0185     | .0191     | .0185     | .0187     | .0185     | .0187     |
| 7    | .0185     | .0185     | .0191     | .0185     | .0187     | .0185     | .0187     |
| 8    | .0185     | .0185     | .0191     | .0185     | .0187     | .0185     | .0187     |
| 9    | .0373     | .0747     | .0572     | .0554     | .0554     | .037      | .0381     |
| 10   | .0381     | .1307     | .1307     | .1478     | .1494     | .1254     | .0554     |
| 11   | .0762     | .2241     | .2241     | .2033     | .1991     | .1867     | .1848     |
| 12   | .1143     | .2241     | .2241     | .2402     | .2241     | .2054     | .1848     |
| 13   | .1524     | .2241     | .2241     | .2772     | .2614     | .2054     | .2033     |
| 14   | .1524     | .2054     | .1867     | .2772     | .2614     | .2033     | .2033     |
| 15   | .1334     | .2241     | .2195     | .2772     | .2614     | .2054     | .2218     |
| 16   | .1524     | .2427     | .2241     | .2772     | .2427     | .2241     | .2587     |
| 17   | .1307     | .1905     | .2241     | .2427     | .2033     | .2054     | .1848     |
| 18   | .0739     | .1334     | .1494     | .112      | .1294     | .1867     |           |
| 19   | .0549     | .1143     | .0924     | .0934     | .0739     | .112      |           |
| 20   | .0549     | .0572     | .0554     | .0747     | .0554     | .0562     |           |
| 21   | .0554     | .0381     | .0554     | .056      | .0554     | .0373     |           |
| 22   | .0549     | .0381     | .056      | .0373     | .0554     | .0373     |           |
| 23   | .037      | .0381     | .0373     | .0373     | .0554     | .0373     |           |
| 24   | .037      | .037      | .0381     | .037      | .0373     | .037      | .0187     |
| Max  | .1524     | .2427     | .2241     | .2772     | .2614     | .2241     | .2587     |
| Min  | .0185     | .0185     | .0191     | .0185     | .0187     | .0185     | .0187     |
| Avg  | .0649     | .1000     | .0988     | .1089     | .1037     | .0953     | .0967     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 202 / MAQBARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4209    | 2.4579    | 2.4958    | 2.524     | 2.5766    | 2.5133    | 2.4646    |
| 2    | 2.1992    | 2.4025    | 2.6101    | 2.4764    | 2.5206    | 2.4764    | 2.4272    |
| 3    | 2.1068    | 2.3101    | 2.5149    | 2.4764    | 2.4272    | 2.4394    | 2.4086    |
| 4    | 2.1992    | 2.4209    | 2.4768    | 2.5133    | 2.3899    | 2.4025    | 2.3899    |
| 5    | 2.2916    | 2.5318    | 2.5766    | 2.5873    | 2.3339    | 2.4764    | 2.4272    |
| 6    | 2.347     | 2.5873    | 2.6139    | 2.5972    | 2.6699    | 2.5503    | 2.6513    |
| 7    | 2.4579    | 2.6427    | 2.7073    | 2.6337    | 2.5953    | 2.8275    | 2.7633    |
| 8    | 2.5873    | 2.7536    | 2.7446    | 2.7166    | 2.6513    | 2.8275    | 2.6513    |
| 9    | 2.8578    | 2.5766    | 2.7244    | 2.7351    | 2.7721    | 2.8275    | 2.7625    |
| 10   | 2.6482    | 2.4646    | 2.3712    | 2.5688    | 2.6242    | 2.8645    | 2.6427    |
| 11   | 2.3624    | 2.2218    | 2.3525    | 2.3655    | 2.4394    | 2.6981    | 2.347     |
| 12   | 2.2862    | 2.3339    | 2.3525    | 2.3655    | 2.2862    | 2.5133    | 2.3655    |
| 13   | 2.0767    | 2.2965    | 2.2779    | 2.2916    | 2.2314    | 2.4025    | 2.3655    |
| 14   | 2.0957    | 2.0351    | 2.0538    | 2.0883    | 2.1216    | 2.1216    | 2.1437    |
| 15   | 2.2862    | 2.0351    | 2.0119    | 2.0698    | 2.0668    | 2.0351    | 2.0883    |
| 16   | 2.4006    | 2.3712    | 2.0485    | 1.9774    | 2.0883    | 2.0538    | 2.1807    |
| 17   | 2.3594    | 2.4958    | 2.0851    | 2.2218    | 2.2546    | 2.0725    | 1.829     |
| 18   | 2.4143    | 2.6139    | 2.1033    | 2.4459    | 2.4394    | 2.3152    |           |
| 19   | 2.8416    | 2.8387    | 2.652     | 3.0434    | 2.9384    | 2.6699    | 2.8166    |
| 20   | 2.8166    | 3.1245    | 3.0178    | 2.7633    | 3.0493    | 2.9874    | 3.0178    |
| 21   | 2.7435    | 2.9874    | 2.6787    | 2.782     | 2.7536    | 2.9687    | 2.8532    |
| 22   | 2.6063    | 2.7816    | 2.6703    | 2.7633    | 2.7166    | 2.7073    | 2.7166    |
| 23   | 2.6612    |           | .5544     | 2.7073    | 2.7905    | 2.4646    | 2.7069    |
| 24   | 2.5503    | 2.5873    | 2.6292    | 2.5606    | 2.6139    | 2.6242    | 2.5953    |
| Max  | 2.8578    | 3.1245    | 3.0178    | 3.0434    | 3.0493    | 2.9874    | 3.0178    |
| Min  | 2.0767    | 2.0351    | .5544     | 1.9774    | 2.0668    | 2.0351    | 1.829     |
| Avg  | 2.4424    | 2.5161    | 2.3885    | 2.5114    | 2.5146    | 2.5350    | 2.5050    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 203 / SAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2614     | .2427     | .2427     | .2452     | .2801     | .2614     | .2614     |
| 2    | .2241     | .2241     | .2427     | .2452     | .2614     | .2614     | .2241     |
| 3    | .2054     | .2054     | .2241     | .2263     | .2427     | .2427     | .2427     |
| 4    | .2054     | .2054     | .2241     | .2263     | .2427     | .2241     | .2614     |
| 5    | .2054     | .2241     | .2241     | .2075     | .2241     | .2054     | .2614     |
| 6    | .2054     | .2241     | .2427     | .1886     | .2427     | .2054     | .2801     |
| 7    | .2054     | .2241     | .2614     | .1886     | .2054     | .2427     | .2427     |
| 8    | .2241     | .2241     | .2987     | .2075     | .2054     | .2427     | .2614     |
| 9    | .2286     | .2241     | .2858     | .2452     | .2829     | .2614     | .2801     |
| 10   | .3429     | .3174     | .3547     | .3734     | .3772     |           | .4108     |
| 11   | .381      | .4481     | .4668     | .6348     | .4481     | .415      | .4481     |
| 12   | .362      | .4108     | .4854     | .4854     | .5093     | .4904     | .4854     |
| 13   | .3429     | .4481     | .5601     | .5228     | .4904     | .4904     | .5415     |
| 14   | .3429     | .3734     | .5228     | .4854     | .547      | .4527     | .4854     |
| 15   | .3048     | .3921     | .5658     | .5228     | .547      | .4854     | .4668     |
| 16   | .2801     | .4294     | .5281     | .5041     | .5093     | .4854     | .5041     |
| 17   | .3206     | .381      | .4904     | .4668     | .4854     | .4668     | .4338     |
| 18   | .2452     | .3048     | .7356     | .3174     | .3174     | .5041     | .2263     |
| 19   | .3018     | .2667     | .3239     | .3547     | .3734     | .4668     | .2641     |
| 20   | .3018     | .3429     | .3584     | .3547     | .3547     | .4108     | .3018     |
| 21   | .3018     | .3429     | .3395     | .3547     | .3361     | .3734     | .3206     |
| 22   | .3206     | .3174     | .3395     | .3361     | .3361     | .3547     | .3206     |
| 23   | .2801     | .2858     | .2829     | .3361     | .3361     | .3361     | .3206     |
| 24   | .2801     | .2801     | .2477     | .2641     | .2987     | .2801     | .3174     |
| Max  | .381      | .4481     | .7356     | .6348     | .547      | .5041     | .5415     |
| Min  | .2054     | .2054     | .2241     | .1886     | .2054     | .2054     | .2241     |
| Avg  | .2781     | .3058     | .3687     | .3456     | .3522     | .3548     | .3401     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 204 / LANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4854     | .5228     | .5041     | .4805     | .4294     | .4854     | .4108     |
| 2    | .4668     | .5041     | .4108     | .4435     | .4294     | .4668     | .4481     |
| 3    | .4294     | .4481     | .4108     | .4435     | .4481     | .4481     | .4294     |
| 4    | .4481     | .4668     | .4481     | .462      | .4481     | .4294     | .4481     |
| 5    | .4668     | .4854     | .4481     | .462      | .4668     | .4481     | .4108     |
| 6    | .4668     | .5041     | .4294     | .4805     | .5228     | .4668     | .4481     |
| 7    | .4294     | .4294     | .4668     | .4938     | .4668     | .4668     | .4854     |
| 8    | .3921     | .4481     | .4481     | .462      | .4108     | .3921     | .3734     |
| 9    | .3429     | .2801     | .4191     | .4251     | .3841     | .4108     | .3734     |
| 10   | .381      | .3921     | .3547     | .3174     | .3881     | .3696     | .3547     |
| 11   | .4191     | .3547     | .3734     | .3547     | .3696     | .3696     | .3547     |
| 12   | .4191     | .3547     | .3547     | .3734     | .3841     | .3511     | .3921     |
| 13   | .4001     | .3734     | .3361     | .3734     | .3881     | .3511     | .3547     |
| 14   | .4572     | .3921     | .3734     | .4108     | .3696     | .3696     | .3734     |
| 15   | .4191     | .4294     | .3881     | .4294     | .3881     | .3734     | .3881     |
| 16   | .4001     | .4294     | .4024     | .4251     | .4251     | .3734     | .3547     |
| 17   | .3881     | .4191     | .4024     | .4294     | .4108     | .3547     | .2587     |
| 18   | .3841     | .381      | .3658     | .4108     | .4108     | .3734     | .2957     |
| 19   | .4938     | .4572     | .499      | .4854     | .4854     | .4481     | .4066     |
| 20   | .5121     | .5144     | .5359     | .5041     | .5041     | .5415     | .4938     |
| 21   | .5121     | .5415     | .499      | .5228     | .5228     | .5228     | .5175     |
| 22   | .5359     | .5525     | .5359     | .5601     | .5415     | .5228     | .5175     |
| 23   | .5415     | .5335     | .5544     | .5415     | .5601     | .4854     | .5359     |
| 24   | .5228     | .5041     | .5144     | .499      | .5228     | .5415     | .5228     |
| Max  | .5415     | .5525     | .5544     | .5601     | .5601     | .5415     | .5359     |
| Min  | .3429     | .2801     | .3361     | .3174     | .3696     | .3511     | .2587     |
| Avg  | .4464     | .4466     | .4365     | .4496     | .4449     | .4318     | .4145     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 205 / 11 KV PANCHHKI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0349    | 1.0534    | 1.105     | 1.1273    | 1.1016    | 1.0903    | 1.1389    |
| 2    | .9979     | 1.0349    | 1.1431    | 1.1088    | 1.0829    | 1.0534    | 1.1203    |
| 3    | .9425     | 1.0164    | 1.1622    | 1.1088    | 1.0829    | 1.0349    | 1.0829    |
| 4    | 1.0349    | 1.0719    | 1.1812    | 1.1458    | 1.0642    | 1.0164    | 1.1016    |
| 5    | 1.0719    | 1.1458    | 1.1431    | 1.0608    | 1.0642    | 1.1458    | 1.1949    |
| 6    | 1.1458    | 1.2012    | 1.2574    | 1.1157    | 1.1763    | 1.2567    | 1.1203    |
| 7    | 1.5524    | 1.2752    | 1.2955    | 1.1643    | 1.2883    | 1.2752    | 1.643     |
| 8    | 1.2936    | 1.3121    | 1.3527    | 1.2437    | 1.307     | 1.3306    | 1.419     |
| 9    | 1.2384    | 1.2883    | 1.2955    | 1.2986    | 1.2254    | 1.2752    | 1.2574    |
| 10   | 1.1431    | 1.1576    | 1.1949    | 1.2012    | 1.1643    | 1.307     | 1.1088    |
| 11   | 1.1241    | 1.1389    | 1.0642    | 1.1088    | 1.1088    | 1.2382    | 1.0719    |
| 12   | 1.2003    | 1.0642    | 1.1203    | 1.0349    | 1.0903    | 1.1827    | 1.1273    |
| 13   | 1.1812    | 1.0082    | 1.0456    | .9979     | .9877     | 1.1458    | .9979     |
| 14   | 1.105     | .9896     | .9896     | .961      | .9425     | .9795     | .9795     |
| 15   | 1.0288    | .9335     | .9328     | .924      | .961      | .9709     | .9425     |
| 16   | .9526     | 1.0269    | .9511     | .9795     | .961      | 1.0082    | .924      |
| 17   | .9795     | 1.2193    | 1.0242    | .9896     | 1.1088    | .9896     | 1.0974    |
| 18   | 1.1157    | 1.2193    | 1.1643    | 1.0829    | 1.2197    | 1.1203    | 1.1643    |
| 19   | 1.4083    | 1.3146    | 1.4784    | 1.2883    | 1.4415    | 1.3443    | 1.3676    |
| 20   | 1.3491    | 1.4861    | 1.5339    | 1.2883    | 1.4415    | 1.3817    | 1.3121    |
| 21   | 1.2752    | 1.4098    | 1.3676    | 1.4563    | 1.2936    | 1.3256    | 1.2752    |
| 22   | 1.2254    | 1.3336    | 1.2986    | 1.307     | 1.2567    | 1.251     | 1.2012    |
| 23   | 1.1643    | 1.2955    | 1.1888    | 1.251     | 1.2197    |           | 1.1458    |
| 24   | 1.0903    | 1.0903    | 1.1812    | 1.1458    | 1.1203    | 1.1827    | 1.1016    |
| Max  | 1.5524    | 1.4861    | 1.5339    | 1.4563    | 1.4415    | 1.3817    | 1.643     |
| Min  | .9425     | .9335     | .9328     | .924      | .9425     | .9709     | .924      |
| Avg  | 1.1523    | 1.1703    | 1.1863    | 1.1413    | 1.1546    | 1.1698    | 1.1623    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 201 / Kohinoor

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2858     | .2667     | .3048     | .2667     | .3239     | .3048     | .3048     |
| 2    | .2858     | .2667     | .3048     | .2667     | .3048     | .3048     | .3048     |
| 3    | .2858     | .2667     | .2858     | .2667     | .3048     | .3048     | .3048     |
| 4    | .2858     | .2667     | .3048     | .3048     | .3048     | .3429     | .3048     |
| 5    | .3048     | .3048     | .3048     | .3429     | .3048     | .3429     | .3048     |
| 6    | .3239     | .3429     | .3048     | .381      | .3429     | .381      | .3429     |
| 7    | .3429     | .4001     | .362      | .4191     | .381      | .4191     | .381      |
| 8    | .381      | .4001     | .4191     | .4191     | .4191     | .4191     | .4191     |
| 9    | .4191     | .4001     | .4382     | .4191     | .4191     | .4191     | .381      |
| 10   | .4191     | .381      | .381      | .381      | .381      | .4191     | .3429     |
| 11   | .4191     | .3429     | .381      | .381      | .362      | .3429     | .3429     |
| 12   | .381      | .3429     | .381      | .381      | .3429     | .3429     | .3239     |
| 13   | .381      | .3048     | .3429     | .3429     | .3048     | .3239     | .3048     |
| 14   | .3429     | .3048     | .3429     | .3429     | .3048     | .3048     | .2858     |
| 15   | .3429     | .2667     | .3048     | .3048     | .2858     | .2286     | .2858     |
| 16   | .3048     | .2667     | .3048     | .3048     | .2858     | .3048     | .3048     |
| 17   | .3429     | .3048     | .3429     | .3429     | .3048     | .3048     | .362      |
| 18   | .362      | .3239     | .362      | .381      | .3429     | .3429     | .381      |
| 19   | .3429     | .381      | .381      | .4191     | .4191     | .4191     | .4001     |
| 20   | .3429     | .362      | .381      | .381      | .381      | .4191     | .381      |
| 21   | .3429     | .3429     | .3429     | .3429     | .3429     | .3429     | .362      |
| 22   | .3048     | .3429     | .3239     | .3429     | .3429     | .3429     | .3429     |
| 23   | .3048     | .3239     | .3048     | .3239     | .3429     | .3429     | .3239     |
| 24   | .3048     | .3048     | .3239     | .3048     | .3239     | .3429     | .3429     |
| Max  | .4191     | .4001     | .4382     | .4191     | .4191     | .4191     | .4191     |
| Min  | .2858     | .2667     | .2858     | .2667     | .2858     | .2286     | .2858     |
| Avg  | .3397     | .3255     | .3429     | .3485     | .3405     | .3485     | .3389     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 202 / Ghati Medical Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4191     | .381      | .4191     | .4191     | .381      | .4191     | .4572     |
| 2    | .4191     | .3429     | .4001     | .4191     | .381      | .0381     | .4191     |
| 3    | .4001     | .3429     | .381      | .381      | .381      | .4191     | .4191     |
| 4    | .4191     | .3429     | .381      | .381      | .381      | .4191     | .4191     |
| 5    | .4191     | .3429     | .381      | .381      | .381      | .4191     |           |
| 6    | .4191     | .3429     | .381      | .4191     | .381      | .4191     | .4572     |
| 7    | .4382     | .362      | .4191     | .4191     | .4191     | .4572     | .5335     |
| 8    | .4191     | .5144     | .4382     | .4954     | .4763     | .4954     | .5716     |
| 9    | .4191     | .5716     | .5525     | .5716     | .6097     | .5716     | .5716     |
| 10   | .4191     | .6478     | .6097     | .6097     | .6478     | .5716     | .4954     |
| 11   | .4191     | .6859     | .6478     | .6859     | .724      | .5716     | .6097     |
| 12   | .4191     | .724      | .6859     | .724      | .7049     | .6097     | .6287     |
| 13   | .4191     | .7621     | .724      | .724      | .6097     | .6287     | .5906     |
| 14   | .4191     | .724      | .724      | .6859     | .6668     | .6097     | .6287     |
| 15   | .4191     | .6859     | .6859     | .6478     | .6668     | .5716     | .5716     |
| 16   | .381      | .6478     | .6478     | .724      | .6478     | .6478     | .4382     |
| 17   | .381      | .6097     | .5716     | .6097     | .5716     | .5335     | .4763     |
| 18   | .4191     | .4572     | .5144     | .4763     | .5335     | .5335     | .4382     |
| 19   | .4382     | .5335     | .4954     | .5525     | .5335     | .5335     | .4001     |
| 20   | .4572     | .5144     | .4954     | .381      | .4763     | .4572     | .4001     |
| 21   | .4572     | .4763     | .4954     | .4763     | .4572     | .4954     | .4191     |
| 22   | .4191     | .4763     | .4572     | .4763     | .4572     | .4954     | .4001     |
| 23   | .4191     | .4572     | .4572     | .4763     | .4572     | .4954     | .381      |
| 24   | .4191     | .381      | .4572     | .4382     | .4191     | .4572     | .4572     |
| Max  | .4572     | .7621     | .724      | .724      | .724      | .6478     | .6287     |
| Min  | .381      | .3429     | .381      | .381      | .381      | .0381     | .381      |
| Avg  | .4199     | .5136     | .5176     | .5239     | .5152     | .4946     | .4862     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 201 / 11 KV MIDC (SANJAWARTHA) SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2096     | .1715     | .2096     | .2477     | .2286     | .2096     | .1905     |
| 2    | .1905     | .1715     | .2286     | .2096     | .2286     | .2286     | .1905     |
| 3    | .1905     | .1524     | .2286     | .1905     | .2096     | .2096     | .1715     |
| 4    | .1715     | .1524     | .2096     | .1905     | .1905     | .1905     | .1905     |
| 5    | .1715     | .1334     | .1905     |           | .1905     | .1905     | .1905     |
| 6    | .1715     | .1524     | .1905     | .2096     | .2096     | .1905     | .1715     |
| 7    | .1715     | .1905     | .2477     | .2096     | .2096     | .2096     | .1905     |
| 8    | .2477     | .2286     | .2858     | .2858     | .2477     | .2096     | .2286     |
| 9    | .2667     | .362      | .4382     | .381      | .381      | .2667     | .4191     |
| 10   | .362      | .5144     | .6478     | .4191     | .6097     | .4382     | .6287     |
| 11   | .381      | .7621     | .8002     | .8954     | .7621     | .5906     | .7621     |
| 12   | .4191     | .7621     | .7621     | .8764     | .8383     | .6287     | .8573     |
| 13   | .362      | .724      | .743      | .7049     | .7621     | .5525     | .7621     |
| 14   | .381      | .7621     | .7621     | .7621     | .8192     | .6287     | .8383     |
| 15   | .3429     | .8002     | .8954     | .8192     | .9717     | .6668     | .8192     |
| 16   | .4001     | .8002     | .8573     | .8002     | .8573     | .6668     | .7621     |
| 17   | .3239     | .7049     | .7621     | .724      | .6478     | .5906     |           |
| 18   | .2858     | .4572     | .4191     | .4191     | .4191     | .3239     | .2667     |
| 19   | .2667     | .381      | .3239     | .3429     | .3239     | .3048     |           |
| 20   | .2667     | .3048     | .2858     | .3048     | .3239     | .2667     | .2667     |
| 21   | .2096     | .2477     | .3048     | .2858     | .3048     | .2286     | .2477     |
| 22   | .2286     | .2858     | .2667     | .3239     | .2667     | .2477     | .2477     |
| 23   | .2096     | .2858     | .2858     | .2667     | .2667     | .2477     | .2667     |
| 24   | .2096     | .1905     | .2477     | .2286     | .2286     | .2477     | .2096     |
| Max  | .4191     | .8002     | .8954     | .8954     | .9717     | .6668     | .8573     |
| Min  | .1715     | .1334     | .1905     | .1905     | .1905     | .1905     | .1715     |
| Avg  | .2683     | .4041     | .4414     | .4390     | .4374     | .3556     | .4036     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 202 / 11 KV I.T.I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4958    | 2.6673    | 2.6673    | 2.5149    | 2.6673    | 2.553     | 2.5911    |
| 2    | 2.572     | 2.7054    | 2.7054    | 2.5339    | 2.553     | 2.572     | 2.5149    |
| 3    | 2.6292    | 2.7244    | 2.7435    | 2.4768    | 2.5149    | 2.5339    | 2.4196    |
| 4    | 2.6863    | 2.7435    | 2.8197    | 2.4958    | 2.5911    | 2.5149    | 2.3624    |
| 5    | 2.7244    | 2.7625    | 2.8387    | 2.3624    | 2.6673    | 2.553     | 2.5339    |
| 6    | 2.8578    | 2.8769    | 3.2198    | 2.934     | 3.0864    | 3.0483    | 2.8959    |
| 7    | 3.0674    | 3.6199    | 3.6199    | 3.3341    | 3.4675    | 2.8959    | 3.0864    |
| 8    | 3.1626    | 3.4865    | 2.934     | 3.3913    | 3.315     | 3.0483    | 3.2388    |
| 9    | 3.296     | 3.1245    | 2.6482    | 3.2388    | 3.0483    | 3.4294    |           |
| 10   | 3.0293    | 2.934     | 2.6863    | 3.2198    | 2.934     | 3.0674    | 3.0102    |
| 11   | 2.8578    | 2.7816    | 2.4768    | 2.8387    | 3.0483    | 2.8578    | 3.1055    |
| 12   | 2.7244    | 2.6292    | 2.7244    | 2.6101    | 2.7054    | 2.6482    | 2.7054    |
| 13   | 2.6101    | 2.7054    | 2.6482    | 2.6673    | 2.6482    | 2.5339    | 2.6673    |
| 14   | 2.3053    | 2.4768    | 2.572     | 2.5339    | 2.7054    | 2.5149    | 2.7244    |
| 15   | 2.2481    | 2.553     | 2.6482    | 2.6673    | 2.5149    | 2.6482    | 2.8197    |
| 16   | 2.4768    | 2.5149    | 2.6482    | 2.7435    | 2.5911    | 2.6101    | 2.8578    |
| 17   | 2.6673    | 2.934     | 3.1436    | 2.9912    | 2.8769    | 3.0864    |           |
| 18   | 2.9721    | 3.0102    | 3.315     | 3.2198    | 3.1626    | 3.296     |           |
| 19   | 3.4294    | 3.5818    | 3.7342    | 3.8485    | 3.5246    | 3.6961    |           |
| 20   | 3.2769    | 3.658     | 3.4675    | 3.6199    | 3.4865    | 3.4484    | 3.2769    |
| 21   | 3.0483    | 3.0864    | 3.4675    | 3.296     | 3.1626    | 3.2388    | 2.915     |
| 22   | 3.0102    | 3.1436    | 3.1626    | 3.1817    | 3.0864    | 3.2198    | 2.8578    |
| 23   | 2.8578    | 3.0293    | 2.8959    | 3.0864    | 3.0864    | 2.7435    | 2.8197    |
| 24   | 2.6482    | 2.7244    | 2.6292    | 2.8197    | 2.7054    | 2.8578    | 2.7816    |
| Max  | 3.4294    | 3.658     | 3.7342    | 3.8485    | 3.5246    | 3.6961    | 3.2769    |
| Min  | 2.2481    | 2.4768    | 2.4768    | 2.3624    | 2.5149    | 2.5149    | 2.3624    |
| Avg  | 2.8189    | 2.9364    | 2.9340    | 2.9427    | 2.9229    | 2.9007    | 2.8092    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 203 / 11 KV KAMAL NAYAN BAJAJ SHEDDABLE FEEDER HAVING WEEKLY  
 EXPR Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .362      | .381      | .362      | .4191     | .381      | .381      |
| 2    | .3239     | .362      | .3429     | .362      | .4001     | .362      | .362      |
| 3    | .3048     | .3429     | .3429     | .3429     | .381      | .362      | .381      |
| 4    | .3048     | .3239     | .3239     | .3429     | .3429     | .3429     | .362      |
| 5    | .3239     | .3239     | .3239     | .3239     | .3048     | .3429     | .3429     |
| 6    | .3429     | .3429     | .3429     | .3429     | .3429     | .3239     | .3239     |
| 7    | .362      | .3429     | .362      | .362      | .362      | .3239     | .3429     |
| 8    | .3239     | .3429     | .4001     | .362      | .362      | .381      | .381      |
| 9    | .2858     | .4191     | .4191     | .362      | .3429     | .4191     | .381      |
| 10   | .2286     | .381      | .4191     | .3429     | .3239     | .381      | .381      |
| 11   | .2477     | .4001     | .381      | .3239     | .3239     | .381      | .4572     |
| 12   | .2286     | .3429     | .4001     | .3429     | .3239     | .4001     | .2477     |
| 13   | .1715     | .381      | .362      | .3048     | .3429     | .4191     | .2667     |
| 14   | .1905     | .362      | .4572     | .3429     | .3429     | .381      | .3048     |
| 15   | .1905     | .4001     | .4572     | .381      | .4763     | .4001     | .362      |
| 16   | .3239     | .4954     | .4954     | .362      | .4382     | .4191     | .4763     |
| 17   | .3239     | .5144     | .4572     | .4572     | .4191     | .4763     |           |
| 18   | .3239     | .4191     | .4763     | .4191     | .4572     | .4001     |           |
| 19   | .362      | .4763     | .4954     | .4763     | .4382     | .4382     |           |
| 20   | .3429     | .4572     | .4763     | .4001     | .4191     | .4191     |           |
| 21   | .381      | .4763     | .4572     | .4382     | .4191     | .4572     | .4382     |
| 22   | .362      | .4763     | .4382     | .4572     | .381      | .4191     | .4001     |
| 23   | .381      | .4572     | .4191     | .4382     | .4572     | .4001     | .4191     |
| 24   | .4001     | .381      | .4382     | .4001     | .4001     | .4572     | .4191     |
| Max  | .4001     | .5144     | .4954     | .4763     | .4763     | .4763     | .4763     |
| Min  | .1715     | .3239     | .3239     | .3048     | .3048     | .3239     | .2477     |
| Avg  | .3072     | .3993     | .4112     | .3771     | .3842     | .3953     | .3715     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 204 / 11 KV GOLWADI SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.448     | 1.5242    | 1.5242    | 1.5432    | 1.6194    | 1.6385    | 1.6194    |
| 2    | 1.467     | 1.5623    | 1.5623    | 1.4861    | 1.5432    | 1.6004    | 1.5623    |
| 3    | 1.4861    | 1.6004    | 1.6004    | 1.448     | 1.5242    | 1.5242    | 1.448     |
| 4    | 1.448     | 1.5813    | 1.6385    | 1.4289    | 1.448     | 1.448     | 1.4098    |
| 5    | 1.467     | 1.5242    | 1.6766    | 1.5242    | 1.4861    | 1.448     | 1.3717    |
| 6    | 1.4289    | 1.4861    | 1.5623    | 1.6004    | 1.5242    | 1.6194    | 1.448     |
| 7    | 1.4861    | 1.7147    | 1.7528    | 1.8099    | 1.7718    | 1.7337    | 1.5242    |
| 8    | 1.6766    | 1.6004    | 1.6956    | 1.7147    | 1.6385    | 1.7147    | 1.5242    |
| 9    | 1.6385    | .1524     | 1.6575    | 1.5623    | 1.5242    | 1.6766    | 1.5051    |
| 10   | 1.6004    | 1.5623    | 1.4289    | 1.5432    | 1.5242    | 1.6004    | 1.5242    |
| 11   | 1.5623    | 1.6194    | 1.5432    | 1.4861    | 1.6575    | 1.6194    | 1.5432    |
| 12   | 1.5432    | 1.5242    | 1.4098    | 1.4289    | 1.5051    | 1.5242    | 1.3717    |
| 13   | 1.4098    |           | 1.2574    | 1.4098    | 1.4861    | 1.4861    | 1.3527    |
| 14   | 1.3717    | 1.5242    | 1.4289    | 1.3908    | 1.4098    | 1.4861    | 1.3146    |
| 15   | 1.3336    | 1.5242    | 1.4861    | 1.5813    | 1.467     | 1.3717    | 1.2955    |
| 16   | 1.467     | 1.5623    | 1.5242    | 1.6194    | 1.3527    | 1.4098    |           |
| 17   | 1.448     | 1.5242    | 1.5242    | 1.5432    | 1.5623    | 1.3717    |           |
| 18   | 1.4098    | 1.4861    | 1.5813    | 1.448     | 1.4098    |           |           |
| 19   | 1.4861    | 1.5623    | 1.6766    | 1.6194    | 1.467     | 1.6004    |           |
| 20   | 1.5242    | 1.6004    | 1.6575    | 1.6766    | 1.6575    | 1.5813    |           |
| 21   | 1.5623    | 1.6194    | 1.5623    | 1.6004    | 1.5432    | 1.6004    |           |
| 22   | 1.6004    | 1.6194    | 1.6575    | 1.6956    | 1.6385    | 1.6194    |           |
| 23   | 1.6194    | 1.7147    | 1.6956    | 1.7528    | 1.7528    | 1.6766    |           |
| 24   | 1.5623    | 1.6385    | 1.6004    | 1.6194    | 1.6766    | 1.7147    | 1.6004    |
| Max  | 1.6766    | 1.7147    | 1.7528    | 1.8099    | 1.7718    | 1.7337    | 1.6194    |
| Min  | 1.3336    | .1524     | 1.2574    | 1.3908    | 1.3527    | 1.3717    | 1.2955    |
| Avg  | 1.5019    | 1.5142    | 1.5710    | 1.5639    | 1.5496    | 1.5681    | 1.4634    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 206 / 11 KV RAHUL NAGAR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4387    | 2.7054    | 2.7625    | 2.572     | 2.5339    | 2.5339    | 2.553     |
| 2    | 2.4768    | 2.7625    | 2.8006    | 2.5149    | 2.0767    | 2.5149    | 2.4387    |
| 3    | 2.4958    | 2.7816    | 2.8387    | 2.4768    | 2.4387    | 2.553     | 2.4006    |
| 4    | 2.5149    | 2.8197    | 2.8769    | 2.5149    |           | 2.553     | 2.3434    |
| 5    | 2.572     | 2.8578    | 2.9721    | 2.6101    | 2.5149    | 2.5149    | 2.553     |
| 6    | 2.8578    | 2.9912    | 3.0864    | 3.0864    | 2.8959    | 2.934     | 2.8578    |
| 7    | 3.2198    | 3.6389    | 3.677     | 3.8104    | 3.5627    | 3.7532    | 3.4294    |
| 8    | 3.6961    | 3.5818    | 3.5627    | 3.658     | 3.4675    | 3.8104    | 3.5246    |
| 9    | 3.658     | 3.4484    | 3.315     | 3.4675    | 3.2007    | 3.8104    | 3.315     |
| 10   | 3.3913    | 3.1245    | 3.0674    | 3.3913    | 2.934     | 3.315     | 3.0483    |
| 11   | 3.2769    | 2.7625    | 2.7816    | 2.934     | 2.5149    | 2.9912    | 2.8387    |
| 12   | 3.0293    | 2.6101    | 2.6863    | 2.7625    | 2.21      | 3.0102    | 2.572     |
| 13   | 2.7625    | 2.5339    | 2.4958    | 2.6673    | 2.5149    | 2.7244    | 2.4387    |
| 14   | 2.6101    | 2.4006    | 2.2862    | 2.5339    | 2.3053    | 2.4387    | 2.4006    |
| 15   | 2.4006    | 2.2291    | 2.2291    | 2.4387    | 2.2862    | 2.2291    | 2.0195    |
| 16   | 2.553     | 2.3624    | 2.3243    | 2.6101    | 2.3053    | 2.1148    | 2.5149    |
| 17   | 2.6673    | 2.553     | 2.6482    | 2.7816    | 2.7625    | 2.4006    |           |
| 18   | 3.1055    | 3.0102    | 3.1055    | 3.296     | 3.1055    | 2.8006    |           |
| 19   | 3.4675    | 3.4675    | 3.7151    | 3.7151    | 3.4675    | 3.4294    |           |
| 20   | 3.5056    | 3.5246    | 3.5437    | 3.6199    | 3.3913    | 3.3722    | 1.5051    |
| 21   | 3.0483    | 3.0864    | 3.0864    | 3.296     | 3.0864    | 2.9721    | 2.6292    |
| 22   | 3.0483    | 2.8578    | 2.9721    | 3.0293    | 2.9912    | 2.8387    | 2.8197    |
| 23   | 2.8769    | 2.8197    | 2.8197    | 2.9721    | 2.8006    | 2.8197    | 2.8578    |
| 24   | 2.553     | 2.7435    | 2.6863    | 2.7625    | 2.7054    | 2.6673    | 2.6673    |
| Max  | 3.6961    | 3.6389    | 3.7151    | 3.8104    | 3.5627    | 3.8104    | 3.5246    |
| Min  | 2.4006    | 2.2291    | 2.2291    | 2.4387    | 2.0767    | 2.1148    | 1.5051    |
| Avg  | 2.9261    | 2.9030    | 2.9308    | 2.9801    | 2.7857    | 2.8792    | 2.6537    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 207 / 11 KV M.I.T. EXPRESS SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0953     | .1143     | .1143     | .0953     | .0953     | .0953     |
| 2    | .1143     | .1143     | .0953     | .0953     | .0953     | .1143     | .1143     |
| 3    | .1143     | .1143     | .0953     | .1143     | .1143     | .0953     | .1143     |
| 4    | .0953     | .0953     | .1143     | .0953     | .0953     | .1143     | .0953     |
| 5    | .0953     | .1143     | .1143     | .0953     | .0953     | .0953     | .0953     |
| 6    | .1143     | .0953     | .0953     | .0953     | .0953     | .1143     | .0953     |
| 7    | .1143     | .1143     | .0953     | .1143     | .0953     | .0953     | .0953     |
| 8    | .1143     | .1143     | .0762     | .1143     | .0953     | .0953     | .0762     |
| 9    | .0953     | .0762     | .0381     | .0762     | .0381     | .0762     | .0191     |
| 10   | .0953     | .0572     | .1143     | .0762     | .0191     | .1143     | .0572     |
| 11   | .0953     | .1524     | .1715     | .3048     | .0381     | .1905     | .1715     |
| 12   | .0953     | .1143     | .1143     | .2858     | .0191     | .0953     | .0572     |
| 13   | .0953     | .0381     | .1143     | .2286     | .0381     | .1143     | .0762     |
| 14   | .0953     | .1143     | .0953     | .2477     | .1334     | .0953     | .0953     |
| 15   | .0953     | .1334     | .1715     | .2667     | .1715     | .1715     | .1143     |
| 16   | .0762     | .1524     | .1905     | .2477     | .2286     | .1524     | .2477     |
| 17   | .1143     | .1905     | .1905     | .1715     | .1334     | .1715     |           |
| 18   | .0953     | 1.448     | .1334     | .0953     | .1334     | .1143     |           |
| 19   | .1143     | .1524     | .1334     | .1143     | .1143     | .1143     |           |
| 20   | .1143     | .1334     | .1334     | .1143     | .1143     | .1143     |           |
| 21   | .1143     | .1334     | .1143     | .1143     | .1143     | .1143     | .1524     |
| 22   | .1334     | .1334     | .1143     | .1143     | .1143     | .1143     | .1524     |
| 23   | .0953     | .0953     | .1334     | .1143     | .1143     | .1143     | .1143     |
| 24   | .0953     | .1143     | .1143     | .1143     | .1143     | .1334     | .0953     |
| Max  | .1334     | 1.448     | .1905     | .3048     | .2286     | .1905     | .2477     |
| Min  | .0762     | .0381     | .0381     | .0762     | .0191     | .0762     | .0191     |
| Avg  | .1032     | .1707     | .1199     | .1469     | .1008     | .1175     | .1067     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 208 / 11kV MIDC(NIRLAP)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5716     | .4001     | .5716     | .6097     | .6859     | .6859     | .6478     |
| 2    | .5335     | .4191     | .5716     | .5716     | .724      | .6478     | .6478     |
| 3    | .5525     | .4001     | .6097     | .5525     | .6287     | .6097     | .6097     |
| 4    | .5716     | .4001     | .6097     | .5716     | .6097     | .6097     | .6287     |
| 5    | .5525     | .381      | .6478     | .5716     | .6478     | .6287     | .5335     |
| 6    | .5525     | .381      | .6287     | .5144     | .6478     | .6097     | .5335     |
| 7    | .5335     | .4954     | .6287     | .6097     | .6478     | .5335     | .5716     |
| 8    | .724      | .724      | .743      | .7621     | .6859     | .6097     | .6668     |
| 9    | .8573     | .8764     | .8192     | .9526     | .9145     | .7621     | .9335     |
| 10   | .9145     | .9907     | .9907     | .9717     | 1.1431    | 1.0669    | 1.1241    |
| 11   | .9526     | .9526     | 1.0288    | 1.3717    | 1.086     | 1.1431    | 1.2574    |
| 12   | .8383     | 1.0288    | .8764     | 1.2574    | 1.2384    | .9526     | 1.0288    |
| 13   | .7049     | 1.0288    | .9717     | 1.086     | 1.1241    | .9907     | .9335     |
| 14   | .743      | .9526     |           | 1.1431    | 1.1812    | .8192     | 1.0479    |
| 15   | .8002     | 1.0669    | 1.2003    | 1.1431    | 1.1812    | .8764     | 1.105     |
| 16   | .6859     | 1.105     | 1.0288    | .9145     | 1.2003    | .8573     | 1.1622    |
| 17   | .6859     | 1.0669    | 1.1431    | 1.0479    | .9907     | .7621     |           |
| 18   | .6287     | 1.105     | .9526     | 1.0288    | .8954     | .7621     |           |
| 19   | .5906     | .9907     | .9335     | .8954     | .8002     | .7621     |           |
| 20   | .5716     | .8002     | .8764     | .7811     | .7811     | .724      | .6287     |
| 21   | .4572     | .5716     | .8002     | .9335     | .743      | .7049     | .8002     |
| 22   | .5144     | .724      | .6859     | .9526     | .7811     | .7811     | .6859     |
| 23   | .4763     | .6478     | .6478     | .9145     | .7621     | .7621     | .6478     |
| 24   | .5716     | .4382     | .5525     | .6287     | .724      | .6859     | .6859     |
| Max  | .9526     | 1.105     | 1.2003    | 1.3717    | 1.2384    | 1.1431    | 1.2574    |
| Min  | .4572     | .381      | .5525     | .5144     | .6097     | .5335     | .5335     |
| Avg  | .6494     | .7478     | .8052     | .8661     | .8677     | .7645     | .8038     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 201 / 11 KV HOLYCROSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.8645    | 2.9127    | 3.2341    | 2.9384    | 2.9938    | 3.2861    | 3.062     |
| 2    | 2.6797    | 2.7721    | 3.2674    | 2.838     | 2.9014    | 3.0247    | 2.894     |
| 3    | 2.7073    | 2.7721    | 3.2341    | 2.8006    | 2.809     | 3.0247    | 2.8006    |
| 4    | 2.6797    | 2.6797    | 3.2341    | 2.8006    |           | 2.9874    | 2.8753    |
| 5    | 2.7073    | 2.7721    | 3.2341    | 2.838     | 2.9938    | 2.9874    | 2.726     |
| 6    | 2.8006    | 2.9569    | 3.3265    | 3.0994    | 3.2674    | 3.1367    | 3.0807    |
| 7    | 2.8829    | 3.5848    | 3.5288    | 3.5475    | 3.5475    | 3.3048    | 3.3048    |
| 8    | 3.1554    | 3.4355    | 3.5475    | 3.2301    | 3.5101    | 3.4915    | 3.1036    |
| 9    | 3.0678    | 3.1971    | 3.4728    | 3.6595    | 3.3234    |           | 3.2156    |
| 10   |           | 3.1417    | 3.4355    | 3.2114    | 3.3981    |           | 3.3634    |
| 11   | 3.1417    | 3.3265    | 3.4728    | 3.6222    | 3.4355    |           | 3.4189    |
| 12   | 2.9569    | 3.1971    | 3.5101    | 3.4728    | 3.4728    | 4.3429    | 3.1602    |
| 13   |           | 3.3265    | 3.4355    | 3.3981    | 3.5101    | 3.9363    | 3.2156    |
| 14   | 2.5873    | 3.1417    | 3.2861    | 3.4168    | 3.4541    |           | 3.0862    |
| 15   | 2.726     | 3.3265    | 3.3234    | 3.4541    | 3.4168    |           |           |
| 16   | 2.6797    | 3.1417    | 3.1741    | 3.5101    | 3.4915    |           |           |
| 17   | 2.7633    | 3.345     | 3.3421    | 3.4374    | 3.2674    |           |           |
| 18   | 2.7446    | 3.1417    | 3.2301    | 3.0493    | 3.1741    | 3.8809    | 1.3491    |
| 19   |           | 3.6408    | 3.8275    | 3.5852    | 3.5113    | 4.0287    | 1.3491    |
| 20   | 2.6699    | 3.5475    | 3.8462    | 3.5113    | 3.5475    | 3.9209    |           |
| 21   | 2.4272    | 3.4355    | 2.3967    | 3.4004    | 3.4915    | 3.6222    | 2.4025    |
| 22   | 3.2861    | 3.3234    | 3.5475    | 3.3634    | 3.5848    | 3.5475    | 2.4272    |
| 23   | 3.4168    | 3.3819    | 3.5662    | 3.4374    | 3.5475    | 3.5848    | 3.4189    |
| 24   | 3.0493    | 3.0678    | 3.2341    | 3.2156    | 3.1417    | 3.5101    | 3.3608    |
| Max  | 3.4168    | 3.6408    | 3.8462    | 3.6595    | 3.5848    | 4.3429    | 3.4189    |
| Min  | 2.4272    | 2.6797    | 2.3967    | 2.8006    | 2.809     | 2.9874    | 1.3491    |
| Avg  | 2.8569    | 3.1903    | 3.3628    | 3.2849    | 3.3387    | 3.5069    | 2.8807    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 202 / 11 KV CANTONMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6078    | 1.6078    | 1.5708    | 1.6078    | 1.6632    | 1.7177    | 1.8298    |
| 2    | 1.587     | 1.5708    | 1.5708    | 1.587     | 1.4784    | 1.6057    | 1.5497    |
| 3    | 1.4937    | 1.4784    | 1.5708    | 1.587     | 1.4415    | 1.531     | 1.4937    |
| 4    | 1.4784    | 1.4784    | 1.5708    | 1.5497    |           | 1.4937    | 1.587     |
| 5    | 1.4784    | 1.4784    | 1.6632    | 1.531     | 1.5524    | 1.4937    | 1.4377    |
| 6    | 1.4784    | 1.4969    | 1.6804    | 1.6804    | 1.643     | 1.6057    | 1.531     |
| 7    | 1.6057    | 1.7551    | 1.7364    | 1.6991    | 1.7177    | 1.7551    | 1.587     |
| 8    | 1.6817    | 1.7924    | 1.6632    | 1.7177    | 1.7364    | 1.7364    | 1.4937    |
| 9    | 1.7737    | 1.5893    | 1.6057    | 1.8671    | 1.6804    |           | 1.4377    |
| 10   | 1.6804    | 1.6632    | 1.5684    | 1.587     | 1.6057    |           | 1.307     |
| 11   | 1.643     | 1.5339    | 1.5684    | 1.5497    | 1.5497    |           | 1.307     |
| 12   | 1.587     | 1.4784    | 1.5684    | 1.531     | 1.5684    | 1.6632    | 1.3491    |
| 13   | 1.4706    | 1.5524    | 1.6804    | 1.4937    | 1.587     | 1.8296    | 1.5708    |
| 14   | 1.4784    | 1.5339    | 1.587     | 1.4003    | 1.587     |           | 1.5497    |
| 15   | 1.4415    | 1.5893    | 1.587     | 1.531     | 1.5497    |           |           |
| 16   | 1.5497    | 1.5708    | 1.587     | 1.531     | 1.6057    |           |           |
| 17   | 1.4563    | 1.5708    | 1.531     | 1.5524    | 1.6632    |           |           |
| 18   | 1.4563    | 1.5524    | 1.6804    |           | 1.7002    |           |           |
| 19   | 1.8111    | 1.885     | 1.9231    | 1.9035    | 1.885     | 2.0883    |           |
| 20   | 1.8298    | 1.9605    | 1.9231    | 1.922     | 1.9774    | 1.9774    |           |
| 21   | 1.8484    | 1.9418    | 1.9231    | 1.885     | 1.9589    | 1.9044    | 2.0698    |
| 22   | 1.8484    | 1.885     | 1.9418    | 1.9404    | 1.922     | 1.848     | 1.9313    |
| 23   | 1.8484    | 1.8296    | 1.9605    | 1.885     | 1.9589    | 1.848     | 1.9404    |
| 24   | 1.6632    | 1.7187    | 1.7556    | 1.6817    | 1.848     | 1.9231    |           |
| Max  | 1.8484    | 1.9605    | 1.9605    | 1.9404    | 1.9774    | 2.0883    | 2.0698    |
| Min  | 1.4415    | 1.4784    | 1.531     | 1.4003    | 1.4415    | 1.4937    | 1.307     |
| Avg  | 1.6166    | 1.6464    | 1.6841    | 1.6618    | 1.6904    | 1.7513    | 1.5866    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 203 / 11 KV M.E.S. EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .3086     | .3086     | .3772     | .3086     | .3361     | .3361     |
| 2    | .3429     | .3086     | .3086     | .3086     | .3052     | .3361     | .2987     |
| 3    | .3429     | .3086     | .3086     | .3086     | .3086     | .3361     | .2987     |
| 4    | .3429     | .3086     | .3086     | .3086     |           | .3361     | .3361     |
| 5    | .3429     | .3086     | .3086     | .3429     | .4161     | .3361     | .3734     |
| 6    | .3772     | .3429     | .3772     | .4287     | .4207     | .4108     | .4481     |
| 7    | .4801     | .4801     | .5373     | .5144     | .4207     | .4854     | .4854     |
| 8    | .5144     | .5144     | .5144     | .5144     | .4207     | .5601     | .4854     |
| 9    | .4252     | .4252     | .4854     | .5975     | .5228     |           | .8501     |
| 10   | .4252     | .4656     | .439      | .4481     | .5121     |           |           |
| 11   | .4656     | .4961     | .4854     | .4481     | .4854     | .0305     |           |
| 12   | .2865     | .5014     | .4854     | .4481     | .4481     | .08       | .5487     |
| 13   |           | .4252     | .3734     | .4481     | .4108     | .0857     | .5487     |
| 14   | .2835     | .4207     | .3734     | .3734     | .3361     |           | .5144     |
| 15   | .2835     | .3224     | .2614     | .3361     | .2987     |           |           |
| 16   | .2835     | .2804     | .2987     | .2987     | .2926     |           |           |
| 17   | .4024     | .4287     | .3734     | .3898     | .3582     |           |           |
| 18   | .4481     | .5144     | .4024     | .3772     | .4252     | .5087     | .5258     |
| 19   | .4854     | .5144     |           | .4854     | .4557     | .5548     |           |
| 20   | .5601     | .5601     | .5601     | .5609     | .4961     | .631      |           |
| 21   | .5228     | .5144     | .5601     | .4961     | .4961     | .5609     | .5258     |
| 22   | .4481     | .4287     | .4854     | .3856     | .3898     | .3856     | .5373     |
| 23   | .3734     | .4287     | .3734     | .3506     | .3856     | .3506     | .5373     |
| 24   | .3772     | .3429     | .4287     | .4287     | .3506     | .3734     | .3361     |
| Max  | .5601     | .5601     | .5601     | .5975     | .5228     | .631      | .8501     |
| Min  | .2835     | .2804     | .2614     | .2987     | .2926     | .0305     | .2987     |
| Avg  | .3981     | .4146     | .4068     | .4157     | .4028     | .3721     | .4698     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 204 / MILIND COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9979     | .961      | 1.0164    | 1.0349    | .961      | .9709     | 1.0082    |
| 2    | .961      |           | 1.0164    | .9795     | .8871     | .9709     | .9709     |
| 3    | .961      | .924      | 1.0164    | .961      | .8131     | .9522     | .9709     |
| 4    | .924      | .924      | 1.0349    | .961      |           | .9522     | .8916     |
| 5    | .924      | .924      | 1.0534    | .924      | .961      | .9709     | 1.0082    |
| 6    | .924      | .961      | 1.1203    | 1.0642    | 1.1203    | 1.0456    | 1.0829    |
| 7    | 1.1203    | 1.1088    | 1.3443    | 1.1203    | 1.2567    | 1.1203    | 1.1203    |
| 8    | 1.1203    | 1.1203    | 1.1203    | 1.1576    | 1.1203    | 1.1203    | 1.1576    |
| 9    | 1.1088    | 1.0349    | 1.0456    | 1.1949    | 1.1203    |           | 1.1203    |
| 10   | 1.0349    | 1.0349    | .9709     | 1.0456    | 1.0456    |           | 1.0829    |
| 11   | 1.0456    | .961      | .9709     |           |           | 1.2012    | 1.0456    |
| 12   | .961      | .9795     | .8962     | .9709     | 1.0082    | 1.1458    | 1.0164    |
| 13   | .9511     | .8871     | 1.1203    | 1.0456    | .9709     | 1.1088    | .9979     |
| 14   | .8871     | .8779     | 1.1203    | 1.0456    | .8962     |           | .9979     |
| 15   | .8871     | .8131     | .9709     | .9709     | .8962     |           |           |
| 16   | .9709     | .8871     | .9709     | .8962     | .8215     |           |           |
| 17   | .9709     | 1.0164    | .9709     | .961      | .961      |           |           |
| 18   | .9709     | .7023     | 1.2696    |           | 1.0349    | 1.1827    |           |
| 19   | 1.1949    | 1.2883    | 1.2696    | 1.1827    | 1.1827    | 1.2567    |           |
| 20   | 1.1949    | 1.251     | 1.2696    | 1.2567    | 1.2567    | 1.1827    |           |
| 21   | 1.1203    | 1.2323    | 1.1949    | 1.1827    | 1.1827    | 1.1949    | 1.1458    |
| 22   | 1.1949    | 1.1088    | 1.1949    | 1.1088    | 1.1949    | 1.1949    | 1.1827    |
| 23   | 1.1949    | 1.1088    | 1.1203    | 1.1088    | 1.1203    | 1.1458    | 1.1458    |
| 24   | 1.0164    | .9979     | 1.0829    | 1.0719    | 1.0349    | 1.0456    | 1.0456    |
| Max  | 1.1949    | 1.2883    | 1.3443    | 1.2567    | 1.2567    | 1.2567    | 1.1827    |
| Min  | .8871     | .7023     | .8962     | .8962     | .8131     | .9522     | .8916     |
| Avg  | 1.0265    | 1.0045    | 1.0900    | 1.0566    | 1.0385    | 1.0979    | 1.0551    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 201 / 11 kV Dishanagari Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8107    | 1.8634    | 1.9774    | 1.9774    | 1.8671    | 1.8671    | 1.8671    |
| 2    | 1.8107    | 1.6975    | 1.7873    | 1.7113    | 1.7177    | 1.7551    | 1.7551    |
| 3    | 1.8107    | 1.6975    | 1.7873    | 1.6732    | 1.6804    | 1.6804    | 1.6804    |
| 4    | 1.8107    | 1.7113    | 1.7113    | 1.6732    | 1.643     | 1.8671    | 1.7551    |
| 5    | 1.8484    | 2.0155    | 1.7113    | 1.9014    | 1.8671    | 2.0538    | 2.0538    |
| 6    | 2.0748    | 2.2257    | 2.0915    | 2.0915    | 2.2405    | 2.2779    | 2.2779    |
| 7    | 2.1502    | 2.3197    | 2.5098    | 2.4338    | 2.3152    | 2.3152    | 2.3525    |
| 8    | 2.2634    | 1.9239    | 2.2817    | 2.2817    | 2.1437    | 2.2177    | 1.9418    |
| 9    | 2.0538    | 1.6221    | 1.8253    |           | 1.848     | 1.9387    | 1.9589    |
| 10   | 2.0538    | 1.5684    | 1.6632    | 2.3899    | 1.7372    | 1.7741    | 1.7741    |
| 11   | 1.922     | 1.5729    | 1.6263    | 1.7372    | 1.5524    | 1.5893    | 1.5893    |
| 12   | 1.6632    | 1.6461    | 1.5893    | 1.6632    | 1.4784    | 1.5524    | 1.5524    |
| 13   | 1.6632    | 1.6095    | 1.5524    | 1.5893    | 1.5524    | 1.5154    | 1.5154    |
| 14   | 1.6632    | 1.5893    | 1.5154    | 1.6632    | 1.5893    | 1.4784    | 1.4784    |
| 15   | 1.7372    | 1.5524    | 1.5893    | 1.6632    | 1.5893    | 1.5154    | 1.4784    |
| 16   | 1.848     | 1.5364    | 1.6632    | 1.6632    | 1.6263    | 1.4784    | 1.6632    |
| 17   | 1.7193    | 1.6461    | 1.6827    | 1.7372    | 1.7002    | 1.6632    |           |
| 18   | 1.829     | 1.7193    | 1.7737    | 1.848     | 1.848     | 1.9589    |           |
| 19   | 2.1216    | 1.9959    | 2.1807    | 2.2032    | 2.1658    | 2.1068    |           |
| 20   | 2.1437    | 2.2177    | 2.2779    | 2.2405    | 2.2405    | 2.0165    |           |
| 21   | 2.1285    | 2.2177    | 2.2032    | 2.2405    | 2.1658    | 2.4272    | 2.1658    |
| 22   | 2.1285    | 2.2405    | 2.2405    | 2.2405    | 2.0911    | 2.3899    | 2.2405    |
| 23   | 2.0165    | 2.1502    | 2.1296    | 1.9791    | 2.0165    | 2.1285    | 2.2405    |
| 24   | 1.8671    | 1.9239    | 2.0155    | 2.0915    | 1.9418    | 1.9418    | 1.9791    |
| Max  | 2.2634    | 2.3197    | 2.5098    | 2.4338    | 2.3152    | 2.4272    | 2.3525    |
| Min  | 1.6632    | 1.5364    | 1.5154    | 1.5893    | 1.4784    | 1.4784    | 1.4784    |
| Avg  | 1.9224    | 1.8443    | 1.8911    | 1.9432    | 1.8591    | 1.8962    | 1.8660    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 202 / 11 kV Deolai Chowk Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8861    | 2.2257    | 2.0535    | 2.0535    | 2.2405    | 2.4272    | 2.2405    |
| 2    | 1.8107    | 1.6975    | 1.8634    | 1.8107    | 2.0538    | 2.3152    | 2.0538    |
| 3    | 1.8107    | 1.7113    | 1.8634    | 1.8253    | 1.8671    | 2.0538    | 1.8671    |
| 4    | 1.8107    | 1.7113    | 1.7493    | 1.8253    | 1.8671    | 1.9791    | 1.8671    |
| 5    | 1.8107    | 1.8484    | 2.0155    | 2.0155    | 2.0165    | 2.0538    | 1.9791    |
| 6    | 1.8484    | 2.1296    | 2.0915    | 2.0535    | 2.0911    | 2.0911    | 2.0538    |
| 7    | 1.8861    | 2.1676    | 2.0915    | 2.0915    | 2.0538    | 2.0538    | 1.9791    |
| 8    | 1.9239    | 1.9616    | 1.9014    | 1.8634    | 1.8671    | 1.848     | 1.848     |
| 9    | 1.7551    | 1.6975    | 1.7493    |           | 1.7741    | 1.7558    | 1.7372    |
| 10   | 1.6804    | 1.643     | 1.4784    | 2.2177    | 1.7741    | 1.6632    | 1.7002    |
| 11   | 1.6632    |           | 1.4415    | 1.922     | 1.7372    | 1.6263    | 1.6632    |
| 12   | 1.6632    | 1.5364    | 1.4415    | 1.848     | 1.6632    | 1.5893    | 1.5893    |
| 13   | 1.6632    | 1.5524    | 1.4045    | 1.7372    | 1.7741    | 1.6263    | 1.6263    |
| 14   | 1.7002    | 1.5154    | 1.4045    | 1.6632    | 1.8111    | 1.6632    | 1.6632    |
| 15   | 1.7002    | 1.4784    | 1.5893    | 1.7741    | 1.848     | 1.7002    | 1.7002    |
| 16   | 1.7002    | 1.7558    | 1.848     | 1.848     | 1.848     | 1.7372    | 1.9589    |
| 17   | 1.7741    | 1.7558    | 1.8111    | 1.848     | 1.848     | 1.7372    |           |
| 18   | 1.885     | 1.7002    | 1.7372    | 1.848     | 2.0538    | 1.9589    |           |
| 19   |           | 2.1068    | 2.1068    | 2.2405    | 2.2405    | 2.0698    |           |
| 20   | 2.0328    | 2.2032    | 2.2405    | 2.2405    | 2.4272    | 2.1658    | 2.1437    |
| 21   | 2.0538    | 2.1807    | 2.3899    | 2.2405    | 2.5019    | 2.1658    | 2.2779    |
| 22   | 2.2405    | 2.3899    | 2.3899    | 2.2405    | 2.5766    | 2.1658    | 2.2405    |
| 23   | 2.3899    | 2.3765    | 2.4718    | 2.4646    | 2.5766    | 2.4646    | 2.3525    |
| 24   | 2.2405    | 2.3388    | 2.1296    | 2.4338    | 2.3899    | 2.5019    | 2.3152    |
| Max  | 2.3899    | 2.3899    | 2.4718    | 2.4646    | 2.5766    | 2.5019    | 2.3525    |
| Min  | 1.6632    | 1.4784    | 1.4045    | 1.6632    | 1.6632    | 1.5893    | 1.5893    |
| Avg  | 1.8665    | 1.8993    | 1.8860    | 2.0046    | 2.0376    | 1.9756    | 1.9456    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 203 / 11 kV Sara Siddhi Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0748    | 2.452     | 2.5859    | 2.5859    | 2.6139    | 2.6139    | 2.4646    |
| 2    | 1.8861    | 1.9616    | 2.4338    | 1.9774    | 2.5393    | 2.5393    | 2.3899    |
| 3    | 1.8861    | 1.9616    | 2.4338    | 1.9774    | 1.9418    | 2.0911    | 2.2405    |
| 4    | 1.8861    | 1.9616    | 2.4338    | 1.9774    | 1.9418    | 2.0911    | 2.1658    |
| 5    | 2.2257    | 2.1879    | 2.2817    | 2.2817    | 2.3899    | 2.4646    | 2.4646    |
| 6    | 2.4143    | 2.6619    | 2.6239    | 2.9662    | 3.1367    | 2.9874    | 2.9874    |
| 7    | 2.7915    | 3.1183    | 3.0422    | 3.1183    | 2.9874    |           | 2.9127    |
| 8    | 2.7161    | 2.5098    | 2.6619    | 2.6406    | 2.5393    | 2.5393    | 2.6139    |
| 9    | 2.4646    | 2.1296    | 2.2817    |           |           | 2.2177    | 2.2177    |
| 10   | 2.3152    | 2.0538    | 2.0698    |           | 2.1437    | 2.0328    | 2.1437    |
| 11   | 2.2177    | 1.848     | 1.9959    | 1.4784    | 1.9589    | 1.7741    | 2.1437    |
| 12   | 1.9589    | 1.7558    | 1.848     | 2.0328    | 1.848     | 1.7002    | 2.0328    |
| 13   | 1.922     | 1.7924    | 1.9589    | 2.2177    | 1.9589    | 1.7372    | 2.0328    |
| 14   | 2.0485    | 1.829     | 1.9959    | 2.0698    | 2.0698    | 1.7741    | 2.1437    |
| 15   | 2.1068    | 1.9022    | 1.848     | 2.0698    | 2.0698    | 1.922     | 2.2177    |
| 16   | 2.1437    | 2.0485    | 1.848     | 2.0698    | 2.1437    | 1.922     | 2.2177    |
| 17   | 2.1948    | 2.1948    | 2.1216    | 2.0328    | 2.0485    | 1.9022    |           |
| 18   | 2.268     | 2.2443    | 2.1216    | 2.2916    | 2.6242    | 2.2916    |           |
| 19   | 2.6337    | 2.7801    | 2.7801    | 2.9127    | 3.1047    | 2.5873    |           |
| 20   | 2.7351    | 2.8829    | 2.8829    | 2.8006    | 2.9874    | 2.838     | 2.4143    |
| 21   | 2.7633    | 2.838     | 2.809     | 2.6139    | 2.9874    | 2.838     | 2.2405    |
| 22   | 2.6886    | 2.809     | 2.838     | 2.6139    | 2.9874    | 2.838     | 2.3899    |
| 23   | 2.5873    | 2.7915    | 2.8901    | 2.838     | 2.7633    | 2.7633    |           |
| 24   | 2.3899    | 2.4897    | 2.5652    | 2.776     | 2.7633    | 2.6886    | 2.5393    |
| Max  | 2.7915    | 3.1183    | 3.0422    | 3.1183    | 3.1367    | 2.9874    | 2.9874    |
| Min  | 1.8861    | 1.7558    | 1.848     | 1.4784    | 1.848     | 1.7002    | 2.0328    |
| Avg  | 2.3050    | 2.3002    | 2.3897    | 2.3792    | 2.4587    | 2.3110    | 2.3487    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 201 / 11 KV AMC EXPRESS

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5975     | .5601     | .5975     | .5788     | .5601     | .5601     | .5601     |
| 2    | .5788     | .5601     | .3734     | .5601     | .5601     | .5601     | .5601     |
| 3    | .5788     | .5788     | .5601     | .5658     | .5601     | .5788     | .5415     |
| 4    | .5788     | .5601     | .5601     | .5601     | .5601     | .5228     | .5415     |
| 5    | .5601     | .5729     | .5415     | .5601     | .5228     | .4668     | .5788     |
| 6    | .5788     | .5914     | .5601     | .5788     | .5601     | .5228     | .5788     |
| 7    | .5975     | .5788     | .5601     | .5788     | .3734     | .5788     | .5975     |
| 8    | .5601     | .5601     | .3734     | .5601     | .5544     | .5601     | .5788     |
| 9    | .567      | .5729     | .5729     | .5975     | .5729     | .5975     | .6161     |
| 10   | .5729     | .6036     | .5601     | .3841     | .6036     | .6161     | .6161     |
| 11   | .5729     | .567      | .3881     | .6036     | .6224     | .5975     | .5601     |
| 12   | .567      | .567      | .5544     | .6036     | .6224     | .5975     | .5914     |
| 13   | .567      | .567      | .6219     | .6036     |           | .6161     | .5853     |
| 14   | .5487     | .6036     | .6036     | .6036     | .6036     | .5975     | .5853     |
| 15   | .567      | .6036     | .6219     | .6036     | .6224     | .5228     | .5487     |
| 16   | .6036     | .5853     | .6036     | .6036     | .6224     | .4854     | .6036     |
| 17   | .567      | .5853     | .6036     | .4024     | .6979     | .4854     |           |
| 18   | .5487     | .567      | .5729     | .567      | .6224     | .4527     | .0549     |
| 19   | .567      | .5853     | .5914     | .567      | .6224     | .5975     | .0739     |
| 20   | .5544     | .5487     | .5487     | .3696     | .5847     | .5788     | .5544     |
| 21   | .5544     | .567      | .0914     | .5729     | .5847     | .5788     | .5788     |
| 22   | .5544     | .5729     | .3734     | .5729     | .6036     | .5975     | .6099     |
| 23   | .5601     | .4294     | .3734     | .5544     | .5847     | .5975     | .5788     |
| 24   | .5975     | .5544     | .5601     | .5601     | .5601     | .5788     | .5975     |
| Max  | .6036     | .6036     | .6219     | .6036     | .6979     | .6161     | .6161     |
| Min  | .5487     | .4294     | .0914     | .3696     | .3734     | .4527     | .0549     |
| Avg  | .5708     | .5684     | .5153     | .5547     | .5818     | .5603     | .5344     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 202 / IRB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1494     | .1478     | .1867     | .168      |           | .1867     | .1867     |
| 2    | .1494     | .1494     | .1867     | .168      |           | .2054     | .2054     |
| 3    | .1494     | .1494     | .1867     | .168      | .2054     | .2054     | .2054     |
| 4    | .1494     | .1494     | .1867     | .1698     |           | .2054     | .2054     |
| 5    | .1867     | .1494     | .2054     | .168      | .2054     | .2427     | .2054     |
| 6    | .2054     | .1867     | .2054     | .1867     | .2427     | .2801     | .1867     |
| 7    | .2054     | .2218     | .2241     | .2241     | .2801     | .2614     | .2054     |
| 8    | .2614     | .2614     | .2427     | .2801     | .2587     | .2427     | .2241     |
| 9    | .2229     | .2614     | .2279     | .2614     | .2587     | .2614     | .2614     |
| 10   | .2218     | .2515     | .2614     | .2743     | .2641     | .2987     | .2587     |
| 11   | .2218     | .2374     | .2957     | .2743     | .2641     | .2614     | .2587     |
| 12   | .2195     | .2454     | .2561     | .2572     | .2641     | .2987     | .2587     |
| 13   | .2195     | .2427     | .2561     | .2572     |           | .2614     | .2561     |
| 14   | .2012     | .2454     | .2561     | .2601     | .2452     | .2427     | .2195     |
| 15   | .2172     | .2454     | .2534     | .2572     | .2452     | .2614     | .2172     |
| 16   | .2896     | .2804     | .2926     | .2572     | .2829     | .2801     | .2926     |
| 17   | .2926     | .298      | .2926     | .2743     | .3395     | .2987     |           |
| 18   | .2926     | .2454     | .2587     | .2601     | .2829     | .2829     | .0739     |
| 19   | .2218     | .2454     | .2218     | .2401     | .2075     | .2427     | .0739     |
| 20   | .2218     | .2279     | .2241     | .2279     | .2263     | .2427     |           |
| 21   | .2218     | .2103     | .1867     | .2402     | .2075     | .2427     |           |
| 22   | .1848     | .2103     | .1867     | .2218     | .2075     | .2054     |           |
| 23   | .1848     | .2054     | .1867     | .2033     | .2075     | .2054     |           |
| 24   | .168      | .1494     |           | .1867     | .2054     | .2054     | .2054     |
| Max  | .2926     | .298      | .2957     | .2801     | .3395     | .2987     | .2926     |
| Min  | .1494     | .1478     | .1867     | .168      | .2054     | .1867     | .0739     |
| Avg  | .2108     | .2174     | .2296     | .2286     | .2450     | .2467     | .2106     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 203 / Nathvalley

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7177    | 1.6804    | .7468     | 1.7364    | 1.9044    | 1.8671    | 1.8484    |
| 2    | 1.6057    | 1.6057    | 1.251     | 1.6804    | 1.8671    | 1.9044    | 1.8298    |
| 3    | 1.5684    | 1.6057    | 1.475     | 1.6975    | 1.8671    | 1.7737    | 1.7924    |
| 4    | 1.587     | 1.5684    | 1.6057    | 1.7177    | 1.7737    | 1.8298    | 1.7551    |
| 5    | 1.587     | 1.6057    | 1.8298    | 1.7551    | 1.7737    | 1.8671    | 1.6617    |
| 6    | 1.7177    | 1.8671    | 1.9418    | 1.8671    | 1.8858    | 1.8858    | 1.8671    |
| 7    | 1.9418    | 1.9605    | 2.0911    | 1.7924    | 2.0725    | 1.9791    | 1.9978    |
| 8    | 1.8671    | 1.7924    | 1.8671    | 1.643     | 1.848     | 1.9231    | 1.8858    |
| 9    | 1.7193    | 1.4937    | 1.7187    | 1.643     | 1.7187    | 1.8671    | 1.6057    |
| 10   | 1.4969    | 1.4632    | 1.6244    | 1.4815    | 1.6598    | 1.6991    | 1.5708    |
| 11   | 1.3169    | 1.3535    | 1.3169    | 1.39      | 1.7541    | 1.5684    | 1.4784    |
| 12   | 1.262     | 1.3535    | 1.2803    | 1.4083    | 1.6409    | 1.5497    | 1.3169    |
| 13   | 1.3169    | 1.3352    | 1.2308    | 1.4083    |           | 1.6057    | 1.39      |
| 14   | 1.3756    | 1.3535    | 1.267     | 1.3352    | 1.5089    | 1.475     | 1.4632    |
| 15   | 1.39      | 1.39      | 1.3032    | 1.4083    | 1.7353    | 1.643     | 1.4266    |
| 16   | 1.448     | 1.4266    | 1.3717    | 1.39      | 1.7541    | 1.6057    | 1.5364    |
| 17   | 1.4815    | 1.5364    | 1.4632    | 1.4449    | 1.773     | 1.6057    |           |
| 18   | 1.6095    | 1.4998    | 1.5524    | 1.4266    | 1.7918    | 1.5466    |           |
| 19   | 1.829     | 1.7741    | 1.7741    | 1.829     | 2.0748    | 1.9605    |           |
| 20   | 1.9404    | 1.8656    | 1.9605    | 1.9589    | 2.1125    | 2.1472    |           |
| 21   | 1.7741    | 1.7924    | 1.8671    | 1.848     | 1.905     | 1.9605    |           |
| 22   | 1.848     | 1.9035    | 1.9044    | 1.9959    | 1.9805    | 1.8298    |           |
| 23   | 1.848     | 1.9044    | 1.8671    | 1.9959    | 2.0559    | 1.8671    |           |
| 24   | 1.8111    | 1.7924    |           | 1.7924    | 1.9044    | 1.9044    | 1.8671    |
| Max  | 1.9418    | 1.9605    | 2.0911    | 1.9959    | 2.1125    | 2.1472    | 1.9978    |
| Min  | 1.262     | 1.3352    | .7468     | 1.3352    | 1.5089    | 1.475     | 1.3169    |
| Avg  | 1.6275    | 1.6218    | 1.5787    | 1.6519    | 1.8418    | 1.7861    | 1.6643    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 205 / Walmi EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0373     | .0373     | .0373     | .0373     | .056      | .056      | .056      |
| 2    | .0373     | .0373     | .0373     | .0373     | .056      | .056      | .056      |
| 3    | .0373     | .0373     | .0373     | .0377     | .056      | .056      | .056      |
| 4    | .0373     | .0373     | .0373     | .0377     | .056      | .056      | .056      |
| 5    | .0373     | .0373     | .0373     | .0377     | .056      | .0747     | .056      |
| 6    | .0187     | .0373     | .0373     | .0373     | .056      | .0747     | .056      |
| 7    | .0187     | .037      | .0373     | .0373     | .056      | .0747     | .056      |
| 8    | .0187     | .056      | .0373     | .056      | .0554     | .0747     | .056      |
| 9    | .0154     | .0373     | .0366     | .056      | .0924     | .056      | .0747     |
| 10   | .0739     | .0732     | .0747     | .0914     | .0943     | .056      | .0747     |
| 11   | .0739     | .1097     | .112      | .0914     | .0943     | .0934     | .0739     |
| 12   | .0732     | .0914     | .112      | .0732     | .0943     | .0934     | .0739     |
| 13   | .0366     | .0914     | .0739     | .0732     |           | .0747     | .0732     |
| 14   | .0366     | .0732     | .0732     | .0732     | .0754     | .0747     | .0549     |
| 15   | .0366     | .0549     | .1097     | .0732     | .0754     | .0747     | .0732     |
| 16   | .0366     | .0549     | .0732     | .0732     | .0754     | .0747     | .0732     |
| 17   | .0366     | .0549     | .0732     | .0549     | .0754     | .0747     | .0185     |
| 18   | .0366     | .0183     | .037      | .0549     | .0566     | .0566     | .0185     |
| 19   | .037      | .0366     | .037      | .0549     | .0566     | .056      | .037      |
| 20   | .037      | .0366     | .0373     | .0514     | .0566     | .056      |           |
| 21   | .037      | .0549     | .0373     | .0554     | .0566     | .0747     |           |
| 22   | .037      | .037      | .0373     | .0526     | .0566     | .056      | .0373     |
| 23   | .0373     | .0373     | .0373     | .0554     | .0566     | .056      | .0373     |
| 24   | .0373     | .0373     | .0373     | .0373     | .056      | .056      | .056      |
| Max  | .0739     | .1097     | .112      | .0914     | .0943     | .0934     | .0747     |
| Min  | .0154     | .0183     | .0366     | .0373     | .0554     | .056      | .0185     |
| Avg  | .0384     | .0507     | .0541     | .0558     | .0661     | .0669     | .0557     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 206 / Nakshatrawadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2883    | 1.2696    | 1.307     | 1.2323    | 1.3817    | 1.307     | 1.3256    |
| 2    | 1.2696    | 1.2696    | 1.1763    | 1.1763    | 1.3817    | 1.3443    | 1.3443    |
| 3    | 1.2696    | 1.251     | 1.1576    | 1.1203    | 1.3443    | 1.363     | 1.307     |
| 4    | 1.2696    | 1.2696    | 1.1763    | 1.1763    | 1.3443    | 1.4003    | 1.307     |
| 5    | 1.1949    |           | 1.251     | 1.2323    | 1.3443    | 1.4937    | 1.307     |
| 6    | 1.6057    | 1.5684    | 1.531     | 1.5684    | 1.6804    | 1.6057    | 1.531     |
| 7    | 1.6991    | 1.6804    | 1.8671    | 1.7924    | 1.9791    | 1.7924    | 1.7924    |
| 8    | 1.7551    | 1.5684    | 1.7924    | 1.7177    | 1.8111    | 1.7177    | 1.7364    |
| 9    | 1.6461    | 1.4045    | 1.6095    | 1.5524    | 1.5708    | 1.6244    | 1.6057    |
| 10   | 1.4784    | 1.4266    | 1.5123    | 1.4998    | 1.5844    | 1.5684    | 1.6617    |
| 11   | 1.3169    | 1.4083    | 1.4045    | 1.39      | 1.5466    | 1.475     | 1.4784    |
| 12   | 1.2803    | 1.4266    | 1.2803    | 1.39      | 1.5089    | 1.4377    |           |
| 13   | 1.2803    | 1.1706    | 1.2803    | 1.3169    |           | 1.307     | .9877     |
| 14   | 1.2308    | 1.3169    | 1.3169    | 1.4083    | 1.3014    | 1.307     | 1.3032    |
| 15   | 1.267     | 1.39      | 1.3032    | 1.3717    | 1.5089    | 1.363     | 1.3169    |
| 16   | 1.2803    | 1.3352    | 1.3717    | 1.4632    | 1.4632    | 1.3817    | 1.4998    |
| 17   | 1.3169    | 1.3352    | 1.39      | 1.4632    | 1.5089    | 1.419     |           |
| 18   | 1.3169    | 1.2986    | 1.4784    | 1.4083    | 1.4335    | 1.3817    |           |
| 19   | 1.4632    | 1.5912    | 1.5524    | 1.5546    | 1.5844    | 1.5123    |           |
| 20   | 1.4969    | 1.6095    | 1.6244    | 1.7002    | 1.6787    | 1.531     |           |
| 21   | 1.4045    | 1.5912    | 1.5154    | 1.5893    | 1.5089    | 1.4937    |           |
| 22   | 1.386     | 1.46      | 1.4563    | 1.5524    | 1.5466    | 1.4377    | .8589     |
| 23   | 1.3306    | 1.4377    | 1.419     | 1.4415    | 1.4523    | 1.4003    | .6722     |
| 24   | 1.3256    | 1.307     | 1.3443    | 1.307     | 1.3817    | 1.3256    | 1.3256    |
| Max  | 1.7551    | 1.6804    | 1.8671    | 1.7924    | 1.9791    | 1.7924    | 1.7924    |
| Min  | 1.1949    | 1.1706    | 1.1576    | 1.1203    | 1.3014    | 1.307     | .6722     |
| Avg  | 1.3822    | 1.4081    | 1.4216    | 1.4344    | 1.5150    | 1.4579    | 1.3534    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 201 / 11 KV DEOGIRI VALLEY  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9345     | .9719     | 1.084     | 1.0093    | 1.0648    | 1.0268    | 1.0268    |
| 2    | .9345     | .9345     | 1.0093    | .9719     | .8746     | .9507     | .9507     |
| 3    | .9345     | .9345     | 1.0093    | .9719     | .8746     | .9507     | .9507     |
| 4    | 1.0093    | 1.0093    | 1.0466    | 1.0093    | .8746     | .9507     | .9507     |
| 5    | 1.1214    |           | 1.084     | 1.084     | .9887     | 1.1028    | 1.0648    |
| 6    | 1.2709    | 1.1588    | 1.1214    | 1.1588    | 1.2169    | 1.2929    | 1.2169    |
| 7    | 1.4204    | 1.3457    | 1.1962    | 1.2709    | 1.407     | 1.407     | 1.369     |
| 8    | 1.3457    | 1.2709    | 1.2709    | 1.1962    | 1.2169    | 1.369     | 1.331     |
| 9    | 1.1588    | 1.2335    | .9345     | 1.084     | 1.2929    |           | 1.2709    |
| 10   | 1.1458    | 1.0456    | 1.2323    | 1.0082    | 1.307     |           | 1.2709    |
| 11   | 1.2323    | 1.0456    | 1.1576    | 1.0456    | 1.2323    | 1.3831    | 1.1588    |
| 12   | 1.1088    | 1.0082    | 1.1203    | 1.1203    | 1.1949    | 1.2335    | 1.1962    |
| 13   | 1.1203    | .9709     | 1.1203    | 1.0082    | 1.0456    | 1.0466    | 1.1588    |
| 14   | .9709     | .9335     | 1.0456    | .9709     | 1.0456    |           | 1.1588    |
| 15   | 1.1203    | .9709     | 1.0456    | 1.0456    | 1.0456    |           |           |
| 16   | 1.0456    | 1.0082    | 1.1203    | 1.0456    | 1.0082    |           |           |
| 17   | 1.1203    | 1.1203    | 1.1576    | 1.1203    | 1.1203    |           |           |
| 18   | 1.2323    | 1.2323    | 1.3817    | 1.2323    | 1.587     | 1.5684    | 1.0829    |
| 19   | 1.3443    | 1.2696    | 1.3443    | 1.3817    | 1.3817    | 1.4937    |           |
| 20   | 1.1949    | 1.3817    | 1.3443    | 1.419     | 1.419     | 1.3817    | 1.1949    |
| 21   | 1.1203    | 1.3443    | 1.307     | 1.2696    | 1.2696    | 1.3443    | 1.1576    |
| 22   | 1.0456    | 1.2335    | 1.2323    | 1.1576    | 1.1949    | 1.2696    | 1.1576    |
| 23   | 1.1962    | 1.1962    |           | 1.1408    | 1.1789    | 1.2549    |           |
| 24   | .9719     | 1.1214    | 1.1214    | 1.0466    | 1.1408    | 1.1408    | 1.1408    |
| Max  | 1.4204    | 1.3817    | 1.3817    | 1.419     | 1.587     | 1.5684    | 1.369     |
| Min  | .9345     | .9335     | .9345     | .9709     | .8746     | .9507     | .9507     |
| Avg  | 1.1292    | 1.1192    | 1.1516    | 1.1154    | 1.1659    | 1.2315    | 1.1478    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 203 / 11 KV PRIYA COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3083    | 1.3083    | 1.3083    | 1.3083    | 1.369     | 1.369     | 1.369     |
| 2    | 1.2709    | 1.3083    | 1.3083    | 1.3083    | 1.2169    | 1.2929    | 1.1408    |
| 3    | 1.2709    | 1.3083    | 1.3083    | 1.3083    | 1.2169    | 1.2929    | 1.1408    |
| 4    | 1.3457    |           | 1.3831    | 1.3457    | 1.2169    | 1.2929    | 1.1408    |
| 5    | 1.4578    | 1.4578    | 1.4578    | 1.4578    | 1.369     | 1.5211    | 1.369     |
| 6    | 1.4952    | 1.5326    | 1.4952    | 1.57      | 1.5972    | 1.6732    | 1.5972    |
| 7    | 1.57      | 1.6447    | 1.5326    | 1.8316    | 1.8253    | 1.8253    | 1.7493    |
| 8    | 1.57      | 1.57      | 1.57      | 1.6447    | 1.7493    | 1.5972    | 1.7493    |
| 9    | 1.57      | 1.4952    | 1.4952    | 1.4952    | 1.5211    |           | 1.4952    |
| 10   | 1.4045    | 1.2696    | 1.3443    | 1.3443    | 1.2696    |           | 1.2709    |
| 11   | 1.3443    | 1.1949    | 1.3443    | 1.2696    | 1.1949    | 1.4952    | 1.2709    |
| 12   | 1.3443    | 1.2696    | 1.2696    | 1.2696    | 1.2696    | 1.2709    | 1.2709    |
| 13   | 1.2696    | 1.2696    | 1.2696    | 1.2696    | 1.1949    | 1.2709    | 1.2709    |
| 14   | 1.1949    | 1.2696    | 1.1949    | 1.2696    | 1.1203    |           | 1.2709    |
| 15   | 1.2567    | 1.2696    |           | 1.2696    | 1.1949    |           |           |
| 16   | 1.1949    | 1.2696    | 1.1203    | 1.2696    | 1.2696    |           |           |
| 17   | 1.2696    | 1.3443    | 1.1576    | 1.3443    | 1.3443    |           |           |
| 18   | 1.3443    | 1.4937    | 1.4563    | 1.419     | 1.4937    | 1.7177    | 1.4937    |
| 19   | 1.4937    | 1.6057    | 1.6057    | 1.643     | 1.7177    | 1.7177    | 1.3817    |
| 20   | 1.643     | 1.7177    | 1.643     | 1.7177    | 1.7177    | 1.643     | 1.419     |
| 21   | 1.6057    | 1.6804    | 1.643     | 1.7177    | 1.643     | 1.5684    |           |
| 22   | 1.4937    | 1.6073    | 1.4937    | 1.6057    | 1.531     | 1.4937    | 1.4937    |
| 23   | 1.4952    | 1.4952    | 1.4952    | 1.5972    | 1.5089    | 1.7493    |           |
| 24   | 1.4578    | 1.4204    | 1.3457    | 1.3457    | 1.4451    | 1.5211    | 1.5211    |
| Max  | 1.643     | 1.7177    | 1.643     | 1.8316    | 1.8253    | 1.8253    | 1.7493    |
| Min  | 1.1949    | 1.1949    | 1.1203    | 1.2696    | 1.1203    | 1.2709    | 1.1408    |
| Avg  | 1.4030    | 1.4262    | 1.4018    | 1.4426    | 1.4165    | 1.5174    | 1.3903    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 204 / 11 KV PETHE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1214    | 1.1214    | 1.1214    | 1.2709    | 1.2929    | 1.2549    | 1.2549    |
| 2    | 1.084     | 1.084     | 1.084     | 1.1962    | 1.0268    | 1.0648    | 1.0648    |
| 3    | 1.084     | 1.084     | 1.084     | 1.1962    | 1.0268    | 1.0648    | 1.0648    |
| 4    | 1.1214    | 1.2709    | 1.1214    | 1.2709    | 1.0268    | 1.1408    | 1.0648    |
| 5    | 1.1962    | 1.3831    | 1.1588    | 1.3831    | 1.2169    | 1.2169    | 1.2929    |
| 6    | 1.3831    | 1.5326    | 1.1962    | 1.5326    | 1.4831    | 1.5211    | 1.5591    |
| 7    | 1.5326    | 1.6447    | 1.2709    | 1.6821    | 1.6352    | 1.6352    | 1.7113    |
| 8    | 1.4578    | 1.3831    | 1.3457    | 1.57      | 1.5211    | 1.5972    | 1.6352    |
| 9    | 1.3457    | 1.2335    | 1.4578    | 1.3083    | 1.331     |           |           |
| 10   | 1.1088    | 1.1203    | 1.1576    | 1.307     | 1.1576    |           |           |
| 11   | 1.1203    | 1.0456    | 1.1203    | 1.1203    | 1.1576    | 1.3457    |           |
| 12   | .9709     | 1.0082    | 1.0456    | 1.1203    | 1.0456    | 1.2709    | .0748     |
| 13   | .9709     | 1.1203    | 1.0456    | 1.0456    | 1.1203    | .9719     | .0748     |
| 14   | .9335     | 1.0082    | 1.0082    | 1.0082    | 1.0082    |           |           |
| 15   | 1.0456    | 1.0456    | 1.0456    | 1.0082    | 1.1203    |           |           |
| 16   | 1.0456    | 1.0082    | 1.0082    | 1.1203    | 1.1203    |           |           |
| 17   | 1.1203    | 1.1203    | 1.0456    | 1.2323    | 1.419     |           |           |
| 18   | 1.2323    | 1.419     | 1.3443    | 1.307     | 1.4937    | 1.307     |           |
| 19   | 1.4563    | 1.531     | 1.6057    | 1.6057    | 1.6804    | 1.531     | 1.3443    |
| 20   | 1.4937    | 1.7177    | 1.7177    | 1.7177    | 1.7177    | 1.7177    | 1.7924    |
| 21   | 1.419     | 1.6057    | 1.6804    | 1.6057    | 1.643     | 1.4937    |           |
| 22   | 1.3443    | 1.4952    | 1.6057    | 1.4937    | 1.4937    | 1.419     | 1.5684    |
| 23   | 1.2335    | 1.2748    | 1.3457    | 1.5591    | 1.5089    | 1.407     | 1.4335    |
| 24   | 1.2335    | 1.1588    | 1.1962    | 1.3083    | 1.331     | 1.2929    | 1.331     |
| Max  | 1.5326    | 1.7177    | 1.7177    | 1.7177    | 1.7177    | 1.7177    | 1.7924    |
| Min  | .9335     | 1.0082    | 1.0082    | 1.0082    | 1.0082    | .9719     | .0748     |
| Avg  | 1.2106    | 1.2673    | 1.2422    | 1.3321    | 1.3157    | 1.3474    | 1.2178    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 206 / 11 KV DARGA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4499     | .4499     | .4499     | .4499     | .4563     | .4183     | .4183     |
| 2    | .4124     | .4124     | .4124     | .4124     | .4183     | .4183     | .4183     |
| 3    | .3749     | .4124     | .4124     | .4124     | .4183     | .4183     | .4183     |
| 4    | .4124     | .4499     | .4124     | .4499     | .4183     | .4563     | .4183     |
| 5    | .4499     | .4874     | .4874     | .5249     | .4536     | .4944     | .4944     |
| 6    | .4874     | .5249     | .5249     | .5249     | .4944     | .5704     | .5324     |
| 7    | .5249     | .5624     | .5249     | .5624     | .5704     | .6084     | .5704     |
| 8    | .5249     | .4874     | .5624     | .5249     | .5704     | .5704     | .5324     |
| 9    | .5249     | .4874     | .5249     | .5249     | .1141     |           | .5249     |
| 10   | .5175     | .4854     | .4854     | .5228     | .112      |           | .4874     |
| 11   | .4481     | .4481     | .4854     | .4854     | .0747     | .5249     | .4499     |
| 12   | .4481     | .2987     | .4854     | .4108     | .0747     | .4499     | .4499     |
| 13   | .4108     | .4108     | .4108     | .4481     | .0747     | .4874     | .4124     |
| 14   | .3734     | .3734     | .4108     | .2614     | .4481     |           | .3749     |
| 15   | .3734     | .3734     | .3734     | .4108     | .4481     |           |           |
| 16   | .2614     |           | .4108     | .4108     | .4108     |           |           |
| 17   | .2987     | .4481     | .3734     | .4481     | .4481     |           |           |
| 18   | .4108     | .5601     | .4854     | .4854     | .5228     | .5975     |           |
| 19   | .5975     | .6348     | .6348     | .5975     | .5975     | .6348     | .5601     |
| 20   |           | .6348     | .6722     | .6722     | .6348     | .5975     | .5975     |
| 21   | .4854     | .5975     | .6348     | .5975     | .5975     | .5601     | .5228     |
| 22   | .4481     | .5249     | .5601     | .5601     | .5601     | .5228     | .5228     |
| 23   | .4874     | .5249     | .4874     | .5324     | .4904     | .5324     | .3772     |
| 24   | .4874     | .4499     | .4874     | .4499     | .4944     | .4563     | .4944     |
| Max  | .5975     | .6348     | .6722     | .6722     | .6348     | .6348     | .5975     |
| Min  | .2614     | .2987     | .3734     | .2614     | .0747     | .4183     | .3749     |
| Avg  | .4439     | .4800     | .4879     | .4867     | .4126     | .5177     | .4789     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 207 / 11 KV RAMGOPAL NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .225      | .225      | .225      | .225      | .3042     | .2662     | .2662     |
| 2    | .225      | .225      | .225      | .225      | .2662     | .2662     | .2662     |
| 3    | .225      | .225      | .225      | .225      | .2662     | .2662     | .2662     |
| 4    | .225      | .2625     | .225      | .225      | .2662     | .3042     | .2662     |
| 5    | .2625     | .3        | .225      | .2625     | .3042     | .3042     | .3042     |
| 6    | .3        | .3374     | .2625     | .3374     | .3042     | .3423     | .3423     |
| 7    | .3374     | .3374     | .2625     | .3374     | .3042     | .3423     | .3423     |
| 8    | .3        | .2625     | .2625     | .2625     | .3042     | .3423     | .3423     |
| 9    | .2587     | .2625     | .225      | .2625     | .2662     |           | .3        |
| 10   | .2957     | .2614     | .2241     | .2241     | .2241     |           | .2625     |
| 11   | .2614     | .2241     | .2241     | .2241     | .2614     | .3374     | .2625     |
| 12   | .2614     | .2241     | .2241     | .2241     | .2241     | .2625     | .225      |
| 13   | .2614     | .2241     | .2241     | .2241     | .2614     | .225      | .225      |
| 14   | .2957     | .2241     | .2241     | .2241     | .2614     |           | .225      |
| 15   | .2614     | .2241     | .2241     | .2241     | .2241     |           |           |
| 16   | .2987     | .2614     | .1867     | .2241     | .2614     |           |           |
| 17   | .3734     | .2987     | .2241     | .2614     | .2987     |           |           |
| 18   | .3734     | .3734     | .2614     | .2987     | .3361     | .3734     | .3361     |
| 19   | .4108     | .3734     | .3734     | .3734     | .3734     | .4108     | .2987     |
| 20   | .3361     | .3361     | .2987     | .4108     | .4108     | .3361     | .2987     |
| 21   | .2987     | .2987     | .2614     | .3734     | .2987     | .2987     | .2987     |
| 22   | .2614     | .2625     | .2241     | .2987     | .2987     | .2614     | .2987     |
| 23   | .2625     | .2625     | .225      | .3042     | .3042     | .3423     |           |
| 24   | .225      | .225      | .225      | .225      | .3042     | .3018     | .3042     |
| Max  | .4108     | .3734     | .3734     | .4108     | .4108     | .4108     | .3423     |
| Min  | .225      | .2241     | .1867     | .2241     | .2241     | .225      | .225      |
| Avg  | .2848     | .2713     | .2401     | .2699     | .2887     | .3102     | .2866     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 209 / 11 KV AMC Padegaon

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0375     | .0375     | .0375     | .0375     | .038      | .057      | .057      |
| 2    | .0375     | .0375     | .0375     | .0375     | .038      | .038      | .038      |
| 3    | .0375     | .0375     | .0375     | .0375     | .038      | .038      | .038      |
| 4    | .0375     | .0375     | .0375     | .0375     | .038      | .038      | .038      |
| 5    | .0375     | .0375     | .0375     | .0375     | .038      | .038      | .038      |
| 6    | .0375     | .0375     | .0375     | .0375     | .057      | .057      | .038      |
| 7    | .0375     | .0375     | .075      | .0375     | .057      | .057      | .038      |
| 8    | .0375     | .0375     | .075      | .075      | .057      | .038      | .038      |
| 9    | .0562     | .0375     | .1125     | .075      |           |           | .0562     |
| 10   | .0739     | .0934     | .0747     | .0747     | .0747     |           | .075      |
| 11   | .0747     | .0934     | .0747     | .0747     | .056      | .0187     | .075      |
| 12   | .1494     | .0934     | .0373     | .056      | .056      | .075      | .075      |
| 13   | .112      | .0934     | .0747     | .056      | .056      | .0375     | .0375     |
| 14   | .0747     | .112      | .056      | .056      | .0373     |           | .0375     |
| 15   | .0747     | .056      |           | .056      | .0373     |           |           |
| 16   | .0747     | .056      | .0747     | .056      | .0747     |           |           |
| 17   | .112      | .0747     | .056      | .0747     | .0747     |           |           |
| 18   | .1494     | .0747     | .056      | .0754     | .112      | .1867     | .056      |
| 19   | .1494     | .056      | .112      | .1132     | .112      | .1494     | .056      |
| 20   | .112      | .1494     | .1307     | .112      | .0943     | .1132     | .112      |
| 21   | .0747     | .112      | .0934     | .0747     | .0566     | .0566     | .0747     |
| 22   | .0747     | .075      | .0747     | .0566     | .0566     | .056      | .0747     |
| 23   | .0375     | .0375     | .0375     | .038      | .0566     | .0761     | .0566     |
| 24   | .0375     | .0375     | .0375     | .0375     | .038      | .057      | .0761     |
| Max  | .1494     | .1494     | .1307     | .1132     | .112      | .1867     | .112      |
| Min  | .0375     | .0375     | .0373     | .0375     | .0373     | .0187     | .0375     |
| Avg  | .0724     | .0647     | .0642     | .0593     | .0589     | .0660     | .0564     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 201 / Jaman Jyoti

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | .4572     | .4572     |
| 2    | .4572     | .4572     |
| 3    | .4572     | .4572     |
| 4    | .4763     | .4763     |
| 5    | .5335     | .5335     |
| 6    | .7811     | .743      |
| 7    | .9907     | 1.0098    |
| 8    | .9526     | .9145     |
| 9    | .8002     | .8954     |
| 10   | .7811     | .724      |
| 11   | .724      | .724      |
| 12   | .6097     | .6478     |
| 13   | .6097     | .6287     |
| 14   | .6097     | .5144     |
| 15   |           | .5525     |
| 16   | .6478     | .5525     |
| 17   | .6859     | .8573     |
| 18   | .8573     | .7049     |
| 19   | .8192     | .724      |
| 20   | .6668     | .7049     |
| 21   | .5716     | .6478     |
| 22   | .5144     | .6478     |
| 23   | .4763     | .4763     |
| 24   | .4572     | .4954     |
| Max  | .9907     | 1.0098    |
| Min  | .4572     | .4572     |
| Avg  | .6494     | .6478     |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 202 / 11 kv subhedari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 1.0098    | 1.086     |
| 2    | .9335     | 1.0669    |
| 3    | .8954     | 1.0669    |
| 4    | .9145     | .9717     |
| 5    | .8764     | .9907     |
| 6    | .9335     | 1.0479    |
| 7    | .8764     | 1.0669    |
| 8    | .9526     | .9526     |
| 9    | .8573     | 1.0479    |
| 10   | .8192     | 1.0098    |
| 11   | .8383     | .8954     |
| 12   | .8764     | .9145     |
| 13   | .8573     | .9335     |
| 14   | .9145     | .9145     |
| 15   | .8192     | .9907     |
| 16   | .8764     | .9335     |
| 17   | .8764     | .9526     |
| 18   | .9335     | 1.0288    |
| 19   | 1.0669    | 1.1622    |
| 20   | 1.105     | 1.2003    |
| 21   | 1.086     | 1.1622    |
| 22   | 1.2384    | 1.1241    |
| 23   | 1.1431    | 1.2003    |
| 24   | 1.0479    | 1.1431    |
| Max  | 1.2384    | 1.2003    |
| Min  | .8192     | .8954     |
| Avg  | .9478     | 1.0360    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 204 / 11 kv Delhi Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 1.5242    | 1.5051    |
| 2    | 1.467     | 1.467     |
| 3    | 1.4861    | 1.4289    |
| 4    | 1.4861    | 1.4289    |
| 5    | 1.5813    | 1.5051    |
| 6    | 2.0767    | 1.9052    |
| 7    | 2.3815    | 2.2291    |
| 8    | 2.3624    | 2.0576    |
| 9    | 2.0957    | 2.0386    |
| 10   | 1.9243    | 1.9433    |
| 11   | 1.7337    | 1.848     |
| 12   | 1.5242    | 1.8099    |
| 13   | 1.5242    | 1.5813    |
| 14   | 1.467     | 1.5432    |
| 15   | 1.448     | 1.448     |
| 16   | 1.5623    | 1.6004    |
| 17   | 1.6575    | 1.829     |
| 18   | 1.9052    |           |
| 19   | 2.21      | 1.5813    |
| 21   | 2.1338    | 1.3146    |
| 22   | 1.9624    | 1.9624    |
| 23   | 1.829     | 1.8099    |
| 24   | 1.5813    | 1.6194    |
| Max  | 2.3815    | 2.2291    |
| Min  | 1.448     | 1.3146    |
| Avg  | 1.7793    | 1.7026    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 205 / 11 kv WATER WORKS  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | .2096     | .2096     |
| 2    | .2096     | .2096     |
| 3    | .2096     | .2096     |
| 4    | .2096     | .2096     |
| 5    | .2286     |           |
| 6    | .2858     | .2858     |
| 7    | .3429     |           |
| 8    | .2858     | .3048     |
| 9    | .2858     | .3048     |
| 10   | .2477     | .2858     |
| 11   | .2477     | .2477     |
| 12   | .2286     | .2477     |
| 13   | .2096     |           |
| 14   | .2096     | .2096     |
| 15   | .2096     | .2286     |
| 16   | .2286     |           |
| 17   | .2286     |           |
| 18   | .2858     | .2477     |
| 19   | .381      | .2667     |
| 20   | .362      |           |
| 21   | .3048     |           |
| 22   | .2667     |           |
| 23   | .2858     |           |
| 24   | .2286     | .2286     |
| Max  | .381      | .3048     |
| Min  | .2096     | .2096     |
| Avg  | .258      | .2464     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 206 / SEVEN HILL

Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.6028    |
| Max  | 2.6028    |
| Min  | 2.6028    |
| Avg  | 2.6028    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 207 / 11 kv Kat kat Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 2.2481    | 2.8387    |
| 2    | 2.191     | 2.0957    |
| 3    | 2.1148    | 2.1148    |
| 4    | 2.1148    | 2.0767    |
| 5    | 2.2291    | 2.1148    |
| 6    | 2.3624    | 2.4196    |
| 7    | 2.7816    | 2.7816    |
| 8    | 2.9531    | 3.0102    |
| 9    | 2.915     | 2.915     |
| 10   | 2.8387    | .6287     |
| 11   | 2.3624    | 2.191     |
| 12   | 2.7054    | 2.2481    |
| 13   | 2.7054    | 2.6292    |
| 14   | 2.5149    | 2.4196    |
| 15   | 2.3624    | 2.3434    |
| 16   | 2.4196    | 2.4006    |
| 17   | 2.5911    | 2.6673    |
| 18   | 2.934     |           |
| 19   | 3.3913    | 3.1245    |
| 20   | 3.3532    | 3.1436    |
| 21   | 3.0864    | 2.9531    |
| 22   | 2.8578    | 3.7532    |
| 23   | 2.7244    | 2.6292    |
| 24   | 2.4387    | 2.3815    |
| Max  | 3.3913    | 3.7532    |
| Min  | 2.1148    | .6287     |
| Avg  | 2.6332    | 2.5165    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 209 / Bhim Tekdi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 1.7718    | 1.9243    |
| 2    | 1.6956    | 1.8861    |
| 3    | 1.6385    | 1.6385    |
| 4    | 1.6575    | 1.6194    |
| 5    | 1.7337    | 1.6956    |
| 6    | 2.1719    | 2.0576    |
| 7    | 2.3624    | 2.0767    |
| 8    | 2.3815    | 2.2291    |
| 9    | 2.2862    | 2.0957    |
| 10   | 1.829     | 1.9052    |
| 11   | 1.829     | 1.829     |
| 12   | 1.7147    | 1.6956    |
| 13   | 1.6004    | 1.6575    |
| 14   | 1.5623    | 1.6194    |
| 15   | 1.6004    | 1.6194    |
| 16   | 1.6385    | 1.6766    |
| 17   | 1.8099    | 1.7909    |
| 18   | 1.8861    |           |
| 19   | 2.2672    |           |
| 20   | 2.2672    | 2.5149    |
| 21   | 2.1529    | 2.2862    |
| 22   | 2.1529    | 2.2291    |
| 23   | 1.9052    | 2.1148    |
| 24   | 1.9052    | 1.9052    |
| Max  | 2.3815    | 2.5149    |
| Min  | 1.5623    | 1.6194    |
| Avg  | 1.9092    | 1.9121    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 210 / Bhagat Singh

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 1.2193    | 1.2193    |
| 2    | 1.1431    | 1.1812    |
| 3    | 1.1241    | 1.1241    |
| 4    | 1.086     | 1.105     |
| 5    | 1.2003    | 1.1812    |
| 6    | 1.467     | 1.448     |
| 7    | 1.6575    | 1.6004    |
| 8    | 1.2955    | 1.4098    |
| 9    | 1.3336    | 1.2955    |
| 10   | 1.2574    | 1.1812    |
| 11   | 1.0479    | 1.0669    |
| 12   | 1.1241    | 1.105     |
| 13   | 1.105     | 1.1241    |
| 14   | 1.2574    | .9907     |
| 15   | 1.105     | 1.105     |
| 16   | 1.1431    | 1.086     |
| 17   | 1.2003    | 1.2765    |
| 18   | 1.2955    | 1.3336    |
| 19   | 1.5432    | 1.4289    |
| 20   | 1.6194    | 1.5242    |
| 21   | 1.5813    | 1.467     |
| 22   | 1.5813    | 1.5051    |
| 23   | 1.4861    | 1.3336    |
| 24   | 1.3146    | 1.2765    |
| Max  | 1.6575    | 1.6004    |
| Min  | 1.0479    | .9907     |
| Avg  | 1.2995    | 1.2654    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 004701 / 132 KV HARSUL S\S

Feeder No / Name : 401 / 33 kv cidco

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 14.5748   | 14.4033   |
| 2    | 13.9461   | 13.7746   |
| 3    | 13.6031   | 13.2602   |
| 4    | 13.203    | 13.0316   |
| 5    | 13.6603   | 13.2602   |
| 6    | 14.9177   | 14.1747   |
| 7    | 16.6324   | 16.0037   |
| 8    | 17.3183   | 16.9182   |
| 9    | 17.604    | 17.3183   |
| 10   | 17.604    | 17.5469   |
| 11   | 17.604    | 17.4897   |
| 12   | 13.203    | 17.5469   |
| 13   | 16.861    | 16.5181   |
| 14   | 16.1751   | 15.9465   |
| 15   | 15.7179   | 15.7179   |
| 16   | 15.6607   | 15.9465   |
| 17   | 16.7467   | 17.0896   |
| 18   | 18.2899   | 17.1468   |
| 19   | 20.6905   | 18.1756   |
| 20   | 20.3475   | 19.2044   |
| 21   | 18.5185   | 17.7755   |
| 22   | 18.0041   | 17.1468   |
| 23   | 17.3183   | 16.4609   |
| 24   | 16.0608   | 15.6607   |
| Max  | 20.6905   | 19.2044   |
| Min  | 13.203    | 13.0316   |
| Avg  | 16.4276   | 16.1466   |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 201 / 11 KV ROSHAN GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.2032    | .2259     | 2.2965    | 2.3525    | .2315     | 2.4272    | .2278     |
| 2    | 2.0538    | .211      | 2.1098    | 2.2405    | .2185     | 2.2032    | .2166     |
| 3    | 1.8671    | .1867     | 1.8671    | 1.8858    | .196      | 1.9791    | .1942     |
| 4    | 2.0911    | .1923     | 1.9231    | 1.8298    | .2016     | 1.8671    | .1942     |
| 5    | 2.1285    | .1998     | 2.0351    | 1.9418    | .2091     | 2.0725    | .196      |
| 6    | 2.0911    | .211      | 2.1098    | 2.0351    | .2203     | 2.2405    | .2016     |
| 7    | 2.1285    | .2203     | 2.3339    | 2.2592    | .2259     | 2.3525    | .2147     |
| 8    | 2.5206    | .2241     | 2.4272    | 2.3525    | .2241     | 2.7446    | .2241     |
| 9    | 2.7446    | 2.5206    | 2.6139    | 2.4646    | 2.4459    | 2.95      | 2.4272    |
| 10   | 2.7073    | 2.5579    | 2.6326    | 2.6139    | 2.5953    | 2.9874    | 2.5766    |
| 11   | 2.6699    | 2.6326    | 2.726     | 2.726     | 2.6139    | 2.9687    | 2.6886    |
| 12   | 2.5206    | 2.6886    | 2.8193    | 2.6699    | 2.4086    | 3.062     |           |
| 13   | 2.5766    | 2.6513    | 2.6699    | 2.6699    | 2.6326    | 3.0994    | 2.6699    |
| 14   | 2.5766    | 2.2779    | 2.6139    | 2.6513    | 2.5393    | 2.782     | 2.6326    |
| 15   | 2.4646    | 2.4459    | 2.4459    | 2.5206    | 2.5579    | 2.3712    | 2.5766    |
| 16   | 2.3899    | 2.3712    | 2.4459    | 2.5019    | 2.3712    | 2.3152    | 2.5393    |
| 17   | .2353     | 2.4272    | 2.5019    | .2502     | 2.5019    | .2334     | 2.5766    |
| 18   | .2521     | 2.5579    | 2.5393    | .2651     | 2.726     | .2521     | 2.4646    |
| 19   | .2894     | 3.1741    | 3.006     | .3099     | 3.0994    | .2857     | 2.9127    |
| 20   | .3025     | 3.0807    | 3.0994    | .3099     | 3.0807    | .2894     | 3.0434    |
| 21   | .2801     | 2.846     | 2.838     | .3025     | 2.95      | .2819     | 2.782     |
| 22   | .2539     | 2.6886    | 2.7073    | .2745     | 2.782     | .2689     | 2.7073    |
| 23   | .2427     | 2.5953    | 2.5953    | .2558     | 2.5579    | .2521     | 2.4832    |
| 24   | 2.3152    | .2371     | 2.4086    | 2.5019    | .2427     | 2.5579    | .2409     |
| Max  | 2.7446    | 3.1741    | 3.0994    | 2.726     | 3.0994    | 3.0994    | 3.0434    |
| Min  | .2353     | .1867     | 1.8671    | .2502     | .196      | .2334     | .1942     |
| Avg  | 1.7461    | 1.726     | 2.4902    | 1.7577    | 1.7430    | 1.8685    | 1.6952    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 202 / 11 KV Nizamuddin Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9605    | .196      | 1.9605    | 1.9418    | .1979     | 2.0725    | .1998     |
| 2    | 1.8671    | .1867     | 1.8671    | 1.8298    | .1886     | 1.8671    | .1886     |
| 3    | 1.6804    | .168      | 1.6804    | 1.6991    | .1774     | 1.6804    | .1774     |
| 4    | 1.7551    | .1736     | 1.7737    | 1.7551    | .1792     | 1.8298    | .1811     |
| 5    | 1.8671    | .183      | 1.8298    | 1.8671    | .183      | 2.1472    | .183      |
| 6    | 1.9404    | .1904     | 2.0165    | 1.9605    | .1904     | 2.2405    | .1867     |
| 7    | 2.0911    | .2259     | 2.1845    | 2.2405    | .2465     | 2.5206    | .2259     |
| 8    | 2.3525    | .2521     | 2.5766    | 2.5206    | .2689     | 2.6886    | .2521     |
| 9    | 2.5206    | 2.4646    | 2.5766    | 2.5766    | 2.6326    | 2.9127    | 2.4086    |
| 10   | 2.726     | 2.5206    | 2.5766    | 2.4646    | 2.5206    | 2.8006    | 2.3525    |
| 11   | 2.5393    | 2.4646    | 2.4646    | 2.4272    | 2.5206    | 2.8567    | 2.3525    |
| 12   | 2.2405    | 2.2405    | 2.4086    | 2.3525    | 2.4086    | 2.9687    | 2.0725    |
| 13   | 2.2405    | 2.2965    | 2.2405    | 2.3525    | 2.3525    | 2.7446    | 2.0725    |
| 14   | 1.9791    | 2.0725    | 2.0165    | 2.1845    | 2.1845    | 2.2405    | 2.0725    |
| 15   | 1.8111    | 1.9605    | 1.9605    | 2.0165    | 1.9605    | 1.8671    | 2.0165    |
| 16   | 1.8671    | 2.0165    | 2.0725    | 2.0725    | 2.0165    | 1.8671    | 2.0165    |
| 17   | .1755     | 2.2405    | 2.1658    | .2072     | 2.3152    | .2016     | 2.0911    |
| 18   | .2259     | 2.4086    | 2.4459    | .2465     | 2.5019    | .2259     | 1.8671    |
| 19   | .2521     | 2.6886    | 2.8006    | .2857     | 2.894     | .2819     | 2.2592    |
| 20   | .2577     | 2.7446    | 2.7446    | .2913     | 2.894     | .2689     | 2.6326    |
| 21   | .2353     | 2.4086    | 2.4272    | .2539     | 2.5393    | .2353     | 2.3339    |
| 22   | .2259     | 2.2965    | 2.2405    | .2409     | 2.5019    | .2353     | 2.2405    |
| 23   | .2147     | 2.2405    | 2.1845    | .2203     | 2.3525    | .2241     | 2.1658    |
| 24   | 3.3362    | .2035     | 2.0165    | 2.0538    | .2072     | 2.2405    | .2147     |
| Max  | 3.3362    | 2.7446    | 2.8006    | 2.5766    | 2.894     | 2.9687    | 2.6326    |
| Min  | .1755     | .168      | 1.6804    | .2072     | .1774     | .2016     | .1774     |
| Avg  | 1.5984    | 1.5351    | 2.2180    | 1.5859    | 1.6014    | 1.7174    | 1.4485    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 203 / 11 KV MONDHA Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.3608    | .351      | 3.4728    | 3.6969    | .379      | 3.5475    | .3828     |
| 2    | 2.9874    | .3342     | 3.3048    | 3.3608    | .3547     | 3.3794    | .366      |
| 3    | 2.8006    | .3174     | 3.1367    | 3.006     | .3342     | 3.2114    | .3398     |
| 4    | 3.1741    | .3267     | 3.2301    | 3.2487    | .3454     | 3.4541    | .3454     |
| 5    | 3.3608    | .3547     | 3.5475    | 3.6969    | .3753     | 3.6969    | .3603     |
| 6    | 3.6222    | .3921     | 4.0703    | 4.145     | .4276     | 4.145     | .379      |
| 7    | 3.9956    | .4686     | 4.481     | 4.537     | .4873     | 4.6864    | .4537     |
| 8    | 4.1823    | .4406     | 4.537     | 4.5744    | .4686     | 4.8544    | .4556     |
| 9    | 4.5184    | 4.425     | 4.2943    | 4.481     | 4.3503    | 4.7051    | 4.5184    |
| 10   | 4.5744    | 4.481     | 4.3503    | 4.3317    | 4.2943    | 4.5184    | 4.2196    |
| 11   | 4.313     | 4.2756    | 4.145     | 4.2383    | 4.313     | 4.5744    | 4.313     |
| 12   | 4.2943    | 4.2383    | 4.0516    | 4.3317    |           | 4.425     | 4.1636    |
| 13   | 3.8089    | 4.0143    | 3.9209    | 4.0143    | 4.2196    | 4.2196    | 3.8649    |
| 14   | 3.5662    | 3.9209    | 3.9022    | 3.8836    | 3.9956    | 3.7342    | 3.6035    |
| 15   | 3.4541    | 3.7902    | 3.8649    | 3.9396    | 4.0143    | 3.4168    | 3.7902    |
| 16   | 3.5101    | 3.5848    | 3.9209    | 3.9582    | 3.9956    | 3.6222    | 4.0143    |
| 17   | .366      | 4.1823    | 4.1636    | .4033     | 4.201     | .3977     | 4.1823    |
| 18   | .4014     | 4.2943    | 4.481     | .4462     | 4.8731    | .435      | 4.145     |
| 19   | .45       | 5.0038    | 5.0598    | .5135     | 5.1158    | .4686     | 4.1823    |
| 20   | .4686     | 5.0972    | 5.0972    | .5228     | 5.1345    | .478      | 4.7238    |
| 21   | .4388     | 4.4997    | 4.5557    | .463      | 4.5744    | .4574     | 4.3317    |
| 22   | .4145     | 4.145     | 4.2196    | .4294     | 4.3317    | .435      | 4.0516    |
| 23   | .394      | 3.9582    | 4.1636    | .4145     | 4.145     | .4182     | 3.9396    |
| 24   | 4.8731    | .3716     | 3.6782    | 3.8649    | .3902     | 3.8462    | .3958     |
| Max  | 4.8731    | 5.0972    | 5.0972    | 4.5744    | 5.1345    | 4.8544    | 4.7238    |
| Min  | .366      | .3174     | 3.1367    | .4033     | .3342     | .3977     | .3398     |
| Avg  | 2.8054    | 2.8028    | 4.0687    | 2.9376    | 2.8313    | 2.9636    | 2.7301    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 204 / Water Works

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .056      | .0037     | .056      | .056      | .0056     | .056      | .0056     |
| 2    | .0373     | .0037     | .0373     | .0373     | .0037     | .056      | .0037     |
| 3    | .0373     | .0037     | .0373     | .0373     | .0037     | .0373     | .0037     |
| 4    | .056      | .0056     | .0373     | .056      | .0056     | .0373     | .0037     |
| 5    | .0747     | .0037     | .056      | .0187     | .0056     | .056      | .0075     |
| 6    | .0747     | .0056     | .0373     | .056      | .0037     | .0747     | .0075     |
| 7    | .0187     | .0037     | .0934     | .056      | .0075     | .0747     |           |
| 8    | .1867     | .0037     | .0747     | .0747     | .0056     | .0747     | .0112     |
| 9    | .1867     | .037      | .0739     | .037      | .1109     | .0747     | .0934     |
| 10   | .0934     | .0924     | .1663     | .1109     | .0934     | .056      | .0934     |
| 11   | .056      | .0739     | .0924     | .0739     | .0934     | .1307     | .0747     |
| 12   | .0373     | .0739     | .0739     | .0554     | .0747     | .1307     | .056      |
| 13   | .056      | .0554     | .037      | .037      | .0373     | .0373     | .0747     |
| 14   | .056      | .0554     | .0739     | .0554     | .0373     | .0373     | .056      |
| 15   | .0373     | .0924     | .037      | .0554     | .056      | .0747     | .0187     |
| 16   | .0373     | .0924     | .0554     | .037      | .0747     | .0934     | .0373     |
| 17   | .0037     | .0747     | .0373     | .0037     | .0747     | .0037     | .1867     |
| 18   | .0037     | .112      | .0934     | .0037     | .1307     | .0075     | .1307     |
| 19   | .0019     | .037      | .0747     | .0037     | .056      | .0075     | .112      |
| 20   | .0112     | .112      | .056      | .0037     | .0934     | .0037     | .112      |
| 21   | .0037     | .1848     | .056      | .0037     | .0934     | .0037     | .0934     |
| 22   | .0093     | .0934     | .056      | .0037     | .1307     | .0112     | .0747     |
| 23   | .0056     | .056      | .0934     | .0056     | .056      | .0093     | .0934     |
| 24   | .056      | .0056     | .056      | .056      | .0075     | .0934     | .0075     |
| Max  | .1867     | .1848     | .1663     | .1109     | .1307     | .1307     | .1867     |
| Min  | .0019     | .0037     | .037      | .0037     | .0037     | .0037     | .0037     |
| Avg  | .0499     | .0534     | .0651     | .0391     | .0525     | .0517     | .0590     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 201 / 11 KV Nehru Bhavan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3292     | .3109     | .3292     | .3109     | .2926     | .3326     | .3292     |
| 2    | .2926     | .2926     | .3109     | .2926     | .2926     | .3326     | .3258     |
| 3    | .2743     | .2926     | .2926     | .2926     | .2743     | .2987     | .2896     |
| 4    | .2743     | .2926     | .2926     | .2926     | .2743     | .2926     | .2896     |
| 5    | .2561     | .2926     | .2926     | .2926     | .2561     | .2957     | .3292     |
| 6    | .2743     | .3292     | .3292     | .3292     | .2561     | .3361     | .3326     |
| 7    | .2926     | .4024     | .3658     | .3475     | .2561     | .3658     | .3292     |
| 8    | .3475     | .3658     | .3658     | .3292     | .3429     | .415      | .3696     |
| 9    | .3395     | .3772     | .3772     | .3772     | .3395     | .3772     | .3292     |
| 10   | .3772     | .3772     | .3772     | .3772     | .3772     | .415      | .2926     |
| 11   | .3772     | .3584     | .3395     | .3772     | .3772     | .415      | .3658     |
| 12   | .3772     | .3395     | .3395     | .3395     | .3772     | .415      | .3658     |
| 13   | .3395     | .3395     | .3018     | .2987     | .2987     | .415      | .3292     |
| 14   | .3361     | .3395     | .3395     | .2987     | .2987     | .3395     | .2926     |
| 15   | .3361     | .3018     | .2987     | .2987     | .2987     | .2987     | .2743     |
| 16   | .2987     | .3018     | .2641     | .2987     | .3018     | .2614     | .2926     |
| 17   | .2957     | .3361     | .2926     | .2987     | .3018     | .3018     | .3395     |
| 18   | .3326     | .2926     | .3292     | .3361     | .3395     | .3018     | .3395     |
| 19   | .3734     | .4024     | .3658     | .3734     | .415      | .415      | .3772     |
| 20   | .4108     | .4755     | .4108     | .4481     | .4527     | .4527     | .3772     |
| 21   | .4066     | .4481     | .3734     | .3696     | .4527     | .415      | .3395     |
| 22   | .3658     | .4108     | .3734     | .3734     | .415      | .415      | .3395     |
| 23   | .3658     | .3658     | .3658     | .3292     | .4108     | .4108     | .3696     |
| 24   | .3658     | .3658     | .3658     | .3292     | .2926     | .3734     | .3326     |
| Max  | .4108     | .4755     | .4108     | .4481     | .4527     | .4527     | .3772     |
| Min  | .2561     | .2926     | .2641     | .2926     | .2561     | .2614     | .2743     |
| Avg  | .3350     | .3504     | .3372     | .3338     | .3331     | .3621     | .3313     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 202 / 11 KV CityChowk Police  
station Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0485    | 2.1948    | 2.1033    | 2.0119    | 2.1948    | 2.1719    | 2.1491    |
| 2    | 1.9204    | 2.0119    | 2.0119    | 1.9204    | 2.1033    | 2.1216    | 2.1216    |
| 3    | 1.7924    | 1.9204    | 1.829     | 1.829     | 2.0119    | 2.0485    | 1.9909    |
| 4    | 1.7558    | 1.8656    | 1.829     | 1.829     | 2.0119    | 2.0538    | 1.9418    |
| 5    | 1.7193    | 1.9204    | 1.829     | 1.9204    | 2.1033    | 1.922     | 1.9753    |
| 6    | 1.7558    | 1.9204    | 1.9204    | 1.9204    | 2.1948    | 2.0911    | 1.9753    |
| 7    | 1.829     | 2.0119    | 1.9753    | 2.0119    | 2.3411    | 2.1068    | 2.0538    |
| 8    | 2.0485    | 2.0119    | 2.0119    | 2.1948    | 2.1948    | 2.2405    | 2.0911    |
| 9    | 2.3152    | 2.3152    | 2.0698    | 2.3152    | 2.3152    | 2.4646    | 2.1948    |
| 10   | 2.5393    | 2.3152    | 2.4646    | 2.3899    | 2.3899    | 2.6139    | 2.3045    |
| 11   | 2.5393    | 2.3899    | 2.4646    | 2.1658    | 2.4646    | 2.6886    | 2.3045    |
| 12   | 2.6886    | 2.6139    | 2.5393    | 2.6139    | 2.6886    | 2.9127    | 2.4691    |
| 13   | 2.6886    | 2.6886    | 2.6886    | 2.4646    | 2.6886    | 2.838     | 2.4143    |
| 14   | 2.5393    | 2.6139    | 2.5393    | 2.3899    | 2.9127    | 2.5393    | 2.3777    |
| 15   | 2.5766    | 2.4646    | 2.4646    | 2.3152    | 2.6513    | 2.3899    | 2.3411    |
| 16   | 2.4646    | 2.4646    | 2.4646    | 2.6139    | 2.6406    | 2.3899    | 2.3045    |
| 17   | 2.5393    | 2.5873    | 2.5873    | 2.5606    | 2.6406    | 2.3388    | 2.4143    |
| 18   | 2.7633    | 2.7351    | 2.7633    | 2.838     | 2.7349    | 2.3388    | 3.5082    |
| 19   | 3.1459    | 3.1367    | 3.4004    | 3.4004    | 3.3573    | 3.2442    | 2.8292    |
| 20   | 3.2922    | 3.3608    | 3.4019    | 3.2526    | 3.3385    | 3.3951    | 3.0178    |
| 21   | 3.0727    | 3.0308    | 2.9995    | 3.1367    | 3.0178    | 3.2442    | 2.5652    |
| 22   | 2.7801    | 2.6139    | 2.7161    | 2.7915    | 2.7161    | 2.9235    | 2.4897    |
| 23   | 2.5606    | 2.3777    | 2.3777    | 2.4691    | 2.2916    | 2.4874    | 2.268     |
| 24   | 2.1948    | 2.3777    | 2.1948    | 2.1948    | 2.3045    | 2.268     | 2.3167    |
| Max  | 3.2922    | 3.3608    | 3.4019    | 3.4004    | 3.3573    | 3.3951    | 3.5082    |
| Min  | 1.7193    | 1.8656    | 1.829     | 1.829     | 2.0119    | 1.922     | 1.9418    |
| Avg  | 2.3988    | 2.4143    | 2.4019    | 2.3979    | 2.5129    | 2.4930    | 2.3508    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 203 / 11KV Ganesh colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.1216    | 2.1033    | 2.0119    | 2.0119    | 2.0119    | 2.2862    | 2.0995    |
| 2    | 2.0119    | 2.0119    | 1.9204    | 1.9204    | 1.9204    | 2.1582    | 2.0698    |
| 3    | 1.829     | 1.9204    |           | 1.829     | 1.9204    | 2.0851    | 2.0119    |
| 4    | 1.7924    | 1.829     | 1.829     | 1.829     | 1.9204    | 2.0538    | 2.0119    |
| 5    | 1.7558    | 1.9204    | 1.9204    | 1.9204    | 2.0119    | 2.0165    | 2.0911    |
| 6    | 1.829     | 2.0119    | 1.9204    | 2.0119    | 2.1033    | 2.1658    | 2.0698    |
| 7    | 2.0119    | 2.1033    | 2.0119    | 2.1033    | 2.1948    | 2.4394    | 2.1719    |
| 8    | 2.1948    | 2.3777    | 2.1948    | 2.1948    | 2.1948    | 2.4025    | 2.3655    |
| 9    | 2.4646    | 2.3899    | 2.3899    | 2.3899    | 2.3899    | 2.6139    | 2.3045    |
| 10   | 2.5019    | 2.2405    | 2.3152    | 2.4646    | 2.5393    | 2.6886    | 2.268     |
| 11   | 2.5393    | 2.3152    | 2.3152    | 2.3899    | 2.4646    | 2.8006    | 2.1948    |
| 12   | 2.5393    | 2.3152    | 2.3152    | 2.3152    | 2.3152    | 2.8006    | 2.1948    |
| 13   | 2.3899    | 2.3152    | 2.3152    | 2.3152    | 2.3152    | 2.7633    | 2.1948    |
| 14   | 2.2405    | 2.4646    | 2.2032    | 2.2405    | 2.0698    | 2.3899    | 2.1033    |
| 15   | 2.2405    | 2.0698    | 2.1437    | 2.0698    | 2.1437    | 1.7741    | 2.0485    |
| 16   | 2.0911    | 2.0698    | 2.1437    | 2.0328    | 2.1125    | 2.0328    | 2.0119    |
| 17   | 2.0911    | 2.1658    | 2.0911    | 2.0911    | 2.1125    | 2.037     | 2.037     |
| 18   | 2.1948    | 2.3899    | 2.2177    | 2.2916    | 2.2634    | 2.1879    | 1.6221    |
| 19   | 2.5133    | 2.5606    | 2.6337    | 2.7069    | 2.3388    | 2.7161    | 2.3388    |
| 20   | 2.5133    | 2.6337    | 2.6981    | 2.8006    | 2.7915    | 2.7161    | 2.452     |
| 21   | 2.3899    | 2.4874    | 2.4874    | 2.5606    | 2.3577    | 2.5652    | 2.2634    |
| 22   | 2.4143    | 2.4646    | 2.4646    | 2.6139    | 2.4897    | 2.4897    | 2.4143    |
| 23   | 2.3045    | 2.2862    | 2.2862    | 2.3777    | 2.5393    | 2.4394    | 2.4272    |
| 24   | 2.1948    | 2.2314    | 2.1948    | 2.1948    | 2.1948    | 2.3411    | 2.3152    |
| Max  | 2.5393    | 2.6337    | 2.6981    | 2.8006    | 2.7915    | 2.8006    | 2.452     |
| Min  | 1.7558    | 1.829     | 1.829     | 1.829     | 1.9204    | 1.7741    | 1.6221    |
| Avg  | 2.2154    | 2.2366    | 2.2184    | 2.2365    | 2.2382    | 2.3735    | 2.1701    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 204 / 11 KV ROJABAG FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5853     | .6401     | .6584     | .695      | .6036     | .6283     | .8871     |
| 2    | .5487     | .6036     | .6219     | .6584     | .5853     | .6348     | .8215     |
| 3    | .5121     | .5853     | .6219     | .6219     | .5487     | .6348     | .7316     |
| 4    | .4755     | .5487     | .6219     | .6219     | .5487     | .5975     | .6878     |
| 5    | .4755     | .5853     | .6584     | .6219     | .5487     | .5975     | .724      |
| 6    | .4961     | .6219     | .6584     | .6584     | .5853     | .6722     | .7762     |
| 7    | .5487     | .6584     | .6584     | .6584     | .5853     | .7095     | .8596     |
| 8    | .5853     | .7316     | .695      | .6584     | .6219     | .7095     | .9335     |
| 9    | .7167     | .7922     | .7922     | .7167     | .7922     | .7545     | .9145     |
| 10   | .679      | .8676     | .8676     | .8676     | .9054     | .8299     | .9511     |
| 11   | .7167     | .9054     | .8676     | .9431     | .9431     | .9431     | .9877     |
| 12   | .7167     | .7922     | .9054     | .9808     | .9808     | .9709     | .9511     |
| 13   | .679      | .7095     | .9431     | .9431     | .9431     | .9808     | .9877     |
| 14   | .7095     | .7545     | .9054     | .9054     | .8962     | 1.0562    | 1.0242    |
| 15   | .7167     | .8676     | .9808     | .8962     | .8589     | 1.1694    | 1.0242    |
| 16   | .7545     | .7095     | .9808     | .9709     | .8299     | 1.1694    | 1.0608    |
| 17   | .7023     | .7023     |           | .9335     | .8299     | 1.0185    | 1.2071    |
| 18   | .7392     | .6283     | .9145     | .8962     | .8676     | .9054     | 1.1317    |
| 19   | .7316     | .8962     | .8871     | .961      | .9431     | 1.094     | 1.1317    |
| 20   | .7842     | .8501     | .8589     | .9431     | .9431     | 1.0562    | 1.0562    |
| 21   | .7023     | .7842     | .7762     | .8962     | .8676     | .9808     | 1.0562    |
| 22   | .6584     | .7842     | .7922     | .8215     | .7545     | .9431     | .9431     |
| 23   | .6584     | .7316     | .7316     | .7316     | .8131     | .961      | 1.0242    |
| 24   | .5853     | .6401     | .695      | .7316     | .6401     | .6722     | .9145     |
| Max  | .7842     | .9054     | .9808     | .9808     | .9808     | 1.1694    | 1.2071    |
| Min  | .4755     | .5487     | .6219     | .6219     | .5487     | .5975     | .6878     |
| Avg  | .6449     | .7246     | .7866     | .8055     | .7682     | .8621     | .9495     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 205 / 11 KV Collector Office NON SHEDDABLE EXPRESS HV FEEDERS  
Express Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0572     | .0572     | .0572     | .0572     | .0572     | .0514     | .0549     |
| 2    | .0572     | .0572     | .0572     | .0572     | .0572     | .0566     | .052      |
| 3    | .0572     | .0572     | .0572     | .0572     | .0572     | .056      | .0543     |
| 4    | .0572     | .0572     | .0572     | .0572     | .0572     | .0554     | .0543     |
| 5    | .0572     | .0572     | .0572     | .0572     | .0572     | .056      | .0739     |
| 6    | .0572     | .0572     | .0572     | .0572     | .0572     | .0554     | .1097     |
| 7    | .0572     | .0572     | .0572     | .0572     | .0572     | .056      | .112      |
| 8    | .0572     | .0762     | .0762     | .0762     | .0572     | .0754     | .1143     |
| 9    | .056      | .1132     | .0754     | .0554     | .0549     | .0566     | .1524     |
| 10   | .0747     | .1886     | .1509     | .1509     | .1509     | .1132     | .1905     |
| 11   | .0754     | .2263     | .2263     | .1886     | .2263     | .1509     | .2286     |
| 12   | .0754     | .2641     | .2263     | .2263     | .2263     | .2263     | .2286     |
| 13   | .0754     | .2263     | .1886     | .2263     | .1886     | .2263     | .2286     |
| 14   | .0566     | .2263     | .1886     | .2263     | .1886     | .2263     | .2286     |
| 15   | .0566     | .1886     | .1886     | .2263     | .1886     | .2263     | .2096     |
| 16   | .056      | .1886     | .2263     | .2263     | .1886     | .2263     | .1905     |
| 17   | .0762     | .1867     | .2218     | .2218     | .1886     | .1886     | .2263     |
| 18   | .0566     | .1509     | .1886     | .1905     | .1509     | .1132     | .1886     |
| 19   | .0566     | .1097     | .1097     | .1494     | .0943     | .0754     | .0943     |
| 20   | .0754     | .0739     | .0754     | .0754     | .0566     | .0377     | .0377     |
| 21   | .0566     | .056      | .1132     | .0566     | .0566     | .0377     | .0377     |
| 22   | .0572     | .0566     | .0754     | .0762     | .0943     | .0377     | .0377     |
| 23   | .0572     | .0572     | .1334     | .0762     | .112      | .0566     | .0732     |
| 24   | .0572     | .0572     | .0572     | .0762     |           | .1132     | .0716     |
| Max  | .0762     | .2641     | .2263     | .2263     | .2263     | .2263     | .2286     |
| Min  | .056      | .056      | .0572     | .0554     | .0549     | .0377     | .0377     |
| Avg  | .0615     | .1186     | .1218     | .1219     | .1141     | .1073     | .1271     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 201 / 11 KV SUREWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9054     | 1.0185    | .9709     | 1.0751    | 1.0829    | 1.094     | 1.0751    |
| 2    | .8589     | .9997     | .9619     | 1.0374    | 1.0374    | 1.0562    | 1.0269    |
| 3    | .8962     | .9808     | .9619     | 1.0185    | .9997     | 1.0374    | 1.0269    |
| 4    | .8962     | .9808     | .9335     | .9997     | .9619     | 1.0185    | .9896     |
| 5    | .9997     | .9431     | 1.0456    | .9431     | 1.0269    | .9997     | 1.0456    |
| 6    | 1.0269    | 1.0374    | 1.0829    | 1.0374    | 1.0829    | 1.0374    | 1.094     |
| 7    | 1.1203    | 1.1694    |           | 1.226     | 1.1458    | 1.2449    | 1.1576    |
| 8    | 1.0642    | 1.0185    |           | 1.094     | 1.0829    | 1.1128    | 1.0642    |
| 9    | 1.0185    | .9808     | 1.3957    | .9808     | 1.0562    | .9709     | .9997     |
| 10   | .9808     | .9619     | 1.0562    | .9808     | .9808     | .9335     | .9431     |
| 11   | .9619     | .9431     | .811      | .9431     | 1.0185    | .8962     | 1.0185    |
| 12   | .9431     | .9431     | .9431     | .9431     | .9808     | .9522     | 1.0374    |
| 13   | .9431     | .9619     | 1.0374    | .9808     | .9808     | .9709     | 1.0082    |
| 14   | .9242     | .9431     | 1.0374    | .9431     | 1.0374    |           | 1.0082    |
| 15   | .9054     | .9808     | 1.0562    | .8676     | .9808     | .9522     | 1.0269    |
| 16   | .9808     | .9522     | 1.0185    | .7922     | .9808     | .9522     | 1.0751    |
| 17   | .9808     | .8962     | 1.0751    | .8676     | 1.0456    | .9709     | 1.094     |
| 18   | 1.0374    | .8402     | 1.0374    | 1.0829    | 1.0642    | 1.0269    | 1.094     |
| 19   | 1.3014    | 1.251     | 1.2826    | 1.2696    | 1.307     | 1.2136    | 1.226     |
| 20   | 1.3957    | 1.3443    | 1.3014    | 1.587     | 1.358     | 1.2826    | 1.226     |
| 21   | 1.3769    | 1.3443    | 1.3014    | 1.4335    | 1.358     | 1.2883    | 1.3203    |
| 22   | 1.2449    | 1.2696    | 1.3014    | 1.2696    | 1.3203    | 1.251     | 1.358     |
| 23   | 1.1694    | 1.2136    | 1.226     | 1.3817    | 1.226     | 1.1883    | 1.2637    |
| 24   | 1.0456    | 1.0562    | 1.0642    | 1.1128    | 1.1203    | 1.1506    | 1.1317    |
| Max  | 1.3957    | 1.3443    | 1.3957    | 1.587     | 1.358     | 1.2883    | 1.358     |
| Min  | .8589     | .8402     | .811      | .7922     | .9619     | .8962     | .9431     |
| Avg  | 1.0407    | 1.0429    | 1.0864    | 1.0778    | 1.0932    | 1.0696    | 1.0963    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 202 / 11kv mayur park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9054     | .9808     | .9619     | .9997     | .9709     | 1.0185    | .9997     |
| 2    | .8589     | .9054     | .8962     | .9431     | .9335     | .9808     | .9522     |
| 3    | .8676     | .9054     | .9149     | .9054     | .8589     | .9431     | .9522     |
| 4    | .9522     | .8865     | .9709     | .9054     | .8871     | .9431     | .9709     |
| 5    | 1.0082    | .9242     | 1.0829    | .8676     | 1.0082    | .9808     | 1.0562    |
| 6    | 1.1016    | 1.094     | 1.2323    | .9808     | 1.2567    | 1.0374    | 1.1949    |
| 7    | 1.2012    | 1.3392    | 1.363     | 1.3014    | 1.3443    | 1.2449    | 1.307     |
| 8    | 1.1203    | 1.1506    | 1.1389    | 1.1883    | 1.1949    | 1.1506    | 1.1576    |
| 9    | 1.0751    | .9808     | .9808     | .9431     | .9808     | 1.0082    | .9808     |
| 10   | .9997     | .8676     | .9054     | .9054     | .8488     | .9335     | .9242     |
| 11   | .9242     | .8676     | .8488     | .8676     | .8488     | .8215     | .8865     |
| 12   | .9054     | .8676     | .8299     | .7922     | .8299     | .8029     | .9054     |
| 13   | .9054     | .8299     | .8299     | .7922     | .8299     | .7655     | .8589     |
| 14   | .9054     | .8299     | .8488     | .8299     | .8676     | .7842     | .8215     |
| 15   | .8299     | .8676     | .8488     | .8299     | .8676     | .8215     | .7842     |
| 16   | .8676     | .8676     | .8488     | .8865     | .9054     | .8215     | .8299     |
| 17   | .8865     | .8962     | .9054     | .9522     | .7095     | .8402     | 1.094     |
| 18   | .9619     | .9808     | .9997     | 1.0082    | .9335     | .8775     | .9997     |
| 19   | 1.0751    | 1.226     | .811      | 1.1576    | 1.1949    | 1.1128    | 1.0185    |
| 20   | 1.2071    | 1.2323    | 1.2071    | 1.587     | 1.3014    | 1.1389    | 1.1694    |
| 21   | 1.2449    | 1.1949    | 1.1883    | 1.7177    | 1.2637    | 1.1389    | 1.4146    |
| 22   | 1.1694    | 1.1389    | 1.2071    | 1.3817    | 1.2637    | 1.1576    | 1.3203    |
| 23   | 1.094     | 1.1506    | 1.1694    | 1.1949    | 1.1694    | 1.1128    | 1.2449    |
| 24   | .9522     | .9997     | .9896     | .9997     | 1.0456    | 1.0374    | .9896     |
| Max  | 1.2449    | 1.3392    | 1.363     | 1.7177    | 1.3443    | 1.2449    | 1.4146    |
| Min  | .8299     | .8299     | .811      | .7922     | .7095     | .7655     | .7842     |
| Avg  | 1.0008    | .9993     | .9992     | 1.0391    | 1.0131    | .9781     | 1.0347    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 204 / 11kv shivneri feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1016    | 1.2071    | 1.1576    | 1.226     | 1.1763    | 1.2826    | 1.251     |
| 2    | 1.0829    | 1.1317    | 1.1203    | 1.1317    | 1.1389    | 1.226     | 1.2449    |
| 3    | 1.0349    | 1.094     | 1.1317    | 1.1317    | 1.1506    | 1.226     | 1.226     |
| 4    | 1.1016    | 1.094     | 1.094     | 1.094     | 1.0642    | 1.2071    | 1.2136    |
| 5    | 1.4563    | 1.1317    | 1.2883    | 1.094     | 1.1883    | 1.2071    | 1.2883    |
| 6    | 1.6817    | 1.3769    | 1.419     | 1.4712    | 1.6032    | 1.5466    | 1.6263    |
| 7    | 2.0911    | 1.8296    | 2.0165    | 2.2634    | 2.0182    | 2.0182    | 2.1845    |
| 8    | 1.9044    | 1.8861    | 2.2779    | 1.9239    | 1.9959    | 1.9239    | 1.885     |
| 9    | 1.8673    | 1.5466    | 1.7164    | 1.773     | 1.7353    | 1.8111    | 1.6598    |
| 10   | 1.5655    | 1.5466    | 1.5466    | 1.4712    | 1.5278    | 1.6804    | 1.4146    |
| 11   | 1.4523    | 1.4335    | 1.4146    | 1.3203    | 1.3957    | 1.531     | 1.3203    |
| 12   | 1.358     | 1.2826    | 1.3203    | 1.2449    | 1.2826    | 1.1203    | 1.2826    |
| 13   | 1.2826    | 1.1506    | 1.2071    | 1.1317    | 1.2449    | 1.1203    | 1.1949    |
| 14   | 1.1694    | 1.094     | 1.1317    | 1.1317    | 1.1506    | 1.1203    |           |
| 15   | 1.094     | 1.0751    | 1.0562    | 1.1317    | 1.1694    | 1.1016    |           |
| 16   | 1.094     | 1.0829    | 1.0562    | 1.1506    | 1.2449    | 1.3443    |           |
| 17   | 1.2826    | 1.1949    | 1.2449    | 1.2323    | 1.2696    | 1.3443    |           |
| 18   | 1.4146    | 1.3443    | 1.5278    | 1.419     | 1.4563    | 1.4003    |           |
| 19   | 1.7541    | 1.7551    | 1.9427    | 1.9231    | 1.9418    | 1.7372    |           |
| 20   | 1.8296    | 1.885     | 1.9239    | 1.8858    | 2.2634    | 1.8673    |           |
| 21   | 1.6221    | 1.6617    | 1.6221    | 1.6632    | 1.6975    | 1.643     | 1.9427    |
| 22   | 1.4901    | 1.4563    | 1.4901    | 1.5123    | 1.5089    | 1.475     | 1.6598    |
| 23   | 1.358     | 1.4003    | 1.4146    | 1.419     | 1.3957    | 1.4335    | 1.4712    |
| 24   | 1.2323    | 1.2449    | 1.2323    | 1.2637    | 1.251     | 1.3203    | 1.251     |
| Max  | 2.0911    | 1.8861    | 2.2779    | 2.2634    | 2.2634    | 2.0182    | 2.1845    |
| Min  | 1.0349    | 1.0751    | 1.0562    | 1.094     | 1.0642    | 1.1016    | 1.1949    |
| Avg  | 1.4300    | 1.3711    | 1.4314    | 1.4171    | 1.4530    | 1.4453    | 1.4774    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 205 / 11kV Aarti  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5281     | .5281     | .5228     | .5658     | .547      | .5658     | .547      |
| 2    | .5041     | .5093     | .4854     | .5281     | .5281     | .5281     | .5228     |
| 3    | .4854     | .5093     | .4904     | .5281     | .5281     | .5281     | .5228     |
| 4    | .5415     | .4904     | .5041     | .547      | .5601     | .5093     | .5281     |
| 5    | .6036     | .4904     | .5041     | .5281     | .6348     | .5093     | .6224     |
| 6    | .6161     | .6602     | .6722     | .6224     | .7655     | .6036     | .7282     |
| 7    | .6722     | .811      | .8402     | .811      | .8215     | .8676     | .8029     |
| 8    | .7842     | .7545     | .7095     | .7922     | .8215     | .8676     | .7655     |
| 9    | .7545     | .679      | .6602     | .7356     | .7545     | .7468     | .7167     |
| 10   | .6413     | .5658     | .6602     | .679      | .6224     | .7468     | .6036     |
| 11   | .6224     | .5658     | .6602     | .6413     | .5281     | .7095     | .6036     |
| 12   | .5658     | .5281     | .6036     |           | .4904     | .6161     | .6036     |
| 13   | .5281     | .5281     | .5093     | .4904     | .415      | .5975     | .5601     |
| 14   | .4904     | .4904     | .4904     | .4904     | .3772     | .5228     | .4481     |
| 15   | .4904     | .5093     | .4904     | .4904     | .3772     | .5041     | .3734     |
| 16   | .5281     | .5041     | .4904     | .5093     | .415      | .4854     | .4904     |
| 17   | .547      | .547      | .6036     | .5415     | .4108     | .5415     | .6413     |
| 18   | .6036     | .6535     | .7733     | .5975     | .4668     | .6348     | .7356     |
| 19   | .6602     | .8029     | .811      | .8029     | .7282     | .8029     | .6602     |
| 20   | .6979     | .7655     | .7545     | .7842     | .7922     | .7468     | .6036     |
| 21   | .6413     | .6722     | .6602     | .6908     | .679      | .6413     | .6036     |
| 22   | .6413     | .6348     | .6413     | .6535     | .6413     | .5975     | .5658     |
| 23   | .5847     | .6161     | .5847     | .5975     | .6036     | .6161     | .5658     |
| 24   | .5415     | .547      | .5601     | .5847     | .5601     | .5847     | .5415     |
| Max  | .7842     | .811      | .8402     | .811      | .8215     | .8676     | .8029     |
| Min  | .4854     | .4904     | .4854     | .4904     | .3772     | .4854     | .3734     |
| Avg  | .5947     | .5985     | .6118     | .6179     | .5862     | .6281     | .5982     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 201 / 11KV JASWANTPURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8673    | 1.7918    | 1.7353    | 1.8099    | 1.8484    | 1.8099    | 1.7528    |
| 2    | 1.8484    | 1.7353    | 1.6975    | 1.7528    | 1.6787    | 1.6956    | 1.6004    |
| 3    | 1.7918    | 1.6975    | 1.7918    | 1.7147    | 1.6598    | 1.5623    | 1.5432    |
| 4    | 1.6975    | 1.8484    | 1.8484    | 1.6385    | 1.7353    | 1.5432    | 1.4861    |
| 5    | 1.7164    | 1.8673    | 1.8673    | 1.6385    | 1.7541    | 1.5813    | 1.4861    |
| 6    | 1.7353    | 1.8861    | 1.8861    | 1.8099    | 1.8107    | 1.829     | 1.6766    |
| 7    | 1.9616    | 2.2822    | 2.3388    | 2.1719    | 2.1879    | 2.2672    | 2.0957    |
| 8    | 2.1879    | 2.32      | 2.4331    | 2.3053    | 2.3765    | 2.6482    | 2.2672    |
| 9    | 2.3954    | 2.452     | 2.3954    | 2.5149    | 2.4006    | 2.7625    | 2.3624    |
| 10   | 2.452     | 2.4143    | 2.3765    | 2.3765    | 2.3434    | 2.6972    | 2.3577    |
| 11   | 2.5086    | 2.3011    | 2.2068    | 2.4143    | 2.3053    | 2.6783    | 2.3011    |
| 12   | 2.452     | 2.1502    | 2.2634    | 2.2634    | 2.0957    | 2.7915    | 2.2634    |
| 13   | 2.2965    | 2.037     | 2.0182    | 2.1502    | 1.9814    | 2.3954    | 2.0748    |
| 14   | 2.1472    | 1.9427    | 1.8484    | 1.9239    | 1.9052    | 2.037     | 1.9805    |
| 15   | 1.8858    | 1.8296    | 1.7541    | 1.8296    | 1.8861    | 1.7541    | 1.9616    |
| 16   | 1.8111    | 1.8107    | 1.8484    | 1.8484    | 1.7528    | 1.7353    | 1.9616    |
| 17   | 2.0005    | 2.0005    | 2.0559    | 2.1338    | 1.9589    | 1.848     | 2.1068    |
| 18   | 2.1338    | 2.2481    | 2.2822    | 2.3053    | 2.1437    | 1.922     | 2.3411    |
| 19   | 2.572     | 2.5149    | 2.6029    | 2.4768    | 2.6326    | 2.4832    | 2.5019    |
| 20   | 2.3815    | 2.4768    | 2.5953    | 2.4196    | 2.5393    | 2.572     | 2.4272    |
| 21   | 2.2672    | 2.3624    | 2.4006    | 2.3815    | 2.3525    | 2.4272    | 2.2965    |
| 22   | 2.2445    | 2.1502    | 2.3624    | 2.2445    | 2.2862    | 2.3152    | 2.2481    |
| 23   | 2.1879    | 2.1691    | 2.3434    | 2.1313    | 2.21      | 2.0576    | 2.1719    |
| 24   | 1.9239    | 1.9239    | 1.8484    | 2.0957    | 1.9239    | 1.9814    | 1.9052    |
| Max  | 2.572     | 2.5149    | 2.6029    | 2.5149    | 2.6326    | 2.7915    | 2.5019    |
| Min  | 1.6975    | 1.6975    | 1.6975    | 1.6385    | 1.6598    | 1.5432    | 1.4861    |
| Avg  | 2.1028    | 2.0922    | 2.1167    | 2.0980    | 2.0737    | 2.1414    | 2.0487    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 202 / 11 Kv JAKATNAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5658     | .679      | .6036     | .6859     | .6224     | .6287     | .6478     |
| 2    | .547      | .6224     | .5658     | .6287     | .6036     | .5716     | .5906     |
| 3    | .5281     | .6036     | .5847     | .5716     | .5847     | .5525     | .5525     |
| 4    | .5847     | .6224     | .6036     | .5716     | .6224     | .5525     | .5525     |
| 5    | .6036     | .6413     | .6036     | .6097     | .6413     | .6287     | .5906     |
| 6    | .6036     | .6602     | .6224     | .6668     | .6602     | .6859     | .6668     |
| 7    | .6224     | .6979     | .7167     | .8192     | .5847     | .8002     | .724      |
| 8    | .7356     | .7356     | .7545     | .8383     | .6979     | .8764     | .7621     |
| 9    | .7922     | .7545     | .7922     | .743      | .7621     | .9145     | .7811     |
| 10   | .8676     | .7545     | .811      | .8865     | .7621     | .8865     | .7356     |
| 11   | .8488     | .7733     | .811      | .8488     | .8002     | .9619     | .7545     |
| 12   | .8299     | .7545     | .7545     | .9431     | .8002     | .9054     | .7356     |
| 13   | .7842     | .7356     | .7167     | .7733     | .7811     | .6979     | .679      |
| 14   | .7468     | .6979     | .679      | .6413     | .7621     | .6979     | .7167     |
| 15   | .7468     | .7167     | .6979     | .6413     | .724      | .6413     | .6979     |
| 16   | .6908     | .6979     | .7356     | .7167     | .6668     | .6224     | .7356     |
| 17   | .743      | .7621     | .7545     | .743      | .7207     | .6838     | .7762     |
| 18   | .7811     | .8002     | .7922     | .8764     | .7762     | .7577     | .7865     |
| 19   | .8573     | .8764     | .8865     | .9335     | .9335     | .8775     | .9335     |
| 20   | .8764     | .8192     | .8962     | .9145     | .9149     | .8764     | .9149     |
| 21   | .8573     | .7811     | .8954     | .8764     | .8402     | .8029     | .8589     |
| 22   | .7733     | .811      | .8573     | .7922     | .8192     | .7842     | .8383     |
| 23   | .7922     | .811      | .8383     | .7167     | .8002     | .7733     | .8002     |
| 24   | .6224     | .7545     | .7167     | .7621     | .6602     | .743      | .743      |
| Max  | .8764     | .8764     | .8962     | .9431     | .9335     | .9619     | .9335     |
| Min  | .5281     | .6036     | .5658     | .5716     | .5847     | .5525     | .5525     |
| Avg  | .7250     | .7318     | .7371     | .7584     | .7309     | .7468     | .7323     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 203 / 11 KV AZAD CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.358     | 1.4146    | 1.4712    | 1.5242    | 1.4901    | 1.4861    | 1.448     |
| 2    | 1.3203    | 1.3203    | 1.4146    | 1.4861    | 1.4523    | 1.4098    | 1.3336    |
| 3    | 1.2826    | 1.3014    | 1.3769    | 1.4289    | 1.4146    | 1.3527    | 1.3336    |
| 4    | 1.4335    | 1.5466    | 1.5466    | 1.4289    | 1.4712    | 1.3527    | 1.3146    |
| 5    | 1.5466    | 1.6598    | 1.6032    | 1.5051    | 1.6221    | 1.3908    | 1.3908    |
| 6    | 1.6221    | 1.773     | 1.6598    | 1.5813    | 1.6598    | 1.5623    | 1.5242    |
| 7    | 1.6598    | 1.9239    | 1.8296    | 1.8861    | 1.905     | 1.9243    | 1.7909    |
| 8    | 2.1125    | 2.1313    | 1.9993    | 2.0005    | 2.037     | 2.2672    | 2.0195    |
| 9    | 2.1125    | 1.9993    | 2.0182    | 2.0957    | 2.0767    | 2.3434    | 2.1338    |
| 10   | 2.2445    | 1.9427    | 1.8861    | 1.8484    | 1.9624    | 2.3388    | 1.9427    |
| 11   | 2.0748    | 1.8107    | 1.8484    | 1.9805    | 1.8099    | 2.3011    | 1.8107    |
| 12   | 1.9239    | 1.7164    | 1.6975    | 1.8484    | 1.7147    | 2.1313    | 1.8107    |
| 13   | 1.7364    | 1.6409    | 1.6598    | 1.6975    | 1.5623    | 1.8673    | 1.8673    |
| 14   | 1.587     | 1.4523    | 1.5466    | 1.5844    | 1.4861    | 1.6221    | 1.6598    |
| 15   | 1.475     | 1.4523    | 1.5089    | 1.4901    | 1.4289    | 1.358     | 1.5466    |
| 16   | 1.531     | 1.4335    | 1.5278    | 1.4712    | 1.3527    | 1.5089    | 1.5466    |
| 17   | 1.6766    | 1.6787    | 1.9427    | 1.8671    | 1.7002    | 1.6263    | 1.885     |
| 18   | 1.848     | 1.905     | 2.1879    | 2.0957    | 2.1437    | 1.9404    | 2.0851    |
| 19   | 2.0957    | 2.0957    | 2.5274    | 2.2862    | 2.3152    | 2.2218    | 2.2218    |
| 20   | 2.0005    | 1.9814    | 2.2965    | 2.0005    | 2.2405    | 2.3053    | 2.0725    |
| 21   | 1.8099    | 1.9052    | 1.9243    | 1.848     | 2.0725    | 1.8671    | 1.9044    |
| 22   | 1.6409    | 1.6409    | 1.7718    | 1.6975    | 1.829     | 1.8671    | 1.8099    |
| 23   | 1.6032    | 1.6032    | 1.6575    | 1.6409    | 1.6385    | 1.8107    | 1.6766    |
| 24   | 1.4712    | 1.5089    | 1.5089    | 1.6004    | 1.5089    | 1.5623    | 1.6956    |
| Max  | 2.2445    | 2.1313    | 2.5274    | 2.2862    | 2.3152    | 2.3434    | 2.2218    |
| Min  | 1.2826    | 1.3014    | 1.3769    | 1.4289    | 1.3527    | 1.3527    | 1.3146    |
| Avg  | 1.7153    | 1.7016    | 1.7671    | 1.7456    | 1.7456    | 1.8091    | 1.7427    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 204 / 11KV A'BAD TIMES COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.6975    | 1.8484    | 1.8484    | 1.848     | 1.8673    | 1.848     | 1.6575    |
| 2    | 1.5089    | 1.6975    | 1.7918    | 1.7528    | 1.7353    | 1.7147    | 1.5623    |
| 3    | 1.4901    | 1.6598    | 1.6975    | 1.6004    | 1.6598    | 1.6385    | 1.5051    |
| 4    | 1.5655    | 1.6032    | 1.6032    | 1.5623    | 1.6032    | 1.5623    | 1.5051    |
| 5    | 1.5655    | 1.6032    | 1.6032    | 1.5623    | 1.5655    | 1.5623    | 1.448     |
| 6    | 1.5844    | 1.6221    | 1.6221    | 1.6194    | 1.5844    | 1.6194    | 1.5242    |
| 7    | 1.5089    | 1.6221    | 1.6598    | 1.6956    | 1.6975    | 1.829     | 1.6385    |
| 8    | 1.6221    | 1.7353    | 1.6598    | 1.7909    | 1.7353    | 2.0005    | 1.7337    |
| 9    | 1.8107    | 1.8107    | 1.8107    | 1.9052    | 1.829     | 2.0767    | 1.7909    |
| 10   | 2.0936    | 1.8861    | 1.9993    | 1.9427    | 1.8671    | 2.2257    | 1.8107    |
| 11   | 2.1313    | 1.8484    | 1.9239    | 1.9805    | 1.9052    | 2.2257    | 1.773     |
| 12   | 2.0559    | 1.8861    | 1.9805    | 1.9616    | 1.8671    | 2.3388    | 1.8107    |
| 13   | 1.8671    | 1.9427    | 1.9239    | 1.905     | 1.848     | 2.1125    | 1.773     |
| 14   | 1.7924    | 1.7353    | 1.8673    | 1.8296    | 1.7718    | 1.8861    | 1.8107    |
| 15   | 1.7364    | 1.7164    | 1.7353    | 1.7541    | 1.7147    | 1.6221    | 1.6598    |
| 16   | 1.7177    | 1.773     | 1.6975    | 1.7353    | 1.6575    | 1.6221    | 1.6598    |
| 17   | 1.7909    |           | 1.8484    | 1.848     | 1.7002    | 1.6263    | 1.6834    |
| 18   | 1.7909    | 1.8484    | 1.8861    | 2.1338    | 1.9959    | 1.7002    | 1.7558    |
| 19   | 2.0957    | 2.0767    | 2.1125    | 2.1338    | 2.2405    | 2.0538    | 1.9231    |
| 20   | 2.0576    | 2.1338    | 2.2032    | 2.1148    | 2.2218    | 2.1338    | 1.9044    |
| 21   | 2.0005    | 2.0767    | 2.0957    | 2.0957    | 2.1472    | 1.9418    | 1.9418    |
| 22   | 1.9616    | 2.1879    | 2.0957    | 1.9993    | 2.1719    | 1.9791    | 2.0005    |
| 23   | 2.0748    | 2.1125    | 2.0767    | 2.037     | 2.191     | 1.9616    | 2.0005    |
| 24   | 1.8861    | 1.8861    | 1.8861    | 1.9243    | 1.8861    | 2.0005    | 1.8671    |
| Max  | 2.1313    | 2.1879    | 2.2032    | 2.1338    | 2.2405    | 2.3388    | 2.0005    |
| Min  | 1.4901    | 1.6032    | 1.6032    | 1.5623    | 1.5655    | 1.5623    | 1.448     |
| Avg  | 1.8086    | 1.8397    | 1.8595    | 1.8639    | 1.8526    | 1.8867    | 1.7392    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004801 / 220 KV PADEGAON SUB STATION

Feeder No / Name : 705 / 132 KV GARWARE FEEDER- NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
WALUJ Feeder KV- 132 / (CONTINOUS PROCESS)(NO STAGGERING  
OUTGOING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.7156    |
| Max  | 5.7156    |
| Min  | 5.7156    |
| Avg  | 5.7156    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004801 / 220 KV PADEGAON SUB STATION

Feeder No / Name : 707 / 132 KV CANPACK 1 (L- NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Sector) Fe Feeder KV- 132 / (CONTINOUS PROCESS)(NO STAGGERING  
OUTGOING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.7156    |
| Max  | 5.7156    |
| Min  | 5.7156    |
| Avg  | 5.7156    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004801 / 220 KV PADEGAON SUB STATION

Feeder No / Name : 710 / 132 KV SOUTH ASIA TYRE NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
FEEDER Feeder KV- 132 / (CONTINOUS PROCESS)(NO STAGGERING  
OUTGOING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.7156    |
| Max  | 5.7156    |
| Min  | 5.7156    |
| Avg  | 5.7156    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 201 / 11 KV E+H

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.5056    | 2.4387    | 3.2198    | 2.7054    | 2.8387    | 3.1626    | 2.1338    |
| 2    | 3.2388    | 2.4958    | 3.2007    | 2.6101    | 2.934     | 3.2198    | 2.1529    |
| 3    | 2.8959    | 2.6863    | 3.0674    | 2.572     | 2.915     | 3.2769    | 2.191     |
| 4    | 3.1436    | 3.0102    | 3.1245    | 2.4768    | 3.0102    | 3.3532    | 2.1719    |
| 5    | 3.2388    | 2.7625    | 2.8006    | 2.4387    | 3.1245    | 3.3722    | 2.191     |
| 6    | 3.0293    | 2.9531    | 3.1245    | 2.4006    | 3.0674    | 3.2198    | 2.2481    |
| 7    | 2.7816    | 2.7625    | 2.9912    | 2.553     | 3.1055    | 2.7244    | 2.5339    |
| 8    | 2.8959    | 2.4958    | 3.1626    | 2.6863    | 3.2769    | 3.2198    |           |
| 9    | 2.9912    | 2.9531    | 4.2676    | 4.3439    |           | 2.7244    | 3.4484    |
| 10   | 3.0674    | 3.2198    | 4.2676    | 3.9057    | 3.9438    |           | 3.8104    |
| 11   | 3.6389    | 4.4201    | 4.0009    | 3.9247    |           | 2.7625    | 4.1343    |
| 12   | 2.572     | 2.6673    | 3.5056    | 3.3722    | 3.6199    | 3.2007    | 3.5627    |
| 13   | 3.3722    | 3.4294    | 3.4294    | 4.6487    | 2.0957    | 3.2388    | 3.8104    |
| 14   | 3.1626    | 3.658     | 4.7249    | 5.4298    | 5.6013    | 3.6199    | 3.9628    |
| 15   | 3.2579    | 3.8866    | 4.5725    |           | 5.144     | 2.8769    | 5.2393    |
| 16   | 3.4484    | 4.2676    | 5.3346    | 5.5251    | 4.9154    | 3.4484    | 5.849     |
| 17   | 2.8769    | 4.5725    | 4.6868    | 5.3536    | 4.9535    | 3.5818    | 4.763     |
| 18   | 2.4006    | 4.2867    | 4.6677    | 5.6203    | 4.8392    | 2.7816    |           |
| 19   | 3.1626    | 3.4294    | 3.8866    | 4.039     | 4.1343    | 2.4958    |           |
| 20   | 2.4387    | 2.915     | 3.4294    | 5.5251    | 3.315     | 2.4387    | 2.8959    |
| 21   | 2.4958    | 3.2388    | 3.2388    |           | 3.4484    | 2.2481    | 3.0102    |
| 22   | 2.6292    | 3.4484    | 3.6389    |           | 3.6199    | 2.2481    | 3.1245    |
| 23   | 2.6863    | 3.4294    | 3.8104    | 3.3722    | 3.5818    | 2.2481    | 3.7532    |
| 24   | 6.4205    | 2.3243    | 2.7625    | 2.7054    | 2.7435    | 2.915     | 2.1148    |
| Max  | 6.4205    | 4.5725    | 5.3346    | 5.6203    | 5.6013    | 3.6199    | 5.849     |
| Min  | 2.4006    | 2.3243    | 2.7625    | 2.4006    | 2.0957    | 2.2481    | 2.1148    |
| Avg  | 3.1396    | 3.2396    | 3.7048    | 3.7242    | 3.6467    | 2.9729    | 3.2905    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 202 / 11 KV GARWARE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.2672    | 2.0576    | 2.7625    | 2.9721    | 2.8769    | 3.0483    | 2.3243    |
| 2    | 2.21      | 2.0957    | 2.8197    | 2.8769    | 2.915     | 3.0102    | 2.3624    |
| 3    | 2.0386    | 2.1338    | 2.7435    | 2.7625    | 2.8197    | 3.0674    | 2.3053    |
| 4    | 2.0195    | 2.1148    | 2.6673    | 2.6673    | 2.7625    | 3.0483    | 2.3053    |
| 5    | 2.0576    | 2.1529    |           | 2.553     | 2.6863    | 3.1245    | 2.3243    |
| 6    | 2.0005    | 2.1148    | 2.4387    | 2.553     | 2.7625    | 2.8387    | 2.3243    |
| 7    | 1.9052    | 2.6863    | 2.2672    | 2.4958    | 2.6292    | 2.4577    | 2.9531    |
| 8    | 2.1338    | 3.0674    | 3.5437    | 3.4484    | 3.4484    | 2.8387    | 3.6389    |
| 9    | 2.191     | 3.2388    | 3.7723    | 4.1914    | 3.7913    | 2.4577    | 4.02      |
| 10   | 2.191     | 3.3913    | 3.9247    | 3.8104    | 3.8104    |           | 4.0962    |
| 11   | 2.3243    | 3.8104    | 4.1914    |           | 3.8104    | 2.1148    | 4.0962    |
| 12   | 2.3243    | 3.2198    | 3.677     |           | 3.4675    | 2.7435    | 3.6389    |
| 13   | 2.191     | 3.5437    | 3.8104    |           | 3.6961    | 2.4768    | 3.7723    |
| 14   | 2.4958    | 3.8104    | 4.0009    |           | 3.9247    | 2.8197    | 3.8104    |
| 15   | 2.4387    | 3.8295    | 4.1914    |           | 4.0009    | 2.8769    | 3.9628    |
| 16   | 2.3053    | 4.0581    | 3.7723    | 3.4675    |           | 2.8769    | 4.039     |
| 17   | 2.2481    | 3.7913    | 4.1914    | 3.658     | 4.2486    | 2.9531    | 3.7532    |
| 18   | 2.1148    | 3.6199    | 3.8104    | 3.3722    | 3.8104    | 2.9531    |           |
| 19   | 2.0005    | 2.7054    | 3.0483    | 2.9531    | 3.0483    | 2.21      | 2.6863    |
| 20   | 2.0005    | 2.9912    | 3.0483    |           | 3.315     | 2.2481    | 3.1245    |
| 21   | 1.9624    | 2.934     | 3.0483    |           | 3.2388    | 2.3243    | 3.0483    |
| 22   | 2.0576    | 2.8578    | 2.9721    |           | 3.2388    | 2.5339    |           |
| 23   | 2.0195    | 2.8197    | 2.7435    | 2.9531    | .9907     | 2.3243    | 2.7816    |
| 24   | 2.2862    | 2.0576    | 2.7816    | 2.8197    | 3.0674    | 3.1245    | 2.3243    |
| Max  | 2.4958    | 4.0581    | 4.1914    | 4.1914    | 4.2486    | 3.1245    | 4.0962    |
| Min  | 1.9052    | 2.0576    | 2.2672    | 2.4958    | .9907     | 2.1148    | 2.3053    |
| Avg  | 2.1576    | 2.9626    | 3.3142    | 3.0972    | 3.2330    | 2.7161    | 3.1678    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 203 / 11 KV KESONA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0957    | 1.3908    | 2.1148    | 2.0576    | 2.3434    | 2.0576    | 1.6956    |
| 2    | 2.0386    | 1.3527    | 1.9433    | 2.0957    | 2.191     | 2.0957    | 1.7147    |
| 3    | 1.9814    | 1.4289    | 1.9814    | 2.0767    | 1.9243    | 2.0767    | 1.6766    |
| 4    | 1.8861    | 1.6385    | 1.9433    | 2.1338    | 1.9052    | 2.1529    | 1.6766    |
| 5    | 1.7147    | 1.3908    | 1.6956    | 2.1719    | 1.8861    | 2.2291    | 1.6194    |
| 6    | 1.6956    | 1.467     | 1.8099    | 1.7909    | 2.0005    | 2.2291    | 1.6766    |
| 7    | 1.6004    | 1.6766    | 1.7718    | 1.7718    | 2.0005    | 1.7147    | 1.9433    |
| 8    | 1.6004    | 1.9243    | 1.9243    | 2.1338    | 2.5339    | 2.2291    | 2.0576    |
| 9    | 1.6385    | 2.2862    | 2.3815    | 2.572     | 2.553     | 1.7147    | 2.8769    |
| 10   | 1.7528    | 2.6292    | 2.5149    | 2.8197    | 3.0674    |           | 2.8197    |
| 11   | 1.9624    | 2.8578    | 2.5149    | 2.7625    | 2.9531    | 1.7147    | 1.9624    |
| 12   | 1.7147    | 2.1529    | 2.2862    |           | 2.553     | 1.8099    | 2.0576    |
| 13   | 1.6194    | 2.8006    | 2.2862    | 2.3243    | 2.6673    | 1.7337    | 1.9814    |
| 14   | 1.7718    | 2.8578    | 2.7625    | 2.8769    | 3.1817    | 2.0957    | 2.2672    |
| 15   | 1.7528    | 2.8959    | 2.5911    | 2.8578    | 2.8387    | 2.0005    | 2.572     |
| 16   | 1.6766    | 2.8578    | 2.4958    | 2.6863    | 2.9721    |           | 2.8197    |
| 17   | 1.8099    | 2.8006    |           | 3.1626    | 2.8578    | 1.7718    | 2.9721    |
| 18   | 1.4861    | 2.6101    | 2.572     | 2.3624    | 2.2672    | 1.6194    | 2.4196    |
| 19   | 1.467     | 2.0005    | 2.2862    | 1.9243    | 1.9814    | 1.6194    | 1.5813    |
| 20   | 1.4289    | 1.9624    | 2.0957    |           | 2.0957    | 1.6385    |           |
| 21   | 1.3146    | 1.9052    | 1.9624    |           | 2.0386    | 1.6766    | 1.1431    |
| 22   | 1.3336    | 1.8861    | 2.0576    |           | 1.9052    | 1.7528    | 1.8099    |
| 23   | 1.3336    | 1.9052    | 2.2291    | 1.7528    | 2.2291    | 1.6194    | 1.6575    |
| 24   | 2.0386    | 1.3717    | 2.0195    | 2.1529    | 2.2481    | 2.0576    | 1.6766    |
| Max  | 2.0957    | 2.8959    | 2.7625    | 3.1626    | 3.1817    | 2.2291    | 2.9721    |
| Min  | 1.3146    | 1.3527    | 1.6956    | 1.7528    | 1.8861    | 1.6194    | 1.1431    |
| Avg  | 1.6964    | 2.0854    | 2.1843    | 2.3243    | 2.3831    | 1.8913    | 2.0295    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 204 / 11 KV HIRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.553     | 2.4387    | 2.5149    | 2.8197    | 2.6863    | 2.6673    | 1.3908    |
| 2    | 2.4387    | 2.3243    | 2.2672    | 2.7054    | 2.6292    | 2.7054    | 1.4289    |
| 3    | 2.6292    | 2.2481    | 2.0576    | 2.5911    | 2.4958    | 2.5911    | 1.5813    |
| 4    | 2.3624    | 2.3053    | 1.9433    | 2.6673    | 2.4006    | 2.5911    | 1.5432    |
| 5    | 1.9433    | 2.3053    | 1.9814    | 2.5911    | 2.3815    | 2.5149    | 1.5623    |
| 6    | 2.0576    | 2.191     | 1.9814    | 2.2862    | 2.3815    | 2.3243    | 1.6766    |
| 7    | 1.9433    | 2.1338    | 2.0576    | 1.9433    | 2.3243    | 2.0195    | 1.8099    |
| 8    | 2.3624    |           | 2.1719    | 2.934     | 2.7816    | 2.3243    | 2.4387    |
| 9    | 2.5911    | 2.6673    | 3.2007    | 3.6199    | 3.6199    | 2.0195    | 3.1245    |
| 10   | 2.8578    | 3.1436    | 3.4294    | 3.0483    | 3.2579    |           | 3.6008    |
| 11   | 3.0674    | 3.4294    | 3.4294    | 3.0102    |           | 1.9243    | 3.8104    |
| 12   | 2.6863    | 2.21      | 3.4294    | 2.6863    | 2.8578    | 1.7528    | 2.7054    |
| 13   | 2.3243    | 2.7816    | 2.6673    | 3.0483    | 2.6673    | 1.9052    | 2.7816    |
| 14   | 2.6863    | 2.7054    | 3.4294    | 1.9052    | 3.2007    | 2.2862    | 3.4675    |
| 15   | 2.6292    | 2.6673    | 3.0483    | 3.2388    | 3.4294    | 2.3243    | 3.5437    |
| 16   | 2.1148    | 2.4768    | 3.8866    | 3.8295    | 3.8104    | 2.1148    | 3.658     |
| 17   | 2.3053    | 3.0293    | 3.4294    | 3.9438    | 1.9814    | 2.1338    | 3.8485    |
| 18   | 2.5339    | 2.7435    | 2.8578    | 3.1626    | 3.4294    | 1.8671    |           |
| 19   | 2.191     | 2.4768    | 2.2862    | 2.7816    | 2.6673    | 1.3717    | 2.7054    |
| 20   | 2.0005    | 2.2862    | 2.2862    |           | 2.8578    | 1.5813    | 2.7054    |
| 21   | 1.9433    | 2.1338    | 2.4768    |           |           | 1.6766    | 2.6673    |
| 22   | 2.1148    | 2.0576    | 2.4196    |           |           | 1.467     | 2.6673    |
| 23   | 2.191     | 2.0576    | 2.2862    | 2.4006    | 2.6673    | 1.6766    | 2.6673    |
| 24   | 2.4387    | 2.2862    | 2.5911    | 2.6673    | 2.8959    | 2.2862    | 1.3717    |
| Max  | 3.0674    | 3.4294    | 3.8866    | 3.9438    | 3.8104    | 2.7054    | 3.8485    |
| Min  | 1.9433    | 2.0576    | 1.9433    | 1.9052    | 1.9814    | 1.3717    | 1.3717    |
| Avg  | 2.3736    | 2.4826    | 2.6720    | 2.8515    | 2.8297    | 2.0924    | 2.5546    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 205 / GANGA MAI I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0572     | .0762     | .0762     | .0953     | .0762     | .0572     |
| 2    | .0953     | .0572     | .0572     | .0762     | .0953     | .0953     | .0381     |
| 3    | .0762     | .0381     | .0572     | .0762     | .0953     | .0762     | .0381     |
| 4    | .0191     | .0381     | .0572     | .0762     | .0953     | .0953     | .0381     |
| 5    | .0762     | .0381     | .0762     | .0762     | .0953     | .1143     | .0381     |
| 6    | .0762     | .0381     | .0953     | .0953     | .0953     | .0762     | .0191     |
| 7    | .0572     | .0381     | .0572     | .0381     | .0572     | .0572     | .0572     |
| 8    | .0762     |           | .1143     | .0953     | .0953     | .0762     | .1143     |
| 9    | .0762     | .1334     | .1334     | .1143     | .1524     | .0572     | .0953     |
| 10   | .0953     | .1143     | .1715     | .1524     | .1715     |           | .1715     |
| 11   | .0953     | .1143     | .1715     |           | .1524     | .0762     | .1715     |
| 12   | .0953     | .0953     | .1524     | .1334     | .1334     | .0762     | .1334     |
| 13   | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     | .0762     |
| 14   | .0953     | .0762     | .1524     | .1334     | .1715     | .0953     | .1143     |
| 15   | .0953     | .1334     | .1715     | .1334     | .1715     | .1143     | .1143     |
| 16   | .0953     | .1143     | .1715     | .1715     | .1715     | .0953     | .1524     |
| 17   | .0953     | .1334     | .1715     | .1524     | .1715     | .0762     | .1143     |
| 18   | .1143     | .0953     | .1334     | .1334     | .1524     | .0762     | .1143     |
| 19   | .0572     | .0762     | .0953     | .0953     | .0762     | .0572     | .0953     |
| 20   | .0572     | .0762     | .1334     |           | 2.0957    | .0572     | .0953     |
| 21   | .0381     | .0572     | .0953     |           | 2.6673    | .0572     | .0762     |
| 22   | .0572     | .0572     | .1143     |           | 2.6673    | .0572     | .0762     |
| 23   | .0572     | .0762     | .1334     | .0762     | .1143     | .0572     | .0762     |
| 24   | .0953     | .0572     | .0762     | .0953     | .0953     | .1143     | .0572     |
| Max  | .1143     | .1334     | .1715     | .1715     | 2.6673    | .1143     | .1715     |
| Min  | .0191     | .0381     | .0572     | .0381     | .0572     | .0572     | .0191     |
| Avg  | .0786     | .0779     | .1151     | .1048     | .4160     | .0795     | .0889     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 207 / 11 KV ADEEP

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4958    | 2.1148    | 2.3434    | 2.7054    | 2.6673    | 2.9721    | 2.4387    |
| 2    | 2.2862    | 2.0576    | 2.2672    | 2.6673    | 2.572     | 2.7244    | 2.2481    |
| 3    | 2.4768    | 2.0386    | 2.21      | 2.572     | 2.2481    | 2.572     | 2.1529    |
| 4    | 2.3434    | 2.0195    | 2.1338    | 2.4768    | 2.3243    | 2.4768    | 2.1148    |
| 5    | 2.2291    | 2.0005    | 2.1719    | 2.4387    | 2.3053    | 2.3624    | 1.8861    |
| 6    | 2.4387    | 2.0005    | 2.2481    | 2.5911    | 2.3053    | 2.5149    | 2.0005    |
| 7    | 2.3815    | 2.191     | 2.7625    | 2.8578    | 3.0674    | 2.3243    | 2.9531    |
| 8    | 2.4006    | 2.3815    | 3.1245    | 3.2388    | 3.4484    | 2.5149    | 3.3722    |
| 9    | 2.3053    | 2.553     | 3.4675    | 3.7342    | 3.8104    | 2.3243    |           |
| 10   | 2.5339    | 2.8197    | 3.9819    | 3.8104    | 4.4201    |           | 4.2295    |
| 11   | 2.8769    | 2.8959    | 2.4768    | 4.0962    | 4.382     | 2.1148    | 4.0771    |
| 12   | 2.6863    | 2.8197    | 3.9628    | 4.2295    | 4.0009    | 2.3815    | 4.1533    |
| 13   | 2.3815    | 3.0102    | 4.0771    | 3.7913    | 3.296     | 2.21      | 4.039     |
| 14   | 2.7435    | 2.934     | 4.0009    | 4.1533    | 4.1724    | 2.2291    | 4.1533    |
| 15   | 2.572     | 2.8959    | 3.8104    | 3.6199    | 3.8104    | 2.191     | 4.1914    |
| 16   | 2.3815    | 3.5246    | 3.677     | 4.02      |           | 2.2481    | 4.2486    |
| 17   | 2.3815    | 3.3722    | 3.9438    | 4.02      | 4.382     | 2.1338    | 4.0009    |
| 18   | 2.191     | 3.1245    | 3.6199    | 3.5818    | 3.9628    | 2.21      | 4.1152    |
| 19   | 2.3434    | 2.6101    | 3.0483    | 3.0674    | 2.9721    | 1.8861    | 3.2579    |
| 20   | 2.1338    | 2.8387    | 2.8578    |           | 3.0864    | 2.2481    | 3.2007    |
| 21   | 2.0195    | 2.7054    | 2.8578    |           | 3.2388    | 2.5339    | 3.0864    |
| 22   | 2.3243    | 2.5911    | 2.934     |           | 3.2388    | 2.3243    | 2.915     |
| 23   | 2.3053    | 2.5911    | 3.0483    | 2.8197    | 2.9531    | 2.3434    | 3.1626    |
| 24   | 2.553     | 2.0386    | 2.3243    | 2.572     | 2.6863    | 2.8578    | 2.4958    |
| Max  | 2.8769    | 3.5246    | 4.0771    | 4.2295    | 4.4201    | 2.9721    | 4.2486    |
| Min  | 2.0195    | 2.0005    | 2.1338    | 2.4387    | 2.2481    | 1.8861    | 1.8861    |
| Avg  | 2.4077    | 2.5887    | 3.0563    | 3.2887    | 3.2761    | 2.3782    | 3.2388    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 208 / 11 KV RUCHA EXP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9907     | .4763     | .8954     | 1.0098    | .8573     | .8002     | .9145     |
| 2    | 1.0098    | .4763     | .8764     | .9526     | .9145     | .8573     | .8954     |
| 3    | .8573     | .4763     | .8383     | .8954     | .9907     | .9526     | .9907     |
| 4    | .8764     | .4763     | .8764     | .8192     | .9335     | .9526     | .9145     |
| 5    | .8954     | .4763     | .8764     | .7621     | 1.105     | .9907     | 1.086     |
| 6    | .9717     | .4763     | .724      | .9907     | 1.0098    | .9717     | .9145     |
| 7    | .7621     | .8764     | .7621     | .6859     | .8383     | .9526     | .7811     |
| 8    | .7811     | .9717     | 1.1812    | .9145     | 1.1622    | .9717     | 1.1622    |
| 9    | .7049     | .8002     | 1.0098    | .9717     | .8383     | .9526     | .8573     |
| 10   | .6287     | .8383     | 1.2193    | 1.3146    | 1.1812    |           | .9526     |
| 11   | .5906     | .8192     | .8192     | 1.105     | .8954     | .8002     | .8192     |
| 12   | .7049     | 1.086     | .8573     | .9907     | .9335     | 1.2574    | 1.1431    |
| 13   | .6668     | 1.105     | 1.1431    | .9145     | .9907     | 1.0669    | 1.2003    |
| 14   | .7049     | 1.086     | 1.2384    | 1.0288    | 4.1724    | .9145     | 1.0098    |
| 15   | .724      | 1.0479    | 1.2955    | 1.0669    | 1.2193    | 1.2574    | 1.105     |
| 16   | .724      | .8954     | .7811     | .9717     |           | .8002     | .8192     |
| 17   | .7049     | 1.2955    | 1.0098    | 1.086     | .9526     | 1.105     | 1.1431    |
| 18   | .7621     | 1.0669    | 1.1812    | .9907     | 1.2574    | 1.3717    | .9145     |
| 19   | .4763     | .6859     | .743      | .8192     | .8192     | .6287     | .8002     |
| 20   | .4954     | .9335     | .8192     |           | .9335     | .8573     | .8573     |
| 21   | .4763     | .8764     | .8954     |           | .9335     | .9145     | .9145     |
| 22   | .4763     | .8573     | .8573     |           | .9145     | .724      | 1.0098    |
| 23   | .4763     | .8002     | .7621     | .8573     | .8573     | .724      | .7621     |
| 24   | .9145     | .4763     | .8192     | .9335     | .9907     | 1.0479    | .9145     |
| Max  | 1.0098    | 1.2955    | 1.2955    | 1.3146    | 4.1724    | 1.3717    | 1.2003    |
| Min  | .4763     | .4763     | .724      | .6859     | .8192     | .6287     | .7621     |
| Avg  | .7240     | .8073     | .9367     | .9562     | 1.1174    | .9509     | .9534     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 401 / 33 KV TAYO LUCID

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 4.6868    | 2.9721    | 5.2584    | 5.2584    | 5.4298    | 6.4015    | 5.3155    |
| 2    | 4.8011    | 3.1436    | 5.2012    | 5.144     | 5.487     | 6.1157    | 5.6584    |
| 3    | 4.8583    | 3.4294    | 5.144     | 5.3155    | 5.4298    | 5.9442    | 5.6013    |
| 4    | 4.5725    | 3.4294    | 5.2012    | 5.3727    | 5.4298    | 5.7728    |           |
| 5    | 4.2295    | 3.4294    | 5.144     | 5.3727    | 5.3155    | 5.7156    | 5.4298    |
| 6    | 4.2295    | 3.2007    | 4.9154    | 5.2584    | 5.7156    | 5.2584    | 5.4298    |
| 7    | 3.658     | 4.8011    | 5.2584    | 5.3155    | 5.487     | 5.7728    | 5.8299    |
| 8    | 3.7151    | 5.6013    | 6.0014    | 6.0014    | 6.7444    | 5.8299    | 6.6301    |
| 9    | 3.4865    | 5.7728    | 6.3443    | 6.5158    | 7.0873    | 6.0014    | 7.2017    |
| 10   | 3.4294    | 5.8871    | 6.6301    | 6.9159    | 6.9159    | 6.5729    | 7.2017    |
| 11   | 3.8866    | 5.9442    | 6.8587    | 6.9159    | 6.7444    | 6.5729    | 7.4303    |
| 12   | 2.2291    | 6.1728    | 6.8587    | 6.973     | 7.316     | 6.3443    | 6.7444    |
| 13   | 2.2862    | 6.4015    | 6.6873    | 7.1445    | 7.2588    | 6.0585    | 6.8587    |
| 14   | 3.1436    | 6.2872    | 6.1728    | 7.8875    | 8.0018    | 6.3443    | 6.973     |
| 15   | 2.9721    | 6.4015    | 6.0014    | 5.0869    | 7.2588    | 6.4586    | 6.7444    |
| 16   | 2.2862    | 7.1445    | 6.23      | 7.9447    | 7.316     | 6.4015    | 6.6301    |
| 17   | 2.2862    | 6.6301    | 6.6873    | 7.9447    | 7.1445    | 6.3443    | 7.0302    |
| 18   | 2.915     | 6.2872    | 6.23      | 6.9159    | 6.973     | 6.3443    | 6.5158    |
| 19   | 2.7435    | 6.0014    | 6.0014    | 6.9159    | 6.3443    | 6.1728    | 5.487     |
| 20   | 3.2007    | 5.8299    | 6.1157    |           | 6.6301    | 5.8871    | 5.6013    |
| 21   | 3.2007    | 5.6013    | 6.23      |           | 6.2872    | 5.4298    | 5.487     |
| 22   | 2.7435    | 5.4298    | 6.0585    |           | 6.1157    | 5.487     | 5.5441    |
| 23   | 3.1436    | 6.0014    | 5.8299    | 6.3443    | 6.2872    | 6.0014    | 5.8871    |
| 24   | 4.6296    | 3.0293    | 5.3155    | 5.2012    | 5.4298    | 5.8871    | 5.4298    |
| Max  | 4.8583    | 7.1445    | 6.8587    | 7.9447    | 8.0018    | 6.5729    | 7.4303    |
| Min  | 2.2291    | 2.9721    | 4.9154    | 5.0869    | 5.3155    | 5.2584    | 5.3155    |
| Avg  | 3.4722    | 5.2012    | 5.9323    | 6.2736    | 6.4229    | 6.0466    | 6.2027    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 402 / 33 KV SIEMENCE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 4.7439    | 3.2007    | 4.8011    | 5.8299    | 5.0869    | 6.8587    | 4.0009    |
| 2    | 4.4582    | 3.315     | 4.6868    | 5.6584    | 5.144     | 6.5158    | 4.4582    |
| 3    | 4.4582    | 3.4294    | 4.5725    | 4.9726    | 5.6584    | 6.23      | 4.5725    |
| 4    | 4.3439    | 3.4865    | 4.6868    | 4.6868    | 5.487     | 5.7156    |           |
| 5    | 4.3439    | 3.5437    | 4.5153    | 4.5153    | 5.6584    | 5.144     |           |
| 6    | 3.7151    | 3.4865    | 4.5725    | 4.4582    | 5.8871    | 4.6868    |           |
| 7    | 3.4865    | 4.0581    | 4.8011    | 4.5725    | 5.144     | 4.0009    |           |
| 8    | 3.6008    | 5.0869    | 5.3727    | 5.6013    | 6.3443    | 4.4582    | 5.0869    |
| 9    | 3.7151    | 5.7728    | 5.8299    | 6.1157    | 6.3443    | 4.8583    | 7.1445    |
| 10   | 3.7151    | 5.7156    | 6.0014    | 5.8871    | 7.6017    | 4.8583    | 6.8587    |
| 11   | 3.315     | 5.6584    | 6.1157    | 5.8871    | 5.6013    | 4.8583    | 6.9159    |
| 12   | 3.4294    | 5.6584    | 5.5441    | 4.8583    | 6.8016    | 4.8583    | 6.5158    |
| 13   | 3.3722    | 6.23      | 5.5441    | 6.5729    | 7.0302    | 4.6868    | 6.5729    |
| 14   | 3.8866    | 6.4015    | 6.1157    | 6.3443    |           | 5.0297    | 6.4015    |
| 15   | 3.7151    | 6.6301    | 6.4586    | 5.0297    | 7.6017    | 5.144     | 6.5158    |
| 16   | 3.315     | 5.6584    | 7.0302    | 6.1728    | 6.5158    | 5.144     | 6.0014    |
| 17   | 3.6008    | 6.2872    | 6.5729    | 5.4298    | 8.1733    | 5.2584    | 6.5729    |
| 18   | 2.8006    | 6.1157    | 7.0873    | 6.7444    | 7.7161    | 5.0297    | 6.5729    |
| 19   | 2.915     | 5.6584    | 6.1728    | 5.8871    | 7.4303    | 4.8583    | 6.0014    |
| 20   | 2.915     | 5.5441    | 6.4015    |           | 6.8016    | 4.7439    | 5.0869    |
| 21   | 3.315     | 5.487     | 5.4298    |           | 6.8587    | 4.5725    | 6.2872    |
| 22   | 3.1436    | 5.4298    | 5.3727    |           | 6.973     | 4.5725    | 6.6873    |
| 23   | 2.9721    | 4.8583    | 5.3155    | 5.0869    | 5.144     | 4.401     | 5.3155    |
| 24   | 4.8011    | 3.0864    | 4.6868    | 5.4298    | 4.8583    | 4.8583    | 4.1152    |
| Max  | 4.8011    | 6.6301    | 7.0873    | 6.7444    | 8.1733    | 6.8587    | 7.1445    |
| Min  | 2.8006    | 3.0864    | 4.5153    | 4.4582    | 4.8583    | 4.0009    | 4.0009    |
| Avg  | 3.6699    | 4.9916    | 5.5703    | 5.5115    | 6.3418    | 5.0559    | 5.8842    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 403 / 33 KV STARLITE CKT NO 1 NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 7.2017    | 7.6017    | 7.6017    | 7.2017    | 7.4303    | 7.6017    | 7.4874    |
| 2    | 7.2017    | 7.7161    | 7.4303    | 7.3731    | 7.3731    | 7.6589    | 7.316     |
| 3    | 7.2017    | 7.4874    | 7.3731    | 7.4303    | 7.4303    | 7.4874    | 7.316     |
| 4    | 7.4303    | 7.4303    | 7.316     | 7.2588    | 7.4874    | 7.3731    | 7.0302    |
| 5    | 7.5446    | 7.4874    | 7.316     | 7.316     | 7.4874    | 7.2017    | 7.0302    |
| 6    | 7.4874    | 7.6017    | 7.6017    | 7.4303    | 7.4303    | 7.7161    | 7.4874    |
| 7    | 7.5446    | 7.2588    | 7.7161    | 7.3731    | 7.2588    | 7.3731    | 7.4303    |
| 8    | 7.6589    |           | 7.4874    | 7.4874    | 7.4874    | 7.316     | 7.1445    |
| 9    | 7.5446    | 7.5446    | 7.9447    | 7.6017    | 7.7161    | 7.1445    | 7.4874    |
| 10   | 7.3731    | 7.6589    | 7.6589    | 7.4303    | 8.1733    | 7.7732    | 7.4874    |
| 11   | 7.7161    | 7.7732    | 7.6017    | 7.7161    | 8.059     | 7.3731    | 7.6589    |
| 12   | 8.059     | 7.7732    | 7.4874    | 7.7732    | 8.0018    |           | 7.8875    |
| 13   | 7.4874    | 7.6589    | 7.8304    | 7.3731    | 7.7161    | 7.7732    | 7.7732    |
| 14   | 7.8304    | 7.7732    | 7.8875    | 7.6017    | 8.0018    | 8.0018    | 7.6589    |
| 15   | 7.8875    | 7.8875    | 7.4303    | 6.4015    | 8.0018    | 7.7732    | 7.5446    |
| 16   | 7.8875    | 7.9447    | 7.7161    | 7.6589    | 7.8304    | 7.4874    | 7.4874    |
| 17   | 7.316     | 7.9447    | 7.7732    | 7.4874    | 8.0018    | 7.2588    | 7.7161    |
| 18   | 7.2017    | 7.4303    | 7.2017    | 7.7732    | 7.8875    | 7.6017    | 7.5446    |
| 19   | 7.4874    | 7.4874    | 7.316     | 7.4303    | 7.2017    | 7.316     | 7.3731    |
| 20   | 7.6017    | 7.5446    | 7.0873    | 7.3731    | 7.5446    | 7.316     | 7.316     |
| 21   | 7.5446    | 7.4303    | 7.1445    | 7.316     | 7.6589    | 7.3731    | 7.4303    |
| 22   | 7.4874    | 7.5446    | 7.316     | 7.4303    | 7.5446    |           | 7.7161    |
| 23   | 7.4874    | 7.4303    | 7.4303    | 7.4303    | 7.316     | 7.6017    | 7.3731    |
| 24   | 7.2588    | 7.5446    | 7.6017    | 7.2588    | 7.2588    | 7.2588    | 7.4874    |
| Max  | 8.059     | 7.9447    | 7.9447    | 7.7732    | 8.1733    | 8.0018    | 7.8875    |
| Min  | 7.2017    | 7.2588    | 7.0873    | 6.4015    | 7.2017    | 7.1445    | 7.0302    |
| Avg  | 7.5184    | 7.6067    | 7.5113    | 7.4136    | 7.6375    | 7.4900    | 7.466     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 404 / 33 KV STARLITE CKT NO II NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 4.1152    | 4.1152    | 4.1152    | 4.1724    | 4.3439    | 4.401     | 4.2295    |
| 2    | 4.0581    | 4.0581    | 4.0581    | 4.1152    | 4.2867    | 4.4582    | 4.1724    |
| 3    | 4.0581    | 4.1152    | 3.9438    | 4.2295    | 4.3439    | 4.2867    | 4.2295    |
| 4    | 4.0581    | 4.1152    | 4.0581    | 4.1724    | 4.3439    | 4.2295    | 4.2295    |
| 5    | 4.1152    | 4.1152    | 4.0009    | 4.2295    | 4.2867    | 4.3439    | 4.2295    |
| 6    | 4.1152    | 4.1724    | 4.1724    | 4.1724    | 4.401     | 4.401     | 4.2295    |
| 7    | 4.1152    | 4.0581    | 4.1152    | 4.1724    | 4.401     | 4.3439    | 4.3439    |
| 8    | 4.1152    | 4.0581    | 4.1152    | 4.2867    | 4.3439    | 4.401     | 4.3439    |
| 9    | 4.1152    | 4.0581    | 4.2295    | 4.3439    | 4.4582    | 4.3439    | 4.401     |
| 10   | 4.1152    | 4.1152    | 4.3439    | 4.5153    | 4.6296    | 4.401     | 4.401     |
| 11   | 4.1724    | 4.3439    | 4.2867    | 4.5153    | 4.6296    | 4.401     | 4.4582    |
| 12   | 4.2295    | 4.2295    | 4.2867    | 4.401     | 4.6296    | 4.4582    | 4.4582    |
| 13   | 4.1724    | 4.1152    | 4.3439    | 4.1724    | 4.5725    | 3.2007    | 4.4582    |
| 14   | 4.1152    | 4.1152    | 4.1724    | 3.4294    | 4.4582    | 4.5725    | 4.5725    |
| 15   | 4.0581    | 4.1152    | 4.3439    | 3.2007    | 4.5725    | 4.5725    | 4.4582    |
| 16   | 4.0581    | 4.1724    | 4.2867    | 4.401     | 4.5725    | 4.5153    | 4.6296    |
| 17   | 3.9438    | 4.1724    | 4.2295    | 4.5725    | 4.6296    | 4.5153    | 4.4582    |
| 18   | 4.1152    | 4.0581    | 4.1724    | 4.401     | 4.5153    | 4.401     | 4.3439    |
| 19   | 3.9438    | 7.4874    | 4.0009    | 4.401     | 4.4582    | 4.3439    | 4.2295    |
| 20   | 3.8295    | 4.0009    | 4.1724    | 4.2867    | 4.3439    | 4.3439    | 4.2867    |
| 21   | 3.8295    | 4.0009    | 4.2295    | 4.401     | 4.4582    | 4.3439    | 4.1152    |
| 22   | 3.9438    | 4.1152    | 4.2295    | 4.2867    | 4.3439    | 4.2867    | 4.0009    |
| 23   | 4.0581    | 4.1152    | 4.2295    | 4.401     | 4.3439    | 4.401     | 4.3439    |
| 24   | 4.0581    | 4.0581    | 4.1724    | 4.2295    | 4.401     | 4.3439    | 4.2295    |
| Max  | 4.2295    | 7.4874    | 4.3439    | 4.5725    | 4.6296    | 4.5725    | 4.6296    |
| Min  | 3.8295    | 4.0009    | 3.9438    | 3.2007    | 4.2867    | 3.2007    | 4.0009    |
| Avg  | 4.0628    | 4.2534    | 4.1795    | 4.2295    | 4.4487    | 4.3462    | 4.3272    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 405 / 33 KV Rural ( Turkabad) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 6.4015    | 6.1728    | 7.2588    | 6.973     | 7.7161    | 6.8587    | 6.5729    |
| 2    | 5.7156    | 6.5729    | 8.4591    | 7.7161    | 8.4591    | 7.316     | 6.7444    |
| 3    | 5.7728    | 8.4591    | 8.802     | 8.4591    | 8.6306    | 7.9447    | 7.4874    |
| 4    | 6.6873    | 8.5734    | 9.145     | 8.6306    | 9.0306    | 8.1162    | 8.059     |
| 5    | 7.5446    | 9.4879    | 9.4879    | 9.3736    | 9.2021    | 8.9735    | 8.6306    |
| 6    | 10.1166   | 10.3452   | 12.1171   | 11.9456   | 11.8884   | 12.1171   | 11.6027   |
| 7    | 5.5441    | 8.059     |           | 8.1733    | 8.2305    | 7.5446    | 8.059     |
| 8    | 7.8875    | 6.5729    | 7.2588    | 7.9447    | 7.316     | 8.1733    | 7.1445    |
| 9    | 9.0878    | 8.1162    | 9.0878    | 7.6017    | 7.7732    | 8.6306    | 8.8592    |
| 10   | 8.5734    | 7.8875    | 8.8592    | 7.5446    |           | 7.7161    | 7.3731    |
| 11   | 8.8592    | 7.0302    | 8.3448    | 7.7161    | 6.4015    | 6.3443    | 8.0018    |
| 12   | 8.1162    | 8.9735    | 6.3443    | 8.059     | 7.0302    | 4.9726    | 7.316     |
| 13   | 8.059     | 6.5729    | 7.6017    | 6.6301    | 6.4586    | 4.9726    | 7.3731    |
| 14   | 8.2305    | 6.8587    | 7.0302    | 7.2017    | 7.0873    | 3.9438    | 7.4303    |
| 15   | 6.9159    | 7.3731    | 7.2017    | 6.3443    | 6.0585    | 5.0869    | 7.6589    |
| 16   | 7.1445    | 7.316     | 7.6017    | 7.4874    | 7.7161    | 6.0014    | 8.059     |
| 17   | 4.0581    | 7.3731    | 5.2012    | 5.4298    | 5.3727    | 4.4582    | 5.4298    |
| 18   | 4.8583    | 5.9442    | 6.1157    | 6.0014    | 5.8299    | 5.4298    | 5.6013    |
| 19   | 5.7156    | 7.1445    | 6.4586    | 7.1445    | 6.8587    | 6.3443    | 4.2867    |
| 20   | 5.4298    | 6.2872    | 6.0585    |           | 6.23      | 7.316     | 5.8871    |
| 21   | 5.7728    | 7.9447    | 7.5446    | 7.6017    | 6.6873    | 7.7161    | 6.4015    |
| 22   | 6.1728    | 8.059     | 7.4303    | 7.8875    | 7.3731    | 7.4874    | 7.6017    |
| 23   | 5.8299    | 7.4874    | 7.3731    | 7.7161    | 7.2017    | 6.7444    | 7.3731    |
| 24   | 6.0585    | 5.7728    | 7.5446    | 6.8587    | 7.7161    | 7.0873    | 6.5729    |
| Max  | 10.1166   | 10.3452   | 12.1171   | 11.9456   | 11.8884   | 12.1171   | 11.6027   |
| Min  | 4.0581    | 5.7728    | 5.2012    | 5.4298    | 5.3727    | 3.9438    | 4.2867    |
| Avg  | 6.8563    | 7.5160    | 7.7533    | 7.6713    | 7.4899    | 6.9707    | 7.3136    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 408 / 33 KV WOCKHARDT BIO EXP NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 4.0581    | 4.0009    | 4.1152    | 4.2295    | 4.0009    | 4.0009    | 3.9438    |
| 2    | 3.9438    | 3.8866    | 4.0009    | 4.1724    | 4.0009    | 4.1152    | 4.0581    |
| 3    | 3.8866    | 3.9438    | 4.0581    | 4.1152    | 4.0581    | 4.0581    | 4.1152    |
| 4    | 3.9438    | 3.9438    | 4.0009    | 4.1152    | 4.0009    | 4.1152    | 4.0581    |
| 5    | 3.9438    | 3.9438    | 3.8866    | 4.0581    | 4.1152    | 4.0009    | 4.0009    |
| 6    | 4.1724    | 4.0009    | 4.0009    | 4.2867    | 4.0009    | 4.1152    | 3.8866    |
| 7    | 4.1152    | 4.0009    | 4.0581    | 4.2295    | 4.0581    | 4.3439    | 3.8866    |
| 8    | 4.0581    | 4.2867    | 4.2295    | 4.3439    | 3.9438    | 4.2867    | 4.1152    |
| 9    | 4.1152    | 4.2867    | 4.1724    | 4.401     | 4.1152    | 4.3439    | 4.1724    |
| 10   | 4.2295    | 4.4582    | 4.4582    | 4.6868    | 4.2867    | 4.5725    | 4.2295    |
| 11   | 4.4582    | 4.5153    | 4.5153    | 4.6296    | 4.5725    | 4.5725    | 4.1724    |
| 12   | 4.1724    | 4.5725    | 4.5725    | 4.6296    | 4.5725    | 4.5725    | 4.401     |
| 13   | 4.2867    | 4.5153    | 4.5725    | 4.4582    | 4.2867    | 4.5725    | 4.2867    |
| 14   | 4.1724    | 4.4582    | 4.6296    | 4.9726    | 4.4582    | 4.7439    | 4.2295    |
| 15   | 4.2867    | 4.4582    | 4.6868    | 4.5725    | 4.3439    | 4.5725    | 4.1724    |
| 16   | 4.401     | 4.5725    | 4.5725    | 4.5725    | 4.2295    | 4.6296    | 4.1152    |
| 17   | 4.1724    | 4.4582    | 4.6868    | 4.5725    | 4.5725    | 4.401     | 4.2867    |
| 18   | 4.0009    | 4.3439    | 4.4582    | 4.2867    | 4.5725    | 4.2867    | 4.0581    |
| 19   | 3.9438    | 4.0581    | 4.2867    | 4.1152    | 4.2867    | 4.2867    | 3.8866    |
| 20   | 4.0009    | 4.0581    | 4.2867    | 4.0581    | 4.1724    | 4.1724    | 3.9438    |
| 21   | 3.9438    | 4.0009    | 4.2867    | 3.9438    | 4.1152    | 4.0009    | 4.0009    |
| 22   | 4.0009    | 3.9438    | 4.2867    | 4.0009    | 4.0009    | 4.2295    | 4.0009    |
| 23   | 4.0009    |           | 4.2867    | 4.0009    | 4.0009    | 4.0581    | 3.8295    |
| 24   | 4.1152    | 3.8866    | 4.1152    | 4.2867    | 4.0009    | 4.0009    | 3.9438    |
| Max  | 4.4582    | 4.5725    | 4.6868    | 4.9726    | 4.5725    | 4.7439    | 4.401     |
| Min  | 3.8866    | 3.8866    | 3.8866    | 3.9438    | 3.9438    | 4.0009    | 3.8295    |
| Avg  | 4.1009    | 4.1997    | 4.3010    | 4.3224    | 4.1986    | 4.2938    | 4.0747    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 409 / 33 KV M - SECTOR FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 5.2584    | 4.1724    | 5.9442    | 6.23      | 6.0014    | 6.1728    | 4.5725    |
| 2    | 5.2012    | 4.2867    | 5.8299    | 6.1728    | 5.8871    | 6.1157    | 4.6296    |
| 3    | 4.9726    | 4.3439    | 6.0585    | 6.0014    | 5.6584    | 6.0014    | 4.6868    |
| 4    | 4.8583    | 4.401     | 5.8299    | 6.0585    | 5.4298    | 6.0585    | 4.8583    |
| 5    | 4.8011    | 4.4582    | 5.8871    | 6.0014    | 5.487     | 6.23      | 4.7439    |
| 6    | 4.8011    | 4.8583    | 6.23      | 6.1157    | 6.1728    | 6.4586    | 4.6868    |
| 7    | 4.0581    | 5.4298    | 5.7728    | 5.144     | 5.6584    | 4.9154    | 6.0014    |
| 8    | 4.0581    | 6.3443    | 6.4015    | 6.7444    | 6.9159    | 5.144     | 6.4586    |
| 9    | 4.1724    | 7.4303    | 7.7732    | 7.8304    | 8.2305    | 5.487     | 8.2305    |
| 10   | 4.4582    | 8.5162    | 8.5734    | 8.2305    | 9.0878    | 5.0297    | 9.145     |
| 11   | 4.401     | 8.6877    | 8.8592    | 8.1162    | 9.145     | 5.487     | 9.6022    |
| 12   | 4.3439    | 7.0873    | 8.8592    | 8.059     | 7.7732    | 5.2012    | 7.7732    |
| 13   | 4.2295    | 8.2876    | 7.4303    | 6.6301    | 7.4874    | 5.3727    | 7.5446    |
| 14   | 5.0297    | 8.1162    | 8.802     | 8.059     |           | 6.2872    | 8.4591    |
| 15   | 5.0869    | 8.4019    | 8.6877    | 7.1445    | 9.4879    | 6.3443    | 8.5734    |
| 16   | 5.144     | 8.3448    | 8.8592    | 8.2305    | 8.8592    | 6.0014    | 9.0306    |
| 17   | 5.2012    | 8.3448    | 9.145     | 8.8592    | 8.802     | 6.4586    | 9.3164    |
| 18   |           |           | 8.802     | 8.059     | 8.802     | 5.487     | 7.1445    |
| 19   | 4.2867    | 6.0014    |           | 6.4586    | 6.6873    | 4.5153    | 6.5158    |
| 20   | 4.1152    | 6.1728    | 6.23      | 6.1728    | 6.8016    | 4.5153    | 6.3443    |
| 21   | 4.2867    | 5.9442    | 6.1728    | 5.8871    | 6.6301    | 4.4582    | 6.2872    |
| 22   | 4.2867    | 6.1157    | 6.2872    | 5.8871    | 6.4015    | 4.7439    | 6.4586    |
| 23   | 4.4582    | 6.3443    | 6.5158    | 6.0014    | 6.2872    | 4.5153    | 6.3443    |
| 24   | 5.2584    | 4.2867    | 6.1728    | 6.5158    | 5.7728    | 6.6301    | 5.6013    |
| Max  | 5.2584    | 8.6877    | 9.145     | 8.8592    | 9.4879    | 6.6301    | 9.6022    |
| Min  | 4.0581    | 4.1724    | 5.7728    | 5.144     | 5.4298    | 4.4582    | 4.5725    |
| Avg  | 4.6421    | 6.3642    | 7.1793    | 6.8587    | 7.1072    | 5.5679    | 6.7920    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 410 / 33 KV E+H EXP FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0572     | .0572     | .1143     | .0572     | .0572     | .0572     | .0572     |
| 2    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 3    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 4    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 5    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 6    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 7    | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| 8    | .0572     | .1143     | .0572     | .0572     | .0572     | .1715     | .0572     |
| 9    | .0572     | .1143     | .2286     | .0572     | .0572     | .1715     | .0572     |
| 10   | .3429     | .0572     | .3429     | .2286     | .1143     | .2858     | .2858     |
| 11   | .4001     | .0572     | .1715     | .2286     | .1143     | .2286     | .0572     |
| 12   | .4001     | .0572     | .0572     | .0572     | .0572     | .0572     | .4001     |
| 13   | .2286     | .1143     | .0572     | .0572     | .0572     | .1143     | .4001     |
| 14   | .3429     | .1143     | .1143     | .4572     | .1143     | .0572     | .1715     |
| 15   | .2858     | .1143     | .1143     | .0572     | .1715     | .0572     | .1143     |
| 16   | .2286     | .4001     | .1715     | .6287     | .1715     | .8002     | .0572     |
| 17   | .0572     | .1715     | .2858     | .2858     | .1143     | .1715     | .1143     |
| 18   | .0572     | .1715     | .1715     | .2858     | .1715     | .1715     | .1715     |
| 19   | .1143     | .4572     | .1715     | .2286     | .5144     | .1715     | .1143     |
| 20   | .0572     | .2286     | .1143     | .2286     | .2286     | .1143     | .1143     |
| 21   | .0572     | .2286     | .1143     | .2858     | .2286     | .1143     | .1143     |
| 22   | .0572     | .2286     | .1143     | .0572     | .2286     | .1143     | .1143     |
| 23   | .0572     | .1715     | .1143     | .2858     | .1143     | .1143     | .0572     |
| 24   | .0572     | .0572     | .1143     | .1143     | .1143     | .0572     | .0572     |
| Max  | .4001     | .4572     | .3429     | .6287     | .5144     | .8002     | .4001     |
| Min  | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     | .0572     |
| Avg  | .1358     | .1358     | .1239     | .1667     | .1262     | .1405     | .1191     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 411 / 33 KV V.A ENGINEERS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0572     | .0572     | .4572     | 1.0288    | 1.0288    | .9717     | .4572     |
| 2    | .0572     | .0572     | .4572     | .8573     | .9717     | .9145     | .0572     |
| 3    | .0572     | .0572     | .4572     | .8002     | .9717     | 1.086     | .0572     |
| 4    | .0572     | .1143     | .4572     | 1.086     | 1.0288    | .9717     | .0572     |
| 5    | .0572     | .2858     | 1.0288    | .9145     | .9717     | .8573     | .0572     |
| 6    | .0572     | .0572     | .9717     | .8573     | .9717     | .8002     | .0572     |
| 7    | .0572     |           | .4001     | .4572     | .4572     | .4001     | .0572     |
| 8    | .0572     | .0572     | 1.0288    | .4572     |           | .4572     | .0572     |
| 9    | .0572     | .0572     | .5144     | .5144     |           | .4572     | .5716     |
| 10   | .4572     | .2858     | 1.086     | .5144     |           | .4572     | .0572     |
| 11   | .0572     | .5144     | 1.0288    | .6287     | 1.086     | .4572     | .5144     |
| 12   | .0572     | .5144     | 1.086     | 1.0288    | 1.086     | .5144     | .0572     |
| 13   | .0572     | .0572     | .5144     | .4572     | .5716     | .4572     | .0572     |
| 14   | .5716     | .2286     | 1.086     | 1.0288    | .9717     | .5144     | .4001     |
| 15   | .6287     | .3429     | .3429     | .9717     | .9717     | .5144     | .3429     |
| 16   | .5716     | .3429     | .5144     | 1.086     | .9717     | .4001     | .0572     |
| 17   | .6287     | .2286     | .9717     | 1.086     | .5144     | .4001     | .0572     |
| 18   | .4572     | .4572     | 1.0288    | 1.0288    | .4572     | .4001     | .5716     |
| 19   | .0572     | .3429     | .5144     | .5144     | .5716     | .4001     | .0572     |
| 20   | .0572     | .4572     | .5144     | 1.0288    | .4001     | .4001     | .5144     |
| 21   | .0572     | .4572     | .5716     | 1.0288    | .5144     | .4001     | .2286     |
| 22   | .0572     | .4572     | .8002     | .5144     | .5144     | .4572     | .0572     |
| 23   | .0572     | .4572     | 1.086     | 1.0288    | .8002     | .4572     | .5144     |
| 24   | .0572     | .0572     | .4572     | 1.086     | .8573     | .9145     | .4572     |
| Max  | .6287     | .5144     | 1.086     | 1.086     | 1.086     | 1.086     | .5716     |
| Min  | .0572     | .0572     | .3429     | .4572     | .4001     | .4001     | .0572     |
| Avg  | .1810     | .2584     | .7240     | .8335     | .7948     | .5858     | .2239     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 412 / 33 KV ORCHID FEEDER  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.915     | 2.3434    | 2.8578    | 2.915     | 2.8578    | 2.8578    | 2.6292    |
| 2    | 2.915     | 2.4006    | 2.6292    | 2.915     | 2.7435    | 2.915     | 2.6863    |
| 3    | 2.915     |           | 2.5149    | 2.915     | 2.6863    | 2.915     | 2.7435    |
| 4    | 2.8578    | 2.5149    | 2.4006    | 2.8578    | 2.6292    | 2.8578    | 2.7435    |
| 5    | 2.8578    | 2.4006    | 2.2862    | 2.8578    | 2.5149    | 2.915     | 2.7435    |
| 6    | 2.8578    | 2.5149    | 2.4006    | 2.8578    | 2.5149    | 2.8578    | 2.6863    |
| 7    | 2.8006    | 2.4006    | 2.4006    | 2.8578    | 2.3434    | 2.8578    | 2.5149    |
| 8    | 2.8006    | 2.2862    | 2.6292    | 2.8578    | 2.4577    | 2.8006    | 2.4577    |
| 9    | 2.7435    | 2.8578    | 2.7435    | 2.8578    |           | 2.8006    | 2.5149    |
| 10   | 2.8578    | 2.8578    | 2.8578    | 2.8578    | 2.8578    | 2.8578    | 3.0864    |
| 11   | 2.3434    | 2.8578    | 2.8578    | 2.8578    | 2.8578    | 2.8578    | 2.9721    |
| 12   | 2.2862    | 2.9721    | 2.8578    | 2.6292    | 2.915     | 2.8578    | 3.0864    |
| 13   | 2.3434    | 3.0864    | 2.8578    | 2.9721    | 2.8578    | 2.8578    | 3.0864    |
| 14   | 2.3434    | 2.9721    | 2.8578    | 3.2007    | 3.0293    | 2.8578    | 3.0293    |
| 15   | 2.3434    | 3.0864    | 2.8578    | .6287     | 2.915     | 2.8578    | 2.9721    |
| 16   | 2.3434    | 2.9721    | 2.8578    | 2.8578    | 3.0864    | 2.915     | 3.0864    |
| 17   | 2.2862    | 3.0864    | 2.8578    | 2.915     | 2.8578    | 2.915     | 2.8578    |
| 18   | 2.6292    | 2.9721    | 2.915     | 2.9721    | 2.8578    | 2.6292    | 2.6292    |
| 19   | 2.8578    | 2.9721    | 2.8578    | 3.1436    | 2.8578    | 2.915     | 2.7435    |
| 20   | 2.6292    | 2.8578    | 2.8578    | 2.9721    | 2.9721    | 2.8578    | 2.7435    |
| 21   | 2.6292    | 2.8578    | 2.8578    | 2.915     | 2.915     | 2.7435    | 2.7435    |
| 22   | 2.3434    | 2.9721    | 2.8578    | 2.8578    | 2.8578    | 2.6292    | 2.9721    |
| 23   | 2.915     | 2.9721    | 2.8578    | 2.7435    | 2.8578    | 2.6292    | 2.7435    |
| 24   | 2.915     | 2.6292    | 2.8578    | 2.8578    | 2.5149    | 2.8578    | 2.6292    |
| Max  | 2.915     | 3.0864    | 2.915     | 3.2007    | 3.0864    | 2.915     | 3.0864    |
| Min  | 2.2862    | 2.2862    | 2.2862    | .6287     | 2.3434    | 2.6292    | 2.4577    |
| Avg  | 2.6554    | 2.7758    | 2.7411    | 2.8030    | 2.7808    | 2.8340    | 2.7959    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 413 / 33KV Mylan

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4006    | 2.1148    | 2.2862    | 2.3434    | 2.4006    | 2.5149    | 2.2862    |
| 2    | 2.4006    | 2.1719    | 2.2862    | 2.3434    | 2.3434    | 2.4006    | 2.3434    |
| 3    | 2.3434    | 2.1148    | 2.2291    | 2.2862    | 2.2862    | 2.3434    | 2.2291    |
| 4    | 2.3434    | 2.0576    | 2.2862    | 2.2862    | 2.7435    | 2.3434    | 2.1148    |
| 5    | 2.3434    | 2.1148    | 2.2291    | 2.2291    | 2.2291    | 2.2862    | 2.1719    |
| 6    | 2.4006    | 2.1148    | 2.2291    | 2.2291    | 2.2862    | 2.2862    | 2.1719    |
| 7    | 2.1148    | 2.1719    | 2.2291    | 2.0576    | 2.1719    | 2.2291    | 2.1719    |
| 8    | 2.2291    | 2.2291    | 2.3434    | 2.2862    | 2.6863    |           | 2.5149    |
| 9    | 2.2862    | 2.2862    | 2.3434    | 2.3434    | 2.572     |           | 2.5149    |
| 10   | 2.4006    | 2.4006    | 2.572     | 2.6863    | 2.8578    |           | 2.6863    |
| 11   | 2.4006    | 2.5149    | 2.572     | 2.6863    | 2.915     | 2.2862    | 2.8006    |
| 12   | 2.3434    | 2.5149    | 2.915     | 2.6292    | 2.572     | 2.8006    | 2.5149    |
| 13   | 2.3434    | 2.2862    | 2.572     | 2.6292    | 2.6292    | 2.8578    | 2.5149    |
| 14   | 2.5149    | 2.5149    | 2.6292    | 2.6292    | 2.572     | 2.572     | 2.572     |
| 15   | 2.4577    | 2.4577    | 2.6292    | .1715     | 2.6292    | 2.3434    | 2.6863    |
| 16   | 2.4006    | 2.572     | 2.4006    | 2.8578    | 2.6292    | 2.2862    | 2.5149    |
| 17   | 2.572     | 2.5149    | 2.6863    | 2.8006    | 2.572     | 2.5149    | 2.5149    |
| 18   | 2.1719    | 2.572     | 2.572     | 2.4006    | 2.6292    | 2.4577    |           |
| 19   | 2.3434    | 2.8006    | 2.4577    | 2.4577    | 2.2862    | 2.7435    |           |
| 20   | 2.0005    | 2.4577    | 2.572     | 2.4006    | 2.572     | 2.5149    | 2.572     |
| 21   | 2.1719    | 2.4006    | 2.5149    | 2.4006    | 2.5149    | 2.5149    | 2.4577    |
| 22   | 2.0576    | 2.2291    | 2.5149    | 2.5149    | 2.4006    | 2.572     | 2.4006    |
| 23   | 2.2291    | 2.2862    | 2.4577    | 2.4577    | 2.4577    | 2.2862    | 2.1719    |
| 24   | 2.4006    | 2.2291    | 2.2862    | 2.2862    | 2.3434    | 2.5149    | 2.2862    |
| Max  | 2.572     | 2.8006    | 2.915     | 2.8578    | 2.915     | 2.8578    | 2.8006    |
| Min  | 2.0005    | 2.0576    | 2.2291    | .1715     | 2.1719    | 2.2291    | 2.1148    |
| Avg  | 2.3196    | 2.3386    | 2.4506    | 2.3505    | 2.5125    | 2.4604    | 2.4187    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 414 / 33 KV Varroc ( M-191/3 ) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.7435    | 2.1719    | 3.2007    | 2.7435    | 2.7435    | 3.4294    | 2.572     |
| 2    | 3.0864    | 2.2862    | 2.9721    | 2.8578    | 2.8578    | 3.2007    | 2.7435    |
| 3    | 3.0864    | 2.3434    | 3.2007    | 2.8578    | 2.572     | 2.9721    | 2.8006    |
| 4    | 2.8578    | 2.4577    | 2.9721    | 2.7435    | 2.8006    | 2.7435    | 2.6863    |
| 5    | 2.6292    | 2.2862    | 3.0864    | 2.7435    | 2.8578    | 2.6292    | 2.8578    |
| 6    | 2.6292    | 2.4006    | 2.5149    | 3.0864    | 2.915     | 2.5149    | 2.6292    |
| 7    | 2.2862    | 2.0576    | 2.4006    | 2.5149    | 2.7435    | 2.5149    | 2.6292    |
| 8    | 2.2862    | 2.8578    | 2.8578    | 4.1152    | 3.1436    | 3.5437    | 3.4294    |
| 9    | 2.1719    | 5.7156    | 2.9721    | 5.7156    | 6.2872    | 5.487     | 2.8578    |
| 10   | 4.0009    | 5.6013    | 6.2872    |           | 3.658     | 5.7156    | 3.315     |
| 11   | 4.0009    | 3.315     | 6.2872    | 5.6584    | 6.8587    | 6.3443    | 3.4294    |
| 12   | 2.2862    | 4.9154    | 5.144     | 5.2584    | 5.7156    | 5.2584    | 3.0864    |
| 13   | 4.0009    | 6.1728    | 2.8578    | .6287     | 6.2872    | 6.2872    | 4.8011    |
| 14   | 4.0009    | 5.6013    | 2.8578    | 5.8299    | 5.7156    | 5.7156    | 4.6868    |
| 15   | 3.9438    | 5.487     | 5.7156    | 1.4861    | 6.0585    | 5.7728    | 4.8011    |
| 16   | 4.0009    | 5.9442    | 5.9442    | 6.9159    | 6.6301    | 6.9159    | 4.9154    |
| 17   | 4.0009    | 3.2007    | 5.7156    | 6.9159    | 5.7156    | 5.487     | 4.8011    |
| 18   | 2.1719    | 3.7723    | 6.6301    | 6.3443    | 6.8587    | 6.0014    | 3.658     |
| 19   | 2.2862    | 2.9721    | 2.8578    | 2.915     | 2.9721    | 6.0014    | 2.9721    |
| 20   | 2.2862    | 2.6292    | 2.8578    | 2.9721    | 2.9721    | 4.0009    | 2.6292    |
| 21   | 2.0576    | 2.6863    | 2.8578    | 2.9721    | 2.915     | 3.0293    | 2.7435    |
| 22   | 2.0576    | 2.7435    | 2.915     | 2.915     | 2.8578    | 2.9721    | 2.9721    |
| 23   | 2.0576    | 2.8578    | 2.9721    | 2.7435    | 2.8578    | 2.8578    | 3.0864    |
| 24   | 2.7435    | 2.0576    | 2.5149    | 2.5149    | 2.5149    | 2.5149    | 2.5149    |
| Max  | 4.0009    | 6.1728    | 6.6301    | 6.9159    | 6.8587    | 6.9159    | 4.9154    |
| Min  | 2.0576    | 2.0576    | 2.4006    | .6287     | 2.5149    | 2.5149    | 2.5149    |
| Avg  | 2.9030    | 3.5222    | 3.7747    | 3.7151    | 4.1462    | 4.3296    | 3.3174    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 415 / 33 KV Endurance ( L-6)

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5432    | 1.0288    | 2.572     | 2.7435    | 2.7435    | 2.8578    | 2.7435    |
| 2    | 1.7147    | 1.7147    | 2.572     | 2.8006    | 2.6863    | 2.915     | 2.9721    |
| 3    | 1.4289    | 1.7147    | 2.6292    | 2.9721    | 2.6292    | 2.8006    | 2.915     |
| 4    | 1.4861    | 1.7147    | 2.572     | 2.9721    | 2.572     | 2.915     | 2.8578    |
| 5    | 1.3717    | 1.7147    | 2.6292    | 3.0293    | 2.7435    | 2.8578    | 3.0293    |
| 6    | 1.3146    | 1.7147    | 2.6863    | 3.0293    | 2.6863    | 3.0864    | 3.1436    |
| 7    | 1.0288    | 2.0005    | 2.2862    | 2.572     | 2.6863    | 2.6863    | 2.572     |
| 8    | 1.0288    | 2.4006    | 2.572     | 2.7435    | 2.6863    | 2.6863    | 2.915     |
| 9    | 1.0288    | 2.2862    | 2.5149    | 2.8578    | 2.8578    | 2.8006    | 2.915     |
| 10   | 1.0288    | 2.4006    | 2.572     |           | 2.8578    | 2.8578    | 2.9721    |
| 11   | .8573     | 2.4577    | 2.572     |           | 2.572     | 2.9721    | 2.915     |
| 12   | .8573     | 2.6292    | 2.572     |           | 2.8578    | 3.1436    | 2.8578    |
| 13   | .8573     | 2.7435    | 2.8578    |           |           | 3.0864    | 2.6292    |
| 14   | .8573     | 2.7435    | 2.8578    |           | 2.7435    | 2.8578    | 2.8578    |
| 15   | .8573     | 2.8006    | 2.8578    |           | 3.2579    | 2.9721    | 2.9721    |
| 16   | .9145     | 2.572     | 2.8578    |           | 3.0864    | 3.1436    | 3.0864    |
| 17   | .8573     | 2.7435    | 2.8578    |           | 2.9721    | 3.1436    | 3.0293    |
| 18   | .8573     | 2.5149    | 2.572     |           | 2.8578    | 3.1436    | 2.8006    |
| 19   | .9145     | 2.5149    | 2.8578    |           | 2.9721    | 2.7435    | 2.6292    |
| 20   | .8573     | 2.5149    | 2.8578    | 2.5149    | 2.8578    | 2.6863    | 2.6292    |
| 21   | .8573     | 2.5149    | 2.572     | 2.4006    | 2.915     | 2.6863    | 2.6292    |
| 22   | .8573     | 2.572     | 2.6863    | 2.8578    | 2.9721    | 2.6863    | 2.6863    |
| 23   | .9145     | 2.572     | 2.7435    | 2.6292    | 2.8578    | 2.915     | 2.572     |
| 24   | 1.6004    | .9145     | 2.2291    | 2.572     | 2.7435    | 2.8578    | 2.6292    |
| Max  | 1.7147    | 2.8006    | 2.8578    | 3.0293    | 3.2579    | 3.1436    | 3.1436    |
| Min  | .8573     | .9145     | 2.2291    | 2.4006    | 2.572     | 2.6863    | 2.572     |
| Avg  | 1.0788    | 2.2291    | 2.6482    | 2.7639    | 2.8180    | 2.8959    | 2.8316    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 416 / 33 KV ENDURANCE EXP (K- NON SHEDDABLE EXPRESS HV FEEDERS  
SECTOR) Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.7435    | 2.9721    | 5.9442    | 6.23      | 5.0297    | 5.8299    | 5.6013    |
| 2    | 2.1719    | 3.2007    | 5.8299    | 6.0014    | 5.0869    | 5.7156    | 5.7156    |
| 3    | 2.1148    | 3.4294    | 5.8299    | 5.8299    | 5.2012    | 5.6584    | 5.7728    |
| 4    | 2.1148    | 3.4865    | 5.8299    | 5.6584    | 5.0297    | 5.5441    | 5.6013    |
| 5    | 2.0005    | 3.7151    | 5.9442    | 5.487     | 5.2584    | 5.487     | 5.6584    |
| 6    | 2.0005    | 3.6008    | 5.5441    | 5.487     | 5.2012    | 5.6013    | 5.7728    |
| 7    | 2.0576    | 4.1152    | 4.8011    | 4.5725    | 4.6868    | 5.2584    | 5.487     |
| 8    | 2.0576    | 5.0869    | 5.6584    | 5.7728    | 5.3727    | 5.7156    | 5.487     |
| 9    | 2.0005    | 5.6013    | 5.487     | 6.4586    | 5.3727    | 6.0585    | 5.7728    |
| 10   | 2.1719    | 5.487     | 5.8871    | 6.1728    | 5.2584    | 5.9442    | 5.487     |
| 11   | 1.5432    | 5.6013    | 5.9442    | 6.1728    | 4.8011    | 6.1157    | 5.3727    |
| 12   | 1.829     | 6.0014    | 6.0585    | 5.6584    | 5.3155    | 5.0297    | 5.6013    |
| 13   | 1.6004    | 6.1728    | 5.9442    | 6.1728    | 5.144     | 5.3727    | 5.6584    |
| 14   | 1.5432    | 5.6013    | 6.0014    | 6.3443    | 5.487     | 5.487     | 5.8299    |
| 15   | 2.0576    | 5.2012    | 6.1157    |           | 5.5441    | 8.059     | 5.7728    |
| 16   | 2.2291    | 5.6013    | 6.1728    |           | 5.2584    | 6.3443    | 5.8299    |
| 17   | 2.1148    | 5.9442    | 6.1157    |           | 5.2584    | 6.3443    | 5.7728    |
| 18   | 2.5149    | 5.487     | 5.8299    |           | 5.487     | 6.3443    | 5.7156    |
| 19   | 2.4006    | 5.5441    | 5.2584    |           | 4.401     | 5.4298    | 5.3155    |
| 20   | 2.8006    | 5.487     | 5.5441    |           | 4.9154    | 6.0014    | 5.144     |
| 21   | 3.315     | 5.5441    | 5.6013    |           | 5.6013    | 6.0585    |           |
| 22   | 2.7435    | 5.6013    | 5.6584    | 3.658     | 5.7728    | 6.0014    |           |
| 23   | 3.2579    | 5.8299    | 5.6013    | 5.0869    | 6.0585    | 6.4586    | 2.9721    |
| 24   | 2.6292    | 3.2007    | 5.7728    | 5.7156    | 5.0297    | 5.6013    | 5.6013    |
| Max  | 3.315     | 6.1728    | 6.1728    | 6.4586    | 6.0585    | 8.059     | 5.8299    |
| Min  | 1.5432    | 2.9721    | 4.8011    | 3.658     | 4.401     | 5.0297    | 2.9721    |
| Avg  | 2.2505    | 4.8964    | 5.7656    | 5.6752    | 5.2322    | 5.8942    | 5.4974    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 201 / KAIZEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8764     | 1.0669    | 1.2193    | 1.2193    | 1.2574    | 1.1431    | 1.0669    |
| 2    | .8383     | 1.0288    | 1.2574    | 1.2574    | 1.1812    | 1.1812    | 1.0288    |
| 3    | .8002     | .9907     | 1.1812    | 1.2193    | 1.2193    | 1.1431    | .9907     |
| 4    | .8383     | 1.0288    | 1.2193    | 1.2193    | 1.2574    | 1.2193    | 1.0288    |
| 5    | .8002     | 1.0669    | 1.1812    | 1.1812    | 1.2193    | 1.1812    | 1.0669    |
| 6    | .8383     | 1.0288    | 1.2574    | 1.1431    | 1.2574    | 1.2193    | .9526     |
| 7    | .724      | .8383     | 1.2384    | 1.0288    | 1.1812    | .9145     | 1.0479    |
| 8    | .6859     | 1.0669    | 1.0669    | 1.1431    | 1.0669    | .9907     | 1.0669    |
| 9    | .8383     | 1.2574    | 1.3336    | 1.3717    | 1.1622    | 1.1431    | 1.3717    |
| 10   | .9526     | 1.3336    | 1.448     | 1.6004    | 1.448     | 1.2193    | 1.4289    |
| 11   | 1.2574    | 1.5623    | 1.2574    | 1.5242    | 1.5242    | 1.2384    | 1.829     |
| 12   | 1.1812    | 1.1812    | 1.5813    | 1.6004    | 1.3717    | 1.2193    | 1.6004    |
| 13   | 1.0669    | 1.105     | 1.0288    | 1.3717    | 1.2193    | 1.1812    | 1.2955    |
| 14   | 1.2384    | 1.5242    | 1.5432    | 1.5242    | 1.3717    | 1.1431    | 1.5242    |
| 15   | 1.2574    | 1.5242    | 1.6004    |           | 1.448     | 1.1431    | 1.448     |
| 16   | 1.0669    | 1.3717    | 1.448     | 1.4861    | 1.3717    | 1.2193    | 1.448     |
| 17   | 1.0669    | 1.3336    | 1.5623    | 1.5242    | 1.3717    | 1.2384    | 1.3717    |
| 18   | .9907     | 1.3336    | 1.448     | 1.448     | 1.2193    | 1.1812    | 1.0669    |
| 19   | .9526     | 1.3336    | 1.0669    | 1.2955    | 1.2955    | .9907     | 1.1812    |
| 20   | .8764     | 1.2384    | 1.0669    | .9907     | 1.1431    | 1.0288    | 1.2193    |
| 21   | 1.0288    | 1.2384    | 1.0098    | 1.2193    | 1.3717    | 1.0669    | 1.3336    |
| 22   | .9907     | 1.3336    | 1.3146    | 1.3336    | 1.3717    | 1.1431    | 1.2384    |
| 23   | .8002     | 1.0669    | 1.7337    | 1.105     | 1.0669    | 1.1431    | 1.2955    |
| 24   | 1.1431    | .8002     | 1.2193    | 1.3717    | 1.1431    | 1.105     | 1.105     |
| Max  | 1.2574    | 1.5623    | 1.7337    | 1.6004    | 1.5242    | 1.2384    | 1.829     |
| Min  | .6859     | .8002     | 1.0098    | .9907     | 1.0669    | .9145     | .9526     |
| Avg  | .9629     | 1.1939    | 1.3035    | 1.3121    | 1.2725    | 1.1415    | 1.2503    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 202 / MDS ALLOYS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3048     | .6097     | .6478     | .6097     | .7049     | .6097     | .2667     |
| 2    | .3048     |           | .6859     | .5716     | .6859     | .5335     |           |
| 3    | .2667     | .6859     | .6097     | .6097     | .6478     | .5716     | .2858     |
| 4    | .2286     | .6478     | .6478     | .5716     | .6478     | .4572     | .2858     |
| 5    | .2667     | .724      | .6668     | .5335     | .6859     | .5335     | .2667     |
| 6    | .2286     | .6859     | .6859     | .5716     | .6287     | .4572     | .2858     |
| 7    | .2286     | .3429     | .6668     | .6859     | .5335     | .3048     | .2858     |
| 8    | .2286     | .5716     | .724      | .6859     | .6859     | .2286     | .3429     |
| 9    |           | .7621     | .8573     | .8383     | .8764     | .381      | .7621     |
| 10   | .3429     | .8573     | .8383     | 1.0098    | .8383     | .4572     | .8573     |
| 11   | .381      | .9526     | 1.0479    | 1.086     | .9145     | .4191     | .8764     |
| 12   | .381      | .8002     | .8383     | 1.0669    | .9145     | .381      | .8383     |
| 13   | .3429     | .8002     | .7621     | .724      | .6859     | .4191     | .9145     |
| 14   | .381      | .9526     | .9335     | .9145     | .8383     | .4191     | 1.0288    |
| 15   | .381      | 1.0479    | .8383     |           | .9145     | .4572     | .9907     |
| 16   | .3429     | 1.0669    | 1.0288    | 1.0669    | .9145     | .4191     | .9907     |
| 17   | .381      | 1.0669    | .9526     | .9526     | .9145     | .381      | 1.0288    |
| 18   | .3429     | .9145     | .8573     | .9145     | .7621     | .3429     | .5335     |
| 19   | .3239     | .6097     | .7049     | .7621     | .6859     | .3048     | .7621     |
| 20   | .3048     | .5335     | .6859     | .7621     | .5335     | .2667     | .724      |
| 21   | .381      | .6097     | .5525     | .7049     | .5906     | .3048     | .6859     |
| 22   | .3429     | .6478     | .5906     | .6859     | .6097     | .2858     | .6859     |
| 23   | .3429     | .724      | .5716     | .724      | .6097     | .2667     | .724      |
| 24   | .2286     | .4572     | .6859     | .5716     | .6859     | .6478     | .3048     |
| Max  | .381      | 1.0669    | 1.0479    | 1.086     | .9145     | .6478     | 1.0288    |
| Min  | .2286     | .3429     | .5525     | .5335     | .5335     | .2286     | .2667     |
| Avg  | .3156     | .7422     | .7534     | .7662     | .7296     | .4104     | .6403     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 203 / NATH FORGING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8383     | .9145     | .9907     | .9526     | 1.105     | .7621     | .724      |
| 2    | .8002     | .8764     | 1.0288    | .9907     | 1.0669    | .8002     | .7621     |
| 3    | .8383     | .9145     | 1.0669    | .9526     | .9907     | .8383     | .6859     |
| 4    | .8002     | .8764     | 1.0288    | .9145     | 1.0669    | .8383     | .724      |
| 5    | .7621     | .9145     | .9907     | .9526     | 1.0288    | .8002     | .7621     |
| 6    | .7621     | .9145     | .9145     | .9526     | 1.0669    | .8383     | .6859     |
| 7    | .6859     | .8764     | 1.2384    | .9145     | .9526     | .6859     | .8573     |
| 8    | .7621     | .9526     | 1.1431    | 1.1431    | 1.1431    | .8383     | .9526     |
| 9    | .7621     | 1.2193    | 1.2574    | 1.1812    | 1.1431    | .7621     | 1.3717    |
| 10   | .8383     | 1.829     | 1.6385    | 1.2193    | 1.448     |           | 1.5242    |
| 11   | .9145     | 1.6766    | 1.6766    | 1.3717    | 1.5242    |           | 1.6766    |
| 12   | .9526     | 1.3717    | 1.2955    | 1.2193    | 1.2955    |           | 1.5623    |
| 13   | .8764     | 1.5242    | 1.2955    | 1.105     | 1.1431    | .7621     | 1.105     |
| 14   | .9907     | 2.0576    | 1.7528    | 1.448     | 1.829     | .7621     | 1.9814    |
| 15   | .9526     | 1.7528    | 1.3717    |           | 1.7528    | .9907     | 1.9243    |
| 16   | .9907     | 1.6766    | 1.3336    | 1.4861    | 1.448     | .7621     | 1.4098    |
| 17   | 1.1431    | 2.21      | 1.5432    | 1.6766    | .7621     | .9526     | 1.6766    |
| 18   | 1.0669    | 1.9052    | 1.2193    | 1.5242    | 1.448     | .7621     |           |
| 19   | .8764     | 1.0669    | 1.1431    | 1.0669    | .9145     | .7621     | 1.105     |
| 20   | .7049     | 1.0479    | .9145     | .9145     | .9145     | .724      | .9145     |
| 21   | .7621     | .9145     | .8383     | .8383     | .8383     | .6478     | .7621     |
| 22   | .7621     | .9907     | .9526     | .9145     | .8383     | .6859     | .8383     |
| 23   | .7621     | 1.0669    | .8954     | .8764     | .7621     | .724      | .8383     |
| 24   | .7621     | .7621     | 1.0288    | .9526     | 1.0288    | .8002     | .7621     |
| Max  | 1.1431    | 2.21      | 1.7528    | 1.6766    | 1.829     | .9907     | 1.9814    |
| Min  | .6859     | .7621     | .8383     | .8383     | .7621     | .6478     | .6859     |
| Avg  | .8486     | 1.2630    | 1.1899    | 1.1116    | 1.1463    | .7857     | 1.1133    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 204 / FOSTERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3717    | 1.2193    | 1.6385    | 1.829     | 1.7147    | 1.5623    | 1.4861    |
| 2    | 1.3717    | 1.1812    | 1.6004    | 1.7528    | 1.7528    | 1.6766    | 1.4098    |
| 3    | 1.0669    | 1.1431    | 1.5623    | 1.7147    | 1.7147    | 1.5242    | 1.448     |
| 4    | 1.1431    | 1.1812    | 1.6004    | 1.6766    | 1.6385    | 1.5623    | 1.5242    |
| 5    | 1.3717    | 1.2193    | 1.6385    | 1.6004    | 1.6766    | 1.5242    | 1.4861    |
| 6    | 1.3717    | 1.1431    | 1.6766    | 1.6004    | 1.5242    | 1.6766    | 1.5242    |
| 7    | 1.0669    | 1.448     | 1.5242    | 1.5242    | 1.3717    | 1.2193    | 1.2384    |
| 8    | 1.0669    | 1.829     | 1.829     | 1.9052    | 1.9052    | 1.5242    | 1.6766    |
| 9    | 1.2193    | 2.0195    | 1.9814    | 2.0957    | 1.9814    | 1.6766    | 1.829     |
| 10   | 1.2574    | 2.1338    | 2.0767    | 2.2862    | 2.1719    | 1.6766    | 1.9814    |
| 11   | 1.2574    | 2.0576    | 2.7435    | 2.21      | 1.9814    | 1.829     | 2.1338    |
| 12   | 1.2193    | 1.5242    | 1.9052    | 1.9814    | 1.829     | 1.8671    | 1.5432    |
| 13   | 1.1431    | 1.829     | 1.7147    | 1.9052    | 1.6766    | 1.9052    | 1.829     |
| 14   | 1.3717    | 1.9814    | 2.191     | 2.2862    | 1.9814    | 1.9814    | 2.0195    |
| 15   | 1.3717    | 1.9814    | 2.0195    |           | 2.1338    | 2.1338    | 1.9814    |
| 16   | 1.2955    | 1.9814    | 1.9433    | 2.1338    | 1.9814    | 1.829     | 1.9814    |
| 17   | 1.3336    | 2.1338    | 2.1529    | 2.2862    | 2.2862    | 1.9814    | 2.0195    |
| 18   | 1.2574    | 1.9814    | 2.2862    | 2.0957    | 1.9814    | 1.6766    | 1.6194    |
| 19   | 1.1431    | 1.5242    | 1.5623    | 1.6766    | 1.6766    | 1.3717    | 1.5242    |
| 20   | 1.3717    |           | 1.7718    | 1.7528    | 1.6766    | 1.4098    | 1.448     |
| 21   | 1.105     | 1.5242    | 1.6385    | 1.7528    | 1.6004    | 1.448     | 1.5242    |
| 22   | 1.0669    | 1.5242    | 1.5623    | 1.7147    | 1.5242    | 1.3336    | 1.448     |
| 23   | 1.2955    | 1.5242    | 1.6956    | 1.829     | 1.5242    | 1.448     | 1.4861    |
| 24   | 1.3717    | 1.1431    | 1.5623    | 1.7147    | 1.7528    | 1.6766    | 1.4861    |
| Max  | 1.3717    | 2.1338    | 2.7435    | 2.2862    | 2.2862    | 2.1338    | 2.1338    |
| Min  | 1.0669    | 1.1431    | 1.5242    | 1.5242    | 1.3717    | 1.2193    | 1.2384    |
| Avg  | 1.2463    | 1.6186    | 1.8282    | 1.8837    | 1.7941    | 1.6464    | 1.6520    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 205 / VARSA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8002     | .9526     | .9526     | .9335     | .9526     | .6859     | .7621     |
| 2    | .8383     | .9145     | .9907     | .9145     | .9907     | .7621     | .8002     |
| 3    | .9145     | .9526     | .9145     | .8764     | .9526     | .8002     | .724      |
| 4    | .9145     | .9145     | .9526     | .9145     | .9145     | .6859     | .8002     |
| 5    | .8383     | .9526     | .9907     | .9145     | .9526     | .724      | .7621     |
| 6    | .8383     | .8764     | .8573     | .8383     | .9907     | .7621     | .724      |
| 7    | .7621     | .9145     | .9145     | .7621     | 1.0098    | .6859     | .8573     |
| 8    | .7621     | 1.0669    | .9907     | .8002     | .9907     | .6097     | .9907     |
| 9    | .7621     | 1.2574    | 1.2384    | .9145     | 1.2193    | .6097     | 1.2384    |
| 10   | .7621     | 1.3717    | 1.2574    | .8764     | 1.2193    | .6859     | 1.2955    |
| 11   | .8002     | 1.2955    | 1.3717    | .9907     | 1.1431    | .724      | 1.1431    |
| 12   | .7621     | 1.1431    | 1.1241    | .8573     | 1.0669    | .7621     | 1.1622    |
| 13   | .724      | 1.2955    | 1.1812    | .8002     | 1.2193    | .724      | 1.2193    |
| 14   | 1.1431    | 1.2955    | 1.1812    | .9145     | 1.1431    | .6668     | 1.2955    |
| 15   | 1.1812    | 1.2384    | 1.1812    |           | 1.1431    | .6097     | 1.3717    |
| 16   | .9907     | 1.2384    | 1.2955    | .9145     | 1.2193    | .6859     | 1.3146    |
| 17   | .9526     | 1.2384    | 1.2955    | .9145     | 1.3717    | .6859     |           |
| 18   | .9907     | 1.2384    | 1.1622    | .8764     | 1.2193    | .6668     | .9145     |
| 19   | .9526     | 1.1431    | 1.1431    | .8383     | 1.0669    | .6859     | 1.0669    |
| 20   | .8764     | .9145     | .9526     | .8383     | .9907     | .7049     | 1.0098    |
| 21   | .8764     | .9907     | 1.0288    | .7621     | .9907     | .7621     | 1.0669    |
| 22   | .9145     | .9145     | .9335     | .7621     | .9907     | .724      | 1.0288    |
| 23   | .8383     | .8573     | .9335     | .7621     | .9145     | .7621     | .9907     |
| 24   | .8383     | .9145     | .9145     | .9335     | .9145     | .9145     | .724      |
| Max  | 1.1812    | 1.3717    | 1.3717    | .9907     | 1.3717    | .9145     | 1.3717    |
| Min  | .724      | .8573     | .8573     | .7621     | .9145     | .6097     | .724      |
| Avg  | .8764     | 1.0788    | 1.0733    | .8656     | 1.0661    | .7121     | 1.0114    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 206 / RUBICON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7621     | .7621     | 1.0288    | .9907     | 1.0669    | .9907     | 1.0669    |
| 2    | .724      | .724      | .9907     | 1.0669    | 1.0288    | 1.0669    | 1.105     |
| 3    | .6859     | .6859     | 1.0669    | 1.1431    | .9907     | 1.1431    | 1.0288    |
| 4    | .7621     | .7621     | 1.105     |           | 1.0288    | .9907     | .9907     |
| 5    | .724      | .6478     | 1.0288    | 1.2574    | 1.0669    | .9907     | 1.0669    |
| 6    | .6859     | .6859     |           | 1.1431    | 1.0288    | .9907     | 1.1431    |
| 7    | .5335     | .6859     | .6668     | .8764     | .7621     | .9907     | .8383     |
| 8    | .6097     | .9526     | .8764     | 1.2955    | 1.1431    | .9145     | 1.1431    |
| 9    | .6859     | 1.6004    | 1.2955    | 1.3336    | 1.6766    | 1.2193    | 1.3336    |
| 10   | .6859     | 1.3717    | 1.4098    | 1.3336    | 1.448     | 1.2193    | 1.5242    |
| 11   | .724      | 1.3336    | 1.3336    | 1.448     | 1.448     | 1.5242    | 1.3717    |
| 12   | .6097     | 1.105     | 1.0288    | 1.0288    | 1.1431    | 1.4861    | 1.2193    |
| 13   | .6859     | 1.5242    | 1.5432    | 1.3717    | 1.2193    | 1.448     | 1.2384    |
| 14   | .6097     | 1.2955    | 1.4289    | 1.448     | 1.6766    | 1.3717    | 1.6004    |
| 15   | .6859     | 1.5623    | 1.8861    |           | 1.6766    | 1.0669    | 1.448     |
| 16   | .6859     | 1.1812    | 1.6004    | 1.5242    | 1.7528    | 1.3336    | 1.3717    |
| 17   | .6859     | 1.3336    | 1.9243    | 1.4098    | 1.829     | 1.4098    | 1.3146    |
| 18   | .6478     | 1.105     | 1.6766    | 1.3336    | 1.448     | 1.1431    | 1.1812    |
| 19   | .5716     | .7621     | .7621     | 1.1812    | .8383     | .6859     | .8573     |
| 20   | .4954     | .8573     | 1.3336    | 1.1812    | 1.2193    | .8764     | 1.2574    |
| 21   | .724      | .9526     | 1.2384    | .9526     | 1.1812    | .8573     | 1.2574    |
| 22   | .5335     | .7621     | .7621     | .8002     | 1.1431    | .9145     | 1.2574    |
| 23   | .6478     | 1.0669    | 1.2574    | 1.0669    | 1.1431    | .8764     | 1.1812    |
| 24   | .9145     | .7621     | 1.0288    | 1.1431    | .9526     | 1.1431    | .9526     |
| Max  | .9145     | 1.6004    | 1.9243    | 1.5242    | 1.829     | 1.5242    | 1.6004    |
| Min  | .4954     | .6478     | .6668     | .8002     | .7621     | .6859     | .8383     |
| Avg  | .6700     | 1.0201    | 1.2293    | 1.1968    | 1.2463    | 1.1106    | 1.1979    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 201 / 11KV TTK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.4006    | 1.829     | 2.0957    | 2.4387    | 2.9721    | 2.7054    | 2.2862    |
| 2    | 2.3624    | 1.829     | 2.1338    | 2.5911    | 2.934     | 2.5149    | 2.2862    |
| 3    | 2.4006    | 1.7528    | 2.1338    | 2.5911    | 2.9721    | 2.3624    | 2.21      |
| 4    | 2.4006    | 1.7528    | 2.0957    | 2.5149    | 2.8959    | 2.553     | 2.1338    |
| 5    | 2.3624    | 1.829     | 2.1338    | 2.5149    | 2.934     | 2.7435    | 2.1338    |
| 6    |           | 2.0576    | 2.1338    | 2.4387    | 2.8959    | 2.8959    | 2.1338    |
| 7    | 1.9814    | 2.1338    | 1.9814    | 2.6673    | 2.5911    | 2.7816    | 2.1338    |
| 8    | 2.2862    | 2.5911    | 2.2862    | 3.2007    | 3.0483    | 2.2862    | 3.2007    |
| 9    | 2.4387    | 3.2007    | 3.4675    | 3.8104    | 4.1152    | 2.2862    | 3.8104    |
| 10   | 2.8959    | 3.8104    | 3.2007    | 3.658     | 4.2676    | 2.2862    | 3.9628    |
| 11   | 3.0483    | 3.8104    | 3.3532    | 3.9628    | 4.5725    | 2.21      | 4.2676    |
| 12   | 3.2007    | 3.8104    | 3.0483    | 3.8104    | 4.4201    | 2.1338    | 3.8104    |
| 13   | 3.2007    | 3.3532    | 3.0483    | 3.3532    | 3.8104    | 2.21      | 3.658     |
| 14   | 3.3532    | 3.3532    | 3.3532    | 3.9628    | 4.8773    | 2.2862    | 3.9628    |
| 15   | 3.2007    | 3.0483    | 3.3532    | 3.8104    | 4.1152    | 2.2862    | 3.8104    |
| 16   | 3.2007    | 3.5056    | 3.3532    | 3.9628    |           | 2.2862    | 3.658     |
| 17   | 3.1245    | 3.3532    | 3.3532    | 3.658     | 4.4201    | 2.4387    | 3.9628    |
| 18   | 3.0483    | 3.2007    | 3.0483    | 3.8104    | 3.8104    | 2.1338    | 3.5818    |
| 19   | 2.7435    | 2.4387    | 2.8959    | 2.7435    | 3.2007    | 1.9814    | 2.5911    |
| 20   | 2.4387    | 2.4387    | 2.5911    | 3.0864    | 2.8578    | 1.9814    | 2.2862    |
| 21   | 2.2481    | 2.1338    | 2.5149    | 3.0483    | 2.7435    | 2.1338    | 2.4387    |
| 22   | 2.0195    | 2.2862    | 2.5911    | 3.0483    | 2.5149    | 2.1338    | 2.5911    |
| 23   | 1.9052    | 2.1338    | 2.5911    | 2.9721    | 2.6673    | 2.2862    | 2.6292    |
| 24   | 2.4006    | 1.829     | 2.1338    | 2.4387    | 2.9721    | 2.8959    | 2.2862    |
| Max  | 3.3532    | 3.8104    | 3.4675    | 3.9628    | 4.8773    | 2.8959    | 4.2676    |
| Min  | 1.9052    | 1.7528    | 1.9814    | 2.4387    | 2.5149    | 1.9814    | 2.1338    |
| Avg  | 2.6375    | 2.6451    | 2.7038    | 3.1706    | 3.4178    | 2.3672    | 2.9927    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 202 / 11KV G Sector  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.448     | 1.448     | 1.3717    | 1.448     | 1.829     | 1.6385    | 1.3717    |
| 2    | 1.448     | 1.3717    | 1.4098    | 1.448     | 1.8671    | 1.5242    | 1.3717    |
| 3    | 1.4098    | 1.3717    | 1.3717    | 1.3717    | 1.829     | 1.5623    | 1.2955    |
| 4    | 1.448     | 1.2955    | 1.4861    | 1.3717    | 1.8671    | 1.448     | 1.2955    |
| 5    | 1.448     | 1.2574    | 1.3717    | 1.448     | 1.829     | 1.4098    | 1.3717    |
| 6    | 1.4098    | 1.2193    | 1.3717    | 1.3717    | 1.8671    | 1.3717    | 1.5242    |
| 7    | 1.2955    | 1.4861    | 1.6004    | 1.6766    | 1.7147    | 1.3717    | 1.2193    |
| 8    | 1.5242    | 1.7147    | 2.1338    | 1.9052    | 2.0957    | 1.4098    | 1.829     |
| 9    | 1.7147    | 2.1719    | 2.2862    | 2.0957    | 2.4768    | 1.5242    | 2.3243    |
| 10   | 2.2862    | 2.4387    | 1.9052    | 2.4006    | 2.6673    | 1.5623    | 2.6673    |
| 11   | 1.9814    | 2.3624    | 2.3624    | 2.6673    | 2.3624    | 1.448     | 2.6673    |
| 12   | 1.829     | 2.2862    | 2.21      | 2.4768    | 2.2862    | 1.2574    | 2.1719    |
| 13   | 1.7147    | 1.9052    | 2.0195    | 2.2862    | 2.1338    | 1.2574    | 2.2862    |
| 14   | 1.7147    | 2.2862    | 2.21      | 2.6673    | 2.553     | 1.3336    | 2.5149    |
| 15   | 1.829     | 2.2862    | 2.2862    | 2.7816    | 2.3624    | 1.3717    | 2.4387    |
| 16   | 1.9433    | 2.21      | 2.3624    | 2.7816    | 2.3624    | 1.3717    | 2.8197    |
| 17   | 1.9433    | 2.5911    | 2.553     | 2.7816    | 2.4006    | 1.3336    | 2.8578    |
| 18   | 1.9433    | 2.3624    | 2.2862    | 2.7054    | 2.1338    | 1.2955    | .9145     |
| 19   | 1.829     | 1.829     | 2.1719    | 2.21      | 1.9052    | 1.2574    | 2.1719    |
| 20   | 1.7147    | 1.829     | 1.9814    | 2.1719    | 1.9052    | 1.2574    | 1.9052    |
| 21   | 1.6385    | 1.6004    | 1.7528    | 1.9052    | 1.7528    | 1.2955    | 1.6004    |
| 22   | 1.5623    | 1.7528    | 1.6766    | 1.829     | 1.7147    | 1.2574    | 1.6004    |
| 23   | 1.5242    | 1.6766    | 1.4861    | 1.829     | 1.7528    | 1.2193    | 1.9052    |
| 24   | 1.3717    | 1.448     | 1.3717    | 1.3717    | 1.829     | 1.7147    | 1.3336    |
| Max  | 2.2862    | 2.5911    | 2.553     | 2.7816    | 2.6673    | 1.7147    | 2.8578    |
| Min  | 1.2955    | 1.2193    | 1.3717    | 1.3717    | 1.7147    | 1.2193    | .9145     |
| Avg  | 1.6655    | 1.8417    | 1.8766    | 2.0417    | 2.0624    | 1.3955    | 1.8941    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 204 / Niton

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .724      | .6478     | .6478     | .7621     | .724      | .7621     | .5716     |
| 2    | .6859     | .6478     | .6859     | .7621     | .7621     | .7621     | .5716     |
| 3    | .724      | .6478     | .6478     | .6859     | .724      | .8002     | .6097     |
| 4    | .6859     | .6478     | .6097     | .724      | .7621     | .8002     | .6478     |
| 5    | .6859     | .6478     | .6097     | .6859     |           | .7621     | .5716     |
| 6    | .6859     | .6478     | .6097     | .6859     | .7621     | .6859     | .6097     |
| 7    | .6478     | .724      | .6859     | .724      | .6478     | .724      | .6859     |
| 8    | .724      | .8764     | .9145     | .8383     | .8764     | .6859     | .7621     |
| 9    | .9526     | .9907     | .9145     | .9526     | 1.0669    |           | .8764     |
| 10   | .8002     | .9907     | 1.0669    | .9526     | 1.1812    |           | .9907     |
| 11   | .8002     | 1.0669    | 1.2193    | 1.1431    | 1.1431    | .6097     | 1.0669    |
| 12   | .8764     | 1.0669    | 1.1431    | 1.0669    | 1.105     | .6097     | .9907     |
| 13   | .8764     | .9907     | 1.0288    | .9907     | 1.0288    | .6097     | .9145     |
| 14   | .9526     | 1.1431    | 1.1812    | 1.1431    | 1.105     | .5716     | 1.0669    |
| 15   | .8764     | 1.1431    | 1.1431    | 1.0288    | 1.2193    | .5716     | 1.1431    |
| 16   | .8764     | 1.0669    | 1.0669    | 1.0669    | 1.1431    | .6097     | 1.1431    |
| 17   | .8383     | 1.0669    | 1.0288    | 1.1431    | 1.105     | .6097     | .9907     |
| 18   | .8002     | .9907     | .9526     | 1.1431    | .9526     | .5716     | 1.0669    |
| 19   | .7621     | .7621     | .9145     | .9145     | .9526     | .5716     | .8764     |
| 20   | .7621     | .7621     | .7621     | .8383     | .8383     | .6097     | .6478     |
| 21   | .724      | .6859     | .8002     | .7621     | .7621     | .6478     | .6478     |
| 22   | .724      | .6859     | .7621     | .7621     | .724      | .6097     | .6478     |
| 23   | .6478     | .7621     | .8002     | .7621     | .724      | .6097     | .6859     |
| 24   | .724      | .6478     | .6859     | .7621     | .7621     | .6859     | .5716     |
| Max  | .9526     | 1.1431    | 1.2193    | 1.1431    | 1.2193    | .8002     | 1.1431    |
| Min  | .6478     | .6478     | .6097     | .6859     | .6478     | .5716     | .5716     |
| Avg  | .7732     | .8462     | .8701     | .8875     | .9162     | .6582     | .8066     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 205 / 11KV E Sector (LIP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6478     | .5335     | .6097     | .7621     | .724      | .8002     | .5335     |
| 2    | .6097     | .5335     | .6859     | .8383     | .724      | .8002     | .5335     |
| 3    | .6478     | .5335     | .6097     | .6859     | .7621     | .7621     | .5716     |
| 4    | .6478     | .5335     | .6478     | .7621     | .724      | .724      | .5716     |
| 5    | .6478     | .5335     | .5335     | .7621     | .7621     | .724      | .5716     |
| 6    | .6478     | .6097     | .6097     | .6859     | .724      | .7621     | .6097     |
| 7    | .5335     | .6097     | .6859     | .8002     | .6859     | .8383     | .6097     |
| 8    | .4572     | .6859     | .8383     | .9526     | .8383     | .6859     | .7621     |
| 9    | .5335     | .9145     | .8383     | 1.0669    | 1.0669    |           | .9907     |
| 10   | .6859     | 1.0669    | .9145     | 1.1431    | 1.1431    |           | 1.1431    |
| 11   | .6859     | .9907     | 1.0669    | 1.1431    | 1.1431    | .6097     | 1.1431    |
| 12   | .6859     | .9145     | 1.0669    | 1.0669    | 1.1431    | .6097     | 1.0669    |
| 13   | .6478     | .9145     | .9907     | .9907     | .9907     | .6097     | 1.2193    |
| 14   | .6478     | .9907     | 1.1431    | 1.1431    | 1.1431    | .6478     | 1.2955    |
| 15   | .6478     | .9907     | 1.1431    | 1.2193    | 1.1431    | .6097     | 1.3717    |
| 16   | .6859     | 1.0669    | 1.2193    | 1.1431    | 1.1812    | .6097     | 1.3717    |
| 17   | .6478     | .9907     | 1.1431    | 1.2955    | 1.2193    | .6097     | 1.0669    |
| 18   | .6097     | .9907     | 1.0669    | 1.1812    | 1.1431    | .5716     | 1.1431    |
| 19   | .6097     | .7621     | .9526     | .8383     | .8383     | .5335     |           |
| 20   | .5716     | .6859     | .8383     | .9145     | .8002     | .5335     |           |
| 21   | .5716     | .6097     | .8764     | .6859     | .7621     | .5335     | .6287     |
| 22   | .5335     | .6859     | .8383     | .724      | .7621     | .5716     | .7621     |
| 23   | .5335     | .6097     | .8383     | .724      | .7621     | .6097     | .7621     |
| 24   | .6859     | .5335     | .6097     | .7621     | .724      | .8002     | .5335     |
| Max  | .6859     | 1.0669    | 1.2193    | 1.2955    | 1.2193    | .8383     | 1.3717    |
| Min  | .4572     | .5335     | .5335     | .6859     | .6859     | .5335     | .5335     |
| Avg  | .6176     | .7621     | .8653     | .9288     | .9129     | .6617     | .8755     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 206 / 11KV Ramnani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1431    | .8383     | .9907     | 1.1431    | 1.2193    | 1.1812    | 1.0669    |
| 2    | 1.1812    | .8383     | .9907     | 1.1431    | 1.2193    | 1.1812    | 1.0669    |
| 3    | 1.1431    | .8764     | 1.0288    | 1.1812    | 1.2193    | 1.1431    | .9907     |
| 4    | 1.1812    | .8764     | 1.0288    | 1.0669    | 1.2574    | 1.105     | .9907     |
| 5    | 1.1431    | .9145     | .9907     | 1.0669    | 1.2574    | 1.1812    | .9907     |
| 6    | 1.1431    | .8383     | .9907     | .9907     | 1.2193    | 1.1431    | 1.0669    |
| 7    | .9907     | .9526     | .9907     | 1.0288    | .9145     | 1.1812    | .9907     |
| 8    | .9907     | 1.1431    | 1.1431    | 1.1431    | 1.1431    | .9145     | 1.2193    |
| 9    | .9145     | 1.3717    | 1.6766    | 1.2955    | 1.3717    |           | 1.448     |
| 10   | .9907     | 1.6004    | 1.6766    | 1.3717    | 1.448     |           | 1.5242    |
| 11   | .9907     | 1.6004    | 1.5242    | 1.6004    | 1.6766    | 1.1431    | 1.6004    |
| 12   | 1.0669    | 1.6766    | 1.6004    | 1.448     | 1.3717    | 1.2193    | 1.448     |
| 13   | .9907     | 1.5242    | 1.6766    | 1.3717    | 1.2955    | 1.2193    | 1.6004    |
| 14   | .9907     | 1.5242    | 1.5242    | 1.448     | 1.5242    | 1.2955    | 1.6385    |
| 15   | 1.0669    | 1.2193    | 1.7528    | 1.6004    | 1.6766    | 1.2955    | 1.6004    |
| 16   | 1.1431    | 1.448     | 1.7147    | 1.6004    | 1.5242    | 1.2193    | 1.6766    |
| 17   | 1.0288    | 1.448     | 1.6004    | 1.448     | 1.3717    | 1.2193    | 1.6004    |
| 18   | .9526     | 1.5242    | 1.5242    | 1.448     | 1.2574    | 1.1431    | 1.448     |
| 19   | .9526     | 1.2193    | 1.3717    | 1.2193    | 1.1431    | 1.1431    | 1.2193    |
| 20   | .9145     | 1.3717    | 1.1431    | 1.2193    | 1.1431    | 1.105     | 1.1431    |
| 21   | .9145     | 1.2193    | 1.1812    | 1.2955    | 1.1431    | 1.0669    | 1.2193    |
| 22   | .9145     | 1.1431    | 1.1812    | 1.2574    | 1.0669    | 1.0669    | .9907     |
| 23   | .8383     | 1.1431    | 1.2193    | 1.2955    | 1.105     | 1.1431    | 1.0669    |
| 24   | 1.2193    | .7621     | 1.2193    | 1.1431    | 1.2193    | 1.1431    | .9907     |
| Max  | 1.2193    | 1.6766    | 1.7528    | 1.6004    | 1.6766    | 1.2955    | 1.6766    |
| Min  | .8383     | .7621     | .9907     | .9907     | .9145     | .9145     | .9907     |
| Avg  | 1.0336    | 1.2114    | 1.3225    | 1.2844    | 1.2828    | 1.1570    | 1.2749    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 207 / IPCA EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9052    | 1.9052    | 1.8099    | 1.9814    |           | 1.829     | 1.829     |
| 2    | 1.9052    | 1.9052    | 1.6194    | 1.9814    |           | 1.829     | 1.829     |
| 3    | 1.829     | 1.9052    | 1.9052    | 1.9814    |           | 1.829     | 1.9052    |
| 4    | 1.9052    | 1.829     | 1.9052    | 1.9052    |           | 1.7528    | 1.9052    |
| 5    | 1.9052    | 1.829     | 1.5242    | 1.9052    |           | 1.7528    | 1.829     |
| 6    | 1.9052    | 1.829     | 1.8099    | 1.829     |           | 1.7528    | 1.9052    |
| 7    | 1.829     | 1.829     | 2.0957    | 1.829     |           | 1.7528    | 1.9052    |
| 8    | 1.829     | 1.829     | 2.191     | 1.9052    |           | 1.7528    | 1.9052    |
| 9    | 1.9052    | 1.829     | 2.0957    | 1.9052    | 1.9052    | 1.9052    | 1.9052    |
| 10   | 1.9814    | 2.0576    | 2.2862    | 1.9814    | 1.9052    | 1.9814    | 1.9052    |
| 11   | 1.9814    | 2.0957    | 1.9814    | 1.9814    | 1.9052    | 1.9814    | 1.9052    |
| 12   | 2.0576    | 1.9052    | 1.9814    | 1.9052    | 1.9814    | 1.9814    | 2.0195    |
| 13   | 2.1338    | 2.2862    | 1.9052    | 2.1338    | 2.0576    | 1.9814    | 1.9814    |
| 14   | 2.21      | 2.0957    | 1.9052    | 2.21      | 2.1338    | 2.0576    | 2.1338    |
| 15   | 2.21      | 1.9052    | 1.9814    | 2.21      | 2.21      | 1.9814    | 2.0576    |
| 16   | 2.21      | 2.191     | 1.9814    | 2.21      | 2.21      | 1.9814    | 2.0576    |
| 17   | 2.1338    | 1.8099    | 2.0576    | 2.0576    | 2.2862    | 1.9433    | 1.9052    |
| 18   | 2.1338    | 2.2862    | 1.9814    | 2.0576    | 2.0576    | 1.9814    | 1.829     |
| 19   | 2.0576    | 2.0957    | 1.9814    | 1.9814    | 1.9052    | 1.9814    | 1.9052    |
| 20   | 1.9814    | 1.6194    | 1.9052    | 1.9814    | 1.9052    | 1.829     | 1.7528    |
| 21   | 1.9814    | 1.9052    | 1.9052    | 1.9052    | 1.9052    | 1.7528    | 1.7528    |
| 22   | 1.9052    | 2.0005    | 1.9052    | 1.9052    | 1.9052    | 1.829     | 1.9814    |
| 23   | 1.9052    | 1.7147    | 1.829     | 1.9052    | 1.829     | 1.9052    | 1.9814    |
| 24   | 2.0576    | 1.9814    | 1.9052    | 1.9814    |           | 1.829     | 1.829     |
| Max  | 2.21      | 2.2862    | 2.2862    | 2.21      | 2.2862    | 2.0576    | 2.1338    |
| Min  | 1.829     | 1.6194    | 1.5242    | 1.829     | 1.829     | 1.7528    | 1.7528    |
| Avg  | 1.9941    | 1.9433    | 1.9354    | 1.9846    | 2.0068    | 1.8814    | 1.9131    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 208 / 11 KV NRB EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2286     | .0762     | .1524     | .2286     | .1905     | .2286     | .1524     |
| 2    | .2286     | .0762     | .1524     | .2286     | .1905     | .2286     | .1524     |
| 3    | .1905     | .0762     | .1524     | .1905     | .1905     | .1905     | .1524     |
| 4    | .1905     | .0762     | .1524     | .1905     | .1905     | .1905     | .1905     |
| 5    | .1905     | .1143     | .1524     | .1524     | .1905     | .2286     | .1905     |
| 6    | .1905     | .1143     | .1524     | .1524     | .1524     | .1524     | .2286     |
| 7    | .1334     | .1524     | .0762     | .2286     | .1334     | .1905     | .1524     |
| 8    | .1334     | .2286     | .1524     | .2286     | .2286     | .1905     | .2286     |
| 9    | .1524     | .2667     | .3048     | .3048     | .2477     | .1905     | .2667     |
| 10   | .2286     | .3048     | .3048     | .3048     | .3048     | .2286     | .3429     |
| 11   | .2286     | .3048     | .2667     | .3048     | .3048     | .1905     | .3048     |
| 12   | .2286     | .2286     | .3048     | .2477     | .2667     | .1524     | .2477     |
| 13   | .2286     | .2286     | .2667     | .3048     | .2286     | .1905     | .2667     |
| 14   | .2286     | .2286     | .3429     | .3429     | .3048     | .2286     | .3429     |
| 15   | .1905     | .2286     | .2667     | .2477     | .2667     | .2286     | .3048     |
| 16   | .1524     | .2286     | .2667     | .2477     | .2667     | .2667     | .2667     |
| 17   | .1524     | .3048     | .3048     | .2667     | .3048     | .2667     | .3239     |
| 18   | .1524     | .3048     | .2667     | .3239     | .2667     | .2286     | .3239     |
| 19   | .1143     | .2286     | .2286     | .2286     | .2667     | .1524     | .2667     |
| 20   | .1143     | .1524     | .1905     | .2286     | .2286     | .1524     | .1524     |
| 21   | .0762     | .1524     | .2286     | .1715     | .2286     | .1524     | .1905     |
| 22   | .0762     | .2286     | .1905     | .1905     | .2286     | .1524     | .2286     |
| 23   | .0762     | .2286     | .1905     | .1905     | .2286     | .1524     | .2286     |
| 24   | .2286     | .0762     | .1524     | .1905     | .1905     | .2286     | .1524     |
| Max  | .2286     | .3048     | .3429     | .3429     | .3048     | .2667     | .3429     |
| Min  | .0762     | .0762     | .0762     | .1524     | .1334     | .1524     | .1524     |
| Avg  | .1715     | .1921     | .2175     | .2373     | .2334     | .1984     | .2358     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 209 / 11 KV Speciality Polyfilm NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .381      | .381      | .3429     | .381      | .4191     | .381      | .381      |
| 2    | .4001     | .381      | .3048     | .381      | .4191     | .381      | .381      |
| 3    | .381      | .381      | .2667     | .4191     |           | .4191     | .4191     |
| 4    | .381      | .381      | .2667     | .4191     | .4572     | .4191     | .4191     |
| 5    | .4001     | .381      | .3048     | .381      | .4572     | .381      | .381      |
| 6    | .381      | .381      | .3048     | .3429     | .381      | .4191     | .4191     |
| 7    | .3239     | .3429     | .3048     | .4191     | .381      | .381      | .381      |
| 8    | .3239     | .3429     | .3048     | .381      | .4001     | .381      | .4191     |
| 9    | .3048     | .381      | .381      | .381      | .4572     | .381      | .4572     |
| 10   | .381      | .3429     | .381      | .4572     | .4572     |           | .4572     |
| 11   | .381      | .381      | .4572     | .4763     | .4572     | .1905     | .4572     |
| 12   | .381      | .381      | .381      | .4572     | .4191     | .2667     | .381      |
| 13   | .381      | .381      | .3429     | .3429     | .4191     | .3048     | .4572     |
| 14   | .381      | .2286     | .4572     | .4191     | .4572     | .381      | .4572     |
| 15   | .381      | .381      | .4191     | .4572     | .4572     | .381      | .381      |
| 16   | .381      | 1.448     | .4572     | .4572     | .381      | .3429     | .4191     |
| 17   | .3429     | .381      | .4572     | .4572     | .2667     | .3429     | .3048     |
| 18   | .381      | .3048     | .4572     | .4572     | .3048     | .381      | .3429     |
| 19   | .381      | .381      | .4191     | .4572     | .3048     | .381      | .381      |
| 20   | .381      | .381      | .381      | .4572     | .3429     | .381      | .381      |
| 21   | .381      | .381      | .4191     | .381      | .381      | .3429     | .3429     |
| 22   | .381      | .381      | .381      | .4191     | .381      | .381      | .4001     |
| 23   | .3429     | .381      | .4191     | .4191     | .3429     | .381      | .4001     |
| 24   | .2477     | .3429     | .3048     | .4191     | .4572     | .381      | .381      |
| Max  | .4001     | 1.448     | .4572     | .4763     | .4572     | .4191     | .4572     |
| Min  | .2477     | .2286     | .2667     | .3429     | .2667     | .1905     | .3048     |
| Avg  | .3659     | .4096     | .3715     | .4183     | .4001     | .3644     | .4001     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 210 / 11 KV Tata Tele Services NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     |
| 2    | .0953     | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     |
| 3    | .0762     | .0953     | .0762     | .0953     | .0762     | .0953     | .0953     |
| 4    | .0953     | .0953     | .0953     | .0953     | .0762     | .0953     | .0953     |
| 5    | .0762     | .0762     | .0953     | .0953     | .0762     | .0953     | .0953     |
| 6    | .0762     | .0762     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 7    | .0762     | .0762     | .1143     | .0953     | .0953     | .0953     | .0762     |
| 8    | .0953     | .0762     | .0762     | .0953     | .0762     | .0953     | .0762     |
| 9    | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     | .0762     |
| 10   | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 11   | .0953     | .0953     | .0953     | .0762     | .0953     | .0953     | .0953     |
| 12   | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 13   | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     | .0762     |
| 14   | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 15   | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 16   | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     | .0953     |
| 17   | .0953     | .0953     | .0953     | .0953     | .0953     | .0762     | .0953     |
| 18   | .0762     | .0953     | .0953     | .0953     | .0953     | .0762     | .0953     |
| 19   | .0762     | .0953     | .0953     | .0953     | .0953     | .0762     | .0953     |
| 20   | .0953     | .0762     | .0953     | .0953     | .0953     | .0762     | .0381     |
| 21   | .0953     | .0953     | .0953     | .0953     | .0953     | .0762     | .0191     |
| 22   | .0762     | .0762     | .0953     | .0953     | .0953     | .0762     | .0191     |
| 23   | .0953     | .0572     | .0953     | .0953     | .0953     | .0953     | .0762     |
| 24   | .0953     | .0953     | .0762     | .0953     | .0953     | .0953     | .0953     |
| Max  | .0953     | .0953     | .1143     | .0953     | .0953     | .0953     | .0953     |
| Min  | .0762     | .0572     | .0762     | .0762     | .0762     | .0762     | .0191     |
| Avg  | .0897     | .0873     | .0921     | .0945     | .0921     | .0905     | .0826     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 401 / NEW ENDURANCE EXP.

FEEDER(E-92 Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     | .1715     | .6287     | .743      | .8002     | .743      | .6287     |
| 2    | .1143     | .2858     | .6859     | .6859     | .8573     | .6859     | .6287     |
| 3    | .1143     | .1715     | .6287     | .6287     | .8002     | .6859     | .5716     |
| 4    | .1143     | .1715     | .5144     | .6859     | .8002     | .6859     | .5716     |
| 5    | .1143     | .1715     | .6859     | .6287     | .6859     | .5716     | .5716     |
| 6    | .1143     | .1715     | .6287     | .6287     | .6287     | .5716     | .5716     |
| 7    | .1143     | .3429     | .5144     | .743      | .4001     | .5716     | .5144     |
| 8    | .1143     | .6287     | .8002     | .8002     | .9145     | .8573     | .743      |
| 9    | .1143     | .9145     | .9717     | .9717     | 1.0288    | .9145     | .9145     |
| 10   | .0572     | 1.0288    | .9145     | 1.1431    | 1.1431    | 1.086     | 1.1431    |
| 11   | .1143     | .8573     | 1.0288    | 1.0288    | 1.1431    | .9717     | 1.0288    |
| 12   | .1143     | .8002     | 1.0288    | 1.0288    | 1.1431    | .9145     | .9717     |
| 13   | .1715     | .9145     | .9717     | .9145     | 1.0288    | 1.0288    | .8573     |
| 14   | .1715     | .8573     | 1.1431    | 1.0288    | 1.1431    | 1.1431    | 1.0288    |
| 15   | .1715     | .9145     | 1.1431    | 1.0288    | 1.1431    | 1.086     | 1.0288    |
| 16   | .1715     | 1.0288    | 1.1431    | 1.0288    | 1.1431    | 1.0288    | .9717     |
| 17   | .1715     | .9717     | 1.086     | .9717     | 1.1431    | 1.0288    | 1.0288    |
| 18   | .1715     | .9717     | .9145     | 1.0288    | 1.0288    | .9145     | .8573     |
| 19   | .1715     | .8002     | .8002     | .8573     | .9145     | .8573     | .6859     |
| 20   | .1715     | .743      | .5716     | .8573     | .8002     | .743      | .4001     |
| 21   | .1715     | .743      | .8002     | .8002     | .8002     | .6859     | .6859     |
| 22   | .1715     | .8002     | .6859     | .8002     | .8002     | .6859     | .6859     |
| 23   | .1715     | .8002     | .743      | .8002     | .8002     | .6859     | .6859     |
| 24   | .1715     | .1715     | .6287     | .6859     | .8002     | .743      | .6287     |
| Max  | .1715     | 1.0288    | 1.1431    | 1.1431    | 1.1431    | 1.1431    | 1.1431    |
| Min  | .0572     | .1715     | .5144     | .6287     | .4001     | .5716     | .4001     |
| Avg  | .1429     | .6430     | .8192     | .8550     | .9121     | .8288     | .7669     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 201 / Indian Tool  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.105     | 1.0288    | 1.448     | 1.2955    | 1.3443    | 1.1389    | .9465     |
| 2    | 1.0669    | 1.0669    | 1.4098    | 1.2574    | 1.3256    | 1.1203    | .9465     |
| 3    | .9907     | 1.0288    | 1.3717    | 1.3336    | 1.3256    | 1.0829    | .9114     |
| 4    | .9526     | 1.0669    | 1.3336    | 1.2955    | 1.3443    | 1.0829    | .8764     |
| 5    | .9907     | 1.0288    | 1.3336    | 1.2574    | 1.3817    | 1.0456    | .8589     |
| 6    | .9526     | 1.0669    | 1.2574    | 1.1431    | 1.251     | 1.0829    | .8939     |
| 7    | .9526     | 1.0288    | 1.1812    | 1.0669    | 1.2136    | 1.0829    | .9114     |
| 8    | .9526     | 1.5242    | 1.5242    | 1.5242    | 1.4563    | 1.2323    | 1.475     |
| 9    | 1.0288    | 1.6004    | 1.7528    | 1.8671    | 1.7528    | 1.2955    | 1.7147    |
| 10   | 1.0669    | 1.9814    | 1.9052    | 1.9052    | 2.0957    |           | 1.7147    |
| 11   | 1.0669    | 1.829     | 2.0576    | 2.0195    | 2.0957    | 1.2955    |           |
| 12   | 1.0288    | 1.9052    | 1.9052    | 1.9052    | 1.7909    | 1.1431    |           |
| 13   | 1.0669    | 1.9052    | 1.7909    | 2.1338    | 1.7909    | 1.2955    | 1.9814    |
| 14   | 1.0669    | 1.9814    | 2.0957    | 2.0576    | 2.0957    | 1.3336    | 2.0957    |
| 15   | 1.0669    | 1.9814    | 2.0195    | 1.7909    | 1.8671    | 1.448     | 1.9052    |
| 16   | 1.1812    | 1.7909    | 1.9239    | 2.1338    | 1.829     | 1.448     | 2.0195    |
| 17   | 1.182     | 1.8484    | 1.8484    | 1.9052    | 1.5623    | 1.4098    | 1.7909    |
| 18   | .9088     | 1.8107    | 1.9239    | 1.8671    | 1.6004    | 1.3717    | 1.7528    |
| 19   | .8048     | 1.531     | 1.531     | 1.5623    | 1.1431    | .9907     | 1.3717    |
| 20   | .7042     | 1.4937    | 1.5844    | 1.2193    | 1.1812    | 1.2193    | 1.448     |
| 21   | .9156     | 1.4901    | 1.5466    | 1.4937    | 1.1431    | 1.0669    | 1.4861    |
| 22   | .8718     | 1.6804    | 1.643     | 1.5123    | 1.2193    | 1.1431    | 1.5242    |
| 23   | .9907     | 1.3717    | 1.6385    | 1.4937    | 1.1949    | 1.0456    | 1.4563    |
| 24   | 1.0669    | .9526     | 1.448     | 1.2574    | 1.307     | 1.1576    | 1.0166    |
| Max  | 1.182     | 1.9814    | 2.0957    | 2.1338    | 2.0957    | 1.448     | 2.0957    |
| Min  | .7042     | .9526     | 1.1812    | 1.0669    | 1.1431    | .9907     | .8589     |
| Avg  | .9992     | 1.4997    | 1.6448    | 1.5957    | 1.5130    | 1.1971    | 1.4135    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 202 / D Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6097     | .7621     | .8002     | .7621     | .8775     | .7655     | .5609     |
| 2    | .6097     | .7621     | .8383     | .7621     | .8402     | .7468     | .5609     |
| 3    | .6859     | .7621     | .7621     | .7621     | .8402     | .7468     | .5609     |
| 4    | .6097     | .7621     | .7621     | .7621     | .8215     | .7468     | .5609     |
| 5    | .6859     | .7621     | .7621     | .7621     | .8029     | .7468     | .5609     |
| 6    | .7621     | .7621     | .7621     | .7621     | .8402     | .7842     | .5959     |
| 7    | .8383     | .9907     | 1.1431    | .7621     | 1.1576    | .7842     | .6836     |
| 8    | 1.1431    | 1.3717    | 1.3717    | 1.3717    | 1.5684    | .8962     | 1.2696    |
| 9    | .7621     | 1.6766    | 1.3717    | 1.448     | 1.7528    | .9145     | 1.5242    |
| 10   | 1.5242    | 1.6766    | 1.7528    | 1.6766    | 1.7528    | .8383     | 1.5242    |
| 11   | 1.6004    | 1.6766    | 1.9052    | 1.7528    | 1.9052    | .8383     | 1.5242    |
| 12   | 1.6004    | 1.7528    | 1.5242    | 1.829     | 1.5242    | .9145     | 1.7528    |
| 13   | 1.6004    | 1.6004    | 1.6766    | 1.6766    | 1.5242    | .9145     | 1.5242    |
| 14   | 1.5242    | 1.829     | 1.9052    | 1.9052    | 1.6766    | .9145     | 1.9052    |
| 15   | 1.6004    | 1.829     | 1.7528    | 1.9052    | 1.9052    | .8383     | 1.6766    |
| 16   | 1.3717    | 1.7528    | 1.8296    | 1.829     | 1.6004    | .8002     | 1.6766    |
| 17   | 1.2883    | 1.6787    | 1.8298    | 1.6766    | 1.6766    | .7621     | 1.7528    |
| 18   | .9979     | 1.5466    | 1.6057    | 1.6385    | 1.3717    | .7621     | 1.448     |
| 19   | .8688     | 1.1949    | 1.3817    | 1.0669    | .9145     | .7621     | 1.1431    |
| 20   | .8859     | .8954     | 1.0082    | .8383     | .8383     | .6859     | 1.0669    |
| 21   | .6516     | .8962     | .8589     | .8215     | .7621     | .6859     | .9907     |
| 22   | .6401     | .8589     | .8962     | .8215     | .7621     | .5335     | .7621     |
| 23   | .7621     | .7621     | .7621     | .8402     | .8029     | .6348     | .8215     |
| 24   | .6859     | .7621     | .7621     | .7621     | .9149     | .7842     | .5609     |
| Max  | 1.6004    | 1.829     | 1.9052    | 1.9052    | 1.9052    | .9145     | 1.9052    |
| Min  | .6097     | .7621     | .7621     | .7621     | .7621     | .5335     | .5609     |
| Avg  | 1.0129    | 1.2218    | 1.2510    | 1.2164    | 1.2264    | .7834     | 1.1253    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 203 / RKHVAL INDUSTRIES  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8383     | .6859     | .9145     | .9907     | .8029     | .9335     | .7186     |
| 2    | .8383     | .6859     | .8764     | .9526     | .8029     | .8775     | .6836     |
| 3    | .8002     | .6859     | .8383     | .9145     | .8029     | .8775     | .6836     |
| 4    | .7621     | .6859     | .8383     | .8764     | .8215     | .7842     | .6762     |
| 5    | .724      | .6859     | .8002     | .9145     | .7842     | .7655     | .6661     |
| 6    | .724      | .6859     | .7621     | .7621     | .7842     | .7095     | .6661     |
| 7    |           | .6859     | .7621     | .9907     | .7842     | .6722     | .7011     |
| 8    | .6097     | .8383     | .9526     | .8764     | 1.0829    | .7095     | .8962     |
| 9    | .6097     | .9907     | 1.448     | 1.0288    | 1.1431    | .9526     | .9907     |
| 10   | .6478     | 1.2955    | 1.4098    | 1.3336    | 1.1431    | .9907     | 1.2574    |
| 11   | .6478     | 1.4861    | 1.2955    | 1.2955    | 1.3336    | 1.2193    | 1.2955    |
| 12   | .6097     | .9907     | 1.1431    | 1.3717    | 1.2574    | 1.1431    | 1.2574    |
| 13   | .6097     | 1.0288    | .9145     | 1.3336    | .9526     | .7621     | .8383     |
| 14   | .5716     | 1.3336    | 1.4098    | 1.3717    | 1.2955    | .9907     | 1.2193    |
| 15   | .6097     | 1.3717    | 1.448     | 1.3336    | 1.4098    | .8764     | 1.1812    |
| 16   | .6097     | 1.2955    | 1.2826    | 1.2574    | 1.3717    | .9907     | 1.3336    |
| 17   | .4275     | 1.0751    | 1.251     | 1.2574    | 1.2574    | 1.0669    | 1.1431    |
| 18   | .3332     | 1.1203    | 1.475     | 1.2193    | 1.3336    | 1.105     | 1.2574    |
| 19   | .2155     | .9511     | 1.0082    | .9145     | 1.0288    | .8002     | .8764     |
| 20   | .2749     | .9015     | .8589     | 1.0288    | .9907     | .8764     | .8764     |
| 21   | .2751     | .8589     | .8775     | .8215     | .8002     | .8002     | .7621     |
| 22   | .2812     | .9335     | .8589     | .8775     | .9907     | .8002     | .8764     |
| 23   | .6859     | .9526     | .9907     | 1.0269    | .8962     | .8215     | 1.0082    |
| 24   | .9526     | .6859     | .8764     | .9526     | .9149     | 1.0456    | .7186     |
| Max  | .9526     | 1.4861    | 1.475     | 1.3717    | 1.4098    | 1.2193    | 1.3336    |
| Min  | .2155     | .6859     | .7621     | .7621     | .7842     | .6722     | .6661     |
| Avg  | .5938     | .9546     | 1.0539    | 1.0709    | 1.0327    | .8988     | .9410     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 204 / 11 KV AURANGABAD ROTOPLAST SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6859     | .6478     | .8002     | .9907     | .8215     | .8402     | .6836     |
| 2    | .6859     | .6097     | .7621     | .9526     | .8029     | .8029     | .6836     |
| 3    | .724      | .6097     | .8002     | .9526     | .8215     | .8029     | .6836     |
| 4    | .6859     | .6478     | .8383     | .9145     | .8215     | .8029     | .6661     |
| 5    | .6859     | .6859     | .8383     | .8764     | .8029     | .8029     | .6661     |
| 6    | .6859     | .6859     | .8383     | .8002     | .7468     | .7842     | .6661     |
| 7    | .724      | .724      | .8002     | .7621     | .7282     | .8029     | .6661     |
| 8    | .7621     | 1.2193    | .9907     | 1.3336    | 1.3443    | 1.0829    | 1.1949    |
| 9    | .9907     | 1.5242    | 1.5242    | 1.1431    | 1.448     | 1.1812    | 1.5242    |
| 10   | .8764     | 1.6385    | 1.7147    |           | 1.5242    | 1.4098    | 1.829     |
| 11   | .8383     | 1.7147    | 1.7528    | 1.5242    | 2.0957    | 1.5242    | 1.9052    |
| 12   | .8383     | 2.0957    | 1.7528    | 1.5242    | 1.9433    | 1.3336    | 1.7147    |
| 13   | .8383     | 1.5242    | 1.4098    | 1.6766    | 1.3336    | .9526     | 1.2574    |
| 14   | .8383     | 2.0957    | 1.7909    | 1.9052    | 1.6766    | 1.3336    | 1.6766    |
| 15   | .8764     | 2.0957    | 1.7528    | 1.9814    | 2.0195    | 1.4861    | 1.5242    |
| 16   | .8383     | 1.6766    | 1.7541    | 1.7528    | 2.0957    | 1.4098    | 2.0957    |
| 17   | .78       | 1.8484    | 1.9993    | 2.0576    | 1.9814    | 1.3336    | 1.9052    |
| 18   | .8238     | 1.8484    | 1.8111    | 1.829     | 1.9433    | 1.448     | 1.5242    |
| 19   | .6687     | 1.1827    | 1.2696    | 1.1812    | 1.2193    | .9907     | .9526     |
| 20   | .4664     | .929      | .9335     | .9526     | .9526     | .7621     | .7621     |
| 21   | .4212     | .8779     | .9709     | .8962     | .9526     | .8002     | .8383     |
| 22   | .4338     | .8589     | 1.0082    | .9149     | .9907     | .7621     | .7621     |
| 23   | .724      | .8764     | .8764     | .8775     | .8962     | .7468     | 1.0829    |
| 24   | .6859     | .6097     | .8002     | .9526     | .8589     | .8589     | .7011     |
| Max  | .9907     | 2.0957    | 1.9993    | 2.0576    | 2.0957    | 1.5242    | 2.0957    |
| Min  | .4212     | .6097     | .7621     | .7621     | .7282     | .7468     | .6661     |
| Avg  | .7324     | 1.2178    | 1.2412    | 1.2501    | 1.2842    | 1.0440    | 1.1652    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 205 / 11 KV HVDS PADHARPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5853     | .5601     | .5975     | .6348     | .5853     | .5853     | .5853     |
| 2    | .5853     | .5975     | .5975     | .5975     | .5487     | .567      | .567      |
| 3    | .5316     | .5975     | .5975     | .5975     | .5487     | .567      | .567      |
| 4    | .5544     | .5975     | .6348     | .5975     | .5487     | .567      | .567      |
| 5    | .5544     | .5975     | .6348     | .6348     | .567      | .6036     | .5853     |
| 6    | .5914     | .5601     | .6348     | .6722     | .6219     | .6036     | .6036     |
| 7    | .5853     | .6722     | .6722     | .6348     | .6401     | .6401     | .6219     |
| 8    | .4961     | .5975     | .5853     | .6348     | .5121     | .567      | .5304     |
| 9    | .6348     | .5601     | .5487     | .6097     | .5975     | .5853     | .6097     |
| 10   | .6283     | .5544     | .5487     | .5487     | .5975     | .5853     | .5975     |
| 11   | .6653     | .5914     | .5853     | .5853     | .6348     | .5853     | .5975     |
| 12   | .5914     | .5975     | .5316     | .5487     | .5853     | .5975     | .5975     |
| 13   | .5914     | .5544     | .5853     | .5975     | .5853     | .5975     | .5853     |
| 14   | .5544     | .5544     | .5853     | .5175     | .5487     | .5853     | .5853     |
| 15   | .5975     | .5601     | .5853     | .5914     | .5853     | .5853     | .6097     |
| 16   | .5601     | .5716     | .567      | .5914     | .6219     | .5853     | .6024     |
| 17   | .6154     | .6219     | .567      | .6283     | .6584     | .6097     | .5544     |
| 18   | .5731     | .6219     | .6584     | .6653     | .5792     | .5853     | .5914     |
| 19   | .6767     | .695      | .695      | .7392     | .695      | .7621     |           |
| 20   | .695      | .7316     | .7133     | .7023     | .7023     | .7316     | .4755     |
| 21   | .6584     | .695      | .695      | .695      | .7023     | .7023     | .7023     |
| 22   | .6838     | .6584     | .6584     | .6584     | .6653     | .6653     | .6653     |
| 23   | .7095     | .6348     | .6348     | .6219     | .6584     | .6584     | .6401     |
| 24   | .5853     | .6348     | .6348     | .6348     | .6036     | .6219     | .6219     |
| Max  | .7095     | .7316     | .7133     | .7392     | .7023     | .7621     | .7023     |
| Min  | .4961     | .5544     | .5316     | .5175     | .5121     | .567      | .4755     |
| Avg  | .6043     | .6091     | .6145     | .6225     | .6081     | .6143     | .5941     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 206 / Tarraco

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8764     | .5716     | 1.2574    | 1.1812    | 1.0082    | 1.0642    | .9593     |
| 2    | .8002     |           | 1.2193    | 1.1431    | .9709     | 1.0829    | .9511     |
| 3    | .7621     | .4954     | 1.1812    | 1.1812    | .9709     | 1.0829    | .9412     |
| 4    | .724      | .4954     | 1.2193    | 1.1431    | 1.0082    | 1.1016    | .9231     |
| 5    | .724      | .4954     | 1.1431    | 1.0669    | 1.0082    | 1.0829    | .905      |
| 6    | .7621     | .4954     | 1.0669    | .9907     | .8775     | 1.0082    | .8413     |
| 7    | .724      | .6097     | .8764     | .8002     | .8589     | .8589     | .7888     |
| 8    | .6097     | .9526     | 1.1812    | 1.2574    | 1.3443    | 1.2136    | 1.3443    |
| 9    | .6478     | 1.1812    | 1.5242    | 1.5242    | 1.3336    | 1.3336    | 1.3717    |
| 10   | .6097     | 1.448     | 1.4861    | 1.7147    | 1.6385    | 1.4861    | 1.6766    |
| 11   | .6478     | 1.5623    | 1.5242    | 1.7528    | 1.6004    | 1.3336    | 1.7528    |
| 12   | .6097     | 1.0288    | 1.1431    | 1.2574    | 1.105     | .9526     | 1.1431    |
| 13   | .6097     | 1.4098    | 1.6004    | 1.5242    | 1.448     | 1.4098    | 1.4861    |
| 14   | .6478     |           | 1.7147    | 1.6004    | 1.3717    | 1.7147    | 1.3717    |
| 15   | .6859     | 1.6385    | 1.6385    | 1.6766    | 1.448     | 1.4098    | 1.7147    |
| 16   | .6097     | 1.4098    | 1.6598    | 1.7528    | 1.448     | 1.3717    | 1.5623    |
| 17   | .5601     | 1.3957    | 1.5278    | 1.6004    | 1.5242    | 1.3336    | 1.5242    |
| 18   | .5243     | 1.3817    | 1.4937    | 1.5242    | 1.5242    | 1.3336    | 1.6004    |
| 19   | .4287     | 1.1203    | 1.0456    | 1.0288    | 1.1812    | .9526     | 1.0669    |
| 20   | .4666     | 1.0631    | 1.0642    | 1.105     | 1.105     | 1.0669    | 1.1812    |
| 21   | .4001     | 1.134     | 1.1576    | 1.0456    | 1.1431    | 1.0288    | 1.1812    |
| 22   | .3307     | 1.1389    | 1.1203    | 1.1203    | 1.0669    | 1.0669    | 1.2574    |
| 23   | .5716     | .9907     | 1.105     | 1.0082    | 1.1203    | 1.0456    | 1.2323    |
| 24   | .8002     | .6097     | 1.2574    | 1.1431    | 1.0829    | 1.1203    | .9465     |
| Max  | .8764     | 1.6385    | 1.7147    | 1.7528    | 1.6385    | 1.7147    | 1.7528    |
| Min  | .3307     | .4954     | .8764     | .8002     | .8589     | .8589     | .7888     |
| Avg  | .6305     | 1.0285    | 1.3003    | 1.2976    | 1.2162    | 1.1856    | 1.2385    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 207 / 11 KV Water Works Express NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.086     | .9145     | .8954     | 1.0669    | 1.105     | 1.0269    | 1.0456    |
| 2    | 1.086     | .9145     | .9145     | 1.086     | 1.086     | 1.0479    | 1.0269    |
| 3    | 1.0669    | .8954     | .9335     | .9717     | 1.086     | 1.0479    | .9709     |
| 4    | 1.0479    | .8764     | .8954     | .9526     | 1.0669    | 1.0479    | .9709     |
| 5    | .9717     | .8573     | .9335     | 1.105     | 1.0669    | 1.0479    | .8775     |
| 6    | .9335     | .7621     | .9526     | 1.1241    | 1.0669    | 1.0479    | .9149     |
| 7    | .8954     | .724      | 1.086     | 1.1241    | 1.0479    | 1.0479    | 1.0456    |
| 8    | 1.086     | .7621     | 1.1241    | 1.1241    | 1.0269    | 1.0269    | 1.0642    |
| 9    | 1.0669    |           | 1.105     | 1.105     | 1.086     | 1.086     | 1.086     |
| 10   | 1.1241    | .8002     | 1.105     | 1.1622    | 1.1431    | .8192     | 1.1431    |
| 11   | 1.1241    | .9717     | 1.1241    | 1.1622    | 1.1431    | .9145     | 1.1622    |
| 12   | .9526     | .9907     | 1.1241    | 1.1622    | 1.1622    | .9526     | 1.1622    |
| 13   | .9526     | .9907     | 1.1241    | 1.1812    | 1.1431    | 1.086     | 1.1622    |
| 14   | .9526     | .9335     | 1.1241    | 1.1812    | .9526     | 1.086     | 1.1241    |
| 15   | 1.086     | .9717     | 1.1241    | .9526     | 1.1241    | 1.086     | .8954     |
| 16   | 1.0669    | .9335     | 1.1128    | 1.1431    | 1.105     | 1.0669    | .9335     |
| 17   | 1.0349    | .9242     | 1.1016    | 1.1241    | 1.105     | 1.0479    | .9335     |
| 18   | .8589     | .8299     | 1.1128    | 1.105     | 1.086     | .9145     | 1.0098    |
| 19   | .8962     | .8488     | 1.1016    | 1.105     | 1.086     | 1.086     | 1.0669    |
| 20   | 1.0349    | .8402     | 1.1016    | 1.105     | 1.0669    | 1.0669    | 1.105     |
| 21   | 1.0425    | .9149     | 1.0829    | 1.0829    | 1.086     | 1.0669    | 1.105     |
| 22   | .9055     | .9149     | 1.1016    | 1.0829    | .8954     | 1.105     | 1.1241    |
| 23   | .9526     | .9335     | 1.1241    | 1.0829    | 1.0456    | 1.0456    | 1.0642    |
| 24   | 1.0669    | .8954     | .8954     | 1.086     | 1.0829    | 1.0269    | 1.0456    |
| Max  | 1.1241    | .9907     | 1.1241    | 1.1812    | 1.1622    | 1.105     | 1.1622    |
| Min  | .8589     | .724      | .8954     | .9526     | .8954     | .8192     | .8775     |
| Avg  | 1.0122    | .8870     | 1.0542    | 1.0991    | 1.0777    | 1.0333    | 1.0433    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 203 / 11 KV VIJAY CO-POLYMER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 204 / 11 KV GUPTA CON COST  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

|      |           |
|------|-----------|
| DATE | 01-APR-18 |
| HR   | Load (MW) |
| 24   | 2.8578    |
| Max  | 2.8578    |
| Min  | 2.8578    |
| Avg  | 2.8578    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 208 / 11 KV ARIAN ORGO.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.8578    |
| Max  | 2.8578    |
| Min  | 2.8578    |
| Avg  | 2.8578    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 212 / 11KV WALUJ MAHANAGAR

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 23   | 2.191     |
| Max  | 2.191     |
| Min  | 2.191     |
| Avg  | 2.191     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 404 / Cosmo Films OLD

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.4865    | 2.4006    | 3.5437    | 3.2579    |
| 2    | 3.6008    | 3.9438    | 3.315     | 3.2007    |
| 3    | 3.7151    | 2.9721    | 3.1436    | 4.1152    |
| 4    | 3.7723    | 3.658     | 3.3722    | 3.2007    |
| 5    | 4.401     | 2.2291    | 3.9438    | 3.0864    |
| 6    | 3.5437    | 3.5437    | 3.2007    | 3.2007    |
| 7    | 2.572     | 2.1719    | 2.5149    | 3.1436    |
| 8    | 2.2291    | 3.658     | 3.658     | 4.3439    |
| 9    | 2.2862    | 2.9721    | 3.7723    | 3.9438    |
| 10   | 2.6292    | 3.8866    | 4.0009    | 4.2867    |
| 11   | 2.4006    | 2.9721    | 3.7151    | 4.1152    |
| 12   | 2.3434    | 4.6296    | 3.0864    | 3.658     |
| 13   | 2.5149    | 4.6296    | 3.8866    | 4.8583    |
| 14   | 2.3434    | 3.8866    | 4.0581    | 4.0581    |
| 15   | 2.2862    | 4.1152    | 3.9438    | 4.1152    |
| 16   | 2.1719    | 4.2867    | 4.0009    | 4.2295    |
| 17   | 2.4006    | 4.0581    | 4.1724    | 4.0009    |
| 18   | 2.2862    | 2.8578    | 4.6296    | 3.7151    |
| 19   | 2.2291    | 3.4865    | .5144     | 2.6863    |
| 20   | 2.3434    | 2.6863    | 2.8006    | 2.8578    |
| 21   | 2.2862    | 4.2295    | 4.3439    | 3.5437    |
| 22   | 3.0293    | 3.4865    | 3.8295    | 4.401     |
| 23   | 3.0293    | 4.2295    | 2.915     | 2.7435    |
| 24   | 3.7723    | 3.0293    | 3.6008    | 2.7435    |
| Max  | 4.401     | 4.6296    | 4.6296    | 4.8583    |
| Min  | 2.1719    | 2.1719    | .5144     | 2.6863    |
| Avg  | 2.8197    | 3.5008    | 3.4984    | 3.6461    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 406 / E SECTOR FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 10.5167   |
| Max  | 10.5167   |
| Min  | 10.5167   |
| Avg  | 10.5167   |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 407 / NEW COSMO EXPREES FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 6.4015    | 6.4015    | 6.7444    | 6.5729    | 6.7444    |
| 2    | 6.3443    | 6.4015    | 6.6873    | 6.4586    | 6.6873    |
| 3    | 6.5158    | 6.1728    | 6.6301    | 6.6301    | 6.8587    |
| 4    | 6.3443    | 6.2872    | 6.7444    | 6.6301    | 6.5158    |
| 5    | 6.5158    | 6.4586    | 6.6873    | 6.8016    | 6.973     |
| 6    | 6.4586    | 6.4586    | 6.6301    | 6.5729    | 6.23      |
| 7    | 6.5729    | 5.7156    | 6.6301    | 6.5729    | 6.6301    |
| 8    | 5.9442    | 5.8871    | 6.5729    | 6.5158    | 6.6873    |
| 9    | 6.0585    | 6.5158    | 6.4586    | 6.8016    | 6.7444    |
| 10   | 5.9442    | 6.8016    | 5.9442    | 6.8587    | 7.1445    |
| 11   | 6.0014    | 6.8016    | 5.4298    | 7.2588    | 6.8016    |
| 12   | 6.0585    | 6.6873    | 6.2872    | 6.6873    | 5.3155    |
| 13   | 6.0585    | 6.6301    | 6.7444    | 6.6301    | 6.0014    |
| 14   | 6.5158    | 6.9159    | 6.9159    | 6.8016    | 6.0014    |
| 15   | 6.1157    | 6.4015    | 7.0302    | 6.973     | 6.5158    |
| 16   | 6.5158    | 6.7444    | 6.8016    | 6.8587    | 6.5158    |
| 17   | 6.5729    | 6.8587    | 6.8587    | 5.9442    | 6.7444    |
| 18   | 6.3443    | 6.6301    | 6.6873    | 6.3443    | 5.7156    |
| 19   | 6.4586    | 6.8587    | 6.5729    | 6.5729    | 5.6013    |
| 20   | 6.4015    | 6.5729    | 6.4015    | 6.2872    | 3.658     |
| 21   | 6.3443    | 6.4586    | 6.4015    | 5.6584    | 4.8011    |
| 22   | 6.5158    | 6.6873    | 6.4586    | 6.3443    | 5.0297    |
| 23   | 6.4015    | 6.3443    | 6.2872    | 6.1728    | 4.2867    |
| 24   | 6.8016    | 6.5158    | 6.5158    | 6.5729    | 6.8016    |
| Max  | 6.8016    | 6.9159    | 7.0302    | 7.2588    | 7.1445    |
| Min  | 5.9442    | 5.7156    | 5.4298    | 5.6584    | 3.658     |
| Avg  | 6.3419    | 6.5086    | 6.5468    | 6.5634    | 6.1252    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 408 / 33 KV D Sector

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.8578    |
| Max  | 2.8578    |
| Min  | 2.8578    |
| Avg  | 2.8578    |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 409 / 33 KV BKT EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.1719    | 2.2862    | 1.9433    | 2.4006    | 1.9433    |
| 2    | 2.1719    | 2.6292    | 2.0576    | 2.5149    | 1.9433    |
| 3    | 2.0576    | 2.4006    | 2.1719    | 2.6292    | 1.9433    |
| 4    | 2.2862    | 2.2862    | 2.8006    | 2.7435    | 1.9433    |
| 5    | 2.2862    | 2.1719    | 2.4006    |           | 1.9433    |
| 6    | 2.4006    | 2.0576    | 2.5149    | 2.6292    | 2.2862    |
| 7    | 1.9433    | 1.9433    | 2.5149    | 2.2862    | 2.2862    |
| 8    | 2.2862    | 2.8578    | 4.0009    | 3.4294    | 2.2862    |
| 9    | 2.5149    | 2.8578    | 3.4294    | 2.9721    | 2.6292    |
| 10   | 2.6292    | 3.2007    | 3.4294    | 2.8578    | 2.6292    |
| 11   | 2.9721    | 2.5149    | 2.5149    | 2.7435    | 3.2007    |
| 12   | 3.0864    | 3.2007    | 2.2862    | 2.8578    | 3.2007    |
| 13   | 2.9721    | 3.315     | 2.6292    | 2.5149    | 2.9721    |
| 14   | 3.2007    | 2.8578    | 2.6292    | 2.4006    | 2.7435    |
| 15   | 2.8578    | 2.8578    | 2.5149    | 2.0576    | 2.5149    |
| 16   | 2.7435    | 2.8578    | 2.8578    | 2.5149    | 2.5149    |
| 17   | 3.0864    | 2.2862    | 2.4006    | 2.5149    | 2.8578    |
| 18   | 2.9721    | 2.1719    | 2.2862    | 2.7435    | 2.5149    |
| 19   | 2.7435    | 1.3146    | 2.6292    | 2.2862    | 2.5149    |
| 20   | 2.6292    | 2.8578    | 2.2862    | 2.6292    | 2.2862    |
| 21   | 2.2862    | 2.8578    | 2.6292    | 2.4006    | 2.0576    |
| 22   | 2.8578    | 2.8578    | 2.2862    | 2.6292    | 2.2862    |
| 23   | 2.5149    | 2.0576    | 2.0576    | 2.7435    | 2.2862    |
| 24   | 2.0576    | 2.2862    | 1.9433    | 2.2862    | 1.9433    |
| Max  | 3.2007    | 3.315     | 4.0009    | 3.4294    | 3.2007    |
| Min  | 1.9433    | 1.3146    | 1.9433    | 2.0576    | 1.9433    |
| Avg  | 2.5720    | 2.5411    | 2.5506    | 2.5994    | 2.4053    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 410 / NEW ENDURANCE (B-2) EXP. NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1431    | 1.1431    | 1.2574    | 1.1431    | 1.3717    |
| 2    | 1.1431    | 1.2003    | 1.1431    | 1.2574    | 1.3717    |
| 3    | 1.1431    | 1.2574    | 1.1431    | 1.2574    | 1.3717    |
| 4    | 1.3717    | 1.2574    | 1.1431    | 1.2574    | 1.3146    |
| 5    | 1.3717    | 1.2574    | 1.0288    | 1.3146    | 1.3146    |
| 6    | 1.1431    | 1.1431    | 1.0288    | 1.2574    | 1.1431    |
| 7    | .6859     | 1.0288    | .743      | 1.1431    | .8002     |
| 8    | .8002     | 1.2574    | 1.2003    | 1.2574    | 1.1431    |
| 9    |           | 1.2574    | 1.1431    | 1.2574    | 1.1431    |
| 10   | .0572     | 1.1431    | 1.2574    | 1.1431    | 1.0288    |
| 11   | .0572     | 1.3146    | 1.2574    | 1.1431    | 1.3717    |
| 12   | .0572     | 1.4861    | 1.2574    | 1.1431    | 1.3717    |
| 13   | .0572     | 1.5432    | 1.4289    | 1.3146    | 1.2574    |
| 14   | .0572     | 1.4861    | 1.3717    | 1.2574    | 1.2574    |
| 15   | .0572     | 1.3717    | 1.2003    | 1.2574    | 1.2574    |
| 16   | .5144     | 1.2574    | 1.4861    | 1.3717    | 1.3146    |
| 17   | .4572     | 1.3146    | 1.2574    | 1.2574    | 1.3146    |
| 18   | .4001     | 1.3717    | 1.3717    | 1.1431    | 1.2574    |
| 19   | .4572     | 1.2574    | 1.2574    | 1.2574    | 1.2574    |
| 20   | .9145     | 1.4289    | 1.2003    | 1.3717    | 1.2574    |
| 21   | .9145     | 1.3717    | 1.1431    | 1.4289    | 1.1431    |
| 22   | 1.0288    | 1.3717    | 1.1431    | 1.4289    | 1.2003    |
| 23   | 1.0288    | .9717     | 1.1431    | 1.3717    | 1.2574    |
| 24   | 1.2003    | 1.0288    | 1.2574    | 1.1431    | 1.3717    |
| Max  | 1.3717    | 1.5432    | 1.4861    | 1.4289    | 1.3717    |
| Min  | .0572     | .9717     | .743      | 1.1431    | .8002     |
| Avg  | .6983     | 1.2717    | 1.2026    | 1.2574    | 1.2455    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 703 / 132 KV BAJAJ CKT-1 FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.658     |
| Max  | 3.658     |
| Min  | 3.658     |
| Avg  | 3.658     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 704 / 132 KV BAJAJ CKT-2 FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

| DATE | 01-APR-18 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.4294    |
| Max  | 3.4294    |
| Min  | 3.4294    |
| Avg  | 3.4294    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 201 / 11KV SUBHASHRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1431    | 1.2936    | 1.2936    | 1.3676    | 1.3676    | 1.3306    | 1.2197    |
| 2    | 1.0669    | 1.2936    | 1.2936    | 1.2936    | 1.3676    | 1.2936    | 1.182     |
| 3    | 1.0288    | 1.2936    | 1.2936    | 1.2567    |           | 1.1458    | 1.1458    |
| 4    | 1.0288    | 1.2936    | 1.2936    | 1.1458    | 1.3676    | 1.1458    | 1.1458    |
| 5    | 1.0669    | 1.2936    | 1.2936    | 1.1458    | 1.3676    | 1.1458    | 1.1088    |
| 6    | 1.1431    | 1.2936    | 1.2197    | 1.1458    | 1.2936    | 1.1458    | 1.1088    |
| 7    | 1.3717    | 1.2936    | 1.2197    | 1.3306    | 1.2936    | 1.2197    | 1.1088    |
| 8    | 1.2955    | 1.2936    | 1.2197    | 1.2197    | 1.1458    | 1.1458    | 1.1458    |
| 9    | 1.1827    | 1.1203    | 1.0829    | 1.0456    | 1.0456    | 1.0456    | 1.0829    |
| 10   | 1.1458    | 1.0456    | 1.0082    | 1.0082    | 1.0082    | 1.0456    | 1.0456    |
| 11   | 1.0349    | 1.0082    | .9709     | 1.0082    | 1.0456    | 1.0082    | 1.0456    |
| 12   | 1.0719    | 1.0829    | 1.0456    | 1.0082    | 1.0082    |           | 1.0082    |
| 13   | 1.0719    | 1.0082    | 1.0456    | 1.0456    | 1.0829    |           | 1.0082    |
| 14   | 1.1088    | 1.1203    | 1.0082    | 1.0829    | 1.0456    |           | 1.0829    |
| 15   | 1.0719    | 1.1203    | 1.0456    | 1.1203    | 1.0829    | 1.2696    | 1.1576    |
| 16   | 1.1458    | 1.0829    | 1.1203    | 1.0829    | 1.1203    | 1.2323    | 1.1203    |
| 17   | 1.0719    | 1.0082    | 1.0719    | 1.1203    | .961      | 1.1576    | .9979     |
| 18   | 1.2197    | 1.1088    | 1.1431    | 1.4784    | 1.1088    | 1.1203    | 1.1458    |
| 19   | 1.4045    | 1.2936    | 1.3676    | 1.5524    | 1.3676    | 1.2936    | 1.3306    |
| 20   | 1.5154    | 1.4045    | 1.4784    | 1.5524    | 1.5154    | 1.4045    | 1.5893    |
| 21   | 1.5154    | 1.5893    | 1.3676    | 1.5524    | 1.6263    | 1.4045    | 1.4784    |
| 22   | 1.4784    | 1.5524    | 1.4045    | 1.5524    | 1.5154    | 1.4784    | 1.5154    |
| 23   | 1.4784    | 1.4784    | 1.4045    | 1.4784    | 1.4784    | 1.4784    | 1.4415    |
| 24   | 1.3717    |           | 1.2936    | 1.3676    | 1.3676    | 1.3676    | 1.2936    |
| Max  | 1.5154    | 1.5893    | 1.4784    | 1.5524    | 1.6263    | 1.4784    | 1.5893    |
| Min  | 1.0288    | 1.0082    | .9709     | 1.0082    | .961      | 1.0082    | .9979     |
| Avg  | 1.2097    | 1.2336    | 1.2077    | 1.2484    | 1.2427    | 1.2323    | 1.1879    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 202 / 11KV N5 CIDCO FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.448     | 1.4784    | 1.4784    | 1.5524    | 1.5893    | 1.6263    | 1.4784    |
| 2    | 1.4098    | 1.4784    | 1.4784    | 1.5524    | 1.5893    | 1.5154    | 1.4784    |
| 3    | 1.3717    | 1.4784    | 1.4784    | 1.4415    | 1.5893    | 1.4045    | 1.3676    |
| 4    | 1.3336    | 1.4784    | 1.4784    | 1.3306    | 1.5893    | 1.4045    | 1.3676    |
| 5    | 1.5623    | 1.4784    | 1.4784    | 1.3306    | 1.5893    | 1.4045    | 1.4784    |
| 6    | 1.829     | 1.5154    | 1.5524    | 1.9589    | 1.5893    | 1.5154    | 1.4784    |
| 7    | 1.7528    | 1.5154    | 1.5524    | 1.7372    | 1.5893    | 1.7372    | 1.4784    |
| 8    | 1.6004    | 1.5524    | 1.5524    | 1.5524    | 1.5524    | 1.6632    | 1.5524    |
| 9    | 1.4415    | 1.531     | 1.4563    | 1.531     | 1.531     | 1.643     | 1.4937    |
| 10   | 1.7372    | 1.4563    | 1.3817    | 1.4563    | 1.4563    | 1.531     | 1.419     |
| 11   | 1.6263    | 1.1949    | 1.419     | 1.307     | 1.531     | 1.531     | 1.531     |
| 12   | 1.5524    | 1.2323    | 1.531     | 1.4563    | 1.4937    |           | 1.2696    |
| 13   | 1.5154    | 1.4937    |           | 1.7551    | 1.531     |           | 1.643     |
| 14   | 1.4784    | 1.3817    | 1.419     | 1.4937    | 1.4563    |           | 1.3817    |
| 15   | 1.4784    | 1.3817    | 1.2696    | 1.4563    | 1.3817    | 1.6804    | 1.4937    |
| 16   | 1.4784    | 1.419     | 1.2323    | 1.4937    | 1.4563    | 1.643     | 1.4563    |
| 17   | 1.5154    | 1.419     | .2957     | 1.4937    | 1.4784    | 1.5684    | 1.4784    |
| 18   | 1.5893    | 1.4784    | 1.5524    | 1.848     | 1.5154    | 1.5684    | 1.6263    |
| 19   | 1.7372    | 1.6632    | 1.9589    | 2.0328    | 1.9589    | 1.848     | 1.885     |
| 20   | 1.7372    | 1.885     | 1.9589    | 1.922     | 1.9589    | 1.848     | 1.922     |
| 21   | 1.7741    | 1.848     | 1.922     | 1.922     | 1.885     | 1.885     | 1.885     |
| 22   | 1.6632    | 1.7741    | 1.8111    | 1.885     | 1.885     | 1.848     | 1.8671    |
| 23   | 1.6632    | 1.7372    | 1.7741    | 1.8111    | 1.6632    | 1.7741    | 1.7372    |
| 24   | 1.5623    | 1.5524    | 1.5893    | 1.6263    | 1.6263    | 1.7002    | 1.6263    |
| Max  | 1.829     | 1.885     | 1.9589    | 2.0328    | 1.9589    | 1.885     | 1.922     |
| Min  | 1.3336    | 1.1949    | .2957     | 1.307     | 1.3817    | 1.4045    | 1.2696    |
| Avg  | 1.5774    | 1.5176    | 1.5052    | 1.6228    | 1.6036    | 1.6352    | 1.5581    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 203 / 11KV RAM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8764     | .924      | 1.0164    | 1.0534    | 1.1088    | 1.1088    | 1.1088    |
| 2    | .8764     | .924      | 1.0164    | 1.0534    | 1.1088    | 1.1088    | 1.1088    |
| 3    | .8764     | .924      | 1.0164    | .924      | 1.1088    | .9979     | 1.1088    |
| 4    | .8383     | .8871     | .924      | .8501     | 1.1088    | .8871     | 1.1088    |
| 5    | .8002     | .8501     | .8501     | .8501     | .9979     | .8501     | .924      |
| 6    | .8192     | .8501     | .8131     | .8501     | .9979     | .8501     | .8501     |
| 7    | .8192     | .8501     | .8501     | .924      | .9979     | .8501     | .7762     |
| 8    | .8316     | .961      | .8501     | .8316     | .7392     | .8316     | .7392     |
| 9    | .7577     | .8029     | .8029     | .7655     | .7468     | .8029     | .8215     |
| 10   | .8131     | .6908     | .7468     | .7468     | .7655     | .7655     | .8402     |
| 11   | .7023     | .7095     | .7655     | .7655     | .7842     | .7282     | .7468     |
| 12   | .7023     | .7468     | .7468     | .7468     | .7282     |           | .7095     |
| 13   | .7392     | .7282     | .7282     | .7468     | .7655     |           | .7095     |
| 14   | .7762     | .7655     | .7655     | .7655     | .7842     |           | .7468     |
| 15   | .8316     | .7842     | .7842     | .8029     | .8589     | .9335     | .8029     |
| 16   | .8501     | .8029     | .8402     | .8589     | .8402     | .9335     | .8589     |
| 17   | .8501     | .8029     | .7947     | .8589     | .7947     | .8402     | .8131     |
| 18   | .7947     | .7392     | .8131     | .924      | .8131     | .8589     | .8131     |
| 19   | .924      | .924      | 1.0903    | .9979     | .961      | .924      | .924      |
| 20   | .924      | 1.0164    | 1.2012    | 1.0164    | 1.0349    | 1.1088    | 1.0349    |
| 21   | 1.0349    | 1.0164    | 1.1827    | 1.0534    | 1.1827    | 1.1088    | 1.0349    |
| 22   | 1.1088    | 1.1088    | 1.1088    | 1.1088    | 1.1458    | 1.2197    | 1.0903    |
| 23   | 1.1088    | 1.1088    | 1.1088    | 1.2197    | 1.2197    | 1.2197    | 1.1458    |
| 24   | 1.0479    | 1.1088    | 1.0719    | 1.1458    | 1.1827    | 1.1827    | 1.1088    |
| Max  | 1.1088    | 1.1088    | 1.2012    | 1.2197    | 1.2197    | 1.2197    | 1.1458    |
| Min  | .7023     | .6908     | .7282     | .7468     | .7282     | .7282     | .7095     |
| Avg  | .8626     | .8761     | .9120     | .9108     | .9490     | .9577     | .9136     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 204 / 11KV SHARADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7147    | 1.848     | 1.848     | 1.7372    | 1.848     | 1.848     | 1.6804    |
| 2    | 1.7147    | 1.848     | 1.848     | 1.6263    | 1.848     | 1.7187    | 1.6804    |
| 3    | 1.6385    | 1.848     | 1.848     | 1.4784    |           | 1.6632    | 1.6804    |
| 4    | 1.5623    | 1.6632    | 1.848     | 1.4784    | 1.848     | 1.5524    | 1.6804    |
| 5    | 1.7528    | 1.6632    | 2.0328    | 1.4784    | 1.6632    | 1.4784    | 1.8671    |
| 6    | 1.9433    | 1.7741    | 2.0328    | 1.7002    | 1.6632    | 1.6263    | 1.9418    |
| 7    | 2.0576    | 1.6632    | 1.6632    | 1.9589    | 1.6632    | 1.885     | 1.7924    |
| 8    | 1.8671    | 1.6632    | 1.5154    | 1.6632    | 1.6263    | 1.848     | 1.643     |
| 9    | 1.7372    | 1.5123    | 1.531     | 1.587     | 1.5684    | 1.5684    | 1.587     |
| 10   | 1.6632    | 1.4937    | 1.5123    | 1.587     | 1.587     | 1.531     | 1.6804    |
| 11   | 1.4784    | 1.5123    | 1.5684    | 1.5684    | 1.643     | 1.587     | 1.6804    |
| 12   | 1.4784    | 1.5684    | 1.587     | 1.6617    | 1.5684    |           | 1.7177    |
| 13   | 1.4784    | 1.5684    | 1.6991    | 1.7177    | 1.8298    |           | 1.7177    |
| 14   | 1.4784    | 1.587     | 1.6244    | 1.6991    | 1.6804    |           | 1.7177    |
| 15   | 1.4784    | 1.5684    | 1.6804    | 1.7364    | 1.6617    | 2.0165    | 1.6991    |
| 16   | 1.4784    | 1.6991    | 1.643     | 1.7924    | 1.643     | 1.8671    | 1.6617    |
| 17   | 1.6263    | 1.6991    | 1.6632    | 1.7924    | 1.7002    | 1.8298    | 1.7741    |
| 18   | 1.7002    | 1.8665    | 1.7002    | 2.0328    | 1.8111    | 1.7924    | 1.7741    |
| 19   | 1.9589    | 2.2177    | 2.2177    | 2.4025    | 2.2546    | 2.0328    | 2.1068    |
| 20   | 2.0328    | 2.4025    | 2.2916    | 2.2916    | 2.2177    | 2.3101    | 2.1807    |
| 21   | 2.2177    | 2.2177    | 2.2361    | 2.2177    | 2.5133    | 2.3101    | 2.2177    |
| 22   | 2.2177    | 2.2177    | 2.0698    | 2.1253    | 2.1068    | 2.2177    | 2.0698    |
| 23   | 2.0698    | 2.1253    | 2.0328    | 2.0698    | 2.1068    | 2.1253    | 2.0328    |
| 24   | 1.9814    | 1.922     | 1.922     | 1.885     | 1.922     | 1.922     | 1.848     |
| Max  | 2.2177    | 2.4025    | 2.2916    | 2.4025    | 2.5133    | 2.3101    | 2.2177    |
| Min  | 1.4784    | 1.4937    | 1.5123    | 1.4784    | 1.5684    | 1.4784    | 1.587     |
| Avg  | 1.7636    | 1.7979    | 1.8173    | 1.8037    | 1.8250    | 1.8443    | 1.8097    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 205 / 11 KV WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1143     | .1097     | .1097     | .1143     | .1097     | .1334     | .1097     |
| 2    | .1143     | .1097     | .1097     | .1143     | .1097     | .1334     | .1097     |
| 3    | .1143     | .1109     | .1097     | .1143     | .1097     | .1334     | .1097     |
| 4    | .1143     | .1109     | .1097     | .1143     | .1097     | .1334     | .1097     |
| 5    | .1143     | .1097     | .1097     | .1143     | .1097     | .1334     | .1097     |
| 6    | .1143     | .1097     | .1097     | .0762     | .1109     | .1334     | .1109     |
| 7    | .1334     | .1097     | .1097     | .1143     | .1109     | .1334     | .1109     |
| 8    | .1524     | .1097     | .1097     | .1132     | .1097     | .1143     | .1109     |
| 9    | .1143     | .0934     | .0934     | .112      | .112      | .0747     | .112      |
| 10   | .1143     | .112      | .0934     | .0934     | .112      | .0934     | .112      |
| 11   | .1143     | .0747     | .0934     | .0934     | .0934     | .0373     | .0934     |
| 12   | .1143     | .112      | .0747     | .0934     | .0934     |           | .0934     |
| 13   | .1524     | .0934     | .0934     | .0747     | .0747     |           | .112      |
| 14   | .1524     | .112      | .112      | .112      | .112      |           | .0747     |
| 15   | .1143     | .112      | .112      | .112      | .112      | .0934     | .112      |
| 16   | .1334     | .112      | .112      | .112      | .0747     | .112      | .112      |
| 17   | .1334     | .112      | .1143     | .0934     | .1143     | .112      | .1143     |
| 18   | .1334     | .1097     | .1334     | .1109     | .1143     | .112      | .1143     |
| 19   | .1143     | .1097     | .1334     | .1109     | .1143     | .1109     | .1143     |
| 20   | .1097     | .1097     | .1334     | .1143     | .1143     | .1109     | .1143     |
| 21   | .1097     | .1109     | .1143     | .1143     | .1143     | .1109     | .1143     |
| 22   | .1097     | .1109     | .1334     | .1143     | .1143     | .1109     | .1143     |
| 23   | .1097     | .1109     | .1334     | .1143     | .1143     | .1109     | .1143     |
| 24   | .1334     | .1097     | .1109     | .1334     | .1097     | .1143     | .1109     |
| Max  | .1524     | .112      | .1334     | .1334     | .1143     | .1334     | .1143     |
| Min  | .1097     | .0747     | .0747     | .0747     | .0747     | .0373     | .0747     |
| Avg  | .1223     | .1077     | .1112     | .1077     | .1073     | .1120     | .1089     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 203 / CIDCO-N4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.0308    | 3.1047    | 3.0308    | 3.1047    | 3.2526    | 3.2674    | 3.1554    |
| 2    | 2.9754    | 2.8829    | 2.809     | 2.9569    | 3.0678    | 3.1181    | 2.9874    |
| 3    | 2.809     | 2.5873    | 2.6981    | 2.7351    | 2.8645    | 2.9874    | 2.7633    |
| 4    | 2.5503    | 2.4579    | 2.6242    | 2.5873    | 2.7351    | 2.8006    | 2.6326    |
| 5    | 2.5503    | 2.4579    | 2.5688    | 2.4949    | 2.7351    | 2.6513    | 2.5579    |
| 6    | 2.4025    | 2.5873    | 2.8645    | 2.6797    | 2.7721    | 2.9874    | 2.5019    |
| 7    | 2.4394    | 2.5873    | 2.7633    | 2.4579    | 2.5873    | 2.726     | 2.4272    |
| 8    | 2.5019    | 2.5953    | 2.4832    | 2.3899    | 2.3285    | 2.5206    | 2.3339    |
| 9    | 2.3525    | 2.4459    | 2.1098    | 2.3152    | 2.2779    | 2.3525    | 2.4459    |
| 10   | 2.2405    | 2.3525    | 2.2592    |           | 2.2032    |           | 2.2032    |
| 11   | 2.2965    | 2.3712    | 2.2965    | 2.3899    | 2.3712    |           | 2.4832    |
| 12   |           | 2.2965    | 2.3712    | 2.4272    | 2.4832    |           | 2.4646    |
| 13   | 2.4086    | 2.3152    | 2.4086    | 2.4832    | 2.6139    |           | 2.4832    |
| 14   | 2.5206    | 2.6699    | 2.6699    | 2.782     | 2.5034    | 3.5475    | 2.6699    |
| 15   | 2.6886    | 2.7073    | 3.062     | 2.9687    | 2.8193    | 3.2786    | 2.8006    |
| 16   | 2.7446    | 2.7633    | 2.9874    | 2.95      | 2.7633    | 3.1417    | 3.0247    |
| 17   | 2.6139    | 2.7633    | 2.8006    | 2.782     | 2.8753    | 2.9938    |           |
| 18   | 2.4832    | 2.6699    | 2.9127    | 2.782     | 2.838     | 2.9938    |           |
| 19   | 3.1181    | 3.1741    | 3.2861    | 3.2674    | 3.3234    | 3.4558    |           |
| 20   | 3.1367    | 3.4915    | 3.5475    | 3.6595    | 3.5662    | 3.5113    | 3.1232    |
| 21   | 3.3234    | 3.5101    | 3.4728    | 3.5848    | 3.5475    | 3.5298    | 3.1971    |
| 22   | 3.3819    | 3.5113    | 3.5298    | 3.6037    | 3.7715    | 3.5482    | 3.5101    |
| 23   | 3.5852    | 3.8439    | 3.7515    | 3.7515    | 3.8649    | 3.6969    | 3.7342    |
| 24   | 4.3115    | 3.3819    | 3.4558    | 3.5113    | 3.6406    | 3.6035    | 3.5288    |
| Max  | 4.3115    | 3.8439    | 3.7515    | 3.7515    | 3.8649    | 3.6969    | 3.7342    |
| Min  | 2.2405    | 2.2965    | 2.1098    | 2.3152    | 2.2032    | 2.3525    | 2.2032    |
| Avg  | 2.8028    | 2.8137    | 2.8651    | 2.8985    | 2.9086    | 3.1356    | 2.8109    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 204 / MUKUNDWADI  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9959    | 2.0328    | 2.1253    | 2.2177    | 2.1068    | 2.1845    | 2.2032    |
| 2    | 1.9035    | 1.9404    | 1.9589    | 2.1807    | 2.0144    | 2.0538    | 2.0538    |
| 3    | 1.8665    | 1.885     | 1.922     | 2.0883    | 1.885     | 1.9978    | 2.0165    |
| 4    | 2.0144    | 2.0144    | 1.885     | 2.1253    | 1.922     | 2.0538    | 1.9978    |
| 5    | 2.0328    | 2.0513    | 2.1622    | 2.2177    | 1.9959    | 2.1658    | 2.0538    |
| 6    | 2.0883    | 2.2916    | 2.4394    | 2.4025    | 2.5133    | 2.5579    | 2.2405    |
| 7    | 2.4764    | 2.4394    | 2.726     | 2.6057    | 2.5873    | 2.5393    | 2.5206    |
| 8    | 2.3152    | 2.5019    | 2.2405    | 2.3525    | 1.9959    | 2.4272    | 2.2405    |
| 9    | 2.0911    | 2.2779    | 1.9044    | 2.0911    | 2.0351    | 1.9978    | 1.9978    |
| 10   | 2.1472    | 1.7737    | 1.643     | 1.8858    | 1.9044    |           | 2.0165    |
| 11   | 2.0165    | 1.7924    | 1.9231    | 1.8111    | 1.8858    |           | 1.8858    |
| 12   | 1.8484    | 1.7551    | 1.9605    | 1.9791    | 1.9044    |           | 1.9605    |
| 13   | 1.9418    | 1.8671    | 1.9605    | 1.8858    | 1.9231    |           | 1.9231    |
| 14   | 2.0165    | 1.8671    | 1.9791    | 1.8671    | 1.9605    | 2.2779    | 1.8858    |
| 15   | 2.1285    | 1.9791    | 1.9231    | 2.1472    | 1.8858    | 1.9231    | 1.9418    |
| 16   | 2.0351    | 2.0911    | 2.0351    | 1.8858    | 1.9418    | 1.9589    |           |
| 17   | 1.9605    | 2.0538    | 2.0538    | 1.9231    | 2.0538    | 2.0328    |           |
| 18   | 2.0911    | 2.2405    | 2.2779    | 2.0538    | 2.1845    | 2.0698    |           |
| 19   | 2.6139    | 2.6513    | 2.5019    | 2.6139    | 2.6513    | 2.5688    | 2.7721    |
| 20   | 2.7073    | 2.7633    | 2.894     | 2.8753    | 2.95      | 2.5873    | 2.7536    |
| 21   | 2.7633    | 2.6886    | 2.7073    | 2.782     | 2.894     | 2.7536    | 2.7721    |
| 22   | 2.5873    | 2.6242    | 2.7351    | 2.7721    | 2.8006    | 2.8829    | 2.8006    |
| 23   | 2.5133    | 2.3655    | 2.6427    | 2.6242    | 2.726     | 2.8006    | 2.5393    |
| 24   | 2.0883    | 2.1437    | 2.3655    | 2.4209    | 2.3285    | 2.4646    | 2.4832    |
| Max  | 2.7633    | 2.7633    | 2.894     | 2.8753    | 2.95      | 2.8829    | 2.8006    |
| Min  | 1.8484    | 1.7551    | 1.643     | 1.8111    | 1.885     | 1.9231    | 1.8858    |
| Avg  | 2.1768    | 2.1705    | 2.2069    | 2.2420    | 2.2104    | 2.3149    | 2.2409    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 205 / High court Exp  
Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1132     | .0943     | .132      | .0943     | .1132     | .1307     |
| 2    | .0943     | .1132     | .0754     | .0943     | .1132     | .112      |
| 3    | .0943     | .0943     | .0943     | .1132     | .1132     | .112      |
| 4    | .0943     | .0943     | .1132     | .0943     | .1132     | .112      |
| 5    | .0943     | .0943     | .0943     | .0943     | .0943     | .112      |
| 6    | .0754     | .0943     | .0943     | .0943     | .0943     | .0934     |
| 7    | .0943     | .0754     | .0754     | .0943     | .0754     | .0747     |
| 8    | .0747     | .0934     | .0934     | .0747     | .1132     | .0934     |
| 9    | .112      | .0934     | .112      | .1307     | .1307     |           |
| 10   | .1307     | .4481     | .4854     | .5228     | .5228     |           |
| 11   | .1307     | .6722     | .5975     | .6161     | .5975     |           |
| 12   | .2054     | .6722     | .5601     | .6348     | .5975     |           |
| 13   | .1867     | .6722     | .6348     | .6348     | .6348     |           |
| 14   | .1867     |           | .5415     | .5601     | .5788     |           |
| 15   | .168      | .5975     | .6348     | .5975     | .5975     |           |
| 16   | .168      | .6348     | .5975     | .6348     | .6348     |           |
| 17   | .1494     | .5601     | .5228     | .5601     | .5601     |           |
| 18   | .1307     | .4108     | .3734     | .4108     | .3734     |           |
| 19   | .1494     | .3174     | .2987     | .2614     | .3361     |           |
| 20   | .1494     | .2241     | .2241     | .2241     | .2614     |           |
| 21   | .1494     | .1867     | .168      | .168      | .1867     |           |
| 22   | .132      | .1886     | .1663     | .1509     | .1867     |           |
| 23   | .1132     | .1698     | .1478     | .132      | .1494     |           |
| 24   | 1.3014    | .0943     | .132      | .1132     | .1509     | .1494     |
| Max  | 1.3014    | .6722     | .6348     | .6348     | .6348     | .1494     |
| Min  | .0747     | .0754     | .0754     | .0747     | .0754     | .0747     |
| Avg  | .1791     | .2911     | .2904     | .2961     | .3054     | .1100     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 201 / MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4854     | .4974     |           | .5041     | .518      | .5348     |
| 2    |           | .4338     | .4417     |           | .4668     | .499      | .5153     |
| 3    |           | .4108     | .4036     |           | .4481     | .4606     | .478      |
| 4    |           | .4294     | .4233     |           | .4668     | .4795     | .4974     |
| 5    |           | .4668     | .4615     |           | .4854     | .5175     | .5169     |
| 6    |           | .5415     | .5944     |           | .5788     | .613      | .5735     |
| 7    |           | .6348     | .6348     | .6375     | .6535     | .6535     | .6161     |
| 8    |           | .5228     | .577      | .526      | .5788     | .6348     | .5601     |
| 9    |           | .4854     | .483      | .4907     | .5041     | .5207     | .4663     |
| 10   | .4854     | .4078     |           | .4481     | .4449     |           | .483      |
| 11   | .4481     | .4066     | .4194     | .3734     | .4444     |           | .4167     |
| 12   | .4481     | .4053     |           | .4108     | .4066     |           | .3999     |
| 13   | .4294     | .4045     | .3813     | .4108     | .4062     |           |           |
| 14   | .4108     | .4041     | .3999     | .4481     | .3681     | .5415     | .3999     |
| 15   | .4108     | .3857     | .4176     | .4668     | .4045     | .4668     |           |
| 16   | .4294     | .4049     |           | .5228     | .4233     | .4668     |           |
| 17   | .4481     | .4242     | .3994     | .4854     | .4422     | .4668     | .4362     |
| 18   | .4294     | .4251     | .4362     | .5228     | .4805     | .4854     | .4539     |
| 19   | .4854     | .5387     |           | .5788     | .5196     | .5228     | .4933     |
| 20   | .5228     | .5764     |           | .6535     | .5975     | .5601     | .5629     |
| 21   | .5788     | .577      |           | .6161     | .5963     | .5788     |           |
| 22   | .5788     | .5932     | .6023     | .7095     | .5956     |           |           |
| 23   | .5788     | .5741     |           | .6722     | .5561     |           |           |
| 24   | .5111     | .5228     | .5169     | .5276     | .5788     | .5544     | .5544     |
| Max  | .5788     | .6348     | .6348     | .7095     | .6535     | .6535     | .6161     |
| Min  | .4108     | .3857     | .3813     | .3734     | .3681     | .4606     | .3999     |
| Avg  | .4797     | .4775     | .4759     | .5278     | .4980     | .53       | .4977     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 202 / RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.587     | 1.5508    |           | 1.6244    | 1.6465    | 1.6263    |
| 2    |           | 1.4937    | 1.4754    |           | 1.531     | 1.5708    | 1.5692    |
| 3    |           | 1.4563    | 1.4539    |           | 1.475     | 1.4954    | 1.4923    |
| 4    |           | 1.6057    | 1.5676    |           | 1.6057    | 1.6482    | 1.6229    |
| 5    |           | 1.6804    | 1.6817    |           | 1.5091    | 1.7443    | 1.7593    |
| 6    |           | 2.0725    | 2.1362    |           | 2.1285    | 2.3712    | 2.157     |
| 7    |           | 2.3339    | 2.4559    | 2.2585    | 2.4646    | 2.4396    | 2.4534    |
| 8    |           | 2.1285    | 2.2032    | 2.0603    | 2.1658    | 2.2218    | 2.0933    |
| 9    |           | 1.9231    | 1.7346    | 1.876     | 1.9231    | 1.9398    | 1.9978    |
| 10   | 1.9605    | 1.7125    |           | 1.6804    | 1.7275    |           | 1.7311    |
| 11   | 1.8298    | 1.466     | 1.5498    | 1.5123    | 1.5402    |           | 1.5615    |
| 12   | 1.7924    | 1.369     |           | 1.2883    | 1.4459    |           | 1.578     |
| 13   | 1.643     | 1.3817    | 1.451     | 1.3443    | 1.4245    |           |           |
| 14   | 1.6244    | 1.3619    | 1.3871    | 1.475     | 1.4969    | 1.9231    | 1.4177    |
| 15   | 1.587     | 1.3817    | 1.3506    | 1.475     | 1.5123    | 1.6991    |           |
| 16   | 1.6244    | 1.386     |           | 1.475     | 1.5844    | 1.6057    |           |
| 17   | 1.6244    | 1.4815    | 1.5149    | 1.419     | 1.7187    | 1.587     | 1.3422    |
| 18   | 1.7177    | 1.6701    | 1.6792    | 1.6804    | 1.9054    | 1.7177    | 1.5697    |
| 19   | 2.0911    | 2.0847    |           | 2.0725    | 2.2337    | 2.0538    | 1.9894    |
| 20   | 2.1658    | 2.2523    |           | 2.3339    | 2.3223    | 2.2592    | 2.0077    |
| 21   | 2.2032    | 2.0268    |           | 2.1285    | 2.1034    | 2.1098    |           |
| 22   | 2.0165    | 1.8928    | 1.8233    | 2.0351    | 2.0082    |           |           |
| 23   | 1.7924    | 1.9074    |           | 1.9231    | 1.8538    |           |           |
| 24   | .8482     | 1.6617    | 1.5893    | 1.621     | 1.6991    | 1.7575    | 1.6632    |
| Max  | 2.2032    | 2.3339    | 2.4559    | 2.3339    | 2.4646    | 2.4396    | 2.4534    |
| Min  | .8482     | 1.3619    | 1.3506    | 1.2883    | 1.4245    | 1.4954    | 1.3422    |
| Avg  | 1.7681    | 1.7216    | 1.6826    | 1.7588    | 1.7918    | 1.8773    | 1.7573    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 203 / Dhoot Exp.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1143     | .1109     |           | .1143     | .1109     | .1108     |
| 2    |           | .1143     | .1105     |           | .1143     | .1107     | .1104     |
| 3    |           | .1143     | .1103     |           | .1132     | .1104     | .1105     |
| 4    |           | .1143     | .1103     |           | .1143     | .1103     | .0922     |
| 5    |           | .1143     | .1104     |           | .1143     | .0921     | .1107     |
| 6    |           | .1143     | .0922     |           | .1524     | .0922     | .1108     |
| 7    |           | .1334     | .1668     | .1701     | .1334     | .1478     | .1296     |
| 8    |           | .1715     | .1856     | .1888     | .1524     | .167      | .1112     |
| 9    |           | .1905     | .2243     | .2268     | .168      | .2241     | .2611     |
| 10   | .1143     | .2442     |           | .2667     | .2824     |           | .2442     |
| 11   | .0572     | .2641     | .2646     | .3018     | .2641     |           | .2375     |
| 12   | .0762     | .2844     |           | .2263     | .1882     |           | .3024     |
| 13   | .0762     | .1886     | .2077     | .2614     | .2266     |           |           |
| 14   | .0953     | .2646     | .2835     | .2641     | .2829     | .1905     | .2457     |
| 15   | .1143     | .2452     | .303      | .2829     | .3226     | .2801     |           |
| 16   | .1132     | .2643     |           | .2858     | .3605     | .2829     |           |
| 17   | .1143     | .2835     | .2641     | .3018     | .3223     | .2641     | .2832     |
| 18   | .1143     | .3226     | .2075     | .2286     | .2263     | .2667     | .1823     |
| 19   | .1524     | .2261     |           | .2286     | .1867     | .2452     | .1699     |
| 20   | .1524     | .1877     |           | .1905     | .2241     | .2096     | .151      |
| 21   | .1143     | .1497     |           | .2477     | .1489     | .1524     |           |
| 22   | .1524     | .13       | .1512     | .1524     | .1677     |           |           |
| 23   | .1334     | .111      |           | .1334     | .1672     |           |           |
| 24   | .1133     | .1143     | .1109     | .1323     | .1143     | .1109     | .1292     |
| Max  | .1524     | .3226     | .303      | .3018     | .3605     | .2829     | .3024     |
| Min  | .0572     | .111      | .0922     | .1323     | .1132     | .0921     | .0922     |
| Avg  | .1129     | .1859     | .1773     | .2272     | .1942     | .1760     | .1718     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 204 / 11 KV Chikalthana  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.0911    | 2.0762    |           | 2.1472    | 2.1362    | 2.1504    |
| 2    |           | 2.0165    | 1.9959    |           | 2.0911    | 2.0926    | 2.1068    |
| 3    |           | 1.9231    | 1.9364    |           | 1.9978    | 2.0328    | 2.0308    |
| 4    |           | 2.1285    | 2.1459    |           | 2.2032    | 2.2245    | 2.2454    |
| 5    |           | 2.2965    | 2.3777    |           | 2.3712    | 2.4409    | 2.4247    |
| 6    |           | 3.062     | 3.1741    |           | 3.0247    | 3.0714    | 3.0247    |
| 7    |           | 3.5288    | 3.5082    | 3.2648    | 3.3608    | 3.2253    | 3.3351    |
| 8    |           | 2.9874    | 3.0589    | 3.0481    | 3.006     | 3.0183    | 3.0178    |
| 9    |           | 2.7633    | 2.7287    | 2.6634    | 2.6699    | 2.8251    | 2.8712    |
| 10   | 2.838     | 2.5631    |           | 2.4459    | 2.6139    |           | 1.6804    |
| 11   | 2.5393    | 2.3874    | 2.1969    | 2.3525    | 2.3664    |           | 2.2853    |
| 12   | 2.3899    | 2.1034    |           | 2.2218    | 2.1384    |           | 2.2174    |
| 13   | 2.1845    | 2.0021    | 2.0581    | 2.1098    | 2.2662    |           |           |
| 14   | 2.1098    | 1.9774    | 1.9791    | 2.0351    | 2.1526    | 2.726     | 1.9951    |
| 15   | 2.0538    | 1.9569    | .2363     | 2.1285    | 2.1133    | 2.4459    |           |
| 16   | 1.9231    | 2.037     |           | 2.1658    | 2.2916    | 2.4459    |           |
| 17   | 2.3899    | 2.2291    | 2.5836    | 2.2405    | 2.4099    | 2.5766    | 2.0807    |
| 18   | 2.726     | 2.6618    | 2.7896    | 2.7073    | 2.7735    | 2.7446    | 2.1879    |
| 19   | 3.2487    | 3.3882    |           | 3.0807    | 3.4377    | 3.2301    | 2.5809    |
| 20   | 3.3234    | 3.24      |           | 3.2861    | 3.1967    | 3.3981    | 2.999     |
| 21   | 2.5579    | 2.9373    |           | 2.782     | 2.7446    | 2.9874    |           |
| 22   | 2.4459    | 2.5315    | 2.4822    | 2.5393    | 2.5129    |           |           |
| 23   | 2.3339    | 2.2848    |           | 2.3525    | 2.2314    |           |           |
| 24   |           | 2.1472    | 2.1362    | 2.1062    | 2.1845    | 2.157     | 2.206     |
| Max  | 3.3234    | 3.5288    | 3.5082    | 3.2861    | 3.4377    | 3.3981    | 3.3351    |
| Min  | 1.9231    | 1.9231    | .2363     | 2.0351    | 1.9978    | 2.0328    | 1.6804    |
| Avg  | 2.5046    | 2.4685    | 2.3214    | 2.5295    | 2.5127    | 2.6544    | 2.4133    |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 201 / GARWARE EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9978    |           |           |           |           |
| 2    | 2.1033    |           |           |           |           |
| 3    | 1.8484    |           |           |           |           |
| 4    | 1.9231    |           |           |           |           |
| 5    | 1.9231    |           |           |           |           |
| 6    | 2.0165    |           |           |           |           |
| 7    | 2.0005    |           |           |           |           |
| 8    | 1.9243    |           |           |           |           |
| 9    | 2.0005    |           |           |           |           |
| 10   | 1.9814    |           |           |           |           |
| 11   | 2.0957    |           |           |           |           |
| 12   | 1.8298    |           |           |           |           |
| 13   | 1.9433    |           |           |           |           |
| 14   | 1.9433    |           |           |           |           |
| 15   | 2.0005    |           |           |           |           |
| 16   | 2.0195    | 1.7177    | 1.8484    | 1.442     | 1.4377    |
| 17   | 2.0386    |           |           |           |           |
| 18   | 1.9052    |           |           |           |           |
| 19   | 2.0195    |           |           |           |           |
| 20   | 1.6804    |           |           |           |           |
| 21   | 1.9243    |           |           |           |           |
| 22   | 1.9433    |           |           |           |           |
| 23   | 1.9433    | 1.8671    | 1.7924    | 1.3599    | 1.5242    |
| 24   | 2.0538    | 1.9624    | 1.7551    | 1.8111    | 1.2498    |
| Max  | 2.1033    | 1.9624    | 1.8484    | 1.8111    | 1.5242    |
| Min  | 1.6804    | 1.7177    | 1.7551    | 1.3599    | 1.2498    |
| Avg  | 1.9608    | 1.8491    | 1.7986    | 1.5377    | 1.4039    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 202 / CENTRON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 1.0669    | 1.2384    |           | 1.3336    | 1.3717    | 1.2955    |
| 23   | .6908     | .6908     | .7356     | .8192     | .9145     | .743      |
| 24   | .6099     | .6219     | .6348     | .6653     | .743      | .6099     |
| Max  | 1.0669    | 1.2384    | .7356     | 1.3336    | 1.3717    | 1.2955    |
| Min  | .6099     | .6219     | .6348     | .6653     | .743      | .6099     |
| Avg  | .7892     | .8504     | .6852     | .9394     | 1.0097    | .8828     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 203 / MAHAVEER EXP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | .1715     | .2286     | .2641     | .3048     | .3048     | .2286     |
| 23   | .2667     | .3048     | .2829     | .3048     | .3048     | .2667     |
| 24   | .3048     | .3048     | .3018     | .2858     | .3048     | .2858     |
| Max  | .3048     | .3048     | .3018     | .3048     | .3048     | .2858     |
| Min  | .1715     | .2286     | .2641     | .2858     | .3048     | .2286     |
| Avg  | .2477     | .2794     | .2829     | .2985     | .3048     | .2604     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 204 / 11 KV CIDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 2.0725    | 2.1807    | 2.0144    | 2.1807    | 2.1068    | 2.1807    |
| 23   | 2.4579    | 2.4579    | 2.5318    | 2.4579    | 2.384     | 2.4394    |
| 24   | 2.1807    | 2.1807    | 2.1992    | 2.2361    | 2.2361    | 2.2177    |
| Max  | 2.4579    | 2.4579    | 2.5318    | 2.4579    | 2.384     | 2.4394    |
| Min  | 2.0725    | 2.1807    | 2.0144    | 2.1807    | 2.1068    | 2.1807    |
| Avg  | 2.2370    | 2.2731    | 2.2485    | 2.2916    | 2.2423    | 2.2793    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 205 / RAMA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 2.191     | 2.6863    | 2.7538    | 2.8578    | 2.8769    | 2.9531    |
| 23   | 1.7909    | 1.9243    | 2.0748    | 2.0576    | 2.0957    | 2.0576    |
| 24   | 1.8861    | 1.7528    | 1.6787    | 1.8671    | 1.7909    | 2.0767    |
| Max  | 2.191     | 2.6863    | 2.7538    | 2.8578    | 2.8769    | 2.9531    |
| Min  | 1.7909    | 1.7528    | 1.6787    | 1.8671    | 1.7909    | 2.0576    |
| Avg  | 1.956     | 2.1211    | 2.1691    | 2.2608    | 2.2545    | 2.3625    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 206 / Wokhardt

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0479    |           |           |           |           |           |
| 2    | .9526     |           |           |           |           |           |
| 3    | .6878     |           |           |           |           |           |
| 4    | 1.0288    |           |           |           |           |           |
| 5    | .7095     |           |           |           |           |           |
| 6    | .7392     |           |           |           |           |           |
| 7    | .8402     |           |           |           |           |           |
| 8    | .8192     |           |           |           |           |           |
| 9    | .8192     |           |           |           |           |           |
| 10   | .8573     |           |           |           |           |           |
| 11   | .8764     |           |           |           |           |           |
| 12   | .8954     |           |           |           |           |           |
| 13   | .9335     |           |           |           |           |           |
| 14   | .9907     |           |           |           |           |           |
| 15   | 1.0288    |           |           |           |           |           |
| 16   | 1.2003    | 1.467     | 1.2449    | 1.2765    | 1.2955    | 1.1622    |
| 17   | 1.1241    |           |           |           |           |           |
| 18   | 1.3256    |           |           |           |           |           |
| 19   | 1.0288    |           |           |           |           |           |
| 20   | 1.0288    |           |           |           |           |           |
| 23   | .9335     | .5525     | .6838     | .9145     | .8215     | .9709     |
| 24   | 1.0669    | .9907     | .9054     | .9335     | .8954     | .4854     |
| Max  | 1.3256    | 1.467     | 1.2449    | 1.2765    | 1.2955    | 1.1622    |
| Min  | .6878     | .5525     | .6838     | .9145     | .8215     | .4854     |
| Avg  | .9516     | 1.0034    | .9447     | 1.0415    | 1.0041    | .8728     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 207 / GREAVES

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 1.5242    | 2.1098    | 3.2114    | 3.1554    | 3.296     | 2.9874    |
| 23   | 1.2003    | 1.5242    | 2.191     | 2.0386    | 2.2291    | 2.0195    |
| 24   | 1.8099    | 1.086     | 1.3203    | 1.7147    | 1.9052    | 1.9814    |
| Max  | 1.8099    | 2.1098    | 3.2114    | 3.1554    | 3.296     | 2.9874    |
| Min  | 1.2003    | 1.086     | 1.3203    | 1.7147    | 1.9052    | 1.9814    |
| Avg  | 1.5115    | 1.5733    | 2.2409    | 2.3029    | 2.4768    | 2.3294    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 208 / RADIANT AGRO

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8785     |           |           |           |           |
| 2    | .9665     |           |           |           |           |
| 3    | .9326     |           |           |           |           |
| 4    | .8288     |           |           |           |           |
| 6    | .8381     |           |           |           |           |
| 7    | .9105     |           |           |           |           |
| 8    | 1.2226    |           |           |           |           |
| 9    | 1.5123    |           |           |           |           |
| 10   | 1.5278    |           |           |           |           |
| 11   | 1.8099    |           |           |           |           |
| 12   | 1.848     |           |           |           |           |
| 13   | 1.2894    |           |           |           |           |
| 14   | 1.3957    |           |           |           |           |
| 15   | 1.5623    |           |           |           |           |
| 16   | 1.5655    | 2.6482    | 2.2068    | 2.934     | 3.1436    |
| 17   | 1.5089    |           |           |           |           |
| 18   | 1.1041    |           |           |           |           |
| 19   | 1.1041    |           |           |           |           |
| 20   | 1.1999    |           |           |           |           |
| 21   | 1.1919    |           |           |           |           |
| 22   | 1.1744    |           |           |           |           |
| 23   | 1.0117    | 1.0513    | 1.0682    | 1.0608    | 1.0322    |
| 24   | .9665     | .9282     | 1.0343    | .8905     | .9061     |
| Max  | 1.848     | 2.6482    | 2.2068    | 2.934     | 3.1436    |
| Min  | .8288     | .9282     | 1.0343    | .8905     | .9061     |
| Avg  | 1.2326    | 1.5426    | 1.4364    | 1.6284    | 1.6940    |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 209 / IND-II

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 1.8861    | 2.2965    |           | 2.7054    | 2.7625    | 2.6863    |
| 23   | 1.3321    | 1.4632    | 1.419     | 1.5123    | 1.6448    | 1.3535    |
| 24   | 1.3289    | 1.262     |           | 1.3306    | 1.386     | 1.4022    |
| Max  | 1.8861    | 2.2965    | 1.419     | 2.7054    | 2.7625    | 2.6863    |
| Min  | 1.3289    | 1.262     | 1.419     | 1.3306    | 1.386     | 1.3535    |
| Avg  | 1.5157    | 1.6739    | 1.419     | 1.8494    | 1.9311    | 1.814     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 210 / 11 KV N-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 1.1016    | 1.2883    | 1.4003    | 1.3817    | 1.475     | 1.251     |
| 23   | 1.307     | 1.2567    | 1.3491    | 1.3121    | 1.386     | 1.2752    |
| 24   | 1.2323    | 1.2012    | 1.1462    | 1.2752    | 1.2197    | 1.1576    |
| Max  | 1.307     | 1.2883    | 1.4003    | 1.3817    | 1.475     | 1.2752    |
| Min  | 1.1016    | 1.2012    | 1.1462    | 1.2752    | 1.2197    | 1.1576    |
| Avg  | 1.2136    | 1.2487    | 1.2985    | 1.323     | 1.3602    | 1.2279    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 211 / ELLORA

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5775    |           |           |           |           |
| 2    | 1.543     |           |           |           |           |
| 3    | 1.439     |           |           |           |           |
| 4    | 1.5074    |           |           |           |           |
| 5    | 1.6478    |           |           |           |           |
| 6    | 1.9004    |           |           |           |           |
| 7    | 2.1033    |           |           |           |           |
| 10   | 3.942     |           |           |           |           |
| 11   | 3.5648    |           |           |           |           |
| 12   | 3.2819    |           |           |           |           |
| 13   | 2.572     |           |           |           |           |
| 16   |           | 3.3341    | 3.4328    | 3.6961    | 3.9057    |
| 18   | 2.7915    |           |           |           |           |
| 19   | 2.9531    |           |           |           |           |
| 20   | 2.8669    |           |           |           |           |
| 21   | 2.6029    |           |           |           |           |
| 22   | 2.0144    |           |           |           |           |
| 23   | 1.8107    | 1.8656    | 2.0911    | 2.4646    | 2.6513    |
| 24   | 1.6301    | 1.701     | 1.7737    | 2.0513    | 2.4086    |
| Max  | 3.942     | 3.3341    | 3.4328    | 3.6961    | 3.9057    |
| Min  | 1.439     | 1.701     | 1.7737    | 2.0513    | 2.4086    |
| Avg  | 2.3194    | 2.3002    | 2.4325    | 2.7373    | 2.9885    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 212 / IND-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 2.782     | 4.1343    | 2.95      | 3.8485    | 3.5818    |
| 23   | 3.0864    | 2.782     | 2.3211    | 2.7905    | 3.296     |
| 24   | 1.7654    | 2.4394    | 2.4535    | 2.0978    | 2.4451    |
| Max  | 3.0864    | 4.1343    | 2.95      | 3.8485    | 3.5818    |
| Min  | 1.7654    | 2.4394    | 2.3211    | 2.0978    | 2.4451    |
| Avg  | 2.5446    | 3.1186    | 2.5749    | 2.9123    | 3.1076    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 213 / 11 KV Naregaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2136    |           |           |           |           |
| 2    | 1.1763    |           |           |           |           |
| 3    | 1.1763    |           |           |           |           |
| 4    | 1.2136    |           |           |           |           |
| 5    | 1.3256    |           |           |           |           |
| 6    | 1.7918    |           |           |           |           |
| 7    | 2.1502    |           |           |           |           |
| 8    | 2.2405    |           |           |           |           |
| 9    | 2.2405    |           |           |           |           |
| 10   | 2.0698    |           |           |           |           |
| 11   | 2.1948    |           |           |           |           |
| 12   | 2.0452    |           |           |           |           |
| 13   | 1.7375    |           |           |           |           |
| 14   | 1.6289    |           |           |           |           |
| 15   | 1.773     |           |           |           |           |
| 16   | 1.7013    | 1.8088    | 1.6476    | 2.0005    | 1.8804    |
| 17   | 1.9185    |           |           |           |           |
| 18   | 1.9185    |           |           |           |           |
| 19   | 2.1132    |           |           |           |           |
| 20   | 2.0144    |           |           |           |           |
| 21   | 1.6804    |           |           |           |           |
| 22   | 1.5684    |           |           |           |           |
| 23   | 1.419     | 1.4377    | 1.5684    | 1.4937    | 1.4563    |
| 24   | 1.2883    | 1.307     | 1.307     | 1.4003    | 1.3256    |
| Max  | 2.2405    | 1.8088    | 1.6476    | 2.0005    | 1.8804    |
| Min  | 1.1763    | 1.307     | 1.307     | 1.4003    | 1.3256    |
| Avg  | 1.7333    | 1.5178    | 1.5077    | 1.6315    | 1.5541    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 214 / INDIAN TOOL

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | .9522     | 1.2003    | 1.3957    | 1.7147    | 1.4861    |
| 23   | .4664     | .5287     | .664      | .7202     | .6958     |
| 24   | .3715     | .4268     | .5281     | .5864     | .6796     |
| Max  | .9522     | 1.2003    | 1.3957    | 1.7147    | 1.4861    |
| Min  | .3715     | .4268     | .5281     | .5864     | .6796     |
| Avg  | .5967     | .7186     | .8626     | 1.0071    | .9538     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 215 / Agro Exp

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.1626    |           |           |           |           |
| 2    | 2.8193    |           |           |           |           |
| 3    | 2.6513    |           |           |           |           |
| 4    | 2.5318    |           |           |           |           |
| 5    | 2.6886    |           |           |           |           |
| 6    | 2.9613    |           |           |           |           |
| 7    | 2.5606    |           |           |           |           |
| 8    | 2.6244    |           |           |           |           |
| 9    | 2.4949    |           |           |           |           |
| 10   | 2.6797    |           |           |           |           |
| 11   | 2.5158    |           |           |           |           |
| 12   | 2.6242    |           |           |           |           |
| 13   | 2.6057    |           |           |           |           |
| 14   | 2.8669    |           |           |           |           |
| 15   | 2.5606    |           |           |           |           |
| 16   | 2.5606    | 3.3532    | 3.9438    | 3.7151    | 3.8104    |
| 17   | 2.9424    |           |           |           |           |
| 20   | 2.2805    |           |           |           |           |
| 21   | 1.9456    |           |           |           |           |
| 22   | 2.1085    |           |           |           |           |
| 23   | 1.9376    | 2.95      | 3.1121    | 3.0483    | 2.7816    |
| 24   | 2.9313    | 2.2731    | 3.5627    | 3.1245    | 2.9235    |
| Max  | 3.1626    | 3.3532    | 3.9438    | 3.7151    | 3.8104    |
| Min  | 1.9376    | 2.2731    | 3.1121    | 3.0483    | 2.7816    |
| Avg  | 2.5934    | 2.8588    | 3.5395    | 3.2960    | 3.1718    |

Feederwise Load Information for **All Feeders**

AURANGABAD ZONE[067]

AURANGABAD URBAN II.DIVSION[222]

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

|   |   |
|---|---|
| Feeder No / Name : 401 / Lupin (Gade Jalgaon<br>Shendre M Feeder KV- 33 /<br>OUTGOING | NON SHEDDABLE EXPRESS HV FEEDERS<br>(CONTINUOUS PROCESS)(NO STAGGERING) |
|---|---|

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4289    |           |           |           |           |           |
| 2    | 1.4861    |           |           |           |           |           |
| 3    | 1.3146    |           |           |           |           |           |
| 4    | 1.3146    |           |           |           |           |           |
| 5    | 1.3146    |           |           |           |           |           |
| 6    | 1.2574    |           |           |           |           |           |
| 7    | 1.0288    |           |           |           |           |           |
| 8    | .9717     |           |           |           |           |           |
| 9    | 1.086     |           |           |           |           |           |
| 10   | .9717     |           |           |           |           |           |
| 11   | 1.0288    |           |           |           |           |           |
| 12   | .9717     |           |           |           |           |           |
| 13   | 1.0288    |           |           |           |           |           |
| 14   | .9145     |           |           |           |           |           |
| 15   | .9145     |           |           |           |           |           |
| 16   | .9145     | 2.1285    | 2.0936    | 2.2862    | 2.1148    | 2.0005    |
| 17   | .9717     |           |           |           |           |           |
| 18   | .8402     |           |           |           |           |           |
| 19   | .8573     |           |           |           |           |           |
| 20   | .8402     |           |           |           |           |           |
| 21   | .8573     |           |           |           |           |           |
| 22   | .8402     |           |           |           |           |           |
| 23   | .7842     | 1.829     | 1.6975    | 1.7147    | 1.6004    | 1.7364    |
| 24   | 1.5432    | .8402     | 1.6575    | 1.4861    | 2.1719    | 1.5432    |
| Max  | 1.5432    | 2.1285    | 2.0936    | 2.2862    | 2.1719    | 2.0005    |
| Min  | .7842     | .8402     | 1.6575    | 1.4861    | 1.6004    | 1.5432    |
| Avg  | 1.0617    | 1.5992    | 1.8162    | 1.829     | 1.9624    | 1.7600    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 402 / Pannalalnagar

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1783     |           |           |           |           |           |
| 2    | .1578     |           |           |           |           |           |
| 3    | .1132     |           |           |           |           |           |
| 4    | .1132     |           |           |           |           |           |
| 5    | .1097     |           |           |           |           |           |
| 6    | .1097     |           |           |           |           |           |
| 7    | .16       |           |           |           |           |           |
| 8    | .1646     |           |           |           |           |           |
| 9    | .3155     |           |           |           |           |           |
| 10   | .3761     |           |           |           |           |           |
| 11   | .5601     |           |           |           |           |           |
| 12   | .5601     |           |           |           |           |           |
| 13   | .5601     |           |           |           |           |           |
| 14   | .5601     |           |           |           |           |           |
| 15   | .5601     |           |           |           |           |           |
| 16   | .5601     | .5601     | .6161     | .6161     | .5601     | .5601     |
| 17   | .5601     |           |           |           |           |           |
| 18   | .5601     |           |           |           |           |           |
| 19   | .5041     |           |           |           |           |           |
| 20   | .5601     |           |           |           |           |           |
| 21   | .5601     |           |           |           |           |           |
| 22   | .4435     |           |           |           |           |           |
| 23   | .3189     | .3189     | .3681     | .3155     | .2486     | .3258     |
| 24   | .3155     | .3189     | .3018     | .3086     | .3086     | .2543     |
| Max  | .5601     | .5601     | .6161     | .6161     | .5601     | .5601     |
| Min  | .1097     | .3189     | .3018     | .3086     | .2486     | .2543     |
| Avg  | .3742     | .3993     | .4287     | .4134     | .3724     | .3801     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 403 / 33 KV Indogerman

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 5.8162    |           |           |           |           |           |
| 2    | 5.5418    |           |           |           |           |           |
| 3    | 5.3224    |           |           |           |           |           |
| 4    | 5.1029    |           |           |           |           |           |
| 5    | 5.1029    |           |           |           |           |           |
| 6    | 5.9259    |           |           |           |           |           |
| 7    | 5.7613    |           |           |           |           |           |
| 8    | 5.4321    |           |           |           |           |           |
| 9    | 5.2126    |           |           |           |           |           |
| 10   | 5.3212    |           |           |           |           |           |
| 11   | 5.104     |           |           |           |           |           |
| 12   | 5.0497    |           |           |           |           |           |
| 13   | 5.104     |           |           |           |           |           |
| 14   | 5.104     |           |           |           | 6.1454    |           |
| 15   | 5.2126    |           |           |           |           |           |
| 16   | 5.2669    | 5.6516    | 5.5927    | 5.9185    | 5.7613    | 5.7065    |
| 17   | 5.2669    |           |           |           |           |           |
| 18   | 5.5927    |           |           |           |           |           |
| 19   | 6.2723    |           |           |           |           |           |
| 20   | 6.5547    |           |           |           |           |           |
| 21   | 6.4472    |           |           |           |           |           |
| 22   | 6.5701    |           |           |           |           |           |
| 23   | 6.5844    | 6.9136    | 7.0233    | 7.1879    | 7.0233    | 6.8416    |
| 24   | 6.2003    | 6.1454    | 6.31      | 6.5844    | 6.6941    | 6.2443    |
| Max  | 6.5844    | 6.9136    | 7.0233    | 7.1879    | 7.0233    | 6.8416    |
| Min  | 5.0497    | 5.6516    | 5.5927    | 5.9185    | 5.7613    | 5.7065    |
| Avg  | 5.6195    | 6.2369    | 6.3087    | 6.5636    | 6.4060    | 6.2641    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 404 / 33 kV Mhada

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 12.62     |           |           |           |           |           |
| 2    | 12.0165   |           |           |           |           |           |
| 3    | 11.6873   |           |           |           |           |           |
| 4    | 11.4678   |           |           |           |           |           |
| 5    | 12.308    |           |           |           |           |           |
| 6    | 13.5831   |           |           |           |           |           |
| 7    | 14.5073   |           |           |           |           |           |
| 8    | 14.2484   |           |           |           |           |           |
| 9    | 13.3882   |           |           |           |           |           |
| 10   | 12.8944   |           |           |           |           |           |
| 11   | 12.5652   |           |           |           |           |           |
| 12   | 12.236    |           |           |           |           |           |
| 13   | 11.6873   |           |           |           |           |           |
| 14   | 12.4554   |           |           |           |           |           |
| 15   | 12.236    |           |           |           |           |           |
| 16   | 12.7298   | 14.1564   | 14.4307   | 14.4856   | 14.6502   | 13.6626   |
| 17   | 13.1139   |           |           |           |           |           |
| 18   | 13.3031   |           |           |           |           |           |
| 19   | 15.6379   |           |           |           |           |           |
| 20   | 16.3512   |           |           |           |           |           |
| 21   | 14.9794   |           |           |           |           |           |
| 22   | 14.9794   |           |           |           |           |           |
| 23   | 14.5405   | 15.2538   | 15.1989   | 15.4733   | 15.4733   | 14.7051   |
| 24   | 13.3882   | 13.6626   | 13.8272   | 14.1015   | 14.1015   | 13.8272   |
| Max  | 16.3512   | 15.2538   | 15.1989   | 15.4733   | 15.4733   | 14.7051   |
| Min  | 11.4678   | 13.6626   | 13.8272   | 14.1015   | 14.1015   | 13.6626   |
| Avg  | 13.2885   | 14.3576   | 14.4856   | 14.6868   | 14.7417   | 14.0650   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 405 / Empire Mall

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2481     |           |           |           |           |           |
| 2    | .2321     |           |           |           |           |           |
| 3    | .208      |           |           |           |           |           |
| 4    | .192      |           |           |           |           |           |
| 5    | .216      |           |           |           |           |           |
| 6    | .1932     |           |           |           |           |           |
| 7    | 1.2952    |           |           |           |           |           |
| 8    | .2006     |           |           |           |           |           |
| 9    | .156      |           |           |           |           |           |
| 10   | .2972     |           |           |           |           |           |
| 11   | .8139     |           |           |           |           |           |
| 12   | 1.1431    |           |           |           |           |           |
| 13   | 1.1431    |           |           |           |           |           |
| 14   | 1.5432    |           |           |           |           |           |
| 15   | 1.5432    |           |           |           |           |           |
| 16   | 1.6004    | 1.3717    | 1.6575    | 1.7718    | 1.9433    | 1.8861    |
| 17   | 1.7147    |           |           |           |           |           |
| 18   | 1.8861    |           |           |           |           |           |
| 19   | 1.9433    |           |           |           |           |           |
| 20   | 1.9433    |           |           |           |           |           |
| 21   | 1.8861    |           |           |           |           |           |
| 22   | 1.4563    |           |           |           |           |           |
| 23   | .4321     | .3681     | .3601     | .4001     | .3601     | .4733     |
| 24   | .2961     | .2881     | .2641     | .2961     | .2881     | .2955     |
| Max  | 1.9433    | 1.3717    | 1.6575    | 1.7718    | 1.9433    | 1.8861    |
| Min  | .156      | .2881     | .2641     | .2961     | .2881     | .2955     |
| Avg  | .9410     | .6760     | .7606     | .8227     | .8638     | .8850     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 201 / 11 KV LAXMI NGR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.1098    | 2.3815    | 2.2862    | 2.4768    | 2.2862    | 2.6139    | 2.3815    |
| 2    | 2.1285    | 2.3624    | 2.2862    | 2.4768    | 2.2862    | 2.4272    | 2.3624    |
| 3    | 2.0911    | 2.3243    | 2.2672    | 2.3815    | 2.2481    | 2.4272    | 2.3624    |
| 4    | 2.0538    | 2.3434    | 2.3815    | 2.3815    | 2.2481    | 2.4832    | 2.3815    |
| 5    | 2.0538    | 2.4006    | 2.4768    | 2.2862    | 2.3815    | 2.6139    | 2.4768    |
| 6    | 2.0538    | 2.6673    | 2.4768    | 2.7054    | 2.4768    | 2.726     | 2.572     |
| 7    | 2.3339    | 2.7816    | 2.5339    | 2.8578    | 2.6673    | 2.8006    | 2.5911    |
| 8    | 2.3525    | 2.7625    | 2.4832    | 2.7625    | 2.5911    | 2.894     | 2.4577    |
| 9    | 2.2965    | 2.6699    | 2.1285    | 2.3899    | 2.2405    | 2.4272    | 2.2218    |
| 10   | 2.2405    | 2.6139    | 2.0538    | 2.2032    | 2.0538    | 2.1285    | 1.9418    |
| 11   | 2.2032    | 2.5393    | 1.8671    | 1.6804    | 1.9044    | 1.7924    | 1.9791    |
| 12   | 2.0538    | 1.9418    | 1.9044    | 1.9978    | 1.9605    | 1.7737    | 1.8298    |
| 13   | 2.1472    | 1.9791    | 1.8111    | 1.8671    | 1.7924    | 1.7551    | 1.7551    |
| 14   | 2.0538    | 1.9231    | 1.8484    | 1.9605    | 1.7924    | 1.7551    | 1.6804    |
| 15   | 2.0538    | 2.0351    | 1.9605    | 2.0538    | 1.7364    | 1.9044    | 1.9605    |
| 16   | 2.0538    | 1.9605    | 2.0165    | 1.9044    | 1.7737    | 1.9044    | 1.8671    |
| 17   | 2.191     | 1.7718    | 2.0957    | 2.0957    | 1.8671    | 1.9052    |           |
| 18   | 2.2862    | 1.0098    | 2.3815    | 2.2862    | 2.0165    | 2.0767    |           |
| 19   | 2.6673    | 2.4958    | 2.8578    | 2.5149    | 2.2405    | 2.4387    | 2.8753    |
| 20   | 2.8578    | 2.5149    | 2.8959    | 2.7244    | 2.7633    | 2.6101    | 2.838     |
| 21   | 2.7625    | 2.4577    | 2.8197    | 2.572     | 2.8006    | 2.5339    | 2.8006    |
| 22   | 2.7435    | 2.572     | 2.8578    | 2.6482    | 2.8006    | 2.6292    | 2.7073    |
| 23   | 2.6292    | 2.4768    | 2.7816    | 2.6673    | 2.838     | 2.6482    | 2.6139    |
| 24   | 2.3339    | 2.4768    | 2.4196    | 2.572     | 2.4387    | 2.6139    | 2.4196    |
| Max  | 2.8578    | 2.7816    | 2.8959    | 2.8578    | 2.838     | 2.894     | 2.8753    |
| Min  | 2.0538    | 1.0098    | 1.8111    | 1.6804    | 1.7364    | 1.7551    | 1.6804    |
| Avg  | 2.2813    | 2.3109    | 2.3288    | 2.3528    | 2.2585    | 2.3284    | 2.3216    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 202 / 11 KV MORESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.0911    | 2.1719    | 2.2862    | 2.191     | 2.1719    | 2.4272    | 2.3815    |
| 2    | 2.0538    | 2.1338    | 2.2862    | 2.0957    | 2.1719    | 2.3899    | 2.2862    |
| 3    | 1.9231    | 2.0576    | 2.3243    | 2.0957    | 2.1338    | 2.3712    | 2.2862    |
| 4    | 1.9044    | 2.0005    | 2.3815    | 2.0005    | 2.0957    | 2.2405    | 2.191     |
| 5    | 1.8484    | 1.8671    | 2.0957    | 1.9052    | 2.0576    | 2.1472    | 2.0957    |
| 6    | 1.7737    | 2.0386    | 2.0957    | 2.0957    | 2.0576    | 2.1098    | 2.0005    |
| 7    | 1.9044    | 2.0005    | 2.0767    | 2.0957    | 1.9814    | 2.0725    | 1.9433    |
| 8    | 1.7177    | 1.7909    | 1.8484    | 1.8861    | 1.6956    | 1.9791    | 1.9052    |
| 9    | 1.7177    | 1.6804    | 1.7177    | 1.6804    | 1.6057    | 1.7551    | 1.5684    |
| 10   | 1.6991    | 1.5123    | 1.6617    | 1.587     | 1.4003    | 1.7364    | 1.6244    |
| 11   | 1.6804    | 1.5123    | 1.587     | 1.531     | 1.419     | 1.4563    | 1.587     |
| 12   | 1.6244    | 1.475     | 1.4563    | 1.419     | 1.475     | 1.4377    | 1.531     |
| 13   | 1.5684    | 1.643     | 1.5497    | 1.6057    | 1.419     | 1.4937    | 1.5497    |
| 14   | 1.5684    | 1.8484    | 1.5684    | 1.6804    | 1.475     | 1.5123    | 1.5684    |
| 15   | 1.587     | 1.9418    | 1.7177    | 1.7551    | 1.8484    | 1.6244    | 1.6991    |
| 16   | 1.7924    | 1.7551    | 1.7924    | 1.587     | 1.7737    | 1.643     | 1.7177    |
| 17   | 1.7718    | 1.7718    | 1.7718    | 1.7147    | 1.8298    | 1.7147    |           |
| 18   | 1.829     | 1.7528    | 2.21      | 1.8099    | 1.8671    | 1.7528    | 1.7737    |
| 19   | 2.0386    | 2.2672    | 2.3053    | 2.1719    | 2.3152    | 2.1148    | 1.8298    |
| 20   | 2.191     | 2.4006    | 2.4006    | 2.4196    | 2.3525    | 2.21      | 2.2032    |
| 21   | 2.21      | 2.3243    | 2.3815    | 2.4387    | 2.3712    | 2.2291    | 2.3712    |
| 22   | 2.191     | 2.4577    | 2.4768    | 2.5339    | 2.4832    | 2.4006    | 2.4272    |
| 23   | 2.553     | 2.3815    | 2.4958    | 2.6101    | 2.6886    | 2.5911    | 2.4646    |
| 24   | 2.3525    | 2.4387    | 2.3815    | 2.4387    | 2.3434    | 2.4646    | 2.3815    |
| Max  | 2.553     | 2.4577    | 2.4958    | 2.6101    | 2.6886    | 2.5911    | 2.4646    |
| Min  | 1.5684    | 1.475     | 1.4563    | 1.419     | 1.4003    | 1.4377    | 1.531     |
| Avg  | 1.8996    | 1.9677    | 2.0362    | 1.9729    | 1.9597    | 1.9948    | 1.9733    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 203 / 11 KV RENUKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8589     | .9526     | .9907     | .8002     | 1.0098    | .7468     | .9907     |
| 2    | .8402     | .9717     | .9907     | .8002     | 1.0098    | .7095     | .9907     |
| 3    | .8589     | .9145     | .9526     | .7621     | .9717     | .7095     | .9526     |
| 4    | .8402     |           | 1.0098    | .7621     | .9717     | .8402     | .9717     |
| 5    | .9149     | .8002     | 1.105     | .7621     | 1.0479    | .9335     | 1.0479    |
| 6    | 1.1016    | 1.1431    | 1.1812    | .9526     | 1.1431    | .9896     | 1.1431    |
| 7    | 1.1576    | 1.1622    | 1.2955    | 1.105     | 1.2384    | 1.0269    | 1.2193    |
| 8    | 1.1576    | 1.0479    | 1.1016    | .9526     | 1.2765    | .9335     | 1.1431    |
| 9    | 1.0456    | .9896     | 1.0642    | .8962     | 1.1576    | .8775     | 1.0269    |
| 10   | .8775     | .9335     | 1.0269    | .8775     | .9149     | .8589     | 1.0642    |
| 11   | .8589     | .8589     | .8402     | .8589     | .9335     | .8402     | 1.0269    |
| 12   | .8402     | .7468     | .8215     | .8402     | .9522     | .8775     | .9335     |
| 13   | .7842     | .7468     | .8589     | .8589     | 1.0269    | .8402     | .8962     |
| 14   | .7095     | .7282     | .8402     | .8402     | 1.0456    | .8215     | .8589     |
| 15   | .7468     | .8029     | .7655     | .7655     | 1.0269    | .7842     | .8775     |
| 16   | .8029     | .8215     | .7842     | .8962     | 1.0082    | .7655     | .8402     |
| 17   | .8383     | .8954     | .8764     | .9145     | 1.0082    | .8383     |           |
| 18   | .8573     | 1.0098    | .8573     | .9335     | .9709     | .9335     | 1.0269    |
| 19   | .9526     | 1.2384    | .9526     | 1.2193    | 1.0642    | 1.086     | 1.0269    |
| 20   | .9907     | 1.2193    | 1.0479    | 1.3146    | 1.0642    | 1.2003    | 1.0456    |
| 21   | .9526     | 1.2765    | .9907     | 1.2384    | 1.0642    | 1.1812    | .8962     |
| 22   | .9526     | 1.1812    | .9907     | 1.1812    | .9709     | 1.1812    | .9335     |
| 23   | .9907     | 1.1431    | .9526     | 1.105     | .8962     | 1.0479    | .9896     |
| 24   | .9149     | .9717     | 1.0098    | .8573     | 1.086     | .8589     | .9907     |
| Max  | 1.1576    | 1.2765    | 1.2955    | 1.3146    | 1.2765    | 1.2003    | 1.2193    |
| Min  | .7095     | .7282     | .7655     | .7621     | .8962     | .7095     | .8402     |
| Avg  | .9102     | .9807     | .9711     | .9373     | 1.0358    | .9118     | .9953     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 204 / 11 KV DEOGIRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3921     | .381      | .4382     | .381      | .4001     | .4294     | .4001     |
| 2    | .3921     | .381      | .4191     | .381      | .4001     | .3921     | .4001     |
| 3    | .3734     | .362      | .4191     | .381      | .381      | .3734     | .381      |
| 4    | .3361     | .3429     | .4382     | .381      | .362      | .3361     | .381      |
| 5    | .3361     | .3429     | .381      | .381      | .362      | .3547     | .362      |
| 6    | .3174     | .381      | .362      | .381      | .3239     | .3734     | .362      |
| 7    | .3921     | .381      | .362      | .6478     | .3239     | .3734     | .362      |
| 8    | .5041     | .3429     | .3174     | .5335     | .3048     | .4481     | .5415     |
| 9    | .3921     | .2987     | .2614     | .2614     | .2801     | .2987     | .3734     |
| 10   | .2987     | .2614     | .2614     | .2614     | .2801     | .2614     | .2614     |
| 11   | .2801     | .2614     | .2614     | .2427     | .2801     | .2614     | .2614     |
| 12   | .2614     | .2614     | .2801     | .2614     | .2987     | .2614     | .2801     |
| 13   | .2801     | .2801     | .2614     | .2801     | .2987     | .2614     | .2987     |
| 14   | .3174     | .2987     | .2987     | .2987     | .3174     | .2801     | .3174     |
| 15   | .3174     | .3361     | .3174     | .3174     | .3174     | .2987     | .2987     |
| 16   | .3174     | .2987     | .2801     | .3174     | .3174     | .2801     | .2987     |
| 17   | .3048     | .2858     | .2858     | .3239     | .3174     | .3048     |           |
| 18   | .3429     | .3048     | .381      | .3048     | .3361     | .3429     | .3547     |
| 19   | .4001     | .4001     | .381      | .4001     | .3921     | .4001     | .3734     |
| 20   |           | .4382     |           | .4572     | .4294     | .4191     | .4108     |
| 21   | .4382     | .4382     | .4382     | .4382     | .4481     | .4382     | .4294     |
| 22   | .4191     | .4572     | .4382     | .4572     | .4668     | .4572     | .4294     |
| 23   | .4572     | .4382     | .4572     | .4763     | .4668     | .4572     | .4294     |
| 24   | .4108     | .4191     | .4382     | .4382     | .4572     | .4481     | .4382     |
| Max  | .5041     | .4572     | .4572     | .6478     | .4668     | .4572     | .5415     |
| Min  | .2614     | .2614     | .2614     | .2427     | .2801     | .2614     | .2614     |
| Avg  | .3600     | .3497     | .3556     | .3752     | .3567     | .3563     | .3672     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 201 / 11KV CHETNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.3482    | 2.4348    | 2.6299    | 2.7092    | 2.8366    | 2.894     | 2.6783    |
| 2    | 2.3458    | 2.3663    | 2.5334    | 2.6063    | 2.799     | 2.6513    | 2.2805    |
| 3    | 2.2542    | 2.2634    | 2.3621    | 2.4863    | 2.7239    | 2.5766    | 2.1434    |
| 4    | 2.104     | 2.1434    |           | 2.2634    | 2.4421    | 2.4272    | 2.0233    |
| 5    | 2.0664    | 2.0576    | 2.2144    | 2.1434    | 2.2542    | 2.3339    | 1.989     |
| 6    | 1.9705    | 1.9719    | 2.2895    | 2.0919    | 2.0664    | 2.2405    | 1.9547    |
| 7    | 1.9933    | 1.9547    | 2.3833    | 2.1605    | 2.1603    | 2.3339    | 1.9547    |
| 8    | 2.0538    | 2.0997    | 2.0576    | 2.1956    | 1.9204    | 2.2542    | 2.2405    |
| 9    | 2.2405    | 2.0434    | 1.9204    | 2.1603    | 1.8861    | 2.1227    | 2.4272    |
| 10   | 2.2405    | 2.01      | 1.9719    | 2.104     | 1.9547    | 2.058     | 2.0538    |
| 11   | 2.1472    | 2.0288    | 1.989     | 2.2497    | 2.0233    | 2.0414    | 2.3339    |
| 12   | 2.0538    | 2.0455    | 1.8861    | 2.2519    | 2.0576    | 2.104     | 2.0538    |
| 13   | 2.0538    | 2.1249    | 1.9719    | 2.1979    | 1.9719    | 2.1328    | 2.0538    |
| 14   | 2.0538    | 2.1979    | 2.0576    | 2.1603    | 2.0576    | 2.1603    | 2.2405    |
| 15   | 2.2405    | 2.3482    | 2.1605    | 2.2474    | 2.1262    | 2.273     | 2.2405    |
| 16   | 1.9719    | 2.4746    | 2.2291    | 2.3645    | 2.4272    | 2.1434    | 2.3482    |
| 17   | 1.9719    | 2.3573    | 2.0576    | 2.327     | 2.5206    | 2.0233    |           |
| 18   | 2.2634    | 2.4021    | 2.0576    | 2.3434    | 2.5206    | 2.0576    | 2.3833    |
| 19   | 2.332     | 2.9058    | 2.572     | 2.897     | 3.0247    | 2.3663    |           |
| 20   | 2.3663    | 2.9747    | 2.6578    | 2.9117    | 3.0807    | 2.6406    | 2.7051    |
| 21   | 2.4006    | 2.9681    | 2.7092    | 2.9523    | 2.9874    | 2.6578    | 2.799     |
| 22   | 2.5206    | 2.9681    | 2.7778    | 3.0463    | 3.0807    | 2.6406    | 2.8929    |
| 23   | 2.6749    | 2.7614    | 2.8121    | 2.956     | 3.2114    | 2.6063    | 2.9681    |
| 24   | 2.7933    | 2.572     | 2.6085    | 2.7778    | 2.8583    | 3.1367    | 2.572     |
| Max  | 2.7933    | 2.9747    | 2.8121    | 3.0463    | 3.2114    | 3.1367    | 2.9681    |
| Min  | 1.9705    | 1.9547    | 1.8861    | 2.0919    | 1.8861    | 2.0233    | 1.9547    |
| Avg  | 2.2276    | 2.3531    | 2.3004    | 2.4418    | 2.4580    | 2.3699    | 2.3335    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 204 / 11 KV PAITHAN GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.9935    | 2.915     | 3.1935    | 3.0007    | 3.2874    | 3.3981    | 3.2236    |
| 2    | 2.9029    | 2.8121    |           | 2.915     | 3.1935    | 3.3608    | 3.1207    |
| 3    | 2.9029    | 2.7778    | 3.0056    | 2.8292    | 3.0996    | 3.3608    | 3.0178    |
| 4    | 2.8554    | 2.7778    | 2.9995    | 2.8464    | 3.0996    | 3.2674    | 2.9835    |
| 5    | 2.8178    | 2.8121    |           | 2.8635    | 3.1371    | 3.2674    | 2.915     |
| 6    | 2.7802    | 2.8292    | 3.0996    | 2.915     | 3.2123    | 3.1741    | 2.8807    |
| 7    | 2.9681    | 2.8292    | 3.2874    | 2.9492    | 3.2686    | 3.3981    | 2.8807    |
| 8    | 2.9874    | 3.1371    | 2.9664    | 3.1747    | 2.915     | 3.3284    | 3.2674    |
| 9    | 3.2674    | 3.218     | 3.0521    | 3.2874    | 2.915     | 3.3029    | 3.4541    |
| 10   | 3.1741    | 3.3149    | 3.2407    | 3.4001    | 3.155     | 3.4753    | 3.2114    |
| 11   | 3.1367    | 3.3813    | 3.4637    | 3.4238    | 3.3608    | 3.6443    | 3.5475    |
| 12   | 3.0807    | 3.412     | 3.3608    | 3.4718    | 3.2579    | 3.6219    | 3.4541    |
| 13   | 2.9874    | 3.5316    | 3.3779    | 3.5692    | 3.3093    | 3.6219    | 3.2674    |
| 14   | 2.95      | 3.6406    | 3.3951    | 3.6406    | 3.1893    | 3.6104    | 3.4541    |
| 15   | 3.0247    | 3.6594    | 3.3608    | 3.7233    | 3.4979    | 3.6256    | 3.5101    |
| 16   | 2.7092    | 3.6744    | 3.3779    | 3.7567    | 3.8275    | 3.2579    | 3.3863    |
| 17   | 2.7778    | 3.5316    | 3.2922    | 3.6819    | 3.8275    | 3.1207    | 3.3813    |
| 18   | 3.2579    | 3.6031    | 3.3265    | 3.7571    | 3.8275    | 3.4637    | 3.2123    |
| 19   | 3.1722    | 4.0078    | 3.6694    | 4.0973    | 4.2943    | 3.7209    |           |
| 20   | 3.1893    | 4.0827    | 3.6866    | 4.0869    | 4.2943    | 4.0295    | 4.0388    |
| 21   | 3.1893    | 3.9449    | 3.5665    | 3.851     | 4.0143    | 3.8066    | 3.7758    |
| 22   | 3.2236    | 3.7571    | 3.4637    | 3.6856    | 3.9209    | 3.6008    | 3.6443    |
| 23   | 3.275     | 3.4753    | 3.3779    | 3.4753    | 3.8275    | 3.3951    | 3.4753    |
| 24   | 4.5699    | 3.1722    | 3.2774    | 3.2922    | 3.3455    | 3.6408    | 3.2579    |
| Max  | 4.5699    | 4.0827    | 3.6866    | 4.0973    | 4.2943    | 4.0295    | 4.0388    |
| Min  | 2.7092    | 2.7778    | 2.9664    | 2.8292    | 2.915     | 3.1207    | 2.8807    |
| Avg  | 3.0914    | 3.3457    | 3.3110    | 3.4039    | 3.4616    | 3.4789    | 3.3200    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 206 / 11 KV DEVA NAGARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9537    | 1.5775    | 1.747     | 1.8004    | 1.9161    | 1.9605    | 1.749     |
| 2    | 1.8034    | 1.5432    |           | 1.6289    | 1.8597    | 1.8671    | 1.6289    |
| 3    | 1.6343    | 1.5089    |           | 1.5432    | 1.6907    | 1.7737    | 1.5089    |
| 4    | 1.4103    | 1.406     | 1.4075    | 1.4575    | 1.5748    | 1.6804    | 1.406     |
| 5    | 1.1835    | 1.3032    | 1.2398    | 1.5089    | 1.4653    | 1.4937    | 1.3032    |
| 6    | 1.126     | 1.286     | 1.1835    | 1.286     | 1.3123    | 1.307     | 1.2003    |
| 7    | 1.2586    | 1.2689    | 1.2774    | 1.2174    | 1.3525    | 1.307     | 1.1831    |
| 8    | 1.2696    | 1.3297    | 1.3546    | 1.2962    | 1.6289    | 1.315     | 1.3443    |
| 9    | 1.307     | 1.315     | 1.2689    | 1.3525    | 1.5775    | 1.3525    | 1.4003    |
| 10   | 1.3443    | 1.2962    | 1.4335    | 1.3525    | 1.4403    | 1.2962    | 1.4003    |
| 11   | 1.3817    | 1.2411    | 1.3717    | 1.3525    | 1.2346    | 1.2198    | 1.4563    |
| 12   | 1.3443    | 1.2398    | 1.3032    | 1.315     | 1.286     | 1.2962    | 1.4003    |
| 13   | 1.307     | 1.2962    | 1.2517    | 1.3525    | 1.2689    |           | 1.307     |
| 14   | 1.307     | 1.3498    | 1.2003    | 1.4089    | 1.3032    | 1.4089    | 1.2696    |
| 15   | 1.307     | 1.4089    | 1.2517    | 1.5764    | 1.3717    | 1.4089    | 1.4937    |
| 16   | 1.2346    | 1.4653    | 1.3032    | 1.6155    | 1.4937    | 1.3203    | 1.3699    |
| 17   | 1.2689    | 1.3901    | 1.3375    | 1.5028    | 1.4563    | 1.3032    | 1.3525    |
| 18   | 1.5089    | 1.3525    | 1.406     | 1.4653    | 1.3443    | 1.3717    | 1.315     |
| 19   | 1.5432    | 1.6514    | 1.6289    | 1.6327    | 1.7737    | 1.5775    |           |
| 20   | 1.5775    | 1.747     | 1.749     | 1.6907    | 1.7737    | 1.749     | 1.6293    |
| 21   | 1.5775    | 1.8034    | 1.7833    | 1.8016    | 1.7737    | 1.7833    | 1.5373    |
| 22   | 1.6461    | 1.8597    | 1.8004    | 1.8785    | 1.8671    | 1.8004    | 1.747     |
| 23   | 1.7147    | 1.9161    | 1.8176    | 1.9497    | 2.0538    | 1.8004    | 1.9161    |
| 24   | 1.4089    | 1.6289    | 1.8597    | 1.8519    | 1.9725    | 2.0538    | 2.4691    |
| Max  | 1.9537    | 1.9161    | 1.8597    | 1.9497    | 2.0538    | 2.0538    | 2.4691    |
| Min  | 1.126     | 1.2398    | 1.1835    | 1.2174    | 1.2346    | 1.2198    | 1.1831    |
| Avg  | 1.4341    | 1.4660    | 1.4535    | 1.5349    | 1.5746    | 1.5412    | 1.4951    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 201 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3881     | .4904     | .5093     | .4904     | .4668     | .499      | .3734     |
| 2    | .3696     | .4715     | .4904     | .4527     | .4108     | .4668     | .3547     |
| 3    | .3696     | .4527     | .4715     | .415      | .4481     | .462      | .4108     |
| 4    | .4294     | .4527     | .4715     | .4294     | .4668     | .4854     | .4668     |
| 5    | .4294     | .5093     | .5041     | .4854     | .5041     | .499      | .5041     |
| 6    | .4294     | .547      | .5658     | .5281     | .5415     | .5601     | .5228     |
| 7    | .499      | .5658     | .6413     | .6224     | .5601     | .5975     | .5415     |
| 8    | .5601     | .5847     | .6413     | .5658     | .5601     | .5975     | .5415     |
| 9    | .6161     | .547      | .5658     | .5281     | .5601     | .5914     | .5041     |
| 10   | .547      | .5041     | .5658     | .5415     | .4854     | .5975     | .499      |
| 11   | .6036     | .5544     | .5788     | .5975     | .4904     | .5658     | .5788     |
| 12   | .6224     | .5601     | .5601     | .6161     | .6413     | .6036     | .5175     |
| 13   | .547      | .5544     | .5228     | .5788     | .6224     | .5847     | .5359     |
| 14   | .5281     | .5729     | .5359     | .5975     | .6224     | .5601     | .5544     |
| 15   | .6036     | .5544     | .6161     | .5788     | .6224     | .5658     | .5175     |
| 16   | .5281     | .5788     | .6348     | .6161     | .6224     | .5975     | .5175     |
| 17   | .547      | .6602     | .6283     | .6722     | .5544     | .5601     |           |
| 18   | .6224     | .6036     | .5975     | .6908     | .6535     | .6161     | .5847     |
| 19   | .6224     | .6413     | .6283     | .6722     | .6535     | .6535     | .6413     |
| 20   | .6602     | .7167     | .6161     | .6908     | .6535     | .6722     | .6348     |
| 21   | .5975     | .6348     | .5729     | .6535     | .5544     | .6348     | .547      |
| 22   | .5788     | .5847     | .5847     | .5975     | .5415     |           | .547      |
| 23   | .5658     | .5658     | .5847     | .5601     | .5544     |           | .547      |
| 24   | .5041     | .547      | .5281     | .5281     | .5041     | .5359     | .3734     |
| Max  | .6602     | .7167     | .6413     | .6908     | .6535     | .6722     | .6413     |
| Min  | .3696     | .4527     | .4715     | .415      | .4108     | .462      | .3547     |
| Avg  | .5320     | .5606     | .5673     | .5712     | .5539     | .5685     | .5137     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0373     | .0566     | .0566     | .0566     | .0373     | .0554     | .0373     |
| 2    | .0373     | .0566     | .0566     | .0566     | .0373     | .037      | .0373     |
| 3    | .0373     | .0566     | .0566     | .056      | .0373     | .037      | .0373     |
| 4    | .0373     | .0566     | .0566     | .0566     | .056      | .037      | .0373     |
| 5    | .0373     | .056      | .0566     | .0566     | .056      | .056      | .056      |
| 6    | .0373     | .0566     | .0754     | .0747     | .0747     | .0747     | .0747     |
| 7    | .0185     | .0754     | .0754     | .0747     | .0747     | .0747     | .0747     |
| 8    | .0187     | .0754     | .0754     | .0754     | .0747     | .0739     | .0747     |
| 9    | .0185     | .0754     | .0754     | .0754     | .0747     | .0739     | .0747     |
| 10   | .0566     | .056      | .0754     | .0747     | .0566     | .0754     | .0554     |
| 11   | .0566     | .037      | .0554     | .0747     | .0754     | .0754     | .0373     |
| 12   | .0754     | .0373     | .056      |           | .0754     | .0754     | .0373     |
| 13   | .0566     | .037      | .056      | .056      | .0754     | .0566     | .0554     |
| 14   | .0377     | .0373     |           | .0747     | .0754     | .0566     | .0739     |
| 15   | .056      | .0747     | .056      | .0747     | .0747     | .0754     | .0739     |
| 16   | .0566     | .0739     | .0747     | .0747     | .0754     | .0754     | .0739     |
| 17   | .0566     | .0754     | .0747     | .0747     | .0739     | .0747     |           |
| 18   | .0566     | .0754     | .0747     | .0747     | .0739     | .0747     | .0754     |
| 19   | .0566     | .0754     | .0739     | .0747     | .0934     | .0747     | .0754     |
| 20   | .0566     | .0943     | .0924     | .0747     | .0739     | .0747     | .0754     |
| 21   | .0377     | .0754     | .0747     | .0747     | .0739     | .0747     | .0747     |
| 22   | .0566     | .0566     | .0566     | .056      | .056      |           | .0566     |
| 23   | .0566     | .0566     | .0566     | .056      | .0554     |           | .0566     |
| 24   | .056      | .0566     | .0566     | .0566     | .0373     |           | .0373     |
| Max  | .0754     | .0943     | .0924     | .0754     | .0934     | .0754     | .0754     |
| Min  | .0185     | .037      | .0554     | .056      | .0373     | .037      | .0373     |
| Avg  | .0462     | .0618     | .0660     | .0676     | .0654     | .0659     | .0592     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 203 / 11 KV CHANAKYAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3256    | 1.4146    | 1.1317    | 1.3957    | 1.4003    | 1.4377    | 1.4937    |
| 2    | 1.2883    | 1.3957    | 1.094     | 1.307     | 1.307     | 1.4045    | 1.4003    |
| 3    | 1.1576    | 1.3203    | 1.1128    | 1.2449    | 1.3443    | 1.2936    | 1.307     |
| 4    | 1.1203    | 1.2696    | 1.1694    | 1.1763    | 1.3256    | 1.2567    | 1.1389    |
| 5    | 1.1763    | 1.3014    | 1.226     | 1.1949    | 1.3256    | 1.2012    | 1.2136    |
| 6    | 1.1763    | 1.3392    | 1.2449    | 1.226     | 1.307     | 1.2696    | 1.2883    |
| 7    | 1.2136    | 1.3817    | 1.3769    | 1.3392    | 1.3817    | 1.3817    | 1.3256    |
| 8    | 1.4003    | 1.4712    | 1.3957    | 1.363     | 1.419     | 1.3817    | 1.2696    |
| 9    | 1.3256    | 1.4901    | 1.4335    | 1.4377    | 1.4377    | 1.4415    | 1.3443    |
| 10   | 1.4712    | 1.4415    | 1.3769    | 1.4003    | 1.6032    | 1.5123    | 1.4969    |
| 11   | 1.4523    | 1.386     | 1.3817    | 1.4563    | 1.4901    | 1.5278    | 1.475     |
| 12   | 1.4146    | 1.4563    | 1.3256    | 1.4377    | 1.358     | 1.3957    | 1.3443    |
| 13   | 1.3769    | 1.5123    | 1.363     | 1.4377    | 1.4712    | 1.3014    | 1.4045    |
| 14   | 1.3203    | 1.4003    | 1.363     | 1.475     | 1.419     | 1.4335    | 1.4045    |
| 15   | 1.358     | 1.475     |           | 1.5123    | 1.4146    | 1.475     | 1.4784    |
| 16   | 1.363     | 1.4045    | 1.5524    | 1.4937    | 1.4712    | 1.4901    | 1.423     |
| 17   | 1.3392    | 1.3957    | 1.5497    | 1.4937    | 1.5154    | 1.531     |           |
| 18   | 1.4901    | 1.4523    | 1.4563    | 1.587     | 1.4784    | 1.4937    | 1.094     |
| 19   | 1.5655    | 1.5844    | 1.5524    | 1.8111    | 1.7187    | 1.7177    | 1.4523    |
| 20   | 1.587     | 1.6598    | 1.6078    | 1.7364    | 1.7002    | 1.7364    | 1.3769    |
| 21   | 1.5655    | 1.6409    | 1.5708    | 1.6804    | 1.6632    | 1.6617    | 1.358     |
| 22   | 1.531     | 1.6598    | 1.5466    | 1.6057    | 1.6804    |           | 1.6787    |
| 23   | 1.5466    | 1.6221    | 1.6991    | 1.531     | 1.7002    |           | 1.6032    |
| 24   | 1.4563    | 1.5278    | 1.5466    | 1.6598    | 1.4937    |           | 1.6244    |
| Max  | 1.587     | 1.6598    | 1.6991    | 1.8111    | 1.7187    | 1.7364    | 1.6787    |
| Min  | 1.1203    | 1.2696    | 1.094     | 1.1763    | 1.307     | 1.2012    | 1.094     |
| Avg  | 1.3759    | 1.4584    | 1.3946    | 1.4585    | 1.4761    | 1.4450    | 1.3911    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 204 / 11 KV MUTHA COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9709     | 1.094     | 1.2071    | 1.0562    | .8402     | 1.0642    | .9335     |
| 2    | .8962     | 1.0456    | 1.1317    | .9335     | .7842     | .9979     | .8402     |
| 3    | .8589     | 1.0185    | 1.0562    | .9054     | .8589     | .961      | .8775     |
| 4    | .8589     | .9808     | .9619     | .9054     | .9335     | .9522     | .9149     |
| 5    | .8962     | 1.0562    | .9431     | .9808     | 1.0642    | .9522     | .9709     |
| 6    | .9709     | 1.1317    | .9997     | 1.0374    | 1.1576    | 1.0456    | 1.0269    |
| 7    | 1.0829    | 1.1643    | 1.1128    | 1.0562    | 1.2136    | .9979     | 1.0642    |
| 8    | 1.0269    | 1.0185    | .9808     | .9431     | 1.0456    | .9979     | 1.0456    |
| 9    |           | .8488     | .8488     | .8589     | 1.0082    | .924      | .9335     |
| 10   | .8488     | .7577     | .7545     | .8029     | .7167     | .7922     | .7947     |
| 11   | .8676     | .7947     | .7164     | .7842     | .7545     | .7545     | .8029     |
| 12   | .8676     | .8402     | .6535     | .8402     | .7356     | .7545     |           |
| 13   | .7733     | .8589     | .7655     | .8215     | .7733     | .6979     | .7392     |
| 14   | .8488     | .8215     | .8029     | .8215     | .811      | .7922     | .7947     |
| 15   | .8488     | .8589     | .8402     | .9149     | .9054     | .7922     | .8131     |
| 16   | .8962     | .8316     | .8131     | .9149     | .8488     | .811      | .8131     |
| 17   | .8676     | .811      | .8402     | .9149     | .8402     | .8402     |           |
| 18   | .8775     | .7167     | .8775     | 1.0829    | .8501     | .9522     |           |
| 19   | .9997     | 1.0456    | 1.0349    | 1.1576    | 1.0534    |           |           |
| 20   | 1.0562    | 1.094     | 1.0829    | 1.2136    | 1.0719    | 1.1016    | 1.0562    |
| 21   | 1.0562    | 1.094     | 1.0082    | 1.1203    | 1.1088    | 1.1203    | 1.1317    |
| 22   | 1.1389    | 1.1317    | 1.1506    | 1.1016    | 1.1273    |           | 1.0829    |
| 23   | 1.2071    | 1.1949    | 1.226     | 1.0269    | 1.2136    |           | 1.1016    |
| 24   | 1.1203    | 1.1506    | 1.1506    | 1.1506    | .9335     |           | .9896     |
| Max  | 1.2071    | 1.1949    | 1.226     | 1.2136    | 1.2136    | 1.1203    | 1.1317    |
| Min  | .7733     | .7167     | .6535     | .7842     | .7167     | .6979     | .7392     |
| Avg  | .9494     | .9734     | .9566     | .9727     | .9438     | .9151     | .9363     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 205 / 11 KV SUHAS COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0456    | 1.0562    | 1.1694    | 1.1317    | .9335     | 1.0719    | .9335     |
| 2    | .9335     | 1.0185    | 1.1317    | 1.0751    | .9522     | 1.0269    | .8962     |
| 3    | .7888     | .9619     | 1.0185    | 1.0562    | .9709     | .9709     | .9149     |
| 4    | .8402     | .9431     | .9431     | 1.0374    | 1.0082    | .9795     | .9522     |
| 5    | .8962     | .9808     | .9619     | 1.0185    | 1.0269    | .9335     | .9709     |
| 6    | .9335     | .9997     | .9808     | 1.0185    | 1.0829    | .9522     | .9896     |
| 7    | .9522     | 1.0751    | 1.0374    | 1.0374    | 1.0269    | .9522     | .9896     |
| 8    | .9335     | .8865     | .9619     | .8865     | .8962     | .8775     | .8962     |
| 9    | .8316     | .8299     | .811      | .8676     | .8589     | .8029     | .8215     |
| 10   | .8029     | .7762     | .7733     | .8029     | .8299     | .7655     | .7947     |
| 11   | .8299     | .8316     | .7947     | .8029     | .8865     | .7922     | .8775     |
| 12   | .8299     | .8589     | .7842     | .8589     | .8676     | .8029     | .8589     |
| 13   | .8488     | .8775     | .8029     | .8589     | .8775     | .7922     | .8131     |
| 14   | .9242     | .8215     | .8402     | .8962     | .9242     | .8676     | .9425     |
| 15   | .9242     | .8962     | .9335     | .9522     | .9149     | .8962     | .9979     |
| 16   | .9619     | .9335     | .9709     | .9896     | .9242     | .8676     | .924      |
| 17   | .9619     | .9619     | 1.0642    | .9522     | .8871     | .9709     |           |
| 18   | .9431     | .9054     | .8589     | 1.0456    | .9709     | .8962     |           |
| 19   | 1.094     | 1.1128    | 1.0719    | 1.1949    | 1.2136    | 1.0829    |           |
| 20   | 1.1694    | 1.2637    | 1.1763    | 1.1949    | 1.1949    | 1.1389    | 1.4146    |
| 21   | 1.1317    | 1.2637    | 1.1088    | 1.1203    | 1.2136    | 1.1203    | 1.4146    |
| 22   | 1.1317    | 1.358     | 1.1883    | 1.1203    | 1.2197    |           | 1.2637    |
| 23   | 1.2637    | 1.3203    | 1.2071    | 1.0269    | 1.3443    |           | 1.251     |
| 24   | 1.1203    | 1.1389    | 1.251     | 1.1506    | .9335     |           | 1.0269    |
| Max  | 1.2637    | 1.358     | 1.251     | 1.1949    | 1.3443    | 1.1389    | 1.4146    |
| Min  | .7888     | .7762     | .7733     | .8029     | .8299     | .7655     | .7947     |
| Avg  | .9622     | 1.0030    | .9934     | 1.0040    | .9983     | .9315     | .9973     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-18 and 07-APR-18

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 206 / 11 KV GAJANAN MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-APR-18 | 02-APR-18 | 03-APR-18 | 04-APR-18 | 05-APR-18 | 06-APR-18 | 07-APR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.2592    | 2.6029    | 2.6029    | 2.6029    | 2.5579    | 2.9569    | 2.838     |
| 2    | 2.2405    | 2.5086    | 2.452     | 2.5274    | 2.4272    | 2.809     | 2.8006    |
| 3    | 2.0538    | 2.4331    | 2.3954    | 2.4709    | 2.4646    | 2.5873    | 2.6139    |
| 4    | 2.0725    | 2.3525    | 2.3577    | 2.4143    | 2.5206    | 2.4764    | 2.4646    |
| 5    | 2.2032    | 2.4331    | 2.32      | 2.5086    | 2.7073    | 2.347     | 2.5766    |
| 6    | 2.3339    | 2.5652    | 2.5274    | 2.584     | 2.8567    | 2.6326    | 2.6139    |
| 7    | 2.4025    | 2.7726    | 2.5652    | 2.8292    | 2.8006    | 2.6242    | 2.7073    |
| 8    | 2.5579    | 2.6783    | 2.5652    | 2.6783    | 2.5393    | 2.5688    | 2.5953    |
| 9    | 2.4025    | 2.4709    | 2.5086    | 2.5274    | 2.5393    | 2.4394    | 2.5393    |
| 10   | 2.4143    | 2.5766    | 2.5274    | 2.5766    | 2.5652    | 2.6972    | 2.5206    |
| 11   | 2.452     | 2.5133    | 2.6139    | 2.6513    | 2.7161    | 2.6029    | 2.6797    |
| 12   |           | 2.5766    | 2.6139    | 2.5206    | 2.6783    | 2.7349    | 2.4579    |
| 13   | 2.5019    | 2.6139    | 2.6513    | 2.6513    | 2.7726    | 2.6217    | 2.5873    |
| 14   | 2.5086    | 2.4579    | 2.6699    | 2.7446    | 2.7349    | 2.6029    | 2.6427    |
| 15   | 2.5463    | 2.6427    | 2.8006    | 2.838     |           | 2.5652    | 2.7166    |
| 16   | 2.584     | 2.6326    | 2.7721    | 2.8753    |           | 2.6217    | 2.7166    |
| 17   | 2.452     | 2.7726    | 2.8006    | 2.8006    | 3.0308    | 2.8006    |           |
| 18   | 2.5274    | 2.8481    | 2.8567    | 2.9313    | 3.0493    | 2.8193    |           |
| 19   | 3.0744    | 3.3385    | 3.1971    | 3.4355    | 3.4558    | 3.2674    | 2.6595    |
| 20   | 3.1499    | 3.3196    | 3.4168    | 3.6408    | 3.5113    | 3.2861    | 2.584     |
| 21   | 3.1121    | 3.2065    | 3.1417    | 3.5475    | 3.3265    | 3.1554    | 3.3608    |
| 22   | 2.9801    | 3.0367    | 3.0744    | 3.3608    | 3.0862    |           | 3.3981    |
| 23   | 2.9424    | 2.9613    | 2.9801    | 2.8006    | 3.0493    |           | 3.1687    |
| 24   | 2.6139    | 2.7446    | 2.6595    | 2.8104    | 2.6139    |           | 2.8006    |
| Max  | 3.1499    | 3.3385    | 3.4168    | 3.6408    | 3.5113    | 3.2861    | 3.3981    |
| Min  | 2.0538    | 2.3525    | 2.32      | 2.4143    | 2.4272    | 2.347     | 2.4579    |
| Avg  | 2.5385    | 2.7108    | 2.7113    | 2.8053    | 2.8184    | 2.7246    | 2.7292    |