

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 201 / 11 KV LOHARISAWANGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3887	.426	.3932	.3563	.3605	.3441
2		.3887	.426	.3932	.3563	.3605	.3277
3		.3887	.4096	.3932	.3239	.3277	.3277
4		.3887	.4096	.3605	.3239	.3277	.3113
5		.3239	.3605	.3605	.3239	.2949	.2949
6		.2753	.3113	.2949	.2753	.2785	.2458
7	.2267	.2105	.213	.1966	.2105	.213	.1966
8	.1619	.1781	.1802	.1638	.1619	.1638	.1638
9	.0972	.1619	.213	.1802	.1844	.1638	.1475
10	.0972	.1311	.1311	.1966	.1677	.1638	.1311
11	.0983	.1311	.1311	.1943	.1638	.1475	.0972
12	.0983	.1311	.1311	.1619	.1638	.1311	.0972
13	.0983	.1311	.1311	.1619	.1638	.1475	.081
14	.0983	.1147	.1147	.1619	.1638	.1311	.0972
15	.0983	.1147	.1311	.1619	.1311	.1311	.1006
16	.0983	.1475	.1311	.1619	.1311	.1147	.1006
17	.0983	.1311	.1147	.1296	.1311	.1147	.0671
18	.1296	.2294	.1966	.1943	.1638	.1638	.1677
19	.2267	.2458	.2294	.2267	.2294	.2458	.218
20	.3887	.3605	.3605	.3688	.3113	.3113	.2543
21	.421	.426	.3932	.3887	.3441	.3277	.2515
22	.421	.4424	.426	.3887	.3768	.3605	.2883
23	.4049	.4424	.4096	.4049	.3768	.3605	.2683
24		.4049	.4424	.4096	.3887	.3768	.3441
Max	.421	.4424	.4424	.4096	.3887	.3768	.3441
Min	.0972	.1147	.1147	.1296	.1311	.1147	.0671
Avg	.1919	.2620	.2676	.2687	.2468	.2383	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 202 / 11 KV LOHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2105	.213	.213	.2012	.1802	.1802
2		.2105	.213	.1966	.1943	.1802	.1802
3		.2105	.1966	.1966	.1677	.1638	.1638
4		.2105	.1966	.1802	.1677	.1311	.1638
5		.1943	.1638	.1638	.1677	.1311	.1475
6		.1296	.1311	.1311	.1174	.1147	.1311
7		.1134	.0819	.0819	.081	.0983	.0983
8		.0972	.0983	.0819	.0671	.0819	.0819
9		.0648	.0655	.0655	.0838	.0819	.0983
10		.0655	.0983	.1311	.0972	.0983	.0819
11			.0983	.0972	.0983	.0819	.0648
12		.0819	.0983	.081	.0328	.0492	.0486
13	.1475	.0655	.0819	.0972	.0164	.0655	.081
14	.1475	.0819	.0655	.1134	.1638	.0655	.0648
15	.1475	.0983	.0655	.1457	.0983	.0655	.1006
16	.1311	.0983	.0819	.1457	.0983	.0655	
17	.1296	.0983	.0819	.1296	.0492	.0492	
18	.0486	.0492	.0655	.0648	.0492	.0655	
19	.1134	.0819	.0983	.081	.0983	.1147	.1174
20	.1943	.1638	.1802	.1943	.1638	.1638	.1357
21	.2267	.1966	.213	.2105	.1802	.1802	.1341
22	.3725	.2294	.2294	.2105	.1802	.1802	.1187
23	.2105	.2294	.2294	.1943	.1802	.1802	.1341
24		.2105	.2294	.213	.1943	.1802	.1802
Max	.3725	.2294	.2294	.213	.2012	.1802	.1802
Min	.0486	.0492	.0655	.0648	.0164	.0492	.0486
Avg	.1699	.1388	.1365	.1425	.1229	.1154	.1194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 203 / 11 KV KHARALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3605	.3605	.3185	.3277	.3277
2		.3239	.3605	.3277	.3185	.3277	.3277
3		.3239	.3277	.3277	.285	.2949	.2949
4		.3239	.2949	.2949	.285	.2949	.2949
5		.2915	.2622	.2622	.2515	.2622	.2622
6		.2267	.2294	.1966	.218	.2294	.2294
7		.1619	.1638	.1475	.1341	.1475	.1475
8		.1296	.1475	.1311	.1174	.1311	.1311
9		.1296	.0983	.1311	.1341	.1147	.1147
10		.1147	.1147	.1638	.1296	.1311	.0983
11	.0164	.1147	.1147	.1296	.1311	.1147	.081
12	.0162	.1147	.1147	.1457	.1311	.1147	.0648
13	.0162	.1147	.1147	.1457	.1147	.1147	.0648
14	.0324	.0983	.0983	.1457	.1475	.1311	.0648
15	.0324	.0983	.1147	.1457	.1147	.1147	.0671
16	.0648	.1311	.1147	.1296	.0983	.0983	.0671
17	.0648	.1147	.0983	.1296	.0983	.0983	.0503
18	.0972	.1311	.1147	.1296	.0983	.1147	.1509
19	.1457	.1802	.1802	.1781	.1638	.1802	.2012
20	.1943	.3277	.3277	.3239	.2949	.2949	.2374
21	.3725	.3932	.3768	.3725	.3113	.3113	.2515
22	.3725	.3932	.3932	.3725	.3277	.3277	.2543
23	.3401	.3932	.3768	.3401	.3277	.3277	.2515
24		.3239	.3932	.3605	.3401	.3277	.3277
Max	.3725	.3932	.3932	.3725	.3401	.3277	.3277
Min	.0162	.0983	.0983	.1296	.0983	.0983	.0503
Avg	.1358	.2199	.2205	.2247	.2038	.2055	.1818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 204 / 11 KV KHARASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0648	.0655	.0655	.0671	.0492	.0655
2		.0648	.0655	.0655	.0671	.0492	.0655
3		.0648	.0655	.0655	.0671	.0492	.0492
4		.0648	.0655	.0655	.0503	.0492	.0492
5		.0648	.0655	.0492	.0503	.0492	.0492
6		.0486	.0655	.0492	.0503	.0492	.0492
7	.0324	.0324	.0492	.0492	.0503	.0328	.0492
8	.0324	.0324	.0492	.0492	.0503	.0328	.0328
9		.0324	.0328	.0328	.0335	.0328	.0328
10	.0324	.0328	.0492	.0819	.0838	.0492	.0492
11	.0324	.0492	.0492	.0972	.0819	.0492	.0648
12	.0324	.0328	.0492	.0972	.0819	.0492	.0486
13	.0324	.0492	.0655	.0972	.0655	.0492	.0486
14	.0324	.0328	.0492	.0972	.0819	.0492	.0486
15	.0324	.0328	.0492	.0972	.0655	.0492	.0503
16	.0324	.0492	.0492	.0648	.0492	.0328	.0503
17	.0324	.0328	.0492	.0648	.0492	.0492	.0503
18	.0324	.0492	.0328	.0486	.0328	.0328	.0335
19	.0486	.0328	.0492	.0486	.0492	.0492	.0503
20	.0648	.0655	.0655	.0648	.0492	.0655	.0509
21	.0648	.0819	.0819	.0648	.0492	.0655	.0503
22	.081	.0819	.0819	.0671	.0492	.0655	.0509
23	.0648	.0655	.0655	.0648	.0492	.0655	.0335
24		.0648	.0655	.0655	.0648	.0492	.0655
Max	.081	.0819	.0819	.0972	.0838	.0655	.0655
Min	.0324	.0324	.0328	.0328	.0328	.0328	.0328
Avg	.0425	.0510	.0574	.0672	.0579	.0485	.0495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 205 / 11 KV Jatlapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0324	.0328	.0328	.0324	.0328	.0328
2		.0324	.0328	.0328	.0324	.0328	.0328
3		.0324	.0328	.0328	.0162	.0164	.0328
4		.0324	.0328	.0328	.0162	.0164	.0328
5		.0324	.0328	.0328	.0162	.0164	.0328
6		.0162	.0328	.0328	.0162	.0164	.0164
7	.0162	.0162	.0164	.0164	.0168	.0164	.0164
8	.0162	.0162	.0164	.0164	.0168	.0164	.0164
9	.0162	.0162	.0164	.0164	.0168	.0164	.0164
10	.0162	.0328	.0164	.0492	.0838	.0328	.0162
11	.0162	.0164	.0328	.0648	.0983	.0328	.0162
12	.0162	.0164	.0328	.0486	.0983	.0164	.0162
13	.0162	.0164	.0164	.0324	.0983	.0164	.0162
14	.0162	.0164	.0164	.0648	.1147	.0328	.0162
15	.0162	.0164	.0328	.081	.0655	.0328	.0168
16	.0162	.0492	.0328	.081	.0655	.0164	.0168
17	.0162	.0328	.0328	.081	.0655	.0328	.0168
18	.0162	.0164	.0164	.0162	.0164	.0164	.0168
19	.0162	.0164	.0164	.0162	.0164	.0164	.0168
20	.0324	.0328	.0328	.0324	.0328	.0328	.017
21	.0324	.0328	.0492	.0324	.0328	.0328	.017
22	.0486	.0492	.0492	.0335	.0328	.0328	.0171
23	.0486	.0492	.0492	.0324	.0328	.0328	.0168
24		.0486	.0492	.0492	.0324	.0328	.0328
Max	.0486	.0492	.0492	.081	.1147	.0328	.0328
Min	.0162	.0162	.0164	.0162	.0162	.0164	.0162
Avg	.0219	.0279	.0301	.0400	.0444	.0246	.0206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 201 / 11KV CHANDANIBURDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.7202	.6962	.663	.6859	.6443	.57
2	.4748	.6859	.6962	.663	.6859	.6443	.57
3	.4748	.6859	.663	.5967	.6859	.6443	.57
4	.4748	.6516	.6299	.5967	.6687	.6443	.57
5	.407	.6001	.6299	.3978	.6344	.5087	
6	.3391	.3944	.2984	.3978	.4458	.4409	
7	.2374	.2915	.1658	.2321	.2743	.3052	.2683
8	.2035	.2058	.1989	.2652	.2401	.2374	.2515
9		.2743	.2652	.2652	.2572	.2374	.2515
10	.373	.2743	.3315	.3978	.4287	.2713	.2347
11		.2743	.3315	.431	.4115	.2347	.2401
12	.2743	.2652	.3315	.4287	.407	.2683	.2058
13	.2572	.2652	.3315	.4287	.407	.2012	.2401
14	.2401	.2652	.3315	.4115	.373	.2012	.2401
15	.2572		.3315	.3601		.2012	.2401
16	.2401	.2984	.3315	.3944	.3391	.2012	.2229
17	.2572	.2984	.3315	.4115	.2374	.1844	.2229
18	.3086	.2321	.2321	.2229	.2543	.2515	.2401
19	.4115	.3978	.431	.3944	.407	.3521	.3429
20	.6516	.6299	.5636	.6001	.5087	.4694	.4287
21	.7202	.6962	.6299	.6859	.5765	.57	.4801
22	.7373	.7293	.6962	.703	.6443	.57	.4801
23	.7373	.7293	.6962	.7202	.6443	.57	.4801
24	.6443	.7202	.7293	.663	.7202	.6443	.57
Max	.7373	.7293	.7293	.7202	.7202	.6443	.57
Min	.2035	.2058	.1658	.2229	.2374	.1844	.2058
Avg	.4180	.4602	.4531	.4721	.4755	.3957	.36

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 202 / 11 KV AMBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.4287	.4409	.373	.4115	.373	.2949
2	.2713	.4115	.407	.373	.3772	.373	.2949
3	.2713	.3772	.407	.373	.3772	.373	.2949
4	.2713	.3429	.3222	.3222	.3772	.373	.2949
5	.2374	.3086	.2543	.3222	.3772	.3052	
6	.2035	.2915	.1696	.2543	.2572	.2374	
7	.1357	.2058	.1696	.1526	.1715	.1526	.1475
8	.1017	.1715	.1526	.1187	.1372	.1357	.1311
9		.1543	.1526	.1017	.12	.1357	.1311
10	.1357	.1372	.1526	.1187	.1543	.1187	.0983
11		.1543	.1696	.1357	.1543	.0983	.1029
12	.12	.1696	.1696	.1372	.1357	.0983	.0857
13	.1372	.1696	.1865	.1372	.1357	.0983	.1029
14	.1715	.1696	.2204	.1715	.1526	.0983	.1029
15	.1543	.1696	.2204	.1715		.0983	.1029
16	.1372	.1865	.2035	.1543	.1526	.1147	.12
17	.1372	.1357	.1526	.1715	.0983	.0819	.1029
18	.1715	.1017	.1526	.1715	.1187	.1311	.1372
19	.2572	.2035	.2543	.2058	.2035	.1802	.1715
20	.3429	.3222	.3222	.3601	.3052	.2949	.2401
21	.3944	.407	.373	.3772	.3561	.3113	.2915
22	.4115	.4239	.407	.4115	.373	.3113	.2915
23	.4458	.4409	.407	.4287	.373	.3113	.2915
24		.4287	.4409	.3647	.4287	.373	.3113
Max	.4458	.4409	.4409	.4287	.4287	.373	.3113
Min	.1017	.1017	.1526	.1017	.0983	.0819	.0857
Avg	.2276	.263	.2628	.2462	.2499	.2158	.1883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 203 / Rampuri Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.1543	.16	.16	.1372		.128
2	.1187	.1543	.16	.128	.1372	.1357	.128
3	.1187	.1543	.16	.128	.1372	.1357	.128
4	.1187	.1543	.096	.1326	.1372	.1357	.128
5	.1017	.1372	.096	.0995	.1372	.1357	
6	.0848	.0857	.096	.064	.0857	.1017	
7	.0509	.0686	.064	.032	.0514	.0509	.048
8	.0339	.0514	.064	.032	.0514	.0339	.048
9		.0514	.064	.032	.0514	.0339	.048
10	.0848	.1029	.128	.128	.12	.1187	.08
11	.0848	.1029	.16	.16	.12	.128	.1029
12	.1029	.096	.16	.1543	.1357	.128	.1029
13	.1029	.096	.16	.1543	.1017	.112	.1029
14	.1029	.096	.192	.1543	.1187	.096	.1029
15	.1029	.096	.192	.1715		.096	.1029
16	.0857	.096	.192	.1715	.1526	.096	.0857
17	.0857	.128	.192	.1715	.1357	.096	.0857
18	.0457	.032	.064	.0514	.0509	.048	.0514
19	.1029	.096	.096	.0686	.0848	.064	.0857
20	.12	.16	.128	.1372	.1187	.112	.12
21	.1543	.16	.128	.1543	.1357	.128	.1372
22	.1543	.16	.16	.1543	.1526	.128	.1372
23	.1543	.16	.16	.1543	.1357	.128	.12
24	.1187	.1543	.16	.1658	.1543	.1357	.128
Max	.1543	.16	.192	.1715	.1543	.1357	.1372
Min	.0339	.032	.064	.032	.0509	.0339	.048
Avg	.1021	.1145	.1347	.1233	.1149	.1034	.1001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 201 / 11KV Thadipawani

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	26-JUN-18
HR	Load (MW)
10	.1029
13	.0772
14	.072
15	.084
19	.0754
Max	.1029
Min	.072
Avg	.0823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 202 / 11 KV WADHONA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.407	.3772	.3688	.373		.3429
2	.373	.407	.3429	.3688	.373		.3429
3	.3772	.373	.3429	.3688	.3391		.3086
4	.3772	.373	.3086	.3688	.3391		.3086
5	.3772	.3052	.3086	.3391	.3052		.3086
6	.3155	.3052	.2743	.3391	.3052		.3086
7	.2454	.3052	.2743	.2713	.2713		.3086
8		.2374	.2401	.2454	.2374		.2743
9		.2035	.2058	.2454	.2035		.2743
10	.0678	.1372	.1063	.1638	.024		.0709
11	.0678	.0686	.1097	.0983	.0309	.0686	.0732
12	.1017	.0686	.1097	.1341	.0171	.0686	.0732
13	.0678	.0686	.1097	.1677	.0343	.0686	.0732
14	.1017	.0686	.1097	.1677		.0686	.0732
15		.1029	.1097	.1341		.0686	.0732
16			.1097	.1677	.0137	.0686	.0732
17	.0509	.1029	.1097	.1341	.0171	.0686	.0732
18	.1017	.1715	.2103	.1017	.0171	.2058	.1753
19	.3052	.2743	.3018	.3052	.0326	.2401	.2713
20	.3391	.3429	.3688	.3391		.3086	.2713
21	.373	.3772	.4024	.3391		.3086	.2713
22	.407	.4115	.407	.373		.3429	.2713
23	.407	.3772	.3688	.373		.3429	.2713
24	.373	.407	.3772	.3688	.373		.3429
Max	.407	.4115	.407	.373	.373	.3429	.3429
Min	.0509	.0686	.1063	.0983	.0137	.0686	.0709
Avg	.2599	.2563	.2494	.2618	.1837	.1715	.2181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 203 / 11KV Lohari-Sawanga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.373	.3086	.3688	.373		.2743
2	.3391	.373	.2743	.3688	.3391		.2743
3	.3429	.3391	.2743	.3688	.3391		.2401
4	.3429	.3391	.2401	.3353	.3052		.2401
5	.3429	.3052	.2401	.3052	.3052		.2058
6	.3429	.2713	.2058		.2374		.2058
7	.2804	.2035	.2058	.2103	.1696		.2058
8	.506	.2035	.1715	.1829	.2035		.1715
9	.6249	.2035	.1715	.1715	.1696		.1715
10	.3353	.1715	.2103	.3605	.0171		.1402
11	.3688	.1372	.2454	.3932	.0343	.1715	.1402
12	.3353	.1372	.2454	.3688	.0497	.1372	.1402
13	.3018	.1372	.2279	.3688	.0343	.1372	.1372
14	.3018	.1372	.2103	.3353	.0343	.1029	.0732
15	.2683	.1372	.2103	.3018	.0343	.1372	.0732
16		.1029	.2454	.3688		.1372	.0732
17	.1677	.1372	.2454	.3353		.1372	.1097
18	.2035	.2058	.1753	.1696		.1715	.2401
19	.2713	.2743	.2427	.3391	.0206	.2401	.2401
20	.3052	.3086	.3353	.373	.0377	.3086	
21	.373	.3772	.3688	.373		.3086	.2374
22	.407	.4115	.4024	.407		.3086	.2713
23	.407	.3772	.4024	.373		.3086	.2713
24	.3391	.373	.3429	.3688	.373		.2743
Max	.6249	.4115	.4024	.407	.373	.3086	.2743
Min	.1677	.1029	.1715	.1696	.0171	.1029	.0732
Avg	.3410	.2515	.2584	.3282	.1709	.2005	.1918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 204 / 11KV Jalalkheda-R

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.373	.3086	.3688	.3391		.2401
2	.373	.373	.2743	.3688	.3391		.2058
3	.373	.3391	.2401	.3688	.3391		.2058
4	.3429	.3391	.2058	.3391	.3052		.1715
5	.3086	.3052	.1715	.3052	.2713		.1715
6	.2126	.2035	.1715	.2279	.1696		.1372
7	.1463	.1357	.1372	.1097	.1357		.1372
8		.1017	.1372	.1097	.1017		.1029
9		.1017	.1029	.1097	.0171		.1029
10	.1357	.1372	.2713	.3605	.0343		.1063
11	.1357	.1372	.3052	.3932	.0377	.1372	.1052
12	.1341	.1715	.2804	.3688	.0171	.1372	.1052
13	.1677	.1715	.2401	.3018	.0171	.1372	.1097
14	.1341	.1715	.2401	.2683	.0206	.1029	.1097
15	.1357	.2058	.2454	.3018	.024	.1029	
16	.1357	.2058	.2683	.4024	.0137		.1097
17	.1341	.2058	.3018	.3688	.0137	.1029	.1097
18	.1017	.2743	.1387	.1696	.0137	.1029	.1372
19	.2035	.3086	.1715	.2713		.1715	.1715
20	.3391	.3429	.3052	.3052		.2743	.1715
21	.373	.3772	.407	.3052		.2743	.2103
22	.407	.4115	.407	.3391		.3086	.2804
23	.407	.3429	.3688	.3391		.2743	.2835
24	.3688	.373	.3086	.373	.3391		.2401
Max	.407	.4115	.407	.4024	.3391	.3086	.2835
Min	.1017	.1017	.1029	.1097	.0137	.1029	.1029
Avg	.2474	.2545	.2504	.2990	.1342	.1772	.1620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 205 / 11 KV PARADSINGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3391	.2743	.3155	.7042		.2058
2		.3391	.2401	.3155	.6706		.2058
3		.3391	.2401	.3155	.6706		.2058
4		.3052	.2058	.3155	.6371		.1715
5		.2713	.1715	.2743	.6036		.1715
6		.1696	.1372	.2035	.5087		.1372
7		.1357	.1372	.1097	.3391		.1372
8		.1017	.1372	.1097	.2374		.1029
9		.1017	.1372	.1097	.2713		.1029
10	.0678	.0857	.1097	.1326	.0343		.1097
11	.0509	.0686	.1097	.1658	.0514	.0686	.1097
12	.0509	.2401	.1829	.3353	.0583	.0686	.0732
13	.0509	.3772	.2743	.4359	.0617	.0686	.0732
14	.0509	.3772	.3086	.503	.0617	.0686	.0732
15	.1017	.3772	.3086	.503	.0514	.0686	.1715
16	.1357	.3772	.3429	.5365	.0377	.0686	.2401
17	.0678	.3086	.4115	.57	.0137	.0686	.2374
18	.1017	.3086	.3052	.2713	.0137	.1372	.1463
19	.1696	.3086	.3086	.5087	.0137	.1715	.1463
20	.2713	.3429	.3391	.5765		.2058	.1387
21	.3052	.3429	.3391	.6371		.2401	.1734
22	.3391	.3429	.3391	.7042		.2743	.2058
23	.373	.3086	.3391	.7377		.2401	.2103
24		.3391	.3086	.3121	.7042		.2401
Max	.373	.3772	.4115	.7377	.7042	.2743	.2401
Min	.0509	.0686	.1097	.1097	.0137	.0686	.0732
Avg	.1526	.2753	.2503	.3749	.2872	.1346	.1579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 206 / 11KV Jalalkheda-U-APDRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.8619	.9259	.9724	.9389		.7545
2	.7499	.8619	.9259	.9061	.9389		.7545
3	.7499	.8288	.8916	.9061	.9054		.7202
4	.6562	.7956	.8573	.9061	.9054		.7202
5	.6249	.7377	.8573	.8749	.8383		.6859
6	.6316	.6706	.7888	.8436	.8048		.6859
7	.5668	.6036	.7545	.8592	.7712		.6516
8	.57	.6706	.823	.8592	.8048		.6173
9	.5533	.7545	.8573	.8124	.9282		.583
10	.57	.823	.7499	.8951			.503
11	.6036	.823	.7865	.9779		.583	.5197
12	.6371	.8916	.7811	.9945		.583	.5197
13	.6371	.9259	.7811	1.0277		.583	.503
14	.6706	.9259	.8749	1.0608		.583	.503
15	.7042	.9259	.8436	1.0277		.583	.503
16	.7209	.9088	.8436	.9945		.583	.5197
17	.6036	.8916	.8436	.9614		.583	.5365
18	.6036	.9088	.828	.9282		.583	.6036
19	.6371	.9259	.9061	.9945		.6859	.663
20	.7956	.9431	.9374	1.0395		.8059	.6299
21	.8288	.9602	.9686	.9945		.8059	.6249
22	.8619	.9774	.9686	.9724		.823	.6562
23	.8951	.9602	.9374	.9556		.7888	.6249
24	.9061	.8951	.9602	.9172	.9389		.7545
Max	.9061	.9774	.9686	1.0608	.9389	.823	.7545
Min	.5533	.6036	.7499	.8124	.7712	.583	.503
Avg	.6887	.8530	.8622	.9451	.8775	.6595	.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 207 / Mendhla

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18
HR	Load (MW)
7	.1928
10	.0678
11	.0678
12	.2012
13	.2012
14	.218
15	.2012
16	.1677
Max	.218
Min	.0678
Avg	.1647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 201 / 11 KV Datewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.3315	.3401	.3521	.3361	.2881	.2347
2		.3315	.3401	.3521	.3361	.2881	.2347
3		.3315	.3239	.3018	.3361	.2881	.218
4		.2984	.2915	.3018	.2881	.2881	.2012
5		.2486	.2753	.2683	.192	.2561	.2012
6		.1989	.1943	.2012	.16	.176	.1509
7		.1326	.1296	.1006	.096	.112	.1174
8		.116	.0972	.0838	.096	.096	.1174
9		.0995	.0983	.0819	.096	.096	.1006
10		.1638	.1802	.1943	.2721	.176	.1006
11		.1311	.1844	.2241	.2721	.1509	.1174
12		.1147	.1844	.2561	.2401	.1174	.1174
13				.2401	.2241	.1174	.1341
14		.1311	.2012	.2241	.176	.1509	.1006
15		.1326	.1943	.2561	.16	.1174	.1006
16		.0983	.1781	.2561		.1174	.1174
17	.0829	.0983	.1475	.2721	.2561	.1006	.1006
18	.116	.1296	.1311	.08	.096	.1174	.1006
19	.2321	.1619	.1509	.144	.16	.1677	.1341
20	.2984	.2591	.2515	.2881	.192	.1844	.1677
21	.3149	.3113	.2785	.3201	.2561	.2347	.2012
22	.3647	.3239	.3353	.3361	.176	.2515	.1844
23	.3481	.3401	.3521	.3361	.2881	.2515	.2012
24		.3315	.3401	.3521	.3361	.2881	.2347
Max	.3647	.3401	.3521	.3521	.3361	.2881	.2347
Min	.0829	.0983	.0972	.08	.096	.096	.1006
Avg	.2569	.2094	.2261	.2426	.2192	.1847	.1537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 203 / 11 KV Wadhona Rural

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4458	.421	.4024	.4001	.3841	.3467
2		.4458	.421	.4024	.4001	.3841	.3294
3		.4458	.3887	.3361	.4001	.3841	.3294
4		.4115	.3401	.3441	.3841	.3841	.3121
5		.3429	.3401	.3018	.3201	.3361	.3121
6		.2743	.2591	.2683	.2241	.2401	.2427
7		.1715	.1619	.1509	.144	.144	.1734
8		.1715	.1296	.1311	.128	.192	.156
9		.1543	.1457	.1296	.128	.144	.156
10		.0678	.0983	.1475	.176	.128	.0693
11		.0983	.1311	.144	.2401	.12	.0867
12		.1147	.1006	.16	.2241	.0343	.0693
13			.1006	.176	.192	.0514	.1006
14		.1147	.1174	.176	.192	.0514	.0693
15		.0983	.1174	.176	.16	.0857	.104
16		.0972	.1006	.192		.0857	.0867
17	.0686	.0983	.1147	.208	.096	.1029	.052
18	.1886	.1781	.0983	.176	.16	.1715	.156
19	.3086	.2105	.1966	.208	.2561	.2401	.208
20	.4115	.3401	.3688	.3521	.3041	.3086	.2601
21	.4458	.426	.4024	.4001	.3361	.3467	.2774
22	.4801	.421	.4359	.4001	.3841	.3641	.2774
23	.4458	.4372	.4527	.4001	.3841	.3641	.2947
24		.4458	.421	.4527	.4001	.3841	.3467
Max	.4801	.4458	.4527	.4527	.4001	.3841	.3467
Min	.0686	.0678	.0983	.1296	.096	.0343	.052
Avg	.3451	.2614	.2443	.2598	.2623	.2263	.2007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 401 / 33 KV Loharisawanga

Feeder KV- 33 / INCOMING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2195	.1646	.1646	.1698	.1526	.1595
16	.4424	.3361	.5407	.4321	.2846	.1806
24	.4527	.4435	.168	.439	.3921	.3841
Max	.4527	.4435	.5407	.439	.3921	.3841
Min	.2195	.1646	.1646	.1698	.1526	.1595
Avg	.3715	.3147	.2911	.3470	.2764	.2414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 402 / 33 KV Bharsingi

Feeder KV- 33 / INCOMING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0208	1.262	1.2357	1.262	1.0425	.9425
16		2.34	2.8487	2.1382	1.0802	1.0517
18	1.9547					
24	1.6632	1.7741	1.8296	1.9605	1.4918	1.4266
Max	1.9547	2.34	2.8487	2.1382	1.4918	1.4266
Min	1.0208	1.262	1.2357	1.262	1.0425	.9425
Avg	1.5462	1.7920	1.9713	1.7869	1.2048	1.1403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 403 / 33 KV Paradsinga

Feeder KV- 33 / INCOMING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2829	.3326	.3395	.1698	.2829	.3395
16	.8745	1.0562	.5847	.5316	.503	.5144
24	.8316	.8962	.8779	.6161	.7842	.7356
Max	.8745	1.0562	.8779	.6161	.7842	.7356
Min	.2829	.3326	.3395	.1698	.2829	.3395
Avg	.663	.7617	.6007	.4392	.5234	.5298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 404 / 33 KV Mowad

Feeder KV- 33 / INCOMING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9122	.763	.7545	.7202	.8048
16		1.0208	1.1963	.8648	.7373	.6241
24	1.3575	1.3032	1.3717	1.2489	1.262	.9877
Max	1.3575	1.3032	1.3717	1.2489	1.262	.9877
Min	1.3575	.9122	.763	.7545	.7202	.6241
Avg	1.3575	1.0787	1.1103	.9561	.9065	.8055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 405 / 33 KV T.Pawani Feeder

(Wadvih Feeder KV- 33 / OUTGOING)

DATE	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0486	.0949	.0469		.0937
16	.3018	.3704			.1492
24	.2658	.2658		.2629	.208
Max	.3018	.3704	.0469	.2629	.208
Min	.0486	.0949	.0469	.2629	.0937
Avg	.2054	.2437	.0469	.2629	.1503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 408 / 33 KV WATHODA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7385	.7968	.8259	.583
16	.9556	1.2289		.5155
24	.7716	1.182	1.1403	.4938
Max	.9556	1.2289	1.1403	.583
Min	.7385	.7968	.8259	.4938
Avg	.8219	1.0692	.9831	.5308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 201 / 11 KV HATLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7265	.7186	.6097	.4784
2			.443	.7265	.7186	.6097	.4784
3			.4252	.7265	.7186	.5716	.4607
4			.3721	.6733	.6661	.5716	.4252
5			.3544	.6201	.6135		.3721
6			.3012	.443	.4382	.1715	.3366
7			.2126	.3189	.3155	.2858	.2835
8			.2303	.2658	.2454	.2858	.2481
9			.2835	.2658	.2328	.2477	.2658
10	.3366	.4252	.4252	.567	.5258	.4001	.2126
11	.3258	.3366	.443	.6661	.6287	.3898	.2126
12	.3403	.3544	.443	.5609	.6287	.3189	.2126
13	.362	.3544	.443	.5434	.6097	.3189	.2126
14	.3403	.3721	.443	.5609	.5716	.2303	.2126
15	.298	.3721	.443	.6135	.5716	.2303	.1772
16	.3224	.3721	.5316	.5784	.5716	.2303	.1772
17	.3439	.3544	.5847	.6135	.6287	.2303	.2658
18		.3189	.3012	.298	.2667	.2481	.3012
19		.4607	.3721	.3856	.381	.3721	.3544
20		.567	.4961	.5083	.5144	.443	.4075
21		.7087	.6379	.6135	.5716	.4784	.4075
22		.7442	.7265	.6661	.6668	.5316	.3898
23		.5194	.7265	.7011	.6668		.3898
24			.9214	.7265	.7186	.6097	.4961
Max	.362	.7442	.9214	.7265	.7186	.6097	.4961
Min	.298	.3189	.2126	.2658	.2328	.1715	.1772
Avg	.3337	.4472	.4592	.5571	.5496	.3811	.3241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 202 / 11 KV Chargaon (old Dorli) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2481	.208	.2103	.1905	.1734
2			.2254	.208	.2103	.1715	.1734
3			.208	.208	.2103	.1715	.156
4			.208	.1734	.1753	.1524	.156
5			.1734	.1387	.1402	.1524	.1387
6			.1387	.104	.1052	.1334	.1214
7			.1214	.0867	.0876	.1143	.104
8			.104	.0867	.0876	.1143	.0867
9			.104	.0867	.0905	.0953	.0867
10	.1387	.208		.2947	.298	.3048	.1734
11	.1791	.2601	.2601	.2629	.4001	.2947	.1734
12	.197	.208	.2601	.298	.4191	.2254	.156
13	.2149	.208	.2601	.2804	.381	.2254	.1387
14	.2534	.2254	.2601	.2629	.3429	.1907	.1387
15	.3045	.2427	.2601	.2804	.2858	.1907	.104
16	.3403	.2427	.2601	.298	.2858	.2427	.104
17	.3761	.2427	.1907	.2804	.3239	.1734	.1387
18		.104	.104	.1052	.1143	.0867	.104
19		.1387	.1214	.1227	.1905	.3641	.1214
20		.1907	.156	.1578	.2096		.1387
21		.2254	.1907	.1928	.2096	.1907	.1387
22		.2254	.208	.2103	.2096	.208	.1214
23		.2865	.208	.2279	.1905		.1214
24			.2427	.208	.2103	.2096	.1907
Max	.3761	.2865	.2601	.298	.4191	.3641	.1907
Min	.1387	.104	.104	.0867	.0876	.0867	.0867
Avg	.2505	.2149	.1962	.1993	.2245	.1910	.1358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 204 / 11 KV Kotwalbardi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8383	.8718	.9114	.9335	.7712
2			.8383	.8718	.9114	.8954	.7545
3			.8048	.8718	.9114	.7621	.6874
4			.7712	.8718	.9114	.7621	.6706
5			.7377	.8048	.8413	.724	.6706
6			.6874	.6371	.6661	.5716	.6203
7			.5868	.4694	.4908	.4954	.4862
8		.4784	.5197	.4359	.4557	.4572	.4527
9			.4862	.4024	.4344	.4191	.4359
10	.6371	.5365		.8383	.929	.6668	.4527
11	.7164	.6874	.7545	.7888	.7621	.6203	
12	.7522	.6874	.8383	.8238	.9717	.5868	.503
13	.8326	.6706	.8383	.8764	.9526	.57	.4359
14	.8596	.6706	.8383	.8764	.8573	.503	.503
15	.8596	.6874	.8383	.9114	.7621	.4862	.4694
16	.8954	.7377	.8383	.8939	.7621	.57	.4694
17	.9313	.7042	.7545	.9114	.7621	.5365	.503
18		.4862	.4694	.4908	.5716	.4527	.6036
19		.57	.6036	.631	.7621	.5533	.7042
20		.7042	.6706	.7011	.8573	.6371	.7712
21		.7545	.7712	.8063	.9145	.7377	.7545
22		.7712	.8383	.8764	.9526	.8048	.7377
23		.8954	.8718	.8939	.9526		.7209
24			.8383	.8718	.9114	.9526	.7712
Max	.9313	.8954	.8718	.9114	.9717	.9526	.7712
Min	.6371	.4784	.4694	.4024	.4344	.4191	.4359
Avg	.8105	.6694	.7406	.7679	.8006	.6391	.6065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 404 / 33 KV T/F Incomer No.II

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5658		.7888	.743	.7716
2			.6687		.7888	.743	.7202
3			.6687		.7888	.6859	.6687
4			.6173		.7362	.6287	.6173
5			.5658		.6836	.4572	.6173
6			.5144		.5258	.4572	.5144
7			.4115		.3681	.3429	.4115
8			.3601		.3155	.3429	.4115
9			.3561		.3258	.3429	.4115
10	.7716	1.0802		1.0802	.8413	.9145	.6687
11	.8145	.5658	.6687	1.262	.8573	.9054	.7202
12	.8596	.5144	.6687	.7888	.8573	.7716	.7202
13	.9134	.5144	.6687	.7888	.9717	.6687	.5144
14	.9231	.823	.6687	1.0517	1.2003	.6173	.3086
15	.9231	.823	.9259	1.1568	1.3146		.5144
16	.9774	.7716	1.0288	1.1568	1.3146	.6687	.5658
17	.9134	.7202	.9774	1.2094	1.1431	.6687	.6687
18		.3601		.4207	.4001	.3601	
19		.5144		.5258	.5716	.5658	
20		.6687		.5784	.6859	.6687	
21		.7202		.6836	.6859	.7202	
22		.7716		.7362	.8002	.823	
23		.8596	.8745	.7888	.8002		
24			.8745		.7888	.743	.7716
Max	.9774	1.0802	1.0288	1.262	1.3146	.9145	.7716
Min	.7716	.3601	.3561	.4207	.3155	.3429	.3086
Avg	.8870	.6934	.6714	.8734	.7731	.6291	.5887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 201 / 11 Kv Paradsinga
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.7293	.8186	.7287	.8328	.5967	.6556
2	.5407	.7293	.815	.7045	.815	.5636	.6556
3	.4915	.6796	.7796	.6554	.815	.5636	.6447
4	.4424	.663	.7442	.6226	.7087	.547	.5731
5	.4144	.6133	.7087	.5801	.6024	.5138	.4656
6	.3772	.5304	.6201	.547	.5316	.4807	.4252
7	.3429	.3647	.4252	.3856	.3898	.3812	.3544
8	.3155	.3149	.3898	.3681	.3544	.3149	.3544
9	.3506	.3647	.394	.3506	.3366	.3315	.3721
10	.1658	.1989	.1949	.1753	.1772	.1823	.1417
11	.1658	.2303	.1907	.2481	.2321	.1772	.1326
12	.1823	.2454	.2058	.2481	.2155	.1772	.1492
13	.1658	.2481	.2035	.2126	.1823	.1595	.116
14	.1823	.2481	.2012	.2454	.1989	.1772	.1326
15	.1823	.2454	.2012	.2454	.1823	.1772	.116
16	.1823	.2481	.213	.2481	.2155	.1772	.0995
17	.1823	.2481	.1696		.1658	.1595	.0995
18	.3481	.4557	.3481	.2835	.2984	.3721	.0995
19	.4973	.5201	.4557	.4075	.3812	.5138	.431
20	.6464	.6733	.5609	.6733	.547	.5847	.4641
21	.7127	.7716	.6443	.7087	.5967	.6201	.4807
22	.779	.7975	.7209	.7796	.6796	.6556	.4973
23	.7956	.8859	.8002	.8328	.6464	.6733	.4807
24		.7459	.8505	.7865	.8328	.6133	.6556
Max	.7956	.8859	.8505	.8328	.8328	.6733	.6556
Min	.1658	.1989	.1696	.1753	.1658	.1595	.0995
Avg	.3926	.4897	.4857	.4799	.4558	.4047	.3582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 202 / 11 Kv MASLI (OLD FEEDER SEPERATION/PURE AG
 BHISHNOOR) Feeder KV- 11 /
 OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5138	.5609	.5735	.5868	.4475	.4409
2		.4807	.5493	.5407	.5533	.4144	.407
3		.4807	.5138	.4973	.503	.3978	.373
4		.4475	.5138	.4475	.4694	.3481	.3353
5		.3647	.4784	.4191	.3353	.3481	.2683
6		.3149	.3898	.3601	.2683	.3149	.2374
7			.2328	.2172	.2012	.2321	.2012
8			.2303	.181	.1989	.1823	.1989
9		.1823	.2328	.1791	.1658	.0829	.1823
10	.1989	.431	.7888	.8907	.9614	.4475	
11	.6299	.6935	.7449	.9116	.8288	.3688	.1492
12	.6133	.7282	.7449	.8619		.3239	.1658
13	.6133	.7265	.8002	.8785		.2515	.2984
14	.663	.7011	.8002	.8619		.3353	.3149
15	.663	.6733	.8029	.8288		.3688	.2984
16	.6464	.6268	.8802	.8288		.2984	.2984
17	.6133	.6379	.7537		.547	.2155	.2818
18	.2486	.2303	.2303		.4973	.218	
19	.2652	.3012	.3155	.3149	.4641	.2515	.2818
20	.2818	.5258	.4382	.4641	.4144	.1267	.3315
21	.5138	.5959	.5258	.5304	.4641	.4527	.3315
22	.5967	.6173	.583	.5636	.5138	.4527	.3812
23	.5967	.6485	.6274	.5801	.4807	.4475	.3481
24		.5304	.6379	.6415	.5868	.4807	.4527
Max	.663	.7282	.8802	.9116	.9614	.4807	.4527
Min	.1989	.1823	.2303	.1791	.1658	.0829	.1492
Avg	.5103	.5206	.5573	.5715	.4758	.3253	.299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 203 / 11 Kv Khangao SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4973	.4961	.5144	.5304	.4475	.4527
2		.4807	.5014	.4854	.503	.4475	.4527
3		.4807	.4835	.4557	.4748	.4144	.4359
4		.4475	.4835	.4252	.4409	.3978	.4024
5		.3978	.4344	.3898	.3688	.3647	.3353
6		.3481	.3582	.3801	.3018	.3647	.3315
7	.2303	.2486	.2835	.2481	.2321	.2486	.2818
8	.2507	.2486	.2715	.2149	.1989	.2155	.2486
9	.2328	.2321	.2658	.2303	.1823	.2155	.2155
10	.2155	.1989	.2303	.2486	.2984	.1989	.1989
11	.2321	.1772	.1928	.2486	.3149	.2321	.1989
12	.1989	.197	.2254	.2321	.3149	.2321	.1989
13	.1823	.1949	.2543	.2458	.2652	.1989	.1492
14	.1823	.1791	.2572	.2486	.2486	.1658	.1326
15	.1492	.1772	.213	.2486	.2155	.1492	.1326
16	.1823	.1772	.1966	.2321	.2155	.1492	.1492
17	.2155	.1791	.2058	.2155	.1989	.1326	.1326
18	.2321	.2507	.2658	.1989	.1989	.1989	
19	.2984	.3544	.3506	.2321	.2652	.3185	
20	.431	.5316	.4382	.431	.3978	.4024	.1326
21	.5138	.5784	.4854	.4641	.4475	.4359	.3481
22	.547	.5895	.5316	.5138	.4973	.4527	.3647
23	.547	.5144	.5658	.5304	.4807	.4475	.3481
24		.5138	.4961	.5487	.5304	.4475	.4527
Max	.547	.5895	.5658	.5487	.5304	.4527	.4527
Min	.1492	.1772	.1928	.1989	.1823	.1326	.1326
Avg	.2848	.3415	.3536	.3410	.3384	.3033	.2771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 204 / 11 KV KHAPRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.116	.1433	.1134	.1326	.116	.116
2	.0492	.0995	.1433	.1147	.1326	.116	.0995
3	.0492	.0995	.1463	.0972	.116	.0995	.0995
4	.0492	.0995	.1254	.0972	.116	.0995	.0829
5	.0332	.0829	.1063	.0819	.0829	.0829	.0829
6	.0332	.0829	.0905	.0819	.0497	.0829	.0663
7	.0166	.0497	.0532	.0492	.0332	.0497	.0499
8	.0328	.0332	.0362	.0492	.0332	.0332	.0332
9	.0328	.0497	.0543	.0332	.0332	.0332	.0332
10	.0166	.0829	.0537	.0972	.0663	.0497	.0332
11	.0995	.0886	.0819	.0829	.0995	.0332	.0497
12	.116	.0895	.0655	.0995	.0829	.0332	.0332
13	.0497	.0709	.0655	.0497	.061	.0332	.0332
14	.0663	.0543	.0655	.0492	.0829	.0332	.0497
15	.0332	.0886	.0655	.0492	.0829	.0332	.0332
16	.0497	.1433	.0655	.0819	.0663	.0332	.0497
17	.0497	.0709	.0497	.0829	.0332	.0332	.0497
18	.0497	.0716	.0492	.0332	.0497	.0497	
19	.0663	.0895	.0819	.0497	.0497	.0663	.0663
20	.0995	.1063	.0983	.0995	.0995	.0829	.0829
21	.116	.1417	.1134	.116	.0995	.0995	.0829
22	.116	.1791	.1134	.1326	.1326	.116	.0829
23	.116	.1772	.128	.1326	.116	.116	.0829
24	.0648	.116	.1772	.128	.1326	.116	.116
Max	.116	.1791	.1772	.1326	.1326	.116	.116
Min	.0166	.0332	.0362	.0332	.0332	.0332	.0332
Avg	.0613	.0951	.0905	.0834	.0827	.0684	.0656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 205 / 11 KV NEW BHISHNOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4475	.5316	.4915	.0995	.3978	.3978
2		.4475	.5373	.4588	.1006	.3647	.3647
3		.431	.4961	.431	.0838	.3647	.3353
4		.3978	.5025	.3978	.0838	.3481	.2984
5		.3481	.4784	.3688	.0663	.3149	.3018
6		.2984	.3898	.3185	.0497	.2818	.2984
7		.2155	.2353	.2229	.0332	.2321	.2155
8		.1823	.2126	.2204	.0332	.1658	.1989
9		.2155	.2328	.2149	.0332	.1823	.1823
10		.2155	.2947	.3856	.0332	.1989	.2155
11		.2303	.3185			.1989	.1823
12			.3277			.1989	.1658
13			.285			.1658	.1823
14						.1989	.1658
15						.1989	
16					.0663	.1658	
17					.0497	.1326	
18	.1658		.2035		.1989	.1658	
19	.1823		.2572	.0497	.2486	.2652	.2652
20	.2321	.2658	.3353	.0663	.3647	.3481	.2984
21	.4807	.443	.4144	.0829	.3978	.3978	.3149
22	.5304	.6001	.4915	.0829	.4475	.4144	.3315
23	.5138	.567	.5506	.0995	.431	.431	.3149
24		.4807	.5316	.5243	.0995	.3978	.431
Max	.5304	.6001	.5506	.5243	.4475	.431	.431
Min	.1658	.1823	.2035	.0497	.0332	.1326	.1658
Avg	.3509	.3616	.3813	.2760	.1537	.2721	.2730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 403 / 33 KV Paradsinga Incomer

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.4744	.4784	.5784	.5973	.427	.4887
2	.0532	.4744	.4887	.5258	.543	.427	.4344
3	.0532	.4744	.4784	.4784	.543	.3795	.4344
4	.0532	.427	.4298	.4784	.4887	.3321	
5	.0532	.3795	.3761	.4252	.3801	.3321	.3258
6	.0532	.3321	.3224	.3721	.2715	.3321	.2715
7	.1063	.0949	.2172	.2172	.2172	.2372	.2715
8	.2126	.0949	.1617	.2149	.2149	.1898	.2172
9	.2103	.1898	.1629	.2149	.1612	.1423	.2172
10	.3795	.6167	1.0631	1.1831	1.3432	.6167	.2172
11	.8065	.6379	.9991	1.2357	1.0911	.6516	.3321
12	.759	.6447	1.0517	1.182	.2846	.5973	.3321
13	.759	.5784	1.1443	1.182	.2372	.4887	.427
14	.8065	.5316	1.1191	1.182	.2372	.543	.427
15	.8539	.5373	1.0802	1.1283	.1898	.543	.427
16	.8065	.591	1.1191	.2686	.1898	.4887	.427
17	.8065	.5847	.9774	.1612	.5693	.3761	.3795
18	.3321	.2149	.2686	.0543	.5218	.2172	
19	.3321	.3189	.3189	.2686	.5218	.2686	.0949
20	.3795	.4252	.4207	.4835	.3795		.2372
21	.4744	.4784	.4784	.543	.427	.4344	.3321
22	.5218	.4784	.5721	.5373	.4744	.4887	.3321
23	.5218	.4835	.6173	.591	.4744	.4887	.3321
24	.0532	.4744	.4835	.6241	.5973	.427	1.3032
Max	.8539	.6447	1.1443	1.2357	1.3432	.6516	1.3032
Min	.0532	.0949	.1617	.0543	.1612	.1423	.0949
Avg	.3934	.4391	.6179	.5888	.4565	.4099	.3755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 404 / 33 kv T/F NO.II P'SINGA

Feeder KV- 33 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.427	.591	.4784	.3224	.3321	.3761
2	.2103	.427	.5316	.4733	.3224	.3321	.3761
3	.2103	.3795	.5373	.4252	.3224	.3321	.3761
4	.1595	.3795	.5316	.4252	.2686	.3321	.3224
5	.1595	.3321	.4835	.3761	.2686	.2846	.2686
6	.1595	.2846	.4344	.3224	.2149	.2846	.2686
7	.1075	.1898	.2715	.2172	.1075	.1898	.2149
8	.1075	.1898	.4298	.2149	.1075	.1423	.1612
9	.1063	.1989	.4344	.2172	.1075	.1898	.1612
10	.1898	.4973	.5373	.6836	.2658	.427	.3761
11	.2372	.4835	.6379	.3189	.3321	.4298	.3321
12	.2846	.3258	.631	.3189	.2846	.4298	.3321
13	.1898	.3189	.5847	.2658	.2372	.3761	.3321
14	.2372	.2686	.2658	.2658	.2846	.4298	.3321
15	.1898	.3189	.2658	.2658	.2372	.4298	.1423
16	.2372	.3761	.3155	.3189	.3321	.3721	.1423
17	.2372	.3224	.2149	.3189	.2372	.3224	.1423
18	.3321	.2172	.2172	.1595	.1898	.1612	
19	.427	.3721	.2658	.1595	.2372	.2686	.427
20	.5693	.4252	.3189	.2658	.3321	.3224	.2846
21	.427	.5316	.4207	.2658	.3481	.3761	.2984
22	.4744	.591	.4733	.3189	.3795	.3761	.2372
23	.4744	.5847	.5201	.3189	.3795	.3761	.2846
24	.0526	.427	.5973	.5201	.3224	.3795	.3761
Max	.5693	.591	.6379	.6836	.3795	.4298	.427
Min	.0526	.1898	.2149	.1595	.1075	.1423	.1423
Avg	.2496	.3695	.4380	.3298	.2684	.3290	.2854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 201 / 11 KV LAXMINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.3841	.4024	.394	.3601	.3292	.8417
2	.1646	.3841	.3658	.3761	.3506	.3292	.2686
3	.1646	.3841	.3292	.3582	.3258	.2926	.2686
4	.1646	.3292	.2926	.3403	.3086	.2926	.7619
5	.1646	.2926	.2743	.3224	.2615	.2561	.2534
6	.1463	.2926	.2561	.2865	.1886	.2561	.2353
7	.128	.2378	.2378	.2012	.1886	.2195	.1829
8	.128	.2378	.1829	.2195	.1886	.2195	.1829
9	.1433	.2195	.2012	.2328	.2378	.2195	.1829
10	.0543	.2195	.1829	.2507	.2401	.1829	.2012
11	.0543	.2926	.2195	.2561	.2378	.1829	.2012
12	.1991	.3109	.2378	.2743	.2195	.1829	.1829
13	.3109	.3292	.2378	.2561	.2195	.1646	.2378
14	.0537	.3292	.2926	.2743	.2353		.2378
15	.0549	.3292	.2561	.2926	.2149	.1646	.2195
16	.3045	.2926	.2561	.2743	.197	.1646	.1829
17	.2896	.2401	.2561	.2378	.1829	.1463	.1646
18	.2865	.1715	.2378	.2172	.1646	.1463	.1829
19		.2561	.2561	.2378	.2561	.1829	
20	.3658	.3292	.2896	.3292	.3109	.2561	.2195
21	.3841	.3841	.3475	.3601	.3109	.2926	.2195
22	.3841	.4024	.394	.3658	.3292	.3109	.2378
23	.3841	.4207	.4207	.3841	.3475	.3045	.2195
24	.2012	.4024	.4024	.394	.3841	.3658	.2865
Max	.3841	.4207	.4207	.394	.3841	.3658	.8417
Min	.0537	.1715	.1829	.2012	.1646	.1463	.1646
Avg	.2042	.3113	.2846	.2973	.2609	.2375	.2683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 202 / 11 KV BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9745	1.1694	1.1694	1.1517	1.1488	1.0631	
2	.9568	1.1163	1.1163	1.1163	1.0974	1.0099	.788
3	.9214	1.0808	1.0631	1.0808	1.046	1.0099	.7619
4	.8859	1.0808	1.0099	1.0277	.9945	.9214	.7619
5	.7973	1.0631	.9391	.9922	.8916	.9214	.7442
6	.7796	.8682	.8859	.8682	.7888	.8328	.7522
7	.7442	.815	.8505	.8505	.7888	.8328	.7442
8	.7087	.7265	.7087	.7265	.7545	.7265	.7265
9	.7442	.7619	.7442	.7619	.7442	.7619	.7265
10	.8859	.8328	.8328	.8505	.7545	.7619	.7087
11	.9922	.9036	.9391	.9745	.9036	.8328	.815
12	1.0631	.9745	1.0099	1.0808	1.0099	.8859	.8505
13	1.0985	1.0099	1.0099	1.1517	1.0631	.8859	.8682
14	1.1517	1.0631	1.0985	1.2048	1.0808	.8859	.8505
15	1.1163	1.0631	1.1163	1.258	1.0808	.8682	.8505
16	1.0808	1.0808	1.0985	1.258	1.0277	.8682	.815
17	1.0631	.9259	.9745	1.134	.9922	.8505	.7973
18	1.0277	.6859	.9568	1.0454	.9391	.8328	.8859
19		.9391	1.0985	1.0985	1.0631	.8859	.9036
20	1.258	1.0631	1.1694	1.2757	1.1517	.9745	.8682
21		1.134	1.1871	1.2174	1.0631	.9214	.7619
22	1.1871	1.1694	1.1517	1.1694	1.0985	.8859	.7265
23	1.1871	1.1871	1.258	1.1871	1.1694	.8859	.691
24	1.0631	1.1871	1.1694	1.2048	1.2226	1.0808	.8682
Max	1.258	1.1871	1.258	1.2757	1.2226	1.0808	.9036
Min	.7087	.6859	.7087	.7265	.7442	.7265	.691
Avg	.9858	.9959	1.0232	1.0703	.9948	.8911	.7942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 203 / 11 kV IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.591	.5731	.7701	.7164	.703	.6805	.5014
2	.5731	.5731	.7522	.6805	.6859	.6805	.4835
3	.5373	.5731	.7343	.6626	.6859	.6805	.5373
4	.5552	.5373	.7164	.6447	.691	.6447	.5552
5	.5731	.5373	.6805	.6268	.6344	.6447	.5731
6	.5731	.6626	.6626	.6805	.6173	.6447	.6089
7	.5552	.6089	.6805	.6984	.6173	.6626	.6089
8	.5552	.6089	.6089	.6089	.583	.6268	.591
9	.5847	.6089	.6268	.6447	.591	.6268	.5731
10	.5847	.6447	.6805	.6805	.6001	.6447	.5552
11	.6024	.6447	.6984	.6984	.6984	.6268	.5731
12	.6268	.6447	.7343	.7164	.6447	.6089	.6089
13	.6805	.6626	.788	.7164	.7164	.5373	.6089
14	.5373	.6447	.6626	.6984	.7343	.4835	.4656
15	.5552	.6268	.6447	.6805	.5552	.5194	.5373
16	.6268	.7164	.6447	.8059	.6447	.4298	.5552
17	.6984	.6516	.6447	.788	.6268	.5014	.5014
18	.6626	.6984	.7164	.6805	.6626	.6089	.6268
19		.7164	.7164	.7343	.7522	.6984	.591
20	.8238	.788	.7343	.8417	.8059	.7522	.5373
21	.7164	.7343	.7343	.7202	.6805	.5731	.5194
22	.7701	.7522	.7537	.7164	.6626	.591	.4835
23	.7522	.7701	.7701	.7343	.6984	.5373	.5014
24	.6268	.7522	.7701	.7522	.7343	.6984	.5014
Max	.8238	.788	.788	.8417	.8059	.7522	.6268
Min	.5373	.5373	.6089	.6089	.5552	.4298	.4656
Avg	.6244	.6555	.7052	.7053	.6677	.6126	.5500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 204 / 11 KV PANCHWATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.9922	1.0099	1.0166	.9945	.8859	.6516
2	.3012	.9568	.9391	.9816	.9774	.8328	.6767
3	.7619	.9568	.8505	.929	.9259	.815	.6584
4	.7265	.8859	.7619	.8954	.8745	.7796	.6401
5	.691	.8859	.7087	.8413	.8291	.7796	.6154
6	.6556	.7619	.6733	.7164	.6859	.7087	.6335
7	.5493	.6379	.6201	.5847	.5487	.5847	.5316
8	.4961	.5493	.567	.5138	.4973	.5138	.4607
9	.5611	.5316	.5493	.5373	.4607	.5138	.4706
10	.5249	.5493	.5493	.4835	.5014	.4961	.4656
11	.5068	.5847	.5847	.5316	.4961	.4607	.4075
12	.4706	.6135	.6024	.6024	.4784	.4252	.4075
13	.6024	.6733	.6379	.5847	.5316	.4252	.443
14	.6516	.7973	.7619	.6733	.5138	.4252	.443
15	.6201	.7973	.691	.7619	.567	.4298	.4252
16	.6154	.7442	.691	.7619	.5138	.4252	.4252
17	.591	.703	.6379	.6733	.4961	.4252	.4252
18	.5973	.6516	.6068	.6024	.5138	.4252	.4961
19	.7087	.6733	.6733	.6556	.6733	.6024	.5493
20	.815	.8328	.815	.8505	.7442	.6556	.6024
21	.9036	.8505	.8505	.8916	.7442	.6556	.5316
22	.8859	.9568	.9745	.9568	.7973	.7265	.5609
23	.9391	1.0277	1.0985	.9922	.9214	.6661	.5316
24	.7973	1.0099	1.0099	1.0692	1.0277	.9036	.6447
Max	.9391	1.0277	1.0985	1.0692	1.0277	.9036	.6767
Min	.3012	.5316	.5493	.4835	.4607	.4252	.4075
Avg	.6371	.7760	.7444	.7545	.6798	.6067	.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 205 / 11 KV PETHBUDHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5028	.5721	.5895	.5959	.583	.5201	.4572
2	.5028	.5721	.5548	.591	.583	.4854	.4525
3	.4854	.5721	.5201	.5609	.5658	.4508	.4525
4	.3467	.5548	.4854	.5609	.5316	.4334	.4298
5	.4161	.4508	.4508	.5552	.4973	.3988	.439
6	.3988	.3988	.4161	.4477	.4287	.3814	.3658
7	.3467	.3988	.3641	.3467	.3258	.3294	.2947
8	.3121	.3294	.3294	.3294	.3012	.3121	.2774
9	.3403	.2947	.3294	.3544	.2835	.2774	.2743
10	.3258	.2601	.3467	.3189	.2915	.2774	.2715
11	.3077	.2947	.3467	.3121	.2658	.2427	.2254
12	.3258	.3294	.3641	.3294	.2835	.2427	.2254
13	.3121	.3814	.3814	.4161	.3155	.2427	.2427
14	.362	.3988	.4161	.4508	.3045	.2427	.2427
15	.3467	.3988	.3988	.4681	.3224	.2427	.208
16	.3475	.3988	.3814	.4508	.3045	.2427	.1907
17	.3475	.3601	.3641	.4075	.2947	.2427	.2254
18	.3121	.3086	.3467	.3544	.2774	.2427	.2427
19	.3467	.3814	.3467	.3898	.3467	.2947	.2774
20	.4508	.4854	.4733	.4784	.4161	.3467	.3121
21	.4854	.5028	.4681	.5144	.4508	.3988	.3294
22	.5201	.5548	.5548		.5201	.4334	.3467
23	.5548	.6068	.5895	.5847	.5201	.443	.3467
24	.5028	.5895	.5895	.6135	.6024	.5548	.4477
Max	.5548	.6068	.5895	.6135	.6024	.5548	.4572
Min	.3077	.2601	.3294	.3121	.2658	.2427	.1907
Avg	.3958	.4331	.4336	.4535	.4007	.3450	.3157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 401 / 33 KV T/F Incomer No.I NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	2.1033	2.2611	2.2085	2.2119	2.0508	1.5775
2	1.6827	1.9982	2.1559	2.1559	2.1091	1.9982	
3	1.5775	1.9982	2.0508	2.0508	2.0576	1.9982	1.5249
4	1.5775	1.9456	1.9456	1.9982	1.9547	1.893	
5	1.4723	1.9456	1.8404	1.893	1.8004	1.7878	1.5249
6	1.4723	1.7878	1.7353	1.7878	1.5947	1.6827	1.5775
7	1.4198	1.6301	1.7353	1.7353	1.5947	1.6827	1.5249
8	1.3672	1.5249	1.4723	1.5249	1.5432	1.5249	1.5249
9	1.4723	1.5249	1.5249	1.5775	.7973	1.5775	1.4723
10	1.5249	1.6827	1.6827	1.7353	1.5947	1.5775	1.4723
11	1.6301	1.893	1.7878	1.893	1.8073	1.6301	1.5775
12	1.8404	1.893	1.9456	1.9982	1.8604	1.6301	1.5775
13	2.0508	1.9982	1.9982	2.0508	1.9667	1.5775	1.6827
14	1.6827	1.9982	1.9982	2.1033	1.9982		1.5249
15	1.6827	1.9982	1.9982	2.1559	1.8404	1.4198	1.5775
16	1.9456	2.0508	1.9982	2.2611	1.8404	1.4198	1.5249
17	1.9982	1.8004	1.8404	2.1262	1.7353		1.5249
18	1.9456	1.5432	1.893	1.9136	1.7353	1.5775	1.5775
19		1.8404	1.9982	2.073	1.9982	1.7353	1.6827
20	2.4188	2.1033	2.1559	2.4451	2.2085	1.9456	1.6301
21	2.3137	2.2085	2.2085	2.3148	1.9982	1.7353	1.4723
22	2.3137	2.2611	2.2611	2.2325	2.0508	1.7878	1.4198
23	2.2611	2.3137	2.4188	2.2857	2.1033	1.701	1.3672
24	1.8404	2.2611	2.2611	2.3137	2.392	2.1033	1.6301
Max	2.4188	2.3137	2.4188	2.4451	2.392	2.1033	1.6827
Min	1.3672	1.5249	1.4723	1.5249	.7973	1.4198	1.3672
Avg	1.7924	1.9294	1.9653	2.0348	1.8664	1.7289	1.5440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 402 / 33 KV T/F Incomer No.II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	1.5775	1.5775	1.6301	1.6496	1.4198	
2	.7888	1.5775	1.4723	1.5775	1.5432	1.3146	1.0517
3	1.3146	1.4723	1.3672	1.4723	1.4918	1.3146	1.0517
4	1.1568	1.4723	1.2094	1.4198	1.3889	1.2094	1.0517
5	1.1043	1.3146	1.1568		1.286	1.2094	.9991
6	1.0517	.9465	1.0517	1.1568	1.1317	1.0517	.9465
7	.8939	.9465	.9465	.9991	.8745	.8939	.8413
8	.7888	.8413	.8939	.8413	.7716	.7888	.7362
9	.8939	.8413	.8939	.8413		.7888	.6836
10	.8413	.7888	.8413	.7888	.7716	.7362	.6836
11	.7888	.8939	.8939	.8413	.7362	.6836	.631
12	.7888	.9465	.9465	.8939	.7888	.6836	.631
13	.8939	1.0517	.9991	.9991	.8413	.6836	.6836
14	.9465	1.1043	1.1568	1.1043	.7888	.6836	.631
15	.9465	1.2094	1.1043	1.2094	.8413	.6836	.5784
16	.9465	1.1043	1.1043	1.2094	.7888	.6836	.5784
17	.8939	1.0802	1.0517	1.0631	.7888	.6836	.631
18	.8939	.9991	.9465	.9568	.7888	.6836	.7362
19	1.0517	1.0517	.9465	1.0517	.9991	.8939	.8413
20	1.262	1.3146	1.262	1.3672	1.1568	.9991	.8413
21	1.4198	1.3146	1.262	1.2346	1.1568	1.0517	.8939
22	1.4723	1.4723	1.5249	1.4883	1.3146	1.0517	.8413
23	1.4723	1.6301	1.6827		1.4198	1.1043	.8939
24	1.3146	1.5775	1.5775	1.6827	1.5947	1.4198	1.0517
Max	1.4723	1.6301	1.6827	1.6827	1.6496	1.4198	1.0517
Min	.4733	.7888	.8413	.7888	.7362	.6836	.5784
Avg	1.0166	1.1887	1.1612	1.1740	1.0832	.9465	.8048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 404 / 33 KV RAPDRP Incomer NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1559	3.8489	3.8386	3.8386	3.8066	3.4705	2.6292
2	2.4714	3.5368	3.6283	3.7334	3.6523	3.3128	2.5766
3	2.8921	3.4328	3.4179	3.5231	3.5494	3.3128	2.5766
4	2.7343	3.3808	3.155	3.4179	3.3436	3.1024	2.5766
5	2.5766	3.2247	2.9973	3.2602	3.0864	2.9973	2.524
6	2.524	2.9127	2.7869	2.9447	2.572	2.7343	2.524
7	2.3137	2.5486	2.6818	2.7343	2.4691	2.5766	2.3663
8	2.1559	2.3663	2.3663	2.3663	2.3148	2.3137	2.2611
9	2.3663	2.3405	2.4188	2.4188	2.3348	2.3405	2.1559
10	2.4434	2.4446	2.524	2.524	2.3663	2.2885	2.1559
11	2.4188	2.7343	2.6818	2.7343	2.6063	2.3405	2.2085
12	2.6292	2.8395	2.8921	2.8921	2.7149	2.3405	2.2085
13	2.9447	3.0498	2.9647	3.0498	2.8778	2.2611	2.3663
14	2.6292	3.1024	3.155	3.2076	2.7869	2.2085	2.1559
15	2.6292	3.2076	3.0687	3.3653	2.6818	2.1033	2.1559
16	2.8921	3.155	3.0687	3.4705	2.6292	2.1033	2.0805
17	2.8921	2.8807	2.8921	3.2579	2.524	2.1559	2.1325
18		2.5206	2.8395	2.9321		2.2611	2.2885
19	1.0402	2.8921	2.9447	3.1493	2.9973	2.6292	4.3644
20	3.6408	3.4179	3.4179	3.8552	3.3653	2.9447	2.4714
21	3.6928	3.5231	3.4705	3.5494	3.1207	2.7869	2.3663
22	3.7449	3.7334	3.786	3.8009	3.3288	2.8395	2.2611
23	3.7334	3.9438	4.1015	3.9638	3.4848	2.7869	2.2611
24	3.155	3.8386	3.8386	3.9963	4.0181	3.5231	2.7343
Max	3.7449	3.9438	4.1015	3.9963	4.0181	3.5231	4.3644
Min	1.0402	2.3405	2.3663	2.3663	2.3148	2.1033	2.0805
Avg	2.7250	3.1198	3.1224	3.2494	2.9840	2.6556	2.4334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 201 / 11kV Ladgaon Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3206	.3395	.3206	.3018	.3018	.2452
2		.3206	.3206	.3206	.3018	.2829	.2452
3		.3018	.3206	.3206	.3018	.2829	.2263
4		.2641	.2829	.3018	.2641	.2641	.2241
5		.2452	.2452	.2829	.2263	.2263	.2054
6		.2075	.2075	.1886	.1698	.1886	.168
7		.1307	.1307	.1307		.1294	.1294
8		.1097	.1109	.128		.1294	.1109
9		.1509	.132	.0905		.1109	.0914
10		.1372	.1638	.1543	.2401	.2315	.0895
11		.16	.16	.1943	.2241	.1372	.0926
12		.1475	.128	.176	.2241	.1406	.0772
13	.1372	.1509	.1311	.2105	.2105	.1389	.0972
14	.1696	.1326	.144	.213	.2241	.1543	.128
15	.1341	.1543	.1492	.2012	.1823	.1134	.0983
16	.1094	.0995	.1296	.213	.1823	.096	.0972
17	.1134	.108	.1094	.176	.1492	.112	.096
18	.1174	.132	.1307	.0924	.1109	.1075	.1254
19	.112	.168	.168	.1109	.1478	.1867	.1663
20	.1526	.2641	.3206	.2641	.2452	.2241	.2033
21	.3206	.3018	.3395	.3206	.2829	.2641	.2075
22	.3395	.3584	.3395	.3206	.3018	.2641	.2054
23	.3395	.3395	.3395	.3206	.3018	.2452	.1867
24		.3206	.3206	.3206	.3018	.3018	.2452
Max	.3395	.3584	.3395	.3206	.3018	.3018	.2452
Min	.1094	.0995	.1094	.0905	.1109	.096	.0772
Avg	.1859	.2094	.2151	.2239	.2331	.1931	.1567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 202 / 11kv Murti Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.4715	.4527	.4338	.3961	.3395
2		.4527	.4715	.4527	.4338	.3772	.3395
3		.4527	.4715	.4338	.415	.3772	.3395
4		.415	.415	.4338	.3961	.3395	.3206
5		.3772	.3395	.3772	.3395	.3206	.3018
6		.3395	.2829	.2829	.2075	.2452	.2641
7		.1698	.2075	.1698	.1509	.1886	.1698
8		.1494	.1698	.1886	.132	.1509	.1886
9		.1698	.1698	.1886	.1698	.1867	.1886
10		.1337	.2134	.2006	.2134	.2115	.1143
11		.0926	.1486	.1907	.1738	.1715	.096
12		.1423	.1252	.1614	.1783	.1593	.1097
13	.1844	.144	.1303	.2134	.1669	.1486	.1158
14	.1677	.144	.132	.1829	.1715	.1204	.096
15	.144	.1457	.1113	.1677	.1572	.1143	.0945
16	.1128	.1389	.1054	.2107	.141	.1014	.1036
17	.1107	.1372	.0903	.1829	.1183	.1014	.0823
18	.0892	.1867	.1848	.1848	.1663	.1848	.1886
19	.1147	.2641	.2829	.2452	.1848	.3018	.2641
20	.1387	.4715	.4715	.4338	.3961	.3584	.3018
21	.5093	.5093	.5093	.4715	.415	.3772	.3018
22	.5093	.5281	.5093	.4527	.4338	.3584	.2829
23	.4527	.4904	.4904	.4338	.415	.3395	.2452
24	.3395	.4527	.4715	.4527	.4338	.3961	.3395
Max	.5093	.5281	.5093	.4715	.4338	.3961	.3395
Min	.0892	.0926	.0903	.1614	.1183	.1014	.0823
Avg	.2394	.29	.2906	.2985	.2685	.2511	.2162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 203 / 11kv Ambada Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2075	.2263	.2263	.2263	.2263	.1886
2		.2075	.2263	.2263	.2263	.2075	.1886
3		.2075	.2075	.2263	.2263	.2263	.1865
4		.1886	.2075	.2075	.2054	.2075	.1844
5		.1698	.1886	.2075	.1867	.1886	.1658
6		.1494	.1509	.1867	.1494	.168	.1475
7			.112	.1463	.1097	.1294	.112
8		.1132	.1294	.1372	.128	.1097	.1094
9		.112	.1294	.1387	.1109	.1267	.1094
10		.1265	.2429	.1783	.3395	.1932	.1303
11		.1505	.1619	.1677	.2591	.1833	.1128
12			.1475	.1406	.2721	.1808	.1067
13		.1457	.1875	.1718	.2315		.1014
14		.128	.1966	.2056	.2439		.1
15	.1265	.1406	.0834	.2214	.2134		.1014
16		.0949	.0389	.2006	.2054		.0869
17	.144	.104		.2372	.0991		.0892
18	.0753	.1014	.1097	.1075	.1109	.1551	.1698
19	.0892	.1509	.1389	.1307	.1307	.1174	.1698
20	.1372	.1886	.168	.1867	.1886	.1355	.1698
21	.2075	.2075	.1867	.2075	.2075	.1593	.1698
22	.2075	.2263	.2427	.1949	.2075	.208	.1698
23	.2075	.2263	.2427	.2075	.2075	.208	.1509
24		.2075	.2075	.2241	.2075	.2263	.1886
Max	.2075	.2263	.2429	.2372	.3395	.2263	.1886
Min	.0753	.0949	.0389	.1075	.0991	.1097	.0869
Avg	.1493	.1616	.1710	.1869	.1956	.1767	.1421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 405 / 33 KV Murti Incomer
Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.4481	.4435	.4481	.3921	.3921
2		.4527	.4481	.4435	.4481	.3921	.3921
3		.4527	.4481	.4435	.3921	.3921	.3361
4		.3961	.3921	.4435	.3921	.3361	.3361
5		.3961	.3361	.3881	.3361	.3361	.3361
6		.3395	.2801	.2772	.2241	.2241	.2801
7		.1698	.2218	.1595	.1595	.168	.2241
8		.1663	.1663	.156	.144	.1629	.2218
9		.1663	.1663	.1646	.1526	.1629	.2218
10		.4218	.6241	.5487	.7968	.535	.3704
11		.427	.4744	.5418	.6401	.4841	.3281
12		.4424	.4744	.463	.703	.5533	.2961
13	.2949	.4424	.4744	.6019	.6093	.503	.2641
14	.3361	.3932	.4801	.6093	.6401	.3018	.3018
15	.3841	.3932	.3749	.5693	.5556	.2486	.2801
16	.2372	.3401	.2915	.6093	.5487	.1943	.2881
17	.3795	.3704	.1875	.6167	.4012	.2229	.2743
18	.2846	.3052	.1595	.1595	.1612	.3401	.168
19	.3481	.2801	.3258	.2241	.1663	.4207	.2829
20	.4681	.4527	.4435	.4527	.3921	.4887	.2829
21	.5093	.5093	.499	.4527	.3921	.4344	.2829
22	.5093	.5041	.499	.4435	.4481	.4481	.2829
23	.4527	.5041	.499	.4435	.3921	.3921	.2263
24	.3395	.4481	.4481	.4435	.4481	.3921	.3921
Max	.5093	.5093	.6241	.6167	.7968	.5533	.3921
Min	.2372	.1663	.1595	.156	.144	.1629	.168
Avg	.3786	.3844	.3818	.4208	.4163	.3552	.2942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 201 / 11 KV MOHPA RURAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3437	.7499	.6024	.7202	.4024	.4481
2	.4207	.3437	.7392	.6024	.6859	.4572	.4481
3	.3856	.3437	.7316	.6024	.6859	.462	.4481
4	.3856	.3437	.695	.6024	.6859	.439	.4668
5	.3506	.3281	.695	.6024	.5487	.4207	.4668
6	.2279	.2968	.5304	.5316	.4458	.3841	
7	.1753	.25	.3361	.3174	.2915	.3658	
8	.1715	.2812	.2987	.2801	.2743	.3353	.1494
9	.2279	.3125	.3361	.2801	.2804	.3201	.112
10	.2915	.3475	.3547	.2743	.2801	.3258	.3361
11	.25	.3881	.3721	.5144	.5344	.2987	.2987
12	.2812	.4066	.4252	.4733	.5182	.3174	.2987
13	.25	.4755	.4252	.4908	.5487	.2987	.2801
14	.4294	.5304	.4252	.5609	.5853	.2801	.2801
15	.4294	.4024	.4252	.5144	.4572	.1307	.2801
16	.3921	.2218	.4252	.5144	.4049	.112	.2801
17	.3361	.2033	.4252	.4908	.3239	.112	.2801
18	.2987	.1663	.6024	.4382	.2915	.1307	.2801
19	.4481	.3696	.7265	.3681	.3547	.4481	.3721
20	.7842	.6908	1.046	.5487	.5415	.5601	.4252
21	.8402	.7468	.8505	.7011	.6722	.6161	.4784
22	.8215	.8413	.6024	.7712	.7282	.6161	.4784
23	.8029	.823	.6024	.7712	.7468	.6348	
24		.7842	.7865	.6024	.7537	.7468	.6348
Max	.8402	.8413	1.046	.7712	.7537	.7468	.6348
Min	.1715	.1663	.2987	.2743	.2743	.112	.112
Avg	.4091	.4267	.5669	.5190	.5150	.3839	.3592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 203 / 11 KV METPANJRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2343	.439	.443	.3681	.4572	.2801
2		.2343	.4024	.443	.3429	.4572	.2801
3	.3856	.2343	.4024	.443	.3429	.3292	.2801
4	.3506	.2187	.4207	.443	.3506	.3109	.2614
5	.3506	.2187	.4066	.443	.3155	.3109	.2614
6	.2454	.1875	.2926	.3544	.2454	.2957	.1677
7	.1402	.1875	.1494	.1698	.1227	.3475	.1867
8	.1227	.1875	.1307	.1509	.1372	.3048	.2241
9	.3856	.2187	.168	.1132	.1372	.2896	.2241
10	.3479	.2218	.1698	.1227	.1307	.3086	.0754
11	.1581	.1848	.3898	.5959	.5182	.0747	.1509
12	.5312	.2033	.3547	.5144	.4858	.1307	.132
13	.3749	.2033	.3547	.3506	.5853	.1307	.1132
14	.1867	.2402	.3898	.4115	.5853	.1307	.0943
15	.2241	.2587	.4075	.5258	.5487	.1307	.0943
16	.2241	.2587	.443	.4908	.3887	.112	.1132
17	.1494	.2218	.4252	.5258	.2915	.112	.1132
18	.1307	.1478	.3361	.5258	.2267	.1307	.132
19	.2054	.2218	.567	.1753	.1867	.2054	.1698
20	.3734	.3174	.7973	.3155	.2801	.2427	.2054
21	.4108	.4108	.8745	.3856	.3734	.2987	.2614
22	.4481	.4207	1.0631	.4207	.3921	.3174	.2801
23	.4481	.4572	.443	.4207	.4108	.3361	
24		.4294	.439	.443	.4031	.3921	.3361
Max	.5312	.4572	1.0631	.5959	.5853	.4572	.3361
Min	.1227	.1478	.1307	.1132	.1227	.0747	.0754
Avg	.2949	.2550	.4278	.3845	.3404	.2565	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 204 / 11KV BUDHLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241	.2587	.443	.3155	.1848	.1867
2		.2241	.2587	.443	.3361	.1663	.1867
3		.2241	.2801	.443	.2743	.1478	.168
4		.1867	.2587	.443	.2804	.1478	.168
5		.1494		.443	.3734	.1294	.168
6	.0175	.112	.2743	.443	.4854	.1109	
7	.0175	.0934	.2743	.5138	.5258	.0924	
8	.0171	.0934	.4115	.5316	.631	.0934	.0373
9	.0175	.0934	.3772	.6024	.6836	.0747	.0373
10	.037	.0924	.4075	.5784	.583	.0934	
11	.0312	.3511	.1509	.0701	.1494	.2801	
12	.0324	.3658	.2241	.1448	.1494	.0373	
13	.0486	.3292	.2241	.1578	.1663	.0934	
14	.0343	.3475	.2427	.1753	.1109	.0934	
15	.2591	.3658	.2241	.1753	.1478	.2241	
16	.2915	.3841	.2241	.1578	.112	.1867	
17	.2915	.3881	.2054	.1402	.0934	.2241	
18	.2591	.3881	.2241	.0701	.0934	.2427	
19	.1307	.1848	.2241	.1227	.1307	.1307	
20	.2241	.2241	.2241	.1578	.168	.1867	
21	.2241	.2614	.2427	.2103	.1867	.1867	
22	.2427	.2587	.2427	.2103	.2054	.1867	
23	.2241	.2218	.2427	.1928	.1867	.1867	
24		.2241	.2402	.2241	.1753	.1867	.1867
Max	.2915	.3881	.4115	.6024	.6836	.2801	.1867
Min	.0171	.0924	.1509	.0701	.0934	.0373	.0373
Avg	.1333	.2412	.2581	.2956	.2735	.1536	.1423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 205 / 11 KV GINNI AGRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1698		.0943	.3018	.4001	.3395
2	.1132	.1698	.1905	.0943	.3018	.4001	.3361
3	.1132	.1698	.1715	.0943	.3018	.4001	.3361
4	.1132	.1698	.1905	.0943	.3018	.381	.1509
5	.1132	.1698	.1715	.0943	.3018	.3429	.132
6	.0943	.1698	.1143	.0943	.1132	.0953	.1132
7	.1132	.132	.132	.0943	.1132	.0762	.132
8	.1132	.1132	.1698	.1132	.1132	.1132	.1494
9	.0943	.0754	.3018	.0943		.1886	.1494
10	.1132	.1524	.2054	.0943	.0754	.1886	
11	.1132	.2286	.1509	.0943	.132	.2263	
12	.0943		.0943	.0943	.0943	.1886	
13	.0943	.0762	.132	.0943	.1143	.1698	
14	.1132	.1143	.132		.2286	.1509	
15	.1132	.1715	.1509	.0754	.2667	.1698	
16	.1132	.2477	.1509	.1886	.2452	.3018	
17	.0943	.2858	.1509	.0754	.2075	.3018	
18	.1132	.3048	.132	.1307	.1886	.1509	
19	.132	.381	.0943	.1509	.2263	.1886	
20	.132	.1132	.0943	.1132	.1698	.1494	
21	.132	.0943	.0943	.1132	.0943	.1698	
22	.132	.1905	.0943	.2829	.3961	.3395	
23	.1886	.2096	.1132	.3206	.3961	.3395	
24		.1698	.1905	.0943	.3018	.3961	.3395
Max	.1886	.381	.3018	.3206	.3961	.4001	.3395
Min	.0943	.0754	.0943	.0754	.0754	.0762	.1132
Avg	.1165	.1774	.1488	.1213	.2168	.2429	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 206 / Mohapa Urban Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228		.0187	.0189	.0187	.0187	.0187
2	.5228		.0187	.0189	.0187	.0187	.0187
3	.4854		.0187	.0189	.0187	.0187	.0187
4	.4854		.0187	.0189	.0187	.0187	.0187
5	.4854		.0187	.0189	.0187	.0187	.0187
6	.4481		.0187	.0189	.0187	.0187	.0187
7	.3547		.0187	.0189	.0187	.0187	.0187
8	.2987		.0187	.0189	.0187		.0187
9	.3361		.0187	.0189	.0187		.0187
10	.3511	.0187	.0189	.0175		.0187	
11	.3429	.0187	.0189	.0187		.0187	
12		.0187	.0189	.0187		.0187	
13		.0187	.0189	.0187	.0187	.0187	
14		.0187	.0189	.0187	.0187	.0187	
15		.0187	.0189	.0187	.0187	.0187	
16		.0187	.0189	.0187		.0187	
17		.0187	.0189	.0187		.0187	
18		.0187	.0189	.0187		.0187	
19		.0187	.0189	.0187		.0187	
20		.0187	.443	.0187		.0187	
21		.0187	.5138	.0187		.0187	
22		.0187	.5493	.0187		.0187	
23		.0187	.0189	.0187		.0187	
24			.0187	.0189	.0187		.0187
Max	.5228	.0187	.5493	.0189	.0187	.0187	.0187
Min	.2987	.0187	.0187	.0175	.0187	.0187	.0187
Avg	.4212	.0187	.0792	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 201 / 11 KV Kumari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.5121	.4835	.6447	.5487	.2896
2		.3772	.4252	.4656	.6089	.5487	.2896
3		.3429	.3841	.4656	.591	.4572	.2896
4		.3429	.3721	.4298	.5552	.4024	.2715
5		.3086	.3658	.4119	.5194	.3898	.2715
6		.2915	.3189	.3258	.3761	.4024	
7		.2401		.2218	.2303	.2658	
8		.4287	.4252	.2218	.197	.1829	.1629
9		.3086	.4075	.2402	.1433	.1829	.2534
10			.3801	.2587	.2149	.2195	.2172
11		.1829	.2957	.4694	.5487		.1865
12		.3077	.3326	.5197			
13	.4801	.3475	.4024	.5533	.2926		
14	.463	.4024	.4207	.5197	.5609		.1865
15	.3944	.4755	.3511	.4527	.6024	.0686	.2035
16	.3086	.3841	.3841	.4862	.5487	.1543	
17	.2743	.2835		.5197	.4706	.2572	
18	.2572	.2378		.503	.3898	.2572	.1865
19	.362	.3012		.2303	.2126	.2743	.1696
20	.543	.4887		.4656	.3856	.2915	.2401
21	.6516	.567		.567	.443	.3086	.2204
22	.5792	.6767		.6626	.567	.3086	.2204
23	.5792	.6697	.4887	.6626	.5959	.3086	.2204
24		.5611	.6584	.4835	.6447	.5847	.2915
Max	.6516	.6767	.6584	.6626	.6447	.5847	.2915
Min	.2572	.1829	.2957	.2218	.1433	.0686	.1629
Avg	.4448	.3886	.4073	.4425	.4497	.3207	.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 202 / nandikheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3189	.3681	.4784	.3544	.1991
2		.3429	.3366	.3506	.4656	.3544	.1886
3		.3086	.3475	.3506	.4477	.3658	.1715
4		.2743	.3189	.3366	.4298	.2658	.1715
5		.2401	.2658	.3045	.3582	.2195	.1543
6		.2058	.2303	.2149	.2865	.2195	.1543
7		.2058	.2561	.2218	.1791	.1829	.1543
8		.2229	.2658	.2054	.1949	.1646	.1715
9		.2401	.3475	.2241	.1791		.2058
10		.1886	.2715	.2427	.1791	.0732	.1886
11		.2534	.2401	.4024	.4607	.1029	.1612
12		.2195	.1886	.4862	.5493	.1372	.0716
13	.0514	.2126	.2572	.4862	.567		.0716
14	.0686	.2012	.2229	.4578	.5487	.1886	.1254
15	.2058	.2658	.3174	.1187	.5138	.1886	.1433
16	.2572	.2481	.2987	.407	.4607	.1886	.1791
17	.2743	.2195		.3224	.4572	.1715	.1791
18	.1886	.2012		.4409	.4075	.2058	.1791
19	.2896	.2454		.2328	.2353	.2572	.2507
20	.4163	.4163		.4298	.3841	.3439	.3403
21	.4706	.4784		.4835	.4075	.3772	.3403
22	.5068			.5194	.4607	.3982	.3582
23	.4887	.3475	.3881	.4835	.4607	.3982	.3403
24		.4706	.3292	.3681	.4835	.443	.3801
Max	.5068	.4784	.3881	.5194	.567	.443	.3801
Min	.0514	.1886	.1886	.1187	.1791	.0732	.0716
Avg	.2925	.2762	.2890	.3524	.3998	.2546	.2033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 203 / Mohapa Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.543	.5487	.5609	.5487	.4755	.3982
2		.5068	.5121	.5609	.5316	.4755	.3982
3		.4887	.5068	.5258	.5316	.4755	.362
4		.4706	.4755	.5258	.5144	.4207	.362
5		.4525	.4525	.4908	.4973	.4207	.362
6		.4525	.4706	.4557	.4458	.4207	.362
7		.362	.362	.3544	.3429	.3658	.2715
8		.3258	.3077	.3012	.3086	.3292	.2715
9		.3077	.3077	.2481	.2915	.3109	.2715
10		.362	.3475	.2835	.2915	.2926	.2896
11		.333	.3544	.3772	.362	.2172	.2572
12	.362	.3801	.3366	.3601	.3475	.2534	.2058
13	.3982	.4572	.4075	.463	.3841		.2743
14	.3801	.4207	.4252	.4287	.4024	.2172	.3601
15	.362	.439	.443	.4287	.4031	.2353	.2401
16	.3982	.4207	.443	.3944	.3841	.2715	.2401
17	.3982	.3982		.3772	.3544	.2896	.2915
18	.362	.3982		.3601	.3841	.3439	.3258
19	.2896	.3898		.3944	.4344	.3982	.3601
20	.5068	.4733		.4973	.439	.4163	.4115
21	.5068	.4961		.5144	.4525	.4344	.3772
22	.5611	.5304		.5144	.4887	.4344	.3772
23	.5792	.5493	.5784	.5316	.5487	.4344	.3601
24		.5792	.567	.5609	.5487	.5304	.4344
Max	.5792	.5792	.5784	.5609	.5487	.5304	.4344
Min	.2896	.3077	.3077	.2481	.2915	.2172	.2058
Avg	.4254	.4390	.4359	.4379	.4266	.3680	.3277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 204 / TELKAMTHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181	.1949		.1696	.1772	.1448
2		.1629	.1595		.1696	.1829	.1086
3		.1448	.1646		.1696	.1772	.1086
4		.1448	.1646		.1526	.1829	.1086
5		.1267	.1417		.1526	.1829	.1086
6		.1267	.1463		.1357	.128	.1086
7		.0905	.0914		.1174	.1463	.0905
8		.0905	.0709		.1509	.1463	.0724
9		.0543	.0732		.1677	.124	.0724
10		.0724	.0532		.1017		.0724
11		.1063	.104	.1075	.0732	.0686	.0678
12	.0514	.0914	.12	.1075	.0886	.0686	.0848
13	.1029	.1097	.1372	.1075	.1097		.0838
14	.1029	.1097	.1543	.1433	.0914	.0686	.0848
15	.0857	.0709	.1543	.1254	.1097	.0686	.0678
16	.1029	.0886	.1372	.1254	.0914	.0724	.0509
17	.0857	.0914		.0895	.0732	.0724	
18	.0857	.0886		.0709	.0724	.0905	.0671
19	.1086	.0886		.0716	.0886	.1267	.1075
20	.1629	.1595		.1612	.1463	.1448	.1254
21	.2172	.1949		.1791	.1829	.1629	.1433
22	.2353	.2195		.2149	.2012	.181	.1433
23	.2353	.2126		.2328	.2195	.181	.1612
24		.2172	.2303		.2149	.2195	.181
Max	.2353	.2195	.2303	.2328	.2195	.2195	.181
Min	.0514	.0543	.0532	.0709	.0724	.0686	.0509
Avg	.1314	.1268	.1352	.1336	.1354	.1352	.1028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 205 / KANIYADOL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362	.3189	.3258	.3018	.3658	.3258
2		.3258	.2835	.3258	.3052	.3658	.2896
3		.2896	.2896	.3086	.3052	.2743	.2534
4		.2715	.2658	.3086	.3018	.2743	.2172
5		.2534	.2658	.3086	.3018	.1829	.2172
6		.2353	.2743	.3258	.3052	.1417	.2172
7		.181		.407	.3521	.1063	.181
8		.1267		.4694	.3856	.0732	.1629
9		.1267	.1463	.5197	.3856		.1629
10		.181	.2012	.4694	.373		.1448
11		.2012	.2915	.2149	.1829	.0543	.1017
12	.1029	.2195	.3258	.2328	.2012	.0514	.1017
13	.1372	.2126	.2915	.2686	.2012		.061
14	.1372	.2303	.2572	.2686	.1829	.0543	.0339
15	.12	.2481	.2915	.2507	.1829	.0543	.0509
16	.1372	.2303	.2401	.2149	.1772	.0543	.1017
17	.1543	.2481		.1612	.1463	.181	.1187
18	.1543	.2658		.1791		.2172	.0848
19	.1991	.1063		.1254	.1772	.2534	.1612
20	.2896	.2835		.3045	.2926	.3077	.2328
21	.4706	.3721		.3761	.3189	.3258	.2507
22	.4163	.4075		.4477	.3841	.362	.2865
23	.362	.4075	.4251	.4298	.3721	.362	.2686
24		.3982	.3544	.3856	.4119	.3841	.3439
Max	.4706	.4075	.4251	.5197	.4119	.3841	.3439
Min	.1029	.1063	.1463	.1254	.1463	.0514	.0339
Avg	.2234	.2577	.2827	.3179	.2847	.2117	.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 201 / 11 KV BELONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8383	.8002	.8573	.7811	.5716	.6478
2	.6859	.8192	.8002	.8383	.743	.743	.6097
3	.6478	.8002	.7811	.8192	.7049	.743	.6097
4	.3429	.8002	.7811	.8192	.6668	.743	.6287
5	.3429	.381	.6287	.724	.6287	.6859	.5144
6	.3048	.2667	.4954	.6097	.6097	.6097	.4572
7	.2477	.2286	.2477	.4763	.5144	.4382	.381
8	.2667	.2286	.2667	.4191	.4191	.4382	.2667
9	.2667	.2477	.2286	.4001	.4001	.4382	.3239
10	.2667	.2667	.2096	.4001	.381		.2858
11	.4001	.2667	.2477	.4191	.3429		
12	.4001	.2858	.1905	.4382	.3239		.2096
13	.4763	.5716	.4763	.362	.3239	.2286	.2667
14	.724	.6097	.4763	.3048	.3239	.2286	.3239
15	.5716	.6097	.4954	.2858	.3239	.2286	.3239
16	.4382	.5906	.4954	.2667	.3239	.2286	.3239
17	.4382	.5906	.4572	.2667	.3239	.2477	.3048
18	.4382	.4191	.4001	.3048	.3239	.2477	.3239
19	.6668	.6097		.3048	.3048	.2667	.4572
20	.743	.6478	.6859	.3048	.3048	.2667	.5906
21	.7621	.7621	.8192	.7621	.7621	.2667	.5906
22	.8192	.8573	.8954	.8383	.8192	.6859	.5716
23	.8573	.8192	.8764	.8383	.8192	.6859	.5906
24	.7621	.8383	.8002	.8573	.8192	.8002	.6859
Max	.8573	.8573	.8954	.8573	.8192	.8002	.6859
Min	.2477	.2286	.1905	.2667	.3048	.2286	.2096
Avg	.5247	.5565	.5459	.5382	.5120	.4663	.4473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 203 / 11 KV MOWAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.6287	.5716	.6287	.5906	.5335	.381
2	.4001	.6097	.5335	.6287	.5906	.5144	.3429
3	.4001	.5906	.4954	.6097	.5716	.5144	.3429
4	.381	.5906	.4572	.6097	.5525	.5144	.4001
5	.362	.4763	.4191	.5335	.4954	.4763	.3239
6	.362	.4382	.381	.4191	.4001	.4572	.3239
7	.362	.381	.362	.3429	.3239	.4572	.2858
8	.3429	.2858	.3048	.2858	.2667	.3429	.2667
9	.3429	.3048	.3048	.3048	.2858	.2477	.2667
10	.3239	.3429	.3239	.2858	.3048		.2858
11	.3429	.381	.3429	.3239	.3048		.2667
12	.381	.4191	.4001	.3429	.3239		.2286
13	.4001	.4572	.4191	.4001	.3429	.2858	.2286
14	.4382	.4954	.4382	.4572	.3429	.2667	
15	.4382	.5144	.4763	.4191	.381	.2667	
16	.4191	.5144	.4763	.381	.381	.2477	.2477
17	.381	.5144	.4382	.381	.5335	.2858	.2477
18	.2858	.3429	.3239	.3429	.2858	.2667	.2858
19	.381	.362	.381	.4572	.381	.3239	.3239
20	.5525	.4954	.4954	.5525	.4382	.4001	.381
21	.5716	.5335	.5335	.5525	.4954	.4382	.381
22	.6097	.6287	.5906	.5716	.5716	.4572	.4001
23	.6478	.6287	.6478	.5906	.5525	.4572	.4001
24		.6287	.6097	.6478	.6097	.5335	.4001
Max	.6478	.6287	.6478	.6478	.6097	.5335	.4001
Min	.2858	.2858	.3048	.2858	.2667	.2477	.2286
Avg	.4150	.4819	.4469	.4612	.4303	.3946	.3187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 204 / 11 KV MANIKWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.381	.4001	.381	.3429	.362
2		.362	.362	.381	.362	.3239	.3429
3		.362	.362	.381	.3429	.3239	.3429
4		.362	.362	.381	.3239	.362	.3429
5		.3239	.3429	.3429	.3048	.3048	.2858
6		.2667	.3239	.2667	.2667	.2667	.2477
7		.2858	.3048	.1905	.2477	.2286	.2286
8		.3048	.3429	.2477	.2286	.2286	.2096
9		.3429	.3048	.2286	.2286	.2096	.2286
10		.3429	.2858	.2096	.2286		.2286
11		.362	.2858	.2096	.1905		.2096
12		.381	.3048	.2286	.1143		.1905
13			.2477	.3239	.1905	.2477	.1905
14		.1715	.2858	.4191	.2286	.2286	.2096
15	.1905	.2477	.2667	.4001	.3239	.2286	.2286
16	.2477	.2286	.2667	.381	.3239	.2286	.2096
17	.2477	.2286	.2286	.381	.3429	.1905	.2096
18	.2477	.2286	.2096	.4191	.3048	.2286	.2286
19	.2667	.2667	.2667	.4191	.3239	.2286	.2667
20	.2858	.3429	.362	.4382	.3429	.2477	.3048
21	.362	.381	.4001	.4001	.362	.2667	.3239
22	.381	.381	.4191	.381	.381	.362	.3239
23	.4001	.381	.4001	.381	.381	.362	.3429
24		.381	.381	.4001	.4001	.3429	.381
Max	.4001	.381	.4191	.4382	.4001	.362	.381
Min	.1905	.1715	.2096	.1905	.1143	.1905	.1905
Avg	.2921	.3181	.3207	.3421	.2969	.2740	.2683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 205 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0381	.0381	.0381	.0191	.0191
2		.0381	.0381	.0381	.0191	.0191	.0191
3	.0191	.0191	.0572	.0381	.0191	.0191	.0191
4	.0381	.0191	.0572	.0381	.0191	.0191	.0191
5	.0381	.0191	.0381	.0381	.0191	.0191	.0191
6	.0572	.0191	.0381	.0381	.0381	.0191	.0191
7	.0572	.0572	.0572	.0381	.0381	.0191	.0381
8	.0572	.0572	.0572	.0572	.0381	.0191	.0381
9	.0572	.0572	.0572	.0572	.0381	.0191	.0381
10	.0572	.0572	.0572	.0191	.0381		.0381
11	.0572	.0572	.0572	.0381	.0381		.0381
12	.0572	.0572	.0572	.0572	.0381		.0381
13	.0572	.0572	.0572	.0572	.0381	.0381	.0572
14	.0572	.0381	.0381	.0381	.0381	.0381	.0572
15		.0572	.0381	.0381	.0381	.0381	.0381
16	.0572	.0572	.0191	.0191	.0381	.0191	.0381
17	.0572	.0572	.0191	.0191	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0191		.0381
20	.0381	.0381	.0572	.0191	.0191	.0381	.0381
21	.0381	.0381	.0381	.0381	.0191	.0191	.0381
22	.0572	.0381	.0191	.0381	.0191	.0191	.0381
23	.0572	.0572	.0381	.0381	.0191	.0191	.0381
24	.0191	.0572	.0381	.0381	.0381	.0191	.0191
Max	.0572	.0572	.0572	.0572	.0381	.0381	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0481	.0453	.0437	.0381	.0310	.0248	.0342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 206 / 11 KV BORKHEDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0572	.0381	.0381	.0191	.0381
2		.0381	.0572	.0381	.0191	.0191	.0381
3		.0381	.0572	.0381	.0191	.0191	.0381
4		.0381	.0572	.0381	.0191	.0191	.0381
5		.0381	.0381	.0572	.0381	.0191	.0381
6		.0381	.0191	.0572	.0572	.0191	.0381
7		.0191	.0191	.0572	.0572	.0381	.0381
8		.0191	.0191	.0572	.0572	.0381	.0381
9		.0381	.0191	.0572	.0381	.0381	.0381
10	.0191	.0381	.0191	.0381	.0381		.0381
11	.0191	.0191	.0191	.0381	.0381		.0191
12	.0191	.0191		.0572	.0381		.0191
13	.0191	.0381		.0572	.0381	.0191	.0381
14	.0381	.0381		.0381	.0381	.0191	.0572
15	.0381	.0381	.0572	.0381	.0191		.0381
16	.0381	.1334	.0572	.0381	.0191	.0381	.0381
17	.0381	.0381	.0572	.0381	.0191	.0191	.0381
18	.0381	.0381	.0381	.0381	.0191	.0191	.0381
19	.0381	.0572	.0572	.0381	.0191	.0381	.0381
20	.0381	.0381	.0572	.0381	.0191	.0191	.0381
21	.0381	.0381	.0381	.0381	.0191	.0381	.0381
22	.0381	.0381	.0381	.0381	.0191	.0381	.0381
23	.0381	.0381	.0381	.0381	.0191	.0381	.0381
24		.0381	.0572	.0381	.0381	.0191	.0381
Max	.0381	.1334	.0572	.0572	.0572	.0381	.0572
Min	.0191	.0191	.0191	.0381	.0191	.0191	.0191
Avg	.0327	.0397	.0418	.0437	.0310	.0267	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV NARKHED URBAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.6118	1.7147	1.8099	1.6118	1.1431
2	1.3432	1.7147	1.6118	1.7147	1.8099	1.6118	1.1431
3	1.3432	1.7147	1.5223	1.6194	1.7147	1.4327	1.1431
4	1.2536	1.5242	1.4327	1.6194	1.7147	1.4327	1.1431
5	1.1641	1.3336	1.2536	1.2384	1.5242	1.2536	1.0479
6	1.0745	1.2384	1.0745	1.1431	1.3336	1.2536	.9526
7	1.0745	1.1431	.8954	1.0479	1.1431	1.0745	.9526
8	.8954	1.0479	.8954	.9526	1.1431	.985	.9526
9	.985	1.0479	.8954	1.1431	1.1431	.8954	.9526
10	.985	1.1431	.8954	1.1431	1.1431	.8954	.9526
11	1.1431	1.1431	1.0479	1.1641	1.1431	1.0479	.8954
12	1.1431	1.1431	1.1431	1.2536	1.1431	1.0479	.8954
13	1.2384	1.2384	1.1431	1.4327	1.1431	1.1431	.8059
14	1.3336	1.3336	1.1431	1.4327	1.1431	1.0479	.8954
15	1.3336	1.3336	1.1431	1.4327	1.1431	.9526	.8954
16	1.2384	1.3336	.7621	1.4327	1.1431	.9526	.985
17	1.2384	1.2536	1.0479	1.3336	1.0745	1.1431	1.0745
18	1.1431	1.0745	.9526	1.1431	1.0745	1.1431	.8954
19	1.5242	1.2536	1.2384	1.4289	1.2536	1.2384	1.0745
20	1.7147	1.4327	1.4289	1.6194	1.4327	1.3336	1.0745
21	1.8099	1.6118	1.6194	1.7147	1.4327	1.3336	1.0745
22	1.7147	1.6118	1.7147	1.8099	1.4327	1.2384	1.0745
23	1.7147	1.6118	1.7147	1.8099	1.6118	1.1431	.985
24		1.7147	1.6118	1.7147	1.8099	1.6118	1.1431
Max	1.8099	1.7147	1.7147	1.8099	1.8099	1.6118	1.1431
Min	.8954	1.0479	.7621	.9526	1.0745	.8954	.8059
Avg	1.2913	1.3630	1.2416	1.4191	1.3525	1.2010	1.0063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV YENIKONI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0154	.0191	.0191	.0154	.0191
2	.0154	.0191	.0154	.0191	.0191	.0154	.0191
3	.0154	.0191	.0154	.0191	.0191		.0191
4	.0154	.0191	.0154	.0191	.0191	.0154	.0191
5	.0154	.0191	.0154	.0191	.0191	.0154	.0191
6	.0154	.0191	.0154	.0191	.0191	.0154	.0191
7	.0154	.0191	.0154	.0191	.0191	.0154	.1334
8	.1372	.0191	.0154	.0191	.0191	.0154	.1524
9	.0154	.0191		.0191	.0191	.0154	
10	.0154		.0154	.0191	.0191	.0154	
11	.0191	.0191	.0191	.0154	.0191	.0191	.0154
12	.0191	.1715	.0191	.0154	.0191	.0191	.0154
13	.0191	.1524	.2667	.2469	.3239	.0191	.0154
14	.0191	.1524	.2477	.2778	.3429	.0191	.0154
15	.0191	.0191	.2477	.2623	.3429	.0191	.0154
16	.0191	.0191	.2286	.2469	.3048	.0191	.0154
17	.0191	.0154	.2096	.3048		.0191	.0154
18	.0191	.0154	.2096	.3048	.1698	.0191	.0154
19	.0191	.0154	.1905	.3239	.1698	.0191	.0154
20	.0191	.0154	.1715	.3239	.1698	.0191	.0154
21	.0191	.0154	.0191	.0191	.0154	.0191	.0154
22	.0191	.0154	.0191	.0191	.0154	.0191	.0154
23	.0191	.0154	.0191	.0191	.0154	.0191	.0154
24		.0191	.0154	.0191	.0191	.0154	.0191
Max	.1372	.1715	.2667	.3239	.3429	.0191	.1524
Min	.0154	.0154	.0154	.0154	.0154	.0154	.0154
Avg	.0231	.0362	.0879	.1079	.0921	.0175	.0282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV NARKHED RURAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0166	.0191	.0191	.0166	.0191
2		.0191	.0166	.0191	.0191	.0154	.0191
3		.0191	.0166	.0191	.0191	.0166	.0191
4		.0191	.0166	.0191	.0191	.0154	.0191
5		.0191	.0166	.0191	.0191	.1823	.0191
6		.0191	.0166	.0191	.0191	.1823	.0191
7		.0191	.0166	.0191	.0191	.1989	.0191
8		.0191	.0166	.0191	.0191	.1658	.0191
9		.0191	.0166	.0191	.0191	.1492	.0191
10		.0191	.0166	.0191	.0191	.1492	.0191
11		.1715	.0191	.0166	.0191	.1715	.0166
12		.1905	.0191	.0166	.0191	.1524	.0166
13		.0191	.362	.4144	.362	.0191	.0166
14		.0191	.3429	.431	.381	.0191	.0166
15		.0191	.3429	.431	.381	.0191	.0166
16	.1524	.0191	.3239	.431	.2667	.0191	.0166
17	.1715	.0166	.3429	.5144	.1823	.0191	.0166
18	.1905	.0166	.3429	.5144	.1989	.0191	.0166
19	.0191	.0166	.2858	.4763	.1823	.0191	.0166
20	.0191	.0166	.2477	.4382	.1823	.0191	.0166
21	.0191	.0166	.0191	.0191	.0166	.0191	.0166
22	.0191	.0166	.0191	.0191	.0166	.0191	.0166
23	.0191	.0166	.0191	.0191	.0166	.0191	.0166
24		.0191	.0166	.0191	.0191	.0166	.0191
Max	.1905	.1905	.362	.5144	.381	.1989	.0191
Min	.0191	.0166	.0166	.0166	.0166	.0154	.0166
Avg	.0762	.0319	.1195	.1646	.1014	.0684	.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV SARDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0474	.0762	.0762	.0474	.0572
2	.0474	.0762	.0474	.0762	.0762	.0474	.0572
3	.0474	.0762	.0474	.0762	.0762	.0474	.0572
4	.0474	.0762	.0474	.0762	.0572	.0474	.0381
5	.0158	.1905	.0316	.0381	.0572	.1898	.0381
6	.0158	.2096	.0158	.0191	.0191	.1898	.0191
7	.2214	.2286	.0158	.0191	.0191	.2056	.1334
8		.2096	.0158	.0191	.0191	.2214	.1715
9		.2096		.0191	.0191	.2056	.2286
10	.1265	.2096	.0158	.0191	.0191	.2056	.2096
11	.1715	.2096	.0191	.0158	.0191	.2286	.1423
12	.1905	.1715	.0191	.0158	.0191	.2096	.1423
13	.0191	.0191	.3239	.3795	.4001	.0191	.0158
14	.0191	.0191	.3429	.3953	.4382	.0191	.0158
15	.0191	.0191	.3239	.3795	.4382	.0191	.0158
16	.0191	.0191	.3239	.3479	.4572	.0191	.0158
17	.0191	.0158	.3429	.4763	.2372	.0191	.0158
18	.0191	.0158	.3429	.5144	.2214	.0191	.0158
19	.0572	.0474	.3239	.4763	.2214	.0381	.0474
20	.0572	.0474	.3239	.4001	.2214	.0572	.0474
21	.0762	.0633	.0762	.0762	.0633	.0572	.0474
22	.0762	.0633	.0762	.0762	.0633	.0572	.0474
23	.0762	.0633	.0762	.0762	.0633	.0572	.0474
24		.0762	.0633	.0762	.0762	.0633	.0572
Max	.2214	.2286	.3429	.5144	.4572	.2286	.2286
Min	.0158	.0158	.0158	.0158	.0191	.0191	.0158
Avg	.0671	.1005	.1419	.1727	.1407	.0954	.0702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV KHARSOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)
1		.0762
2		.0762
3		.0762
4		.0762
5		.0381
6		.0191
7		.0191
8		.0191
9		.0191
10		.0191
11		.0191
12		.0191
13		.0164
14		.0164
15		.0164
16		.0164
17		.0164
18	.0191	.0164
19	.0191	.0164
20	.0191	.0164
21	.0762	.0572
22	.0762	.0572
23	.0762	.0572
24		.0762
Max	.0762	.0762
Min	.0191	.0164
Avg	.0477	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV PARSODI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0316	.0381	.0381	.0316	.0381
2	.0316	.0381	.0316	.0381	.0381	.0316	.0381
3	.0316	.0381	.0316	.0381	.0381	.0316	.0381
4	.0316	.0381	.0316	.0381	.0381	.0316	.0381
5	.0316	.0381	.1739	.1715	.2286	.0316	.0191
6	.0158	.0191	.1898	.1905	.2667	.0316	.0191
7	.0158	.0191	.2056	.2286	.3239	.0158	.0191
8	.0158	.0191	.2372	.2858	.3048	.0158	.0191
9	.0158	.0191	.2294	.2858	.3239	.0158	.0191
10	.0158	.0191	.2056	.3239	.3239	.0158	.0191
11	.0191	.0191	.2286	.2688	.3048	.0191	.0158
12	.0191	.0191	.2096	.253	.2858	.0191	.0158
13	.1143	.2096	.0381		.0191	.1334	.0633
14	.1334	.1905	.0381	.0316	.0191	.1334	.0791
15	.1334	.2286	.0381	.0316	.0191	.1143	.0791
16	.1334	.2667	.0381	.0316	.0381	.1143	.0949
17	.1905	.2056	.0191	.0381	.0158	.1524	.0949
18	.2096	.2372	.0191	.0381	.0158	.1715	.0633
19	.2096	.2056	.0381	.0381	.0316	.1143	.0791
20	.1905	.1739	.0381	.0381	.0316	.0953	.0791
21	.0381	.0316	.0381	.0381	.0316	.0381	.0316
22	.0381	.0316	.0381	.0381	.0316	.0381	.0316
23	.0381	.0316	.0381	.0381	.0316	.0381	.0316
24		.0381	.0316	.0381	.0381	.0316	.0381
Max	.2096	.2667	.2372	.3239	.3239	.1715	.0949
Min	.0158	.0191	.0191	.0316	.0158	.0158	.0158
Avg	.0760	.0906	.0925	.1113	.1182	.0611	.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 207 / 11 kv Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1372	.1905	.1715	.1543	.0572
2	.3429	.2096	.1372	.1905	.1715	.1372	.0572
3	.3086	.1905	.1543	.1715	.1524	.1372	.0572
4	.2743	.1524	.1543	.1715	.1524	.1372	.0572
5	.2401	.1524	.1543	.1905	.1524	.12	.0762
6	.2572	.1334	.1372	.2667	.1715	.12	.0762
7	.2572	.1905	.1372	.2286	.1524	.1029	.0762
8	.12	.2667	.1543	.2096	.3429	.0857	.0762
9	.1886	.381	.2058	.1524	.4572	.2743	.2286
10	.2688	.5144	.2915	.2667	.5144	.2743	.3048
11	.4191	.7621	.3239	.2229	.6097	.3048	.2572
12	.4954	.6668	.3048	.2058	.6668	.3048	.2915
13	.4954	.5716	.3239	.1543	.6478	.2858	.2572
14	.4954	.5335	.3239	.1715	.6097	.2858	.2743
15	.4954	.6097	.2858	.2401	.5716	.2858	.2915
16	.5716	.6668	.1905	.2915	.5335	.2858	.3258
17	.5716	.583	.1905	.2858	.1543	.2667	.3601
18	.1334	.5658	.1905	.2286	.0857	.2667	.2915
19	.1334	.3086	.1905	.2477	.1372	.1905	.1372
20	.1334	.1715	.2096	.2477	.1715	.0953	.1029
21	.1905	.1543	.2477	.2286	.1886	.0762	.1372
22	.2096	.1372	.2667	.2286	.2058	.0572	.1543
23	.2286	.1372	.2667	.1905	.1715	.0572	.1715
24		.2286	.12	.2096	.1715	.1543	.0572
Max	.5716	.7621	.3239	.2915	.6668	.3048	.3601
Min	.12	.1334	.12	.1524	.0857	.0572	.0572
Avg	.3105	.3541	.2124	.2163	.3068	.1858	.1740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 208 / 11 KV YENIKONI II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1638	.2477	.2096	.1475	.1524
2	.1311	.1905	.1638	.2477	.1905	.1475	.1524
3	.1265	.1905	.1638	.2477	.1905	.1475	.1524
4	.1107	.1905	.1638	.2286	.1715	.1475	.1524
5	.0983	.4954	.1475	.1905	.1334	.4915	.1143
6	.0819	.5335	.1147	.1334	.1143	.5243	.0762
7	.4096	.5144	.0655	.0953	.0762	.5571	.3239
8	.4588	.5144	.0474	.0572	.0572	.5735	.381
9	.3953	.5144	.0492	.0762	.0572	.5243	.4001
10	.3932	.4954	.0655	.1143	.0762	.1966	.362
11	.4572	.4954	.0762	.1147	.0572	.2286	.2949
12	.4572	.4954	.0572	.1147	.0572	.1905	.2458
13	.0762	.1143	.9145	1.065	1.2003	.0191	.0492
14	.0953	.1143	.8954	1.0978	1.2384	.0572	.0492
15	.0762	.1143	.8764	1.0978	1.2193	.0572	.0492
16	.0762	.1143	.8764	1.0814	.0191	.0572	.0492
17	.0762	.0819	.8954		.7865	.0572	.0492
18	.0762	.0655	.9335	1.1622	.7701	.0572	.0655
19	.1334	.1311	.9335	1.1431	.7537	.0953	.0983
20	.1715	.1475	.9335		.7373	.1334	.0983
21	.1905	.1638	.2286	.1905	.1802	.1524	.1147
22	.2096	.1638	.2477	.2096	.1802	.1524	.1147
23	.2096	.1638	.2477	.2096	.1638	.1524	.1147
24		.1905	.1638	.2477	.2096	.1475	.1524
Max	.4588	.5335	.9335	1.1622	1.2384	.5735	.4001
Min	.0762	.0655	.0474	.0572	.0191	.0191	.0492
Avg	.2050	.2661	.3927	.4260	.3687	.2090	.1589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 209 / 11 KV Tinkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.3479	.381	.381	.3163	.2477
2		.4191	.3479	.381	.381	.3163	.2477
3		.381	.3479	.362	.362	.3163	.2477
4		.381	.3479	.3429	.3429	.3005	.2286
5		.3429	.506	.6097	.3429	.2846	.2096
6		.2858	.5218	.6478	.3048	.253	.2096
7		.1334	.5376	.8002	.2477	.1739	.1715
8	.0633	.1143	.6325	.8954	.8573	.1423	.1143
9	.1581	.1143	.6642	.8954	1.0669	.1423	.1715
10	.1423	.1143	.6958	1.1241	1.1812		.1715
11	.1334	.1143	.8002		1.086		.1107
12	.1143	.1334	.7621	.0158	.9526		.1107
13	.4954	.7049	.2477	.2056	.2477	.0953	.253
14	.5144	.6668	.2667	.2056	.2286	.4191	.253
15	.5144	.6859	.2477	.2372	.2286	.4954	.253
16	.5525	.6859	.2286	.0633	.1905	.5144	.253
17	.5335	.6325	.2096	.0953	.1423	.4763	.253
18	.4572	.6167	.1905	.1143	.1423	.3429	.3005
19	.4382	.6167	.3239	.2477	.2372	.362	.2688
20	.4191	.6009	.3429	.362	.2688	.381	.253
21	.5144	.3637	.381	.4001	.2846	.2096	.1581
22	.5144	.3479	.4001	.4001	.2846	.2096	.1581
23	.4763	.3479	.4191	.4001	.3005	.1905	.1739
24		.4382	.3479	.381	.4001	.3163	.2477
Max	.5525	.7049	.8002	1.1241	1.1812	.5144	.3005
Min	.0633	.1143	.1905	.0158	.1423	.0953	.1107
Avg	.3776	.4025	.4216	.4160	.4359	.2980	.2111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 201 / 11 KV SONOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3258	.3506	.5935	.543	.1753	.0848
2	.2896	.3258	.3506	.5087	.5068	.1753	.0848
3	.2896	.2896	.3506	.5087	.4525	.1753	.0848
4	.2172	.0781	.2629	.5087	.362	.1753	.0848
5	.2172	.081	.2629	.3391	.3258	.1402	.0848
6	.1296	.081	.1753	.2035	.2896	.1402	.0848
7	.081	.081	.1402	.1017	.0905	.0876	.0848
8	.1296	.0972	.1052	.1017	.0905	.0876	.0848
9	.1296	.1311	.1052	.1017	.0876	.0876	.0848
10	.1619	.1966	.1357	.1357	.0876	.0848	.0848
11	.1619	.1638	.1357	.1357	.0876	.0848	.0848
12	.0905	.1052	.2984	.6478	.4915		.0848
13	.0905	.1402	.5801	.664	.6554	.1017	.0848
14	.0905	.1402	.6299	.6478	.6554	.1017	.1017
15	.0905	.1402	.663	.6478	.6554	.1017	.1017
16	.0905	.1402	.6796	.7287	.1677	.1187	.1017
17	.0905	.1402	.6962	.7773	.1638	.1357	.0848
18	.0905	.1402	.6796	.7287	.1638	.1017	.0848
19	.0905	.1402	.663	.3239	.1311	.1017	.0848
20	.2896	.1753	.2035	.181	.1402	.1017	.1017
21	.2896	.4382	.3391	.4525	.1753	.1017	.1017
22	.2896	.4382	.5087	.4525	.1753	.1017	.1017
23	.3258	.4382	.5426	.543	.1753	.1017	.1017
24	.181	.3258	.3506	.5935	.6335	.1753	.1017
Max	.3258	.4382	.6962	.7773	.6554	.1753	.1017
Min	.081	.0781	.1052	.1017	.0876	.0848	.0848
Avg	.1749	.1981	.3837	.4428	.3045	.1200	.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 202 / 11 KV NANDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024	.3856	.4334	.4572	.3681	.2947
2		.3841	.3856	.4334	.439	.3506	.2947
3		.3658	.3856	.4161	.439	.3506	.2774
4		.2785	.3856	.3814	.4024	.3506	.2774
5		.2622	.3681	.3641	.3658	.3155	.208
6		.2294	.2454	.2601	.3292	.2454	.1734
7	.1646	.2458	.1578	.156	.128	.1402	.1214
8	.2195	.2458	.1402	.1387	.1463	.1227	.1214
9	.1966	.2622	.1578	.1387	.1578	.1227	.1387
10	.1966	.2785	.156	.156	.1578	.1214	.1387
11	.1966	.3277	.1734	.1734	.1402	.1214	.1214
12	.128	.1753	.39	.4424	.4588	.1214	.104
13	.1463	.2103	.5087	.4915	.5407	.104	.104
14	.1829	.2454	.5935	.5735	.4915		.104
15	.1829	.2454	.6274	.6718	.5243	.1387	.104
16	.1311	.2279	.6443	.6226	.2347	.156	.1214
17	.0914	.1928	.6274	.5735	.2458	.1734	.1214
18	.0914	.1753	.6104	.5898	.2622	.1734	.1387
19	.2561	.2279	.5765	.5571	.2622	.156	.1734
20	.3841	.3681	.3294	.3292	.2804	.2601	.2427
21	.4207	.4207	.3988	.4024	.3681	.2774	.2601
22	.439	.4031	.4508	.4207	.3856	.3121	.2774
23	.439	.4031	.4681	.4572	.3681	.3121	.2774
24		.4207	.3856	.4508	.4572	.3681	.2947
Max	.439	.4207	.6443	.6718	.5407	.3681	.2947
Min	.0914	.1753	.1402	.1387	.128	.104	.104
Avg	.2275	.2916	.398	.4014	.3351	.2244	.1871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 203 / 11 KV MALAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.1086	.0857	.0934	.1052	.0857
2	.0934	.0934	.1052	.0857	.0934	.1052	.0857
3	.0934	.0934	.1052	.0857	.0934	.1052	.0686
4	.0934	.0934	.1006	.0838	.081	.0876	.0686
5	.0934	.0934	.1006	.0838	.081	.0838	.0514
6	.056	.056	.0838	.0838	.081	.0838	.0514
7	.056	.056	.0838	.0838	.081	.0671	.0514
8	.056	.056	.1006	.0838	.081	.0671	.0514
9	.056	.0526	.1006	.1006	.0838	.0671	.0514
10	.056	.0526	.1006	.1174	.1006	.0686	.0514
11	.056	.0526	.1006	.1341	.1006	.0686	.0514
12	.081	.0838	.0514	.0549	.0526	.0514	.0686
13	.081	.1006	.0857	.0549	.0526	.0514	.0686
14	.081	.1006	.0857	.0549	.0526	.0514	.0686
15	.081	.1006	.0857	.0549	.0526	.0514	.0686
16	.081	.1006	.0857	.0549	.0526	.0514	.0686
17	.081	.1006	.0514		.0526	.0514	.0686
18	.081	.1006	.0514	.056	.0526	.0514	.0686
19	.2105	.1006	.0514	.056	.0526	.0514	.0686
20	.056	.1052	.0514	.056	.1052	.0857	.0514
21	.056	.1052	.0857	.0934	.1052	.0857	.0857
22	.0934	.1052	.1029	.0934	.1052	.0514	.0857
23	.0934	.1052	.1029	.0934	.1052	.0857	.0857
24	.0934	.0934	.1052	.1029	.0934	.1063	.0857
Max	.2105	.1052	.1086	.1341	.1052	.1063	.0857
Min	.056	.0526	.0514	.0549	.0526	.0514	.0514
Avg	.0822	.0873	.0869	.0806	.0794	.0723	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 204 / 11KV MANNATH AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.5914	.5258	.6268	.6283	.4908	.4477
2	.4805	.5729	.5258	.6089	.5914	.4733	.4298
3	.462	.5729	.5083	.5731	.5914	.4733	.4298
4	.462	.5544	.4096	.5256	.6464	.6554	.4119
5	.4435	.462	.426	.5596	.663	.6554	.3582
6	.2772	.3326	.3932	.5935	.6962	.6226	.2686
7	.1848	.2218	.4096	.6274	.7127	.5898	.4119
8	.1663	.2033	.5079	.763	.8453	.5407	.2686
9	.1663	.1928	.5079	.8309	.7045	.5079	.2507
10	.1848	.2279	.5087	.763	.7865	.5373	.2328
11	.2033	.2454	.4748	.8139	.8029	.5014	.2149
12	.4144	.3932	.2507	.2772	.1928	.1612	.3403
13	.3978	.4588	.2686	.2772	.2454	.1612	.3761
14	.3481	.4752	.3224		.2279	.1791	.3582
15	.3481	.4915	.3403	.3696	.2454	.1791	.3582
16	.3315	.5243	.3224	.3326	.1928	.1612	.3761
17	.3149	.4915	.3045	.2587	.1928	.1612	.394
18	.3481	.5079	.3045	.2218	.2103	.2149	.3582
19	.3978	.5079	.2865	.2957	.3155	.3045	.3582
20	.4805	.4557	.4477	.499	.5784	.3761	.3582
21	.5729	.5784	.5731	.5544	.5434	.4119	.3761
22	.5914	.5258	.6089	.5729	.5083	.4477	.394
23	.6099	.5434	.6447	.6468	.5083	.4656	.394
24	.4805	.5914	.5434	.6268	.6468	.4908	.4477
Max	.6099	.5914	.6447	.8309	.8453	.6554	.4477
Min	.1663	.1928	.2507	.2218	.1928	.1612	.2149
Avg	.3811	.4468	.4340	.5312	.5115	.4068	.3589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 205 / SAWARGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4024	.3605	.4382	.4572	.3353	.333
2	.3658	.3841	.3605	.4207	.439	.3185	.333
3	.3658	.3841	.3441	.4207	.3841	.3185	.3155
4	.3475	.3658	.3441	.3856	.3658	.3185	.298
5	.3475	.3658	.3353	.3681	.3658	.285	.2804
6	.2561	.2561	.2683	.3155	.3475	.2683	.2103
7	.2378	.2195	.2347	.2103	.1829	.218	.1928
8	.2012	.2012	.218	.2279	.1646	.2012	.1928
9	.2012	.1844	.2515	.2454	.1677	.1844	.1791
10	.2195	.218	.2629	.2454	.1844	.1928	.1753
11	.2195	.2012	.2804	.2629	.1677	.1753	.1578
12	.2012	.218	.2804	.2926	.2012	.1753	.1402
13	.2195	.2683	.2804	.2926	.2012	.1578	.1402
14	.2378	.285	.298	.2926	.218	.1402	.1928
15	.2195	.3018	.298	.3109	.2347	.1402	.1928
16	.2378	.285	.298	.2743	.1677	.1578	.1753
17	.2195	.2515	.2804	.2743	.2012	.1753	.1753
18	.2561	.2683	.2629	.2195	.218	.2103	.1753
19	.2743	.285	.2454	.2561	.218	.2454	.2103
20	.3658	.3185	.333	.3475	.285	.298	.2454
21	.3841	.3605	.3856	.3841	.3353	.333	.2629
22	.4024	.3768	.4207	.4024	.3521	.3506	.2804
23	.4207	.3768	.4557	.439	.3353	.3506	.298
24	.3658	.4024	.3605	.4382	.4572	.3353	.333
Max	.4207	.4024	.4557	.439	.4572	.3506	.333
Min	.2012	.1844	.218	.2103	.1646	.1402	.1402
Avg	.2888	.2992	.3108	.3235	.2772	.2452	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 201 / 11 KV MOHGAON-JATAMZARI-
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.3961	.5407	.4854	.5218	.3361	.4715
2	.112	.3961	.5407	.4854	.5376	.3361	.4715
3	.112	.3961	.5407	.4854	.5376	.3174	.4715
4	.0934	.3772	.5407	.5228	.5693	.2987	.4527
5	.0934	.3206	.4915	.5228	.5851	.2427	.415
6	.056	.2263	.5079	.5975	.6167	.1867	.2829
7	.0373	.1132	.5735	.6908	.7116	.112	.2263
8	.0373	.132	.6554	.8402	.9488	.0934	.1886
9	.056	.1509	.6964	.8962	1.0279	.0934	.2075
10	.0934	.2155	.2263	.112	.112		.3563
11	.1989	.4096	.2241	.1494	.112	.1326	.3384
12	.2155	.3725	.2427	.1307	.112	.1326	.282
13	.1823	.3077	.2801	.112	.112	.2321	.2538
14	.3647	.2429	.2987	.2241	.112	.2321	.3525
15	.3812	.3563	.2241	.2241	.0934	.2401	.4652
16	.2984	.4049	.1494	.2241	.0934	.3201	.4089
17	.3812	.4049	.112		.0934	.3041	.3384
18	.132	.132	.112		.112	.2263	.2115
19	.2263	.2075	.1867	.168	.168	.3206	.2397
20	.3395	.3395	.2987	.3174	.2829	.3772	.2679
21	.3584	.3961	.3734	.3734	.3174	.4527	.2961
22	.4338	.4338	.4108	.3921	.3734	.4715	.3102
23	.3961	.6413	.4108	.3921	.3734	.4715	.2961
24	.112	.3961	.5407	.4854	.4904	.3547	.4715
Max	.4338	.6413	.6964	.8962	1.0279	.4715	.4715
Min	.0373	.1132	.112	.112	.0934	.0934	.1886
Avg	.2010	.3237	.3824	.4014	.3756	.2732	.3365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 202 / 11 KV AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2622	.1698	.1286	.168	.213	.1619
2		.2622	.1698	.1286	.1494	.213	.2267
3		.2622	.1698	.1143	.1265	.2294	
4		.2622	.1509	.1143	.1307	.2294	
5		.2458	.132	.0857	.1307	.2294	
6		.2622	.1132	.0572	.112	.2458	
7		.2785	.0754	.0429	.056	.3277	
8			.0754	.0286	.056	.2949	
9		.8192	.0754	.0286	.056	.2785	.1311
10	.2591	.0566	.3401	.1	.4572	.0377	.0943
11	.2949	.0754	.2858		.4858	.0566	.0754
12	.3113	.0943	.2572		.0486	.0566	.0754
13	.0566	.0943	.2858	.6706	.0486	.0566	.0754
14	.0754	.0943	.3144	.6706	.5182	.0754	.0754
15		.0943	.3429	.6706	.6154	.0754	.0754
16		.0943	.3715	.6706	.4534	.0754	.0566
17	.0754	.0566	.4001		.3401	.0754	.0566
18	.0943	.0566	.0429		.2591	.0754	
19	.132	.0943	.0714	.4725	.0943	.1132	.0377
20	.1509	.1698	.1143	.1307	.132	.132	.0754
21	.1698	.2075	.1286	.1867	.1698	.1509	.1132
22	.2075	.1698	.1429	.168	.1698	.1509	.1132
23	.2075	.1698	.1286	.168	.1698	.1509	.1132
24	.1698	.2622	.1698	.1286	.168	.213	.1475
Max	.3113	.8192	.4001	.6706	.6154	.3277	.2267
Min	.0566	.0566	.0429	.0286	.0486	.0377	.0377
Avg	.1696	.1932	.1887	.2383	.2131	.1565	.1003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 203 / 11 kv pipila feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1698	.176	.2218	.208	.1698	.1698
2		.1698	.176	.2218	.208	.1698	.1698
3		.1698	.176	.2218	.208	.1509	.1509
4		.1509	.16	.2033	.1932	.1509	.1509
5		.1132	.16	.2033	.1932	.1132	.1509
6		.0943	.16	.1848	.1932	.0754	.0943
7	.0189	.0566	.112	.1848	.208	.0754	.0943
8	.0189	.0566	.144	.2402	.2378	.0566	.0566
9	.0189	.0566	.144	.2957	.2378	.0566	.0377
10	.0754	.0819	.0566	.0739	.056		.08
11	.0655	.128	.0739	.0747	.0566	.0492	.0772
12	.0655	.16	.0924	.0934	.0754	.0983	.0926
13	.0819	.16	.0924	.112	.0566	.1147	.0926
14	.0819	.16	.1109	.1307	.0754	.0983	.0926
15	.0819	.16	.0924	.1307	.0566	.0949	.0772
16	.0983	.16	.0739	.1307	.0566	.1107	.0772
17	.0819	.144	.0739		.0566	.112	.0926
18	.0566	.0566	.0739		.0566	.1132	.0772
19	.1132	.0943	.0924	.0373	.0943	.1132	.0772
20	.1509	.1509	.1294	.1307	.132	.132	.0772
21	.1698	.1698	.1478	.168	.1509	.1509	.0772
22	.1698	.1509	.1663	.168	.1698	.1509	.0926
23	.1698	.1698	.1663	.168	.1698	.1509	.0926
24		.1698	.1781	.2218	.208	.1698	.1509
Max	.1698	.1698	.1781	.2957	.2378	.1698	.1698
Min	.0189	.0566	.0566	.0373	.056	.0492	.0377
Avg	.0894	.1314	.1262	.1644	.1399	.1164	.1001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 201 / 11 KV KALMBHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2534	.2587	.7682	.2353	.2155	.2033
2	.1867	.2534	.2587	.7499	.2172	.1989	.2033
3	.1867	.2534	.2587	.7316	.2172	.1989	.2033
4	.168	.2534	.2587	.695	.2172	.1989	.2033
5	.1494	.2172	.2218	.6767	.181	.1823	.1848
6	.1307	.1629	.1663	.5304	.1629	.1658	.1663
7	.112	.1086	.1294	.3696	.1267	.116	.1109
8	.0934	.1086	.1109	.2614	.0905	.1267	.112
9		.1086	.0739	.2801	.0905	.1307	.1097
10	.3185	.3561	.3647	.6464	.1311	.0671	.0663
11	.3149	.3647	.5256	.8684	.1326	.0671	.0509
12	.2155	.3647	.5256	.5735	.0995	.0671	.0678
13	.1658	.3315	.4578	.5571	.0995	.0678	.0693
14	.2294	.3688	.4578	.5571	.0995	.0678	.0693
15	.2652	.3647	.5087	.5735	.0819	.0678	.0693
16	.2984	.3978	.4917	.5407	.0663	.0509	.052
17	.2984	.3978	.4748	.4917	.0663	.0678	.0509
18	.0724	.1109	.2987	.0724	.0554	.0924	.0943
19	.1086	.1478	.4066	.0905	.1075	.1478	.112
20	.181	.4435	.6036	.1991	.1629	.1663	.1478
21	.1991	.4706	.6767	.2172	.1991	.1848	.168
22	.2353	.2865	.7316	.2353	.2172	.1848	.1848
23	.2534	.2534	.7682	.2353	.2328	.2054	.1753
24	.1867	.2534	.2534	.7842		.2328	.2033
Max	.3185	.4706	.7682	.8684	.2353	.2328	.2033
Min	.0724	.1086	.0739	.0724	.0554	.0509	.0509
Avg	.1981	.2763	.3868	.4877	.1430	.1363	.1283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 202 / 11 KV ISAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4656	.4207	
2		.4656	.4207	
3		.4656	.4207	
4		.4298	.4031	
5		.3582	.3641	
6		.2865	.2947	
7		.2149	.208	.1448
8		.1612	.1791	.1494
9		.1075	.2054	.2172
10		.4024	.2347	.2622
11		.4915	.2515	.2035
12		.4096	.1989	.2058
13		.4752	.2012	.1715
14		.4752	.1677	.1886
15		.3978	.1677	.1886
16		.3978	.1989	.1886
17		.3605	.1989	.1509
18		.1829	.1829	.1867
19	.2149	.2328	.2743	.2218
20	.3761	.362	.2926	.2218
21	.4298	.3761	.3292	.2957
22	.4477	.4163	.3658	.2957
23	.4835	.4298	.3734	.2804
24		.4656	.3812	
Max	.4835	.4915	.4207	.2957
Min	.2149	.1075	.1677	.1448
Avg	.3904	.3679	.2806	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 203 / 11 KV YENWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.591	.6219	.6219	.5731	.5201	.4755
2		.591	.6219	.6219	.5731	.5201	.4755
3		.5973	.6219	.6219	.5731	.5201	.4755
4		.5552	.5853	.5914	.5373	.543	.4755
5		.5194	.5487	.5544	.4656	.4938	.439
6		.3582	.4066	.4066	.3582	.3982	.3658
7		.2715	.3109	.2772	.2686	.2865	.2686
8	.2614	.2149	.2195	.2241	.2149	.1991	.2614
9	.2241	.1791	.2012	.2402	.0537	.2614	.2012
10	.1006	.1989	.3441	.5138	.5967	.2683	.2294
11	.1638	.218	.3647	.547	.5243	.2683	.2035
12	.1475	.2652	.3647	.4588	.4752	.2155	.2058
13	.1638	.3018		.5243	.4372	.1823	.2058
14	.1802	.2818		.5571	.4424	.1844	.2058
15	.1966	.2818	.3978	.5243	.4534	.1677	.1886
16	.1966	.2486	.3978		.3887	.2012	.2058
17	.1966	.2984	.3647	.6036	.3563	.1844	.1677
18	.2149	.2561	.2241	.2507	.197	.1448	
19	.2865	.3258	.2772	.2865	.2507	.3077	.2772
20	.4656	.4344	.4572	.4298	.362	.3403	.3292
21	.4656	.5068	.5121	.5014	.4024	.3801	.3511
22	.5731	.5068	.5853	.5194	.5068	.4298	.4066
23	.6089	.6154	.5121	.5853	.5487	.4854	.3856
24		.591	.6219	.6348	.5731	.543	.4755
Max	.6089	.6154	.6219	.6348	.5967	.543	.4755
Min	.1006	.1791	.2012	.2241	.0537	.1448	.1677
Avg	.2779	.3837	.4346	.4825	.4222	.3352	.3163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 204 / 11 KV GONHI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012	.1991	.2241	.2195	.2126	.1629
2		.2012	.1991	.2241	.2195	.197	.1612
3		.2012	.197	.2241	.2195	.1949	.1629
4		.2012	.197	.2054	.2012	.197	.1629
5		.1829	.1791	.2054	.1829	.1595	.1448
6		.1463	.1448	.168	.1463	.1433	.1267
7		.0914	.0905	.112	.0732	.1063	.0895
8		.0732	.0905	.0747	.0549	.0895	.0934
9		.0732	.1991	.0943	.0549		.0724
10		.0343	.0655	.1187	.1029		.064
11	.1134	.0343	.0857	.1187	.1296		.052
12		.0509	.0857	.1311	.1326		
13	.0324	.0509	.0514	.0819	.0972		.0526
14	.0324	.0514	.0686	.1311	.0972	.0347	.0526
15	.0328	.0343	.0686	.1147	.0819	.0343	.0701
16	.0324	.0343	.0686	.1147	.0655	.052	.0526
17	.0324	.0514	.0686	.12	.0486	.052	.052
18	.0732	.0724	.0943	.0732	.0895	.0895	.0943
19	.128	.1086	.1307	.1097	.124	.1254	.112
20	.1829	.1829	.1867	.1646	.1612	.1254	.112
21	.2195	.2172	.2054	.2195	.1417	.1448	.1494
22	.2378	.2012	.2241	.2195	.2328	.1629	.168
23	.2195	.2126	.2241	.2195	.2279	.168	.1629
24		.2012	.1949	.2241	.2195	.2126	.1629
Max	.2378	.2172	.2241	.2241	.2328	.2126	.168
Min	.0324	.0343	.0514	.0732	.0486	.0343	.052
Avg	.1114	.1212	.1383	.1539	.1385	.1317	.1102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 205 / 11 KV KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2534	.2507	.2772	.2534	.2328	.197
2	.2054	.2534	.2507	.2772	.2534	.2353	.197
3	.2054	.2534	.2507	.2587	.2534	.2353	.197
4	.1867	.2172	.2507	.2587	.2328	.2353	.197
5		.1991	.2507	.2614	.2353	.2012	.1791
6		.1629	.1612	.1867	.1629	.1629	.1612
7		.1086	.1075	.0943	.1086	.1086	.0895
8	.0934		.0895	.0934	.0724	.0914	.112
9	.0934	.0905	.0895	.0754	.0905	.0934	.0724
10	.1341	.1017	.1296	.2347	.2374	.1006	.081
11	.1147	.1017	.1357	.2683	.2241	.1174	.12
12	.1134	.1174	.1526	.2294	.1943	.0509	
13	.1134	.1006	.2035	.1802	.176	.0848	.0867
14	.0983	.1017	.2035	.2458	.1781	.1187	.0686
15	.08	.1341	.1638	.2294	.1475	.1174	.0867
16	.0648	.1677	.1865	.2458	.08	.1174	.0867
17	.096	.1357	.1696	.2543	.112	.1017	.0678
18	.0905	.1075	.0934	.0905	.0895	.0895	.0934
19	.1448	.1433	.1494	.1086	.1254	.1433	.112
20	.2353	.2353	.2427	.2172	.1991	.1848	.168
21	.2715	.2715	.2587	.2534	.2149	.197	.1663
22	.2896	.2686	.2987	.2715	.2353	.2149	.1848
23	.2715	.2715	.2772	.2534	.2378	.2241	.1753
24	.2054	.2715	.2534	.2801		.2353	.197
Max	.2896	.2715	.2987	.2801	.2534	.2353	.197
Min	.0648	.0905	.0895	.0754	.0724	.0509	.0678
Avg	.1578	.1769	.1925	.2144	.1789	.1539	.1346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 201 / 11 KV KACHARISAWANGA
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0972	.4534	.4534	.4534	.3887	.0162
2	.0162	.0972	.4534	.4534	.4534	.3887	.0162
3	.0162	.0972	.4534	.421	.421	.3887	.0162
4	.0162	.0972	.4534	.3887	.3887	.3887	.0162
5	.0162	.0972	.3887	.3887	.3887	.3563	.0162
6	.0162	.0972	.2267	.2915	.2591	.3239	.0162
7	.0162	.0648	.1943	.2267	.1943	.1943	.0162
8	.0162	.0648	.1619	.1943	.1943	.1619	.0162
9	.0162	.0648	.1781	.1619	.1943	.1619	.0162
10	.0972	.0972	.1943	.2267	.2591	.1134	.0162
11	.0972	.0648	.1943	.2591	.2591	.0972	.0324
12	.0972	.1943	.2267	.2591	.2915	.0972	.0324
13	.0648	.1619	.1943	.2267	.2267		.0324
14	.0648	.1296	.1619	.1943	.2267		.0324
15	.0648	.1296	.2195	.2267	.2591	.0162	.0648
16	.0648	.0648	.2561	.2267	.2267	.0162	.0648
17	.0648	.1619	.1943	.2591		.0162	.0648
18	.0324	.1619	.1943	.2591		.0162	.0972
19	.0324	.2267	.2915	.2591	.0648	.0162	.0972
20	.0972	.3563	.3887	.3887	.3563	.0162	.0972
21	.0972	.421	.5121	.4858	.3887	.0162	.0972
22	.0972	.4858	.4534	.4858	.3887	.0162	.0972
23	.0972	.4858	.4858	.4534	.421	.0324	.0972
24	.0162	.0972	.4534	.4534	.4534	.3887	.0162
Max	.0972	.4858	.5121	.4858	.4534	.3887	.0972
Min	.0162	.0648	.1619	.1619	.0648	.0162	.0162
Avg	.0513	.1674	.3077	.3185	.3077	.1642	.0452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 202 / 11 KV KHURSAPAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.6299	.663	.6299	.663	.5304	.4973
2	.4973	.5967	.663	.6299	.663	.5304	.4973
3	.5304	.5636	.663	.5967	.6299	.5304	.4973
4	.5304	.4973	.663	.5304	.6299	.5304	.4641
5	.5304	.4973	.5967	.4973	.5636	.4973	.4641
6	.3647	.431	.3315	.3978	.3315	.4641	.3647
7	.2321	.2321	.2652	.2652	.2652	.2984	.2652
8	.1989	.2321	.2321	.2652	.2486	.2321	.2321
9	.1989	.2321	.2321	.2652	.2321	.2321	.2984
10	.2984	.431	.3978	.4641	.431	.3978	.2984
11	.3647	.3978	.431	.4973	.4973	.431	.2652
12	.3647	.3978	.431	.4973	.5304	.431	.2652
13	.3647	.3647	.3978	.4973	.5636	.3978	.2984
14	.3647	.3647	.3315	.431	.431	.3315	.2652
15	.3315	.3315	.3978	.5304	.426	.8288	.2652
16	.2984	.3315	.431	.5304	.431	.2984	.2652
17	.2984	.3647	.3315	.4973	.3647	.2984	.2652
18	.3315	.2652	.2321	.431	.2321	.2321	.3978
19	.3978	.3978	.3978	.431	.3315	.431	.4973
20	.663	.663	.6299	.7293	.5636	.5636	.4973
21	.7293	.7293	.6962	.7293	.5967	.5636	.4973
22	.7293	.7625	.6962	.7293	.5967	.5636	.4973
23	.6299	.7293	.6962	.663	.6133	.5304	.3978
24	.5636	.6299	.6962	.663	.663	.5636	.4973
Max	.7293	.7625	.6962	.7293	.663	.8288	.4973
Min	.1989	.2321	.2321	.2652	.2321	.2321	.2321
Avg	.4296	.4614	.4793	.5166	.4791	.4462	.3771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 204 / 11 KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.6516	.724	.724	.724	.6154	.543
2	.1448	.6516	.724	.724	.724	.6154	.543
3	.1448	.6154	.724	.6878	.6516	.6154	.543
4	.1086	.543	.724	.6516	.6154	.6154	.543
5	.1086	.543	.6516	.6516	.5792	.543	.5068
6	.1086	.4344	.362	.3982	.362	.4706	.4344
7	.1086	.2896	.3258	.2896	.2896	.2896	.362
8	.1086	.2896	.2896	.2896	.2896	.2534	.3258
9	.1086	.2896	.2896	.2896	.2896	.2896	.3258
10	.1086	.4344	.5068	.543	.5792	.3982	.2172
11	.1448	.362	.4344	.5068	.5068	.4706	.181
12	.2172	.3258	.4706	.5068	.543	.362	.181
13	.181	.2896	.4706	.4706	.5068	.3258	.181
14	.181	.3258	.4344	.4706	.4706	.2172	.181
15	.2172	.181	.3982	.2534	.4344	.1829	.181
16	.2534	.0905	.362	.4344	.4706	.181	.181
17	.2534	.0724	.362	.4344	.3982	.1448	.181
18	.362	.3258	.2896	.4706	.2534	.3258	.4344
19	.4706	.5068	.543	.4706	.3258	.5792	.543
20	.724	.6516	.6878	.724	.6154	.6154	.543
21	.724	.7602	.7602	.7964	.6516	.6154	.543
22	.724	.7964	.7602	.7964	.6516	.6516	.5068
23	.6878	.724	.7602	.724	.6516	.6154	.5068
24	.0362	.6878	.724	.724	.724	.6878	.5792
Max	.724	.7964	.7602	.7964	.724	.6878	.5792
Min	.0362	.0724	.2896	.2534	.2534	.1448	.181
Avg	.2655	.4517	.5324	.543	.5128	.4450	.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 205 / 11 KV KONDHALI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7712	.9465	1.0166	1.0166	.9465	.8413	.7011
2	.8063	.9114	1.0166	1.0166	.9465		.7011
3	.7712	.9114	1.0166	1.0517	.8764	.8413	.6661
4	.7362	.8413	1.0166	.9816	.8764	.8413	.6661
5	.7362	.8413	.9816	.9465	.8413	.8063	.6661
6	.7011	.8063	.7011	.7712	.7011	.7011	.5959
7	.6661	.6661	.7011	.7712	.6661	.7712	.6661
8	.631	.6661	.7011	.631	.631	.5959	.5609
9	.5959	.7011	.631	.5959	.5609	.5609	.5609
10	.5959	.7362	.7011	.5609	.631	.5258	.5258
11	.5609	.7011	.7362	.6661	.5258	.5258	.4908
12	.5959	.7362	.631	.7011	.6661	.4557	.4908
13	.631	.7362	.6154	.7362	.631	.4557	.5258
14	.631	.7712	.7011	.7362	.631	.4908	.5609
15	.7011	.8063	.7362	.7362	.6661	.5258	.5258
16	.5959	.7712	.8764	.7362	.631	.5258	.4908
17	.6661	.7362	.7449	.7362	.631	.4908	.5258
18	.7011	.7011	.7011	.7712	.5609	.5487	.5258
19	.7712	.8063	.7712	.7712	.5609	.631	.5959
20	.9816	.9465	.8764	.9465	.8063	.7011	.5959
21	.9816	.9816	.9465	.9816	.8063	.7362	.5959
22	1.0166	1.0867	1.0166	1.0166	.8063	.7712	.5959
23	.9816	1.0867	1.0867	.9816	.8764	.7712	.5609
24	.8063	1.0242	1.0517	1.0166	.9816	.8764	.7362
Max	1.0166	1.0867	1.0867	1.0517	.9816	.8764	.7362
Min	.5609	.6661	.6154	.5609	.5258	.4557	.4908
Avg	.7347	.8300	.8323	.8282	.7274	.6518	.5886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 206 / 11KV MASOD NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0328	.0328	.0328	.0328	.0328	.0328
2	.0328	.0328	.0328	.0328	.0328	.0328	.0328
3	.0328	.0328	.0328	.0328	.0328	.0328	.0328
4		.0328	.0328	.0328	.0328	.0328	.0328
5	.0328	.0328	.0328	.0328	.0328	.0328	.0328
6	.0328	.0328	.0328	.0328	.0328	.0328	.0328
7	.0328	.0328	.0328	.0328	.0328	.0328	.0328
8	.0328	.0328	.0328	.0328	.0328	.0328	.0328
9	.0328	.0328	.0328	.0328	.0492	.0328	.0328
10	.0655	.0655	.0701	.0492		.0492	.0655
11	.0655	.0655	.0655	.0655	.0492	.0492	.0492
12	.0492	.0655	.0655	.0655	.0655	.0492	.0492
13	.0983	.0655	.0655	.0655	.0492	.0492	.0492
14	.0983	.0655	.0655	.0655	.0492	.0492	.0492
15	.0983	.0655	.0655	.0492	.0492	.0492	.0492
16	.0983	.0492	.0655	.0492	.0655	.0492	.0492
17	.0655	.0492	.0655	.0492	.0492	.0328	.0701
18	.0328	.0328	.0328	.0328	.0328	.0328	.0328
19	.0328	.0328	.0328	.0328	.0328	.0328	.0328
20	.0328	.0328	.0328	.0328	.0328	.0328	.0328
21	.0328	.0328	.0328	.0328	.0328	.0328	.0328
22	.0328	.0328	.0328	.0328	.0328	.0328	.0328
23	.0328	.0328	.0328	.0328	.0328	.0328	.0328
24	.0328	.0351	.0328	.0328	.0328	.0328	.0328
Max	.0983	.0655	.0701	.0655	.0655	.0492	.0701
Min	.0328	.0328	.0328	.0328	.0328	.0328	.0328
Avg	.0492	.0424	.0439	.0410	.0399	.0376	.0398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 207 / 11 KV WW

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1052	.0876	.0701	.1052	.1052	.0701
2	.1052	.1052	.0876	.0701	.1052	.1052	.1052
3	.1402	.1052	.0876	.0701	.1052	.1052	.1402
4	.1753	.1052	.0876	.1402	.1753	.1052	.1753
5	.1753	.1052	.1402	.1753	.1753	.1402	.1753
6	.2103	.2103	.1753	.1402	.2103	.1753	.1753
7	.2103	.2103	.1753	.1402	.1928	.1753	.1753
8	.2103	.2103	.2804	.1052	.2103	.1753	.1753
9	.2103	.2103	.1753	.0351	.2454	.0876	.1753
10	.2103	.2103	.1753	.1753		.2103	.1753
11	.2454	.1753	.2103	.2103	.2103	.1829	.1753
12	.2454	.1753	.2103	.2454	.2454	.2195	.1753
13	.1402	.2103	.1753	.2454	.2103	.1829	.2103
14	.1402	.1402	.1463	.1052	.1227	.0732	.1052
15	.2103	.2103	.2454	.2454	.2103	.1829	.1753
16	.2103	.1753	.2195	.2103	.2103	.2195	.1753
17	.2454	.1402	.1829	.2103	.1578	.1829	.1753
18	.2454	.1753	.2195	.2454	.1753	.2195	.1753
19	.2454	.1753	.1402	.2454	.1753	.1753	.1753
20	.1052	.1052	.0701	.1052	.1052	.1052	.1052
21	.1052	.0876	.0732	.1052	.0701	.0701	.1052
22	.1052	.0876	.0701	.1052	.0701	.1052	.1052
23	.1052	.1052	.0701	.1052	.1052	.1052	.1052
24	.1052	.1052	.0876	.4207	.1052	.1052	.1052
Max	.2454	.2103	.2804	.4207	.2454	.2195	.2103
Min	.1052	.0876	.0701	.0351	.0701	.0701	.0701
Avg	.1767	.1519	.1497	.1636	.1608	.1464	.1505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 402 / 33 KV Katol Kondhali

Incomer Feeder KV- 33 /
INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4019	5.2126	5.6516	5.5967	5.9808	5.2675	4.4993
2	3.8958	5.1578	5.6516	5.5967	5.9259	5.2675	4.6639
3	4.0604	4.9383	5.6516	5.6516	5.7613	5.2675	4.6639
4	4.1152	4.7737	5.6516	5.487	5.7613	5.2675	4.4993
5	3.8958	4.6639	5.4321	5.487	5.487	4.9931	4.225
6	3.7311	4.2798	4.1152	4.7737	4.3347	4.7737	4.0604
7	3.1276	4.8834	3.5117	2.963	3.7311	3.9506	3.5117
8	3.3471	5.1029	4.0055	3.0727	4.1701	3.0178	3.786
9	3.5117		3.9506	2.9081	5.3224	2.7435	3.8958
10	3.7311	6.31	4.8285	5.2675		3.5117	4.1701
11	4.1152	5.5967	4.3896	5.5418	4.7188	7.1331	4.1701
12	3.8409	6.2552	4.9931	5.6516	5.3224	8.1756	4.1701
13	4.225	5.6516	4.8285	5.4321	4.7188	8.0659	4.3347
14	4.1701	4.5542	4.1152	5.1578	5.048	7.9561	4.1701
15	3.7311	4.0055	4.5542	4.9383	4.7737	7.8464	4.2798
16	4.1152	4.1701	4.8285	5.6516	5.1578	3.6214	4.225
17	3.0727	4.3896	3.6763	5.9259		3.6763	4.3347
18	3.4568	4.1152	3.9506	4.8834	3.6214	3.7311	4.2798
19	4.225	4.4445	4.3896	4.7737	3.9506	4.1701	4.7188
20	5.2675	5.5418	5.2675	5.5418	5.6516	4.0055	4.6091
21	5.487	5.9259	4.9931	5.8162	5.3772	3.786	4.2798
22	5.5967	6.0357	5.4321	5.8162	5.2675	4.9931	4.1152
23	5.3224	5.3224	5.3772	5.8711	5.487	4.3896	3.8409
24	4.0604	5.3224	5.8711	5.9808	6.0357	5.5418	4.4993
Max	5.5967	6.31	5.8711	5.9808	6.0357	8.1756	4.7188
Min	3.0727	4.0055	3.5117	2.9081	3.6214	2.7435	3.5117
Avg	4.0627	5.0719	4.7965	5.1578	5.0730	5.0480	4.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 403 / 33 KV Kondhali B'gaon
outgoing Feeder KV- 33 /
INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.701	2.6337	2.524	2.4691	2.9081		2.524
2	2.1948	2.6337	2.524	2.524	2.8532		2.6337
3	2.3045	2.524	2.524	2.6337	2.8532		2.6337
4	2.4143	2.524	2.524	2.6337	2.8532		2.524
5	2.1948	2.4143	2.524	2.6337	2.7435		2.3045
6	2.1948	2.1948	2.1948	2.6337	2.3045		2.3594
7	1.8107	3.2922	1.7558	1.1523	2.0302		1.9204
8	2.0851	3.5117	2.1948	1.4815	2.4691	1.4266	2.4143
9	2.2497	3.5117	2.3045	1.4815	2.0302	1.262	2.4143
10	2.3045	4.2798	2.7435	3.1276	3.0178	1.7558	2.7984
11	2.5789	3.7311	2.1948	3.1824	2.524	5.3224	2.9081
12	2.1948	4.2798	2.8532	3.2373	2.8532	6.4746	2.9081
13	2.6337	3.7311	2.7435	3.0727	2.4691	6.5844	2.963
14	2.5789	2.6337	2.1948	3.0178	3.0178	6.6941	2.9081
15	1.9753	2.1948	2.3594	2.7984	2.6337	6.4746	2.9081
16	2.4691	2.6337	2.524	3.2922		2.3045	2.9081
17	1.3717	2.7435	1.5912	3.6214		2.4143	2.963
18	1.6461	2.3594	2.1948	2.524	2.3045	2.3594	2.524
19	2.1948	2.1948	2.0851	2.4143	2.4143	2.1948	2.6337
20	2.524	2.6337	2.4143	2.4143	3.0178	1.8656	2.6337
21	2.6337	2.7435	2.5789	2.4691	2.6337	1.6461	2.3045
22	2.6886	2.6337	2.1948	2.4691	2.524	2.7435	2.1948
23	2.6337	2.0302	2.0302	2.7435	2.524	2.1948	2.0302
24	2.3594	2.6337	2.6337	2.4691	2.9081	2.7435	2.4691
Max	2.6886	4.2798	2.8532	3.6214	3.0178	6.6941	2.963
Min	1.3717	2.0302	1.5912	1.1523	2.0302	1.262	1.9204
Avg	2.2474	2.8624	2.3503	2.6040	2.6312	3.3212	2.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 201 / 11 KV MASOD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2225	.2591	.2743	.2804	.2743	.2591	.218
2	.221	.2591	.2591	.2789	.2591	.2439	.2164
3	.2164	.2439	.2591	.2759	.2591	.2439	.2149
4	.2119	.2439	.2591	.2728	.2439	.2134	.2134
5	.1707	.2286	.2439	.2576	.2286	.2134	.1844
6	.1372	.1524	.1524	.1738	.1524	.1372	.1402
7	.0975	.1219	.1219	.1417	.1219	.1219	.1128
8	.096	.1067	.1067	.1082	.1067	.0914	.1174
9	.0914	.1067	.128	.1067	.1067	.096	.1128
10	.1067	.1067	.1661	.1981	.1219	.1448	.0701
11		.1067	.1357	.2286	.1219	.128	.0716
12		.1067	.1631	.2286	.1219	.1311	.0701
13	.1067	.1067	.1402	.2134	.1372		.0808
14	.1372	.1067	.157	.2286	.1524	.0975	.0823
15	.1067	.1067	.1539	.1829	.1997	.1097	.0884
16	.0762	.1067	.1661	.1981	.218	.1143	.1021
17	.0914	.1067	.1387	.2134	.1844	.1021	.096
18	.0914	.1067	.0975	.1219	.1067	.1052	.1143
19	.1677	.1524	.1753	.1677	.1677	.1799	.1738
20	.2591	.2439	.2713	.2743	.2439	.1707	.1799
21	.2743	.3048	.2942	.3048	.2591	.2332	.1981
22	.2896	.3048	.3094		.2743	.2271	.1844
23	.2591	.2896	.2957	.2743	.2591	.2256	.1844
24	.2271	.2591	.2743	.282	.2743	.2591	.2195
Max	.2896	.3048	.3094	.3048	.2743	.2591	.2195
Min	.0762	.1067	.0975	.1067	.1067	.0914	.0701
Avg	.1663	.1766	.1976	.2179	.1915	.1673	.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 202 / 11 KV DHURKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2439	.2743	.2469	.2591	.1981	.1768
2		.2286	.2591	.2454	.2439	.2896	.1753
3		.2286	.2591	.2439	.2286	.1677	.1738
4		.2286	.2439	.2439	.2286	.1524	.1722
5		.2286	.2286	.2362	.2134	.1524	.1433
6		.1219	.1372	.1235	.1219	.1219	.0975
7		.1067	.0914	.1082	.0914	.0762	
8		.0914	.0914	.0945	.0914	.0762	.0533
9	.0762	.1067	.1067	.0914	.0914	.0854	.0914
10	.1219	.1677	.1494	.1677	.2286	.2713	.1524
11	.1524	.1372	.189	.0914	.2439	.1875	.1433
12	.1219	.1372	.1372	.2743	.2743	.1753	.125
13	.1372		.1097	.2134	.2743	.1829	.1067
14	.1219	.1372	.1311	.2134	.2743	.1539	.1143
15	.1372	.1524	.1265	.2439	.2835	.1204	.0914
16	.1372	.1219	.192	.2591	.2484	.1463	.0838
17	.1219	.1372	.1799	.2134	.2103	.1006	.0701
18	.0914	.0762		.0914	.0762	.0732	.096
19	.1372	.1372	.1494	.1219	.1067	.1067	.1296
20	.2134	.2286	.218	.2439	.1829	.1707	.1357
21	.2439	.2591	.2393	.2591	.1829	.1875	.1478
22	.2439	.2743	.253	.2591		.1844	.1433
23	.2439	.2743	.2515	.2591	.2134	.1844	.1372
24		.2439	.2743	.2484	.2591	.1981	.1814
Max	.2439	.2743	.2743	.2743	.2835	.2896	.1814
Min	.0762	.0762	.0914	.0914	.0762	.0732	.0533
Avg	.1534	.1769	.1866	.1997	.2012	.1568	.1279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 203 / 11 KV DHOTIWADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.4572	.4572	.471	.4725	.442	.4237
2	.3506	.4572	.4572	.4694	.4572	.4115	.4176
3	.3368	.442	.4572	.4633	.4572	.3963	.4191
4	.346	.442	.442	.4512	.4268	.3963	.4146
5	.3064	.4268	.442	.4283	.4115	.3658	.4039
6	.2545	.3048	.3048	.3079	.2743	.2743	.2759
7	.1677	.1981	.1524	.1997	.1981	.1981	.1128
8		.1981	.1372	.1814	.1524	.1981	.1951
9		.2134	.1859	.1981	.1677	.1905	.1844
10	.2591	.2439	.2545	.3353	.3506	.3475	.2058
11	.2286	.2134	.2713	.3506	.3658	.2957	.1966
12	.2134	.1981	.2789	.3658	.3658	.2469	.1799
13	.1981	.2134	.282	.381	.3506	.2561	.1722
14	.1829	.2134	.2393	.3506	.3201	.2301	.1616
15	.1524	.2134	.2606	.3658	.3201	.2195	.157
16	.1677	.2286	.2622	.381	.346	.221	.1494
17	.1829	.1981	.2454	.3506	.3003	.2073	.1478
18	.1981	.1829	.2332	.1677	.1829	.2119	.1875
19	.3048	.2896	.3018	.2743	.2591	.2789	.2881
20	.4268	.4268	.4283	.4115	.381	.3658	
21	.4725	.4877	.4893	.4877	.4268	.4039	
22	.503	.503	.5152	.503	.4725	.4283	
23	.4725	.4877	.4893	.4725	.4572	.4268	
24	.3521	.442	.4572	.474	.4725	.442	.4237
Max	.503	.503	.5152	.503	.4725	.442	.4237
Min	.1524	.1829	.1372	.1677	.1524	.1905	.1128
Avg	.2922	.3201	.3352	.3684	.3495	.3106	.2558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 401 / 33 KV Masod B'gaon feeder

Feeder KV- 33 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.3749	.4115	.407	.4024	.3658	.3292
2	.2835	.3704	.4115	.407	.3932	.3658	.3246
3	.2789	.3658	.4115	.407	.3887	.3658	.3246
4	.2743	.3658	.4115	.3978	.3749	.3658	.3201
5	.2423	.3612		.3841	.3567	.3201	.3155
6	.2058	.2515	.3658	.2698	.2469	.1829	.1783
7	.1509	.1738	.1829	.2195	.16	.1829	.1783
8	.1006	.1692	.1372	.1692	.1417	.1829	.1646
9	.128	.1692	.1692	.1692	.1372	.2743	.16
10	.4618	.5213	.5761	.7087	.7773	.6996	.4252
11	.3795		.6264	.7042	.7316	.5944	.4572
12	.3658	.4572	.6127	.8688	.7773	.5761	.3658
13	.4252	.4572	.5487	.823	.823	.5075	.3475
14	.4115	.4572	.5167	.8733	.823	.4664	.3429
15	.3887	.4572	.5533	.8551	.823	.4572	.3201
16	.3795	.503	.6584	.9008	.8459	.4938	.3338
17	.3887	.503	.663	.9099	.7773	.4344	.3201
18	.16	.1829	.1646	.1646	.1372	.1692	.2012
19	.2515	.2286	.2378	.2286	.2286	.2332	.2286
20	.3749	.3658	.3658	.3795	.3201	.2972	.1189
21	.3887	.4115	.4161	.4252	.3658	.3338	.1189
22	.4344	.4572	.4344	.3932	.4115	.3429	.1143
23	.3887	.4115	.4252	.4115	.4115	.3384	.1097
24	.2926	.3749	.4115	.4161	.407	.3658	.3292
Max	.4618	.5213	.663	.9099	.8459	.6996	.4572
Min	.1006	.1692	.1372	.1646	.1372	.1692	.1097
Avg	.3102	.3648	.4223	.4955	.4692	.3715	.2679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 201 / 11 KV Yerkheda 1

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9791	1.7864	1.9605	1.8671	2.0121	1.6924	1.3817
2	1.9791	1.73	1.9044	1.8671	1.9745	1.636	1.3443
3	1.9791	1.6548	1.8298	1.8858	1.918	1.5984	1.307
4	1.9418	1.636	1.8298	1.8671	1.8428	1.5608	1.2696
5	1.9044	1.5984	1.7737	1.8671	1.6924	1.5043	1.1949
6	1.5497	1.5796	1.6057	1.5497	1.5043	1.4103	1.1703
7	1.4937	1.4103	1.475	1.4937	1.3539	1.3163	1.1389
8	1.2696	1.2599	1.3443	1.2883		1.1283	1.0829
9	1.1765	1.2787	1.307	1.2883	1.1283		1.0269
10	1.1283	1.3163	1.363	1.2323	1.2035		1.0456
11	1.2411	1.2696	1.4003	1.2787	1.1283		1.0829
12	1.1659	1.2883	1.3443	1.3163	1.1471	.9335	.9709
13	1.1659	1.3443	1.3443	1.2787	1.1471	.9335	.9412
14	1.1471	1.363	1.3443	1.3163	1.1471	.8962	.9709
15	1.1659	1.5123	1.363	1.4667	1.2599	.8962	1.0642
16	1.1847	1.531	1.3817	1.4103	1.0907	.8589	1.0642
17	1.4291	1.4003	1.4003	1.3727	1.1283	.9709	1.0456
18	1.2035	1.2696	1.307	1.2787	1.1471	.9149	.9709
19		1.307	1.2136	1.3539	1.2035	1.0642	.9709
20	1.5043	1.643	1.6617	1.5796	1.4667	1.363	1.0456
21	1.5043	1.6804	1.6617	1.6548	1.4479	1.3443	1.0642
22	1.636	1.6991	1.7375	1.8428	1.542	1.363	1.0456
23	1.8052	1.9418	1.9418	1.9556	1.6924	1.4377	1.0642
24	1.7737	1.8804	1.9791	1.8823	2.0121	1.7676	1.4003
Max	1.9791	1.9418	1.9791	1.9556	2.0121	1.7676	1.4003
Min	1.1283	1.2599	1.2136	1.2323	1.0907	.8589	.9412
Avg	1.4925	1.5159	1.5614	1.5497	1.4430	1.2662	1.1110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 202 / 11 KV NERI 1 Fdr

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.6199	.6268	.6878	.6564	.6381	.5194
2	.5068	.6017	.6268	.6878	.6564	.6199	.5194
3	.5068	.5652	.6089	.6878	.6564	.6017	.5014
4	.4887	.547	.6089	.6878	.6564	.5834	.5014
5	.4887	.5288	.6089	.6878	.5834	.5834	.5014
6	.3801	.4923	.5014	.4887	.5105	.4376	.4298
7	.3439	.3829	.4298	.4525	.4376	.4194	.4119
8	.3077	.5105	.5014	.4344	.4558	.2735	.4477
9	.362	.547	.6089	.4344	.6381		.5014
10	.4194	.6564	.7164	.5249	.7658		.6447
11	.4194	.591	.5249	.5288	.6199	.4298	.6447
12	.4194	.5731	.543	.543	.6017	.4477	.6335
13	.6017	.7343	.5611	.5288	.5834		.5611
14	.6928	.6268	.7421	.5105	.6199		.5792
15	.4741	.788	.7421	.6017	.8022	.2328	.5973
16		.7164	.7421	.5105	.5834	.2149	.5973
17	.5105	.6805	.5792	.4376	.5834	.2149	.5611
18	.4923	.5731	.5249	.3647	.6381	.3403	.5068
19	.5652	.4656	.6516	.4558	.8022	.3582	.4344
20	.6199	.6626	.7059	.6199	.8752	.5194	.4344
21	.6381	.6447	.724	.6381	.6381	.5194	.3982
22	.6381	.6805	.724	.6746	.6381	.5552	.3982
23	.6564	.6984	.7059	.6928	.6564	.5552	.362
24	.5068	.6564	.6626	.7059	.6564	.6564	.5194
Max	.6928	.788	.7421	.7059	.8752	.6564	.6447
Min	.3077	.3829	.4298	.3647	.4376	.2149	.362
Avg	.5020	.6060	.6238	.5661	.6381	.4601	.5086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 205 / 11 KV YERKHEDA 2 FDR FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0429	.0433	.0572	.0286	.0569	.0288
2	.0429	.0433	.0572	.0286	.0569	.0288
3	.0429	.0433	.0572	.0286	.0569	.0288
4	.0429	.0433		.0286	.0569	.0288
5	.0572	.0433	.0572	.0286	.0569	.0288
6	.0572	.0433	.038	.0429	.0759	.0433
7	.0572	.0721	.075	.0857	.1155	.0577
8	.0572	.1298	.075	.1	.1589	.0721
9	.0572	.0577	.0857	.1143	.2022	
10	.0577	.0721	.0608	.1143	.2022	
11	.0721	.0599	.1067	.1155	.2019	.038
12	.0721	.088	.1219	.1155	.1875	
13	.0865	.0598	.1219	.1155	.1442	
14	.0721	.0598	.1143	.1155	.1298	
15	.0721	.0838	.1143	.1155	.1154	
16	.0433	.0838	.1143	.1155	.0865	
17	.0577	.0838	.1286	.1444	.0865	
18	.0577	.0838	.0857	.1444	.0865	.0543
19	.0577	.038	.0572	.1155	.0721	.0429
20	.0577	.0572	.0429	.0722	.0577	.0459
21	.0577	.0572	.0429	.0569	.0433	.0459
22	.0577	.0572	.0429	.0569	.0433	.0459
23	.0577	.0572	.0429	.0569	.0433	.0459
24	.0429	.0577	.0572	.0429	.0569	.0433
Max	.0865	.1298	.1286	.1444	.2022	.0721
Min	.0429	.038	.038	.0286	.0433	.0288
Avg	.0575	.0633	.0764	.0826	.0998	.0425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 206 / 11 KV Neri 2
Feeder KV- 11 / OUTGOING

DATE	24-JUN-18
HR	Load (MW)
14	1.1222
15	1.1222
16	1.1222
17	1.1222
18	1.0498
19	1.1765
Max	1.1765
Min	1.0498
Avg	1.1192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 207 / 11 KV MODI 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4299	1.3575	1.4327	1.4784	1.4842	1.2308	1.0387
2	1.4299	1.3213	1.4327	1.448	1.448	1.1765	.985
3	1.4415	1.267	1.3969	1.448	1.448	1.1403	.985
4	1.3937	1.2308	1.3969	1.448	1.4118	1.1041	.985
5	1.3756	1.2127	1.5581	1.448	1.448	1.086	1.1283
6	1.2308	1.1765	1.1641	1.2308	1.2308	1.0679	.9492
7	1.086	.9774	1.0566	1.086	1.0136	.9412	.8238
8	.9955	.9412	1.0029	1.0136	.9774	.8688	.7701
9	.9412	.9231	.9492	.9593	.9412		.7701
10	.9593	.9231	.9492	.9955	.9412		.8059
11	1.0498	1.0566	1.0136	1.0679	1.0136	1.2536	.8417
12	1.1041	1.0566	1.0498	1.086		1.1283	.905
13	1.1222	1.1104	1.1041		1.086	1.0387	.9412
14	1.1041	1.2178		1.267	1.1222	.9492	.9412
15	1.1584	1.2178		1.267	1.1584	.9313	.9231
16		1.2178		1.267	1.0136		.905
17	1.1041	1.1104		1.2308	1.086	1.0208	.905
18	.4525			1.1041	1.0498	.9134	.8145
19	1.1222	1.1462		1.1222	1.1041	1.0387	.9412
20	1.2489	1.2715	1.267	1.2127	1.2308	1.1283	.9412
21	1.3032	1.2536	1.267	1.267	1.1765	1.0924	.9412
22	1.3032	1.379	1.3756	1.3394	1.2308	1.0745	.905
23	1.3575	1.3432	1.3575	1.4118	1.267	1.0745	.905
24	1.4299	1.3937	1.4327	1.3575	1.4842	1.267	1.0745
Max	1.4415	1.3937	1.5581	1.4784	1.4842	1.267	1.1283
Min	.4525	.9231	.9492	.9593	.9412	.8688	.7701
Avg	1.1802	1.1785	1.2337	1.2416	1.1899	1.0727	.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 209 / 11 KV YASHODHARA NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.6582	.7023	.6838	.703	.6393	.5175
2	.7023	.6582	.6653	.6838	.703	.6393	.499
3	.7023	.6393	.6653	.6838	.6845	.6205	.499
4	.6838	.6205	.6283	.6838	.666	.6205	.499
5	.6653	.6205	.6283	.6838	.629	.6017	.499
6	.5914	.6017	.6099	.5914	.555	.5453	
7	.5359	.4701	.499	.5175	.4995	.4701	.4805
8	.499	.4701	.499	.5544	.481	.4325	.4251
9	.4887	.4889	.5175	.5544	.4625		.4251
10	.5641	.5265	.4805	.5914	.4995		.4066
11	.5453	.5201	.4805	.629	.5077	.3696	.4251
12	.5077	.499	.5175	.629			.4435
13	.5265	.5914	.5359	.592	.5641	.3326	.462
14	.5453	.6283	.5914	.629	.5829	.3326	.462
15	.5265	.6468	.6099	.629	.6017	.3326	.4251
16		.6653	.6099	.6105	.5077	.3881	.4251
17	.5453	.499	.6099	.6105	.5265	.4066	.4251
18	.4644	.499	.5544	.481	.4701	.4066	.3326
19	.4137	.5175	.462	.518	.4701	.4435	.4066
20	.5453	.6283		.6105	.5641	.5175	.4066
21	.5829	.6653	.6653	.592	.6017	.4805	.4066
22	.6205	.7023	.6838	.666	.6205	.5359	.4251
23	.7146	.7392	.7392	.666	.6393	.5359	.4251
24	.7023	.6958	.7023	.7392	.7215	.6582	.5175
Max	.7146	.7392	.7392	.7392	.7215	.6582	.5175
Min	.4137	.4701	.462	.481	.4625	.3326	.3326
Avg	.5815	.5938	.5938	.6179	.5766	.4909	.4452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 210 / 11 kv Ramanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1161	2.9294	3.1674	2.364	2.3891	2.1971	1.3575
2	3.1161	2.8745	3.0407	2.364	2.3529	2.1605	1.3394
3	3.1161	2.8379	3.0045	2.364	2.3529	2.1055	1.2851
4	3.0982	2.7463	2.9502	2.364	2.3167	2.014	1.267
5	3.0445	2.6548	3.3484	2.3461	2.3529	1.9774	2.0452
6	2.5968	2.5449	2.8054	2.0058	1.9909	1.8492	1.5927
7	2.4893	2.3435	2.4796	1.7909	1.9366	1.7394	1.5203
8	2.3102	2.2703	2.4072	1.7551	1.6108	1.538	1.448
9	2.2207	2.3069	2.371	1.7551	1.6108		1.3937
10	2.252	2.1971	2.3891	1.7909	1.647		1.3756
11	2.252	2.1538	1.7551	1.9004	1.6844	1.5746	1.4118
12	2.5083	2.4434	2.0595	1.9185	1.8492	1.9366	1.4685
13	2.5816	2.552	2.2314	1.8099	1.7943	1.7194	1.5043
14	2.4534	2.6606	2.5072	2.1357	1.776	1.5746	1.5223
15	2.3802	2.6244	2.4893	2.1357	2.014	1.5927	1.5223
16	2.4717	2.7511	2.4893	1.9909	1.6844	1.4842	1.5223
17	2.4168	2.5158	1.9521	1.9909	1.7943	1.3575	1.5223
18	2.3619	2.5158	1.8983	1.9366	1.8492	1.4842	1.5043
19	3.2407	2.6787	2.167	2.0814	2.0323	1.9185	1.6118
20	2.9995	3.0445	2.2028	2.3348	2.3435	2.0452	1.6297
21	2.9661	3.0045	2.2497	2.3167	2.2703	1.9185	1.6297
22	2.9294	3.0407	2.2028	2.3348	2.1238	1.8823	1.6297
23	2.3435	3.1312	2.364	2.3348	2.1971	1.8099	1.6118
24	3.0769	3.0027	3.2217	2.364	2.3891	2.2337	1.9004
Max	3.2407	3.1312	3.3484	2.364	2.3891	2.2337	2.0452
Min	2.2207	2.1538	1.7551	1.7551	1.6108	1.3575	1.267
Avg	2.6809	2.6594	2.4897	2.1035	2.0151	1.8233	1.5257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTTEE(DRAGON
PALACE

Feeder No / Name : 211 / 11 kv J P NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	1.4632	1.5729	1.5729	1.568	1.3717	1.134
2	1.5565	1.4266	1.5729	1.5729	1.5316	1.3535	1.0974
3	1.5565	1.39	1.5364	1.5729	1.4951	1.2986	1.0608
4	1.5546	1.3717	1.4998	1.5729	1.4586	1.262	1.0608
5	1.5181	1.3535	1.7375	1.5729	1.4951	1.262	1.1706
6	1.2986	1.3352	1.3535	1.3717	1.3128	1.2803	1.0791
7	1.1157	1.0791	1.1523	1.1888	1.094	1.0425	.9145
8	.9877	1.0242	1.0974	.9955	1.021	.9511	.8779
9	.9694	.9511	1.0608	1.0269	.9846		.8413
10	.9511	.9145	1.0425	1.0269	.9663		.823
11	.9511	1.0425	1.0608	1.0575	.9511	1.1888	.8413
12	.9877	1.0791	1.0608	1.094	.9145	.9877	.8326
13	.9145	1.1157	1.0608	2.2973	1.0425	.9145	.823
14	1.0059	1.2254	1.1157	1.1851	.9877	.823	.823
15	.9877	1.262	1.134	1.2034	.9877	.823	.823
16	1.0059	1.2254	1.134	1.1669	1.0425	.7682	.823
17	1.007	1.1157	1.134	1.1669	1.0059	.7133	.823
18	.9877	1.0059	1.0974	1.0575	1.0059	.7865	.7865
19	.9877	1.134	1.134	1.1304	1.0059	.9694	.9145
20	1.2437	1.3352	1.39	1.2763	1.2437	1.0974	.9511
21	1.3535	1.39	1.4266	1.3675	1.2803	1.134	.9694
22	1.4632	1.5181	1.4685	1.4951	1.3352	1.1523	.9694
23	1.6644	1.6095	1.6095	1.6045	1.4266	1.2071	.9145
24	1.5364	1.4815	1.6095	1.5927	1.6045	1.4449	1.134
Max	1.6644	1.6095	1.7375	2.2973	1.6045	1.4449	1.1706
Min	.9145	.9145	1.0425	.9955	.9145	.7133	.7865
Avg	1.2157	1.2437	1.2942	1.3404	1.1984	1.0833	.9370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 401 / 33 KV DRAGON PALACE
INCOMMER Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.425	8.9163	9.6965	8.7597	9.0278	7.8018	6.0185
2	9.425	8.6934	9.4179	8.7597	8.8606	7.6346	5.8513
3	9.425	8.4705	9.2507	8.7597	8.7492	7.4117	5.7399
4	9.3141	8.2476	9.0835	8.7597	8.5262	7.1888	5.6284
5	9.2587	8.0804	9.8637	8.7597	8.4148	7.0773	6.6315
6	7.8727	7.8018	8.1919	7.3737	7.3003	6.6315	5.7956
7	7.1519	6.6873	7.3003	6.7638	6.5758	6.0185	5.4055
8	6.653	6.6873	7.0773	6.2094	6.13	5.2941	5.0712
9	6.0985	6.5758	7.0216	6.2649	6.13		5.0154
10	6.4643	6.6315	7.1331	6.4312	6.4086		5.1826
11	6.6873	6.7987	6.3758	6.6873	6.2414	4.9597	5.2941
12	6.7987	7.1331	6.7638	6.8544	6.3529	5.517	5.2669
13	7.0216	7.6346	7.0965	6.743	6.4643	5.0154	5.2669
14	6.8544	7.9132	7.5955	7.3003	6.4086	4.6253	4.9897
15	6.9388	8.3033	7.5955	7.5789	6.2972	4.8483	4.3244
16	7.0773	8.3033	7.5955	7.1888	6.0185	3.7337	4.1581
17	7.0773	7.6346	7.041	7.0773	6.2972	4.7368	3.9918
18	6.6873	7.1331	6.7638	6.4643	6.2972	4.9597	5.0452
19	7.0773	7.356	7.2628	6.9102	6.743	5.9628	5.5441
20	8.2476	8.8049	7.4846	7.8575	7.8018	6.7987	5.5441
21	8.4705	8.8049	8.039	8.0247	7.4674	6.6315	5.5441
22	8.6934	9.195	8.2053	8.5262	7.5789	6.6873	4.8234
23	8.6377	9.6965	8.9815	8.8049	7.969	6.743	4.8234
24	9.2587	9.2507	9.808	9.0369	9.0278	8.1362	6.6315
Max	9.425	9.6965	9.8637	9.0369	9.0278	8.1362	6.6315
Min	6.0985	6.5758	6.3758	6.2094	6.0185	3.7337	3.9918
Avg	7.7757	7.9481	7.9435	7.5790	7.2120	6.1097	5.3162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 201 / 11 KV Bhilgaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.1763	1.2382	1.3256	1.2936	1.0534	.6722
2	1.1827	1.0829	1.1576	1.307	1.2567	1.0164	.6535
3	1.1458	1.0642	1.0903	1.2696	1.2197	1.0164	.6535
4	1.1088	.9709	1.0829	1.2696	1.1706	.9425	.6348
5		.9149	1.0349	1.1203	1.1203	.8871	.6348
6	.961	.8589	1.0164	1.0082	.9979	.8501	.6161
7	.8686	.8962	.9335	1.0082	.8501	.8402	.6535
8	.8871	.8775	.8589	.8215	.8501	.7468	
9	.8775	1.1763	1.1016	.8962	.8871	.6908	.8029
10	.8032	1.0534	.9979	.9709	.8962	.7392	.8131
11	1.1389	1.1827	1.0903	1.2323	.9149	.7577	.9425
12	1.251	1.423	1.2197	.9709	1.1949		.6722
13	.9522	1.0164	1.0269	1.307	1.2323		.5788
14	.8775	.961	1.0903	1.0082	.9522	.5729	.7842
15	.9896	1.1827	1.3817	1.0642	1.1763		.7655
16	.9522	1.2936	1.1827	1.251	1.1763	.5228	
17		1.2567	1.1016	1.1888	.8589	.5788	
18		1.2696	1.0829	1.0719	1.2012	.5228	.7392
19	1.4003	1.3443	.9335	1.363	1.0903	.6535	.9055
20	1.4003	1.5497	1.2696	1.4415	1.0349	.6722	
21	1.1203	1.1016	1.0642	1.1203	.9795	.6535	
22	1.0642	1.1576	1.2136	1.1643	1.0349	.6722	.6468
23	1.2323	1.2696	1.307	1.2696	1.0534	.7095	.6099
24	1.2197	1.251	1.2883	1.307	1.307	1.0903	.6722
Max	1.4003	1.5497	1.3817	1.4415	1.307	1.0903	.9425
Min	.8032	.8589	.8589	.8215	.8501	.5228	.5788
Avg	1.0778	1.1388	1.1152	1.1565	1.0729	.7709	.7080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 202 / 11 KV Ranala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.0642	1.2136	1.2012	1.2197	.9795	.7842
2	1.1273	.9896	1.1088	1.1827	1.1827	.9425	.7842
3	1.0719	.9335	1.0642	1.1643	1.1458	.924	.7655
4	1.0164	.8402	1.0269	1.1763	1.1088	.8871	.7655
5	.961	.7842	.924	1.0269	1.0082	.8316	.7095
6	.8501	.7842	.8501	.8402	.8589	.7577	.6348
7	.7392	.6908	.7468	.7655	.7023	.6722	.5788
8	.7023	.7655	.7095	.8215	.6653	.7468	
9	.7282	.6535	.7282	.6908	.7392	.6161	.5788
10	.6908	.6468	.7023	.6348	.7282	1.4969	.5788
11	.6722	.7023	.7023	.7095	.6348	1.3676	.5788
12	.6535	.7392	.7207	.7842	.7095		.5601
13	.6535	.7577	.7842	.8029	.6535		.5788
14	.9149	.8501	.8871	.8029	.7095	.1494	.5228
15	.7468	.924	.9149	.9335			.5415
16	.7095	.924	.924	.8962	.6535	.6283	
17		.8501	.8775	.8131	.6535	.4294	
18			.7468	.7023	.6283	.5975	.499
19	.7095	.8215	.7095	.7577	.6653	.6908	.6468
20	.8589	.9335	.9149	.9425	.8316	.7282	
21	.9149	.9709	.9709	.9145	.8501	.7095	
22	.9709	1.1203	1.0642	1.0349	.9055	.7655	.6283
23	1.1203	1.2696	1.2136	1.1765	.9979	.8029	.6099
24	1.2012	1.1389	1.2696	1.2323	1.2382	.9979	.8029
Max	1.2012	1.2696	1.2696	1.2323	1.2382	1.4969	.8029
Min	.6535	.6468	.7023	.6348	.6283	.1494	.499
Avg	.8717	.8763	.9073	.9170	.8474	.7963	.6394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 203 / 11 KV Ankit Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947	.6908	.8589	.7842	.9522	.6161	.6348
2	.8131	.6908	.8589	.7468	.924	.6161	.6535
3	.7762	.6722	.8589	.7468	.9522	.5975	.6535
4	.7947	.6535	.8402	.7282	.9149	.6161	.6348
5	.7947	.6722	.8215	.6908	.9522	.5975	.6722
6	.8316	.6722	.7947	.7095	.924	.5975	.6535
7	.7762	.8029	.7468	.9522	.9055	.5601	.6908
8	1.1827	.9896	.9522	.8402	.7577	.5729	
9		1.1389	.7842	1.0456	.7316	.5601	1.0456
10	.9896	1.2936	.9425	1.1949	1.1576	.5544	.9979
11	.7468	1.1273	1.0164	1.2696	1.4563		1.1643
12	.6348	1.2197	1.1157	1.1949	1.251		.8589
13	.8589	1.1827	1.2567	1.3256	1.3817		1.5339
14	1.1016	1.1643	1.0974	1.1389	1.9044	.3511	1.4045
15	1.475	1.2382	1.1827	1.251	1.1389		1.2752
16	1.2696	2.0119	1.0349	1.1949	1.1389	.2957	
17		1.0719	1.1203	1.1088	.9149	.3174	
18		1.9044	1.0642	1.1827	1.0164	.3734	1.6078
19	.8775	1.2696	.9149	1.0164	1.0534	.4294	1.8111
20	.9896	1.0082	.8029	1.1389	.7947	.5415	
21	1.0082	.8775	.8402	1.8111	.7392	.6348	
22	1.0082	.8402	.8589	.8215	.7282	.5788	.7577
23	.7282	.8589	.8215	.961	.6348	.6161	.8131
24	.7947	.6908	.8589	.7655	.9425	.7023	.6348
Max	1.475	2.0119	1.2567	1.8111	1.9044	.7023	1.8111
Min	.6348	.6535	.7468	.6908	.6348	.2957	.6348
Avg	.9165	1.0309	.9352	1.0258	1.0111	.5364	.9736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 204 / 11 KV Suman Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4668	.5415	.5228	.4481	.4668	.3734
2	.499	.4668	.5415	.5415	.4435	.4668	.3547
3	.462	.4481	.5415	.4854	.4251	.4854	.3547
4	.4668	.4481	.5041	.4668	.4435	.4854	.3361
5		.4481	.4668	.4481	.4435	.4668	.3361
6	.1494	.4108	.4066	.4108	.4251	.4854	.3174
7	.2427	.4108	.3921	.3734	.3841	.3734	.3361
8		.4294	.4668	.4854	.4066	.3921	
9	.2987	.4294	.3734	.4481	.4251	.3734	.3734
10	.3361	.5041	.4435	.3361	.4668	.3881	.4108
11	.5975	.5415	.5601	.5975	.5041		.4481
12	.5975	.5228	.5487	.5975	.5228		.4481
13	.4481	.5228	.499	.5601	.5041		.4294
14	.5788	.6099	.6468	.5601	.5041	.3696	.4294
15	.6348	.5175	.7392	.6535	.5975		.5041
16	.6161	.5914	.6838	.6908	.4668	.3696	
17		.5788	.5975	.6036	.5788	.3547	
18		.5041	.4668	.6099	.5544	.2987	.3326
19	.6161	.4854	.4481	.4755	.5228	.3921	.4066
20	.5601	.5041	.4481	.4854	.4066	.3361	
21	.5788	.5415	.4854	.4805	.4668	.3734	
22	.5788	.5415	.5228	.499	.4668	.3734	.3326
23	.5228	.5788	.5041	.5415	.5041	.3734	.3142
24	.5175	.4854	.5601	.5975	.4435	.4854	.3734
Max	.6348	.6099	.7392	.6908	.5975	.4854	.5041
Min	.1494	.4108	.3734	.3361	.3841	.2987	.3142
Avg	.4912	.4995	.5162	.5196	.4731	.4055	.3795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 205 / 11 KV Khasala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3121	1.1458	1.2936	1.3491	1.2752	1.1088	
24	1.423	1.3306	1.3491	1.4415	1.3491	1.3676	.8501
Max	1.423	1.3306	1.3491	1.4415	1.3491	1.3676	.8501
Min	1.3121	1.1458	1.2936	1.3491	1.2752	1.1088	.8501
Avg	1.3676	1.2382	1.3214	1.3953	1.3122	1.2382	.8501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 201 / 11 KV MES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.9145	1.1203	.9335	1.086	1.0974	.9431
2	1.1203	.905	1.1203	.9335	1.086	1.0974	.9335
3	1.1203	.8145	1.1203	.9335	.905	1.1317	.7468
4	1.0974	.8145	1.1203	.9335	.905	1.0059	.7468
5	1.1203	.724	.9335	.9335	1.086	.9145	.7468
6	.9335	.8145	.9335	.9431	.905	.7545	.7468
7		.8145	.9431	.9335	.8488	.8488	.7468
8	.9335	1.0974	.9431	.9431	.9431	.905	.4715
9	.9335	1.0974	1.1317	.9431	1.1317	.9145	.4715
10	1.1203	.9145	1.1317	1.1317		.9431	.3658
11	1.1203	1.3203	.9431		1.086	.9145	.5658
12	1.0974	1.3203	.905	1.1317	1.0974	.7316	.9145
13	.9145	1.4146	1.1317		1.0974	.9145	.9431
14	.9145	1.3203	1.1317		1.0974	.9145	.9431
15	.9145	1.1317	1.1317	1.226	1.0974	.9145	.9431
16	1.0974	1.1317	1.0059	1.1317	1.0974	.9145	.7545
17	.9145	1.226	1.0374	1.1317	.9145	.9145	.9431
18	1.0974	1.1317	1.1317	1.1317	.9145	1.0974	.9431
19	1.0974	1.226	1.0974	1.086	1.0059	1.1317	1.1317
20	1.086	1.5089	1.1317	1.3203	1.0974	1.1317	1.1317
21	1.0974	1.5089	1.1317	1.3203	1.086	1.1317	.9431
22	1.0974	1.3203	1.0374	1.1317	1.086	1.0374	.9431
23	1.0974	1.3203	1.226	1.1317	1.0974	1.0374	.7545
24	1.1203	1.0974	1.1203	.9431	1.1317	1.0974	.9431
Max	1.1203	1.5089	1.226	1.3203	1.1317	1.1317	1.1317
Min	.9145	.724	.905	.9335	.8488	.7316	.3658
Avg	1.0507	1.1204	1.0692	1.0594	1.0349	.9790	.8215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 205 / 11 KV AIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.724	1.1088	1.0974	.5487	.4572	.362
2	.924	.724	1.1088	.9335	.5487	.4572	.3696
3	.7392	.724	.3696	.9335	.5487	.3658	.2772
4	.7316	.724	.3658	.9335	.3658	.3658	.2772
5	.7392	.724	.3696	.7468	.3658	.3658	.2772
6	.5544	.543	.3696	.7468	.3658	.3658	.3658
7	.5544	.4525	.3658	.5601	.3658	.3658	.2772
8	.462	.3658	.3658		.3772	.362	.362
9	.3696	.3658	.4572	.543	.3658		.2829
10	.3696	.2715	.7316	.543	.3658		.3658
11	.3696	.2715	1.0059	.3658	.362		.3658
12	.4572	.3658	.9955	.3658	.3658		.2743
13	.2743	.3658	.905	.4572	.362		.1848
14	.1829	.3658	.9145	.4572	.2715		.1848
15	.181	.3658	.9145	.4572	.3658		.2772
16	.2715	.4572	1.1317	.4525	.2743	.181	.2772
17	.2743	.543	.905	.4572	.2743	.2715	.1848
18	.1829	.3658	.9145	.3658	.2743	.362	.1848
19	.1829	.4572	.9145		.3658	.181	.2743
20	.181	.7316	1.086	.4572	6.0357	.1829	.2772
21	.181	.9145	1.1317	.3658	.362	.362	.3734
22	.2715	1.0974	1.1765	.3658	.362	.362	.3696
23	.7316	1.0974	1.1765	.5487	.3658	.362	.3696
24	.924	.724	1.086	1.1888	.5487	.4525	.362
Max	.924	1.0974	1.1765	1.1888	6.0357	.4572	.3734
Min	.181	.2715	.3658	.3658	.2715	.181	.1848
Avg	.4597	.5726	.8279	.6065	.6170	.3425	.2990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 206 / 11 KV NCDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.362	.3696	.2715	.1829	.5487	.2715
2	.4525	.362	.3658	.181	.1829	.4572	.3658
3	.4572	.362	.2743	.181	.1829	.4572	.3658
4	.4572	.362	.3658	.181	.1829	.3658	.3658
5	.4525	.181	.2743	.181	.1829	.3658	.2743
6	.4572	.181	.1829	.181	.1829	.3658	.2743
7	.4572	.181	.1829	.181	.1829	.3658	.2743
8	.362	.2715	.1829	.3658	.1829	.362	.2715
9		.3258	.3658	.362	.1829	.2743	.3658
10	.2715	.2715	.1829	.362	.1829	.2743	.0366
11	.2715	.0914	.3658	.2743	.3658	.2715	
12	.0905	.0905	.362	.2743	.362	.2743	.0914
13	.181	.0914	.362	.2743	.362	.2715	.0914
14	.362	.1829	.3658	.3658	.362	.2715	.0924
15	.362	.1829	.3658	.2743	.3658	.2715	.0914
16	.2743	.1829	.2743	.2715	.3658	.2743	.0914
17	.2715	.1829	.2715	.2743	.3658	.1829	.0914
18	.181	.1829	.2743		.3658	.2715	.3772
19	.181	.1829	.1829	.181	.3658	.2715	.3658
20	.181	.1829	.2715	.181	.3658	.2715	.3658
21	.181	.1829	.2715	.1829	.362	.2715	.3658
22	.2743	.2743	.362	.181	.362	.2743	.3658
23	.439	.2743	.3658	.1829	.5487	.2715	.3658
24	.4525	.4525	.362	.2743	.1829	.5487	.2715
Max	.4572	.4525	.3696	.3658	.5487	.5487	.3772
Min	.0905	.0905	.1829	.181	.1829	.1829	.0366
Avg	.3271	.2332	.3002	.2452	.2888	.3265	.2562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 208 / 11 KV KAMPTEE I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0362	.0362	.905	.724	.5487	.4525
2	.0358	.0366	.0358	.905	.724	.5487	.362
3	.0362	.0366	.0362	.905	.724	.5487	.2715
4	.0358	.0366	.0362	.724	.8145	.5487	.2715
5	.0362	.0366	.0358	.724	.8145	.7316	.2715
6	.0362	.0183	.0362	.724	.724	.5853	.362
7	.0358	.0183	.0362	.724	.6335	.5487	.2715
8	.0358	.0362	.0362	.7316	.362	.4525	.543
9	.0358		.0362	.724	.362	.5487	.2715
10	.0358	.0362	.0362	.7316	.362	.9145	.543
11	.0358	.0362	.6401		.6335	.724	.4525
12	.0914	.0373	.6335	.362	.5487	.7316	.5487
13	.0362	.0362	.6335	.4525	.5487	.7316	.4572
14	.0362	.0362	.6401	.4525	.5487	.543	.4572
15	.0362	.0362	.6401	.4525	.4572	.543	.5487
16	.0362	.0362	.7316	.362	.3658	.5487	.5487
17	.0362	.0362	.724	.362	.362	.4525	.4572
18	.0362	.0362	.7316	.362	.2743	.5487	.4572
19	.0366	.0362	.7316	.3658	.5487	.543	.4572
20	.0366	.0362	.724	.724	.7316	1.5384	.4572
21	.0362	.0362	.6335	.724	.7316	.5487	.5487
22	.0366		.724	.724	.543	.543	.3658
23	.0362	.0362	.724	.8145	.362	.543	.5487
24	.0358	.0362	.0362	.9145		.543	.5658
Max	.0914	.0373	.7316	.9145	.8145	1.5384	.5658
Min	.0358	.0183	.0358	.362	.2743	.4525	.2715
Avg	.0384	.0347	.3879	.6465	.5609	.6274	.4371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 210 / 11 KV KAMPTEE II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.97	2.1033	2.1719	2.1719	2.1719	1.829	1.448
2	1.9909	2.1033	2.1719	2.1719	2.1948	1.829	1.448
3	1.97	1.829	1.9909	2.1719	1.9909	1.829	1.4327
4	1.7909	1.829	1.9909	1.9909	1.9909	1.829	1.4327
5	2.1491	1.9204	2.1719	1.9909	2.1719	2.0119	1.6289
6	1.97	1.829	1.9909	1.8099	1.9909	1.829	1.4632
7	1.8099	1.6461	1.8099	1.8099	1.6289	1.6461	1.267
8	1.6289	1.4632	1.8099	1.829	1.8099	1.4632	.905
9	1.6289	1.4632	1.8099	1.7194	1.6289	1.2803	.9145
10	1.6289	1.4632	1.6289	1.6289	1.6289	1.2803	1.1888
11	1.6289	1.448	1.6461	1.6289	1.448	1.267	1.2803
12	1.4632	1.448	1.6289	1.6289	1.2803	1.2803	1.3717
13	1.448	1.6289	1.448	1.6289	1.4632	1.086	1.0974
14	1.448	1.6289	1.4632	1.6289	1.448	1.086	.9145
15	1.4632	1.6289	1.829	1.8099	1.2803	.905	.9145
16	1.267	1.6289	1.829	1.8099	1.267	.9145	.4572
17	1.267	1.6289	1.6289	1.6289	1.2803	.9145	.823
18	1.267	1.448	1.6461	1.6289	1.267	1.086	.9145
19	1.448	1.448	1.6461	1.6461	1.5546	1.086	1.0974
20	1.6461	1.8099	1.8099	1.8099	1.7375	1.5546	1.0974
21	1.6461	1.8099	1.9004	1.8099	1.6461	1.5546	1.3717
22	1.829	1.9909	2.0119	1.8099	1.829	1.5384	.9145
23	1.829	2.0814	1.9909	2.1719	1.829	1.5384	.9145
24	1.9909	2.0119	1.829	2.3777	1.7918	1.829	1.5384
Max	2.1491	2.1033	2.1719	2.3777	2.1948	2.0119	1.6289
Min	1.267	1.448	1.448	1.6289	1.267	.905	.4572
Avg	1.6741	1.7204	1.8273	1.8464	1.6804	1.4361	1.1598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 401 / 33KV Khaparkheda

Feeder KV- 33 / INCOMING

DATE	24-JUN-18
HR	Load (MW)
24	2.0633
Max	2.0633
Min	2.0633
Avg	2.0633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 402 / 33 KV Khaperkheda 2
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2798	4.1152	4.4445	4.4353	3.7311	3.8409	3.7912
2	4.225	3.9506	4.5542	4.1152	3.6763	3.8409	3.6763
3	4.2798	3.8409	4.5542	4.201	3.4019	3.7311	3.6763
4	4.3896	3.8409	4.3896	3.8409	3.8409	3.7311	3.6763
5	4.3896	4.225	4.225	3.9209	4.0604	3.5665	3.5665
6	4.0055	3.8409	3.0178	3.9209	4.1152	3.5665	3.5117
7	3.5117	3.6763	1.9753	3.5117	3.6763	3.4019	3.3471
8	3.6214	3.5665	1.8656	3.8409	3.5665	3.2373	3.6214
9	3.7311	3.5665	1.9204	3.8409	3.7311	3.2922	3.5117
10	3.0178	3.6763	2.0851	4.0741	3.9506	3.6763	3.6763
11	3.0727	2.524	2.4143	3.8409	3.7311	3.2579	3.77
12	3.6763	.9877	2.4897	3.786	3.8409	3.2373	3.5288
13	3.2579	3.5117	4.1307	4.0604	3.638	3.4019	3.4928
14	3.8009	3.5117	4.1152	4.225	3.4019	3.2579	3.4374
15	3.2922	2.4143	4.6639	4.2798	3.8409	3.5665	3.8649
16	3.6763	4.4993	4.6639	4.4993	4.1152	3.0727	3.271
17	3.638	4.3347	3.9609	4.3896	3.6763	3.2922	3.4928
18	3.8409	3.8958	3.8409	3.5665	4.1152	3.4019	3.3819
19	4.0724	4.225	3.8409		4.1152	3.7346	3.8089
20	4.1152	4.4993	4.2438	3.9506	4.225	3.5837	4.0472
21	3.8409	4.7188		4.4993	4.1152	3.1121	3.8409
22	3.8409	4.9383	4.3896	4.5542	3.9506	3.9609	3.77
23	4.3439	3.7311	4.5268	4.7188	3.8409	3.9609	3.8649
24	4.3896	4.4993	4.4993	4.3896	4.5068	3.8958	3.9609
Max	4.3896	4.9383	4.6639	4.7188	4.5068	3.9609	4.0472
Min	3.0178	.9877	1.8656	3.5117	3.4019	3.0727	3.271
Avg	3.8462	3.7746	3.6875	4.1070	3.8693	3.5259	3.6495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 403 / 33 KV Water Works II
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	24-JUN-18
HR	Load (MW)
24	2.3663
Max	2.3663
Min	2.3663
Avg	2.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 404 / 33 KV SAGGU CASTING

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	8.8706	8.962	9.1301	9.2587	8.3809	7.7298	4.0741
16	11.1317	5.9876	11.9187	11.4117	10.9511	5.5996	3.6969
17		6.0985					
24	10.4231	12.939	13.7163	10.1943	11.9896	9.5914	9.2981
Max	11.1317	12.939	13.7163	11.4117	11.9896	9.5914	9.2981
Min	8.8706	5.9876	9.1301	9.2587	8.3809	5.5996	3.6969
Avg	10.1418	8.4968	11.5884	10.2882	10.4405	7.6403	5.6897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 408 / 33 KV MAHADULA I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4435	.168	.168	.1663	.3881	.8962	.9054
Max	.4435	.168	.168	.1663	.3881	.8962	.9054
Min	.4435	.168	.168	.1663	.3881	.8962	.9054
Avg	.4435	.168	.168	.1663	.3881	.8962	.9054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 409 / 33 KV MAHADULA II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	6.2649	6.5535	6.6095	6.7084	5.7613	4.5931	5.0926
Max	6.2649	6.5535	6.6095	6.7084	5.7613	4.5931	5.0926
Min	6.2649	6.5535	6.6095	6.7084	5.7613	4.5931	5.0926
Avg	6.2649	6.5535	6.6095	6.7084	5.7613	4.5931	5.0926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 201 / 11KV VASAHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.056	.056	.056	.056	.056	.056
2	.0373	.056	.056	.056	.056	.056	.056
3	.056	.056	.056	.056	.056	.056	.056
4	.056	.056	.056	.056	.056	.056	.056
5	.056	.056	.056	.056	.056	.056	.056
6	.056	.056	.056	.056	.056	.056	.0373
7	.056	.056	.056	.056	.056	.056	.0373
8	.056	.056	.0373	.056	.056		.056
9	.056	.056	.056	.056	.0187	.0187	.056
10	.0187	.0373	.0373	.056	.0187		.0373
11	.0373	.056	.0373	.056	.056		.056
12	.056		.0373	.056	.056	.0373	.056
13	.056	.056	.0373	.056	.056	.056	.0373
14	.056	.056		.056	.056	.056	
15	.056			.056	.056	.056	.056
16	.056		.056	.056	.056	.056	.056
17	.056		.056	.0373	.0187	.056	.056
18	.056		.056	.0373	.0373	.056	.056
19	.056		.056	.0373		.056	.056
20	.056		.056	.056	.056	.056	.056
21	.0514	.056	.056	.056	.056	.056	.0373
22	.056	.056	.056	.0373	.056	.056	.0373
23	.056	.056	.056	.056	.056	.056	.0373
24	.0373	.056	.056	.056	.0373	.4481	.056
Max	.056	.056	.056	.056	.056	.4481	.056
Min	.0187	.0373	.0373	.0373	.0187	.0187	.0373
Avg	.0511	.0549	.0518	.0529	.0495	.0720	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 202 / 11kv BORDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4108	.4294	.4481	.4294	.4294	.4294
2	.3734	.4108	.4294	.4294	.4294	.4108	.4108
3	.3734	.3921	.4294	.4294	.4108	.4108	.4108
4	.3734	.3734	.4294	.4294	.4108	.4108	.4108
5	.3361	.3361	.4108	.4108	.3734	.4108	.3734
6	.2987	.3174	.4108	.4294	.3547	.4108	.3361
7	.2801	.2427	.4108	.3734	.3547	.3734	.2987
8	.2054	.2427	.3921	.3547	.3547		.2801
9	.2241	.2801	.3361	.3734	.3547	.2987	.2614
10	.2427	.3174	.3547	.3734	.2801	.2987	.2241
11	.2241	.2241	.3734	.3361	.2241		.2054
12	.2054		.3547	.2801	.2241		.1867
13	.1867	.2614	.3921	.3174	.2614		.1867
14	.1867	.3361		.3174	.2987	.2614	
15	.2241			.3174	.2054	.2987	.1867
16	.2241		.3361	.2614	.2614	.3174	.1867
17	.2801		.2614	.2614	.2801	.2987	.2054
18	.1867		.3361	.2241	.2801	.2427	.2241
19	.2614		.4294	.3361		.4108	.2614
20	.3734	.3921	.4854	.3734	.1867	.4481	.2801
21	.4108	.4668	.4481	.4481	.4668	.4854	.2987
22	.4481	.4668	.4668	.4481	.4668	.4668	.3174
23	.4294	.4668	.4481	.4481	.4668	.4481	.3174
24	.3734	.4294	.4481	.4481	.4294	.4481	.4481
Max	.4481	.4668	.4854	.4481	.4668	.4854	.4481
Min	.1867	.2241	.2614	.2241	.1867	.2427	.1867
Avg	.2956	.3537	.4006	.3695	.3393	.3790	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 203 / 11 KV TEKADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	1.1949	1.419	1.3676	1.3443	1.2197	1.0719
2	.6348	1.1576	1.3817	1.3306	1.307	1.2197	1.0349
3	.6348	1.1576	1.3817	1.3121	1.2696	1.2197	.9795
4	.5975	1.1203	1.3443	1.2936	1.1203	1.1458	.9425
5	.5601	1.0829	1.2883	1.2567	1.2323	1.1458	.9055
6	.4854	1.0269	1.2883	1.2197	1.1203	.961	.8501
7	.4108	1.1576	1.0082	1.0903	1.0082	1.1088	.6468
8	.3921	.8402	.7842	.9795	.9522	.8131	.7023
9	.5601	.8962	.9709	1.2382	.8962	.9055	.6283
10	.6348	.9522	1.0082	1.251	.8589	.8316	.5359
11	.6348	.9709	1.0349	1.1576	.8402	.7947	
12	.6535		1.0164	1.0269	.8402	.8871	.6722
13	.7842	.9522	1.0349	1.0829	.9335	.9425	.7468
14	.8402	.8962		1.1203	.9522	.9055	
15	.8402			1.1576	.8589	.8871	.5601
16	.8589		1.0164	1.1949	.8589	.9425	.6722
17	.8775		.961	1.1576	.8402	.8501	.7095
18	.8215		1.0903	.9522	.9335	.8131	.7842
19	1.0829		1.2752	1.2883	1.1389	1.0719	.9709
20	1.363	1.3443	1.3491	1.4937	1.1203	1.1827	.6348
21	1.307	1.4377	1.3121	1.475	1.2883	1.2567	.9709
22	1.2696	1.531	1.4045	1.4563	1.1203	1.2197	1.0269
23	1.1949	1.363	1.3676	1.3443	1.3256	1.2012	1.0082
24	.0747	1.1949	1.5123	1.3306	1.3443	1.3443	1.1643
Max	1.363	1.531	1.5123	1.4937	1.3443	1.3443	1.1643
Min	.0747	.8402	.7842	.9522	.8402	.7947	.5359
Avg	.7562	1.1265	1.1932	1.2324	1.0627	1.0362	.8281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 201 / 11 KV VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0191
16	.0191	.0191		.0191		
17			.0191		.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 203 / 11 KV KANHAN U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0191
16	.0191	.0191		.0191		
17					.0191	
23			.0191			
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 205 / 11 KV KANHAN R

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.0191		.0191	.0191	
22					.0191
23		.0191			
Max	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 206 / 11 KV KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0191
16	.0191		.0191			
17				.0191	.0191	
23		.0191				
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 207 / 11 KV WCL NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0191
16	.0191	.0191	.0191			
17				.0191	.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 209 / 11KV KFA II
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)
14	.0191	
17		.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 210 / 11 KV STATION T/F
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0191
14		.0191				
15	.0191					
16			.0191	.0191		
17					.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 211 / 11 KV REHAB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18
HR	Load (MW)	Load (MW)
16		.0191
17	.0191	
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 400 / 33KV Mansar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13						.0572
16	.0572	.0572	.0572			
17					.0572	
18				.0572		
23	.0572					
Max	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 401 / 33 KV KANHAN W/W
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.0572	.0572	.0572	.0572		
17					.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 402 / 33KV GONDEGAON
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.0572	.0572		.0572		
17					.0572	.0572
23			.0572			
Max	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 403 / 33kv Dragon Palace fdr NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.0572	.0572	.0572		
17				.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 201 / 11 KV GUMTHALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4191	.4458	.4904	.4458	.381	.415
2	.5093	.381	.4115	.4904	.463	.3429	.415
3	.4527	.381	.463	.4715	.463	.3429	.3961
4	.415	.3429	.4287	.4715	.4458	.3048	.3772
5	.3961	.3429	.4973	.4338	.4115	.2858	.3772
6	.3772	.2858	.3258	.415	.3772	.3239	.3584
7	.3206	.3048	.3429	.3961	.3086	.3429	.3584
8	.3018	.2667	.3601	.3772	.3772	.3429	.3018
9	.2572	.2641	.2915	.3961	.3429	.3239	.3018
10	.2401	.2829	.3584	.3086	.4763	.3395	.1029
11	.2401	.1509	.3395	.583	.4954	.3584	.1372
12	.2229	.1698	.3584	.3944	.4382	.3395	.1543
13	.2572	.1886	.3961	.4115	.4191	.2829	.12
14	.2401	.3584	.3772	.3429	.5335	.2829	.1372
15	.2572	.3584	.3584	.3086	.3429	.2829	.2401
16	.2401	.3772		.3258	.3239	.2641	.2229
17	.2477	.3601	.3584	.4115	.3429	.2641	.2401
18	.2858	.2915	.3018	.4287	.3429	.3395	.2743
19	.362	.3258	.3584	.4458	.4001	.3772	.2915
20	.4572	.4287		.463	.4382	.3961	.3258
21	.4191	.4458	.4904	.4458	.4191	.415	.2915
22	.4572	.463	.5281	.4801	.4763	.415	.2743
23	.4382	.4115	.5093	.463	.4763	.415	.2915
24	.5093	.4382	.4458	.5093	.463	.4382	.415
Max	.5093	.463	.5281	.583	.5335	.4382	.415
Min	.2229	.1509	.2915	.3086	.3086	.2641	.1029
Avg	.3506	.3350	.3976	.4277	.4176	.3417	.2841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 202 / 11 KV PALSAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.8029	.6001	.6602	.6001	.4668	.7545
2	.6602	.7468	.7716	.6602	.6859	.4668	.7545
3	.6602	.7095	.7716	.6602	.6859	.4294	.7167
4	.6413	.7095	.6859	.6413	.6859	.3734	.7167
5	.6413	.6535	.6859	.6413	.6001	.3361	.7167
6	.6224	.5788	.6001	.6413	.6001	.3361	.6602
7	.6602	.5601	.6859	.6413	.6001	.3018	.6602
8	.6413	.5788	.5144	.5847	.6859	.4294	.5658
9	.6859	.8488	.6001	.6602	.6859	.5228	.6413
10	.9431	1.0374	.9431	.6859	.8029	.6036	
11	.9431	1.094	.9431	.9431	.9149	.6413	.6859
12	.8573	1.1694	1.0185	.5144	.8029	.6413	.6859
13	1.0288	.9997	.9619	.8573	.7842	.6602	.7716
14	1.0288	1.0751	1.0185	.9431	.8402	.6602	.6859
15	1.0288	1.1317	.9808	.8573	.8589	.6413	.7716
16	.8573	1.094	.9431	.9431	.8962	.6224	.6859
17	.9896	1.0288	1.0185	.8573	.8402	.6224	.7716
18	1.0456	.9431	1.0374	1.0288	.7468	.6413	.7716
19	.9896	1.0288	.9997	.8573	.7095	.6602	.7716
20	.9335	.7716	.679	.8573	.7095	.6602	.8573
21	.8962	.6859	.7922	.8573	.6161	.6602	.7716
22	.9149	.6859	.9054	.6859	.5415	.6602	.6859
23	.8589	.6859	.7545	.6001	.5228	.7545	.6859
24	.6602	.8589	.6001	.7545	.6001	.4854	.7545
Max	1.0456	1.1694	1.0374	1.0288	.9149	.7545	.8573
Min	.6224	.5601	.5144	.5144	.5228	.3018	.5658
Avg	.8270	.8533	.8130	.7514	.7090	.5532	.7193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 203 / 11 KV BHUGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8402	.8573	.8688		.8029	.724
2	.4887	.8029	.9088	.8688	.6001	.7468	.724
3	.4887	.8029	.9088	.8688	.6516	.6535	.6878
4	.5068	.7095	.8573	.8326	.6001	.5975	.6878
5	.5068	.6535	.8059	.7602	.5144	.5601	.6335
6	.4525	.6161	.7545	.724	.5144		.5792
7	.362	.5788	.5487	.6516	.5487	.5415	.5611
8	.3439	.5975	.5316	.7602	.6173	.5228	.5611
9	.3429	.5611	.5487	.7602	.6001	.5601	.5792
10	.3086	.5611	.6154	.823	.8029	.5068	.6001
11	.1715	.5249	.6697	.6516	.9709	.4706	.6859
12	.2915	.5611	.6697	.6173	.9335		.6001
13		.6335	.6697	.6859	.8962	.3982	.3429
14		.6697	.7421	.7545	.8402	.3801	.4115
15	.4115		.7421	.823	.8402	.362	.2572
16	.3429	.5792		.8402	.8775	.3439	.3944
17	.5228	.5144	.6878	.5487	.8029	.4344	.463
18	.5975	.4801	.724	.7545	.7655	.5068	.4115
19	.7095	.4801	.5611	.8059	.8962	.5611	.463
20	.8029	.7545	.543	.9774	.9522	.6516	.5487
21	.8962	.7716	.9619	.9602	.9335	.7059	.5658
22	.9522	.9259	1.0185	1.046	.9896	.7421	.583
23	.8962	.9259	.9412	1.0288	.9335	.5415	.583
24		.8402	.3772	.9412	.9774	.8962	.724
Max	.9522	.9259	1.0185	1.046	.9896	.8962	.724
Min	.1715	.4801	.3772	.5487	.5144	.3439	.2572
Avg	.5198	.6689	.7237	.8064	.7852	.5676	.5572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 204 / 11 KV BHOWARI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.2401	.3361	.2572	.1886	.1867
2	.0189	.1132	.3258	.3174	.2915	.1886	.1867
3	.0189	.1132	.3944	.3174	.2743	.1886	.1494
4	.0189	.132	.3601	.0189	.2572	.2263	.0187
5	.0189	.1509	.3086	.0187	.1886	.1886	.0187
6	.0189	.1886	.1886	.3174	.1886	.1886	.1867
7	.1698	.1698	.2743	.3361	.1029		.2054
8	.1867	.1509	.1886	.2241	.1029		.2241
9	.1886	.1494	.1715	.2801	.1886		.2241
10	.1029	.2452	.2054	.2401	.3395	.3174	.2229
11	.1029	.2801	.2075	.2401	.3961	.3734	.2743
12	.1372	.2241	.2829	.2229	.3395		.3086
13	.3086	.1867	.1867	.1886	.3772		.4115
14	.2401	.2241	.168	.3086	.3395		.3086
15	.2572	.2241	.2241	.3086	.3395		.4973
16	.1886	.2054	.1867	.2401	.3772		.3944
17	.1886	.2229	.2054	.2915	.3395		.2915
18	.2075	.1372	.2452	.2401	.3206		.463
19	.1886	.1886	.2075	.1886	.2829		.2915
20	.1509	.2401	.1494	.3429	.2263	.1494	.2743
21	.1886	.1886	.1867	.2401	.2075	.1867	.2401
22	.2075	.3086	.2241	.1715	.2452	.2241	.3258
23	.1886	.2401	.3921	.1715	.1886	.1867	.3086
24	.1698	.1509	.2743	.3361		.1509	.1886
Max	.3086	.3086	.3944	.3429	.3961	.3734	.4973
Min	.0189	.1132	.1494	.0187	.1029	.1494	.0187
Avg	.1515	.1911	.2416	.2457	.2683	.2121	.2584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 205 / 11 KV SAWALI GARLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.1132	.4287	.1086	.3429	.1886	.0905
2	.0724	.1132	.4287	.1086	.4287	.1886	.0905
3	.0543	.0943	.3429	.1086	.4287	.1698	.0905
4	.0543	.0943	.3429	.0905	.5144	.1698	.0543
5	.0543	.0754	.2572	.0905	.4287	.1509	.0543
6	.0543	.1132	.1715	.0724	.3429	.1698	.0724
7	.0543	.1886	.1715	.1448	.2572	.1886	.0724
8	.0543	.1698	.2572	.1086	.4287	.1698	.0724
9	.0857	.0724	.1715	.1448	.5144	.1886	.0724
10	.2572	.0543	.1267	.1715	.4904	.1629	.0857
11	.1715	.0543	.0724	.5144	.547	.1448	.1715
12	.1715	.0543	.0724	.4287	.5281		.1715
13	.1715	.0905	.0905	.4287	.547	.0362	.1715
14	.1715	.0905	.1086	.5144	.415	.0362	.1715
15	.1715	.0905	.1267	.4287	.3772	.0362	.1715
16	.1715	.0905	.1448	.5144	.3395	.0362	.2572
17	.1509	.2572	.1267	.3429	.3018	.0543	.1715
18		.1715	.0724	.4287	.2829	.0362	.1715
19	.1509	.0857	.0905	.4287	.2452	.0362	.1715
20	.1886	.1715	.1448	.6001	.2263		.2572
21	.1509	.1715	.1509	.4287	.1886	.0543	.1715
22	.1886	.3429	.1448	.5144	.2263	.0543	.2572
23	.1509	.3429	.1448	.4287	.1886		.2572
24	.0724	.1132	.4287	.1448	.3429	.1886	.0724
Max	.2572	.3429	.4287	.6001	.547	.1886	.2572
Min	.0543	.0543	.0724	.0724	.1886	.0362	.0543
Avg	.1259	.1340	.1924	.3040	.3722	.1172	.1417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 206 / 11 KV VAISHNAVI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0514	.0566	.0514	.0754	.0377
2	.0377	.0566	.0514	.0566	.0514	.0566	.0377
3	.0377	.0566	.0514	.0566	.0514	.0566	.0377
4	.0377	.0566	.0514	.0566		.0566	.0377
5	.0377	.0566	.0514	.0566		.0566	.0377
6	.0377	.0566	.0514	.0566		.0566	.0377
7	.0377	.0754	.0514	.0566	.0514	.0566	.0377
8	.0377	.0754	.0514	.0566	.0514	.0566	.0377
9	.0514	.0566	.0514	.0566	.0514	.0566	.0377
10	.0857	.2075	.1509	.1715	.4904	.0377	.1372
11	.3429	.6224	.132	.3429	.6036	.0377	.2572
12	.4287	.1509	.1698	.4287	.5281	.0377	.3429
13	.5144	.0566	.1698	.3429	.3961	.0377	.4287
14	.5144	.0566	.1698	.5144	.415	.0377	.4287
15	.4287	.132	.1509	.4287	.3772	.0377	.5144
16	.3429	.0566	.0566	.4287	.4715	.0377	.4287
17	.2263	.0514	.0566	.3429	.2829	.0377	.0514
18	.1509	.0514	.0566	.0514	.1886	.0377	.0514
19	.1509	.0514	.0566	.0514	.1509	.0377	.0514
20	.1509	.0514	.0566	.0514	.1132	.0377	.0514
21	.0754	.0514	.0566	.1029	.0754	.0377	.0514
22	.0754		.0566		.0754	.0377	.0514
23	.0754	.0514	.0566	.0514	.0754	.0377	.0514
24	.0377	.0754	.0514	.0566	.0514	.0754	.0377
Max	.5144	.6224	.1698	.5144	.6036	.0754	.5144
Min	.0377	.0514	.0514	.0514	.0514	.0377	.0377
Avg	.1647	.0962	.0796	.1685	.2192	.0471	.1364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 207 / 11KV WADODA INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.4108	.3601	.415	.3601	.3547	.3772
2	1.094	.4108	.3944	.415	.3944	.3547	.3772
3	1.1317	.3921	.3944	.415	.4287	.3361	.3961
4	1.1694	.3921	.3601	.415	.3944	.3361	.3772
5	1.2449	.3734	.3772	.415	.3601	.3547	.415
6	1.1317	.4294	.3601	.3961	.3601	.4108	.415
7	.9619	.4108	.3258	.4338	.4115	.4294	.3584
8	1.0562	.4481	.3086	.3772	.463	.5415	.4527
9	1.0288	.4904	.3429	.4527	.5144	.6161	.4338
10	1.1488	.5658	.5658	.5144	.9896	.7545	.4287
11	1.2517	1.3203	.7167	1.7147	1.2883	.8488	.8573
12	1.2003	.9431	.7922	1.3717	1.307	.7922	.6001
13	1.3546	.547	.811	1.0288	1.3443	.7922	.4458
14	1.3717	.6602	.679	.6516	1.0829	.7733	.463
15	1.6461	1.1317	.9242	.6859	.9896	.7545	.4458
16	1.2003	.6413	.8488	.7202	.9149	.7167	.4801
17	1.1389	.6516	.6602	1.3717	.8029	.679	.463
18	.9709	.4801	.6602	.8573	.7282	.679	.5487
19	1.1576	.463	.7167	.6859	.4668	.3772	.5144
20	1.4563	.3429	.5281	.5658	.3921	.3772	.3944
21	.5228	.3258	.3961	.5144	.3734	.3961	.3429
22	.4294	.4287	.3961	.4801	.3734	.415	.3086
23	.4108	.4115	.415	.4287	.3547	.3961	.2915
24	1.0374	.3921	.3944	.415	.3429	.3547	.3772
Max	1.6461	1.3203	.9242	1.7147	1.3443	.8488	.8573
Min	.4108	.3258	.3086	.3772	.3429	.3361	.2915
Avg	1.0897	.5443	.5303	.6559	.6432	.5350	.4402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 208 / 11 KV CHIKHALI NIMBHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.1132	.12	.1267	.12	.1509	.0905
2	.0543	.1132	.1372	.1267	.1372	.1509	.0905
3	.0362	.0943	.1372	.1267	.1372	.1132	.0724
4	.0362	.0943	.1372	.1086	.12	.1132	.0724
5	.0362	.1132	.12	.1086	.1029	.0943	.0724
6	.0362	.0943		.0905	.1029	.1132	.0724
7	.0543	.1132		.1629		.0943	.0543
8	.0362	.132		.2172	.1715	.0754	.0543
9	.0514	.0905		.181	.1886	.0943	.0543
10	.0343	.0724		.1543	.2263	.0724	.0857
11	.0343	.0905	.1267	.2401	.2452	.0724	.0514
12	.0343	.0905	.0724	.2229	.2075	.0724	.0514
13		.1086		.2058	.2263	.0724	.0343
14	.0343	.1086		.0857	.1886	.0724	.0343
15	.0343	.1086		.1029	.2263	.0724	.0514
16	.0343	.1086	.1267	.1715	.2075	.0754	.0514
17	.0566	.0857	.1267	.2229	.1886	.0543	.0514
18	.0754	.1029	.1086	.2058	.1886	.0543	.0343
19	.1132	.0514	.1448	.1886	.1698	.0724	.0343
20	.132	.1543	.1448	.1543	.1698	.0905	.1029
21	.1132	.1372	.1448	.1543	.1509	.0724	.0857
22	.1509	.1372	.1448	.1543	.1886	.0543	.0686
23	.132	.1372	.1448	.1372	.1886	.0905	.0686
24	.0543	.1132	.12	.1448	.1372	.1698	.0905
Max	.1509	.1543	.1448	.2401	.2452	.1698	.1029
Min	.0343	.0514	.0724	.0857	.1029	.0543	.0343
Avg	.0621	.1069	.1285	.1581	.1735	.0903	.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 209 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0377	.0377	.0171	.0377	.0377	.0377
24	.0754	.0377		.0754		.0754
Max	.0754	.0377	.0171	.0754	.0377	.0754
Min	.0377	.0377	.0171	.0377	.0377	.0377
Avg	.0566	.0377	.0171	.0566	.0377	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 201 / 11 KV BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6268	1.7147	1.9052	1.8625	2.21	2.0957	1.4449
2	.6089	1.7147	1.9052	1.8267	2.21	2.0195	1.4266
3	.6089	1.6766	1.848	1.7909	2.1338	2.0005	1.4083
4	.591	1.6766	1.8099	1.7551	2.1338	2.0005	1.4083
5	.5731	1.6385	1.6194	1.7193	2.0195	1.9052	1.39
6	.4784	1.5242	1.448	1.4403	1.8861	1.7528	1.3352
7	.3772	1.2574	1.2955	1.2763	1.6766	1.3527	1.1888
8	.3601	1.2955	1.2765	1.1603	1.5813		1.2071
9	.3077	1.2384	1.2955	1.3056	1.5051		1.1041
10	.2915	1.1431	1.3717	1.3226	1.6956	1.1431	.9231
11	.3239	1.2193	1.2346	1.5432	1.5623	.3601	.8573
12	.3239	1.1812	1.286	1.9433	1.829	.4458	.8192
13	.3239	1.1431	1.166	1.9433	1.7147	.5138	.8002
14	.4191	1.2955	.8059	2.1148	1.7528	.5304	.724
15	.743	1.4098	1.3717		1.7337	.3978	.8002
16	.743	1.2003	.6516	1.7147	1.5813	.3978	.7811
17	.4001	1.1241	1.2174	1.7528	1.5813	.4641	.9335
18	1.0479	1.1431	1.1797	1.5623	1.5242	.6962	.8954
19	1.5813	1.2193	1.379	1.8671	1.7337	1.0566	1.1622
20	1.6385	1.6575	1.7551	2.1338	2.0005	1.4998	1.2574
21	1.7718	1.8671	1.9342	2.2672	2.1719	1.5729	1.2574
22	1.7909	2.0195	1.9879	2.3434	2.2291	1.5364	1.2193
23	1.7337	1.9243	1.9342	2.2481	2.191	1.5181	1.1622
24		1.7147	1.9052	1.8983	2.2481	2.0957	1.4632
Max	1.7909	2.0195	1.9879	2.3434	2.2481	2.0957	1.4632
Min	.2915	1.1241	.6516	1.1603	1.5051	.3601	.724
Avg	.7680	1.4583	1.4826	1.7736	1.8711	1.2434	1.1237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 204 / 11 kv Pawaddona

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1334	.1143	.1402	.1905	.1905	.0914
2	.0934	.1334	.1143	.1402	.1905	.1905	.0914
3	.0934	.1334	.1143	.1402	.1905	.1715	.0732
4	.0934	.1143	.1143	.1402	.1715	.1715	.0732
5	.0934	.1143	.0953	.1402	.1715	.1524	.0732
6	.0554	.0762	.0953	.0972	.1334	.1334	.0732
7	.0549	.0572	.0953	.1027	.1334	.1143	.0716
8	.0549	.0572	.0953	.1174	.1524	.0953	.0716
9	.0686	.0953	.1143	.1337	.2096	.1143	.0532
10	.0686	.0953	.1143	.1337	.2096	.0953	.0532
11	.0572	.0953	.0937	.1905	.1905	.0876	.0381
12	.0572	.1143	.0937	.1524	.1715	.0526	.0381
13	.0572	.0953	.1094	.1715	.1715	.052	.0381
14	.0572	.1143	.0937	.1715	.1715	.0347	.0572
15	.0572	.0953	.0781		.1715	.052	.0572
16	.0572	.1334	.1094	.1143	.1905	.052	.0572
17	.0572	.0953	.0937	.1524	.1334	.0347	.0572
18	.0572	.0953	.0903	.1905	.1524	.0347	.0381
19	.0953	.0762	.0876	.1715	.1524	.0732	.0953
20	.1143	.1143	.1227	.1715	.1715	.0732	.1334
21	.1334	.1334	.1402	.1715	.1905	.0732	.0572
22	.1334	.1334	.1402	.1905	.2096	.0732	.0762
23	.1334	.1334	.1402	.1905	.1905	.0914	.0762
24		.1334	.1334	.1402	.1905	.1905	.0914
Max	.1334	.1334	.1402	.1905	.2096	.1905	.1334
Min	.0549	.0572	.0781	.0972	.1334	.0347	.0381
Avg	.0807	.1072	.1081	.1506	.1754	.1002	.0682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 205 / 11 KV NEHARVANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	.9907	1.2574	1.2715	1.6194	1.5242	.8871
2	1.0608	.9907	1.2384	1.2536	1.6194	1.5242	.8686
3	1.0425	.9526	1.2384	1.2536	1.5432	1.5242	.8501
4	1.0425	.9526	1.1812	1.2357	1.5242	1.4289	.8501
5	1.0242	.9145	1.0479	1.2178	1.467	1.3336	.8316
6		.8383	.9335	.9431	1.3527	1.1241	.724
7	.6154	.743	.8764	1.0562	1.3336	.9335	.6154
8		.4954	.8192	1.0059	.6097		.5792
9	.6135	.743	.9526	.788	.4572		.5731
10	.5959	.7811	.9907	1.073	.5335	.4001	.4656
11	.5716	.8954	.9945		1.1622	.407	.4191
12	.5716	.7811	.9088		1.3146	.5087	.4382
13	.5525	.8383	1.0974	.9145	1.3717	.5028	.4191
14	.6287	.5716	1.1145	.0191	1.3336	.4508	.4191
15	.6287	.9145	1.0631		1.3146	.2427	.4191
16	.6097	.9145	.9774	1.3908	1.3146	.4681	.4572
17	.6097	.8383	.9259	1.4861	1.3527	.4508	.4763
18	.6668	.8764	.8421	1.5242	1.3336	.5028	.5525
19	.8383	.9335	.9671	1.5051	1.2955	.7316	.743
20	1.0479	1.086	1.1462	1.5432	1.448	.8871	.8002
21	1.105	1.2955	1.2536	1.5432	1.5432	.9425	.8002
22	1.1812	1.3336	1.3253	1.6575	1.5813	.9425	.7811
23	1.0288	1.3146	1.3253	1.6385	1.5623	.9055	.7621
24		1.0288	1.2765	1.2894	1.6385	1.5432	.9055
Max	1.1812	1.3336	1.3253	1.6575	1.6385	1.5432	.9055
Min	.5525	.4954	.8192	.0191	.4572	.2427	.4191
Avg	.8141	.9177	1.0731	1.2195	1.3178	.8763	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 206 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0953	.1715	.1715	.1715	.1524	.1524
2	.1715	.0953	.1715	.1715	.1715	.1524	.1524
3	.1715	.0953	.1715	.1715	.1715	.1524	.1524
4	.1715	.0953	.1715	.1715	.1715	.1524	.1524
5	.1715	.0953	.1715	.1715	.1715	.1524	.1524
6	.0381	.0953	.0572	.0572	.0572	.0381	.0381
7	.0381	.0381	.0381	.0381	.0572	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.3239	.0381	.0381	.0572	.0381	.0381	.0381
12	.0381	.0381	.0381	.0572	.0381	.0381	.0381
13	.0381	.0381	.0572	.0572	.0381	.0381	.0381
14	.0381	.0381	.0572	.0572	.0381	.0381	.0381
15	.0381	.0381	.0572		.0381	.0381	.0381
16	.0381	.0381	.0572	.0572	.0381	.0381	.0381
17	.0381	.0381	.0572	.0572	.0381	.0381	.0381
18	.0381	.0572	.0572	.0572	.0381	.0381	.0381
19	.0381	.0572	.1143	.0572	.0381	.1524	.1524
20	.0953	.1715	.1715	.1715	.1524	.1524	.1524
21	.0953	.1524	.1715	.1715	.1524	.1524	.1334
22	.0953	.1524	.1715	.1715	.1524	.1524	.1334
23	.0953	.1715	.1715	.1715	.1524	.1524	.1334
24		.0953	.1715	.1715	.1715	.1524	.1524
Max	.3239	.1715	.1715	.1715	.1715	.1524	.1524
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0895	.0770	.1024	.1036	.0921	.0905	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 201 / 11 KV MOUDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.6804	1.7551	1.8671	1.6651	1.848	.0934
2	1.531	1.6617	1.7551	1.8671	1.6289	1.8111	.0934
3	1.531	1.6766	1.7177	1.7924	1.5384	1.7924	.0934
4	1.531	1.6221	1.7177	1.7177	1.448	1.6787	.0934
5	1.4937	1.5123	1.6804	1.6057	1.3575	1.5123	.0747
6	1.3443	1.386	1.3817	1.419	1.3394	1.2136	.0934
7	1.2136	1.1706	1.2323	1.2883	1.0498		.0747
8	1.0269	.8589	1.1203	1.1203	1.0679		.056
9	1.0082		1.226	1.1576	1.0498		.0747
10	.9808	1.5813	1.2071	1.2696	1.1222		.0934
11	1.0479	1.358	1.307	1.3032	1.3908		.0934
12	1.1389	1.3769	1.3817	1.3717	1.3957		.0934
13	1.1458	1.4335	1.4377	1.4299	1.4003	.056	.0934
14	1.1389	1.5123	1.5123	1.5203	1.3535	.0747	.0747
15	1.1203	1.4712	1.587	1.5746	1.4377	.056	.0934
16	1.1584	1.5466	1.5123	1.647	1.4289	.0754	.0747
17	1.1949	1.3769	1.475	1.448	1.251	.056	.0747
18	1.1458	1.2136	1.307	1.3213	1.1643	.0747	.0747
19	1.3443	1.419	1.419	1.3394	1.4045	.0934	.0934
20	1.6194	1.5844	1.6804	1.4842	1.6385	.0934	.0747
21	1.5432	1.6991	1.7364	1.7556	1.7364	.0934	.0934
22	1.7551	1.8484	1.9044	1.828	1.7924	.0934	1.0082
23	1.7737	1.8298	1.8858	1.9185	1.8673	.0934	
24	1.5684	1.7177	1.8111	1.8858	1.7194	1.7924	.0934
Max	1.7737	1.8484	1.9044	1.9185	1.8673	1.848	1.0082
Min	.9808	.8589	1.1203	1.1203	1.0498	.056	.056
Avg	1.3302	1.5016	1.5313	1.5388	1.4270	.6949	.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 202 / 11 KV WADODA IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0456	.8488	1.1883	1.0425	1.0269	.9242
2	.0377	1.0456	.8488	1.1694	1.0242	1.0242	.9242
3	.0377	1.0099	.8299	1.1317	.9511	1.0242	.9242
4	.0377	1.0269	.8299	1.1317	.9145	1.0425	.9242
5	.0377	.9186	.7922	.9431	.8779	1.0387	.9242
6	.0377	.9145	.7167	.8865	.8326	.6722	.9054
7	.0377	.9335	.6413	.9054	.7783		.7545
8	.0566	.8029	.8488	.8299	.6697		.7167
9	.0754		1.2826	1.2071	1.1222		.8299
10	.0754	1.1949	1.3203	1.1694	1.1222		1.0562
11	.0914	1.3203		1.2254	1.2193		.9431
12	.8686	1.1694	1.0185	1.2986			.9808
13	.9522	1.094	.9619	1.0791			.9054
14	.9709	1.226	1.1317	1.1765			.9431
15	.905	1.2637	1.1506	1.2437			.9054
16	.9795	1.3014	1.1317	1.2254	.8775		.8488
17	.961	1.4146	.0943	1.086	.7468		.8676
18	.8686	.8865	1.0185	.9877	.5975		.9054
19	.8779	.9431	1.226	1.3535	.6908		.9808
20	.9795	.9896	.9997	1.2803	.8962	.811	.811
21	1.0082	.8962	1.094	1.086	.9149	.8676	.7545
22	.9955	.8299	1.1506	1.0317	1.0242	.9054	.2452
23	.9774	.8865	1.1694	1.086	1.0425	.8676	
24		1.0269	.8865	1.1506	1.0425	1.0082	.9619
Max	1.0082	1.4146	1.3203	1.3535	1.2193	1.0425	1.0562
Min	.0377	.8029	.0943	.8299	.5975	.6722	.2452
Avg	.5395	1.0496	.9562	1.1197	.9194	.9353	.8668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 203 / 11 KV WADODA R

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.5138	.5258	.4534	.3582	.4024	.2957
2	.1402	.5304	.5258	.4696	.3439	.4024	.2957
3	.1402	.5014	.5083	.5281	.3258	.4251	.2957
4	.1402	.4938	.4733	.421	.3077	.3982	.2587
5	.1052	.499	.4557	.3277	.2865	.4163	.2587
6	.1052	.3109	.3506	.3113	.2896	.2378	.2402
7	.0876	.2772	.2804	.2294	.3077	.2012	.2054
8	.0716	.2353	.2774	.2294	.3077	.1829	.1867
9	.0716		.298	.2591	.3045	.2033	.1867
10	.0886	.2402	.2804	.2591	.2865	.1829	.2033
11	.0732	.2401	.2949	.2686	.2987	.1372	.1475
12	.1646	.2743		.2926	.2926	.1543	.1457
13	.0739	.2774	.0164	.3045	.2715	.1494	.1296
14	.1991	.298	.1311	.3258	.2561	.1663	.0648
15	.0739	.1214	.1311	.3224	.2614	.1307	.1457
16	.0914		.2294	.3224	.0724	.168	.1311
17	.2218	.1928		.2534	.1646	.1494	.0648
18	.2195		.2429	.3045	.2378	.168	.1619
19	.4024	.2454	.3239	.2865	.2601	.2218	.2267
20	.3841	.5083	.4534	.3801	.4024	.2987	.2591
21	.5194	.5083	.4696	.5249	.4207	.2987	.2267
22	.4805	.5609	.4696	.4163	.5041	.2987	.2429
23	.5487	.567	.4534	.394	.4938	.3174	
24	.1595	.4706	.5493	.3441	.3801	.4938	.3361
Max	.5487	.567	.5493	.5281	.5041	.4938	.3361
Min	.0716	.1214	.0164	.2294	.0724	.1307	.0648
Avg	.1967	.3746	.3519	.3428	.3098	.2585	.2048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 204 / 11 KV TARSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	1.0974	.3224	.1227	.2715	.2715	.2507
2	.0532	1.0679	.3224	.1402	.2172	.2743	.2507
3	.0532	1.0719	.3224	.1402	.181	.2561	.2507
4	.0532	1.0425	.3045	.1578	.1629	.2743	.2328
5	.0532	1.0059	.2865	.1578	.1629	.2743	.2254
6	.0532	.8048	.2507	.2103	.1448	.2241	.197
7	.0354	.7207	.2328	.1753	.1448	.1478	.1791
8	.0362	.5014	.2353	.0709	.1448	.1267	.1448
9	.1267		.181	.1448	.1267	.128	.124
10	.0362	.4854	.0905	.1402	.128	.128	.1267
11	.0358	.4481	.1227	.1267	.1109	.1086	.1052
12	.1663	.5228	.1402	.1448	.2012	.0543	.1052
13	.1629	.7842	.1578	.1629	.0732	.0886	.0876
14	.1646	.7865	.1402	.1448	.0716	.0537	
15	.1463	.7602	.1578	.1448	.1646	.0914	.1402
16	.1829	.181	.0526	.1448	.1629	.0537	.1052
17	.1772	.0362	.0526	.0724	.0747	.0905	.1052
18	.128	.0543		.0724	.2012	.0905	.1227
19	.2033	.181	.1402	.1448	.2195	.1791	.1928
20	.8326	.2896	.2279	.1629	.2561	.2328	.1753
21	1.0277	.3258	.2629	.2561	.2801	.2149	.1928
22	1.1458	.3292	.2804	.2896	.2926	.197	.1928
23	1.0608	.3109	.2629	.0362	.2743	.2715	
24	.0526	1.1041	.3292	.1227	.2715	.2743	.2686
Max	1.1458	1.1041	.3292	.2896	.2926	.2743	.2686
Min	.0354	.0362	.0526	.0362	.0716	.0537	.0876
Avg	.2517	.6049	.2120	.1453	.1808	.1711	.1716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 205 / 11 KV NIMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.9877	.1132	.0747	.0366	.0532	.0377
2	.0924	1.0164	.1132	.0747	.0366	.0549	.0377
3	.0924	.9877	.1132	.0747	.0366	.0543	.0377
4	.0924	1.0164	.0943	.056	.0362	.0549	.0377
5	.0934	.9955	.0943	.1494	.0366	.0362	.0377
6	.0747	.905	.0754	.0373	.0366	.0366	.0377
7	.0747	.7682	.0754	.056	.0366	.0362	.0373
8	.0739	.6878	.056	.0373	.0366	.0366	.0377
9	.0739		.0566	.0747	.0183		.0377
10	.0739	.8059	.0566	.0543	.0181	.0183	.0377
11	.0739	.7545	.0943	.0543	.0185	.037	
12	.0716	.6979	.0377	.0724	.0181	.0373	.0187
13	.0924	.4715	.0377	.0543	.0183	.0373	.0187
14		.547	.0373	.0366	.0183	.0373	.0187
15	.0716	.0354	.0377	.0362	.0181	.0377	
16	.0543	.0532	.0377	.0724	.0362	.0377	.0189
17		.0526	.0377	.543	.0183	.0377	.0187
18	.0732	.0526	.0377	.0724	.0549	.0377	.0187
19	.0914	.0532	.0377	.0362	.0549	.0377	.0187
20	.1267	.0532	.0754	.0362	.0543	.0377	.0189
21	.1463	.0754	.0747	.0362	.0549	.0377	.0187
22	.4024	.0754	.056	.0362	.0549	.0377	.0189
23	1.0974	.0943	.0747	.0366	.0549	.0377	
24	.0943	1.0164	.1132	.0747	.0366	.0366	.0373
Max	1.0974	1.0164	.1132	.543	.0549	.0549	.0377
Min	.0543	.0354	.0373	.0362	.0181	.0183	.0187
Avg	.1468	.5306	.0682	.0786	.035	.0394	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 206 / 11 KV BAPDEO SUGAR FACTORY NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0354	.0377	.0187	.0181	.0354	.0189
2	.0189	.037	.0377	.0189	.0181	.0362	.0189
3	.0189	.0366	.0377	.0189	.0366	.0366	.0189
4	.0189	.0362	.0377	.0189	.0366	.0366	.0189
5	.0189	.0362	.0377	.0189	.0362	.0366	.0189
6	.0189	.0362	.0377	.0189	.0181	.0183	.0189
7	.0189	.0366	.0189	.0189	.0181		.0189
8	.0189	.0366	.0189	.0189	.0181		.0189
9			.0189		.0183	.0187	.0189
10		.0362	.0189	.0189	.0181	.0366	.0189
11		.0189	.0189	.0181	.0181	.0189	.0377
12		.0189	.0189	.0181	.0183	.0189	.0189
13		.0189	.0189	.0181	.0177	.0189	.0189
14		.0377	.0189	.0183	.0183	.0189	.0189
15	.0362	.0377	.0189	.0181	.0177	.0189	.0187
16	.0183	.0189	.0189	.0181	.0177	.0189	.0377
17	.0366	.0189	.0377	.0181	.0183	.0377	.0189
18	.0366	.0189	.0377	.0181	.0183	.0189	.0189
19	.0366	.0377	.0377	.0183	.0354	.0189	.0189
20		.0377	.0189	.0366	.0366	.0189	.0189
21	.0366	.0377	.0189	.0362	.0362	.0189	
22	.0366	.0377	.0189	.0362	.0366	.0189	
23	.0366	.0377	.0189	.0362	.0366	.0189	
24	.0189	.0362	.0377	.0189	.0181	.0366	.0377
Max	.0366	.0377	.0377	.0366	.0366	.0377	.0377
Min	.0183	.0189	.0189	.0181	.0177	.0183	.0187
Avg	.0261	.0322	.0267	.0216	.0242	.0253	.0216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 207 / 11 KV BORGAO (33 KV DCL
STN) Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3841	.3696	.362	.3439	.4406	1.3014
2	.2587	.3841	.3772	.362	.362	.4805	1.3014
3	.2587	.3658	.3772	.362	.3761	.4572	1.3014
4	.2587	.3841	.3772	.3258	.3582	.439	1.2826
5	.2402	.3696	.3395	.2896	.3439	.4572	1.2449
6	.2402	.2987	.3206	.1991	.362	.3658	1.2071
7	.2427	.2172	.3292	.2353	.362	.2378	1.1203
8	.2402	.2561	.3109	.3174	.3582	.2926	1.0562
9	.2218		.3326	.2715	.3403	1.2254	1.0562
10	.1848	.2353	.3326	.2534	.3582	1.1523	1.0751
11	.197	.2427	.3395	.3582	.3841	1.1203	1.0136
12	.1791	.2241	.3174	.5014	.3658	1.0974	1.0136
13	.1595	.2402		.5014	.4207	1.0374	.9412
14	.2195	.2772	.3801	.5014	.4024	.9808	.9412
15	.2012	.2772	.362	.4835	.4031	.9335	.9593
16	.2303	.2587	.362	.4477	.362	.9054	.9896
17	.2303	.2587	.362	.4119	.3475	.9431	.9412
18	.2126	.2402	.3258	.362	.3475	.9431	.9231
19	.2126	.2614	.3361	.3761	.4066	1.1317	1.0082
20		.2614	.3734	.4075	.4207	1.4335	1.0082
21	.3292	.2801	.3801	.394	.439	1.4335	1.0269
22	.3544	.2987	.4108	.394	.4207	1.4335	.2427
23	.4024	.3734	.362	.3761	.4024	1.3957	
24	.1463	.362	.3921	.3734	.362	.4755	1.3392
Max	.4024	.3841	.4108	.5014	.439	1.4335	1.3392
Min	.1463	.2172	.3109	.1991	.3403	.2378	.2427
Avg	.2381	.2935	.3552	.3694	.3771	.8672	1.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359] BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 208 / 11 KV STATION XMER
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.181		.1509
16	.1829			.2263	
24		.1029		.4024	.2641
Max	.1829	.1029	.181	.4024	.2641
Min	.1829	.1029	.181	.2263	.1509
Avg	.1829	.1029	.181	.3144	.2075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 201 / 11 KV TARSA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.2752	1.3306	1.4045	1.0974
2		1.0974	1.307	1.3306	1.4045	1.0974
3		1.0974	1.2936	1.2567	1.3121	1.0242
4		1.0242	1.307	1.2567	1.2197	1.0242
5		.9511	1.2803	1.2012	1.2197	1.0242
6		.9145	1.1706	1.1088	1.1827	.8413
7		.8048	.961	1.0719	1.0719	.9145
8		.7682	.9145	1.0349	.924	.9145
9		.7499	.7682	.7392	.5729	.8779
10			.924	.6838	.6283	.9145
11		.6468	.7023	.9425	.9145	.6767
12		.7842	.7392	1.1827	.823	.3475
13		.6401	.8871	1.0164	.823	.5914
14	.1097	.9149	1.0903	1.0719	.7682	.6908
15	.1097	.9328		.961	.695	.8048
16	.6219	.8686		1.0719	.8048	.823
17	.5121	.7865		.7023	.4938	.4024
18		.7682	.7947		.5121	.7865
19	.6036	.8048	.6468	.7577	.6767	.567
20	.8413	1.0425	1.0903	1.0534	.8048	.6036
21	.8779	.9694	1.1088	1.1088	.8413	.6219
22	1.0242	1.0974	1.2197	1.1827	.9877	.6099
23	1.0242	1.134	1.4045	1.5154	1.2071	.6653
24		1.2071	1.2254	1.386	1.46	1.2437
Max	1.0242	1.2071	1.4045	1.5154	1.46	1.2437
Min	.1097	.6401	.6468	.6838	.4938	.3475
Avg	.6361	.9175	1.0529	1.0855	.9480	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 202 / 11 KV NIMKHEDA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.8779	.8501	.9425	.7577	.695
2	.0187	.8779	.8501	.9425	.7577	.695
3	.0187	.8779	.8316	.924	.7023	.6219
4	.0187	.8413	.8316	.924	.7023	.6219
5	.0187	.695	.7947	.8316	.6653	.6219
6	.0187	.6584	.7023	.7392	.6468	.567
7	.0187	.5487	.6283	.6283	.6099	.5121
8	.0187	.6401	.5304	.5544	.5175	.5304
9	.0187	.6219	.5415	.6838	.499	.5121
10	.0187	.5304	.6535	.7023	.6283	.5121
11	.0185	.6099	.7762	.6653	.5853	.5175
12	.0185	.6161	.7762	.7947	.5487	
13	.0183	.5175	.7392	.7023	.4938	.1463
14	.0183	.5175	.7023	.7577	.4938	.1663
15	.6036	.6838		.7577	.4755	.5601
16	.6219	.6838		.6838	.5487	.6348
17	.6036	.6283		.6283	.6219	.4294
18	.6219	.4805	.5914	.7207	.5853	.5729
19	.6767	.5729	.7392	.6838	.6767	.462
20	.8596	.8131	.8871	.7577	.6584	
21	.8779	.9425	.961	.8131	.6584	
22	.9145	.9896	1.0534	.8871	.6767	.1663
23	.8779	.9231	.9979	.8501	.6767	.1478
24	.0187	.8596	.8871	.9795	.8316	.695
Max	.9145	.9896	1.0534	.9795	.8316	.695
Min	.0183	.4805	.5304	.5544	.4755	.1463
Avg	.2890	.7087	.7774	.7731	.6258	.4947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 204 / 11 KV STN XMER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0366	.0373	.0343	.0343	.0366
2		.0377	.0366	.037	.0343	.0343	.0366
3		.0377	.0366	.0373	.0343	.0343	.0366
4		.0377	.0366	.0373	.0343	.0343	.0366
5		.0377	.0366	.0373	.0343	.0343	.0366
6		.0377	.0183	.0373	.0171	.0171	.0183
7		.0377	.0183	.0373	.0171	.0171	.0183
8		.0377	.0183	.0373	.0171	.0171	.0183
9		.0377	.0183	.0373	.0171	.0171	.0183
10		.0189	.0183	.0187	.0171	.0171	.0183
11		.0183	.0185	.0171	.0171	.0183	.0187
12		.0183	.0187	.0171	.0171	.0183	.0187
13		.0183	.0187	.0171	.0171	.0183	.0187
14		.0183	.0185	.0171	.0171	.0183	.0187
15		.0183	.0183	.0171	.0171	.0183	.0185
16		.0183	.0183	.0171	.0171	.0183	.0187
17		.0183	.0187	.0171	.0343	.0183	.0187
18		.0183	.0187	.0343	.0343	.0183	.0189
19		.0366	.0366	.0343	.0343		.037
20		.0366	.037	.0343	.0343	.0366	.037
21		.0366	.0373	.0343	.0343	.0366	.037
22	.0377	.0366	.0373	.0343	.0343	.0366	.037
23	.0377	.0366	.0373	.0343	.0343	.0366	.037
24		.0377	.0366	.0373	.0343	.0343	.0366
Max	.0377	.0377	.0373	.0373	.0343	.0366	.037
Min	.0377	.0183	.0183	.0171	.0171	.0171	.0183
Avg	.0377	.0302	.0269	.0299	.0264	.0254	.0269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 401 / 33 KV GUMTHALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	9.3364		6.677	6.0545		8.3179
16	11.0906	7.1296	8.4019		5.6584	
24	9.4879	9.6594	7.4691	6.677		8.3745
Max	11.0906	9.6594	8.4019	6.677	5.6584	8.3745
Min	9.3364	7.1296	6.677	6.0545	5.6584	8.3179
Avg	9.9716	8.3945	7.516	6.3658	5.6584	8.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 403 / 33 KV VISAKHA

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			6.5638	6.8467	6.9033		6.5638
16	5.3727	6.5638	6.8467			6.4506	7.0302
24		5.4298	7.356	7.2428			7.0165
Max	5.3727	6.5638	7.356	7.2428	6.9033	6.4506	7.0302
Min	5.3727	5.4298	6.5638	6.8467	6.9033	6.4506	6.5638
Avg	5.3727	5.9968	6.9222	7.0448	6.9033	6.4506	6.8702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 702 / 132 KV DCL 2

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.3951		3.6214	3.3951	3.3951		3.3951
16	3.6214	3.6214	3.6214			3.3951	3.3951
24	3.6214	3.6214	3.6214	3.5117			3.3951
Max	3.6214	3.6214	3.6214	3.5117	3.3951	3.3951	3.3951
Min	3.3951	3.6214	3.6214	3.3951	3.3951	3.3951	3.3951
Avg	3.5460	3.6214	3.6214	3.4534	3.3951	3.3951	3.3951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 703 / 132 KV PENNAR

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	6.2094		5.3772	5.3498	5.1578		6.0997
16	3.8477	6.0334	4.7531			5.6584	5.2058
24	4.4353	4.3004	4.5268	5.2126			3.6214
Max	6.2094	6.0334	5.3772	5.3498	5.1578	5.6584	6.0997
Min	3.8477	4.3004	4.5268	5.2126	5.1578	5.6584	3.6214
Avg	4.8308	5.1669	4.8857	5.2812	5.1578	5.6584	4.9756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 201 / 11 kV Chacher

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6173	.6602	.6344	.7167	.6224	.5281
2	.6036	.6068		.6173	.679	.5658	.5093
3	.547	.5487	.5658	.6001	.679	.5281	.4904
4	.5658	.5316	.5281	.583	.6413	.5093	.4904
5	.6224	.5548	.5093	.5895	.6036	.4904	.4904
6	.5093	.4115	.5281	.4801	.5281	.4904	.4527
7	.415	.4115	.3772	.4115	.4904	.5093	
8	.3772	.4115	.415	.4854	.5093		.4527
9	.3961	.373	.5281	.407	.5658		.4527
10	.415	.4458		.6036	.6413	.5658	.415
11	.3988	.4904	.5087	.6413	.7545	.4904	.415
12	.3772	.5281	.5144	.7167	.7922	.415	.3772
13	.4287	.4904	.5487	.7167	.7922	.3772	
14	.1543	.4904	.4239	.7922	.4527	.415	.3772
15	.1543	.4527	.6173	.7167	.3772	.3772	
16	.3258	.4527	.583	.7922	.4527	.3772	
17	.3391	.4527	.5487	.6036	.5658	.3395	
18		.415	.4508	.415	.5281	.2641	.415
19	.3429	.4904	.4458	.5658	.4904	.3772	.4527
20	.3944	.6036	.5721	.679	.5658	.4527	.415
21	.4854	.6413	.5895	.7167	.6036	.4904	.4715
22	.6068	.679	.6613	.7545	.6413	.5281	.4527
23	.583	.679	.6443	.7356	.6413	.5658	.415
24	.679	.5895	.679	.6344	.7167	.6413	.547
Max	.679	.679	.679	.7922	.7922	.6413	.547
Min	.1543	.373	.3772	.407	.3772	.2641	.3772
Avg	.4505	.5153	.5409	.6205	.6012	.4724	.4537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 202 / 11 KV NAGARDHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.2197	1.3957	1.2887	1.3957	1.226	1.0374
2	1.1694	1.1643	1.358	1.2548	1.3957	1.1883	1.0374
3	1.1506	1.1827	1.2826	1.2209	1.358	1.094	1.0185
4	1.1694	1.134	1.1694	1.2548	1.3769	.9808	1.0185
5	1.1694	1.1411	1.094	1.1869	1.3769	.9431	.9997
6	.9242	.8596	.9808	.8987	1.0751	.9619	.8865
7	.811	.543	.8488	.78	.9054	1.0374	
8	.7733	.7296	.8676	.8417	.9054	.7545	.4715
9	.5847	.7265	.811	.6952	.811	.7545	.2075
10	.7356	.7087		.811	.9242	.5847	.3961
11	.6335	.7922	.7969	.9054	.9431	.6036	.415
12	.6335	.8299	.8596	.8865	.811	.5658	.4338
13	.6201	.8865	.9134	.811	.8488	.547	.3961
14	.6447	.8865	.9671	.7545	.8299	.6224	.3018
15	.6447	.9242	.8775	.9242	.7545	.5093	
16	.788	.8676	.9134	.8488	.7733	.5847	
17	.7291	.811	.7164	.811	.5093	.547	
18		.8488	.788		.7167	.6979	.9054
19	.9412	.8865	.8779	.415	.8676	.811	.9054
20	1.2382	.9619	1.2071	1.2826	1.1883	.9808	.9619
21	1.4003	1.1883	1.3676	1.4335	1.3014	1.094	.8676
22	1.3491	1.5089	1.3565	1.5278	1.3769	1.1317	.9242
23	1.2567	1.4712	1.3056	1.4335	1.3203	1.0562	.9431
24	1.2071	1.2197	1.4335	1.2717	1.4335	1.3014	1.0374
Max	1.4003	1.5089	1.4335	1.5278	1.4335	1.3014	1.0374
Min	.5847	.543	.7164	.415	.5093	.5093	.2075
Avg	.9462	.9789	1.0517	1.0234	1.0500	.8574	.7582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 203 / 11 KV BELDONGRI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.6878	.7167	.6584	.4338	.6602	.6413
2	.8299	.6516	.6602	.6401	.415	.6413	.679
3	.7167	.6335	.6036	.6036	.4338	.6224	.679
4	.6979	.6335	.5658	.6036		.5658	.5658
5	.6979	.6154	.6602	.4755	.4527	.547	.5281
6	.679		.7356	.439	.415	.5281	.4715
7	.6036	.6024	.9054	.439	.415	.5093	.4527
8	.4527	.5258	.8676	.3429	.4527	.5093	.4527
9	.5658	.3772	1.0562	.4108	.5281	.5093	.4904
10	.547	.4115		.4527	.5281	.5281	.6036
11	1.0374	.6036	1.307	.4715	.6224	.6979	.6413
12	.8676	.6036		.3961	.7922	.679	.6413
13	.8029	.679	1.4335	.3961	.6224	.7167	.6036
14	.8488	.5658	1.0374	.4715	.7545	.679	.6979
15	.9619	.4904	.8676	.3961	.6224	.6602	.5281
16	.8865	.5093	.9054	.415	.5093	.6224	.8299
17	.6584	.4904	.9808	.3961		.6036	.8865
18		.4904	.7545	.3961	.4904	.679	.547
19	.5914	.4527	.6468	.415	.7545	.5658	.6602
20	.567	.415	.6485	.4527	.6224	.5281	.5281
21	.5304		.6219	.5281	.5847	.5658	.6036
22	.4887	.4338	.6161	.4527	.5093	.6036	.5658
23	.695	.679	.6722	.4527	.6036	.5658	.547
24	.9054	.8131	.7545	.6767	.415	.7167	.6036
Max	1.0374	.8131	1.4335	.6767	.7922	.7167	.8865
Min	.4527	.3772	.5658	.3429	.415	.5093	.4527
Avg	.7157	.5620	.8190	.4743	.5444	.6044	.602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 205 / 11 KV Incomer I Nagardhan

Feeder KV- 11 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8296	1.8461	2.0559	2.1098	2.1125	1.8484	1.5655
2	1.773	1.7737	1.9616	1.8652	2.0748	1.7541	1.5466
3		1.7375	1.8484	1.9978	2.037	1.6221	1.5089
4		1.7194	1.6975	2.0351	2.0182	1.4901	1.5089
5	1.7918	1.6834	1.6032	1.9418	1.9805	1.4335	1.4901
6	1.4335	1.1043	1.5089	1.5123	1.6032	1.4523	1.3392
7	1.226	1.1043	1.226	1.307	1.3957	1.5466	
8	1.1506	1.1393	1.2826	1.3289	1.4146	.7545	
9	.9808	1.1043	1.3392	1.1022	1.3769	.7545	
10	1.1506	1.1694		1.4146	1.5655	1.1506	
11	1.0166	1.2826	1.3056	1.5466		1.0562	
12	.9991	1.358	1.4266	1.6032	1.6032	.9808	
13	1.0517	1.3769	1.4706	1.5278	1.6409	.9242	
14	.7973	1.3769	1.3998	1.5466	1.2826	1.0374	
15	.8328	1.3769	1.5061	1.6409	1.1317	.8865	
16	1.1163	1.3203	1.5061	1.6409	1.226	.9619	
17	1.0682	1.2637	1.262	1.4146	1.0751	.8865	
18		1.2637	1.2403	.415	1.2449	.9619	1.3203
19	1.2894	1.3769	1.3253	.9808	1.358	1.1883	1.358
20	1.6289	1.7541	1.773	1.9616	1.7541	1.4335	1.3769
21	1.8858	2.0182		2.1502	1.905	1.5844	1.3392
22		2.1879	2.0178	2.2822	2.0182	1.6598	1.3769
23	1.8461	2.1502	1.95	2.1691	1.9616	1.6221	1.358
24	1.8861	1.8099	2.1125	2.0911	2.1502	1.9427	1.5844
Max	1.8861	2.1879	2.1125	2.2822	2.1502	1.9427	1.5844
Min	.7973	1.1043	1.226	.415	1.0751	.7545	1.3203
Avg	1.3377	1.5124	1.5827	1.6494	1.6491	1.2889	1.4364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 206 / 11kv Incomer II Nagardhan

S/s Feeder KV- 11 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.724	.7167	.6584	.4338	.6602	.6413
2	.8299	.6878	.6602	.6401	.415	.6413	.679
3	.7167	.6516	.6036	.6036	.4338	.6224	.679
4	.6979	.6335	.5658	.6036	.4338	.5658	.5658
5	.6979	.6154	.6602	.4755	.4527	.547	.5281
6	.679	.543	.7356	.439	.415	.5281	.4715
7	.6036	.6024	.9054	.439	.415	.5093	.4527
8	.4527	.5373	.8676	.3429	.4527	.5093	1.3769
9	.5658	.3772		.4024	.5281	.5093	1.1506
10	.547	.4115		.4527	.5281	.5281	1.4146
11	1.0374	.6036	1.307	.4715	.6224	.6979	1.4712
12	.8676	.6036		.3961	.7922	.679	1.4523
13	.8029	.679	1.4335	.3961	.6224	.7167	.9997
14	.8488	.5658	1.0374	.4715	.7545	.679	1.3769
15	.9619	.4904	.8676	.3961	.6224	.6602	.5281
16	.8865	.5093	.9054	.415	.5093	.6224	.8299
17	.6584	.4904	.9808	.3961		.6036	.8865
18		.4904	.7545	.3961	.4904	.679	.547
19	.5914	.4527	.6468	.415	.7545	.5658	.6602
20	.567	.415	.6485	.4527	.6224	.5281	.5281
21	.5304	.4527	.6283	.5281	.5847	.5658	.6036
22	.4887	.4338	.5847	.4115	.5093	.6036	.5658
23	.695	.679	.6379	.4527	.6036	.5658	.547
24	.9054	.8131	.7545	.6767	.415	.7167	.6036
Max	1.0374	.8131	1.4335	.6767	.7922	.7167	1.4712
Min	.4527	.3772	.5658	.3429	.415	.5093	.4527
Avg	.7157	.5609	.8049	.4722	.5396	.6044	.8150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 202 / 11 KV Deolapar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.924	1.1431	1.1431	.7621	1.0669	.9907
2	1.1431	.924	1.1431	1.1431	.7621	.9145	.5335
3	1.1431	.924	1.1431	1.1431	.7621	1.3717	.4572
4	1.0479	.924	1.1431	1.1431	.8573	.9145	.5335
5	1.0479	.924	1.1431	1.0479	.8573	.9145	.5335
6	.9526	.924	.9526	.9526	.9526	.9145	.5792
7	.8573	.7392	.7621	.8573	.7621	.7621	.5335
8	.6668	.7392	.7621	.8573	.7621	.7621	.5792
9	.7621	.5914	.9526	.7621	.7621	.6097	
10	.7392	.6468	.9526	.7621	1.0669	.4572	
11	.7392	.9145	1.0479	.7621	.1219	.4572	
12	.7392	.8573	.9526	.7621		.4572	.2772
13	.7392		.9526	.7621		.4572	.462
14	.7392		.9526	.9526	.7621	.381	.3696
15	.7392		.9526	.7621	.7621	.381	.4066
16	.6468		.7621	.8002	1.2193	.3963	.4066
17	.5544	.9526	.7621	.7621	.0914	.6859	.4251
18	.7392	.9526	.8573	.7621	.1829	.7621	
19	1.1088	.1524	1.1431	.9526	1.2193	.7621	
20	1.2012	1.3336	1.3336	1.3336	.8383	.9145	1.0164
21	1.2936	1.3336	1.3336	1.3336	.6097		1.0164
22	1.2012	1.2384	1.2384	1.3336	1.0669	.6859	1.0164
23	1.0164	1.1431	1.2384	1.2384	1.0669	.5792	.924
24	1.2384	.924	1.1431	1.1431	.7621	1.0669	.5335
Max	1.2936	1.3336	1.3336	1.3336	1.2193	1.3717	1.0164
Min	.5544	.1524	.7621	.7621	.0914	.381	.2772
Avg	.9250	.9031	1.0320	.978	.7732	.7250	.6102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 203 / 11 KV TOTALADOH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1109	.0953	.1143	.0762	.1219	.1219
2	.0381	.1109	.0953	.1143	.0762	.1219	.0914
3	.0953	.1109	.0953	.1143	.0762	.1219	.1219
4	.0953	.1478	.0953	.1143	.0762	.0914	.0914
5	.0953	.1478	.0953	.1143	.0762	.1067	.1219
6	.0953	.1478	.1143	.1143	.0762	.1219	.0914
7	.0762	.0934	.0762	.0953	.0762	.1219	.0914
8	.0762	.1109	.0762	.0953	.0762	.0762	.1109
9	.0762	.0924	.0762	.1143	.0762	.0762	.1433
10	.1109	.1109	.0953	.0953	.0914	.0762	.1478
11	.0739	.0762	.0953	.0953	.0914	.9145	
12	.0554		.0953	.0953	.0914	.0762	
13	.0554		.0953	.0953	.1219	.0914	.0554
14	.0739		.0953	.0953	.1219		.0739
15	.1294		.0953	.0762	.1219		.0739
16	.0739		.0953	.0762	.0762	.061	.0554
17	.0739	.0953	.0762	.0762	.1219	.0914	.0554
18	.1109		.0953	.0953	.1219	.0914	
19	.1109		.1524	.1143	.0914	.0914	
20	.1294	.1524	.1905	.1524	.1219	.1219	
21	.1848	.1143	.1524	.1524	.1219		
22	.1109	.1143	.1143	.1524	.1219		
23	.1109	.1143	.1143	.1143	.0914		
24	.0953	.1478	.0953	.1143	.1143	.0914	.0914
Max	.1848	.1524	.1905	.1524	.1219	.9145	.1478
Min	.0381	.0762	.0762	.0762	.0762	.061	.0554
Avg	.0935	.1175	.1032	.1080	.0962	.1404	.0962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 204 / 11 KV Ambazari AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.037			.0381		
2	.0191	.037			.0381		
3	.0191	.037			.0381		
4	.0191	.037			.0381		
5	.0191	.037			.0381		
6	.0191	.037			.0381		
7	.0191	.0554			.0381	.0305	
8	.0381	.0554			.0381	.0305	.0305
9	.0381	.0554			.0381	.0305	.037
10	.037	.0554					.037
11	.037	.0381	.0953		.0305		.037
12	.0185	.0572					.037
13	.0185					.0305	.0185
14	.0185		.0381	.0381	.0305		.0185
15	.037			.0762			.0185
16	.037			.0572	.0305	.0305	.0185
17	.037	.0381		.0762			.0185
18	.0554	.0762		.0762			
19	.0554	.0762		.0762	.0305	.0305	
20	.037	.0572		.0762		.0305	.0185
21	.037			.0762			.0185
22	.037			.0762			.0185
23	.037			.0381			.0185
24	.0191	.037			.0381		.0305
Max	.0554	.0762	.0953	.0762	.0381	.0305	.037
Min	.0185	.037	.0381	.0381	.0305	.0305	.0185
Avg	.0303	.0484	.0667	.0667	.0359	.0305	.0250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 205 / 11 KV Incomer I Pauni

S/Stn Feeder KV- 11 /

INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.0719	1.2384	1.2574	.8764	1.0364	1.0364
2	1.2574	1.0719	1.2384	1.2574	.8764	1.0364	.5792
3	1.2574	1.0719	1.2384	1.2574	.8764	1.0364	.5792
4	1.1622	1.1088	1.2384	1.2574	.9717	1.5089	.6097
5	1.1622	1.1088	1.2384	1.1622	.9717	1.5089	.6554
6	1.0669	1.1088	1.0669	1.0669	1.0669	1.0669	.6554
7	.9526	.8871	.8383	.9526	.8764	.8688	.6554
8	.7811	.9055	.8383	.9526	.8764	.8688	.6859
9	.8764	.7947	1.0288	.8764	.8764	.7011	.1848
10	.8871	.8316	1.0479	.8573	.7011		.1848
11	.8501	1.0288	1.1431	.8573	.6401	.5639	.037
12	.8131	1.0098	1.0479	.8573	.8078	.5639	.3142
13	.8131		1.0479	.8573	.7011	.5639	.5359
14	.8316		1.0479	1.0479	1.0059	.4877	.462
15	.8501		1.0479	.9145	.7011	.4877	.499
16	.7577		.8573	.9335	.8383	.4877	.4805
17	.6653		.8573	.9145	.1981	.8078	.499
18	.9055	1.1431	.9526	.9335	.2743	.884	
19	1.2752	1.3717	1.2574	1.1431	.884	.884	
20	1.3491	1.3908	1.5432	1.5623	1.1126	1.0669	1.0349
21	1.5154	1.5051	1.4861	1.5623	1.2193	1.0669	1.0349
22	1.3491	1.3527	1.4098	1.5623	1.1888	1.2193	1.0349
23	1.1643	1.2384	1.2765	1.3908	1.1888	.7621	.9425
24	1.3717	1.1088	1.2384	1.2574	.9145	1.1888	.6554
Max	1.5154	1.5051	1.5432	1.5623	1.2193	1.5089	1.0364
Min	.6653	.7947	.8383	.8573	.1981	.4877	.037
Avg	1.0488	1.1111	1.1344	1.1122	.8602	.8986	.6071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 206 / 11 KV Standby Feeder Pauni SINGLE PHASING

I Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.1088	1.1431	1.2384	1.2384	1.0669	.8383
2	1.9052	1.1088	1.1622	1.2384	1.2003	1.0669	.8383
3	1.848	1.1088	1.1622	1.2384	1.1812	.5716	.8383
4	1.8099	1.1088	1.1431	1.2384	1.1431	.9145	.7621
5	1.7147	1.0164	1.1431	1.2384	1.1431	.8993	.8383
6	1.6194	.924	.9717	1.0479	1.1622	1.2651	.7621
7	1.4289	.7947	.9717	1.5051	1.6194	1.2651	1.0669
8	1.0479	.924	.9907	1.5623	1.5242	1.1126	.8078
9	.9526	.9795	1.0288	1.5623	1.5242	1.0822	1.1827
10	1.0164	.9795	1.0479	1.5242	1.1736	1.0669	1.1088
11	.9795	.9526	.8383	1.5242	1.1126	.9145	.8316
12		.9526	.8192	1.5432		.1524	.7947
13			.9335	1.4289		.1524	.7207
14			.9335	1.5813		.1219	.7392
15			.9335	1.5242	1.1888	.1524	.6468
16			1.4289	1.467		.1524	.462
17		.7621	1.448	1.467		.6859	.462
18	1.2382	1.086	1.448	1.448		.7621	
19	1.386	1.3908	1.9624	2.0195			
20	1.8296	1.3336	2.6863	2.6673	2.0576	1.3565	2.0328
21	1.9404	1.3336	1.467	1.4861	1.1584		1.9959
22	1.7926	1.2765	1.4289	1.448	1.1584		1.9959
23	1.6632	1.2003	1.2955	1.3336	1.0669		1.7556
24	2.0005	1.1088	1.1812	1.2574	1.2574	1.0669	.8383
Max	2.0005	1.3908	2.6863	2.6673	2.0576	1.3565	2.0328
Min	.9526	.7621	.8192	1.0479	1.0669	.1219	.462
Avg	1.5620	1.0725	1.2320	1.4829	1.2888	.7914	1.0145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 201 / Ramtek I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9907	1.0288	1.1431	1.105	.9526	.9526
2	1.0288	.9907	.9526	1.0479	1.105	.9145	
3		.9145	.9145	1.0669	1.0479	.8764	
4	.9145	.9145	.8764	1.0479	1.0479	.8764	
5		.8573	.8383	.9907	.9526	.8383	.8002
6	.8192	.8002	.8002	.8383	.8764	.8383	.7621
7	.7621		.743	.7621	.8002	.7621	.6859
8	.7049	.7049	.6478	.7049	.6859	.6478	.6668
9	.6668	.6287	.6859	.6478	.6287	.6668	.7049
10	.6859	.6859	.724	.9335	.6668	.6668	.7049
11	.7049	.8002	.8002	.8573	.7811	.6859	.6287
12	.7621	.7621	.8764	.8954	.7811	.6668	.6859
13	.7811	.8192	.9145	.9526	.8192		.6478
14	.8192	.9526	.9526	.9717	.8383		.6097
15	.8002	.9526	.9526	1.0098	.8192		.5906
16	.8002	.8954	.9526	.9717	.8192		.6097
17	.7621	.7811	.9526	.9145	.8383	.6097	.6097
18	.743	.8192	.7811	.8383	.7621	.6668	.6478
19	.8954	.9335		.9145	.8573	.724	.6668
20	.9907	1.0669		1.0669	.9335		.7621
21	.9907	1.0479		1.105	.9335	.7811	.7049
22	.9907	1.0288		1.1431	1.0098	.8954	.6668
23	1.0288	1.086	.7811	1.2193	1.0288		.6668
24	.8573	1.0288	1.0669	1.1241	1.1431	1.0098	.9907
Max	1.0288	1.086	1.0669	1.2193	1.1431	1.0098	.9907
Min	.6668	.6287	.6478	.6478	.6287	.6097	.5906
Avg	.8391	.8896	.8621	.9653	.8867	.7822	.7031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 202 / Ramtek II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1143	.1524	.1715	.1524	.1524
2	.1524	.1524	.1143	.1524	.1715	.1524	
3	.1143	.1334	.1143	.1715	.1715	.1524	
4	.1524	.1334	.0762	.1905	.1524	.1143	
5	.1143		.0762	.1334	.1524	.1143	.0953
6	.1143	.0953	.0762	.2096	.1715	.1143	.0953
7	.1143	.0953	.0762		.1715	.0953	.1143
8	.2286	.1334	.1715	.1334	.2096	.2477	.1334
9	.2477	.2096	.1143	.1715	.1905	.1905	.1334
10	.3048	.2477	.2667	.1143	.2858	.4001	.1905
11	.2858	.3239	.1715	.3048	.3048	.1905	.2477
12	.1905	.2667	.1905	.3429	.3239	.1905	.2096
13	.362	.3048	.1905	.362	.3048		.2858
14	.3048	.2286	.3048	.2858	.3429		.2477
15	.2667	.1715	.2667	.2477	.3048		.2477
16	.3239	.2096	.2286	.381	.3048		.2286
17	.1715	.1334	.1905	.3429	.2096	.1143	.1715
18	.1715	.1143	.1524	.2667	.2477	.1905	.1715
19	.1334	.1334		.1715	.2096	.2286	.2477
20	.1334	.1143		.1524	.1905		.1524
21	.1334	.1143		.1524	.1143	.1334	.1334
22	.1715	.0953		.1905	.1905		.1715
23	.1715	.1334	.1524	.1905	.1524	.1905	.1715
24	.1905	.1524	.1143	.1905	.1715	.1524	.1905
Max	.362	.3239	.3048	.381	.3429	.4001	.2858
Min	.1143	.0953	.0762	.1143	.1143	.0953	.0953
Avg	.1977	.1673	.1581	.2179	.2175	.1736	.1806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 204 / BORI SINGLE PHASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.8002	.8002	.9145	.9526	
2		.9145	.7621	.7621	.9145	.9145	
3		.8573	.724	.8192	.8573	.8764	
4		.8573	.6859	.8383	.8573	.8383	
5		.7621	.6097	.8192	.8002	.8002	
6		.2286	.5525	.8383	.724	.8002	
7		.4191	.6097	.8573	.5716	.724	
8		.4191	.5716	.6859	.5144	.6478	
9		.4191	.5525	.4572	.5716		
10		.4191	.5906	.4763	.5144		
11	.1524	.4191	.5906	.5144	.4954		.1143
12	.1334	.4763	.6097	.4954	.6287		.1715
13	.1524	.1524	.6097	.5144	.6668		.5525
14	.1524	.5525	.6478	.4954	.6478		.5525
15	.362	.1524	.5716	.5144	.5906		.5335
16	.362	.1905	.5525		.1905		.4954
17	.3429	.3048	.5525	.6668	.1905	.4382	.4763
18	.5144	.5144	.5525	.743	.3239	.4763	.8383
19	.8192	.8192		.8573	.8002	.5525	.7811
20	1.0669	.9717		1.1812	1.0098		.9907
21	1.1241	.8764		.9907	1.0479	.6478	.9717
22	1.0669	.9526		1.0479	1.0669		.9335
23	.9907	.8764	1.2193	1.0098	.9907	.6668	
24		.9717	.8573	1.1812	.9526	.9907	
Max	1.1241	.9717	1.2193	1.1812	1.0669	.9907	.9907
Min	.1334	.1524	.5525	.4572	.1905	.4382	.1143
Avg	.5569	.6017	.6611	.7637	.7018	.7376	.6176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 205 / 11 KV RAMTALAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.3717	1.4289	1.5623	1.5623	1.4861	1.3527
2	1.2765	1.3717	1.4098	1.4861	1.5623	1.4289	
3	1.1431	1.2955	1.3336	1.4289	1.448	1.3336	
4	1.1812	1.2955	1.2955	1.3336	1.448	1.2955	
5	1.0479	1.2384	1.2574	1.2955	1.3336	1.2193	1.2574
6	1.1241	1.1431	1.2193	1.2384	1.2193	1.1622	1.1431
7		1.086	1.086	1.1431	1.1241	1.1431	1.0098
8	1.0288	1.0098	.9907	1.0288	1.0098	.9526	
9	.8954	.9145	1.0288	1.0288	.9526	.9526	
10	.9145	.9145	1.0479	.9907	.9145	.8954	
11	.9145	.9907	1.0669	1.0669	.9907	.8573	1.2384
12	.9526	1.0479	1.1241	1.1622	1.0098	.8002	1.0669
13	.9526	1.0479	1.1812	1.2765	1.105		.9145
14	.9145	1.2003	1.2384	1.2574	1.0669		.8573
15	.9717	1.2003	1.2384	1.2765	1.105		.8764
16	.9907	1.1812	1.2384	1.2384	1.105		.8383
17	.9907	1.086	1.1431	1.1431	1.0669	.8954	.8002
18	1.0098	1.0479	1.0479	1.0669	.9907	.9526	.8383
19	1.0669	1.1812	1.1812	1.2003	1.105	.9907	.9907
20	1.2765	1.4289		1.448	1.2765		1.0479
21	1.3527	1.467		1.5051	1.2955	1.1812	1.0288
22	1.448	1.5051		1.6004	1.4289		1.0288
23	.1715	1.5432	1.6385	1.6766	1.5051	1.2955	1.0479
24	1.1431	1.448	1.5242	1.6385	1.6194	1.5242	1.3717
Max	1.448	1.5432	1.6385	1.6766	1.6194	1.5242	1.3717
Min	.1715	.9145	.9907	.9907	.9145	.8002	.8002
Avg	1.0437	1.2090	1.2248	1.2955	1.2185	1.1315	1.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 206 / 11 KV Musewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)
12		.1715
14	.4954	
Max	.4954	.1715
Min	.4954	.1715
Avg	.4954	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 400 / 33 KV Ramtek Transformer I

Feeder KV- 33 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3434	2.5149	2.572	2.8578	2.8006	2.572	2.4577
2	2.4577	2.5149	2.4577	2.6863	2.8006	2.5149	
3	2.2862	2.3434	2.3434	2.6863	2.6863	2.3434	
4	2.2291	2.3434	2.2291	2.572	2.6863	2.2862	
5	2.0005	2.2291	2.1719	2.4006	2.5149	2.1719	2.1148
6	2.0576	2.0576	2.1148	2.2862	2.2291	2.1148	2.0005
7	1.8861	1.9433	1.8861	2.0576	2.1148	2.0005	1.7718
8	1.9433	1.829	1.829	1.829	1.8861	1.829	.8002
9	1.7147	1.7718	1.829	1.829	1.7718	1.829	.8002
10	1.8861	1.829	2.0576	2.0005	1.8861	1.9433	.8573
11	1.8861	2.1148	2.0005	2.2291	2.0576	1.7147	2.1148
12	1.8861	2.0576	2.1719	2.4006	2.1148		1.9433
13	2.1148	2.1719	2.2862	2.8006	2.2291		1.829
14	2.0576	2.4577	2.4577	2.5149	2.2291		1.7147
15	2.0576	2.3434	2.4577	2.5149	2.2291		1.7147
16	2.1148	2.2862	2.4006	2.572	2.2291		1.6575
17	1.9433	2.0005	2.2862	2.4006	2.1148	1.6004	1.6004
18	1.9433	2.0005	1.9433	2.1719	2.0005	1.7718	1.6575
19	2.1148	2.2291		2.2862	2.1719	1.9433	1.8861
20	2.4006	2.6292		2.6863	2.4006		1.9433
21	2.4577	2.6292		2.7435	2.3434	3.7723	1.8861
22	2.6292	2.6292		2.915	2.6292		1.8861
23	2.6292	2.7435	2.9721	3.0864	2.6863	2.3434	1.829
24	2.1719	2.6292	2.6863	2.9721	2.915	2.572	2.5149
Max	2.6292	2.7435	2.9721	3.0864	2.915	3.7723	2.5149
Min	1.7147	1.7718	1.829	1.829	1.7718	1.6004	.8002
Avg	2.1338	2.2624	2.2577	2.4791	2.3220	2.1955	1.7609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 401 / 33 KV Ramtek Transformer

II Feeder KV- 33 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.8002	.8002	.9145	.9717	
2		.9145	.743	.743	.9145	.9145	
3		.8573	.743	.8002	.8573	.8573	
4		.8573	.6859	.8002	.8573	.8573	
5		.743	.6287	.8002	.8002	.8002	
6		.2286	.5716	.8002	.743	.8002	
7		.4001	.6287	.8573	.5716	.743	
8		.4001	.5716		.5144	.6287	
9		.4001	.5716	.4572	.5716		
10		.4572	.5716	.4572	.5144		
11	.1715	.4001	.5716	.5144	.5144		.1143
12	.1143	.4572	.5716	.5144	.6287		.1715
13	.1715	.1715	.5716	.5144	.6859		.5716
14	.1715	.5716	.6287	.5144	.6287		.5716
15	.3429	.1715	.5716	.5144	.5716		.5144
16	.3429	.1715	.5144		.1715		.5144
17	.3429	.2858	.5144	.6859	.1715	.4001	.4572
18	.5144	.5144	.5144	.743	.3429	.4572	.6287
19	.8002	.8002		.8573	.8002	.5144	.8002
20	1.086	.9717		1.2003	1.0288		.9717
21	1.086	.8573		.9717	1.0288	.6287	.9717
22	1.086	.9717		1.0288	1.086		.9145
23	.9717	.8573	1.2003	1.0288	.9717	.6859	
24		.9717	.8573	1.2003	.9717	.9717	
Max	1.086	.9717	1.2003	1.2003	1.086	.9717	.9717
Min	.1143	.1715	.5144	.4572	.1715	.4001	.1143
Avg	.5540	.5978	.6516	.7638	.7026	.7308	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 201 / 11 KV Aroli Khindasi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	24-JUN-18
HR	Load (MW)
24	1.267
Max	1.267
Min	1.267
Avg	1.267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 202 / 11 KV Moil
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	23-JUN-18	24-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
10	.6535	.5093	
24			.7282
Max	.6535	.5093	.7282
Min	.6535	.5093	.7282
Avg	.6535	.5093	.7282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 203 / 11 KV DEOLAPAR KANDRI
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-JUN-18	24-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.964	1.0059	.9328
Max	.964	1.0059	.9328
Min	.964	1.0059	.9328
Avg	.964	1.0059	.9328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 204 / 11 KV Ramtek U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
24	1.423	1.2197	1.2382
Max	1.423	1.2197	1.2382
Min	1.423	1.2197	1.2382
Avg	1.423	1.2197	1.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 207 / Mansar 11 KV Incomer I
Feeder KV- 11 / INCOMING

DATE	24-JUN-18
HR	Load (MW)
24	2.2624
Max	2.2624
Min	2.2624
Avg	2.2624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 208 / Mansar 11 KV Incomer II
Feeder KV- 11 / INCOMING

DATE	24-JUN-18
HR	Load (MW)
24	1.7364
Max	1.7364
Min	1.7364
Avg	1.7364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164071 / 33 KV Khat S/Stn

Feeder No / Name : 201 / 11 KV KHAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	1.1222	1.1222	1.1584	1.3466	1.3575	1.0136
2	.5258	1.086	1.1041	1.1946	1.3112	1.3756	.9955
3	.5959	1.086	1.1041	1.1765	1.2757	1.3394	.9955
4	.631	1.0317	1.086	1.1765	1.2403	1.3032	.9774
5	.631	.9955	1.0498	1.1041	1.2403	1.267	.9774
6	.5609	.8145	.9231	1.0498	1.2048	1.2308	.9412
7	.5959	.6878	.8688	.8688	1.2048	1.1222	.9412
8	.5959	.724	.7783	.8145	1.1871	1.0679	.8507
9	.5784	.7602	.8507	1.086	1.134	1.0136	.8688
10	.6335	.8145	.9134	1.1744	1.1765		.5068
11	.8869	.8507	.8775	1.0867	1.1641		.6516
12	.724	.905	.6268	1.1568	1.2489		.5973
13	.724		.985	1.2269	1.3756		.8326
14	.7964	.9774	1.1104	1.2445	1.3756		.8507
15	.7421	.8326	1.1283	1.262	1.2127		.8507
16	.7059	.7421	1.0924	1.2269	1.1946		.8507
17	.7059	.7059	1.0387	1.1043	1.1222		.9593
18	.7059	.7783	.9134	1.0692	1.0498	.8688	.9231
19	.8507	.905	.8954	1.1393	1.1765	.9774	1.086
20	1.1946	1.1584	1.0387	1.4022	1.4842	1.1765	
21	1.267	1.1584	1.1641	1.4175	1.3937	1.1403	.8326
22	1.2127	1.1765	1.1999	1.4175	1.448	1.1222	.9955
23	1.1946	1.1584	1.1641	1.382	1.448	1.086	.9774
24	.298	1.1765	1.1222	1.1283	1.3466	1.3756	1.0498
Max	1.267	1.1765	1.1999	1.4175	1.4842	1.3756	1.086
Min	.298	.6878	.6268	.8145	1.0498	.8688	.5068
Avg	.7437	.9412	1.0066	1.1695	1.2651	1.1765	.8924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 403 / 33 KV WCL GONDEGAON
Feeder KV- 33 / INCOMING

DATE	23-JUN-18	26-JUN-18
HR	Load (MW)	Load (MW)
24	7.5057	7.3937
Max	7.5057	7.3937
Min	7.5057	7.3937
Avg	7.5057	7.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 404 / 33 kV Aroli
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-JUN-18	26-JUN-18
HR	Load (MW)	Load (MW)
24	5.5813	6.8233
Max	5.5813	6.8233
Min	5.5813	6.8233
Avg	5.5813	6.8233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 202 / 11 KV NAXI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.7973	
8		.5973	.7973	1.2003	.8573	.929	.3772
9	.2743	.6626	1.0498	1.3717	.8916	.964	.4534
10	.3258	.7716	1.0745	1.4022	.9259	.8573	.4801
11	.3721	.7716	1.0745	1.3146	1.0631	.8573	.5144
12	.3544	.7716	1.1694	1.3146	1.3717	.7011	.5487
13	.3721	.7202	1.0924	.8764	1.3032	.5258	.583
14	.3366	.6859	1.1641	1.1568	1.046	.2715	.583
15	.3366	.7202	1.1462		1.2048	.2715	.5487
16						.2743	
Max	.3721	.7716	1.1694	1.4022	1.3717	.964	.583
Min	.2743	.5973	.7973	.8764	.8573	.2715	.3772
Avg	.3388	.7126	1.0710	1.2338	1.0830	.6449	.5111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 203 / 11 KV PULLAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0364				
2			1.0364				
3	.7621		1.0364				
4	.7011		1.0364				
5	.7011		1.0364				
6	.6554		1.004				
7	.6706		.9717				
8	.7164	1.004	1.2793	1.0059	1.1498		.3401
9	.7621	1.2631	1.4413	1.1431	1.1012		.3239
10	.7335	1.2498	1.3592	1.2651		.1829	.2915
11	.7922	1.2346	1.4563	1.186	1.1984	.1829	.3239
12	.7775	1.2346	1.166		1.2146	.3658	.3077
13	.823	1.1584		.5344	1.1498	.4024	.3401
14	.8383	1.0822	1.2631	1.1336	1.2308	.3841	.3401
15	.8592		1.1822	1.1336	1.3117	.3841	.3401
16		1.1126		1.1336	1.1336	.3801	
17		1.1822		1.0364	1.2631		
18		1.0562					
19		.9536					
20		1.0467					
21		1.0623					
22		1.085					
23		1.0364					
24			1.0364				
Max	.8592	1.2631	1.4563	1.2651	1.3117	.4024	.3401
Min	.6554	.9536	.9717	.5344	1.1012	.1829	.2915
Avg	.7533	1.1174	1.1561	1.0635	1.1948	.3260	.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 204 / 11 KV KARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.1088	1.1431	1.2574	1.1431	1.1431	
2	.9526	1.1088	1.1431	1.1431	1.1431	1.1431	.5571
3	.9526	1.0456	1.1431	1.1431	1.1431	1.1431	.5243
4	.9526	1.0269	1.1431	1.1431	1.0479	1.1431	.5243
5	.9526		.9526	1.0479	1.0479	.9526	.426
6	.8573	.7095	.7621	.6859	.9526	.6668	.3605
7	.8573	.5041	.5716	.5716	.5716	1.2574	.3277
8	.8573	1.0867	1.6194	1.7556	.7865	1.4289	.5898
9	.8573	1.286	1.848	1.9404	.8848	1.3717	.5243
10	.8954	1.5708	1.6632	2.0005	1.0814	1.3336	.4534
11	.8954	1.6632	1.7147	1.9052	1.0159	1.0479	.5716
12		1.6632	1.7147	2.0957	1.7204	.9526	.5716
13	.9907	1.5708	1.7147	1.9052	1.6385	.7621	.7621
14	1.0479	1.4045	1.7147	1.7147	1.6385	.7621	.7621
15	1.0479	1.5708	1.7147	1.9052	1.7718	.6668	
16	.5716	.5716	.6722	1.9052	.6859	.5716	.4191
17	.5601	.5716	.5716	1.5775	.5144	.4915	.4572
18	.5601	.5716	.5144	.5601	.5716	.4915	
19	.6722	.7621	.8002	.5601	.6859	.6154	.5716
20	1.1088	1.1431	1.2003	1.1088	1.086	.5898	.9717
21	1.1088	1.2384	1.2574	1.2012	1.2384		.9717
22	1.2012	1.2384	1.3336	1.2384	1.2384	.5898	.9717
23	1.2012	1.2384	1.3336	1.3336	1.2003	.5898	.9526
24	1.1431	1.1088	1.2003	1.2574	1.1431	1.1431	.5571
Max	1.2012	1.6632	1.848	2.0957	1.7718	1.4289	.9717
Min	.5601	.5041	.5144	.5601	.5144	.4915	.3277
Avg	.9216	1.1202	1.2269	1.3732	1.0813	.9068	.6108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 205 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.3658	.362	.12
2		.0191	.0191	.0191	.3841	.362	.12
3		.0191	.0191	.0191	.3841	.362	.1372
4		.0191	.0191	.0191	.4207	.362	.1372
5		.0191	.0191	.0191	.4207	.362	.1372
6		.0191	.0191	.0191	.4207	.4163	.1372
7		.0191	.0191	.0191	.0191	.0191	.0171
8		.2865	.362	.0191	.0171	.0191	.1372
9	.1524	.3681	.4163	.0191		.0191	.1372
10	.1267	.3801	.4075	.0191	.0171	.0191	.12
11		.3801	.4207	.0191	.0171	.0191	
12		.3801	.4557	.0191	.0171		
13	.2534	.4251	.4458	.0191	.0171	.0191	.0953
14	.2715	.4163	.4334	.0191	.0171	.0191	.1524
15	.2896	.4163	.4161	.0191	.0191	.0191	.1524
16	.3077	.0191	.0191	.0191	.0191	.0191	.0191
17	.2896	.0191	.0191	.0191	.0191		.0191
18	.0191	.0191	.0191	.0191	.0191		
19	.0191	.0191	.0191		.0191	.0171	.0191
20	.0191	.0191	.0191	.0191	.0191	.0171	.0191
21	.0191	.0191	.0191	.3258	.3439	.1372	.0191
22	.0191	.0191	.0191	.3801	.3801	.1029	.0191
23	.0191	.0191	.0191	.3801	.3801	.1029	.0191
24		.0191	.0191	.0191	.3658	.362	.1029
Max	.3077	.4251	.4557	.3801	.4207	.4163	.1524
Min	.0191	.0191	.0191	.0191	.0171	.0171	.0171
Avg	.1389	.1399	.1526	.0638	.1784	.1494	.0875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 206 / 11 KV BHIWAPUR BUS STAND
FEEDER Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.5914	.6154	.6335	.3658	.5973	.362
2	.543	.5914	.6154	.6154	.3658	.5973	.362
3	.543	.5601	.6154	.5792	.3658	.543	.362
4	.543	.5601	.543	.543	.3292	.543	.3258
5	.5068	.5228	.543	.543	.3109	.5068	.3258
6	.4163	.4435	.4525	.4344	.2926	.4344	.3077
7	.362	.3109	.362	.3439	.4207	.3439	.2896
8	.3439	.3077	.3258	.3258	.3439	.3077	.2896
9	.3077	.3258	.3439	.3439	.3439	.3258	.2507
10	.3511	.3801	.3696	.4163	.362	.3292	.2534
11	.4066	.3982	.4207	.4163	.3258	.3292	.2534
12	.4207	.3801	.4755	.4525	.4344	.3109	.2896
13	.4344	.4525	.4755	.4887	.4887	.3109	.2896
14	.4344	.4525	.4784	.4706	.4344	.3109	.2896
15	.4344	.4344	.4755	.4525	.4163	.3109	.2896
16	.4163	.4344	.4706	.4706	.4163	.3077	.3077
17	.3801	.3761	.4344	.3982	.4163	.2715	.3077
18	.362	.3761	.3801	.4163	.3982	.3077	
19	.439	.4298	.4163	.4525	.4163	.1991	.3982
20	.5601	.5544	.543	.5487	.5068	.3982	.4572
21	.5975	.6099	.5792	.6283	.5611	.4119	.4525
22	.6283	.6335	.6335	.6767	.6154	.4163	.4525
23	.6099	.6335	.6516	.6697	.6154	.3982	.4344
24	.6154	.6099	.6154	.6335	.3658	.5973	.3982
Max	.6283	.6335	.6516	.6767	.6154	.5973	.4572
Min	.3077	.3077	.3258	.3258	.2926	.1991	.2507
Avg	.4696	.4737	.4932	.4981	.4130	.3920	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 207 / 11 KV BHIMADEVI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3511	.362	.3841	.2743	.3439	.2353
2	.3292	.3547	.362	.3841	.2743	.3439	.2353
3	.2926	.3361	.362	.3658	.2743	.3439	.2328
4	.2743	.3361	.362	.3658	.2743	.3439	.2149
5	.2743	.3142	.362	.3658	.2743	.2896	.2149
6	.2561	.2402	.2896	.2561	.2743	.2534	.197
7	.2534	.1991	.2172	.2195	.2378	.2172	.1791
8	.2012	.1991	.1991	.1829	.197	.181	.1612
9	.2012	.2172	.2172	.2378	.2149	.1991	.1612
10	.2195	.2378	.2353	.2715	.2507	.2012	.1791
11	.2561	.2561	.2896	.2534	.2686	.1829	.1829
12	.2534	.2926	.2715	.2715	.2686	.1829	.1829
13	.362	.2743	.3077	.2896	.2686	.1829	.1646
14	.2896	.3109	.3077	.2896	.2686	.1829	.1829
15	.2715	.2926	.2865	.2896	.2715	.1829	.1829
16	.2715	.3109	.3224	.3077	.2534	.1829	.2012
17	.2715	.2896	.2561	.2658	.2534	.197	.1829
18	.2353	.2629	.2743	.2658	.2353	.2865	
19	.2353	.3155	.2926	.2896	.2715	.197	.2743
20	.3511	.3292	.3475	.3292	.3258	.2507	.2926
21	.3326	.3292	.3475	.3658	.3439	.2507	.2743
22	.3658	.3801	.3841	.3658	.362	.2534	.2561
23	.3696	.3801	.3841	.3841	.362	.2507	.2561
24	.3658	.3696	.362	.3841	.2743	.3439	.2328
Max	.3696	.3801	.3841	.3841	.362	.3439	.2926
Min	.2012	.1991	.1991	.1829	.197	.181	.1612
Avg	.2859	.2991	.3084	.3077	.2739	.2435	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 201 / JAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.6004	1.6194	1.6385	1.6194	1.6194	.6668
2	1.6385	1.5623	1.6004	1.6194	1.6004	1.6004	.6478
3	1.6194	1.5242	1.5813	1.6004	1.5623	1.6004	.6859
4	1.5432	1.4861	1.5623	1.5813	1.5242	1.5623	.6478
5	1.4289	1.448	1.4861	1.5051	1.4861	1.3336	.6859
6	1.0669	.9526	.9335	1.0479	1.0098	.8764	.5716
7	.8002	.724	.7811	.7621	.743	.6859	.4001
8	.964	1.1744	1.5074	1.335	1.8107	1.3094	.5906
9	1.0288	1.4217	1.595	1.56	1.7204	1.3094	.6097
10	1.0174	1.5249	1.4563	1.6766	1.7436	1.1603	.5906
11	.9667	1.4083	1.439	1.6057	1.3889	1.0774	.381
12	.9012	1.5939	1.4043	1.6876	1.6278	.9614	.362
13	.9175	1.4723	1.4089	1.6617	1.5089	.5243	.3429
14	.9175	1.4449	1.442	1.5912	1.5089	.5201	.2477
15	.9012	1.3375	1.3916	1.5581	1.4918	.3641	.4572
16	.8192	1.3908	1.2483	.9335	.7049	.4334	.3048
17	.724	1.1812	.7621	.7811	.724	.4572	.3239
18	.6478	1.1241	.6668	.6859	.6859	.4954	
19	.8954	.9526	.9526	.9526	.9145	.5716	.5716
20	1.3908	1.5242	1.4289	1.3717	1.3336	.2858	.9717
21	1.6575	1.7147	1.6956	1.6956	1.6385	.6478	.8383
22	1.7147	1.7528	1.7337	1.7147	1.6385	.6287	.8002
23	1.6956	1.6956	1.6956	1.6766	1.6385	.6097	.7621
24	1.6766	1.6385	1.6385	1.6766	1.6575	1.6194	.6287
Max	1.7147	1.7528	1.7337	1.7147	1.8107	1.6194	.9717
Min	.6478	.724	.6668	.6859	.6859	.2858	.2477
Avg	1.1905	1.4021	1.3763	1.4133	1.3868	.9272	.5691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 202 / TATOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.156	.2328	.3768	.4477	.4694	.3441	.1254
9	.1543	.3012	.4359	.567	.583	.4191	.1029
10	.1526	.3366	.4191	.5658	.5596	.3688	.1029
11	.1638	.3258	.4191	.503	.5868	.3185	.1029
12	.1802	.3292	.4359	.4915	.4458	.2683	.1029
13	.1802	.333	.4694	.4807	.4748	.2374	.1029
14	.1802	.3086	.4862	.4915	.4458		.1029
15	.1475	.3475	.4862	.4915	.463		.1029
17						.2096	
18						.2286	
Max	.1802	.3475	.4862	.567	.5868	.4191	.1254
Min	.1475	.2328	.3768	.4477	.4458	.2096	.1029
Avg	.1644	.3143	.4411	.5048	.5035	.2993	.1057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 203 / 11 KV PAHAMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7011	.9568	1.1961	1.2269	1.2071	.9667	.3109
9	.7888	1.1919	1.358	1.56	1.4419	.9995	.3048
10	.8573	1.1871	1.2407	1.3916	1.5581		.2858
11	.7712	1.39	1.1797	1.5249	1.1797	.639	.2477
12	.8192	1.1999	1.1633	1.4746	1.4586	.5571	.2286
13	.8192	1.2003	1.2597	1.4582	1.3735	.5243	.2667
14	.8192	1.2795	1.326	1.4586	1.5089	.3506	.5525
15	.8192	1.2689	1.2763	1.4091	1.335	.3681	.2477
16						.3121	.1905
17						.3048	
18						.3239	
Max	.8573	1.39	1.358	1.56	1.5581	.9995	.5525
Min	.7011	.9568	1.1633	1.2269	1.1797	.3048	.1905
Avg	.7994	1.2093	1.2500	1.4380	1.3829	.5346	.2928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 204 / 11 KV Sarandi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2103	.2835	.426	.3761	.3944	.2652	.1227
9	.2915	.3898		.3898	.4854	.2347	.1227
10	.2883	.3761	.4527	.463	.3601	.218	.1227
11	.3185	.3841	.4527	.4527	.3601	.1844	.1227
12	.3113	.4477	.4359	.426	.3988	.1638	.1227
13	.3605	.4115	.4359	.431	.3814	.1475	.1227
14	.3441	.4024	.4527	.4424	.3988		.1227
15	.2949	.3761	.4527	.426	.3641		.1227
17						.0953	
18						.0953	
Max	.3605	.4477	.4527	.463	.4854	.2652	.1227
Min	.2103	.2835	.426	.3761	.3601	.0953	.1227
Avg	.3024	.3839	.4441	.4259	.3929	.1755	.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 402 / 33 KV INCOMER NO 2 JAWALI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.6004	1.6004	1.6575	1.6004	1.6004	.6859
2	1.6575	1.5432	1.6004	1.6004	1.6004	1.6004	.6287
3	1.6004	1.5432	1.6004	1.6004	1.5432	1.6004	.6859
4	1.5432	1.4861	1.5432	1.6004	1.5432	1.5432	.6287
5	1.4289	1.4289	1.4861	1.4861	1.4861	1.3146	.6859
6	1.086	.9717	.9145	1.0288	1.0288	.8573	.5716
7	.8002	.743	.8002	.743	.743	.6859	.4001
8	1.829	2.2862	3.0178	2.8006	3.2579	2.524	.9145
9	1.9605	2.8578	3.1824	3.3471	3.4751	2.5789	.9145
10	2.0302	2.915	2.9081	3.3471	3.7723	1.262	.8573
11	1.9004	2.7984	2.8532	3.4208	2.915	1.9204	.6287
12	1.9004		2.7984	3.4751	3.4865	1.701	.5716
13	1.9004	2.7984	2.963	3.3471	3.2007	1.1523	.5716
14	1.9004	2.7401	3.0727	3.3122	3.3722	.9328	.8002
15	1.9004	2.7984	2.9081	3.2579	3.1436	.8002	.6859
16	.8002	1.3717	1.3717	.9145	.6859	.7682	.2858
17	.743	1.2003	.743	.8002	.743	.743	.3429
18	.6287	1.1431	.6859	.8573	2.0576	.8002	
19	.9145	.9717	.9717	.9717	.9145	.5716	.5716
20	1.3717	1.5432	1.4289	1.3717	1.3146	.6859	.9717
21	1.6575	1.7147	1.7147	1.7147	1.6575	.6287	.8573
22	1.7147	1.7718	1.7147	1.7147	1.6575	.6287	.8002
23	1.7147	1.7147	1.7147	1.6575	1.6575	.6287	.743
24	1.6575	1.6575	1.6575	1.6575	1.6575	1.6004	.6859
Max	2.0302	2.915	3.1824	3.4751	3.7723	2.5789	.9717
Min	.6287	.743	.6859	.743	.6859	.5716	.2858
Avg	1.5124	1.8087	1.8855	1.9868	2.0214	1.2137	.6735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 406 / 33 KV Gokul WCL Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3429	.3429	.3429	.3429	.3429	.5716
2	.4572	.3429	.3429	.3429	.3429	.3429	.5716
3	.4572	.3429	.3429	.3429	.3429	.3429	.5716
4		.3429	.3429	.3429	.3429	.3429	.5716
5	.4572	.3429	.3429	.3429	.3429	.3429	.5716
6	.4572	.3429	.3429	.3429	.3429	.3429	.5716
7	.4572	.3429	.3429	.3429	.3429	.3429	.5716
8	.4572	.3429	.3429	.3429	.3429	.3429	.5716
9	.3429	.3429	.3429	.3429	.3429	.3429	.5716
10	.3429	.3429	.3429	.3429	.3429	.3429	.5716
11	.3429	.4572	.3429	.3429	.3429	.3429	.5716
12	.3429	.4572	.3429	.3429	.3429	.3429	.4572
13	.3429	.4572	.3429	.3429	.3429	.3429	.4572
14	.3429	.4572	.3429	.3429	.3429	.3429	.4572
15	.4572	.4572	.3429	.3429	.3429	.3429	.4572
16	.4572	.4572	.4572	.3429	.3429	.3429	.3429
17	.3429	.3429	.3429	.3429	.3429	.5716	.3429
18	.3429	.3429	.3429	.3429	.3429	.5716	
19	.3429		.3429	.3429	.3429	.5716	.4572
20	.3429		.3429	.3429	.3429	.5716	.3429
21	.3429	.3429	.3429	.3429	.3429	.5716	.4572
22	.3429	.3429	.3429	.3429	.3429	.5716	.4572
23	.3429	.3429	.3429	.3429	.3429	.5716	.4572
24	.4572		.3429	.3429	.3429	.3429	.5716
Max	.4572	.4572	.4572	.3429	.3429	.5716	.5716
Min	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.3926	.3756	.3477	.3429	.3429	.4096	.5020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 201 / 11 KV KUHI U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.743	.8764	.8954	.8764	.7621	.6097
2	.8383	.724	.8764	.8764	.8573	.724	.6097
3	.8383	.7049	.8383	.8573	.8573	.6859	.6097
4	.8383	.6859	.8383	.8573	.8383	.6478	.6097
5	.8383	.6668	.8002	.8192	.8192	.5716	.6097
6	.6668	.5716	.6859	.6478	.6668	.5335	.5716
7	.5906	.4572	.5716	.5716	.5335	.4763	.4763
8	.5716	.4572	.5716	.4954	.5335	.4763	.4954
9	.5525	.4382	.5525	.5525	.5335	.4763	.4954
10	.5525	.5144	.6097	.5906	.6478	.4763	.4572
11	.5335	.5716	.6478	.6287	.743	.4763	.4191
12	.5716	.6287	.7049	.6859	.6097	.4763	.4001
13	.5906	.6097	.724	.724	.5335	.4572	.4001
14	.5716	.5906	.724	.724	.5716	.4191	.4191
15	.5525	.5906	.7049	.724	.5716	.4191	.4191
16	.5335	.6097	.6859	.6478	.5335	.381	.4382
17	.5335	.6478	.6668	.5716	.4954	.4382	.4382
18	.5716	.5525	.6859	.5144	.5716	.4954	
19	.6097	.6859	.7049	.6097	.6097	.5525	.5335
20	.6859	.8002	.8383	.7621	.6478	.6097	.5716
21	.724	.8383	.8764	.8573	.6859	.6668	.5716
22	.743	.8954	.9145	.9526	.7049	.6478	.5906
23	.7621	.9145	.9335	.9526	.724	.6478	.5525
24	.8573	.7621	.9145	.9145	.9335	7.697	.6097
Max	.8573	.9145	.9335	.9526	.9335	7.697	.6097
Min	.5335	.4382	.5525	.4954	.4954	.381	.4001
Avg	.6660	.6525	.7478	.7264	.6708	.8423	.5177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 202 / 11 KV CHAFEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7621	.9526	1.0098	1.0098	.9526	.5716
2	.8573	.7621	.9145	.9907	.9907	.9145	.5716
3	.8573	.743	.8764	.9907	.9907	.8383	.5716
4	.8383	.743	.8764	.9717	.9907	.8002	.5335
5	.8383	.724	.8573	.9717	.9717	.7621	.5335
6	.7621	.7621	.8383	.7811	.7621	.7049	.4954
7	.724	.8002	.8383	.6859	.6478		.4001
8	.5716	.7811	.9145	.6287			.4001
9	.5335	.743	1.0098	.6478			.4001
10	.4763	.8002		.724			.381
11	.4001	.8383	1.0669	.9526			.362
12	.5525	.8954	1.105	1.1431	.743		.3048
13	.6859	.8954	1.1431	1.2193	.7621		
14	.724	.8954	.9526	1.3717	.9526		.362
15	.6859	.8954	.9335	1.3717	.9907		.362
16		.8954	.8192	1.3336	1.0288		.4001
17		.8764	.6668	1.3146	1.0669		.4191
18		.8764	.743	1.2955	1.0669		.4001
19	1.1812	.8764	.8002	1.2574	1.105		.362
20	1.3336	.9145	1.2574	1.2384	1.086	.4572	.381
21	.8954	.9526	.9717	1.0098	1.086	.4954	.4191
22	.8192	.9907	1.0098	1.105	1.0288	.5335	.4382
23	.7811	.9717	1.0479	1.0669	.9907	.6097	.4191
24	.8573	.7811	.9526	1.0288	1.0288	.9526	.6097
Max	1.3336	.9907	1.2574	1.3717	1.105	.9526	.6097
Min	.4001	.724	.6668	.6287	.6478	.4572	.3048
Avg	.7730	.8407	.9369	1.0463	.9650	.7292	.4390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 203 / 11 KV DONGARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.4001	.381	.4763	.4763	.4382	.1905
2	.2667	.4001	.3429	.4763	.4763	.381	.1905
3	.2667	.381	.3048	.4763	.4763	.381	
4	.2477	.381	.2667	.4572	.4572	.3429	
5	.2667	.381	.2477	.4572	.4001	.3048	
6	.2286	.1524	.1905	.2477	.2667	.1905	
7	.1715	.1524	.2286	.2096	.1715		
8	.1905	.1905	.1905	.1905	.1905		
9	.2096	.2096	.1524	.1715	.1905	.1905	.0381
10	.2096	.2096	.0953	.2096	.1905	.2096	.0381
11	.1905	.2096	.2096	.2096	.1905	.2096	.0191
12	.1715	.2096	.2858	.2096	.1905	.2096	
13	.1524	.2286	.3239	.2096	.2096	.1143	.1715
14	.1905	.2286	.3048	.4572	.3048	.1143	.1715
15	.1905	.2477	.2858	.4572	.3048	.0762	.1715
16	.1715	.2477	.2858	.4572	.3239	.0762	.1715
17	.1715	.2477	.2096	.4572	.3429	.0762	.1524
18	.2477	.2667	.2286	.4572	.381	.1143	.1715
19	.3429	.381	.2477	.4001	.4001	.1143	.1905
20	.381	.4191	.4763	.362	.4191	.1524	
21	.4001	.4191	.5335	.4001	.4191	.1905	
22	.4191	.4572	.4954	.4763	.4191	.1905	.1524
23	.4191	.4191	.4763	.4763	.4382	.1143	.1524
24	.1905	.4191	.4191	.4763	.4763	.4382	.1524
Max	.4191	.4572	.5335	.4763	.4763	.4382	.1905
Min	.1524	.1524	.0953	.1715	.1715	.0762	.0191
Avg	.2485	.3024	.2993	.3699	.3382	.2104	.1423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 204 / 11 KV SATARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.6859	.9526	.9907	1.0098	.9907	.4572
2	.8002	.6859	.9526	.9907	1.0098	.9526	.4191
3	.8002	.6859	.9717	.9907	.9907	.9145	.4191
4	.8192	.6859	.9717	.9907	.9907	.8573	.4191
5	.8192	.6668	.9907	.9907	.9907	.7621	.4191
6	.7621	.6668	.7621	.9907	1.1431	.8002	.381
7	.6287	.6668	.5525	1.0669	1.2003	.8002	.362
8	.5335	.5716	.5335	1.1431	1.2384	.6668	.3429
9	.4763	.5335	.5144	1.2193	1.2574	.5716	.3048
10	.4382	.5335	.5716	1.2765	1.1431	.4954	.3048
11	.381	.5335	.6097	1.1431	1.086	.4954	.3239
12		.5335	.6478	.9526	1.105	.4572	.3239
13	.4954	.4954	.6668	.9145	1.1241	.3429	.3239
14	.3429	.8002	1.2003	.6668	.5144	.381	.3048
15	.362	.8764	1.2193	.6478	.4763	.3048	.3048
16	.3239	1.0479	1.2193	.5716	.4572	.3429	.3048
17	.7049	1.0669	1.2193	.4763	.4191	.362	.3239
18	.724	1.086	1.2003	.4382	.5716	.381	.3429
19	.7621	1.086	1.1812	.5716	.6859	.4001	.381
20	.7811	1.086	1.2003	.9335	.8764	.4572	.4001
21	.7621	1.0669		1.105	.9907	.5335	.4001
22	.724	1.0669	1.086	1.1241	1.0098	.4954	.4191
23	.6859	1.0479	1.0288	1.0669	1.0288	.4382	.4191
24	.8002	.6859	1.0479	1.0098	1.0479	1.0288	.4572
Max	.8192	1.086	1.2193	1.2765	1.2574	1.0288	.4572
Min	.3239	.4954	.5144	.4382	.4191	.3048	.3048
Avg	.6403	.7859	.9261	.9280	.9320	.5930	.3691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 205 / 11 KV BHOJAPUR GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2858	.2667	.2858	.2858	.2858	.2286
2	.3239	.2858	.2667	.2858	.2858	.2858	.2286
3	.3239	.2667	.2667	.2667	.2858	.2667	.2286
4	.3239	.2667	.2667	.2667	.2667	.2667	.2286
5	.3239	.2477	.2667	.2477	.2667	.2286	.2286
6	.2858	.1905	.1905	.2096	.2286	.2096	.1905
7	.2286	.1524	.1715	.1905	.1715	.1715	.1715
8	.1905	.1524	.1524	.1715	.2096	.1334	.1524
9	.1715	.1524	.1334	.1715	.2096	.1905	.1524
10	.1143	.1905	.1524	.1715	.2096	.1905	.1715
11	.0572	.1905	.1715	.1905	.1905	.2286	.1905
12	.1143	.2096	.1905	.2286	.2286	.2286	.2096
13	.1715	.1905	.2096	.2477	.2667	.0381	.2096
14	.1715	.1715	.2286	.2477	.2667	.0381	.2286
15	.1524	.1715	.2286	.2286	.3048	.0381	.2286
16	.1524	.1524	.2096	.2477	.2477	.1143	.1905
17	.1334	.1524	.1715	.2667	.2477	.1524	.1524
18	.1715	.1715	.1905	.2667	.2667	.1905	.1905
19	.2096	.1905	.2286	.2858	.2667	.2477	.2286
20	.2477	.2286	.2667	.3048	.2858	.2477	.2286
21	.2477	.2667	.3048	.3048	.2858	.2477	.2286
22	.2667	.2667	.3239	.2858	.2858	.2477	.2286
23	.2858	.2667	.3239	.2858	.3048	.2477	.2286
24	.3048	.3048	.2667	.3048	.2858	.3048	.2286
Max	.3239	.3048	.3239	.3048	.3048	.3048	.2286
Min	.0572	.1524	.1334	.1715	.1715	.0381	.1524
Avg	.2207	.2135	.2270	.2485	.2564	.2000	.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 206 / 11 KV TITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4382	.4954	.5716	.5525	.5335	.4382
2	.4954	.4572	.4954	.5716	.5525	.4954	.4382
3	.4954	.4572	.4572	.5716	.5525	.4763	.4382
4	.4954	.4954	.4191	.5525	.5525	.4191	.4382
5	.4954	.724	.4001	.5335	.5335	.381	.4382
6	.4954	.4572	.3048	.3239	.381	.3239	.4191
7	.5144	.381	.3048	.2858	.2858		.4191
8	.5144	.381	.3429	.2477	.2286		.4001
9	.4954	.381	.381	.2667	.2477		.4001
10	.4382	.3429	.381	.2477	.2286		.4001
11	.4001	.3429	.381	.2858	.2286	.2286	.4191
12	.381	.3429	.4001	.3048	.2477	.2286	.4191
13	.4001	.3048	.4191	.3429	.2477	.3048	.4001
14		.2286	.3239	.5144	.5716	.3429	.4191
15	.381	.2477	.3048	.5144	.5716	.381	.4001
16	.4001	.2477	.2667	.5144	.6097	.4001	.4001
17	.4001	.2667	.1905		.6287	.4001	.381
18	.4191	.3048	.2667	.4572	.6097	.4191	.4191
19	.4382	.381	.3239	.4954	.5906	.4382	.4001
20	.4572	.4572	.5716	.5716	.5716	.4572	.4001
21	.4572	.5716	.6097	.5716	.5716	.4572	
22	.4572	.6097	.6097	.6097	.6097	.4382	.4382
23	.4572	.5906	.5906	.5716	.5906	.4382	.4382
24	.4763	.4382	.5906	.5716	.5716	.5716	.4382
Max	.5144	.724	.6097	.6097	.6287	.5716	.4382
Min	.381	.2286	.1905	.2477	.2286	.2286	.381
Avg	.4539	.4104	.4096	.4564	.4723	.4068	.4175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 207 / 11KV MIDC KUHI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2096	.2096	.1905	.2667	.1905	.0381
2	.2286	.2096	.2096	.2286	.2667	.1905	.0572
3	.2286	.2286	.2096	.2667	.2667	.2096	.0572
4	.2096	.2286	.2096	.2858	.2858	.2096	.0572
5	.2096	.2477	.2096	.2667	.2858	.2286	.0572
6	.2096	.2096	.1905	.2667	.2858	.2286	.0762
7	.1905	.1905	.1905	.2667	.2667	.2096	.0762
8	.2096	.1715	.2286	.2477	.2858	.1905	.0762
9	.2286	.1715	.2667	.0953	.2858	.1905	.0762
10	.2667	.3048	.3429	.0953	.3239	.1905	.1524
11	.4191	.381	.3429	.1143	.3429	.1905	.1905
12	.381	.5525	.362	.1905	.2667	.1905	.1715
13	.3239	.381	.362	.2096	.1905	.1524	.1905
14	.3239	.2858	.362	.1905	.2667	.1143	.1905
15	.3239	.3239	.362	.1334	.3239	.0381	.2096
16	.3239	.4001	.4001	.1905	.381	.0381	.1905
17	.3239	.4572	.4191	.2858	.4191	.0381	.1715
18	.2667	.5335	.381	.3048	.3429	.0381	.1334
19	.2286	.4572	.3239	.3239	.3048	.0381	.0953
20	.1905	.381	.2858	.3239	.2667	.0381	.1524
21	.1905	.3429	.2667	.2858	.2286	.0381	.1715
22	.1905	.2096	.2477	.2667	.2286	.0381	.1715
23	.1905	.2096		.2667	.2096	.0381	.1715
24	.2477	.1905	.2096	.2286	.2477	.1905	.0381
Max	.4191	.5525	.4191	.3239	.4191	.2286	.2096
Min	.1905	.1715	.1905	.0953	.1905	.0381	.0381
Avg	.2556	.3032	.2866	.2302	.2850	.1342	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 208 / 11 KV BHOJAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.2096	.3429	.4191	.1143	.1334	.0381
2	.0762	.0572	.1143	.0953	.1143	.1334	.0381
3	.0762	.0572	.1143	.0953	.1143	.1334	.0381
4	.0762	.0572	.1143	.0762	.1143	.1334	.0381
5	.0572	.0572	.0762	.0762	.1143	.1334	.0381
6	.0762	.0572	.0572	.381	.4954	.4191	.0381
7	.0762	.0572	.0572	.3429	.5335	.381	.0381
8	.0762	.0572	.0762	.1524	.6097	.362	.0381
9	.0953	.0572	.0953	.381	.6859	.3048	.0381
10	.0762	.0953	.1143	.4382	.724	.3048	.0381
11	.0762	.0953	.1143	.4382	.7621	.2667	.0381
12	.0762	.0953	.1334	.4572	.7621	.2667	.0381
13	.0762	.0953	.1334	.4763	.7811		.0381
14	.3429	.4572	.6097	.5716	.724		.0381
15	.362	.4954	.6097	.6097	.6859		.0381
16	.3429	.6097	.6097	.5716	.6287	.0762	.0572
17	.3239	.5716	.6097	.5716	.5716	.0762	.0762
18	.2858	.5335	.5335	.1334	.1143	.0381	.0762
19	.2477	.4954	.4763	.1334	.1143	.0381	.0762
20	.2286	.4572	.4382	.1334	.1334	.0381	.0762
21	.2286	.381	.4191	.1143	.1334	.0381	.0381
22	.2096	.3429	.4191	.1143	.1334	.0381	.0381
23	.2096	.3429	.4191	.1143	.1334	.0381	.0381
24	.1143	.2096	.3429	.4191	.1143	.1334	.0381
Max	.362	.6097	.6097	.6097	.7811	.4191	.0762
Min	.0572	.0572	.0572	.0762	.1143	.0381	.0381
Avg	.1619	.2477	.2929	.3048	.3922	.1660	.0452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 201 / 11 KV MANDHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.381	.4572	.4572	.8764	.4382	.362
2	.4954	.381	.4572	.4572	.8764	.4191	.4001
3	.5335	.381	.4572	.4572	.8383	.4191	.362
4	.5335	.3429	.381	.4191	.8383	.381	.3239
5	.5716	.3429	.381	.381	.8383	.381	.3239
6	.4763	.3048	.362	.362	.6478	.381	.3239
7	.4382	.2667	.362	.3429	.4954	.3239	.2858
8	.5335	.6859	.6859	.8383		.3048	.381
9	.6859	.724	.9145	.9335	.9526	.5716	.381
10	.6859	.7621	.8764	.9907	1.0098	.6097	.362
11	.6478	.7811	.8764	1.0479	.8954	.5716	.362
12	.6668	.7811	.8954	.9526	.8383	.5335	.4382
13	.7049	.7811	.9335	.9526	.8573	.5335	.4382
14	.6859	.7811	.9145	1.0288	.8954	.4954	.4382
15	.6668	.8002	.8764	.9145	.8383	.4572	.4382
16	.2096	.4001	.3429	.4954	.3429	.2858	.1905
17	.2667	.3429	.3429	.5144	.362	.2286	.2096
18	.2858	.3429	.3429	.5525	.3429	.2286	.2477
19	.3048	.3239	.381	.6287	.381	.2667	.2858
20	.362	.4382	.4191	.8764	.4001	.3429	.4001
21	.381	.4382	.4572	.9717	.4382	.362	.4001
22	.4001	.4572	.4763	.9717	.4572	.362	.4191
23	.381	.4572	.4763	.9145	.4572	.3429	.4001
24	.5335	.381	.4572	.4572	.8764	.4572	.362
Max	.7049	.8002	.9335	1.0479	1.0098	.6097	.4382
Min	.2096	.2667	.3429	.3429	.3429	.2286	.1905
Avg	.4977	.5033	.5636	.7049	.6850	.4041	.3556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 202 / 11 KV CHICHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3429	.4001	.4001	.3239	.362	.1905
2	.2286	.3429	.381	.4001	.3048	.3239	.1905
3	.2286	.3048	.381	.4001	.3429	.3048	.1905
4	.2667	.3048	.381	.3429	.3429	.3048	.1715
5	.2667	.2286	.3429	.3048	.3429	.2667	.1524
6	.1715	.2096	.2477	.2477	.2477	.2667	.1524
7	.1524	.1905	.2096	.3048	.1715	.2096	.1334
8	.1524	.2096	.2858	.3048			.1334
9	.1524	.2286	.362	.3048	.3429		.1334
10	.1524	.2286	.3048	.3239	.362		.1143
11	.1715	.2667	.3048	.2858	.3239	.1334	.1143
12	.1715	.3048	.3239	.2667	.3048	.1715	.0953
13	.1715	.2858	.3239	.3048	.3048	.1524	.0953
14	.1715	.2858	.3239	.3239	.2667	.1524	.0953
15	.1524	.2858	.3239	.3048	.2858	.1524	.0953
16	.1524	.2286	.1715	.2096	.1905	.1334	.0953
17	.1524	.1905	.1715	.1905	.1905	.1334	.1524
18	.1524	.1715	.1715	.1905	.1905	.2286	.1715
19	.2286	.2286	.2477	.2096	.3048	.1715	.2286
20	.3048	.3429	.3239	.3429	.3239	.1905	.2858
21	.362	.381	.381	.4001	.3429	.2096	.2858
22	.381	.381	.4191	.4001	.381	.2096	.2858
23	.362	.4001	.4191	.381	.381	.2096	.2858
24	.2667	.3429	.4001	.4001	.362	.381	.1905
Max	.381	.4001	.4191	.4001	.381	.381	.2858
Min	.1524	.1715	.1715	.1905	.1715	.1334	.0953
Avg	.2167	.2786	.3167	.3144	.3015	.2223	.1683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 203 / 11 KV DONGARMOUDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8192	.743	.9335		.8764	.4954
2	.8002	.8002	.743	.9335		.8573	.4954
3	.8002	.7621	.743	.9145		.7621	.4954
4	.8383	.7621	.6668	.8573		.6668	.4954
5	.8764	.6287	.5525	.7811		.6668	.381
6	.6478	.6097	.4572	.724		.6287	.3239
7	.6097	.5144	.6668	.7621		.4954	.4191
8	.6859	.743	1.0098	1.1241		.4763	.4191
9	.724	.9145	1.2193	1.2003	1.3336		.381
10	.5906	.743	.9335	1.1622	1.2193	.362	.3048
11	.6859	.8002	1.2384	1.1812	.9526	.3048	.3239
12	.6668		1.2955	1.2384	1.1241	.362	.2477
13	.6287	1.0669	1.2384	1.2955	1.1622	.362	.2477
14	.6478	1.0288	1.2384	1.2193	1.086	.3048	.3239
15	.6097	.9526	1.2574	1.1431	.9526	.2858	.3429
16		.5335	.5906		.381	.2477	.2096
17	.381	.4191	.5335		.4382	.2286	.3239
18	.4191	.381	.4001		.4763	.381	.381
19	.5335	.4001	.5525		.743	.4572	.4572
20	.7811	.8764	.8192		.8192	.6097	.5335
21	.8383	.8764	.9145		.8764	.6287	.5335
22	.8764	.8383	1.0098		.9526	.6287	
23	.8383	.7811	.9907		.9145	.6287	.5144
24	.8573	.8192	.7811	.9526		.8954	.5525
Max	.8764	1.0669	1.2955	1.2955	1.3336	.8954	.5525
Min	.381	.381	.4001	.724	.381	.2286	.2096
Avg	.7016	.7422	.8581	1.0264	.8954	.5268	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 205 / 11 KV WAG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.724	.7049	.8002	.7049	.6859	.4572
2	.6097	.6859	.7049	.8002	.7049	.6859	.4572
3	.6097	.6668	.7049	.7621	.724	.6668	.4572
4	.6478	.5716	.7049	.7621	.724	.6668	.4572
5	.6859	.5716	.6668	.724	.743	.6097	.381
6	.4954	.5335	.5906	.6478	.6097	.5716	.362
7	.4572	.4572	.6097	.6478	.6478	.5335	.3239
8	.4763	.5335	.743	.7811		.2096	.3048
9	.5144	.4763	.7811	.8383	.7621	.2096	.3048
10	.4954	.743	.8002	.8764	.8002	.0953	.3048
11	.4763	.8002	.4001	.8954	.7049	.0953	.3048
12	.5525	.8954	.8764	.9145	.743	.2858	.2667
13	.5906	.8573	.9145	.9526	.7621	.2858	.2667
14	.6097	.8573	.8954	.9145	.6287	.3239	.2858
15	.6097	.8192	.8764	.8764	.3429	.3239	.2858
16	.4572	.7049	.6287	.7049	.5335	.3239	.3239
17	.4954	.6478	.5716	.6668	.5525	.2858	.3429
18	.5335	.5144	.5525	.6859	.5525	.3239	.4572
19	.5906	.7049	.6859	.6859	.5716	.4001	
20	.6859	.7621	.743	.8573	.6097	.4954	.5335
21	.7621	.7621	.8002	.8002	.6668	.5335	.5335
22	.7811	.7621	.8383	.8954	.7621	.5335	.5144
23	.7621	.724	.8192	.8383	.743	.5144	.4954
24	.6668	.724	.743	.8002	.7621	.724	.5144
Max	.7811	.8954	.9145	.9526	.8002	.724	.5335
Min	.4572	.4572	.4001	.6478	.3429	.0953	.2667
Avg	.5906	.6875	.7232	.7970	.6677	.4327	.3885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 206 / 11 KV PUNARVASAN FFEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.3429	.362	.362	.3048	.3239	.3048
2	.2477	.3429	.362	.362	.3048	.3048	.3048
3	.2667	.3239	.362	.362	.3239	.3048	.2858
4	.2667	.3048	.362	.3429	.3429	.3048	.2667
5	.3048	.2477	.3048	.3048	.3429	.2858	.2667
6	.2667	.2286	.2667	.2667	.2667	.2858	.2477
7	.2096	.1905	.2286	.2286	.2096	.2477	.2477
8	.1905	.2286	.381	.362		.2286	.2858
9	.1715		.3048	.381	.381	.2286	.2096
10	.1715	.2667	.4001	.3429	.362	.1715	.1905
11	.1905	.3239	.4191	.3048	.3239	.2096	.1905
12	.1905	.3048	.381	.362	.3429	.2096	.1524
13	.2286	.4001	.381	.4001	.3429	.2096	.1524
14	.2286	.362	.381	.362	.3429	.1715	.1715
15	.2286	.362	.3429	.3429	.3048	.1524	.1715
16	.1524	.2096	.1905	.1905	.1524	.1524	
17	.1524	.1905	.1715	.1715	.1524	.1524	.1334
18	.1524	.1905	.1334	.1524	.1524	.1524	
19	.2286	.2667	.1905	.1905	.2858	.2286	.1143
20	.3048	.2477	.3429	.3429	.3048	.3048	.3048
21	.3429	.4001	.381	.381	.3429	.3239	.3048
22	.362	.5335	.4001	.381	.362	.3239	.3048
23	.3429	.5335	.381	.362	.362	.3048	.2858
24	.2858	.3429	.362	.381	.3429	.3429	.3048
Max	.362	.5335	.4191	.4001	.381	.3429	.3048
Min	.1524	.1905	.1334	.1524	.1524	.1524	.1143
Avg	.2389	.3106	.3247	.3183	.3023	.2469	.2364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 201 / 11 KV VELTUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0682	1.0631	1.2003	1.17	1.2378	.7973	.7265
2	1.0682	.9431	1.2003	1.17	1.2378	.7619	.7265
3	1.0513	.964	1.2003	1.17	1.2209	.7343	.7087
4	1.0343	.8764	1.1831	1.153	1.2039	.7164	.7087
5	1.0174	.8505	1.1317	1.1191	1.1191	.6805	.7164
6	.8478	.7973	.9602	.9665	.9326	.6805	.567
7	.6952	.8063	.8987	.8478	.9665	.6447	.5493
8	.7291	.9259	1.046	.9556	.9556	.5973	
9	.763	.9835	1.1022	1.0562	.9945	.5973	.4835
10	.6706	1.0059	1.1361	1.1065	1.0277	.5973	.5249
11	.6203	1.0442	1.1768	1.0852	.9945	.5731	.4191
12	.6203	.9448	1.1768	1.0059	1.0395	.5487	.4527
13	.7373	1.1603	1.094	1.073	1.0562	.3361	.4359
14	.6783	1.1437	1.1934	1.1065	.9945	.3475	.4862
15	.6613	1.1105	1.094	1.0774	.9614	.2561	.4527
16	.8215	1.0174	.7712	1.1361	.9282		.6379
17	.78	.7122	1.0985	1.0852	.9259	.6161	.6733
18	.7461	.763	1.0454	1.0682	.8669	.5731	.8939
19	.9431	.9156	1.1694	1.1963	.8764		1.0985
20	1.0288	1.1361	1.0513	1.1145	.8764	.9313	1.2934
21	1.0802	1.2431	1.2003	1.2742	.9991	.8954	1.2934
22	1.17	1.2266	1.2346	1.291	1.0631	.9328	1.2048
23	1.153	1.1768	1.2003	1.2574	1.0277	.8779	1.2403
24	1.0802	1.1191	1.2003	1.1831	1.2239		.8688
Max	1.17	1.2431	1.2346	1.291	1.2378	.9328	1.2934
Min	.6203	.7122	.7712	.8478	.8669	.2561	.4191
Avg	.8777	.9971	1.1152	1.1112	1.0304	.6522	.7462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 202 / 11 KV BHIWKUND

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6379	.6344	.7796	.7522	.8954	.6379	.394
2	.6379	.6001	.7701	.7522	.8954	.5847	.3761
3	.6379	.5258	.7783	.7522	.8775	.5373	.394
4	.6135	.4908	.7701	.7522	.8596	.5373	.394
5	.6135	.443	.7602	.7164	.788	.5014	.3582
6	.5304	.4075	.5847	.5731	.5731	.5014	.3045
7	.4344	.4382	.5731	.5552	.5847	.3582	.2865
8	.3641	.5316	.5316		.7127		.2896
9	.3772	.5765	.6952	.7537	.7459		.2865
10	.4024	.6203	.7202	.6718	.7625		.2328
11	.3856	.663	.7209	.6882	.7459		.1989
12	.3856	.6203	.7865	.6299	.7545		.1989
13	.3772	.6443	.7701	.6796	.7545		.2155
14	.3391	.6133	.7373	.7127	.6962		.2155
15	.3391	.6104	.6882	.7127	.6464		.2155
16	.2347	.6268	.591	.6516	.4973	.2033	.2172
17	.2883	.6036	.591	.6516	.5144	.2801	.2353
18	.373	.6219	.5552	.6516	.5201	.2686	.2172
19	.463	.6401	.4835	.788	.5959		.2896
20	.6001	.788	.7164	.8505	.631	.3582	.362
21	.6344	.7973	.788	.8939	.6836	.3761	.3439
22	.6613	.7975	.8059	.9015	.7265	.415	.3045
23	.6443	.7796	.7701	.9134	.6733	.394	.2865
24	.6447	.6274	.788	.7522	.8859	.6733	.4024
Max	.6613	.7975	.8059	.9134	.8954	.6733	.4024
Min	.2347	.4075	.4835	.5552	.4973	.2033	.1989
Avg	.4842	.6126	.6981	.7285	.7092	.4418	.2925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 203 / 11 KV CHIKHALI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5552	.5144	.5731	.567	.6516	.5316	.3403
2	.5552	.463	.5731	.567	.6516	.4784	.3475
3		.4382	.5973	.567	.6516	.4477	.3326
4	.5138	.4031	.5731	.567	.6036	.4119	.3292
5	.4961	.3898	.5552	.5487	.543	.3761	.3292
6	.3224	.3544	.394	.3841	.4163	.3761	.2686
7	.2896	.3506	.3841	.3841	.394	.3582	.2149
8	.2686	.3429	.463	.4409	.4191	.2279	.2012
9	.2454	.39	.5087	.4748	.4024		.2195
10		.4527	.5426	.4917	.39		.197
11	.3353	.4475	.5596	.4917	.4144		.2035
12	.285	.4694	.5765	.4409	.4191	.0739	.1526
13	.2915	.4578	.5596	.4578	.4359	.0914	.1865
14	.3052	.4578	.5256	.4694	.3978	.0924	.1865
15	.3052	.4239	.5487	.407	.3978	.0924	.1865
16	.2515	.407	.3292	.3944	.3481	.0934	.1829
17	.2543	.4435	.3292	.3814	.3258	.1086	.2195
18	.2543	.3761	.3475	.3772	.2947	.0914	.2172
19	.4287	.4207	.4024	.5609	.4382		.3475
20	.4973	.5914	.567	.6379	.5083	.3582	.4572
21	.5487	.6268	.6219	.6733	.5609	.3658	.4938
22	.5765	.6268	.6401	.6661	.5847	.3403	.4572
23	.5426	.6036	.6219	.6485	.567	.3475	.439
24	.5552	.5256	.5973	.567	.6379	.567	.3439
Max	.5765	.6268	.6401	.6733	.6516	.567	.4938
Min	.2454	.3429	.3292	.3772	.2947	.0739	.1526
Avg	.3944	.4574	.5163	.5069	.4772	.2915	.2856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 201 / 11KV LANJALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0762	.0901	.1143	.0901	.0953	.0953
2	.1143	.0762	.0901	.0953	.0901	.0953	.0953
3	.1143	.0953	.0901	.0953	.0901	.0762	.0953
4	.1143	.0953	.0901	.0953	.0901	.0762	.0953
5	.1143	.0953	.0901	.1143	.0901	.0762	.0953
6	.0953	.0953	.0901	.0953	.0901	.0762	.0762
7	.0953	.1143	.0721	.0953	.1262	.0762	.0953
8	.0953	.1143	.0901	.1143	.1262	.1143	.0762
9	.1143	.1143	.1081	.1143	.1081	.0762	.0762
10	.0762	.1143	.1143	.0953	.1143	.0762	.0953
11	.1143	.108	.1334	.1081	.1143	.0762	.0894
12	.1334	.126	.1524	.1081	.1334	.0953	.0894
13	.1334	.1081	.1334	.1442	.1334	.0953	.0715
14	.1334	.1081	.1334	.1442	.1143	.0762	.0715
15	.1334	.0901	.1143	.1442	.1143	.0762	.0894
16	.0953	.0693	.1143	.0901	.0762	.0762	.0894
17	.0762	.0693	.0953	.0901	.0762	.0762	.0715
18	.0762	.0541	.0762	.0901	.0953	.0953	.0715
19	.0953	.0721	.0953	.0901	.0953	.0953	.0715
20	.0953	.0901	.1143	.1081	.0953	.0953	.0894
21	.0953	.0901	.0953	.0901	.0953	.0953	.0894
22	.0953	.09	.0953	.1081	.0953	.0953	.0894
23	.0953	.0901	.0953	.1081	.0762	.0953	.0894
24	.1334	.0762	.0901	.1143	.0901	.0762	.0953
Max	.1334	.126	.1524	.1442	.1334	.1143	.0953
Min	.0762	.0541	.0721	.0901	.0762	.0762	.0715
Avg	.1072	.0930	.1026	.1070	.1008	.0857	.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 202 / 11 KV SASEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.381	.2529	.381	.3372	.381	.381
2	.2286	.381	.2529	.381	.3372	.4001	.381
3	.2286	.362	.2529	.381	.3372	.381	.381
4	.2286	.3429	.2529	.3429	.3372		.3429
5	.1905	.3429	.2361	.3429	.3035		.3429
6	.1905	.2667	.2361	.3429	.2698		.2858
7	.1715	.2667	.2529	.2858	.3204		.2858
8	.1524	.2858	.2698	.381	.4049		.2858
9		.2858	.2591	.4572	.4384	.0572	.2858
10		.2858	.3239	.4572	.4954	.0953	.2477
11		.2698	.381		.4954		.1262
12	.1905	.2698	.4763	.0337	.5144		.1104
13	.1524	.2698	.381	.4215	.4763		
14	.1524	.2866	.381		.4572		.1262
15	.2286	.2866	.381	.3878	.4763		.142
16	.3048	.1855	.3429	.3878	.2096		.1437
17	.3048	.1517	.381	.3709	.1905	.1524	.1262
18	.2858	.1134	.2858	.3372	.1905	.1905	.1104
19	.3429	.1517	.2286	.3372	.2858	.2667	.1104
20	.4001	.2529	.2858	.4215	.3429	.2858	.1104
21		.2698	.3048	.4072	.381	.3429	.1578
22	.4382	.2698	.3048	.4047	.4001	.381	.1578
23	.4191	.2429	.3048	.3887	.381	.381	.2682
24	.2667	.4001	.2529	.3048	.3372	.381	.3429
Max	.4382	.4001	.4763	.4572	.5144	.4001	.381
Min	.1524	.1134	.2286	.0337	.1905	.0572	.1104
Avg	.2553	.2759	.3034	.3616	.3633	.2843	.2284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 203 / 11 KV KHAPRI-MANGLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.052	.0953	.052	.0572	.0572
2	.0762	.0572	.052	.0953	.052	.0572	.0572
3	.0762	.0572	.052	.0762	.052	.0381	.0572
4	.0762	.0572	.052	.0762	.052	.0381	.0572
5	.0572	.0572	.052	.0762	.0525	.0381	.0381
6	.0572	.0572	.052	.0762	.052	.0381	.0381
7	.0381	.0762	.052	.0572	.052	.0381	.0572
8	.0381	.0762	.0693	.0762	.0693	.0572	.0572
9	.0381	.0762	.0693	.0953	.0693	.0381	.0572
10		.0572	.0762	.0572	.0762	.0381	.0381
11	.0572	.052	.0953	.0693	.0762	.0381	.0337
12	.0572	.052	.0953	.0693	.0953	.0381	.0337
13	.0381	.0693	.0953	.0693	.0572	.0381	.0337
14	.0381	.0693	.0953	.0693	.0572	.0381	.0337
15	.0572	.052	.0762	.0693	.0381	.0381	.0337
16	.0572	.052	.0953	.0693	.0381	.0381	.0337
17	.0572	.052	.0953	.0693	.0381	.0381	.0506
18	.0572	.052	.0762	.0693	.0381	.0381	.0473
19	.0762	.052	.0572	.052	.0762	.0381	.0506
20	.0762	.0693	.0572	.0693	.0953	.0381	.0674
21	.0762	.0721	.0572	.0693	.0572	.0381	.0674
22	.0572	.0721	.0953	.0693	.0572	.0381	.0674
23	.0572	.052	.0953	.052	.0381	.0572	.0506
24	.0762	.0572	.052	.0762	.0693	.0572	.0381
Max	.0762	.0762	.0953	.0953	.0953	.0572	.0674
Min	.0381	.052	.052	.052	.0381	.0381	.0337
Avg	.0597	.0606	.0716	.0718	.0588	.0421	.0482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 201 / 11 kV ADAM FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3601	.381	.3429	.3429	.2572
2	.3601	.3086	.381	.3048	.3086	.2572
3	.3601	.2572	.381	.2667	.3086	.2229
4	.3429	.2572	.381	.2667	.3086	.2229
5	.3086	.2058	.3239	.2286	.2743	.2058
6	.2572	.2058	.2477	.2286	.2572	.1715
7	.2058	.1543	.2096	.2096	.2058	.1715
8	.2743	.4287	.4001	.381		.1372
9	.3258	.3239	.5144	.5525	.0857	.1524
10	.3944	.4954	.5906		.12	.1524
11	.4287	.5335	.6478		.1372	.1524
12	.4973	.5716	.6097		.1886	.1524
13	.463	.5906	.6097	.6097	.1715	.1524
14	.4287	.5906	.5906	.5906	.1372	.1524
15	.4458	.5906	.5906	.5906	.1543	.1524
16	.2743	.2858	.2858	.2858	.1543	.1334
17	.2401	.3048	.2286	.2286	.1372	.1334
18	.2401	.3429	.2477	.2477	.1372	.1524
19	.2401	.3429	.2286	.2286	.1886	.2286
20	.2743	.3429	.2858	.2858	.2572	.2477
21	.3086	.381	.4191	.4191	.2915	.2667
22	.3944	.4191	.4191	.4191	.2743	.2667
23	.3772	.4001	.4001	.4001	.2743	.2667
24	.3601	.3772	.381	.4001	.3601	.2743
Max	.4973	.5906	.6478	.6097	.3601	.2743
Min	.2058	.1543	.2096	.2096	.0857	.1334
Avg	.3401	.3779	.4064	.3565	.2207	.1951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 202 / 11 kV MAJARI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3772	.4382	.4191	.3772	.2058
2	.3086	.3601	.4382	.4191	.3772	.2058
3	.3086	.3429	.4382	.4382	.3601	.1715
4	.2915	.3429	.4382	.4382	.3601	.1715
5	.2743	.3429	.4191	.4382	.3601	.1715
6	.2572	.3429	.381	.4572	.3772	.1715
7	.2401	.3944	.4191	.5525	.3086	.1715
8	.2401	.4287		.1715	.2572	.1543
9	.3086	.4191		.5335		.1524
10	.2572	.4572				.1715
11	.2743	.4954			.2058	.1524
12	.3086	.5716			.2401	.1524
13	.3429	.5716	.5716		.2401	.1524
14	.3601	.5525	.5906		.1543	.1524
15	.3601	.5335	.5906			.0762
16	.3086	.4191	.5716			.1143
17	.3772	.4191	.5906			.1524
18	.3429	.4191	.6097		.1543	.1715
19	.3086	.4382	.5716		.1886	.2096
20	.3086	.4382	.5716		.2058	.2286
21	.3086	.4572	.4763		.2229	
22	.3601	.4572	.4763		.2058	.3048
23	.3772	.4572	.4763		.2058	.3048
24	.3086	.3772	.4382	.4191	.4115	.2058
Max	.3772	.5716	.6097	.5525	.4115	.3048
Min	.2401	.3429	.381	.1715	.1543	.0762
Avg	.3101	.4340	.5004	.4287	.2744	.1793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 201 / 11 KV SIRSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0802	1.1025	1.07	1.1265	1.07	.3378
2	1.0734	1.0734	1.0923	1.0048	.9448	1.0631	.3429
3	.9962	1.0545	1.0717	.9208	1.1608	1.0305	.3515
4	.499	.5144	.5658	.8813	1.0322	1.0014	.3481
5	.5093	.5041	.5041	.811	.8933	.9208	.3395
6	.523	.5658	.5538	.6979	.7493	.4595	.3395
7	.5316	.6293	.7973		.691	.6619	.3052
8	.6379	.7785	.8488	.5298	.5161	.4904	.3206
9	.7785	.8008	.7596	.5933	.5658	.4595	
10	.6413	.7425	.7647	.631	.547	.4664	.2949
11	.6584	.7768	.7716	.751	.6173		.2658
12	.6499	.7853	.7082	1.0802	.799	.5796	.2675
13	.6893	.8179	.8368		1.0408	.6739	.2418
14	.7425	.8419	.9019	.8813	.8573	.4167	.2435
15	.6293	.8436	.9036	.8299	.5676	.415	.2281
16	.5847	.7099	.8145	.571	.5538	.3807	.2075
17	.619	.6139	.6241	.9259	.811	.3498	.4492
18	.6653	.4938	.5624	.9328	.7253	.3498	
19	.6687	.6241	.6516	.7133	.6087	.3618	.6756
20	1.0099	1.0374	1.0099	.691	.9019		.823
21	1.1608	1.2483	1.1608	.6687	1.046	.3687	.8728
22	1.2294	1.2277	1.2311	.6584	1.142	.3652	.8608
23	1.1248	1.1814		1.178	1.0957	.3447	.8042
24	1.1677	1.0923	1.1265	1.1248	1.1403		.3395
Max	1.2294	1.2483	1.2311	1.178	1.1608	1.07	.8728
Min	.499	.4938	.5041	.5298	.5161	.3447	.2075
Avg	.7884	.8349	.8419	.8248	.8389	.5824	.4209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 202 / 11 kV Mahalgao

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7185	.8831	.7785	.6379	.9174	.7425	.3549
2	.6859	.8728	.7665	.5984	.9139	.7219	.3498
3	.6413	.8436	.727	.5521	.9208	.6807	.3361
4	.7047	.7013	.7819	.5247	.751	.6053	.3344
5	.7082	.7322	.8385	.4681	.5813	.5333	.3206
6	.7099	.8419	.9156	.3841	.511	.3292	.2949
7	.7167	.9516	1.0048		.3978	.3944	.3035
8	.775	1.0974	1.2449	.3361	.3909	.3721	.3069
9	.7785	1.1968	1.2363	.3858	.4098	.3515	.2778
10	.7905	1.0923	1.25	.4098	.3635	.3584	.2606
11	.8676	1.0768	1.2329	.4407	.4338		.2366
12	.4544	.5058	.5247	1.25	1.0717	.6619	.2229
13	.5058	.5556	.5641		1.25	.8299	.2143
14	.5161	.5607	.5933	.6739	1.13		.2281
15	.4235	.5521	.5778	.6756	.9054	.3172	.2229
16	.4201	.4715	.5213	1.1711	.8985		.2212
17	.439	.4167	.3978	1.262	.9568	.3378	.3635
18	.4527	.3275	.3155	1.1317	.9739	.3481	
19	.4664	.4921	.4372	1.0048	.8745	.3669	.7013
20	.9191	.7459	.7064	1.0288	.6619	.4287	.7785
21	.9551	.9225	.8162	.9997	.787	.4081	.8282
22	.9825	.8985	.7699	.9414	.8265	.3772	.775
23	.9465	.8436		.9276	.7836	.3635	.7562
24	.7459	.8796	.8213	.6876	.9054		.3601
Max	.9825	1.1968	1.25	1.262	1.25	.8299	.8282
Min	.4201	.3275	.3155	.3361	.3635	.3172	.2143
Avg	.6802	.7692	.7749	.7496	.7757	.4764	.3934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 402 / 33KV INCOMER(sirsi Stn)

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844		1.5792	1.7798	1.5689	1.5123	.9465
2	1.5123	1.4918	1.5123	1.6101	1.6204	1.4918	.9465
3	1.4455	1.4763	1.4712	1.4506	1.5741	1.4712	.9414
4	1.4249	1.4352	1.4969	1.3323	1.4661	1.4095	.9259
5	1.4352	1.4403	1.5792	1.1008	1.2963	1.3426	.9105
6	1.4455	1.6204	1.7078	.8848	.9928	1.0751	.8848
7	1.4506	1.8056	1.9239		.7305	.6893	.8333
8	1.6049	2.1451	2.3148	.7305	.7562	.6842	.8693
9	1.9239	2.1914	2.1811	.7922	.7407	.6533	.8591
10	1.6358	2.1914	2.1914	.8848	.7202	.6533	.7922
11	1.7078	2.0165	2.1554	.8488	.751		.7613
12	.7922	1.0237	1.0957	2.4177	2.1451	1.3683	.7459
13	.9002	1.1368	1.1626		2.4537	1.6564	.715
14	.8951	1.1574	1.2397	1.6101	2.1914	.5864	.7305
15	.7665	1.178	1.2037	1.0854	1.8416	.9722	.715
16	.7613	.9928	1.0597	2.0113	1.6307	.5195	.6996
17	.8128	.8693	.8899	2.4589	1.9239	.8436	.6327
18	.8796	.715	.6893	2.2274	1.8827	.9105	
19	.9259	1.0031	.9311	1.9444	1.6615	.9362	1.0905
20	1.4866	1.5021	1.5072	1.9496	1.3375		1.3169
21	1.6821	1.7901	1.7798	1.8879	1.5381	1.07	1.3837
22	1.6821	1.7593	1.7438	1.8519	1.6152	.9877	1.358
23	1.5586	1.6512		1.6461	1.5792	.9516	1.286
24	1.6204	1.5432	1.6307	1.6821	1.5638	1.5072	.9414
Max	1.9239	2.1914	2.3148	2.4589	2.4537	1.6564	1.3837
Min	.7613	.715	.6893	.7305	.7202	.5195	.6327
Avg	1.3306	1.4842	1.5238	1.5540	1.4826	1.0587	.9255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 201 / 11 kV Pachgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4344	.4525	.4706	.4344	.4163	.3439
2	.4163	.4163	.4525	.4525	.4344		.3439
3	.3982	.4163	.4525	.4525	.4344	.4344	.3258
4	.3801	.4163	.4344	.4706	.4252	.4163	.3077
5	.362	.3982	.4163	.4344	.4344	.3801	.2896
6	.362	.3439	.3982	.3801	.3439	.3439	.3077
7	.3439	.3077	.3801	.362	.3439	.3439	.2715
8	.2715	.3012	.362	.4163	.3801	.3258	.2534
9	.362	.3801	.4344	.4163	.4163	.3439	.2715
10	.3439	.4961	.4163	.4338	.3982	.3258	.2715
11	.3077	.3801	.4525	.4525	.3982	.2896	.2534
12	.2896	.3982	.4706	.4344	.3982	.3258	.2353
13	.2896	.3982	.4525	.4525	.4163		.2172
14	.3077	.4163	.4525	.4887	.3982		.181
15	.3439	.3982	.4525	.4525	.362		.2172
16	.3258	.4344	.4706	.4163	.3982		.2353
17	.3077	.4525	.4163	.4163	.4344	.1991	.2172
18		.3982	.3801	.2534	.3982	.2658	.2353
19	.3801	.4344	.3982	.3982	.362	.3258	.2715
20	.4163	.4706	.4163	.4344	.3982	.362	.3439
21	.4525	.4525	.4706	.4706	.4163	.362	.3258
22	.4525	.4887	.4887	.4887	.4344	.362	.3077
23	.4163	.4706	.4887	.4887	.4344	.3439	.3077
24	.4344	.4163	.4525	.4706	.4706	.4344	.3439
Max	.4525	.4961	.4887	.4887	.4706	.4344	.3439
Min	.2715	.3012	.362	.2534	.3439	.1991	.181
Avg	.3651	.4133	.4359	.4336	.4069	.3474	.2783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 202 / 11 kV Surgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.6036	.5281	.6036	.6413	.5847	.4904
2	.4904	.4961	.5281	.5611	.6224		.4607
3	.4527	.5281	.5281	.543	.6224	.5847	.4715
4	.4338	.5093	.4715	.5847	.6224	.5658	.4527
5	.415	.4904	.4338	.5658	.6036	.5093	.415
6	.3961	.3961	.415	.5093	.547	.4527	.3961
7	.2829	.3584	.415	.4527	.547	.4527	.3395
8	.2641	.3206	.4338	.3395	.6413	.415	.3018
9	.2641	.3772	.4527	.3258	.6036	.4338	.3018
10	.3018	.415	.3395	.362	.6224	.3961	.3206
11		.415	.3982	.3584	.6224	.2829	.3018
12	.2829	.4527	.4715	.3772	.6224	.2452	.2641
13		.4715	.4344	.4715	.6036		
14	.3584	.4715	.4904	.6224	.6224		.2452
15	.415	.5281	.5658	.6602	.5093		.2641
16	.3584	.4338	.5068	.6413	.5093		
17	.3018	.4527	.5093	.6224	.5093	.2715	
18		.4715	.4887	.6413	.4715	.3077	
19	.547	.3961	.4904	.6979	.4715	.415	
20	.6036	.547	.5847	.7356	.5658	.4607	.3944
21	.6413	.5658	.6224	.7167	.6036	.5281	.5658
22	.6413	.5658	.6413		.6413	.5281	.4338
23	.6036	.5281	.6413	.6413	.6224	.5093	.415
24	.5093	.6036	.5281	.6036	.6413	.6036	.4904
Max	.6413	.6036	.6413	.7356	.6413	.6036	.5658
Min	.2641	.3206	.3395	.3258	.4715	.2452	.2452
Avg	.4311	.4749	.4966	.5494	.5871	.4498	.3855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 203 / 11 KV Jassal Industrial
champa Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.3121	.743	.6602	.8676	.3763	.061
2	.6908	.2934	.6224	.4191	.8215		.0335
3	.7545	.208	.6219	.7392	.8215	.2949	.0389
4	.7133	.2031	.6697	.9054	.8962	.2324	.0427
5	.6468	.2305	.6268	.6249	.9431	.2629	.0335
6	.6485	.2599	.3475	.1036	.7356	.4656	.0305
7	.0427	.5144	.1286	.0793	.4904	.2622	.0213
8	.3725	.5014	.1337	.16	.2591	.306	.2241
9	.7023	.5281	.1189	.3772	.3982	.3185	.0549
10	.7282	.5175	.4209	.924	.5731	.1879	.0686
11	.8962	.298	.9335	1.0374			.056
12	1.2136	.8573	.9808	.788	.8573	.0914	.3086
13	1.1203	.5975	.811	.7392	.8488		.4066
14	.3395	.4207		.4066	.4534		.6468
15	.8962	.811		1.0669	1.0751		1.0082
16	.547	1.0185	.5228	1.0479	.7922		.8413
17	.3921	.9619	.9526	1.0098	.3772	.0372	.8316
18	.3361	.3018	.5121	1.2071	.3761	.0314	
19	.7922	.3788	.2286	.3334	.5611	.0429	.7042
20	.4251	.3001	.5973	.1303	.1894		.5658
21	.6036	.2572	.2972	.2824	.4904	.04	.1069
22	.8573	.7282	.5041	.4784	.5975	.0429	.2785
23	.6602	.6908	.3241	.5316	.8962	.0945	.5093
24	.4294	.6722	.7282	.4668	.9054	1.0269	.1097
Max	1.2136	1.0185	.9808	1.2071	1.0751	1.0269	1.0082
Min	.0427	.2031	.1189	.0793	.1894	.0314	.0213
Avg	.6492	.4943	.5375	.6049	.6620	.2420	.3036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 204 / 11 KV CHAMPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3544	.3898	.4784	.4252	.4075	.1949
2	.3544	.3721	.3898	.4607	.4075		.2126
3	.3544	.3544	.3721	.5138	.4075	.4075	.1949
4	.3366	.3544	.3544	.4607	.4075		.1772
5	.3189	.3366	.3544	.4607	.3898		.1417
6	.3189	.3012	.3544	.4252	.4075		.1595
7	.2658	.3366	.3366	.4607	.4607		.1772
8	.1949	.3544	.4607	.6024	.567	.2481	.2126
9	.2481		.443	.6201	.5493	.3012	.1772
10	.3898	.4252	.5316	.6024	.5493	.3189	.1772
11	.3898	.443	.6201	.567	.6201	.3012	.1417
12	.415	.4075	.567	.4607	.5847	.3012	.0886
13	.415	.4961	.5792	.4607	.567		.1063
14	.4338		.5847	.4961	.567		.2126
15	.3366	.443	.5847	.567	.5138		.2303
16	.415	.4961	.5792	.567	.2481		.2126
17	.415	.2481	.5316	.567	.2835	.1772	.1417
18	.415	.3012	.567	.5138	.3898	.1949	.2303
19	.3721	.3721	.5316	.5493	.4075	.1949	.2481
20	.4252	.4784	.567	.567	.4961	.2303	.2658
21	.4252	.4784	.5493	.5493	.4607	.2126	.2835
22	.4075	.443	.5316	.4607	.443	.2126	.2481
23	.3898	.4252	.4961	.443	.443	.2126	.2481
24	.3544	.3544	.3898	.4784	.4252	.4075	.1949
Max	.4338	.4961	.6201	.6201	.6201	.4075	.2835
Min	.1949	.2481	.3366	.4252	.2481	.1772	.0886
Avg	.3644	.3898	.4861	.5138	.4592	.2752	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 205 / 11 KV PACHGAON II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.2637	1.226	1.358	1.3769	1.4335	1.1317
2	1.094	1.226	1.358	1.3203	1.3203		1.1317
3	1.0562	1.2637	1.2637	1.1946	1.3203	1.4146	
4	1.0751	1.2826	1.3203	1.226	1.4146	1.4146	
5	1.0374	1.1694	1.3392	1.226	1.5278	1.3203	
6	1.0751	1.1694	1.3203	1.2449	1.4146	1.4146	
7	1.6032	1.4523	1.6221	1.1694	1.5089	1.3203	
8	2.2068	1.6975	2.1879	1.6975	1.6975	1.2826	
9	1.4712	2.2634	2.3765	2.2634	2.3765	1.4712	.0377
10	.9431	2.584	2.6029	2.9235	2.1691		.3584
11	2.5274	1.905	2.4897	2.452	2.0182	1.2637	1.094
12	1.6221	2.5463	3.2253	2.4897	2.2822	1.1694	1.1317
13	1.226	1.9239	2.5463	2.0748	2.4897		2.1691
14	1.3203	1.905	2.452	1.8296	1.9993		1.4712
15	2.3011	2.3577	2.3388	2.7161	2.1125		1.7918
16	2.8669	2.8481	3.3008	3.0178	3.3008		2.1691
17		2.452	2.3765	2.6406	2.3388	1.0562	1.4146
18		2.3765	1.9805	2.9047	2.6406	.9431	1.2637
19	1.6975	1.6598	1.9616	1.2826	1.773	1.0374	1.3203
20	1.4523	1.5278	1.2826	1.2449	1.4146	1.2637	1.226
21	1.3957	1.358	1.4146	1.3769	1.3203	1.2449	1.226
22	1.5844	1.4146	1.3392	1.4146	1.4146	1.1317	1.773
23	1.4146	1.2637	1.3203	1.4146	1.4712	1.1506	1.2449
24	1.1694	1.4146	1.4335	1.2826	1.4146	1.6032	1.1317
Max	2.8669	2.8481	3.3008	3.0178	3.3008	1.6032	2.1691
Min	.9431	1.1694	1.226	1.1694	1.3203	.9431	.0377
Avg	1.5106	1.7635	1.9199	1.8235	1.8382	1.2742	1.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 206 / 11 KV CHAMPA II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	1.0185	1.3769	.8865	1.1317	1.1883	.6224
2	.7733	1.0751	.9619	1.2826	1.0374		.6287
3	.7545	1.1694	1.0751	1.1317	1.1317		.6036
4	.7167	1.1317	1.0751	.811	1.0479		.5847
5	.8488	.9431	1.0374	.8865	.7356		.6036
6	.9997	1.0185	1.0751	.8488	1.0185		.6602
7	.1886	1.3392	.9997	.9054	.9619		.5847
8	.2452	1.094	1.0751	.9808	1.1694	.1509	.7733
9	.4715	1.4523	1.3203	1.9805	1.8673		.6413
10	1.1317	1.9805	1.6221	2.5463	2.6972	.6036	.679
11	1.6409	1.905	1.6032	3.3762	2.1502	.9242	
12	2.4177	2.584		3.3385	2.5463	.7545	.7545
13	2.4143	2.3388	2.1691	2.8292	2.7915		.9054
14	1.9993	1.6598	1.905	1.5466	1.3769		1.2637
15	1.226	1.8861	1.6221	2.1879	2.452		1.1317
16	2.0936	2.2068	1.7918	2.5652	1.7918		1.2637
17	2.3765	2.037	1.7353	2.584	1.8484	.4904	.5658
18		2.2445	1.7164	2.6972	2.32	.6413	.2452
19	1.7164	1.3203	1.358	1.2449	1.3957	.5093	.3018
20	1.5089	.9431	1.0185	.9997	.9619	.6413	.3584
21	.9431	1.4523	.811	.9054	.9808	.6036	.7167
22	1.3203	1.094	1.0185	1.2826	1.1506	.6224	.7545
23	1.226	1.1506	1.1317	1.1317	1.5089	.6413	.7922
24	.9431	1.2826	1.3957	1.0751	.9431	.9619	.6224
Max	2.4177	2.584	2.1691	3.3762	2.7915	1.1883	1.2637
Min	.1886	.9431	.811	.811	.7356	.1509	.2452
Avg	1.2548	1.5136	1.3433	1.6677	1.5424	.6718	.6982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 207 / 11KV Anand Mohta

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1524	.1524	.1715	.1524	.1334
2	.1334	.1143	.1334	.1524	.1715		.1334
3	.1334	.1143	.1524	.1524	.1715	.1524	.1334
4	.1143	.0953	.1524	.1524	.1715	.1715	.1334
5	.1143	.1143	.1334	.1715	.1524	.1524	.1334
6	.0953	.1143	.1334	.1524	.1334	.1334	.1524
7	.0953	.1143	.1524	.1524	.1524	.1524	.2286
8	.0953	.1334	.1524	.1715	.1524	.1524	.2286
9	.1143	.1334	.1334	.1524	.1524	.1524	.2286
10	.1143	.1143	.1334	.1524	.1524	.1524	.2286
11	.1143	.1334	.1715	.1334	.1524	.1524	.2096
12	.1334	.1524	.1715	.1334	.1524	.1524	.1334
13	.0953	.1524	.1524	.1334	.1715		.1334
14	.1143	.1524	.1524	.1334	.1524		.1143
15	.1334	.1524	.1524	.1524	.1524		.1334
16	.1143	.1524	.1715	.1524	.1524		.1524
17	.0953	.1715	.1524	.1334	.1715	.1334	.1524
18		.1524	.1334	.1524	.1524	.1524	
19	.1524	.1334	.1715	.1524	.1524	.1334	.1334
20	.1524	.1524	.1524	.1334	.1334	.1524	.1334
21	.1715	.1524	.1715	.1715	.1524	.1334	.1334
22	.1715	.1524	.1524	.1524	.1524	.1334	.1334
23	.1715	.1715	.1715	.1524	.1715	.1524	.1334
24	.1334	.1143	.1524	.1524	.1524	.1524	.1334
Max	.1715	.1715	.1715	.1715	.1715	.1715	.2286
Min	.0953	.0953	.1334	.1334	.1334	.1334	.1143
Avg	.1251	.1357	.1524	.1500	.1564	.1484	.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 403 / 33KV DONGARGAO(KUHI SDN)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544		.5041	.5658	.3921	.3326
2		.5487	.3361	.4481	.5487	.4481	.3361
3		.5487		.4435	.5487		.3326
4		.5093		.4207	.4527		.3326
5		.5093		.4207	.5093		.2801
6		.3395		.3258	.3961		
7		.3326		.3721	.3395		
8		.3761	.3841	.4801	.5093		
9			.3601		.5658		
10		.3761	.3681	.5716	.7356		
11		.3258	.4733	.6224	.5658		
12		.3721	.4344	.5658	.5144		
13		.3258	.4784	.5658	.5316		
14		.3292	.4481		.5041		
15		.3258	.4481		.4252		
16			.4298	.5093			
17			.4207	.4527			
18				.3961			
19	.3961			.4887			
20	.5658		.3361	.6224	.3395	.3224	
21	.5658	.3395	.3361	.6224	.3921	.3921	
22	.6099	.3395	.4481	.6224	.3921	.4481	.3961
23		.3361	.4784	.6224	.3921	.3224	.3395
24		.5601	.3361	.5041	.5487	.3921	.3189
Max	.6099	.5601	.4784	.6224	.7356	.4481	.3961
Min	.3961	.3258	.3361	.3258	.3395	.3224	.2801
Avg	.5344	.4083	.4073	.5039	.4889	.3882	.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 405 / 33 kv Vidhi alloy pvt ltd. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.7541	1.8107	1.8673	1.9239	2.1502	1.7541
2	1.8107	1.7541	1.9239	1.4712	1.9805	1.8107	1.5844
3	1.8673	1.5844	1.8673	1.6975	1.9805	1.9239	1.5844
4	1.7541	1.6975	1.9805	1.5844	2.0936	1.0185	1.6975
5	1.8107	1.8107	1.8107	1.7541	2.037	1.8107	1.5278
6	1.8107	1.8673	1.9805	1.8673	1.7541	1.8673	1.4146
7	1.8673	1.9239	1.5844	1.5278	1.6975	1.8107	1.5278
8	1.7541	1.8107	1.9239	1.8673	1.8673	1.8107	1.6409
9	1.4146	1.8107	1.5844	2.1502	1.8673	1.9239	1.6975
10	1.5278	1.8107	1.4712	1.9805	1.3014	1.7541	1.4712
11	1.6975	1.5844	1.7541	1.8673	1.8673	1.5844	1.6975
12	1.8107	1.9239	1.6975	2.0936	1.8673	1.7741	1.5844
13	1.5844	1.9239	1.8107		1.9239	1.8673	1.6975
14	1.6975	1.9805	1.8673	1.8673	1.7541	1.9239	1.7541
15	1.4712	1.7541	1.9805	1.8107	1.8107	1.7541	.0566
16	1.6975	1.9239	1.5844	1.8861	1.9805	.7356	.5658
17	1.2449	2.037	1.6975	1.4712	1.9239	1.9239	1.5278
18	1.4146	2.037	1.7541	1.9805	1.7541	.5658	1.6409
19	1.6409	1.6975	1.6975	2.037	1.9239	1.358	1.7541
20	1.6975	1.8107	1.7541	1.4712	1.8107	1.8673	1.6975
21	1.3014	1.9239	1.8673	1.8673	1.8107	1.8673	1.8107
22		1.9805	1.7541	1.8673	1.8673	1.8107	1.4712
23		1.8107	1.9805	1.8107	1.5844	1.8673	1.8107
24	1.8673	1.6975	1.9239	1.9805	1.9805	2.037	1.8107
Max	1.8673	2.037	1.9805	2.1502	2.0936	2.1502	1.8107
Min	1.2449	1.5844	1.4712	1.4712	1.3014	.5658	.0566
Avg	1.6615	1.8296	1.7942	1.8164	1.8484	1.7007	1.5325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 202 / 11 KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.905	.9694	.9774	.9955	.905	.6878
2	.6516	.8688	.9511	.9593	.9412	.8688	.6697
3	.5792	.8145	.9145	.9593	.905	.8326	.6697
4	.543	.7602	.8779	.9593	.8688	.7602	.6516
5	.5068	.724	.8048	.905	.8145	.7602	.6154
6	.4706	.6878	.7682	.724	.7783	.6878	.5792
7	.4525		.8413	.724	.8507	.6154	.5792
8	.4525	.7964	.9145	.8869	.9412	.724	.543
9	.4706	.8326	1.0608	.9774	1.0498	.6878	.5068
10	.4706	.8326	.9877	.9593	1.0498	.5068	.4706
11	.4163	.8688	.9877	.9774	.7964	.4706	.4706
12	.5792	.9145	.7421	.4163	.8688	.6154	.439
13	.6516	.9511	.4344	1.0498	.9412	.6516	.4755
14		.9511	.7964	.7421	.905		.4024
15	.6516	.9511	.7964	1.0679	.905	.2353	.5121
16	.5068	.8779	.8145	1.0136	.9412	.2353	.5121
17	.5792	.8413	.543	1.0136	.9774	.2715	.5121
18	.724	.7682	.543	.9955	.5792	.3258	.4755
19	.7964	.8048	.8688	.8688	.8326	.362	.6584
20	.8688	.9511	.9412	.9593	.905	.7783	.7316
21	.9412	1.0242		1.0136	.9412	.7602	.7682
22	.9412	1.0974	1.0317	1.086	.9412	.724	.7316
23	.9412	1.0242	.9955	1.0498	.9412	.7059	.7316
24	.724	.905	.9877	.9774	1.0136	.905	.6878
Max	.9412	1.0974	1.0608	1.086	1.0498	.905	.7682
Min	.4163	.6878	.4344	.4163	.5792	.2353	.4024
Avg	.6351	.8762	.8510	.9276	.9035	.6256	.5867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 203 / 11 KV Daheli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.1448	.3048	.2353	.2149	.181	.181
2	.3582	.1448	.3048	.2353	.197	.181	.181
3	.3224	.1448	.2858	.2353	.197	.1629	.1629
4	.3224		.2667	.2353	.1791	.1448	.1629
5	.2507	.1267	.2858	.2172	.1791	.1448	.1629
6	.2507	.1086	.3239	.1991	.197	.1448	.1267
7	.2149	.1448	.3429	.3077	.2149	.2172	.1086
8	.2149	.2172	.381	.3258	.394	.2172	
9	.2149		.362	.3982	.394	.2172	
10	.2149	.181	.362	.4344	.4835	.181	
11	.1791	.2896	.381	.4163	.4477	.2534	
12	.181	.3429	.3439	.4298	.3258	.3077	
13	.1629	.3429	.3258	.4477	.2896	.2896	.1524
14		.3429	.3258	.3582	.2353		.1905
15	.1991	.362	.2353	.394	.2896		.1905
16	.1629	.3048	.3077	.3982	.2534		.1334
17	.1448	.3048		.3761	.2896	.0362	.1524
18	.1448	.2667	.1991	.394	.362	.0543	.1524
19	.181	.2286	.2534	.3403	.2534	.1097	.2096
20	.2172	.2667	.2353	.3224	.2534	.1448	.2667
21	.181	.3048	.2534	.3224	.2172	.1448	.3048
22	.181	.3429	.2534	.2865	.181	.1629	.3429
23	.1629	.381	.2353	.2507	.1991	.1629	.2858
24	.394	.1448	.3239	.2353	.2149	.181	.181
Max	.394	.381	.381	.4477	.4835	.3077	.3429
Min	.1448	.1086	.1991	.1991	.1791	.0362	.1086
Avg	.2282	.2472	.2997	.3248	.2693	.1733	.1920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 401 / 33 KV PURTI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0549	.056	.0549	.0549	.0549	.2743
2	.0549	.0549	.056	.0549	.0549	.0549	.2195
3	.0549	.0549	.056	.0549	.0549	.0549	.2195
4	.0549	.0549	.056	.0549	.0549	.0549	.1646
5	.0549	.0549	.056	.0549	.0549	.5487	.1646
6	.0549	.0549	.056	.0549	.0549	.8779	.1646
7	.0549	.0543	.056	.0549	.0549	.823	.1646
8	.0549	.0549	.056	.0549	.0549	.823	.1646
9	.0549	.0549	.056	.0549	.0549	.823	.1646
10	.0549	.0549	.056	.0543	.0549	.823	.1646
11	.0549	.0549	.056	.0549	.0549	.7682	.1646
12	.0549	.056	.0549	.0549	.0549	.5487	.168
13	.0549	.056	.0549	.0549	.0549	.5487	.168
14		.056	.0549	.0549	.0549	.439	.168
15	.0549	.0514	.0549	.0549	.0549	.439	.168
16	.0549	.056	.0549	.0549	.0549	.439	.168
17	.0549	.056	.0549		.0549	.3841	.168
18	.0549	.056	.0549	.0549	.0549	.3292	.168
19	.0549	.056	.0549	.0549	.0549	.3841	.168
20	.0549	.056	.0549	.0549	.0549	.3841	.2241
21	.0549	.056	.0549	.0549	.0549	.3292	.168
22	.0549	.056	.0549	.0549	.0549	.2743	.168
23	.0549	.056	.0549	.0549	.0549	.2715	.168
24	.0549	.0549	.056	.0549	.0549	.0549	.2743
Max	.0549	.056	.056	.0549	.0549	.8779	.2743
Min	.0549	.0514	.0549	.0543	.0549	.0549	.1646
Avg	.0549	.0552	.0555	.0549	.0549	.4388	.1824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 402 / 33KV INCOMER(Bela)

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.262	1.3375	1.3169	1.3717	1.3717	1.262
2	1.5364	1.262	1.286	1.3169	1.3169	1.3717	1.1523
3	1.4266	1.2071	1.286	1.3169	1.3169	1.3169	1.1523
4	1.2071	1.0974	1.2346	1.3169	1.262	1.262	1.1523
5	.9877	.9877	1.1831	1.262	1.2071		1.0974
6	.8779	.8779	1.1317	1.0425	1.0974	2.3045	1.0425
7	.6584	.823	1.286	1.0974	1.2071	1.7558	.9328
8	.7133	.9877	1.2346	1.262	1.3169	2.0302	.9328
9	.7133	.8779	1.286	1.4266	1.4815	1.9204	.823
10	.7133	1.0974	1.286	1.4266	1.4815	1.8107	.7682
11	.6584	1.262	1.3375	1.4266	1.262	1.8107	.7133
12	.8779	1.286	1.2071	1.1523	1.3717	1.6461	.7202
13	.8779	1.286	.9328	1.5364	1.3717	1.701	.7716
14		1.286	1.262	2.4143	1.3169	.5487	.823
15	.823	1.286	1.0974	2.6337	1.3169	.7682	.823
16	.7133	1.2346	1.2489	1.5364	1.3169	.823	.7716
17	.823	1.0802	.7133	1.4815	1.3717	.7682	.8745
18	.8779	.9774	.823	1.4266	.9877	.8779	.9259
19	1.0425	1.0288	1.262	2.4143	1.2071	.8779	1.1831
20	1.262	1.286	1.3169	1.3169	1.3717	1.4266	1.286
21	1.3717	1.3375	1.4815	1.4266	1.4266	1.3717	1.286
22	1.3717	1.3889	1.4815	1.4815	1.4815	1.3717	1.286
23	1.3169	1.3889	1.4815	1.4266	1.4266	1.3169	1.2346
24	1.5912	1.3169	1.3375	1.3717	1.3717	1.4266	1.3169
Max	1.5912	1.3889	1.4815	2.6337	1.4815	2.3045	1.3169
Min	.6584	.823	.7133	1.0425	.9877	.5487	.7133
Avg	1.0449	1.1636	1.2306	1.4929	1.3192	1.3860	1.0138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 201 / 11 KV SIRPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.4024	.3429	.3944	.4191	.3521	.2058
2	.4287	.3688	.3429	.3944	.4191	.3521	.2058
3	.4287	.3688	.3429	.3772	.4191	.3353	.2058
4	.4287	.3353	.3086	.3772	.4191	.3353	.1715
5	.3772	.2515	.2572	.3429	.4191	.3018	.1715
6	.2743	.218	.2229	.2915	.3521	.3018	.1372
7	.2229	.2347	.2915	.3429	.4024	.2683	.1543
8	.2229	.2347	.3944	.4755	.4024	.3185	.1715
9	.2195	.3521	.3772	.4938	.4191	.285	.1886
10	.2204	.3258	.3601	.3887	.4024	.12	.1715
11	.2012	.3772	.3772	.3563	.4144	.1372	.1543
12	.1844	.4115	.4115	.3887	.431	.1372	.1372
13	.2486	.4115	.4801		.3647		.1372
14	.2486	.3772	.5144		.3315	.1543	.1372
15	.2486	.3601	.4973		.3812	.1372	.12
16	.2321	.3601	.4801	.3725	.3978	.12	.12
17	.218	.3429	.4287	.4049	.3647	.12	.12
18	.2515	.3429	.2915	.3887	.3353	.1715	
19	.285	.3601	.3429	.3563	.3018	.2058	.2195
20	.4115	.4287	.3944	.4372	.3521	.2401	.2572
21	.4191	.4973	.4458	.4534	.373	.2572	.2743
22	.4191	.4801	.463	.4858	.407	.2572	.2743
23	.4191	.4115	.463	.4696	.4024	.2401	.2572
24	.4239	.4359	.3944	.3944	.4527	.3688	.2401
Max	.4287	.4973	.5144	.4938	.4527	.3688	.2743
Min	.1844	.218	.2229	.2915	.3018	.12	.12
Avg	.3102	.3620	.3844	.3993	.3910	.2399	.184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 202 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.6783	.2058	.2012	.1696	.2035	.1715
2	.695	.6859	.2058	.2012	.1696	.2058	.1715
3	.695	.6859	.2058	.2012	.1696	.1886	.1715
4	.695	.6173	.2058	.2012	.1696	.1886	.1372
5	.6584	.5487	.1715	.1463	.1696	.1715	.12
6	.5487	.4801	.12	.1097	.1187	.12	.1029
7	.4755	.5144	.1029	.0914	.0848	.0857	.0857
8	.4938	.5487	.0857	.0886	.0848	.0686	.0857
9	.5121	.6613	.0857	.0914	.0848	.0857	.0732
10	.4917	.7373	.2743	.2896	.3052	.1715	.0914
11	.5087	.6859	.2743	.2896	.3391	.1886	.0914
12	.5426	.583	.2561	.2715	.1865	.1715	.0732
13	.5426	.6173	.2743		.1357		.0732
14	.6104	.7716	.2743		.2035	.12	.0747
15	.5935	.7888	.2561		.218	.1029	.0732
16	.5596	.823	.2561	.2534	.2347	.1029	.0732
17	.5256	.6859	.2378	.362	.2035	.0857	.0732
18	.5087	.6859	.0732	.2896	.0848	.1029	
19	.5087	.1543	.0914	.2896	.1006	.1372	.1463
20	.6783	.2401	.1829	.2896	.1865	.1543	.1829
21	.7716	.2401	.2012	.2534	.2035	.1715	.2012
22	.7545	.2401	.2195	.2353	.2374	.1715	.1829
23	.7202	.2401	.2195	.2353	.2035		.1829
24	.7133	.703	.2401	.2012	.2035	.2035	.1715
Max	.7716	.823	.2743	.362	.3391	.2058	.2012
Min	.4755	.1543	.0732	.0886	.0848	.0686	.0732
Avg	.6049	.5674	.1967	.2187	.1778	.1455	.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 203 / 11 KV DAWWA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.2374	.2058	.213	.2035	.2035	.1715
2	.1543	.2374	.2058	.2204	.2035	.2035	.1715
3	.1543	.2374	.2058	.2035	.2035	.2035	.1715
4	.1526	.2035	.2058	.2035	.2035	.1865	.1715
5	.1526	.1696	.1715	.1357	.2035	.1696	.1543
6	.1526	.1187	.1029	.1029	.1187	.1357	.1372
7	.1357	.1017	.0686	.0983	.0678	.1017	.12
8	.1526	.0678	.0686	.0848	.0678	.0678	.1029
9	.1886	.0678	.0686	.0678	.0678	.0848	.1029
10	.1865	.3086	.2883	.3086	.2713	.2058	.1187
11	.1865	.2743	.2743	.3429	.2374	.2401	.1017
12		.2401	.2374	.3601	.2035	.2058	.1017
13		.2401	.2229		.2035		.1017
14	.2035	.2229	.2058		.2035		.1097
15	.2204	.2058	.2229		.1865		.1017
16	.2374	.2058	.2401	.2058	.2374		.1029
17	.2035	.1886	.2229	.2915	.2035		.1017
18	.0848	.0857	.0857	.2229	.0848	.1372	
19	.1357	.1543	.1017	.1886	.1017	.1372	.1526
20	.2204	.2058	.2374	.1715	.1865	.1543	.1696
21	.2374	.2401	.2401	.2058	.2035	.1715	.1865
22	.2374	.2401	.2374	.2401	.2204	.1715	.1865
23	.2374	.2401	.2401	.2401	.2204	.1886	.1865
24	.1475	.2374	.2401	.2204	.2204	.2204	.1886
Max	.2374	.3086	.2883	.3601	.2713	.2401	.1886
Min	.0848	.0678	.0686	.0678	.0678	.0678	.1017
Avg	.1788	.1971	.1917	.2061	.1802	.1678	.1397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 204 / 11KV MIDC Water Works
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0089	.0308	.0304	.0311		.0308	.0304
2	.0091	.0308	.0304	.0301		.0308	.0304
3	.0091	.0308	.0304	.0311		.0308	.0304
4	.0091	.0308	.0304	.0311	.0308	.0308	.0304
5	.0091	.0308	.0304	.0311	.0308	.0308	.0304
6	.0329	.0308	.0304	.0311	.0308	.0308	.0304
7	.0311	.0308	.0304	.0311	.0308	.0308	.0291
8	.0311	.0308	.0291	.0301	.0308	.0308	.0304
9	.0311	.0308	.0304	.0301	.0308	.0308	.0291
10	.0308	.0322	.0329	.0308	.0308	.0304	.0317
11	.0308	.0309	.0329	.0308	.0308	.0304	.0311
12	.0308	.0309	.0329	.0308	.0308	.0304	.0311
13	.0308	.0322	.0329		.0308		.0311
14	.0308	.0322	.0329		.0308	.0304	.0311
15	.0308	.0304	.0329		.0308	.0304	.0091
16	.0308	.0304	.0311	.0326	.0308	.0304	.0091
17	.0308	.0304	.0329	.0308	.0308	.0291	.0311
18	.0308	.0322	.0311	.0308	.0308	.0304	
19	.0288	.0304	.0311	.0308	.0308	.0304	.0311
20	.0308		.0311	.0308	.0308	.0304	.0311
21	.0308	.0322	.0311	.0308	.0308	.0291	.0311
22	.0308	.0322	.0311	.0308	.0308	.0304	.0311
23	.0308	.0322	.0311	.0308	.0308	.0304	.0311
24	.0091	.009	.0322	.0311	.009	.0308	.0291
Max	.0329	.0322	.0329	.0326	.0308	.0308	.0317
Min	.0089	.009	.0291	.0301	.009	.0291	.0091
Avg	.0254	.0302	.0314	.0309	.0298	.0305	.0287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 205 / MIDC OLD WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0073	.0091	.0086	.0073	.0091	.0091	.0086
2	.0073	.0091	.0086	.0073	.0091	.0091	.0086
3	.0071	.0091	.0086	.0073	.0091	.0091	.0086
4	.0073	.0091	.0086	.0073	.0091	.0091	.0086
5	.0073	.0091	.0034	.0071	.0091	.0091	.0086
6	.0073	.0091	.0086	.0073	.0091	.0091	.0086
7	.0073	.0091	.0086	.0073	.0091	.0091	.0086
8	.0073	.0091	.0086	.0071	.0091	.0091	.0086
9	.0073	.0091	.0086	.0073	.0091	.0091	.0086
10	.0091	.0086	.0073	.0065	.0091	.0086	.0074
11	.0091	.0086	.0073	.0065	.0091	.0086	.0074
12	.0091	.0086	.0073	.0065	.0091	.0086	.0074
13	.0091	.0086	.0073		.0091		.0073
14	.0091	.0086	.0073		.0091	.0086	.0074
15	.0091	.0086	.0073		.0091	.0086	.0073
16	.0091	.0086	.0073	.0065	.0091	.0086	.0073
17	.0091	.0154	.0073	.0065	.0091	.0086	.0073
18	.009	.0086	.0311	.0065	.0091	.0086	
19	.009	.0086	.0073	.0065	.0091	.0086	.0073
20	.0091	.0086	.0073	.0065	.0091	.0086	.0073
21	.0091	.0086	.0073	.0065	.0091	.0086	.0073
22	.0091	.0086	.0073	.0065	.0091	.0086	.0073
23	.0091	.0086	.0073	.0065	.0091	.0086	.0073
24	.0073	.0091	.0086	.0073	.0091	.009	.0086
Max	.0091	.0154	.0311	.0073	.0091	.0091	.0086
Min	.0071	.0086	.0034	.0065	.0091	.0086	.0073
Avg	.0083	.0091	.0086	.0069	.0091	.0088	.0079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 206 / 11KV GAOTHAN MAKARDHOKDA

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2534	.2401	.2498	.2624	.2534	.1629
2	.2561	.2498	.2401	.2561	.257	.2516	.1629
3	.2561	.2389	.2315	.2561	.2534	.2425	.1543
4	.2561	.2262	.2229	.2561	.2498	.2281	.1492
5	.2195	.2027	.2058	.2195	.2353	.2244	.1423
6	.1829	.1701	.1715	.1646	.181	.1864	.1303
7	.1646	.1647	.1252	.1463	.1774	.1321	.1286
8	.1573	.1448	.1372	.1463	.1502	.1122	.12
9	.1536	.1484	.1457	.161	.1502	.1303	.12
10	.143	.1715	.161	.1792	.1376	.12	.1244
11	.1647	.18	.1829	.181	.1611	.1029	.1097
12	.1647	.1852	.2195	.2172	.1738	.1029	.1024
13	.2081	.192	.2195		.1864		.1079
14	.2063	.1886	.2231		.1937	.12	.1176
15	.2027	.18	.2195		.1774	.1029	.1225
16	.181	.1715	.2195	.2407	.1611	.1029	.1244
17	.1919	.1543	.128	.2407	.1538	.1029	.1134
18	.1502	.1715	.128	.2045	.152	.12	.1134
19	.1538	.1972	.1646	.2299	.1502	.144	.15
20	.21	.2315	.2378	.248	.2081	.1629	.1829
21	.2389	.2401	.2561	.2534	.2244	.18	.1957
22	.2643	.2572	.278	.2805	.2516	.18	.1829
23	.2715	.2572	.2743	.2715	.2534	.1715	.1829
24	.267	.2552	.2486	.2615	.2624	.257	.1715
Max	.2715	.2572	.278	.2805	.2624	.257	.1957
Min	.143	.1448	.1252	.1463	.1376	.1029	.1024
Avg	.2050	.2013	.2034	.2221	.1985	.1622	.1405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 401 / 33KV INCOMER(makardhokda) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	1.2346	.5144	.6036	.5658	.5144	.3601
2	1.2483	1.1831	.5144	.6036	.5658	.5144	.3601
3	1.2483	1.1831	.5144	.5487	.5658	.5144	.3601
4	1.2483	1.0802	.463	.5201	.5658	.5144	.3086
5	1.1443	.8745	.3601	.4681	.5658	.463	.3086
6	.9882	.7716	.3601	.3641	.463	.4115	.2572
7	.8322	.823	.3601	.439	.463	.3601	.2572
8	.8842	.823	.463	.5487	.463	.4115	.2572
9	.8842	1.0802	.463	.5601	.4578	.3601	.3086
10	.9156	1.3889	.9362	1.0288	1.0174	.5144	.3641
11	.9054	1.3375	.9362	1.0288	1.0059	.6173	.3681
12	.7545	1.286	.9362	1.0288	.8551	.5658	.3258
13	.7956	1.3375	.9882		.7459		.3292
14	1.094	1.4403	1.0425		.7459	.3086	.3121
15	1.094	1.3889	.9882		.7956	.2572	.3292
16	1.0442	1.4403	1.0425	.8745	.8951	.2572	.3292
17	.9556	1.2346	.9328	1.0802	.8048	.2572	.3292
18	.8048	1.0802	.3841	.9774	.4024	.3601	
19	.8648	.5144	.439	.9231	.407	.4115	.3292
20	1.17	.6173	.6036	.9774	.5087	.463	.4344
21	1.3226	.7202	.6241	.6516	.5596	.5144	.4344
22	1.286	.6687	.6241	.6687	.6104	.5144	.4298
23	1.2346	.6173	.6584	.6687	.6104	.5144	.439
24	1.2483	1.286	.6173	.5721	.6104	.6104	.463
Max	1.3226	1.4403	1.0425	1.0802	1.0174	.6173	.463
Min	.7545	.5144	.3601	.3641	.4024	.2572	.2572
Avg	1.0507	1.0588	.6569	.7208	.6354	.4448	.3476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 201 / 11KV GANGAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.7783	.8483	.8779	2.1719	2.0287	1.3676
2	.8413	.724	.793	.8413	2.0814	1.8996	1.3306
3	.8048	.7059	.7377	.8048	1.9909	1.7889	1.2936
4	.7316	.6335	.7008	.7316	1.9909	1.6783	1.1706
5	.6878	.6154	.6455	.6516	1.7194	1.5492	1.0974
6	.6154	.5611	.6086	.543	1.448	1.4385	1.0242
7	.4887	.5068	.5164	.4344	1.3032	1.2725	.905
8	.3982	.3801	.4242	.4163	1.0136	.959	.8688
9	.3544	.3898	.443	.4119	1.0277	.9145	
10	.3898	.4252	.4656	.4252	1.0631	.9145	.7619
11	.4252	.4656	.5014	.4961	1.1517	.905	.7973
12	.4477	.5014	.5194	.5316	1.1694	.8869	.815
13	.5014	.5373	.6805	1.0387	1.2178	.905	.8238
14	.5373	.6089	.6447	1.2536	1.2403	.905	.8059
15	.543	.6089	.6089	1.576	1.3032	.8596	.8238
16	.5068	.5792	.6516	1.5927	1.2178	.8417	.8596
17	.4706	.5348	.567	.6516	1.2356	.8688	.8326
18	.5068	.4795	.5487	1.1765	1.1988	.905	
19	.5068	.5533	.5175	1.3756	1.2356	1.1458	1.0608
20	.543	.6824	.6468	1.6108	1.5676	1.2936	1.2308
21	.6697	.7746	.7577	1.8823	1.6967	1.386	1.3756
22	.7602	.8483	.8316		1.9918	1.46	1.4118
23	.8507	.9221	.924		2.1578	1.4415	1.3394
24	.924	.8326	.9037	.8962	2.2443	2.1393	1.4045
Max	.924	.9221	.924	1.8823	2.2443	2.1393	1.4118
Min	.3544	.3801	.4242	.4119	1.0136	.8417	.7619
Avg	.5993	.6104	.6453	.9191	1.5183	1.2661	1.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 203 / 11KV KAWARAPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.8099	2.0226	1.9936	2.1357	1.8354	1.2197
2	1.9753	1.7375	1.9103	1.9204	2.0271	1.7604	1.1458
3	1.9022	1.6832	1.7979	1.829	1.9547	1.6668	1.1088
4	1.829	1.6289	1.7043	1.6827	1.9366	1.5732	1.0608
5	1.6289	1.5384	1.5919	1.5203	1.7194	1.4982	1.0242
6	1.448	1.3756	1.4982	1.3575	1.3756	1.4046	1.0059
7	1.2851	1.1765	1.3484	1.2489	1.267	1.2548	.9774
8	1.086	1.0679	1.1237	1.086	1.086	1.03	.9412
9	1.1163	1.1163	1.0985	1.134	1.134	.9877	.9036
10	1.1694	1.2048	1.134	1.2048	1.1694	.9774	.9214
11	1.3611	1.2536	1.2757	1.4529	1.2048	1.0136	.9036
12	1.4327	1.4685	1.4864	1.5592	1.4529	1.0608	.9036
13	1.4685	1.6118	1.448	1.6118	1.4685	.9955	.8954
14	1.5223	1.6478	1.5947	1.6834	1.4685	.9412	.8775
15	1.5203	1.6655	1.6655	1.7551	1.4685	.9313	.9492
16	1.448	1.6651	1.576	1.7194	1.4327	.9134	1.0029
17	1.448	1.6293	.2561	1.6289	1.4795	.9412	1.0498
18	1.5023	1.5357	1.5364	1.647	1.4046	.9593	
19	1.5384	1.6106	1.6632	1.6289	1.4982	1.2012	1.3032
20	1.6289	1.7792	1.848	1.8461	1.6293	1.3306	1.3575
21	1.7013	1.929	1.9404	1.8823	1.723	1.3676	1.4118
22	1.7737	2.0226	2.0513		1.8541	1.3491	1.3394
23	1.8823	2.1163	2.1622		1.9477	1.2936	1.2308
24	2.0513	1.9004	2.0975		2.0633	1.9103	1.2567
Max	2.0513	2.1163	2.1622	1.9936	2.1357	1.9103	1.4118
Min	1.086	1.0679	.2561	1.086	1.086	.9134	.8775
Avg	1.5721	1.5906	1.5763	1.5901	1.5792	1.2582	1.0778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 204 / 11KV DREAM CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.267	1.2905	1.3352	1.3213	1.1087	.6838
2	1.2803	1.2127	1.2178	1.2803	1.267	1.0542	.6838
3	1.2437	1.1765	1.1269	1.2437	1.2308	.9997	.6653
4	1.1706	1.086	1.0542	1.1706	1.1765	.9451	.6584
5	1.086	1.0136	.9815	1.086	1.1222	.8906	.6401
6	.9412	.8688	.9088	.9955	.9412	.8361	.6219
7	.8507	.8145	.8543	.8507	.724	.727	.5973
8	.724	.7421	.7997	.7421	.724	.6543	.6154
9	.7265	.7442	.7619	.7265	.7442	.6584	.6024
10	.7442	.7796	.7442	.7442	.7442	.6584	.5847
11	.7442	.8238	.815	.815	.788	.6335	.6024
12	.7522	.8596	.8775	.8505	.788	.6154	.5731
13	.8238	.9391	.9313	.9492	.7973	.5973	.5731
14	.8688	1.0029	.985	1.0029	.788	.5792	.5194
15	.905	.9922		1.0387	.788	.5731	.591
16	.8869	1.0498	1.086	1.0498	.8238	.5552	.6335
17	.9412	.9815	.9694	.9412	.9088	.6154	.5792
18	.905	.8724	.9511	.9593	.8361	.6697	
19	.905	.9088	.924	.9412	.7634	.7023	.7602
20	.9955	1.0724	1.1088	1.0974	.9088	.7392	
21	1.086	1.1632	1.2012	1.1584	.9815	.7762	.7964
22	1.2127	1.2905	1.3306		1.0905	.7947	.7602
23	1.267	1.3813	1.423		1.1632	.7762	.724
24	1.3491	1.3394	1.3632	1.3717	1.39	1.1632	.7023
Max	1.3491	1.3813	1.423	1.3717	1.39	1.1632	.7964
Min	.724	.7421	.7442	.7265	.724	.5552	.5194
Avg	.9886	1.0159	1.0307	1.0159	.9505	.7635	.6440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 205 / 11KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.5611	.6005	.4207	.5068	.6381	.5544
2	.6219	.6154	.563	.4207	.5792	.6005	.5175
3	.5853	.6335	.5255	.439	.543	.563	.5175
4	.5487	.5792	.563	.439	.5304	.5255	.5304
5	.5068	.6516	.5067	.4525	.5068	.5442	.5487
6	.5068	.6697	.4692	.4706	.543	.6193	.5304
7	.543	.7602	.6381	.4525	.5249	.6756	.5068
8	.6878	.8507	.8069	.543	.5068	.6381	.5973
9	.7442	.8682	.7973	.5493	.567	.5487	.567
10	.815	.8859	.7796	.567	.7442	.5121	.5138
11	.9955	.9671	.8954	.7442	.8059	.543	.5316
12	1.182	.985	.9313	.8505	.9922	.6335	.5316
13	1.0029	.9671	.9671	.8238	.9922	.7602	.5731
14	.8954	.9313	1.0387	.788	1.0387		.5194
15	.905	.9313	1.0745	.7522	1.086	.2715	.6268
16	1.1403	.8238	1.1222	.7499	1.0566	.3045	.9313
17	1.267	1.0134	1.134	.6878	1.0509	.2896	.9412
18	1.0136	1.1635	1.0608	.724	.8445	.2172	
19	.7602	.9758	.7023	.7602	.7319	.2772	.6154
20	.6516	.6381	.5544	.6697	.6005	.3511	.543
21	.5973	.3753	.4251	.3982	.4504	.3326	.3982
22	.724	.5255	.462		.563	.5914	.4706
23		.6005	.5175		.6756	.6099	.5068
24	.6653	.5611	.6381	.4755	.6154	.6756	.5544
Max	1.267	1.1635	1.134	.8505	1.086	.7602	.9412
Min	.5068	.3753	.4251	.3982	.4504	.2172	.3982
Avg	.7826	.7723	.7406	.5990	.7107	.5097	.5707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 401 / 33KV TATA EXP FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2085	.2281	.2377	.1866	.2281	.2487	.2439
2	.2195	.2335	.2259	.1811	.2443	.2374	.2218
3	.2085	.2443	.2138	.1701	.2172	.2202	.1996
4	.1975	.2498	.202	.1866	.2118	.2028	.2085
5	.1846	.2118	.1788	.19	.1955	.191	.1975
6	.1738	.1955	.1836	.1846	.1955	.179	.1811
7	.2009	.2118	.1984	.1792	.2063	.2106	.1846
8	.2281	.2172	.2245	.1846	.19	.2466	.19
9	.2551	.2233	.2551	.2179	.202	.2414	.2126
10	.2658	.2392	.2764	.2605	.2339	.2359	.2658
11	.2686	.2471	.2711	.2658	.202	.2498	.2817
12	.2364	.2579	.2769	.2817	.2418	.2715	.287
13	.2126	.2418	.2579	.2955	.2711	.2281	.2042
14	.1792	.2203	.2471	.2848	.2848	.1629	.1397
15	.2281	.2257	.1612	.274	.2901	.2257	.2063
16	.2606	.2878	.1683	.2226	.2525	.2686	.2418
17	.2552	.2511	.1811	.2063	.2231	.2063	.2878
18	.2606	.1914	.1811	.2281	.2402	.1846	
19	.2715	.307	.1996	.2552	.2628	.2329	.2443
20	.2498	.2639	.2051	.2335	.2424	.1774	.2281
21	.2118	.2369	.1996	.1955	.21	.1885	.1955
22	.2009	.2653	.1885		.2215	.194	.2172
23	.1955	.2495	.194		.2051	.183	.2443
24	.1996	.2118	.25	.1756	.2389	.2389	.2329
Max	.2715	.307	.2769	.2955	.2901	.2715	.2878
Min	.1738	.1914	.1612	.1701	.19	.1629	.1397
Avg	.2239	.238	.2157	.2209	.2296	.2177	.2224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 201 / 11 kV Umrer U I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2437	1.2071	1.182	1.2896	.0183	.0183	.0189
2	1.2071	1.1706	1.1946	1.2308	.0189	.0183	.0189
3	1.1706	1.0974	1.1641	1.1963	.0189	.0183	.0189
4	1.0974	1.0608	.9774	1.1523	.0189	.0185	.0189
5	1.0608	1.0136	.905	1.0974	.0189	.0183	.0189
6	.8779	.8413	.8326	.8779	.0189	.0181	.0189
7	.695	.6584	.6584		.0189	.0183	.0189
8	.5487	.695	.6401	.6584	.0189	.0183	.0189
9	.5487	.695	.6401	.695	.0189	.0183	.0189
10	.6219	.695	.7316	.7316	.0189	.0183	.0189
11	.6584		.8145	.7682	.0183	.0189	.0175
12	.695	.8048	.8688	.9328	.0183	.0189	.0183
13	.7682		.905		.0183	.0189	.0183
14	.7316		.9145		.0183	.0189	.0183
15	.7714	.905	.9511		.0183	.0189	.0183
16	.8048	.8326	.9145	.0189	.0185	.0189	
17	.7316	.7682	.8779	.0189	.0183		.0183
18	.695		.7316	.0189	.0183	.0189	
19	.8048	.8048	.8048	.0189	.0183	.0189	.0366
20	.9511	.9774	1.0164	.0189	.0183	.0189	.0366
21		1.0745	1.2071	.0189	.0183	.0189	.0366
22	1.2254	1.4529	1.2437	.0189	.0183	.0189	.0183
23	1.2437	1.2403	1.3535	.0189	.0187	.0189	.0183
24	.0189	1.2071	1.2536	1.3169	.0189	.0183	.0189
Max	1.2437	1.4529	1.3535	1.3169	.0189	.0189	.0366
Min	.0189	.6584	.6401	.0189	.0183	.0181	.0175
Avg	.8336	.9601	.9493	.6049	.0186	.0186	.0211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 202 / 11 KV UMRER U II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1463	.1509	.1448	.1646	.1463	.0943
2	.1646	.1097	.1509	.1448	.1463	.1463	.132
3	.1463	.128	.1509	.1097	.1463	.1267	.132
4	.1463	.128	.1509	.1097	.1463	.1086	.1132
5	.128	.128	.132	.1463	.128	.1086	.0943
6	.128	.0914	.132	.1097	.1097	.112	.0943
7	.1097	.0914	.0943		.0914	.1097	.0754
8	.128	.0914	.1132	.1086	.1097	.0914	.0943
9	.1097	.1097	.1132	.1086	.128	.1097	.1132
10	.1097	.0914	.1132	.1097	.1097	.128	.0754
11	.1097		.1132	.128	.1448	.0943	.0732
12	.1097	.1132	.1132	.128	.1097	.0943	.0732
13	.1097		.1132		.1097	.0943	.0732
14	.1097		.128		.0366	.0943	.0732
15	.1097	.132	.128		.0732	.0943	.0732
16	.1097	.132	.1086	.1646	.0732	.0943	.0724
17	.0914		.1097	.1463	.1097	.0943	.0732
18	.0732		.1097	.128	.1097	.0754	
19	.1097	.1132	.1097	.128	.128	.0754	.1097
20	.1097	.132	.1463	.128	.1097	.1132	.0914
21		.1509	.1463	.128	.128	.0943	.0914
22	.128	.1867	.1463	.1463	.1267	.0943	.0905
23	.1448	.1867	.1829	.1646	.1463	.0943	.0732
24	.1463	.1463	.1509	.1463	.1646	.1463	.0943
Max	.1646	.1867	.1829	.1646	.1646	.1463	.132
Min	.0732	.0914	.0943	.1086	.0366	.0754	.0724
Avg	.1216	.1268	.1295	.1314	.1187	.1059	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 203 / 11 KV HEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7682	.8048	.8413	1.2803		.9774
2	.7316	.7499	.7682	.8048	1.262		
3	.7316	.7316	.7316	.8048	1.262		.905
4	.7133	.7133	.6767	.7682	.8962	.7897	.8507
5	.7133	.695	.6099	.7682	.8779	.7714	.8048
6	.5487	.5121	.5544	.6219	.8779	.6219	.7133
7	.4572	.5121	.5914		.8413	.5487	.5544
8	.3658	.5121	.6401	.6584	.823	.4755	.5544
9	.3292	.5853		.7682	.823	.5853	.5175
10	.0377	.6401	.7316	.5121	.7316	.439	.2987
11	.439	.6584	.8048	.8048	.695	.4108	.3292
12	.4755	.695	.8326	.6036		.3921	.2926
13	.5504	.7682	.8688			.4108	.2926
14	.5487	.7682	.8413			.4108	.2926
15	.5853	.7316	.8048			.3734	.3109
16	.5487	.6767	.7682	.9328		.3734	.3292
17	.4755	.6219	.7682	.8413		.3361	.2926
18	.4572		.6447	.7316		.4066	
19	.5487	.6219	.6401	.823		.5544	.5504
20	.7682	.7682	.8413	1.262		.9774	
21	.823	.8326	.8779	1.4266		1.0745	
22	.823	.8326	.9097	1.4266		1.0745	.5853
23	.8048	.8145	.8413	1.3169		1.0566	.5487
24	.7682	.7682	.7964	.8326	1.2803		.9774
Max	.823	.8326	.9097	1.4266	1.2803	1.0745	.9774
Min	.0377	.5121	.5544	.5121	.695	.3361	.2926
Avg	.5839	.6947	.7543	.8775	.9709	.6041	.5489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 205 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.5487	1.2803		.9955
2		.5544	.543	1.3014		.9774
3		.5175	.5132	1.2437		.8869
4		.462	.5121	.5487	.5871	.8145
5		.462	.4706	.5487	.5504	.8145
6		.4108	.4024	.5304	.4344	.7133
7		.3734		.5304	.439	.5729
8		.3881	.362	.5853		.5544
9		.4108	.3658	.6036		.5359
10		.4805	.439	.5487		
11		.5175	.439	.5121	.4805	
12		.5175	.7499		.4435	
13		.5544				
14		.5487				.3292
15		.4706			.1867	.3292
16		.4755	1.0059		.2614	.3109
17		.4755	.6584		.2614	
18		.3898	.5487		.2801	
19	.4435	.3982	.8962		.3696	.439
20	.5914	.543	1.2803		1.0136	
21	.5914	.581	1.4266		1.0745	
22	.5729	.5853	1.4266		1.1462	
23	.5544	.5487	1.3352		1.0208	.439
24		.5544	.5014	1.2986		1.0029
Max	.5914	.5853	1.4266	1.3014	1.1462	1.0029
Min	.4435	.3734	.362	.5121	.1867	.3109
Avg	.5507	.4906	.7213	.7943	.5699	.6477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 207 / 11KV Express Water work
feeder Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.1509	.1463	.0549	.0905	.1509
2	.0732	.0732	.1698	.1254	.0549	.0905	.1509
3	.0914	.0732	.1867	.0914	.0914	.0732	.1509
4	.0914	.0732	.1867	.0914	.1097	.0739	.132
5	.0914	.0732	.1867	.0732	.1097	.0732	.1132
6	.0732	.1267	.1698	.1646	.0914	.0732	.1132
7	.0914	.1829	.1698		.0914	.0732	.1132
8	.1463	.1646	.1509	.181	.1646	.0549	.132
9	.1097	.1463	.132	.128	.128	.0732	.1509
10	.1097	.128	.1132	.1829	.1646	.0732	.1698
11	.128		.1132	.128	.1829	.1132	.1463
12	.1448	.1698	.1132	.1829	.1646	.1509	.1463
13	.1829		.0566		.1829	.132	
14	.1829		.1086		.1646	.1132	
15	.181	.1698	.1448		.1097	.132	
16	.1646	.1698	.1463	.0377	.1097	.1509	
17	.1463		.1463	.1097	.1629	.1509	.1646
18	.1463		.1448	.0914	.1829	.1509	
19	.1463	.1698	.1086	.0914	.1829	.1509	.1812
20	.1097	.1132	.1463	.0914	.0732	.1132	.1097
21	.128	.1132	.1463	.0914	.0732	.0754	.1097
22	.1097	.0943	.1448	.0549	.0914	.0943	.1463
23	.0724	.0754	.0732	.0377	.0724	.0943	.1463
24	.0914	.0732	.0754	.0905	.0366	.0914	.0943
Max	.1829	.1829	.1867	.1829	.1829	.1509	.1812
Min	.0724	.0732	.0566	.0377	.0366	.0549	.0943
Avg	.1210	.1201	.1369	.1096	.1188	.1026	.1380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 208 / 11KV UMRED AG SEPERATED

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0377	.0732	.0754	.1829	.1646	.0366	
11	.0549		.0943	.1463	.1629	.0377	
12	.0732		.0943	.1463	.1646	.0377	.0183
13	.0549		.0754		.1463		.0183
14	.0549		.0914		.128	.0377	.0183
15	.0732		.0905		.0732		.0183
16	.0549		.1829	.0187	.0914		.0183
17	.0543		.1829	.1463	.0724		.0183
18				.1097	.0905		
19				.0732			
Max	.0732	.0732	.1829	.1829	.1646	.0377	.0183
Min	.0377	.0732	.0754	.0187	.0724	.0366	.0183
Avg	.0573	.0732	.1109	.1176	.1215	.0374	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 402 / 33 KV PACHGAON -VIRANGANA- NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3746	.7282	.7133	.823	.7682	.5601
2	1.3169	1.3169	.7282	.7133	.823	.7133	.5601
3	1.262	1.3169	.6722	.7133	.7682	.7207	.5093
4	1.2071	1.2071	.6722	.6653	.7682	.6584	.4527
5	1.2071	1.262	.6161	.7133	.7682	.7133	.3961
6	1.2071	.9328	.5601	.6036	.6584	.5544	.3961
7	.8779	.7682	.3961		.6584	.439	.2829
8	.9328	.9877	.5601	.6584	.7133	.5487	.5601
9	.9328	1.2489	.7282	.7682	.9328	.6584	.6722
10	1.0425	1.3717	1.0642	1.2071	1.0425	.6584	.6722
11	1.0425	1.4415	1.1203	1.0425	1.262	.7282	.6036
12	.9877		1.1203	1.2071	.9877	.6722	.4938
13	1.0425	1.5524	1.2197		1.3717	.5601	.4938
14	1.2071	1.5524	1.1946		.9328	.3395	.4938
15	1.3196	1.4415	1.1523		.9774	.3395	.4938
16	1.3717	1.386	1.2071	1.0425	1.0425	.2829	.4938
17	1.0425	1.3306	.823	1.262	.6584	.2263	.5487
18	.7888	1.1203	.5973	1.2071	.6653	.3961	
19	.7682	.6161	.6036	.9877	.5544	.6161	.5487
20	1.3169	.7842	.6984	1.0974	.7133	.6722	.7133
21	1.5364	.8402	.7762	.9328	.7059	.6722	.7133
22	1.5364	.8402	.8316	.9328	.7133	.6161	.6584
23	1.4118	.7842	.7133	.823	.7133	.5093	.6584
24	1.3717	1.3717	.7282	.7207	.823	.7682	.6161
Max	1.5364	1.5524	1.2197	1.262	1.3717	.7682	.7133
Min	.7682	.6161	.3961	.6036	.5544	.2263	.2829
Avg	1.1709	1.1673	.8130	.9006	.8365	.5763	.5474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 404 / 33 KV NCDC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.8461	2.0851	2.3045	2.4143	2.2497	1.9204
2	1.4815	1.7558	1.9753	2.1948	2.1948	2.0851	1.7741
3	1.5364	1.6461	1.9204	2.0851	2.524	1.6289	1.6632
4	1.701	1.4815	1.9204	1.9753	2.7435	1.4815	1.6632
5	1.4266	1.3169	1.7741	1.9753	2.2497	1.9204	1.4969
6	1.4815	1.0974	1.6632	1.578	2.1948	1.6832	1.3306
7	1.5364	1.4266	1.885		2.1399	1.8656	1.6078
8	1.4266	1.4815	1.6632		2.0302	1.701	1.5524
9	1.262	1.4661	1.5524		1.7558	1.5912	1.4969
10	1.4266	1.5203	1.7741	1.5912	2.0302	1.3717	1.6078
11	1.7558	1.386	1.8656	2.0851	2.0633	1.2323	1.4118
12	1.8656	1.386	1.8656	2.4691		1.386	1.4815
13	1.4661	1.386	1.4969		1.8656	1.2752	1.5945
14	1.7375	1.5524	1.9204			1.1643	1.6461
15	1.8656	1.7741	2.2497		2.3594	1.3306	1.7558
16	1.7918	1.7741	2.2262	1.4266	2.2497	1.386	1.8107
17	1.1403	1.8656	2.0633	1.8656	1.9204	1.4969	
18	1.6512	1.9753	1.1523	2.4691	2.1399	1.885	
19	2.1948	2.0851	1.6461	2.524	2.1399	2.4977	2.2262
20	2.4143	2.1948	2.0851	2.4691	2.2497	2.0302	2.1399
21	1.8656	2.0851	2.0851	1.9753	1.9204	1.8296	2.1399
22	1.8656	2.1948	1.9404	2.1399	2.2177	2.0851	2.009
23	1.8107	2.3045	2.2497	2.5789	2.3045	2.3891	1.8714
24	1.8656	1.9204	2.1948	2.5789	2.4691	2.3045	1.8296
Max	2.4143	2.3045	2.2497	2.5789	2.7435	2.4977	2.2262
Min	1.1403	1.0974	1.1523	1.4266	1.7558	1.1643	1.3306
Avg	1.6733	1.7051	1.8856	2.1270	2.1899	1.7446	1.7286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 201 / 11 KV TOWN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4954	.381	.381		.5335	.3429
2	.381	.4763	.381	.381	.381	.5335	.3048
3	.381	.4763	.381	.381	.381	.4954	.3048
4	.1905	.4572	.1905	.3429	.1905	.4954	.3048
5	.1905	.4572	.1905	.3239	.1905	.4954	.3048
6	.1905	.4954	.1905	.3048	.1905	.5335	.2858
7	.1905	.4763	.1905	.3429	.3429	.5335	.2858
8	.1905	.4954	.1905	.381	.3429	.4954	.2667
9	.381	.6097	.381	.5716	.7621	.4572	.2286
10	.5716	.6097	.381	.6668	.724	.5335	.381
11	.5716	.6478	.4572	.9145	.7621	.5716	.4572
12	.5716	.6478	.4954	.8764	.9526	.6097	.5335
13	.5716	.6859		.8383	.8764	.5716	.5144
14	.5716	.6478	.5335	.8002	.8002	.4572	.4954
15	.6478	.724	.5525	.8002	.8002	.5335	.5144
16	.6478	.7621	.5716	.7621	.724	.4954	.5335
17	.5716	.7621	.5716	.7621	.5716	.4954	.4954
18	.5716	.7621	.4763	.7621	.4954	.4572	.5144
19	.5716	.5716	.4763	.5716	.4954	.4954	.4572
20	.4572	.5335	.4191	.5716	.4191	.4763	.4572
21	.4954	.5335	.4191	.5716	.4954	.4191	.5335
22	.5335	.5716	.381	.4763	.5716	.381	.5335
23	.4954	.381	.381	.381	.5716	.381	.5144
24	.381	.4954	.381	.381	.381	.5716	.381
Max	.6478	.7621	.5716	.9145	.9526	.6097	.5335
Min	.1905	.381	.1905	.3048	.1905	.381	.2286
Avg	.4461	.5740	.3901	.5644	.5401	.5009	.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 202 / 11 KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.6004	1.2574	1.105	1.6004	1.4861	1.0288
2	.9145	1.6004	1.2955	1.0669	1.6766	1.448	.9907
3	1.0669	1.6385	1.2384	.9907	1.5623	1.5623	1.0288
4	1.2955	1.6385	1.1431	1.1431	1.6004	1.3717	1.1431
5	1.467	1.4861	1.105	1.3717	1.5242	1.3336	1.0669
6	1.4861	1.1241	1.105	1.5242	1.5242	1.2955	.9907
7	1.2193	1.0288	.8764	1.3336	1.6004	1.1812	.9526
8	.9145	.6859	.8383	1.1431	1.3717	1.0098	.9145
9	1.1431	1.0288	1.1431	1.2193	1.4289	.9907	.9526
10	1.3146	1.2193	1.2193	1.3717	1.5242	1.0288	1.1431
11	1.3717	1.2574	1.2955	1.6766	1.6766	.9907	1.2193
12	1.6194	1.2955	.8383	1.6766	1.3527	.9526	1.2574
13	1.5623	1.7528	1.3717	1.2193	1.2955	.9526	1.3717
14	1.5242	1.7147	1.5242	1.1431	.6668	.9145	1.5051
15	1.4861	1.8671	1.448	1.6004	.7049	1.0288	1.448
16	1.3527	1.9052	1.3717	1.7528	.743	.9907	1.4098
17	1.5623	1.5242	1.448	1.6766	1.2765	.9907	1.3336
18	1.6575	1.3336	1.5242	1.4861	1.6575	1.0288	1.2955
19	1.4861	1.2193	1.0669	1.5242	1.3717	1.1431	1.1241
20	1.1431	1.0098	.9907	1.6575	.9907	1.0669	.8764
21	1.086	1.1431	1.0669	1.6766	1.2574	1.105	1.2955
22	1.5242	1.2193	1.1431	1.6766	1.6004	1.1431	1.7147
23	1.5623	1.2955	1.1431	1.6575	1.4861	1.0669	1.7528
24	.9145	1.5242	1.3336	1.105	1.6575	1.2193	1.0288
Max	1.6575	1.9052	1.5242	1.7528	1.6766	1.5623	1.7528
Min	.9145	.6859	.8383	.9907	.6668	.9145	.8764
Avg	1.3162	1.3797	1.1995	1.4083	1.3813	1.1376	1.2019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 203 / 11 KV WENA FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4001	.381	.1905	.4191	.4001	.4001
2	.362	.4001	.381	.381	.4191	.4001	.4001
3	.362	.381	.4001	.381	.4001	.4001	.4001
4	.362	.381	.4001	.4001	.4001	.4001	.4001
5	.362	.381	.4001	.4001	.4001	.4001	.4191
6	.362	.4001	.4001	.4001	.4001	.4001	.4001
7	.381	.381	.4001	.4001	.4191	.4001	.4001
8	.381	.1715	.4191	.4001	.4001	.381	.4001
9	.381	.381	.4001	.4001	.4191	.4001	.4001
10	.4001	.4001	.4001	.4191	.4191	.4001	.4001
11	.381	.4001	.4001	.4191	.4191	.4001	.4001
12	.381	.4001	.4001	.4001	.4191	.381	.4001
13	.381	.4001	.4001	.4191	.4191	.4001	.4191
14	.381	.4001	.4001	.4191	.4191	.381	.4191
15	.381	.4001	.4001	.4001	.4191	.381	.4191
16	.381	.4001	.4001	.4001	.4191	.4001	.4001
17	.381	.381	.4001	.4001	.4191	.4001	.4001
18	.381	.4001	.4001	.4001	.4191	.4001	.4001
19	.381	.4001	.4001	.381	.4191	.4001	.4001
20	.1715	.1905	.4001	.4191	.4191	.4001	.4001
21	.1905	.1905	.4001	.4001	.4001	.4572	.4001
22	.2096	.2096	.4191	.4191	.4001	.4001	.4001
23	.2096	.1905	.4001	.4001	.4001	.4001	.4001
24	.362	.4001	.381	.4001	.4001	.4001	.4001
Max	.4001	.4001	.4191	.4191	.4191	.4572	.4191
Min	.1715	.1715	.381	.1905	.4001	.381	.4001
Avg	.3453	.3517	.3993	.3937	.4120	.3993	.4033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 204 / CHANVIM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.1143	.0953	.0953
2	.0953	.0953	.0953	.0762	.1143	.0762	.0953
3	.0762	.0762	.0762	.0762	.1143	.0762	.0953
4	.0762	.0762	.0762	.0762	.1143	.0762	.0953
5	.0762	.0762	.0762	.0762	.0953	.0762	.0953
6	.0762	.0762	.0762	.0762	.0762	.0762	.0953
7	.0953	.0762	.1143	.0762	.1143	.0762	.0953
8	.1715	.0762	.1143	.0953	.1143	.0762	.1143
9	.2286	.2667	.0953	.1905	.2286	.1905	.2096
10	.3048	.3429	.0953	.2858	.4191	.1905	.2858
11	.3048	.381	.0762	.362	.381	.3429	.3048
12	.3429	.381	.0762	.3429	.2667	.2858	.3048
13	.381	.4001	.0762	.3048	.3429	.3239	.3239
14	.4191	.4191	.0762	.381	.3239	.3048	.3048
15	.4191	.4191	.0762	.3429	.3239	.3048	.3048
16	.4572	.4191	.0762	.2667	.3048	.362	.3048
17	.381	.4572	.0762	.2858	.2858	.381	.3048
18	.2667	.3048	.0762	.2477	.2667	.2858	.2858
19	.2286	.2858	.0762	.2286	.2667	.2858	.2858
20	.1905	.1905	.0953	.1905	.2477	.1905	.1905
21	.1524	.1905	.0953	.1143	.1524	.1524	.1524
22	.0953	.1524	.0953	.1143	.0953	.1524	.0953
23	.0953	.1524	.0953	.1143	.0953	.1334	.0953
24	.1143	.0953	.1524	.0953	.1143	.0762	.0953
Max	.4572	.4572	.1524	.381	.4191	.381	.3239
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0953
Avg	.2143	.2294	.0889	.1881	.2072	.1913	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 206 / 11KV GONDKHAIRY AG SEP SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0191	.0381	.0191	.0381	.0191
2	.0191	.0381	.0191	.0381	.0191	.0381	.0191
3	.0191	.0381	.0191	.0381	.0191	.0381	.0191
4	.0191	.0381	.0381	.0381	.0191	.0381	.0191
5	.0191	.0191	.0191	.0381	.0191	.0381	.0191
6	.0191	.0191	.0191	.0381	.0191	.0191	.0191
7	.0191	.0191	.0191	.0381	.0191	.0191	.0191
8	.0191	.0381	.0381	.0381	.0191	.0191	.0191
9	.0381	.0381	.0762	.0762	.0762	.0381	.0572
10	.0381	.0572	.0762	.0953	.0762	.0381	.0572
11	.0381	.0381	.0953	.0953	.0762	.0381	.0381
12	.0572	.0381	.0762	.0762	.0762	.0381	.0191
13	.0381	.0381	.0762	.0762	.0572	.0381	.0381
14	.0572	.0381	.0762	.0953	.0762	.0191	.0381
15	.0572	.0381	.0762	.0953	.0762	.0191	.0381
16	.0572	.0762	.0762	.0762	.0762	.0381	.0191
17	.0191	.0191	.0191	.0191	.0381	.0191	.0191
18	.0191	.0191	.0191	.0191	.0381	.0381	.0191
19	.0381	.0191	.0381	.0191	.0381	.0381	.0191
20	.0381	.0381	.0381	.0381	.0381	.0191	.0381
21	.0381	.0191	.0381	.0191	.0381	.0191	.0381
22	.0381	.0191	.0381	.0191	.0381	.0381	.0381
23	.0381	.0191	.0381	.0191	.0381	.0191	.0381
24	.0191	.0381	.0191	.0381	.0191	.0381	.0191
Max	.0572	.0762	.0953	.0953	.0762	.0381	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0326	.0334	.0445	.0492	.0429	.0310	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 207 / 11 KV NEW TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.8764	.8002	.7621	.7621	.7621	.5716
2	.724	.8764	.724	.7621	.724	.724	.5144
3	.6097	.8383	.6668	.7049	.724	.6859	.5144
4	.6097	.8002	.724	.6668	.6668	.6859	.4763
5	.5716	.724	.6668	.6478	.6478	.6478	.4763
6	.5716	.6859	.6097	.6287	.6097	.5716	.4572
7	.5335	.6478	.5335	.6287	.5716	.5335	.4572
8	.6097	.4572	.5525	.4763	.5716	.5144	.4191
9	.7621	.6097	.4954	.5716	.5716	.5144	.4572
10	.7621	.724	.5144	.5716	.6287	.5335	.5335
11	.8573	.8002	.5335	.6859	.8002	.4954	.5716
12	.8573	.8383	.5144	.743	.8573	.4954	.6097
13	.8573	.8383	.724	.7811	.8383	.4954	.6287
14	.8764	.8192	.724	.7621	.8192		.6097
15	.8764	.9145	.6859	.9145	.8383	.1905	.6478
16	.8573	.9526	.6859	.9335	.8383	.2667	.6478
17	.8383	.9526	.6859	.8573	.7621	.2096	.6859
18	.8192	.8954	.5716	.8192	.6668	.5335	.7621
19	.8383	.9526	.6859	.8383	.724	.5716	.8192
20	.8764	.8002	.7621	.8192	.7621	.6097	.8954
21	.8764	.9145	.7621	.8764	.7811	.6097	.8192
22	.9526	.9335	.8573	.9145	.8002	.6097	.8192
23	.9145	.9526	.7621	.8383	.7811	.6097	.8002
24		.8954	.8002	.7621	.8002	.7621	.5716
Max	.9526	.9526	.8573	.9335	.8573	.7621	.8954
Min	.5335	.4572	.4954	.4763	.5716	.1905	.4191
Avg	.7654	.8208	.6684	.7486	.7311	.5492	.6152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 401 / 33 KV NISHANT TUBE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5729	9.2593	10.2881	9.145	8.5734	9.145	8.8592
2	9.145	9.0306	10.0595	9.4307	8.9163	9.2593	9.7165
3	10.4024	8.6877	9.4307	9.7165	10.1166	9.0306	9.145
4	8.8592	9.6022	8.2876	8.6877	10.2881	8.6877	8.8592
5	8.2876	8.9163	8.9163	8.0018	8.8592	8.4591	8.5734
6	7.8875	8.802	8.2876	7.7161	8.4019	8.1162	8.4591
7	9.145	8.4591	8.0018	6.5158	8.4591	8.2305	8.1162
8	8.7449	8.2305	7.8875	6.973	8.6877	8.0018	7.4303
9	9.145	8.6877	7.3731	8.3448	8.8592	8.1162	8.3448
10	8.9163	9.4879	7.2017	8.8592	8.802	9.4879	8.4591
11	9.0878	9.145	9.2593	9.2021	9.0878	8.8592	7.1445
12	9.145	9.7165	9.145	8.7449	8.8592	8.5162	7.5446
13	8.2876	8.5734	8.6306	10.0023	9.0306	4.5725	8.1162
14	6.4015	9.0878	9.7737	10.3452	8.5734	2.1148	8.5734
15	9.0306	9.6022	8.7449	9.0306	8.9163	10.8596	8.3448
16	9.2593	8.9735	8.2876	8.9163	9.3164	5.7156	8.5162
17	9.6022	7.9447	10.8596	9.4879	8.8592	6.8587	8.1162
18	8.8592	9.4307	8.8592	8.5734	1.8861	8.3448	8.2305
19	9.2021	9.145	8.2876	8.2876	5.8299	8.6306	6.9159
20	9.145	8.9163	6.9159	7.7161	7.8875	8.1162	8.3448
21	8.6306	9.145	7.5446	7.7161	5.6584	8.5162	8.6877
22	8.0018	8.6877	8.6306	9.3736	8.2305	10.2881	8.1162
23	8.4591	8.2876	9.145	7.7161	9.145	9.145	7.9447
24	5.0869	8.9163	11.2026	8.8592	8.5162	8.802	8.5734
Max	10.4024	9.7165	11.2026	10.3452	10.2881	10.8596	9.7165
Min	5.0869	7.9447	6.9159	6.5158	1.8861	2.1148	6.9159
Avg	8.5544	8.9473	8.7925	8.6401	8.3233	8.1614	8.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 201 / 11 KV MIDC -I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.5466	1.4146	1.6975	1.7147	1.6975	.4572
2	1.2765	1.3717	1.4523	1.6032	1.6956	1.6221	.4763
3	1.2574	1.2346	1.4712	1.5466	1.6956	1.5089	.4763
4	1.2193	1.3769	1.5278	1.5278	1.6575	1.3957	.5144
5	1.2003	1.3957	1.5655	1.5466	1.6575	1.3203	.5144
6	1.1622		1.6032	1.5655	1.6385	1.1317	.5716
7	1.1431	1.1317	1.5466	1.6975	1.6004	1.0562	.6097
8	1.6385	.7167	1.9616	1.8272	2.1338	.7733	1.4098
9	2.0936	2.2068	2.1502	2.3815		.9717	1.7164
10	2.1524	2.1502	2.6595	2.572	2.6029	1.0288	1.7164
11	2.1502	2.4897	2.8292	2.8197	2.3388	.6668	1.9616
12	1.9447	2.4331	1.9376	2.6482	2.4709	.6668	1.9239
13	1.9427	2.2634	1.8861	2.3815	2.4897	.743	2.037
14	1.9427	2.6406	2.2445	2.3053	2.3388	.7811	2.0748
15	2.3577	2.452	2.2634	2.572	2.4143	.7811	2.1313
16	2.3577	2.6217	2.4143	2.4768	2.3765	.6668	1.6975
17	2.1313	2.452	2.452	2.3434	2.3765	.5525	1.905
18	1.9616	1.9239	1.8107	2.1338	1.9805	.4001	1.7541
19	1.9239	1.7918	1.8296	2.0195	1.8861	.4382	1.5844
20	1.8673	1.8107	1.8107	1.848	1.8107	.4572	1.4712
21	1.8296	1.8296	1.4746	1.7909	1.7353	.4382	1.5466
22	1.8673	1.8484	1.406	1.7718	1.8107	.4572	1.4523
23	1.7353	1.6221	1.4918	1.7337	1.7541	.4763	1.6598
24	1.3527	1.4575	1.3769	1.6975	1.7147	1.7353	.4572
Max	2.3577	2.6406	2.8292	2.8197	2.6029	1.7353	2.1313
Min	1.1431	.7167	1.3769	1.5278	1.6004	.4001	.4572
Avg	1.7434	1.8595	1.8575	2.0211	1.9954	.9070	1.3383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 202 / 11 KV MIDC-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5093	.8299	.9808	.743	.5281	.4954
2	.4954	.4904	.811		.724	.4904	.4954
3	.4001	.5093	.7922	.9054	.724	.4904	.4954
4	.362	.4904	.7545	.9431	.7049	.4715	.5144
5	.362	.5093	.7167	.9619	.6859	.4527	.5144
6	.3429	.5093	.6979	.9242	.6859	.4715	.5144
7	.3239	.9808	.7733	.2075	.5144	.4715	.5335
8	1.0288	1.2738	.8488	.7545	1.0669	.6413	.5716
9	1.1128	1.3203	.9997	1.0098	1.2449	.6287	.6602
10	1.4146	1.5844	1.5844	.9907	1.5844	.6097	1.0751
11	1.7353	1.5844	1.5844	1.1622	1.6032	.6668	1.2637
12	1.3392	1.1883	1.6409	1.4861	1.7164	.5335	1.1128
13	1.3203	1.1694	1.4523	1.4861	1.5655	.5906	1.1317
14	1.8673	1.4712	1.7353	1.5432	1.1694	.5144	1.2071
15	1.6598	1.5089	1.3014	1.6385	1.2071	.5716	1.2449
16	1.7918	1.6409		1.5242	1.2449	.4763	1.1317
17	1.6598	1.6032	1.6032	1.4861	1.2637	.4382	1.1128
18	.9774	1.1694	.8676	.7621	.811	.4191	.7167
19	.9431	.8488	.8865	1.0479	.7356	.4763	.6602
20	.9054	.8865	.7733	.8573	.6413	.4572	.547
21	.9431	.8299	.6036	.8002	.5847	.4954	.5281
22	.9242	.7545	.8676	.7811	.5281	.4572	.4904
23	.7167	.8299	.5847	.7621	.547	.4763	.6036
24	.6097	.4973	.8488	1.0751	.7621	.5281	.4763
Max	1.8673	1.6409	1.7353	1.6385	1.7164	.6668	1.2637
Min	.3239	.4904	.5847	.2075	.5144	.4191	.4763
Avg	.9920	1.0067	1.0243	1.0474	.9608	.5149	.7540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 203 / 11 KV GONDKHAIRY

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.5658	.7545	.9431	1.2574	.7545	.6478
2	.1905	.4904	.7167	.9054	1.2193	.7167	.5906
3	.1905	.5281	.7167	.9054	1.1622	.7167	.5716
4	.2096	.5093	.6979	.8865	1.1241	.679	.5716
5	.2096	.4904	.679	.9431	1.0288	.6602	.4954
6	.2286	.4904	.679	.9242	.9526	.679	.4572
7	.2286	.4225	.6979	.9619		.5847	.4382
8	.2477	.5093	.7922	1.094	.1715	.7167	
9	.3018	.4527	.8676	1.3146	.3018	.7049	.132
10	.415	.679	.6036	1.3908		.6478	.1132
11	.415	.4338	.8676	1.3527	1.358		.0943
12	.1132	.4904	1.0374	.2477	1.3392	.1905	.1132
13	.3772	.2263	.9808	.8573	1.226	.2858	.1132
14	.415	.5093	.8676	1.2384	1.226	.362	.1132
15	.2829	.4904	.8488	1.2193	1.094	.3048	.1132
16	.3584	.6979	.8488	1.1622	1.0185	.381	.0943
17	.3772	.6979	.9242	1.1431	.9808	.4191	.1132
18	.9431	.7733	.8573	1.4098	.9242	.4572	
19	.6224	.7356	.9858	1.467	.8865		.4904
20	.679	.7356	.9997	1.3527	.8488	.6097	.2452
21	.679	.7922	1.0751	1.3908	.811		.3395
22	.6602	.8488	1.0751	1.3908	.811	.6668	.3772
23	.6413	.7922	.9808	1.3527	.7733	.6859	.3772
24	.1905	.6224	.7545	.9619	1.3336	.7545	.6668
Max	.9431	.8488	1.0751	1.467	1.358	.7545	.6668
Min	.1132	.2263	.6036	.2477	.1715	.1905	.0943
Avg	.3820	.5827	.8462	1.1173	.9931	.5704	.3304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 204 / 11 kv Mohapa

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0189	.0377	.0377	.0381	.0189	.0381
2	.0381	.0189	.0377	.0377	.0381	.0189	.0381
3	.0381	.0189	.0377	.0377	.0381	.0189	.0381
4	.0381	.0189	.0377	.0377	.0381	.0189	.0381
5	.0381	.0189	.0377	.0377	.0381	.0189	.0381
6	.0381	.0344	.0377	.0377	.0381	.0189	.0381
7	.0191	.0377	.0377	.0377	.0572	.0189	.0381
8	.0381	.0189	.0377	.0377	.0381	.0189	.0381
9	.0377	.0189	.0377	.0381	.0377	.0191	.0377
10	.0189	.0189	.0343	.0381	.0377	.0191	.0189
11	.0377	.0377	.0377	.0381	.0377	.0191	.0189
12	.0171	.0189	.0377		.0189	.0191	.0189
13	.0189	.0377	.0377		.0189	.0381	.0189
14	.0189	.0377	.0189	.0191	.0377	.0381	.0189
15	.0377	.0189	.0189	.0191	.0377	.0191	.0189
16	.0189	.0189	.0377	.0191	.0377	.0381	.0189
17	.0171	.0189	.0189	.0191	.0189	.0381	.0189
18	.0189	.0377	.0189	.0191	.0189	.0191	.0189
19	.0377	.0377	.0377	.0381	.0377	.0381	.0189
20	.0377	.0566	.0377	.0572	.0377	.0381	.0189
21	.0189	.0566	.0343	.0572	.0377	.0381	.0189
22	.0189	.0566	.0377	.0572	.0377	.0381	.0377
23	.0189	.0566	.0377	.0381	.0377	.0381	.0189
24	.0381	.0189	.0377	.0377	.0381	.0377	.0381
Max	.0381	.0566	.0377	.0572	.0572	.0381	.0381
Min	.0171	.0189	.0189	.0191	.0189	.0189	.0189
Avg	.0291	.0305	.0343	.0362	.0355	.0269	.0277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 206 / 11 KV STEEL ASSOCIATE
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3395	.3395	.3206	.3239	.3206	.3429
2	.3429	.3395	.3395	.3018	.3239	.3206	.3429
3	.3429	.3426	.3395	.3045	.3239	.3018	.3239
4	.3429	.3395	.3395	.3206	.3429	.3018	.3239
5	.362	.3395	.3395	.3395	.3429	.3206	.3239
6	.3429	.3584	.3584	.3395	.3429	.3395	.3239
7	.362	.3395	.3395	.3395	.3429	.3584	.3429
8	.362	.3395	.3206	.2832	.3239	.3395	.3429
9	.6036	.3018	.3395	.2667	.3018	.3429	.3206
10	.679	.3772	.547	.5144	.6224	.362	.3395
11	.5093	.7167	.823	.2477	.5281	.362	.2829
12	.703	.7922	.7356	.7811	.5093	.362	.3206
13	.4904	.7545	.547	.5144	.3961	.3429	.3395
14	.4338	.679	.547	.8383	.5093	.3429	.3584
15	.3018	.7356	.3961	1.4098	.7545	.362	.3584
16	.547	.6413	.3206	1.3527	.7167	.362	.3961
17	.3395	.679	.3206	.5716	.7167	.362	.415
18	.3584	.679	.4715	1.0098	.4527	.3429	.547
19	.2829	.4527	.547	.5335	.4527	.362	.4338
20	.3086	.3395	.7733	.3429	.3772	.381	.3395
21	.3395	.3395	.3206	.3429	.3395	.362	.3395
22	.3395	.3395	.3395	.3429	.3395	.362	.3395
23	.3395	.3395	.3395	.3429	.3206	.362	.3206
24	.362	.3395	.3395	.3395	.3429	.3206	.3429
Max	.703	.7922	.823	1.4098	.7545	.381	.547
Min	.2829	.3018	.3206	.2477	.3018	.3018	.2829
Avg	.4066	.4685	.4343	.5125	.4311	.3457	.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 208 / 11 KV KALMESHWAR U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2481	2.4143	2.6783	2.8292	2.8578	2.3577	2.0957
2	2.0767	2.3577	2.5652	2.6217	2.6863	2.3011	2.0195
3	1.9243	2.2634	2.452	2.4897	2.5911	2.2634	1.9433
4	1.9052	2.1691	2.3011	2.3577	2.3053	2.1502	1.829
5	1.829	2.0748	2.1879	2.1691	2.21	1.9993	1.7147
6	1.7909	1.9427	2.0748	2.0748	2.0576	1.8673	1.6004
7	1.7528	1.6975	1.8484	1.773	1.7337	1.6409	1.5623
8	1.5623	1.5466	1.6787	1.6221	1.5432	1.4523	1.4289
9	1.6032	1.6598	1.4746	1.6766	1.6787	1.5051	1.3957
10	1.4335		1.4918	1.7147	1.6787	1.5813	1.4901
11	1.5466		1.8296	1.829	1.6032	1.467	1.4712
12	1.5466		1.8861	1.9243	1.7353	1.5242	1.358
13	1.6221	2.3388	2.0182	2.0767	1.7164	1.4289	1.358
14	1.6598	2.3388	2.1691	2.21	1.8861	1.3908	1.3769
15	1.7164	2.3388	1.9547	2.3624	1.905	1.3527	1.3769
16	1.6409	2.1879	2.0936	2.2862	1.8107	1.4098	1.3957
17	1.6787	2.1691	1.9805	2.0957	1.6975	1.5051	1.4146
18	1.6598	1.905	1.8107	1.9433	1.5844	1.4098	1.4523
19	2.0559	2.4143	2.0748	2.0576	1.8484	1.7718	1.7164
20	2.4143	2.5463	2.4331	2.7054	1.9993	1.9624	1.7541
21	2.452	2.6783	2.4709	2.7816	2.2257	2.0957	1.7164
22	2.4897	2.8292	2.6972	2.9721	2.3765	2.1338	1.6975
23	2.5463	2.9801	2.9613	2.9912	2.5086	2.1719	1.6787
24	2.572	2.6217	2.8292	2.9047	2.9531	2.452	2.1529
Max	2.572	2.9801	2.9613	2.9912	2.9531	2.452	2.1529
Min	1.4335	1.5466	1.4746	1.6221	1.5432	1.3527	1.358
Avg	1.9053	2.2607	2.1651	2.2695	2.0497	1.7998	1.6250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 210 / 11 KV AGSEPARATED GHOGLI
FEEDER Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0189	
2						.0189	
3						.0189	
4				.0189		.0189	
5				.0189		.0189	
6				.0189		.0377	
7				.0189		.0566	
8				.0189	.1334	.0566	
9					.0754	.0381	
10	.0171	.0377	.0189				.0189
11	.0377	.0377	.0189				.0189
12	.0189	.0189	.0566				.0189
13	.0189	.0189	.0377				.0189
14	.0189	.0189	.0377				.0189
15	.0189	.0189	.0377				.0189
16	.0171	.0189	.0377				.0189
17	.0189	.0189	.0566				.0189
23			.0189				
24				.0189		.0189	
Max	.0377	.0377	.0566	.0189	.1334	.0566	.0189
Min	.0171	.0189	.0189	.0189	.0754	.0189	.0189
Avg	.0208	.0236	.0356	.0189	.1044	.0302	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 211 / 11 kv NEW DHAPEWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-JUN-18	25-JUN-18
HR	Load (MW)	Load (MW)
24	.0189	.019
Max	.0189	.019
Min	.0189	.019
Avg	.0189	.019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 212 / 11 KV GURUNANAK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.0754	.0943	.1132	.0762	.0943	.0762
2	.6097	.0754	.0943	.0943	.0953	.0754	.0762
3	.6287	.0754	.0943	.0943	.0953	.0754	.0762
4	.6287	.0754	.0754	.0943	.0953	.0566	.0953
5	.6478	.0754	.0754	.0943	.0762	.0566	.0953
6	.6287	.0754	.0943	.0754	.0762	.0754	.0953
7	.6478	.0754	.0754	.0566	.0762	.0754	.0953
8	.4954	.0943	.0754	.0943	.0762	.0754	.0953
9	.2829	.3395	.0943	.0572	.0943	.1524	.0754
10	.3772	.3584	.1132	.0953	.1132	.1524	.0754
11	.3772	.3772	.0943	.0953	.0754		.0754
12	.3961	.3206	.0754	.0953	.0943	.1524	.1132
13	.132	.0943	.0943	.0953	.0943	.1524	.1132
14	.3772	.3206	.0943	.7621	.0943	.0762	.0943
15	.3395	.2641	.0943	.8573	.1132	.1906	.0943
16	.415	.1132	.0943	.7621	.1132	.1524	.0943
17	.1132	.0754	.0943	.743	.0943	.0762	.0943
18	.0754	.0943	.0943	.724	.0754	.0572	
19	.0857	.0943	.0943	.0953	.0754	.0953	.0943
20	.0943	.0943	.1132	.0762	.0943	.0953	.0754
21	.0943	.0943	.0943	.1143	.0943	.0953	.0943
22	.0754	.0943	.1132	.0762		.0953	.0943
23	.0754	.0943	.1132	.0762	.1886	.0953	.0754
24	.6097	.0754	.0943	.1132	.0762	.0943	.0762
Max	.6478	.3772	.1132	.8573	.1886	.1906	.1132
Min	.0754	.0754	.0754	.0566	.0754	.0566	.0754
Avg	.3674	.1469	.0935	.2315	.0938	.1008	.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 201 / 11 KV Dhapewada town
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.463	.5144	.5716	.4287	.4001
2	.381	.4458	.4458	.5144	.5525	.4287	.381
3	.381		.4458	.4954	.5525	.4458	.381
4	.381	.4458	.4458	.4572	.5335	.4458	.381
5	.3429		.3772	.4191	.4954	.4458	.362
6	.3048	.3601	.3429	.381	.4382	.3429	.3429
7	.2096		.2915	.3239	.3429	.3086	.2667
8	.1905	.2743	.2743	.2858	.2477	.2572	.2477
9			.2572	.2858	.2477	.2915	.2286
10	.3239	.4287	.3239	.4191	.2743	.2858	.3048
11	.4572	.463	.362	.381	.2743	.2858	.3048
12	.4191	.4801	.381	.4382	.3258	.3048	.2858
13	.4191	.4458	.4191	.4382	.3258	.2667	.2858
14	.4382	.4973	.4191	.4382	.3429	.2858	.3048
15	.4382	.5144	.4191	.4382	.3429	.2858	.3048
16		.4801	.4001	.4572	.3258	.2858	.3239
17		.463	.4001	.4191	.3086	.2858	.2667
18		.4287	.362	.4191	.3258	.2858	.3429
19	.6097	.463	.4001	.4382	.3429	.362	.381
20	.5335	.4287	.4572	.4954	.4287	.4382	.362
21	.5335	.463	.4954	.4954	.4287	.4001	.362
22	.4954	.4801	.5335	.6097	.4801	.4382	.362
23	.5144	.4801	.5525	.5335	.463	.4191	.362
24	.4572	.4954	.4801	.5335	.5716	.463	.4001
Max	.6097	.5144	.5525	.6097	.5716	.463	.4001
Min	.1905	.2743	.2572	.2858	.2477	.2572	.2286
Avg	.4121	.4493	.4062	.4430	.3976	.3537	.3310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 202 / 11 KV Dhapewada Ag
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.4287	.5335	.4572	.3944	.362
2	.4001	.3601	.5144	.5144	.4572	.3944	.362
3	.4001		.4973	.4572	.4382	.3772	.362
4	.4001	.3429	.5281	.4191	.4191	.3772	.3429
5	.4001		.4115	.4191	.381	.3772	.3239
6	.3429	.2915	.3429	.381	.3239		.3048
7	.2667		.1886	.381	.3429	.2743	
8	.3048	.2743	.1715	.4382	.4191	.2743	
9	.3239			.4382	.4382	.3429	.0381
10	.2858	.2229	.381	.4763	.3601	.3048	.1905
11	.2858	.2915	.381	.5144	.3944	.2286	.2858
12	.2858	.3086	.381	.4382	.463	.2477	.2477
13	.2858	.4115	.4382	.4954	.4458	.2477	.2096
14	.3048	.3772	.4572		.4115	.2096	.2477
15	.2858	.3601	.4382	.5144	.4115	.2286	.2477
16	.2667	.3429	.381	.4954	.4458	.2286	.2096
17	.3048	.3429	.3239	.4763	.2743	.2096	.2286
18	.2858	.3429	.3239	.5144	.2915	.2286	.2096
19	.2858	.3258	.381	.4954	.3086	.3239	.2667
20	.362	.3944	.4382	.5144	.3772	.3429	.3048
21	.4001	.463	.4572	.5335	.4115	.381	.3048
22	.4572	.5316	.5144	.5335	.3944	.381	.3239
23	.4763	.4458	.5335	.4572	.3944	.381	.3239
24		.4191	.4287	.5525	.4572	.3944	.381
Max	.4763	.5316	.5335	.5525	.463	.3944	.381
Min	.2667	.2229	.1715	.381	.2743	.2096	.0381
Avg	.3388	.3605	.4061	.4780	.3966	.3109	.2763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 203 / 11 KV Purti feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
11	.0191		
12	.0191		
14	.0191	.0171	
15	.0381		.0191
16	.0191		
17		.0171	
Max	.0381	.0171	.0191
Min	.0191	.0171	.0191
Avg	.0229	.0171	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 201 / 11 KV KALMESHWAR NEW URBAN SHEDDABLE URBAN
FEE Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.2477	.2477	.2477	.2286	.2286	.1905
2	.1524	.2286	.2286	.2286	.1905	.2096	.1905
3	.1524	.1905	.1905	.2286	.1905	.1905	.1715
4	.1334	.1905	.1905	.1905	.1905	.1905	.1715
5	.1715	.1905	.1905	.1524	.1715	.1715	.1524
6	.1905	.1715	.2096	.1524	.1715	.1524	.1524
7	.2096	.2096	.1524	.1905	.1715	.2096	.1524
8	.2667	.1524	.1905	.1905	.2096	.2477	.1524
9	.2096	.2096	.2286	.2286	.2286	.1905	.1715
10	.3048	.2667	.3429	.362	.3429	.2477	.381
11	.3048	.2477	.2858	.4191	.2667	.1715	.4001
12	.2858	.3048	.3429		.2667	.2286	.3048
13	.1715	.2858	.2096		.0191	.1334	.2667
14	.1905	.2286	.2096		.1715	.1905	.1524
15	.3048	.3048	.3429		.3429	.1905	.1334
16	.3048	.2286	.2286		.2096	.1524	.1524
17	.2858	.2667	.2858		.2096	.1905	.1905
18	.1715	.1715	.1524		.1524	.1524	.1524
19	.1905	.1905	.1715		.1905	.1905	.1905
20	.2096	.2286	.2096		.2286	.1905	.1715
21	.2858	.2477	.2286		.1905	.1905	.2096
22	.2286	.2477	.2477		.2096	.1905	.2096
23	.2286	.2477	.2477	.2477	.2096	.1905	.1715
24	.1143	.2286	.2477	.2477	.2286	.2096	.1905
Max	.3048	.3048	.3429	.4191	.3429	.2477	.4001
Min	.1143	.1524	.1524	.1524	.0191	.1334	.1334
Avg	.2167	.2286	.2326	.2374	.2080	.1921	.1993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 203 / 11 KV KALMESHWAR AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0572		.0191	
2				.0572		.0191	
3				.0381		.0191	.0381
4				.0381			
5				.0381			
6				.0381			.0381
7				.0762			
8				.0762			
9			.0191	.0762	.0572		
10			.0381	.0762	.0572	.0381	
11		.0381	.0191	.0762	.0572		
12					.0572		
14			.0381		.0572		.0381
15	.0191		.0381		.0381		
16	.0191		.0572				
17	.0191		.0762		.0381		
18	.0381	.0191	.0572		.0381		
19	.0381	.0381	.0572		.0191		
20			.0381		.0191		
21			.0572		.0381		
22			.0572		.0191		
23			.0572		.0191		
24				.0572		.0191	
Max	.0381	.0381	.0762	.0762	.0572	.0381	.0381
Min	.0191	.0191	.0191	.0381	.0191	.0191	.0381
Avg	.0267	.0318	.0469	.0588	.0396	.0229	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 204 / 11 KV DAHEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.2477	.2667	.2477	.2286	.2096	.2096
2	.6478	.2286	.2286	.2286	.2286	.2096	.1905
3	.6097	.2286	.2286	.2286	.2096	.1905	.1905
4	.5716	.2286	.1905	.2286	.1905	.1905	.1905
5	.5716	.2096	.1905	.1905	.2477	.1905	.1715
6	.5335	.1905	.1905	.1905	.3048	.1715	.1715
7	.5716	.2096	.1905	.2096	.2858	.1715	.1143
8	.1905	.2096	.3048	.2477	.3048	.2477	.1143
9	.2477	.1905	.3048	.2667	.3429	.2286	.1905
10	.1905	.1715	.2096	.2477	.2667	.2286	.1905
11	.2096	.1524	.2286	.2667	.2286	.1334	.1524
12	.1905	.1905	.2477				.1334
13	.2096	.1905	.3048		.1905		.1334
14	.1905	.1715	.1905		.1905		.1334
15	.1905	.1905	.2286		.1524	.1143	.1524
16	.2096	.1905			.1715	.1143	
17	.2096	.1905	.1905		.1524	.1143	.1143
18	.2096	.1905	.1905		.1334	.1143	.1524
19	.1715	.2477	.1905		.1715	.1715	.1715
20	.2096	.2096	.2286		.2096	.1905	.1524
21	.2286	.2667	.2477		.2096	.1905	.1905
22	.2477	.2667	.2667		.2096	.1905	.1905
23	.2477	.2477	.2477	.2858	.2096	.1905	.1524
24	.2477	.2477	.2667	.2477	.2667	.2096	.1905
Max	.6478	.2667	.3048	.2858	.3429	.2477	.2096
Min	.1715	.1524	.1905	.1905	.1334	.1143	.1143
Avg	.3199	.2112	.2319	.2374	.2220	.1796	.1632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 205 / 11 KV GHORAD FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8002	.9145	.9907	.9907	.8383	.7049
2	.724	.7811	.8573	.9526	.9526	.8192	.6668
3	.724	.7621	.8192	.8954	.9526	.8192	.6478
4	.6478	.7621	.7621	.8383	.9145	.8002	.6097
5	.6097	.724	.743	.8002	.8764	.7811	.5716
6	.6287	.6478	.7621	.7621	.8573	.6668	.5716
7	.5906	.5716	.724	.8764	.9145	.6097	.4763
8		.6287	.724	1.0098	1.0669	.6478	.4954
9	.2667	.5716	.8192	1.2003	1.2574	.724	.5335
10	.5906		.7811	1.1241	1.2003		.5335
11	.5716		.7621	.9526	1.086		.4382
12	.5525		.7621			.3429	.381
13	.5906	.6668	.8954			.4001	.4191
14	.5144	.743	.8954		.9717	.4001	.4763
15	.4763	.743	.9145		.9145	.4572	
16	.362	.7621	.8192		.9335	.4763	.4191
17	.5144	.6859	.8764		.8002	.4763	.4572
18	.5144	.6859	.9145		.743	.4382	.4954
19	.5335	.6478	.8002		.743	.5525	.5335
20	.7049	.7621	.8573		.8383	.6478	.5335
21	.7621	.8192	.9526		.8383	.6668	.5716
22	.8192	.8764	.9907		.8383	.7049	.5716
23	.8002	.8764	.9907	1.0098	.8573	.7049	.4954
24	.743	.8002	.8764	.9717	.9907	.8383	.7049
Max	.8192	.8764	.9907	1.2003	1.2574	.8383	.7049
Min	.2667	.5716	.724	.7621	.743	.3429	.381
Avg	.6088	.7294	.8423	.9526	.9335	.6278	.5351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	23-JUN-18	24-JUN-18
HR	Load (MW)	Load (MW)
24	1.4118	1.4118
Max	1.4118	1.4118
Min	1.4118	1.4118
Avg	1.4118	1.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 401 / 33 kv INDUSTRIAL
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0288	2.7606	2.6349	2.4897	2.915	2.6029	2.0576
Max	1.0288	2.7606	2.6349	2.4897	2.915	2.6029	2.0576
Min	1.0288	2.7606	2.6349	2.4897	2.915	2.6029	2.0576
Avg	1.0288	2.7606	2.6349	2.4897	2.915	2.6029	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 402 / 33 KV Kohali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	5.4298	6.5501	6.5501	5.9414	6.5729	6.394	5.7156
Max	5.4298	6.5501	6.5501	5.9414	6.5729	6.394	5.7156
Min	5.4298	6.5501	6.5501	5.9414	6.5729	6.394	5.7156
Avg	5.4298	6.5501	6.5501	5.9414	6.5729	6.394	5.7156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 405 / 33KV OMCO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.0576	2.0519	2.1548	2.2634	1.2574	1.358	1.5432
Max	2.0576	2.0519	2.1548	2.2634	1.2574	1.358	1.5432
Min	2.0576	2.0519	2.1548	2.2634	1.2574	1.358	1.5432
Avg	2.0576	2.0519	2.1548	2.2634	1.2574	1.358	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 408 / 33 kV KSL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2286	.2286	.6287	.2829	.2286	.2829
Max	.2286	.2286	.6287	.2829	.2286	.2829
Min	.2286	.2286	.6287	.2829	.2286	.2829
Avg	.2286	.2286	.6287	.2829	.2286	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 409 / 33 kv Bazargaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	5.6013	9.3736	9.1221	9.393	10.974	9.6759
Max	5.6013	9.3736	9.1221	9.393	10.974	9.6759
Min	5.6013	9.3736	9.1221	9.393	10.974	9.6759
Avg	5.6013	9.3736	9.1221	9.393	10.974	9.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 410 / 33 KV DHAPEWADA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5144	.8573	.9374	.9054	.9717	.8488
Max	.5144	.8573	.9374	.9054	.9717	.8488
Min	.5144	.8573	.9374	.9054	.9717	.8488
Avg	.5144	.8573	.9374	.9054	.9717	.8488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 806 / 220 kV Ispat

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	14.4795	13.6031	13.4126	16.9753	16.0037	16.9753	14.0985
Max	14.4795	13.6031	13.4126	16.9753	16.0037	16.9753	14.0985
Min	14.4795	13.6031	13.4126	16.9753	16.0037	16.9753	14.0985
Avg	14.4795	13.6031	13.4126	16.9753	16.0037	16.9753	14.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 201 / 11kV Khapa-U-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808			.9242		.9808	
2	.9431			.9242		.9242	
3	.9431			.9054		.8488	
4	.9054			.9054		.7733	
5	.8488			.8676		.6979	
6	.6602			.6036		.6413	
7	.5658			.6413		.5847	
8	.6413			.6413		.5847	
9		.6602		.679	.811		
10		.6602		.679	.7922		
11		.6979		.7545	.679		
12		.6979		.8488	.679		
13		.7545		.8488	.679		
14		.7356		.9054	.679		
15		.6979		.9054	.6602		
16		.6979		.9054	.6602		
17			.7545		.6413		.7167
18			.9054		.6224		.7167
19			.9808		.6979		.7545
20			1.0185		.7545		.7545
21			1.0185		.9054		.7922
22			1.0185		.9619		.7922
23			.9808		1.0185		.811
24	.9431			.9808		1.0374	
Max	.9808	.7545	1.0185	.9808	1.0185	1.0374	.811
Min	.5658	.6602	.7545	.6036	.6224	.5847	.7167
Avg	.8257	.7003	.9539	.8188	.7494	.7859	.7625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366] BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 205 / 11kV Water Works New
Feeder KV- 11 / OUTGOING

DATE	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)
17	.6413	
18	.6224	
19	.6979	
20	.7545	
21	.9054	
22	.9619	
23	1.0185	
24		1.0374
Max	1.0185	1.0374
Min	.6224	1.0374
Avg	.8003	1.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 208 / 11 KV Kothulna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658			.9242		1.0751	
2	.5658			.9242		.9997	
3	.5281			.9054		.8865	
4	.5281			.9054		.811	
5	.3772			.9054		.7356	
6	.5281			.7545		.6602	
7	.3772			.5281		.5658	
8	.3395			.4904		.3584	
9		.5281		.4527	.4904		
10		.5658		.4527	.4904		
11		.5658		.4904	.4904		
12		.415		.4904	.415		
13		.3961		.5093	.415		
14		.415		.5281	.415		
15		.4527		.5281	.415		
16		.4527		.5658	.4338		
17			.5658		.4338		.3772
18			.7922		.4338		.4715
19			.9431		.5847		.6036
20			.9808		.7356		.7356
21			1.0562		.8865		.8488
22			1.0562		1.0374		.9431
23			.9808		1.1506		.9431
24	.4715			.9808		1.1883	
Max	.5658	.5658	1.0562	.9808	1.1506	1.1883	.9431
Min	.3395	.3961	.5658	.4527	.415	.3584	.3772
Avg	.4757	.4739	.9107	.6668	.5885	.8090	.7033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 401 / 33kv I/C Khapa- Parshioni

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5761			.8642		1.3014	
2	.7202			.8642		1.3014	
3	.7202					1.0059	
4	.8162					1.0059	
5	.8162					.9602	
6	.8642					.9145	
7	.5281					.8688	
8	.5281					.8688	
9		.7202		.7316	.9619		
10		.7202		.4572	.9619		
11		.8162		.7316	.9619		
12		.8162		.6401	.7773		
13		.8642		.5944	.7773		
14		.8642		.823	.7773		
15		.9122		.823	.7773		
16		.9122		.9145	.7773		
17			.8642		.7316		.7682
18			.8642		.7316		.8642
19			.9602		.823		.8642
20			.9602		.9145		.8642
21			.9602		1.0059		.8642
22			.9602		1.0517		.8642
23			.9602		1.0974		.8642
24	.9602			.9602		1.0974	
Max	.9602	.9122	.9602	.9602	1.0974	1.3014	.8642
Min	.5281	.7202	.8642	.4572	.7316	.8688	.7682
Avg	.7255	.8282	.9328	.764	.8752	1.0360	.8505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 201 / 11 kv Kochhi Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.8589	1.0425	1.3121	.9145		.8501
2	.8962	.7842	1.0242	1.2936	.9145	.7577	.8131
3	.8316	.7468	1.0242	1.2136	.8779	.7207	.7392
4	.7682	.7095	1.0136	1.1827	.8779	.6838	.7392
5	.7133	.6722	1.0164	1.1016	.8413	.6468	.6653
6	.6268	.6099	.8962	.8962	.5853	.5729	.462
7	.4938	.4854	.5121	.6653	.5121	.4251	.4207
8	.4115	.4805	.5487	.5487	.5853	.3601	.2561
9	.4115	.39	.6036	.4973	.5853	.3258	.2561
10	.3772	.4475	.6099	.547	.5487	.3647	.2561
11	.3812	.567	.5258	.5304	.5426	.3812	.2561
12	.3978	.567	.5258	.547	.4862	.3086	.2715
13	.4144	.5853	.3681	.5636	.4862	.2915	.2896
14	.431	.5853	.4733	.5801	.5596	.2743	.2865
15	.4144	.5914	.5784	.5801	.57	.2229	.2926
16		.823	.5434	.8238		.4144	.3658
17	.4119	.7392	.543	.7316		.4207	.4163
18	.3658	.6219	.6584	.5121		.5304	.4435
19	.6722	.8048	.8596	.5853	.7362	.8048	.4805
20	.811	1.1888	1.1888	1.0791	1.0867	1.0242	.6468
21	.9149	1.0242	1.3032	1.1523	1.258	1.0974	.7023
22	.9522	1.0242	1.4266	1.4998	1.3321	1.1706	.6283
23	.9335	1.0059	1.39	.8962	.905	1.2012	.5914
24	.9955	.8962	1.0425	1.3676	.9511	.7973	1.1827
Max	.9955	1.1888	1.4266	1.4998	1.3321	1.2012	1.1827
Min	.3658	.39	.3681	.4973	.4862	.2229	.2561
Avg	.6338	.7170	.8216	.8628	.7694	.5999	.5130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 202 / 11 kv Sironji

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.0456	1.0242		1.0974	1.0059	.7392
2	1.2437	1.0456	1.0608		1.0242	.9694	.7392
3	1.2254	.9709	1.0059		1.0242	.9145	.6653
4	1.1706	.8962	1.0164		.9511	.823	.6653
5	1.0608	.8215	.9877		.8779	.823	.5914
6	.9145	.6653	.7682		.6584	.7499	.4435
7	.6584	.4435	.3109		.5121	.567	.4435
8	.3475	.2195	.2195	.3077	.2926	.2926	.2195
9	.4024	.3658	.2926	.3224	.2926	.2926	.2195
10	.3109	.4298	.2957	.2865	.2926	.2378	.2195
11	.3582	.4066	.3439	.2865	.2172		.1829
12	.2865	.4066	.3292	.2865	.2743		
13	.2149	.439	.2715	.3582	.2715		.1829
14	.2149	.4207	.2715	.2865	.2926	.0716	.1463
15	.3582	.4066	.2561	.2865	.2926	.1433	.1463
16	.3582	.724		.3658		.1463	
17	.439	.5121		.439		.1463	
18	.3696	.543		.439		.5121	
19	.5914	.7316		.6584	.7499	.7316	
20	1.0349	1.0974		1.0974	1.1157	.8779	
21	1.1827			1.1706	1.2308	1.0242	
22	1.1949			1.1706	1.3169	1.0242	
23	1.1203	.9877		1.0974	1.0974	.9511	
24	1.2437	1.1203	1.0059		1.0974	1.0425	.961
Max	1.2803	1.1203	1.0608	1.1706	1.3169	1.0425	.961
Min	.2149	.2195	.2195	.2865	.2172	.0716	.1463
Avg	.7326	.6682	.5913	.5537	.7133	.6356	.4377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 203 / 11 kv Industrial Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10				.0358	.0549	
11		.0181	.0381	.0358	.0503	.0377
12		.0183	.0377	.0358	.0509	.0377
13		.0183	.0566	.0358	.0514	.0377
14	.0179	.0181	.0373	.0358	.0497	.0377
15	.0537	.0183	.0377	.0537	.0503	.0377
16	.0537	.0185	.0566	.0366		.0377
17	.0537	.0183	.0191	.0366		
18	.0366	.0183	.0191			
19			.0191			
20			.0191			
21			.0191			
22			.0191			
Max	.0537	.0185	.0566	.0537	.0549	.0377
Min	.0179	.0181	.0191	.0358	.0497	.0377
Avg	.0431	.0183	.0316	.0382	.0513	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 402 / 33kV Chargaon I/C from
Khapa Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	.9522	.9877	1.2323	.9877	.9328	.6653
2	1.1643	.8962	.9877	1.2197	.9328	.8779	.7207
3	1.1643	.8402	.9328	1.1203	.9328	.8316	.6653
4	1.0974	.7842	.9328	1.1203	.8779	.7762	.6653
5	1.0425	.7282	.9328	1.0082	.823	.7207	.6099
6	.8871	.6099	.8779	.8402	.6584	.6653	.4435
7	.679	.4481	.823	.6161	.6036	.499	.4435
8	.7362	.7762	.823	.9328	.8779	.6687	.4435
9	.6882	.6584	.8871	.8596	.9877	.6687	.4938
10	.6104	.8059	.9328	.8596	.9877	.6036	.4938
11	.6984	.8871	.9328	.8596	.823	.3224	.4887
12	.6447	.9328	.9328	.8596	.8048	.2686	.3361
13	.6447	.9877	.6447	.9671	.7865	.3224	.5487
14	.7522	.9979	.8596	.9134	.8745	.3224	.5487
15	.7522	.9877	.8505	.9134	.8951	.3224	.5544
16	.3224	.7682	.5373	.7133		.439	.499
17	.439	.6584	.5487	.6036		.3841	.4938
18	.4435	.6036	.6099	.439		.5487	.5487
19	.6653	.7682	1.0534	.6036	.6687	.9328	.6036
20	.9425	1.0425	1.1643	1.1523	1.0631	.9877	.7762
21	1.0534	.5544	1.2752	1.1523	1.1317	1.0425	.8316
22	1.0642	.7207	1.3306	1.3169	1.2226	1.0974	.7762
23	1.0082	.823	1.3169	.9259	1.0517	1.1088	.7207
24	1.2071	.9522	.8779	1.3306	1.0425	.9036	1.0534
Max	1.2197	1.0425	1.3306	1.3306	1.2226	1.1088	1.0534
Min	.3224	.4481	.5373	.439	.6036	.2686	.3361
Avg	.8303	.7993	.9188	.9400	.9064	.6770	.6010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 201 / SBM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0293	.0362	.0293		.0362	.0305
2		.0293	.0362	.0293		.0343	.0305
3	.0343	.0293	.0343	.0297	.0343	.0362	.0305
4		.0293	.0343	.0293		.0343	.0305
5		.0293	.0343	.0293		.0343	.0305
6	.0343	.0293	.0343	.0293	.0343	.0343	.0305
7	.0343	.0293	.0343	.0293		.0343	.0305
8		.0293	.0343	.0293		.0362	.0305
9	.0343	.0293	.0362	.0293	.0343	.0343	.0305
10	.0293	.0362	.0293		.0343	.0305	.0362
11	.0293	.0362	.0293	.0343	.0343	.0305	.0343
12	.0293	.0362	.0293		.0343	.0305	.0343
13	.0293	.0362	.0293	.0343	.0362	.0305	.0343
14	.0293	.0362	.0293		.0362	.0305	.0362
15	.0293	.0362	.0293	.0343		.0305	.0362
16	.0293		.0293		.0343	.0305	.0362
17	.0293	.0362	.0293	.0343	.0343	.0305	.0362
18	.0293	.0362			.0343	.0305	.0362
19	.0293	.0905	.0293	.0343	.0343	.0305	.0343
20	.0293	.0362	.0293		.0343	.0305	.0905
21	.0293	.0343	.0293		.0362	.0305	.0362
22	.0293	.0362	.0293	.0343	.0343	.0305	.0343
23	.0293	.0362	.0293	.0343	.0362	.0305	.0343
24	.0343	.0293	.0343	.0293	.0343	.0362	.0305
Max	.0343	.0905	.0362	.0343	.0362	.0362	.0905
Min	.0293	.0293	.0293	.0293	.0343	.0305	.0305
Avg	.0308	.0355	.0317	.0314	.0347	.0324	.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 202 / 11 kV Patansawangi R
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6001	.6335	.6001	.6001	.543	
2	.5144	.5144	.5144	.6001	.6001	.543	.2429
3	.5144	.5144	.543	.6001	.6001	.543	.2429
4	.5144	.5144	.543	.5144	.6001	.543	.1619
5	.4287	.4287	.4525	.5144	.6001	.4525	.1619
6	.4287	.4287	.4525	.5144	.6001	.4525	.1619
7	.3429	.4287	.543	.5144	.5144	.4525	.1619
8	.3429	.4287	.543	.4287	.4287	.4525	.1619
9	.4287	.4287	.4525	.4287	.5144	.3429	.1524
10	.4287	.4525	.4287	.4287	.5144		.362
11	.4287	.4525	.4801	.5144	.543	.0324	.362
12	.2572	.4525	.5144	.5144	.362	.0324	.2715
13	.2572	.4525	.5144	.5144	.362	.0324	.2715
14	.2572	.4525	.5144	.5144	.2715	.0324	.362
15	.3429	.543	.5144	.5144		.1619	.362
16	.3429	.543	.5144	.4287		.3239	.362
17	.3086	.362	.4801	.4287	.1715	.3239	.362
18	.3429	.362	.4801	.4287		.3239	.362
19	.4801	.4525	.4801	.4287	.362	.4049	.4525
20	.6001	.543	.6001	.6001	.4287	.4858	.4525
21	.6859	.6335	.6859	.6859	.6001	.4858	.4525
22	.6859	.6335	.6859	.6859	.6335	.4858	.4525
23	.6859	.6335	.6859		.6335	.4858	.4525
24	.5144	.6001	.6335	.6859	.6859	.543	.3239
Max	.6859	.6335	.6859	.6859	.6859	.543	.4525
Min	.2572	.362	.4287	.4287	.1715	.0324	.1524
Avg	.4437	.4940	.5371	.5256	.5060	.3687	.3092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 203 / WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1203	1.086	1.1203	.8859	.9955	.924
2	1.0631	1.1203	1.086	1.1203	1.0631	.905	1.1088
3	1.1517	1.2136	1.1765	1.307	1.1517	.905	1.1088
4	1.1517	1.307	1.1765	1.307	1.2403	1.1765	1.0164
5	1.2403	1.4937	1.448	1.4937	1.4175	1.267	1.0164
6	1.3289	1.8671	1.5384	1.587	1.5061	1.448	.924
7	.8859	1.4003	.905	.3734	1.0631	1.086	.924
8	.3506	.5601	.362	.2801	.7973	.724	.7392
9	.2629	.9335	.2715	.6535	.9745	.8145	1.386
10	1.307	1.1765	1.307	1.0631	1.2048	.8316	1.3575
11	1.587	1.5384	1.6804	1.5061	1.1765	.7392	1.448
12	1.6804	1.5384	1.6804	1.5947	1.1765	1.2012	1.3575
13	1.6804	1.448	1.6804	1.5947	1.267	1.2936	1.448
14	1.6804	1.448	1.6804	1.6832	1.6289	1.386	1.448
15	1.587	.6335	.6535	1.0631		1.386	1.267
16	.3734	.3258	.2801	.8859	.2715	.6468	.6335
17	1.4003	.362	.8402	1.5061	.362	.7392	.543
18	1.587	1.6289	1.4937	1.2403	1.8099	1.0164	1.267
19	1.7737	1.8099	1.6804	1.4175	1.6289	1.2936	1.3575
20	1.587	1.6289	1.6804	1.5061	1.7194	1.4784	1.5384
21	1.587	1.5384	1.6804	1.5947	1.7194	1.2936	1.6289
22	1.587	1.1765	1.587	1.2403	1.6289	1.1088	1.267
23	1.307	1.086	1.4937	1.0517	1.3575	1.1088	.905
24	.6201	.9335	1.1765	.9335	.7973	1.086	.8316
Max	1.7737	1.8671	1.6804	1.6832	1.8099	1.4784	1.6289
Min	.2629	.3258	.2715	.2801	.2715	.6468	.543
Avg	1.2435	1.2204	1.2352	1.2135	1.2108	1.0804	1.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 204 / Town APDRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0288	1.1765	1.1145	1.1517	1.086	.8764
2	1.0631	1.0288	1.1765	1.1145	1.1517	1.086	.7888
3	1.0631	1.0288	1.1765	1.0288	1.0631	.9955	.7888
4	1.0631	.9431	1.1765	1.0288	1.0631	.9955	.7888
5	.9745	.9431	1.1765	1.0288	.9745	.9955	.7011
6	.8859	.8573	.905	.9431	.8859	.905	.7011
7	.7973	.7716	.8145	.8573	.7888	.8145	.6135
8	.7011	.6859	.8145	.7716	.7087	.724	.6135
9	.7087	.6859	.724	.6859	.7011	.724	.6135
10	.6859	.724	.6859	.7973	.7011	.7011	.6335
11	.6859	.724	.7716	.7973	.724	.7011	.6335
12	.6859	.905	.7716	.8859	.724	.7011	.6335
13	.6859	.905	.7716	.8764	.8145	.6135	.6335
14	.6859	.905	.7716	.8764	.905	.6135	.6335
15	.6859	.905	.8573	.8764		.6135	.6335
16	.6859	.905	.8573	.8859	.8145	.5258	.6335
17	.6001	.905	.7716	.8764	.724	.5258	.6335
18	.6859	.724	.8573	.7888	.724	.5258	.6335
19	.8573	.905	.9431	.7888	.8145	.7888	.724
20	1.0288	1.0288	1.0288	1.0631	.9412	.8764	.724
21	1.1145	1.1765	1.1145	1.1517	.9955	.964	.8145
22	1.1145	1.267	1.1145	1.1393	1.086	.964	.8145
23	1.1145	1.267	1.1145	1.1517	1.1765	.964	.8145
24	1.0631	1.1145	1.267	1.1145	1.1517	1.086	.8764
Max	1.1145	1.267	1.267	1.1517	1.1765	1.086	.8764
Min	.6001	.6859	.6859	.6859	.7011	.5258	.6135
Avg	.8625	.9306	.9516	.9435	.9037	.8121	.7065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 205 / 11 KV Itangoti water
supply Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0905	.0857	.0876	.0905	.0857
2	.0876	.0857	.0905	.0857	.0876	.0905	.0857
3	.0876	.0857	.0905	.0857	.0876	.0905	.0857
4	.0876	.0857	.0905	.0857	.0876	.0905	.0857
5	.0876	.0857	.0905	.0857	.0876	.0905	.0857
6	.0876	.0857	.0905	.0857	.0876	.0905	.0857
7	.0876	.0857	.0905	.0857	.0876	.0905	.0857
8	.0876	.0857	.0857	.0857	.0876	.0905	.0857
9	.0876	.0857	.0905	.0857	.0876	.0905	.0857
10	.0857	.0905	.0857	.0876	.0876	.0857	.0905
11	.0857	.0905	.0857	.0876	.0905	.0857	.0905
12		.0905	.0857	.0876	.0905	.0857	.0905
13		.0905	.0857	.0876	.0905	.0857	.0905
14	.0857	.0905	.0857	.0876	.0905	.0857	.0905
15	.0857	.0905	.0857	.0876		.0857	.0905
16	.0857	.0905	.0857	.0876	.0905	.0857	.0905
17	.0857	.0905	.0857	.0876	.0905	.0857	.0905
18	.0857	.0905	.0857	.0876	.0905	.0857	.0905
19	.0857	.0905	.0857	.0876	.0905	.0857	.0905
20	.0857	.0905	.0857	.0876	.0905	.0857	.0905
21	.0857	.0905	.0857	.0876	.0905	.0857	.0905
22	.0857	.0905	.0857	.0876	.0905	.0857	.0905
23	.0857	.0905	.0857	.0876	.0905	.0857	.0905
24	.0876	.0857	.0905	.0857	.0876	.0905	.0857
Max	.0876	.0905	.0905	.0876	.0905	.0905	.0905
Min	.0857	.0857	.0857	.0857	.0876	.0857	.0857
Avg	.0866	.0885	.0875	.0868	.0891	.0877	.0885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 401 / 33 KV SOOTGIRNI FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	1.1203	1.086	1.0082		.9774	1.2449
2	.9877	1.1203	1.086	1.1203	.9877	.9774	1.2449
3	.9877	1.1203	1.086	1.1203	.9877	.9774	1.1883
4	.9877	1.1203	1.0317	1.1203	.9877	1.086	1.1883
5	.9877	1.1203	.9774	1.1203	1.0974	1.086	1.1883
6	.9877	1.1203	1.0317	1.1203	1.0974	1.1403	1.1883
7	.9877	1.0082	1.0317	1.0082	1.0974	1.086	1.0751
8	.9877	.8962	1.086	.8962	1.0974	.9231	.9619
9	.8402	1.0082	1.086	1.0082	1.0974	1.0317	.7356
10	1.1203	1.086	1.0642	1.2071	1.0974	1.1317	.8145
11	1.1203	1.1403	1.2323	1.2071	.9774	1.1317	.9774
12	1.1203	.8688	1.2323	1.2071	1.1946	1.1317	.9774
13	1.0082	1.0317	1.2323	1.2071	1.086	1.3014	.8145
14	1.0082	1.3032	1.1203	1.2071	1.1403	1.0751	.9231
15	1.1203	1.3032	1.1203	1.2071	.9774	.9619	.8688
16	1.1203	1.3032	1.1203	1.2071	.8688	1.1883	.9774
17	1.1203	1.1946	1.1203	1.2071	1.086	1.0751	.8688
18	1.2323	1.3032	1.1203	1.0974	1.086	1.1883	1.0317
19	1.1203	1.086	1.1203	1.0974	1.3032	1.1883	1.3575
20	1.1203	.9231	.8962	1.0974	1.3575	1.1883	1.086
21	1.2323	.8688	1.1203	1.0974	1.086	1.2449	.8688
22	1.0082	.9774	1.0082	1.0974	1.086	1.2449	.9774
23	1.1203	1.1403	1.0082	1.0974	1.086	1.1883	1.1403
24	.9877	1.1203	1.086	1.0082	.9877	.9774	1.1317
Max	1.2323	1.3032	1.2323	1.2071	1.3575	1.3014	1.3575
Min	.8402	.8688	.8962	.8962	.8688	.9231	.7356
Avg	1.0542	1.0952	1.0877	1.1155	1.0813	1.1043	1.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 402 / 33 KV Incomer I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9321	2.8292	3.9095	3.5494	3.5837		1.9456
2		2.7263	3.8552	3.7037	4.1267		2.3137
3	3.0407	2.8292	3.9095	3.8066	4.0724		2.3137
4	3.0407	2.8292	3.9095	3.7551	4.0724		2.1559
5	2.9321	2.8807	4.2353	4.0638	4.2353		2.0508
6	2.8778	3.1379	3.9095	4.2696	4.3439		1.9456
7	2.2805	2.6749	2.7692	2.9321	2.9321		1.8404
8	1.6289	1.8004	1.9547	2.8292	2.1719		1.6827
9	1.6289	2.1091	1.6832	2.9321	2.4434		2.3137
10	2.4691	2.4977	2.4691	3.0407	2.6606		2.552
11	2.7263	2.8778	2.9835	***	2.6606	1.6301	2.6063
12	2.572	3.095	2.9835	3.2579	2.4977	2.1559	2.4434
13	2.572	2.9864	2.9835	.3258	2.7149	2.0508	2.552
14	2.6235	2.9864	2.9835	3.3665	2.9864	2.1559	2.6063
15	2.6235	2.2805	2.1091	2.7149		2.3137	2.4434
16	1.5432	1.9547	1.749	2.4434		1.7353	1.8461
17	2.3148	1.8461	2.2119	2.1719		1.7878	1.7375
18	2.6235	2.9321	2.8292	2.7692		2.0508	2.4434
19	3.0864	3.3665	3.1379	2.9321		2.6818	2.7149
20	3.2407	3.5294	3.3436	3.4751		2.9973	2.9321
21	3.3951	3.5294	3.4979	3.6923		2.9447	3.095
22	3.3951	3.2579	3.3951	3.3665		2.7343	2.7692
23	3.1379	3.3665	3.2922	2.4434		2.7343	2.3891
24	2.4977	2.7263	3.9638	3.1893	3.4208		2.2085
Max	3.3951	3.5294	4.2353	49.3028	4.3439	2.9973	3.095
Min	1.5432	1.8004	1.6832	.3258	2.1719	1.6301	1.6827
Avg	2.6601	2.7937	3.0862	5.0139	3.2615	2.3056	2.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 403 / 33 KV Incomer II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6639	11.2026	7.0588	6.6095	6.6941	9.6108	5.9322
2	5.487	10.6424	6.7873	7.0016		9.1764	5.9877
3	5.9259	6.6095	6.2986	7.1696	7.1331	8.742	6.154
4	6.4198	6.4415	6.0271	7.2817	7.4074	10.0452	6.3203
5	6.5295	6.1614	5.8642	7.5617	7.572	10.4796	6.4312
6	6.5844	5.8253	6.733	7.9538	7.6818	10.751	6.4866
7	5.9259	5.0412	5.3755	4.9291	5.487	7.8189	5.5996
8	5.4298	4.9291	5.2126	5.0412	4.7188	6.9502	3.7146
9	5.4298	5.3212	4.9954	5.2652	5.9259	6.8416	3.6037
10	6.3295	6.8959	6.7215	7.5474	6.8587	6.7084	5.1583
11	5.7133	7.5474	7.0576	7.1331	5.9728	4.4353	5.5384
12	6.8336	7.1674	6.8896	7.2428	6.8416	7.3183	5.104
13	5.5453	7.0045	7.1136	7.3525	6.7873	6.9302	3.5294
14	6.2734	7.3846	7.1696	7.2428	6.6787	6.9302	4.6153
15	6.1614	6.4072	6.6655	6.8587	5.9728	5.2669	4.4525
16	4.5931	5.9728	5.0412	5.5967	5.8642	5.1006	6.0814
17	4.7611	6.0814	3.3608	4.1701	7.4389	4.1581	6.3529
18	7.6738	6.5158	3.9209	5.2126	9.2307	6.3758	6.7873
19	7.7858	7.0576	5.9374	7.1331	10.8596	6.8747	6.8959
20	8.57	7.8732	6.3855	7.6818	10.8596	7.2074	6.8416
21	8.794	7.9275	6.8336	8.011	11.5655	7.3183	6.5158
22	8.85	7.7103	7.2817	7.3303	11.1854	7.5955	6.1357
23	8.4019	7.4389	6.2734	6.9685	10.8596	6.3758	5.7013
24	4.3896	6.9456	7.4932	6.4975	6.0357	10.0452	5.7105
Max	8.85	11.2026	7.4932	8.011	11.5655	10.751	6.8959
Min	4.3896	4.9291	3.3608	4.1701	4.7188	4.1581	3.5294
Avg	6.3780	7.0043	6.1874	6.6997	7.6361	7.4607	5.6521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 201 / 11 kV Lonara w/w
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.0953
2	.1905	.1905	.1905	.1905	.1905	.1905	.0953
3	.1905	.1905	.1905	.1905	.1905	.1905	.0953
4	.1905	.1905	.1905	.1905	.1905	.1905	.0953
5	.1905	.1905	.1905	.1905	.1905	.1905	.0953
6	.1905	.1905	.1905	.1905	.1905	.1905	.0953
7	.1905	.1905	.1905	.1905	.1905	.1905	.0953
8	.2858	.1905	.1905	.1905	.2858	.1905	.0953
9	.1905	.1905	.1905	.1905	.2858	.1905	.0953
10	.1905	.1905	.1905	.1905	.2858	.1905	.0953
11	.1905	.1905	.1905	.1905	.2858	.0953	.0953
12	.1905	.1905	.2858	.2858	.1905	.0953	.0953
13	.1905	.1905	.1905	.2858	.2858	.0953	.0953
14	.1905	.1905	.1905	.2858	.2858	.0953	.1905
15	.1905	.1905	.2858	.2858	.1905	.0953	.1905
16	.1905	.2858	.2858	.2858	.1905	.0953	.1905
17	.1905	.1905	.2858		.1905	.1905	.1905
18	.1905	.1905	.1905	.2858	.1905	.1905	.1905
19	.1905	.1905	.1905	.2858	.1905	.0953	.1905
20	.1905	.1905	.1905	.2858	.1905	.0953	.1905
21	.1905		.1905	.2858	.1905	.0953	.1905
22	.1905	.1905	.1905	.1905	.1905	.0953	.1905
23	.1905	.1905	.1905	.1905	.1905	.0953	.1905
24	.2858	.1905	.1905	.1905	.2858	.1905	.0953
Max	.2858	.2858	.2858	.2858	.2858	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.0953	.0953
Avg	.1984	.1946	.2064	.2278	.2183	.1469	.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 203 / 11 kV Colony

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	25-JUN-18
HR	Load (MW)
19	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 204 / 11 kV Polefactory
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.2858
2	.381	.381	.381	.381	.381	.381	.2858
3	.381	.381	.381	.381	.381	.381	.2858
4	.2858	.381	.381	.381	.381	.381	.2858
5	.2858	.2858	.381	.381	.381	.381	.2858
6	.2858	.2858	.2858	.2858	.2858	.2858	.1905
7	.1905	.1905	.2858	.1905	.1905	.2858	.1905
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.2858	.1905	.1905	.1905	.1905
12	.1905	.1905	.2858	.2858	.2858	.1905	.1905
13	.1905	.1905	.2858	.2858	.2858	.1905	.1905
14	.2858	.381	.381	.381	.2858	.1905	.1905
15	.2858	.381	.381	.381	.1905	.1905	.1905
16	.2858	.381	.2858	.381	.1905	.1905	.1905
17	.2858	.381	.2858		.1905	.1905	.1905
18	.2858	.2858	.2858	.2858	.1905	.1905	.1905
19	.2858	.2858	.2858	.381	.1905	.2858	.1905
20	.381	.2858	.381	.381	.381	.381	.2858
21	.381	.381	.381	.381	.381	.381	.2858
22	.381	.381	.4763	.381	.381	.381	.2858
23		.381	.4763	.381	.381	.381	.2858
24	.381	.381	.381	.381	.381	.381	.2858
Max	.381	.381	.4763	.381	.381	.381	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2858	.3056	.3294	.3230	.2858	.2818	.2302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 207 / 11 kV Mahadula

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6668	.6668	.7621	.7621	.6668	.4763
2	.5716	.6668	.6668	.7621	.6668	.6668	.4763
3	.5716	.6668	.6668	.7621	.6668	.6668	.4763
4	.5716	.6668	.6668	.6668	.5716	.6668	.4763
5	.5716	.6668	.5716	.5716	.5716	.5716	.2858
6	.4763	.4763	.4763	.4763	.4763	.4763	.381
7	.381	.381	.4763	.381	.381	.4763	.2858
8	.381	.2858	.381	.381	.2858	.381	.2858
9	.2858	.2858	.381	.381	.2858	.381	.2858
10	.2858	.2858	.381	.381	.2858	.2858	.2858
11	.2858	.2858	.381	.381	.2858	.2858	.1905
12	.2858	.381	.381	.381	.2858	.2858	.1905
13	.2858	.381	.4763	.381	.2858	.2858	.2858
14	.381	.4763	.4763	.4763	.2858	.2858	.2858
15	.381	.4763	.5716	.4763	.2858	.2858	.2858
16	.381	.4763	.4763	.4763	.381	.2858	.2858
17	.381	.4763	.4763		.381	.2858	.2858
18	.381	.381	.381	.4763	.381	.2858	.2858
19	.4763	.4763	.4763	.4763	.381	.381	.381
20	.5716	.4763	.5716	.5716	.5716	.4763	.381
21	.6668	.6668	.6668	.5716	.5716	.4763	.381
22	.6668	.7621	.6668	.6668	.5716	.4763	.381
23	.6668	.7621	.7621	.7621	.6668	.4763	.381
24	.6668	.6668	.6668	.7621	.7621	.6668	.4763
Max	.6668	.7621	.7621	.7621	.7621	.6668	.4763
Min	.2858	.2858	.381	.381	.2858	.2858	.1905
Avg	.4684	.5080	.5319	.5384	.4604	.4366	.3413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 208 / 11 KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384		1.3336	1.3336	1.3336	1.1431	.9526
2	1.1431			1.3336	1.2384	1.1431	.9526
3	1.1431	1.2384	1.2384	1.2384	1.2384	1.1431	.8573
4	.9526	1.2384	1.2384	1.1431	1.1431	1.1431	.8573
5	.9526	1.1431	.9526	1.0479	1.0479	.9526	.7621
6	.9526	.8573	.8573	.9526	.9526	.8573	.7621
7	.8573	.7621	.8573	.8573	.8573	.7621	.7621
8	.7621	.7621	.7621	.8573	.7621	.7621	.7621
9	.7621	.7621	.7621	.8573		.7621	.7621
10	.8573	.8573	.7621	.8573	.7621	.7621	.6668
11	.8573	.9526	.8573	.8573	.7621	.7621	.6668
12	.7621	.9526	.8573	.8573	.7621	.7621	.6668
13	.7621	.9526	.9526	.8573	.8573	.7621	.6668
14	.8573	1.1431	1.0479	.9526	.8573	.6668	.6668
15	.8573	1.1431	1.0479	.9526	.8573	.6668	.6668
16	.8573	1.0479	1.0479	.9526	.8573	.6668	.6668
17	.7621	1.0479	.9526		.8573	.6668	.6668
18	.7621	.9526	.7621	.6668	.7621	.7621	.6668
19	.8573	.9526	.9526	1.0479	.8573	.8573	.8573
20	1.1431	1.1431	.5716	1.2384	.9526	.9526	.8573
21	1.1431	1.1431	1.2384	1.3336	.9526	.9526	.8573
22	1.0479	1.1431	1.2384	1.3336	1.1431	.9526	.8573
23	1.1431	1.3336	1.3336	1.3336	1.1431	.9526	.8573
24	1.2384	1.2384	1.3336	1.3336	1.3336	1.1431	.9526
Max	1.2384	1.3336	1.3336	1.3336	1.3336	1.1431	.9526
Min	.7621	.7621	.5716	.6668	.7621	.6668	.6668
Avg	.9447	1.0349	.9982	1.0520	.9692	.8732	.7779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 209 / 11 kV Koradi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6668	.6668	.7621	.7621	.6668	.4763
2	.6668	.6668	.6668	.7621	.7621	.6668	.4763
3	.5716	.6668	.6668	.7621	.6668	.6668	.4763
4	.5716	.6668	.6668	.6668	.6668	.6668	.4763
5	.5716	.5716	.5716	.5716	.5716	.6668	.4763
6	.4763	.4763	.4763	.4763	.4763	.5716	.381
7	.4763	.381	.4763	.381	.381	.4763	.381
8	.381	.2858	.381	.381	.381	.381	.381
9	.381	.2858	.381	.381	.381	.381	.2858
10	.381	.381	.381	.381	.2858	.381	.2858
11	.381	.381	.381	.381	.2858	.381	.381
12	.381	.381	.4763	.381	.381	.2858	.381
13	.381		.4763	.381	.381	.2858	.2858
14	.381	.4763	.5716	.4763	.381	.2858	.2858
15	.381	.4763	.5716	.4763	.381	.2858	.2858
16	.381	.4763	.5716	.4763	.381	.2858	.2858
17	.381	.4763	.4763		.381	.2858	.2858
18	.381	.381	.381	.381	.381	.2858	.2858
19	.4763	.4763	.4763	.4763	.381	.381	.4763
20	.5716	.4763	.5716	.5716	.5716	.4763	.4763
21	.6668	.5716	.6668	.6668	.5716	.4763	.4763
22	.6668	.6668	.6668	.6668	.5716	.4763	.4763
23	.6668	.7621	.7621	.7621	.6668	.4763	.4763
24	.7621	.6668	.6668	.7621	.7621	.6668	.4763
Max	.7621	.7621	.7621	.7621	.7621	.6668	.4763
Min	.381	.2858	.381	.381	.2858	.2858	.2858
Avg	.5041	.5094	.5438	.5384	.4922	.4525	.3929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 210 / 11 kV Lonkhairy

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1905	.1905	.2858	.1905	.1905
2	.1905		.1905	.1905	.1905	.1905	.1905
3	.1905	.1905	.1905	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905		.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	.1905
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	.1905	.1905	.1905
12		.1905	.1905	.1905	.1905		.1905
13	.1905	.1905	.1905	.1905	.1905	.1905	.1905
14	.1905	.1905	.1905	.1905	.2858		.1905
15	.1905	.1905	.1905	.1905	.1905		.1905
16	.1905	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905		.1905	.1905	
18		.1905	.1905	.1905		.1905	.1905
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905	.1905	.1905	.1905
22	.2858	.1905	.1905	.2858	.1905	.1905	.1905
23	.2858	.7621	.1905	.2858	.1905	.1905	.1905
24	.1905	.1905	.1905	.1905	.2858	.1905	.1905
Max	.2858	.7621	.1905	.2858	.2858	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.1992	.2165	.1905	.1988	.2029	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 211 / 11 kV Gayatri Bricks
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191	.0191	.0191	.0191	.0191
2	.0191		.0191	.0191	.0191	.0191	.0191
3	.0191		.0191	.0191	.0191	.0191	.0191
4	.0191		.0191	.0191	.0191	.0191	.0191
5	.0191		.0191	.0191	.0191	.0191	.0191
6	.0191		.0191	.0191	.0191		.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0381	.0191	.0191	.0191	.0191	.0191
9	.0381	.0572	.0191	.0191	.0381	.0191	.0191
10		.0953	.0191	.0762	.0572	.0191	.0191
11	.0953	.0953	.0191	.0762	.0572	.0381	.0191
12	.0953	.0953	.0191	.0762	.0572	.0381	.0191
13	.0572	.0953	.0191	.0762	.0572	.0381	.0191
14	.0191	.0381	.0191	.0381	.0572	.0191	.0191
15	.0191	.0381	.0191	.0381	.0762	.0381	
16	.0191	.0572	.0191	.0572	.0762	.0381	
17	.0762	.0381	.0191		.0762	.0191	
18	.0572	.0381		.0953	.0762	.0572	.0953
19	.0572	.0381		.0953	.0762		.0191
20	.0381	.0381	.0191	.0953	.0762	.0381	
21	.0191	.0381	.0191	.0953	.0762	.0381	.0191
22		.0191	.0191	.0191	.0191		.0191
23		.0191	.0191	.0191	.0191	.0191	.0191
24	.0191		.0191	.0191	.0191	.0191	.0191
Max	.0953	.0953	.0191	.0953	.0762	.0572	.0953
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0363	.0505	.0191	.0456	.0445	.0272	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 213 / 11 KV Panjara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.4763	.381	.2858
2	.4763	.381	.4763	.4763	.4763	.381	.2858
3	.381	.381	.4763	.4763	.4763	.381	.2858
4	.381	.381	.4763	.381	.381	.381	.2858
5	.381	.2858	.381	.381	.381	.381	.2858
6	.2858	.2858	.2858	.2858	.2858	.2858	.1905
7	.2858	.2858	.2858	.2858	.2858	.2858	.1905
8	.2858	.2858	.2858	.2858	.2858	.1905	.1905
9	.2858	.2858	.2858	.2858	.2858	.1905	.2858
10	.2858		.2858	.2858	.2858	.2858	.2858
11	.2858	.2858	.2858	.2858	.2858	.2858	.1905
12		.2858	.2858	.381	.2858	.1905	.1905
13		.2858	.2858	.381	.2858	.1905	.1905
14		.381	.381	.2858	.2858	.1905	.1905
15		.381	.381	.2858	.2858	.1905	.1905
16	.1905	.381	.2858	.381	.2858	.1905	
17	.2858	.2858	.2858	.2858	.2858	.1905	.1905
18	.2858	.2858	.2858	.2858	.2858	.1905	.1905
19	.2858	.2858	.2858	.381	.2858	.2858	.1905
20	.381	.2858	.381	.381	.381	.2858	.2858
21	.381	.381	.381	.4763	.381	.2858	.2858
22	.4763	.4763	.4763	.4763	.381	.2858	.2858
23	.4763	.4763	.4763	.4763	.4763	.2858	.2858
24	.4763	.4763	.4763	.4763	.4763	.381	.381
Max	.4763	.4763	.4763	.4763	.4763	.381	.381
Min	.1905	.2858	.2858	.2858	.2858	.1905	.1905
Avg	.3525	.3479	.3612	.3691	.3453	.2739	.2444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 214 / NANDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4763	.4763	.4763	.4763	.2858
2	.381	.4763	.4763	.4763	.4763	.4763	.2858
3	.381	.381	.4763	.381	.4763	.4763	.2858
4	.381	.381	.4763	.381	.381	.4763	.2858
5	.381	.2858	.4763	.381	.381	.381	.2858
6	.2858	.2858	.381	.2858	.381	.2858	.1905
7	.2858	.2858	.381	.2858	.381	.2858	.1905
8	.2858	.2858	.2858	.2858	.2858	.2858	.1905
9	.2858	.381	.2858	.2858	.381	.2858	.2858
10	.381	.4763	.381	.381	.381	.1905	.2858
11	.381	.4763	.381	.381	.381		.1905
12	.381	.5716	.4763	.4763	.381		.1905
13	.381	.5716	.4763	.4763	.381		.2858
14	.4763	.5716	.4763	.4763	.381	.1905	.2858
15	.4763	.5716	.4763	.4763	.2858	.1905	.2858
16	.4763	.5716	.4763	.5716	.2858	.1905	.2858
17	.5716	.4763	.4763		.2858	.1905	.2858
18	.5716	.4763	.4763	.381	.381	.1905	.381
19	.5716	.4763	.4763	.5716	.381	.2858	.381
20	.7621		.4763	.5716	.4763	.2858	.381
21	.6668	.4763		.5716	.4763	.2858	.381
22	.5716	.4763		.4763	.4763	.381	.381
23	.5716	.4763	.5716	.4763	.4763	.381	.381
24	.4763	.5716	.4763	.4763	.381	.4763	.2858
Max	.7621	.5716	.5716	.5716	.4763	.4763	.381
Min	.2858	.2858	.2858	.2858	.2858	.1905	.1905
Avg	.4485	.4556	.4460	.4349	.3929	.3175	.2897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 215 / NEW ROPEWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4763	.4763	.4763	.4763	.381
2	.381	.381	.4763	.4763	.4763	.4763	.381
3	.381	.381	.4763	.4763	.4763	.4763	.2858
4	.381	.381	.4763	.381	.4763	.4763	.2858
5	.381	.381	.4763	.381	.381	.4763	.2858
6	.381	.2858	.381	.381	.381	.381	.2858
7	.2858	.2858	.381	.2858	.381	.381	.1905
8	.2858	.2858	.2858	.2858	.2858	.2858	.1905
9	.2858		.2858	.2858	.2858	.2858	.1905
10	.2858		.381	.2858	.2858	.1905	.1905
11	.2858	.2858	.2858	.2858	.2858	.1905	.2858
12	.2858	.381	.381	.381	.2858	.2858	.2858
13	.2858	.381	.381	.381	.2858	.2858	.2858
14	.2858	.381	.381	.381	.381	.1905	.2858
15	.2858		.381	.381	.2858	.1905	.1905
16	.2858	.381	.381	.2858	.2858	.1905	.1905
17	.2858	.1905	.381		.2858	.2858	.1905
18	.2858	.381	.381	.381	.2858	.2858	.2858
19	.381	.381	.381	.381	.381	.2858	.381
20	.4763	.381	.381	.4763	.4763	.381	.381
21	.4763	.4763	.5716	.4763	.4763	.381	.381
22	.4763	.4763	.5716	.4763	.4763	.381	.2858
23	.4763	.4763	.4763	.4763		.381	.2858
24	.381	.4763	.4763	.4763	.4763	.4763	.381
Max	.4763	.4763	.5716	.4763	.4763	.4763	.381
Min	.2858	.1905	.2858	.2858	.2858	.1905	.1905
Avg	.3493	.3765	.4128	.3893	.3728	.3374	.2818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 216 / MODERN SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2384	1.3336	1.3336	1.2384	1.1431	.7621
2	1.0479		1.3336	1.3336	1.1431	1.1431	.7621
3	1.0479	1.3336	1.3336	1.2384	1.1431	1.1431	.7621
4	.9526	1.2384	1.2384	1.1431	.9526	1.1431	.7621
5	.9526	1.0479	.9526	.9526	.9526	.9526	.6668
6	.8573	.8573	.8573	.8573	.8573	.7621	.5716
7	.7621	.7621	.8573	.7621	.7621	.7621	.5716
8	.6668	.6668	.7621	.7621	.7621	.6668	.5716
9	.6668	.7621	.6668	.8573	.7621	.6668	.6668
10	.8573	.8573	.8573	.9526	.8573	.6668	.7621
11	.8573	.9526	.9526	.9526	.9526	.5716	.6668
12	.8573	.9526	.9526	.9526	.9526	.5716	.6668
13	.9526	.9526	.9526	.9526	.8573	.5716	
14	.9526	1.0479	1.0479	1.0479		.4763	
15	.9526	1.0479	1.1431	1.0479	.8573	.4763	.6668
16	.9526	1.1431	1.1431	1.0479	.8573	.4763	.6668
17	.7621	1.0479	.9526		.8573	.4763	.6668
18	.7621	.8573	.8573	.9526	.7621	.4763	.5716
19	.8573	.8573	.8573	1.0479	.8573	.5716	.6668
20	.9526	.9526	.9526	1.0479	.9526	.7621	.6668
21	1.0479	1.1431	1.1431	1.1431	.9526	.7621	.6668
22	1.1431	1.3336	1.1431	1.1431	.9526	.7621	.6668
23	1.1431		1.2384	1.3336	1.1431	.7621	
24	1.1431	1.1431	1.3336	1.3336	1.3336	1.1431	.7621
Max	1.1431	1.3336	1.3336	1.3336	1.3336	1.1431	.7621
Min	.6668	.6668	.6668	.7621	.7621	.4763	.5716
Avg	.9288	1.0089	1.0359	1.052	.9443	.7462	.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 401 / 33 KV Incomer I(Uppalwadi NON SHEDDABLE EXPRESS HV FEEDERS
 I) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4289	1.1431
2			1.4289	1.1431
3			1.4289	1.1431
4			1.4289	1.1431
5			1.4289	1.1431
6			1.1431	.8573
7			1.1431	.8573
8			.8573	.8573
9			.8573	.8573
10			.8573	.8573
11		.8573	.8573	.8573
12		.8573	.5716	.8573
13		.8573	.8573	.8573
14		.8573		.8573
15		.8573		.8573
16		1.1431		
17		1.1431		
18		.8573	.8573	
19	1.1431	1.1431	.8573	
20	1.4289	1.1431	1.1431	
21	1.4289	1.4289	1.1431	
22		1.4289	1.1431	
23		1.4289	1.1431	
24			1.4289	1.1431
Max	1.4289	1.4289	1.4289	1.1431
Min	1.1431	.8573	.5716	.8573
Avg	1.3336	1.0771	1.1002	.9645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 402 / 33 KV INCOMER II(UPPALWADI NON SHEDDABLE EXPRESS HV FEEDERS
 II) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.145		9.4307	10.0023	10.2881	7.1445	5.144
2	8.5734		9.4307	9.7165	9.4307	7.1445	5.144
3	8.2876	8.2876	9.4307	9.4307	9.145	7.1445	4.8583
4	7.7161	8.5734	9.145	8.5734	8.2876	7.1445	4.8583
5	7.7161	8.0018	8.2876	8.2876	8.0018	6.5729	4.5725
6	6.8587	6.8587	7.1445	7.1445	7.4303	5.7156	4.5725
7	6.2872	6.0014	6.5729	6.0014	6.2872	5.144	4.0009
8	5.7156	5.7156	5.7156	6.0014	6.0014	4.5725	4.0009
9	5.7156	6.0014	5.7156	6.2872	6.2872	4.5725	4.2867
10	6.0014	6.2872	6.0014	6.8587	5.7156	4.2867	4.2867
11	4.8583	6.0014	6.5729	6.5729	3.4294	3.7151	4.2867
12	4.2867	6.5729	7.1445	6.0014	3.4294	4.0009	4.0009
13	4.5725	6.5729	7.4303	6.0014	3.1436	4.0009	4.2867
14	4.8583	7.1445	8.0018	7.4303	3.7151	4.0009	4.2867
15	4.8583	7.1445	8.5734	7.4303	3.4294	4.0009	4.0009
16	5.144		8.0018	6.8587	2.572	4.5725	4.5725
17	4.8583	6.8587	7.4303		2.572	4.5725	4.5725
18	6.0014	6.2872	6.2872	7.4303	2.2862	4.5725	4.8583
19	5.4298	6.8587	6.8587	8.0018	2.572	4.5725	5.7156
20	6.8587	6.8587	8.0018	8.8592	2.572	5.4298	6.5729
21	7.4303	8.0018	8.8592	9.4307	4.2867	5.4298	6.2872
22	9.145	8.8592	9.4307	9.7165	4.8583	5.7156	6.2872
23	9.145	8.8592	10.0023	10.2881	7.1445	5.7156	6.0014
24	9.4307	9.145	8.8592	10.0023	10.5739	7.1445	5.4298
Max	9.4307	9.145	10.0023	10.2881	10.5739	7.1445	6.5729
Min	4.2867	5.7156	5.7156	6.0014	2.2862	3.7151	4.0009
Avg	6.6206	7.1853	7.8470	7.9273	5.5608	5.2869	4.8702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 403 / 33 KV Rohana I

Feeder KV- 33 / INCOMING

DATE	23-JUN-18
HR	Load (MW)
1	5.144
2	3.7151
Max	5.144
Min	3.7151
Avg	4.4296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 405 / 33 KV GODHANI RAILWAY
Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.8573	.8573	1.1431	.8573	.5716
2	.5716	.5716	.8573	.8573	.8573	.8573	.5716
3	.5716	.8573	.8573	.8573	.8573	.8573	.5716
4	.5716	.8573	.8573	.8573	.8573	.8573	.5716
5	.5716	.8573	.8573	.8573	.8573	.8573	.5716
6	.5716	.5716	.8573	.5716	.8573	.8573	.5716
7	.5716	.5716		.5716	.5716	.5716	.5716
8	.5716	.5716		.5716	.5716	.5716	.5716
9	.5716	.5716		.8573	.8573	.5716	.5716
10	.5716	.5716	.5716	.8573	.5716	3.4294	.5716
11	.5716	.5716	.8573	.8573	.5716	.5716	.5716
12	.5716	.8573	.8573	.8573	.5716	.5716	.5716
13	.5716	.8573	.8573	.8573		.5716	.5716
14	.5716	.5716	.8573	.8573	.5716	.5716	.5716
15	.5716	.5716	.8573	.8573	.5716	.5716	.5716
16	.5716		.8573	1.1431	.5716	.5716	.5716
17	.5716	.8573	.8573		.5716	.5716	.5716
18	.5716	.5716	.5716	.8573	.5716	.5716	.5716
19	.5716	.5716	.5716	.8573	.8573	.5716	.5716
20	.8573	.5716	.5716	.8573	.8573	.5716	.5716
21	.8573	.8573		.8573	.5716	.5716	.5716
22	.8573	.8573		.8573	.8573	.8573	.5716
23	.8573	.8573	.8573	1.1431	.8573	.8573	.5716
24	.5716	.8573	.8573	.8573	1.1431	.8573	.5716
Max	.8573	.8573	.8573	1.1431	1.1431	3.4294	.5716
Min	.5716	.5716	.5716	.5716	.5716	.5716	.5716
Avg	.6192	.6958	.7972	.8449	.7455	.7978	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 201 / 11 KV Rohana Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.6201	.7087	.7087	.7087	.6201	.443
2	.5316	.6201	.7087	.6201	.6201	.6201	.443
3	.5316	.6201	.7087	.6201	.6201	.5316	.443
4	.443	.6201	.6201	.6201	.6201	.5316	.443
5	.443	.5316	.6201	.6201	.6201	.5487	.443
6	.443	.5316	.5316	.5316	.5316	.443	.443
7	.3544	.443	.443	.443	.443	.443	.3544
8	.3544	.443	.443	.443	.443	.443	.3544
9	.443	.443	.443	.443	.443	.443	.3544
10	.2658	.443	.443	.443	.443	.443	.443
11	.2658	.443	.443	.443	.443	.3544	.443
12	.2658	.443	.443	.443	.443	.3544	.3544
13	.2658	.443	.5316	.5316	.443	.3544	.3544
14	.2658	.443	.5316	.5316	.443	.443	.443
15	.2658	.5316	.5316	.5316	.443	.1772	
16	.1772	.5316	.5316	.5316	.443	.1772	.443
17	.1772	.5316	.443	.443		.2658	.443
18	.443	.443	.5316	.443	.2658	.2658	.443
19	.443	.443	.5316	.443	.2658	.3544	.443
20	.5316	.6201	.6201	.5316	.443		.443
21	.6201	.7087	.6201	.6201	.5316	.443	.443
22	.6201	.7087	.6201	.7087	.5316	.443	.443
23	.7087	.7087	.7087	.7087	.6201	.443	.443
24	.5316	.6201	.7087	.7087	.7087	.6201	.443
Max	.7087	.7087	.7087	.7087	.7087	.6201	.443
Min	.1772	.443	.443	.443	.2658	.1772	.3544
Avg	.4135	.5389	.5611	.5463	.5008	.4245	.4237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 203 / Silewara

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.267	1.086	1.1088	1.086	.905	.924
2	1.6632	1.6289	1.9909	1.5708	1.8099	1.267	1.2012
3	2.0328	1.6289	1.9909	1.848	1.9909	.905	1.2936
4	2.4025	1.6461	1.8099	2.0328	2.2624	1.8671	1.386
5	2.3101	1.8099	1.8099	2.2177	1.9909	1.9909	1.4784
6	2.0328	1.8099	1.6289	2.1253	1.8099	1.9909	1.386
7	1.6632	1.086	1.448	1.2012	.905	1.448	.924
8	1.1088	.905	.905	1.1088	.905	.905	.924
9	1.1088	1.0974	1.448	1.6632	1.086	.905	1.1765
10	1.5708	1.829	2.2862	2.1719	1.9909	1.6289	1.448
11	1.9909	2.1719	1.7375	2.2624	1.6289		1.4632
12	2.1719	2.3529	1.4632	1.8099	1.7375	1.2803	1.1765
13	2.1719	2.1719	1.9909	1.8099	1.9909	1.448	
14	1.8099	2.1948	2.1948	2.1719	1.6289	1.267	1.267
15	1.267	1.5546	1.448	1.5546	.9955	1.086	1.8099
16	.905	1.0974	1.0059	1.0974	.905	1.086	1.267
17	.905	1.1765	1.1088	1.1888	1.086	.905	1.086
18	1.9909	1.9909	.924	1.9909	1.8099	1.4784	1.8099
19	2.1719	2.1719	1.848	2.1719	2.3529	1.6632	1.8099
20	2.1719	1.9909	2.2177	2.3529	2.1719		1.8099
21	2.3529	2.1719	2.2177	2.3101	2.3529	1.3717	1.8099
22	2.1719	2.3529	2.4025	2.3529	1.9909	1.3717	1.448
23	1.6289	1.6289	1.1088	1.0517	1.267	.724	1.086
24	.924	1.086	.905	.7392	.905	.905	.8316
Max	2.4025	2.3529	2.4025	2.3529	2.3529	1.9909	1.8099
Min	.905	.905	.905	.7392	.905	.724	.8316
Avg	1.7425	1.7009	1.6240	1.7464	1.6108	1.2909	1.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 206 / 11 KV D point Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6461	1.7375	1.829	1.829	1.6461	1.3717
2	1.5546	1.6461	1.7375	1.7375	1.7375	1.6461	1.3717
3	1.5546	1.6461	1.7375	1.7375	1.7375	1.6461	1.4632
4	1.6461	1.6461	1.7375	1.6461	1.6461	1.6461	1.6461
5	1.6461	1.6461	1.7375	1.6461	1.7375	1.6461	1.6461
6	1.7375	1.0974	1.0059	1.7375	1.7375	1.0974	1.0059
7	1.0974	1.0974	1.0059	1.0059	1.0974	1.0059	1.0974
8	1.3717	.1829	1.701	1.6461	1.6461	1.5384	
9	1.2803	1.5546	1.6461	1.5546	1.4632	1.5546	
10	1.4632	1.3717	1.5729	1.5546	1.39	1.4632	
11	1.4632	1.5546	1.5729	1.5546	1.4632	1.4632	.0914
12	1.4632	1.5546	1.5546	1.5546	1.4632	1.2803	.0914
13	1.3717	1.5546	1.5546	1.4632	1.39	1.1888	.0914
14	1.3717	1.5546	1.4632	1.5546	1.3717	1.1888	.0914
15	1.3717	1.5729	1.5546	1.5546	1.4632	1.0059	.9145
16	.9145	1.5546	1.5546	.9145	.9145	.7316	.9145
17	.823	.0914	.0914	.1829	.1829	.1829	1.4815
18	1.4632	1.5546	.6401	1.3717	.9145	1.6461	1.5546
19	1.6461	1.7375	1.6461	1.6461	1.6461	1.5546	1.6461
20	1.9204	2.0119	2.0119	2.0119	1.829	1.7375	1.6461
21	1.9204	2.0119	2.0119	2.0119	1.829	1.7375	1.5546
22	1.9204	1.9204	1.9204	2.0119	1.7375	1.5546	1.4632
23	1.829	1.829	1.9204	1.9204	1.7375	1.6461	1.3717
24	1.6461	1.829	1.829	1.829	1.829	1.7375	1.3717
Max	1.9204	2.0119	2.0119	2.0119	1.829	1.7375	1.6461
Min	.823	.0914	.0914	.1829	.1829	.1829	.0914
Avg	1.5051	1.4944	1.5394	1.5699	1.4914	1.3977	1.1374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 207 / Walni I NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	.9145	.9431	.9145	.9145	1.5089
2		1.1888	1.4632	1.1317	1.0974	.9145	1.6975
3		1.2803	1.0974	1.226	1.2803	.9145	1.8861
4		1.4632	1.0974	1.3203	1.3717	.9145	1.8861
5	.7545	1.4632	1.2803	1.4632	1.4632	.9145	2.0748
6	.2829	.9145	.9145	1.5089	.823	.5487	1.6032
7	.3772	.3658	.4572	.3772	.6401	.3658	.7545
8	.5658	.1829	.3658	.2829	.3658	.3658	.7545
9	.5658	.3658	.3658	.2829	.3658	.1829	.7316
10	.7545	1.5546	1.4632	1.4632	1.6461	.9145	2.0119
11	.5487	1.5546	.9145	1.2803	1.0974	.9145	1.829
12	.7316	1.0974	1.0974	1.1888	1.0974	2.1948	1.9204
13		1.1888	1.1888	1.2803	1.3717	2.3777	1.829
14	.7316	1.2803	1.0974	1.0059	1.0974	2.3777	
15	1.0974	1.0059	1.0974	1.3717	1.0059	1.4632	
16	.9145	.9145	.9145	.9145	.823	.9145	.1829
17	.9145	.9145		.9145	.9145	1.1888	.7316
18	1.3717	1.0059		1.1888	1.4632	1.226	1.2803
19	1.4632	1.0974		1.0974	1.2803	1.6975	1.2803
20	1.4632	1.2803		1.4632	1.2803	1.5089	1.2803
21	1.4632	1.2803		1.226	1.2803		.9145
22	1.5546	1.0974	.1886	1.0974	1.0974	1.6461	1.4632
23	1.2803	.9145	.4715	1.0974	.9145	1.2803	.9145
24		.9145	.9145	.9431	.9145	.9145	1.1317
Max	1.5546	1.5546	1.4632	1.5089	1.6461	2.3777	2.0748
Min	.2829	.1829	.1886	.2829	.3658	.1829	.1829
Avg	.9353	1.0593	.9107	1.0862	1.0669	1.1589	1.3485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 401 / 33 KV Incomer I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	23-JUN-18
HR	Load (MW)
1	4.481
2	4.7611
Max	4.7611
Min	4.481
Avg	4.6211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 402 / 33 KV Incomer NON SHEDDABLE EXPRESS HV FEEDERS
 II(Bhagimari) Feeder KV- 33 / (NON-CONTINUOUS PROCESS)(NO
 INCOMING STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6037	9.2981	4.4993	4.6639	4.7125	4.2135	4.4353
2	3.8809	10.0263	5.9808	5.2126	5.5441	4.5462	4.6639
3	4.1581	5.3224	5.6516	5.487	5.7613	4.201	4.9383
4	4.6639	5.487	5.3772	5.7613	5.9728	4.9931	5.487
5	5.2126	5.5418	5.5418	6.0357	5.9728	5.2126	5.487
6	4.3896	4.4445	4.0295	6.0357	4.8868	4.1701	4.3896
7	3.3608	2.9447	3.3848	3.0807	3.2579	3.3471	3.3608
8	3.3608	2.9835	3.155	3.6408	3.2579	3.2579	2.2405
9	3.6408	3.219	3.8683	4.1581	3.5294	3.095	2.4691
10	4.1581	5.0503	5.6413	5.5927	5.4841	4.4445	3.8958
11	4.4445	5.7013	4.6639	5.3212	4.6153	2.8778	3.8409
12	4.7188	5.4298	4.6639	4.9411	4.7782	5.2126	3.3951
13	3.9769	5.3755	5.2675	5.104	4.0055	5.487	2.1605
14	4.2798	5.487	5.2675	5.2675	4.6091	4.8868	1.6712
15	3.6763	4.7188	4.6091	4.9931	4.0329	3.8009	2.2577
16	3.0178	4.225	4.0055	3.4751	3.2487	2.9864	2.6155
17	2.963	2.7435	1.9605	2.7692		2.4434	3.5888
18	5.0869	5.1029	2.2405	5.1583	4.4593	4.6639	5.048
19	5.6344	5.5418	4.1581	5.4298	5.5927	4.9383	5.2669
20	6.0814	5.9259	4.9383	6.2443	5.8213	5.2126	5.2126
21	6.3529	6.2649	4.9383	6.31	6.154	5.6013	4.3982
22	6.2986	6.2003	5.2126	6.2443	5.5441	5.0412	4.8834
23	5.5418	5.2115	4.4353	4.9897	4.7125	4.201	3.8958
24	3.0807	.1646	4.4907	4.1581	4.4353	4.3244	3.8809
Max	6.3529	10.0263	5.9808	6.31	6.154	5.6013	5.487
Min	2.963	.1646	1.9605	2.7692	3.2487	2.4434	1.6712
Avg	4.3993	5.1004	4.4992	5.0031	4.7995	4.2983	3.8951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 201 / 11 kV Khaperkheda

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1807	2.1658	2.0919	2.4394	2.347	2.0698	1.5432
2	2.1285	2.1285	2.0233	2.4025	2.2546	2.0538	1.5089
3	2.0911	2.1098	1.9204	2.4394	2.1437	2.0165	1.4746
4	2.0351	2.0911	1.8176	2.1948	2.0538	1.9791	1.4403
5	1.9418	1.8858	1.7147	2.1582	1.9605	1.8671	1.3717
6	1.7918	1.6804	1.6118	1.8473	1.8484	1.6804	1.3375
7	1.6617	1.5684		1.6461	1.643	1.5684	1.3032
8	1.4563	1.4377		1.5546	1.4563	1.4003	1.166
9	1.4563	1.4937		1.4632	1.4937	1.363	1.2174
10	1.4415	1.3889		1.4842	1.531	1.3443	1.166
11	1.475	1.4746		1.6244	1.5684	1.2174	1.2696
12	1.475	1.6632	2.3777	1.6804	1.6057	1.166	1.2382
13	1.5339	1.6804	2.1582	1.9044	1.6617	1.166	1.2197
14	1.5154	1.749	2.1948	2.0165	1.643	1.0802	1.2136
15	1.4784	1.7661	2.1582	2.0698	1.6057	1.046	
16	1.4937	1.7147	2.0328	1.9791	1.531	1.046	1.2323
17	1.46	1.6289	1.7375	1.8298	1.4937	1.0974	1.251
18	1.5154	1.5604	1.7187	1.7364	1.587	1.1488	1.2567
19	1.8111	1.8176	1.9774	1.9044	1.8111	1.4403	1.531
20	2.0698	2.0748	2.2032	2.2218	1.9774	1.6118	1.4937
21	2.1437	2.1091	2.4025	2.347	2.0165	1.6289	1.4563
22	2.1845	2.1948	2.4025	2.4764	2.0538	1.6118	1.419
23	2.2032	2.2119	2.3777	2.5133	2.1285	1.5604	1.3256
24	2.2546	2.1658	2.1605	2.4025	2.4394	2.1098	1.5432
Max	2.2546	2.2119	2.4025	2.5133	2.4394	2.1098	1.5432
Min	1.4415	1.3889	1.6118	1.4632	1.4563	1.046	1.166
Avg	1.7833	1.8234	2.0569	2.0140	1.8273	1.5114	1.3469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 202 / 11 kV Bhanegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8402	.8573	.8779	.9149	.7762	.583
2	.8402	.8215	.7888	.8871	.8775	.7468	.5487
3	.7842	.7842	.7545	.823	.8299	.7095	.5487
4	.8029	.8029	.6859	.8048	.7842	.6722	.5316
5	.8402	.7842	.6516	.7316	.7282	.6535	.5144
6	.7095	.6348	.6173	.695	.6722	.6348	.5144
7	.5975	.6535	.5658	.5359	.5601	.5788	.4458
8	.5788	.5601	.5658	.6036	.5415	.5601	.4287
9		.1867	.6173	.6584	.6348	.5601	.4458
10		.1715	.6516	.7392	.7468	.5601	.4973
11		.3258	.7316	.7468	.7095	.4801	.5041
12		.3429	.6219	.7468	.6908	.4287	.4854
13	.1478	.3429	.7316	.8029	.6722	.4287	.4668
14	.1867	.12	.8413	.8029	.6535	.3944	.4668
15	.2801	.7202	.8779	.8215	.6348	.3772	
16	.7392	.823	.7316	.8775	.6348	.3772	.4668
17	.7947	.8402	.6584	.8402	.6535	.4458	.4481
18	.7392	.5316	.5853	.6161	.5975		.462
19	.7023	.6516	.6036	.6161	.6099	.4801	.5228
20	.7392	.6859	.7316	.7842	.6722	.5144	.5415
21	.7577	.7888	.7682	.8589	.7655	.5316	.5228
22	.8402	.8916	.8779	.9522	.7842	.6001	.5228
23	.8413	.9774	1.3717	.9795	.8029	.583	.5041
24	.9522	.8402	.9088	.823	.9709	.7947	.583
Max	.9522	.9774	1.3717	.9795	.9709	.7947	.583
Min	.1478	.12	.5658	.5359	.5415	.3772	.4287
Avg	.6885	.6301	.7416	.7760	.7143	.5604	.5024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 203 / 11 KV WCL BHANEGAON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.39	1.2003	1.1088	1.3256	1.307	1.406
2	1.251	1.4563	1.2689	1.0974	1.3817	1.3443	1.4403
3	1.307	1.4377	.8688	1.1157	1.4563	1.3256	1.4403
4	1.386	1.4563	1.3717	1.4632	1.4937	1.307	1.4232
5	1.587	1.6057	1.406	1.4815	1.5497	1.3443	1.406
6	1.531	1.4937	1.3032	1.5546	1.6244	1.3256	1.3375
7	1.307	1.4937	1.166	1.2071	1.5684	1.3443	1.3546
8	1.6057	1.1576	1.1488	1.4632	1.6244	1.643	1.406
9	1.6244	1.1576	.7773	1.6095	1.6617	1.643	1.8004
10	1.6991	1.0802	1.3375	1.4632	1.7187	1.6617	1.7833
11	1.7177	.7545	1.5546	1.531	1.7177	1.2346	1.9605
12	1.7002	.7202	1.39	1.4937	1.7364	1.0974	1.9418
13	1.6991	1.4403	1.3169	1.475	1.6991	1.4232	1.9605
14	1.7002	1.4232	1.0974	1.4377	1.6804	1.406	1.9605
15	1.7187	1.4403	1.5546	1.4377	1.3443	1.406	1.8671
16	1.7372	1.5089	1.8107	1.7372	1.363	1.3889	1.7737
17	1.7556	1.5775	1.5729	1.7551	1.3817	1.4746	1.7364
18	1.7187	1.4746	1.6095	1.2696	1.7364	1.4403	1.848
19	1.6827	1.4746	1.5364	1.3256	1.7002	1.286	1.9035
20	1.6632	1.4575	1.4045	1.0829	1.4415	1.406	1.9231
21	1.3676	1.5432	1.0974	1.307	1.307	1.406	1.9418
22	1.6827	1.5089	1.4632	1.2696	1.1949	1.406	1.9231
23	1.6804	1.166	1.3717	1.3443	1.2136	1.406	2.0165
24	1.1763	1.643	1.166	1.0974	1.2696	1.2936	1.406
Max	1.7556	1.643	1.8107	1.7551	1.7364	1.6617	2.0165
Min	1.1763	.7202	.7773	1.0829	1.1949	1.0974	1.3375
Avg	1.5630	1.3692	1.3248	1.3803	1.5079	1.3884	1.7067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 401 / 33 KV GCR1

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0008	.1008	.1029		.0007	.1008	.1029
2	.0007	.1008	.1029		.0008	.1008	.1029
3	.0007	.1008	.1029		.0008	.1008	.1029
4	.0007	.1008	.1029		.0008	.1008	.1029
5	.0008	.1008	.1029		.0007	.1008	
6	.0006	.1008	.1029		.0006	.1008	.1029
7	.0007	.1008			.0007	.1008	.1029
8	.0008	.1008	.1029		.0008	.1008	.1029
9	.0008	.1008	.1029		.0008	.1008	.1029
10	.1008	.1029	.1029		.0008	.1019	.1029
11	.1008	.1029		.0008	.1008	.1029	.1008
12	.1008	.1029		.0009	.1008	.1029	.1008
13		.1029		.0008	.1008	.1029	.1008
14	.0998	.1029		.0009	.1008	.1029	.1008
15	.0998	.1029		.0008	.1008	.1029	.1019
16	.0998	.1029		.0008	.1008	.1029	.1075
17	.0998	.1029			.1008	.1029	.1064
18	.0998	.1029			.1008	.1029	.1109
19	.1053	.1029		.0008	.1109	.1029	.1109
20	.1097	.1029		.0009	.112	.1029	.112
21	.112	.1029		.0008	.112	.1029	.112
22	.112	.1029		.0008	.112	.1029	.1132
23	.112			.0008	.1064	.1029	.1132
24	.0008	.1064	.1029		.0008	.1064	.1029
Max	.112	.1064	.1029	.0009	.112	.1064	.1132
Min	.0006	.1008	.1029	.0008	.0006	.1008	.1008
Avg	.0591	.1022	.1029	.0008	.057	.1022	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 402 / 33 KV GCR2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0008	.1008	.1029	.1097	.0007	.0998	.1029
2	.0007	.1008	.1029	.1097	.0008	.1008	.1029
3	.0007	.1008	.1029	.1097	.0008	.1008	.1029
4	.0007	.1008	.1029	.1109	.0008	.1008	.1029
5	.0008	.1008	.1029	.1097	.0007	.1008	.1029
6	.0006	.1008	.1029	.1097	.0006	.1008	.1029
7	.0007	.1008		.1109	.0007	.1008	.1029
8	.0008	.1008	.1029	.1097	.0008	.1008	.1029
9	.0008	.1008	.1029	.1097	.0008	.1008	.1029
10	.1008	.1029	.1029	.1097	.0008	.1019	.1029
11	.1008	.1029	.1109	.0008	.1008	.1029	.1008
12	.1008	.1029	.1109	.0009	.1008	.1029	.1019
13	.1008	.1029	.1109	.0008	.1008	.1029	.1008
14	.0998		.1109	.0009	.1008	.1029	.1075
15	.0998	.1029		.0008	.1008	.1029	.1019
16	.0998	.1029		.0008	.1008	.1029	
17	.1008	.1029			.1008	.1029	.1008
18	.0998	.1029			.1008	.1029	.1109
19	.1053	.1029	.1097	.0008	.1109	.1029	.1109
20	.1097	.1029	.1097	.0009	.112	.1029	.112
21	.1043	.1029	.1109	.0008	.112	.1029	.112
22	.1064	.1029	.1109	.0008	.112	.1029	.1132
23	.1064	.1029	.1097	.0008	.1064	.1029	.1132
24	.0008	.1064	.1029	.1097	.0008	.1053	.1029
Max	.1097	.1064	.1109	.1109	.112	.1053	.1132
Min	.0006	.1008	.1029	.0008	.0006	.0998	.1008
Avg	.0601	.1022	.1065	.0554	.057	.1021	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 403 / 33 KV Incomer I(KANHAN) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.313	4.5931	4.2181	4.481	4.5931	4.0329	3.3951
2	4.201	4.369	4.2181	4.2798	4.481	3.8089	3.4979
3	4.145	4.313	4.1152	4.2798	4.425	3.6969	3.4979
4	4.201	4.3244	4.0124	4.3896	4.313	3.6969	3.6008
5	4.425	4.257	3.7037	4.3896	4.257	3.6969	3.6008
6	4.0889	3.9209	3.7037	4.1701	4.257	3.6408	3.2922
7	3.7529	3.8089	1.8519	3.8477	3.7529	3.4728	3.1893
8	3.8089	3.2487	1.8004	3.7311	3.6408	3.3608	3.0864
9	3.1367	3.0247	1.8519	3.8409	3.8649	3.2487	3.6008
10	3.1367	2.7778	1.8519	3.8409	4.0329	3.2487	3.5494
11	3.1367	2.3663	2.4143	3.9209	4.0329	3.0864	3.6969
12	3.2487	2.3663	4.3244	3.9209	4.145	2.8807	3.5848
13	3.4374	3.3951	4.1701	4.257	4.145	2.9835	3.6969
14	3.4374	3.2922	4.6571	4.369	4.145	2.7778	3.6969
15	3.4374	4.1152	4.7188	4.481	3.6969	2.7778	3.1367
16	3.8809	4.2181	4.7188	4.8171	3.6969	2.8807	3.4728
17	3.9918	4.2181	4.0604	4.537	3.5848	2.8807	3.4728
18	3.8809	3.7037	3.9918	3.9043	3.9209	2.572	3.5482
19	4.257	4.0124	4.2798	3.9209	4.145	3.2922	3.9918
20	4.3244	4.4239	4.1701	4.145	4.145	2.8807	4.0329
21	4.2798	4.4753	4.3244	4.7051	4.0329	2.9321	3.9209
22	4.768	4.6296	4.2798	4.8171	3.9209	3.6008	3.8089
23	4.768	4.6296		4.9343	4.145	3.3951	3.9209
24	4.481	4.5931	4.2181	4.3896	4.8171	4.145	3.3951
Max	4.768	4.6296	4.7188	4.9343	4.8171	4.145	4.0329
Min	3.1367	2.3663	1.8004	3.7311	3.5848	2.572	3.0864
Avg	3.9391	3.8782	3.7241	4.2654	4.0913	3.2912	3.5703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 404 / 33 KV Incomer II(ROHANA) NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	24-JUN-18	25-JUN-18
HR	Load (MW)	Load (MW)
2		.1097
3		.1097
4		.1097
5		.1097
6		.1097
16	.1097	
18	.1097	
19	.1097	
20	.1097	
Max	.1097	.1097
Min	.1097	.1097
Avg	.1097	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 201 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709		.1595	.1578	.0351	.0351	.0175
2	.0709		.1595	.1578	.0351	.0351	.0175
3	.0709	.0532	.1595	.1578	.0351	.0351	.0175
4	.0709	.0532	.1595	.1578	.0351	.0351	.0175
5	.0709	.0532	.1595	.1578	.0351	.0351	.0175
6	.0709	.1772	.1595	.1578	.0351	.1402	.1578
7	.0709	.1772	.1595	.1578	.1578	.1402	.1578
8	.1949	.1595	.1595	.1578	.1578	.1578	.1578
9	.1949	.1772	.1595	.1578	.1578	.1753	.1578
10	.2126	.1772	.1595	.1753	.0351	.1753	.298
11	.1949	.1772	.1578	.1578	.0351	.1753	.1753
12	.2126	.1949	.1578	.1578	.0351	.0351	.1753
13	.2126	.1949	.1578	.1578	.0354	.0351	.1753
14			.1753	.0351	.0351	.0351	.1753
15		.1772	.0351	.0351	.0175	.0351	.1753
16		.1595	.1402	.0351	.0175	.0351	.298
17		.1595	.0175	.0351	.0351	.0351	.1928
18		.1595	.0175	.0381	.1578	.1578	.1753
19		.1595	.0175	.1402	.1402	.1402	.1578
20	.1772	.1595	.0175	.1402	.1402	.0351	.1578
21	.1772	.1417	.0175	.1578	.1402	.0351	.1578
22	.1772	.1595	.0175	.1402	.1402	.0351	.1578
23	.1772	.1595	.0175	.1402	.1402	.0351	.1578
24	.0709	.1772	.1595	.0175	.1402		.0351
Max	.2126	.1949	.1753	.1753	.1578	.1753	.298
Min	.0709	.0532	.0175	.0175	.0175	.0351	.0175
Avg	.1388	.1527	.1125	.1243	.0804	.0778	.1410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 202 / 11 KV Jagdamba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0381	.0381	.0381	.0351	.0381
2	.0381		.0381	.0381	.0381	.0351	.0381
3	.0381	.0381	.0191	.0381	.0381	.0381	.0381
4	.0381	.0381	.0191	.0381	.0381	.0381	.0381
5	.0381	.0381	.0191	.0381	.0381	.0381	.0381
6	.0381	.0381	.0191	.0191	.0381	.0381	.0191
7	.0381	.0381	.0381	.0191	.0381	.0191	.0191
8	.0381	.0381	.0381	.0191	.0381	.0381	.0191
9	.0381	.0191	.0381	.0191	.0381	.0381	.0191
10	.0381	.0381	.0381	.0381	.0381	.0381	.0191
11	.0572	.0381	.0191	.0381	.0381	.0381	.0191
12	.0381	.0381	.0381	.0381	.0381	.0381	.0191
13	.0381	.0381	.0381	.0381	.0191	.0381	.0191
14	.0381	.0381	.0191	.0381	.0381	.0191	.0191
15	.0191	.0381	.0191	.0381	.0381	.0191	.0191
16	.0381	.0381	.0191	.0381	.0381	.0191	.0191
17	.0381	.0381	.0191	.0381	.0381	.0191	.0191
18	.0381	.0381	.0191	.0381	.0381	.0381	.0191
19	.0381	.0381	.0191	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0572	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0381	.0372	.0294	.0349	.0373	.0339	.0278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 201 / 11KV PARSEONI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6516	.9602	.9431	1.0288	.8573	.5144
2	.6344	.6344	.9602	.8916	1.0288	.823	.5144
3	.6001	.6173	.9431	.8573	1.0288	.7888	.5144
4	.6001	.6001	.9431	.823	.9774	.7716	.4973
5	.5658	.583	.9088	.7888	.9431	.7716	.4973
6	.5487	.5487	.8573	.7716	.7716	.7373	.4801
7	.4973	.463	.6859	.823	.7373	.6344	.4287
8	.4973	.463	.6859	.6173	.6859	.6344	.4287
9	.4801	.463	.6859	.6001	.6173	.6173	.4287
10	.4973	.4973	.6859	.6859	.6859	.6173	.4115
11	.463	.5316	.6687	.7202	.6516	.5658	.3944
12	.5144	.6516	.7202	.7888	.6516		.3944
13	.5144	.7716	.7545	.8059	.6516	.0171	.4115
14	.4801	.7716	.7545	.8059	.6859	.1372	.4287
15	.4973	.7716	.7545	.823	.703	.1372	.4287
16	.4973	.7716	.7202	.8402	.6859	.6516	.3944
17	.4973	.7373	.6687	.7716	.6859	.5658	.4287
18	.4801	.703	.6687	.7202	.6516	.5144	.4287
19	.5487	.823	.7716	.703	.7545	.5316	.4801
20	.6173	.8745	.8916	.9431	.7545	.5487	.4973
21	.6516	.9259	.9259	.9602	.8573	.5487	.463
22	.6859	.9602	.9774	1.0288	.8745	.5487	.463
23	.6859	.9945	.9945	1.046	.8916	.5487	.4458
24	.6344	.6859	.9774	.9945	1.0288	.8916	.5316
Max	.6859	.9945	.9945	1.046	1.0288	.8916	.5316
Min	.463	.463	.6687	.6001	.6173	.0171	.3944
Avg	.5551	.6873	.8152	.8230	.7931	.5852	.4544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 202 / 11 KV PARASEONI RURAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.823	.7888	.823	.823	.6516	.5487
2	.6687	.7888	.7888	.7888	.823	.6516	.5658
3	.6344	.7888	.7373	.7545	.8059	.6344	.5316
4	.6344	.7202	.6859	.7202	.7716	.6344	.5144
5	.6001	.6859	.6859	.703	.7545	.6687	.4801
6	.5658	.6001	.6344	.6859	.6344	.6173	.4115
7	.5316	.5144	.5658	.5658	.6001	.5144	.4287
8	.5144	.4973	.5487	.6344	.5487	.463	.4458
9	.4801	.4973	.5316	.703	.5487	.463	.463
10	.463	.4801	.463	.6859	.6001	.463	.4458
11	.4287	.4973		.6173	.5487	.4287	.4115
12	.4115	.4801	.583	.6173	.5144	.3086	.3944
13	.4287	.4801	.6687	.6173	.5144		.3601
14	.4287	.4458	.703	.6173	.4973	.3086	.3601
15	.3258	.4458	.6859	.6001	.4801	.2915	.4115
16	.3429	.3086	.6516	.583	.4801	.2915	.3601
17	.4287	.3086		.4801	.4801	.3429	.3086
18	.4458	.3258		.5144	.463	.3944	.4115
19	.6516			.6687	.6344	.6687	.583
20	.8573	.8059		.9602	.8059	.7202	.6687
21	.8573	.9088	.8916	.9602		.703	.6344
22	.8573	.8573	.9259	.9431	.7888	.703	.6344
23	.823	.823	.8745	.823	.7888	.6859	.6173
24	.6687	.823	.7888	.8573	.823	.6859	.6173
Max	.8573	.9088	.9259	.9602	.823	.7202	.6687
Min	.3258	.3086	.463	.4801	.463	.2915	.3086
Avg	.5716	.6046	.6949	.7052	.6404	.5345	.4837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 203 / 11 KV SURYLATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2572	.2915	.3086	.2572	.2401
2	.2401	.2743	.2401	.2743	.3086	.2401	.2229
3	.2229	.2572	.2401	.2572	.2915	.2401	.2229
4	.2229	.2401	.2229	.2401	.2915	.2229	.2229
5	.2229	.2401	.2058	.2401	.2572	.2229	.2058
6	.2058	.2058	.1886	.2229	.2229	.2058	.1886
7	.1886	.1372		.1715	.2058	.1715	.1543
8	.1886	.1543	.1715	.1886	.1886	.1715	.1543
9	.1715	.2058	.1886	.2229	.1543	.1543	.1543
10	.1543	.2058	.1543	.2229	.1543	.1372	.1543
11	.1543	.2229	.1543	.1886	.1715	.1372	.1543
12	.1372	.2058	.1886	.2058		.12	.1372
13	.1372	.1886	.2058	.2058	.1543	.1029	.1372
14	.1372	.1886	.1886	.2058	.1715	.1029	.1372
15	.1372	.1886	.2058	.2058	.1886	.1029	.1372
16	.1372	.1886	.2058	.2058	.1715	.1029	.1372
17	.1372	.1886	.1543	.2058	.1543	.1029	.1372
18	.1372	.1886	.1715	.1715	.1715	.1029	.1372
19	.1886	.2229	.2401	.2058	.2058	.1372	.1886
20	.2915	.2572	.3258	.2915	.2572	.2401	.2229
21	.2915	.2915	.3258	.3258	.2743	.2401	.2058
22	.2915	.2743	.3258	.3258		.2401	.2058
23	.2915	.2743	.3086	.3086	.2915	.2401	.2058
24	.2401	.2915	.2572	.3086	.3086	.2572	.2401
Max	.2915	.2915	.3258	.3258	.3086	.2572	.2401
Min	.1372	.1372	.1543	.1715	.1543	.1029	.1372
Avg	.1986	.2236	.2229	.2372	.2229	.1772	.1793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 204 / 11KV TAMSWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	1.2003	1.2174	1.2346	1.2346	1.0117	.703
2	.463	1.2003	1.2003	1.2003	1.2174	.9945	.703
3	.4973	1.166	1.2003	1.166	1.2003	.9602	.7202
4	.4973	1.0974	1.1317	1.0974	1.2003	.9259	.7202
5	.5658	1.0288	1.1317	1.0288	1.166		.7202
6	.6516	.9774	1.046	.9945	.9259	.8916	.7545
7	.7888	.8573	.9259	.9602	.9431	.7545	.7716
8	.7716	.8573	.9431	.9945	.9431	.7545	.7545
9	.7716	.8745	.9774	1.0288	.5487	.703	.7545
10	.7716	.7888	1.046	1.0631	.7545	.4287	.7373
11	.7202	.6859	1.046	1.0802	.823	.4287	.463
12	.703	.6001	1.0117	1.0631	.9431	.463	.2743
13	.823	.5487	1.0288	1.0288	.9431	.4973	.3944
14	.8402	.5316	1.0631	1.0288	.9088	.5144	.583
15	.8402	.5316	1.0631	1.0288	.9259	.5144	.6173
16	.8059	.5487	1.0631	.6344	.8573	.5658	.6173
17	.7716	.4973	.8916	.9945	.8059	.583	.3944
18	.8059	.4458	.9431	.9774	.823	.6001	.6344
19	.9602	.6001	1.0974	1.0117	.1715	.7373	.6516
20	1.2003	.7373	1.0974	1.3203	.8059	.9774	.9088
21	1.2689	1.3032	1.2346	1.3203	.9945	1.0288	.8573
22		1.286	1.3203	1.3032		1.046	.823
23	1.2346	1.286	1.2689	1.286	1.0802	.9259	.6687
24	.3258	1.2346	1.2517	1.2517	1.2346	1.0802	.823
Max	1.2689	1.3032	1.3203	1.3203	1.2346	1.0802	.9088
Min	.3258	.4458	.8916	.6344	.1715	.4287	.2743
Avg	.7567	.8702	1.0917	1.0874	.9326	.7560	.6687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 205 / 11 kV MIDC Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0171	.0343
2	.0343	.0343	.0343	.0343	.0343	.0171	.0343
3	.0343	.0343	.0343	.0343	.0343	.0171	.0343
4	.0343	.0343	.0343	.0343	.0343	.0171	
5	.0343	.0343	.0343	.0343	.0343	.0171	.0343
6	.0343	.0343	.0343	.0343	.0343		.0343
7	.0343	.0343	.0343	.0343	.0343	.0171	.0343
8	.0343	.0343	.0514	.0343	.0343	.0171	.0343
9	.0343	.0343	.0514	.0343	.0343		.0343
10	.1543		.0514	.2229	.2229	.2058	.1715
11	.1886		.0514	.2229	.2572	.2058	.1886
12	.2401		.0343	.2229	.2572	.1886	.1886
13	.1886		.0343	.2229	.2572	.1886	.1886
14	.1715	.2229	.0343	.2229	.2229	.1543	.1886
15	.1715	.2229	.0343	.2058	.2058	.1543	.2229
16	.1372	.2229	.0343	.1886	.2058	.1372	.2229
17	.2058	.1543		.1886	.2229	.1372	.1886
18	.0343	.0343	.0343	.0343	.0343	.12	.0343
19	.0343	.0343	.0343	.0343	.0343	.0857	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0171	.0343
Max	.2401	.2229	.0514	.2229	.2572	.2058	.2229
Min	.0343	.0343	.0343	.0343	.0343	.0171	.0343
Avg	.0836	.0686	.0373	.0936	.1000	.0842	.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSHIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 206 / 11 KV PARSHIONI URBAN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944		.0343		.3429
2	.3944		.0343		.3429
3	.3601		.0343		.3258
4	.3601		.0343		.3258
5	.3429		.0343		.3086
6	.3258		.0343		.2743
7	.2743		.0343		.2572
8	.2572		.0343		.2401
9	.2401		.0343		.2229
10		.0343		.0343	.2058
11		.2058		.0343	.1543
12		.2058		.0343	.1715
13		.2229		.0343	.1715
14		.0343		.0343	.1886
15		.0343		.0343	.1886
16		.0343		.0343	.1886
17		.0343		.0343	.1886
18		.0343		.0343	.1715
19		.0343		.2229	.2401
20		.0343		.3086	.2743
21		.0343		.3429	.2743
22		.0343		.3772	.2743
23		.0343		.3772	.2743
24	.3944		.0343		.3601
Max	.3944	.2229	.0343	.3772	.3601
Min	.2401	.0343	.0343	.0343	.1543
Avg	.3344	.0723	.0343	.1384	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 207 / AG SEPERATION FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-JUN-18
HR	Load (MW)
10	.0171
11	.0171
12	.0171
13	.0171
14	.0171
15	.0171
16	.0171
17	.0171
18	.0171
19	.0171
20	.0171
21	.0171
22	.0171
23	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 201 / Bitoli AG Separated

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0514	.0328	.056	.0344	.0328	.0373
2	.056	.0514	.0328	.056	.0343	.0328	.0373
3	.056	.0514	.0328	.0373	.0343	.0328	.0373
4	.0373	.0343	.0328	.0373	.0343	.0328	.0373
5	.0373	.0343	.0328	.0373	.0343	.0328	.0373
6	.0373	.0343	.0328	.0373	.0514	.0328	.0373
7	.0747	.0343	.0328	.0373	.0514	.0328	.0373
8	.0373	.0343	.0328	.0328	.0686	.0492	.0373
9	.0343	.0328	.0373	.2401	.0655	.0328	.0328
10	.0686	.0655	.0747	.2572	.0983	.0819	.0164
11	.0686	.0655	.0819	.2743	.1147	.0328	.0492
12	.0686	.0983	.1147	.2915	.1147	.0934	.0492
13	.0686	.0655	.0819	.2915	.1311	.0819	.0655
14	.0686	.0655	.0934	.2915	.1311	.0655	.0655
15	.0686	.0655	.0819	.2915		.0655	.0655
16	.0686	.0655		.2915	.0819	.0819	.0655
17	.0686	.0819	.1147	.2572	.0819	.0655	.0655
18	.0343	.0328	.0655	.2058	.0328	.0164	.0328
19	.0343	.0492	.0492	.0514	.0492	.0328	.0492
20	.0343	.0328	.0492	.0343	.0328	.0492	.0492
21	.0343	.0492	.0164	.0343	.0328	.0373	.0492
22		.0492	.0164	.0343	.0328	.0328	.0492
23	.0343	.0328	.0328	.0343	.0328	.0328	.0492
24	.056	.0514	.0328	.0328	.0343	.0328	.0373
Max	.0747	.0983	.1147	.2915	.1311	.0934	.0655
Min	.0343	.0328	.0164	.0328	.0328	.0164	.0164
Avg	.0523	.0512	.0524	.1352	.0613	.0464	.0454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 202 / INDUSTRIAL -H.T.-FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0514	.0543	.0747	.0343	.0362	.0373
2	.0373	.0514	.0362	.0747	.0343	.0362	.0373
3	.0373	.0514	.0543	.056	.0343	.0362	.0373
4	.0373	.0514	.0362	.056	.0343	.0362	.0187
5	.0373	.0343	.0362	.0373	.0343	.0362	.0187
6	.0373	.0343	.0362	.0373	.0343	.0362	.0187
7	.0373	.0343	.0543	.0373	.0343	.0362	.0187
8	.0373	.0514	.0362	.0362	.0514	.0362	.0187
9	.0343	.0543	.056	.0343	.0362	.0362	.0175
10	.0343	.0362	.0187	.0171	.0328	.0362	.0362
11	.0514	.0362	.0181	.0171	.0362	.0362	.0362
12	.0514	.0362	.0362	.0343	.0362	.0373	.0181
13	.0514	.0362	.0362	.0343	.0362	.0362	.0362
14	.0343	.0362	.0373	.0343	.0362	.0181	.0362
15	.0343	.0543	.0373	.0514	.0362	.0181	.0362
16	.0171	.0362	.0373	.0514	.0181	.0362	.0543
17	.0171	.0362	.0362	.0514	.0543	.0362	.0543
18	.0171	.0362	.0362	.0514	.0543	.0362	.0362
19	.0343	.0362	.0543	.0514	.0543	.0362	.0362
20	.0514	.0362	.0543	.0514	.0543	.0362	.0351
21	.0514	.0724	.0543	.0514	.0543	.0373	.0362
22	.0514	.0724	.0543	.0343	.0543	.0362	.0362
23	.0514	.0543	.0724	.0343	.0543	.0362	.0362
24	.0373	.0514	.0543	.0724	.0343	.0543	.0373
Max	.0514	.0724	.0724	.0747	.0543	.0543	.0543
Min	.0171	.0343	.0181	.0171	.0181	.0181	.0175
Avg	.0383	.0450	.0432	.0451	.0406	.0355	.0327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 203 / 11KV CHARGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1029	.1132	.132	.0857	.0943	.0943
2	.0943	.1029	.1132	.132	.0857	.0943	.0754
3	.0943	.1029	.1132	.1132	.0857	.0943	.0754
4	.0754	.1029	.0943	.1132	.0857	.0943	.0754
5	.0754	.0857	.0943	.0943	.0857	.0943	.0754
6	.0754	.0857	.0943	.0943	.0857	.0943	.0754
7	.0754	.0857	.0943	.0943	.0857	.0943	.0943
8	.0943	.1029	.0943	.1142	.0686	.0754	.0943
9	.1029	.0943	.0754		.0943	.0724	.0754
10		.0566	.0566		.1132	.057	.0754
11	.0686	.0566	.0761		.0566	.057	.0754
12	.0343	.0754	.0761		.0754	.0377	.0754
13	.0343	.0754	.0761		.0754	.0761	.0754
14	.0343	.0754	.0754		.0566	.057	.0754
15	.0343	.0754	.0566		.0754	.057	.0377
16	.0514	.0754	.0754		.0754	.0761	.0754
17	.0514	.0754	.0761		.0377	.0761	.0724
18	.1029	.0754	.057		.0566	.1141	.0566
19	.12	.132	.0951	.0686	.1132	.1521	.0566
20	.1372	.132	.1903	.12	.132	.1711	.0377
21	.1372	.132	.1713	.1029	.132	.1509	.0377
22	.1372	.132	.1713	.1029	.132	.1521	.0377
23	.1372	.132	.1713	.1029	.132	.1521	.0377
24	.1132	.12	.132	.1713	.0857	.132	.132
Max	.1372	.132	.1903	.1713	.132	.1711	.132
Min	.0343	.0566	.0566	.0686	.0377	.0377	.0377
Avg	.0859	.0953	.1018	.1112	.088	.0969	.0706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 204 / Bitoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3772	.439	.4481	.4458	.4207	.3174
2	.3921	.3772	.439	.4481	.4115	.4024	.2614
3	.3734	.3429	.4207	.3921	.3772	.4024	.3174
4	.3734	.3429	.4024	.3734	.3429	.3841	.2241
5	.3361	.3086	.3841	.3361	.3086	.3658	.2241
6	.2987	.2743	.3292	.2987	.3086	.2926	.2241
7	.2614	.2401	.2378	.2614	.2572	.2195	.2241
8	.2614	.2572	.2561	.2772	.2572	.1829	.2241
9	.2058	.2743	.2801		.2561	.1663	.1829
10	.1886	.2378	.2614		.2378	.2033	.1646
11	.1715	.2743	.2587		.2012	.1663	.1646
12	.1715	.2743	.2957		.2195	.1867	.1646
13	.1886	.2926	.2957		.2195	.1478	.1463
14	.2058	.3109	.2987		.2378	.1478	.1646
15	.2058	.3109	.2987		.1829	.1294	.1829
16	.2058	.2926	.2801		.128	.1109	.1463
17	.2058	.2378	.2033		.1463	.1478	.1646
18	.2572	.2378	.2402		.2012	.2402	.1829
19	.3086	.3109	.3142	.3086	.2378		.3109
20	.4115	.4572	.4805	.4115	.3841	.3511	.3475
21	.4287	.4755	.4805	.4115	.4024	.3547	.3475
22	.4458	.4938	.4805	.4115	.439	.3511	.3475
23	.4458	.4755	.4805		.439	.3511	.3475
24	.4294	.4287	.4755	.462	.4458	.439	.3361
Max	.4458	.4938	.4805	.462	.4458	.439	.3475
Min	.1715	.2378	.2033	.2614	.128	.1109	.1463
Avg	.2993	.3294	.3472	.3723	.2953	.2680	.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 205 / 11 KV SATRAPUR Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0172	
2		.0171	
3		.0171	
4		.0171	
5		.0171	
6		.0171	
7		.0171	
8		.0171	
10	.0171		
11	.0171		
12	.0171		
13	.0171		
14	.0171		
15	.0171		
16	.0171		
17	.0171		.0191
18	.0171		
19	.0171		
20	.0171		.0191
21	.0171		
22	.0171		
23	.0171		
24		.0171	
Max	.0171	.0172	.0191
Min	.0171	.0171	.0191
Avg	.0171	.0171	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 401 / 33 KV SMS RBC Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549		.0537	.0549		.0537	.056
2	.0549		.0537	.0532		.0537	.056
3	.0549		.0537	.0532		.0537	.056
4	.0549		.0537	.0532		.0537	.056
5	.0549		.0537	.0532		.0537	.056
6	.0549		.0537	.0532		.0537	.056
7	.0549		.0537	.0532		.0537	.056
8	.0549		.0537	.052		.0537	.056
9		.0537	.0549		.0537	.0572	.0537
10		.0537	.0549		.0537	.0572	.0537
11		.0537	.0572		.0537	.0572	.0537
12		.0537	.052		.0537	.056	.0537
13		.0537	.052			.0572	.0537
14		.0537	.0549		.0537	.0572	.0537
15		.0537	.0549		.0537	.0572	.0537
16		.0537	.0549			.0572	.0537
17		.0537	.052		.0537	.0572	.0537
18		.0537	.052	.0514	.0537	.0572	.0537
19		.0537	.052		.0537	.0572	.0537
20		.0537	.052		.0537	.0572	.0537
21	.0514	.0537	.052		.0537	.056	.0537
22	.0514	.0537	.052		.0537	.0572	.0537
23		.0537	.052		.0537	.0572	.0537
24	.0549		.0537	.052		.0537	.056
Max	.0549	.0537	.0572	.0549	.0537	.0572	.056
Min	.0514	.0537	.052	.0514	.0537	.0537	.0537
Avg	.0543	.0537	.0535	.0530	.0537	.0558	.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 201 / nanda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.7621	.743	.9526	1.0669	1.105	1.1431
2	.4954	.7621	.724	.9526	1.0669	1.0669	1.1431
3	.4954	.7621	.724	.9526	1.0669	1.0288	.9526
4	.4954	.7621	.724	.9526	1.0669	.9907	.9526
5	.4572	.5716	.6859	.9145	1.0669	.9145	.9145
6	.4572	.5716	.6097	.8764	1.0288	.8002	.9145
7	.4572	.5335	.5716	.8002	.9526	.6668	.7621
8	.4572	.5335	.4191	.8002	.9907	.6668	.6097
9	.4191	.5335	.5335	.8002	1.0288	.6668	.6097
10	.4191	.5335	.724	.8002	1.0669	.6097	.4572
11	.4191	.5716	.5716	.8383	.724	.6097	.4572
12	.4191	.5716	.6478	.9145	.6097	.5716	.381
13	.4191	.5716	.724	.9145		.5716	.381
14	.4191	.5716	.7621	.9526	.4954	.4954	.4572
15	.4572	.5716	.8002	1.0288	.4954	.4954	
16	.4572	.5335	.8002	1.1431	.4572	.4572	.4954
17	.4954	.5335	.7621	1.1431	.4191	.4191	.5716
18	.5335	.6478	.7621		.4191	.4191	.6097
19	.9526	.6859	.724	1.5242	.8002	.8764	.9145
20	1.4861	.8383	.7621	1.6004	1.0669	1.2193	.9526
21	1.5242	.8383	.8383	1.5242	1.1622	1.3336	.9526
22	.8002	.8002	.9145	1.0288	1.2574	1.4098	
23	.8002	.8002	.9526	1.0288	1.2955	1.4098	1.2193
24	.4954	.8002	.7811	.9526	1.0669	1.1431	1.4098
Max	1.5242	.8383	.9526	1.6004	1.2955	1.4098	1.4098
Min	.4191	.5335	.4191	.8002	.4191	.4191	.381
Avg	.5970	.6526	.7192	1.0172	.8988	.8311	.7846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 202 / KHAPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.5335	.6478	.5716	.5716	.6097	.2667
2	.1143	.5335	.6478	.5716	.5335	.5335	.2667
3	.1143	.5335	.6097	.5716	.4954	.4954	.2667
4	.1143	.4954	.6668	.5716	.4572	.4572	.2286
5	.1143	.4954	.6478	.5716	.4191	.381	
6	.1524	.4572	.6478	.381	.381	.3429	
7	.1524	.381	.6097	.2667	.2667	.2667	
8	.1524	.381	.6097	.2286	.2286	.2667	
9	.1524	.381	.4191	.2477	.2096	.2667	.2286
10	.1524	.381	.4001	.4572	.2477	.2667	.2286
11	.1143	.4191	.3239	.5716	.4954	.3048	.1905
12	.1524	.4191	.3429	.6097	.7811	.3048	.1715
13	.2667	.4191	.381	.6859		.3048	.1715
14		.381	.4954	.724	.8383	.3048	.1905
15		.381	.5144	.743	.8002	.3048	.1905
16	.2286	.3429	.4954	.724	.724	.3429	.1905
17	.2667	.3429	.4572	.724	.6859	.3429	.2286
18	.2858	.4572	.4191		.6478	.3429	.2477
19	.3048	.4954	.3048	.724	.4001	.3048	.3429
20	.5335	.5716	.381	.6287	.5525	.3048	.381
21	.5716	.6097	.6097	.6668	.5906	.3048	.4572
22	.6097	.6287	.6859	.7049	.6478	.3048	.5144
23	.5716	.6287	.724	.7049	.6478	.3048	.5144
24		.5716	.5716	.6859	.5716	.6097	.3048
Max	.6097	.6287	.724	.743	.8383	.6097	.5144
Min	.1143	.3429	.3048	.2286	.2096	.2667	.1715
Avg	.2495	.4684	.5255	.5799	.5302	.3572	.2791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 203 / 11 kV Budhala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0572	.0762	.0762	.1143	.0381
2		.0762	.0572	.0762	.0762		.0381
3		.0762	.0572	.0762	.0762	.1143	.0381
4		.0381	.0572	.0381	.0762	.1143	.0381
5		.0381	.0572	.0381	.0762	.1143	.0381
6		.0381	.0572	.0381	.0762	.1143	.0381
7		.0381	.0381	.0381	.0762	.0762	.0381
8		.0381	.0381	.0381	.0762	.0762	.0762
9	.0381	.0381	.0572	.0762	.0762	.0762	.0762
10	.0381	.0381	.0762	.0762	.0762	.0762	.0762
11		.0381	.0762	.0762	.0953	.0572	.0762
12		.0381	.0381	.0762	.1334		.0762
13		.0381	.0191	.0762		.0572	.0762
14		.0381	.0381	.0762	.1524	.0572	.0762
15		.0381	.0191		.1334	.0381	.0762
16		.0381	.0381		.1524	.0381	.0762
17	.0191	.0381	.3048	.0762	.1524	.0381	.0762
18		.0381	.5335		.1334	.0381	.0762
19		.0572	.5525	.0762	.1334	.0381	.0762
20		.0572	.7621	.0762	.1334	.0381	
21	.0381	.0572	.9145	.1524	.1334	.0762	.0762
22	.0762	.0572	.8383	.1524	.1334	.0762	.0762
23	.0762	.0572	.0762	.1524	.1334	.0762	.0762
24		.0762	.0572	.0762	.1143	.1143	.0762
Max	.0762	.0762	.9145	.1524	.1524	.1143	.0762
Min	.0191	.0381	.0191	.0381	.0762	.0381	.0381
Avg	.0476	.0484	.2009	.0780	.1085	.0736	.0646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 204 / 11 kV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	1.2193	1.2384	1.1431	1.3336	1.2574	.9526
2	.8002	1.1812	1.2384	1.1431	1.3336	1.2193	.8383
3	.8764	1.1812	1.2003	1.1431	1.3527	1.1812	.8383
4	.9145	1.1431	1.2574	1.1431	1.3527	1.1431	.8002
5	.9526	1.1431	1.2574	.9526	1.3717	1.105	.8002
6	.9907	1.1431	1.2193	.9526	1.3717	1.0669	.8002
7	1.2003	1.105	1.1431	.9526	1.3908	1.0288	.7621
8	1.3336	1.1431	1.105	.9145	1.4098	1.0288	.7621
9	1.5242	1.3336	1.4861	.8002	1.448	.9907	1.1431
10	1.5242	1.3717	1.5813	1.0288	1.7909	.9907	1.1431
11	1.7147	1.5623	1.6385	1.3336	1.7528	.9907	1.1431
12	1.9052	1.5623	1.7147	1.5242	1.7147	.9907	1.2384
13	2.0957	1.6004	1.7909	1.6575		.9526	1.2384
14	2.0957	1.6385	1.7528	1.7147	1.829	.9526	1.1812
15	1.9814	1.6385	1.7147	1.848	1.6004	.9526	1.1431
16	1.9052	1.6766	1.5242	1.5242	1.9243	.9145	1.1431
17	1.7147	1.6766	1.3336	1.3336	1.9624	.9145	1.0479
18	1.4289	1.4861	1.1431		1.9433	.9145	1.0479
19	1.1431	1.3717	1.2384	1.1431	1.6766	.9526	1.0288
20	1.1431	1.3146	1.2574	1.0288	1.6004	1.1431	1.0288
21	1.1431	1.2574	1.2955	1.1431	1.3717	1.1812	1.0669
22	1.1812	1.1812	1.2574	1.2384	1.2955	1.2193	1.0669
23	1.1812	1.1622	1.2193	1.2574	1.2574	1.2193	1.0669
24	.7621	1.2193	1.1241	1.1812	1.2955	1.2193	1.1431
Max	2.0957	1.6766	1.7909	1.848	1.9624	1.2574	1.2384
Min	.7621	1.105	1.105	.8002	1.2574	.9145	.7621
Avg	1.3463	1.3463	1.3638	1.2218	1.5382	1.0637	1.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 401 / 33 KV Incomer Umari SStn

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	2.0576	2.4577	2.6292	2.8006	2.2862	1.829
2	1.2574	2.0576	2.4577	2.6292	2.8578	2.1719	1.829
3	1.2574	2.0576	2.3434	2.6863	2.8578	2.0576	1.7147
4	1.2574	2.0576	2.5149	2.572	2.8006	1.9433	1.7147
5	1.2574	1.9433	2.572	2.572	2.8006	1.9433	1.7147
6	1.3717	1.9433	2.572	2.4577	2.8006	1.9433	.6859
7	1.3717	2.0576	2.7435	2.1148	2.7435	1.9433	.6859
8	1.3717	2.0576	2.7435	2.3434	3.0864	1.7147	.5716
9		2.0005	2.572	2.6292	3.2007	1.7147	.9145
10	1.829	2.1148	2.4006	2.7435	2.6863	1.7147	.9145
11	1.829	2.2291	2.4006	2.7435	2.6863	1.7147	1.0288
12	1.9433	2.4006	2.5149	2.8578	3.315	1.6004	1.1431
13	2.4006	2.4577	2.5149	2.9721		1.4861	1.1431
14	2.1148	2.4577	2.4577	2.9721	3.2007	1.4861	1.1431
15	1.829	2.4577	2.4577	3.0293	3.2007	1.3717	1.2574
16	1.829	2.4006	2.4577	2.9721	3.0864	1.3717	1.2574
17	1.7718	2.4006	2.4006	2.8578	2.6863	1.3717	1.3717
18	1.7147	2.4006	2.1719		2.4577	1.3717	1.3717
19	1.9433	2.4577	1.9433	2.7435	2.2862	1.829	1.6004
20	1.9433	2.4577	2.1719	2.572	2.3434	1.9433	1.7147
21	2.1719	2.4577	2.4006	2.6292	2.4006	2.0576	1.9433
22	2.1719	2.572	2.572	2.4577	2.4006	2.1148	2.0005
23	2.1148	2.572	2.572	2.4577	2.5149	2.1148	2.0005
24	1.2574	2.1148	2.3434	2.5149	2.572	2.4006	2.0576
Max	2.4006	2.572	2.7435	3.0293	3.315	2.4006	2.0576
Min	1.2574	1.9433	1.9433	2.1148	2.2862	1.3717	.5716
Avg	1.7072	2.2577	2.4482	2.659	2.7733	1.8195	1.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 402 / 63 Mah. Border check post NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572		.0572	.0572		.0572
2	.0572	.0572		.0572	.0572		.0572
3	.0572	.0572		.0572	.0572		.0572
4	.0572	.0572		.0572	.0572		.0572
5	.0572	.0572		.0572	.0572		.0572
6	.0572	.0572		.0572	.0572		.0572
7	.0572	.0572		.0572	.0572		.0572
8	.0572			.0572	.0572	.0572	.0572
9	.0572			.0572	.0572	.0572	.0572
10	.0572			.0572		.0572	.0572
11	.0572			.0572		.0572	.0572
12	.0572		.0572	.0572		.0572	.0572
13	.0572		.0572	.0572		.0572	.0572
14	.0572		.0572	.0572		.0572	.0572
15	.0572		.0572	.0572		.0572	.0572
16	.0572		.0572	.0572		.0572	.0572
17	.0572		.0572	.0572		.0572	.0572
18	.0572		.0572			.0572	.0572
19	.0572		.0572	.0572		.0572	.0572
20	.0572		.0572	.0572		.0572	.0572
21	.0572		.0572	.0572		.0572	.0572
22	.0572		.0572	.0572		.0572	.0572
23	.0572		.0572	.0572		.0572	.0572
24	.0572	.0572		.0572	.0572		.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 403 / 33 KV Sawargaon out
going(umri Feeder KV- 33 /
INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.5716	.6859	.8002	1.086	.6287	.3429
2	.1143	.5716	.6859	.8002	1.1431	.6287	.3429
3	.1143	.5716	.6287	.8573	1.1431	.5716	.3429
4	.1143	.5716	.6287	.8573	1.086	.6287	.3429
5	.1143	.5716	.6859	.8573	1.086	.5716	.3429
6	.1143	.5716	.9145	.8573	1.2003	.6287	.3429
7	.1143	.5716	.9145	.8573	1.2574	.6859	.3429
8	.1143	.5716	1.0288	1.0288	1.3717	.6287	.3429
9	.1143	.4572	.9145	1.2574	1.4289	.5716	.3429
10	.4572	.4572	.8002	1.2574	1.1431	.5716	.3429
11	.5144	.5716	.8002	1.0288	1.1431	.4572	.3429
12	.5144	.6287	.8002	1.0288	.9717	.4572	.3429
13	.5716	.6859	.6859	1.1431		.4572	.3429
14	.5716	.6859	.5716	1.1431	.9145	.4572	.3429
15	.4572	.743	.5716	1.2003	1.0288	.4572	.2286
16	.4572	.743	.5716	1.2003	1.0288	.3429	.2286
17	.4001	.743	.5716	1.1431	.6859	.3429	.2286
18	.3429	.743	.4572		.4572	.3429	.2286
19	.4572	.743	.3429	.4572	.6287	.4572	.3429
20	.4572	.743	.4572	.4572	.6287	.4572	.4572
21	.5716	.743	.5716	.4572	.6287	.4572	.4572
22	.5716	.8002	.6859	.4572	.5716	.4572	.5144
23	.5716	.8002	.6859	.4572	.6859	.4572	.5144
24	.1143	.5716	.6859	.5716	.6859	.6287	.3429
Max	.5716	.8002	1.0288	1.2574	1.4289	.6859	.5144
Min	.1143	.4572	.3429	.4572	.4572	.3429	.2286
Avg	.3358	.6430	.6811	.8772	.9567	.5144	.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 200 / 11 KV STATION TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0191	.0381
4	.0381	.0381	.0381	.0381	.0381	.0191	.0191
5	.0381	.0191	.0381	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191		.0191
14	.0191	.0191	.0191	.0191	.0191		.0191
15	.0191	.0191	.0191	.0191	.0191		.0191
16	.0191	.0191	.0191	.0191	.0191		.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0381	.0381
20	.0381	.0381	.0381	.0381	.0191	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0270	.0262	.0270	.0262	.0254	.0267	.0265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 201 / Kelod Town

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4191	.4835	.4954	.4763	.3326
2	.381	.4763	.381	.4835	.4572	.4382	.3326
3	.3429	.4382	.381	.4477	.4572	.4382	.3142
4	.3429	.4001	.3429	.4298	.4191	.4191	.2772
5	.3048	.381	.3429	.394	.4191	.381	.2195
6	.2667	.3048	.2858	.3801	.4001	.381	.2033
7	.2477	.2477	.2286	.2033	.1905	.1905	.1848
8	.2667	.2858	.3239	.2218	.2096	.2096	.2012
9	.2667	.3239	.3189	.2286	.2286	.2054	.2096
10	.2667	.3429	.3366	.2477	.2286	.2054	.2286
11	.2667	.381	.3366	.2477	.2286	.2054	.2286
12	.2858	.4191	.3761	.2858	.2286	.1829	.2477
13	.3048	.4191	.3721	.3048	.2286		.2667
14	.381	.4191	.4252	.3239	.2477		.2667
15	.4191	.4191	.394	.3429	.2477		.1905
16	.2477	.3239	.3109	.3429	.2667		.2286
17	.2286	.2858	.2378	.2667	.2477	.2218	.2286
18	.2667	.2477	.2378	.2477	.2286	.2218	.2096
19	.3239	.3048	.2561	.2477	.2667	.2378	.2477
20	.381	.381	.3292	.3429	.3239	.2772	.2858
21	.4191	.4191	.3696	.4954	.4572	.3326	.3048
22	.4572	.4191	.5014	.5335	.4763	.3511	.3239
23	.4763	.4382	.4887	.5335	.4954	.3511	.3239
24	.4001	.4954	.4191	.4887	.4954	.4763	.3326
Max	.4763	.4954	.5014	.5335	.4954	.4763	.3326
Min	.2286	.2477	.2286	.2033	.1905	.1829	.1848
Avg	.3302	.3771	.3506	.3552	.3310	.3101	.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 202 / Jatamkhora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.1991	.2286	.2477	.0572
2	.0572	.0762	.0572	.197	.2286	.2286	.0572
3	.0572	.0572	.0572	.1791	.2096	.2286	.0572
4	.0381	.0572	.0572	.1629	.1905	.1905	.0381
5	.0381	.0572	.0381	.1629	.2096	.1905	.0381
6	.0381	.0381	.0381	.1433	.2286	.1905	.0381
7	.0191	.0381	.0191	.0381	.0381	.0381	.0381
8	.1334	.1905	.1524	.0381	.0381	.0381	.0762
9	.2286	.2477	.2294	.0381	.0381	.0381	.0762
10	.2286	.2477	.213	.0381	.0381	.0381	.0953
11	.2286	.2096	.1966	.0381	.0381	.0381	.1143
12	.2096	.1905	.213	.0572	.0381	.0377	.1143
13	.1715	.1524	.1475	.0572	.0381		.1143
14	.1905	.1715	.1475	.0572	.0381		.0953
15	.1905	.1905	.1638	.0572	.0381		.0762
16	.0381	.0381	.0373	.0572	.0381		.0191
17	.0381	.0381	.0377	.0381	.0381	.0377	.0381
18	.0381	.0381	.0381	.0381	.0381	.0377	.0381
19	.0572	.0572	.0381	.0381	.0381	.0381	.0381
20	.0572	.0572	.0572	.0572	.0572	.0381	.0572
21	.0572	.0572	.1143	.1905	.1715	.0572	.0572
22	.0762	.0572	.2378	.1905	.2286	.0572	.0572
23	.0953	.0572	.0914	.2667	.2477	.0572	.0381
24	.0572	.0762	.0572	.1991	.2286	.2477	.0572
Max	.2286	.2477	.2378	.2667	.2477	.2477	.1143
Min	.0191	.0381	.0191	.0381	.0381	.0377	.0191
Avg	.1000	.1032	.1040	.1058	.1135	.1038	.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 203 / 11 KV Parsodi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2667	.543	.5335	.5144	.2218
2	.2667	.2858	.2667	.5249	.4954	.5144	.2033
3	.2667	.2477	.2286	.5068	.4954	.4954	.1848
4	.2286	.2286	.2286	.4163	.4572	.4763	.1663
5	.2286	.1905	.2286	.3801		.4763	.1463
6	.1715	.1905	.1905	.3439	.4191	.4382	.1294
7	.1334	.1524	.1524	.1294	.1143	.1143	.1109
8	.1143	.3048	.2667	.3801	.1143	.1143	.1629
9	.0953	.4572	.4607	.1143	.1143	.112	.1905
10	.0953	.381	.3898	.1334	.1143	.112	.1905
11	.0953	.3429	.3898	.1334	.1334	.0953	.1905
12		.381	.3721	.1715	.1334	.0934	.1905
13	.381	.4191	.443	.1905	.1334		.1905
14	.3239	.4191	.3544	.1905	.1334		.1905
15	.2477	.381	.4572	.1905	.1524		.1715
16	.2286	.1143	.168	.1905	.1524		.1143
17	.2286	.1143	.1463	.1524	.1524	.1294	.1143
18	.1905	.1143	.1307	.1334	.1334	.1294	.1143
19	.2477	.1905	.1463	.1334	.1715	.1494	.1524
20	.3048	.2477	.2241	.2286	.2286	.1663	.1715
21	.2477	.2477	.2743	.381	.3429	.2033	.1905
22	.2858	.2477	.5068	.5716	.4763	.2218	.2096
23	.3048	.2858	.5249	.5335	.5144	.2218	.2096
24	.2858	.3239	.2858	.5487	.5335	.5144	.2218
Max	.381	.4572	.5249	.5716	.5335	.5144	.2218
Min	.0953	.1143	.1307	.1143	.1143	.0934	.1109
Avg	.2286	.2731	.2960	.3009	.2717	.2646	.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 401 / 33 KV Incomer Kelwad SStn

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.8573	.743	1.262	1.2574	1.2574	.6161
2	.6859	.8573	.6859	1.2071	1.2003	1.2003	.6099
3	.6859	.743	.6859	1.1523	1.1431	1.1431	.5544
4	.6287	.6859	.6287	1.0425	1.086	1.086	.5144
5	.5716	.6287	.6287	.9328	1.086	1.0288	.3881
6	.4572	.5144	.5144	.8779	1.0288	1.0288	.3881
7	.4001	.4572	.4001	.3881	.3429	.3429	.3326
8	.5144	.8002	.743	.3921	.3429	.3429	.439
9	.5716	1.0288	1.0099	.4001	.4001	.3429	.4572
10	.5716	.9717	.9259	.4001	.4001	.3429	.5144
11	.5716	.9145	.823	.4001	.4001		.5144
12	.5144	.9717	.9259	.5144	.4001	.3361	.5716
13	.8573	.9717	.9259	.5716	.4001		.5716
14	.9145	1.0288	.9259	.5716	.4001		.5716
15	.8573	.9717	1.0425	.5716	.4572		.4572
16	.5144	.4572	.5041	.5716	.4572		.3429
17	.5144	.4572	.439	.4572	.4572	.4001	.4001
18	.5144	.4001	.3841	.4001	.4001	.3921	.3429
19	.6287	.5716	.439	.4001	.4572	.4481	.4572
20	.743	.6859	.6036	.6287	.6287	.499	.5144
21	.743	.743	.7682	1.0288	.9717	.6161	.5716
22	.8002	.743	1.262	1.3146	1.2003	.6099	.5716
23	.8573	.8002	1.0974	1.3146	1.2574	.6099	.5716
24	.743	.9145	.743	1.262	1.2574	1.2574	.6099
Max	.9145	1.0288	1.262	1.3146	1.2574	1.2574	.6161
Min	.4001	.4001	.3841	.3881	.3429	.3361	.3326
Avg	.6501	.7573	.7437	.7526	.7264	.6992	.4951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 201 / SAONER URBAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.8954
16		.8192	
23			1.086
24	1.6575	1.6575	1.1622
Max	1.6575	1.6575	1.1622
Min	1.6575	.8192	.8954
Avg	1.6575	1.2384	1.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 202 / SAONER URBAN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004			1.7147		
2	1.6194			1.6004		
3	1.5623			1.448		
4	1.448			1.3336		
5	1.3717			1.2574		
6	1.2955			1.2193		
7	1.2193			1.1812		
8	1.0669			1.1431		
9			.9907	1.0669		.9717
10			1.105	1.105		
11			1.2384			
12			1.3336			
13			1.4289			
14			1.5051			
15			1.5623			
16			1.5242		.9717	
17			1.4289			
18			1.2384			
19			1.3908			
20			1.4861			
21			1.6194			
22			1.7528			
23			1.829			
24		1.9052		1.7528	1.7147	1.4861
Max	1.6194	1.9052	1.829	1.7528	1.7147	1.4861
Min	1.0669	1.9052	.9907	1.0669	.9717	.9717
Avg	1.3979	1.9052	1.4289	1.3475	1.3432	1.2289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 203 / patsaongi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478			.6859		
2	.5906			.6478		
3	.5716			.6097		
4	.4572			.5716		
5	.4191			.5335		
6	.381			.4763		
7	.4001			.4954		
8	.381			.5144		
9			.5525	.5525		.381
10			.6097	.5716		
11			.5906			
12			.5716			
13			.6097			
14			.6668			
15			.6478			
16			.6668		.4191	
17			.6097			
18			.5906			
19			.5906			
20			.5716			
21			.6478			
22			.6859			
23			.7811			
24		.7621		.724	.724	.5525
Max	.6478	.7621	.7811	.724	.724	.5525
Min	.381	.7621	.5525	.4763	.4191	.381
Avg	.4811	.7621	.6262	.5802	.5716	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 204 / telkamthi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			.5906		
2	.5906			.6097		
3	.5335			.5716		
4	.4572			.5906		
5	.4191			.5716		
6	.381			.5716		
7	.4001			.4572		
8	.381			.4001		
9			.4001	.381		.362
10			.4191	.4191		
11			.4572			
12			.4763			
13			.4954			
14			.5525			
15			.5906			
16			.5335		.3239	
17			.4572			
18			.362			
19			.5525			
20			.5716			
21			.6478			
22			.6668			
23			.6287			
24		.5716		.6097	.6097	1.4098
Max	.6859	.5716	.6668	.6097	.6097	1.4098
Min	.381	.5716	.362	.381	.3239	.362
Avg	.4811	.5716	.5208	.5248	.4668	.8859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 205 / nanda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477			.381		
2	.2286			.4001		
3	.1905			.3429		
4	.1905			.3048		
5	.1715			.2667		
6	.1524			.2477		
7	.1524			.1905		
8	.1524			.1715		
9			.1715	.1905		
10			.1905	.1715		
11			.1905			
12			.2096			
13			.2286			
14			.2286			
16			.2286		.1524	
17			.2096			
18			.1905			
19			.2096			
20			.2286			
21			.2667			
22			.2858			
23			.3048			
24		.381		.3429	.2667	.3429
Max	.2477	.381	.3048	.4001	.2667	.3429
Min	.1524	.381	.1715	.1715	.1524	.3429
Avg	.1858	.381	.2245	.2736	.2096	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 206 / kelod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.743		
2				.724		
3	.3429			.7621		
4	.381			.7621		
5	.3048			.724		
6	.2667			.7049		
7	.1715			.4191		
8				.381		
9	.1905		.8383	.3239		.4382
10			.8764	.2858		
11			.8383			
12			.8573			
13			.8383			
14			.8002			
15			.7621			
16			.6859		.4382	
17			.5716			
18			.381			
19			.4572			
20			.5716			
21			.6668			
22			.7811			
23			.8192			
24		.8002		.7621	.7811	.6668
Max	.381	.8002	.8764	.7621	.7811	.6668
Min	.1715	.8002	.381	.2858	.4382	.4382
Avg	.2762	.8002	.7164	.5993	.6097	.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 401 / 33 KV Khapa outgoing

Feeder KV- 33 / INCOMING

DATE	22-JUN-18	23-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435			4.2295		
2	2.6292			3.8866		
3	2.5149			3.5437		
4	2.4006			3.315		
5	2.572			2.9721		
6	2.5149			2.8006		
7				2.6292		
8	2.6863			3.8295		
9			4.0009	3.658		3.0293
10			4.2867	4.2295		
11			4.401			
12			4.4582			
13			4.2867			
14			4.1724			
15			4.0009			
16			3.8866		2.0576	
17			3.658			
18			3.5437			
19			4.3439			
20			4.4582			
21			4.6296			
22			4.5725			
23			4.5725			
24	2.7435	5.144		4.3439	4.5725	3.8866
Max	2.7435	5.144	4.6296	4.3439	4.5725	3.8866
Min	2.4006	5.144	3.5437	2.6292	2.0576	3.0293
Avg	2.6006	5.144	4.2181	3.5852	3.3151	3.4580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365] BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 401 / 33 kv Umri

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	25-JUN-18
HR	Load (MW)
24	3.1436
Max	3.1436
Min	3.1436
Avg	3.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 201 / 11 KV APEX
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024		.4755		.4024	.4024	.4024
2	.3658		.4755		.4024	.439	.4024
3	.3292		.5121		.3658	.4755	.3658
4	.3292		.5121		.3658	.5121	.3658
5	.3658		.4024		.3658	.4024	.3292
6	.3658		.3109		.3658	.3841	.3292
7	.3658		.3292		.3292	.3475	.3292
8	.4024		.3658	.3841	.3292	.3109	.3292
9	.3658		.4024		.3658		.4024
10	.439		.4024	.4908			.4755
11				.4755	.3658		.4031
12				.4024	.3475		.4207
13				.439	.3841		
14		.2378		.439	.439		.439
15		.4207	.4207	.4024	.4755	.3292	
16		.6036	.4755	.4024	.4755	.2561	.4207
17		.5487		.4572	.439	.2926	
18		.5121		.4024	.4024	.3292	.3841
19		.4755		.4024	.4024	.3658	
20		.439		.3658	.3841	.439	
21		.439		.3658	.3841	.3658	
22		.4572		.4024	.3841	.2926	
23		.4572		.4024	.4024	.3292	
24	.2561	.3658	.4755	.3658	.3658	.4024	.3658
Max	.439	.6036	.5121	.4908	.4755	.5121	.4755
Min	.2561	.2378	.3109	.3658	.3292	.2561	.3292
Avg	.3625	.4506	.4277	.4125	.3889	.3709	.3853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 202 / 11 KV BAZARGAON PAPER MILL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.9511	1.0974	1.3169	1.2437	1.2803	.8413
2	1.2071	.9328	1.0608	1.262	1.1706	1.2437	.7682
3	1.1706	.9511	1.0242	1.3169	1.0974	1.1706	.7316
4	1.134	.9511	.9877	1.2803	1.0608	1.0974	.6584
5	1.0974	.8779	1.2437	1.2986	.9877	1.0242	.4024
6	1.1706	1.262	1.39	1.2986	.9511	.9511	1.2437
7	1.0608		1.39	1.2803	.8779	.9511	1.1706
8	.9511		1.3717	1.2071	.2926	.9694	1.0974
9	1.1706	.9511	1.39	1.0242	.2561		.9145
10	1.0242		1.4266	1.0425			.9511
11			1.39	1.0974	.2926	.2926	1.1706
12			1.39	1.134	.3292	.3292	1.3352
13			1.3535	1.134	.3658	.2926	1.307
14		.3109	1.3535	1.2071	.4207	1.39	1.3817
15		.3109	1.3535	1.1706	.8779	1.1706	1.3443
16	.9877	.2743	1.3169	1.2803	.9328	.9145	1.1389
17	.9877	1.0974	1.3169	1.134	1.0242	1.134	1.0829
18	.9877	1.2071	1.3717	.9877	1.0791	1.0608	1.1016
19	.9511	.9511	1.3717	1.2071	1.134	1.0242	1.0242
20	.9511	.2561	1.3535	1.3169	1.0425	.9877	1.0059
21	.9511	.2561		1.2803	1.1706	1.0242	.2743
22	.9511	1.0608		1.3535	1.3169	1.0242	.2743
23		1.0974		1.2803	1.3717	.9877	
24	.3292	.9511	1.134	1.3443	1.2803	1.2803	.9145
Max	1.2071	1.262	1.4266	1.3535	1.3717	1.39	1.3817
Min	.3292	.2561	.9877	.9877	.2561	.2926	.2743
Avg	1.0100	.8139	1.2899	1.2190	.8946	.9818	.9624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 203 / 11 KV UMBARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3772	.439	.4908	.4458	.439	.4115
2	.2401	.3772	.4024	.4908	.4115	.439	.4115
3	.2401	.3772	.4024	.4908	.4115	.4024	.3772
4	.2401	.3429	.3658	.4557	.3772	.4024	.3772
5	.2058	.3429	.3658	.3856	.3772	.3658	.3429
6	.2058		.3841			.3292	.2743
7	.2401						.1715
8	.2401					.3292	.1715
9	.2743						.1372
10	.3086						.0686
11							.2058
12							.2229
13							.2229
14							.2401
15		.3292			.2378	.1715	.2629
16	.3086	.4755	.5658	.5144	.567	.2401	.2572
17	.3086	.439	.5487	.4801	.5487	.3086	.2915
18	.3086	.3841	.4458	.4458	.4938	.3429	.2915
19	.3086	.439		.4458	.4938	.3429	.2915
20	.3601	.5121		1.3169	.4755	.3429	.2915
21	.4115	.5121		.4458	.4755	.3772	.3086
22	.4115	.4938		.4458	.4938	.3772	.3086
23		.4938		.4458	.4938	.5144	
24	.3086	.3772	.4755	.4801	.4458	.4755	.3429
Max	.4115	.5121	.5658	1.3169	.567	.5144	.4115
Min	.2058	.3292	.3658	.3856	.2378	.1715	.0686
Avg	.2886	.4182	.4395	.5239	.4499	.3647	.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 204 / 11KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3429	.4024	.4382	.4115	.439	.3086
2	.2401	.3506	.3658	.4382	.4115	.439	.3086
3	.2401	.3506	.3292	.4382	.3772	.4024	.2743
4	.2401	.3506	.3292	.4908	.3772	.4024	.1029
5	.2058	.2454	.3292	.333	.3429	.4024	.1029
6	.2058		.3292			.3658	.1029
7	.1715						.1029
8	.1715						.1372
9	.2058						
10	.4801						
11							.1372
12							.2454
13							.2401
14							.2572
15		.2926			.2561		
16	.2401	.4024	.5258	.4458	.567		.1372
17	.2454	.3292	.4908	.6516	.5121		.2401
18	.2454	.1829	.4382	.5144	.4572	.2058	.2561
19	.3155	.3658	.4382	.5144	.4572	.3086	.2454
20	.3155	.4024	.4382	.5487	.4572	.3429	.2454
21	.3506	.4024		.5487	.4572	.3429	.2629
22	.3506	.439		.5144	.4572	.3429	.2629
23		.439		.4801	.4755	.3086	
24	.2401	.3506	.4024	.4382	.3772	.4755	.3086
Max	.4801	.439	.5258	.6516	.567	.4755	.3086
Min	.1715	.1829	.3292	.333	.2561	.2058	.1029
Avg	.2613	.3498	.4016	.4853	.4263	.3676	.2139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 205 / 11KV KONDALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3155	.3658	.3506	.3429	.3658	.2743
2	.2401	.3155	.3658	.3506	.3086	.3292	.2743
3	.2401	.3155	.3292	.3506	.3086	.3292	.2743
4	.2401	.3155	.3292	.3506	.2743	.2926	.2743
5	.2401	.3155	.3292	.2629	.2743	.2926	
6	.2058	.2454	.3292	.2629	.631	.2743	
7	.2058		.3109	.631	.5258	.4755	.1715
8	.2058	.3506	.3292	.7712	.4557	.5304	.1715
9	.2058	.3506	.3658	.6859	.4557		.1715
10	.1715	.3506	.4024	.5434			.1715
11		.439	.6135	.5959	.5121	.4557	.1715
12			.6135	.631	.567	.4908	.1753
13		.4755	.6661	.6661	.567	.4908	.1402
14		.4755	.6661	.6661	.5853	.1753	.1372
15		.4024	.6135	.7011	.2561	.1753	.1715
16	.2103	.3658	.3506	.2743	.3475	.1753	.1715
17	.2103	.3658	.333	.2743	.3109	.2103	.1715
18	.2454	.3292	.333	.2743	.2926	.2103	.1928
19	.3155	.3292	.3506	.3429	.2926	.2743	.2229
20	.3155	.3658	.3681	.3772	.3475	.2743	.2279
21	.3086	.3658	.3429	.3772	.3475	.3086	.2279
22	.3086	.3658		.3429	.3475	.3086	.2279
23		.3658		.3429	.3658	.2743	
24	.2743	.3155	.3658	.3506	.3429	.3658	.2743
Max	.3155	.4755	.6661	.7712	.631	.5304	.2743
Min	.1715	.2454	.3109	.2629	.2561	.1753	.1372
Avg	.2437	.3562	.4124	.4490	.3939	.3218	.2046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 206 / 11KV POLO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.0732	.0914	.0914	.1075	.0914	.1075
2	.1075	.0732	.0914	.0914	.1052	.0914	.1075
3	.1075	.0732	.0732	.0914	.1075	.0914	.1075
4	.1075	.0701	.0732	.0732	.1075	.0732	.1075
5	.0716	.0526	.0732	.0732	.1075	.0732	.1075
6	.0716	.0732	.0732	.0914	.1075	.0914	.1075
7	.0716		.0732	.0914	.1075	.0914	.0716
8	.0716	.0366	.0549	.0876	.1075	.0549	.0716
9	.0716	.0366	.0732	.0701	.1075		.1075
10	.0716	.0732	.0732	.0701			.0716
11			.1829	.1075	.1463	.1075	.1463
12			.1829	.1433	.1646	.1433	.1463
13		.2012	.2195	.1791	.2195	.1791	.1463
14		.1829	.2195	.2149	.5121	.1791	.1463
15		.1463	.2195	.2865	.1829	.1791	.0373
16	.0701	.128	.2195	.1433	.1097	.1433	.0732
17	.1052	.1463	.2195	.1433	.1463	.1075	.0914
18	.1029	.1829	.2103	.1791	.2012	.1075	.0914
19	.1097	.1097	.2195	.1433	.1097	.1075	.0914
20	.0351	.0732	.0914	.1075	.0914	.1075	.0914
21	.0366	.0732		.1075	.0914	.1075	.0914
22	.0366	.0914		.0716	.0914		.0914
23		.0914		.0716	.0914	.0716	
24	.0716	.0732	.0914	.0914	.1075	.0914	.0716
Max	.1097	.2012	.2195	.2865	.5121	.1791	.1463
Min	.0351	.0366	.0549	.0701	.0914	.0549	.0373
Avg	.0793	.0982	.1346	.1175	.1405	.1091	.0993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 208 / Adegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6516	.6584	.6516	.6516	.6219	.5144
2	.5487	.6516	.6219	.6516	.6173	.5853	.5144
3	.5144	.6516	.5487	.6516	.6173	.5487	.4801
4	.4801	.6516	.5121	.6173	.583	.5121	.4801
5	.4458	.5487	.3292	.4908	.583	.3292	.4801
6	.4458	.4572	.1463	.4031	.2374	.2743	.1715
7	.2035		.1829	.2572	.2035	.2561	.2401
8	.2035	.2058	.2012	.2629	.2035	.2012	.2743
9	.2401	.2229	.2012	.2454	.2713		.2401
10	.1696	.2279	.2378	.2629			.0701
11		.1829	.2229	.3052	.2561	.1696	.0686
12		.1646	.2401	.3052	.2195	.2035	.0686
13		.1646	.1886	.3052	.2195	.1696	.1341
14		.1646	.1886	.3052	.2378	.1696	.1715
15		.2195	.2058	.3052	.3109	.1696	.1029
16	.3086	.4572	.4115	.4207	.3475	.1696	.1029
17	.3086	.3658	.407	.3086	.2743	.2058	.1029
18	.3772	.3109	.4115	.2743	.2561	.2401	.1715
19	.5144	.5121	.5365	.3772	.4024	.3429	.2012
20	.6516	.6767	.6203	.6173	.6036	.5144	.2058
21	.6859	.7316		.6859	.6584		.2012
22	.6859	.7865		.7202	.7133	.5487	.2012
23		.7499		.6859	.7316	.5144	
24	.5487	.6516	.7316	.6859	.6173	.6584	.5144
Max	.6859	.7865	.7316	.7202	.7316	.6584	.5144
Min	.1696	.1646	.1463	.2454	.2035	.1696	.0686
Avg	.4397	.4525	.3716	.4499	.4268	.3526	.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 209 / 11 KV ECONOMIC EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2641	.1463	.2263	.2195	.1829	.1829
2	.2195	.2263	.1463	.2263	.1829	.1829	.1829
3	.2195	.2195	.1097	.2195	.1829	.1463	.1829
4	.1829	.2195	.1097	.1829	.1829	.1463	.1829
5	.1829	.2263	.1097	.1867	.1829	.1463	.1829
6	.1646	.3018	.1097	.1463	.2195	.1463	.1829
7	.2378		.1097	.5093	.2926	.1463	.2743
8	.2926		.1463	.5093	.2926	.1829	.2926
9	.3292		.1829	.5093	.3109		.3292
10	.2195		.2195	.6348			.2926
11	.7167		.4338	.4024	.3292	.2195	.695
12	.7167		.4338	.4024	.3658	.2926	.695
13	.7167			.5121	.4024	.4755	.6979
14	.8676	.1097	.3395	.5121	.439	.4755	.6224
15	.8488	.1463	.3395	.4755	.4755	.439	.6348
16	.7356	.2195	.3395	.439	.5121	.2926	.6348
17	.7167	.2561	.3395	.4024	.5487	.4024	.6722
18	.5658	.2561	.3206	.4024	.5853	.4024	.6722
19	.4527	.2561	.3206	.2926	.4024	.2743	.7545
20	.5847	.2561	.2829	.2926	.3292	.2743	.4715
21	.415	.2195		.3292	.2926	.2926	.4338
22	.3772	.2195		.3292	.2561	.2926	.415
23	.3206	.1829		.2561	.2195	.2561	
24	.1097	.2641	.1829	.2263	.2378	.1829	
Max	.8676	.3018	.4338	.6348	.5853	.4755	.7545
Min	.1097	.1097	.1097	.1463	.1829	.1463	.1829
Avg	.4339	.2261	.2361	.3594	.3244	.2660	.4402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 211 / 11 KV ORIENT EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0732	.1463	.0876	.1075	.1829	.0716
2	.0716	.0732	.1463	.0914	.0716	.1829	.0716
3	.0716	.0732	.1097	.0914	.0716	.1463	.0716
4	.0716	.0732	.1097	.0914	.0716	.1463	.0716
5	.0716	.0732	.1097	.0914	.0716	.1463	.0716
6	.0716	.0732	.1097	.0914	.0716	.1463	.0716
7	.0716		.1463	.0914	.0716	.1097	.0358
8	.0716		.1463	.0914	.1075	.1097	.0358
9	.1075		.1829	.1052	.0716		.1075
10	.1075		.1829	.0914			.1075
11			.0732	.1075	.1097	.1075	.1097
12			.0914	.1075	.1097	.1075	.1097
13			.0732	.1075	.1463	.1075	.1097
14		.1097	.0732	.1075	.1829	.0716	.0732
15		.1463	.1097	.1075	.2195	.0716	.0914
16	.1097	.1829	.1097	.1075	.2561	.0716	.0914
17	.1097	.2195	.1097	.1075	.2926	.0716	.0732
18	.1097	.2195	.1097	.1075	.2561	.0716	.0732
19	.0732	.2195	.1097	.1075	.2561	.0716	.056
20	.0732	.2195	.1097	.1075	.2195	.0716	.0366
21	.0732	.1829		.1075	.2195		.0351
22	.0701	.1829		.1075	.1829		.0366
23		.1463		.1075	.1829	.0716	
24	.0716	.0701	.1463	.0934	.1075	.1829	.0716
Max	.1097	.2195	.1829	.1075	.2926	.1829	.1097
Min	.0701	.0701	.0732	.0876	.0716	.0716	.0351
Avg	.0821	.1375	.1193	.1006	.1503	.1124	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 401 / 33 kv kalmeshwar to baz
income Feeder KV- 33 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9963	5.3772	5.5453	5.2652	5.5213	5.7716	4.5748
2	4.5222	5.3212	4.9794	5.2652	5.2584	5.5453	4.4696
3	4.417	5.3212	4.8097	5.1578	5.048	5.2058	4.2593
4	4.2593	5.2652	4.5268	5.1029	4.8377	5.036	4.0489
5	4.2067	4.8731	4.4702	4.537	4.7325	4.4702	3.3653
6	3.9963	4.3896	4.4136	3.6408	3.9963	4.5833	3.8386
7	4.1541		4.0175	4.9291	4.1015	3.8477	3.9963
8	4.2067		4.3004	5.0412	3.3653	3.9609	3.9963
9	4.7325		4.357	5.0412	4.0489		3.9963
10	4.9429		4.4136	5.2092			3.8912
11			4.7611	5.2058	4.0741		4.9291
12			4.9291	5.1006	4.1872		4.9851
13			4.8171	5.4687	4.357		4.201
14		2.6595	4.7051	5.5213	4.9794		4.313
15		4.1872	4.3347	5.7316	5.5453		4.7051
16	5.4332	5.1492	5.5453	6.31	6.0357	2.9973	4.6491
17	5.2092	5.4321	5.6584	6.0997	6.5072	3.5757	4.6491
18	5.0972	5.4887	5.4321	5.3109	6.4506	4.1015	4.7611
19	5.2652	5.5453	5.6573	5.7842	6.0545	4.3118	4.9291
20	5.8814	5.0926	5.4893	6.2049	5.998	4.5748	4.481
21	5.6573	5.0926		6.5204	6.0545	4.8903	3.7529
22	5.6573	6.1111		6.31	6.4506	5.048	3.7529
23	5.6013	5.8848		5.5739	6.2809	4.7851	
24	3.9438	5.3772	5.8848	5.2126	5.4687	5.8848	4.6799
Max	5.8814	6.1111	5.8848	6.5204	6.5072	5.8848	4.9851
Min	3.9438	2.6595	4.0175	3.6408	3.3653	2.9973	3.3653
Avg	4.7989	5.0922	4.9070	5.3977	5.1893	4.6229	4.3141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 402 / 33 kv kondhali to baz
incomer Feeder KV- 33 /
INCOMING

DATE	23-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)
11		2.3137
12		2.8921
13	1.6975	3.6283
14		3.6283
15	1.6975	3.9963
Max	1.6975	3.9963
Min	1.6975	2.3137
Avg	1.6975	3.2917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 405 / 33 KV PIX

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-JUN-18	24-JUN-18	26-JUN-18	27-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6584		.6584
2		.439		.5487
3		.439		.439
4		.3292		.439
5		.3292		.3292
6		.439		.6584
7		.5487		.5487
8		.6584		.6584
9		.439		
10		.3292		
11			.6584	
12			.7682	
13			.7682	
14	.7682		.8779	
15	.7682		.8779	
16	.8779		.7682	
17	.7682		.9877	
18	.8779		1.0974	
19	.7682		.9877	
20	.7682		.8779	
21	.7682		.7682	
22	.7682		.9877	
23	.6584		.7682	
24		.6584		.6584
Max	.8779	.6584	1.0974	.6584
Min	.6584	.3292	.6584	.3292
Avg	.7792	.4789	.8610	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 201 / CHIKNA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2853	.2681	.2681	.3035	.2856	.2856	.2142
2	.2853	.2502	.2681	.2853	.2856	.2678	.2142
3	.2853	.2502	.2502	.2853	.2856	.2678	.1964
4	.2675	.2323	.2505	.2499	.2856	.2499	.1964
5	.2497	.2144	.2683	.2318	.2678	.2499	.1785
6	.214	.1966	.2326	.2142	.2499	.1964	.1428
7	.214	.2144	.2862	.2142	.2856	.1785	.1785
8	.214	.3038	.2683	.2321	.3392	.2142	
9	.2318	.3038	.3399	.2499	.3035	.1785	
10	.214	.3217	.5004	.3035	.411	.4106	
11	.2497	.3395	.4646	.4106	.3038	.3035	.0179
12	.214	.4646	.3932	.2856	.3217	.357	.0179
13	.2318	.428	.3395	.3035	.4646		
14	.2318	.3038	.3753	.2856	.3574	.0179	
15	.214	.3038	.3932	.2678	.3038		.0179
16	.1962	.3932	.3753	.4284	.3038	.1428	.2142
17	.1962	.3574	.2681	.4284	.3753	.1607	.2499
18	.1783	.3395	.3395	.2678	.2859	.1071	.1785
19	.1962	.2859	.2323	.2321	.3285	.2142	.1964
20	.2675	.2859	.2681	.2856	.3103	.2142	.2142
21	.2853	.3038	.2859	.2678	.292	.2142	
22	.2675	.3217	.3038	.3035	.3103	.2142	.0179
23	.2675	.3217	.2859	.3035	.3103		.0357
24	.2853	.2675	.2859	.3038	.3035	.3103	.2142
Max	.2853	.4646	.5004	.4284	.4646	.4106	.2499
Min	.1783	.1966	.2323	.2142	.2499	.0179	.0179
Avg	.2393	.3030	.3143	.2893	.3154	.2264	.1498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 202 / Kirnapur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0873	.1047	.0873	.1047	.0873	.0873	.0686
2	.0873	.1047	.0873	.1047	.0873	.0873	.0686
3	.0873	.0873	.0873	.1047	.0873	.0873	.0686
4	.0873	.0873	.0873	.0873	.0873	.0873	.0686
5	.0873	.0698	.0873	.0873	.0698	.0698	.0686
6	.0698	.0698	.0873	.0698	.0698	.0524	.0524
7	.0698	.0873	.0873	.0873	.0873	.0524	.0698
8	.0873	.1047	.0698	.1222	.0873	.0349	.0698
9	.0698	.0873	.0698	.0873	.0873	.0524	.0698
10	.0873	.0698	.1047	.0873	.0873	.0525	.0524
11	.0698	.0873	.0873	.0873	.0873	.0368	.0698
12	.0873	.0873	.1047	.0873	.0873	.0368	.0524
13	.0873	.1047	.1047	.1047	.0873	.0736	.0524
14	.0524	.0873	.0524	.1047	.0873	.0736	.0524
15	.0698	.0873	.1222	.0873	.0524		.0524
16	.0873	.0873	.1047	.1047	.0524	.0698	.0349
17	.0857	.0873	.0873	.0873	.0349	.0524	.0349
18	.0698	.0873	.0698	.0873	.0524	.0524	.0349
19	.0857	.0873	.0873	.0698	.0698		.0524
20	.0873	.0873	.0873	.0873	.0873	.0698	.0698
21	.0873	.1047	.0873	.0873	.1047	.0698	.0698
22	.0873	.1047	.1047	.1047	.0873	.0686	.0698
23	.1047	.1047	.1047	.1047	.0873		.0698
24	.0873	.1047	.0873	.1047	.0873	.0873	.0698
Max	.1047	.1047	.1222	.1222	.1047	.0873	.0698
Min	.0524	.0698	.0524	.0698	.0349	.0349	.0349
Avg	.0821	.0909	.0895	.0938	.0793	.0645	.0601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 203 / Adyali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3643	.4007	.4189	.4007	.4189		
2	.4007	.3825	.4189	.3821	.4189	.4371	.1819
3	.4007	.3825	.4189	.3639	.3825	.4007	.3093
4	.4007	.3643	.4189	.3275	.3825	.4007	.3096
5	.4007	.3278	.4189	.2911	.3643	.4007	.2914
6	.3278	.3278	.3289	.2729	.3096	.3461	.255
7	.2732	.3461	.3278	.2547	.3096	.3461	.2368
8	.2914	.3278	.3278	.3096	.3278	.3461	.2368
9	.3643	.3639	.3825	.2186	.4371	.3278	.3096
10	.3825	.3825	.3643	.4007	.4553	.3639	.3825
11	.3825	.4736	.4371	.4371	.5646	.3643	.3643
12	.3278	.4371	.4367	.4736	.4736		.3643
13	.3825	.4371	.4371	.4736	.4918		.1639
14	.4007	.4371	.4371	.51	.4189		
15	.4553	.4371	.4189	.4553	.4371		.2732
16	.4371	.4189	.3825	.4371	.3825	.0182	.3461
17	.3639	.4189	.3825	.4007	.4007	.0182	.1821
18	.4007	.4007	.3643	.4007	.3825	.0182	.2914
19	.4189	.3643	.3825	.3461	.4007	.0182	.3461
20	.4189	.4736	.3643	.4371	.3825	.0182	.2732
21	.4371	.4007	.3825	.4007	.4189	.0182	.2914
22	.4736	.4189	.3825	.4189	.4553	.3643	.2732
23	.4371	.4553	.3825	.4371	.4736		.3096
24		.4189	.4371	.4007	.4189	.4371	.3278
Max	.4736	.4736	.4371	.51	.5646	.4371	.3825
Min	.2732	.3278	.3278	.2186	.3096	.0182	.1639
Avg	.3888	.3999	.3939	.3854	.4128	.2580	.2873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 204 / Pipla

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9461	.9097	.9643	1.0189	1.02	.8743	.6732
2	.9461	.8733	.9097	1.0189	1.0018	.8378	.6732
3	.9097	.837	.8733	.9825	1.0018	.8014	.655
4	.8551	.8006	.8733	.9471	.856	.765	.6368
5	.8006	.746	.8551	.8196	.7832	.7468	.6368
6	.746	.746	.7278	.765	.7468	.6921	.6193
7	.6368	.6186	.6914	.6011	.6011	.6193	.5282
8	.5822	.564	.6004	.5464	.5828	.5464	.5464
9	.5822	.564	.6004	.5464	.5646	.5646	.4918
10	.564	.6004	.655	.6011	.6011	.5464	.4736
11	.5458	.6732	.6732	.6375	.6011	.51	.4736
12	.564	.6368	.7278	.6011	.6193	.4918	.4918
13	.564	.7278	.7096	.6557	.6193	.4736	
14	.5822	.6732	.7642	.6557	.6193	.4553	
15	.6368	.7278	.8188	.7103	.5646		.4371
16	.6004	.7278	.8188	.6739	.5828	.4553	.5464
17	.655	.7642	.6914	.7285	.6011	.4553	.4736
18	.6186	.655	.746	.6739	.6193	.4553	.5282
19	.746	.7096	.7278	.6921	.6193		.6283
20	.8006	.8188	.837	.8014	.7285	.6375	.5759
21	.837	.8733	.8733	.8014	.7103	.6739	.5828
22	.9461	.9279	.9461	.9289	.8378	.6921	.6011
23	.9461	1.0553	1.0189	1.0382	.8743		.5464
24	.9643	.9279	1.0007	1.0189	1.0382	.9107	.6921
Max	.9643	1.0553	1.0189	1.0382	1.0382	.9107	.6921
Min	.5458	.564	.6004	.5464	.5646	.4553	.4371
Avg	.7323	.7566	.7960	.7694	.7248	.6288	.5687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 201 / Saibaba nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3361	.4294	.4108	.4294	.3734	.2801
2	.3734	.2915	.3734	.3734	.4294	.3734	.2614
3	.3734	.2987	.3734	.3921	.4108	.3361	.2614
4	.3361	.2987	.3921	.3734	.3921	.3174	.2241
5	.3361	.2801	.3361	.3361	.3734	.2987	.2241
6	.2987	.2614	.3174	.2987	.2987	.2987	.2054
7	.2801	.2614	.2801	.2801	.2987	.2614	.1867
8	.2614	.2614	.2801	.2614	.2614	.2427	.2241
9	.2614	.2614	.2614	.2427	.2427	.2241	.1867
10	.2241	.2614	.2801	.2427	.2241	.2241	.2054
11	.2427	.2427	.2801	.2801	.2241	.1867	.168
12	.2427	.2427	.2614	.2614	.2614	.2054	.2241
13	.2614	.2987	.2987	.2801	.2801	.1867	.1867
14	.2614	.2987	.3361	.3361	.2614	.1867	.1867
15	.2427	.3361	.3174	.3361	.2427	.1867	.1867
16	.2614	.3174	.3361	.3361	.2614	.168	.168
17	.2614	.2987	.3361	.3174	.2801	.168	.1867
18	.2427	.2801	.3174	.2987	.2614	.1867	.2054
19	.2572	.3174	.3174	.3361	.2801	.2054	.2241
20	.2987	.3547	.3734	.3547	.3361	.2801	.2241
21	.3361	.4108	.3921	.3734	.3361	.2801	.2054
22	.3734	.4108	.4108	.4108	.3547	.2801	.2054
23	.3921	.4294	.4294	.4294	.3734	.2801	.2241
24	.4294	.3734	.4481	.4294	.4481	.3734	.2801
Max	.4294	.4294	.4481	.4294	.4481	.3734	.2801
Min	.2241	.2427	.2614	.2427	.2241	.168	.168
Avg	.3025	.3093	.3408	.3330	.3151	.2552	.2140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 202 / NAVNATH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7468	.8402	.8215	.8029	.8029	.5653
2	.7468	.7095	.7842	.7842	.7842	.7842	.5601
3	.7468	.6722	.7468	.7468	.7468	.7468	.5601
4	.6722	.583	.7468	.7095	.7468	.7095	.5228
5	.6722	.5975	.7095	.6722	.7095	.6722	.5228
6	.6348	.5601	.6535	.6348	.5975	.6161	.5041
7	.5601	.5228	.5415	.5601	.5228	.5228	.4481
8	.5228	.4668	.5041	.4854	.4854	.4668	.4294
9	.4854	.4854	.4854	.4668	.4668	.4481	.4294
10	.4854	.4854	.5041	.4481	.4668	.4294	.3921
11	.4668	.4481	.5415	.4854	.4108	.4108	.3734
12	.4458	.5228	.5415	.5228	.4481	.3734	.3734
13	.4668	.5415	.5975	.5601	.4668	.3734	.3734
14	.4481	.5975	.6535	.6161	.4854	.3734	.3734
15	.4854	.6161	.6348	.5975	.4854	.3361	.3921
16	.4668	.5975	.6535	.6161	.4668	.3734	.3734
17	.4854	.5601	.5975	.5228	.4481	.3547	.3258
18	.4668	.5228	.6161	.4854	.4854	.3547	.3734
19	.5228	.5415	.6348	.5601	.5228	.4294	.4108
20	.5601	.6722	.7095	.6722	.6348	.5228	.4668
21	.6348	.7468	.7468	.7282	.2614	.5601	.4854
22	.7468	.8215	.7655	.8402	.7468	.5788	.4854
23	.8029	.8775	.8029	.8402	.8029	.5975	.5041
24	.8215	.7842		.8589	.8402	.8029	.5788
Max	.8215	.8775	.8402	.8589	.8402	.8029	.5788
Min	.4458	.4481	.4854	.4481	.2614	.3361	.3258
Avg	.5888	.6117	.6527	.6348	.5765	.5267	.4510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 203 / 11 KV BAHADURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5041	.5788	.5601	.5415	.5415	.4108
2	.5228	.4458	.5228	.5415	.5415	.5601	.4108
3	.4854	.4668	.5228	.5228	.5228	.5601	.4108
4	.4854	.4481	.4854	.5228	.5228	.5415	.4108
5	.5041	.4108	.5041	.4854	.5415	.5601	.4108
6	.4668	.3921	.4668	.4481	.4294	.4294	.3734
7	.4108	.3734	.4294	.3921	.4108	.3734	.3361
8	.3921	.3547	.3734	.3921	.3734	.3547	.3174
9	.3921	.3547	.3921	.3361	.3734	.3361	.3174
10	.3547	.3734	.3921	.3734	.3734	.3174	.2987
11	.3361	.3921	.4294	.3547	.3361	.2987	.3174
12	.3174	.3734	.4481	.2427	.3734		.2614
13	.2241	.4294	.4481	.2614	.3734		.2614
14	.2054	.3361	.4481	.4481	.3547		.2614
15	.1867	.3921	.4294	.4294	.3361	.1867	.2614
16	.1867	.3921	.4481	.4294	.2987	.168	.2427
17	.168	.3734	.4481	.3921	.3361	.2987	.2614
18	.3547	.3734	.4108	.3174	.3361	.3174	.2987
19	.4294	.4481	.3734	.3921	.3174	.3174	.3361
20	.4668	.5041	.5041	.5041	.4481	.3921	.3547
21	.5228	.5601	.5228	.5415	.4854	.4108	.3361
22	.5601	.5975	.5601	.5975	.5228	.4294	.3547
23	.5601	.6161	.5975	.5975	.5601	.4294	.3547
24	.5415	.5228	.6161		.5975	.5415	.3921
Max	.5601	.6161	.6161	.5975	.5975	.5601	.4108
Min	.168	.3361	.3734	.2427	.2987	.168	.2427
Avg	.3999	.4348	.4730	.4384	.4294	.3983	.3330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 204 / Dhangawali SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2801	.3174	.2987	.3174	.2801	.2054
2	.3174	.2614	.2987	.2801	.3174	.2801	.2054
3	.3174	.2614	.2987	.2614	.2987	.2614	.2054
4	.2614	.2427	.2801	.2614	.2987	.2614	.1867
5	.2427	.2241	.2614	.2427	.2801	.2427	.1867
6	.2241	.2241	.2427	.2241	.2427	.2241	.1867
7	.1867	.2054	.2427	.2054	.2241	.2054	.1663
8	.2054	.2054	.2241	.2054	.2054	.2054	.1867
9	.2054	.2241	.1867	.1867	.2241	.1867	.1663
10	.1867	.2427	.2054	.1867	.2054	.1867	.1867
11	.2054	.2427	.2054	.2054	.1867	.1494	.1867
12	.2241	.2241	.2241	.2241	.1867	.1663	.168
13	.2054	.2427	.2427	.2427	.2427	.1494	.168
14	.2054	.2614	.2427	.2241	.2054	.1663	.1867
15	.1867	.2614	.2241	.2427	.1867	.1494	.1543
16	.2054	.2427	.2427	.2427	.2054	.1494	.1372
17	.2054	.2241	.2241	.2614	.2054	.1494	.1307
18	.2241	.2241	.2427	.2241	.1867	.1478	.1494
19	.2427	.2427	.2427	.2241	.2054	.1867	.168
20	.2614	.2801	.2801	.2614	.2427	.2054	.1867
21	.2801	.2801	.2987	.2987	.2614	.2054	.1867
22	.2987	.3174	.2987	.3174	.2801	.2241	.1543
23	.2987	.3174	.3174	.3361	.2801	.2241	.1867
24	.3361	.2801	.3361	.3174	.3361	.2801	.2054
Max	.3361	.3174	.3361	.3361	.3361	.2801	.2054
Min	.1867	.2054	.1867	.1867	.1867	.1478	.1307
Avg	.2443	.2505	.2575	.2490	.2427	.2036	.1771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 201 / 11 kv NIT industrial 1

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0019		.1905	.2096	.2096	
2		.0019		.1905	.2096	.2096	
3		.0019		.1905	.2096	.2096	
4		.0019		.2096	.2096	.2096	
5		.0019		.1905	.2096	.2096	
6		.0019		.2096	.2096	.2096	
7		.0019		.2096	.2096	.2096	
8		.0019		.2096	.2096	.2286	
9		.0019		.2477	.2096	.2286	
10			.0019	.2286	.2058	.2058	.0019
11	.0019		.0019	.2477	.2058	.2058	.0019
12	.0019		.0019	.2477	.2058	.2058	.0019
13	.0019		.1715		.2058	.2058	.0019
14	.0019		.1715		.2058	.0019	.0019
15	.0019		.1715		.2058	.0019	.0019
16	.0019		.1715		.1886	.0019	.0019
17	.0019		.1715		.1886	.0019	.0019
18	.0019		.2096		.2096	.0019	
19	.0019		.2096	.2096	.2096		
20	.0019		.2096	.2096	.2096		
21	.0019		.2096	.2096	.2096		
22	.0019		.2096	.2096	.2096		
23	.0019		.2096	.2096	.2096		
24		.0171		.1905	.2096	.2096	
Max	.0019	.0171	.2096	.2477	.2096	.2286	.0019
Min	.0019	.0019	.0019	.1905	.1886	.0019	.0019
Avg	.0019	.0034	.1515	.2117	.2069	.1561	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 202 / 11 KV MAHURZARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.3048	.2477	.2641	.2477	.2075
2		.2401	.2858	.2477	.2667	.2286	.2075
3		.2058	.2858	.2286	.2641	.2286	.2075
4		.2572	.2667	.2667	.2641	.2096	.2075
5		.1886	.2667	.2667	.2452	.2096	.2075
6		.1715	.2286	.2477	.2452	.1905	.2075
7		.1886	.1905	.2096	.2263	.1905	.2075
8		.1715	.1905	.2096	.3018	.2477	.1886
9	.2263	.2058	.2286	.2096	.3395	.2286	.1886
10	.3018	.2477	.2743	.4527	.2743	.2058	
11	.2058	.3429	.2058	.2829	.3086	.2058	.1029
12	.2743	.3429	.2058	.3772	.2743	.1372	.2229
13	.2572	.3048	.2743		.2915	.1372	.1715
14	.2743	.2667	.2229		.2401	.1372	.1886
15	.3258	.2096	.2229		.2743	.1372	.1029
16	.2743	.3429	.1886		.1886	.1372	.1543
17	.2743	.3429	.2915		.1543	.2058	.1715
18	.1715	.3239	.3048		.2096	.2229	.1715
19	.1886	.3239	.2477	.1886	.1905	.3206	.2096
20	.2058	.3048	.3048	.2641	.2858	.2641	.2667
21	.2229	.2667	.2477	.2641	.2477	.2263	.2667
22	.2572	.3048	.2858	.2829	.2667	.2075	.2286
23	.2572	.2667	.2667	.2667	.3048	.2075	.2477
24		.2229	.3048	.2667	.2667	.2477	.2075
Max	.3258	.3429	.3048	.4527	.3395	.3206	.2667
Min	.1715	.1715	.1886	.1886	.1543	.1372	.1029
Avg	.2478	.2625	.2540	.2655	.2581	.2076	.1975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 203 / 11 kv Bodhala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.463	.5716	.6478	.5959	.5716	.4382
2		.4458	.5716	.6097	.5784	.5335	.4382
3		.4115	.5335	.6097	.5784	.5335	.3506
4		.4115	.5335	.5716	.5784	.5144	.3506
5		.3772	.5144	.5716	.5959		.3506
6		.3601	.4954	.5525	.5959		.298
7		.3772	.4763	.6478	.5959		.3155
8		.3601	.381	.743	.631	.4001	.3506
9	.4031	.463	.4763	.743	.631	.6097	.333
10	.381	.4763	.4801	.6836	.5487	.3429	.3429
11	.3258	.4954	.5316	.7011	.5144	.1029	.2572
12	.2572	.5144	.4287	.6661	.4801	.1372	.2572
13	.3429	.5335	.4801		.5144	.2229	.2401
14	.4287	.5525	.5144		.5316	.2915	.2229
15	.3601	.5716	.4973		.4115	.2058	.2401
16	.4115	.5716	.4458		.4973	.2229	.2572
17	.4287	.4572	.4973		.1372	.2572	.2401
18	.2229	.4382	.4954		.2477	.2401	.3239
19	.4115	.4572	.4763	.6135	.3048	.4382	.2667
20	.4287	.5525	.5906	.7011	.5525	.4207	.3048
21	.4973	.5906	.6478	.7011	.5525	.3506	.3429
22	.4973	.6287	.6859	.7011	.5716	.5906	.3429
23	.4973	.6097	.6668	.5959	.5716	.4382	.362
24		.4801	.6097		.5959	.5716	.4715
Max	.4973	.6287	.6859	.743	.631	.6097	.4715
Min	.2229	.3601	.381	.5525	.1372	.1029	.2229
Avg	.3929	.4833	.5251	.6506	.5172	.3808	.3207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 204 / 11 kv fetari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3944	.4572	.4763	.4938	.4001	.3658
2		.3772	.4572	.4572	.4207	.381	.3658
3		.3601	.4191	.4001	.4207	.3429	.3292
4		.3772	.4191	.381	.3658	.3048	.3292
5		.3429	.4001	.381	.3658	.3048	.3292
6		.2915	.4191	.381	.3658	.2858	.3292
7		.3086	.4001	.381	.4572	.2858	.2926
8		.2915	.4001	.4001	.3658	.2667	.3292
9	1.0974	.3601	.4572	.4382	.3658	.3048	.3841
10	.4024	.3239	.3772	.5121	.3258	.2229	.3086
11	.3258	.4001	.3601	.4572	.1029	.1886	.2743
12	.3429	.381	.4458	.3475	.2915	.2229	.2572
13	.4287	.4191	.3944		.2915	.2058	.2915
14		.4191	.3772		.3429	.1886	.3086
15	.3772	.4382	.3944		.3601	.1715	.2743
16	.3429	.4572	.3944		.2915	.2229	.2915
17	.3601	.5144	.3944		.2915	.2572	.2229
18	.3601	.4763	.381		.3048	.2229	.3048
19	.3944	.4382	.4001	.4755	.3429	.3658	.3048
20	.4115	.4382	.4572	.5121	.4191	.3841	.3048
21	.4115	.4763	.4191	.4572	.4001	.3658	.2667
22	.4115	.4763	.4572	.4572	.4001	.3841	.2858
23	.4458	.4763	.4763	.4572	.4001	.3658	.2477
24		.4287	.4763	.4763	.4207	.4001	.3658
Max	1.0974	.5144	.4763	.5121	.4938	.4001	.3841
Min	.3258	.2915	.3601	.3475	.1029	.1715	.2229
Avg	.4366	.4028	.4181	.4360	.3586	.2936	.3068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 205 / 11 kv industrial 2 jain

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.4001	.2286	.2477	.2286	.4572
2		.4115	.4001	.2286	.2477	.2286	.4572
3		.3944	.381	.2286	.2477	.2286	.4572
4		.3601	.3429	.2286	.2477	.2286	.4572
5		.3429	.3429	.2286	.2286	.2286	.4572
6		.3086	.381	.2286	.2286	.2286	.4572
7		.3258	.4001	.2286	.2667	.2286	.4191
8		.3086	.4001	.2286	.2667	.2286	.4763
9	.381	.3258	.362	.2096	.2477	.2286	.4572
10	.4763	.4191	.3086	.3048	.1886	.2058	.3772
11	.4287	.4763	.2572	.3048	.2743	.2572	.4458
12	.5316	.4572	.1715	.381	.2572	.2743	.4115
13	.4973	.4382	.1543		.2743	.2743	.4287
14	.463	.4382	.1372		.3086	.2401	.4458
15	.4287	.4763	.1543		.3086	.2229	.4458
16	.3258	.4763	.1543		.2401	.3258	.4115
17	.4115	.4572	.1543		.2572	.2915	.3944
18	.3772	.4001	.2096		.2286	.3258	
19	.3429	.4191	.2286	.2667	.2286	.4572	.381
20	.3429	.4001	.2286	.2858	.2286	.4572	.381
21	.3258	.4001	.2477	.2667	.2286	.4382	.381
22	.3429	.4001	.2286	.2858	.2286	.4382	.362
23	.3429	.4001	.2477	.2477		.4382	.362
24		.3601	.4001		.2477	.2286	.4382
Max	.5316	.4763	.4001	.381	.3086	.4572	.4763
Min	.3258	.3086	.1372	.2096	.1886	.2058	.362
Avg	.4012	.3989	.2789	.2577	.2491	.2889	.4244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 206 / 11 KV BORGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	26-JUN-18
HR	Load (MW)
23	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 207 / 11 kv station transformer

Feeder KV- 11 / OUTGOING

DATE	22-JUN-18	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0191	.0191	.0191	.0191	.0191
2		.0171	.0191	.0191	.0191	.0191	.0191
3		.0171	.0191			.0191	.0191
4		.0171	.0191	.0191	.0191	.0191	.0191
5		.0171	.0191	.0191	.0191	.0191	.0191
6		.0171	.0191	.0191	.0191	.0191	.0191
7		.0171	.0191	.0191	.0191	.0191	.0191
8		.0171	.0191	.0191	.0191	.0191	.0191
9	.0191	.0171	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0171	.0191	.0171	.0171	.0171
11	.0171	.0191	.0171	.0191	.0171	.0171	.0171
12	.0171	.0191	.0171	.0191	.0171	.0171	.0171
13	.0171	.0191	.0171		.0171	.0171	.0171
14	.0171	.0191	.0171		.0171	.0171	.0171
15	.0171	.0191	.0171		.0171	.0171	.0171
16	.0171	.0191	.0171		.0171	.0171	.0171
17	.0171	.0191	.0171		.0171	.0171	.0171
18	.0171	.0191	.0191		.0191	.0171	.0191
19	.0171	.0191	.0191	.0191	.0191	.0191	.0191
20	.0171	.0191	.0191	.0191	.0191	.0191	.0191
21	.0171	.0191	.0191	.0191	.0191	.0191	.0191
22	.0171	.0191	.0191	.0191	.0191	.0191	.0191
23	.0171	.0191	.0191	.0191	.0191	.0191	.0191
24		.0171	.0191		.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0171	.0171	.0191	.0171	.0171	.0171
Avg	.0174	.0183	.0184	.0191	.0184	.0184	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 213 / 11 kV Hudkeshwar Urban 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	27-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.5242	1.7147	1.6194	1.5242	1.3336	1.5242
Max	1.5242	1.7147	1.6194	1.5242	1.3336	1.5242
Min	1.5242	1.7147	1.6194	1.5242	1.3336	1.5242
Avg	1.5242	1.7147	1.6194	1.5242	1.3336	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-18 and 28-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 401 / 33 KV BESA LUXORA KHAPARI

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	23-JUN-18	24-JUN-18	25-JUN-18	26-JUN-18	28-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.3086	.3086	.3086	.3086	.3086
Max	.3086	.3086	.3086	.3086	.3086
Min	.3086	.3086	.3086	.3086	.3086
Avg	.3086	.3086	.3086	.3086	.3086