

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194002 / 33 KV BHOOM S/S

Feeder No / Name : 201 / 11 KV WASHI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
1		.381
2		.3429
3		.3429
4		.4001
5		.5144
6		.4954
7		.4954
8		.7049
23	.3429	
Max	.3429	.7049
Min	.3429	.3429
Avg	.3429	.4596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194002 / 33 KV BHOOM S/S

Feeder No / Name : 202 / 11KV PATHRUD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194002 / 33 KV BHOOM S/S

Feeder No / Name : 203 / 11 KV BHOOM URBAN
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	1.6289
Max	1.6289
Min	1.6289
Avg	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194002 / 33 KV BHOOM S/S

Feeder No / Name : 205 / 11 KV SHEKAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194002 / 33 KV BHOOM S/S

Feeder No / Name : 206 / 11kV W/W Express Bhoom
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	.6668
Max	.6668
Min	.6668
Avg	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194017 / 33/11 KV IEET S/S

Feeder No / Name : 201 / 11 KV IEET

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194017 / 33/11 KV IEET S/S

Feeder No / Name : 202 / 11 KV GIRWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.4954
Max	.4954
Min	.4954
Avg	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194017 / 33/11 KV IEET S/S

Feeder No / Name : 203 / 11 KV PAKHRUD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194017 / 33/11 KV IEET S/S

Feeder No / Name : 204 / 11 KV ANDRUD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194017 / 33/11 KV IEET S/S

Feeder No / Name : 205 / 11 KV NAGEWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 201 / 11 KV WALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 202 / 11 KV Ganegaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 203 / Walwad GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194061 / 33/11KV SUB-STATION AMBHI

Feeder No / Name : 201 / AMBHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 201 / 11 KV SUKTA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.381	.3429	.2667		.5944
2	.2667		.381	.381	.2667		.663
3	.2858		.4763		.2858		.6859
4	.3239		.5335		.3239		.7324
5	.381		.6097		.381		.7678
6	.5906		.724	.6859	.5335		.8049
7	.7621		.8002	.8002	.5906		.9328
8	.6859		.6859	.7811	.724	.6859	1.0002
9	.5144	.6859	.5716	.4954	.4954	.5335	1.0136
10			.4572	3.1908	.9907	.6811	.381
11		.4763	.3429	1.105		.8049	.2667
12		2.1338	1.8435	.6287		.9069	.2286
13		2.4768	2.1765	1.1431		.9717	.2477
14		2.5149	2.1445	1.086		.6287	.2858
15		2.3815	2.1285	.724		.9328	.2667
16		2.4768	1.9757	.9526		.9335	.2858
17		2.5149	2.1052	.4572		.9602	.3429
18		2.5339	2.1376	.5906		.381	.4572
19		2.4768	2.0317			.4382	.5716
20		.8002	.8002	.6859		.7621	.7621
21		.724	.6287	.4954		.5716	.6097
22		.4954	.5144	.4001		.5335	.381
23		.4191	.4191	.3429		.4191	.381
24	.3429		.381	.4191	.3048		.5258
Max	.7621	2.5339	2.1765	3.1908	.9907	.9717	1.0136
Min	.2667	.4191	.3429	.3429	.2667	.381	.2286
Avg	.4458	1.6507	1.0521	.7854	.4694	.6965	.5495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 203 / GhatNandur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858		.2286	.2683			.2858
2	.5335		.2431	.3391			.3239
3	.6097		.3429				.3429
4	.6097		.3658				.5716
5	.6668		.4001				.724
6	.8764		.5182				.9145
7	.9526		.6089				.7621
8	.9907		.6089			.743	.6859
9	1.086	.9907	.6192		.5335	.8002	.5716
10		.5716	.7042		.5335	.3429	.4161
11		.4801	.421	.381		.3048	.2622
12		.2858	.2667	.3239		.2858	.4161
13			.1905	.2858		.2286	.2477
14		.2858	.2096	.2477		.2286	
15		.2858	.1905	.2096		.1905	
16		.2858	.2667	.1905		.2286	.1204
17		.2858	.3048	.381		.2858	.3841
18		.3239	.2286			.3048	
19		.5716	.4954	.4572		.4954	.4572
20		.8002	.8002	.2667		.6668	.6859
21		.6668	.5716	.362		.4763	.4572
22		.3429	.362	.362		.381	.381
23		.2858	.2667	.3239		.3429	.2667
24	.3239		.2477	2.54	.381		.2858
Max	1.086	.9907	.8002	2.54	.5335	.8002	.9145
Min	.2858	.2858	.1905	.1905	.381	.1905	.1204
Avg	.6935	.4616	.3942	.4626	.4827	.3941	.4554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194070 / 33/11 kv Antargaon

Feeder No / Name : 201 / ANTARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194070 / 33/11 kv Antargaon

Feeder No / Name : 202 / SAKAT KD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194071 / 33/11 kv warud sub-station

Feeder No / Name : 201 / 11 KV Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194071 / 33/11 kv warud sub-station

Feeder No / Name : 202 / 11 KV Gormala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194071 / 33/11 kv warud sub-station

Feeder No / Name : 203 / 11 KV Bavi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 201 / 11 KV PATHRUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 202 / 11 KV Sawargaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	.6668
Max	.6668
Min	.6668
Avg	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 203 / 11 KV Pathrud Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 204 / JAMB GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 201 / 11 KV YERMALA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.8299
8		.4862	.5365		.439	.4557	.7164
10		.4641	.4973		.7049	.724	.3647
11		.4144	.4807		.6668	.6478	.3978
12			.724		.6097		.4807
13		.724	.6668				.4807
14		.8002	.7621			.7621	.4973
15					.7621	.6859	.431
16	.8048			.743	.6097	.6859	
17				.7621	.6097	.7621	
18				.7621	.6478	.7621	
19						1.105	
20				1.1431	.9526	1.1431	
21	1.0669			1.0288	.9526	1.1431	
22							.6706
24						.373	.8413
Max	1.0669	.8002	.7621	1.1431	.9526	1.1431	.8413
Min	.8048	.4144	.4807	.743	.439	.373	.3647
Avg	.9359	.5778	.6112	.8878	.6955	.7708	.5710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 202 / 11 KV UMRA PANGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.9667
8		.6706	.6584			.8688	1.0898
10		.381	.4382			.7625	.4572
11		.3048	.2858			.8453	.3239
12			.9945		.7377		
13		1.2763	1.1768				.3239
14		1.21	1.1603			.9945	.2667
15					.3185	.8619	.2858
16	1.2483			.4191	.8383	1.0098	
17				.4572	.8002	.8916	
18				.4954	.4763	.3239	
19						.743	
20				.724	.8573	.8002	
21	.6287			.4572	.724	.7621	
24						.3961	.5935
Max	1.2483	1.2763	1.1768	.724	.8573	1.0098	1.0898
Min	.6287	.3048	.2858	.4191	.3185	.3239	.2667
Avg	.9385	.7685	.7857	.5106	.6789	.7716	.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 203 / 11 KV RATNAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.3961
8		.503			.39	.4409	.4108
10		.663	.7127		.3048	.2667	.3315
11		.6299	.6464		.1905	.2096	.3978
12			.3048		.1905		.4807
13		.2667	.2477				.4641
14		.2667	.2477			.2286	.3812
15					.2286	.2286	.431
16	.2149			.2477	.2286	.2286	
17				.2667	.2286	.2286	
18				.2667	.2096	.2286	
19						.381	
20				.4191	.381	.4001	
21	.4572			.3429	.362	.362	
24						.4024	.2561
Max	.4572	.663	.7127	.4191	.39	.4409	.4807
Min	.2149	.2667	.2477	.2477	.1905	.2096	.2561
Avg	.3361	.4659	.4319	.3086	.2714	.3005	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 205 / 11 KV BANGARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.811
8		1.2574	1.56		.9892	.9221	
10		1.326	1.326		.5525	.4954	.8288
11		1.3094	1.2929			.362	.8619
12			.4001		.4001		.8951
13		.4763	.4382				.9282
14		.4382	.4382			.381	.7127
15					.3239	.362	
16	.3961			.4001	.4001	.381	
17				.4763	.4572	.381	
18				.5335	.4572	.362	
19						.724	
20				.7811	.8192	.7811	
21	.6287			.743	.7621	.7621	
22							.1905
24						.5765	.5373
Max	.6287	1.326	1.56	.7811	.9892	.9221	.9282
Min	.3961	.4382	.4001	.4001	.3239	.362	.1905
Avg	.5124	.9615	.9092	.5868	.5735	.5409	.7207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 206 / 11 KV CHORAKHALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.3353
8		.503	.6036		.5281	.6104	
10		.4001	.4572		.3856	.3688	.4382
11		.3239	.362		.362	.3978	.3429
12			.3647		.3353		.2667
13		.6962	.779				.1905
14		.6464	.6464			.2155	.2286
15					.285	.3688	.2667
16	.6104			.4115	.362	.4191	
17				.381	.5335	.381	
18				.4572	.4954	.381	
19						.6097	
20				.6859	.7621	.5716	
21	.6097			.6097	.6097	.5716	
22							.2858
24						.439	.3391
Max	.6104	.6962	.779	.6859	.7621	.6104	.4382
Min	.6097	.3239	.362	.381	.285	.2155	.1905
Avg	.6101	.5139	.5355	.5091	.4659	.4445	.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 201 / 11 KV MOHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3715	.3734	.3932	1.2289	3.9792	4.638	.587
2	1.8233	2.3388	2.3072	2.1956	4.5319	4.7104	.5905
3	1.8233	2.452	2.3375	2.3579	4.9671	4.9245	.591
4	2.1548	2.7161	2.4348	2.4272	4.8557	5.1297	.545
5	2.5434	3.062	2.4789	2.774	5.4078	5.3053	.8382
6	3.083	3.5852	3.0323	2.774	5.8447	6.5917	1.2483
7	3.3813	3.8809	3.3922	.6219	7.0386	6.8587	
8	3.4202	3.8439	3.0111	.7529	6.6759	6.5917	
9	3.5475	3.0428	2.5857	.8001	5.915	5.6304	
10	3.5101		2.7526				1.3016
11	3.4915	2.9329	2.2298			.6881	2.8468
12	.3868		.2675	.3715	.7895	.5415	2.8554
13	.3628	.2949	.2675		.5981	.5457	3.1305
14	.3498	.2981	.2675		.5953	.5344	3.0588
15	.3498	.2949	.2675		.5898	.6729	2.854
16	.3368	.2949	.2675		.5921	.6729	2.7789
17	.4001	.2981	.2675	.4016	.5921	.8433	2.854
18	.5213		.2675		.9444	.7938	.5532
19	.5624	.5742	.4733	.6716	1.1554	.9426	.7127
20	.751	.702		.6478	1.3891	1.3632	.7102
21	.631	.5963	.5304	.6478	1.1961	1.1202	.6268
22	.5201	.4969	.3692	.4954	1.0965	1.0456	.4815
23		.4012	.2576	.421	.9923	.9282	.3809
24	.3715	.4001	.3932	.8551	3.5879	3.8009	.7267
Max	3.5475	3.8809	3.3922	2.774	7.0386	6.8587	3.1305
Min	.3368	.2949	.2576	.3715	.5898	.5344	.3809
Avg	1.5084	1.5657	1.3414	1.2026	2.8788	2.8206	1.4415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 202 / 11 KV KHERDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3048	.3048		.6096	.3048	2.4181
2	.2667	.3048	.3048		.5716	.6096	2.4074
3	.2667	.3048	.3048		.6096	.6096	2.7339
4	.381	.381	.3048		.762	.6096	2.5926
5	.4191	.4572	.381		.9908	.762	3.2007
6	.6097	.6478	.6097		1.2956	1.2194	5.1051
7					1.6766		6.8008
8							4.2768
9							2.8753
10				.7449		4.2715	.4191
11	.381	.2591		.8097	4.5396	6.0303	.2858
12	3.1367	2.9508		.6687	5.7677	4.2036	.2096
13	3.4004	2.9165	2.6871			4.949	
14	3.1741	2.8551	2.5819		5.3736	5.3963	.2096
15	3.1047	2.6094	2.4669	2.7873	5.2897	5.7614	.2286
16	3.1367	2.6368	2.6886		4.9602		.2286
17	3.5482	3.0078	2.6566	2.7873	5.2184	4.731	.2286
18	3.6222	2.4847		.2353	.3749	.4572	.381
19	3.1047			.2972	.7521	.8382	.6478
20	.5716	.6097		.3963	1.2194	1.1432	.5716
21	.5335	.5335			1.067	.8216	.4954
22	.4001	.4572		.4572	.9144	.7629	.362
23	.381	.3048		.3239	.6096	.7041	.3239
24	.3048	.3048	.3048		.6096	.6096	2.4181
Max	3.6222	3.0078	2.6886	2.7873	5.7677	6.0303	6.8008
Min	.2667	.2591	.3048	.2353	.3749	.3048	.2096
Avg	1.5505	1.2806	1.2997	.9508	2.1606	2.2397	1.7139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 203 / 11 KV NAGZARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1772	.0975	.0777	.2258	.285	1.0974
2	.1753	.1772	.0983	.0777	.266	.285	1.134
3	.1753	.1772	.0994	.0777	.266	.2834	1.1584
4	.2743	.2126	.0994	.0777	.3273	.285	1.2308
5	.3429	.2804	.1988	.1166	.5847	.5608	1.2536
6	.3772	.4252	.3009	.1555	.6132	.8322	1.8823
7					.7042		1.8778
8							1.576
9							1.8671
10				1.004	3.0796	2.9126	.2715
11	.1886	.1504		1.1336	2.9017	3.8835	.1772
12	1.7101	1.8308	1.2178	1.2334	3.3379	3.9568	.1448
13	1.869	1.7572	1.8351	1.1873		3.8896	.1402
14	1.8233	1.6921	1.0456	.9242	3.0178	3.6214	.1402
15	1.7436	1.786	1.1888	1.0105	2.855	3.5911	.1417
16	1.8107	1.7881	1.6049	.9922	2.3853	3.3532	.124
17	1.6766	1.8829	1.6217	1.3756	3.2172	2.8806	.1448
18		1.9845	1.2795	.1029	.24	.2774	.1204
19	1.6598	1.7778	1.0562	.1749	.604	.631	.3382
20	.3155	.2949	.2058	.2469	.7156	.8459	.2995
21	.2835	.1988	.1555	.2469	.4801	.4935	.2733
22	.1949	.2006	.136	.1646	.3578	.4252	.1337
23	.1772	.1044	.1166	.1029	.2411	.1433	.1073
24	.1715	.1772	.0975	.0777	.2271	.285	1.0608
Max	1.869	1.9845	1.8351	1.3756	3.3379	3.9568	1.8823
Min	.1715	.1044	.0975	.0777	.2258	.1433	.1073
Avg	.7969	.8538	.6555	.5029	1.2689	1.6058	.6956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 201 / 11 KV MANDAWA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.1145		1.1145	.6706
10	1.1736				
24			.0848		
Max	1.1736	1.1145	.0848	1.1145	.6706
Min	1.1736	1.1145	.0848	1.1145	.6706
Avg	1.1736	1.1145	.0848	1.1145	.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 202 / 11 KV ITKUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)
6		2.1052
24	.08	
Max	.08	2.1052
Min	.08	2.1052
Avg	.08	2.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 203 / 11 KV KOTHALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-MAY-18	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
6	3.3532		3.7342
9		3.0178	
24		.1581	
Max	3.3532	3.0178	3.7342
Min	3.3532	.1581	3.7342
Avg	3.3532	1.5880	3.7342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 204 / 11 KV ADHALA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)
6		.7202
24	.08	
Max	.08	.7202
Min	.08	.7202
Avg	.08	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 205 / 11 KV ITKUR GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
6		1.4937	1.4937
24	.7392		
Max	.7392	1.4937	1.4937
Min	.7392	1.4937	1.4937
Avg	.7392	1.4937	1.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 201 / 11 KV GOVINDPUR GAOTHAN

GAOTHAN FEEDER

(NEW) Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1715	.1829		.1715	.181	.1791
2	.1791	.1715	.181		.1715	.1829	.1791
3	.1791	.1715	.1829		.1715	.181	.1791
4	.1791	.1715	.181		.1715	.2715	.1791
5	.1791	.1715	.2743		.1715	.362	.1791
6	.1791	.1715	.362		.3429	.3658	.1791
7	.2686	.2572	.2715		.3429	.2686	.2686
8	.2743	.2572	.2743		.3429	.1829	.2743
9	.2743	.2572	.2743		.2572	.1829	.1829
10	.1715	.1829	.2743		.1829	.1791	.1715
11	.1715	.1829	.1791		.181	.1791	.1715
12	.1372	.1829	.1791	.1372		.1791	.0857
13	.1372	.181	.1791	.0857	.1829	.1791	.0857
14	.0857	.1829	.1791	.0857	.181	.0895	.0857
15	.0857	.181	.1791	.0857	.181	.0895	.0857
16	.1372	.1829	.1791	.0857	.1829	.0895	.0857
17	.1715	.181	.1791	.0857	.181	.1791	.0857
18	.1715	.2743	.1791	.1715	.2743	.2686	.0857
19	.2572	.362	.16	.3429	.362	.2686	.3429
20	.3429	.3658	.2686	.3429	.2715	.2686	.2572
21	.2572	.3658	.2686	.2572	.2715	.1791	.2572
22	.2572	.2715	.2686	.1715	.181	.1791	.1715
23	.1715	.1829	.1715	.1715	.181	.1791	.1715
24	.1829	.1715	.1829	.1715	.1715	.1829	.1829
Max	.3429	.3658	.362	.3429	.362	.3658	.3429
Min	.0857	.1715	.16	.0857	.1715	.0895	.0857
Avg	.1929	.2188	.2171	.1688	.2230	.2029	.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 202 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0572		.0572	.0381	1.5242
2	.0381	.0572	.0381		.0572	.0381	1.5242
3	.0381	.0572	.0381		.0572	.0381	1.5242
4	.0381	.0572	.0381		.0572	.0381	1.5242
5	.0381	.0572	.0381		.0572	.0377	1.5242
6	.0381	.0572	.0381		.0572	.0381	
7	.0381	.0572	.0381		.0572	.0381	
8	.0381	.0572	.0381		.0572	.0377	
9	.0381	.0572	.0381		.0572	.0377	
10	.0381	.0381	.0381		1.2193	1.9052	
11	.0381	.0381	.0381		1.6004	2.0957	
12	2.572	2.4768	2.0957	2.0957		2.0957	
13	2.4768	2.1338	2.6673	2.0957	1.7528	2.2862	
14	2.3815	1.9204	2.6673	2.0957	1.9204	2.2862	.0572
15	2.2862	1.6194	2.6673	2.2862	1.829	2.2862	.0572
16	2.4768	1.9433	2.6673	2.3815	1.9814	2.2862	.0572
17	2.4768	2.2672	2.6673	2.2862	1.829	2.2862	.0572
18	2.6673	1.7814	2.2862	.0953	.0377	.0381	.0572
19	2.6673	1.5242	2.3815	.0953	.0381	.0381	.0953
20	.0953	.0305	.0381	.0953	.0953	.0381	.0953
21	.0953	.0381	.0381	.0572	.0381	.0381	.0953
22	.0953	.0381	.0381	.0572	.0953	.0381	.0953
23	.0572	.0381	.0381	.0572	.0381	.0381	.0953
24	.0381	.0572	.0381	.0381	.0572	.0381	1.5242
Max	2.6673	2.4768	2.6673	2.3815	1.9814	2.2862	1.5242
Min	.0381	.0305	.0381	.0381	.0377	.0377	.0572
Avg	.8669	.6858	.8637	1.0567	.5673	.7557	.6192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 203 / 11 KV KHAMASWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0953	.0953		.0953	.0943	1.0974
2	.0914	.0953	.0953			.0914	1.0974
3	.0914	.0953	.0953		.0953	.0905	1.0974
4	.0914	.0953	.0953		.0953	.0905	1.0974
5	.0914	.0953	.0953		.0953	.0905	1.0974
6	.0914	.0953	.0953		.0953	.0905	1.0974
7	.0914	.0953	.0953		.0953	.0943	1.0974
8	.0914	.0953	.0953		.0953	.0914	
9	.0914	.0953	.0953		.0953	.0914	
10	.0953	.0953	.0914		1.2193	1.4632	.0953
11	.0953	.0953	.0914		1.5242	1.6461	.0953
12	1.9052	1.5242	1.4632			1.829	.0953
13	1.9052	1.5242	1.829		.9145	1.829	.0953
14	1.9052	1.7604	1.829		1.6004	1.829	.0953
15	1.7147	1.7604	1.829	1.9052	1.6004	1.829	.0953
16	2.0957	1.5242	1.829	2.0957	1.7604	2.0119	.0953
17	2.0957	1.6766	1.829	2.0957	1.5242	1.829	.0953
18	2.0957	1.6004		.0953	.0943	.0914	.0953
19	2.0957	1.8099		.0953	.0905	.0914	.0953
20	.0953	.0905	.0914	.0953	.0905	.0914	.0953
21	.0953	.0953	.0914	.0953	.0905	.0914	.0953
22	.0953	.0953	.0914	.0953	.0914	.0914	.0953
23	.0953	.0953	.0953	.0953	.0905	.0914	.0953
24	.0914	.0953	.0953	.0953	.0953	.0943	1.0974
Max	2.0957	1.8099	1.829	2.0957	1.7604	2.0119	1.0974
Min	.0914	.0905	.0914	.0953	.0905	.0905	.0953
Avg	.7208	.6125	.5506	.6764	.5249	.6556	.4597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 204 / 11 KV JAWALA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0762	.0714		1.3717	.9145	.081
2	.9717	1.3717	1.448		1.3717	.9602	.081
3	1.2955	1.3717	.9907		1.448	1.2955	.081
4	1.2955	1.448	1.3765		1.6289	1.5242	.081
5	1.2955	1.448	1.5384		1.3717	1.2803	.081
6	1.6194	1.448	1.6194		1.3717	1.4575	.081
7	1.6194	1.5242	1.6804		1.7147	1.4575	.081
8	1.7814	1.6766	1.6194		1.7147	1.3717	.081
9	1.2146	1.6766	1.5242		1.2193	1.2193	.081
10	1.5242	1.5242	1.6194		.0714	.081	1.5242
11	1.5242	1.4403	1.6194		.0714	.081	1.5242
12	.0762		.081			.081	1.0669
13	.0762	.0943	.081		.0714	.081	1.2193
14	.0762	.0943	.081			.081	1.2193
15	.0762	.0953	.081	.0762	.0714	.081	1.3717
16		.0953	.081	.0762	.0714	.081	1.5242
17		.0953	.081	.0762	.0714	.081	1.5242
18		.0953	.081	.0762	.0714	.081	.0762
19	.0762	.0953	.081	.0762	.0714	.081	.0762
20	.0762	.0953	.081	.0857	.0667	.081	.0762
21	.0762	.0714	.081	.0762	.0714	.081	.0762
22	.0762	.0714	.081	.0762	.0714	.081	.0762
23	.0762	.0905	.0762	.0762	.0714	.081	.0762
24	.081	.0762	.0714	.9145	1.8004	.7621	.081
Max	1.7814	1.6766	1.6804	.9145	1.8004	1.5242	1.5242
Min	.0762	.0714	.0714	.0762	.0667	.081	.0762
Avg	.7138	.6989	.6727	.1610	.7211	.5574	.5101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 205 / 11 KV DEODHANORA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953		2.2862	1.6004	.0953
2	2.0957	2.0005	1.4403		2.0957	1.6766	.0953
3	2.2862	2.572	1.6194		2.0957	1.6766	.0953
4	2.2862	2.572	1.829		2.0957	1.9433	.0953
5	2.6673	2.3815	2.2405		2.2862	2.2405	.0953
6	2.8578	2.3815	2.2405		2.2862	2.1052	
7	2.8578	2.4768	2.2862		2.2862	2.2672	.0953
8	2.8578	2.6673	2.4006		2.4768		.0953
9	2.6673	2.572	2.2405		1.9052	1.9814	.0953
10	2.6673	1.9814	2.6673		.0943	.0953	2.0957
11	2.6673	1.829	2.6673		.0953	.0953	
12	.0953		.0953	.0953		.0953	1.7147
13	.0953	.0943	.0953		.0914	.0953	2.2862
14	.0953	.0953	.0953		.0953	.0953	2.4768
15	.0953	.0857	.0953		.0953	.0953	2.4768
16	.0953	.0905	.0953	.0953	.0943	.0953	2.572
17		.0905	.0953	.0953	.0905	.0953	2.6673
18		.0905	.0953	.0953	.0953	.0953	.0953
19	.0953	.0905	.0953	.0953	.0943	.0953	.0953
20	.0953	.0905	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	1.5242	2.2862	1.2193	.0953
Max	2.8578	2.6673	2.6673	1.5242	2.4768	2.2672	2.6673
Min	.0953	.0857	.0953	.0953	.0905	.0953	.0953
Avg	1.2297	1.0712	.9569	.2382	1.0142	.7846	.8054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 206 / 11 KV DEODHANORA GAOTHAN

GAOTHAN FEEDER

FEEDE Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1715	.1829		.1715	.181	.181
2	.1829	.1715	.181		.1715	.181	.1829
3	.1829	.1715	.181		.1715	.181	.1829
4	.1829	.1715	.181		.1715	.2715	.1829
5	.1829	.1715	.2715		.1715	.3658	.1829
6	.2743	.3429	.3658		.3429	.4525	
7	.3658	.3429	.4525		.3429	.3658	.1829
8	.3658	.3429	.362		.3429	.362	.1829
9	.1829	.2572	.2743		.2572	.362	.1829
10	.1715	.1829	.2743		.1829	.1829	.1715
11	.1715	.1829	.1829		.181	.181	.1715
12	.1715		.1829			.1829	.1715
13	.1715	.181	.1829		.1829	.181	.1715
14	.1715	.181	.1829			.181	.1715
15	.1715	.181	.1829	.1715	.181	.1829	.1715
16	.1715	.181	.1829	.1715	.181	.1829	.1715
17		.2743	.1829	.1715	.181	.1829	.1715
18		.3658	.1829	.1715	.2743	.3658	.1715
19	.2572	.362	.1829	.3429	.362	.3658	.3429
20	.3429	.4525	.2743	.3429	.362	.3658	.3429
21	.4287	.3658	.2743	.3429	.362	.2743	.2572
22	.4287	.362	.2743	.1715	.2715	.2743	.1715
23	.3429	.2715	.1715	.1715	.181	.1829	.1715
24	.1829	.1715	.1829	.1715	.1715	.1829	.1829
Max	.4287	.4525	.4525	.3429	.362	.4525	.3429
Min	.1715	.1715	.1715	.1715	.1715	.181	.1715
Avg	.2403	.2547	.2312	.2229	.2372	.2580	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 201 / 11 KV PADOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.7164		1.7159	1.9135	1.9502
16	.3692		.4057	.4141	.4582
24	1.3206	1.4805		.3965	
Max	1.7164	1.4805	1.7159	1.9135	1.9502
Min	.3692	1.4805	.4057	.3965	.4582
Avg	1.1354	1.4805	1.0608	.9080	1.2042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 202 / 11 KV WADGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6876		.7757			
16	.3174		1.4935	1.5344	1.6334	.3889
24	1.2539	1.4754		.3761		
Max	1.6876	1.4754	1.4935	1.5344	1.6334	.3889
Min	.3174	1.4754	.7757	.3761	1.6334	.3889
Avg	1.0863	1.4754	1.1346	.9553	1.6334	.3889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 203 / 11 KV NAIGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.85		.5981	.7015	.4137	.4795
24	.5276	.6212		1.3457		
Max	1.85	.6212	.5981	1.3457	.4137	.4795
Min	.5276	.6212	.5981	.7015	.4137	.4795
Avg	1.1888	.6212	.5981	1.0236	.4137	.4795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 204 / 11 KV WATWADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7733		.5693		.8291	
16	.8292		.2942	.3497	.2763	.6618
24	.2454	.2646		.2457		
Max	.8292	.2646	.5693	.3497	.8291	.6618
Min	.2454	.2646	.2942	.2457	.2763	.6618
Avg	.6160	.2646	.4318	.2977	.5527	.6618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194063 / 33/11 KV SUB-STATION

KHAMASWAD

Feeder No / Name : 202 / 11 KV KHAMASWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18
HR	Load (MW)
8	.5668
24	1.3717
Max	1.3717
Min	.5668
Avg	.9693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 201 / 11 KV BHOGJI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				2.572
23	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	2.572
Min	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	1.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 202 / 11 KV BHOGJI GAOTHAN GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.0934			
18	.1307				
24		.0934	.1494	.112	.112
Max	.1307	.0934	.1494	.112	.112
Min	.1307	.0934	.1494	.112	.112
Avg	.1307	.0934	.1494	.112	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 203 / 11 KV PIMPALGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			2.4272		
8	2.4272			2.782	
17					2.4272
24		.0934			
Max	2.4272	.0934	2.4272	2.782	2.4272
Min	2.4272	.0934	2.4272	2.782	2.4272
Avg	2.4272	.0934	2.4272	2.782	2.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 201 / 11 KV MANGRUL FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381		.0381		.5335
2	.0381	.0572	.0381		.0381		.5335
3	.0381	.0572	.0381		.0381		.5335
4	.0381	.0572	.0381		.0381		.5401
5	.0381	.0762	.0572		.0572		.6173
6	.0762	.0953	.0762		.0762		.6718
7	.0953	.1143	.0953		.0953	.0762	.7716
8	.0953	.0762	.0762		.1143	.0762	.7621
9		.0762	.0762		.0762	.0762	.7011
10	.0762	.0762	.0572		.5506	.6401	.0572
11	.0572	.0762	.0381		.3812	.7773	.0572
12	.7034	.9145	.9145		.7562	.7579	.0572
13	.8951	.9214	.9145	.8619	.8951	.7727	.0381
14	.8592	.9181	.8993		.8796	.7526	.0191
15	.8109	.8509	.9145	.9069	.8642	.823	
16	.8655	.873		.9069	.8796	.7827	.0381
17	.9259	.9145		.0332		.5487	.0191
18	1.0059	.9957		.0381		.0572	.0381
19	.9145	.8509		.0572		.0572	.0572
20	.0762	.0762		.0572		.0762	.0572
21	.0762	.0572		.0381		.0572	.0572
22	.0572	.0572		.0381		.0572	.0381
23	.0572	.0572		.0381	.0572	.0381	.0381
24	.0381	.0381	.0572		.0381	.0381	.5335
Max	1.0059	.9957	.9145	.9069	.8951	.823	.7716
Min	.0381	.0381	.0381	.0332	.0381	.0381	.0191
Avg	.3424	.3469	.2706	.2976	.3263	.3592	.2943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 202 / 11 KV BHATSHIRPURA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.1905		.0191		.1204
2	.2286	.2286	.1524		.0191		.1174
3	.2286	.2477	.1524		.0191		.1174
4	.2286	.2477	.1905		.0191		.1505
5	.2858	.3239	.2858		.0381		.1505
6	.381	.381	.3429		.0762		.1806
7	.4572	.4001	.4191		.0381	.0191	.1715
8	.4763	.3429	.4572		.0191	.0191	.1806
9		.3239	.381		.0191	.0191	.1524
10	.381	.2858	.3048		.0162	.1372	.0191
11	.2286	.1905	.1715		.0152	.1429	.0191
12	.5411	.5281	.5487		.0676	.1715	.0191
13	.4988	.5007	.5792		.141	.1715	.0191
14	.4401	.4172	.6097	.1619	.1593	.1738	.0191
15	.4287	.4451	.6097	.1619	.1572	.1486	
16	.423	.4858		.1619	.1509	.208	.0191
17	.535	.5144		.1658		.1524	.0191
18	.6203	.5563		.1524		.0191	.0191
19	.5944	.5007		.0191		.0191	.0191
20	.4191	.381		.0191		.0191	.0191
21	.3239	.2286		.0191		.0191	.0191
22	.2286	.2286		.0191		.0191	.0191
23	.1905	.2286		.0191	.0191	.0191	.0191
24	.2286	.1905	.1905		.0191	.0191	.1204
Max	.6203	.5563	.6097	.1658	.1593	.208	.1806
Min	.1905	.1905	.1524	.0191	.0152	.0191	.0191
Avg	.3738	.3503	.3491	.0899	.0563	.0832	.0743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 203 / 11 KV PIMPALGAON (D) SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381		.8097		.5716
2	.5935	.9116	.7621		.8097		.5716
3	.7122	1.0936	.9374		.8097		.5716
4	.8288	1.2944	1.0402		.9717		.7621
5	.9945	1.3279	1.2431		1.0526		.9526
6	1.1336	1.5524	1.4575		1.326		1.2193
7	1.2003	1.7238	1.6004		1.5912	1.829	1.3717
8	1.6156	1.704	1.7284		1.6244	1.6766	1.2003
9		1.5623	1.6446		1.6907	1.6766	1.1431
10	1.448	1.4148	1.531		.7621	.7621	.6325
11	1.3032	1.3108	1.448		.5525	.5335	1.4998
12	.381	.3048	.381		.5144		1.5935
13	.3429	.3048	.381	.4572	.4001		1.6204
14	.3429	.3048	.3048	.2667		.5335	1.7444
15	.3239	.3429	.2858	.4572	.4382	.5335	
16	.3239	.3429		.381	.4954	.4954	1.2193
17	.381	.381		.4763		.6097	1.4563
18	.381	.381		.9907		.6859	.5906
19	.5335			.8573		.8192	.7621
20	.724	.7621		.9907		1.1431	.724
21	.5906	.5716		.8573		.9335	.6668
22	.4763	.4954		.7621		.7621	.6668
23	.4382	.4191		.5716	.6668	.5716	.5716
24	.4763	.4191	.381		.6802	.8383	.5716
Max	1.6156	1.7238	1.7284	.9907	1.6907	1.829	1.7444
Min	.3239	.3048	.2858	.2667	.4001	.4954	.5716
Avg	.6924	.8394	.9692	.6426	.8938	.9002	.9862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 201 / 11 KV DHORALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.4534
2							.5668
3							.5668
4							.6154
5							.7287
6							.7701
7							.7287
8							.7287
9							.7287
10				.6478	.4733	.7773	
11				.5668	.5258	.8697	
12	.9231	.8482	.8322			.8962	
13	.8745	.8223	.8173	.7287	.5653	.8905	
14	.8097	.8592	.8025	.6478	.5784	.8802	
15	.8421	.8223	.7727	.6802	.6047	.8642	
16	.8192	.8002	.8322	.7773	.631	.8124	
17	.7099	.8684	.8471	.8192	.6704	.7811	
18	.8282	.8907	.8025				
19	.7362	.8749	.7727				
24							.3239
Max	.9231	.8907	.8471	.8192	.6704	.8962	.7701
Min	.7099	.8002	.7727	.5668	.4733	.7773	.3239
Avg	.8179	.8483	.8099	.6954	.5784	.8465	.6211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 202 / 11 KV DEOLALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5716	.3384	
2	.6859		.7202			.4512	
3	.7011	.6485	.7865		.6001	.5357	
4	.7011	.6908	.8482		.6287	.6203	
5	.7164	.6908	.933	.5487	.6287	.6485	
6	.9145	.7895	1.0402	.6401	.6573	.7613	
7	1.0059	.9023	1.0688	.6554	.7145	.8459	
8	.9755	.9728	1.0082	.6859	.7859	.7331	
9	.9602	.9023	.9922	.6706	.8573	.6767	
10	1.0002	1.0279	.9145				
11	.9288	1.0202	.9145				.8573
12							.8002
13							.8573
14							.6001
15							.5716
16							.543
17							.5716
24				.6401	.2858	.2679	
Max	1.0059	1.0279	1.0688	.6859	.8573	.8459	.8573
Min	.6859	.6485	.7202	.5487	.2858	.2679	.543
Avg	.8590	.8495	.9226	.6401	.6367	.5879	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 203 / 11 KV DHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1991	.2149		.1829	.1791	.2012
2	.2012	.181	.181		.1829	.1791	.1619
3	.1829	.181	.1629		.2195	.1791	.1829
4	.1829	.197	.1612		.2195	.197	.1646
5	.2195	.2172	.181	.1829	.2195	.2149	.2743
6	.3292	.2507	.3045	.3658	.2926	.2507	.3475
7	.3658	.3439	.3439	.3658	.3292	.3403	.3475
8	.3292	.3224	.3045	.2926	.3658	.3045	.2561
9	.3109	.3045	.2715	.2561	.3658	.2865	.2195
10	.2195	.2715	.2378	.2195	.2896	.2353	.2195
11	.1829	.1791	.2195		.2172	.1791	.1829
12	.1463	.1991	.1646	.1829		.1612	
13	.1463	.1791	.1829	.2743		.181	
14	.1463	.1612	.1829	.1829		.1991	
15	.1463	.1629	.1646	.1311		.181	.1829
16	.1829	.1612	.1829	.1463	.1791	.181	.1829
17	.1791	.181	.2012	.1829	.197	.181	.2195
18	.1791	.1991	.2195	.2195	.2149	.2686	.2195
19	.2507	.2353	.2561	.1829	.2507	.2896	.2195
20	.3258	.3439	.3292	.1829	.3224	.3439	.2195
21	.2865	.3801	.2743	.2195	.2587	.3224	.1829
22	.2507	.2353	.2561	.2195	.2172	.3077	.2195
23	.2172	.2172	.2195	.2195	.197	.2896	.1429
24	.2195	.2149	.181	.2012	.1829	.1791	.2743
Max	.3658	.3801	.3439	.3658	.3658	.3439	.3475
Min	.1463	.1612	.1612	.1311	.1791	.1612	.1429
Avg	.2258	.2299	.2249	.2225	.2452	.2346	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194093 / 33/11 KV SUBSTATION DIKSAL

Feeder No / Name : 201 / 11 Kv DIKSAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.407			
6					.5087		
7	.4748		.547	.5256	.5426		
8	.4917			.4748	.5087	.4578	1.6108
9	.407			.373		.4144	
10	.3561			.9835			.3222
11	.373		1.3395	1.153			.2035
12			1.7465	1.5261	1.8821		.3052
13	1.8652		1.7635	1.4582	1.8482		.3052
14	1.8991		1.7635	1.6956			.3052
15	1.95		1.8482	1.8313			.3222
16	2.0008			1.8482	1.8991		.3391
17	2.0348			1.8821	1.7465		.3561
18				.3561			
19			.8309	.5087			
20			.5765	.5087			
21			.5087	.5087			
22		.5087	.5426	.4748			
23			.4748	.4748			.4409
24	.4239		.407	.4409	.4239	.39	
Max	2.0348	.5087	1.8482	1.8821	1.8991	.4578	1.6108
Min	.3561	.5087	.407	.3561	.4239	.39	.2035
Avg	1.1160	.5087	1.0291	.9174	1.1700	.4207	.4510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194093 / 33/11 KV SUBSTATION DIKSAL

Feeder No / Name : 202 / 11 KV W/W KALLAM FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.0953			
6					.1334		
7	.0572		.0572	.1143	.1524		
8	.1143			.1334	.1143	.1334	.1334
9	.1524		.0572	.1334		.1524	
10	.0953		.0762	.1715			.1715
11	.1715		.1715	.1905			.1524
12			.1715	.1334	.1334		.1715
13	.1715		.1334	.0953	.1143		.1334
14	.0953		.1143	.1334			.1334
15	.0953		.1334	.1334			.1524
16	.1143			.1334	.1524		.0762
17	.0953		.0953	.1143	.0762		.0762
18			.1143	.1524			
19			.1143	.1334			
20			.0953	.0953			
21			.1143	.0953			
22		.0953	.0953	.1334			
23			.1334	.1715			.1143
24	.1715		.1524	.1524	.1334	.1524	
Max	.1715	.0953	.1715	.1905	.1524	.1524	.1715
Min	.0572	.0953	.0572	.0953	.0762	.1334	.0762
Avg	.1213	.0953	.1143	.1324	.1262	.1461	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194093 / 33/11 KV SUBSTATION DIKSAL

Feeder No / Name : 203 / 11 KV KHADKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				1.8399			
6					2.4863		
7	2.6023			2.3371	2.652		
8	2.536			2.42	2.6189	2.5029	.1492
9	2.5029		2.7515	2.5194		1.6741	
10	2.4863		2.7183	.0829			
11	.0497		.0663	.0829			2.5692
12			.0663	.0829	.0497		2.6023
13	.0663		.0663	.0663			2.6686
14	.0663		.0663	.0663			2.6852
15	.0663		.0663	.0663			2.6686
16	.0663			.0663	.0663		2.5526
17			.0497	.0663	.0663		2.4366
18			.0829	.0995			
19			.0995	.116			
20			.1492	.1326			
21			.116	.0995			
22		.0829	.0995	.0829			
23			.0829	.0829			.0663
24	.0829		.0663	2.0885	2.0885	2.1714	
Max	2.6023	.0829	2.7515	2.5194	2.652	2.5029	2.6852
Min	.0497	.0829	.0497	.0663	.0497	1.6741	.0663
Avg	1.0525	.0829	.4365	.6526	1.4326	2.1161	2.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 201 / 11 Takali B.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
24	.4801	.5144
Max	.4801	.5144
Min	.4801	.5144
Avg	.4801	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 202 / 11KV Dhutta Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
24	.4458	.4207
Max	.4458	.4207
Min	.4458	.4207
Avg	.4458	.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 203 / 11 KV Borkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
24	.4115	.3467
Max	.4115	.3467
Min	.4115	.3467
Avg	.4115	.3467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 201 / 11 KV POHNER AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0312				
2		.3563	.3117				
3		.4481	.3896		.1861		
4		.3314	.4208				
5		.4706	.4364			.2494	
6		.4209	.4364			.4208	
7		.5544	.6234			.4987	
8		.5373	.7013		.1863		
9					.3873		
10	.4364				.4012		.3749
11	.452						.4761
12							.506
13							.4841
14							.4824
15							.4999
16							.5079
17							.4999
24			.0312	.1175	.187	.2649	.0312
Max	.452	.5544	.7013	.1175	.4012	.4987	.5079
Min	.4364	.3314	.0312	.1175	.1861	.2494	.0312
Avg	.4442	.4456	.3758	.1175	.2696	.3585	.4292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 202 / 11 KV WALGUD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	01-JUN-18	02-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.1263
7					.1047
9					.3563
11			.3812	.3315	
12	.4624		.319	.1562	
13			.3352	.2818	
14				.2263	
15				.2427	
16	.6084	.1961	.3647	.2759	
17	.5693	.6264	.3849	.3467	
18	.5138	.463			
19	.4641	.376			
Max	.6084	.6264	.3849	.3467	.3563
Min	.4624	.1961	.319	.1562	.1047
Avg	.5236	.4154	.357	.2659	.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 203 / 11 KV RAGHUCHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.4632	1.2186			
3		1.3748	1.2574	.4877		
4		1.3672	1.3109			
5		1.4578	1.3791		.5137	
6		1.6735	1.4546		.6675	
7		1.8656	1.6285		.905	
8		1.4506	1.6824	.57		
9				.631		
10	1.4805			.8962		
11	1.4769					.8619
12						.9156
13						.9069
14						1.2803
15						.9602
16						1.1888
17						1.1142
24			.076	.4801	.5376	.0909
Max	1.4805	1.8656	1.6824	.8962	.905	1.2803
Min	1.4769	1.3672	.076	.4801	.5137	.0909
Avg	1.4787	1.5218	1.2509	.613	.6560	.9149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 204 / 11 KV GAOSUD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.8556
2							.8937
3							.8937
4							.8556
5							.9127
6							.9127
7							1.331
8							1.4641
9							1.426
11				1.1789	.8413		
12	1.5591			1.2359	.9709		
13				1.4641	1.2696		
14					1.1111		
15					1.3413		
16	1.6922	1.7303		1.426	1.4045		
17	1.6732	1.8063		1.388	1.2186		
18	1.4918	1.7683					
19	1.3094	1.7493					
24			.038	.0761		.019	.9127
Max	1.6922	1.8063	.038	1.4641	1.4045	.019	1.4641
Min	1.3094	1.7303	.038	.0761	.8413	.019	.8556
Avg	1.5451	1.7636	.038	1.1282	1.1653	.019	1.0458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 205 / 11 KV GAOSUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1863				.1686
2		.1736	.1684				.1509
3		.1486	.1689		.1387		.1512
4		.1543	.188				.1504
5		.208	.2075			.1521	.1677
6		.2561	.2261			.1704	.2039
7		.2218	.2211			.1861	.2241
8		.1909	.2001		.1867		.1668
9					.168		.1494
10	.1271				.1509		.137
11	.0896			.1095	.1457		.1379
12				.0839	.1311		.1387
13				.1244	.108		
14					.125		.1515
15					.1279		.1509
16	.1102	.2241		.1104	.144		.1612
17	.1252	.1875		.1268	.1658		.1579
18	.168	.2195					
19	.1867	.2768					
20	.2374	.2701			.2422		
21	.2614	.2534					
22	.2241	.237			.1808		
23	.2241	.2202	.1867	.1886	.1698		.1429
24	.1867	.1867	.1858	.1711	.1886	.1512	.1882
Max	.2614	.2768	.2261	.1886	.2422	.1861	.2241
Min	.0896	.1486	.1684	.0839	.108	.1512	.137
Avg	.1764	.2127	.1939	.1307	.1582	.1650	.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 206 / 11 KV RAGHUCHIWADI GAOTHAN

GAOTHAN FEEDER

FEE Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0648	.0699				.0502
2		.0648	.0525				.0503
3		.0732	.0526		.081		.0503
4		.0829	.0703				.0508
5		.081	.0707			.0548	.0514
6		.0815	.0709			.0549	.0687
7		.0772	.0707			.0706	.0668
8		.0934	.0533		.0701		.0484
9					.0671		.0509
10	.0514				.0648		.0663
11	.052			.0325			.0636
12				.0455	.0747		.064
13				.0592	.0819		
14					.0781		.064
15					.0795		.0643
16	.0512	.0693		.0502	.0762		.0633
17	.0677	.0862		.0662	.0794		.0618
18	.0934	.0835					
19	.1307	.0819					
20	.0934	.0995			.0872		
21	.0678	.0835					
22	.1086	.0861			.0633		
23	.1086	.0865	.0683	.0747	.065		.0497
24	.0747	.0841	.0693	.0517	.0747	.0516	.048
Max	.1307	.0995	.0709	.0747	.0872	.0706	.0687
Min	.0512	.0648	.0525	.0325	.0633	.0516	.048
Avg	.0818	.0811	.0649	.0543	.0745	.0580	.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 207 / 11 KV WALGUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.1327				.1316
2		.1187	.133				.1319
3		.1195	.1331		.1524		.132
4		.151	.1331				.1509
5		.1509	.1517			.1495	.1698
6		.1509	.1704			.1704	.1888
7		.168	.1698			.1517	.171
8		.1562	.15		.1867		.1523
9					.1505		.1319
10	.11				.0868		.1294
11	.1138			.1035	.1494		.1307
12				.1048	.1494		.1199
13				.0908	.1379		.112
14					.1215		.104
15					.124		.0995
16	.112	.1267			.1235		.0972
17	.1084	.1463			.1276		.0995
18	.0747	.165					
19	.1267	.1675			.1515		
20	.168	.1867			.1842		
21	.1357	.1696					
22	.1017	.1698			.15		
23	.1494	.1515	.1331	.1267	.1311		.1141
24	.1143	.1005	.1331	.0951	.1715	.0754	.1315
Max	.168	.1867	.1704	.1267	.1867	.1704	.1888
Min	.0747	.0972	.1327	.0908	.0868	.0754	.0972
Avg	.1195	.1468	.144	.1042	.1436	.1368	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 208 / 11 KV POHNER GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.1495				.132
2		.0914	.1494				.1134
3		.1097	.1295		.0892		.1137
4		.1107	.1481				.1327
5		.0972	.1491			.1521	.1324
6		.112	.168			.1698	.1485
7		.1135	.1498			.1515	.1463
8		.0943	.1315		.1494		.1424
9							.1294
10	.0917				.1267		.1111
11	.0919			.1315			
12				.1375	.0934		.0876
13				.0931	.0862		
14					.0848		.0687
15					.0843		
16	.0874	.1844		.1113			.0716
17	.0713	.1634		.091	.0984		.0693
18	.1086	.1646			.1006		
19		.1655			.1806		
20	.1307	.1867			.2092		
21	.1187	.1888					
22	.1017	.1704			.1859		
23	.112	.1711	.1483	.1468	.1643		.0747
24	.1494	.1086	.1521	.168	.1494	.1477	.1319
Max	.1494	.1888	.168	.168	.2092	.1698	.1485
Min	.0713	.0914	.1295	.091	.0843	.1477	.0687
Avg	.1063	.1378	.1475	.1256	.1287	.1553	.1129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 201 / 11 KV BEMBALI GAOTHAN SINGLE PHASING
FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5935	.8573	.6668	.724	.6783	.4382
2	.6668	.5935	.8192		.6668	.7122	.4572
3	.6668	.6443	.8573	.6287	.6097	.7122	.4191
4	.6668	.6783	.8192	.5716	.6287	.7461	.4763
5	.724	.6783	.8573	.5716	.6287	.7461	.4572
6	.724	.6783	.8573	.6097	.6668	.7461	.4763
7	.724	.6443	.743	.6287	.6668	.763	.4954
8	.724	.6104	.6859	.6668	.5716	.763	.4763
9	.6668	.6859	.7049	.6668	.5335	.6668	.4382
10	.5716		.6859	.4001	.5335	.6668	.4748
11	.5087		.6478	.4572	.4239	.4763	.5426
12	.407		.4954	.4763	.39	.4954	.6274
13	.4239		.4954	.4763	.39		.6274
14	.4239		.4954	.4763	.3561	.4763	.6443
15	.4239		.4954	.4763	.3391	.4954	.6443
16	.4239	.6478	.4954	.5335	.3391	.4763	.6783
17	.4409	.6287	.5335	.5716		.4001	.7122
18	.4578	.6668	.5716	.6097	.5087	.6668	.7291
19	.4578	.7049	.6478	.724	.6443	1.0288	.763
20	.6783	.6859	.6859		.6783	1.0479	.78
21	.8478	.6287	.6668		.763	1.0288	.8139
22	.763	.9907			.8478	.9717	.8648
23	.7122	.8954	.6668		.763	.8764	.763
24	.8002	.6783	.8383	.6668	.7621	.6783	.4572
Max	.8478	.9907	.8573	.724	.8478	1.0479	.8648
Min	.407	.5935	.4954	.4001	.3391	.4001	.4191
Avg	.6111	.6852	.6793	.5726	.5842	.7095	.5940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 202 / 11KV BORKHEDA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 203 / 11 KV Ambewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 205 / 11 KV Ambewadi GaothAn
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0509	.0572	.0572	.0572	.0509	.0572
2	.0572	.0509	.0572		.0572	.0678	.0572
3	.0572	.0339	.0572	.0572	.0572	.0848	.0572
4	.0572	.0509	.0572	.0572	.0762	.0848	.0572
5	.0762	.0678	.0572	.0762	.0953	.0848	.0762
6	.0953	.0678	.0762	.0953	.0953	.0678	.0953
7	.0953	.0678	.0953	.0953	.0953	.0678	.0953
8	.0953	.0509	.0762	.0762	.0953	.0678	.0762
9	.0953	.0572	.0572	.0762	.0762	.0572	.0762
10	.0762		.0572	.0762	.0572	.0191	.0509
11	.0339		.0572	.0572	.0509	.0191	.0509
12	.0339		.0381	.0572	.0339	.0191	.0509
13	.0339		.0381	.0572	.0339		.0509
14	.0339		.0381	.0572	.0339		.0509
15	.0339		.0381	.0572	.0339	.0191	.0509
16	.0339	.0572	.0381	.0572	.0339	.0191	.0509
17	.0509	.0381	.0381	.0572	.0339	.0191	.0678
18	.0678	.0572	.0572	.0572	.0509	.0572	.0678
19	.0678	.0762	.0762	.0953	.0678	.0953	.0678
20	.0848	.0953	.0953		.0848	.0953	.0678
21	.0848	.0953	.0762		.0848	.0762	.0509
22	.0848	.0762	.0762		.0678	.0762	.0509
23	.0678	.0572	.0762		.0678	.0572	.0509
24	.0762	.0678	.0572	.0572	.0572	.0509	.0572
Max	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Min	.0339	.0339	.0381	.0572	.0339	.0191	.0509
Avg	.0646	.0621	.0604	.0672	.0624	.0571	.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 206 / 11KV NEW MAHADEVWADI AG. SINGLE PHASING
FEEDE Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.017	.0191			.017	.8954
2		.017	.0191			.017	.9145
3		.017	.0191			.017	.8954
4		.017	.0191			.017	.9335
5		.017	.0191			.017	.9526
6		.017	.0191			.017	1.1241
7		.017	.0191			.017	1.2384
8		.017	.0191			.017	1.3146
9			.0191			.0191	.9907
10				.8573		1.2765	
11				.9145	1.0174	1.2765	
12			1.6194	.9526	1.1191	1.3717	
13	1.3565		1.6194	1.0479	1.1191	1.4289	.017
14	1.4413		1.7147	1.2384	1.153	1.4098	.017
15	1.5261		1.7147	1.3336	1.1869	1.4289	.017
16	1.5261	2.0005	1.7147	1.3336	1.1869	1.4289	.017
17	1.4413	2.0386	1.6194	1.2384	1.1869	1.448	.017
18	1.3565	2.0195	1.6194	.0191	.017	.0191	.017
19	1.3735	1.7909		.0191	.017	.0191	.017
20	.017	1.6575			.017	.0191	.017
21	.017	1.4861	.0191		.017	.0191	.017
22	.017	.0191			.017	.0191	.017
23	.017	.0191			.017	.0191	.017
24		.017	.0191			.017	.8573
Max	1.5261	2.0386	1.7147	1.3336	1.1869	1.448	1.3146
Min	.017	.017	.0191	.0191	.017	.017	.017
Avg	.9172	.6579	.6573	.8955	.6209	.4732	.4906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 207 / 11 KV VTTHALWADI AG SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5716	.3391	
2	.7621	.5935	.7621		.5716	.3391	
3	.8573	.6783	.8573		.7049	.3391	
4	.9145	.7122	.9145			.3391	
5	.9526	.7969	.9526			.3391	
6	.9526	.8987	1.1241			.3391	
7	1.0479	1.0174	1.2384			.4239	
8	1.0479	1.1022	1.2384			.5087	
9	1.0479	1.0098	1.2003	.381		.8954	
10	1.1431		1.3527				.6783
11	1.5769		1.3336				.0848
14							.8478
15							.9496
16							.9496
17							.8478
20					.2543		.9496
21					.3052		
22					.3391		
23					.3391		
24					.381	.3391	
Max	1.5769	1.1022	1.3527	.381	.7049	.8954	.9496
Min	.7621	.5935	.7621	.381	.2543	.3391	.0848
Avg	1.0303	.8511	1.0974	.381	.4334	.4202	.7582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 201 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2915	.8907	1.2146	
16				1.3279
24		.7125	.8097	
Max	.2915	.8907	1.2146	1.3279
Min	.2915	.7125	.8097	1.3279
Avg	.2915	.8016	1.0122	1.3279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 203 / 11 KV BAMNI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.1862	2.3663	1.4251	1.4737	1.9109
Max	2.1862	2.3663	1.4251	1.4737	1.9109
Min	2.1862	2.3663	1.4251	1.4737	1.9109
Avg	2.1862	2.3663	1.4251	1.4737	1.9109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194039 / 33/11 KV Patoda

Feeder No / Name : 201 / 11 KV PATODA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194039 / 33/11 KV Patoda

Feeder No / Name : 203 / 11 KV PATODA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194039 / 33/11 KV Patoda

Feeder No / Name : 206 / 11 KV NANDURGA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194047 / 33 KV WADGAON (S)

Feeder No / Name : 201 / 11 KV NEW WADGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8322	1.6032
10		1.186		
11		1.2334		
12		1.2018		
13		1.1702		
14		1.0595		
15		1.186		
16		1.2176	1.4737	
24	.4049			1.166
Max	.4049	1.2334	1.4737	1.6032
Min	.4049	1.0595	.8322	1.166
Avg	.4049	1.1792	1.1530	1.3846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194047 / 33 KV WADGAON (S)

Feeder No / Name : 202 / 11 KV PALASWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8		1.4506	.4858
11	1.2191		
12	.2623		
13	.2932		
14	.2623		
16	.3086		
24			.3887
Max	1.2191	1.4506	.4858
Min	.2623	1.4506	.3887
Avg	.4691	1.4506	.4373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194047 / 33 KV WADGAON (S)

Feeder No / Name : 203 / 11 KV BAVI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6127			.5624	.9465
9			.5573		
11			.4201		
12			.5049		
13			.4382		
14			.4115		
15			.4127		
16			.5083	.743	
24	.4146	.7621			.583
Max	.6127	.7621	.5573	.743	.9465
Min	.4146	.7621	.4115	.5624	.583
Avg	.5137	.7621	.4647	.6527	.7648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 201 / 11 KV RUIBHAR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0678			1.0974		
2		1.6842			1.2803		
3		1.7974			1.3413		
4		1.7974			1.3413		
5		1.8442					
6		1.7985					
7	1.0669	2.3739					
8		2.13		1.1385		1.5223	
9		2.0317	2.2348			1.5729	1.012
10	1.2887			.884			
11	1.4922			.9145			
12	1.0513			.945			
13	1.0852			.945			
14	1.0852			.8993			
15	1.0159			.9145			
16	1.2548			.945	1.0852		1.7295
17	1.1797			.9755			
18	1.2209						
19	1.1869						
20	.0848			.061			
21	.0848			.061			
22	.0848			.061			
23	.0678			.061			
24		.0678		.0995	.823	.9156	
Max	1.4922	2.3739	2.2348	1.1385	1.3413	1.5729	1.7295
Min	.0678	.0678	2.2348	.061	.823	.9156	1.012
Avg	.8833	1.5593	2.2348	.6361	1.1614	1.3369	1.3708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 202 / 11 KV EXPRESS FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.2035					
2		.1966					
3	.1219	.1017					
4	.2134	.0972					
5	.2134	.0983					
6	.1829	.0983					
7	.1981	.1966					
8	.2134	.2035		.1581		.1989	
9	.2134	.2035	.1638			.2267	.1989
10	.1966			.1219			
11	.0983			.1219			
12	.1017			.1219			
13	.1017			.1524			
14	.1017			.0762			
15	.0983			.1677			
16	.0972			.1524	.0972		.1696
17				.1524			
18	.1017						
19	.1357						
20	.2321			.0914			
21	.2294			.0914			
22	.2294			.0914			
23	.2267						
24	.1981	.1989		.2012		.1943	
Max	.2321	.2035	.1638	.2012	.0972	.2267	.1989
Min	.0972	.0972	.1638	.0762	.0972	.1943	.1696
Avg	.1649	.1598	.1638	.1308	.0972	.2066	.1843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 203 / 11 KV Ruibhar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263				.2263		
2	.2241				.2241		
3	.2241				.2241		
4	.2218				.2614		
5	.3696				.3326		
6	.3696				.3696		
7	.3326				.4024		
8	.3292	.2622		.3326	.3658	.2987	
9	.2957	.1867	.2957	.2926		.2561	.2561
10	.1867			.2218			
11	.1867			.197			
16	.1867			.2534	.2241		.1867
17				.2534			
18				.2587			
19				.362			
20				.4024			
21				.3734			
22				.2957			
23				.2263			
24	.2286	.2172		.2218	.2286	.2561	
Max	.3696	.2622	.2957	.4024	.4024	.2987	.2561
Min	.1867	.1867	.2957	.197	.2241	.2561	.1867
Avg	.2601	.2220	.2957	.2839	.2859	.2703	.2214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 201 / 11 KV Ambejawalge Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0572		.3201
2	.0652	.0572	.0762		.0572		.3201
3	.0652	.0572	.0762		.0572	.066	.3201
4	.0057	.0572	.0762				.3201
5	.0419	.0572	.0762				.4001
6	.0431	.0572	.0762				.4001
7	.0335						.4801
9							.6081
10					.2263	.594	
12	1.1142						
13	1.2193		1.2803				
14	1.2041						
15	1.2498		1.2803	.2629			
16	1.2498	1.4095	1.2803				
17	1.2498	1.5126	1.3123	.3932			
18	1.2654	1.3614	1.2003				
19	.9389	1.2707	1.1203				
20							.0762
21							.0762
22							.0762
23							.0762
24				.8383	.0572	.0655	.3201
Max	1.2654	1.5126	1.3123	.8383	.2263	.594	.6081
Min	.0057	.0572	.0762	.2629	.0572	.0655	.0762
Avg	.6961	.6489	.7141	.4981	.0910	.2418	.2918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 202 / 11 KV Ghatangri Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0549	.1524		.3064		.0762
2	1.8212	1.4327	1.3049		.3064		.0762
3	1.8149	1.6461	1.3969		.3064		.0762
4	1.8149	1.6461	1.5318			.9831	.0762
5	2.6398	1.7071	1.5642				.0762
6	2.7404	1.89	2.1024				.0762
7	2.3099	2.284	2.5667			.33	.0762
8	2.4291	2.3148	2.4787				
9	2.7062		2.2032		.3319	1.1219	
10	2.6398						.8732
11	2.1948		2.0805				1.1309
12							.4572
13							1.1987
14							1.166
15							.1678
16							1.2195
17							1.2507
20	.0823	.1524		.0572			
21	.0854	.1524		.0572			
22	.0716	.1524		.0572			
23	.0716	.1524		.0572	.0662		
24		.0854	.1524		.2808	.6744	.0762
Max	2.7404	2.3148	2.5667	.0572	.3319	1.1219	1.2507
Min	.0716	.0549	.1524	.0572	.0662	.33	.0762
Avg	1.6730	1.0516	1.5940	.0572	.2664	.7774	.5046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 203 / 11 KV Sonegaon Ag. SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0255				.0381		.6554
2	.0213	.0381	.0381		.0381		.6554
3	.0328	.0381	.0381		.0381	.0338	.6554
4	.033	.0381	.0381				.6554
5		.0381	.0381				.8192
6		.0381	.0381				.8192
7	.0326						.8192
8	.033						.7373
9							.7373
10					.3814		
12	1.1142		.3277				
13	1.5546		1.3108				
14	1.4632						
15	1.5729		1.3108				
16	1.5729	1.6251					
17	1.5729	1.702	.6554	.4161			
18	1.6842	1.6921	1.5565				
19	1.5043	1.4688					
20	.1524						.0381
21							.0381
23				.8383			.0381
24					.0381	.0328	.6554
Max	1.6842	1.702	1.5565	.8383	.3814	.0338	.8192
Min	.0213	.0381	.0381	.4161	.0381	.0328	.0381
Avg	.8247	.7421	.5352	.6272	.1068	.0333	.5633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 204 / 11 KV Ambejawalga Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1126	.112	.132		.112
2	.132	.132	.1129		.132		.112
3	.1305	.132	.1133		.132	.1305	.112
4	.1688	.1509	.1137				.1307
5	.198	.1698	.1126			.165	.1494
6		.1886	.1863				.1867
7		.1867	.1852			.231	.2241
8	.2936	.168	.1478				.1867
9	.165		.1469			.165	.1494
10	.099				.1886	.1296	.1047
11	.0747		.0373	.1021			.1093
12	.1097		.112				.0732
13	.0924		.112				.0742
14	.1097		.112				.11
15	.1097		.112	.0732			.1077
16	.1097	.1439	.1307	.0762			.1092
17	.128	.1779	.1307	.1475			.1056
18	.128	.1768	.1494	.1823			.141
19	.1612	.1764	.2241	.2204			.0693
20	.2195	.2499		.1791			.1799
21	.1829	.2193	.0747	.1791			.1846
22	.1663	.1489	.0747	.168			.1867
23	.1307	.1491	.0747	.1307	.132		.151
24	.099	.1307	.1495	.112	.132	.135	.112
Max	.2936	.2499	.2241	.2204	.1886	.231	.2241
Min	.0747	.1307	.0373	.0732	.132	.1296	.0693
Avg	.1427	.1666	.1239	.1402	.1414	.1594	.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 205 / 11 KV Ghatangri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1028	.0943	.066	.0716	.0564		.0709
2		.0943	.0705		.0564		.0709
3	.132	.1132	.0711		.0564	.1013	.0709
4	.165	.1132	.0719				.0709
5	.165	.1509	.1089			.1305	.1063
6	.1638	.168	.1491			.1305	.1791
7	.165	.168	.1848				.1433
8	.1631	.112	.1117				.1075
9	.1638		.0739		.0791	.1078	.0716
10	.0662			.0716	.081	.099	.0716
11	.0549		.0532				.0617
12	.0347		.0354	.0372			.062
13	.0537		.0354	.0533			.0618
14	.0709		.0354	.0533			.061
15	.0686		.0532	.0556			.0587
16	.0693	.07	.0709	.0671			.0703
17	.0857	.0697	.0709	.0762			.0762
18	.1029	.104	.1075	.1355			.0697
19	.1448	.1085	.1791	.1389			.1158
20	.1463	.1341		.1429			.1513
21	.128	.1224		.1036			.1094
22	.1052	.1143	.0716	.1			.0817
23	.0894	.0895	.0716	.0714	.099		.0828
24	.099	.1132	.0928	.0716	.0564	.0979	.0886
Max	.165	.168	.1848	.1429	.099	.1305	.1791
Min	.0347	.0697	.0354	.0372	.0564	.0979	.0587
Avg	.1104	.1141	.0850	.0833	.0692	.1112	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 206 / 11 KV Sonagaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0943	.1077	.0724	.0164	.0652	.0362
2	.099	.0943	.0729		.0164		.0362
3	.1324	.0943	.0737		.0164		.0362
4	.1311	.132	.0738			.066	.0362
5	.165	.168	.1126				.0543
6	.0264	.2241	.2261				.0549
7	.2035	.2241	.225			.066	.0549
8	.165	.2054	.1867				.0549
9	.132		.1093		.0158	.0652	.0366
10	.0979				.0162		.0357
11	.0732		.0549				.0351
12	.0732		.0362				.0356
13	.052		.0543				.0361
14	.0514						.0355
15	.0537		.0543				.0354
16	.0537	.1065	.0724				.0366
17	.0716	.0709	.0724	.0152			.0368
18	.0914	.1072	.1448	.016			.0364
19	.1646	.1456	.181	.0297			.0706
20	.1494	.2177		.0297			.1064
21	.1494	.1778		.0297			.072
22	.1029	.1038	.0724				.0722
23	.0838	.1049	.0724	.0164	.066		.0727
24	.0098	.0943	.1055	.0724	.0164	.066	.0362
Max	.2035	.2241	.2261	.0724	.066	.066	.1064
Min	.0098	.0709	.0362	.0152	.0158	.0652	.0351
Avg	.1013	.1391	.1054	.0352	.0234	.0657	.0481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-STATION

Feeder No / Name : 201 / 11 KV CHILWADI AGRL.

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	1.173	1.4362	
23			.3658
Max	1.173	1.4362	.3658
Min	1.173	1.4362	.3658
Avg	1.173	1.4362	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-STATION

Feeder No / Name : 202 / 11KV WALGUD AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-18
HR	Load (MW)
16	.8498
Max	.8498
Min	.8498
Avg	.8498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-STATION

Feeder No / Name : 203 / 11KV CHILWADI GAOTHAN
FEEDER Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2257	.2343	.2343	
16	.1081	.1442		
23	.1262	.1442		
24	.1264	.1262	.1442	.0762
Max	.2257	.2343	.2343	.0762
Min	.1081	.1262	.1442	.0762
Avg	.1466	.1622	.1893	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 202 / 11 KV NEHARU CHOWK FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9945	.9774	.9602	.8745	.9088	.9774	.7202
16	1.0288	.9431	1.1317	.8916	1.0288	.9602	.9431
19	1.2174			1.2517		1.1831	
20		1.2346			1.2517		
23	1.0802	.9431	1.1317	1.0288		.9945	.9945
24	1.046	1.0117	1.0974	1.0631	.9602	.8916	.8573
Max	1.2174	1.2346	1.1317	1.2517	1.2517	1.1831	.9945
Min	.9945	.9431	.9602	.8745	.9088	.8916	.7202
Avg	1.0734	1.0220	1.0803	1.0219	1.0374	1.0014	.8788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 203 / 11KV DARGA FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1317	1.0802	1.2003	.9259	1.0974	1.0974	1.1317
16	1.1317	1.1317	1.2174	1.0631	1.0974	1.2003	1.166
19	1.3032			1.2174		1.3032	
20		1.5089			1.3546		
23	1.3546	1.3717	1.3375	1.2517	1.1317	1.1831	1.3032
24	1.2689	1.3032	1.286	1.2517	1.1831	1.1145	1.1317
Max	1.3546	1.5089	1.3375	1.2517	1.3546	1.3032	1.3032
Min	1.1317	1.0802	1.2003	.9259	1.0974	1.0974	1.1317
Avg	1.2380	1.2791	1.2603	1.1420	1.1728	1.1797	1.1832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 204 / 11KV TER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0974	1.0631	1.046	.4458	.9945	1.0288	1.046
16	.8059	.7888	.7716	.7202	.7202	.6001	.5658
19	.9602			.9602		.9259	
20		1.2003			1.1145		
23	.8059	.8402	.7888	1.5175	.703	.7373	.7888
24	.8059	.7545	.7716	.7545	.7202	1.406	.6859
Max	1.0974	1.2003	1.046	1.5175	1.1145	1.406	1.046
Min	.8059	.7545	.7716	.4458	.703	.6001	.5658
Avg	.8951	.9294	.8445	.8796	.8505	.9396	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 205 / 11KV UPLA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0802	1.1488	1.2517	1.1488	1.1145	1.046	1.0631
11					1.0288		
16	1.2346	1.1317	1.2346	1.0117		1.0117	1.0117
19	1.3032			1.3032		1.1145	1.2346
20		1.5089					
23	1.5089	1.5261	1.4575	1.3546		1.2003	1.3717
24	1.5775	1.406	1.4403	1.3889	1.2346	1.0974	1.1317
Max	1.5775	1.5261	1.4575	1.3889	1.2346	1.2003	1.3717
Min	1.0802	1.1317	1.2346	1.0117	1.0288	1.0117	1.0117
Avg	1.3409	1.3443	1.3460	1.2414	1.1260	1.0940	1.1626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 206 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.583	.5316	.583	.583	.5658	.5316	.5144
16	.4801	.6344	.4801	.4801	.4115	.4458	.4115
19	.6173			.6516		.5316	
20		.703			.6173		
23	.583	.583	.5144	.5658	.4801	.5144	.4801
24	.5144	.5144	.5658	.7402	.5144	.4287	.4458
Max	.6173	.703	.583	.7402	.6173	.5316	.5144
Min	.4801	.5144	.4801	.4801	.4115	.4287	.4115
Avg	.5556	.5933	.5358	.6041	.5178	.4904	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 209 / 11 kv New Shivaji Chouk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6632	1.5432	1.6804	1.6289	1.5432	1.4403	1.5432
16	2.0919	2.0576	2.1776	1.8176	1.7147	1.5432	1.8347
19	2.1262			2.4006		1.749	
20		2.2634			1.9547		
23	2.0576	2.0576	1.9033	1.7833	1.5775		1.8004
24	1.8519	1.7833	1.989	1.749	1.5432	1.4746	1.5089
Max	2.1262	2.2634	2.1776	2.4006	1.9547	1.749	1.8347
Min	1.6632	1.5432	1.6804	1.6289	1.5432	1.4403	1.5089
Avg	1.9582	1.9410	1.9376	1.8759	1.6667	1.5518	1.6718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 211 / New Collector Office
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0686	.0514	.0686	.0686	.0514	.0343	.0343
16	.2401	.2401	.2229	.2058	.1886	.0686	.2229
19	.12			.1029		.0514	
20		.12			.1543		
23	.0686	.0857	.0686	.0686	.0686	.0686	.0686
24	.0686	.0686	.0857	.0686	.0686	.0686	.0686
Max	.2401	.2401	.2229	.2058	.1886	.0686	.2229
Min	.0686	.0514	.0686	.0686	.0514	.0343	.0343
Avg	.1132	.1132	.1115	.1029	.1063	.0583	.0986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 201 / 11 KV MIDC _I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2286				
4	.1524						
6					.2286		
7		.1524					
8	.1524	.1905	.3048	.2286	.2477		
10				.3429			
11				.5103			
12	.2667		.5335	.381	.4954		
14		.3429			.2667		
16	.2667	.4191	.4191				
17			.4191				
18				.2667			
21				.2667			
24	.1524	.1524	.2286	.2286	.2286	.2286	.1143
Max	.2667	.4191	.5335	.5103	.4954	.2286	.1143
Min	.1524	.1524	.2286	.2286	.2286	.2286	.1143
Avg	.1981	.2515	.3556	.3178	.2934	.2286	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 202 / 11 KV DNYANESHWAR TEMPLE SHEDDABLE URBAN
TOWN Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7528				
2					1.3717		
4	1.5242						
6					1.2955		
7		1.5242					
8	1.448	1.5242	1.5242	1.5242	1.2955		
10				1.5242			
12	1.7147		1.7528	1.5242	1.2574		
14		1.7147			1.2955		
16	1.7147	1.829	1.7909				
18				1.6004			
21				1.7909			
24	1.7528	1.829	1.829	1.829	1.5242	1.5242	1.4861
Max	1.7528	1.829	1.829	1.829	1.5242	1.5242	1.4861
Min	1.448	1.5242	1.5242	1.5242	1.2574	1.5242	1.4861
Avg	1.6309	1.6842	1.7299	1.6322	1.3400	1.5242	1.4861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 204 / 11KV MIDC -II FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381				
4	.3048						
6					.2667		
7		.2286					
8	.3048	.3048	.381	.2286	.3048	.3048	.4572
10				.4191			
12	.2286			.3048	.5335		.6287
13			.7049				
14		.4954					
16	.2286	.5716	.5716		.4763	.6478	.5716
18				.3048			
21				.3048			
23							.3048
24	.381	.2286	.381	.3429	.3048	.3048	.3048
Max	.381	.5716	.7049	.4191	.5335	.6478	.6287
Min	.2286	.2286	.381	.2286	.2667	.3048	.3048
Avg	.2896	.3658	.4839	.3175	.3772	.4191	.4534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 205 / 11 KV AMBEJAWALAGA AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6668				
2					.5335		
4	.6287						
6					.5144		
7		.0953					
8		.6287	.6478	.6097	.5335	.6097	.5335
9	.6097						
10				.6097			.4572
12	.6287		.5716	.4572	.381		.4382
14		.6097					
16	.6668	.6287	.6097		.4191	.5144	.4763
18				.5335			
21				.6287			
23							.4954
24	.7049	.6859	.6859	.6668	.5716	.6097	.5335
Max	.7049	.6859	.6859	.6668	.5716	.6097	.5335
Min	.6097	.0953	.5716	.4572	.381	.5144	.4382
Avg	.6478	.5297	.6364	.5843	.4922	.5779	.4890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 206 / 11 KV CKT HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0953				
4	.0572						
6					.0762		
7		.0953					
8	.0762	.0953	.0953	.0762	.0762	.0762	.0953
10				.0762			
12	.0953		.1143	.0953	.0572		.0762
13				.141			
14		.0762					
16	.0953	.0762	.0762		.1143	.1143	.0572
18				.1334			
21				.0953			
23							.0953
24	.0953	.0953	.0953	.0762	.0762	.0762	.0953
Max	.0953	.0953	.1143	.141	.1143	.1143	.0953
Min	.0572	.0762	.0762	.0762	.0572	.0762	.0572
Avg	.0839	.0877	.0953	.0991	.0800	.0889	.0839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 207 / 11KV EXPRESS UPALA WW
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.0762
4	.0762		
7		.0762	
8	.0762	.0762	.0762
12	.2286		.0762
14		.0762	
16	.0762	.0762	
24	.0762	.0762	
Max	.2286	.0762	.0762
Min	.0762	.0762	.0762
Avg	.1067	.0762	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 201 / 11 KV wadaga Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0448	.0518	.0389	.9393	.63	.7806	.0324
2	.8802		.3644	.6251	.5571	1.1336	.0291
3	.909	.9214	.4615	.6316	.583	1.1498	.0356
4	.9263	1.0105	.9959	.6931		1.0089	.0453
5	.9295	.97	1.1352	.6802		1.1028	.0551
6	.9862	1.0931	1.2777	.7223		.915	.0583
7		1.1939	1.3123			.8194	.0421
8	1.2146	1.2988	1.1984			.9069	.0389
9			1.2729		.5953	.8583	
10	1.1368		1.2696	.0065	.0356	.0288	
11	1.0274		1.234	.0032	.0356	.0259	
12	.0224		.0389			.0291	
13	.0192		.0324			.0291	
14			.0421				
15	.0192		.0356	.0032			
16	.0224	.0227	.0453			.0227	1.0267
17	.0224	.0227	.0486		.0291	.0324	1.0073
18			.0583		.0324	.0453	.0256
19	.0583	.0583	.068		.0356	.0518	.0324
20	.081	.0583	.0648	.0576	.0421	.068	.0453
21	.0608	.0615	.0583	.0486	.0421	.0486	.0384
22	.0576	.0421	.0486	.032	.0336	.0356	.0324
23	.0567	.0518	.0453	.0356	.0324	.0324	.0384
24	.0512	.0768	.0453	.9101	.7741	.6883	.0324
Max	1.2146	1.2988	1.3123	.9393	.7741	1.1498	1.0267
Min	.0192	.0227	.0324	.0032	.0291	.0227	.0256
Avg	.4263	.4622	.4663	.3849	.247	.4461	.1539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 202 / 11 KV Express WW

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.025	.024	.0016	.0223	.0014	.0014	.0223
2	.025	.0014	.0014	.0012	.0027	.0014	.0223
3	.0264	.0014	.0014	.0012	.0014	.0014	.0223
4	.0236	.0014	.0014	.0037		.0254	.0235
5	.0014	.0254	.0014	.0025		.0282	.0198
6	.0014	.0219	.0254	.0012		.0254	.0211
7		.024	.0226	.0248		.024	.0211
8	.025	.0226	.0226	.0223		.024	.0235
9			.0226		.0014	.024	
10	.0254		.0223	.0268	.0149	.0014	
11	.024		.0211	.0254	.0173	.0014	
12	.0014		.0025	.0254	.0198	.0028	
13	.0233		.0012	.024	.0223	.0027	
14	.0014		.0223		.0235		
15	.0014		.0235		.0211		
16	.0014	.0014	.0248	.0233		.0211	.0014
17	.0014	.0014	.0223	.0219	.0254	.0223	.0254
18	.0014		.0012	.0261	.0032	.0235	.0254
19	.0014	.0254	.0012	.0261	.0028	.0235	.0028
20	.0268	.0268	.0223	.0233	.0282	.0012	.0028
21	.0304	.0268	.0235	.0247	.0168	.0025	.0282
22	.0268	.0268	.0211	.0014	.0254	.0235	.0254
23	.024	.0268	.0223	.0027	.0028	.026	.024
24	.0278	.0268	.0268	.0235	.0028	.0014	.0198
Max	.0304	.0268	.0268	.0268	.0282	.0282	.0282
Min	.0014	.0014	.0012	.0012	.0014	.0012	.0014
Avg	.0157	.0178	.0150	.0168	.0130	.0140	.0195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /
STATION

Feeder No / Name : 401 / 33 KV OSMANABAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	7.0988	6.7387		6.07	6.4301	6.2757	6.1728
16	7.2531		7.7161	6.3272	6.2243	5.8642	6.5329
19	8.0761			7.8189		7.1502	
20					8.0247		
23	7.8704		7.5103	6.9959	6.4301	6.4815	6.8416
24	7.6132	7.3045		7.2531	6.4815	6.07	6.1728
Max	8.0761	7.3045	7.7161	7.8189	8.0247	7.1502	6.8416
Min	7.0988	6.7387	7.5103	6.07	6.2243	5.8642	6.1728
Avg	7.5823	7.0216	7.6132	6.8930	6.7181	6.3683	6.4300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /
STATION

Feeder No / Name : 407 / 33 kV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.2007				
6					2.4006		
7		3.4294					
8	2.8578	2.915	4.3439	3.4294	2.572	3.4294	2.6863
10				2.9721			
12	3.0293		3.7723		2.572		2.5149
14		3.315					
16	3.0293	3.6008	3.4865		2.915		4.1152
18				2.8578			
21				3.0864			
23							2.8578
24	3.1436	3.4294	3.315	3.4294	3.4294	3.4294	2.572
Max	3.1436	3.6008	4.3439	3.4294	3.4294	3.4294	4.1152
Min	2.8578	2.915	3.2007	2.8578	2.4006	3.4294	2.5149
Avg	3.015	3.3379	3.6237	3.1550	2.7778	3.4294	2.9492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 201 / PARANDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.56			1.3146		
2	1.6126	1.5424			1.2971	1.262	
3	1.5775	1.5249			1.2795	1.2445	
4	1.595	1.5074			1.262	1.2269	
5	1.6301	1.4899	1.4899	1.2971	1.2445	1.2269	
6	1.595	1.4723	1.5249	1.2445	1.1919	1.1218	
7	1.5775	1.4548	1.5424	1.1919	1.3146	1.2795	1.3496
8	1.6301	1.5424	1.595	1.1744	1.262		1.4198
9	1.6651	1.5775	1.5775	1.1744	1.262	1.3496	1.3672
10	1.56	1.6126	1.6301	1.3847	1.3672	1.4022	1.4723
11	1.6476	1.6827	1.7528		1.3496	1.4723	1.4723
12	1.7353	1.7703	1.7703		1.5074	1.5249	1.5775
13	1.7703	1.7703	1.6651	1.5424	1.6301	1.5249	1.4198
14	1.7703	1.7177	1.7528		1.5424	1.5074	
15	1.7528	1.6827	1.6651	1.2971	1.4198	1.4899	1.4198
16	1.7703	1.595	1.7528		1.4899	1.5249	1.4373
17	1.7177	1.6827	1.8054	1.3672	1.3672	1.4723	1.4548
18	1.6301	1.8054	1.8054		1.4899	1.4198	1.595
19	1.6827	1.858	1.9281	1.6126	1.5424	1.6827	1.6827
20	1.893	1.9281	1.9631		1.595	1.7002	1.8229
21	1.8054	1.7703	1.858	1.595	1.56	1.6827	1.7353
22	1.7353	1.8229			1.4899		
23	1.6827	1.7177		1.4198	1.4022		
24	1.7002	1.4575	1.6476	1.595	1.3847	1.2971	
Max	1.893	1.9281	1.9631	1.6126	1.6301	1.7002	1.8229
Min	1.56	1.4548	1.4899	1.1744	1.1919	1.1218	1.3496
Avg	1.6827	1.6477	1.7070	1.3766	1.3986	1.4206	1.5162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 202 / LONI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0754			.0943		
2	.0943	.0754			.0943	.0754	
3		.0754			.0943	.0754	
4	.0754	.0754			.0943	.0943	
5	.0754	.0754	.0686		.132	.1132	
6	.132	.132	.12		.132	.132	
7	.4049	.421	.3286		.2429	.253	
8	.421	.4049	.3715		.2143		
9	.4372	.4534	.3858		.2143	.3005	.2715
10	.3479	.4001	.427		.2143	.2715	.3637
11	.3321	.4001	.427	.2429	.2143	.2572	.3163
12	.3321	.3858	.4111		.2	.2858	.3163
13							.3163
19		.1029	.0943		.12	.1132	
20	.12	.1543	.1509		.132	.1509	.1698
21	.1372	.12	.1509	.1509	.1509	.1509	.1509
22	.1132	.1029			.132		
23	.0943	.0857		.1132	.1132		
24	.0943	.0754	.0686		.0943	.0943	
Max	.4372	.4534	.427	.2429	.2429	.3005	.3637
Min	.0754	.0754	.0686	.1132	.0943	.0754	.1509
Avg	.2066	.2009	.2504	.169	.1491	.1691	.2721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 203 / WAGEGAVAN SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6032	1.4899			1.4575		
2	1.6032	1.5384			1.4737	1.5565	
3	1.6032	1.587			1.5061	1.6057	
4	1.6356	1.6356			1.5384	1.6712	
5	1.668	1.7004	2.1538	1.1822	1.6032	1.7859	
6	1.7976	1.7814	1.749	1.1822	1.5223	1.8679	
7	1.1336	.9878	1.1012	.4534	.7449	.6964	
8	1.1203	1.085	1.1498	.4858	.6802		
9	1.1203	1.085	1.1336	.502	.6154	.7537	
10	1.0814	1.1174	1.1305	.5668	.664	.7287	
11	1.1305	1.1012	1.0978	.5992	.5992	.7537	
12	1.0322	1.0688	1.6549		.6478	.7125	
13	1.6221	1.4575	1.7695	.7287	1.2631	.9393	1.2289
14	1.5074	1.4737	1.7532		1.2793	1.004	
15	1.6385	1.3117	1.7859	.8421	1.3927	1.0526	1.2944
16	1.7695	1.3279	1.6712		1.3279	.9878	1.2944
17	1.7004	1.3117	1.6712	.9069	1.3765	1.004	1.2146
18	1.5708	1.2631	1.7204		1.2955	.9555	1.166
19	1.247	1.668	1.3272	1.262	.9878	1.1984	.9555
20	1.2955	1.7166	1.2289		.9339	1.1984	.9555
21	1.2631	1.668	1.2125	1.0526	.9175	1.1336	.9231
22	1.2146	1.5384			.9175		
23	1.1498	1.6194		.9393	.8848		
24	1.5708	1.1174	1.6518	1.0688	.9555	.8848	
Max	1.7976	1.7814	2.1538	1.262	1.6032	1.8679	1.2944
Min	1.0322	.9878	1.0978	.4534	.5992	.6964	.9231
Avg	1.4199	1.4021	1.4979	.8409	1.1077	1.1245	1.1291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 204 / KHASAPURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8664	2.4291			1.7166		
2	2.8988	2.4486			1.6842	1.643	
3		2.4966			1.6518	1.6575	
4	2.5101	2.5446			1.6194	1.6907	
5	2.7368	2.6406	2.753		1.6032	1.7238	
9							2.2672
11							2.4034
12							2.4034
13							2.2874
14	2.42		2.8669			2.4615	
15	2.7349		3.2895		1.7976	2.4291	2.1216
16	2.8502	2.8826	3.2556		1.8785	2.3805	2.5194
17	2.672	2.7368	3.1352		2.0405	2.4291	
18	2.5587	2.7368	2.7664			2.3644	
19		1.3603	1.5415				
20	1.5546	1.8299	1.8351		.679	.7356	2.2186
21	1.5546	1.8299	1.7901	.6224	.5093	.6413	2.2186
22	1.5223	1.8138			.6602		
23	1.4899	1.7166		.5847	.6036		
24	2.2024	2.3805	2.2996	2.2834	1.6518	1.5415	
Max	2.8988	2.8826	3.2895	2.2834	2.0405	2.4615	2.5194
Min	1.4899	1.3603	1.5415	.5847	.5093	.6413	2.1216
Avg	2.3266	2.2748	2.5533	1.1635	1.3920	1.8082	2.3050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 205 / DONJA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.8299			.6413		
2	.8299	.8488			.679	.6413	
3		.8488			.7167	.679	
4	.9054	.8676			.7545	.7545	
5	.9808	.8865	.703		.811	.8676	
6	2.0405	2.6726	1.7004		1.3603	1.8233	
7	2.332	3.0445	1.8461		1.587	2.2211	
8	2.3805	3.1093	1.9757		1.5546		
9	2.4291	1.5708	2.0405		1.6842	2.2045	
10	2.304	1.6356	2.1548	.4534	1.6842	2.1376	
11	2.3371	1.5708	2.2542	.4534	1.6194	2.1376	
12	2.1548	1.5223	2.1216		1.6842	1.1822	
13	2.2708	1.4737	2.0222	.9717	1.587	1.2146	
15				1.0364			1.2763
16							1.3108
19	2.0729	2.1052	1.7901		1.6194	1.8785	
20	2.17	2.3967	2.1548		1.7072	1.9271	1.8138
21	2.1538	2.1376	1.989	1.4413	1.7238	1.7814	1.6194
22	1.8785	1.9433			1.5415		
23	1.7004	1.6518		1.1498	1.4091		
24	.8865	.811	.823	.703	.6602	.6979	
Max	2.4291	3.1093	2.2542	1.4413	1.7238	2.2211	1.8138
Min	.811	.811	.703	.4534	.6413	.6413	1.2763
Avg	1.8132	1.6804	1.8135	.887	1.3171	1.4765	1.5051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 206 / 11KV WATER SUPPLY EXPRESS NON SHEDDABLE WATER SUPPLY AND
FEED Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0168			.0503		
2	.0168	.0168			.0168	.0162	
3		.0168			.0168	.0162	
4	.0168	.0168			.0168	.0162	
5	.0168	.0168			.0168	.0162	
6	.0503	.0335	.016		.0168		.032
7	.0503	.0335	.032		.0503	.0701	.048
8	.0486	.0335	.048		.048		.064
9	.0671	.0671	.048		.048	.064	.064
10	.0486	.048			.048	.064	.0648
11	.0486	.064			.048	.064	.0648
12	.0486	.064	.0486		.048	.08	.0648
13	.0648	.048	.0486		.048	.08	.0648
14	.0648	.048	.0486			.08	
15	.0648		.0486		.032	.064	.0648
16	.0648	.048	.0486		.016	.064	.0648
17	.048	.048	.0486		.016	.0503	
18		.032	.0324			.0168	
19	.048	.048			.064	.0168	
20	.0164	.048			.0486	.0168	.0168
21	.0162			.0503	.0324	.0168	.0168
22	.0168				.0324		
23	.0335			.0503	.0162		
24	.0335	.0168			.0503	.0162	
Max	.0671	.0671	.0486	.0503	.064	.08	.0648
Min	.0162	.0168	.016	.0503	.016	.0162	.0168
Avg	.0417	.0382	.0425	.0503	.0355	.0436	.0525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 202 / 11 Kv Chinchpur AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	2.2005			
4	2.2005			
6			2.2005	
8	1.7604			1.0269
23		2.2005	1.9071	
24	2.2005			
Max	2.2005	2.2005	2.2005	1.0269
Min	1.7604	2.2005	1.9071	1.0269
Avg	2.0905	2.2005	2.0538	1.0269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 203 / 11 Kv Tandulwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
3			.0686
6		.0686	
23	.0686	.0686	
Max	.0686	.0686	.0686
Min	.0686	.0686	.0686
Avg	.0686	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 205 / 11 KV CHINCHPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1543			
3				.1543
4	.1698			
6	.2469		.1543	
23		.1543	.1543	
24	.2469			
Max	.2469	.1543	.1543	.1543
Min	.1543	.1543	.1543	.1543
Avg	.2045	.1543	.1543	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194099 / 33/11 kv DHAGPIMPARI SUB

STATI

Feeder No / Name : 201 / 11kv DHAGPIMPARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0686	.0514	.0857	.0514
2	.0514	.0514	.0514	.0857	.0514	.0686	.0514
3	.0514	.0686	.0514		.0514	.0514	.0514
4	.0514	.0857	.0514		.0514	.1029	.0686
5	.0686	.0857	.0514		.0514	.2229	.0857
6	.12	.1029	.0686			.2229	.0857
7	.3353	.3658	.442			.2439	.2439
8	.3506	.381	.3201			.2743	.2743
9	.3201	.4268	.3048			.3048	.3201
10	.3201	.3963	.3658			.2896	.3048
11	.2743	.3658	.3353			.2439	.3048
12		.4115	.3201		.2591	.2439	.2591
13		.4268	.3048		.3048	.2439	.2896
14		.3963	.2896	.2134	.3353	.2439	.2896
15	.0514	.0343	.0343	.2743	.0343	.0343	.0514
16	.0514	.0343	.0514	.2439	.0457	.0343	.0343
17	.0514	.0514	.0343	.2591	.0514	.0343	
18	.0343	.0514	.0514	.0514	.0514	.0343	
19	.0857	.0686	.0857	.0686	.0686	.0686	
20	.1029	.0857	.1029	.0686	.12	.0857	
21	.1029	.0857	.0686	.0686	.0857	.0857	
22	.0686	.0857	.0686	.0514	.0686	.0857	
23	.0514	.0686	.0514	.0686	.0857	.0686	
24	.0514	.0514	.0686	.1029	.0514	.1029	.0686
Max	.3506	.4268	.442	.2743	.3353	.3048	.3201
Min	.0343	.0343	.0343	.0514	.0343	.0343	.0343
Avg	.126	.1764	.1511	.1250	.1011	.1449	.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194099 / 33/11 kv DHAGPIMPARI SUB

STATI

Feeder No / Name : 202 / 11KV SARANWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	.0857	2.0729	1.9814	2.1033	1.1431	1.1431
2	1.6766		2.0424	2.0119	1.9966	1.2193	1.1431
3	1.7528	.0857	1.9814		1.9662	1.6766	1.1584
4	1.829	.1029	2.0119		1.829	1.6613	1.1888
5	1.6309	.12	1.9814		1.829	1.4784	1.1888
6	1.7833	.1372	1.9662			.9145	1.2193
7	1.6918	.5639	1.9966			1.4022	1.4175
8	1.9662	1.829	1.9662				1.5242
9	1.9204	2.1795	2.0119			1.448	1.7223
10	1.9052	2.2862	2.0729			1.3717	1.7375
11	1.7223	2.1643	2.0424			1.4632	1.7528
12		2.1186	1.9814			1.4175	1.7223
13		2.0424	1.9357		1.6766	1.4022	1.6766
14		1.9966	1.7528			1.3717	1.5851
15	.0686		.0686		.0514	.0514	.0343
16	.0686	.0686	.1029			.0514	.0514
17	.0857	.0686	.0857		.0686	.0514	
18		.0857	.0686		.0857	.0686	
19	.12	.0857	.1543	1.89	.1029	.0857	
20	.1372	.1029	.2915	1.9204	.1543	.12	
21	.1372	.1372	.1029	1.9966	.1715	.12	
22	.12	.1029	.1029	2.0729	.1715	.12	
23	.1029	1.9814	1.829	2.0119	1.6289	1.1736	
24	1.6309	.1029	2.0119	1.9052	2.0729	1.5242	1.1431
Max	1.9662	2.2862	2.0729	2.0729	2.1033	1.6766	1.7528
Min	.0686	.0686	.0686	1.89	.0514	.0514	.0343
Avg	1.0998	.8385	1.3598	1.9738	1.0606	.9277	1.2593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194099 / 33/11 kv DHAGPIMPARI SUB

STATI

Feeder No / Name : 203 / 11KV KHASGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2229	.2743	.2401	.2401	.2743	.2058
2	.2229	.2229	.2743	.3258	.2401	.2915	.2058
3	.2229	.2401	.2743		.2401	.3258	.2401
4	.2229	.2915	.2743		.2401	.3601	.2915
5	.2401	.3258	.2743		.2401	.3429	.3258
6	.3429	.3429	.3086			.3944	.3601
7	.3258	.3258	.3506			.2058	.3601
8	.2572	.2572	.3086			.1715	.3086
9	.2401	.2401	.2401			.2572	.2229
10	.2058	.2401	.1715			.2058	.3429
11	.2229	.2401	.1886			.2058	.4115
12		.2401	.1543			.1886	.1886
13		.1886	.1715			.1715	.1715
14		.1886	.1372		.12	.1715	.1886
15	2.4082	2.2558	2.4691	.823	1.7071	1.9662	1.829
16	2.5149		2.6825	1.3717	1.8595	2.0119	2.0881
17	2.5911		2.4691	1.5851	1.829	2.1033	
18	2.332	2.652	2.3929	1.4632	1.7528	2.0729	
19	2.4387	2.8197	2.1643	1.4327	1.6766	1.9509	
20	2.2862	2.7435	2.0119	1.387	1.7071	1.7528	
21	2.1338	2.4996	1.9814	1.4022	1.7375	1.6766	
22	2.0576	2.1643	1.8747	1.2803	1.6004	1.5242	
23	.2572	.3086	.1886	.2743	.2743	.2401	
24	.2229	.2401	.3086	.2743	.2743	.2058	.2058
Max	2.5911	2.8197	2.6825	1.5851	1.8595	2.1033	2.0881
Min	.2058	.1886	.1372	.2401	.12	.1715	.1715
Avg	1.0461	.8750	.9144	.9883	.9837	.7946	.4675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV SUB-STATION YEDASHI

Feeder No / Name : 201 / 11 KV AMBEJAWALGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.4854		.2949	.3688	.3601
2	.4024	.4854		.2683	.4191	.3601
3	.4527	.4908			.3391	.3601
4	.5087	.5201			.3222	.3429
5		.5487			.3561	.3772
6		.6036			.39	.3944
7		.6036			.3391	.4287
8	.5087	.5765				.3772
9		.5765			.373	.3601
10		.2561		.1734	.2774	.3258
11				.2254		.4075
12						.4075
13		.3258		.208		.4382
14		.2926				.4382
15		.3258				.4252
16		.3582				.3109
17						.3439
18						.2402
19		.5316				.3761
20		.5201		.407		.4382
21		.4908		.4031		.4252
22				.3294		.4075
23				.3467		.3761
24	.3391	.4557	.3391	.3113	.407	.3772
Max	.5087	.6036	.3391	.407	.4191	.4382
Min	.3391	.2561	.3391	.1734	.2774	.2402
Avg	.4393	.4693	.3391	.2968	.3592	.3791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV SUB-STATION YEDASHI

Feeder No / Name : 202 / 11 KV YEDSHI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8779			.8669	.9779
2	.8238	.7865			.8842	.9779
3	.7712	.8097			.8764	.9779
4	.7011	.8097			.8589	.9779
5	.7802	.8697			.9114	1.0774
6		.9014			.8669	1.2431
7		.8905			.8413	1.1934
8	.8842	.8482			.9536	1.0111
9	.8238	.7625			.8764	.9945
10		1.2483		.8139	.8817	.8097
11		1.3032		.788		.7459
12		.9259		.78		.7537
13		1.6072		.763		.7459
14		1.5638		.7042		.7459
15		1.5203		.9665		.7537
16		1.3672		.8383		.7042
17		.9907				.6952
18		.7865				.6874
19		.8097				.8097
20		.8421				.8749
21		.8482		.8551		.8381
22				.8063		.8322
23						.8029
24	.8413	.7865	.7975		.8322	.9945
Max	.8842	1.6072	.7975	.9665	.9536	1.2431
Min	.7011	.7625	.7975	.7042	.8322	.6874
Avg	.8018	1.0071	.7975	.8128	.8773	.8844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV SUB-STATION YEDASHI

Feeder No / Name : 203 / 11 KV JAWALA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.5201			.4191	.2743
2	.4748	.5201			.373	.2743
3	.5197	.5201			.3391	.2743
4	.5935	.5083			.373	***
5		.5201			.4239	.3086
6		.5201			.4578	.3772
7		.6104				.4287
8	.6443	.6036			.4748	.3429
9	.6443	.4252			.4578	.3086
10		.4733		.3681	.2601	.2402
11				.3467		.4207
12						.394
13				.3155		.4382
14						.3898
15						.4075
16						.4382
17		.394				.4557
18		.3761		.2947		.2402
19		.443				.3439
20		.4908		.3988		.4252
21		.443		.3506		.394
22				.2947		.3761
23				.3052		.3258
24	.2713	.5083	.4681		.373	.2915
Max	.6443	.6104	.4681	.3988	.4748	95.0447
Min	.2713	.3761	.4681	.2947	.2601	.2402
Avg	.5006	.4923	.4681	.3343	.3952	4.3006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV SUB-STATION YEDASHI

Feeder No / Name : 204 / 11KV TOLL PLAZA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.56	1.4289			1.6766	1.3413
2	1.3565	1.448			1.6108	1.3077
3	1.2548	1.448			1.643	1.2742
4	.8383	1.4083			1.8442	1.2407
5	.9326	1.3108			1.5261	1.1401
6	.763	1.448			1.1736	1.073
7	.7042	.7865			1.0898	
8	.8139	.7865			.8718	
9		.8322			.8817	.8718
10		.9414			.8139	.7865
11		.8855				.8482
12		.9061				.8697
13						.8436
14						.8029
15						.8029
16						.8592
17						.8097
18						.8097
19						.9414
20						1.382
21						1.39
22						1.4098
23				1.7126		1.3672
24	1.6278	1.4289	1.3904		1.7126	1.3413
Max	1.6278	1.448	1.3904	1.7126	1.8442	1.4098
Min	.7042	.7865	1.3904	1.7126	.8139	.7865
Avg	1.0946	1.1584	1.3904	1.7126	1.3495	1.0688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33/11 KV SUB-STATION PADOLI

(A

Feeder No / Name : 201 / 11 KV PADOLI (A) FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3621	.4578		.4625	
2		.3964	.4694		.5438	
3		.428	.4917		.528	
4		.5127	.503		.545	
5		.581	.5365		.5778	
6		.5438	.5365		.5778	
7			.5426			
8		.2966	.4694			
9		2.4756	2.6595	.4106		.4115
10	.561	2.4078	1.8861	.4599		.3601
11	2.3924	2.3807	2.4177	.4769		
12	2.4419	2.5434	2.4006			
13	2.4584	2.4587	2.2634			
14	2.4749	2.2801	2.3663	.9923		
15	2.4784	2.4078	2.3663	.9934		
16	2.3675	2.4247	2.3663			
17	.2716	.3206	.2743	1.5492		2.1262
18		.3391	.2743	1.4502		
19	.4074	.4409		1.3529		
20	.5115	.6104		.264		
21	.5121	.5365		1.1621		2.1948
22	.4614	.5256				2.1948
23	.4599	.4748		1.0937		2.1948
24		.4609	.4359		1.0559	
Max	2.4784	2.5434	2.6595	1.5492	1.0559	2.1948
Min	.2716	.2966	.2743	.264	.4625	.3601
Avg	1.3691	1.1395	1.2483	.9277	.6130	1.5804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33/11 KV SUB-STATION PADOLI

(A

Feeder No / Name : 202 / 11 KV MENDHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3296	.3688		.3937	
2		.3296	.4359		.4102	
3		.3955	.4359		.3831	
4		.4944	.4694		.341	
5		.5603	.5087		.462	
6		.4774	.5087		.5432	
7		.4944	.5197		.511	
8	.5195	.445	.503		.5804	
9	.3288	.3391	.4359	.495		.3086
10	.2908	.2035	.4801	.3751		.2058
11	.1707	.1526	.1715			.1372
12	.1364	.1357	.1715	.1648		
13	.132	.1357	.1372	.1364		.1372
14	.1363	.1357	.1372	.1318		.1372
15	.1363	.1526	.1372			.1029
16	1.8164	.1526	.1372	.1978		.1715
17	1.8149	2.2257	2.0233	1.1741		.1715
18	1.681	1.7101		1.1182		.2743
19	1.7489	1.7126				.2401
20	1.6499	1.8861	1.4575			.3086
21	1.6388	1.6598	1.5432	.8889		.3429
22	1.5329	1.8671		.825		.3772
23	1.4486	1.6108		.5623		.3086
24		1.3967	1.4251		.561	
Max	1.8164	2.2257	2.0233	1.1741	.5804	.3772
Min	.132	.1357	.1372	.1318	.341	.1029
Avg	.9489	.7918	.6004	.5518	.4651	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33/11 KV SUB-STATION PADOLI

(A

Feeder No / Name : 205 / 11 KV VISHWARUPA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0493	.0339	.0514		.0509	
2		.0565	.017	.0171		.0494	
3		.0494		.0171		.0511	
4		.0494	.0503			.0341	
5		.0661	.0339	.0686		.0513	
6		.0659	.0678	.0686		.0684	
7		.0659	.0339	.0686		.0513	
8	.0346	.0511	.0339	.0514		.0494	
9	.0495	.0503	.0377		.033		.0343
10	.0492	.0509	.0514		.0495		.0514
11	.0495	.0509	.0514		.0546		.0514
12	.0494	.0754	.0514		.0512		.0686
13	.0494	.0509	.0514		.0496		.0514
14	.0497	.0509	.0514				.0514
15	.0495	.0339	.0514		.0329		.0514
16	.0495	.0339	.0514		.0341		.0514
17	.0494	.017	.0514		.0341		.0171
18	.0165	.0168	.0514				.0171
19	.0165	.017	.0171				.0171
20		.0168	.0171				.0171
21		.0168	.0171				
22		.0373	.0171		.0331		
23		.0339	.0343		.0342		.0514
24		.0329	.0339	.0514		.0328	
Max	.0497	.0754	.0678	.0686	.0546	.0684	.0686
Min	.0165	.0168	.017	.0171	.0329	.0328	.0171
Avg	.0427	.0433	.0395	.0493	.0406	.0487	.0409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194094 / 33/11 KV SUB-STATION

TADAWALA

Feeder No / Name : 201 / 11 KV GOPALWADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7621	.8097	.7621	.583	.5792	.7287	.048
8	.9145	.8421	.9145	.7449	.7316	.9069	.112
12	.0162	.0152	.0162		.0324	.016	
16	.0162	.0152	.0162	.0152	.0324		
17						.048	
20	.0648	.0914	.081	.0914	.0486	.08	
23	.0162						
24	.0305	.0324	.0305	.502	.5792	.6154	.032
Max	.9145	.8421	.9145	.7449	.7316	.9069	.112
Min	.0162	.0152	.0162	.0152	.0324	.016	.032
Avg	.2601	.301	.3034	.3873	.3339	.3992	.064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194094 / 33/11 KV SUB-STATION

TADAWALA

Feeder No / Name : 202 / 11 KV TADAWALA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6401	.7773	.7011	.583	.7011	.7773	.6952
8	.7621	.8583	.9145	.7287		.8097	.2374
10	.6097						
12	1.1984	1.0669	1.2955	.4268	.8097	1.0682	
16	.9878	1.0669	1.166	.8535			
17						.9665	
20	1.1336	.7316	1.2146	.823	1.1336	1.0174	
24	.6097	.8097	.6097	.8259	.7316	.7773	.6783
Max	1.1984	1.0669	1.2955	.8535	1.1336	1.0682	.6952
Min	.6097	.7316	.6097	.4268	.7011	.7773	.2374
Avg	.8488	.8851	.9836	.7068	.844	.9027	.5370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194040 / 33/11KV SUB-STATION PARA

Feeder No / Name : 201 / 11KV Para

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 201 / 11 KV TERKHEDA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 202 / 11 KV INDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820] BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 203 / 11 KV BAWI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 204 / 11 KV WADJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 205 / 11 KV TERKHEAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	.9431
Max	.9431
Min	.9431
Avg	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 201 / 11 kv pargaon gaodan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
23	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 203 / 11 kv rui-pimpalgaon
gaodan Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
23	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 204 / 11 kv rui

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
23	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 202 / 11KV SALEGAON SPP feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 204 / 11KV YENEGUR SPP feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 205 / 11 KV Nalwadi SPP feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.3108
Max	1.3108
Min	1.3108
Avg	1.3108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 207 / 11KV ASHTA (KASAR) SPP SINGLE PHASING
feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3353
Max	.3353
Min	.3353
Avg	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 201 / 11 KV HIPPARAGA S SPP SINGLE PHASING
feeder Feeder KV- 11 / OUTGOING

DATE	29-MAY-18
HR	Load (MW)
1	.7716
2	.823
3	.8573
4	.8573
5	.8573
6	.9259
7	.9259
8	.9259
24	.6859
Max	.9259
Min	.6859
Avg	.8478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 201 / 11 KV BHATANGALI SPP

SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6004	1.7833	.9145	1.6004	1.0669	.3239
2	1.5242	1.6004	1.8138		2.0576	1.3336	.3429
3	1.5242		1.829		1.6766	1.0669	.3429
4	1.829	1.6156	1.7985		1.7071	1.0669	.3239
5	1.829	1.6766	1.829		1.6766	1.1431	.3429
6	1.9814	1.7528	1.9662		1.6766	.823	.3048
7	1.3717	1.9204	1.9357	.1905	1.6766	1.1431	.3429
8	1.9814	1.768	1.9052	.4572	1.3413	1.2193	.3239
9	.2858	.2286	.2667		.2858	.2096	1.829
10	.2286	.1905	.1905		.2477	.2096	1.829
11	.1905	.1524	.1905	.1905	.1524	.1905	1.9814
12	.1524	.1334	.1905	.1905	.1524	.1905	2.1338
13	.1715	.1524	.1905	.1905	.1715	.1715	2.1338
14	.1715	.1905	.1905	.2096	.1715	.1905	2.1338
15	.1524	.1905	.1905	.2096		.1715	2.1338
16	.1715	.1905	.1905	.2096	.1524	.2096	2.1338
17	.1524	.1524	.1905	.1905	.1334	.1524	
18	.1905	.2477	.2858		.1715	.2286	.2858
19	.2477	.2477	.381	.2858	.2858	.2667	.381
20	.3429	.362	.381	.381	.3429	.3429	.381
21	.3429	.3429	.381	.381	.3429	.3239	.381
22	.3239	.3239		.3239	.3239	.3048	.381
23	.3048	.2858		.3048	.2667	.3239	.2858
24	.381	.2667	.2667		.2858		.3048
Max	1.9814	1.9204	1.9662	.9145	2.0576	1.3336	2.1338
Min	.1524	.1334	.1905	.1905	.1334	.1524	.2858
Avg	.7240	.6779	.8340	.3086	.7348	.5369	.9286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 202 / 11 KV NAGUR SPP FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4572	.4382	.4763	.4572	.4572	.5525
2	.4763	.4572	.4191	.4763	.4572	.4572	.5335
3	.4763	.4572	.4382	.4763	.4763	.4572	.5144
4	.4763	.4572	.4954	.4763	.4763	.4763	.5144
5	.5716	.4763	.5335	.4763	.5716	.5335	.5716
6	.6668	.4954	.5716	.5716	.6668	.6097	.5906
7	.5716			.4763	.6097	.5335	.5716
8	.4763		.4001	.4763	.5716	.5144	.4572
9	2.4387	2.5301	2.3624	1.829	2.1643	2.332	.5144
10	2.3472	2.7587	2.7435	2.1338	2.3472	2.3472	.381
11	2.2862	1.829	2.7435	2.1033	2.3167	2.3624	.381
12	1.9052	2.5453	2.7435	2.2862	2.2862	2.4082	.381
13		2.5301	2.7435	2.4082	2.3167	2.4844	.381
14		2.7282	2.8959	2.4387	2.3624	2.5606	.381
15		2.713	2.8959	2.4387	2.4387	2.5911	.381
16	1.9966	2.7282	3.0483	1.829	2.3624	2.3472	
17	.381	.362	.9526	.4001	.381	.381	2.8959
18	.362	.4191	.4763	.4001	.4763	.4001	3.0483
19	.4954	.4954	.5716	.5716	.6097	.4572	2.7435
20	.6097	.6668	.7621	.6668	.6859	.6859	2.5911
21	.6668	.6668	.724	.6478	.6097	.5906	2.4387
22	.6097	.5716		.5906	.5716	.5335	2.4387
23	.5335	.4954		.5144	.4763	.5144	2.4387
24	.4763	.4572	.4572	.4763	.4763		.5335
Max	2.4387	2.7587	3.0483	2.4387	2.4387	2.5911	3.0483
Min	.362	.362	.4001	.4001	.381	.381	.381
Avg	.9190	1.2408	1.4008	1.0683	1.1320	1.1754	1.1406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 203 / 11 KV KANEGAON SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4382	.5335	.4763	.4572	.4763	1.2346
2	.4763	.4382	.5525	.4763	.4382	.4763	1.2498
3	.4763	.4382	.5716	.4763	.4763	.4763	1.2498
4	.4763	.4572	.5716		.4763	.4763	1.2346
5	.5716	.4572	.6097		.5335	.5335	1.326
6	.6668	.5335	.6287		.6287	.6287	1.3413
7	.5716	.5906	.5716	.4763	.6287	.5525	1.4327
8	.4763	.5144	.5335	.381	.5906	.5335	1.4175
9	.4763	.5144	.4191	.2858	.5144	.4572	.4382
10	.4382	.381	.381	.381	.4191	.4191	.381
11	.4191	.4191	.4763	.381	.381	.4001	.381
12	.4001	.4382	.4763	.381	.3429	.4001	.4763
13	.4382	.4763	.4763	.381	.381	.381	.381
14	.4382	.4954	.4763	.4191	.4001	.4001	.4763
15	.4001		.4763	.4001	.4001	.4191	.381
16		.4572	.381	.4382	.4001	.4191	.4763
17	1.6156	1.7071	2.1338	1.3717	1.3717	1.4022	.381
18	1.7528	1.829	2.1338	1.5394	1.6004	1.4327	.4763
19	1.6766	1.6766	1.9814	1.5242	1.5242	1.448	.5716
20	1.6766	1.7528	1.829	1.3717	1.3717	1.3108	.6668
21	1.6004	1.7071	1.829	1.3413	1.2498	1.2498	.6668
22	1.5546	1.6461		1.2955	1.2193	1.1888	.5716
23	1.5242	1.5851		1.2346	1.1431	1.2041	.5716
24	1.5242	1.4175	1.5546	1.0669	1.1888		1.2193
Max	1.7528	1.829	2.1338	1.5394	1.6004	1.448	1.4327
Min	.4001	.381	.381	.2858	.3429	.381	.381
Avg	.8751	.8857	.8908	.7666	.7557	.7255	.7918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 201 / 11kv Tawshigad SPP feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.7621	1.0288
2		.9145	1.1145
3		.9145	1.2003
4		.9907	1.286
5		1.0669	1.286
6		1.0669	1.3717
7		1.1431	1.3717
8		1.2193	1.4575
9	.8383	1.286	1.4575
16	.0953	.1905	.0953
17	.1905	.1905	.1905
18		.1905	.1905
19	.2858	.2858	.1905
20	.381	.2858	
21	.381	.1905	
22	.2858	.1905	
23	.1905	.1905	
24		.6097	.8573
Max	.8383	1.286	1.4575
Min	.0953	.1905	.0953
Avg	.3310	.6494	.9356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 202 / 11KV Dhanuri SPP feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.4763
2	.5716	.5716	.4763
3	.6668	.6668	
10	.6859	1.0288	2.0576
11	.7621	2.3148	2.4863
12		2.2291	2.4006
13	1.6766	2.2291	2.4863
14	1.9814	2.0576	2.4863
15	1.9052	2.3148	2.4863
16	2.0576	2.0576	2.572
17	2.21	2.2291	2.7435
18	.4763	.4763	.6668
19	.6668	.5716	.5716
20	.6668	.4763	
21	.6668	.5716	
22	.7621	.4763	
23	.5716	.4763	
24	.4763	.5716	.4763
Max	2.21	2.3148	2.7435
Min	.4763	.4763	.4763
Avg	1.0221	1.2162	1.7220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 203 / 11kv Harali SPP feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-MAY-18	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.381	.6859	.8573
2	.381	.7621	1.0288
3	.4763	.9145	1.0288
4	.5716	.9145	1.1145
5	.6668	.9907	1.1145
6	.7621	.9907	1.2003
7	.5716	1.0669	1.1145
8	.6668	.9907	1.2003
9		1.1145	1.1145
16		.2858	.2858
17		.381	.2858
18	.5335	.381	.381
19	.7621	.4763	.4763
20	.5716	.5716	
21	.5716	.5716	
22	.4763	.4763	
23	.381	.381	
24	.2858	.5335	.7716
Max	.7621	1.1145	1.2003
Min	.2858	.2858	.2858
Avg	.5373	.6938	.8553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 201 / 11KV MURUM feeder- Urban
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
1		.8573
2		.8573
3		.8573
4		.8573
5		1.0288
6		1.0288
7		1.0288
8		1.0288
9		.8573
10	.8573	.8573
11	.8573	
12	.8573	
13	.8573	
14	.8573	
15	.8573	
16	.8573	
17	.8573	
18	1.0288	
19	1.0288	
20	1.0288	
21	1.0288	
22	1.0288	
23	.8573	
24		.8573
Max	1.0288	1.0288
Min	.8573	.8573
Avg	.9186	.9197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 202 / 11KV KOTHSALI SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
1		1.1431
2		1.5242
3		1.5242
4		1.5242
5		1.5242
6		1.5242
7		1.5242
8		1.5242
9		1.5242
10	1.5242	
11	1.5242	
12	.381	
13	.381	
14	.381	
15	.381	
16	.381	
17	.381	
18	.381	
19	.381	
20	.9526	
21	.9526	
22	.9526	
23	1.1431	
24		1.1431
Max	1.5242	1.5242
Min	.381	1.1431
Avg	.7212	1.4480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 203 / 11KV BELUMB (ACHALER) SPP SINGLE PHASING
FEE Feeder KV- 11 / OUTGOING

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
1		.381
2		.381
4		.381
5		.5716
6		.5716
7		.5716
8		.5716
9		.381
10		.9526
11	1.1431	
12	.9526	
13	.9526	
14	.9526	
15	.9526	
16	.9526	
17	.9526	
18	.9526	
19	.9526	
20	.381	
21	.381	
22	.381	
23	.381	
24		.381
Max	1.1431	.9526
Min	.381	.381
Avg	.7914	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 204 / 11KV ALOOR FEEDER- Ag.

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-MAY-18	31-MAY-18
HR	Load (MW)	Load (MW)
1		.7621
2		.7621
3		.7621
4		.7621
5		.7621
6		.7621
7		.7621
8		.7621
9		.7621
10	.6097	1.5242
11	.6097	
12	1.829	
13	1.5242	
14	1.829	
15	1.829	
16	1.829	
17	1.829	
18	1.829	
19	1.829	
20	.4572	
21	.6097	
22	.6097	
23	.7621	
24		.7621
Max	1.829	1.5242
Min	.4572	.7621
Avg	1.2847	.8314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 201 / 11KV TURORI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					1.467	1.1336
9					1.3336	1.2269
10					1.467	.7621
11					1.6671	.9526
12			.4287		1.4861	.9526
13		1.6004		1.9433		
14	1.9433	1.9433		1.7147		
15	2.0576	2.0576	2.5339	1.7147		
16	2.0805	2.1148	2.4672	1.829		
17	2.0576	2.2634	1.7147	2.0005		
18	1.7718	1.829		1.9433		
Max	2.0805	2.2634	2.5339	2.0005	1.6671	1.2269
Min	1.7718	1.6004	.4287	1.7147	1.3336	.7621
Avg	1.9822	1.9681	1.7861	1.8576	1.4842	1.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 202 / 11KV MULAJ FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.6766	
2						1.7528	
5						1.9814	
7						2.6673	
8							1.1336
9							1.0002
10	1.9605	2.0271	1.5718		1.6004		
11	1.3336	2.0576	1.7147	1.9204	2.0005		
12		2.6863	1.8099	1.829	1.8938		
13	2.4006	2.8006			2.1338		
14	2.4006	2.572			2.6978		
15	2.4577	2.5835	2.8673		1.8938		
16	2.5034	2.6863	2.934	2.2291	2.2672		
17	2.6292	2.7435	2.191	2.0348			
24						1.3717	
Max	2.6292	2.8006	2.934	2.2291	2.6978	2.6673	1.1336
Min	1.3336	2.0271	1.5718	1.829	1.6004	1.3717	1.0002
Avg	2.2408	2.5196	2.1815	2.0033	2.0696	1.8900	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 203 / 11KV TALMOD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.7621	1.0669		1.2193		
2	1.0517	.8383	1.1279				
3		.9145	1.2041				
4		1.1431	1.2955				
5	.9145	1.3717	1.5546				
6	1.448		1.8595				
7	1.7528		2.1338				
8	1.6004	1.9814	1.8671	.8573			
9		1.2003	1.5203	1.2003	.16		.3334
10						.4001	.4001
11						.3201	
12							.5335
13						.4001	
14						1.2003	
15							.8002
16						1.0669	
22				.6668			
23				.9335			
24	.9602	.6097	1.0059		1.2955		
Max	1.7528	1.9814	2.1338	1.2003	1.2955	1.2003	.8002
Min	.9145	.6097	1.0059	.6668	.16	.3201	.3334
Avg	1.2476	1.1026	1.4636	.9145	.8916	.6775	.5168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 204 / 11KV Mulaj Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4268	.4268	.2667	.4115	.5182	
2	.4115	.4268	.4268	.1905	.4115		
3	.4572	.4572	.4572	.2934	.4572	.5182	
4	.6097	.5335	.5792	.2667	.5792		
5	.7621	.7164	.7468	.4001	.7011		
6	.9145	.945	.9755		.9145		
7	.8383	.8535	.8383		.9907	.9755	
8	.6668		.6668	.4572	.6668		
9	.5868	.6268	.5868	.8002			
10	.5335	.5601	.362		.6401	.6401	.5735
11	.4534	.4534	.5201	.4934	.4668	.5601	
12		.3601	.4001	.3868	.3734	.4001	
13						.3334	
14						.2934	
15						.2934	.2858
16	.2629	.2972	.2858	.2858		.3201	
17	.3429	.3429	.2858	.3772			.4001
18	.3658	.3658		.4115			
19	.4801	.5335		.5601		.4534	.5239
20	.7202	.7335		.7468		.6001	
21	.6135	.6401		.5868			
22	.5335	.5068		.4801			
23	.4001	.4534		.3734		.3601	
24	.4268	.4268	.4572	.2382	.4268	.5182	
Max	.9145	.945	.9755	.8002	.9907	.9755	.5735
Min	.2629	.2972	.2858	.1905	.3734	.2934	.2858
Avg	.5403	.5330	.5343	.4231	.5866	.4846	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 205 / P.B.A.INFRA EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
KAR Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1334	.16	.1524	.1372	
2	.1524	.1524		.16	.1524	.1372	
3	.1524	.1524	.1524	.1143	.1524	.1372	
4	.1524	.1524	.1524	.16	.1524		
5	.1524	.1524	.1524	.1143	.1524	.1372	
6	.1524	.1524	.1524	.0838	.1524	.1372	
7	.1524	.1524	.1524		.1524	.1372	
8	.1334	.1524	.1524	.1467	.1524	.1067	
9	.1334	.1334	.1524		.1372	.2286	
10	.2534	.0914	.1524		.1372	.2743	
11	.2934	.2667		.16	.2667	.2743	.0934
12	.12	.2934	.1467	.2934	.2801	.1829	.0934
13	.12	.2667		.2667	.2515	.2743	
14	.12	.2		.1334	.08	.3048	
15	.2401	.2667		.2401	.2286	.1524	.0953
16	.2401	.2667		.2667	.2934	.1524	
17	.1334	.2667	.2934	.2934	.2058	.1524	.1067
18	.1867	.2934		.1334	.1143		
19	.16	.2667		.1524	.2058		.1524
20	.16	.1334		.1524			
21	.1334	.1524		.1524			
22	.1524	.1524		.1524			
23	.1524	.1524		.1372			
24	.2591	.1524	.1524	.1143	.1524	.1372	
Max	.2934	.2934	.2934	.2934	.2934	.3048	.1524
Min	.12	.0914	.1334	.0838	.08	.1067	.0934
Avg	.1691	.1906	.1621	.1708	.1786	.1802	.1082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 201 / 11 kv Chourasta gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.2096	.3772		.1715	.3658
2	.4801	.2096	.3429		.1905	.3658
3	.5144	.2286	.4115		.2096	.3658
4	.5487	.2477	.4458		.2286	.4755
5	.5487	.2858	.5487		.2382	.5487
6	.6173	.2667	.6859			
9				.1524		.4024
10	.2858	.5853	.5487	.2286	.6219	.2858
11	.2667	.5121	.5487	.2286	.5487	.2382
12	.2382	.4755	.4801		.5121	.2382
13	.2096	.4755	.3772	.2096	.4572	.2096
14	.1905	.4755	.3772	.1905	.4024	.1905
15	.1715	.439	.3772	.3048		.1715
16	.1905	.4024	.3429	.1524	.3658	.1715
17	.2096	.3658	.3601	.1715		.1619
18	.2191	.4755	.3772	.2096		.2096
19	.2858	.6219	.5144	.2286		.2286
20	.3048	.7316		.2667		.2477
21	.2667			.2858	.5487	.2667
22	.2477	.5121		.2858	.4755	.2667
23		.4755		.2477	.439	.2286
24	.4115	.2286	.439		.2286	.4024
Max	.6173	.7316	.6859	.3048	.6219	.5487
Min	.1715	.2096	.3429	.1524	.1715	.1619
Avg	.3327	.4112	.4444	.2259	.3759	.2877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 203 / 11 kv EKURGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145					
2	1.2003					
3	1.2346					
4	1.2346					
5	1.2346					
6	1.3717					
7	1.4403					
9					.2446	
10		1.3047	1.3032			
11		1.5656	1.3717			
12		1.2394			.8154	
13		1.3699	1.166	.1715	1.0437	
14		1.3047	1.1145	.2058	1.0111	
15		1.1742	1.0974	.2058	.848	.2058
16		1.4351	1.1317	.2286		.3429
17		1.3047	1.1488	.2286		.3658
24	1.0288					
Max	1.4403	1.5656	1.3717	.2286	1.0437	.3658
Min	1.0288	1.1742	1.0974	.1715	.2446	.2058
Avg	1.2324	1.3373	1.1905	.2081	.7926	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 204 / 11 KV JAKEKUR AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	2.0576		.3887	
2		.7773	1.9719		.4572	
3		.8916	1.7147		.5487	
4		1.0288	2.0576		.663	
5		1.1431	2.1948		.663	
6		1.1431	2.2977			
7		1.2574	2.332		.6859	
8		1.3489	2.2291			
9		1.957	2.0576			
10	.9831					
11	1.1431					
12	1.2803					
14	1.4632					
15	1.4861					
16	1.5089					
17	1.4861					
22				.2286		.1715
23				.2743		.1715
24		.4572	1.8861		.3429	
Max	1.5089	1.957	2.332	.2743	.6859	.1715
Min	.9831	.4572	1.7147	.2286	.3429	.1715
Avg	1.3358	1.0690	2.0799	.2515	.5356	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 206 / NEW 11 KV MIDC FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.0476	.3944		.1524	
2	.4115	.0476	.3601		.1334	
3	.4458	.0476	.3429		.1334	
4	.4115	.0381	.3258		.1715	
5	.4115	.0572	.4115		.2096	
6	.3601	.0667	.3601		.2858	
7	.3601	.0953	.3772		.2858	
8	.1143	.1715	.3601		.3292	
9	.1143	.3475	.3601		.4207	
10	.1143	.4755	.4115		.439	
11	.1048	.6219	.4115	.2858	.439	.2
12	.1143	.7316	.4115	.3334	.4024	.2191
13	.1048	.4572	.4287	.3239	.2743	.2572
14	.1048	.439	.5144	.3048	.4024	.362
15	.0857	.4024	.4458	.2858	.5487	.3715
16	.0857	.5487	.583	.3048		.3525
17	.1048	.6219	.583	.2858		.3144
18		.6401	.5487	.2477		.2858
19		.567	.5487	.2286		.2477
20	.0857	.4572		.2096		.2286
21	.0667	.4572		.1905		.2096
22	.0572	.4572		.1905		.2477
23		.4938		.2096		.1905
24	.4458	.0381	.4287		.2	
Max	.4458	.7316	.583	.3334	.5487	.3715
Min	.0572	.0381	.3258	.1905	.1334	.1905
Avg	.2150	.3470	.4304	.2616	.3017	.2682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 201 / 11 KV BALSUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3887	.503	.2427	.4359	.3725
2	.4191	.3563	.5868	.2427	.4694	.3239
3	.4191	.3239	.5868	.2427	.4694	.3077
4	.4359	.583	.6706	.2614	.503	.4534
5	.4694	.6154	.7042	.2614	.4694	.6154
6	.547	.6316	.6706	.2987	.421	.5992
7	.4877	.5344	.503	.2987	.3239	.4534
8	.4401	.4696	.503	.2801	.3239	.4696
9	.3715	.4049	.4973	.2957	.4858	.4534
10	.4049	.5197	.4641		.3887	.407
11		.3353	.4475	.2515	.3077	.39
12	.4372	.57	.4359	.2515	.3401	.373
13	.502	.503	.431	.2515	.2915	.3561
14		.3856	.4409	.3353	.2753	.407
15	.4372	.381	.4409	.3353	.3077	.39
16	.4696	.4191	.3647	.3353		.407
17	.5182	.4191	.3315	.4024	.3401	
18	.5344	.503	.4287	.4191	.4372	
19	.5668	.5868	.6516	.57	.583	
20	.6964	.6539	.6859	.6706	.6478	
21	.6802	.6371		.6706	.5506	
22	.5182	.6706		.6706	.502	
23	.4696	.4191		.503	.4372	
24	.4359	.3887	.3521	.2427	.4191	.3887
Max	.6964	.6706	.7042	.6706	.6478	.6154
Min	.3715	.3239	.3315	.2427	.2753	.3077
Avg	.4854	.4875	.5095	.3623	.4230	.4216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 202 / 11 kv BALSOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221					
2	.9389					
3	.9389					
6	.9389					
7	1.3108					
8	1.291					
9	1.2483					
10	1.3927					
11	1.1498					
12		1.3077	1.2742	.6706	.7287	1.0004
13		1.6766	1.5083	.8383	.9555	1.0004
14		1.6766	1.5261		1.0526	1.3056
15		1.6766	1.5261	.8383	1.0526	1.0343
16		1.4754	1.5249	1.1401	.9878	1.1022
17		1.6766	1.5746	.8383	.8421	
18		1.1736	1.749	.4191	1.2146	
19		1.6766	1.8004	1.6095	1.3117	
20		1.6766		1.6095	1.1174	
21		1.4251		1.3413	1.1174	
22		1.3413		1.1568	1.004	
23		1.3413		.8718	.9717	
24	.7545					
Max	1.3927	1.6766	1.8004	1.6095	1.3117	1.3056
Min	.7545	1.1736	1.2742	.4191	.7287	1.0004
Avg	1.0886	1.5103	1.5605	1.0303	1.0297	1.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 203 / 11KV RAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9717	1.0059	.8097	.5506
2		1.1012	1.1736	.8097	.9069
3		1.1822	1.0059		.9717
4		1.4413	.9221		.9555
5		1.587	1.0059		1.1498
6		1.5223	.8383	.9717	
7		1.9433	2.0119	.9717	
8		2.0405	2.079	1.2308	
9		1.8623	2.0222		.8097
10		1.8945	1.9393		1.0513
11		1.9448	1.9062	.4696	
12	1.6194				
13	2.0243				
14	1.8299				
15	1.9989				
16	1.9757				
17	2.1214				
18	1.7814				
19	1.2146				
20	1.1174				
21	1.2146				
22	1.1012				
23	1.0688				
24		.9555	.8383	.5668	.3563
Max	2.1214	2.0405	2.079	1.2308	1.1498
Min	1.0688	.9555	.8383	.4696	.3563
Avg	1.5890	1.5372	1.3957	.8329	.8440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 201 / 11 KV GUNJOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9671		.9568		.7545	.7459	.7362
2	.9671		.9465		.503	.8048	.7011
3	1.0029		1.0277			.8619	.7011
4	1.1222		1.1584			1.0059	.8145
5	1.2489		1.4118			1.1269	.9412
6	1.3717		1.7002			1.3032	1.0498
7		1.2308					
9		.8505			.6081		
10		.8505	1.2127		.6401	.6687	1.0498
11		.8328		.5304	.6036	.583	
12		.8764		.7293	.6203	.6687	.8173
13		.9465		.664	.5335	.9036	.823
14	1.1744	.9114		.6874	.5365	.9036	.8886
15	1.2048	.8764		.6952	.5182	.8859	.8718
16	1.1789	1.0277		.6478	.4961	.9214	.7459
17	.6485	1.0631	1.1934	.6401	.4481		.7461
18	1.0791	1.0745	1.2209	.703	.6093		.7716
19	1.2536	1.1706	1.2689	.8802	.9054		.9816
20	1.4998	1.531	1.2689	.9393	.945		1.004
21	1.3575	1.307		.8951	1.0059		.9779
22	1.2178	1.1706		.8421	.7537	.8775	.9326
23	1.134	1.0425		.8002	.7459	.7973	.8916
24	.9492	.9671	.9745		.7956	.7287	.7362
Max	1.4998	1.531	1.7002	.9393	1.0059	1.3032	1.0498
Min	.6485	.8328	.9465	.5304	.4481	.583	.7011
Avg	1.1399	1.0429	1.1951	.7426	.6679	.8617	.8591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 202 / 11 KV AURAD FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0838	.0417
2					.1006	.0564
3					.1006	.0564
4					.1006	.0564
5					.1006	.0714
6					.1017	.0705
7					.12	.0846
10	1.5604	1.1431	1.6876			
11	1.6617	1.4784				
12	1.8785	1.7497				
13	2.0005	1.9433				
14		1.9757		.1054		
15		2.0243		.1189		
16	.6706	1.9433		.132		
17	.3353	1.8947	2.5987			
18			2.4078			
19			2.1434			
22				.061	.0564	.1543
23				.0829	.0564	.1543
24					.0762	.0556
Max	2.0005	2.0243	2.5987	.132	.12	.1543
Min	.3353	1.1431	1.6876	.061	.0564	.0417
Avg	1.3512	1.7691	2.2094	.1000	.0897	.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 203 / 11 KV KHASGI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6584		
2	.743	.7716		
3	.8288	.8288		
4	1.0402	1.0669		
5	1.2955	1.2186		
6	1.4327	1.5043		
7	1.7966	2.0243		
8	1.4784	1.8623		
9	1.3413	1.4937	.2401	.0867
10			.3334	.2
11			.3978	
12			.4115	.3315
13			.443	.4191
14			.5001	
15			.5502	.2543
16			.5944	.5487
24	.6001	.5335		
Max	1.7966	2.0243	.5944	.5487
Min	.6001	.5335	.2401	.0867
Avg	1.1197	1.1962	.4338	.3067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 201 / 11 KV ALOOR SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.5144		.3772	.3048	.0343
2	.0457	.5144		.4287	.3048	.0343
3	.0762	.5144			.4115	.0343
4	.1067	.6001			.4115	.0343
5	.1067	.6001			.442	.0343
6	.0762	.6859			.4572	.0343
7	.1067					
8	.1219	.8573			.5639	
9						.2401
10	.1067				.0857	.2743
11				.3353	.0857	
12					.0857	.3429
13	.3429			.6001	.0857	.3429
14	.4287			.4877	.0343	.3429
15			.0762	.381	.0343	
16				.4572	.0686	.3429
17		.12	.6859	.0857	.1029	.0857
18	.0857	.1372	.4877	.1029		.0857
19	.6859	.1372	.4572	.12	.1715	.0857
20	.6859	.1543	.3658	.2572		.0857
21	.6001		.3658	.1886	.1715	.0857
22	.6001		.3353	.1715	.1715	.0857
23	.6001		.3353	.1715	.1372	.0857
24	.0762	.0857		.3429	.3048	.0857
Max	.6859	.8573	.6859	.6001	.5639	.3429
Min	.0457	.0857	.0762	.0857	.0343	.0343
Avg	.2721	.4101	.3887	.3005	.2218	.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 202 / 11 KV ACHLER SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4287		.3429	.3429	.3429
2	.3429	.4287		.3429	.3429	.3429
3	.3429	.5144			.3429	.3429
4	.5144	.5144			.3429	.4287
5	.6859	.6001		.3429	.4287	.4287
6	.4287	.6001		.4287	.5144	.4287
7	.5144	.6001		.5144	.5144	.4287
8	.5144			.5144	.4287	
9		.9431		.7164	.7621	.463
10	.7373	.8383	.9145	.7621	.7621	.3429
11	.8573		.8383	.6859	.7316	
12	.8573		.9145	.7621	.823	.3429
13	.7716		.8993	.8383	.5335	.3429
14	.6859		.8383	.7926	.8383	.3429
15	.6859		.7621	.7164	.7621	.3429
16	.7716		.6859	.7621	.7621	.3429
17		1.1431	.3429	.3944	.4287	.5144
18		.2743	.4458	.4287	.4287	.6001
19		1.1736	.5144	.5144	.5144	.6001
20		1.0669	.6859	.6001	.6859	.6859
21			.6001	.6001	.6859	.6001
22			.6001	.4287	.6001	.6001
23			.5658	.4287	.5144	.5144
24	.3429	.4287		.5144	.4115	.4287
Max	.8573	1.1736	.9145	.8383	.8383	.6859
Min	.3429	.2743	.3429	.3429	.3429	.3429
Avg	.5873	.6825	.6863	.5651	.5626	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 203 / 11 KV KESARJAWLGA SPP SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2572		.3772	.3429	.3048
2	.2229	.2572		.3772	.3429	.3048
3	.2401	.2572			.3429	.3506
4	.2915	.3429			.4287	.3506
5	.2915	.4287		.3429	.381	.381
6	.2915	.4287		.3772	.4801	.381
7	.2915	.4287		.3772	.4287	.503
8	.2572	.4287		.3772	.2058	.4725
9		.3429		.2743	.2572	.2743
10	.463			.3086	.2572	.2572
11	.6001			.2572	.2058	
12	.2572			.2401		.1715
13	.1715		.3429	.2058		.1715
14	.1715		.3429	.2058	.2401	.1715
15	.1715		.2572		.0686	.1715
16	.1715		.2743	.2229		.1715
17		.7373	.6097	.4115	.5944	.1715
18	.8573	.7716	.5487	.4572		.2572
19	.6859	.6687	.4572	.4572	.2743	.3429
20	.6001		.381	.381	.2286	.4287
21	.6001		.381	.3658	.2743	.4287
22	.5144		.381	.3353	.2591	.3429
23	.5144		.3506	.3048	.2591	.3429
24	.4115	.5144		.3772	.3048	.2286
Max	.8573	.7716	.6097	.4572	.5944	.503
Min	.1715	.2572	.2572	.2058	.0686	.1715
Avg	.3772	.4511	.3933	.3349	.3088	.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 204 / 11KV ALLOR GAOTHAN
(DDUGJY) Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572		.1829	.1981	.2286
2	.2743	.2572		.1829	.2286	.2286
3	.2591	.2572			.2743	.2743
4	.2743	.3429			.2743	.2743
5	.3048	.3429			.2591	.2743
6	.2896	.3429			.2591	.2743
7				.2743		
8				.2591		
9				.1829		
10	.2743			.1829	.1829	
11	.2572				.1981	
12	.2572			.2286	.1829	.2572
13	.2572		.2134	.2286		.2572
14	.2572		.1829	.1524	.1677	.2572
15	.1715		.1524	.1372	.1677	.2572
16	.1715		.1677	.1981	.1524	
17		.2743		.2286		
18	.3429	.3048	.1677	.2286		
19	.3429	.2896	.1981	.2286	.2286	.2572
20	.4287	.2286	.2439	.2286	.2286	.3429
21	.4287		.2286	.2439	.2134	.3429
22	.3429		.2286	.2439	.1981	.3429
23	.3429		.1981	.2286	.1829	.2572
24	.2743	.2572		.1524	.1677	.1677
Max	.4287	.3429	.2439	.2743	.2743	.3429
Min	.1715	.2286	.1524	.1372	.1524	.1677
Avg	.2913	.2868	.1981	.2102	.2091	.2684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194091 / 33/11 KV MADAJ SUBSTATION

Feeder No / Name : 201 / 11 KV MADAJ SINGLE PHASE SINGLE PHASING
FEEDE Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.1886	.2896		.1715	.2775	
2	.3482	.1886	.3258		.1543	.3116	
3	.3853	.2058	.3258		.1715	.3302	
4	.4224	.2229	.362		.1715	.3673	
5	.4596	.2572	.4656		.2058	.4045	
6	.5521	.4115	.6268		.2058	.5516	
7	.6774	.4801	.6805		.2401	.5337	
8	.6781	.4801	.6584				
9	.4287	.4287	.4755				
11							.2561
12							.3109
13	.4458	.3841	.4049	.3429	.3841	.4024	.3109
14	.4115	.3841	.4207	.3944	.3486	.4207	.3109
15	.3429	.3475	.4024	.2229	.349	.4207	.2926
16	.3429	.3475	.4207	.2229	.3677	.4207	.2926
17	.3429	.3475	.3658	.3086	.3479		.3475
18	.3429	.3475	.4207	.4115	.4399		.4207
19	.5144	.4938	.6584	.4973	.5853		.5853
20	.7716	.9145		.7888	.7889		.7316
21	.6687	.6706		.703	.6979		.567
22	.5316	.6036		.2229	.2942		.6036
23	.3944	.4755		.1886	.2577		.4755
24	.2939	.2058	.2534		.1886	.2587	
Max	.7716	.9145	.6805	.7888	.7889	.5516	.7316
Min	.2939	.1886	.2534	.1886	.1543	.2587	.2561
Avg	.4605	.3993	.4445	.3913	.3353	.3916	.4235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194091 / 33/11 KV MADAJ SUBSTATION

Feeder No / Name : 202 / 11 KV BABALSUR SINGLE SINGLE PHASING

PHASE FE Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1312	.128	.1341		.112	.1312	
2	.1478	.128	.1341		.128	.1642	
3	.1644	.144	.1509		.144	.1809	
4	.1811	.176	.1844		.16	.214	
5	.2142	.208	.2347		.192	.2469	
9				.4801	.4161	.4915	
10	.7682	.7459	.7209	.5281	.4641	.5741	
11	.9282	.9116	1.0242		.4275	.6203	.2753
12	.8642	.7625	1.0059	.5121	.4757		.421
13	.8642	.8785	.7773	.5761	.4774	.503	.4534
14	.8642	.8619	.8097	.5761	.4768		.1296
15	.8642		.8259	.5921	.5103	.57	.1134
16	.9122	.8951	.8421	.6882	.6592	.6371	.1134
17	.9122	1.065	1.1012	.128	.1481		.1457
18	.128	.1677	.1457	.144	.1807		.1457
19	.16	.2347	.2105	.16	.1802		.1943
20	.2881	.3018		.2561	.2466		.2429
21	.2561	.2515		.208	.1811		.2267
22	.192	.218		.16	.1648		.2753
23	.16	.1677		.128	.132		.2753
24	.1152	.112	.1509		.112	.1147	
Max	.9282	1.065	1.1012	.6882	.6592	.6371	.4534
Min	.1152	.112	.1341	.128	.112	.1147	.1134
Avg	.4558	.4399	.5283	.3669	.2852	.3707	.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194091 / 33/11 KV MADAJ SUBSTATION

Feeder No / Name : 203 / 11 KV WAGHDARI SINGLE SINGLE PHASING

PHASE FE Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6323	.6478	.7956		.4858	.3891	
2	.6655	.664	.8951		.4534	.3733	
3	.6988	.664	.9282		.4049	.4063	
4	.7322	.6964	.9831		.3563	.3905	
5	.7819	.7287	1.0159		.3077	.3905	
6	.9459	.8802	1.0978		.5668	.5538	
7	1.0701	1.1984	1.2289		.664	.6523	
8	1.0713	1.1174	1.0159				
9	.9878	.8907	.9995				
12							.3277
13	.1296	.1341	.1147		.0972	.0671	.5079
14	.1134		.1311		.1297	.0671	.5898
15	.1134		.1311	.3887	.0812	.0671	.5571
16		.1341	.1147		.0975	.0671	.5571
17	.1134	.1341	.1147	.1457	.1302		.1147
18		.1341	.1311	.1296	.1299		
19	.1781	.1844	.1475	.1781	.1943		
20	.2267	.2347		.2591	.2113		.1802
21	.2105	.2347		.2429	.2115		.1638
22	.2105	.2347		.4534	.3747		.1475
23	.1943	.218		.4858	.3747		.1475
24	.602	.6478	.7042		.5182	.3725	
Max	1.0713	1.1984	1.2289	.4858	.664	.6523	.5898
Min	.1134	.1341	.1147	.1296	.0812	.0671	.1147
Avg	.5094	.5146	.6205	.2854	.3047	.3164	.3293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194005 / 33/11KV NALDURGA

Feeder No / Name : 201 / 11KV NALDURG URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.1218
Max	1.1218
Min	1.1218
Avg	1.1218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194005 / 33/11KV NALDURGA

Feeder No / Name : 204 / 11KV TJR NP EXP BORI DAM NON SHEDDABLE EXPRESS HV FEEDERS
WW Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
1	.0168
Max	.0168
Min	.0168
Avg	.0168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194005 / 33/11KV NALDURGA

Feeder No / Name : 205 / 11KV SUGAR FACTORY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-JUN-18
HR	Load (MW)
1	.0147
Max	.0147
Min	.0147
Avg	.0147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194005 / 33/11KV NALDURGA

Feeder No / Name : 208 / 11 KV YEDOLA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.3561
Max	.3561
Min	.3561
Avg	.3561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 201 / 11 kv URBAN TULJAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.6461	1.5432	1.4575	1.3717		1.3717
2	1.4883	1.6461	1.5432	1.4403	1.4403	1.3289	1.3717
3	1.4883	1.6118	1.5089	1.4746	1.406		1.3717
4	1.4883	1.5947	1.4746	1.4403	1.4746	1.3289	1.3375
5	1.4883	1.5775	1.4746	1.4746	1.3717		1.3375
6	1.5238	1.5775	1.4575	1.4746	1.5089	1.5061	1.3375
7	1.4706	1.5432	1.4403	1.5089	1.3375	1.5592	1.3375
8	1.3643	1.4403	1.3717	1.5089		1.5238	1.3717
9	1.2934	1.4403	1.3717	1.3375		1.2757	1.286
10	1.2174	1.286	1.3203	1.2689	1.1871	1.2346	1.2517
11	1.2174	1.3375	1.2517	1.2174		1.166	1.2174
12	1.286	1.3375		1.1317	1.0985	1.166	1.1831
13	1.3717	1.3375	1.286	1.166		1.2003	1.2003
14	1.406	1.3375	1.3203	1.0974	1.0985	1.2003	1.2174
15		1.3717	1.3717	1.0802		1.2517	1.2689
16	1.5432	1.406	1.406	1.2174	1.2226	1.2346	1.3203
17	1.5775	1.406	1.4232	1.2003		1.286	1.3203
18	1.5466	1.3032	1.406	1.2003	1.2403	1.2689	1.3203
19	1.5432	1.5432	1.5775	1.4746		1.3375	1.4918
20	1.749	1.6804	1.6461	1.4403	1.5947	1.5432	1.5432
21	1.7318	1.6461	1.6804			1.5432	1.5775
22	1.7147	1.7147	1.6461	1.5947	1.5592	1.5089	1.6118
23	1.6975	1.6461		1.5432	1.5592	1.5089	1.6461
24	1.6655	1.6804	1.5432	1.5775	1.4232	1.4883	1.406
Max	1.749	1.7147	1.6804	1.5947	1.5947	1.5592	1.6461
Min	1.2174	1.286	1.2517	1.0802	1.0985	1.166	1.1831
Avg	1.4986	1.5046	1.4575	1.3620	1.3684	1.3553	1.3625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 202 / 11 kv APSINGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316	.9945		.5487		.6516
2		.8573	1.0974		.5792	.3429	.6859
3			1.166		.6097		.7202
4			1.2346		.6706	.3429	.7888
5			1.2689		.6097		.823
6			1.3032		.7621	.583	.823
7		1.3413	1.9547	.4877	.9602	.823	1.2689
8		1.5699	1.7833				
9		1.9814	1.0059				
10	.0762						
11	.2286						
12	.8688						
13	1.2193						
14	1.2003						
15	1.0974						
17	.9907						
19		.0686	.061	.0762		.0514	.0762
20	.0914	.061	.061	.0762	.0686	.0686	.061
21	.0914	.061	.0762	.0857		.0514	.0457
22	.0914	.0762	.0762	.061	.3429	.4801	.3201
23		.1029		.061	.3429	.4268	.6706
24		.7011	.8383		.061	.3429	.5316
Max	1.2193	1.9814	1.9547	.4877	.9602	.823	1.2689
Min	.0762	.061	.061	.061	.061	.0514	.0457
Avg	.5956	.6866	.9229	.1413	.5051	.3513	.5744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 203 / 11 KV KAKRAMBA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0892	1.2193	1.5775	.9755	1.0669		1.3717
2	.0892	1.2803	1.6804		1.0669	1.07	1.4403
3	.0892	1.3413	1.749		1.0974		1.6461
4	.0892	1.3717	1.8519		1.1279	1.07	1.7147
5	.0892	1.6766	1.9547				1.7147
6		1.829	1.768			1.382	1.7147
7		2.0119	2.1948			1.8724	2.2634
8		2.1948	2.1795				
9		2.1338	1.9814				
12	1.2346						
13	1.2193						
14	1.829						
15	2.0119						
19	.1829	.1524	.1829	.1829		.1715	
20	.1829	.1829	.1829	.1829	.0743	.2058	
21	.1829	.1829	.1829	.1829		.2058	
22	.1829	.2058	.1829	.7926	1.1294	1.1431	
23		.2058		.9145	1.174	1.286	
24	.0892	1.2193	1.2498	.4268	1.0364	1.1443	1.2346
Max	2.0119	2.1948	2.1948	.9755	1.174	1.8724	2.2634
Min	.0892	.1524	.1829	.1829	.0743	.1715	1.2346
Avg	.5401	1.1472	1.3513	.5226	.9717	.9551	1.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 204 / HANGARGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202		.0152	.0305	.0152		.0171
2	.7202	.0152	.0171	.0305	.0152	.0171	.0171
3	.7202	.0152	.0171	.0305	.0152		.0171
4	.7202	.0152	.0171	.0305	.0152	.0171	.0171
5	.7545	.0152	.0171	.0305	.0152		.0171
6	.8573	.0152	.0171	.0305	.0152	.0171	.0171
7	1.1317						
8	1.0631						
9	1.0288					.6859	.7316
10			.7621			.8383	.884
11			.945			.9145	.9755
12			1.0364			.7926	1.0212
13		.5792	1.0669			.884	
14		1.0059	.8993			1.0288	1.0059
15		1.0669	.8078	.7621		.945	.9907
16		1.1279	.9755	.945	.463	1.0669	.9907
17		1.1736	1.0669				
19	.0152	.0171	.0305	.0152		.0171	
20	.0305	.0152	.0305	.0152	.0171	.0171	
21	.0152	.0152	.0305	.0152		.0152	
22	.0152	.0152	.0343	.0152	.0171	.0152	
23	.0152	.0152		.0152	.0171	.0152	
24	.7202	.0152	.0153	.0305	.0152	.0171	.0152
Max	1.1317	1.1736	1.0669	.945	.463	1.0669	1.0212
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.5685	.3202	.4106	.1426	.0564	.4297	.4798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 205 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6598	1.6975	1.5432	1.4232	1.5089		1.3375
2	1.1317	1.6975	1.5432	1.406	1.5466	1.4335	1.3375
3	1.6032	1.6598	1.5089	1.406	1.5844		1.3032
4	1.6032	1.5844	1.4746	1.3717	1.5089	1.4335	1.3375
5	1.6032	1.5089	1.4746	1.3717	1.4146		1.3375
6	1.6221	1.4335	1.4746	1.3375	1.4712	1.5089	1.3375
7	1.6221	1.2689	1.3717	1.3032	1.5844	1.4712	1.3375
8	1.4901	1.3203	1.3032	1.286		1.4712	1.0631
9	1.4901	1.2071	1.3375	1.1488		1.2637	1.0974
10	1.4335	1.1317	1.2346	1.2003	1.358	1.1317	1.166
11	1.3203	1.3032	1.286	1.2003		1.2003	1.2003
12	1.3769	1.3375	1.3203	1.2449	1.2826	1.166	1.2346
13	1.4146	1.3375	1.3203	1.3203		1.166	1.2174
14	1.6975	1.3717	1.3717	1.3957	1.3203	1.2003	1.2003
15	1.7353	1.3717	1.3375	1.3203		1.2689	1.3032
16	1.6975		1.3546	1.4523	1.3203	1.2689	1.3375
17	1.6598	1.406	1.3375	1.4523		1.286	1.3203
18	1.5844	1.3375	1.3375	1.3769	1.4335	1.2003	1.3203
19	1.8484	1.5432	1.5261	1.6032		1.3717	1.5261
20	1.905	1.7147	1.5775	1.6975	1.773	1.5432	1.5432
21	2.1125	1.6804	1.5947	1.7164		1.5432	1.5604
22		1.6461	1.5432	1.773	1.7164	1.4403	1.5775
23	1.8107	1.5775	1.4575	1.3717	1.6598	1.4403	1.5604
24	1.7164	1.8484	1.3717	1.4918	1.5844	1.6032	1.3375
Max	2.1125	1.8484	1.5947	1.773	1.773	1.6032	1.5775
Min	1.1317	1.1317	1.2346	1.1488	1.2826	1.1317	1.0631
Avg	1.6147	1.4776	1.4168	1.4030	1.5042	1.3530	1.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 206 / 11 KV SALAGARA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4062	.0762	.0686	.0762	.0457		.0514
2	.3437	.0762	.0686	.0762	.061	.0625	.0514
3	.3437	.0762	.0686	.061	.061		.0514
4	.3437	.0762	.0686	.061	.0514	.0625	.0514
5	.3437	.0762	.0857	.0762	.0457		.0514
6	.3437	.0762	.0857	.0762	.0457	.0625	.0514
7	.4843						
8	.4687						
9	1.1873			1.0517		1.4712	1.2003
10		1.2803	1.448		1.1717	1.6804	1.3717
11		1.6461	1.8442	1.3413		1.8176	1.7375
12		2.0576	1.9052	.3201		1.7147	1.7833
13		1.9204	1.9204			1.8861	1.6766
14		1.749	1.7985	1.2193	1.4998	1.9204	1.4937
15		1.3717	1.448	1.4022		.7545	1.4784
16		1.9204	1.6461	1.6309	1.5623	1.6156	1.4937
17		1.989	1.9966				
19	.0762	.0686	.0762	.0762		.0686	.061
20	.0762	.0686	.1067	.0762	.0625	.0686	.061
21	.0762	.0686	.1372	.0762		.0514	.061
22	.0857	.0686	.1219	.0457	.0625	.0514	.061
23	.0762	.0686		.0457	.0625	.0514	.061
24	.3906	.0762	.0857	.0762	.0457	.0625	.0514
Max	1.1873	2.0576	1.9966	1.6309	1.5623	1.9204	1.7833
Min	.0762	.0686	.0686	.0457	.0457	.0514	.0514
Avg	.3364	.7405	.7884	.4327	.3675	.7883	.645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 207 / 11 KV KAKRAMBA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4572	.5144	.4268	.4572		.4572
2	.3734	.4572	.5144	.4268	.4268	.4268	.4572
3	.3734	.4268	.5487	.5182	.4268		.5487
4	.4268	.5792	.6706	.6097	.3658	.4801	.823
5	.4801	.6401	.7316	.6706			.7926
6	.8002	.8535	.9602			.6935	.9145
7	.8002	.9145	.884			.8002	.9145
8	.7468	.8535	.7621	.4877		.8002	.9755
9	.6935	.7011	.6097			.6935	.9259
10	.6173	.6097	.6097	.6097	.5335	.5182	.5487
11	.5182	.5487	.4268			.5182	.4877
12		.4268	.4877	.0305	.4001	.4572	.4268
13		.4458	.2591	.4877		.4801	.4572
14	.5487	.4268	.3658	.5144	.3734	.4458	.3658
15	.6097	.3963	.4877	.3658		.3658	.3963
16	.5487	.4458	.5487	.5487	.3201	.3658	
17	.6097	.3963	.6097	.4877		.4877	
18	.4877	.4877	.6097	.6097	.4001	.6706	
19	.7316	.6401	.7926	.7316		.823	
20	.7926	.8535	.7621	.6706	.8002	.9145	
21	.7316	.7621	.7316	.7316		.9259	
22	.6097	.6401	.6706	.5182	.4801	.6401	
23	.5487	.5487		.4572	.4801	.5182	
24	.4268	.4877	.4877	.4268	.4877	.4268	.5487
Max	.8002	.9145	.9602	.7316	.8002	.9259	.9755
Min	.3734	.3963	.2591	.0305	.3201	.3658	.3658
Avg	.5853	.5833	.6107	.5165	.4578	.5930	.6275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 208 / 11 KV APSINGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3429	.3772	.6172	.3086		.3772
2	.4024	.3772	.3772	.6172	.3429	.3658	.3772
3	.4024	.4115	.4115	.6858	.3772		.3772
4	.4024	.4458	.4801		.3772	.3658	.4115
5	.439	.4801	.5144		.4115		.4458
6	.5121	.4801	.5487		.4458	.5487	.4801
7	.4755	.5487	.5487	.2743	.4115	.4755	.5144
8	.439	.3429	.4801	.4115		.4755	.4115
9	.439	.3086	.4801	.3772		.4755	.4801
10	.3429	.3772	.4115	.3429	.4755	.3353	.4115
11	.2743	.3429	.3772	.3772		.3772	.4115
12	.3048	.3429	.3772	.3429	.3658	.3772	.3772
13	.2743	.3429	.4115	.3429		.3772	.3772
14	.3429	.3429	.3601	.3086	.2926	.3772	.3772
15	.3086	.3429	.3086			.3429	.3772
16	.3772	.3429	.3086	.4115	.2926	.3429	.3772
17	.3772	.3429	.2915	.3429		.3429	.4115
18		.3772	.3429	.3429	.439	.4115	.3429
19		.4115	.4458	.5487		.4458	.4801
20		.5144	.4458	.5144	.5487	.5487	.4801
21	.4801	.4801	.4115	.5144		.5144	.4801
22	.4458	.4801	.4115	.3429	.4755	.4801	.4458
23	.4115	.4115		.2743	.439	.3772	.4115
24	.4024	.3429	.3772	.3429	.3086	.4024	.3772
Max	.5121	.5487	.5487	.6858	.5487	.5487	.5144
Min	.2743	.3086	.2915	.2743	.2926	.3353	.3429
Avg	.3932	.3972	.4130	.4166	.3945	.4171	.4172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 209 / TIRTH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696		.2058	.3429	.2058		.3429
2	.3696		.2058	.3429	.2058	.3696	.3429
3	.3696	.2641	.2058	.3772	.2401		.3772
4	.3696		.2401		.3429	.3696	.4801
5	.4066	.4115	.3086		.4287		.5487
6	.5175	.5144	.3429		.5144	.5175	.583
7	.5544	.583	.3086		.5658	.5175	.5144
8	.4435	.3944	.4115			.5175	.4801
9	.4435	.3429	.4115			.4435	.3772
10	.2683	.2439	.2743		.3696	.3353	.3086
11	.2641	.2743	.3429	.3429		.3429	.3086
12	.2641	.2134	.3086	.3601		.2439	.2915
13	.3018	.2401	.2915			.2743	.2743
14	.0857	.2134	.2572	.3429	.2218	.2743	.2743
15	.3395	.2743	.2229	.3086		.2439	.2743
16	.3018	.2439	.2572	.2743	.2587	.2439	.2743
17	.3772	.2401	.3086	.1886		.2743	.2743
18	.3086	.2743	.3601	.3601	.3326	.3429	.3601
19	.4115	.3086	.3258	.5316		.4287	.4801
20	.4801	.4115	.5487	.5144	.6653	.5487	.5144
21		.5144	.6001	.5487		.5144	.5316
22	.3429	.4287	.4877	.4268	.4805	.381	.5144
23	.2915	.2401		.3429	.4066	.3772	.5316
24	.4066	.2572	.2058	.0857	.1886	.4066	.3429
Max	.5544	.583	.6001	.5487	.6653	.5487	.583
Min	.0857	.2134	.2058	.0857	.1886	.2439	.2743
Avg	.3603	.3280	.3231	.3557	.3618	.3794	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 210 / 11 KV TULJAPUR NP EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 WATE Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0514	.0514	.0343		.0514
2	.0343	.0343	.0514	.0514	.0343	.0343	.0514
3	.0343	.0514	.0514	.0514	.0343		.0514
4	.0343	.0343	.0514	.0514	.0343	.0343	.0514
5	.0343	.0514	.0514	.0514	.0514		.0514
6	.0343	.0514	.0514	.0514	.0514	.0343	.0514
7	.0686	.0514	.0514	.0514	.0686	.0343	.0514
8	.0686	.0514	.0514	.0514		.0343	.0514
9	.0514	.0343	.0514	.0514	.0514	.0343	.0514
10	.0514	.0457	.0514	.0686	.0686	.0514	.0514
11	.0514	.0457	.0514				.0514
12	.0514	.0514	.0514	.0343	.0514	.0514	.0514
13	.0514	.0514	.0514	.0514		.0457	.0514
14	.0514	.0457	.0514	.0514	.0514	.0514	.0343
15	.0343	.0514	.0514	.0514		.0514	.0514
16	.0514	.0514	.0514	.0514	.0514	.0514	.0514
17	.0343	.0514	.0343	.0514		.0514	.0343
18	.0343	.0514	.0514	.0514	.0514	.0514	.0343
19	.0343	.0514	.0514	.0514		.0514	.0514
20	.0457	.0514	.0514		.0343	.0686	.0514
21	.0514	.0514	.0343	.0514	.0686	.0514	.0514
22	.0514	.0514	.0514	.0343	.0343	.0514	.0514
23	.0343	.0514	.0514	.0514	.0343	.0514	.0514
24	.0343	.0343	.0514	.0514	.0514	.0343	.0514
Max	.0686	.0514	.0514	.0686	.0686	.0686	.0514
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0440	.0471	.0500	.0506	.0476	.0460	.0493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 405 / 33KV YEOTI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	2.6749	2.9835	1.9547	2.4691		2.1605
2	.9259	2.3777	3.1893	1.9547	2.572	2.572	2.3663
3	.9259	2.8807	3.2922	2.0576	1.4403		2.4691
4	.9259	3.0864	3.4979	2.1605	2.8807	2.572	2.572
5	1.0288	3.0864	3.6008	2.1605	2.6749		2.6749
6	1.4403	3.3951	3.7037	2.572	3.1893	3.1893	2.6749
7	.3086	3.6008	4.0124	2.7778	3.2922	3.2922	3.0864
8	1.0288	2.8807	4.1152	.6173	1.3375	.1029	.2058
9	1.5432	2.7778	3.0864	1.0288		1.0288	1.1317
10	2.9835	1.5432	.5144	1.3375	1.2346	1.6461	.9259
11	3.1893	2.1605	1.749	1.5432		1.6461	1.4403
12	3.6008	2.3663	2.1605	1.6461	1.6461	2.0576	1.6461
13	3.7037	2.4691	1.749	1.8519		1.749	1.6461
14		2.0576	1.6461	1.749	1.749	1.749	1.6461
15	3.4979	2.0576	1.8519	1.749		.4115	1.6461
16	1.8519	2.3663	2.1605	1.749	1.4403	1.749	1.5432
17	1.8519	2.1605	2.2634	1.8519		.3086	1.5432
18	.3086	.4115	.1029	.1029	.4115	.6173	.3086
19	.6173	.6173	.6173	.5144		.6173	.5144
20	.7202	.7202	.6401	.3086	.7202	.7202	.7202
21	.6173	1.2346	.6173			.6173	.6173
22	.5144	.6173	.5144		2.2634	1.0288	1.9547
23	.5144	.5144	2.1605		2.4691	1.8519	2.3663
24	.9259	2.4691	2.8807	.4115	2.4691	2.572	1.9547
Max	3.7037	3.6008	4.1152	2.7778	3.2922	3.2922	3.0864
Min	.3086	.4115	.1029	.1029	.4115	.1029	.2058
Avg	1.4761	2.1053	2.2129	1.5285	2.0153	1.5285	1.6590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 201 / 11 KV ITKAL AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746					
2	1.4746					
3	1.4746					
4	1.6385					
5	1.6385					
6	1.7695					
7	2.0481					
8	2.0972					
9					1.3927	1.5074
10				1.2125	1.5729	1.8351
11		1.1142	2.0481	1.9662	1.7204	2.0645
12		2.1136	2.3266	2.2283	1.8679	2.1464
13		2.4249	2.1792	2.0972	1.7859	1.8515
14		2.4249	2.1792	2.0972	1.4582	1.8679
15		2.0645	2.2119	2.0972	1.8679	2.2447
16		2.13	1.9662	1.8842	1.9006	1.9662
17		2.1956	1.8679			
24	1.4746					
Max	2.0972	2.4249	2.3266	2.2283	1.9006	2.2447
Min	1.4746	1.1142	1.8679	1.2125	1.3927	1.5074
Avg	1.6767	2.0668	2.1113	1.9404	1.6958	1.9355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 202 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	1.2146	1.2146		1.6194	1.6194	
2	.0972	1.3279	1.2955		1.6194	1.6194	
3	.0972	1.4251	1.2955		1.6194	1.749	
4	.0972	1.6032	1.6194		1.7814	1.9433	
5	.0972	1.749	1.9919		1.9433	2.1862	
6	.0648	1.9662	2.3967	1.6518	2.4291	2.2348	
7		2.1376	2.5101	2.0729	2.6073	2.4939	
8		2.1214	2.1862				
9		1.8785	2.0891				
10	1.2955						
11	1.8947						
12	2.0567						
13	1.9919						
14	1.7166						
16	2.0243						
17	1.8299						
19	.0972	.1134	.081	.0972	.1134		.0972
20	.1134	.1134	.1134	.0972	.1134		.0972
21	.1134	.1134	.1134	.0972	.0972		.0972
22	.0972	.1134	.0972	1.4251	1.3765		.9717
23	.0972	.1134		1.6194	1.5061		1.1012
24	.0972	1.1822	1.1822		1.6194	1.5384	
Max	2.0567	2.1376	2.5101	2.0729	2.6073	2.4939	1.1012
Min	.0648	.1134	.081	.0972	.0972	1.5384	.0972
Avg	.7356	1.1448	1.2990	1.0087	1.4189	1.9231	.4729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 203 / 11 KV ITKAL GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.5316	.5316	.2303	.5316	.4607	
2	.4961	.6201	.5847	.2835	.5316	.4961	
3	.4961	.6201	.6024	.2835	.5316	.443	
4	.5316	.7087	.6024	.2835	.6024	.4607	
5	.7087	.7796	.6733	.3189		.4961	
6	.8505	.8859	.7619	.3721	.7442	.815	
7	.7796	.8505	.7265	.3898	.8505	.7619	
8	.7442	.8328	.7087	.3544	.7087	.6201	
9	.6379	.7087	.691	.3898	.567	.6024	
10	.6733	.691	.5847	.4784	.5493	.6024	
11	.6024	.6379	.6733	.4252	.567	.6201	
12	.6379	.6556	.6733	.3544	.5493	.6733	
13	.6379	.6733	.6379	.5847	.5493	.5138	
14	.6379	.691	.6201	.6024	.567	.5316	
15	.7087	.691	.6733	.6379	.5847	.5493	.3189
16	.7087	.6733	.6379	.691	.6024	.6733	.6201
17	.3721	.6556	.7087	.7265	.6733		.7619
18	.5493	.7087	.7619	.7796	.6379		.7442
19	.8328	.8505	.9391	.8505	.815		.7265
20	.9036	.815	.8682	.9391	.6733		.7796
21	.7973	.7442	.6733	.7796	.6556		.6556
22	.6733	.6733	.5138	.6733	.567		.567
23	.6024	.6379		.6024	.5138		.5138
24	.567	.5316	.5316		.5316	.4961	
Max	.9036	.8859	.9391	.9391	.8505	.815	.7796
Min	.3721	.5316	.5138	.2303	.5138	.443	.3189
Avg	.6519	.7028	.6687	.5231	.6132	.5774	.6320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 204 / 11 KV VAISHNODEVI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.415	.3772	.3206	.3018	.2829	
2	.4527	.415	.3772	.3395	.3018	.3206	
3	.4527	.4527	.3772	.3584	.3018	.3206	
4	.4527	.4904	.3961	.3584	.3018	.3018	
5	.4904	.4904	.3961	.4904	.3018	.3772	
6	.4904	.5281	.3961	.4904	.3395	.3018	
7	.4904	.4338	.3018	.4527	.3018	.2829	
8	.3018	.4338	.2829	.3961	.1886	.2829	
9	.3772	.4904	.3018	.3395	.3018	.3206	
10	.3018	.415	.2452	.3018	.3018	.3206	
11	.3961	.4338	.3018	.3772	.3018	.3772	
12	.415		.2829	.415	.3018	.3961	
13	.4338	.4338	.3206	.4527	.3772	.3206	
14	.2829	.415	.3018	.4527	.3584	.3018	
15	.3772	.4338	.415	.4527	.3772	.3206	.3772
16	.4527	.3395	.3206	.3772	.3018	.3395	.2829
17	.3961	.2641	.3772	.3395	.3584		.3395
18	.3961	.2452	.3206	.3018	.3772		.2829
19	.3395	.3018	.3961	.3395	.3395		.3018
20	.3206	.3206	.3206	.3395	.3772		.3018
21	.3961	.3395	.2641	.1886	.2452		.3961
22	.3772	.3206	.3772	.3018	.132		.415
23	.3584	.3584		.3018	.1509		.415
24	.3772	.3961	.3772	.3395	.3018	.1886	
Max	.4904	.5281	.415	.4904	.3772	.3961	.415
Min	.2829	.2452	.2452	.1886	.132	.1886	.2829
Avg	.3992	.3986	.3403	.3678	.3018	.3151	.3458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 201 / 11 KV TAMALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3535	1.0242	1.134				
9				.5487	.1829	.9877	
10							.8413
15						1.0136	
16	.9145	1.6095	1.6461	.6401			1.1888
23			.5487		.5121		
24	.7316	.5853		2.0576	.4024	.5487	.6219
Max	1.3535	1.6095	1.6461	2.0576	.5121	1.0136	1.1888
Min	.7316	.5853	.5487	.5487	.1829	.5487	.6219
Avg	.9999	1.073	1.1096	1.0821	.3658	.85	.884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 202 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1448	.1448	.0724
9	.1829			
16	.181	.2926	.2172	.2378
24	.4287	.1463	.1463	.1097
Max	.4287	.2926	.2172	.2378
Min	.181	.1448	.1448	.0724
Avg	.2642	.1946	.1694	.1400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 203 / 11 KV TAMALWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3258	.3258	.3658	.2926
16	.2715	.3658	.2926	.2926
23	.3429			
24		.3258	.3292	.2926
Max	.3429	.3658	.3658	.2926
Min	.2715	.3258	.2926	.2926
Avg	.3134	.3391	.3292	.2926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 201 / 11 KV SALGARA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)
10	.6201	
13	.8505	
14	.6556	
15	.6733	
16	.8505	
17	.9568	
19	.7442	
20	.7973	
21	.6733	
24		.4075
Max	.9568	.4075
Min	.6201	.4075
Avg	.7580	.4075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 203 / 11 KV DEVSINGA TUL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAY-18
HR	Load (MW)
10	.2481
14	.124
15	.124
16	.1949
17	.1949
18	.2658
19	.3658
20	.4252
21	.3841
Max	.4252
Min	.124
Avg	.2585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 204 / 11 KV WADGAON DEV SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAY-18
HR	Load (MW)
10	.567
12	1.5415
13	1.5061
14	1.134
15	1.382
16	1.5061
17	1.5947
19	.1772
20	.3189
21	.3366
Max	1.5947
Min	.1772
Avg	1.0064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 205 / 11 KV GANDHORA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAY-18
HR	Load (MW)
10	.3601
12	1.1163
13	1.1163
14	1.0631
15	1.0985
16	1.134
17	.8859
18	.3544
19	.4252
20	.4784
21	.4607
22	.3544
Max	1.134
Min	.3544
Avg	.7373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 206 / 11 KV KILAJ SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAY-18
HR	Load (MW)
13	.2658
14	.2303
15	.2303
16	.2303
17	.1949
20	.5121
21	.4252
Max	.5121
Min	.1949
Avg	.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 201 / 11 KV GANJEWADI SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	2.0233
Max	2.0233
Min	2.0233
Avg	2.0233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 202 / 11 KV SAWARGAON SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0446
Max	.0446
Min	.0446
Avg	.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 203 / 11 KV WADGAON SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 205 / 11 KV KEMWADI SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0274
Max	.0274
Min	.0274
Avg	.0274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 201 / 11 KV HANGARGA FEEDER-SPP SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	.5487	.5144		.5256
2	1.3717	.5144	.4908		.5087
3	1.4575	.6173	.583		.4578
4	1.5089	.6687	.6687		.5959
5	1.5775	.6859	.7545		.6443
6	1.5432				
7	1.6289			.6201	
8	1.4575			.691	.6874
9	1.5432			1.2651	1.0852
10		1.5261	1.7857	1.5023	1.0974
11		1.9719	1.9719	1.5592	1.2003
12		1.8176	1.8861	1.7772	1.3717
13		1.8004	2.0576	1.7436	1.406
14		1.7635	1.9719	1.6598	1.406
15		1.8482	2.0576	1.7269	1.3717
16		1.95	2.1434	1.5089	1.406
17		2.1874	2.2291	.4801	.4287
18		.4578	.4287		.7202
19		.5765	.6001	.6516	.6859
20		.8145	.5144	.7011	.7202
21	.6859	.7122		.6539	.6859
22	.6173	.7461		.5868	.6516
23	.6001	.6443		.5596	.583
24	1.1145	.6001	.5658	.5316	
Max	1.6289	2.1874	2.2291	1.7772	1.406
Min	.6001	.4578	.4287	.4801	.4287
Avg	1.2609	1.1226	1.2485	1.0717	.8685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 202 / 11 KV SINDGAON SPP FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.5144	.4801			.5087
2	1.286	.5144	.4973			.4748
3	1.3717	.583	.5487			.5765
4	1.286	.6173	.583			.6104
5	1.3717	.6516	.6173			.6783
6	1.4575				.6201	.7122
7	1.5432				.6024	
8					.5316	
9					.8539	.8048
10			1.406		1.186	.8916
11		1.7635	1.8861		1.2811	.9431
12		2.0687	1.9719	.3772	1.2498	.9945
13		1.7804	2.0576	1.0117	1.2186	1.0288
14		1.933	1.9719	1.046	1.2651	1.0288
15		2.0348	1.8176	1.0117	1.153	1.0288
16		2.0687	1.9719	1.1317	1.3565	.9945
17		1.6956	2.0576	1.0974	.4409	.3429
18		.4409	.4458	.4458		.4287
19		.5765	.4458	.6173	.5533	
20		.7461	.6001	.6516	.57	.6173
21	.7202	.6859			.5765	.6516
22	.6859	.6104		.6859	.5935	.6516
23	.583	.583		.6173	.5765	.6173
24	.4287	.5487	.5316		.5138	.5365
Max	1.5432	2.0687	2.0576	1.1317	1.3565	1.0288
Min	.4287	.4409	.4458	.3772	.4409	.3429
Avg	1.0849	1.0746	1.1700	.7903	.8413	.7201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 203 / 11 KV NANDGAON SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.7888			
2		.3429	.823			
3		.3772	.8916			
4		.4458	.9602			
5		.463	1.0117			
6		.4801	1.0631		.8697	
7			1.1317		.9172	
8		.7716	1.166			
9		.9088	1.0288	.5144		
11	.4801					
14						.3772
15						.3429
16		.4527	.3772	.3601	.5087	.4115
17		.4801	.4287	.3601	.503	.4287
18		.5487		.3772		.6001
19		.583	.5144	.5316		
20		.8745	.5487	.6516		.5144
21	.7545	.8573		.703		.6859
22	.703	.6687		.6344		.8573
23	.6001	.583		.583		.8916
24		.3429	.7545		.6009	
Max	.7545	.9088	1.166	.703	.9172	.8916
Min	.4801	.3429	.3772	.3601	.503	.3429
Avg	.6344	.5602	.8206	.5239	.6799	.5677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 205 / 11KV LOHGAON SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.4458	.6516			.3391
2	.2572	.463	.6687			.3222
3	.2743	.5144	.703			.3052
4	.2915	.5487	.7202			.3391
5	.2915	.6001	.7373			.3222
6		.6344	.7545	.2743	.5218	.373
7		.4973	.7373		.4586	.463
8		.6859	.7545			
9		.583	.703	.2743		
10	.463					
11	.5658					
12	.6859					
14					.0838	
15					.0671	.1029
16		.0857	.12	.1372	.0648	
17		.1029	.1029	.0137	.0857	
18		.12	.12	.1372		.1715
19		.1886	.1715	.2229		.2058
20		.2401		.2401	.2543	.2401
21	.2229	.2229		.2572	.2374	.2058
22	.2058	.2401		.3772	.3052	.4287
23	.2058	.2058		.6173	.2883	.3772
24	.2572	.4458	.6173		.3479	.3222
Max	.6859	.6859	.7545	.6173	.5218	.463
Min	.2058	.0857	.1029	.0137	.0648	.1029
Avg	.3301	.3791	.5401	.2551	.2468	.3012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 201 / 11 KV HORTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926		.3258	.1753	.2896	.2229
2	.3258	.2984	.362	.1772	.3292	.2279
3	.3155		.3801	.2629	.362	.2658
4	.3982	.2818	.4706	.2835	.4252	.3292
5	.4588		.543	.298	.4706	.3467
6	.5792	.5533	.6335	.4252	.5068	.5258
7	.6584	.503	.6335	.4961	.5853	.5487
8	.5853	.5533	.5611	.5258	.5487	.5847
9	.5792	.431	.4887	.4207	.4755	.463
10	.3315	.4191	.3721	.3544	.3681	.3294
11		.3258	.2774	.3109	.2601	
12	.2818	.3077	.3258	.3109	.1907	.2818
13		.2715	.2947		.1907	
14	.2486	.181	.2804		.1715	.2486
15			.2254	.2926	.1753	
16		.2353	.2629	.2534	.2229	
17		.2896	.3121	.2622	.3012	
18	.3315	.362	.3721	.4207	.2947	
19		.4525	.3988	.4572	.4477	
20	.57	.5249	.4961	.5121	.4607	
21		.4163		.426	.4161	
22	.3149	.3439		.5121	.2804	
23		.3258		.3292	.2572	
24	.2896	.2652	.2896		.2926	.2254
Max	.6584	.5533	.6335	.5258	.5853	.5847
Min	.2486	.181	.2254	.1753	.1715	.2229
Avg	.4101	.3671	.3955	.3574	.3468	.3538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 202 / 11 HORTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192					
2	1.0526					
3	1.1336					
4	1.1797					
5	1.1797					
6	1.1069					
7	2.1052	1.2574	1.8461		.426	.5864
8	2.2939	1.8031	1.8299		.4344	.6401
9		1.8204	1.587		.6167	.5247
10	1.1736	1.7511	1.6057		.4475	.5937
11			1.5432		.5182	
12	1.4754		1.6404		.4572	1.0059
13			1.7404		.5535	
14	1.4754	.8745	1.6004	.4096	.5247	1.1401
15			2.0557	.9393	.8796	
16		2.2672	2.1296	1.0688	.9907	
17		2.3482	2.2297	1.1544	.9602	
18		2.2672	2.1822	1.2289	.933	
19		2.0081	1.9044	1.2289	.9217	
20		.5249	1.9334	1.1469	.8362	
21		2.0567		1.1523	.6241	
22		2.0891		1.0202	.6483	
24	.7373					
Max	2.2939	2.3482	2.2297	1.2289	.9907	1.1401
Min	.7373	.5249	1.5432	.4096	.426	.5247
Avg	1.3110	1.7557	1.8449	1.0388	.6733	.7485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 203 / 11 KV MURTA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5708		.9145
2		1.0059	1.5708		.8977
3			1.6032		.9214
4		1.1568	1.6194		.945
5			1.6518		1.012
6		1.4754	1.7004		1.0936
14				.9012	
16	2.3034				
18	2.3034				
20	1.8898				
22	1.8378				
23		1.5546		.953	
24		1.7337	1.5546		.9217
Max	2.3034	1.7337	1.7004	.953	1.0936
Min	1.8378	1.0059	1.5546	.9012	.8977
Avg	2.0836	1.3853	1.6101	.9271	.9580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 201 / 11 KV NANDURI SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	1.0498	.7948		.7602
2	.2172	1.1765	.7948		.8326
3	.2534	1.3032	.8516		.9412
4	.2715	1.4118	.9084		1.0136
5	.2896	1.5565	.9652		1.0136
6	.181	1.647	.9765		1.1222
7	.3258	1.6289	.9652		1.1946
8	.3077	1.3756	.9652		1.2127
9		1.3575	.9538		.2715
10	1.0136	.2353	.1713		
11	1.5565	.2172	.1713		
12	1.5927	.2092	.2286		
13	1.7375	.2852	.2665	.181	
14		.2852	.2665	.181	
15	1.5927	.2852	.2175	.181	
16	1.5565	.2284	.2175	.1991	
17	1.5746	.2472	.2177	.2353	
18	.2715	.2474	.2051	.2715	
19	.2896	.2474	.4182	.3077	
20	.2896	.2284	.3847	.3439	
21	.3077	.3045	.3042	.3077	
22	.2715	.3045	.2509	.2715	
23	.1991	.2474		.5068	
24	.2353	.8326	.7721	1.2003	.6516
Max	1.7375	1.647	.9765	1.2003	1.2127
Min	.181	.2092	.1713	.181	.2715
Avg	.6598	.7047	.5334	.3489	.9014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 202 / 11 KV KATGAON SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362			
2	.0543			
3	.0724			
4	.0724			
5	.0905			
6	.0905			
7	.1267			
8	.1267			
9	.0905			
10		.0724		
11		.1991	.3247	
12		.2162		
13		.2175	.1673	
14		.1004	.1709	
15		.1004	.2512	
16		.1004	.3764	
17		.1171		
24	.0362			.3429
Max	.1267	.2175	.3764	.3429
Min	.0362	.0724	.1673	.3429
Avg	.0796	.1404	.2581	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 203 / 11 KV ARALI SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.5792	.716		.5792
2	.8326	.5792	.7537		.5792
3	1.0136	.6516	.7537		.6516
4	1.0498	.8688			.6516
5	1.086	1.0136	1.0363		.8688
6	1.086	1.1584	1.2436		1.2127
7		1.1403	1.6016		1.1041
8			1.5074		.9593
9	1.4299				.8507
10	.4163	1.3756	1.1871		.9412
11	.4344	1.7918	.716		1.2489
12	.4344		1.7142		
13	.3982	1.8662	1.7701	1.3394	
14	.362	2.5909	1.3602	1.3032	
15	.3801	1.8843		1.267	
16	.4525			1.2851	
17	.5068			1.2308	
18	.6516	.6195		1.1765	
19	.9412	.9371		.7602	
20	1.086	.8663		1.086	
21	.9774	.8635		1.0136	
22	.8688	.8654		.8688	
23	.7059	.816	.7639	.8145	
24	.5249	.6516	.716	2.572	.6878
Max	1.4299	2.5909	1.7701	2.572	1.2489
Min	.362	.5792	.716	.7602	.5792
Avg	.7421	1.1115	1.1314	1.2264	.8613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 204 / 11 KV YEOTI SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.8326	1.2087	
2	.2353	.9774	1.2087	
3	.2534	1.086	1.3043	
4	.3077	1.1222	1.4876	
5	.3982	1.1765	1.484	
6	.4706	1.2127	1.7665	
7	.4344	1.3575	1.8037	
8	.3801	1.2489	1.7665	
9	.3982	1.267	1.5434	
10	.362	.2896		
11	1.3032	.2353		
12	1.4118	.2231	.2975	.2789
13	1.4842	.2422	.2975	
14	1.4661	.2603	.2975	
15	1.4118	.2772		
16	1.3756	.2975		
17		.3161		
19		.5392		
20		.5392		
21	.543		.5578	
22	.4525			
23	.3439	.3719	.5578	
24	.2353	.6878	1.2273	1.3717
Max	1.4842	1.3575	1.8037	1.3717
Min	.2172	.2231	.2975	.2789
Avg	.6742	.6933	1.1206	.8253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194078 / 33/11 KV FULWADI SUBSTATION

Feeder No / Name : 201 / 11 KV FULWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4272	2.2032			1.1317	1.6804
2	2.4272	2.2405			1.1317	1.643
3	2.3899	2.3525			1.1506	1.643
4	2.3899	2.3899			1.1694	1.6057
5	2.3899	2.452			1.1694	1.531
6	2.2965				1.1694	1.5684
7			.5228	2.3899	2.5019	2.2405
8			.5228	2.3899	2.6139	2.7633
9		.3772	.4481	2.5766	2.7073	2.838
10		.5228	.4481	2.2592	2.5766	2.7633
11			.4854	2.5019	2.4272	
12		.5228	.3734	2.4646	2.3152	
13		.4668	.5228	1.9616	2.2405	
14			.5041	2.2032	2.1658	
15	1.4937	3.0994	3.3608			
16	1.5497	3.3981	3.4915			
17			3.3981			
18			3.3421			
19			3.1181			
20			2.6139			
21			2.3712			
23	2.0538			1.0374	1.643	
24	2.4646	2.2405		2.2291	1.094	1.6804
Max	2.4646	3.3981	3.4915	2.5766	2.7073	2.838
Min	1.4937	.3772	.3734	1.0374	1.094	1.531
Avg	2.1882	1.8555	1.7015	2.2013	1.8255	1.9961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194078 / 33/11 KV FULWADI SUBSTATION

Feeder No / Name : 202 / 11 KV ANDUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	.985	1.0242		1.1458	.9774
2	1.2012	1.0029	1.0498		1.1458	.9774
3	1.3306	1.086			1.3306	1.0242
4	1.5497	1.267	1.386		1.4563	1.4266
5	1.7177	1.6095	1.6617		1.531	1.4784
6		1.7193	1.6991		1.5684	1.5684
9	1.4299	1.4632	1.4784	1.6278	1.4083	1.2382
10	1.2536	1.2757	1.423	1.3352	1.1523	1.0974
11	1.1203		1.3443	1.2357	1.0136	
12			1.1389	1.1283	.8954	
13	.9568	1.0456	1.0829	.9214	.8775	
14	1.0029	.9774	1.0456		.8775	
15	.8596	.9391	1.0829		.9036	
16	.8417	1.0566	1.1016	1.1283	.8954	
17	.8764		1.2136	1.0808	1.0745	
18	1.0745		1.251	1.1163		
19	1.267		1.531	1.3032		
20	1.39		1.5684	1.5927	1.4998	
21	1.2437		1.6057	1.3253	1.2567	
22	1.1157		1.3256	1.1827	1.0974	
23	1.0498			1.0903	1.0349	
24	1.1458	.9774	1.0059	.8573	1.0719	.9511
Max	1.7177	1.7193	1.6991	1.6278	1.5684	1.5684
Min	.8417	.9391	1.0059	.8573	.8775	.9511
Avg	1.1814	1.1850	1.3010	1.2090	1.1618	1.1932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194078 / 33/11 KV FULWADI SUBSTATION

Feeder No / Name : 203 / 11 KV ANDUR CHIVARI AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.5813		
4		1.6518		
5		1.6518		
6		1.668		
7	1.873			
9	1.7341			
10	1.9334			
11	1.8785			
14	2.0805			
15			1.7444	1.8564
16			2.2542	1.9204
17			2.0005	1.7924
18			1.9364	
19			1.9044	
20			1.7764	1.4706
21			1.6644	1.4685
22			1.6804	1.4864
24		.9172	2.0576	
Max	2.0805	1.668	2.2542	1.9204
Min	1.7341	.9172	1.6644	1.4685
Avg	1.8999	1.4940	1.8910	1.6658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 201 / 11 KV SHAHAPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9231	1.2654		1.1717	1.5061	.8436
2		1.004	1.2967		1.1717	1.5708	.8749
3		1.1174	1.3748		1.2186	1.7004	.8905
4		1.247	1.3904		1.0936	1.7652	.8905
5		1.3279	1.3904		1.4373	1.8299	.9686
6		1.5061	1.7185		1.656	1.9757	1.4685
7		1.749	2.1091	1.7029	1.9997	2.0405	1.9372
8		1.7814					
9		1.587					
10	1.7185						
11	1.9433						
12	2.0405						
13	1.9757						
14	2.0405						
15	2.0729						
16	2.0405						
17	1.9757						
18						.0312	
19		.0312				.0312	
20		.0312				.0312	
21		.0312				.0312	
22		.0312		1.0623	1.2793	.9217	.953
23		.0312		1.0936	1.3765	.9061	.9998
24		.7935	1.2186		1.1405	1.4575	.9374
Max	2.0729	1.7814	2.1091	1.7029	1.9997	2.0405	1.9372
Min	1.7185	.0312	1.2186	1.0623	1.0936	.0312	.8436
Avg	1.9760	.8795	1.4705	1.2863	1.3545	1.1285	1.0764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 202 / 11 KV SHAHAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2534	.2561		.2378	.2172	.1097
2	.2195	.2353	.2743		.2378	.2353	.128
3	.2561	.2715	.2926	.2378	.2561	.2715	.1463
4	.3292	.3077	.3109	.2561	.2926	.3077	.1463
5	.4207	.3801	.3292	.2743	.3475	.3563	.2012
6	.4755	.5249	.4755	.3109	.439	.5068	.3109
7	.4938	.4706	.439	.2743	.4024	.4344	.2743
8	.3658	.4344		.2561	.3841	.3982	.2743
9	.3109	.4163	.3841	.1829	.3292	.3077	.2012
10	.2561	.3077	.3475	.1646	.2896		.1646
11	.2353	.2561	.2743		.1991	.2561	.1463
12	.2715	.2926		.1829		.2195	.128
13	.2534	.2378	.3109		.1267	.2195	.1829
14	.2534	.2378	.2926		.1086	.2195	.2561
15	.2715	.2378	.2743	.1463	.181	.2195	.2378
16	.2896	.2561	.2926	.2195	.2172	.2195	.2378
17	.3439	.2561	.2926	.2378	.2534		.2743
18	.3801	.2743	.3109	.2195	.2896	.1829	.4024
19	.4525	.439	.3658	.2743	.3982	.2195	.4207
20	.4163	.4755	.3475	.2743	.362	.3475	.3841
21	.3801	.4024	.2926	.2378	.3258	.3109	.3475
22	.362	.3109	.2743	.2378	.2896	.2743	.2926
23	.3258	.2926		.2561	.2534	.2743	.2561
24	.2378	.1981	.2743		.2561	.2172	.2561
Max	.4938	.5249	.4755	.3109	.439	.5068	.4207
Min	.2195	.1981	.2561	.1463	.1086	.1829	.1097
Avg	.3258	.3237	.3196	.2357	.2816	.2825	.2408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 203 / 11 KV DAHITANA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655						
2	.7186						
3	.7499						
4	.7499						
5	.7811						
6	.7186						
7	1.0936						
8	1.0623						
9	.9686			.7655	.8124	1.004	.7343
10		.7935	1.0155	.8592	1.004	1.1092	.8905
11		1.078	1.2029	.9374	1.0688	1.1561	.9842
12		1.1092	1.2342	1.0311	1.0526	1.1092	.9374
13		.6249	1.2186		1.1174	1.1405	.9217
14		1.1717	1.1248		1.1822	1.0623	.9998
15		1.1873	1.0936	.9998	1.1984	1.0311	1.0155
16		1.1561	1.078	1.078	1.1822	1.0467	1.0623
17		1.1248	1.0155				
24	.7343						
Max	1.0936	1.1873	1.2342	1.078	1.1984	1.1561	1.0623
Min	.7186	.6249	1.0155	.7655	.8124	1.004	.7343
Avg	.8342	1.0307	1.1229	.9452	1.0773	1.0824	.9432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 201 / 11 KV KUMBHARI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.6401	.9175	.5868	.7468	1.0486	.6539
2	.0503	.7621	.9503	.6371	.6668	1.0814	.6706
3	.0503	.7773	1.0159	.6706	.6668	1.0978	.7042
4	.0503	.7335	1.0322	.7042	.6802	1.0978	.7042
5	.0503	.8993	1.0486	.7545	.6935	1.1142	.7377
6	.0503	.9755	1.0486	.8215	.7335	1.1305	.7712
7	.0503	.9869	1.2289	.9054	.9069	1.2616	.8048
8	.0503	.9602	1.278	1.0227	.0457	.0503	.0503
9	.0457	.9297	1.1961	.8993	.0457	.0335	.0457
10		.0503	.0503	.0457		.0335	.0457
11	.9755	.0503	.0503	.0457	.0335	.0503	.0457
12	1.0212	.0335	.0503	.0457		.0503	.0457
13	1.2498	.0335	.0503	.0457	.0503	.0503	.0457
14	1.1279	.0335	.0503	.0457	.0503	.0335	.0457
15	1.1126	.0503	.0503	.0457	.0503	.0335	.0457
16	1.1126	.0503	.0503	.0457	.0503	.0335	.0457
17	1.0822	.0335	.0503	.0457	.0503	.0335	.0457
18	.061	.0335	.0503	.0457	.0503	.0335	.0457
19	.061	.0335	.0503	.0457	.0503	.1006	.0762
20	.061	.0503	.0503	.0457	.0671	.0671	.061
21	.0762	.0503	.0671	.0457	.0671	.1006	.061
22	.0762	.0503	.0671	.6706	.8848	.6036	.5335
23	.061	.0503	.0503	.7011		.6539	.5487
24	.0503	.6859	.8848	.5868	.7468	1.0159	.6539
Max	1.2498	.9869	1.278	1.0227	.9069	1.2616	.8048
Min	.0457	.0335	.0503	.0457	.0335	.0335	.0457
Avg	.3729	.3731	.4724	.3962	.3494	.4504	.3120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 202 / 11 KV MANGRUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.1524	.1341	.0838	.1219	.0671	.0671
2	.5365	.1524	.1341	.0838	.1219	.0671	.0671
3	.5533	.1524	.1341	.0838	.1219	.0671	.0671
4	.5533	.1524	.1341	.0838	.1219	.0671	.0671
5	.6036	.1524	.1341	.0838	.1219	.0671	.0671
6	.7042	.1524	.1341		.1219	.0671	.0838
7	.9389	.1524	.1341		.1372	.0838	.0838
8	1.0562	.1524	.1341		.1372	.1006	.0838
9	.8383	.1524	.1341		.5468	.7373	.4572
10	.1067	.6226	.8048	.442	.7373	.9556	.5601
11	.1067	.8684	1.0227	.4801	.852	1.1233	.7868
12	.1067	1.0486	1.1065	.4801		1.1736	.945
13	.1067	1.1142	1.1401	.4801	.9012	1.2239	.9145
14		1.0814	1.1401	.6802	.9339	1.1736	.884
15		1.0814	1.1401	.884	.9339	1.1233	.823
16	.1372	1.1469	1.1233	.8269	.9503	1.1568	.8993
17	.1524	1.1961	1.1233	.1524	.0671	.0838	
18	.1524	.1341	.0734	.1372		.0671	.0762
19	.1524	.1341	.0838	.1219	.1006	.1006	.1067
20	.1524	.1341	.0838	.1372	.1174	.1174	.1067
21	.1524	.1341	.1006	.1372	.1174	.1006	.1067
22	.1372	.1341	.1006	.1372	.0838	.0838	.0762
23	.1372	.1341	.0838	.1219		.0671	.0762
24	.5365	.1372	.1341	.0838	.1219	.0671	.0671
Max	1.0562	1.1961	1.1401	.884	.9503	1.2239	.945
Min	.1067	.1341	.0734	.0838	.0671	.0671	.0671
Avg	.3829	.4364	.4362	.2861	.3557	.4142	.3249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 203 / 11 KV MANGRUL GAONTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2591	.2785	.2515	.2439	.2949	.2515
2	.2515	.2591	.2949	.2515	.2439	.3277	.2515
3	.3018	.2591	.3277	.2683	.2439	.3605	.3018
4	.3688	.3048	.3932	.3185	.3048	.426	.3353
5	.4694	.3963	.4588	.4024	.3506	.032	.3856
6	.5197	.503	.5243	.4694	.4877	.5735	.4527
7	.4862	.4268	.4588	.4527	.4877	.4752	.5197
8	.381	.4115	.2622	.3856	.3963	.3932	.4527
9	.3353	.3201	.2785	.3048	.3201	.3605	.3201
10	.2591	.2949	.2515	.2591	.3113	.3185	.2134
11		.3113	.2515		.2949	.2515	.1981
12		.2949	.2683	.2896		.2515	.1219
13		.2785	.3018	.2591	.2622	.2347	.1219
14	.2439	.2622	.285	.2439	.2622	.2515	.1372
15	.2591	.2785	.285	.2591	.2785	.2683	.1981
16	.2591	.2294	.3185	.2134	.2785	.2683	.2134
17	.3048	.2949	.3353	.2439	.2622	.285	.2286
18	.3201	.2949	.3521	.3048		.285	.2896
19	.3658	.4588	.5197	.3658	.4588	.3521	.3963
20	.4268	.4915	.4694	.3506		.4191	.3658
21	.381	.3932	.3856	.3506	.3932	.3521	.3353
22	.3353	.3605	.3185	.2896	.3441	.3018	.2896
23	.2743	.2949	.285	.2743		.2515	.2743
24	.2515	.2591	.2785	.2515	.2439	.2785	.2515
Max	.5197	.503	.5243	.4694	.4877	.5735	.5197
Min	.2439	.2294	.2515	.2134	.2439	.032	.1219
Avg	.3355	.3307	.3409	.3070	.3234	.3172	.2877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194095 / 33/11KV Chavanwadi Sub-Station

Feeder No / Name : 201 / 11 KV CHAVANWADI SPP SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.7621	.6706		.6097	.6706	.5792
2	.0686	.7621	.6706	.4097	.6401	.6097	.5792
3	.0686	.7468	.6706	.4609	.6401	.5944	.5792
4	.0857	.6401	.7042	.4945	.6401	.6249	.6097
5	.1029	.6554	.7209	.4263	.6706	.6401	.6401
6	.1029	.7926	.7545	.5804	.6706	.6859	.7011
7	.0857	.8688	.7545	.5633	.7468	.6401	.7773
8	.0857	.7316	.7545	.1023	.0857	.0857	.0853
9	.0686	.8048	.9389	.1023	.0686	.0838	.0853
10	.7316	.0671	.0683	.0857	.0686	.0838	.0681
11	.884	.0503	.0512	.0686	.0514	.0838	.0681
12	.9602	.0503	.0512	.0686	.0514	.0838	.0512
13	.9755	.0503	.0512	.0686		.0671	.0512
14	.9145	.0503	.0681	.0686		.0671	.0512
15	.8688	.0503	.0682	.0514	.0686	.0503	.0512
16	.9145	.0503	.0854	.0514	.0857	.0671	.0512
17	.884	.0503	.0854	.0514	.0686		.0682
18	.0514		.0854	.0857	.0857	.0838	.0683
19	.0857	.1006	.1023	.1029	.1029	.1006	.1024
20		.1174	.1024	.1029	.12		.1192
21			.0682	.0857	.1029	.1006	.1021
22			.5298	.5182	.5335	.5365	.5274
23				.5792	.6706	.6203	.648
24	.0686	.6554	.6874	1.5432	.5944	.7011	.6371
Max	.9755	.8688	.9389	1.5432	.7468	.7011	.7773
Min	.0514	.0503	.0512	.0514	.0514	.0503	.0512
Avg	.4038	.4028	.3802	.2901	.3353	.3310	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194095 / 33/11KV Chavanwadi Sub-Station

Feeder No / Name : 202 / 11 KV KASAI SPP SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4725	.5868	.6139	.5182	.503	.5335
2	.3086	.503	.5868	.6316	.5487	.503	.5335
3	.3086	.5335	.6371	.6658	.6097	.5182	.5335
4	.3772	.5335	.6874	.6999	.6554	.5792	.5335
5	.5144	.6249	.7377	.5463	.7164	.6249	.5335
6	.6344	.8535	.8383	.7682	.7468	.884	.7773
7	.5658	.9755	.9556	.8032	.945	.945	.945
8	.4801	.9907	1.0059	.3764	.463	.4973	.4268
9	.3601	.9724	1.0059	.3756	.2743	.4191	
10	.5639	.285	.2899	.2743	.3086	.3688	
11	.7621	.2515	.2387	.2572	.2401	.3018	.3073
12	.884	.2515		.2401	.1715	.285	.2563
13	.945	.2515		.2401	.1886	.285	.239
14	.8383	.2515	.2219	.2229	.1886	.285	.2217
15	.8535	.2515	.2387	.2229	.2058	.285	.239
16	.8688	.2347	.2728	.2401		.285	.2558
17	.884	.2515	.2561	.2229	.2572		
18			.3069	.1543	.2572		
19	.4287		.478	.3601	.4115	.4191	.4092
20		.57	.478	.4973	.6001		.495
21			.4092	.4801	.4973	.503	.4609
22			.734	.442	.5335	.5868	.6316
23				.4725	.5182	.5868	.6828
24	.3258	.5335	.6036	1.8861	.4725	.5335	.5868
Max	.945	.9907	1.0059	1.8861	.945	.945	.945
Min	.3086	.2347	.2219	.1543	.1715	.285	.2217
Avg	.5901	.5048	.5509	.4872	.4491	.4856	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194095 / 33/11KV Chavanwadi Sub-
StationFeeder No / Name : 203 / 11 KV KATGAON NO-II SPP SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAY-18	30-MAY-18	31-MAY-18	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	.6344	.6371	.5975	.6516	.6516	.5658
2	1.9052	.6344	.5868	.5804	.6516	.6516	.5658
3	1.9662	.6859	.5868	.564	.6516	.6687	.5658
4	2.0576	.7202	.6539	.6494	.6859	.7716	.6516
5	2.1033	.8059	.7042	.4609	.7888	.8573	.7373
6	2.1795	.9431	.7545	.8203	.9259	.9602	.8573
7	2.3624	.7545	.6203	.8535	.8402	.8402	.8745
8	2.1338	.7545	.6203	.7357	.7716	.6687	.6687
9	2.0424		.5868	1.4713	1.5546	1.6766	1.4559
10	.463	1.5927	1.6767	1.6461	1.7985	2.0454	1.6271
11	.3772	2.1125	2.572	1.7833	1.9052	2.3975	2.1776
12		2.0119	2.6235	2.1795	2.0576	2.4813	2.3002
13		2.5149	2.6092	2.1338	2.3472	2.1795	2.0256
14	.4801		2.4204	2.0576	2.21	2.4813	2.1114
15	.463	2.6155	2.3002		2.3624		2.2487
16	.463	2.7328		2.1338	2.271	2.3975	2.0405
17	.463	2.2634	2.5892	.463	.3944	.5868	.5133
18	.4287	.503		.5487	.4458	.4359	.5469
19	.6516		.8535			.5868	.6152
20		.8383	.9058	.8402	.8745		.7852
21			.7519	.823		.7377	.7178
22			.6843	.7545	.7373	.7042	.6821
23				.703	.6859	.6371	.6665
24	1.6461	.6344	.6706	2.2291	.6516	.6516	.5868
Max	2.3624	2.7328	2.6235	2.2291	2.3624	2.4813	2.3002
Min	.3772	.503	.5868	.4609	.3944	.4359	.5133
Avg	1.3316	1.3196	1.2575	1.1377	1.1938	1.1850	1.1078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-18 and 04-JUN-18

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 198006 / 220 KV TULJAPUR SUBSTATION

Feeder No / Name : 401 / 33KV TULJAPUR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.3889
Max	1.3889
Min	1.3889
Avg	1.3889