

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 201 / 11 KV SAJAPUR FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1463	.1494	.1227	.0339	.0328	.0351
2	.132	.1307	.132	.1753	.0366	.0328	.0351
3	.132	.1463	.132	.1928	.0366	.0328	.0351
4	.1886	.1829	.1698	.2103	.0366	.0328	.0351
5	.2829	.2561	.2263	.2454	.0366	.1132	.0351
6	.3395	.2926	.3206	.333	.0914	.0328	.1227
7	.415	.2561	.4338	.2629	.2378	.2622	.2279
8	.2641	.3292	.3584	.2454	.0983	.1475	.1753
9	.2641	.3292		.2804	.0549	.0492	.1052
10	.0343	.0328		.0343	.1509	.1052	.0526
11	.0857	.0328	.0351	.0343	.0943	.0351	.0351
12	.0819	.0492	.0351	.0343	.0754	.0701	.0351
13	.0848	.0655	.0351	.0339	.0754	.0351	.0526
14	.0549	.0655	.0351	.0343	.0566	.0526	.0366
15	.0732	.0492	.0351	.0867	.0373	.0351	.0377
16	.0514	.0655	.0876	.0819	.0566	.0526	.0732
17	.1097	.0492	.0701	.1463	.1132	.0876	.0732
18	.2241	.132	.1578	.1463	.1509	.1227	.0934
19	.2427	.2829	.2629	.2204	.2641	.1753	.2195
20	.2195	.2614	.2279	.2614	.2263	.2629	.2561
21	.1829	.1886	.2103	.2012	.1494	.2103	.1829
22	.1494	.1509	.1578	.1646	.1132	.1227	.1463
23	.1187	.1509	.1578	.1463	.1132		.1463
24	.112	.1029	.1307	.1402	.0343	.0328	.0351
Max	.415	.3292	.4338	.333	.2641	.2629	.2561
Min	.0343	.0328	.0351	.0339	.0339	.0328	.0351
Avg	.1649	.1562	.1619	.1598	.0989	.0929	.0951

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 202 / 11KV DAULATABAD FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.4937	1.419	1.4022	.5426	.5243	.5609
2	1.4523	1.4449	1.4146	1.4198	.5144	.5079	.5609
3	1.5089	1.5089	1.4377	1.4548	.4752	.5407	.7011
4	1.6032	1.5181	1.5089	1.4548	.5079	.6602	.7186
5	1.7918	1.7193	1.7918	1.6301	.5243	.639	.7362
6	2.1879	2.1313	2.1691	1.9105	.6687	.9242	.8589
7	2.4897	2.3712	2.2822	2.1033	.8684	1.0322	1.0341
8	2.32	2.3712	2.2068	2.3137	.8029	.9995	1.0517
9	2.1313	2.3594		2.1033	.6882	.852	1.0166
10	.9326	.9997		.7291	1.8484	1.7353	1.6827
11	.8916	1.094	.8764	.9511	1.773	1.7878	1.6827
12	.7956	.9339	.929	.8684	1.6409	1.5775	1.262
13	.7545	.8356	.8238	.8192	1.4712	1.4723	1.4373
14	.639	.6882	.8063	.7282	1.5466	1.3847	2.1691
15	.7045	.6718	.7537	.6882	1.5089	1.4373	1.4632
16	.8059	.7537	.8589	.7611	1.5466	1.5775	1.5546
17	.8684	.2294	.8413	.7865	1.6409	1.5074	1.643
18	1.957	1.8861	1.7177	1.9022	1.7918	1.6827	1.6787
19	2.2965	2.2634	2.1033	2.2314	2.2822	1.9281	2.1948
20	2.1399	2.2634	2.1209	2.1879	2.0748	2.0332	2.0485
21	2.0302	2.0748	1.9631	2.0485	2.0182	2.0332	2.0485
22	1.8473	1.8484	1.7528	1.9022	1.9616	1.8755	1.9239
23	1.6644	1.6975	1.6651	1.7558	1.7541		1.6827
24	1.4712	1.4632	1.5089	1.4373	.5243	.5407	.5784
Max	2.4897	2.3712	2.2822	2.3137	2.2822	2.0332	2.1948
Min	.639	.2294	.7537	.6882	.4752	.5079	.5609
Avg	1.5315	1.5259	1.4978	1.4829	1.2907	1.2719	1.3454

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 203 / 11KV FATIYABAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2785	.2785	.2622	.2629	.6413	.6535	.6135
2	.2294	.2915	.2458	.2804	.6154	.679	.6661
3	.2829	.2915	.2785	.3155	.6401		.7011
4	.2785	.3222	.3277	.3506	.7316		.8413
5	.4096	.3605	.4096	.2629	.8413		.8413
6	.6344	.4588	.5079	.5258	1.0242		1.1043
7	1.2071	.78	.8684	.7011	1.0608	1.2071	1.0867
8	.7045	.6443	.5898	.7888	.8048	.9619	.8764
9	.4915	.373		.6135	.6584		.7362
10	.6413	.6979		.5658	.5735	.6661	.5609
11	.5121	.6036	.5258	.6219	.6718		.6135
12	.4755	.5788	.6135	.5792	.6554	.7362	.6485
13	.4854	.5658	.5959	.5487	.639	.7011	.5609
14	.5487	.5281	.5083	.5304	.5079	.5609	.4424
15	.5487	.5658	.5083	.5068	.5079	.4557	.4588
16	.6161	.5658	.5258	.5788		.5959	.4915
17	.6584	.5658	.5609	.6401		.5609	.4915
18	.7282	.5847	.631	.724	.7733	.631	.6219
19	.8413	.9335	.8238	.8962	.9522	.7888	.8779
20	.8676	.8865	.8238	.9242	.9431	.8939	.9619
21	.7842	.8215	.7537	.823	.811	.8764	.8962
22	.6535	.7282	.7011	.7865	.7733	.7888	.8413
23	.6335	.5735	.6661	.7133	1.7541		.7499
24	.3277	.2915	.2785	.3155	.6584	.6413	.631
Max	1.2071	.9335	.8684	.9242	1.7541	1.2071	1.1043
Min	.2294	.2785	.2458	.2629	.5079	.4557	.4424
Avg	.5766	.5538	.5457	.5773	.7836	.7293	.7215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 204 / PARAS INDUSTRIAL Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	05-MAR-18
HR	Load (MW)
14	.5788
Max	.5788
Min	.5788
Avg	.5788



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 205 / ASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.213	.1696	.213	.2103	.5658	.5658	.5258
2	.1966	.2713	.2294	.2103	.6097	.5847	.5258
3	.2458	.2915	.2458	.2279	.6478	.6036	.5434
4	.3395	.3222	.2785	.2454	.724	.7545	.7011
5	.4096	.39	.3277	.333	.8002	.8676	.7186
6	.5658	.4578	.3605	.4031	.9907	1.0269	.9816
7	.852	.763	.7045	.5258	1.0374	1.0374	1.0166
8	.6062	.6344	.6062	.6485	.9054	.9054	.8413
9	.4915	.4748		.5258	.6401	.7922	.6135
10	.6036			.5121	.3605	.4382	.298
11	.5658			.4954	.5041	.4031	.3506
12	.5144	.547	.4733	.4572	.3932	.4207	.3681
13	.5144	.4527	.4382	.415	.4915	.3681	.1753
14	.4763	.5041	.4207	.381	.4096	.333	.373
15	.5144	.4715	.4557	.4572	.4527	.298	.3768
16	.5716	.4904	.4557	.381	.4096	.298	.407
17	.6036	.4904	.4382	.4763	.3277	.4031	.4287
18	.7049	.6161	.5434	.5716	.5041	.5083	.5716
19	.8573	.8488	.7186	.8573	.7733	.7011	.8764
20	.8764	.8215	.7888	.823	.7733	.8238	.9145
21	.7811	.7545	.6485	.8002	.6979	.6836	.8383
22	.6859	.2334	.6135	.724	.2614	.6485	.7049
23	.6036	.415	.5609	.3429	.6602		.6668
24	.2458	.2543	.2294	.2103	.5658	.5975	.5258
Max	.8764	.8488	.7888	.8573	1.0374	1.0374	1.0166
Min	.1966	.1696	.213	.2103	.2614	.298	.1753
Avg	.5433	.4852	.4643	.4681	.6044	.6114	.5976

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 206 / 11 KV JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9526	.9431	.8764	.5087	.3605	.4207
2	.9054	.9808	.9808	.9114	.5087	.4338	.4207
3	.9431	.9496	1.0374	.9465	.4915	.4715	.5258
4	1.094	1.1883	1.358	1.0517	.4915	.4915	.5959
5	1.307	1.3014	1.358	1.1919	.5243	.5571	.5959
6		1.3957			.6859	.6226	.6661
7	1.358	1.3203	1.3203		.9831	1.1142	1.1919
8	1.3957	1.1431	1.358	1.0517	.78	1.0374	1.0517
9	1.1317	1.0669		1.0517	.4748	.4915	.7011
10	.5087	.4527		.6584	.5281	.631	.6661
11	.6882	.4527	.5258	.4748	.5228	.2629	
12	.6104	.3277	.5959	.5243	.4527	.4207	.4557
13	.5087	.3605	.5609	.5087	.4481	.4207	.4207
14	.5426	.2949	.4908	.4748	.5228	.3856	.4572
15	.5571	.3605	.4908	.4748	1.5089	.4207	.4954
16	.6882	.6882	.631	.5898	.4904	.4557	.4954
17	.7209	***	.5959	.5426	.4904	.4557	.5716
18	.9145	.7095	.5959	.6668	.5601	.5959	.6478
19	1.1812	1.3203	1.0166	1.2955	1.1317	.8764	1.2193
20	1.105	1.2826	1.1919	1.2071	1.2071	1.0867	1.2574
21	.9907	.7167	1.0517	1.1431	1.0562	1.0166	1.2193
22	1.0288	1.0185	.9114	1.0288	1.0082	.9465	1.0669
23	.9907	1.0185	.8764	.9907	.9335		1.7528
24	1.2586	.9431	.9431	.8764	.4915	.426	.3856
Max	1.3957	10.0438	1.358	1.2955	1.5089	1.1142	1.7528
Min	.5087	.2949	.4908	.4748	.4481	.2629	.3856
Avg	.9259	1.2620	.8968	.8426	.7000	.6079	.7513

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 207 / SHAHAPUR BANJARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.3222	.2294	.2279	.4382	.415	.3506
2	.3018	.3222	.213	.2454	.4207	.4294	.4382
3	.3584	.3258	.2458	.2629	.415	.4715	.5258
4	.3584	.3561	.2785	.2629	.439	.5658	.6135
5	.3277	.4458	.3277	.3155	.679	.5407	.6135
6	.415	.5243	.3605	.333	.7316	.7545	.7186
7	.6554	.7537	.5898	.4382	.743	.7468	.7362
8	.4752	.5765	.5079	.4908	.5335	.5847	.4908
9	.4904	.4424		.4382	.3292	.3772	.4382
10	.3048	.4338		.3077	.3441	.333	.3506
11	.2713	.3206	.1928	.2858	.3932	.4031	.3681
12	.3048	.2829	.1928	.2286	.4915	.4031	.3155
13	.2477	.2263	.1753	.2263	.4915	.3856	
14	.2477	.2829	.2103	.2263		.298	.2949
15	.2286	.2452	.1753	.2286		.2804	.39
16	.4001		.1578	.2477	.3768	.3681	.4409
17	.3429	.3018	.2103	.2477	.3932	.4207	.4096
18	.4572	.3174	.2804	.3429	.3206	.2804	.381
19	.4527	.5658	.298	.5525	.547	.3681	.6097
20	.5906	.5093	.333	.4938	.547	.5083	.5906
21	.5716	.4409	.333	.5716	.5228	.5083	.5487
22	.381	1.8296	.333	.4954	.4854	.4733	.5121
23	.4763	.4108	.2804	.4763	.4338		.4763
24	.7236	.3222	.2622	.2454	.4338	.415	
Max	.7236	1.8296	.5898	.5716	.743	.7545	.7362
Min	.2286	.2263	.1578	.2263	.3206	.2804	.2949
Avg	.4033	.4591	.2812	.3413	.4777	.4492	.4824

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 208 / Paper Mill (Saptashrunji) SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3475	.168	.1928	.3292	.1867	
2	.2452	.3475	.1494	.2103	.3206	.1886	.1753
3	.2241	.3292	.1307	.1928	.2561	.2054	.1928
4	.2054	.3174	.1307	.1928	.2561	.2054	.1928
5	.2241	.3292	.1494	.2103	.2378	.2054	.1928
6	.2241	.3109	.1307	.2279	.2353	.2614	
7	.2641	.3475	.1307	.2454	.2012	.2427	.2629
8	.2452	.2012	.1307	.2454	.3109	.2452	.2454
9	.2427	.1829		.2279	.2926	.3584	.1928
10	.2926	.1307		.2743	.3547	.4207	.2103
11	.4527	.6224	.2103	.2641	.415	.4382	.4557
12	.4294	.168	.298	.2561	.3361	.4207	.4733
13	.3658	.1509	.2804	.2715	.3584	.3155	.3681
14	.3921	.1509	.2804	.2926	***	.2804	.3292
15	.3772	.2241	.3506	.3841		.3506	.3658
16	.5487	.2075	.4207	.3658	.2829	.3506	.3561
17	.6036	.1886	.2804	.2378	.2263	.4031	.2926
18	.3475	.1867	.3506	.3439	.3921	.3681	.3109
19	.3921	.1886	.3856	.3475	.3961	.3506	.3174
20	.3292	.2054	.333	.3547	.3395	.3506	.3772
21	.3077	.2241	.298	.3658	.3361	.2629	.3841
22	.3439		.3506	.3658	.2641	.2629	.3841
23	.3077	.2054	.2804	.3292	.2241		.3475
24	.3018	.3475	.1698	.2804	.3475	.2241	
Max	.6036	.6224	.4207	.3841	62.8653	.4382	.4733
Min	.2054	.1307	.1307	.1928	.2012	.1867	.1753
Avg	.3312	.2571	.2459	.2783	3.0251	.2999	.3061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 201 / 11KV Chowka Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2286	.2286	.1905	.2286	.2286
2	.2667	.2477	.2096		.1905	.2667	.2286
3	.2858	.2667	.2858	.2858	.2858	.3048	.3048
4	.362	.362	.381	.381	.381	.362	.381
5	.4572	.4572	.5335	.4763	.4763	.4382	.4954
6	.6668	.6668	.6287	.6859	.5716	.5335	.6668
7	.8002	.8573	.8764	.6097	.7621	.8002	.8383
8	.6287	.6478	.7811	.6097	.7621	.7621	.7621
9	.6859	.5716	.6668	.7621	.6287	.5716	.724
10	.5525	.4763	.5716	.5335	.4382	.5716	.4572
11	.4001	.2667	.4763	.4191	.2858	.4763	.381
12	.362	.2858	.381	.3429		.381	.3429
13	.3429	.1715	.2858	.2667	.1334	.2858	.2477
14	.381	.1715	.2858	.2286	.1905	.2858	.2096
15		.1524	.2858	.2096	.2096	.2858	.2286
16	.2667	.2477	.1905	.2286	.1905	.1905	.2477
17	.1715	.2858	.3239	.2858	.2667	.2667	.3429
18	.5335	.4001	.4001	.381	.3429	.381	.4191
19	.6097	.6668	.6668	.5716	.4572	.6287	.6097
20	.4763	.5525	.6097	.5716	.5144	.5335	.6287
21	.3429	.381	.4001	.4763	.362	.4382	.4954
22	.3048	.2667	.3239	.381	.3048	.3239	.381
23	.2286	.2477	.2667	.2858	.2286	.2858	.2286
24	.6954	.2286	.2286	.2286	.1905	.2286	.2477
Max	.8002	.8573	.8764	.7621	.7621	.8002	.8383
Min	.1715	.1524	.1905	.2096	.1334	.1905	.2096
Avg	.4386	.3795	.4287	.4109	.3636	.4096	.4207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 202 / 11 KV SAWANGI Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.4382	.4763	.5144	.6097
2	.4572	.4763	.4572	.4382	.6668	.5716	.6287
3	.4763	.5144	.4954	.4954	.8573	.5716	.6859
4	.5335	.5335	.5716	.5716	.9526	.724	.7621
5	.5525	.5716	.5716	.5716	1.1431	.7621	.8002
6	.5716	.5716	.5716	.5716	1.4289	.8002	.8383
7	.5716				1.4289	1.6385	1.5242
8					.9526	1.7147	1.448
9					.6859	1.1431	.9907
10	1.2003	1.448	.7621	1.2955		.5716	
11	1.1622	1.2384	.8573	1.1431		.4763	.4763
12	1.1241	1.1241	.8573	.9907	.5716	.381	.4572
13	1.0479	.9717	.9526	1.105	.5525	.5335	.5335
14	.9907	.8002	.9526	.9526	.5335	.381	.5144
15	1.0479	.8383	.9526	1.0288	.4954	.381	.5335
16	1.1241	.5716	.8573	.9526	.5716	.381	.5716
17	.9526	.9526	1.0098	.9526	.5716	.5716	.5716
18	.5716	.5716	.4954	.381	.5716	.4763	.5716
19	.5716	.5716	.6478	.2858	.5716	.5716	.5716
20	.5716	.5716	.6287	.5716	.5716	.5716	.5716
21	.5716	.5335	.5906	.4763	.5716	.5335	.5144
22	.5716	.4763	.4763	.381	.4954	.5144	.4954
23	.5144	.4572	.4382	.381	.4763	.4191	.4572
24	.4572	.4572	.4382	.4382	.4763	.5144	.5716
Max	1.2003	1.448	1.0098	1.2955	1.4289	1.7147	1.5242
Min	.4572	.4572	.4382	.2858	.4763	.381	.4572
Avg	.7318	.7004	.6686	.6868	.7101	.6549	.6826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 203 / 11 KV CHOWKA Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1524	.1524	.0953	.0953	.0953
2	.0953	.1334	.1334	.1524	.0953	.0953	.0953
3	.0953	.1524	.1905	.1524	.0953	.1334	.1334
4	.1143	.1715	.2858	.1715	.1905	.1334	.1524
5	.1524	.1715	.381	.1905	.1905	.1715	.1524
6	.1905	.381	.4191	.3239	.1905	.1905	.1905
7	.7621	.724	.7621	.6287	.1905	.2286	.2096
8	.7621	.724	.5906	.4763	.1905	.2096	.2096
9	.2096	.3239	.5716	.4572	.1905	.1905	.1715
10	.0953	.1334	.0953	.1715	.4954	.1905	.362
11	.0953	.0953	.0953	.1334	.5716	.1905	.4382
12	.0953	.1143	.0953	.1334	.6859	.1905	.5144
13	.0953	.1143	.0953	.1143	.1905	.381	.4763
14	.0953	.1334	.0953	.1334	.4763	.2858	.4382
15		.1334	.1905	.1143	.4001	.2858	.4001
16	.1905	.0762	.1905	.2286	.4763	.1905	.4572
17	.1334	.0953	.1905	.1905	.4191	.3429	.381
18	.1715	.1524	.0953	.0953	.1334	.1143	.4191
19	.1905	.1715	.1334	.1905	.1715	.1524	.1905
20	.1715	.1143	.1715	.1905	.1524	.1524	.1715
21	.1334	.0953	.1715	.1905	.1334	.1143	.1334
22	.1143	.0953	.1715	.1905	.1143	.1143	.1143
23	.0953	.0953	.1524	.0953	.0953	.0953	.0953
24	.9602	.1143	.1524	.1715	.0953	.0953	.0953
Max	.9602	.724	.7621	.6287	.6859	.381	.5144
Min	.0953	.0762	.0953	.0953	.0953	.0953	.0953
Avg	.2223	.1937	.2326	.2104	.2517	.1810	.2540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 204 / Lingdari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0762	.0762	.0953	.0953	.0953
2	.0953	.1334	.0762	.0762	.0953	.0953	.0953
3	.0953	.1334	.1143	.0953	.0953	.1143	.0953
4	.1143	.1524	.1524	.1143	.1905	.1334	.1143
5	.1334	.1524	.1905	.1524	.1905	.1334	.1143
6	.1715	.1715	.2096	.1143	.1905	.1334	.1334
7	.1905	.2286	.2477	.2286	.1905	.2286	.2096
8	.1715	.1905	.1905	.2096	.1905	.1905	.1905
9	.1334	.1715	.1905	.1905	.1143	.1905	.1905
10	.0953	.0953	.0953	.2096	.1143	.1905	.1715
11	.0953	.1143	.0953	.1715	.1334	.1905	.1524
12	.1334	.1334	.0953	.1524	.0953	.1905	.1143
13	.0953	.1334	.0953	.1334	.0762	.0953	.0953
14	.1143	.0953	.0953	.1715	.0953	.0953	.0953
15		.0953	.0953	.1334	.0953	.0953	.1143
16	.1143	.0762	.0953	.1143	.1143	.0953	.0953
17	.1334	.0953	.0953	.1905	.1334	.1143	.0953
18	.1905	.1334	.1524	.1905	.1334	.1905	.1143
19	.1715	.1905	.1715	.1905	.1334	.2096	.1143
20	.1334	.1715	.1524	.1905	.1334	.1524	.1524
21	.1143	.1334	.1334	.1905	.1143	.1334	.0953
22	.1143	.0953	.1143	.1905	.0953	.1524	.0762
23	.0953	.0762	.0762	.0953	.0953	.1143	.0762
24	.4382	.0953	.0762	.0762	.1905	.0953	.0953
Max	.4382	.2286	.2477	.2286	.1905	.2286	.2096
Min	.0953	.0762	.0762	.0762	.0762	.0953	.0762
Avg	.1408	.1326	.1286	.1524	.1294	.1429	.1207



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 205 / Sawangi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.8764	.9526	1.0098	.8573	1.0288	.9907
2	.9907	.8764	.9717	1.0098	.9526	1.0669	.9526
3	1.0098	.9526	1.1812	1.086	1.1431	1.1431	1.105
4	1.2384	1.1431	1.3527	1.1622	1.4289	1.3336	1.2384
5	1.448	1.448	1.5242	1.2574	1.7147	1.5242	1.4861
6	1.7909	1.7147	1.7718	1.6575	1.8099	1.7147	1.8671
7	2.0957	2.0005	2.1719	1.9814	2.0957	2.1719	2.0005
8	1.9052	1.7147	1.9624	2.0957	1.9052	1.9052	1.8099
9	1.5813	1.6575	1.5242	1.7528	1.6575	1.7147	1.6004
10	1.2955	1.5432	1.3336	1.5242	1.3527	1.5242	1.3717
11	1.086	1.3527	1.2384	1.1431	1.0479	1.3336	1.0288
12	1.0098	1.2003	1.1431	1.0288	.9717	1.1431	.8764
13	.9526	1.0669	.9526	.9145	.7621	.7621	.8002
14	.9145	.9907	.7621	.8764	.8002	.7621	
15		.9717	.8573	.8764	.8383	.7621	
16	1.2003	1.0098	.7621	.8954		.7621	
17	1.2955	1.1431	1.1431	1.1431	1.1431	1.1431	
18	1.6766	1.4098	1.467	1.3336	1.3336	1.3527	1.5242
19	1.829	1.7337	1.7909	1.6194	1.6766	1.848	1.9433
20	1.6004	1.5242	1.6004	1.5242	1.4861	1.6194	1.8671
21	1.3336	1.3717	1.3717	1.4289	1.2193	1.3527	1.5432
22	1.1431	1.1431	1.1431	1.3336	1.1431	1.2193	1.3717
23	.9526	.9717	1.0479	1.1431	1.105	1.0669	1.1431
24	1.0098	.9145	.9145	1.0098	.9526	1.0288	1.0098
Max	2.0957	2.0005	2.1719	2.0957	2.0957	2.1719	2.0005
Min	.9145	.8764	.7621	.8764	.7621	.7621	.8002
Avg	1.3196	1.2805	1.2892	1.2836	1.2781	1.3035	1.3765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 206 / 11 KV Tuljapur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2477	.2858	.2858	.2858	.2286	.2286
2	.2858	.2667	.2858	.2858	.2858	.2477	.2286
3	.2858	.2667	.3048	.2858	.2858	.2858	.2286
4	.2858	.2667	.3429	.3048	.2858	.3048	.2477
5	.2858	.3048	.381	.3048	.2858	.3239	.2858
6	.2858	.2667	.4001	.3048	.2858	.362	.3239
7	.0191	.3429	.4001	.3048	.2858	.381	.3239
8	.3429	.3239	.3239	.2477	.2858	.362	.2858
9	.5335	.3048	.381	.2286	.8954	.5716	.5144
10	1.0669	.3048	.381	.4382	.9526	.6668	.9526
11	1.0098	.4191	.5716	.5716	.4191	.7621	1.448
12	.9526	.3239	.7621	.5144	.9717	.9526	1.2384
13	.8192	.3239	.9526	.4572	.8764	1.0479	1.4861
14	.8002	.3048	1.1431	.362	1.105	.9526	1.2955
15	.8573	.381	1.2384	.3429	1.8099	.9526	1.0479
16	.9145	.4001	1.1431	.362		.9526	1.3717
17	.5716	.4572	1.467	.381	1.5242	.5716	1.5623
18	.724	.3429	.4191	.2858	1.2955	.5144	1.2193
19	.3429	.381	.2858	.2858	.4572	.4382	.4954
20	.3048	.381	.2858	.2858	.362	.3239	.3239
21	.2858	.4001	.2858	.2858	.3429	.3429	.3239
22	.2667	.381	.2858	.2858	.3048	.3239	.3048
23	.2477	.3048	.2858	.2858	.2858	.2858	.3048
24	.2858	.2286	.2858	.2858	.2858	.2667	.2286
Max	1.0669	.4572	1.467	.5716	1.8099	1.0479	1.5623
Min	.0191	.2286	.2858	.2286	.2858	.2286	.2286
Avg	.5025	.3302	.5374	.3326	.6163	.5176	.6779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 207 / 11 KV Unique Stone crusher SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0381	.0191	.0191	.0191	.0381
2	.0191	.0191	.0381	.0191	.0191	.0191	.0381
3	.0191	.0191	.0381	.0191	.0191	.0191	.0381
4	.0191	.0191	.0381	.0191	.0191	.0191	.0381
5	.0191	.0191	.0381	.0191	.0191	.0191	.0381
6	.0191	.0191	.0381	.0191	.0191	.0191	.0381
7	.0191	.0191	.0381	.0191	.0191	.0381	.0381
8	.0191	.0191	.0381	.0572	.0191	.0191	.0381
9	.0381	.0191	.0381	.0381	.0381	.0381	.0381
10	.0381	.0191	.0381	.0381	.0381	.0381	.0191
11	.0381	.0191	.0191	.1334	.0381	.0381	.1334
12	.0572	.0191	.0191	.0762	.0762	.0381	.0762
13	.0572	.0191	.0191	.1334	.0572	.0381	.0572
14	.0572	.0191	.0191	.0381	.0191	.0762	.0381
15	.0381	.0191	.0191	.0381	.0381	.0762	.0572
16	.0381	.0191	.0191	.0191	.0381	.1143	.0381
17	.0191	.0191	.0191	.0381	.0191	.1715	.0572
18	.0191	.0191	.0191	.0381	.0191	.1143	.0381
19	.0191	.0191	.0191	.0381	.0191	.0572	.0381
20	.0191	.0191	.0191	.0381	.0191	.0381	.0572
21	.0191	.0191	.0191		.0191	.0381	.0381
22	.0191	.0191	.0191		.0191	.0381	.0381
23	.0191	.0191	.0191	.0191	.0191	.0381	.0381
24	.0191	.0191	.0191	.0191	.0191	.0191	.0381
Max	.0572	.0191	.0381	.1334	.0762	.1715	.1334
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0278	.0191	.0270	.0407	.0270	.0476	.0461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 201 / 11KV GROWTH CENTRE I

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7865	.7682	.8048	.7499	.7621	.7811
2	.4938	.7316	.7316	.7499	.7133	.7621	.743
3	.4572	.823	.7316	.823	.7865	.724	.724
4	.4938	.7316	.8048	.7682	.823	.8954	.8573
5	.5304	.7682	.8779	.8048	.8962	1.0098	1.0669
6	.7316	.8048	.9328	.8048	.9877	1.1622	1.1431
7	1.0974	.8596	1.0059	.9877	1.0425	1.2574	1.2193
8	1.0974	.9511	1.0242	1.1888	1.0242	1.086	1.2574
9	.9717	.8764	.8192	1.2384	.8573	.8192	.8413
10	.6859	.8573	.6859	1.0669	.6668	.8383	.8413
11	.6287	.8764	.8573	.8192	.6668	.6859	.6767
12	.6097	.8764	.8573	.5716	.5906	.5906	.5853
13	.5716	.5716	.7049	.4763	.5716	.5716	.5304
14	.5335	.5144	.5525	.5144	.6097	.5716	.4572
15		.5335	.5335	.4954	.4763	.5906	.5487
16	.4572	.5716	.5144	.4572	.6097	.6097	.6401
17	.6478	.6859	.5906	.5906	.5716	.6478	.6401
18		.8383	.6097	.6859	.6859	.6859	.6036
19		.8764	.8764	.8764	.9526	.9907	.8048
20		.9526	.8573	.8764	1.0288	.9526	.9694
21		.8573	.8573	.9145	.9907	.9145	1.0059
22		.8573	.8764	.8573	.9526	.8573	.9694
23	.823	.8596	.8413	.8573	.8954	.8192	.9328
24	.6401	.7865	.8048	.7682	.7865	.8002	.8192
Max	1.0974	.9526	1.0242	1.2384	1.0425	1.2574	1.2574
Min	.4572	.5144	.5144	.4572	.4763	.5716	.4572
Avg	.6678	.7853	.7798	.7916	.7890	.8169	.8191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 202 / 11KV A.S.CLUB FEEDER Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0549	.0732	.0549	.0549	.0572	.0762
2	.0366	.0549	.0732	.0549	.0549	.0572	.0572
3	.0366	.0732	.0732	.0549	.0549	.0572	.0572
4	.0366	.0732	.0732	.0732	.0549	.0953	.1334
5	.0549	.1097	.128	.1097	.0914	.1334	.2096
6	.0732	.1463	.2012	.1829	.1646	.2096	.3239
7	.1097	.2195	.2561	.1829	.2926	.2667	.381
8	.1097	.2195	.2561	.3109	.3658	.362	.5716
9	.1334	.2477	.2477	.2858	.3239	.3239	.3658
10	.2858	.0381	.0381	.1334	.1524	.1524	.0732
11	.2667	.1334	.0953	.1524	.1334	.1143	.0732
12	.2667	.1334	.0953	.1143	.1334	.1524	.0914
13	.2667	.1143	.0762	.0953	.1524	.1524	.0914
14	.2858	.1524	.0762	.0762	.0953	.1334	.0914
15	.3048	.1334	.0572	.0572	.0953	.1143	.1097
16	.2858	.1334		.0572	.1143	.1143	.128
17	.3048	.1334	.0953	.0762	.1334	.1334	.0914
18		.1143	.1143	.0953	.1143	.1524	.1097
19		.1334	.0953	.1143	.1905	.1715	.1097
20		.1334	.1143	.1143	.1524	.1715	.0914
21		.1143	.0953	.1143	.1334	.1334	.0914
22		.1143	.0762		.1334	.1143	.0914
23	.0732	.0732	.0549	.1143		.0953	.128
24	.0549	.0549	.0732	.0732	.0549	.0762	.0381
Max	.3048	.2477	.2561	.3109	.3658	.362	.5716
Min	.0366	.0381	.0381	.0549	.0549	.0572	.0381
Avg	.1600	.1212	.1104	.1173	.1412	.1477	.1494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 203 / 11KV P.M.CHORDIA FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0366	.0366	.0366	.0381	.0381
2	.0366	.0366	.0366	.0366	.0366	.0381	.0381
3	.0366	.0366		.0366	.0366	.0381	.0381
4	.0366	.0366	.0366	.0366	.0366	.0381	.0381
5	.0366	.0366	.0366	.0366	.0366	.0381	.0381
6	.0366	.0366	.0366	.0366	.0366	.0381	.0381
7	.0366	.0366	.0366	.0366	.0366	.0381	.0381
8	.0366	.0366	.0366	.0366	.0366	.0381	.0191
9	.0953	.0191	.1334	.0381	.0381	.0381	.0914
10	.0953	.0381	.2286	.0191	.0381	.0953	.2012
11	.1715	.0381	.2477	.0762	.0381	.1524	.2561
12	.2286	.0381	.2477	.1143	.1524	.2667	.3658
13	.2096	.0381	.1334	.2477	.2858	.3429	.1829
14	.2667	.0953	2.1338	.1715	.0953	.0762	.0914
15	.2858	.0381	.2477	.0762	.2667	.1905	.1646
16	.2477	.0381	.362	.0762	.3429	.3239	.2195
17	.1905	.0381	.1905	.1715	.3239	.3239	.1829
18		.0381	.2667	.0762	.362	.3239	.1829
19		.0381	.0953	.0381	.0953	1.448	.128
20		.0381	.0762	.0953	.0953	.1143	.0183
21		.0381	.0953	.2286	.0953	.0953	.0183
22		.0381	.0953	.1143	.0953	.0762	.0183
23	.0732	.0366	.0549	.0572	.0381	.0762	.0183
24	.1829	.0732	.0366	.0366	.2012	.0381	.0381
Max	.2858	.0953	2.1338	.2477	.362	1.448	.3658
Min	.0366	.0191	.0366	.0191	.0366	.0381	.0183
Avg	.1232	.0406	.2131	.0804	.1190	.1786	.1027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 204 / 11KV Growth Center II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2926	.3475	.2743	.3048	.3239
2	.2743	.2561	.2743	.3292	.2743	.2667	.3048
3	.2561	.2561	.2561	.3109	.2561	.2667	.2858
4	.2561	.2743	.2561	.3109	.2561	.2858	.3239
5	.2926	.2926	.3109	.3292	.2926	.3239	.3429
6	.3475	.3109	.3658	.3292	.3292	.362	.381
7	.4024	.3475	.4207	.3109	.3658	.381	.4001
8	.4024	.3109	.3658	.3475	.3658	.362	.4001
9	.362	.362	.3429	.362	.2477	.3048	.3109
10	.3429	.3239	.2858	.4191	.2667	.2858	.2926
11	.3048	.3239	.2477	.381	.2858	.2858	.2926
12	.2858	.3048	.2477	.362	.2858	.2477	.2743
13	.2667	.3239		.381	.2667	.2477	.2743
14	.2667	.3048	.2477	.3429	.2477	.2286	.2926
15	.2667	.3048	.2667	.3048	.0953	.2477	.2561
16	.2667	.3048	.3048	.2858	.2667	.2667	.2195
17	.2858	.3429	.3048	.2858	.2477	.2667	.2743
18			.3429	.3048	.2667	.2858	.2561
19		.381	.4191	.362	.381	.381	.3292
20		.4191	.362	.4001	.4191	.4191	.3841
21		.4191	.4001	.362	.4001	.4001	.3658
22		.381	.362	.362	.4001	.381	.3841
23	.3292	.3658	.3475	.362	.3429	.362	.3658
24	.3109	.3109	.3292	.3658	.2926	.3239	.3429
Max	.4024	.4191	.4207	.4191	.4191	.4191	.4001
Min	.2561	.2561	.2477	.2858	.0953	.2286	.2195
Avg	.3049	.3259	.3197	.3441	.2970	.3120	.3199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 205 / 11KV Sara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6461	1.4083	1.6461	1.5729	1.5242	1.7147
2	1.7375	1.701	1.4632	1.7375	1.4815	1.4861	1.6766
3	1.8107	1.5912	1.5546	1.6644	1.6278	1.4289	1.7147
4	1.7193	1.5546	1.7741	1.6278	1.7741	1.5623	2.0005
5	2.0119	1.8107	2.0302		2.0302	2.1338	2.5339
6	2.652	2.0302	2.5606	1.9387	2.6155	2.7244	2.9721
7	3.4202	2.5423	2.9813	2.9264	3.219	3.3341	3.0674
8	2.9813	2.9081	2.7252	3.0178	2.8349	3.0102	2.934
9	2.5339	2.5911	2.3624	2.9912	2.5339	2.4196	2.1765
10	2.21	2.6101	1.7337	2.4387	2.1719	2.1148	2.0119
11	1.9433	2.572	1.5432	2.0386	1.8861	1.7909	1.8107
12	1.7909	2.553	1.5432	1.8861	1.6956	1.7337	1.5546
13	1.7147	2.2862	1.5242	1.7528	1.6385	1.6575	1.5546
14	1.7337	2.1338	1.6194	1.6956	1.5432	1.5432	1.5546
15	1.7147	1.9624	1.5242	1.6385	1.6004	1.6194	1.5729
16	1.8671	1.9052	1.6575	1.5432	1.6385	1.6194	1.5912
17	2.1338	2.0005	1.8671	1.829	1.848	1.9052	1.7741
18		2.2481	2.0386	2.0576	2.1719	2.0576	2.0119
19		2.553	2.5911	2.6482	2.6863	2.5339	2.396
20		2.3243	2.5339	2.5911	2.3243	2.6292	2.5972
21		2.2481	2.3434	2.3624	2.2291	2.2862	2.396
22		2.0005	2.1529	2.21	2.1529	2.1148	2.0851
23	1.7741	1.6827	1.7924	1.9243	1.8861	1.9624	1.9387
24	1.6644	1.6278	1.4815	1.6827	1.6644	1.5432	1.7337
Max	3.4202	2.9081	2.9813	3.0178	3.219	3.3341	3.0674
Min	1.6461	1.5546	1.4083	1.5432	1.4815	1.4289	1.5546
Avg	2.0558	2.1285	1.9503	2.0804	2.0345	2.0306	2.0572



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 206 / 11KV South City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3109	.2926	.3292	.2561	.3048	.3239
2	.2378	.3109	.2926	.3109	.2743	.2858	.3048
3	.2378		.3109	.2926	.2561	.2858	.3048
4	.2561	.2926	.3292	.3475	.2926	.362	.381
5	.3475	.3475	.3841	.4207	.3841	.4572	.4763
6	.4755	.4207	.439	.4755	.4755	.5716	.5906
7	.567	.4938	.5487	.4572	.6036	.6478	.6478
8	.567	.4755	.4572	.567	.3841	.5906	.5716
9	.5335	.4382	.4572	.5716	.4954	.4763	.4207
10	.5525	.4382	.4572	.4763	.4191	.4382	.4207
11	.4954	.4954	.4001	.4191	.4572	.4191	.4207
12	.4572	.4954	.4001	.4001	.4572	.4191	.3475
13	.4191	.362	.381	.381	.4572	.4001	.4207
14	.4572	.3048	.3429	.4001	.4763	.362	.4207
15	.4572	.3239	.4382	.4001	.4572	.4191	.4024
16	.4191	.3429	.4001	.381	.4382	.4572	.3841
17	.4572	.3429	.4763	.4001	.4572	.4382	.4024
18		.381	.4191	.4763	.4382	.5144	.439
19		.4572	.5716	.4191	.6097	.5335	.439
20		.4191	.5335	.4954	.5716	.5335	.439
21		.4572	.4191	.4001	.5144	.4954	.439
22		.381	.4382	.4382	.4191	.4572	.3658
23	.3109	.3292	.3292	.4191	.381	.4001	.3658
24	.2926	.3109	.2926	.3109	.3475	.362	.3239
Max	.567	.4954	.5716	.5716	.6097	.6478	.6478
Min	.2378	.2926	.2926	.2926	.2561	.2858	.3048
Avg	.4104	.3883	.4088	.4162	.4301	.4430	.4188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 209 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.695	.8779	.823	1.0479	1.0669
2	.8413	.9328	.6584	.9511	.7499	.9907	1.0288
3	.8962	.8596	.6219	.9145	.7865	.9526	.9907
4	.9328	.8962	.6401	.9694	.8596	.9145	.9526
5	.9694	.823	.6767	1.0242	.9328	.9526	1.0098
6	1.0425	.8596	.7133	1.0608	1.0059	.9717	1.0288
7	1.134	.8048	.7682	1.0242	1.0425	1.0098	1.0669
8	1.262	.7865	1.0059	1.3169	1.2803	1.5242	1.3336
9	1.0479	.8383	1.7337	1.8099	2.0195	2.0386	2.1948
10	1.9814	.7621	2.0576	2.0957	2.3624	2.0386	1.9936
11	1.9052	.8002	1.9433	2.191	2.4958	2.3624	2.3045
12	1.8671	.8764	1.9433	2.2672	1.6385	2.2481	2.1948
13	1.9624	.8573	2.0005	1.5432	1.2765	2.0195	2.1033
14	2.191	.8192	2.1338	1.8671	2.0767	2.3815	1.9936
15	2.2862	.743	2.0005	2.0576	2.3624	2.0195	1.957
16	2.0386	.6478	2.0957	2.0957	2.2291	2.0195	1.9204
17	1.0098	.6478	2.0195	2.191	2.0957	2.1338	1.9022
18		.6859	2.0957	2.0195	2.0386	1.829	2.0485
19		.6859	1.4098	1.3146	1.4861	1.448	1.6278
20		.8002	1.3146	1.2574	1.3717	1.2384	1.3352
21		.9335	1.2193	.9526	1.2193	1.1431	.9511
22		.8192	1.086	1.0098	1.105	1.105	1.0059
23	.9328	.7865	1.0608	.9717	1.2003	1.1241	1.134
24	1.0059	.9511	.7316	.9145	.823	1.1431	1.1431
Max	2.2862	.9511	2.1338	2.2672	2.4958	2.3815	2.3045
Min	.8413	.6478	.6219	.8779	.7499	.9145	.9511
Avg	1.3801	.8138	1.3594	1.4457	1.4700	1.5273	1.5120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 201 / 11 KV Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2947	.2896	.3077	.3544	.3224	.3224	.3224
2	.2774	.3292	.2896	.3366	.3224	.362	.3403
3	.3086	.3658	.3224	.3366	.3582	.3982	.3544
4	.3814	.3982	.3582	.3681	.4075	.4298	.3898
5	.5201	.4298	.3898	.4207	.4835	.4784	.4207
6	.5426	.443	.4607	.4908	.5138	.5258	.4557
7	.6443	.4908	.5784	.5895	.5847	.5548	.5548
8	.6952	.4908	.5375	.8149	.5959	.7202	.5434
9	.6859	.4733	.7108	.7282	.7265	.6762	.7362
10	.6984	.6687	.703	.7455	.6687	.4287	.6935
11	.5068	.6783	.6344	.4748	.5426	.4458	.4287
12	.4572	.6036	.4161	.3772	.3688	.4161	
13	.4706	.4359	.3641	.373	.3812	.3814	.3121
14	.4477		.3467	.39	.3647	.3641	
15	.4706	.3222	.3988	.3856	.39	.3856	.3988
16	.4835	.3086	.3988	.3688	.3856	.4031	.4115
17	.5493	.3121	.3988	.3561	.4334	.4252	.4287
18	.6485	.3681	.4382	.3898	.4557	.4031	.4681
19	.6201	.5609	.7011	.7265	.7373	.5609	.7628
20	.5014	.6379	.4557	.7087	.6068	.7011	.7537
21	.3801	.5316	.4557	.5316	.4908	.5316	.4382
22	.3292	.4298	.4031	.4119	.4119	.4252	.4207
23	.3109	.3224	.3721	.3403	.3544	.3403	.3681
24	.3086	.2896	.3224	.3544	.3224	.3224	.3045
Max	.6984	.6783	.7108	.8149	.7373	.7202	.7628
Min	.2774	.2896	.2896	.3366	.3224	.3224	.3045
Avg	.4805	.4426	.4485	.4739	.4679	.4584	.4685

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 202 / 11 KV Patoda Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9882	.2241	.2172	.2507	.2507	.2241	.2149
2	.9882	.2452	.2172	.2507	.2507	.2829	.2328
3	.9945	.2801	.2507	.2686	.2686	.3174	.2481
4	.9945	.3174	.2865	.2835	.2835	.4108	.2658
5	1.0229	.3395	.3189	.3189	.3403	.4294	.2804
6	1.0004	.3734	.3898	.3898	.4075	.4668	.3506
7	1.0343	.4338	.4908	.4908	.4252	.5228	.4161
8	1.0513	.4481	.3988	.4382	.4382	.3772	.3856
9	1.0343	.3961	.4207	.3506	.4252	.3961	.4031
10	.3224	1.1831	1.2717	1.3889	1.4575	1.3203	1.387
11	.3174	1.2717	1.2887	1.3565	1.4582	1.4746	1.3565
12	.3395	1.3413	1.3375	1.3717	2.8838	1.4737	
13	.3174	1.3077	1.3203	1.3226	2.8178	1.4217	1.3203
14	.2987	1.3056	1.2517	1.2717	2.7514	1.387	
15	.3361	1.2548	1.2346	1.2574	1.3904	1.3672	1.2689
16	.3734	1.2346	1.2689	1.2407	1.358	1.3496	1.2717
17	.3361	1.2309	1.2517	1.2209	1.3523	1.3289	1.2209
18	.3174	.3506	.2481	.2835	.2987	.2629	
19	.3361	.3681	.4075	.3544	.4668	.2804	.298
20	.3395	.3898	.3544	.3366	.4108	.3155	.3012
21	.3547	.3366	.3012	.3189	.3772	.2835	.2835
22	.3361	.2865	.2658	.3045	.3395	.2481	.2835
23	.3174	.2328	.2686	.2865	.2801	.2328	.2658
24	.9945	.2263	.2328	.2686	.2686	.2263	.2149
Max	1.0513	1.3413	1.3375	1.3889	2.8838	1.4746	1.387
Min	.2987	.2241	.2172	.2507	.2507	.2241	.2149
Avg	.6144	.6408	.6373	.6511	.8750	.6833	.5843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 203 / WALDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935						
2	.7282						
3	.7202						
4	.7975						
5	.8322						
6	.8139						
7	.8817						
8	.9496						
9	.9156						
10		1.2346	1.153	1.0288	1.2003	1.1145	.9709
11		1.2209	1.2887	1.0852	1.153	1.3032	1.2548
12		1.2071	1.3032	1.166	1.2574	1.283	
13		1.1736	1.3032	1.1869	1.1271	1.2483	1.2003
14		1.153	1.3032	1.2209	1.0277	1.2483	
15		1.153	1.166	1.2407	1.1022	1.2269	1.0974
16		1.166		1.2407	1.1233	1.1919	1.153
17		1.0056	.9602	1.2209	1.2136	1.1694	1.0852
24	.6516						
Max	.9496	1.2346	1.3032	1.2407	1.2574	1.3032	1.2548
Min	.6516	1.0056	.9602	1.0288	1.0277	1.1145	.9709
Avg	.7984	1.1642	1.2111	1.1738	1.1506	1.2232	1.1269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 201 / Adgaon(Sarak)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4424	.4096	.3605		.1638	.1638	.1475
2	.4424	.4096	.3605		.1638	.1638	.1475
3	.4915	.4096	.3605		.1638	.1638	.1638
4	.6062	.4915	.4424		.1802	.1638	.1802
5	.6882	.639	.4915	.4096	.1966	.1802	.1966
6	1.0322	.8192	.9012	.8192	.213	.213	.213
7	1.3763	1.491	1.3108	1.4255	.213	.2294	.213
8	.8684	.9069	.9503	1.065	.1802	.2294	.1802
9	.7209	.6882	.6226	.7373	.1311	.1638	.1638
10	.1147	.1475	.1638	.1311	.7865	.7045	.8192
11	.0983	.1311	.1134	.1311	.9012	.7537	.6882
12	.0983	.1311	.1147	.1147	.9175	.8192	.8029
13	.0983	.0983	.0983	.0983	.8192	.7537	.8356
14	.0983	.0983	.0983	.0819	.7865	.5571	.6882
15	.0983	.1147	.0983	.0819	.5243	.5735	.5898
16	.1147	.0983	.0819	.0983	.7209	.6882	.7373
17	.1147	.0983	.0819	.0983	.6226	.7373	.7209
18	.1311	.1147	.1147	.1475	.1966	.1311	.1311
19	.1802	.1802	.1638	.1802	.1802	.1638	.1966
20	.1802	.1802	.1638	.1802	.1802	.1802	.213
21	.1638	.1638	.1475	.1802	.1966	.1802	.213
22	.1638	.1475	.1311	.1638	.1966	.1802	.213
23	.1311	.1475	.1311	.1638	.1802	.1638	.1638
24	.4752	.4096	.3277	.3768	.1638	.1638	.1475
Max	1.3763	1.491	1.3108	1.4255	.9175	.8192	.8356
Min	.0983	.0983	.0819	.0819	.1311	.1311	.1311
Avg	.3721	.3552	.3263	.3342	.3741	.3509	.3652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 202 / Mandki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.128	.0819	.1006	.1638	.2622	
2	.0953	.128	.0819		.1638	.2622	
3	.0953	.128	.0819		.1638	.2622	
4	.1143	.128	.0983		.3277	.4424	
5	.1143	.1463	.0983		.4096	.7865	
6	.1334	.1463	.0983	.1715	.5735	.9012	
7	.1143	.181	.0983	.197	1.0159	.9831	
8	.1143	.1646	.0819	.1174	.6554	.8192	.5281
9	.0819	.12	.0914	.0819	.426	.5468	.6062
10	.6554	.7209		.6554	.0848	.0762	.0819
11	.8029	.8259		.9012	.0686	.0953	.0655
12	1.065	.8097	.6718	1.0486	.0671	.0953	.0655
13	.9831	.8097	1.0526	.9831	.0503		.0671
14	.7045	.6316	.7865	.9012	.0503	.0762	.0503
15	.7373	.5506	.759	.6554	.0503	.0762	.0503
16	.6554	.664	.6882	.5735	.0503	.0762	.0671
17	.4915	.6554		.7701	.0492	.0762	.0503
18	.1097	.0655	.1006	.1311	.0655	.0953	.0995
19	.128	.0983	.1509	.1463	.0819	.1334	
20	.128	.0983	.1715	.181	.0819	.0953	.1543
21	.1646	.0983	.1844	.1629	.0819	.1334	.1543
22	.1463	.0819	.1823	.1646	.0819	.1334	.1715
23	.1463	.0819	.1677	.1646	.0819	.1143	.1372
24	.0953	.128	.0819	.1006	.1943	.2785	.2214
Max	1.065	.8259	1.0526	1.0486	1.0159	.9831	.6062
Min	.0819	.0655	.0819	.0819	.0492	.0762	.0503
Avg	.3322	.3163	.2766	.4104	.2100	.2966	.1607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 203 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.6767	.6584		.7316	.7316	.695
2	.7023	.6767	.6584		.7316	.7316	.695
3	.7392	.6767	.6584		.7316	.7316	.7392
4	.8402	.823	.7865		.9328	.8779	.8686
5	.9896	.9145	1.0059		1.134	.9145	1.0349
6	1.3392	1.2071	1.1706	1.0498	1.3169	1.2071	1.4146
7	1.4146	1.3535	1.3169	1.3203	1.3717	1.2803	1.4335
8	1.3769	1.2437	1.1523	1.1458	1.2437	1.2437	1.358
9	1.1157	1.1706	1.0242	.7499	1.0208	1.0269	1.1523
10	.9511	.9259	.7796	.823	.7802	.7392	.8596
11	.6584	.9465	.6401	.7316	.583	.5729	.6584
12	.6401	.7545	.439	.6584	.5316	.5304	.5853
13	.5487	.6687	.567	.7133	.5316	.5611	.4973
14	.6767	.6687	.6036	.6767	.5487	.5611	.5144
15	.7316	.6001	.6036	.6219	.5658	.6036	.5144
16	.7865	.5658	.567	.6584	.5316	.6219	.5316
17	.9145	.6584		.7133	.7133	.7023	.4801
18	1.0608	.7316	.985	.8962	.7682	.9055	.8954
19	1.0974	1.0242	1.0974	1.1888	.9145	1.2449	1.307
20	.9877	.9145	.964	1.1157	.9694	1.1506	1.1584
21	.9145	.8596	.8589	.9511	.9328	.9979	.985
22	.8779	.7682	.7888	.9145	.823	.9425	.8764
23	.7499	.7133	.7202	.8048	.7865	.7865	.7888
24	.695	.6767	.6584	.6859	.7499	.7499	.7316
Max	1.4146	1.3535	1.3169	1.3203	1.3717	1.2803	1.4335
Min	.5487	.5658	.439	.6219	.5316	.5304	.4801
Avg	.8960	.8425	.8132	.8642	.8310	.8506	.8656



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 204 / 11 KV Jatwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.4372	.3887		.4915	.4858	.4858
2	.4534	.4372	.3887		.4915	.4858	.4858
3	.4858	.4372	.3887		.4915	.4858	.5182
4	.5182	.4915	.4372	.5344	.4915	.583	.5506
5	.5506	.6316	.4858		.5407	.6316	.583
6	.9069	.8259	1.0202	.8259	.639	.6802	.6316
7	1.6194	1.4575	1.2631	1.4575	.7373	.7773	.7287
8	1.0202	1.0688	.8421	1.3765	.7373	.8421	.8097
9	.6802	.6964	.7373	1.2146	.6802	.7125	.7287
10	.6316	.6964	.6316	.583	.9878	.9717	.8259
11	.583	.6316	.5344	.6154	1.2146	1.1822	.9231
12	.583	.583	.4858	.4858	.4372	1.3603	.9231
13	.6316	.5506	.4858	.4858	.3887	1.1012	
14	.583	.502	.5344	.5344	.3887	.8421	.3887
15	.583		.5407	.5344	.8583	.8097	.9555
16	.583	.5344	.5344	.5344	1.085	.9717	.7935
17	.639	.583	.5506	.5407	1.166	.8097	.9878
18	.6882	.4858	.583	.5898	.6316	.502	.5344
19	.6802	.6316	.6316	.5898	.6802	.6316	.6802
20	.583	.583	.6316	.6316	.6316	.583	.6478
21	.5344	.5344	.5344	.5407	.5344	.5506	.583
22	.5344	.5344	.5182	.4858	.4858	.5182	.5344
23	.4858	.4858	.5182	.4915	.4858	.5182	.5182
24	.4858	.4372	.3887	.4372	.4858	.4858	.502
Max	1.6194	1.4575	1.2631	1.4575	1.2146	1.3603	.9878
Min	.4534	.4372	.3887	.4372	.3887	.4858	.3887
Avg	.6457	.6198	.5856	.6745	.6568	.7301	.6661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 201 / 11 Kv Sajapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823	.7095	.8402	.4001	.5041	.3658
2		.8059	.6722	.7888	.4191	.4854	.3658
3		.7716	.6535	.823	.4001	.4481	.381
4		.7888	.5975	.7888	.381	.5228	.4115
5		.7716	.6722	.7716	.3429	.5601	.4268
6		.8573		.9088	.4572	.5788	.4268
7		.8916	.7655	.9088	.5335	.6161	.4572
8		.7888	.6722	.7888	.5335	.4294	.4572
9		.8573	.5144	.2229	.2987	.4294	.3353
10	.2591	.3921		.3429	.7095	.703	.5975
11	.2915	.3734	.1715	.381	.6908	.6859	.8215
12	.2743	.3547	.3429	.362	.6722	.583	.7655
13	.2743	.3547	.3601	.4001	.6535	.6687	.7282
14	.2591	.3361	.3601	.381	.6722	.6516	.7095
15	.2591	.3361	.3601	.4191	.6722	.6344	.6908
16	.3048	.3361	.3601	.4001	.6722	.6173	.6097
17	.3048	.3174	.2572	.362	.7095	.6687	.724
18	.6687	.3547	.6344	.7049		.7373	.7811
19	.7888	.6348	.7545	.8764		.8745	.9717
20	.8573	.7842	.7888	.8764	1.307	.8916	1.0288
21	.8916	.8962	.823	.9526	.7095	.9259	1.0288
22	.9431	.8589	.8916	.8764	.6535	.9259	1.0479
23	.8916	.8402	.8059	.9145	.5601	.8745	1.0288
24	.1715	.8573	.7468	.8059	.3429	.5228	.3353
Max	.9431	.8962	.8916	.9526	1.307	.9259	1.0479
Min	.1715	.3174	.1715	.2229	.2987	.4294	.3353
Avg	.4960	.6410	.587	.6624	.5814	.6475	.6457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 202 / 11kv Karodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258	.4294	.3258	.3429	.3547	.2286
2		.3086	.4108	.2915	.3048	.3547	.2134
3		.3429	.4481	.3258	.2858	.3921	.2439
4		.3772	.4854	.3772	.3048	.4294	.2743
5		.5144	.5788	.4287	.3429	.4668	.3048
6		.6001	.7095	.6516	.4001	.4854	.3506
7		.6173	.7842	.6859	.381	.4668	.503
8		.6173	.6161	.6173	.4191	.6535	.3658
9		.5487	.3601	.4973	.3361	.4668	.2896
10	.2591	.3921		.4001	.3734	.3429	.3361
11	.2439	.3921	.3601	.3048	.3361	.3086	.2987
12	.3353	.3734	.4287	.3239	.2801	.2572	.2801
13	.3201	.3734	.3772	.3239	.2427	.2572	
14	.2743	.3361	.3429	.3429	.2452	.2229	.2987
15	.3048	.2987	.3258	.3048	.2427	.2229	.2987
16	.3201	.3174	.3601	.3429	.2801	.2229	.2858
17	.3048	.3361	.3258	.362	.3174	.2572	.4001
18	.4458	.5228	.3429	.4191	.4108	.3944	.4572
19	.5487	.4481	.4801	.6097	.6161	.5487	.5525
20	.4458	.4108	.4458	.5525	.5975	.5316	.5716
21	.3944	.4481	.4115	.4382	.4668	.463	.5335
22	.3429	.4481	.8082	.362	.3921	.3772	.4001
23	.3086	.4108	.3258	.362	.3361	.3258	.3429
24	.1334	.3086	.4108	.3429	.3048	.3361	.1829
Max	.5487	.6173	.8082	.6859	.6161	.6535	.5716
Min	.1334	.2987	.3258	.2915	.2427	.2229	.1829
Avg	.3321	.4195	.4595	.4164	.3566	.3808	.3484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 203 / 11 kv INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.2614	.4877	.5335	.5975	.6516
2		.3944	.2427	.4725	.4954	.6161	.6173
3		.3772	.2241	.442	.5906	.5975	.6001
4		.3772	.2614	.463	.6097	.6348	.6344
5		.3601	.2801	.463	.5716	.6535	.6173
6		.3772	.2987	.4268	.5525	.6535	.6344
7		.3429	.3361	.4268	.6097	.6722	.6173
8		.3086	.4294	.4973	.6478	.7468	.6516
9		.2572	.3944	.7164	.8589	.8775	.9088
10	.7716	.2987		.9907	1.3817	.9259	1.0829
11	.8059	.2987	.5792	1.105	1.307	.8573	1.1576
12	.6401	.2987	.8535	1.0479	1.3256	.823	1.307
13	.6554	.2987	.6097	1.0288	1.2696	.7716	1.363
14	.6401	.2987	1.166	.9335	1.3256	.9602	1.4003
15	.8059	.2801	1.1279	.8573	1.4003	1.0288	1.475
16	.8573	.2801	1.2955	1.1622	1.2323	1.0802	1.2765
17	.7888	.2987	1.1888	1.3908	1.0269	1.286	1.5051
18	.7373	.2987	1.1431	1.0669	.9335	1.2689	1.6766
19	.4458	.2801	1.1584	1.0288	.9149	1.0288	1.5242
20	.4458	.2987	.7888	.7049	.8589	.7888	.6859
21	.4801	.2987	.6001	.5525	.8402	.7373	.6668
22	.5144	.2987	.6687	.4954	.8589	.7545	.6478
23	.463	.2614	.5182	.4954	.8402	.7373	.6097
24	.5144	.4287	.2614	.5335	.4763	.7545	.703
Max	.8573	.4287	1.2955	1.3908	1.4003	1.286	1.6766
Min	.4458	.2572	.2241	.4268	.4763	.5975	.6001
Avg	.6377	.3218	.6386	.7412	.8942	.8272	.9589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 201 / 11 KV SUKHNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.0953	.1143	.1905
2	.1905	.1905	.1905	.1905	.0953	.1143	.1905
3	.1905	.1905	.2286	.2286	.0953	.1524	.1905
4	.2858	.2286	.3048	.2858	.1905	.1715	.2286
5	.381	.2858	.4191	.2858	.1905	.2286	.2858
6				.381	.381	.3048	.381
7					.4763	.5144	.5716
8	.381				.4763	.5525	.381
9	.381	.381	.4191		.381	.4191	.381
10	.2858	.3048	.381	.381	.2858	.4191	.2858
11	.3048	.3048	.381	.381	.2286	.1905	.1905
12	.381	.2667	.381	.381	.1905	.1905	.1905
13	.381	.3429	.2858	.381	.1905	.1905	.0953
14	.2858	.2858	.2286	.381	.1715	.1905	.1905
15	.381	.2667	.2286	.381	.1715	.1905	.0953
16	.3048	.3048	.2286	.381	.1524	.1905	.0953
17	.381	.3239	.2858	.2858	.1715	.1905	.1905
18	.381	.3048	.2286	.2858	.3048	.2858	.2858
19	.4763	.4191	.381	.4763	.4191	.4763	.381
20	.381	.362	.2858	.381	.362	.381	.381
21	.381	.3048	.2286	.2858	.2858	.381	.2858
22	.2858	.2477	.2286	.2858	.2477	.2858	.2858
23	.1905	.2286	.1905	.2858	.2286	.2286	.2858
24	.1905	.1905	.1905	.1905	.1905	.1334	.1905
Max	.4763	.4191	.4191	.4763	.4763	.5525	.5716
Min	.1905	.1905	.1905	.1905	.0953	.1143	.0953
Avg	.3178	.2821	.2803	.3193	.2493	.2707	.2596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 202 / 11 KV KHODEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.1524	.1905	.2286	.2286
2	.1905	.1524	.1905	.1524	.1905	.2286	.2286
3	.1905	.1524	.1905	.1905	.1905	.381	.2858
4	.1905	.1905	.2286	.2286	.2858	.5144	.381
5	.2858	.1905	.2667	.2286	.381	.4191	.381
6	.2858	.2286	.3239	.2858	.4763	.4763	.381
7	.381	.381	.4572	.381			
8	.381	.381	.4191	.381			
9	.381	.2858	.3429	.2858	.2858	.3429	.1905
10	.381	.2858	.381	.381	.3239	.2286	.2858
11	.381	.3429	.2286	.2858	.3429	.2286	.2858
12	.2858	.3048	.1905	.1905	.2477	.381	.2858
13	.1905	.362	.1905	.1905	.2286	.2858	.2858
14	.2858	.3048	.1905	.1905	.1905	.1905	.1905
15	.381	.2286	.1905	.1905	.1905	.2286	.1905
16	.4763	.2667	.1905	.1905	.2667	.2286	.2858
17	.4763	.362	.2858	.1905	.3429	.2858	.2858
18	.381	.381	.2858	.381	.3239	.381	.4763
19	.4763	.2096	.4763	.4763	.4382	.5716	.381
20	.381	.2286	.381	.4763	.2286	.381	.381
21	.2858	.3429	.3239	.381	.381	.381	.2858
22	.2858	.2858	.2858	.2858	.2858	.2858	.2858
23	.2286	.2477	.2286	.2858	.2667	.2858	.2858
24	.1905	.1905	.1905	.1524	.1905	.2667	.2858
Max	.4763	.381	.4763	.4763	.4763	.5716	.4763
Min	.1905	.1524	.1905	.1524	.1905	.1905	.1905
Avg	.3151	.2691	.2762	.2723	.2840	.3273	.2979

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 203 / 11 KV MURADABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.7621	.7621	.7621	.381	.4954	.4763
2	.381	.7621	.7621	.7621	.381	.4954	.4763
3	.5716	.8573	.8573	.8573	.5716	.5716	.4763
4	.9526	1.0479	1.105	1.1431	.5716	.7049	.5716
5	1.2384	1.3336	1.3527	1.2384	.7621	.8002	.7621
6				1.3336	.9526	.8192	.7621
7					1.3336	1.3908	1.3336
8	1.2384				1.1431	1.3146	1.2384
9	1.0479	1.3336	1.1241		.8573	1.1812	.9526
10	.9526	1.0669	.9526	1.0479	.6668	.6668	.5716
11	1.1431	1.2955	.9526	1.0479		.5716	.4763
12	1.1431	1.1812	.9526	1.0479		.381	.381
13	1.1431	1.0288	.7621	1.0479		.381	.2858
14	.9526	1.0288	.7621	1.1431	.381	.381	
15		.6668	.7621	1.0479	.381	.1905	
16	1.1431	.9335	.9526	1.0479	.362	.2858	.381
17	1.1431	1.0098		.9526	.4954	.381	.4763
18	1.1431	.6478	.5716	.7621	.6287	.7621	.5716
19	1.3336	1.2193	1.3336	1.1431	1.0288	1.3336	.9526
20	.9526	.9907	1.0479	1.0479	.8573	1.1431	1.0479
21	.9526	.8954	.8573	.9526	.9145	.9526	.9526
22	.8573	.8002	.7621	.7621	.8002	.8573	.8573
23	.7621	.743	.7621	.7621	.7621	.7621	.7621
24	.4763	.7621	.7621	.7621	.5716	.4954	.4763
Max	1.3336	1.3336	1.3527	1.3336	1.3336	1.3908	1.3336
Min	.381	.6478	.5716	.7621	.362	.1905	.2858
Avg	.9481	.9698	.9078	.9844	.7049	.7216	.6928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 204 / 11 KV RAJAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.9526	.8573	.9526	1.3336	1.3336	1.5242
2	.9526	.9526	.9145	.8573	1.5242	1.3336	1.5242
3	1.1431	1.0479	.9526	.9526	1.7147	1.7147	1.5242
4	1.3336	1.2384	1.0479	1.1431	1.9052	1.9624	2.0957
5	1.7147	1.5242	1.3717	1.4289	2.4768	2.4958	2.6673
6	2.4768	1.9052	2.0005	1.8099	2.8578	2.9912	3.2388
7	2.8578	2.6673	2.934	2.8578			
8	2.6673	2.7625	3.0102	2.8578			
9	.381	2.2862	2.6101	2.0957	2.8578	2.8578	1.5242
10	2.4768	2.553	2.2862	2.191	2.0195	1.7147	2.0957
11	1.9052	2.0767		1.7147	2.2291	1.9052	
12		1.7147	1.7147	1.5242	1.9624	1.5242	2.4768
13		1.6004	1.5242	1.5242	2.0005	1.7147	2.3815
14		1.4861	1.5242	1.3336	2.0195	1.5242	1.9052
15	1.9052	1.3336	1.3336	1.3336	2.0386		1.9052
16	1.9052	1.448	1.7147	1.5242	1.8671		1.8099
17	2.2862	1.8671	1.9052	2.0957	1.9433	1.7147	2.0005
18	2.6673	2.3243	2.6673	2.3815	2.21	2.8578	
19	3.0483	2.7816	3.0483	2.8578	2.6863		2.8578
20	2.4768	2.3053	2.2862	2.4768	2.191	2.6673	2.4768
21	1.9052	1.9624	2.0005		1.9052	2.2862	2.0957
22	1.7147	1.6766	1.9052	1.9052	1.7718	1.9052	1.8099
23	1.5242	1.4861	1.5242	1.5242	1.5242	1.5242	1.7147
24	.9526	.9526	.9145	.9526	1.3336	1.4098	1.5242
Max	3.0483	2.7816	3.0483	2.8578	2.8578	2.9912	3.2388
Min	.381	.9526	.8573	.8573	1.3336	1.3336	1.5242
Avg	1.8780	1.7877	1.8282	1.7520	2.0169	1.9704	2.0576



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 205 / 11 KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.4763	.5716	.4763	.5716	.5716	.6668
2	.5716	.5716	.6097	.4763	.5716	.6097	.6668
3	.5716	.5716	.6478	.4763	.7621	.7621	.6668
4	.7621	.6668	.6668	.5716	.9526	.9717	.9526
5	.9526	.7621	.8573	.7621	1.2384	1.2765	1.2384
6	1.3336	1.0479	1.1241	.9526	1.3336	1.5242	1.5242
7	1.9052	1.8099	1.6385	1.4289			
8	1.5242	1.5242	1.6766	1.3336			
9	1.0479	1.1431	1.2003	1.1431	1.2384	1.3717	.7621
10	1.1431		.9526	1.0479	1.1812	.9526	1.0479
11	.7621	.9907	.7621	.7621	1.1812	.8002	.5716
12		.8002	.6668	.6668	1.0669	.7621	.9526
13		.6859		.6668	.9907	.7621	.7621
14		.6097	.5716	.5716	.9335		
15	.9526	.6478	.5716	.5716	.8764	.7621	.9526
16	1.1431	.7049	.5716	.6668	.9907	.9526	1.0479
17		.8764	.7621	.7621	.9526		.9526
18	1.3336	1.0479	.9526	1.0479	1.1241	1.1431	.9526
19	1.5242	1.2955	1.1431	1.3336	1.448	1.5242	1.1431
20	1.1431	1.1812	.9526	1.0479	1.0669	1.1431	1.2384
21	.9526	.9717	.8573	.9526	.8764	1.0479	.9526
22	.8573	.7811	.7621	.7621	.743	.9526	.8573
23	.7621	.6859	.7621	.7621	.7049	.7621	.7621
24	.5716	.5716	.6097	.4763	.5716	.6287	.6668
Max	1.9052	1.8099	1.6766	1.4289	1.448	1.5242	1.5242
Min	.5716	.4763	.5716	.4763	.5716	.5716	.5716
Avg	1.0288	.888	.8648	.8216	.9717	.9640	.9209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 206 / EHV THAPTI TANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763	.4954	.5716	.5716	.8002	.7621
2	.5716	.4763	.5335	.5716	.7621	.9145	.7621
3	.5716	.4763	.5716	.5716	.7621	1.105	.8573
4	.7621	.5716	.6478	.6668	.9526	1.1812	1.0479
5	.9526	.7621	.8764	.8573	1.1431	1.3717	1.1431
6	1.1431	.9526	1.0288	1.0479	1.7147	1.6766	1.1431
7	1.1431		1.1431	1.1431	1.9052	2.0957	1.9052
8	1.1431	.9526	.9907	.9526	1.7147	2.0957	1.9052
9	.9526	.7621	.9145	.7621	1.5242	1.6004	.6668
10	1.1431	1.5623	1.1431	1.3336	.5335	.7621	.5716
11		1.7147	1.8099	1.8099	.5335	.5716	.381
12	1.7147	2.21	2.0957	2.0957	.381	.4763	.4763
13	2.2862		1.7147	2.0957		.381	.5716
14	1.9052	1.9052	1.9052	1.7147	.381	.381	.5716
15	2.0957	1.9814	1.7147	1.9052	.381	.381	.5716
16	2.0957	2.1338	2.0957	2.0957	.5716	.5716	.6668
17	1.9052	1.9433	2.0005	1.7147	.6097	.6668	.7621
18	.8573	.724	.5716	.5716	.8383	.7621	.7621
19	.9526	1.0288	.9526	1.1431	1.105	.9526	.9526
20	.7621	.9526	.7621	.9526	.9526	.7621	.7621
21	.6668	.8002	.6668	.7621	.6097	.7621	.7621
22	.5716	.6478	.6668	.5716	.5716	.9526	.5716
23	.5716	.5716	.5716	.5716	.5335	.4763	.5716
24	.6668	.4763	.5335	.5716	.5716	.8002	.7621
Max	2.2862	2.21	2.0957	2.0957	1.9052	2.0957	1.9052
Min	.5716	.4763	.4954	.5716	.381	.381	.381
Avg	1.1307	1.0946	1.1003	1.1273	.8532	.9375	.8296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 207 / ANTERWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763		.4763	.381	.5335	.4763
2	.5716	.5335		.4763	.4763	.5335	.4763
3	.7621	.5716		.5716	.4763	.6097	.4763
4	.8573	.7621		.8573	.6668	.7049	.4763
5	1.0479	1.0479		.9526	.9526	.9145	.6668
6				1.1431	1.3336	1.1431	.9526
7					1.6194	1.7909	
8	1.2384				1.4289	1.7147	.7621
9	1.1431	1.1431			1.1431	1.3336	.7621
10	1.0479	.8192	.9526	.7621	.7621	.7621	.4763
11	1.1431		.9526	1.2384	.4382	.381	.381
12	1.3336		1.3336	1.6194	.4572	.3048	.4763
13	1.4289		1.5242	1.6194	.4763	.381	.4763
14	1.3336	1.6004	1.4289	1.5242	.4954	.381	.4763
15	1.2384	1.5623	1.3336	1.3336	.5144	.381	.4763
16	1.1431	1.5813	1.1431	1.4289	.5716	.4763	
17	1.1431	1.4289	.7621	1.2384	.7049	.5716	.5716
18	1.0479	.724	.6668	.8573	.8764	.7621	.7621
19	1.0479		1.1431	1.1431	1.2574	1.1431	1.1431
20	.8573		.9526	.9526	.9717	.9526	.9526
21	.7621		.6668	.7621	.6859	.7621	.7621
22	.6668		.5716	.6668	.6287	.7621	.6668
23	.5716		.5716	.5716	.5335	.6668	.5716
24	.5716	.4763		.5144	.5716	.5335	.4763
Max	1.4289	1.6004	1.5242	1.6194	1.6194	1.7909	1.1431
Min	.5716	.4763	.5716	.4763	.381	.3048	.381
Avg	.9786	.9790	1.0002	.9862	.7676	.7708	.6235

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 201 / 11 KV KARMAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0754	.2012	.2012	.1677
2	.0943	.0377	.0943	.0377	.2012	.2347	.1677
3	.0943	.0943	.0754	.0377	.2012	.2012	.2347
4	.1132	.132	.0943	.1132	.2347	.2347	.3018
5	.132	.1509	.1132	.0377	.2683	.2683	.2683
6	.1509	.1886	.1509	.0377	.3018	.3018	.3018
7	.1886	.2263	.2263	.2452	.4359	.4024	.3688
8	.2263	.2452	.2452	.2452	.3353	.3688	.4024
9	.1698	.2075	.1886	.1132	.3353	.3353	.503
10	.4191	.57	.4715	.583	.1509	.1132	.0943
11	.4527	.4694	.4359	.6001	.1509	.1132	.0754
12	.4527	.503	.4694	.6001	.1509	.0943	.0754
13	.4359	.4359	.4694	.5144	.0754	.0943	.0754
14	.4024	.4694	.4694	.5365	.0754	.0943	.0761
15	.4191	.503	.4694	.4191	.0566	.0943	.0754
16	.4024	.4359	.503	.3353	.0754	.0943	.0754
17	.4694	.4694	.503	.3353	.1132	.1509	.1132
18	.1132	.1509	.57	.0943	.1509	.1509	.1132
19	.2075	.1509	.1698	.1509	.2263	.1509	.1886
20	.1886	.1886	.1886	.1509	.1886	.1886	.1886
21	.1509	.1509	.1509	.132	.1886	.1886	.1509
22	.1132	.1132	.1132	.1132	.1509	.1509	.1509
23	.0943	.0943	.1132	.0943	.1132	.1132	.132
24	.0943	.0943	.0943	.0754	.2012	.2347	.1677
Max	.4694	.57	.57	.6001	.4359	.4024	.503
Min	.0943	.0377	.0754	.0377	.0566	.0943	.0754
Avg	.2366	.2573	.2697	.2366	.1910	.1906	.1862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 202 / 11 KV GADHE JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8048	.7545	.7042	.9431	.9808	.9054
2	.9431	.8048	.7209	.9724	.9808	.9431	.7922
3	.9221	.8048	.7545	1.4083	1.0185	.9808	.7167
4	1.0898	.8718	.8383	1.5089	1.2449	1.2181	1.094
5	1.2574	1.073	1.0059	1.7101	1.6221	1.5466	1.4712
6	1.5089	1.5424	1.0151	1.8442	1.9993	1.9239	2.0559
7	2.2298	2.1795	2.1795	2.1125	2.037	1.9239	1.9805
8	1.9113	2.146	2.2131	2.1795	1.9239	1.8861	1.8673
9	1.6598	1.7436	1.7269	1.5927	1.5466	1.2826	1.4335
10	.7922	1.3203	1.094	1.1506	1.4083	1.2574	1.2407
11	.7545	.9431	.8299	.7545	1.6095	1.5089	1.3077
12	.7545	.7922	.5658	.6602	1.576	1.2574	1.4083
13	.7167		.5658	.5658	1.643	1.4251	1.3413
14	.7922	.6413	.6036	.6224	1.3748	1.2239	1.1065
15	.7922	.679	.6413	.7356	1.291	1.073	1.073
16	1.0374	.6413	.6413	.5281	1.5089	.5868	1.1736
17	1.1694	.7167	.9054	.679	1.5089	1.2742	1.0898
18	1.4335	1.0374	.8488	.9431	1.0374	.9431	1.5089
19	1.5466	1.4146	1.6032	1.6221	1.6221	1.6221	1.6975
20	1.4335	1.6032	1.5089	1.4335	1.4146	1.5089	1.5278
21	1.1317	1.2071	1.3957	1.2449	1.2637	1.2887	1.226
22	.9808	.9431	1.0185	1.1317	1.1694	1.1694	1.1317
23	.9054	.9054	.9431	1.0185	.9431	1.0185	.9997
24	.9431	.8048	.7209	.6371	.9431	.9431	.9431
Max	2.2298	2.1795	2.2131	2.1795	2.037	1.9239	2.0559
Min	.7167	.6413	.5658	.5281	.9431	.5868	.7167
Avg	1.1520	1.1139	1.0456	1.1567	1.4013	1.2828	1.2955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 203 / 11 KV SHEKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.6095	1.4419	1.4419	.9054	.8676	.7922
2	1.7147	1.6095	1.4754	1.4419	.9054	.9054	.7922
3	1.6766	1.6095	1.4419	1.6095	.9054	.8676	.9054
4	2.0119	1.643	1.5089	1.8778	.9054	.9054	.9808
5	2.3472	1.6766	1.5927	2.146	1.1694	1.1317	1.2826
6	3.0178	2.1795	2.3472	2.649	1.4712	1.4335	1.358
7	3.3532	2.9508	2.9843	3.1855	1.6975	1.6975	1.4712
8	1.3413	3.0178	3.0178	2.9172	1.5844	1.5844	1.3957
9	1.6095	2.649	2.5819	2.4813	1.2449	1.3392	1.2449
10	.7545	.9808	.9054	.9431	2.5819	2.3472	2.1795
11	.6979	.9054	.7613	.9054	2.9843	2.8502	2.4478
12	.6979	.7545	.7545	.8488	2.6825	2.5484	2.7161
13	.8865	.8676	.679	.7545	2.9508	2.6825	2.4143
14	.8676	.7922	.7167	.7545	2.7161	2.5484	2.4143
15	.8676	.8299	.7167	.7545	2.4143	2.5484	3.0178
16	.9054	.7545	.6036	.7545	2.5819	2.5819	2.9843
17	1.0374	.8488		.7922	2.5819	2.431	2.8502
18	1.2826	.9431		.9431	.9808	.9808	1.3203
19	1.4335	1.5089	1.4146	1.5089	1.5089	1.358	1.5089
20	1.3203	1.358	1.4712	1.3957	1.2637	1.3957	1.5089
21	1.1694	1.1317	1.2071	1.2449	1.2449	1.1694	1.4523
22	1.0185	.9054	.9997	1.1317	1.0562	1.094	1.1317
23	.9054	.8488	.9054	1.0185	.9431	.9808	1.0562
24	1.5432	1.6095	1.4754	1.4083	.9054	.9054	.7922
Max	3.3532	3.0178	3.0178	3.1855	2.9843	2.8502	3.0178
Min	.6979	.7545	.6036	.7545	.9054	.8676	.7922
Avg	1.4239	1.4160	1.4092	1.4545	1.6744	1.6314	1.6674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 205 / 11 KV GOLATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.094	1.0374	1.0185	.7042	.7545	.8048
2	1.0374	1.094	1.094	1.1317	.7042	.8048	.8718
3	1.0374	1.1317	1.0374	1.2826	.7042	.7545	1.0395
4	1.226	1.3203	1.226	1.358	.6874	.8048	1.1401
5	1.5089	1.6975	1.6032	1.6598	.9389	.9724	1.2071
6	1.7918	1.9239	1.9616	1.773	1.1736	1.4251	1.3748
7	1.9427	2.1125	2.1502	2.0559	2.079	2.3137	1.643
8	1.9427	1.9993	2.037	1.9805	1.643	1.9281	1.6095
9	1.5089	1.5466	1.4901		1.3748	1.3413	1.4419
10	1.6933	1.5089	1.576	1.5592	.8676		.9054
11	1.7604	1.8107	1.6766	1.8107	.6413		.7167
12	1.7604	1.9448	1.643	1.7939	.6036		.6036
13	1.7101	1.643	1.4083	1.6766		.7545	.7167
14	1.7604	1.4419	1.3748	1.291	.7167	.7167	.679
15	1.7604	1.2742	1.3413	1.2407	.7545	.7356	.7922
16		1.4754	1.4754	1.4251	.7545	.7545	.8299
17	1.3748	1.4251	.6706		.8488	.7922	.9808
18	1.3203	1.1317	.811	.8676	1.226	1.0185	1.5089
19		1.6221	1.5844	1.7353	1.4712	1.7353	1.7918
20	1.6221	1.5844	1.5844	1.6598	1.5089	1.5089	1.7164
21	1.4335	1.3957	1.4712	1.3203	1.358	1.4335	1.3957
22	1.2826	1.2071	1.2826	1.2449	1.226	1.3203	1.3203
23	1.1317	1.1317	1.1694	1.1317	1.0374	1.1694	1.1317
24	1.0374	1.094	1.1128	1.094	.7209	.8048	.7712
Max	1.9427	2.1125	2.1502	2.0559	2.079	2.3137	1.7918
Min	1.0374	1.094	.6706	.8676	.6036	.7167	.6036
Avg	1.4855	1.4838	1.4091	1.4596	1.0324	1.1354	1.1247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 206 / 11 Kv Mirza industrial SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 201 / 11 KV SHENDRA FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0806	.7716	.8573	.8573	1.2003	1.166	1.2003
2	.0857	.7716	.8573	.8573	1.2003	1.166	1.2003
3	.1029	.7716	.8573	.8573	1.2003	1.2003	1.2003
4	.12	.9431	1.0288	.8573	1.3717	1.3717	1.2003
5	.1372	1.1145	1.2689	1.3717	1.7147	1.6804	1.3717
6	.1457	1.6289	1.5775	1.8861	2.1434	2.0576	1.7147
7	.1715	2.1434	2.0233	1.8861	2.0576	2.2291	1.3717
8	1.4403	1.8004	2.1605	2.0062	1.8861	2.0919	1.8004
9	1.3717	1.7147	1.6289	1.6804	1.8861	.1715	1.8004
10	1.0974	1.2517	1.3717	1.2689	1.5432	.1372	1.286
11	1.0288	1.1488	1.2003	1.0974	1.7833	.1715	1.5432
12	.6001		1.1145	.8573	1.7147	.1972	1.6289
13	.6344		1.0288	.9259	1.7147	.1715	1.6289
14	.9259	.9431	.9431	.8916	1.6461	.1629	1.5432
15	.9602	.8573	.9431	.8916	1.7147	.1457	1.3717
16	1.0974	.8573	.9431	.9259	1.7147		1.4575
17	1.2003		1.0288	.9431	1.5775		
18	.7716	1.3032		1.2003	1.2003	1.2003	.1286
19	1.3717	1.7147	1.7147	1.6289	1.7147	1.7147	.18
20	1.3717	1.5432	1.7147	1.5432	1.5432	1.5775	.1715
21	1.3717	1.406	1.5432	1.3717	1.3375	1.3717	.1543
22	1.2003	1.3717	1.3717	1.3717	1.2003	1.5432	.12
23	1.0288	1.2346	1.286	1.2003	1.166	1.5432	.12
24	1.0288	.7716	.8573	.8573	1.2003	1.166	1.2003
Max	1.4403	2.1434	2.1605	2.0062	2.1434	2.2291	1.8004
Min	.0806	.7716	.8573	.8573	1.166	.1372	.12
Avg	.8060	1.2411	1.2748	1.2181	1.5597	1.1017	1.1041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 202 / 11 KV MAHALPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.7888	.7716	.4287	.5144	.5144
2	.0772	.7716	.7888	.7716	.4287	.5144	.5144
3	.0857	.7716	.7888	.7716	.4287	.5144	.5144
4	.1029	.9431	.9602	.8573	.6001	.6173	.6001
5	.12	1.2003	1.2003	1.0288	.6859	.7545	.8573
6	.1543	1.4575	1.3717	1.2003	1.0288	1.0288	1.1145
7	.1543	1.4575	1.3717	1.3717	1.3717	1.5775	1.3717
8	1.3717	1.286	1.2003	1.2003	1.1145	1.2003	1.3717
9	1.2003	.8573	1.0288	.9602	1.0288	1.0288	1.1145
10	.6859	.8573	1.0288	.6859	.9431	.0943	.8573
11	.9945	.8573		1.1317	.8573	.0857	.6859
12	.9259	.8573		1.2346	.6001	.0686	.6001
13	.9259	.9088		1.0288	.6001	.06	.6001
14	.9602	.8573		.9259	.5144	.06	.5144
15	.8916	.8573		.8916	.5144	.06	.5144
16	.7545	.8573		1.0631	.5144	.06	.5144
17	1.0288	1.0288	.7716	1.1145	.7202	.6516	.0686
18	1.1145	.4801	.8573	.7716	.7888	.8573	.0857
19	1.2003	1.3717	1.3717	1.1145	1.2003	1.2003	1.286
20	1.0288	1.2003	1.0288	1.0288	1.0974	1.1488	.1029
21	1.0288	1.1317	1.1145	.9431	.9945	1.0288	.1029
22	.8573	1.0288	1.0288	.8573	.8573	.9088	.0857
23	.8573	.8916	.8573	.7716	.823	.8573	.0686
24	.0772	.7716	.823	.7716	.4287	.5144	.5144
Max	1.3717	1.4575	1.3717	1.3717	1.3717	1.5775	1.3717
Min	.0772	.4801	.7716	.6859	.4287	.06	.0686
Avg	.7237	.9781	1.0212	.9695	.7737	.6419	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 203 / 11 KV BHALGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	1.1145	1.1317	1.1145	1.4575	1.4746	1.4575
2	.1372	1.1145	1.1317	1.1145	1.4575	1.4746	1.4575
3	.1543	1.1145	1.1317	1.1145	1.4575	1.4746	1.4575
4	.1715	1.286	1.2689	1.2003	1.7147	1.7147	1.5432
5	.1886	1.4575	1.4746	1.3717	2.0576	2.0576	1.7147
6	.2401	1.9719	1.7147	1.7147	2.4006	2.2291	1.8861
7	.2743	2.572	2.4006	2.3148	2.572	2.572	2.2291
8	2.1262	2.4006	2.572	2.2634	2.2291	2.2977	1.8861
9	1.8861	2.0576	1.9719	2.0233	2.0576	.1423	1.8861
10	1.5775	1.4575	1.5432		1.8004	.1886	1.8004
11	1.3375	1.1145	1.2003	1.0974	2.1434	.2058	2.2291
12	1.2003	1.0288	1.0288	.7888		.2229	2.2291
13	1.166	1.2517	1.0288	.8573	1.8004	.2058	2.0576
14	1.166	1.2003	1.0288	.7545	2.3148	.2143	
15		1.1145	.9431	.6516	2.2291	.1886	1.7147
16	1.7833	1.1145	1.0288	.8916	2.0576	.2058	2.0576
17	1.7147	1.3032	1.1145	1.0288	2.0919	1.9719	.1972
18	1.9719	1.6804	1.2003	1.4575	1.4746	1.7147	.1457
19	2.2291	2.2634	2.2634	1.9719	2.0576	2.0919	.2143
20	1.8861	1.8861	1.8861	1.8861	1.8861	1.9376	.1886
21	1.7147	1.7833	1.8004	1.8004	1.749	1.7147	.18
22	1.5432	1.7147	1.5432	1.6289	1.5432	1.7661	.1543
23	1.3717	1.5432	1.3717	1.4575	1.5089	1.5432	.1372
24	.1372	1.1145	1.2003	1.2003	1.4575	1.4746	1.4575
Max	2.2291	2.572	2.572	2.3148	2.572	2.572	2.2291
Min	.1372	1.0288	.9431	.6516	1.4575	.1423	.1372
Avg	1.1354	1.5275	1.4575	1.3784	1.8921	1.2952	1.3166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 205 / 11KV Om Gajanan Industrial SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086	.0686	.0686	.1372	.0857	.0857	.1029
2	.0086	.0686	.0686	.1372	.0857	.0857	.1029
3	.0086	.0686	.0686	.1372	.0857	.0857	.0857
4	.0069	.0686	.0686	.1372	.0686	.0686	.0857
5	.0069	.0686	.0686	.12	.0686	.0514	.0857
6	.0069	.0686	.0686	.0857	.0686	.0686	.0686
7	.0069	.0686	.0686	.0514	.0514	.0686	.0514
8	.0857	.0857	.0857	.0857	.0686	.12	.0686
9	.1715	.0857	.1029	.12	.1543	.0171	.1543
10	.1543	.0857	.1372	.2058	.1715	.0137	.2058
11	.1886	.0857	.2915	.2401	.1886	.0137	.2743
12	.2743	.1029	.3601	.2229	.2058	.0149	.1543
13	.1543	.0686	.2572	.2572	.2058	.0137	.2058
14	.2058	.0686	.2401	.2401	.3086	.0137	.3258
15	.1372	.0686	.4287	.1372	.2743	.0137	.2743
16	.1372	.0686	.3429	.1715	.1886	.0154	.2915
17	.1029	.0686	.3086	.12	.3086	.1886	.0223
18	.1029	.0686	.2401	.1715	.2743	.2229	.0171
19	.1029	.1029	.2401	.1029	.12	.1715	.012
20	.1029	.12	.1372	.12	.1372	.1715	.0206
21	.1029	.12	.1372	.1372	.12	.1372	.0206
22	.1029	.1029	.12	.1372	.12	.0857	.0171
23	.0857	.1029	.12	.1029	.12	.12	.0137
24	.0086	.0686	.0857	.1372	.0857	.0857	.1029
Max	.2743	.12	.4287	.2572	.3086	.2229	.3258
Min	.0069	.0686	.0686	.0514	.0514	.0137	.012
Avg	.0948	.0815	.1715	.1465	.1486	.0806	.1152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 206 / 11 Kv R. K. Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0343	.0343	.0343	.0343	.0343	.0343
2	.0034	.0343	.0343	.0343	.0343	.0343	.0343
3	.0034	.0343	.0343	.0343	.0343	.0343	.0343
4	.0034	.0343	.0343	.0343	.0343	.0343	.0343
5	.0034	.0343	.0343	.0343	.0343	.0343	.0343
6	.0034	.0343	.0514	.0343	.0514	.0343	.0343
7	.0086	.0343	.0686	.0514	.0686	.0686	.0514
8	.0343	.0514	.0514	.0514	.0686	.0514	.0514
9	.0857	.0514	.0686	.0514	.0514	.0069	.0686
10	.0686	.0343	.0857	.0514	.0514	.0086	.0686
11	.0514	.0514	.0514	.0343	.0514	.0086	.0514
12	.0686	.0343	.0686	.0686	.0514	.0086	.0686
13	.0686	.0343	.0514	.0514	.0514	.0069	.0686
14	.0514	.0343	.0343	.0514	.0686	.0069	.0514
15	.0514	.0514	.0514	.0514	.0514	.0069	.0514
16	.0343	.0343	.0514	.0686	.0514	.0069	.0514
17	.0343	.0343	.0514	.0514	.0343		.0069
18	.0343	.0343	.0343	.0514	.0343	.0343	.0034
19	.0514	.0343	.0514	.0514	.0514	.0514	.0051
20	.0343	.0343	.0343	.0514	.0514	.0514	.0051
21	.0514	.0343	.0343	.0514	.0514	.0514	.0051
22	.0343	.0343	.0343	.0514	.0514	.0514	.0514
23	.0343	.0343	.0343	.0514	.0343	.0514	.0034
24	.0034	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0857	.0514	.0857	.0686	.0686	.0686	.0686
Min	.0034	.0343	.0343	.0343	.0343	.0069	.0034
Avg	.0342	.0372	.0464	.0471	.0471	.0309	.0376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 201 / 11KV HARMAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	.6668	.381	1.3527	.8573	1.3336	1.3336
2	1.1812	.7621	.381	1.2765	.9526	1.2955	1.2955
3	1.1431	.6668	.4191	1.1812	.9526	1.2384	1.2955
4	.9907	.6668	.4572	1.0288	.9526	1.1431	1.2574
5	.9526	.6668	.4954	.8573	.9907	1.1812	1.2193
6	.9526	.5716	.5525	.743	.9907	1.1431	1.1812
7	.9907	.4954	.6097	.8764	1.0669	1.2193	1.1431
8	.9526	.4382	1.0288	1.0479	1.5623	1.4861	1.6766
9	1.0479	.4763	1.2193	1.0669	1.5242	1.6766	1.9433
10	1.1431	.4191	1.4098	1.1431	1.6194	1.6766	1.8861
11	1.1431	.4382	1.4289	1.2384	1.6575	1.9052	1.9052
12	1.1812	.4572	1.448	1.1431	1.5242	1.5242	1.829
13	1.1622	.4572	1.467	1.1431	1.4289	1.448	1.6194
14	1.1431	.4191	1.4289	1.2193	1.4289	1.5623	1.7718
15	1.1431	.4191	1.5051	1.2193	1.4098	1.8099	2.0195
16	1.0479	.4191	1.5623	.9526	1.4289	1.9052	2.0386
17	.9526	.4191	1.5051	1.2193	1.4098	1.7147	2.0767
18	.8764	.4001	1.2765	.9145	1.3717	1.6004	1.9052
19	.8573	.381	1.3336	.8573	1.3336	1.2955	1.7337
20	.8573	.362	1.3336	.8002	1.2384	1.1812	1.7528
21	.9907	.3429	1.3146	.7049	1.2384	1.4098	1.7528
22	.8573	.381	1.5242	.5716	1.1812	1.3717	1.7337
23	.7621	.381	1.4861		1.3336	1.4861	1.6766
24	1.2955	.7621	.381	1.4289	.7621	1.3336	1.3908
Max	1.2955	.7621	1.5623	1.4289	1.6575	1.9052	2.0767
Min	.7621	.3429	.381	.5716	.7621	1.1431	1.1431
Avg	1.0336	.4945	1.0812	1.0429	1.2590	1.4559	1.6432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 202 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.6097	.9335	.8002	.9907	.9907
2	.6668	.8002	.6097	.9335	.8192	.9526	.9526
3	.6668	.8002	.6287	.8954	.8002	.9145	.9526
4	.6859	.8002	.6287	.8764	.8002	.9145	.9145
5	.6859	.7621	.6287	.8383	.7621	.8764	.9145
6	.724	.7621	.6478	.5525	.8002	.8002	.8954
7	.8002	.7049	.6478	.8383	.7621	.8002	.8764
8	.8573	.5716	.724	.8573	.9526	.7621	.8764
9	.9526	.6097	.8764	1.1812	1.1431	1.0669	1.2193
10	1.1431	.5335	1.1431	1.4289	1.3336	1.3717	1.4289
11	1.3527	.6097	1.1812	1.6004	1.5242	1.2574	1.5623
12	1.2384	.6097	1.1812	1.4861	1.4289	1.6385	1.5242
13	1.1431	.5716	1.2003	1.3717	1.3336	1.3336	1.467
14	1.2384	.5716	1.1431	1.5242	1.3717	1.7147	1.6766
15	1.2384	.5716	1.3908	1.5432	1.4289	1.6766	1.8099
16	1.2955	.5335	1.5242	1.3336	1.4289	1.6766	1.7718
17	1.1431	.5335	1.4861	1.3908	1.4289	1.3336	1.7147
18	.9907	.5716	1.4289	1.105	1.4098	1.2955	1.4861
19	.9526	.5716	1.1241	.9526	1.3336	1.2193	1.1431
20	1.0669	.6097	1.1241	.8764	1.1431	1.1431	1.0669
21	1.1431	.6478	1.1241	.8954	1.1431	1.1812	1.0098
22	.9907	.6287	1.0098	.8192	.5335	1.1431	.9526
23	.9526	.6097	.9907	.6668	1.105	1.0669	.9907
24	.6668	.8573	.6097	.9526	.8002	1.0479	.9907
Max	1.3527	.8573	1.5242	1.6004	1.5242	1.7147	1.8099
Min	.6668	.5335	.6097	.5525	.5335	.7621	.8764
Avg	.9701	.6541	.9860	1.0772	1.0995	1.1741	1.2162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 203 / 11KV KUMBHEPHAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.3361	.4904	.3547	.3547	.4572	.4715
2	.4191	.3361	.4954	.3547	.3734	.4572	.5093
3	.4191	.3734	.5281		.3734	.5335	.5281
4	.4763	.4108	.547	.3921	.4481	.6668	.5658
5	.5335	.4481	.5658	.4481	.5601	.7621	.6224
6	.6859	.6722	.6602	.5415	.6722	.9145	.7356
7	.7621	.8589	.7545	.6161	.7655	.9526	.8488
8	.8002	.9335	.7733	.6908	.6722	.8002	.679
9	.7621	.9149	.7356	.7655	.7468	.8002	.7733
10	.7842	.9242	.6535	.7468	.7621	.6602	.5788
11	.8402	.8676	.7167	.7468	.743	.6224	.6535
12	.8775	.8488	.7545	.7468	.7621	.6602	.6348
13	.8775	.8865	.7545	.6908	.8002	.6979	.6348
14	.8402	.7733	.7167	.6535	.7621	.6224	.5601
15	.7842	.7356	.7167	.5788	.724	.7356	.2427
16	.7545	.7922	.7167	.7095	.6668	.7733	.6535
17	.7468	.811	.679	.8029	.6668	.7922	.8215
18	.7468	.7733	.5975	.5788	.6097	.8299	.7811
19	.6348	.7167	.6348	.5601	.5716	.7545	.7095
20	.5601	.5658	.5415	.5601	.5335	.6979	.5975
21	.5788	.5658	.4294	.6161	.5335	.6036	.4854
22	.5228	.547	.4481	.5041	.5335	.547	.4668
23	.4481	.5093	.4108	.4854	.5335	.4715	.4294
24	.4763	.3734	.4904	.3734	.3547	.4954	.4715
Max	.8775	.9335	.7733	.8029	.8002	.9526	.8488
Min	.4191	.3361	.4108	.3547	.3547	.4572	.2427
Avg	.6586	.6656	.6171	.5877	.6051	.6795	.6023



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 204 / 11KV BALIRAJA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	.8573	.8383	1.6194	1.5242	1.4289	1.7147
2	1.3717	.8764	.8573	1.5813	1.5242	1.3336	1.6194
3	1.3717	.8764	.8573	1.5242	1.4861	1.3336	1.5242
4	1.3336	.8954	.8764	1.5242	1.4289	1.3717	1.5242
5	1.3336	.8573	.8764	1.4861	1.4289	1.3717	1.5051
6	1.3717	.8764	.8954	1.467	1.4098	1.4098	1.448
7	1.4098	.8573	.9145	1.4098	1.3908	1.4289	1.3336
8	1.448	.8383	1.2574	1.3717	1.3908	1.3717	1.448
9	1.7147	.8002	1.4098	1.4098	1.5432	1.9052	1.6766
10	1.7528	.8383	1.9052	1.7147	1.448	2.0576	2.1338
11	1.8099	.724	2.21	2.0767	1.3527	1.9433	2.4196
12	2.0195	.6859	2.4196	1.9052	1.4861	2.0195	2.4387
13	2.1338	.6859	2.4768	1.7528	1.5242	1.4861	2.4006
14	2.0957	.7049	2.2862	1.8099	1.4861	1.5623	2.4577
15	2.0957	.724	2.3434	1.8099	1.5242	1.6004	1.9624
16	1.9433	.724	2.4387	2.0005	1.4289	1.6385	2.191
17	1.7147	.724		1.467	1.4098	1.5242	2.2672
18	1.448	.7621	2.2862	1.3527	1.3717	1.448	1.9814
19	1.2193	.7621	1.6766	1.1431	1.3336	1.3336	1.7147
20	1.2193	.8002	1.7337	.8764	1.3336	1.1812	
21	1.3717	.8383	1.8099	1.1812	1.3717	1.2574	1.8099
22	1.5242	.8383	1.7718	1.2384	1.448	1.1812	1.7718
23	1.5242	.8383	1.7147	1.6766	1.7147	1.829	1.7147
24	1.5242	.8002	.8383	1.6766	1.6194	1.7147	1.829
Max	2.1338	.8954	2.4768	2.0767	1.7147	2.0576	2.4577
Min	1.2193	.6859	.8383	.8764	1.3336	1.1812	1.3336
Avg	1.5916	.7994	1.5954	1.5448	1.4575	1.5305	1.8646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 205 / 11KV VAISHNAVI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.3961	.3772	.5716	.679	.5716	.5658
2	.5716	.3961	.3772	.5601	.679	.5335	.5281
3	.5716	.3395	.3584	.5906	.7922	.4954	.5281
4	.6097	.2829	.3584	.5975	.7922	.4954	.5281
5	.6097	.2263	.3395	.5975	.7545	.4763	.5093
6	.6478	.2241	.3395	.6161	.7922	.4954	.5093
7	.6478	.2263	.3584	.6161	.7922	.4763	.5093
8	.6859	.2263	.4904	.6161	.5658	.5335	.6413
9	.6859	.2263	.5281	.8488	.9619	.5716	.6413
10	.9054	.2263	.5093	.9619	.9145	.7922	.6413
11	.9054	.2263	.5093	.9808	.8573	.6224	.8002
12	.8488	.2263	.5093	.8488	.8002	.679	.7811
13	.7922	.1886	.5093	.7922	.8002	.7922	
14	.7922	.1886	.4904	.8488	.8573	.7356	.724
15	.8488	.2263	.5093	.8488	.9526	.5281	.679
16	.8488	.2263	.5281	.7356	.9907	.5335	.7621
17	.7922	.2263	.5658	.8676		.5281	.8192
18	.7922	.2263	.5658	.9431	.9907	.5281	.7922
19	.6224	.2263	.5415	.8488	.9526	.5847	.7545
20	.547	.3395	.5788	.679	.8002	.6036	.8002
21	.6979	.3395	.6287	.6602	.8002	.6224	.8002
22	.7545	.3395	.5415	.7545	.7621	.6413	.8764
23	.7356	.3772	.5415	.6602	.6097	.5658	.8573
24	.6097	.3961	.3772	.5601	.679	.5716	.5658
Max	.9054	.3961	.6287	.9808	.9907	.7922	.8764
Min	.547	.1886	.3395	.5601	.5658	.4763	.5093
Avg	.7139	.2718	.4764	.7335	.8077	.5824	.6789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 206 / 11KV SUSHMA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.5716	.3429	.6287	.743	.9907	.8573
2	.7621	.5716	.3429	.6224	.7621	.9526	.8383
3	.7621	.5144	.362	.6036	.743	.9526	.8383
4	.8002	.4763	.362	.6036	.743	.9907	.8192
5	.8383	.4572	.381	.6036	.7621	.9526	.8192
6	.8383	.4763	.4191	.5788	.7621	.9526	.8002
7	.8573	.4191	.4572	.6097	.7621	.9907	.8002
8	.8764	.362	.6097	.6097	.9907	1.0479	.8764
9	1.1431	.3429	1.0288	.5716	.9335	1.6004	1.4098
10	1.1812	.3429	1.0098	.7621	1.1431	1.2193	1.5623
11	1.1812	.3429	1.0479	.8764	1.4098	1.2193	1.6575
12	1.1431	.381	1.0669	.7621	1.0479	1.5242	1.3336
13	.8954	.381	.9907	.7049	.9907	1.1431	.9145
14	.9526	.3429	.8573	.8383	1.1431	1.448	1.0669
15	.9526	.3429	1.0098	.8192	1.3717	1.448	1.2574
16	1.105	.3429	1.1622	.8764	1.3717	1.4861	1.2765
17	1.0479	.3048	1.0669	.8764	1.4289	1.5623	1.1622
18	1.0288	.3048	.8954	.9145	1.5242	1.6004	.9907
19	.7811	.3048	.8573	.8002	1.1431	1.4098	.7811
20	.7621	.3048	.6668	.6478	.9526	1.105	.724
21	.6097	.3048	.5144	.7621	.9526	.9526	.6668
22	.5906	.3429	.5716	.7811	.9526	.9145	.6859
23	.6097	.3429	.5716	.7049	1.0669	.8764	.724
24	.7621	.5716	.3429	.6097	.7049	1.0479	.8764
Max	1.1812	.5716	1.1622	.9145	1.5242	1.6004	1.6575
Min	.5906	.3048	.3429	.5716	.7049	.8764	.6668
Avg	.8867	.3937	.7057	.7153	1.0169	1.1828	.9891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 207 / 11KV Aurangabad Jalna

TollWays Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0305	.0566	.0648	.0457	.0762	.0566
2	.0762	.0305	.0566	.048	.0533	.0381	.0377
3	.0762	.0267	.0377	.0457	.0343	.0381	.0377
4	.0762	.0305	.0377	.0446	.0229	.0381	.0377
5	.0762	.0267	.0377	.0429	.0191	.0381	.0377
6	.0762	.0267	.0377	.04	.0191	.0381	.0377
7	.0762	.0229	.0377	.0343	.0191	.0381	.0377
8	.0953	.0305	.0377	.0217	.0305	.0381	.0377
9	.0381	.0305	.0377	.0118	.0191	.0381	.0377
10	.0191	.0377	.0091	.0305	.0381	.0377	.0213
11	.0229	.0377	.0145	.0229	.0381	.0377	.0255
12	.0229	.0377	.0206	.0191	.0762	.0377	.0248
13	.0229	.0377	.0171	.0229	.0762	.0377	.0225
14	.0267	.0377	.0149	.0229	.0381	.0377	.0236
15	.0267	.0377	.0229	.0229	.0381	.0377	.0271
16	.0305	.0377	.0263	.0191	.0381	.0377	.0343
17	.0305	.0377	.0457	.0229	.0381	.0377	.0337
18	.0305	.0377	.0532	.0343	.0381	.0377	.0434
19	.0343	.0377	.0526	.0305	.0381	.0566	.0543
20	.0514	.0566	.0857	.0305	.0381	.0566	.0905
21	.0514	.0566	.0983	.0457	.0381	.0566	.1086
22	.0514	.0566	.0937	.0514	.0381	.0566	.1406
23	.0457	.0566	.1029	.0514	.0762	.0566	.1372
24	.0953	.0343	.0566	.0838	.0457	.0762	.0566
Max	.0953	.0566	.1029	.0838	.0762	.0762	.1406
Min	.0191	.0229	.0091	.0118	.0191	.0377	.0213
Avg	.0512	.0372	.0455	.0360	.0399	.0450	.0501

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 201 / LADSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.4144	.4144	.5611	.5068	.4144
2	.4525		.4973	.4144	.543	.543	.4973
3	.4887		.4144	.4144	.5249	.5792	.663
4	.5611		.4973	.4973	.6516	.5973	.7459
5	.7602		.5801	.5801	.724	.8326	.8288
6	.9955		.663	.663	.9774	1.267	.9945
7	1.2308		.8288	.8288	1.3937	1.3032	1.0774
8	1.3937		.7459	.9602	1.2851	1.267	.9116
9	.7421		.8288	.9116	1.1584	1.1584	.9945
10	.905	.7202	.9116	1.086	.905		
11	.6516	.5801	.9945	.8507	.8507		
12	.5792	.4973		.724	.724	.9116	.905
13	.6516	.663		.6697	.6878		.9412
14	.6878	.7459		.5611	.6516		.905
15	.724			.543	.724		.7783
16	.8145			.5249	.7783		.7421
17	.9412			.6335	.8326		.8326
18	1.0317			.8507	.8507		.9231
19	1.1041			.9955	1.086		1.0498
20	1.1584			.8145	.905		.9774
21	.9412			.7421	.8326		.8869
22	.8326				.724	.5801	.7602
23	.724			.5973	.6516		.6697
24	.4163				.5611	.543	
Max	1.3937	.7459	.9945	1.086	1.3937	1.3032	1.0774
Min	.4163	.4973	.4144	.4144	.5249	.5068	.4144
Avg	.8017	.6413	.6706	.6944	.8160	.8408	.8333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 202 / 11 KV ANJANDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448		.663	.5801	.2534	.4706	.4144
2	1.5384		.8288	.7459	.2353	.362	.4144
3	1.5746		.9945	.9945	.2172	.3801	.4973
4	1.7194		1.1603	1.326	.362	.4163	.663
5	1.9004		1.326	1.6575	.4344	.4706	.9945
6	2.0271		1.4918	1.989	.5068	.543	1.0774
7	2.2624		1.6575	2.0719	.543	.6878	.7202
8	2.3529		1.8233	1.989	1.4118	.724	.5801
9	2.4434		1.989	1.8233	.4344	.5973	.4973
10		.5801			1.1041		.7459
11		.4973			1.3213	1.0136	1.4118
12		.3315			1.5203	1.1603	1.5203
13		.2486			1.6108		1.5384
14	.2534	.2486		.3439	1.6832		1.4661
15	.2172			.3801	1.6289		1.3575
16	.181			.4344	1.5203		1.4118
17	.2172			.4525	1.2308		1.4842
18	.5249			.5249	.4706		.5792
19	.3801			.4344	.5973		.7059
20	.5068			.3982	.6878		.6335
21	.3982			.3801	.724		.5611
22	.362			.362	.6516	.7459	.4525
23	.3258			.2534	.5792		.3801
24	1.4118				.2353	.5068	
Max	2.4434	.5801	1.989	2.0719	1.6832	1.1603	1.5384
Min	.181	.2486	.663	.2534	.2172	.362	.3801
Avg	1.1023	.3812	1.3260	.9022	.8318	.6214	.8742

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 203 / 11 KV PIMPALKHUTTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439		.1658	.2486	.7059	.6878	.3315
2	.362		.2486	.3315	.8326	.724	.3315
3	.3801		.2486	.3315	.905	.7602	.4144
4	.4525		.3315	.3315	.9412	.724	.4973
5	.5068		.3315	.4144	.9774	.8145	.5801
6	.5792		.4973	.5801	1.0136	.8688	.663
7	.7059		.5801	.4973	.9774	.9412	.8288
8	.6516		.5801	.4525	.724	1.0136	.9116
9	.362		.4973	.2715	.543	.7964	.7459
10	.5973	.5801	.5601	.362	.3801	.2715	.3315
11	.7421	.7202	.663	.8145	.1086	.1629	.1267
12	.7602	.663		.8326	.1086	.1658	.0905
13	.8688	.7459		.7783	.1086		.0905
14	.9774	.663		.724			.1267
15	.905			.7602			.1086
16	.7964			.724	.1267		.1267
17	.8688			.724	.1991		.1629
18	.5611			.181	.3982		.2353
19	.6335			.4525	.5792		.543
20	.724			.362	.543		.4525
21	.6516			.3439	.5068		.3801
22	.543			.3077	.4706	.2486	.2715
23	.4706			.3258	.4344		.2172
24	.3439				.5249	.6516	
Max	.9774	.7459	.663	.8326	1.0136	1.0136	.9116
Min	.3439	.5801	.1658	.181	.1086	.1629	.0905
Avg	.6162	.6744	.4276	.4848	.5504	.6308	.3725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 204 / SAYYAIDPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439		.4144	.4973	.6697	.8326	.4973
2	.3982		.4973	.4144	.724	.9774	.5801
3	.4525		.5801	.4973	.7964	1.1222	.663
4	.5249		.663	.8288	.905	1.3394	.8288
5	.6335		.8288	.9116	1.3394	1.4118	.9945
6	.8507		.9116	.9945	1.6289	1.448	1.1603
7	1.1946		.9945	.9602	1.8461	2.4434	1.5746
8	1.1765		1.0774	.8288	1.647	2.3167	1.9062
9	.9412		.8288		1.5746	1.8823	2.0719
10	1.448	1.2003	.9945	.4144	.724	.4706	.8288
11	1.9004	1.6004	1.4918	1.4118	.3982	.2896	.3982
12	1.8461	1.9062		1.6108	.362		.3077
13	1.9547	1.989		1.647	.3258		.2896
14	2.0271	2.0719		1.6651	.2353		.2896
15	2.1357			1.7737	.3258		.2896
16	1.9004			1.8099	.362		.2896
17	1.8461			1.7918	.3982		.3077
18	.8507			.4525	.5792		.5611
19	.8869			.8326	.9412		.9412
20	.8869			.724	.8326		.6335
21	.8326			.6516	.724		.5068
22	.724			.4163	.6154	.4973	.4344
23	.6516			.362	.543		.3801
24					.5249	.7783	
Max	2.1357	2.0719	1.4918	1.8099	1.8461	2.4434	2.0719
Min	.3439	1.2003	.4144	.362	.2353	.2896	.2896
Avg	1.1481	1.7536	.8438	.9771	.7926	1.2161	.7276



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 205 / 11 KV Hatmali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.5801	.2486	.5249	.9774	.5801
2	.4525		.663	.3315	.7059	1.1222	.8288
3	.4887			.4144	.724	1.3756	.9945
4	.5249		.8288	.5801	.9231	1.4118	1.1603
5	.6335		.9116	.9945	1.086	1.448	1.2431
6	.7602		.9945	1.0774	1.2489	1.5023	1.326
7	.8869		.7459	.7459	1.5565	1.6108	1.4089
8	1.1222		.5801	.4973	1.1041	1.647	1.2431
9	.7421		.4973	.4144	.9774	1.3575	1.1603
10	.8507	.9945	.663	1.086	.4344	.4344	
11	1.1041	1.0774	.9945	1.2127	.3077	.2896	
12	1.267	1.1603		1.2489	.362	.2486	.3258
13	1.3394	1.2431		1.086	.3258		.2715
14	1.267	1.326		.8869	.2715		.2172
15	1.2308			.8688	.2534		.2534
16	1.2489			.8507	.2353		.2353
17	1.3213			.9593	.2715		.362
18	.7059			.3982	.4163		.2172
19	.9412			.8507	.7783		.9231
20	.905			.5611	.8326		.7783
21	.8326			.5068	.6878		.6154
22	.6878			.5068	.6516	.4144	.5249
23	.543			.4344	.5792		.3801
24	.4344				.5068	.724	
Max	1.3394	1.326	.9945	1.2489	1.5565	1.647	1.4089
Min	.4344	.9945	.4973	.2486	.2353	.2486	.2172
Avg	.8643	1.1603	.7459	.7288	.6569	1.0403	.7166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 206 / BHAKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412		.1658	.4144	.3174	.2172	.2486
2	.9955		.3315	.4973	.2896	.2534	.2486
3	1.086		.663	.663	.2715	.2896	.3315
4	1.1765		.8288	.8288	.3439		.3315
5	1.2851		.9945	.9945	.3801	.3801	.3315
6	1.4118		1.0774	1.1603	.4344	.543	.4144
7	1.5565		1.1603	1.326	.6154	.5068	.4973
8	1.3937		1.326	1.1603	.5249	.4525	.5801
9	.6154		1.4089	1.2431	.4344	.362	.4144
10	.2172	.3201	.4144	.362	.8869	1.0498	.7459
11	.181	.2486	.3315	.1991	1.1584	1.3213	1.3756
12	.181	.1658		.1629	1.3756	1.2431	1.4661
13	.2172	.1658		.1448	1.4842		1.5384
14	.1086	.1658		.1267	1.5565		1.2308
15	.1448			.1267	1.5203		1.2127
16	.2172			.1267	1.448		1.2127
17	.2534			.1629	1.4118		1.2851
18	.3982			.2896	.362		.3439
19	.5068			.3439	.4525		.3439
20	.5068			.3258	.543		.3439
21	.4344			.362	.4706		.362
22	.362			.3077	.4344	.4144	.3258
23	.3258			.3439	.362		.2715
24					.3077	.2896	
Max	1.5565	.3201	1.4089	1.326	1.5565	1.3213	1.5384
Min	.1086	.1658	.1658	.1267	.2715	.2172	.2486
Avg	.6311	.2132	.7911	.5075	.7244	.5633	.6720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 201 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0343	.3429	.3429	.0257	.0257	.2572
2	.3429	.0343	.3429	.3429	.0343	.0257	.2572
3	.4287	.0429	.4287	.4287	.0429	.0343	.2572
4	.6001	.06	.5144	.5144	.0429	.0429	.3429
5	.6859	.0686	.6859	.6859	.0429	.0429	.4287
6					.06	.0772	.6859
7					.0772	.1029	.8573
8					.0686	.0857	.7716
9	.5144	.0514	.5144	.4287	.0514	.0514	.6001
10	.4287	.5144	.4287	.4287	.0171	.0171	.1715
11	.6001	.6001	.5144	.06		.0086	
12	.6001	.6001	.6001	.0772			
13	.06	.6001	.6001	.0686	.0171		
14	.06	.5144	.6001	.0686	.0171	.1715	.0171
15	.06	.5144	.5144	.0686	.0171	.1715	.0171
16	.06	.5144	.6859	.06	.0171	.1715	.0171
17	.0686	.5144	.6001	.06	.0171	.1715	.0171
18	.0343	.3429	.2572	.0343	.0343	.3429	.0257
19	.06	.5144	.5144	.0343	.0429	.4287	.0257
20	.0514	.5144	.5144	.0429	.0514	.4287	.0257
21	.0429	.4287	.5144	.0429	.0429	.4287	.0429
22	.0429	.4287	.4287	.0429	.0343	.4287	.0429
23	.0343	.3429	.3429	.0429	.0343	.4287	.0343
24	.3429	.0343	.3429	.3429	.0257	.0257	.2572
Max	.6859	.6001	.6859	.6859	.0772	.4287	.8573
Min	.0343	.0343	.2572	.0343	.0171	.0086	.0171
Avg	.2601	.3462	.4899	.2009	.0370	.1688	.2454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 202 / EKLAHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0857	.0857	.1286	.1372	1.286
2	.0857	.0086	.0857	.0857	.1286	.1372	1.286
3	.0857	.0086	.0857	.0857	.1372	.1457	1.3717
4	.1715	.0171	.1715	.1715	.1457	.1457	1.3717
5	.2572	.0257	.2572	.2572	.1372	.1457	1.3717
6					.1629	.1543	1.7147
7					.1715	.1543	
8					.18	.1715	1.8861
9	.1715	.0257	.2572	.2572	.18	.1543	1.6289
10	1.8004	1.7147	1.3717	1.5432	.0086	.0086	.0857
11	1.9719	1.8004	1.6289	.1886	.0857	.0086	.0086
12	1.9719	1.8004		.1972	.0086	.0857	.0034
13	.1972	1.8004	1.5432		.0086	.0857	.0086
14	.1886	1.7147	1.7147	.18	.0086		.0086
15	.18	1.7147	1.6289	.1972			.0086
16	.18	1.7147	1.7147	.1972		.0857	.0086
17	.18	1.5432	1.6289	.1886	.0086	.0857	
18	.0171	.1715	.0857	.0086	.0086	.1715	.0086
19	.0171	.2572	.1715	.0171	.0171	.1715	.0086
20	.0171	.2572	.1715	.0086	.0171	.1715	.0171
21	.0171	.1715	.1715	.0171	.0171	.1715	.0171
22	.0171	.1715	.1715	.0171	.0086	.0857	.0171
23	.0171	.1715	.0857	.0086	.0086	.0857	.0086
24	.0857	.0086	.0857	.0857	.1286	.1457	1.3717
Max	1.9719	1.8004	1.7147	1.5432	.18	.1715	1.8861
Min	.0171	.0086	.0857	.0086	.0086	.0086	.0034
Avg	.3674	.7194	.6559	.1899	.0776	.1231	.6135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 203 / CHITEPIMPALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.1629	1.5432	1.5432	.06	.0686	.6001
2	1.6289	.1715	1.6289	1.5432	.06	.0772	.6516
3	1.7147	.1715	1.7147	1.5432	.0686	.0857	.6859
4	1.8004	.18	1.7147	1.6289	.0943	.1115	.9431
5	2.0576	.1972	1.8004	1.8004	.12	.1286	1.3717
6	2.2291	.2401	2.2291	2.0576			
7	2.6578	.2658	2.4863	2.3148			
8	2.3148	.2572	2.4863	2.572			
9	1.9719	.2401	2.2291	2.4006	.1286	.12	1.1145
10	.8573	1.1145	.8573	.9431	.2486	.2401	2.1434
11	.7716	.8573	.6001	.0686	.2658	.2401	.2401
12	.6859	.6859	.6001		.2658	2.2291	.2143
13	.0686	.6001	.5144	.06			
14	.0772	.6001	.4287	.06	.2143	2.572	.2143
15	.0857	.6001	.5144	.06	.2315	2.4006	.2143
16	.0857	.6859	.6001	.06	.2229	2.2291	.2143
17	.1029	.7716	.6859	.0686	.2229	2.0576	.1886
18	.1029	.9431	.9431	.0857	.0943	.9431	.0943
19	.12	1.1145	1.1145	.0943	.0943	1.2003	.0943
20	.1029	.9431	.9431	.0943	.0943	1.1145	.1115
21	.0772	.8573	.7716	.0857	.0857	.8573	.0857
22	.0686	.6859	.5144	.0686	.0772	.7716	.0772
23	.06	.6001	.5144	.06	.0772	.6001	.0686
24	1.6289	.1629	1.5432	1.5432	.06	.0686	.6001
Max	2.6578	1.1145	2.4863	2.572	.2658	2.572	2.1434
Min	.06	.1629	.4287	.06	.06	.0686	.0686
Avg	.9506	.5462	1.2074	.9024	.1393	.9058	.4964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 204 / pachod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.0857	.9431	.8573	.0514	.0514	.5144
2	1.0288	.1029	.9431	.9431	.0514	.06	.5144
3	1.1145	.1115	1.0288	.9431	.06	.0686	.6001
4	1.2003	.1115	1.1145	1.0288	.06	.0772	.6859
5	1.286	.1115	1.2003	1.2003	.0772	.0857	.8573
6	1.7147	.1715	1.5432	1.4575			
7	1.6289	.2058	1.8004	1.8004			
8	1.4575	.2058	1.9719	1.9719			
9	1.4575	.1886	1.7147	1.6289	.0772	.0857	.7716
10	.6859	.8573	.6001	.6001			
11	.5658	.6001	.3429	.0343	.1886	.2229	.1972
12	.5144	.5144	.2572	.0257	.2058	1.8004	.2229
13		.4287	.3429	.0343	.0514	1.9719	.2229
14		.3429	.2572	.0343	.0429	1.8004	.2229
15		.3429	.2572	.048	.0429	1.8861	.2315
16		.3429	.3429	.0429	.0429	1.9719	.2143
17	.06	.4287	.3429	.0429	.0429	1.5432	.1886
18	.0772	.6001	.4287	.06	.0514	.6001	.06
19	.0857	.7716	.7716	.0686	.06	.8573	.06
20	.0772	.6859	.6001	.0772	.0686	.7716	.0686
21	.0686	.6859	.6001	.0686	.06	.6859	.0686
22	.0514	.5144	.5144	.06	.06	.6001	.06
23	.0514	.4287	.5144	.0514	.0514	.5144	.0514
24	1.0288	.0857	.8573	.9431	.0514	.0514	.5144
Max	1.7147	.8573	1.9719	1.9719	.2058	1.9719	.8573
Min	.0514	.0857	.2572	.0257	.0429	.0514	.0514
Avg	.7592	.3719	.8037	.5843	.0699	.7853	.3164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 205 / Pimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.0772	.7716	.7716	.0429	.0343	.3429
2	.7716	.0772	.7716	.7716	.0429	.0429	.3429
3	.7716	.0857	.8573	.8573	.0514	.0429	.4287
4	.8573	.0943	.9431	.9431	.0514	.0514	.4287
5	1.0288	.1115	1.0288	1.1145	.0429	.0514	.5144
6					.06	.06	.6001
7					.06	.0686	.6001
8					.06	.0772	.6001
9	1.0288	.1286	1.2003	1.2003	.0514	.06	.4001
10	.5144	.6859	.6001	.6001	.0857	.0772	.6859
11	.5144	.6001	.5144	.0514	.0772	.0772	.0686
12	.5144	.5144	.5144	.06	.0686	.6859	.06
13	.0514	.5144	.4287	.06	.06	.6001	.0514
14	.0514	.5144	.4287	.06	.0686	.6001	.0514
15	.0514	.5144	.4287	.06	.06		.0514
16	.0429	.5144	.4287	.06	.06	.6001	.0514
17	.06	.5144	.4287	.06	.0686	.6859	.0686
18	.0943	.8573	.7716	.0943	.0686	.8573	.0857
19	.1029	1.0288	1.0288	.1115	.0943	1.1145	.0857
20	.1029	1.0288	1.0288	.1029	.1029	1.0288	.0943
21	.1029	.9431	.9431	.0943	.1029	1.0288	.1029
22	.0857	.9431	.9431	.0943	.0943	.9431	.0943
23	.0772	.8573	.8573	.0857	.0857	.8573	.0857
24	.7716	.0772	.7716	.7716	.0429	.0343	.3429
Max	1.0288	1.0288	1.2003	1.2003	.1029	1.1145	.6859
Min	.0429	.0772	.4287	.0514	.0429	.0343	.0514
Avg	.3985	.5087	.7471	.3821	.0668	.4208	.2599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 206 / Bafana feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0857	.0857	.0086	.0086	.0857
2	.0857	.0086	.0857	.0857	.0086	.0086	.0857
3	.0857	.0086	.0857	.0857	.0086	.0086	.0857
4	.0857	.0086	.0857	.0857	.0086	.0086	.0857
5	.0857	.0086	.0857	.0857	.0086	.0086	.0857
6		.0086	.0857	.0857	.0086	.0086	.0857
7		.0086	.0857		.0086	.0086	.0857
8	.0857	.0086	.0857	.0857	.0086	.0086	.0857
9	.0857	.0086	.0857	.0857	.0086	.0086	.0857
10	.0857		.0857	.0086	.0086	.0086	.0857
11	.0857	.0857	.0857	.0086	.0086	.0086	.0086
12	.0857	.0857	.0857	.0086	.0086	.0857	.0086
13	.0086	.0857	.0857	.0086		.0857	.0086
14	.0086	.0857	.0857	.0086	.0086	.0857	.0086
15	.0086	.0857	.0857	.0086	.0086	.0857	.0086
16	.0086	.0857	.0857	.0086	.0086	.0857	.0086
17	.0086	.0857	.0857	.0086	.0086	.0857	.0086
18	.0086	.0857	.0857	.0086	.0086	.0857	.0086
19	.0086	.0857	.0857	.0086	.0086	.0857	.0086
20	.0086	.0857	.0857	.0086	.0086	.0857	.0086
21	.0086	.0857	.0857	.0086	.0086	.0857	.0086
22	.0086	.0857	.0857	.0086	.0086	.0857	.0086
23	.0086		.0857	.0086	.0086	.0857	.0086
24	.0857	.0086	.0857	.0857	.0086	.0086	.0857
Max	.0857	.0857	.0857	.0857	.0086	.0857	.0857
Min	.0086	.0086	.0857	.0086	.0086	.0086	.0086
Avg	.0472	.0507	.0857	.0388	.0086	.0472	.0439



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 207 / Ambikarpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0857	.0857	.0343	.0171	.1715
2	.0857	.0086	.0857	.0857	.0343	.0171	.1715
3	.0857	.0086	.0857	.0857	.0343	.0257	.1715
4	.0857	.0086	.0857	.1715	.0343	.0257	.2572
5	.0857	.0086	.0857	.1715	.0343	.0257	.2572
6					.0514	.0343	.4287
7					.06	.0514	.6001
8					.06	.06	.6001
9		.0086	.0857	.0857	.0514	.0514	.6001
10	.4287	.4287	.1715	.5144	.0086	.0086	.0857
11	.6001	.4287	.3429	.06	.0086	.0086	.0086
12	.6001	.4287	.4287	.06	.0086	.0943	.0086
13	.06	.4287	.6001	.06	.0086	.0857	.0086
14	.06	.3429	.5144	.06	.0086	.0857	.0086
15	.06	.3429	.4287	.06	.0086	.0857	.0086
16	.0514	.2572	.4287	.0514	.0086	.0857	.0086
17	.06	.3429	.6001	.0514	.0086	.0857	.0086
18	.0086	.0857	.0857	.0086	.0086		.0086
19	.0086	.0857	.0857	.0086	.0086	.0943	.0086
20	.0086	.0857	.0857	.0086	.0086	.0857	.0171
21	.0086	.0857	.0857	.0086	.0086	.0857	.0171
22	.0086	.0857	.0857	.0086	.0086	.0857	.0086
23	.0086	.0857	.0857	.0086	.0086	.0857	.0086
24	.0857	.0086	.0857	.0857	.0343	.0171	.1715
Max	.6001	.4287	.6001	.5144	.06	.0943	.6001
Min	.0086	.0086	.0857	.0086	.0086	.0086	.0086
Avg	.1243	.1702	.2204	.0829	.0229	.0566	.1518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 201 / GANDHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.6687	.6859	.6979		.3772	.4854
2	.7202	.703	.7888	.7167	.3429	.4287	.5601
3	.8059	.7888	.8745	.7356	.3944	.4973	.5601
4	.8745	.8745	.9602	.9619	.4458	.5316	.6722
5	.9774	.9259	1.0288	1.1883	.463	.6344	.7842
6	1.2003	1.2517	1.2174	1.307	.6687	.7716	.8402
7	1.406	1.3717	1.3546	1.3491	.9774	1.0288	.9149
8	1.3717	1.3375	1.3203	1.2936	.8402	1.0288	.8402
9	1.2517	1.2517	1.1488	1.3306	.7373	.823	.8029
10	.7888	.8059	.8059	.7888	.8402	.8316	.7888
11	.8402	.823	.7373	.8238	.703	.7207	.6344
12	.8573	.8402	.7716	.7373	.6516	.6722	.583
13	.8573	.8059	.5658	.6859	.5487	.6283	.5316
14	.7888	.7888	.7716	.4458	.5316	.6099	.5144
15	.7888	.7716	.6859	.6859	.4801	.6283	.5144
16	.823	.6859	.7888	.6516	.5487	.6468	.6173
17	.8745	.8029	.7922	.6859	.8029	.7207	.6687
18	1.0631	1.0269	.9431	.8402	1.0456	.8962	.6859
19	1.1145	1.2826	1.2071	1.1317	1.2696	1.1576	1.0288
20	.9431	1.0456	1.1317	.9774	1.1949	1.1203	1.0288
21	.7888	.9149	.9522	.8402	.8059	.9709	.8059
22	.6859	.811	.8589	.7545	.7202	.5228	.6344
23	.6344	.6516	.7282	.6516	.3772	.7468	.3944
24	.6516	.6001	.6173	.6908	.3258		.4294
Max	1.406	1.3717	1.3546	1.3491	1.2696	1.1576	1.0288
Min	.6344	.6001	.5658	.4458	.3258	.3772	.3944
Avg	.9074	.9096	.9057	.8738	.6833	.7389	.6800

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 202 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.3429	.3258	.415	.5487	.4801	.5975
2	.4801	.4115	.4287	.4338	.6001	.5316	.5975
3	.5144	.4801	.4973	.4805	.6687	.6001	.5975
4	.5316	.5658	.583	.5544	.7373	.7545	.7468
5	.583	.6687	.6344	.7207	.8059	.8916	.9709
6	.9088	.8573	.8916	.9425	1.0802	1.0288	1.307
7	1.2174	1.2517	1.1831	1.3491	1.2689	1.2003	1.3256
8		1.0288	.8916	1.2197	1.1831	1.1317	1.2696
9	.9945	.8745	.8573	1.0534	.9259	.9774	1.0642
10	.8059	.8059	.6516	.6859	.7545	1.1317	.7716
11	.6859	.823	.463	.5658	.8745	1.0349	.9431
12	.6001	.7545	.463	.463	.9602	.7392	.9431
13	.7202	.6173	.4115	.4115	1.046		.8745
14	.7716	.5658	.3429	.3944	1.046		.8573
15	.7545	.4973	.3944	.3772	.9945	.6722	.7716
16	.823	.5316	.3944	.4458	.9774		.8573
17	.8745	.6161	.6036	.4801	1.0269	1.0534	.7716
18	.8402	.7282	.7733	.6173	.6722	.7095	
19	.9774	1.0562	1.0562	.9774	.8402	.9149	1.0802
20	.7888	.7282	.7356	.823	.9896	.9522	.9602
21	.6516	.7282	.6979	.7202	.703	.7468	.6859
22	.5487	.503	.5658	.6516	.6344	.6348	.6173
23	.4458	.6687	.5281	.5658	.5487	.5975	.5144
24	.463	.2915	.2915	.3584	.5144	.5144	.5975
Max	1.2174	1.2517	1.1831	1.3491	1.2689	1.2003	1.3256
Min	.4458	.2915	.2915	.3584	.5144	.4801	.5144
Avg	.7150	.6832	.6111	.6544	.8501	.8237	.8575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 203 / SINDHON BINDHON SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6344	.6173	.9808	.3772		.4481
2	.8573	.6859	.7202	1.0374	.3944	.4458	.4481
3	.8573	.7716	.7373	1.0751	.4287	.5487	.4481
4	.9774	.823	.8059	1.1203	.4801	.6344	.7468
5	1.166	1.0117	.8745	1.2323	.5144	.7202	.9335
6	1.3546	1.2003	1.1145	1.2936	.8573	.8059	1.1203
7	1.406	1.2689	1.2689	1.5339	1.0288	.9259	1.251
8	.8745	1.2174	1.286	1.531	1.5261	.8745	1.1203
9	.6859	1.2003	1.0974	1.2936		.7202	.8589
10	.583	.6001	.5316	.5658		1.0903	1.2003
11	.4287	.3944	.3944	.3429	1.1488	1.3491	1.3203
12	.3601	.3429	.3258	.2915	.9431	1.5524	1.3546
13	.4115	.3086	.2229	.2572		1.46	1.3717
14	.5144	.3944	.2401	.2401		1.2936	1.3889
15	.5316	.3601	.2401	.3086		1.2752	1.2346
16	.6173	.4115	.2229	.3429		1.2382	1.3717
17	.6516	.4668	.3206	.4458		1.3491	.6687
18	.7202	.7842	.4715	.6344	.6348	.6722	.6859
19	.7888	.9054	.6979	.8573	.6722	.7655	1.0288
20	.6001	.7282	.6161	.6687	.7095	.7095	1.0288
21	.5316	.6224	.5847	.5144	.4801	.5601	.8059
22	.4287	.4854	.547	.4458	.4458	.5228	.6344
23	.4115	.4287	.4715	.4115	.3944	.4481	.3944
24	.823	.6173	.583	.9242	.3772	.3772	.4481
Max	1.406	1.2689	1.286	1.5339	1.5261	1.5524	1.3889
Min	.3601	.3086	.2229	.2401	.3772	.3772	.3944
Avg	.7209	.6943	.6247	.7645	.6713	.8843	.9297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 204 / 11 KV EXP.MAHANANDA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0686	.0754	.0686	.1029	.112
2	***	.0686	.0686	.0747	.0686	.0857	.112
3	.0857	.0514	.0514	.056	.0514	.0514	.112
4	.0686	.0514	.0514	.0739	.0343	.0343	.112
5	.0514	.0514	.0343	.0554	.0343	.0343	.0934
6	.0514	.0514	.0514	.0566	.0343	.0514	.0747
7	.0514	.0514	.0514	.0554	.0514	.0514	.056
8	.0857	.0514	.0686	.0924	.0514	.0514	.0373
9	.1029	.0686	.0857	.1109	.0686	.0857	.0934
10	.12	.0686	.1029	.12		.1109	.0857
11	.12	.0686	.0857	.1029	.0857	.128	.0857
12	.0857	.1029	.0686	.12	.0686	.0924	.0686
13	.0857	.0514	.0857	.12		.1109	.0514
14	.1372	.1029	.1372	.0857	.12	.0739	.0514
15	.12		.1029	.1029	.12	.1109	.0514
16		.1029	.12	.12	.12	.1294	.0686
17	.1029	.1307	.1132	.12	.1307	.1294	.0686
18	.1029	.112	.0934	.1029		.112	.0857
19	.0686	.0943	.0566	.0857	.0747	.112	.0686
20			.0754	.0686	.056	.0747	.0686
21	.0857		.0754	.0686	.0686	.0747	.0514
22	.0857		.0754	.0686	.0857	.0747	.0686
23	.0857	.0857	.0943	.0857	.1029		.0686
24	.0857	.0514	.0514	.0943	.0514	.0857	.112
Max	14.4719	.1307	.1372	.12	.1307	.1294	.112
Min	.0514	.0514	.0343	.0554	.0343	.0343	.0373
Avg	.7428	.0743	.0779	.0882	.0737	.0856	.0774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 205 / PRATIK METAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1543	.1663	.2641	.1715	.12	.1886
2	.1286	.1543	.1663	.2641	.1715	.1252	.1867
3	.1372	.1543	.1715	.2614	.0137	.132	.1886
4	.1406	.1543	.1715	.2614	.0154	.1457	.1867
5	.1715	.1715	.1715	.2614	.0154	.1492	.2054
6	.1457	.1886	.1886	.2587	.1715	.1698	.2241
7	.1492	.2058	.1886	.3142	.1715	.1715	.2241
8	.1543	.2058	.1715	.8589	.1715	.2229	.2427
9	.6859	.1715	.2058	.9055	.2743	.2572	.2987
10	.9259	.1715	.2915	.7373	.6173	.6099	.8573
11	.5487	.1886	.583	.463	1.0288	1.1949	1.0288
12	.9945	.1886	.5144	.9088	.3944	.6908	1.0288
13	.5144	.1886	.5144	.8745	.4973	.8871	.6344
14	.6001	.1715	.463	.7716	.6173	.6283	.6516
15	1.0974	.1715	.3601	.9602	.8573	1.0269	1.2346
16	.4458	.2229	.4801	.9088	.6859	1.1827	.9602
17	.6001	.1715	.4338	.5658	.8029	1.2012	.9088
18	.4973	.1715	.5093	.6001	.6348	.6161	.8573
19	.2743	.1886	.2829	.2915	.6348	.6161	.463
20	.1886	.1886	.2829	.1715	.1867	.2427	
21		.1715	.2452	.1492	.1543	.1867	.1715
22	.1886	.1715	.2452	.1578	.1543	.1867	.1663
23	.1543	.1543	.2452	.1886	.1303	.2054	
24	.1663	.1543	.168	.2641	.1886	.1337	.1867
Max	1.0974	.2229	.583	.9602	1.0288	1.2012	1.2346
Min	.1286	.1543	.1663	.1492	.0137	.12	.1663
Avg	.3944	.1765	.3009	.4859	.3651	.4626	.5043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 206 / 11 KV MGM FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.012	.0171	.0189	.0206	.0154	.0187
2	.0171	.012	.0171	.0189	.0171	.0154	.0187
3	.0171	.012	.0171	.0189	.0154	.0137	.0187
4	.0171	.0137	.0171	.0187	.0154	.0137	.0187
5	.0171	.0154	.0206	.0187	.0154	.0154	.0187
6	.0171		.0171	.0189	.0171	.024	.028
7	.1372	.024	.0137	.0185	.0223	.0171	.0373
8	.1372	.024	.0103	.0185	.048	.0343	.0187
9	.0343	.0171	.0154	.0185	.0309	.0377	.0187
10	.0171	.0171	.0343	.1543	.0343	.056	.0343
11	.0171	.0171	.0514	.0343	.0514	.0554	.0171
12	.0373	.12	.0343	.0343	.0343	.0739	.0171
13	.0343	.1029	.0457	.0343	.0343	.056	.0171
14	.0343	.1543	.0514	.0171	.0343	.037	.0171
15	.0343	.12	.0171	.0171	.0343	.0185	.0343
16	.0171	.12	.0171	.0171	.0343	.0185	.0343
17	.0171	.1478	.0189	.0171	.0187	.037	.0291
18	.0137	.0183	.0377	.012	.0131	.0187	.012
19	.012	.0189	.0377	.0257	.0187	.0187	.024
20	.0171		.0189	.0257	.0187	.0149	.0309
21	.0171	.0187	.0189	.024	.0171	.0187	.0291
22	.0171	.0373	.0189	.024	.0137	.0187	.0309
23	.012	.0171	.0189	.024	.0206		.0291
24	.0171	.0137	.0206	.0377	.0171	.0137	.0187
Max	.1372	.1543	.0514	.1543	.0514	.0739	.0373
Min	.012	.012	.0103	.012	.0131	.0137	.012
Avg	.0303	.0479	.0245	.0278	.0249	.0279	.0238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 201 / Khodegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7922	.7545	.5658	.7011	.6001	.362
2	.7167	.811	.7545	.6602	.6878	.6173	.3582
3	.6602	.8865	.8488	.6602	.6335	.6173	.394
4	.8299	.9054	.9431	.7545	.7059	.6859	.5138
5	1.0269	.9431	1.0269	1.0562	.7537	.8718	.6135
6	1.1203	1.1128	1.2323	1.1694	.7545	.9892	.7796
7		1.1883	1.358	1.0829	1.2071	1.1961	1.4243
8		1.1128			.8817	1.1305	1.5089
9	.9431	1.0374	.7733	.9242	.5373	.5434	
10	.7202	.763	.7545	.9156	.3584	.3961	.6001
11	.7716	.8951	.763	.8907	.3961	.3772	.3429
12	.8402	.852	.8048	.9995	.3961	.3395	.3506
13	.8573	.7935		.8288	.3772		.298
14	.8059	.6802	.7377	.7712	.3961		
15	.8402	.7287	.7956	.8048	.3961	.4715	
16	.8573	.8097	.8192	.8288	.415	.5658	.3772
17	.7716	.8436	.8192	1.0395	.4527	.6979	.5093
18	.9242	.8488	.5601	.3921	.811	.8488	.6068
19	.9997	.9431	.8488	.8488	.8865	1.0751	.8299
20	1.0185	1.0374	.8299	1.0374	.9431	.8488	.9808
21	.9431	.9808	.811	.9431	.8676	.7733	.9431
22	.9054	.9242	.7922	.8488	.6602	.8488	.8865
23	.8299	.9054	.7733	.811	.547	.811	.7545
24	.7545	.7922	.8488	.7545	.724	.5487	.362
Max	1.1203	1.1883	1.358	1.1694	1.2071	1.1961	1.5089
Min	.6602	.6802	.5601	.3921	.3584	.3395	.298
Avg	.8587	.8995	.8477	.8517	.6454	.7206	.6570



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 202 / Kachner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.394	.5601	.5258	.5281	.547	.547
2	.3258	.4119	.5228	.5068	.5281		.5658
3	.3658	.4715	.5121	.5611	.4715	.679	.6224
4	.3982	.6173	.5487	.6401	.679	.8865	.6979
5	.6201	.6687	.543	.8238	1.0562	.9709	.9619
6	.7537	1.0395	.8059		1.2696	1.1949	1.2826
7	.9724	1.2407	1.1641	1.0631			
8	.6104	1.1065	.964	.9156	1.2826		
9	.5868	.8718	.8648	.8596	1.1883	1.1949	1.358
10	.9054	1.0751	.9054	.8488	.8402	.4961	.7167
11	.8488	.7545	.7167	.6602	.9431	.4681	.8488
12	.679	.6602	.5658	.6036	.9774	.779	.8488
13	.6036	.5658		.4715	.823	.6962	.8299
14	.6036	.5658	.5093	.4715	.7373	.6299	.6224
15	.7167	.6036	.5281	.4715			
16	.9896	.6224	.547	.4715	.823	.6882	.7545
17	1.0456	.7922	.6224	.5601	.9602	.7287	.8488
18	1.2883	.8865	1.0829	.8488	1.0456	.8402	.9431
19	1.3443	.8865	1.226	1.2826	1.1389	1.3957	1.0374
20	.9709	.9054	1.0374	1.1317	1.0829	1.0562	.9997
21	.8589	.7545	.7356	.9054	1.0269	.7545	.9431
22	.6413	.5847	.6036	.6413	.6036	.679	.8488
23	.547	.5281	.5281		.5658	.5658	.6036
24	.3142	.394	.5729	.5258	.5658	.547	.547
Max	1.3443	1.2407	1.226	1.2826	1.2826	1.3957	1.358
Min	.3142	.394	.5093	.4715	.4715	.4681	.547
Avg	.7212	.7251	.7246	.7177	.8699	.7899	.8299

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 203 / Gadiwat

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.823	.9717	1.0059	.5281	.547	.5658
2	.9503	1.1317	.9503	1.0395	.5281	.5281	.5658
3	.9503	1.291	.9012	.9012	.4715	.547	.6036
4	.9717	1.278	.9503	.9175	.4715	.547	.6602
5	1.0526	1.278	.9503	1.0526	.5093	.6224	.7545
6	1.4083	1.3108	1.2631	1.1843	.5228	.7167	.9808
7					.8676	.9808	1.0185
8	1.6194	1.6194	1.9757	1.9204	.7167	.6602	.8299
9	1.2955	1.6356	1.4575	1.5546	.6413	.547	.7167
10	.547	.7167	.5658	.6036	1.6095	1.2803	.7356
11	.4527	.5658	.4715	.415	1.7695	1.4723	.811
12	.4338	.5658	.4527	.3395			
13	.4338	.547		.3772	1.8023	1.6324	.6036
14	.415	.5093		.415	1.9989	1.6446	1.3957
15	.5093	.5281	.4715	.415	1.9334	1.4883	1.8861
16	.6036	.5658	.4527	.415	1.8023	1.406	1.7918
17	.6602	.5658	.4904	.4904	1.5074	1.2803	1.8861
18	.679	.7167	.5975	.2987	.679	.5093	1.0374
19	.679	.7356	.8299	.9709	.7356	.7356	.9808
20	.679	.7545	.7167	.7356	.7356	.8299	.8865
21	.6602	.6602	.6036	.6602	.7167	.7167	.8488
22	.6413	.6224	.5658	.6413	.6602	.6413	.6602
23	.6036	.5847	.5281	.6224	.5658	.6224	.5658
24	.9393	.6859	.6287	1.0174	.5658	.547	.6036
Max	1.6194	1.6356	1.9757	1.9204	1.9989	1.6446	1.8861
Min	.415	.5093	.4527	.2987	.4715	.5093	.5658
Avg	.7894	.8562	.7998	.7823	.9713	.8914	.9299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 204 / 11 Kv Power Grid

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	04-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2172		.1509
2	.181	.2172		
3	.181	.181		
4	.1448	.181		
5	.1402	.1629		
6	.1402	.1448		
7	.1433	.0905		
8	.0701	.0724		
9	.0362	.0724		
11			1.7918	
21	.0366			
22	.0488			
23	.061			
24	.1791	.2172		
Max	.181	.2172	1.7918	.1509
Min	.0362	.0724	1.7918	.1509
Avg	.1186	.1557	1.7918	.1509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 201 / 11KV Hiwara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.6001	.7716	.5487	.4287	.4458	.4239
2	1.0174	.6173	.8573	.6001	.4458	.4578	.4287
3	1.1145	.6443	.8573	.6783	.4748	.4748	.4287
4	1.1022	.6443	.9431	.763	.5426	.5426	.5087
5	1.2003	.6613	1.1145	.8817	.6274	.6036	.6001
6	1.3717	1.1145	1.4575	1.0562	.6687	.7042	.6859
7	1.9204	1.4746	1.6632	1.3916	.7888	.7377	.7202
8	1.5261	1.286	1.3717	1.5089	.5487	.5868	.6001
9	1.2209	1.1145	1.1191	1.1904	.3772		.3944
10	.3429	.4527	.2915	.3391	.9892	1.1145	.9945
11	.2713	.285	.1886	.2012	1.291	1.3203	1.0288
12	.2204	.2683	.1543	.2035	1.4083	.823	1.2174
13	.2374	.2683	.2229	.2035	1.3413	1.1869	1.1145
14	.2543	.2515	.2058	.2058	1.2407	.9665	
15	.2743	.2347	.2401	.2058	1.1401	.9259	.9945
16	.2915	.1677	.2204	.1886	1.0227	.8573	1.1488
17	.3429	.3018	.2058	.2572	1.0562	1.0682	1.0631
18	.4207	.3429	.2743	.3429	.3086	.3086	.4115
19	.4961	.5487	.3772	.5144	.463	.5144	.5316
20	.4733	.5316	.3944	.6135	.463	.5144	.5487
21	.4733	.5487	.5144	.631	.4458	.4801	.5258
22	.4733	.5144	.4973	.6516	.4458	.463	.5083
23	.4458	.4801	.4801	.5258	.463	.4287	.463
24	1.0288	.5487	.6859	.5144	.4382	.463	.4801
Max	1.9204	1.4746	1.6632	1.5089	1.4083	1.3203	1.2174
Min	.2204	.1677	.1543	.1886	.3086	.3086	.3944
Avg	.7312	.5793	.6295	.5924	.7258	.6951	.6879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 202 / 11KV KARMAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.8573	.9431	.9431	.407	.4115	.5487
2	1.1145	.823	.9326	.8916	.4115	.4409	.5935
3	1.1869	.8817	1.0174	.8478	.4409	.4409	.5935
4	1.1869	.9835	1.0288	.8478	.4409	.4748	.6859
5	1.286	1.1361	1.2003	.9496	.4578	.5365	.6859
6	1.4746	1.4575	1.4575	1.3413	.6344	.57	.763
7	1.5947	1.6118	1.6289	1.6095	.7202	.6371	.9088
8	1.4575	1.6461	1.4575	1.5089	.6173	.6203	.8573
9	1.3375	1.4403	1.3032	1.3413	.4801	.57	.7202
10	.703	.5533	.6344	.4917	1.1401	1.1317	1.0631
11	.6443	.6371	.6173	.6036	1.0898	1.0174	1.0288
12	.6443	.503	.6516	.5935	.9054	.8916	.9774
13	.6443	.503	.6516	.583	1.0562	.8573	1.0288
14	.6173	.503	.583	.5658	1.0395	1.0852	1.0288
15	.6001	.502	.2401	.583	1.0059	1.0852	1.0288
16	.6859	.4527	.583	.6001	1.1065	1.046	1.046
17	.6173	.4527	.6516	.5487	1.0562	1.0631	1.0288
18	1.1393	1.0117	1.0802	.9945	1.1145	1.17	1.2003
19	1.4373	1.286	1.3203	1.3889	1.3717	1.4575	1.4746
20	1.3321	1.2346	1.3203	1.3717	1.406	1.3717	1.3889
21	1.262	1.2346	1.2346	1.2971	1.3032	1.2689	1.3146
22	1.1568	1.1022	1.2174		1.2003	1.2039	1.2269
23	1.046	1.0288	1.166	1.0166	1.0631	1.0974	1.166
24	1.1145	.9602	1.0288	.9945	.3856	.4115	.5087
Max	1.5947	1.6461	1.6289	1.6095	1.406	1.4575	1.4746
Min	.6001	.4527	.2401	.4917	.3856	.4115	.5087
Avg	1.0582	.9501	.9979	.9528	.8689	.8692	.9528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 203 / 11KV Ladgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.583	.5487	.6516	.6173	.583	.6859
2	.5144	.5487	.5087	.6859	.6516	.6104	.6783
3	.5144	.5426	.5087	.7202	.6783	.6443	.7202
4	.6443	.6104	.5087	.7461	.7291	.7461	.7716
5	.6783	.763	.5935	.8139	.763	.9389	.7716
6	.7969	.823	.7716	.8718	.9431	1.1401	.8573
7	.7373	.8916	.9088	.9221	1.046	1.2071	.9602
8	.6859	.8573	.7716	.763	.8573	1.1904	.8573
9	.5935	.823	.6344	.5868	.7888	.9556	.8059
10	.9088	.7377	.9602	.78	.4191	.3772	.3601
11	.9496	.503	1.0974	.8383	.3856	.3601	.2401
12	1.153	1.0059	1.0974	.9156	.3353	.3429	.2058
13	1.0513	.9054	.9602	.8573	.3353		.2058
14	1.0288	.8886	.8478	.7716	.3353		.3429
15	.9945	.8718	.8573	.7716	.3185		.3772
16	.9088	.8718	.8402	.7716	.3521		.4115
17	.9259	.9054	.7716	.8745	.3856	.5658	.4115
18	.6661	.5144	.3944	.6516	.463	.5765	.6001
19	.7202	.763	.5658	.7373	.6687	.7373	.7202
20	.7011	.6859	.6001	.6859	.6859	.6859	.703
21	.631	.6687	.6173		.6173	.6516	.6661
22		.6344	.6687	.631	.6001	.6001	.5784
23	.6344	.6344	.6516	.1814	.583	.6001	.5658
24	.5144	.6344	.6001	.6344	.5959	.5658	.6859
Max	1.153	1.0059	1.0974	.9221	1.046	1.2071	.9602
Min	.5144	.503	.3944	.1814	.3185	.3429	.2058
Avg	.7594	.7361	.7202	.7332	.5898	.7040	.5909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 201 / 11KV DUDHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.4424	.4096	.5243	.4588	.8684	.7545
2	.4424	.4752	.4424	.5243	.5243	.9012	.7716
3	.4752	.5243	.4915	.5243	.6226	1.1797	.8551
4	.6226	.5571	.5898	.5898	.7373	1.1797	.9175
5	.7701	.7865	.7373	.7701	.8848	1.3927	1.065
6	1.004	.9831	.9503	1.065	1.1961	1.4746	1.6741
7	1.2125	1.1633	1.065	1.1142	1.6876	2.0153	2.2611
8	1.1469	1.0814	.9831	.7701	1.3599	1.704	2.0972
9	.9175	.9175	.6226	.5243	1.2289	1.4091	1.6549
10	1.5729	1.4091	1.4255	.7373	.583	.5243	.4588
11	1.7532	1.6549	.8259	.9012	.3605	.3401	.2622
12	2.0119	1.6876	1.5074	1.6712	.1638	.2458	.2458
13		1.6549	1.6549	1.6712	.2622	.2622	.2949
14	1.6712	1.6549	1.5074	1.6385	.2949	.2622	.2785
15	1.7204	1.6549	1.5074	1.6385	.3113	.2458	.2949
16	1.6876	1.6549		1.5565	.3441	.2622	.2949
17	1.5893	1.6549	1.2125	1.5893	.426	.3441	.3113
18	.6226	.4915	.4534	.3768	.4915	.4144	.426
19	.7865	.7865	.7287	.7865	.8029	.8029	.8029
20	.7045	.7373	.7701	.6882	.7373	.7865	.8192
21	.6226	.6882	.639	.7373	.6882	.6554	.6226
22	.5571	.5407	.5898	.5407	.5407	.5898	.5735
23	.4752	.4915	.5079	.4752	.4915	.4973	.4915
24	.4424	.4424	.4424	.5079	.4424	.8192	.9389
Max	2.0119	1.6876	1.6549	1.6712	1.6876	2.0153	2.2611
Min	.4424	.4424	.4096	.3768	.1638	.2458	.2458
Avg	1.0116	1.0056	.8723	.9134	.6517	.7990	.7986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 202 / 11KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3077	.8718	.8383	.9892	.8383	.7545	.8383
2	1.2407	.9054	.8718	.9892	.8383	.7545	.8745
3	1.2407	.9556	.9221	1.0059	.8383	.8048	.8886
4	1.2574	1.0059	1.0059	1.0562	.9054	.9221	.9175
5	1.2407	1.3413	1.2071	1.3916	.9724	1.0898	1.065
6	1.7901	1.7101	1.6598	1.7269	1.1065	1.4251	1.0774
7	2.6825	2.7161	2.3472	2.4143	1.3413	1.358	1.1142
8	1.7604	2.146	1.9784	2.146	1.1736	1.0898	1.0898
9	1.3546	1.8107	1.6766	1.3094	.8048	.7712	.8122
10	.6036		.5533	.6036	1.6956	1.6766	1.6095
11	.4359	.5197	.3018	.3688	1.9616	1.6933	1.8778
12	.4096	.3353	.3018	.285	1.9616	1.861	1.7101
13	.503	.4191	.3018	.285	1.8107	1.3413	1.643
14	.503	.4024	.3185	.3185	1.5927	1.5089	1.6095
15	.5197	.3185	.3856	.285	1.4251	1.3077	1.5927
16	.5868	.4024	.3688	.285	1.4754	1.3413	1.5592
17	.7377	.4191	.3768	.3185	1.5927	1.278	1.5424
18	.8048	.6036	.5636	.503	.5365	.4973	.5365
19	.8048	.9389	.8122	.7377	.9389	.9831	.9724
20	.8551	.9221	.788	.788	.9054	.9724	.9389
21	.8048	.8551	.8951	.8215	.8383	.8886	.8718
22	.7545	.6706	.7545	.8551	.8383	.8886	.8718
23	.7377	.7042	.8048	.8551	.8048	.8402	.8551
24	1.4083	.8718	.8383	.9892	.8383	.788	.8048
Max	2.6825	2.7161	2.3472	2.4143	1.9616	1.861	1.8778
Min	.4096	.3185	.3018	.285	.5365	.4973	.5365
Avg	1.0143	.9498	.8697	.8887	1.1681	1.1182	1.1530



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 048010 / 220KV SHENDRA SUBSTATION

Feeder No / Name : 405 / 33 KV Sunderwadi feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 048010 / 220KV SHENDRA SUBSTATION

Feeder No / Name : 408 / Bonatrans Express  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 201 / BIDKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7343		.1372	.2035	.0857
2					.1372	.2035	.0857
3					.1372	.2035	.1029
4					.1372	.2035	.12
5					.1372	.2035	.1372
6					.2229	.2035	.2058
7					.3086	.4748	.4458
8					.3086	.407	.4973
9					.2915	.3391	.3944
10	.4049	.407	.3429				
11	.4049	.4409	.3772	.463	.2883		
12	.4858	.4409	.4115	.4801			
13	.4858	.407	.4115	.5144			
14	.4858	.407	.4115	.5316			
15	.4049	.3391	.4115	.4287			
16	.4687	.407	.4458	.4801			
17	.4858			.5658			
24					.1543	.1696	.0857
Max	.4858	.4409	.7343	.5658	.3086	.4748	.4973
Min	.4049	.3391	.3429	.4287	.1372	.1696	.0857
Avg	.4533	.4070	.4433	.4948	.2055	.2612	.2161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 202 / INDUSTRIAL STONE CRUSHER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4668	.1357	.3429	.2743	.5765	.3429
2	.3429	.4668	.1357	.3429	.2743	.5426	.3086
3	.4115	.4668	.1357	.3429	.3086	.5087	.3086
4	.4801	.4668	.1357	.4801	.3258	.5087	.3086
5	.5658	.4668	.1357	.2915	.3429	.2713	.3086
6	.5144	.5601	.1696	.2572	.3429	.5087	.2915
7	.4458	.3734	.2035	.2229	.3429	.3052	.3772
8	.3429	.3734	.1696	.12	.2743	.1696	.2401
9	.4115	.1867	.1357		.1886	.373	.1886
10	.4858	.2713	.2229		.7461	.4287	.5601
11	.6535	.2035	.4287	.2229	.6443	.4287	.5601
12	.5601	.3391	.6173	.2229	.3052	.4287	.8402
13	.5601	.2713	.5658	.2058	.7122	.4287	.5601
14	.3239	.2035	.4801	.2058	.2035	.4287	.5601
15		.373	.3772	.2401	.2713	.4287	.7468
16	.6478	.2713	.4115	.2572	.4409	.4287	.5601
17	.6535			.2743	.373	.6001	.5668
18	.4668	.3052	.6001	.3601	.9496	.6687	.6535
19	.3734	.373	.5144	.4458	.8478	.7373	.1867
20	.1867	.1696	.4287	.5487	.1638	.6516	.1867
21	.1867	.1357	.4287	.4801	.373	.5658	.1867
22	.4668	.1696	.3772	.4115	.5426	.4973	.1867
23	.5601	.1696	.3429	.3429	.5426	.4287	.3734
24	.3429	.7468	.1696	.3429	.2743	.5426	.3944
Max	.6535	.7468	.6173	.5487	.9496	.7373	.8402
Min	.1867	.1357	.1357	.12	.1638	.1696	.1867
Avg	.4490	.3404	.3183	.3164	.4194	.4774	.4082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 203 / LAKHEGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3239	.2713	.2058			
2	.3429	.2429	.2713	.2401			
3	.3944	.2429	.2374	.2572			
4	.4287	.2429	.2374	.2572			
5	.463	.3239	.3052	.2743			
6	1.2003	.4858	.4409	.4115			
7	1.3032	.8907	.9835	.1029			
8	.9259	.9717	.9835	.1715			
9	.7545	.8097	.8139				
10					.8478	.7716	.4287
11					1.0174	.823	.5668
12					1.1191	.8745	.4858
13					.9835	.9259	.7287
14					.9156	.9602	.7287
15						1.0117	.6478
16					.8817	1.0631	.7287
17					.9496	.9602	.7287
24	.2572	.2429	.2713	.2058			
Max	1.3032	.9717	.9835	.4115	1.1191	1.0631	.7287
Min	.2572	.2429	.2374	.1029	.8478	.7716	.4287
Avg	.6379	.4777	.4816	.2363	.9592	.9238	.6305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 204 / PANGRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3239	.4409	.3429			
2	.5144	.3239	.407	.4115			
3	.5487	.3239	.407	.4458			
4	.6001	.3239	.407	.4973			
5	.6516	.4049	.4748	.5144			
6	1.1145	.6478	.7461	.6173			
7	1.5261	.8907	1.2209	.1029			
8	1.1831	1.2136	1.3565	.0514			
9	.9602	.7468	1.0852				
10					1.1191	.8916	.9335
11					1.5939	1.0288	1.1203
12					1.8313	1.166	.6287
13					1.6956	1.3032	1.4003
14					1.56	1.3032	1.1336
15					1.6617	1.3032	1.1336
16					1.4922	1.3032	1.4003
17					1.3226	1.1145	.9717
24	.4287	.3239	.407				
Max	1.5261	1.2136	1.3565	.6173	1.8313	1.3032	1.4003
Min	.4287	.3239	.407	.0514	1.1191	.8916	.6287
Avg	.8008	.5523	.6952	.3729	1.5346	1.1767	1.0903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 205 / NILAJGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3601	.5426	.463
2					.3944	.5426	.4973
3					.4115	.5765	.6173
4					.4287	.6443	.6859
5					.4458	.8139	.7545
6					.823	1.0174	1.1145
7					.8916	1.8652	1.7661
8					.7888	1.56	1.4232
9					.3258	1.0174	1.5089
10	1.1336	1.1869	1.0802		.3222		
11		1.56	1.3375	1.8004			
12		1.5939	1.5775	1.7661			
13	1.6194	1.5261	1.5432	1.7318			
14		1.4922	1.4918	1.6975			
15	1.8623	1.3226	1.4403	1.5604			
16	2.2405	1.4582	1.4746	1.4232			
17	1.7814			1.3032			
18		1.3565					
19		1.3565					
24					.3258	.5087	.4287
Max	2.2405	1.5939	1.5775	1.8004	.8916	1.8652	1.7661
Min	1.1336	1.1869	1.0802	1.3032	.3222	.5087	.4287
Avg	1.7274	1.4281	1.4207	1.6118	.5016	.9089	.9259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 207 / INDUSTRIAL BIDKIN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2801	.2035	.2058	.3429	.2374	.2401
2	.2401	.2801	.2035	.2058	.3086	.2713	.2401
3	.2401	.2801	.1696	.2401	.2572	.3052	.2572
4	.2401	.2801	.1696	.2572	.2229	.3391	.2743
5	.2401	.2801	.1696	.2915	.2229	.2713	.2915
6	.2743	.2801	.2035	.2401	.2572	.3605	.2058
7	.2915	.2801	.2035	.1886	.2915	.3391	.2743
8	.2915	.1867	.2035	.1543	.3429	.407	.2915
9	.3258	.1867	.407		.463	.4748	.3086
10	.4668	.1357	.5487		.373	.583	.4668
11	.4668	.2035	.463	.3772	.5087	.5144	.4668
12	.5601	.2035	.3601	.4115	.2949	.463	.3734
13	.5601	.1696	.3772	.4287	.4409	.4115	.3734
14	.4668	.1696	.4115	.4458		.4287	.3734
15	.4668	.2035	.4287	.3944	.407	.4458	.2801
16	.3734	.2035	.463	.4115	.5087	.463	.4668
17	.2801			.4115	.5087		.3734
18	.3734	.2035	.3429	.3601	.4748	.2743	.2801
19	.3734	.2374	.3258	.3086	.3052	.3086	.3734
20	.3734	.2035	.3086	.2572	.3391	.2915	.3734
21	.3772	.2035	.2743	.2915	.2713	.2743	.3734
22	.2801	.1696	.2401	.3258	.2374	.2572	.3734
23	.2801	.2035	.2058	.3601	.2374	.2401	.2801
24	.3086	.2801	.1696	.2058	.4115	.3052	.2401
Max	.5601	.2801	.5487	.4458	.5087	.583	.4668
Min	.2401	.1357	.1696	.1543	.2229	.2374	.2058
Avg	.3510	.2228	.2979	.3079	.3490	.3594	.3271



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 209 / BIDKIN Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0269	.8817	1.3717	1.0117	1.2209	1.2003
2	.8573	1.1203	1.0174	1.3717	1.0117	1.3226	1.2003
3	1.166	1.307	1.2887	1.6461	1.1145	1.4582	1.2689
4	1.7833	1.6975	1.5939	1.7661	1.7833	1.7635	1.6804
5	2.3491	2.5206	2.34	2.2462	2.5549	2.3739	2.3148
6	2.0748	1.7737	1.5261	.5144	2.8121	2.6113	1.5775
7	1.6975	.9335	1.6278	.5658	1.6632	1.3226	1.5604
8	.7373	.9335	.8139	.5658	1.5947	1.1869	1.5947
9	.6001	2.4272	1.933		.9774	2.0348	1.0117
10	1.9605	2.2721	2.0405		.9156	1.6118	1.6956
11		1.8652	1.5432	.9774	.8478	1.3889	1.4937
12		1.6278	1.0288	.9774	.6554	1.0288	.9335
13	1.8671	1.3226	.9774	.9602	.8817	.9088	1.1203
14	1.8671	1.0174	.9259	.9431	.9156	.8573	1.1203
15	1.8671	1.0174	.8916	.9088		.8059	1.1203
16	2.2405	1.2887	1.4746	1.2517	1.0174	.7373	1.4003
17	2.3739			1.5947	1.6956	.9431	1.8671
18	2.6139	1.7974	1.9204	1.8347	1.8652	1.749	2.2405
19	2.894	2.4078	2.1091	2.0748	2.3739	2.5549	2.894
20	2.0538	2.4078	2.2977	2.3148	1.8652	2.2291	2.4272
21	1.8671	1.5939	2.2291	1.989	1.6956	1.9033	2.0538
22	1.0269	1.2887	1.869	1.6632	1.5261	1.5775	1.6804
23	1.0269	1.0174	1.5432	1.3375	1.2548	1.2517	1.307
24	.8573	1.0269		1.3717	1.0117	1.1869	1.2003
Max	2.894	2.5206	2.34	2.3148	2.8121	2.6113	2.894
Min	.6001	.9335	.8139	.5144	.6554	.7373	.9335
Avg	1.6654	1.5518	1.5397	1.3749	1.4367	1.5012	1.5818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 210 / Bidkin Town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1203	.9835	1.0288	1.0288	1.0174	1.0288
2	1.0288	1.1408	.9835	1.0288	1.0288	1.0513	1.0288
3	1.0974	1.2136	1.0174	1.0631	1.0974	1.1191	1.0974
4	1.2689	1.307	1.0513	1.0802	1.3032	1.153	1.2346
5	1.406	1.4003	1.3904	1.406	1.5089	1.6278	1.4232
6	1.869	1.9605	2.0008	1.869	1.9547	2.1026	
7	2.332	2.4272	2.3739	1.3032	2.4006	2.34	
8	2.2805	2.3339	2.2043	.9945	2.1434	2.1704	2.2634
9	1.8004	***	2.0008		1.9204	1.8313	2.1262
10	1.8519	1.8313	1.5261		1.56	1.6118	2.0538
11	1.4937	1.6956	1.166	1.989	1.4922	1.4575	1.9605
12	1.2136	1.5939	.823	1.6975	1.2548	1.3032	1.7737
13	1.4937	1.3565	1.0117	1.406	1.1869	1.166	
14	1.4937	1.2209	1.2003	1.1317	1.0852	.9602	
15	1.587	1.153	1.406	1.2517	1.153	.7545	1.307
16	1.6804	1.153	1.6461	1.3375	1.3565	.5487	
17	1.8671			1.4403	1.4922	.703	1.6804
18	2.0538	1.6617	1.9204	1.5604	1.7295	1.406	1.9605
19	2.2405	1.933	1.8519	1.6804	2.0008	2.1091	2.3339
20	1.7737	1.6956	1.7833	1.8176	1.7635	1.869	2.0538
21	1.4413	1.4243	1.6461	1.6289		1.6289	1.7737
22	1.2136	1.153	1.5432	1.4403	1.3226	1.3889	1.4937
23	1.2136	1.0852	1.406	1.2517	1.153	1.166	1.307
24	1.0288	1.1203	1.0174	1.166	1.0631	1.0513	1.1145
Max	2.332	21.6023	2.3739	1.989	2.4006	2.34	2.3339
Min	1.0288	1.0852	.823	.9945	1.0288	.5487	1.0288
Avg	1.5733	2.3732	1.4762	1.3897	1.4782	1.3974	1.6324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 201 / 11 KV PACHOD GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 202 / 11 KV KADETHAN AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 203 / 11 KV MURMA AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 204 / 11 KV COTTON MILL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
12	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 205 / 11 KV MURMA GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-MAR-18
HR	Load (MW)
11	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 207 / 11 KV PACHOD AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 201 / 11 KV VIHAMANDWA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 202 / 11 KV CHONDHALA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 203 / Hiradpuri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 204 / Vihamandava Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 205 / Navgaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 206 / Navgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 207 / 11KV Sharad karkhana  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 201 / BARANAGAR I

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.7468	.7468	.6859	.5601		
2	.8402	.7468	.7468	.6859	.5601		
3	1.0269	.9335	.8573	.8573	.6535		
4	1.4003	1.1203	1.1203	.823	.7468		
5	1.587	1.2136	1.2136	.6859	.7468		
6	2.0538	1.587	1.6804	.6859	1.307		
7	2.9874	2.1472	2.7073		1.9791		
8		2.3339	2.2032		1.8671		
9	1.307		1.6804		1.7737		
10					1.6804	1.3717	
11					1.9418	1.4403	2.4272
12					2.0538	.3086	2.6139
13					2.1472	.3429	2.6139
14					1.8671	.2058	2.4272
15					1.7737	.5487	2.2405
16					1.8671	.6516	2.0538
17					1.7737	.6516	1.8671
24	.7468	.7468	.7468	.6859	.4668		
Max	2.9874	2.3339	2.7073	.8573	2.1472	1.4403	2.6139
Min	.7468	.7468	.7468	.6859	.4668	.2058	1.8671
Avg	1.4211	1.2862	1.3703	.7300	1.4314	.6902	2.3205



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 202 / BARANAGAR II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2801	.2801	.2058	.2801	1.307	1.0288
2	.3174	.2801	.2801	.1715	.2801	1.307	1.1145
3	.3174	.2801	.2801	.2058	.2801	1.307	1.2003
4	.3174	.2801	.2801	.1715	.2801	1.4003	1.2003
5	.3174	.2801	.2572	.2058	.2801	1.4937	1.166
6	.3547	.2801	.2801	.1715	.3547	1.6804	1.2689
7	.3547	.2801	.2801		.3734	2.1434	2.0576
8	.3734	.2801	.2801		.2801	1.6289	
9	.3174	.2801	.2801		.3174	1.6289	1.0288
10	.9335	.9335	.7716		.3174	.1372	
11		1.4003	1.4746	1.7147	.2801	.1372	
12	1.8671	1.6804	1.6804	2.3339	.2801	.0686	
13	1.8671	1.587	1.5775	2.2405	.2801	.0686	
14	1.8671	1.4937	1.6975	2.2405	.2801	.0686	.2801
15	1.9605	1.4937	1.6118	2.3339	.2801	.0686	.2801
16	1.8671	1.4937	1.5432	2.4272	.2801	.12	.2801
17	1.587	1.4937	1.6118	2.1472	.2801	.0686	.2801
18	.2801	.2801	.1715	.2801	.2801	.0686	.3361
19	.2801	.2801	.1715	.3174	.2801	.0686	.3361
20	.2801	.2801	.2572	.3174	.2801	.2572	.3361
21	.2801	.2801	.2572	.3174	.2801	.2572	.3174
22	.2801		.2401	.3174	.2801	.2572	.3174
23	.2801		.1715	.3174	.2801	.2401	.3174
24	2.2862	.2801	.2801	.2058	.3174	1.2136	1.0288
Max	2.2862	1.6804	1.6975	2.4272	.3734	2.1434	2.0576
Min	.2801	.2801	.1715	.1715	.2801	.0686	.2801
Avg	.8219	.7044	.6673	.9321	.2918	.7082	.7460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 203 / 11 KV KAPUS WADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3734	.5601	.5144	.2801	.1307	.1029
2	.5601	.3734	.6535	.6001	.2801	.1307	.1029
3	.5601	.5601	.5601	.5144	.3174	.1307	.1029
4	.5601	.5601	.6535	.5487	.3921	.112	.1029
5	.5601	.5601	.6535	.6001	.3921	.112	.12
6	.7468	.7468	.6535	.5144	.5041	.112	.1029
7	1.1949	.9335	1.1203		.8775	.12	.1029
8	.9335	.9335	.9335	.5144	.7468	.1029	
9	.7468	.9335	.8402		.7468	.1029	.1029
10	.0934		.1029		.7468	.6859	.6516
11	.0747	.0934	.1029	.0857	.8402	.7202	.7468
12	.0934	.0747	.1029	.0934	.7468	.6859	.8402
13	.0934	.056	.1029	.0934	.9335	.7202	.7468
14	.0934	.056		.0934	1.0456	.6859	.7468
15	.0934	.056	.0686	.0934	.6722	.7716	.6535
16	.0934	.056	.0686	.0934	.7468	1.0288	.8029
17	.0934	.0747	.0686	.0934	.6535	1.0288	.7468
18	.0934	.0747	.0686	.0934	.0934	.1029	.0934
19	.0934	.0934	.0686	.112	.112	.1029	.0934
20	.0934	.0934	.0857	.112	.112	.1029	.0934
21		.0934	.1029	.112	.0934	.1029	.0934
22	.0934		.1029	.112	.1307	.1029	.0934
23	.0934		.1029	.0934	.112	.1029	.0934
24	.9526	.3734	.5601	.5144	.2801	.112	.1029
Max	1.1949	.9335	1.1203	.6001	1.0456	1.0288	.8402
Min	.0747	.056	.0686	.0857	.0934	.1029	.0934
Avg	.3686	.3414	.3625	.2668	.494	.3379	.3234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 204 / 11 kv Balanagar Gaothan  
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9335	.9335	.8916	.9335	.9335	.8573
2	.9335	.9335	.9335	.8573	.9335	.9335	.8573
3	1.2136	.9335	.9335	.8573	1.2136	1.2136	1.2003
4	1.4003	1.307	1.307	1.2003	1.307	1.4003	1.3717
5	1.8671	1.9605	2.0538	1.8861	2.0538	1.9719	2.0576
6	2.5206	2.4272	2.6139	2.4006	2.7073	2.5206	2.1605
7					2.5206	2.3148	2.4006
8						2.0919	
9	2.5206				2.0538	1.8861	1.8861
10	1.9605	2.0538	1.5432		1.587	1.0288	1.3032
11	1.307	1.587	1.0288	1.286	.9335	.7545	1.1203
12	1.1203	1.363	.7888	1.1203	.8402	.6859	.8402
13	1.1203	1.2136	.8573	1.1203	.7468	.583	.7655
14	1.1203	.9335	.9945		.6535	.5144	.6535
15	1.1203	1.0269	.7202	.9335	.6908	.583	.8402
16	1.4003	1.0269	.7202		1.0269	1.0631	.8402
17	1.587	1.307	1.0288	1.1763	1.2136	1.0288	1.2136
18	1.9605	1.8671	1.7147	1.587	1.6804	1.6118	1.7737
19	1.8671	2.1472	2.1262	2.3339	2.1472	2.0233	2.3339
20	1.4937	1.3413	1.4575	1.587	1.587	1.7147	1.4937
21	1.1203	1.1203	1.1317	1.2136	1.1203	1.6118	1.307
22	.9335		1.0288	1.0642	1.0456	9.9966	1.2136
23	.9335		.9945	.9335	.9335	.8573	1.0269
24	1.0269	.9335	.9335	.8573	.9335	.9335	.8573
Max	2.5206	2.4272	2.6139	2.4006	2.7073	9.9966	2.4006
Min	.9335	.9335	.7202	.8573	.6535	.5144	.6535
Avg	1.4300	1.3903	1.2307	1.2948	1.3419	1.6774	1.3206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 205 / Ginning

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2801	.112	.1029	.2801	.1867	.1372
2	.2241	.1867	.0934	.1029	.2801	.1867	.1715
3	.1867	.1867	.0934	.1029	.2801	.1867	.1715
4	.1867	.1867	.112	.1029	.2801	.1867	.1715
5	.1867	.1867	.0905	.1372	.2801	.1867	.1372
6	.2241	.1867	.0934	.1715	.3174	.1867	.1715
7	.2801	.1715	.1867		.3734	.1886	.1715
8	.2801	.1867	.1867	.1029	.3174	.1715	
9	.2801		.2801		.3734	.2058	.1372
10	.1867	.1867	.2572		.4668	.1886	.1715
11	.2801	.1867	.2572	.583	.2801	.1372	.3174
12	.1867	.0934	.2058	.3734	.2801	.1715	.2987
13	.1867	.0934	.2401	.3734	.2801	.1372	.2987
14	.1867	.0934	.1524	.3734	.1867	.1372	.2801
15	.1867	.0934	.2058	.2801	.1867	.1715	.3734
16	.1867	.0934	.2058	.3174	.1867	.1372	.3734
17	.1867	.0934	.2058	.3174	.1867	.1372	.2801
18	.1867	.0934	.2058	.2801	.1867	.1372	.2427
19	.1867	.1867	.1715	.2801	.0934	.1715	.2427
20	.1867	.0934	.1715	.3921	.1494	.1715	.3547
21	.1867	.0934	.1715	.3921	.1867	.1372	.3361
22	.1867		.1715	.3734	.1494	.1372	.3547
23	.1867		.1715	.2801	.1494	.1372	.3734
24	.7621	.1867	.112	.1029	.2801	.1867	.1372
Max	.7621	.2801	.2801	.583	.4668	.2058	.3734
Min	.1867	.0934	.0905	.1029	.0934	.1372	.1372
Avg	.2309	.1504	.1731	.2639	.2513	.1659	.2480

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 206 / kherda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1203	1.0288
2					1.1576	1.0631
3					1.2136	1.0631
4					1.2136	1.0288
5					1.2136	1.0974
6					1.307	1.0631
7					1.8204	1.6118
8					1.3717	
9					1.2003	1.3717
10	1.1203	1.1203	1.0288			
11	1.6804	1.4937	1.4403	1.6289		
12	1.6804	1.4937	1.3717	1.8671		
13	1.8671	1.4003	1.4575	1.8671		
14	1.7737	1.3443	1.0631	.4668		
15	1.587	1.4003	.9945	1.4937		
16	1.6804	1.4563	1.0288	1.6804		
17	1.587	1.4003	1.3375	1.587		
24					1.1203	1.0288
Max	1.8671	1.4937	1.4575	1.8671	1.8204	1.6118
Min	1.1203	1.1203	.9945	.4668	1.1203	1.0288
Avg	1.6220	1.3887	1.2153	1.513	1.2738	1.1507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 201 / 11 KV LOHAGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 202 / 11 KV DHAKEPHAL FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 203 / 11 KV TONDOLI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.3336
Max	1.3336
Min	1.3336
Avg	1.3336



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 204 / 11 KV BRAMHAGAWAN FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 205 / 11 KV VIJAYPUR FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 206 / 11 kv Lohgaon Gaothan  
feeder Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 207 / 11 KV Segenta

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 208 / 11 KV Gadegaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 201 / 11 KV HARSHI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0943	.0572	.1905	.3048	.2294
2	.0943	.0754	.0943	.0762	.1905	.3048	.3113
3	.0943	.0754	.0943	.0762	.1905	.3429	.3441
4	.0943	.0754	.0943	.0754	.2096	.381	.3605
5					.2286	.4001	.5079
6	1.0562				.2477	.4191	.5407
7	1.3435				.3239	.5144	.7865
8	1.2191				.4001	.6668	.8583
9					.4572	.7811	.4752
10	.3932	.3768	.4748	.2972			
11	.5898	.4858		.4572			
12	.6062	.5506	.4904	.5335			
13	.639	.5668	.5079	.6097			
14	.5735	.5506	.4115	.5716	.0191	.0189	.0191
15	.5571	.5182	.3666	.6097	.0381	.0189	.0191
16	.5735	.502	.3864	.6478	.0381	.0189	.0191
17	.5407	.4858	.2896	.6859	.0381	.0189	.0191
18	.0754	.0377	.0572	.0381	.0572	.0377	.0762
19	.0754	.0943	.0572	.0572	.0381	.0566	.0762
20	.0754		.0762	.0572	.0572	.0566	.0953
21	.0754	.1132	.0572	.0572	.0381	.0566	.0762
22	.0754	.1132	.0572	.0572	.0572	.0754	.0572
23	.0754	.0943	.0572	.0381	.0572	.0566	.0572
24	.0754	.0754	.0943	.0572	.1905	.2286	.213
Max	1.3435	.5668	.5079	.6859	.4572	.7811	.8583
Min	.0754	.0377	.0572	.0381	.0191	.0189	.0191
Avg	.4081	.2704	.2089	.2663	.1534	.2379	.2571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 202 / 11KV DADEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.639		.6226	.1143	.1524	.1886
2	.6964	.6882		.6081	.1143	.1143	.1886
3	.7373	.7373		.6962	.1524	.1524	.1886
4	.7935	.8421		.7377	.1143	.1524	.1698
5	.8421	.9555		.788			
6	1.0202	1.1174		.8916			
7	1.4685	1.247		1.9498			
8	1.3123	1.7814		2.0622			
9	1.1385	1.4419		.8962			
10					.8573	.9995	.4371
11					1.105	1.247	1.0551
12					1.4289	1.2631	1.2631
13					1.5813	1.2793	1.1591
14		.0191	.0191	.0381	1.6385	1.0526	1.0254
15	.0189	.0191	.0191	.0381	1.6956	.9555	.9267
16	.0189	.0377	.0191	.0381	1.6385	1.004	1.2186
17	.0189	.0377	.0189	.0572	1.5432	1.2146	1.1523
18	.0943	.1132	.1132	.1143	.0572	.0943	.1006
19	.1698	.2614	.1494	.1143	.0762	.132	.1677
20	.1698	.2452	.1494	.0953	.0572	.132	.1886
21	.1698	.1867	.1494	.1524	.1143	.1698	.168
22	.1698	.1509	.1334	.1143	.1524	.1698	.1698
23	.1509	.1132	.0953	.1143	.1524	.1698	.1698
24	.6226	.5735	.6154	.535	.1524	.1524	.1698
Max	1.4685	1.7814	.6154	2.0622	1.6956	1.2793	1.2631
Min	.0189	.0191	.0189	.0381	.0572	.0943	.1006
Avg	.5404	.5604	.1347	.5332	.6708	.5583	.5320

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 203 / 11KV KUTUBKHEDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0754	.0943	.0572	.2096	.381	.2785
2	.0943	.0754	.0943	.0572	.2667	.4001	.3113
3	.0943	.0754	.0943	.0572	.3048	.4382	.3441
4	.0943	.0754	.0943	.0572	.3048	.4763	.4588
5					.3429	.5906	.5243
6					.362	.6859	.639
7					.4001	.743	.9231
8					.5144	.8573	.8259
9					.6097	.9335	.9231
10	.5079	.6226	.4633	.4904			
11	.6226	.8097	.5487	.7049			
12	.6718	.8962	.7011	.7811			
13	.7209	.7935	.5182	.8383			
14	.6718	.7682	.5075	.8764	.0191		.0191
15	.6062	.7186	.6097	.8002	.0191	.0189	.0191
16	.6226	.7186	.6241	.7811	.0381	.0189	.0191
17	.5898	.7116	.5792	.7621	.0381	.0189	.0191
18	.0566	.0754	.0572	.0572	.0572	.0189	.0762
19	.0566	.1132	.0566	.0381	.0381	.0377	.0953
20	.0566	.1132	.0762	.0572	.0572	.0566	.0953
21	.0566	.1132	.0572	.0953	.0572	.0566	.0943
22	.0754	.1132	.0572	.0953	.0953	.0566	.0754
23	.0754	.0943	.0566	.1143	.0953	.0566	.0572
24	1.5242	.0943		.0572	.2096	.3429	.2458
Max	1.5242	.8962	.7011	.8764	.6097	.9335	.9231
Min	.0566	.0754	.0566	.0381	.0191	.0189	.0191
Avg	.3838	.3714	.2939	.3567	.2020	.3257	.3022



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 204 / 11KV DAWARWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2294	.4641	.2317	.0572	.0762	.0566
2	.3441	.2458	.5079	.2606	.0762	.0572	.0566
3	.3725	.2785	.5243	.2896	.0572	.0762	.0566
4	.4372	.3605	.5668	.3437	.0572	.0572	.0566
5	.5182	.4752	.583	.4588			
6	.6964	.5735	.6401	.5312			
7	.9878	.7865	.8697	.8642			
8	.8907	.7432		.9122			
9	.7935	.8065		.7621			
10					.4191	.6062	.4793
11					.6668	.8356	.7202
12					.9717	.8583	.7316
13					1.2955	.8907	.6097
14		.0189	.0191	.0381	1.2955	.8583	.6882
15	.0189	.0189	.0191	.0381	1.2384	.8421	.7522
16	.0189	.0377	.0191	.0381	1.1431	.8583	.7049
17	.0189	.0377	.0191	.0572	1.2955	.8745	.5182
18	.0377	.0754	.0381	.0572	.0762	.0377	.0377
19	.0566	.0754	.0572	.0381	.0572	.0377	.0381
20	.0566	.0754	.0572	.0572	.0572	.0566	.0381
21	.0566	.0566	.0572	.0381	.0572	.0566	.0381
22	.0566	.0566	.0572	.0381	.0572	.0566	.0381
23	.0566	.0566	.0381	.0572	.0762	.0566	.0381
24	.9526	.213	.3932	.2378	.0572	.0762	.0566
Max	.9878	.8065	.8697	.9122	1.2955	.8907	.7522
Min	.0189	.0189	.0191	.0381	.0572	.0377	.0377
Avg	.3529	.2611	.2739	.2675	.4743	.3826	.3008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 205 / 11 KV NANDAR AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0762	.5335	.724	.5735
2	.0943	.0754	.0754	.0762	.8002	.8192	.7373
3	.0943	.0754	.1132	.0953	.9717	1.1241	1.0526
4	.0943	.0754	.1132	.0943	1.105	1.3717	1.1012
5					1.2955	1.4861	1.2146
6					1.4098	1.5623	1.3765
7					1.5813	1.6385	1.5384
8					1.6575	1.7528	1.6518
9					1.7147	1.7337	1.668
10	1.4575	.7865	1.3969	1.382			
11	1.8785	1.8519	1.6362	2.0005			
12	1.8947	1.9966	1.9204	2.3434			
13	1.9109	1.8595	1.7985	2.4768			
14	1.9109	1.8595	1.9364	2.3243	.0191	.0189	.0156
15	1.9271	1.829	1.8084	2.4006	.0191	.0189	.0189
16	1.9919	1.8827	1.9528	2.4387	.0381	.0189	.0191
17	2.0243	1.7497	1.9006	2.3053	.0381	.0189	.0191
18	.0566	.0943	.0754	.0572	.0572	.0377	.0566
19	.0754	.1132	.0943	.0381	.0572	.0754	.0934
20	.0754	.0943	.0934	.0572	.0762	.0943	.0943
21	.0754	.0754	.0754	.0572	.0762	.0943	.0754
22	.0754	.0754	.0762	.0762	.0762	.0943	.0566
23	.0566	.0754	.0754	.0762	.0953	.0943	.0566
24	1.5242	.0566	.0754	.0762	.4572	.6097	.3768
Max	2.0243	1.9966	1.9528	2.4768	1.7147	1.7528	1.668
Min	.0566	.0566	.0754	.0381	.0191	.0189	.0156
Avg	.9102	.7738	.8049	.9712	.6040	.6694	.5898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 206 / 11 KV GFSS-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3441	.3277	.2743	.4191	.4001	.3113
2	.3315	.3932	.3441	.2683	.4572	.4382	.3563
3	.3605	.4588	.3768	.3041	.4954	.724	.4752
4	.4588	.5243	.4752	.4862	.724	.8002	.5243
5	.6154	.8029	.7125	.7377	.9717	1.1622	.8029
6	1.0688	1.085	1.1092	.9214	1.2574	1.3717	1.085
7	1.3108	1.1012	1.1111	1.2452	1.2955	1.3336	1.1984
8	1.2041	.9877	1.1728	1.1431	1.2765	1.2955	1.2146
9	1.1265	.953	1.0467	1.0517	1.2384	1.2384	.9878
10	.8905	.7274	.6241	.6661	.9526	.639	.7468
11	.8259	.6478		.6097	.8002	.4096	.503
12	.7773	.583	.3475	.4954	.6287	.3113	.442
13	.7287	.4372	.3077	.381	.4001	.2785	.3048
14	.7125	.4372	.2881	.4001	.4191	.2785	.2675
15	.6964	.4696	.3605	.4382	.4572	.2949	.2401
16	.7773	.4858	.4191	.5335	.4954	.3441	.3506
17	.8907	.6154	.4607	.5716	.743	.4588	.5944
18	1.004	.9122	.6882	.724	.8002	.639	.8482
19	.8421	1.0623	1.0227	.8764	.9145	1.0526	.9145
20	.6718	.7748	.7133	.9526	.7621	.7373	.7011
21	.4915	.5344	.4843	.724	.6668	.5407	.4778
22	.4588	.426	.4161	.5525	.5906	.4096	.4481
23	.4096	.3563	.3768	.4191	.4572	.3605	.3887
24	.3113	.3605	.3277	.3201	.381	.4001	.3113
Max	1.3108	1.1012	1.1728	1.2452	1.2955	1.3717	1.2146
Min	.3113	.3441	.2881	.2683	.381	.2785	.2401
Avg	.7201	.6450	.5875	.6290	.7335	.6633	.6039

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 207 / 11 KV GFSS-II FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2785	.2515	.2134	.3048	.3429	.2785
2	.2785	.2949	.2652	.2439	.3429	.4191	.3113
3	.3113	.3441	.2949	.2881	.4191	.4572	.3441
4	.3605	.4096	.3441	.4024	.6668	.5335	.4588
5	.5079	.6226	.5182	.5407	.7811	.743	.639
6	.8482	.8356		.7865	.9717	1.0288	.7865
7	.9374	.8583	1.0753	.9374	.9717	1.105	.9069
8	.8905	.7865	.9686	.9717	.9526	.9526	.8745
9	.8436	.6718	.8381	.7316	.9145	.8002	.7125
10	.7373	.5921	.4877	.5639	.6287	.4915	.7468
11	.5735	.421	.2591	.5335	.5335	.2785	.2294
12	.5407	.3563	.2134	.362	.362	.1966	.1829
13	.5243	.2949	.4877	.2477	.2477	.1475	.16
14	.5079	.2915	.1981	.2286	.2667	.1638	.1429
15	.5407	.2915	.2515	.3429	.2667	.1802	.12
16	.6226	.3077	.3239	.4001	.2477	.2458	.144
17	.6718	.4321	.3353	.4191	.4763	.3113	.2591
18	.7773	.5601	.4359	.5335	.5335	.5243	.4481
19	.6316	.759	.7865	.6478	.6859	.7611	.6401
20	.4588	.6241	.5761	.6859	.6097	.5735	.4424
21	.3113	.421	.3506	.5335	.4763	.3932	.2915
22	.2949	.2785	.2915	.4001	.4001	.3605	.2439
23	.2785	.2515	.2743	.3239	.3048	.3113	.2347
24	.2652	.2785	.2458	.1974	.3048	.3048	.2949
Max	.9374	.8583	1.0753	.9717	.9717	1.105	.9069
Min	.2652	.2515	.1981	.1974	.2477	.1475	.12
Avg	.5408	.4692	.4380	.4807	.5279	.4844	.4122

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 201 / 11KV NATH MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.7343	.7682	.8299	.8779	1.1883
2	.7922	.7087	.7316	.811	.8779	1.1694
3	.8488	.7087	.7316	.8299	.8962	1.226
4	.9054	.7783	.8048	.8589	1.0425	1.2883
5	.9997	.8779	.8779	.924	1.134	1.3443
6	1.0829	1.0349	1.134	1.134	1.2437	1.5524
7	1.1458	1.1203	1.1523	1.134	1.4083	1.4415
8	1.1157	1.0269	.9694	1.0974	1.4449	1.2254
9	1.0059	1.0534	1.0242	1.0059	1.0242	1.0974
10	.8869	.9694	.9328	1.0059	1.0242	1.1157
11		.9694	.9328		1.0059	
12		.7682	.9231		.9694	1.1584
13		.823	.905	.8779	.9412	1.0679
14		.7499	.8326	.7682	.8869	.9412
15		.7316	.9231	.823	.8326	.9134
16		.8779	.8326		.8507	1.0791
17		.9145	.7783	.7682	1.0242	1.1222
18		1.0059	1.0974	1.1706	1.1157	1.3169
19		1.134	1.2254	1.2986	1.5893	1.7551
20		1.3169	1.3121	1.4815	1.6817	1.7737
21		1.134	1.1643	1.3535	1.6448	1.6991
22		1.0425	1.1576	1.2071	1.5684	1.6461
23			1.0082	1.0608	1.4563	1.5154
24	.811		.823	.8676	1.0608	1.2449
Max	1.1458	1.3169	1.3121	1.4815	1.6817	1.7737
Min	.7922	.7087	.7316	.7682	.8326	.9134
Avg	.9459	.9309	.9601	1.0147	1.1501	1.2992

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 204 / 11 KV OPEN JAIL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0747	.0914	1.7394	1.7976	1.8501
2	.1132	.0747	.0914	1.5339	1.7814	1.8501
3	.1132	.0934	.0914		1.8138	1.866
4	.1132	.0934	.0914		1.8461	1.9044
5	.132	.112	.0732		1.9109	1.9204
6	.1509	.112	.0732		2.0243	2.0243
7	.1509	.1307	.0732		2.2672	2.251
8	.132	.0934	.0732		2.2834	2.3758
9	.1132	.0732	.0732	1.6004	2.2542	2.4086
10	3.083	2.4453	2.7854	.0549		
11		2.672	2.8841	.0732		
12		2.7044	2.8178	.0732		
13		2.7206	2.7846	.0732		
14		2.6558	2.7515	.0549		
15		2.672	2.6216	.0549		
16		2.7368	2.6379			
17		2.753	2.6379	.0732		
18		.0732	.0943	.0732	.0566	.0747
19		.0914	.0943	.0914	.0754	.0747
20		.0914	.1132	.0732	.0754	.0747
21		.0732	.0754	.0732	.0754	.0747
22		.0732	.0754	.0732	.0566	.0747
23		.0732	.0754		.0566	.0747
24	.1132		.0914	1.8027	1.7652	1.9044
Max	3.083	2.753	2.8841	1.8027	2.2834	2.4086
Min	.1132	.0732	.0732	.0549	.0566	.0747
Avg	.3935	.9867	.9697	.4699	1.2588	1.3002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 205 / 11 KV CHANGATPURI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7604	1.2498	1.3117	.0754	.0732	.0943
2	1.8084	1.2498	1.3117	.0566	.0914	.0943
3	1.8404	1.2498	1.3603	.0566	.0914	.0943
4	1.9109	1.3279	1.3441	.0754	.0914	.0943
5	1.9433	1.3748	1.4575	.0943	.0914	.1132
6	2.0153	1.4842	1.5223	.1132	.0914	.1132
7	2.3205	1.9608	1.6194	.1132	.1097	.1132
8	2.2542	2.0153	1.5223	.0943	.1097	.1132
9	2.0645	2.0241	1.8138	.0943	.1132	.0943
10	.0943	.0549	.0732	2.0243	2.4905	2.2245
11		.0732	.0566	2.2672	2.5692	2.556
12		.0732	.0566	2.672	2.6189	2.6216
13		.0732	.0377	2.7854		2.6216
14		.0549	.0377	2.4939	2.6216	2.1464
15		.0549	.0377	2.672	2.5888	2.5232
16		.0366	.0377	2.6235	2.7018	2.5911
17		.0366	.0377	2.7206	2.6189	2.3967
18		.0549	.0754	.0732	.0754	.1097
19			.0943		.132	.0924
20		.1097	.0754		.132	.0914
21		.0914	.0754	.1097	.1132	.0914
22		.0914	.0754	.0914	.1132	.0905
23		.0914	.0754	.0732	.0943	.0905
24	1.7394		1.3117	.0754	.0732	.0943
Max	2.3205	2.0241	1.8138	2.7854	2.7018	2.6216
Min	.0943	.0366	.0377	.0566	.0732	.0905
Avg	1.7956	.6742	.6425	.9752	.8611	.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 206 / 11kV Telwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1307	.1097	1.4661	1.5223	1.3904
2	.1132	.1307	.128	1.4373	1.5546	1.406
3	.1132	.1307	.128	1.4373	1.6057	1.406
4	.132	.1307	.1463	1.4373	1.6032	1.406
5	.1509	.1307	.1463	1.4373	1.6032	1.406
6	.1509	.1307	.1646	1.5181	1.587	1.4706
7	.1509	.1307	.1829	1.5844	1.6842	1.7444
8	.132	.1307	.2195	1.6804	1.7652	1.7284
9	.1886	.1494	.128	1.749	1.7814	1.7652
10	2.6189		2.1862	.0732		
11		2.4291	2.5396	.0732		
12		2.6558	2.652	.0914		
13		2.6397	2.7183	.0914		
14		2.753	2.7349	.0732		
15		2.7692	2.9172	.0732		
16		2.7206	2.8012	.0732		
17		2.6235	2.5888	.0732		
18		.1463	.1509	.0914	.132	.1097
19		.128	.1509	.0914	.132	.1132
20		.1646	.1132	.1463	.132	.1132
21		.1463	.1132	.1097	.1132	.1132
22		.1463	.1132	.1097	.1132	.0934
23		.128	.1132	.128	.0943	.0934
24	.1132	.1307	.128	1.4969	1.4575	1.406
Max	2.6189	2.7692	2.9172	1.749	1.7814	1.7652
Min	.1132	.128	.1097	.0732	.0943	.0934
Avg	.3615	.9033	.9739	.6893	1.0551	.9853



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 207 / 11kV Nath Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0171	.0183	.0189	.0183	.0377
2	.0189		.0171	.0183	.0189	.0183	.0377
3	.0189		.0171	.0183	.0189	.0183	.0377
4	.0189		.0171	.0183	.0189	.0183	.0377
5	.0189		.0171	.0183	.0189	.0183	.0377
6	.0189		.0171	.0183	.0189	.0183	.0377
7	.0189		.0171	.0183	.0189	.0183	.0189
8	.0189			.0183	.0189	.0183	.0189
9	.0189		.0171	.0183	.0189	.0189	.0189
10	.0189	.0171	.0183	.0183	.0183	.0189	.0377
11		.0171	.0183	.0189	.0183	.0189	.0366
12		.0171	.0183	.0189		.0189	.0366
13		.0171	.0183	.0189	.0183	.0189	.0373
14		.0171	.0183	.0189	.0183	.0189	.0373
15		.0171	.0183	.0189	.0183	.0189	.0373
16			.0183	.0189		.0189	.037
17			.0183	.0189		.0189	.0373
18			.0183	.0189	.0183	.0189	.0373
19			.0183	.0189	.0183	.0377	.0373
20			.0183	.0189	.0183	.0377	.0373
21			.0183	.0189	.0183	.0377	.056
22			.0189	.0189	.0183	.0377	.0373
23			.0183	.0189	.0183	.0377	.0373
24	.0189			.0183	.0189	.0183	.0377
Max	.0189	.0171	.0189	.0189	.0189	.0377	.056
Min	.0189	.0171	.0171	.0183	.0183	.0183	.0189
Avg	.0189	.0171	.0179	.0186	.0186	.0226	.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 208 / 11kV Urban Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4938	.4755		.4938	.5658
2	.4904	.5041	.4755		.4938	.5658
3	.6036	.5415	.5121		.5304	.679
4	.9997	.7842	.8048		.8779	.9997
5	1.2136	1.0456	1.0608		1.0974	1.1203
6	1.4415	1.4937	1.39		1.5364	1.5524
7	1.6827	1.7177	1.7193		1.829	1.7926
8	1.6644	1.6244	1.6827		1.5384	1.6644
9	1.5912	1.4003	1.5181		1.386	1.4449
10	.9694	1.0242	1.1888		1.0534	1.1763
11		.7499	.7865	.9511	.7865	.9149
12		.5853	.6878	.823	.6401	.5304
13		.4938		.7133	.543	.5788
14		.439	.4706	.5853	.543	.4207
15		.4938	.3982	.6401		
16		.5506	.5121	.6767	.4706	.567
17		.695	.6036	.7133	.7499	.7282
18		.9694	1.0608	1.134	.8779	1.0829
19		.9877	1.3306	1.2254	1.3491	1.3443
20		1.0791	1.2382	1.1523	1.2197	
21		.823	.8029	.8962	.8029	.8215
22		.567	.5975	.6767	.7095	.7023
23			.5281	.5853	.5847	
24	.4904		.4755		.5304	.5658
Max	1.6827	1.7177	1.7193	1.2254	1.829	1.7926
Min	.4904	.439	.3982	.5853	.4706	.4207
Avg	1.0579	.8665	.8835	.8287	.8976	.9437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 209 / 11KV GHARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.749	1.6404	1.6842	.0566	.0914	.0754
2	1.7814	1.6716	1.7652	.0754	.0914	.0754
3	1.8299	1.7328	1.749	.0754	.0914	.0754
4	1.8842	1.7394	1.7652	.0754	.0914	.0754
5	1.9498	1.7341	1.7814	.0943	.0914	.0943
6	2.0153	1.9204	1.7976	.1132	.0914	.0943
7	2.3205	2.1765	2.3411	.1132	.0732	.0943
8	2.2045	2.2186	2.0405	.1509	.0732	.0943
9	2.1548	2.0729	2.0891	.1132	.0754	.0754
10	.0754	.0732	.0732	2.0729	2.2939	2.4249
11		.0732	.0377	2.3805	2.7183	2.7526
12		.0732	.0377	2.5101	2.5888	2.7854
13		.0732	.0377	2.6397	2.4086	2.6052
14		.0549	.0377	2.5101	2.652	2.5396
15		.0549	.0377	2.5911	2.7183	2.5724
16		.0366	.0377	2.5587	2.8012	2.556
17		.0366	.0377	2.4371	2.5857	2.4291
18		.0549	.0566	.0549	.0566	.0747
19		.0732	.0754	.0732	.0943	.0747
20		.0732	.0754	.0732	.0943	.0934
21		.0549	.0754	.0914	.0943	.0747
22		.0549	.0754	.0914	.0754	
23		.0732	.0566	.0732	.0754	.0747
24	1.6872		1.7328	.0566	.0732	.0754
Max	2.3205	2.2186	2.3411	2.6397	2.8012	2.7854
Min	.0754	.0366	.0377	.0549	.0566	.0747
Avg	1.7865	.7725	.8124	.8784	.9209	.9516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 201 / 11KV DHORKIN GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2427	.2241	.2452	.2614	.2801
2	.1886	.1886	.2427	.2241	.2427	.2614	.2801
3	.1886	.1886	.2801	.2241	.2452	.3547	.2801
4	.4715	.3772	.3734	.2801	.3772	.4668	.4668
5	.5658	.5658	.5601	.5601	.5658	.6722	.5975
6	.5658	.6602	.7468	.7468	.6602	.7842	.7468
7	.7545	.6602	.8402	.9335	.7468	.8402	.8402
8	.6602	.7545	.7842	.7468	.6602	.7468	.7468
9	.5658	.6602	.6722		.4715	.5975	.5975
10	.5601	.6602	.4481		.3734	.4481	.4668
11	.4668	.5601	.3921	.3734	.2987	.3734	.3734
12	.3734	.3734	.2801	.2801	.2614	.2987	.2801
13	.2801	.3734	.2801	.2427	.2801	.2987	.2427
14	.3734	.3361	.2987	.2801	.2801	.2987	.2801
15	.3734	.2987	.2987	.2801	.2987	.2987	.2801
16	.2801	.3361	.3361	.3174	.4108	.3734	.2801
17	.4668	.4294	.3734	.3734	.4481	.4668	.3734
18	.5658	.4854	.4668	.4668	.4854	.5601	.3772
19	.5658	.5975	.6535	.5601	.6348	.7468	.4715
20	.4715	.5228	.5601	.5601	.5228	.5601	.4715
21	.3772	.4294	.3734	.5601	.4294	.3361	.4715
22	.3772	.3361	.3361	.2829	.3734	.3361	.3772
23	.1886	.2987	.2987	.2801	.3361	.3361	.2829
24	.1886	.1886	.2614	.2801	.2427	.2614	.3361
Max	.7545	.7545	.8402	.9335	.7468	.8402	.8402
Min	.1886	.1886	.2427	.2241	.2427	.2614	.2427
Avg	.4191	.4362	.4333	.4126	.4121	.4574	.4250

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 202 / 11KV DHORKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.381	.4816	.5975	.1905	.1143	.1867
2	.6097	.381	.4816	.5975	.1905	.1143	.1867
3	.6097	.381	.5117	.6535	.1905	.1524	.1867
4	.6097	.4572	.5268	.6722	.1905	.1715	.1867
5	1.2498	.5335	.5418	.7468	.1905	.1905	.1867
6	.8488	.5792	.5719	.7468	.1905	.1905	.1867
7	.8383	.7373	.6923	.2241	.2286	.1905	.2054
8	.5639	.828	.8916	.2241	.2096	.1715	.1867
9	.6249	.7968	.9145		.2286	.1524	.1867
10	.1715	.1905	.4191		.7468	.828	.9389
11	.2286	.3429	.4001	.2096	1.0202	.8592	1.0467
12	.2667	.2858	.4763	.1905	1.1012	.9842	1.1248
13	.1905	.381	.4763	.1905	1.1633	.953	1.1248
14	.1905	.4001	.5144	.2286	1.1633	.9061	1.0467
15		.4191	.4854	.2286	1.1797	.8592	1.1203
16		.4763	.3547	.2286	1.0978	.8749	1.1203
17	.1905	.4763	.3361	.3048	1.0978	1.0155	.9282
18	.2477	.4572	.2987	.2667	.1334	.1867	.1524
19	.2477	.381	.2427	.2286	.0953	.2054	.1524
20	.0754	.362	.2241	.1905	.1334	.2241	.1905
21	.1698	.3239	.1867	.1905	.1715	.2054	.1905
22	.1524	.3048	.1867	.1715	.1715	.1867	.1905
23	.2858	.2667	.168	.1715	.1524	.1867	.1905
24	.6097	.381	.4755	.5975	.1334	.1334	.1867
Max	1.2498	.828	.9145	.7468	1.1797	1.0155	1.1248
Min	.0754	.1905	.168	.1715	.0953	.1143	.1524
Avg	.4360	.4385	.4524	.3573	.4738	.4190	.4751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 203 / 11KV KARKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0747	.0747	.1219	.1429	.2201
2	.0566	.0754	.0747	.0747	.1219	.1429	.2229
3	.0566	.0754	.0747	.0747	.1219	.153	.2229
4	.0566	.0754	.0747	.0747	.1219	.1646	.2229
5	.0754	.0754	.0747	.0747	.1219	.1783	.2229
6	.0754	.0943	.0747	.0934	.1219	.2494	.4458
7	.1132	.1132	.112	.112	.1829	.4816	.5944
8	.1132	.0943	.112	.112	.1981	.4458	.2934
9	.1132	.0943	.0934		.1829	.3475	.3353
10	.2606	.2751	.2397		.0566	.0739	.0934
11	.4161	.4515	.4161	.503	.0934	.0747	.0566
12	.4607	.5053	.5498	.5335	.056	.0747	.056
13	.4877	.5201	.535	.5335	.0934	.0747	.056
14	.5639	.4458	.5201	.5182	.0934	.056	.0934
15	.5487	.3715	.535	.5335	.0934	.056	.0943
16	.5639	.4755	.5944	.5335	.0934	.0747	.0934
17	.5335	.5498	.5944	.5792	.0934	.0934	.0943
18	.0943	.0747	.0934	.0566	.0934	.0934	.0754
19	.0566	.0934	.0934	.0754	.112	.0934	.0754
20	.0754	.112	.0934	.0754	.0934	.0747	.0754
21	.0943	.0747	.0934	.0754	.0934	.0934	.0754
22	.0566	.0934	.0747	.0754	.0747	.0934	.0566
23	.0566	.0747	.0747	.0754	.0747	.0934	.0754
24	.0566	.0566	.0747	.0747	.0754	.141	.2801
Max	.5639	.5498	.5944	.5792	.1981	.4816	.5944
Min	.0566	.0566	.0747	.0566	.056	.056	.056
Avg	.2101	.2061	.2228	.2243	.1077	.1486	.1722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 204 / 11KV DHANGAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7204	1.7604	1.8023	1.7814	.0754	.0747	.0747
2	1.7204	1.7604	1.8023	1.7814	.0754	.0747	.0747
3	1.8023	1.7604	1.7859	1.7814	.0754	.0747	.0747
4	1.8023	1.9204	1.8138	1.8138	.0754	.0747	.0747
5	1.9662	1.9662	1.8461	1.8138	.0754	.0747	.0747
6	2.1792	2.0972	1.9989	2.1052	.0754	.0747	.0747
7	2.343	2.4741	2.1464	.1296	.0754	.056	.0934
8	2.1792	2.3102	2.3758	.0972	.0377	.056	.0747
9	2.0005	2.1925	2.3102		.0189	.056	.056
10	.0566	.056	.0857		2.3594	2.1348	2.1879
11	.056	.056	.056	.0189	2.5888	2.2653	2.4863
12	.0566	.056	.0566	.0377	2.6216	2.451	2.652
13	.0566	.056	.0934	.0377	2.6707	2.4036	2.652
14	.0566	.0377	.0934	.0377	2.6216	2.2138	2.5692
15	.0566	.0377	.0934	.0377	2.5232	2.2929	2.652
16	.0377	.0377	.0934	.0377	2.6543	2.4036	2.3205
17	.0566	.0377	.0747	.0377	2.5232	2.4006	2.3758
18	.0566	.056	.0934	.0377	.0739	.0747	.1509
19	.0566	.0566	.0934	.0377	.0739	.0747	.1509
20	.0566	.056	.0934	.0377	.0924	.0747	.1524
21	.0566	.056	.0934	.0377	.0924	.0747	.0762
22	.0566	.056	.0934	.0566	.0924	.0747	.0377
23	.0566	.056	.0934	.0377	.0924	.0747	.0566
24	2.0481	1.6385	1.8187	1.7204	.0566	.0747	.0747
Max	2.343	2.4741	2.3758	2.1052	2.6707	2.451	2.652
Min	.0377	.0377	.056	.0189	.0189	.056	.0377
Avg	.8556	.8580	.8711	.6143	.9051	.8210	.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.032	.112	.112	.0446	.0747
2	.0943	.0943	.0314	.112	.112	.0446	.0747
3	.0566	.0943	.0309	.112	.112	.0452	.0747
4	.0377	.0943	.0303	.112	.112	.0457	.0747
5	.0377	.0566	.0297	.0934	.112	.0463	.0747
6	.0377	.0377	.0286	.0747	.112	.0457	.0747
7	.0377	.0377	.0762	.056	.112	.0152	.0934
8	.0377		.0412	.056	.112	.016	.112
9	.0373		.1307		.112	.168	.1494
10	.0747	.0061	.132		.1307	.1494	.168
11	.1307	.0202	.1509	.0747	.112	.168	.1307
12	.1307	.0191	.132	.0934	.0934	.1494	.1307
13	.1307	.0183	.1132	.0934	.0747	.1494	.1307
14	.168	.0171	.112	.0934	.0549	.1494	.1307
15	.1307	.0164	.1307	.0934	.0362	.1494	.112
16	.0943	.0152	.1867	.1867	.0934	.1494	.112
17	.1867	.0202	.1494	.1494	.0934	.1494	.1494
18	.0762	.0191	.1307	.1307	.0747	.1494	.132
19	.2096	.0343	.1494	.1494	.0739	.1494	.132
20	.0754	.286	.1494	.056	.0514	.1494	.1132
21	.0566	.0417	.0934	.0934	.0446	.1494	.0377
22	.1886	.0412	.112	.0747	.0412	.1494	.0754
23	.1886	.0354	.112	.056	.0423	.1494	.1886
24	.0943	.0943	.0332	.112	.0747	.0429	.1307
Max	.2096	.286	.1867	.1867	.1307	.168	.1886
Min	.0373	.0061	.0286	.056	.0362	.0152	.0377
Avg	.1003	.0543	.0966	.0993	.0875	.1094	.1115



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 211 / NANDALGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1219	.301	.3048
2					.1219	.301	.3048
3					.1219	.3612	.3048
4					.1219	.3913	.3048
5					.1829	.4214	.3048
6					.2439	.4816	.5201
7					.381	.6171	.7621
8					.3856	.5569	.381
9					.3201	.2972	.4458
10	.4475	.4475	.5487				
11	.6562	.5944	.6401	.6554			
12	.6718	.6401	.6636	.7011			
13	.6718	.6539	.6401	.6859			
14	.6874	.6097	.6706	.7655			
15	.6874	.5639	.6097	.7499			
16	.5335	.6249	.6401	.7655			
17	.4687	.6097	.6097	.7011			
24						.2675	.3048
Max	.6874	.6539	.6706	.7655	.3856	.6171	.7621
Min	.4475	.4475	.5487	.6554	.1219	.2675	.3048
Avg	.6030	.5930	.6278	.7178	.2223	.3996	.3938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 212 / 11KV KARKIN GAOTHAN FEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2054	.2241	.2452	.2427	.2241
2	.0943	.1886	.2054	.2241	.2452	.2427	.2241
3	.1886	.1886	.2614	.2241	.2452	.3361	.2801
4	.3772	.3772	.3921	.2801	.3772	.4481	.3734
5	.4527	.4715	.5601	.4668	.5658	.5601	.4668
6	.6224	.5658	.6348	.7468	.7167	.5975	.5601
7	.7167	.6602	.7095	.6535	.7842	.6348	.5601
8	.6979	.7356	.6535	.7468	.6979	.5601	.5601
9	.547	.6602	.4854		.4527	.4481	.4668
10	.5228	.6535	.3921		.3547	.3361	.3734
11	.4108	.4668	.2427	.4108	.2241	.1867	.2614
12	.2987	.3734	.1494	.2241	.1867	.1867	.2427
13	.2801	.3361	.168	.2241	.168	.1867	.2241
14	.3361	.2987	.168	.2241	.168	.2241	.2241
15	.3361	.2614	.1867	.2241	.1867	.2241	.2241
16	.4481	.3174	.2241	.2614	.2241	.2241	.2614
17	.4854	.3547	.2614	.2987	.2801	.3734	.3734
18	.5658	.4854	.4668	.4294	.3734	.4668	.4904
19	.5658	.6161	.5601	.5041	.4854	.5601	.4904
20	.4904	.5041	.3734	.5601	.4294	.5601	.4904
21	.3395	.4108	.3361	.5601	.3734	.3734	.4338
22	.3395	.2801	.2987	.3174	.3174	.2987	.3772
23	.2829	.2427	.2987	.2801	.2801	.2439	.3395
24	.1886	1.9239	.2241	.2241	.2427	.2427	.2987
Max	.7167	1.9239	.7095	.7468	.7842	.6348	.5601
Min	.0943	.1886	.1494	.2241	.168	.1867	.2241
Avg	.4073	.4817	.3524	.3777	.3593	.3649	.3675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 201 / 11KV Ranjangaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0309	.2915	.2743	.2743	.2743	.2915	.2915
2	.2915	.2915	.2743	.2572	.2743	.2915	.2743
3	.2915	.3086	.2743	.2572	.2743	.2915	.2743
4	.3086	.3601	.3353	.3086	.3353	.3429	.3086
5	.6516	.6697	.6401	.7716	.6401	.7059	.703
6	.8402	.8501	.823	.8916	.823	.9795	.9945
7	.9431	1.0642	.8993	.9259	.8535	1.0829	1.0288
8	.8573	1.0903	.7926	.8573	.7926	.8871	.9602
9	.6859	.8078	.6554	.8059	.6401	.7762	.7888
10	.5973	.7164	.5316	.5487	.5792	.5487	.6335
11	.5249	.5487	.3258	.3963	.3944	.3772	.4382
12	.4887	.4877	.3086	.3963	.3429	.3086	.3258
13	.5249	.3963	.2743	.2896	.2743	.2743	.3086
14	.5792	.3963	.2572	.2743	.2743	.2572	.2915
15	.6335	.3963	.2743	.2743	.2915	.2572	.3086
16		.4115	.3086	.3048	.4525	.3086	.3601
17	.8686	.4725	.4973	.3353	.5611	.4287	.463
18	.8131	.823	.583	.503	.6335	.5487	.7392
19	.7282	.7468	.7716	.6706	.9149	.7202	1.0082
20	.543	.5944	.7202	.6401	.7059	.583	.6878
21	.4163	.4572	.5316	.4572	.543	.4801	.5068
22	.3429	.3353	.3772	.3506	.3772	.3601	.3772
23	.3086	.2896	.3258	.2896	.3086	.3258	.3429
24	.3086	.3086	.2896	.2743	.2743	.2915	.2915
Max	.9431	1.0903	.8993	.9259	.9149	1.0829	1.0288
Min	.0309	.2896	.2572	.2572	.2743	.2572	.2743
Avg	.5469	.5464	.4727	.4731	.4931	.4883	.5295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 202 / Marhola

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1372	.1219	.1219	.6249	.6859	.7011
2	.1219	.1372	.1219	.1219	.6249	.6859	.7164
3	.1219	.1372	.1219	.1219	.6249	.6859	.7164
4	.1524	.1715	.1372	.1372	.6249	.7164	.7316
5	.1524	.1715	.1981	.1524	.7011	.7655	.7926
6	.1829	.2058	.2286	.2134	.7773	.8592	.8535
7	.2286	.2572	.2591	.2591	.8383	1.0623	1.1279
8					.8383	1.2029	1.0974
9	.1524		.1981		.7926	1.0467	1.0212
10	.9998	1.1126	1.0822			.0914	.1372
11	1.2967	1.2651	1.1431			.0914	.12
12	1.4083	1.2498	1.2193	1.1431	.1029	.0762	
13	1.2811	1.1584	1.2346	1.2651	.1029	.061	
14	1.2967	1.1584	1.2498	1.0974	.1029	.061	
15	1.3123	1.1584	1.2346	1.1584	.1029	.061	.1543
16	1.3123	1.2193	1.2803	1.2193	.12	.061	.1715
17	1.2811	1.2651	1.2803	1.2193	.1543		.2058
18	.1372	.1829	.1067	.1524	.1543	.0457	.2058
19	.1715	.1981	.1372	.1677	.2572	.1067	.2058
20	.1715	.1829	.1524	.1677		.1372	.1886
21	.1543	.1524	.1372	.1524	.1886	.1372	.1543
22	.1543	.1372	.1219	.1372	.12	.1219	.1372
23	.1372	.1372	.1372	.1372	.1029	.0914	.12
24	.1219	.1372	.1372	.1219	.6249	.6859	.7011
Max	1.4083	1.2651	1.2803	1.2651	.8383	1.2029	1.1279
Min	.1219	.1372	.1067	.1219	.1029	.0457	.12
Avg	.5422	.5424	.5235	.4633	.4086	.4148	.4886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 203 / Shekta

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2286	.3048	.3201	.0572	.0514	.0305
2	.3353	.2286	.3048	.3201	.0191	.0514	.0305
3	.3353	.2439	.3048	.3353	.0572	.0514	.0305
4	.3201	.2591	.3048	.3353	.0572	.0514	.0457
5	.3506	.2743	.3048	.3353	.0572	.0686	.0457
6	.381		.3201	.3658	.0572	.0514	.0457
7	.4268	.381	.4115	.4115	.0762		.061
8	.4572	.4115	.3963	.3963	.0457		.0457
9	.3201	.2743	.1981	.3658	.0457	.0514	.061
10	.0762	.0572	.0572	.0457	.3658	.3963	.3963
11	.0572	.0572	.0572	.0572	.4572	.4115	.381
12	.0572	.0572	.0572	.0572	.4725	.4115	.381
13	.0572	.0572	.0381	.0572	.4877	.442	.3658
14	.0572	.0572	.0572	.0572	.4115	.4115	.3506
15	.0572	.0572	.0381	.0572	.381	.3963	.3658
16	.0572	.0572	.0381	.0572	.4115	.442	.381
17	.0572	.0572	.0572	.0572	.4572	.4572	.3963
18	.0572	.0572	.0572	.0572			.0686
19	.0191	.0572	.0762	.0572		.0305	.0857
20	.0572	.0762	.0762	.0457	.0686	.0457	.0686
21	.0572	.0572	.0572	.0457	.0686	.0457	.0686
22	.0572	.0572	.0572	.0457	.0514	.0457	.0514
23	.0457	.0572	.0572	.0572	.0514	.0305	.0514
24	.3353	.2286	.3048	.3048	.0572	.0514	.0343
Max	.4572	.4115	.4115	.4115	.4877	.4572	.3963
Min	.0191	.0572	.0381	.0457	.0191	.0305	.0305
Avg	.1820	.1456	.1640	.1769	.1916	.1902	.1601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 204 / AURANGPURWADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	1.5844	1.3108	1.326	.1372	.1067	.0914
2	1.8595	1.6004	1.3108	1.3413	.1372	.1067	.1067
3	1.8595	1.6164	1.3108	1.3413	.1372	.1067	.1067
4	1.89	1.6804	1.3717	1.3565	.1372	.1219	.1067
5	1.9204	2.0005	1.4632	1.5089	.1372	.1372	.1372
6	1.9814	2.2024	1.5699	1.5851	.1524	.1372	.1524
7	2.1033	2.2996	1.9966	1.9204	.1981	.1524	.1677
8	1.8138	2.0485	1.9662	1.89	.1524	.1524	.1524
9	1.6309	1.768	1.7833		.1372	.1981	.1524
10		.1524	.1219		1.4883	1.448	1.7444
11		.1372	.1219		1.8404	1.5546	1.8404
12		.1219	.1067		1.9204	1.6766	1.9845
13		.1067	.1067		1.9845	1.7528	1.9919
14		.1067	.1067		1.8724	1.7375	2.0081
15		.1067	.1219			1.768	2.0243
16		.1067	.1219		1.9204	1.6004	1.9204
17		.1981	.1524		2.0325	1.5242	1.8947
18		.1829	.1829	.1981	.1981	.1524	.1981
19		.1829	.1829	.1981	.2134	.1524	.1677
20	.1981	.1829	.1677	.1981	.1981	.1829	.1829
21	.2286	.1524	.1829	.1829	.1981	.1829	.1981
22	.1981	.1524	.1981	.1677	.1829	.1372	.1677
23	.1829	.1372	.1524	.1524	.1829	.1219	.1372
24	1.6766	1.5684	1.3108	1.1888	.1372	.1524	.1219
Max	2.1033	2.2996	1.9966	1.9204	2.0325	1.768	2.0243
Min	.1829	.1067	.1067	.1524	.1372	.1067	.0914
Avg	1.3848	.8498	.7259	.9704	.6824	.6401	.7398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 205 / DARGHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0191	.0152	1.3108	1.3123	1.2346
2	.0152	.0152	.0191	.0152	1.3108	1.3123	1.2498
3	.0152	.0152	.0191	.0152	1.3108	1.3279	1.2498
4	.0152	.0152	.0191	.0152	1.3108	1.3763	1.2651
5	.0152	.0152	.0191	.0152	1.3108	1.4083	1.2651
6	.0152	.0152	.0191	.0152	1.3108	1.4243	1.3108
7	.0152	.0152	.0191	.0152	1.3565	1.6164	1.3413
8	.0152	.0152	.0191	.0152	1.2955	1.5524	1.4327
9	.0152	.0191	.0191	.0152	1.2346	1.5364	1.3717
10	2.2996	1.9966	1.9814	1.9357	.0152	.0152	.0152
11	2.3805	2.21	2.0424		.0152	.0152	.0152
12	2.3644	2.21	1.9814			.0152	.0152
13	2.3805	2.1338	1.9662		.0152		.0171
14	2.3482	2.0729	2.0424	2.1338	.0152		.0152
15	2.3158	2.0119	1.9814	1.9814	.0152		.0152
16	2.2834	1.9509	1.9509	1.89	.0152		.0152
17	2.0485	1.9052	1.9357	1.829	.0152		.0152
18	.0152	.0191	.0152	.0191	.0152	.0152	.0152
19	.0152	.0191	.0152	.0191	.0152	.0152	.0152
20	.0152	.0191	.0152	.0191	.0152	.0152	.0152
21	.0152	.0191	.0152	.0191	.0152	.0152	.0152
22	.0152	.0191	.0152	.0191	.0152	.0152	.0152
23	.0152	.0191	.0152	.0191	.0152	.0152	.0152
24	.9678	.0152	.0152	.0152	1.3413	1.2967	1.1888
Max	2.3805	2.21	2.0424	2.1338	1.3565	1.6164	1.4327
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.8174	.6984	.6733	.4779	.5778	.7526	.5469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 201 / Wadwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.1888
Max	1.1888
Min	1.1888
Avg	1.1888



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 202 / Anantpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0183
Max	.0183
Min	.0183
Avg	.0183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 203 / Apegaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
20	.0183
24	.0177
Max	.0183
Min	.0177
Avg	.018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 204 / WADWALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3189
Max	.3189
Min	.3189
Avg	.3189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 205 / 11kvWAGHADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.2193
Max	1.2193
Min	1.2193
Avg	1.2193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 208 / 11KV Naigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.4022
Max	1.4022
Min	1.4022
Avg	1.4022

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 201 / UDYOGMITRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.1576	.7545	1.0631	1.0387	1.1203	1.0631
2	1.1163	1.1576	.7202	1.0631	1.0029	1.1203	1.0631
3	1.1163	1.1389	.7202	1.0631	1.0387	1.1203	1.0631
4	1.1163	1.1389	.7202	1.0631	1.0387	1.1203	1.0631
5	1.134	1.1389	.7545	1.0631	1.0566	1.1203	1.0288
6	1.1641	1.0829	.9431	1.0985	1.0745	1.1203	1.0288
7	1.1641	.8589	.8573	1.0985	1.0745	1.1949	1.0288
8	1.1104	.8501	.9945	1.1641	1.1222	1.2323	1.2346
9	1.1641	.7716	1.1641	1.1999	1.1641	1.363	1.286
10	1.307	.7716	1.2178	1.448	1.4563	1.2346	1.5364
11	1.419	.7716	1.3253	1.4998	1.3256	1.1145	1.5546
12	1.3817	.7716	1.2536	1.5546	1.2696	1.286	1.5546
13	1.307	.7716	1.1641	1.39	1.2696	1.2346	1.2803
14	1.3443	.7716	1.1999	1.4266	1.2696	1.3717	1.4266
15	1.419	.7716	1.1999	1.4632	1.2696	1.286	1.5565
16	1.3817	.7716	1.2357	1.3213	1.3443	1.286	1.448
17	1.2883	.7716	1.1641	1.3575	1.3817	1.286	1.448
18	1.3443	.7202	1.1462	1.267	1.1576	1.2003	1.267
19	1.2323	.7716	1.0387	1.086	1.1203	1.1145	1.3575
20	1.363	.7716	1.0029	1.0498	1.1203	1.0288	1.3073
21	1.307	.7202	.9745	1.0745	1.1203	1.0288	1.3073
22	1.1949	.7202	1.0099	1.0745	1.1203	1.0288	1.2894
23	1.1949	.7202	1.0277	.985	1.0829	1.1145	1.1641
24	1.1462	1.1576	.7545	1.2048	.985	1.1203	1.0631
Max	1.419	1.1576	1.3253	1.5546	1.4563	1.3717	1.5565
Min	1.1104	.7202	.7202	.985	.985	1.0288	1.0288
Avg	1.2438	.8771	1.0143	1.2116	1.1627	1.1770	1.2675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 202 / NAIGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7442	.7655	.583	.7796	.8859	.7468	.823
2	.7087	.7468	.583	.7442	.8505	.7468	.7716
3	.7087	.7842	.6173	.7973	.8682	.7842	.7716
4	.7973	.7842	.6859	.8505	.9214	.8589	.823
5	.9922	.8402	.7545	.9568	1.0631	1.0456	.8573
6	1.4327	1.2323	1.0631	1.3969	1.5061	1.3443	1.286
7	1.6118	1.531	1.5089	1.5223	1.7718	1.6804	1.4232
8	1.7375	1.3817	1.4685	1.4864	1.6832	1.7177	1.5223
9	1.3611	1.166	1.3432	1.4327	1.5223	1.4937	1.3203
10	1.4563	1.0387	1.3969	1.5384	1.4937	1.0974	1.3575
11	1.4563	1.0208	1.2894	1.448	1.4003	1.166	1.448
12	1.2696	.8596	1.1283	1.3717	1.307	1.0745	1.2127
13	1.0082	.8596	.985	1.0059	.8962	.9313	1.0608
14	1.2323	.7522	1.0029	1.086	.9709	1.0745	1.086
15	1.2696	.7164	1.1462	1.1584	1.1203		1.267
16	1.307	.7164	1.182	1.1641	1.307		1.2894
17		.7522	1.1641	1.1765	1.3256		1.3575
18	1.2136	.9313	1.3253	1.267	1.307		1.3717
19	1.2136	1.0029	1.2715	1.3213	1.4003		1.4327
20	1.1203	.8954	1.1462	1.1641	1.1203	.985	1.182
21	.8962	.7522	.9568	1.0745	.9709	1.0387	1.0029
22	.8215	.7164	.9214	.8954	.9335	.9671	.8954
23	.8215	.6626	.8859	.9134	.8775	.8954	.8764
24	2.3038	.7655	.6089	.815	.8859	.7468	.8954
Max	2.3038	1.531	1.5089	1.5384	1.7718	1.7177	1.5223
Min	.7087	.6626	.583	.7442	.8505	.7468	.7716
Avg	1.1950	.9031	1.0424	1.1403	1.1829	1.0734	1.1389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 203 / 11 KV CHITEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7712	.8048	.7202	.8413	.9465	.823	.9259
2	.7362	.8048	.7202	.8063	.9465	.8048	.9259
3	.8413	.823	.6859	.8413	.9465	.8048	.8916
4	.9114	.8779	.7888	.9465	1.0517	.8779	.9945
5	1.1218	.924	.9602	1.1218	1.2269	1.1458	1.1317
6	1.4175	1.2197	1.3717	1.4352	1.4723	1.4937	1.3717
7	1.7718	1.531	1.6118	1.6301	1.6827	1.8298	1.6804
8	1.701	1.5684	1.5775	1.5947	1.6476	1.7551	1.749
9	1.6655	1.2689	1.4403	1.5238	1.4217	1.531	1.4746
10	1.6804	1.3375	1.2757	1.4022	1.419	1.3032	1.4022
11	1.2696	1.2346	1.2403	1.2971	1.1949	1.2003	1.262
12	1.2323	1.0974	1.1694	1.1393	1.1203	1.0631	1.2269
13	1.1949	.9602	1.0985	.9816	1.0456	1.0631	1.0867
14	1.2323	.7888	1.1694	.9816	1.1203	1.0974	1.0867
15	1.2323	.7888	1.0985	.9816	1.1203	1.0631	1.1218
16	1.419	.7888	1.2048	1.0517	1.1203	1.0631	1.1568
17	1.419	.8573	1.2403	1.1568	1.1949	1.0974	1.262
18	1.3817	1.0288	1.4175	1.2269	1.307	1.3032	1.3321
19	1.307	1.2346	1.5947	1.4563	1.419	1.4403	1.5074
20	1.2323	1.1317	1.3466	1.387	1.307	1.4746	1.387
21	1.1088	.9602	1.134	1.3003	1.1203	1.2003	1.2136
22	.9511	.8573	1.0166	1.0402	1.0456	1.166	1.0056
23	.8048	.7545	.9465	.9709	.9511	.9945	.9015
24	.8063	.8048	.7202	.8764	.9816	.8501	.9259
Max	1.7718	1.5684	1.6118	1.6301	1.6827	1.8298	1.749
Min	.7362	.7545	.6859	.8063	.9465	.8048	.8916
Avg	1.2171	1.0187	1.1479	1.1663	1.2004	1.1852	1.2093



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 205 / 11 KV CHITEGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7796	.6584	.4801	.8328	.8413	.6767	.6859
2	.7619	.6584	.463	.815	.8238	.7316	.6859
3	.7619	.631	.463	.815	.8238	.7316	.6859
4	.7973	.6584	.4973	.7973	.8238	.7316	.6859
5	.815	.6584	.5144	.815	.8764	.7316	.6859
6	.8505	.6584	.5144	.7973	.8764	.7316	.6859
7	.8505	.6219	.4973	.7796	.8764	.8413	.6859
8	.8859	.6219	.6859	.8859	.9465	.9979	.823
9	1.0745	.4801	.823	1.0924	1.0277	1.1203	1.166
10	1.419	.4801	1.2178	1.6644	1.4563	1.4746	1.3756
11	1.7177	.4801	1.3611	1.6827	1.8671	1.989	1.829
12	1.7924	.4801	1.3969	1.6461	1.587	1.8861	1.7375
13	1.8111	.4801	1.2536	1.5546	1.4377	1.6289	1.828
14	1.6057	.4801	1.5565	1.5927	1.8671	1.6461	1.8099
15	1.419	.4801	1.5384	1.701	1.8858	1.5775	1.5927
16	1.307	.4801	1.3969	1.5223	1.8671	1.6289	1.5565
17	1.4937	.4801	1.4685	1.6827	1.7551	1.6461	1.7375
18	.9709	.4458	1.5223	1.2254	1.4937	1.3717	1.448
19	.7762	.4801	.8954	.8417	.8589	.8573	1.0029
20	.7682	.463	.8505	.8596	.7762	.6859	.8059
21	.7682	.4287	.815	.8417	.7499	.6859	.7701
22	.7682	.4801	.8328	.8238	.7316	.7545	.7164
23	.7316	.5144	.8505	.8238	.695	.7545	.6836
24	.7796	.6584	.4801	.8328	.8063	.6767	.6859
Max	1.8111	.6584	1.5565	1.701	1.8858	1.989	1.829
Min	.7316	.4287	.463	.7796	.695	.6767	.6836
Avg	1.0711	.5399	.9323	1.1219	1.1563	1.1066	1.0987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 201 / RAPDRP NEW KAWSAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4066	.462	.4435	.4938	.4887	.5792
2	.4755	.3696	.4435	.4435	.4938	.4887	.543
3	.5304	.3696	.4435	.462	.4755	.4706	.543
4	.6036	.4066	.5359	.5359	.5121	.5068	.5792
5	.6767	.4805	.5914	.6099	.5304	.543	.6154
6	.7682	.5914	.7947	.7207	.7602	.8326	.905
7	.8779	.8316	.8131	.8871	.8145	.8145	.9774
8	.7316	.7207	.7207	.7392	.7602	.7964	.8145
9	.6653	.6468	.7392	.7059	.6878	.5973	.6335
10	.6099	.6283	.499	.5973	.543	.5611	.543
11	.5544	.5914	.5544	.5249	.5068	.5249	.5611
12	.5544	.5544	.499	.4344	.4525	.4887	.5611
13	.5359	.499	.462	.4344	.4163	.4706	.5249
14	.462	.4805	.4435	.4163	.4344	.4887	.5792
15	.499	.4435	.4805	.3982	.4344	.6335	.5792
16	.5544	.462	.499	.3982	.4344	.5611	.5973
17	.5729	.462	.5175	.4344	.4706	.5068	.6516
18	.5729	.5359	.6099	.4525	.5249	.543	.6697
19	.5914	.6838	.6283	.6697	.724	.7783	.7964
20	.5914	.6653	.7023	.6335	.7421	.7783	.7602
21	.6099	.7023	.6283	.6154	.6878	.724	.7059
22	.5914	.5914	.5914	.5973	.6335	.6697	.6878
23	.5175	.5175	.5175	.5249	.5792	.6335	.6697
24	.4887	.4706	.4706	.4887	.4938	.543	.5973
Max	.8779	.8316	.8131	.8871	.8145	.8326	.9774
Min	.462	.3696	.4435	.3982	.4163	.4706	.5249
Avg	.5887	.5463	.5686	.5487	.5669	.6018	.6531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 202 / RAPDRP POWER HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7392	.7023	.6838	.7316	.7602	.8145
2	.7577	.7023	.7023	.6838	.7133	.7059	.7783
3	.7947	.7023	.7023	.7023	.695	.6878	.7783
4	.8686	.7392	.7762	.7762	.7316	.7421	.8507
5	.961	.7947	.924	.8871	.8596	.9774	.9231
6	1.0903	.9979	1.0349	1.0349	1.1041	1.1041	1.1584
7	1.2567	1.1643	1.1827	1.2197	1.2308	1.2308	1.4118
8	1.2752	1.2752	1.2936	1.2012	1.2851	1.2851	1.2851
9	1.1458	1.2936	1.1273	1.1041	1.1765	1.1584	1.1946
10	1.0719	1.2197	1.0349	1.086	.543	1.086	1.1584
11	1.0719	1.1273	.8871	1.0136	.9593	1.1403	.9955
12	1.0164	1.0903	.8501	.9774	.905	.9955	1.0317
13	.961	.924	.8871	.905	.8507	.9231	.9593
14	.9425	.7947	.7762	.8507	.7783	.8688	.9412
15	.924	.7392	.8316	.7964	.7964	.8507	.8869
16	.961	.7207	.8871	.8145	.8145	.8869	.9231
17	1.0349	.7947	.961	.8688	.9412	.9412	1.0679
18	.9979	.924	1.0903	.905	1.0317	1.1222	1.1584
19	1.0719	1.1643	1.1827	1.2851	1.1765	1.448	1.3756
20	1.1273	1.1273	1.2382	1.267	1.267	1.3575	
21	1.1458	.924	1.1458	1.086	1.1222	1.086	1.1765
22	.924	.7947	1.0534	1.0679	.9774	1.086	1.1222
23	.8501		.7762	.905	.905	1.0317	1.086
24	.7602	.7602	.6878	.7421	.7682	.7964	.8688
Max	1.2752	1.2936	1.2936	1.2851	1.2851	1.448	1.4118
Min	.7577	.7023	.6878	.6838	.543	.6878	.7783
Avg	.9911	.9354	.9473	.9527	.9318	1.0113	1.0411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 201 / PANTHEWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 202 / KAUTGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 203 / PAITHAN

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 204 / RAHATGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 205 / MIDC FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 206 / CHAGATPURI  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 207 / PIMPALWADI GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 208 / BALANAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 401 / 33 KV Paper Mill  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 402 / 33 KV Bidkin  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 403 / 33 KV Pachod

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 404 / 33 KV ABAD WATER WORKES  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 407 / 33 KV Dawarwadi  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
23	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 703 / 132 kv HYDRO POWER PLANT NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
Feeder KV- 132 / OUTGOING (NON CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	11.4312
Max	11.4312
Min	11.4312
Avg	11.4312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 401 / 33 KV Bidkin

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
23	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 402 / 33 KV Allana  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 403 / 33 KV Badve Engineering  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 404 / 33 KV Water Workes  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 405 / 33 KV AURANGABAD ELECTRICAL NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 406 / 33 KV CHITEGAON

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 407 / 33 KV Jailaxmi

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 408 / 33 KV Videcon  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 409 / 33 KV RAJANGAON(KHURI)  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 703 / 132 KV R L STEEL FEEDER  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	11.4312
Max	11.4312
Min	11.4312
Avg	11.4312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11 KV JAMGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2689		
2			1.2003		
3			1.1145		
4			1.2346		
5			1.3375		
6			1.4403		
8	1.7147				
9	.0343	1.5775		.0514	.0343
10		.0514		.0343	.0343
11		.0514		1.7833	1.7147
12	.0343	.0343		1.6975	1.989
13				1.6975	1.8861
14				1.6975	1.8347
15				.0343	.0171
16		.0343		.0343	.0171
17	.0343				
18	.0514				
19	.0514				
20	.0514				
21	.0514				
22	.0514				
23	.0514				
24	1.3717	1.4918	1.3375		
Max	1.7147	1.5775	1.4403	1.7833	1.989
Min	.0343	.0343	1.1145	.0343	.0171
Avg	.3180	.5401	1.2762	.8788	.9409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11 KV MANJARI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.1029	
5			.0686	
8	.12			
9	.0343			2.2805
10	2.5377			.0857
11	3.155	2.7435		.0514
12	3.155	2.8121		
13	3.2236	3.0178		.0514
14	3.1893	2.915		.0686
15	2.8292	2.8121		.0857
16	2.8292	2.8807		.0343
17	2.4006	2.572		
18	.0857			
19	.12			
20	.1029			
21	.1029			
22	.1029			
23	.12			
24	.1029	.12		
Max	3.2236	3.0178	.1029	2.2805
Min	.0343	.12	.0686	.0343
Avg	1.4242	2.4842	.0858	.3797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11 KV MALUNJA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7147		
2			1.6118		
3			1.6804		
4			1.8519		
5			1.9719		
6			2.1091		
8	2.5892				
9	.2058	2.4691		.2058	.1886
10	.2058	.1715		.1029	.1886
11	.1372	.1715		2.2634	.1715
12	.2058	.1715		2.8464	.1715
13	.1715	.1715		.2058	.1372
14	.1715	.1715		.1372	.12
15	.1715	.1715		2.4863	3.2922
16		.1715		2.7435	3.1379
17	.1715	.1715			
18	.2058				
19	.2572				
20	.2401				
21	.2229				
22	.1715				
23	.12				
24	2.3148	2.1605	2.7263		
Max	2.5892	2.4691	2.7263	2.8464	3.2922
Min	.12	.1715	1.6118	.1029	.12
Avg	.4726	.6002	1.9523	1.3739	.9259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / TOWN I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.823		
2			.8573		
3			.9259		
4			.9945		
5			1.0288		
6			1.286		
8	1.3889				
9	1.2346	1.3203		1.3717	1.2346
10	1.2003	1.2689		1.166	1.1488
11	1.2003	1.2517		1.1317	1.2174
12	1.1317	1.2003		1.0802	1.0631
13	1.1317	1.4403		1.0288	1.0288
14	.9602	.8573		.9945	.9945
15	.9774	.8059		.9602	.9945
16	1.0288	.8059		1.0117	1.0802
17	1.1145	1.0631			
18	1.1145				
19	1.3546				
20	1.2003				
21	1.046				
22	.9945				
23	.8916				
24		.7716	.7888		
Max	1.3889	1.4403	1.286	1.3717	1.2346
Min	.8916	.7716	.7888	.9602	.9945
Avg	1.1231	1.0785	.9578	1.0931	1.0952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 205 / TOWN II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3772		
2			.4458		
3			.5144		
4			.5487		
5			.5144		
6			.6173		
8	.9088				
9	.7716	.8573		.823	.7202
10	.7202	.8059		.6687	.6516
11	.6859	.7888		.6516	.6516
12	.6173	.6859		.6344	.583
13	.5658	.6859		.5658	.5316
14	.583	.5487		.5144	.5144
15	.583	.5144		.5144	.5144
16	.6344	.5487		.5487	.5316
17	.7202	.6001			
18	.6859				
19	.7716				
20	.6859				
21	.6173				
22	.5144				
23	.4458				
24	.4287	.4115			
Max	.9088	.8573	.6173	.823	.7202
Min	.4287	.4115	.3772	.5144	.5144
Avg	.6435	.6447	.5030	.6151	.5873



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 206 / TOWN III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058		
2			.1715		
3			.1372		
4			.2058		
5			.2743		
6			.3944		
8	.5144				
9	.4458	.4115		.4287	.3772
10	.4115	.463		.3944	.3772
11	.3944	.3944		.3429	.2743
12	.3429	.3772		.3429	.1715
13	.3772	.3429		.3258	.2915
14	.3429	.3429		.2915	.2915
15	.3429	.3086		.3086	.3086
16	.4115	.3429		.3429	.3601
17	.1715	.3772			
18	.3944				
19	.3601				
20	.3429				
21	.3429				
22	.2743				
23	.2229				
24	.2401	.2401			
Max	.5144	.463	.3944	.4287	.3772
Min	.1715	.2401	.1372	.2915	.1715
Avg	.3490	.3601	.2315	.3472	.3065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 207 / 11 KV WARKHED FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
10	.5144	
11	.7545	1.8519
12	.7888	2.0576
13	.823	1.7147
14	.6859	1.7833
15	.7202	1.7147
16	.6859	1.9204
17	.6859	1.7147
Max	.823	2.0576
Min	.5144	1.7147
Avg	.7073	1.8225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 208 / 11 kv NAWABPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4115		
2			.5144		
3			.7545		
4			.9431		
5			1.2003		
9	1.166			.9259	.9259
10	.7202	.9088		.5144	.7202
11	.6859	.6001		.3944	.3944
12	.583	.463			.3772
13	.5144	.4458		.4287	.3772
14	.3429	.4115		.4115	.4115
15	.6516	.4115		.3601	.3429
16	.6173	.3944		.4115	.3772
17	.7888	.5144			
18	.8059				
19	1.0631				
20	.9259				
21	.6859				
22	.6344				
23	.5316				
24	.4458	.463	.463		
Max	1.166	.9088	1.2003	.9259	.9259
Min	.3429	.3944	.4115	.3601	.3429
Avg	.6977	.5125	.7145	.4924	.4908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 209 / 11KV NEW INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.0514		
8	.1372				
9	.12			.1715	.1715
10	.12			.1372	.1715
11	.1372			.1372	.1715
12	.1029			.1543	.1715
13	.1029	.0514		.1543	.1715
14	.1029			.1543	.1543
15	.0857			.1543	.1543
16				.1715	.1372
17		.0343			
21	.1029				
22	.0857				
23	.2058				
24	.2572	.1886			
Max	.2572	.1886	.0514	.1715	.1715
Min	.0857	.0343	.0514	.1372	.1372
Avg	.1300	.0914	.0514	.1543	.1629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 201 / 11KV TURKABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.5716	.5716	.7461	.0762	.0381	.0655
2	.4096	.724	.5716	.7373	.0762	.0381	.0655
3	.4096	.724	.6097	.763	.0953	.0381	.4915
4	.6226	.7621	.6859	.7969	.0762		.0509
5	.7373	.8002	.7202	.8139	.0762	.0572	.0648
6	.9012	.9145	.7888	.8192	.0762		.0648
7	.9503	.9526	.9259	.8383	.0762	.0762	.0655
8	.9831	1.0288	.9259	.7956	.0762	.0381	.0655
9	.9526		.6859	.7373	.0762	.0381	.0678
10	.0381	.0381		.0678	.0762	.5668	.0762
11	.0381	.0381			.7621	.5735	.6516
12	.0381	.0381			.7202	.5765	.6516
13	.0381	.0381			.7545	.5668	.6516
14	.0381	.0381		.0762	.7202	.5801	.6516
15	.0381	.0381		.0381	.6516	.6371	.6173
16	.0381	.0381		.0381	.6516	.6478	.5487
17	.0381	.0381		.0381	.1905	.6718	.5144
18				.0381	.1905	.4694	.4572
19		.0572		.0381	.0381	.0486	.0762
20	.0762	.0762		.0381	.0381	.0486	.0762
21		.0381		.0381	.0381	.0648	.0762
22		.0381		.0762	.0381	.0655	.0762
23		.0381			.0381	.0648	.0762
24	.2949	.4954	.5335	.6962	.0762	.0381	.0655
Max	.9831	1.0288	.9259	.8383	.7621	.6718	.6516
Min	.0381	.0381	.5335	.0381	.0381	.0381	.0509
Avg	.3668	.3421	.7019	.4115	.2370	.2702	.2612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 202 / 11 KV SHIVRAI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0953	.0953	.0655	1.1431	1.105	1.065
2	.0819	.0953	.0953	.0819	1.1812	1.105	1.166
3	.1017	.0953	.1143	.0983	1.1812	1.1812	1.3108
4	.0972	.0762	.1143	.1147	1.4861	1.4098	1.442
5	.1134	.0953	.1143	.1187	1.4861	1.5242	1.5565
6	.1174	.0762	.1334	.0983	1.8861	1.5775	1.5927
7	.1017	.0762	.1334	.1017	1.9052	1.8004	1.6385
8	.1147	.1334	.1524	.0819	1.848	1.9204	1.7295
9	.1334	.1334	.0953	.0848	1.4232	1.6975	1.3927
10	.1334	.1143		.0678	.0762	.0838	.1143
11	2.2672	2.0405		1.9052	.0762	.0655	.0762
12	2.4006			2.0957	.0762	.0655	.0572
13	2.5149	2.1262		2.3053	.0762	.0492	.0572
14	2.4958	2.0748		2.2481	.0572	.0509	.0572
15	2.4768	2.0576			.0572	.0648	.0572
16	2.2862	1.8176		1.9052	.0762	.0678	.0572
17	2.0005	1.7833		1.9052	.0762	.2753	.0762
18	1.8861	1.749		1.7147	.0762	.0848	.0762
19	.0762	.1524		.0762	.0953	.0829	.1524
20	.0762	.1334		.0953	.1143	.0972	.1143
21		.1143		.0762	.0953	.0972	.0953
22		.0953		.0762	.0762	.0819	.0762
23		.0953			.0762	.0972	.0762
24	.081	.0762	.0953	.0655	.9145	1.0288	1.004
Max	2.5149	2.1262	.1524	2.3053	1.9052	1.9204	1.7295
Min	.0762	.0762	.0953	.0655	.0572	.0492	.0572
Avg	.9353	.6655	.1143	.6992	.6483	.6506	.6267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 203 / 11 KV DAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	.1715	.1524	.2035	.3429	.4572	.6154
2	.1619	.1715	.1524	.2486	.3048	.4763	
3	.1638	.1524	.1524	.2515	.3048	.5335	.6554
4	.2294	.1905	.1524	.2883	.3429	.5716	.6882
5	.2458	.2286	.1905	.2713	.3429	.6097	.6802
6	.2458	.2477	.2667	.2949	.4191	.583	.7461
7	.2785	.2667	.3239	.2949	.4954	.6516	.7373
8	.2785	.3048	.3048	.2486	.6287	.6859	.7287
9	.3429		.2667	.1966	.3944	.4973	.6478
10	.3429	.2667		.1638	.1143	.0819	.1143
11	.5144	.2477		.381	.0953	.0648	.0762
12	.5144			.4954	.0762	.0486	.1143
13	.5335	.3258		.381	.0572	.0503	.1143
14	.5335	.3601		.381	.0762	.0486	.1143
15	.5335			.362	.0953	.0819	.1143
16	.5335	.1715		.3429	.1524	.0972	.1524
17	.5144	.381			.1905	.0848	.1524
18	.4763	.4001		.2477	.1905	.1296	.1524
19	.1715	.2667		.1905	.2286	.1296	.2286
20	.1715	.2286		.1905	.2096	.1296	.2286
21		.1905		.2286	.1715	.1147	.1905
22		.1524		.1905	.1524	.1134	.1524
23		.1524			.1143	.1134	.1143
24	.1187	.1524	.1524	.2035	.381	.4572	.5801
Max	.5335	.4001	.3239	.4954	.6287	.6859	.7461
Min	.1187	.1524	.1524	.1638	.0572	.0486	.0762
Avg	.3358	.2395	.2115	.2753	.2451	.2838	.3521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 204 / 11 KV MANGEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554		.4144	.0381	.0381	.0497
2	.6783		.431	.0381	.0381	.0648
3	.6882		.4424	.0381	.0381	.0655
4	.7373		.4578	.0381	.0572	.0655
5	.8097		.4748	.0381	.0762	.0819
6	.852		.4578	.0381	.0762	.081
7	.8718		.4748	.0381	.0572	.0848
8	.8848		.4534	.0381	.0572	.081
9	1.0288		.421	.0381	.0381	.0655
10	.0381		.0164	.0381	.0339	.0762
11	.0381		.0191	.583	1.1142	1.0288
12	.0191			.5487	1.1469	1.0117
13	.0191			.8745	1.1469	.9945
14	.0381		.0191	1.2003	1.1174	.9945
15	.0191		.0191	1.2517	.8192	.9259
16	.0381	.0191	.0381	1.0974	.6554	.8916
17	.0381	.0191	.0381	.9774	.6783	.7888
18	.0381	.0191	.0381	.9774	.7701	.7545
19	.0381	.0381	.0381	.0762	.0486	.0762
20	.0381	.0381	.0381	.0572	.0509	.0572
21		.0381	.0381	.0572	.0335	.0572
22		.0191	.0381	.0572	.0509	.0572
23		.0191		.0572	.0486	.0572
24	.6226		.4096	.0381	.0381	.0509
Max	1.0288	.0381	.4748	1.2517	1.1469	1.0288
Min	.0191	.0191	.0164	.0381	.0335	.0497
Avg	.3900	.0262	.2275	.3431	.3429	.3526



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 205 / 11 kv DAHEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.5716	.5716	.5935	.6859	.7049	.852
2	.9012	.6859	.5716		.6097	.743	.8192
3	1.1797	.9145	.6478		.724	.8002	1.1633
4	1.3565	1.2574	.724		.9145	1.0288	1.3904
5	1.4413	1.3336	.8002		1.1812	1.3527	1.5261
6	1.3927	1.6385	1.0288		1.4861	1.8099	1.7126
7	1.4091	1.8861	1.8099		1.8861	1.7147	1.6956
8		1.6766	1.7909	.7373	1.6575	1.5604	1.5729
9	1.2955	1.5623			1.6766	1.6194	1.2955
10	1.1431	1.3527		1.5708	1.2003	.9012	
11	1.0479	1.2003		1.3336	.8954	.8288	
12	.9526			1.2574	.8002	.5992	
13	.9145	.9145		.6859	.743	.5935	.7621
14	.9526	.8383		.7621	.724	.5935	.743
15	.9907			.8002	.7049	.6154	.8002
16	1.0669	.8383		.9526	1.0288	.6554	.9145
17	1.2574	1.0098		1.0669	1.1431	.6882	.9526
18		1.2955		1.1622	1.3146	.9717	1.3336
19		1.6194		1.5242	1.4861	.8907	1.7147
20	1.8861	1.1812		1.8861	1.3336	.8718	1.4861
21		1.0288		1.8861	1.1812	.8097	1.105
22		.7621		1.0669	.9526	.7449	.8764
23					.7811	.6802	.8002
24	.6783	.5335	.5716	.6539	.6097	.7049	.7122
Max	1.8861	1.8861	1.8099	1.8861	1.8861	1.8099	1.7147
Min	.6783	.5335	.5716	.5935	.6097	.5935	.7122
Avg	1.1419	1.1477	.9463	1.1212	1.0717	.9368	1.1537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 206 / 11 KV TURKABAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6097	.6478	.8192	.5335	.724	.7773
2	.6554	.724	.6478	1.0343	.5335	.724	.8478
3	.7373	.7621	.6478	1.1869	.724	.724	1.004
4	.7956	.8764	.8002	1.3435	1.0669	.8002	1.1336
5	1.065	1.105	1.2193	1.4746	1.0669	1.2765	1.1469
6	1.3435	1.4861	1.7147	1.6956	1.5623	1.829	1.4899
7	1.4922	1.829	2.0767	1.8143	1.7528	1.9052	1.7004
8	1.4746	1.829	1.7147	1.3904	1.8099	1.6766	
9	1.2574	1.6385	1.4289	1.2378	1.448	1.3717	1.2955
10	1.0669	1.3336		.9012	1.2955	.9503	.9907
11	.9145	1.0098			.7049	.7373	.6668
12	.7621	.8192				.5426	.6097
13	.6859	.8192			.6097	.5304	.6097
14	.7621	.8002		.5716	.6097	.4973	.5906
15	.9335	.8002		.5335	.6097	.502	.6097
16	1.0669	.8002		.6859	.8002	.5304	.724
17	1.3336	1.0288		.6859	.9526	.5407	.8002
18	1.3908	1.2003		.9907	1.1241	.8745	.9526
19	1.4861	1.6004		1.3717	1.4098	1.0059	1.7528
20	1.829	1.3717		1.829	1.2955	.9835	1.3717
21		1.105		1.3717	1.0288	.8383	1.0669
22		.8764		1.1431	.8764	.7449	.9145
23		.6478			.8002	.6802	.8002
24	.663	.5335	.6478	.763	.5716	.724	.6478
Max	1.829	1.829	2.0767	1.829	1.8099	1.9052	1.7528
Min	.6554	.5335	.6478	.5335	.5335	.4973	.5906
Avg	1.0664	1.0669	1.1546	1.1422	1.0081	.9047	.9784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 207 / 11 KV YESGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339	.0381	.0381	.0168	.3429	.4191	.4915
2	.0328	.0381	.0381	.0162	.362	.4763	.5426
3	.0328	.0381	.0381	.0339	.381	.5335	.5426
4	.0335	.0381	.0381	.0332	.381	.5716	.5668
5	.0328	.0381	.0381	.0339	.4191	.724	.6154
6	.0339	.0381	.0572	.0335	.4954	.8002	.6783
7	.0339	.0191	.0762	.0162	.3772	.9431	.7122
8	.0339	.0381	.0381	.0166	.4458	.8745	.7122
9	.0381	.0191	.0381	.0162	.3429	.6859	.6783
10	.0381	.0191		.0162	.0381	.0164	.0572
11	.6859	.8573			.0381	.0166	.0381
12	.6859	.823				.0164	.0381
13	.724	.7888			.0191	.017	.0381
14		.7545		.5335	.0191	.0168	.0191
15	.7621	.7202		.4954	.0191	.0166	.0191
16	.7621	.6859		.4191	.0381	.017	.0191
17	.6859	.6173		.4191	.0381	.0168	.0191
18	.6097	.5487		.4191	.0381	.0168	.0381
19	.0381	.0762		.0381	.0762	.0328	.0762
20	.0381	.0953		.0381	.0572	.0324	.0762
21		.0572		.0381	.0381	.0328	.0762
22		.0381		.0381	.0381	.0328	.0381
23		.0381			.0381	.0324	.0381
24	.0332	.0381	.0381	.0164	.5716	.4191	.4588
Max	.7621	.8573	.0762	.5335	.5716	.9431	.7122
Min	.0328	.0191	.0381	.0162	.0191	.0164	.0191
Avg	.2684	.2693	.0438	.1344	.2006	.2817	.2746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 208 / 11KV ARYANSH IND FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5426	.4954	.1905	.5304	.6859	.6668	.5571
2	.5596		.1905	.3401	.6097	.6478	.5765
3	.5596		.1905	.4752	.6097	.5906	.5935
4	.5506		.1905	.4858	.5716	.6097	.6226
5	.5636		.1905	.5087	.6097	.6097	.6554
6	.5801		.2096	.5138	.5716	.6859	.6882
7	.5801	.6859	.2286	.5256	.6097	.6668	.7461
8	.5636	.4954	.2667	.6706	.6478	.9526	.78
9	.6859	.1905	.7621	.8139	.7621	.9526	
10	.7621	.1905		.852	.6097	.8817	.8764
11	.8002	.1905			.5335	.9116	.8573
12	.7621	.1905			.4763	.9231	.9526
13	.7621	.1905			.4382	.9231	.9907
14	.8002	.1905		.7621	.8002	1.0004	1.0479
15	.8764	.1905		.8002	.8954	.8097	1.0479
16	.7621	.1905		.7621	.7621	.7122	1.0288
17	.8002	.1905		.8002	.743	.6802	.9526
18	.6859	.1715		.8192	.743	.664	.8764
19	.6097	.1715		.6478	.6859	.6554	.7621
20	.5716	.1905		.0572	.6287	.6554	.6478
21		.1905		.6097	.6478	.5735	.6478
22		.1905		.6097	.6668	.5426	.6287
23		.1905			.6859	.5426	.6097
24	.5426	.5716	.1905	.5243	.5716	.6668	.5243
Max	.8764	.6859	.7621	.852	.8954	1.0004	1.0479
Min	.5426	.1715	.1905	.0572	.4382	.5426	.5243
Avg	.6629	.2667	.261	.6054	.6486	.7302	.7683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 209 / SAVERA IND FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9835	.9145	.1905	.9339	.9145	.9907	.7122
2	.9503	.8002	.1905	.8907	.8002	.9526	.763
3	.9012	.8002	.1905	.9503	.7621	.9526	.7537
4	.852	.8764	.1905	1.0004	.8002	.9907	.7773
5	.8478	.9145	.7621	.9717	.8002	1.0098	.7773
6	.7865	.5716	.9145	1.0174	.8764	.9907	.8478
7	.7373	.9907	.9335	1.004	.9907	.9907	.8478
8	.7209	.5335	.8002	1.0174	.9526	.9907	.8648
9	.7621	.5144	.5716	1.0174	1.1241	.9907	.8478
10	.8383	.381		.9835	1.1431	.8551	1.105
11	.8764	.3048			1.1812	.8097	1.1431
12	.9145	.2286			1.2193	.7811	1.1812
13	.9335	.2096			1.2574	.7773	1.2193
14	.9335	.1905		.7621	1.1812	.7773	1.2574
15	.9335	.1905		.8002	1.0669	.7773	1.2574
16	.9526	.2096		.8192	1.1431	.9717	1.2193
17	1.0288	.1905		1.0098	1.1431	.9878	1.1812
18	.7621	.1715		1.1431	1.1431	.9069	1.1431
19	.8002	.1715		1.0098	1.0669	.852	1.105
20	.8002	.1715		1.0288	1.0288	.8192	1.086
21		.1905		.9907	1.0288	.7545	1.0669
22		.2096		.9907	1.0479	.7127	1.0288
23		.1905			1.0479	.6478	.9907
24	1.0059	.8002	.1905	.9339	.8764	.9907	.6802
Max	1.0288	.9907	.9335	1.1431	1.2574	1.0098	1.2574
Min	.7209	.1715	.1905	.7621	.7621	.6478	.6802
Avg	.8724	.4469	.4934	.9638	1.0248	.8867	.9940

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 201 / 11 KV SHENDURWADA 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641	1.4575	1.406	1.4022	.9431	.7545	.8488
2	1.2178	1.4575	1.406	1.4373	.9431	.8402	.9335
3	1.2894	1.6289	1.406	1.4899	1.0374	.8402	.9335
4	1.3289	1.7147	1.4737	1.5775	1.1317	1.0269	1.0269
5	1.4529	1.7147	1.7375	1.647	1.3203	1.2136	1.1949
6	1.5592	1.7147	1.6289	1.7337	1.4146	1.531	1.531
7	1.6478	1.8099	1.7147	1.6651	1.3203	1.5497	1.4937
8	1.701	1.7147	1.7337	1.5249	1.3392	1.307	1.2696
9	1.2254	.9145	.9431	1.3203	1.4022	1.5775	1.5775
10	1.134	.823	.8488	.9431	1.4899	1.3611	
11	1.0974	.823		.7545	1.4175	1.4175	
12	1.0608	.6401		.7545	1.3432	1.4706	1.4175
13	.823	.6401		.6602	1.3253	1.4706	1.4529
14	.7316	.7316		.6602	1.4175	1.4529	1.4175
15	.7316	.7468	.6602	.6602	1.4706	1.4352	1.382
16	.823	.823	.6979	.7545	1.5238	1.4529	1.3611
17	1.0059	1.0059	.8488	.9431	.8775		
18	1.1888	1.226	.9431	1.1317	.9335	.8402	
19	1.1888	1.1888	1.3014	1.3203	1.2696	1.2883	1.1317
20	1.0974	1.0974	1.3203	1.1883	1.1949	1.3443	1.0374
21	1.0974	.9145	1.226	1.0374	1.0269	1.1016	.9619
22	1.0974	.9145	.9431	1.0374	.8488	.9335	.9619
23	1.0974	.9145	.8488	.9431	.7922	.8402	.8488
24	.6979	1.0059	.9431	.7167	.9431	.7356	.6602
Max	1.701	1.8099	1.7375	1.7337	1.5238	1.5775	1.5775
Min	.6979	.6401	.6602	.6602	.7922	.7356	.6602
Avg	1.1441	1.1509	1.2016	1.1376	1.1969	1.2080	1.1721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 202 / 11 KV SAWAKHEDA 1 SINGLE PHASING  
 PHASHING Feeder KV- 11 /  
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.7147	1.7147	1.5775	.1886	.1886	.1886
2	1.5223	1.7337	1.7147	1.647	.1886	.1886	.1886
3	1.7013	1.7147	1.7147	1.647	.1886	.1886	.1886
4	1.7364	1.7147	1.7147	1.7337	.1886	.1886	.1886
5	1.8073	1.9071	1.7147	1.7337	.2829	.2641	.2263
6	1.8427	1.9719	1.7147	1.7337	.3395	.3395	.3018
7	1.893	2.0576	1.8861	1.7528	.3395	.3772	.3772
8	1.9631	2.1434	1.8861	1.9071	.2829	.3584	.3395
9	.3658	.0943	.2829	.3395	1.7147	1.8313	1.9113
10	.2743	.0943	.2829	.2829	1.8861	1.8778	1.9281
11	.1829	.0943	.2263	.2263	1.9281	1.861	1.9113
12	.1829	.0943	.2263	.1886	1.989	1.8778	2.0199
13	.1829	.0943	.1886	.1886	2.0719	1.9784	1.9845
14	.1829	.1886	.1886	.1886	2.0553	1.989	1.9845
15	.1829	.1886	.1886	.1886	2.0388	2.0056	1.9845
16	.2263	.1886	.1886	.1886	2.0222	1.989	1.9845
17	.2452	.2263	.2263	.1886	.2829	.2263	.1886
18	.2452	.2263	.2829	.2263	.3395	.2641	.1886
19	.2452	.2452	.3395	.2829	.3772	.3395	.2829
20	.2263	.1886	.3395	.2829	.3584	.3018	.2263
21	.1886	.1886	.2829	.2263	.3206	.2641	.1886
22	.1886	.1886	.2263	.1886	.2829	.2263	.1509
23	.1886	.1886	.2263	.1886	.2075	.1886	.1509
24	.3018	.1886	.1886	.2263	.1886	.1886	.1886
Max	1.9631	2.1434	1.8861	1.9071	2.0719	2.0056	2.0199
Min	.1829	.0943	.1886	.1886	.1886	.1886	.1509
Avg	.7296	.7348	.7477	.7223	.8360	.8126	.8031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 203 / 11 KV MAHALAXMIKHEDA(LIS- SINGLE PHASING  
I) 1 Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.1888	1.2803	1.3203	1.3203	1.4937	1.4937
2	1.1694	1.1888	1.5546	1.3296	1.3203	1.587	1.6804
3	1.3203	1.1888	2.3777	1.6975	1.5089	1.6804	2.0538
4	1.5089	2.0119	2.3777	1.8861	1.6975	1.8671	2.2405
5	2.2634	2.3777	2.4691	2.2405	2.2634	2.0538	2.6326
6		2.3594				2.3339	
7						2.5766	
9	2.2805	1.8861	1.9071	1.9071			
10	2.2291	1.5432	2.0805	2.1434			1.7924
11		1.5432	2.0576	2.0805	1.6804		.112
12	1.9719	1.6289	1.9071	1.9938			1.1317
13	1.829	1.6289	1.8204	1.9938		.6602	.8865
14	1.7147	1.7147	1.8204	1.9071	.7545	.6602	.8865
15	1.7147	1.8861	1.8204	1.9071	.8488	.7545	.8865
16	1.8004	1.9719	1.8204	1.8724	1.2323	.8775	
17	1.8861	1.5089	1.3203	1.3203	1.989	1.861	2.2207
18	2.3577	1.3717	1.6975	1.6975	2.13	1.9616	2.2028
19	2.2862	1.9204	2.2405	2.2634	2.2119	2.13	2.2148
20	1.2826	2.1033		2.2405	2.0388	1.9951	2.1262
21	1.3014	2.1948	2.0748	1.8861	1.8945	1.9448	2.0376
22	1.1317	1.1888	1.6975	1.6975	1.7804	1.8442	1.9163
23	1.1317	1.1888	1.5089	1.3203	1.7147	1.7147	1.7909
24	1.358	1.1317	1.226	1.3203	1.3203	1.6817	1.6817
Max	2.3577	2.3777	2.4691	2.2634	2.2634	2.5766	2.6326
Min	1.1317	1.1317	1.226	1.3203	.7545	.6602	.112
Avg	1.6910	1.6694	1.8529	1.8107	1.6298	1.6673	1.6836



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 204 / 11KV MUKTESHWAR HT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0566	.0747	.0747	.056	.056
2	.0566	.0754	.0566	.0747	.0747	.056	.056
3	.0566	.0754	.0566	.0747	.0747	.056	.056
4	.0566	.0732	.0566	.0747	.0747	.056	.056
5	.0566	.0732	.0566	.0747	.0747	.056	.056
6	.0566	.0732	.0566	.0747	.0747	.056	.056
7	.0566	.0754	.0566	.0747	.0747	.056	.0747
8	.0566	.1132	.0747	.0934	.0934	.056	.0747
9	.0754	.0754	.0747	.0934	.0934	.0747	.0747
10	.0754	.0747	.0924	.0934	.0934	.0747	.0747
11	.0754	.0566	.0924	.112	.0924	.1109	.0924
12	.0943	.0566	.1109	.112	.0924	.1109	.0943
13	.0943	.0566	.1109	.112	.0924	.1294	.0754
14	.0943	.0566	.1109	.1109	.0924	.1294	.0943
15	.0943	.0566	.1109	.1109	.0924	.1294	.0754
16	.0754	.0566	.0924	.1109	.0924	.1294	.0754
17	.0754	.0566	.0935	.1132	.1109	.1294	.0943
18	.0754	.0566	.0934	.0934	.1109	.1294	.0754
19	.0566	.0566	.0934	.0934	.0747	.0934	.0754
20	.0566	.0566	.0747	.0754	.0747	.0747	.0754
21	.0566	.0566	.0747	.0747	.0747	.0747	.0754
22	.0566	.0566	.0747	.0747	.0747	.0747	.0754
23	.0566	.0566	.0747	.0747	.056	.056	.0754
24	.0566	.0566	.0566	.0747	.0747	.0747	.056
Max	.0943	.1132	.1109	.1132	.1109	.1294	.0943
Min	.0566	.0566	.0566	.0747	.056	.056	.056
Avg	.0676	.0657	.0793	.0894	.0837	.0852	.0727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 205 / 11KV LIS II 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.1886	.1132	.1509	.132	.0943
2	.0943	.1132	.1886	.1132	.1509	.132	.0943
3	.1509	.112	.1886	.1509	.1886	.132	.0943
4	.1886	.1132	.3018	.1886	.2263	.1698	.1698
5	.2829	.1509	.3206	.2829	.3395	.1886	.2075
6	.3206	.1509	.3395	.2829	.415	.2452	.2829
7	.3772	.1829	.3658	.2829	.3772	.3772	.3584
8	.3772	.1886	.2829	.3018	.3772	.3772	.3772
9	.2378	1.8861	2.4006	2.3926	.2829	.3206	.3584
10	2.0576	1.8861	2.4587	2.3739	.1886	.2263	.2263
11	1.8519	1.9719	2.4587	2.3739	.1509	.0943	.1132
12	1.869	1.9719	2.4348	2.3739	.0943	.0943	.0943
13	1.869	1.9719	2.4348	2.3148	.0943	.0943	.0943
14	1.8378	1.9719	2.4348	2.3405	.0943	.0943	.0943
15	1.8004	1.8861	2.4619	2.2539	.0943	.0943	.0943
16	1.7661	1.8861	2.4272	2.1672	.0943	.0943	
17	.1886	.2263	.1886	.1886	2.2283	2.1464	2.392
18	.2075	.2263	.2263	.1886	2.3158	2.2672	2.4451
19	.2263	.1886	.3018	.2829	2.2447	2.2672	2.3034
20	.1886	.1886	.3018	.3018	2.1464	2.2283	2.2148
21	.1886	.1886	.2829	.2829	2.1216	2.1051	2.1262
22	.1886	.1886	.1886	.2263	2.0719	1.989	2.073
23	.1886	.1886	.1509	.1886	2.0719	1.9951	2.0376
24	.1132	.1886	.1886	.1132	.1509	2.0388	1.9784
Max	2.0576	1.9719	2.4619	2.3926	2.3158	2.2672	2.4451
Min	.0943	.112	.1509	.1132	.0943	.0943	.0943
Avg	.6944	.7559	.9799	.92	.7780	.8293	.8837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 206 / 11KV GURUDHANORA 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.5658	.3772	.2829	1.3289	1.0498	1.086
2		.5487	.3772	.2829	1.3289	1.086	1.1765
3	.3772	.5658	.3772	.2829	1.4022	1.086	1.2178
4	.5658	.823	.5658	.3772	1.4899	1.1765	1.2357
5	.7545	.9145	.8488	.5658	1.5604	1.1765	1.2536
6	.9242	.9145	.9431	.8488	1.5604	1.2894	1.3073
7	.8676	1.0059	1.0059	.8488	1.5604	1.7147	1.6991
8	.8865	.9145	.7545	.6602	1.5604	1.6126	1.5238
9	.823	.6401	.6602	.4715	.3772	.6602	.5281
10	.7316	.4572	.3772	.3584	.3018	.3018	.3018
11	.6401	.4572	.2829	.2829	.2641	.2263	.2263
12	.5487	.4572	.2263	.1886	.2263	.1698	.1886
13	.5487	.3658	.1886	.1886	.2263	.1509	.1698
14	.5544	.3658		.1886	.2263	.0943	.1698
15	.4572	.4572	.1886	.1886	.1886	.0943	.132
16	.4715	.5487	.1886	.1886	.1886	.132	.0943
17	1.8004	1.8861	1.5604	1.5604	.2641	.1698	.2263
18	1.8861	1.8004	1.647	1.7337	.3772	.3395	.3206
19	1.8861	1.7147	1.7337	1.647	.6413	.7545	.3772
20	1.6289	1.7147	1.7337	1.4706	.5658	.6413	.3395
21	1.4575	1.7147	1.5604	1.4022	.3961	.4527	.2829
22	1.4883	1.829	1.5775	1.4175	.3395	.3395	.2641
23	1.4232	1.7375	1.4022	1.3289	.3018	.3018	.2263
24	1.3032	1.4232	1.6651	1.3575	1.3289	.2829	.2641
Max	1.8861	1.8861	1.7337	1.7337	1.5604	1.7147	1.6991
Min	.2263	.3658	.1886	.1886	.1886	.0943	.0943
Avg	.9674	.9926	.8801	.7551	.7502	.6376	.6088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 207 / 11 KV DHAMORI (BK) SINGLE PHASING  
 1PHASING Feeder KV- 11 /  
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.1886	.1886	1.3289	1.3432	1.3432
2	.0943	.1829	.1886	.1886	1.3289	1.4175	1.3432
3	.0943	.1829	.1886	.1886	1.3289	1.5061	1.3432
4	.1132	.1867	.2263	.2263	1.3289	1.5775	1.4175
5	.1132	.1829	.2641	.2829	1.4022	1.647	1.5592
6	.1132	.2195	.2829	.2829	1.4899	1.6817	1.5769
7	.1132	.2378	.2452	.2829	1.5604	1.7804	1.6817
8	.1132	.1886	.1886	.2829	1.5604	1.7126	1.7295
9	.1132	.1886	.1509	.2263	.2263	.1886	.2075
10	.0943	.0943	.1509	.1886	.1509	.1509	
11	.0943	.0943	.1509	.1509		.132	
12	.0943	.0943	.1509	.1509	.1509	.0943	.1132
13	.0943	.0943	.1509	.1509	.1509	.0943	.1132
14	.0943	.0943	.1509	.1509	.1509	.0943	.0943
15	.0943	.0943	.1509	.1509	.1509	.0943	.0943
16	.0943	.0943	.1509	.1509	.1509	.1132	.1132
17	2.0748	1.8861	1.9071	1.7337	.1509	.132	
18	1.9719	1.8861	1.9071	1.9092	.1698	.3206	
19	1.9719	1.9204	1.9719	1.9719	.2263	.2263	.2829
20	1.7147	1.7375	1.9071	1.8004	.2075	.2263	.2263
21	1.6289	1.5947	1.7337	1.7337	.2075	.2263	.2075
22	1.5947	1.6827	1.5775	1.5775	.1698	.2075	.2075
23	1.7353		1.5775	1.6651	.1509	.1886	.1886
24	1.6301	1.6126	1.5775	1.5775	1.4175	.132	.1698
Max	2.0748	1.9204	1.9719	1.9719	1.5604	1.7804	1.7295
Min	.0943	.0943	.1509	.1509	.1509	.0943	.0943
Avg	.6644	.6614	.7141	.7172	.6591	.6370	.7006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 201 / 11 KV SAWANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7621	.6859	.6668		.7621
2			.8573	.7621	.8573		.8383
3			.9526	.8383	.8573		.8002
4			1.0479	.9145	.9526		.8764
5			1.1431	.9526	1.0479		1.1431
6			1.2384	1.1431	1.1431		1.2574
7			1.3336	.9526	1.1431		1.3717
8			1.2765	1.1812	1.1431		1.3336
9			1.1431	1.0288	1.0479		1.0669
10	1.1431		.9526	.8383	.9526		.8573
11	1.1812		.8764	.8383	.9526		1.105
12	1.1241		.7621		1.1431	.6668	.8573
13	.9717		.7621	1.1431	1.1431	.8573	.8573
14	1.0098	1.1431	.6859		1.1431	.8573	.2667
15	.9526	1.1431	.6859		.9526	.9526	1.2765
16	.9717	.8573	.7621	.9526	.9526		1.2574
17	.8573	1.2384	.9526	.8573	1.0479	.8478	1.2193
18		1.2193	1.0669	.8573	1.0479	.9496	1.086
19		1.1431	1.2574	.9526	.9526	1.0669	.8573
20		1.0479	1.3336	.9526	.9526	1.1431	1.0479
21		.9526	1.2574	1.0479	.9526	.9526	1.1431
22		.8954	1.2574	.9526	.8573	.8764	.9526
23		.7621	.6097	.9526	.7621	.8764	.8573
24	.6668	.9526	.9526	.5975	.7621		.7621
Max	1.1812	1.2384	1.3336	1.1812	1.1431	1.1431	1.3717
Min	.6668	.7621	.6097	.5975	.6668	.6668	.2667
Avg	.9865	1.0323	.9971	.9239	.9764	.9133	.9939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 202 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.7621	.7621	.7621	.6668	.7468
2		.7621	.8573	.7621	.7621	.7621	.7468
3		.8573	.9526	.8002	.8573	.7621	.7316
4		.9526	1.0479	.8383	.9526	.8573	.8048
5		1.0479	1.1431	.8764	1.0479	.9526	.8688
6		1.086	1.2384	.9907	1.1431	1.0479	.905
7		1.2384	1.2955	.9526	1.1431	.9145	1.0136
8		1.105	1.1812	.9907	1.1431	.9145	1.086
9		1.0288	1.105	.9526	1.0479	.9145	1.0136
10	.9907	1.0098	.905	.8764	.9526	.9145	1.0669
11	.9907	1.105	.905	1.105	.9526		1.0669
12	.8002	1.1431	.905	.8573		.8326	.8764
13	.9907	.8573	.905	.7621	.9526	.8326	.9526
14	.9907	.8002	.905		.8573	.8326	
15	.9526	.8764	.905	.9526	.7621	.7964	1.0669
16	1.0288	1.1431	.9412	.9145	.7621	.8326	.9145
17	1.0669	1.1812	1.0136	.8002	.8573	.905	1.0669
18	.9335	.8002	1.086	.8573	.9526	.9145	1.1431
19	1.2193	1.2193	1.1946	.7621	.9526	1.0974	1.2384
20		1.1431	1.267	.7621	1.0479	1.134	1.0479
21	1.0669	1.0669	1.1706	.6668	.9526	.9877	1.086
22	.9717	.9526	.9335	.6668	.8573	.9877	1.0479
23	.9069	.8764	.8215	.6668	.7621	.8048	.8764
24		.7049	.7621	.5716	.6668	.6668	.7468
Max	1.2193	1.2384	1.2955	1.105	1.1431	1.134	1.2384
Min	.8002	.6668	.7621	.5716	.6668	.6668	.7316
Avg	.9930	.9844	1.0085	.8325	.9195	.8840	.9615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 203 / 11 KV RAIPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.5716	.381	.381	.4954	.4572
2		.5335	.7621	.4191	.381	.5716	.4572
3		.5716	.8573	.4572	.4763	.6859	.4954
4		.6668	.9526	.4954	.5716	.6478	.4954
5		.724	1.0479	.5335	.6668	.6859	.6097
6		.7621	1.1431	.5716	.5716	.7621	.7621
7		.8002	1.1812	.7621	.5716	.7621	.7621
8		1.1812	1.105	.8002	.5716	.4954	.6859
9		.6097	.8764	.2286	.5716	.5716	.5716
10	.381	.381	.2667	.2667	.5716	.5716	.5335
11	.2096	.4572	.1905	.3048	.6668	.5335	.5716
12	.2858	.381	.1524	.1905	.6668	.4572	.5716
13	.2667	.381	.1524	.2667	.6668	.6584	.4763
14	.4763	.3048	.1524	.1905	.6668	.6554	.5716
15	.2667	.4954	.1524	.2667	.6668	.4915	.381
16	.3048	.3048	.1524	.1524	.5716	.5898	.4572
17	.3429	.3048	.1905	.1524	.5716	.4954	.6097
18	.4001	.3048	.2286	.2858	.5716	.439	.6478
19	.5716	.5335	.4954	.1905	.5716	.6097	.6097
20	.6097	.6478		.4763	.6668	.6859	.6478
21	.4954	.5335	.4954	.381	.6668	.5335	.5525
22	.4763	.4572	.4954	.381	.5716	.4954	.5144
23	.4382	.4382	.4191	.381	.5716	.4954	.4954
24		.4572	.4763	.381	.381	.4954	.4954
Max	.6097	1.1812	1.1812	.8002	.6668	.7621	.7621
Min	.2096	.3048	.1524	.1524	.381	.439	.381
Avg	.3947	.5295	.5442	.3715	.5755	.5785	.5597

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 204 / 11 KV MALIWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.5716	.6097	.5716		3.4168
2		.6668	.6668	.6478	.6668		.3361
3		.7621	.7621	.6859	.7621		.3658
4		1.0479	.9526	.8764	.8573		.4024
5		1.2193	1.1431	1.2574	.9526		.4115
6		.7621	1.3336	1.5242	1.0479		.5243
7		1.4098	1.4861	1.2574	1.1431		.6554
8		1.2955	1.2574	.9526	1.1431		.852
9		.9526	.9526	.9145	.9526		.5898
10	.6287	.8764	.5716	.6097	.9526		.4191
11	.4763	.9526	.421	.6722	.5716		.3429
12	.4572	.9907	.3841	.6097	.5716	.5716	.2477
13	.4191	.4763	.3887	.4763	.5716	.5716	.2858
14	.4763	.381	.3239	.6097	.5716	.4954	.3429
15	.4572	.8002	.3887	.381	.5716	.3772	.2858
16	.4954	.5716	.421	.5716	.5716	.381	.3048
17	.5335	.5716	.3932	.7621	.6668	.4572	.381
18	.4191	.381	.3277	.7621	.6668	.5716	.6668
19	1.0479	.9145	.8383	.7621	.6668	.7621	1.1431
20	1.1431	.9526	.7621	.6668	.6668	.9526	1.0669
21	.7811	.8002	.6859	.6668	.7621	.8383	.7811
22	.6668	.7621	.7621	.5716	6.8016	.724	.6859
23	.5906	.724	.6097	.5716	.5716	.6097	.6478
24		.4763	.5716	.5716	.5716		.3734
Max	1.1431	1.4098	1.4861	1.5242	6.8016	.9526	3.4168
Min	.4191	.381	.3239	.381	.5716	.3772	.2477
Avg	.6137	.8018	.7073	.7496	.9939	.6094	.6470



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 206 / 11 kv GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572		.0572		.0381		.0572
2	.0572		.0572	.0572	.0381		.0572
3			.0572	.0572	.0572		.0572
4	.0572		.0381	.0762	.0572		.0572
5	.0572		.0572	.0762	.0572		.0572
6	.0572		.0572	.0762	.0572		.0572
7	.0762		.0381	.0762	.0572		.0572
8	.0762		.0762	.0762	.0572		.0572
9			.0381	.0762	.0572		.0572
10	.0762	.0572	.0572	.0572	.0572		.0572
11	.0572	.0572	.0572	.0572	.0572		.0572
12	.0572	.0762	.0572	.0762	.0381	.0572	.0572
13	.0762	.0762	.0572	.0572	.0381	.0572	.0572
14	.0762	.0762	.0572	.0762	.0381		.0572
15	.0572	.0762	.0572	.0762	.0381	.0572	.0572
16	.0762	.0762	.0572	.0762	.0381	.0572	.0572
17		.0762	.0572	.0762	.0381	.0572	.0572
18	.0572	.0762	.0572	.0572	.0381	.0572	.0572
19		.0572	.0572	.0572	.0572	.0572	.0572
20		.0572	.0572	.0572	.0572	.0572	.0572
21		.0572	.0572	.0572	.0572	.0572	.0572
22		.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0762	.0572
24	.0191		.0381	.0572	.0381		.0572
Max	.0762	.0762	.0762	.0762	.0572	.0762	.0572
Min	.0191	.0572	.0381	.0572	.0381	.0572	.0572
Avg	.0617	.0667	.0548	.0663	.0492	.0589	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 208 / SULTANABAD AG SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.4763	.3429	.381		.381
2		.5144	.5335	.381	.4763		.381
3		.5716	.5716	.4191	.4763		.4191
4		.6097	.6668	.4572	.5716		.4572
5		.6668	.7049	.381	.6668		.4954
6		.7621	.7621	.8002	.7621		.5716
7		.8002	.7811	.8002	.7621		.4954
8		.8192	.6668	.8002	.6668		.5335
9		.6668	.5716	.6478	.4763		.381
10	.3048	.3048	.3048	.6478	.5716		.3429
11	.2096	.2477	.1524	.2477	.6668		.6668
12	.2096	.2096	.1524	.0953	.6668	.5571	.6097
13	.1715	.1524	.1524	.1143	.5716	.5087	.6668
14	.1715	.1715	.1143	.1334	.6668	.4915	.6668
15	.1715	.1905	.1143	.1334	.5716	.4239	.4954
16	.2096	.1715	.1524	.1524	.5716	.4588	.6668
17	.2667	.1905	.2667	.2858	.6668	.4801	.5144
18	.362	.2858	.381	.381	.4763	.5144	.5525
19	.4954	.4954	.381	.381		.5335	.3239
20	.5716	.5716	.4572	.381		.4954	.4763
21	.3429	.362	.3048	.4763		.3429	.5144
22	.2667	.3048	.3048	.381		.3429	.2858
23	.2667	.2667	.2667	.381		.3429	.2858
24	.4763	.362	.3429	.6097	.381		.381
Max	.5716	.8192	.7811	.8002	.7621	.5571	.6668
Min	.1715	.1524	.1143	.0953	.381	.3429	.2858
Avg	.2998	.4239	.3993	.4096	.5816	.4577	.4819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 201 / 11 KV SILLEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.4477	.7316	.7316
2	.0953	.0953	.0953	.0953	.4477	.7316	.7973
3	.0953	.0953	.0953	.0953	.5258	.8954	.8764
4	.0953	.0953	.0953	.0953	.6935	1.0745	1.0517
5	.0953	.1905	.0953	.0953	.9431	1.0745	1.1145
6	.0953	.1905	.0953	.0953	1.1869	1.2269	1.3146
7	.0953	.1905	.0953	.0953	1.3413	1.286	1.3717
8	.0953	.0953	.0953	.0953	1.3565	1.5223	1.6108
9	.1429	.0953	.0953	.0476	.6935	.985	1.3289
10	.0476	.0476	.0953	.0476	.0476	.0476	.0476
11	1.2536	1.0745	1.0745	1.2536	.0476	.0476	.0476
12	1.1269	1.2536	1.0631	1.0402	.0476	.0476	.0476
13	1.0174	1.1641	1.0517	.9326	.0476	.0476	.0476
14	.9221	1.0745	.9431	.8383	.0476	.0476	.0476
15	.9945	1.0745	.9221	.8383	.0476	.0476	.0476
16	1.1736	1.0745	.8288	1.1022	.0476	.0476	.0476
17	1.1736	1.0745	1.0059	1.1269	.0476	.0476	.0476
18	1.0402	.985	.6935	1.0402	.0476	.0476	.0476
19	.0953	.0476	.0476	.0476	.0476	.0476	.0476
20	.0953	.0953	.0953	.0476	.0476	.0476	.0476
21	.0953	.0953	.0953	.0476	.0476	.0476	.0476
22	.0953	.0953	.0953	.0476	.0476	.0476	.0476
23	.1905	.0953	.0953	.0476	.0476	.0476	.0476
24	.0953	.0953	.0953	.0953	.4477	.7316	.7316
Max	1.2536	1.2536	1.0745	1.2536	1.3565	1.5223	1.6108
Min	.0476	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.4301	.4371	.3775	.3901	.3646	.4552	.4831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 202 / 11KV MALUNJA (BK) AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3432	1.2403		1.0631	.1905	.0953	.0953
2	1.3432	1.2403	1.2536	1.0631	.1905	.0953	.0953
3	1.4327	1.3146	1.3432	1.2136	.1905	.0953	.0953
4	1.4899	1.5432	1.4899	1.3717	.1905	.0953	.1905
5	1.6289	1.8107	1.7147	1.6766	.1905	.0953	.0953
6	1.8442	1.8233	1.8442	1.8233	.2858	.1429	.1429
7	2.2634	2.2043	2.1795	2.1195	.2858	.1429	.1429
8	2.431	2.5149	2.0119	2.3405	.2858	.1429	.1429
9	.1429	2.0576	1.9281	1.8004	.1905	.1429	.1429
10	.0953	.1905	.0953	.1905	.1905	.0953	.0953
11	.1905	.0953	.1905	.1905	2.1434	1.2003	2.0957
12	.1905	.0953	.1905	.0953	2.1795	1.5604	2.2634
13	.1905		.1905	.0953	2.0957		2.0119
14	.1905	.0476	.0953	.0953	2.0119	1.8652	1.8442
15	.1905	.0476	.0953	.0953	2.0119	1.8404	1.8442
16	.1905	.0476	.0953	.0953	2.0119	.9526	1.9281
17	.1905	.0476	.0953	.0953	2.0119	1.5261	1.9281
18	.2858	.0953	.1905	.0953	1.6766	1.3717	1.6766
19	.2858	.0953	.2858	.2858	.1429	.0953	.1429
20	.1905	.1429	.2858	.2858	.1429	.0953	.1429
21	.1905	.0953	.2858	.2858	.1429	.0953	.1429
22	.1905	.0953	.1905	.1905	.0953	.0953	.0953
23	.1905	.0953	.1905	.1905	.0953	.0953	.0953
24	1.3432	1.2403	1.2536	1.0631	.1905	.0953	.0953
Max	2.431	2.5149	2.1795	2.3405	2.1795	1.8652	2.2634
Min	.0953	.0476	.0953	.0953	.0953	.0953	.0953
Avg	.7510	.7905	.7607	.7426	.7976	.5231	.7311

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 203 / 11 KV GAJGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3715	.4287	.3715	.3429	.0953	.0953	.0953
2	.3715	.4287	.3715	.3429	.0953	.0953	.0953
3	.3715	.503	.3715	.4191	.0953	.0953	.0953
4	.4572	.503	.5335	.4191	.0953	.0953	.0953
5	.5468	.4973	.6249	.4973	.0953	.1905	.0953
6	.7202	.5668	.6401	.6554	.1905	.1905	.1905
7	.8002	.6325	.7202	.7287	.1905	.1905	.1905
8	.8002	.7811	.8802	.7287	.1905	.1905	.1905
9	.0953	.7287	.6401	.5468	.0953	.1905	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.5601	.5335	.5468
12	.0953	.0953	.0953	.0953	.5601	.6097	.6401
13	.0953	.0953	.0953	.0953	.5601	.5401	.5601
14	.0953	.0953	.0953	.0953	.5601	.4458	.5601
15	.0953	.0953	.0953	.0953	.5601	.4515	.5601
16	.0953	.0953	.0953	.0953	.5601	.3763	.5601
17	.0953	.0953	.0953	.0953	.6401	.463	
18	.1905	.0953	.0953	.0953	.6401	.5335	.5601
19	.1905	.1905	.0953	.0953	.0953	.0953	.0953
20	.1905	.1905	.1905	.0953	.0953	.0953	.0953
21	.0953	.0953	.1905	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.3715	.4334	.3715	.3467	.0953	.0953	.0953
Max	.8002	.7811	.8802	.7287	.6401	.6097	.6401
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.2719	.2928	.2937	.2651	.2688	.2481	.2521

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 204 / 11 KV KATEPIMPALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7011	.6097	.7164	.2858	.2858	.1905
2	.6859	.7011	.6097	.7164	.2858	.2858	.1905
3	.7621	.8573	.6859	.8764	.2858	.2858	.1905
4	.9374	1.0059	.7811	1.0288	.2858	.2858	.2858
5	1.0402	1.1603	1.0402	1.1736	.2858	.2858	.1905
6	1.2003	1.326	1.3108	1.4918	.381	.381	.2858
7	1.8023	1.6385	1.6385	1.7814	.381	.381	.381
8	1.8842	1.8623	1.7204	1.7814	.381	.381	.381
9	.2858	1.326	1.3108	1.326	.2858	.1905	.2858
10	.2858	.1905	.1905	.1905	.2858	.1905	.0953
11	.1905	.1905	.1905	.1905	1.7204	.5335	.4687
12	.1905	.1905	.1905	.1905	1.6385	.7621	
13	.1905	.1905	.1905	.1905	1.6327		1.2289
14	.1905	.1905	.1905	.1905	1.3927	.9145	1.3927
15	.1905	.1905	.1905	.1905	1.4746	.9907	1.3108
16	.2858	.1905	.1905	.1905	1.4746	1.0536	1.3108
17	.2858	.1905	.1905	.1905	1.5565	.9907	1.3927
18	.2858	.1905	.1905	.1905	1.2289	.9145	1.1469
19	.2858	.2858	.2858	.2858	.2858	.1905	.2858
20	.2858	.2858	.2858	.2858	.2858	.2858	.2858
21	.1905	.2858	.2858	.2858	.2858	.2858	.2858
22	.1905	.1905	.1905	.2858	.2858	.1905	.2858
23	.1905	.1905	.1905	.2858	.2858	.1905	.2858
24	.9288	.6935	.6097	.7164	.2858	.2858	.1905
Max	1.8842	1.8623	1.7204	1.7814	1.7204	1.0536	1.3927
Min	.1905	.1905	.1905	.1905	.2858	.1905	.0953
Avg	.5605	.5927	.5529	.6147	.7074	.4583	.5369

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 205 / 11 KV SHILLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5316	.5144	.5316	.5316	.5144	.543
2	.5144	.5316	.5144	.5316	.5316	.5144	.5316
3	.7011	.7164	.7011	.8059	.8059	.7011	.7802
4	1.0745	1.086	1.0745	1.1088	1.086	1.0745	.9431
5	1.4937	1.386	1.4937	1.386	1.386	1.4937	1.2003
6	1.8861	1.8861	1.8861	1.7918	1.7918	1.7918	1.3717
7	1.7918	1.7918	1.7918	1.7918	1.7918	1.8861	1.6108
8	1.587	1.4937	1.4937	1.4937	1.4937	1.587	1.2041
9	1.1888	1.2012	.8049	1.2012	1.2012	1.1888	1.0974
10	.985	.9955	.8059	.905	.8145	.763	.8059
11	.5316	.8059	.443	.6268	.6135	.6335	.6135
12	.5316	.5258	.443	.5316	.4287	.5201	.4287
13	.5316	.4287	.443	.443	.4287	.3506	.4287
14	.5316	.4287	.443	.443	.4287	.3506	.4287
15	.5316	.4287	.443	.443	.4287	.443	.4287
16	.6268	.4287	.5316	.5316	.4287	.5258	.4287
17	.6268	.5258	.6268	.6268	.5258	.5144	.5258
18	.9955	.8413	.7164	.7164	.6401	.5144	.7164
19	1.2936	1.2136	1.2012	1.2012	1.2136	.6135	1.307
20	.9955	1.2136	1.1088	1.1088	1.0974	.7011	1.1888
21	.8145	1.0059	.7164	.905	.8059	.8859	.8059
22	.5316	.8059	.6268	.7164	.7164	.7316	.7164
23	.5316	.6135	.5316	.6268	.6135	.6335	.6135
24	.5144	.5316	.5144	.5316	.5316	.5144	.5487
Max	1.8861	1.8861	1.8861	1.7918	1.7918	1.8861	1.6108
Min	.5144	.4287	.443	.443	.4287	.3506	.4287
Avg	.8885	.8924	.8279	.8750	.8473	.8103	.8028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 206 / 11 KV Shahapur AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1429	.1905	.1429	.1905	.3582	.3658	.362
2	.1429	.1905	.1429	.1905	.3582	.3658	.5316
3	.1429	.1905	.1429	.1905	.4382	.4572	.7011
4	.1429	.1905	.1429	.1905	.4382	.5373	.7802
5	.1429	.2858	.1429	.2858	.5144	.6135	.8573
6	.1905	.381	.1905	.2858	.5144	.7011	.9326
7	.2382	.381	.2667	.381	.5868	.7716	1.0174
8	.1905	.381	.1905	.2858	.663	.8059	1.0174
9	.1429	.1905	.1905	.1905	.5258	.8059	.985
10	.0953	.1905	.1715	.1905	.1905	.0953	.0476
11	.6201	.8059	.5935	.6935	.0476	.0953	.0476
12	.6135	.8059	.5801	.5868	.0476	.0476	.0476
13	.5316	.8059	.4858	.4973	.0476	.0476	.0476
14	.5316	.7164	.4858	.5258	.0476	.0476	.0476
15	.5258	.7164	.4858	.5258	.0476	.0476	.0476
16	.5316	.8059	.4858	.6068	.0476	.0476	.0476
17	.6068	.8059	.5868	.6068	.0476	.0953	.0476
18	.5258	.8059	.7011	.5316	.0476	.0953	.0476
19	.2858	.1429	.2858	.2858	.1715	.0953	.1429
20	.2858	.1429	.2858	.2858	.1429	.0953	.1429
21	.2858	.1429	.2858	.2858	.0953	.0953	.0953
22	.1905	.1429	.1905	.2858	.0953	.0953	.0953
23	.1905	.1429	.1905	.1905	.0953	.0953	.0953
24	.1429	.1905	.1429	.1905	.3582	.3658	.3696
Max	.6201	.8059	.7011	.6935	.663	.8059	1.0174
Min	.0953	.1429	.1429	.1905	.0476	.0476	.0476
Avg	.31	.4060	.3129	.3533	.2470	.2869	.3564



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 207 / 11 KV Wadali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1905	.0953	.1905	.443	.4572	.4525
2	.0953	.1905	.0953	.1905	.443	.4572	.543
3	.0953	.1905	.0953	.1905	.6135	.6268	.7011
4	.0953	.1905	.0953	.1905	.6935	.8059	.9431
5	.0953	.1905	.0953	.1905	.9326	.964	1.2003
6	.1429	.1905	.1429	.2858	1.0898	1.1736	1.2717
7	.1429	.1905	.1429	.2858	1.2431	1.3717	1.3565
8	.1429	.1905	.0953	.2858	1.2431	1.5432	1.4575
9	.0476	.1905	.0476	.1905	1.0517	1.2003	1.1641
10	.0476	.0953	.0476	.0953	.0953	.0953	.0476
11	1.3146		1.1022	1.0898	.0476	.0953	.0476
12	1.387	1.4575	1.0059	1.0898	.0476		
13	1.2269	1.3717	1.0774	1.0774	.0476		
14	1.1517	1.286	1.0526	1.0402	.0476	.0953	.0476
15	1.0517	1.2003	.9717	1.0517	.0476	.0476	.0476
16	1.1517	1.2003	.9945	1.1269	.0476	.0476	.0476
17	1.1269	1.2003	1.0059	1.1393	.0476	.0476	.0476
18	.8764	1.1393	1.0517	.964	.0476	.0476	.0476
19	.1905	.0953	.0953	.1905	.0953	.0476	.0953
20	.1905	.0953	.1905	.1905	.0953	.0476	.0953
21	.1905	.0953	.1905	.1905	.0476	.0953	.0476
22	.1905	.0953	.0953	.0953	.0476	.0476	.0476
23	.1905	.0953	.1905	.0953	.0476	.0476	.0476
24	.0953	.1905	.0953	.1905	.443	.4572	.4572
Max	1.387	1.4575	1.1022	1.1393	1.2431	1.5432	1.4575
Min	.0476	.0953	.0476	.0953	.0476	.0476	.0476
Avg	.4723	.4927	.4197	.4845	.3752	.4463	.4643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 208 / 11 KV Katepimpalgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /  
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2658	.2572	.2658	.2658	.2572	.2743
2	.2572	.2658	.2572	.2658	.2658	.2572	.3582
3	.3506	.3582	.3429	.3582	.3582	.3506	.3506
4	.5373	.543	.5373	.543	.543	.5487	.443
5	.7316	.6401	.8402	.7392	.7392	.7316	.5316
6	.9335	.8402	.9335	.8402	.8402	.9335	.6068
7	.9335	.8402	.8402	.8402	.8402	.9335	.6859
8	.7468	.7392	.7316	.7468	.6468	.7468	.503
9	.6401	.6468	.6268	.543	.543	.5487	.5373
10	.4477	.543	.4382	.4525	.2686	.3429	.2629
11	.3582	.3506	.2658	.3582	.2629	.3544	.1715
12	.2658	.2572	.2658	.2658	.1715		
13	.2658	.2572	.1753	.1753	.1715		
14	.2658	.2572	.1753	.1753	.1715	.3544	.2572
15	.2658	.2572	.1753	.1753	.1715	.3506	.2572
16	.3582	.3429	.2658	.2658	.1715	.2629	.2572
17	.3582	.3506	.2658	.2658	.2629	.2629	.2629
18	.6468	.4477	.3582	.4525	.3658	.3506	.3582
19	.6468	.7468	.6468	.5544	.7468	.3429	.7468
20	.543	.6535	.543	.543	.6401	.3658	.6401
21	.4477	.5487	.4525	.4525	.4477	.3658	.4477
22	.3582	.3582	.3582	.4525	.3506	.3544	.3506
23	.2658	.3506	.2658	.3582	.2572	.2743	.3429
24	.2877	.2658	.2572	.2658	.2658	.2572	.2743
Max	.9335	.8402	.9335	.8402	.8402	.9335	.7468
Min	.2572	.2572	.1753	.1753	.1715	.2572	.1715
Avg	.4654	.4636	.4282	.4315	.4070	.4340	.4055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 201 / 11KV JAMGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6244	2.4863	2.4863	2.332	1.531	1.7177	1.419
2	2.5377	2.572	2.6063	2.4691	1.7924	1.9044	1.4937
3	2.6578	2.6406	2.6749	2.5377		1.7177	1.531
4	2.7778	2.7778	2.7435	2.572		1.6057	1.5684
5	2.9492	2.8292	2.7778	2.6063		1.643	
6	3.035	2.915	2.8292	2.6749		1.6804	
7	3.2065	3.0864	3.0769	2.8292			
8	3.2065	3.0521	2.915	2.8292			
9	3.2065	3.1722	2.7435	2.6749			
10	1.0269	1.5947	.9335	1.0456	1.3256	1.2136	1.2323
11					2.7949	2.8121	2.7778
12					2.9321	2.7435	2.915
13					2.8807	2.7435	2.9835
14					2.7606	2.692	2.8807
15					2.9664	2.8807	2.8121
16					2.8292	2.8464	2.9664
17				.9709	3.0007	3.3008	3.1379
18		.8962		1.363	3.035	2.9835	3.2236
19	2.1285	1.8671		2.0538	1.8519	1.5947	2.1691
20	1.7177	1.7177	2.0911	1.9791	1.749	1.7661	1.7147
21	1.6057	1.5497	1.6057	1.8298	1.7147	1.7147	1.1203
22	1.4937	1.4937	1.5123	1.6617	1.5432	1.5947	1.5775
23	1.363	1.3443	1.4003	1.4563	1.5261	1.4918	1.4746
24	2.4863	2.4348	2.4863	2.2634	1.4563	1.6617	1.6617
Max	3.2065	3.1722	3.0769	2.8292	3.035	3.3008	3.2236
Min	1.0269	.8962	.9335	.9709	1.3256	1.2136	1.1203
Avg	2.3765	2.2606	2.3255	2.1194	2.2170	2.1099	2.1400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 202 / 11KV L.I.S. FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7633	2.452	2.2462	2.3148	.2241	.2241	.1867
2	2.838	2.4691	2.332	2.332	.2427	.8962	.1867
3	2.7511	2.5377	2.3663	2.3663	.2427	.2987	.1867
4	2.6063	2.6063	2.4691	2.3663	.3361	.3361	.168
5	2.7873	2.6406	2.5034	2.3834	.3734	.3361	.2241
6	2.6578	2.6749	2.7633	2.6139	.4294	.3361	.2987
7	2.6749	2.7092	2.8292	2.572	.4294	.3547	.3361
8	2.8121	3.2065	2.9492	2.7778	.4294	.3547	.3734
9	2.5463	3.2442	2.8292	2.6406	.3921	.3547	.3547
10	.3944	.4115	.2427	.3734	.3174	.2987	
11	.3944	.3395	.2614	.3921	3.1722	3.2236	3.3779
12	.2829	.2401	.3174	.3734	3.0693	3.4637	3.4637
13	.2915	.2401	.2801	.3734	3.275	3.4979	3.4979
14	.3772	.2829	.3174	.3361	3.3093	3.3436	3.5151
15	.3772	.2743	.3361	.3734	3.2922	3.5322	3.6866
16	.3601	.3086	.3921	.4294	3.2579	3.4637	3.6008
17	.3772	.4481	.3547	.4668	3.4465	3.3779	3.4979
18	.3772	.4481	.3547	.4854	3.3951	3.155	3.4637
19	.3601	.4668	.4115	.4481	.3772	.3086	.3086
20	.2401	.4668	.4108	.4481	.3772	.3086	.3429
21	.2058	.4481	.2401	.3734	.3086	.2401	.3086
22	.2058	.3174	.2427	.2801	.2401	.2401	.2058
23	.2263	.3174	.2241	.2241	.2229	.2401	.16
24	2.4006	2.3663	2.2462	2.3148	.2241	.1886	.2427
Max	2.838	3.2442	2.9492	2.7778	3.4465	3.5322	3.6866
Min	.2058	.2401	.2241	.2241	.2229	.1886	.16
Avg	1.3045	1.3299	1.2467	1.2525	1.3077	1.3489	1.3908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 203 / 11KV NEVARGAON 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5788	.5601	.5788	2.1472	1.8861	1.8858
2	.6722	.6161	.5975	.6161	2.1658	1.8519	1.9044
3	.7095	.6722	.6722	.7095	2.1472	1.8861	1.9791
4	.8962	.8589	.7842	.7842	2.2405	1.9204	1.8484
5	.9709	1.0082	.8962	.8962	2.6513	1.989	2.0911
6	1.1016	1.1203	1.0082	1.0829	2.8193	2.0233	2.2032
7		1.2136	1.1763	1.1949	3.0247	2.1434	2.2965
8		1.046	.9896	1.0269	2.838	2.1605	2.7633
9	.5788	1.046	.8215	.8775	2.7446	2.2119	2.4177
10	.5228	.7042	.5228	.5601	.5415	.4163	.5975
11	2.915	3.3008	2.9492	2.8464	.3601	.3547	.3361
12	2.8292	3.0521	3.0007	3.2065	.3547	.3174	.3734
13	2.7435	3.3951	3.0007	2.8978	.3547	.3734	.3921
14	2.7263	3.4328	3.0864	2.9321	.3361	.3361	.3734
15	2.6749	3.1207	3.1379	2.8006	.3921	.3361	.3734
16	2.6406	2.9835	2.692	2.6578	.3921	.3734	.3547
17	2.6063	2.7606	2.9313	2.6235	.4854	.4115	.4904
18	2.5549	2.3834	2.95	2.3491	.5316	.5487	.7356
19	.9896	.9896	.8775	.8962	.9259	.8745	.9997
20	.8402	.7468	.7842	.8589	.8402	.6059	.9431
21	.7282	.5788	.6535	.7468	.6602	.7373	.6173
22	.6722	.5601	.6348	.4294	.5144	.3944	.5144
23	.5975	.5601	.5975	.3921	.5144	.5658	.5144
24	.5788	.5601	.5601	.5788	2.1845	1.6975	1.8671
Max	2.915	3.4328	3.1379	3.2065	3.0247	2.2119	2.7633
Min	.5228	.5601	.5228	.3921	.3361	.3174	.3361
Avg	1.4612	1.5537	1.4952	1.4393	1.3403	1.1007	1.2030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.056	.0747	.056	.056	.056
2	.056	.0934	.056	.056	.0747	.112	.112
3	.056	.056	.056	.056	.056	.112	.112
4	.0373	.0373	.056	.056	.056	.112	.112
5	.056	.056	.056	.056	.056	.112	.112
6	.056	.0747	.056	.0747	.056	.056	.056
7	.056	.056	.0747	.0373	.056	.112	.056
8	.1307	.0857	.1494	.056	.056	.0747	.0934
9	.0747	.0377	.1494	.0373	.2054	.1307	.0373
10	.1494	.0857	.0373	.0187	.0934	.056	.168
11	.0747	.0514	.0373	.1307	.0747	.056	.056
12	.0747	.0377	.056	.1307	.1307	.056	.112
13	.056	.0343	.1307	.0187	.0747	.112	.0373
14	.0373	.0343	.0373	.1307	.0934	.0373	.1307
15	.0373	.0343	.0373	.112	.0747	.056	.056
16	.112	.0514	.0373	.112	.0934	.056	.0747
17	.056	.0373	.0373	.0373	.2054	.1029	.0943
18	.0373	.0373	.112	.112	.132	.0686	.1372
19	.112	.0377	.0373	.0373	.1509	.0514	.1029
20	.056	.0373	.0747	.1867	.0754	.0514	.1509
21	.1307	.0373	.0343	.1494	.132	.0377	.1886
22	.056	.0373	.112	.112	.1372	.0686	.1372
23	.056	.056	.056	.0747	.0514	.0514	.0343
24	.056	.056	.056	.0934	.056	.056	.056
Max	.1494	.0934	.1494	.1867	.2054	.1307	.1886
Min	.0373	.0343	.0343	.0187	.0514	.0373	.0343
Avg	.0700	.0508	.0668	.0817	.0936	.0748	.0951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 205 / 11Kv KANADGAON 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3018	.2801	.2987	2.4272	2.0576	1.7924
2	.3258	.3018	.3361	.3361	2.4459	2.2624	2.0538
3	.4108	.3361	.3361	.4108	2.4086	2.371	2.0911
4	.5068	.4481	.4481	.5228	2.6513	2.332	2.4272
5	.6348	.5975	.5975	.5975	2.726	2.5339	2.6699
6	.7468	.7842	.7282	.7468	2.7633	2.5892	2.726
7	.8962	.9149	.8962	.9149	2.9313	2.8235	2.8753
8	.7842	.8059	.8402	.8589	2.838	2.7092	3.0434
9	.3206	.7733	.6173	.6348	2.8006	2.7092	2.6406
10	.3944	.4801	.3921	.4294	.4108	.362	.3361
11	2.6406	3.1722	3.2579	3.1893	.2241	.1867	.168
12	2.7435	3.2579	3.3093	3.3951	.1494	.1494	.112
13	3.0521	3.5837	2.9492	3.1036	.168	.1494	.1307
14	3.6025	3.6734	3.1207	3.0007	.168	.1867	.1494
15	3.2579	3.275	2.9492	2.9664	.168	.1494	.168
16	3.3265	3.5082	2.9835	3.0178	.1867	.2054	.168
17	3.3265	3.275	3.0247	2.9321	.2427	.3206	.3086
18	2.8978	2.9664	2.6513	2.8464	.3429	.415	.5487
19	.5658	.7095	.6535	.5975	.583	.6979	.6344
20	.463	.5975	.5975	.5228	.4801	.6001	.6859
21	.3772	.5601	.4481	.4108	.3601	.4527	.4801
22	.547	.4854	.3921	.3734	.3601	.3961	.3601
23	.3584	.3547	.4108	.3734	.3429	.3961	.3429
24	.3174	.3018	.2801	.2987	2.3899	2.0062	1.6804
Max	3.6025	3.6734	3.3093	3.3951	2.9313	2.8235	3.0434
Min	.2896	.3018	.2801	.2987	.1494	.1494	.112
Avg	1.3661	1.4777	1.3542	1.3658	1.2737	1.2109	1.1914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 206 / 11 KV NEW LIS SHANTAI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896		.362	.4163	.4294	.4525	.4481
2	.2896		.362	.4294	.4294	.4525	.4481
3	.2896		.362	.4163	.4108	.4525	.4294
4	.2896		.362	.4163	.4294	.4525	.4294
5	.3077		.362	.4163	.4294	.4525	.4108
6	.3077		.362	.4163	.4294	.4525	.3734
7	.3077		.362	.4163	.4294	.4706	.3734
8	.3258		.3982	.4163	.4108	.4525	.3734
9	.2829		.3801	.4294	.4108	.4525	.3801
10	.3395		.3921	.4294	.4108	.4344	.362
11	.3429		.3921	.4854	.5228	.4344	.4163
12	.3961		.4294	.4854	.4854	.4525	.3982
13	.415		.4294	.4668	.4854	.4525	.3982
14	.415		.4481	.2241	.4854	.4525	.3982
23	.0754		.4108	.3734	.4715		.3734
24	.2896	.0724		.4163	.4294	.4525	.4481
Max	.415	.0724	.4481	.4854	.5228	.4706	.4481
Min	.0754	.0724	.362	.2241	.4108	.4344	.362
Avg	.3102	.0724	.3876	.4159	.4437	.4513	.4038



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 207 / 11KV BAGADI Ag 1-PHASING SINGLE PHASING  
FEEDE Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3734	.3174	.3734	.6348	.6878	.5975
2	.4108	.3921	.3547	.4108	.6722	.7421	.6722
3	.4854	.4481	.3734	.5228	.7095	.8326	.7282
4	.5228	.5601	.5228	.5601	.7468	.823	.8962
5	.5601	.6722	.6348	.6348	.8589	.905	.9709
6	.7282	.7468	.7095	.6908	.9149	.8745	1.0829
7	.7655	.7095	.7468	.7282	1.1389	.9602	1.1949
8	.7095	.6602	.5975	.6908	1.1203	.9774	1.307
9	.5228	.5658	.4854	.6348	1.1016	1.0117	1.1763
10	.4108	.4115	.3921	.3734	.2987	.3077	.3174
11	.905	1.0288	1.0288	.9945	.2427	.2241	.2614
12	1.166	1.1145	1.0974	1.1016	.2241	.2054	.2427
13	1.2003	1.166	1.0802	.9259	.1867	.2054	.2054
14	1.1145	1.2003	1.0288	.9774	.168	.1867	.2054
15	1.0631	1.2003	.9774	.9259	.1867	.1886	.2054
16	1.1203	1.0974	.7545	.8916	.2641	.2241	.2054
17	1.2136	1.0974	.8962	.9259	.2572	.2572	.3086
18	1.0802	1.046	1.1016	.7373	.3601	.3086	.5144
19	.5975	.5975	.5788	.5041	.6001	.5144	.5658
20	.4668	.5487	.5601	.5041	.4115	.3601	.4801
21	.4481	.5228	.4668	.4481	.3601	.3601	.4115
22	.4108	.4481	.4294	.3921	.3601	.2915	.3601
23	.3734	.3921	.5788	.3174	.3772	.2743	.3601
24	.3734	.3734	.3734	.3921	.6161	.6516	.5601
Max	1.2136	1.2003	1.1016	1.1016	1.1389	1.0117	1.307
Min	.3734	.3734	.3174	.3174	.168	.1867	.2054
Avg	.7100	.7239	.6703	.6524	.5338	.5156	.5762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 201 / 11 KV BHENDALA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0572	.0572	2.0005	1.5242	.4001
2	.0953	.0953	.0762	.0381	1.9624	.1524	.4001
3	.0953	.0953	.0762	.0572	2.0576	1.7147	.5525
4	.0953	.0953	.0953	.0572	2.0957	2.0957	.5525
5	.0953	.0953	.0953	.0572	2.0957	2.0957	.6668
6	.0953	.0953	.0953	.0762	2.0957	2.0957	.743
7	.0953	.0953	.0953	.0762	2.0957	2.0957	.7621
8	.0953	.0953	.0953	.0762	2.0957	2.1529	.8573
9	.0953	.0953	.0762	.0762	2.0957	2.2862	1.7528
10	2.6673	2.8769	2.5149	2.6292	.0953	.0953	.0572
11	2.7054	2.8769	2.8006	2.7625	.0953	.0953	.0572
12	2.7054	2.8387	2.8197	2.7054	.0953	1.9433	.0762
13	2.7816	2.8578	2.7816	2.8578	.0953	1.9624	.0572
14	2.6292	2.934	2.8197	2.8197	.0953	.0572	.0572
15	2.7054	2.915	2.7625	2.8959	.0953	.0953	.0762
16	2.7054	2.8959	2.7625	2.8578	.0953	.0762	.0762
17	2.6673	2.6482	2.7244	2.7054	.0953	.0762	.0762
18	.0953	.0953	.0762	.0762	.0953	.0762	.0762
19	.0953	.0953	.0762	.1334	.0953	.0762	.0762
20	.0953	.0762	.0762	.1143	.0953	.0762	.0762
21	.0953	.0762	.0762	.1143	.0953	.0762	.0762
22	.0953	.0762	.0762	.0762	.0953	.0762	.0762
23	.0953	.0762	.0762	.0953	.0953	.0762	.0762
24	.0953	.0953	.0953	.0762	2.0005	1.5242	.381
Max	2.7816	2.934	2.8197	2.8959	2.0957	2.2862	1.7528
Min	.0953	.0762	.0572	.0381	.0953	.0572	.0572
Avg	.9622	1.0122	.9709	.9788	.9137	.9415	.3358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 202 / 11 DHOREGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.3048	.2286	2.6863	2.0576	2.572
2	.4572	.4191	.2667	.2667	2.5911	2.0576	2.572
3	.4572	.4191	.2667	.2667	2.553	2.0576	2.572
4	.4572	.4191	.362	.3048	2.553	2.2862	2.8578
5	.381	.4191	.4001	.3048	2.6673	2.6673	2.8578
6	.4572	.4191	.4572	.3429	2.7816	2.6673	3.0483
7	.381	.4191	.4954	.4191	2.8578	3.0483	3.0483
8	.3048	.4191	.4191	.4572	2.934	3.0483	3.2769
9	.3048	.4191	.3429	.381	3.0102	3.0483	3.0483
10	3.4294	3.4294	3.296	3.4294	.2286	.1905	.2858
11	3.4294	3.1245	3.3341	1.829	.2096	.1905	.2858
12	3.4294	3.0864	3.5056	3.2388	.2286	.1905	.1524
13	3.4294	3.0483	3.5056	3.7342	.1905	.1905	.1524
14	2.8578	3.0293	3.5437	3.6199	.1905	.1905	.1524
15	2.8578	3.0293	3.5437	3.0483	.1905	.1905	.1524
16	2.8578	2.9912	3.4294	3.4294	.1905		.1524
17	2.8578	3.1626	.3048	3.4675	.2286	.2096	.1524
18	.4572	.3239	.3048	.2667	.2286	.2858	.1905
19	.4572	.4572	.381	.362	.2858	.4001	.381
20	.4572	.4763	.381	.381	.3429	.381	.4191
21	.4191	.4191	.3429	.3239	.381	.4001	.381
22	.4191	.381	.3429	.3239	.381	.4001	.3429
23	.4191	.3239	.3048	.362	.381	.381	.3048
24	.4572	.4191	.362	.2667	2.6863	2.0576	
Max	3.4294	3.4294	3.5437	3.7342	3.0102	3.0483	3.2769
Min	.3048	.3239	.2667	.2286	.1905	.1905	.1524
Avg	1.3289	1.3114	1.2582	1.2939	1.2908	1.2433	1.2765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 203 / 11 KV AMALNER FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.448	1.4289	1.448	.1524	.3048	.1905
2	1.6194	1.448	1.4289	1.448	.1143	.2286	.1905
3	1.6194	1.448	1.448	1.4861	.1143	.2286	.1905
4	1.7147	1.448	1.448	1.4861	.1334	.3048	.1905
5	1.7147	1.7147	1.5051	1.5242	.1143	.3048	.2096
6	1.7147	1.7147	1.5432	1.5242	.1334	.2286	.2096
7	1.7718	1.7147	1.6194	1.5623	.1524	.3048	.2286
8	1.7718	1.7147	1.6194	1.5623	.1905	.3048	.2286
9	1.7718	1.7147	1.3717	1.6004	.1905	.3048	.1905
10	.1524	.1524	.1524	.1524	1.9433	2.2862	.2096
11	.1524	.1524	.0762	.1143	2.1529	2.2862	2.4768
12	.1524	.1334	.0762	.1143	2.2862	2.2862	2.5911
13	.1524	.1143	.0762	.1143	2.2862	2.21	2.8197
14	.1524	.0953	.0762	.1143	2.2862	2.1719	2.7816
15	.1524	.0762	.0762	.1143	2.2862	2.21	.1524
16	.2286	.0953	.0762		2.8578	2.1719	.1524
17	.2667	.1143	.0762	.1524			.1524
18	.2667	.1715	.0762	.1524	.381	2.2862	.1524
19	.2667	.1905	.1524	.1905	.381		.1524
20	.3048	.2096	.1524	.1524	.381	.2477	.1524
21	.3048	.1905	.1143	.1524	.3048	.2096	.1524
22	.3048	.1715	.1143	.1143	.3048	.2096	.1143
23	.3048	.1715	.0762	.1334	.2286	.2096	.1143
24	1.6194	1.448	1.4098	1.4289	.1905	.2286	.1905
Max	1.7718	1.7147	1.6194	1.6004	2.8578	2.2862	2.8197
Min	.1524	.0762	.0762	.1143	.1143	.2096	.1143
Avg	.8375	.7438	.6748	.7323	.8507	.9786	.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 204 / 11 KV GANESHWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3048	.2667	.2667	.3048	.2858	.3048
2	.3239	.3048	.3048	.2667	.3048	.2858	.3048
3	.4763	.3048	.362	.3048	.3048	.2858	.3048
4	.5716	.4763	.4191	.3048	.2858	.4763	.4572
5	.6668	.5335	.5525	.3429	.362	.743	.7049
6	.743	.6668	.724	.5335	.5144	.8002	.7621
7	.7811	.8002	.8954	.724	.743	.8002	.7811
8	.8002	.8002	.9145	.8954	.8002	.6668	.6287
9	.7621	.8573	.7621	.743	.6097	.6668	.6287
10	.5716	.6287	.5525	.5335	.381	.381	.5335
11	.4763	.5335	.4572	.362	.362	.3048	.4191
12	.4191	.4382	.381	.381	.362	.2667	.3048
13	.381	.381	.3429	.2858	.381	.2477	.2667
14	.362	.362	.3048	.3239	.381	.2858	.2667
15	.362	.362	.2858	.2667	.2858	.2286	.3048
16	.381	.381	.2286	.3048	.2858	.2667	.362
17	.5716	.4001	.4191	.3048	.2858	.2667	.4382
18	.6097	.6097	.5525	.4001	.5716	.362	.5144
19	.743	.7811	.6859	.5335	.6097	.4954	.6859
20	.8002	.5906	.724	.4954	.8002	.4191	.724
21	.4763	.5525	.4001	.4954	.5716	.3429	.4763
22	.4191	.5144	.3429	.381	.2858	.3048	.381
23	.381	.4191	.2667	.3429	.2858	.3048	.3048
24	.3239	.3048	.362	.2667	.3048	.2858	.3048
Max	.8002	.8573	.9145	.8954	.8002	.8002	.7811
Min	.3239	.3048	.2286	.2667	.2858	.2286	.2667
Avg	.5303	.5128	.4795	.4191	.4326	.4072	.4652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 205 / 11kv Kokan agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4001	.4954	.4191	.5716	.5716	.4001
2	.4191	.4001	.4572	.4954	.5335	.5716	.4001
3	.4191	.4001	.4191	.4954	.4763	.4382	.4191
4	.6478	.4572	.4572	.5144	.4954	.4382	.4191
5	.6097	.4954	.4954	.5144	.4954	.4382	.4191
6	.6668	.5716	.5144	.5335	.5144	.4382	.4191
7	.8573	.5716	.5335	.5335	.5716	.4382	.4191
8	1.1431	.5716	.6859	.6097	1.0098	.4763	.6859
9	1.3527	.6287	.9907	.7811	1.3146	.8764	1.1431
10	1.2384	.8192	1.2003	1.2193	1.3146	.7049	1.3908
11	1.2384	.8192	1.2955	.743	1.3336	1.3146	1.3908
12	1.2003	1.086	1.2955	1.2955	1.4289	1.5623	1.2384
13	1.2003	.9907	1.2574	1.1622	1.4289	.8573	1.2574
14	1.0479	.9145	1.2574	1.1812	1.4289	.8002	1.2384
15	1.0479	.7621	1.2384	1.3336	1.4289	1.3908	1.2193
16	1.0669	.6287	1.1431	1.2955	1.4289	1.3527	1.0288
17	1.0479	.5906	.8573	.743	.9526	1.0288	1.0669
18	1.0479	.5906	.5335	.8002	.7621	.8954	.8192
19	.5716	.5335	.5335	.7811	.7621	.7049	.7811
20	.5144	.5335	.5525	.5906	.7621	.6668	.7621
21	.4191	.5335	.5525	.5525	.7621	.6478	.724
22	.4001	.5144	.5335	.5144	.6097	.5716	.6478
23	.4001	.4763	.5335	.5144	.6097	.5716	.6097
24	.4001	.4001	.5335	.4572	.7049	.6097	.4001
Max	1.3527	1.086	1.2955	1.3336	1.4289	1.5623	1.3908
Min	.4001	.4001	.4191	.4191	.4763	.4382	.4001
Avg	.8065	.6121	.7653	.7533	.9042	.7653	.8041

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 206 / 11 KV GALNEEMB AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.6194	1.5432	1.3717	.0381	.0381	.0381
2	1.7528	1.6194	1.5432		.0381	.0381	.0381
3	1.8861	1.6194	1.6004	1.3908	.0381	.0381	.0572
4	1.8861	1.6194	1.6004	1.4098	.0381	.0381	.0572
5	1.8861	1.7147	1.6766	1.3336	.0381	.0381	.0381
6	1.8861	1.7147	1.6766	1.3336	.0381	.0381	.0381
7	1.8861	1.7147	1.7147	1.3527	.0381	.0381	.0381
8	1.8861	1.7147	1.7528	1.3717	.0953		.0381
9	1.8861	1.7147	1.7147	1.3717	.0381	.0381	.0381
10	.0381	.0381	.0191	.0381	1.7147	1.9052	.0191
11	.0381	.0381	.0191	.0191	1.7718	1.9433	1.829
12	.0381	.0381	.0381	.0191	1.9052	1.9433	1.8671
13	.0381	.0381	.0381	.0191	1.9052	1.8671	1.9433
14	.0381	.0191	.0381	.0191	1.9433	1.9052	1.9814
15	.0381	.0191	.0381	.0191	1.9433	2.0005	2.0957
16	.0381	.0191	.0381	.0191	1.9433	1.9624	2.1529
17	.0381	.0191	.0381	.0191	1.9433	1.829	2.0957
18	.0381	.0191	.0381	.0191	.0381	2.1338	2.0195
19	.0381	.0381	.0381	.0191	.0381	.0381	.0381
20	.0381	.0381	.0381	.0191	.0381	.0381	.0381
21	.0381	.0191	.0381	.0191	.0381	.0381	.0572
22	.0381	.0191	.0381	.0191	.0381	.0381	.0572
23	.0381	.0191	.0381	.0191	.0381	.0381	.0381
24	1.7528	1.6194	1.5432	1.5242	.0381	.0381	.0381
Max	1.8861	1.7147	1.7528	1.5242	1.9433	2.1338	2.1529
Min	.0381	.0191	.0191	.0191	.0381	.0381	.0191
Avg	.7914	.7105	.7026	.5542	.6557	.7836	.6938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 207 / 11Kv Lakhmapur Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5242	1.5242	1.5242	.1524	.1905	.2096
2	1.7147	1.5242	1.5051	1.3717	.1524	.1905	.2096
3	1.7147	1.5242	1.5051	1.3717	.1334	.1905	.2096
4	1.7147	1.7147	1.5432	1.3717	.1524	.1905	.2096
5	1.7147	1.7718	1.6385	1.448	.1524	.2858	.2477
6	1.7147	1.7718	1.6385	1.448	.1334	.2858	.2477
7	1.7147	1.7718	1.6766	1.4861	.1524	.2858	.2477
8	1.7147	1.7718	1.6385	1.4861	.1905	.2858	.2477
9	1.7147	1.829	1.4289	1.3717	.2286	.2858	.1905
10	.1905	.1524	.1524	.1524	1.4289	2.0957	.1524
11	.1905	.1524	.1143	.1143	1.7718	2.0957	.1524
12	.1905	.1715	.1143	.1143	2.0957	1.9624	.0762
13	.1905	.1334	.1143	.1143	2.0957	2.191	.1143
14	.1905	.1143	.1143	.1143	2.0957	2.1529	.1143
15	.1905	.1334	.0762	.0762	2.0957	2.1338	2.4768
16		.1524	.0762	.0953	2.4387	2.0957	2.5149
17	.1905	.1524	.0762	.0953	2.4387	2.1719	2.4768
18	.2286	.1905	.1143	.0953	.3048	.1143	2.4768
19	.2286	.2286	.1905	.2286	.3048	.2286	.1905
20	.2477	.2667	.1905	.1905	.3048	.2477	.1905
21	.2667	.2286	.1524	.1905	.3048	.2286	.1905
22	.2667	.2096	.1524	.1905	.3048	.2667	.1524
23	.2667	.1905	.1143	.1524	.3048	.2667	.1524
24	1.6004	1.5242	1.5051	1.4861	.2667	.1905	.1715
Max	1.7147	1.829	1.6766	1.5242	2.4387	2.191	2.5149
Min	.1905	.1143	.0762	.0762	.1334	.1143	.0762
Avg	.8640	.8002	.7232	.6787	.8335	.8597	.5676



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 208 / 11 kv MAUJABAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6097	.6668	.6478
2					.6668	.6668	.6478
3					.6668	.6668	.6478
4					1.1431	.7621	.724
5					1.3717	1.0479	.9907
6					1.5242	1.1431	1.105
7					1.5813	1.3146	1.2574
8					1.5813	1.2384	1.2574
9					1.1622	1.2384	1.1622
10	1.5242	1.5242	1.1241	1.1812			
11	1.5242	1.6385	1.1431	1.5051			
12	1.2384	1.6194	1.2955	1.448			
13	.8002	1.5623	1.2955	1.6004			
14	1.2955	1.5432	1.3717	1.5623			
15	1.4289	1.5623	1.4861	1.5242			
16	1.4861	1.6004	1.4861	1.4861			
17	1.4289	1.448	1.4861	.9145			
24					.6668	.6668	.5906
Max	1.5242	1.6385	1.4861	1.6004	1.5813	1.3146	1.2574
Min	.8002	1.448	1.1241	.9145	.6097	.6668	.5906
Avg	1.3408	1.5623	1.3360	1.4027	1.0974	.9412	.9031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 209 / 11 KV BHIVDHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8383	.743	.7621	.7621	.9145	.8192
2	.8192	.8573	.7621	.8002	.8002	.9145	.8192
3	.8192	1.3146	.8383	.8383	.8192	.9145	.8192
4	1.0479	1.3146	.9717	.8764	.8383	1.4289	1.3717
5	1.4289	1.7147	1.4861	1.1812	1.4289	1.8861	1.6956
6	1.7147	1.8671	1.8861	1.2955	2.0005	2.0957	2.0576
7	2.0005	1.8861	2.0957	2.0576	1.9624	2.1338	2.0957
8	2.0767	1.9052	1.9814	1.9433	2.0005	1.8099	1.9814
9	1.7718	1.9052	1.6766	1.6766		1.6194	1.6385
10	1.5242	1.5242	1.1622	1.3146		1.1431	1.2193
11	1.4289	1.2003	.8764	.9907	.7811	.9335	.8383
12	1.1431	.9907	.724	.9526		.6859	.6478
13	.9526	.7621	.6859	.7049	.8573	.6668	.6097
14	.6859	.6668	.724	.6668	.8573	.6287	.5716
15	.6859	.743	.6859	.7049	.8573	.6859	.6097
16	.8002	.8573	.7621	.6478	1.1431	.6478	.6287
17	1.2574	.9907		.9526	1.4861	.9907	.8192
18	1.6194	1.4289	1.2574	1.7337	1.6956	1.1622	1.1431
19	1.8099	1.9433	1.6766	1.7337	1.8099	1.6004	1.829
20	1.8861	1.5432	1.5623	1.6194	1.9052	1.7718	1.7528
21	1.1431	1.1431	1.105	1.5432	1.1431	1.105	1.2003
22	.9526	1.0479	.9526	1.0479	1.0479	1.0098	.9907
23	.8573	.8192	.7621	.8192	.9145	.8573	.8002
24	.8192	.8383	.7621	.7621	.8192	.9145	.8192
Max	2.0767	1.9433	2.0957	2.0576	2.0005	2.1338	2.0957
Min	.6859	.6668	.6859	.6478	.7621	.6287	.5716
Avg	1.2527	1.2543	1.1365	1.1511	1.2347	1.1884	1.1574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 201 / NARAYANPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.12	.112	.1307	1.7924	2.4741	2.3403
2	.1307	.12	.1097	.112	1.6617	2.4741	2.3805
3	.132	.12	.128	.112	1.7814	2.4741	2.3805
4	.1494	.1372	.128	.132	1.9669	2.4905	2.4697
5	.1494	.1543	.1463	.1494	2.0576	2.556	2.4615
6	.1886	.1543	.1494	.1698	2.1874	2.6707	2.6686
7	.1698	.1372	.1463	.1886	2.5396	2.8018	2.8012
8	.1509	.12	.1494	.1463	2.2862	2.8675	2.9007
9	.0934	.0857	.0914	.128	1.9662		2.0885
10	.0934	.1029	.056	.0914	.1097		.112
11	3.0001	3.4252	3.2891	3.8462	.0857	.112	.0857
12	3.4808	3.4252	3.3745	3.4421	.0686	.112	.0857
13	3.4311	3.2895	3.3208	3.0352	.0686	.0934	.0686
14	3.4145	3.2556	3.131	3.0352	.0686	.0943	.0686
15	3.3979	3.103	3.0607	3.0352	.0686	.0934	
16	3.1161	2.8509		2.5604	.0686	.0747	.0514
17	2.8018	2.95	2.6355	2.5579	.0686	.0934	.0686
18	2.6189	.1097	1.8896	2.3339		.0747	.0686
19	.12	.128	.1307	.1494		.112	.1029
20	.1372	.1494	.1698	.1494	.12	.1307	.1029
21	.1372	.128	.168	.1494	.1029	.132	.1029
22	.1372	.1307	.1494	.1307	.0857	.1132	.0857
23	.12	.1307	.1509	.112	.0857	.112	.0857
24	.1307	.12	.1097	.1307	1.2437	2.4577	2.2771
Max	3.4808	3.4252	3.3745	3.8462	2.5396	2.8675	2.9007
Min	.0934	.0857	.056	.0914	.0686	.0747	.0514
Avg	1.1438	1.0186	.9911	1.0845	.9311	1.1188	1.1243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 202 / RANJANGAON S.P.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1068	2.0165	1.9791	2.0911	1.7558	2.1285	2.1658
2	2.0911	1.9791	1.8671	2.0538	1.829	2.1285	2.0911
3	2.1879	1.9791	2.0538	2.0538	2.0119	2.1285	2.0911
4	2.4897	2.0725	2.4272	2.3388	2.5393	2.2405	2.2032
5	2.95	2.4272	2.838	2.6783	2.9264	2.5766	2.6406
6	3.4355	2.6326	3.2487	3.2819		3.0247	3.1687
7		2.7073	2.95	3.2442		2.9874	3.2442
8	1.9418	2.6513	2.726	2.9874	2.5606	2.4646	2.7161
9	3.2114	2.5206	2.4272	2.726	2.5766		2.3765
10	2.5652	2.5393	2.1285	2.2779	2.2779		2.037
11	2.2177	2.5206	2.0748	2.2405	1.9589	2.3899	1.9605
12	2.1472	2.5393	1.7177	1.9791	1.848	1.9044	1.9035
13	2.0165	2.2405	1.6975	1.9044	1.848	1.8671	1.885
14	1.9035	2.1285	1.8107	1.8861	1.8296	1.8861	1.885
15	2.0165	2.0538	1.9418	1.9044	1.885	1.9418	1.848
16	2.1068	2.037	1.9616	1.9791	1.9404	1.9239	1.9589
17	2.384	2.0538	1.9791	2.1658	2.0144	2.0911	2.1622
18	2.5206	2.1658	2.2634	2.3152	2.1845	2.2634	2.2592
19	2.6513	2.6139	2.7161	2.726	2.6326	2.8669	2.9127
20	2.6886	2.7633	2.9047	3.0178	2.7073	2.9424	
21	2.7633	2.838	2.8669	3.4355	2.7633	2.9424	3.0434
22	2.6326	2.5766	2.6029	2.6139	2.6326	2.6783	2.8567
23	2.2592	2.3152	2.3765	2.4272	2.3525	2.4143	2.5206
24	2.2257	2.0911	2.0538	2.2032	2.0538	2.0911	2.2634
Max	3.4355	2.838	3.2487	3.4355	2.9264	3.0247	3.2442
Min	1.9035	1.9791	1.6975	1.8861	1.7558	1.8671	1.848
Avg	2.4136	2.3526	2.3172	2.4388	2.2331	2.3583	2.3562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 203 / PIMPARKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2561	.2641	.2561	.2829	.2829
2	.2641	.2641	.2926	.2641	.2926	.2641	.2641
3	.2829	.2641	.3772	.2829	.3658	.2641	.2641
4	.3395	.3018	.4108	.3584	.439	.3395	.3206
5	.4338	.3584	.4854	.4191	.4854	.3961	.4191
6	.6287	.415	5.176	.4954	.5228	.4904	.5144
7	.5906	.5281	.6348	.5906	.5853	.6036	.6097
8	.5906	.5847	.5975	.567	.5601	.547	.547
9	.5525	.5658	.4572	.5601	.4938		.4715
10	.4715	.5093	.4954	.4668	.4207		.4294
11	.4338	.5304		.4294	.3772	.4668	.4108
12	.3921	.4938	.3772	.3734	.3547	.3961	.3547
13	.3547	.4108	.3584	.3361	.3174	.3772	.3174
14	.3174	.3174	.3206	.3361	.2987	.3395	.2987
15	.3174	.3547	.3206	.2987	.2614	.3206	.2801
16	.3174	.3361	.3921	.3361	.2614	.3206	.3361
17	.3921	.3361	.3018	.3734	.3174	.3584	.3584
18	.4108	.3921	.4572	.4481	.4338	.4338	.4338
19	.5093	.4572	.5525	.4854	.5093	.4904	.547
20	.4527	.3841	.4904	.4481	.4527	.4763	.4904
21	.3584	.3841	.415	.3921	.415	.4382	
22	.3584	.3547	.3584	.3547	.3772	.381	.3772
23	.2829	.2987	.3206	.3174	.3018	.3395	.3206
24	.3018	.2829	.2614	.2987	.2926	.2829	.3018
Max	.6287	.5847	5.176	.5906	.5853	.6036	.6097
Min	.2641	.2641	.2561	.2641	.2561	.2641	.2641
Avg	.4007	.3912	.6134	.3957	.3913	.3913	.3891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 204 / JOGESHWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7922	.6535	.7842	.6535	.8048	.7947
2	.7733	.811	.8589	.7392	.8589	.8299	.7762
3	.7733	.811	1.0269	.7577	1.0269	.8131	.8686
4	.9335	.8488	1.1203	1.46	1.2323	.8962	1.0829
5	1.251	.9054	1.2323	1.0829	1.4563	1.0269	1.0829
6	1.4377	1.0374	1.4003	1.3203	1.5123	1.4146	1.4523
7	1.4937	1.226	1.4003	1.4146	1.5123	1.4335	1.5089
8	1.3817	1.358	1.3817	1.3817	1.2136	1.226	1.358
9	1.1506	1.2071	1.0269	1.251	1.0374		1.094
10	.9808	1.2136	.8775	.9522	.8775		.8589
11	.8402	1.1203	.8865	.8402	.8402	.9054	.8316
12	.8215	1.1389	.8299	.8215	.6535	.7095	.6838
13	.8131	.9896	.7655	.8402	.6908	.6722	.8501
14	.6468	1.0269	.7842	.8589	.6722	.6161	.8501
15	.6468	.8402	.7842	.8402	.6838	.6535	.8316
16	.8501	.8402	.7655	.7655	.6838	.6722	.8501
17	1.0164	.8775	.8589	.8402	.8316	.8402	.8402
18	.9896	.9896	.8962	.8402	1.0269	.9522	.9896
19	1.0374	1.0269	1.1317	1.0269	1.0829	1.0829	1.2323
20	1.2449	1.1763	1.1317	1.1203	1.1389	1.1949	1.2323
21	1.0374	1.0269	1.0185	1.0642	1.1317	1.1576	
22	.9997	.9896	.9522	.9896	1.0374	1.094	1.0374
23	.8865	.8775	.8775	.8402	.8488	.8962	.9997
24	.8299	.8299	.7316	.8215	.7468	.8488	.8402
Max	1.4937	1.358	1.4003	1.46	1.5123	1.4335	1.5089
Min	.6468	.7922	.6535	.7392	.6535	.6161	.6838
Avg	.9845	.9984	.9747	.9856	.9771	.9428	.9977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 205 / 11 kv NANDEDA gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.0269	1.0269	1.0242	1.0269	1.0349	1.0534
2	.9795	1.0642	1.1203	1.0059	1.2696	1.0642	1.0059
3	1.0534	1.1763	1.475	.9955	1.6057	1.1203	1.0608
4	1.5154	1.4563	1.7924	1.3256	1.7924	1.3443	1.3394
5	1.8673	1.6804	2.0165	1.7002	1.8861	1.7924	1.8484
6	2.1125	1.8858	2.1472	1.9753	2.0165	2.1691	2.2257
7	2.2068	2.1098	2.0725	1.9936	1.9993	2.037	2.32
8	1.9616	1.9605	1.6095	2.0351	1.8671	1.773	2.0936
9	1.5466	1.8484	1.643	1.6057	1.6221		1.7164
10	1.5844	1.7737	1.307	1.307	1.3535		1.358
11	1.3491	1.643	1.1576	1.2136	1.1643	1.4003	1.1273
12	1.2567	1.4563	.9694	1.0642	.961	1.0829	.9328
13	1.1458	1.3443	.9328	.9896	.924	.9709	.9145
14	1.1827	1.251	.9259	.9335	.9055	.8962	.9145
15	1.2254	1.1763	1.0269	.9694		.8402	1.0059
16	1.4083	1.3443	1.1506	1.1389	1.0242	.9709	1.0791
17	1.5912	1.2883	1.251	1.2449	1.1523	1.1576	1.3306
18	1.7002	1.475	1.4712	1.4712	1.3121	1.4784	1.5154
19	1.7556	1.9044	1.9239	1.7737	1.6448	1.7187	1.9044
20	1.5123	1.6804	1.7164	1.643	1.5497	1.7737	1.7364
21	1.3256	1.4937	1.475	1.4003	1.4563	1.4523	1.4937
22	1.2696	1.2323	1.2323	1.2323	1.2136	1.3014	1.3443
23	1.0456	1.1576	1.1203	1.1576	1.1203	1.1203	1.1949
24	1.0829	1.0829	1.1203	1.0829	1.0269	1.0642	1.0829
Max	2.2068	2.1098	2.1472	2.0351	2.0165	2.1691	2.32
Min	.9795	1.0269	.9259	.9335	.9055	.8402	.9145
Avg	1.4453	1.4797	1.4035	1.3451	1.3867	1.3438	1.3999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 206 / 11 KV Waluj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.2071	1.1203	1.2012	1.1203	1.2071	1.2567
2	1.2136	1.2071	1.262	1.1643	1.419	1.2254	1.2382
3	1.2127	1.262	1.6617	1.1643	1.6617	1.262	1.2936
4	1.6108	1.39	2.0538	1.531	2.0538	1.3717	1.475
5	2.268	1.9959	2.5206	2.1658	2.5206	2.1948	2.1313
6	2.7511	2.2546	2.8006	2.7538	2.7633	2.8006	2.8104
7	3.2253	2.838	3.1367	3.1121	2.9874	3.1367	3.131
8	2.9424	2.782	2.8006	2.95	2.6886	2.894	2.9424
9	2.6029	2.7446	2.4143	2.6139	2.452		2.5652
10	2.1502	2.5206	1.9791	2.1658	2.0538		2.0351
11	1.7926	2.396	1.6804	1.8858	1.8107	2.0513	1.6632
12	1.701	1.9044	1.531	1.643	1.5729	1.7737	1.4784
13	1.5912	1.6804	1.363	1.4937	1.4632	1.531	1.3717
14	1.5546	1.6617	1.3014	1.307	1.39	1.3817	1.3717
15	1.701	1.5684	1.3203	1.419	1.4083	1.419	1.3717
16	1.4815	1.6617		1.5684	1.4998	1.5684	1.7741
17	1.701	1.8671	1.643	1.7364	1.7375	1.7551	1.9035
18	2.2032	2.0851	2.0748	2.0351	2.2032	2.1285	2.2779
19	2.4459	2.2862	2.3954	2.3339	2.5766	2.5652	2.6139
20	2.0725	2.0351	2.2445	2.1285	2.1285	2.32	2.2032
21	1.7551	1.7364	1.8111	1.7924	1.848	1.9239	1.8484
22	1.4449	1.475	1.4937	1.4937	1.4969	1.6598	1.6244
23	1.2986	1.3443	1.3443	1.307	1.3169	1.4003	1.3491
24	1.307	1.2437	1.307	1.2696	1.2323	1.2254	1.3256
Max	3.2253	2.838	3.1367	3.1121	2.9874	3.1367	3.131
Min	1.2127	1.2071	1.1203	1.1643	1.1203	1.2071	1.2382
Avg	1.8874	1.8811	1.8809	1.8432	1.8919	1.8543	1.8773



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 207 / 11 KV Ghanegaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2018	1.2029	1.0974	1.012	.1829	.2401	.2263
2	1.2176	1.1873	1.39	.9962	.2614	.3395	.2263
3	1.2803	1.2334	1.4937	1.0279	.2987	.3395	.2641
4	1.3443	1.2334	1.7924	1.1702	.3734	.3584	.3206
5	1.4883	1.3441	1.7924	1.3441	.4108	.4527	.4191
6	1.704	1.668	1.8107	1.5546	.4668	.6287	.5144
7	2.2377	2.0567	2.1098	1.7976	.4668	.5335	.4572
8	2.1216	2.2283	2.2779	2.0485	.4481	.4572	.4572
9	1.9393	1.9662	1.8858	1.7924	.3921		.3961
10	.3395		.2829	.2801	.2801		.3361
11	.2134		.2241	.2427	2.1052	1.8818	1.9826
12	.2		.2477	.2054	2.2447	1.9925	2.0809
13	.16		.2477	.2241	2.0809	1.9524	2.13
14	.16		.2263	.1867	1.9989	1.9227	2.13
15	.1734	.2427	.2286	.168	2.0645	1.8399	2.0153
16	.1867	.2378	.3018	.1867	2.0645	1.8399	2.0153
17	.2401	.2801	.2641	.2241	1.8679	1.9062	1.8515
18	.2534	.2614	.2452	.2427	1.5565	1.2018	1.6032
19	.3067	.3734	.415	.3174	.2934	.3734	.2934
20	.2267	.2987	.3961	.3361	.3201	.3429	.2667
21	.2134	.2987	.3584	.2987	.2801	.3584	
22	.2134	.2427	.3018	.2801	.2401	.3018	.2
23	.2829	.2241	.2667	.2427	.2401	.2401	.2
24	1.2018	1.1248	.8962	1.0437	.1867	.2401	.2427
Max	2.2377	2.2283	2.2779	2.0485	2.2447	1.9925	2.13
Min	.16	.2241	.2241	.168	.1829	.2401	.2
Avg	.7878	.9318	.8564	.7176	.8802	.8974	.8969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 208 / 11 KV East West Industri SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3772	.2987	.4481	.4024	.5658	.4066
2	.3734	.3772	.3361	.4527	.3292	.5281	.3734
3	.4108	.3772	.3734	.415	.439	.4904	.3734
4	.4108	.3772	.3361	.415	.4108	.4527	.4108
5	.4904	.3395	.4108	.415	.3734	.3772	.415
6	.5658	.3018	.2987	.3772	.3292	.3772	.4527
7	.6413	.2641	.3734	.4527	.4108	.5658	.6036
8	.7545	.2263	.4481	.6348	.5975	.6413	.6413
9	.9709	.1886	.8048	.8048	.7842		.9431
10	.9431	.2263	1.0829	.7468	.9877		1.0829
11	.9335	.2926	1.0082	.8215	.9709	1.0829	1.2323
12	.8962	.2561	1.0082	.8215	.9709	1.2071	1.0829
13	.8215	.2614	1.0456	.7167	.9335	1.1694	1.1203
14	.9335	.2241	1.0562	.7468	1.1203	1.1317	1.1827
15	.8962	.1867	.9808	.8215	.9709	1.0562	1.1949
16	.9335	.1867	1.0829	.8962	.9335	.9808	1.0456
17	.6653	.1867	.9054	.7095	.9709	.924	.9335
18	.4527	.1494	.5975	.7095	.6722	.7762	.7545
19	.415	.2896	.5975	.4481	.5281	.5228	.5281
20	.4527	.1867	.415	.3734	.4527	.4481	.6036
21	.4527	.2614	.4572	.3734	.4904	.4527	.5658
22	.4904	.2614	.4572	.5228	.5658	.5281	.5658
23	.4527	.2614	.4854	.4854	.5658	.5658	.679
24	.3772	.415	.2195	.4527	.3658	.3772	.415
Max	.9709	.415	1.0829	.8962	1.1203	1.2071	1.2323
Min	.3734	.1494	.2195	.3734	.3292	.3772	.3734
Avg	.6295	.2698	.6283	.5859	.6490	.6919	.7336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 201 / 11 KV GAJGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1143	.1097	.0953	.4904	.381	.2058
2	.1905	.1143	.1097	.0953	.5304	.4572	.2572
3	.1905	.1524	.1463	.1143	.5487	.5716	.2572
4	.2286	.1905	.1097	.1334	.6219	.6668	.3429
5	.2286	.1905	.132	.1524	.6401	.6668	.4024
6	.2286	.1905	.1097	.1715	.6413	.7049	.6478
7	.2286	.1715	.0914	.1905	.6767	.724	.7287
8	.2286	.1524	.0732	.1524	.8413	.7621	.7287
9	.1524	.1524	.0732	.1334	.9335	.7621	.6802
10	.1143	.1132	.0762	.1509	.0762	.0953	.0953
11	.463	.3772	.5335	.5658	.0572	.0762	.0762
12	.5407	.5304	.6097	.5847	.0572	.0572	.0572
13	.5506	.5853	.6859	.5487	.0572	.0572	.0572
14	.5601	.6224	.6287	.5658	.0572	.0572	.0572
15	.5468	.6413	.6097	.6036	.0572	.0572	.0572
16	.5441	.5847	.5716	.567	.0572	.0572	.0572
17	.4858	.6219	.5716		.0381	.0762	.0572
18	.4096	.6979	.6097	.567	.0381	.0762	.0754
19	.0943	.1132	.1143	.1097	.0572	.0953	.0953
20	.1143	.1463	.1334	.128	.0572	.1143	.0953
21	.1143	.1132	.1334	.128	.0572	.1143	.1132
22	.1334	.1509	.1143	.128	.0572	.1143	.1143
23	.1334	.1463	.1143	.1132	.0572	.1143	.1143
24	.1334	.1132	.1097	.0953	.3658	.3429	.1715
Max	.5601	.6979	.6859	.6036	.9335	.7621	.7287
Min	.0943	.1132	.0732	.0953	.0381	.0572	.0572
Avg	.2835	.2911	.2738	.2650	.2947	.3001	.2310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 202 / 11 kv RANJANGAON POL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.5658		.5716	.547	.5335	.4763
2	.9907	.6001		.6668	.5487	.5335	.4763
3	.9907	.7716		.7621	.679	.5335	.5144
4	1.0479	.8192		.9145	.6584	.5335	.5716
5	1.3336	1.0279		1.105	.6219	.5335	.5716
6	1.3336	1.1717		1.3336	.6602	.5335	.5906
7	1.5242	1.2193		1.4098	.6401	.4572	.5716
8	1.4289	1.1888		1.2384	.3658	.4572	.4763
9	.9145	1.1069		1.0479	.381	.4572	.381
10	.3429	.2012	.2286	.1829	.4191	.3772	.3395
11	.2858	.1886	.2286	.1886	1.2003	.6554	.6859
12	.2286	.1829	.1905	.2012	1.1431	.7682	.7373
13	.2286	.1886	.1905	.1829	1.105	.7373	.7125
14	.1905	.1886	.1905	.1829	1.0479	.7907	.6964
15	.2096	.2075	.1905	.2012	1.0479	.8421	.6802
16	.2286	.2195	.1905	.2195	1.0479	.8436	.7373
17	.3018	.2641	.2096	.2561	1.0479	.7865	.6554
18	.3772	.2641	.2286	.2561	1.0479	.7716	.5868
19	.5716		.381	.3658	.2858	.4191	.5144
20	.5716		.5716	.4755	.3429	.5716	.5716
21	.5716		.5716	.5487	.381	.5716	.5716
22	.4763		.4763	.5487	.4001	.5144	.5144
23	.4763		.4763	.5487	.4001	.5144	.4763
24	.8573	.5258		.5716	.5487	.4763	.4763
Max	1.5242	1.2193	.5716	1.4098	1.2003	.8436	.7373
Min	.1905	.1829	.1905	.1829	.2858	.3772	.3395
Avg	.6848	.5738	.3089	.5825	.6903	.5922	.5661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 204 / 11 KV RAJANGAON POL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2772		.2667	.2561	.3292	.2772
2	.3658	.2801		.3048	.2926	.3292	.2987
3	.4572	.3326		.381	.4904	.3658	.3326
4	.4572	.4024		.4763	.5487	.439	.4066
5	.5121	.5487		.5906	.6401	.5121	.5487
6	.5487	.7316		.724	.7316	.6401	.695
7	.7682	.8048		.8002	.8048	.7865	.7499
8	.695	.7316		.724	.6401	.8048	.6401
9	.5487	.5487		.5335	.3658	.4755	.5487
10	.4024		.4191	.3658	.2926	.3658	.4572
11	.3292		.3048	.3018	.2378	.2743	.2743
12	.2195		.2096	.1886	.2195	.1829	.1829
13	.2218		.1905	.1886	.1829	.1663	.1646
14	.2587		.1905	.1829	.1646	.1848	.168
15	.2378		.1905	.1646	.1829	.1848	.1494
16	.2561		.2286	.2926	.2195	.2033	.1848
17	.3658		.2858	.3658	.2743	.2587	.2195
18	.5121		.381	.3292	.3658	.2926	.2587
19	.5487		.5335	.3475	.5121	.3292	.4024
20	.5487		.4763	.3658	.439	.439	.5487
21	.4572		.4191	.4755	.3475	.4024	.4572
22	.3696		.381	.2743	.2926	.3696	.3658
23	.2772		.3048	.2561	.2561	.2957	.2957
24	.2667	.2587		.2667	.2926	.2561	.2801
Max	.7682	.8048	.5335	.8002	.8048	.8048	.7499
Min	.2195	.2587	.1905	.1646	.1646	.1663	.1494
Avg	.4147	.4916	.3225	.3820	.3771	.3703	.3711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.2572		.381	.1097	.1143	.0953
2	.6668	.3086		.4763	.0943	.1143	.0953
3	.724	.3772		.5716	.1097	.1143	.0953
4	.7621	.503		.6287	.0914	.1143	.1143
5	.7621	.5668		.724	.1097	.1143	.1524
6	.8573	.7287		.7621	.1097	.1334	.1524
7	.8764	.8002		.8573	.1097	.1334	.1334
8	.8573	.703		.8002	.0732	.1334	.0953
9	.0953	.5851		.724	.0762	.1334	.0762
10	.0572		.0381	.0566	.0381	.0953	.0572
11	.0381		.0381	.0377	.6478	.3429	.3688
12	.0381		.0191	.0377	.6287	.3932	.502
13	.0381		.0191	.0377	.5906	.3953	.4534
14	.0381		.0191	.0377	.5716	.3953	.4001
15	.0381		.0191	.0377	.5335	.4374	.421
16	.0381		.0191	.0549	.5144	.4902	.4096
17	.0572		.0191	.0366	.4954	.4915	.426
18	.0762		.0191	.0366	.4763	.4024	.4578
19	.0953		.0953	.0549	.0762	.0953	.0953
20	.1143		.0953	.0732	.0953	.1143	.1143
21	.1143		.1143	.1097	.1143	.1143	.1143
22	.1143		.1143	.0914	.1143	.1143	.1143
23	.1143		.1143	.1097	.1143	.1143	.1143
24	.4001	.1402		.381	.0732	.1143	.1143
Max	.8764	.8002	.1143	.8573	.6478	.4915	.502
Min	.0381	.1402	.0191	.0366	.0381	.0953	.0572
Avg	.3144	.497	.0531	.2966	.2487	.2173	.2155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 206 / 11 KV GAWALI SHIWARA AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 FEEDER Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.0953		.0953	.2012	.1905	.1267
2	.0762	.0953		.0953	.1829	.2286	.1463
3	.0953	.1143		.1143	.1829	.2286	.1402
4	.0762	.1334		.1143	.1829	.2667	.1578
5	.0953	.1334		.1143	.2012	.2667	.1715
6	.0762	.1334		.1334	.2195	.2858	.2058
7	.0762	.1334		.1334	.2452	.2858	.2572
8	.0953	.1143		.1143	.2561	.3429	.2401
9	.0572	.0762		.0953	.3048	.3429	.2058
10	.0572		.0953	.1463	.0381	.0953	.0572
11	.1715		.1905	.1886	.0381	.0762	.0381
12	.2229		.2286	.1886	.0381	.0762	.0381
13	.2058		.2667	.2075	.0191	.0572	.0381
14	.2401		.2286	.1886	.0191	.0572	.0381
15	.2572		.1905	.1829	.0191	.0572	.0381
16	.2572		.1905	.1829	.0191	.0572	.0381
17	.1715		.1715	.1829	.0191	.0762	.0572
18	.1578		.1524	.1646	.0762	.0762	.0572
19	.0953		.0953	.1097	.0762	.0953	.0953
20	.1143		.1143	.0732	.0762	.0953	.1143
21	.1143		.1143	.0914	.0762	.0953	.1143
22	.1334		.1143	.0732	.0762	.0953	.1143
23	.1334		.0953	.0732	.0762	.0953	.1143
24	.0762	.1143		.0953	.1829	.1905	.1097
Max	.3292	.1334	.2667	.2075	.3048	.3429	.2572
Min	.0572	.0762	.0953	.0732	.0191	.0572	.0381
Avg	.1411	.1143	.1606	.1316	.1178	.1556	.1131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 207 / 11KV KBS INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191		.0381	.0183	.0191	.0191
2	.0191	.0191		.0381	.0183	.0191	.0191
3	.0191	.0191		.0381		.0191	.0191
4	.0191	.0191		.0381	.0183	.0191	.0191
5	.0191	.0191		.0381	.0183	.0191	.0191
6	.0191	.0191		.0381	.0189	.0191	.0191
7	.0191	.0191		.0381	.0183	.0191	.0191
8	.0191	.0191		.0381	.0183	.0191	.0191
9	.0191	.0191		.0381	.0191	.0191	.0191
10	.0189	.0183	.0381	.0183	.0191	.0191	.0191
11	.0191	.0189	.0381	.0189	.0191	.0191	.0191
12	.0191	.0189	.0381	.0183	.0191	.0191	.0191
13	.0191	.0183	.0381	.0189	.0191	.0191	.0191
14	.0191	.0189	.0381	.0183	.0191	.0191	.0191
15	.0191	.0189	.0381	.0189	.0191	.0191	.0191
16	.0191	.0189	.0381	.0183	.0191	.0191	.0191
17	.0191	.0189	.0381	.0183	.0191	.0191	.0191
18	.0191	.0183	.0381	.0183	.0191	.0191	.0191
19	.0191	.0189	.0381	.0189	.0191	.0191	.0191
20	.0191	.0189	.0381	.0183	.0191	.0191	.0191
21	.0191	.0189	.0381	.0183	.0191	.0191	.0191
22	.0191	.0183	.0381	.0183	.0191	.0191	.0191
23	.0191	.0183	.0381	.0189	.0191	.0191	.0189
24	.0191	.0191		.0381	.0183	.0191	.0191
Max	.0191	.0191	.0381	.0381	.0191	.0191	.0191
Min	.0189	.0183	.0381	.0183	.0183	.0191	.0189
Avg	.0191	.0189	.0381	.0267	.0188	.0191	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 208 / Dhananjay auto  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524		.1524	.1097	.1524	.0953
2	.1334	.1334		.1524	.128	.1715	.1494
3	.1524	.1334		.1524	.1463	.1715	
4	.1143	.1334		.1524	.1463	.1905	.1334
5	.1715	.1524		.1524	.128	.1905	.1494
6	.1715	.1524		.1524	.1463	.1905	.1494
7	.1715	.1715		.1524	.1463	.1905	.1867
8	.0953	.1905		.0953	.1463	.1715	.1905
9	.0953	.1905		.0953	.1143	.1715	.1524
10	.1307	.1097	.1715	.1097	.0953	.1524	.168
11	.1494	.1463	.1715	.0943	.0762	.1334	.1905
12	.1334	.1646	.1715	.0914	.0762	.1334	.1867
13	.1334	.0732	.1524	.1097	.0762	.1143	.168
14	.1143	.0732	.1524	.0914	.0762	.1524	.1524
15	.1494	.0377	.1524	.0914	.0762	.1715	.1494
16	.1494	.0377	.1524	.1097	.0762	.1524	.1307
17	.1494	.0366	.1524	.128	.0762	.1524	.168
18	.168	.0732	.1524	.128	.0762	.1307	.1715
19	.1524	.1132	.1524	.1097	.0953	.1143	.1494
20	.1334	.1097	.1524	.128	.1143	.1143	.1334
21	.1334	.132	.1524	.132	.1143	.0953	.132
22	.1334	.1698	.1524	.128	.0762	.0953	
23	.1143	.1463	.1524	.128	.0762	.1143	.1334
24	.0953	.1143		.1524	.1097	.0762	.1143
Max	.1715	.1905	.1715	.1524	.1463	.1905	.1905
Min	.0953	.0366	.1524	.0914	.0762	.0762	.0953
Avg	.1382	.1228	.1565	.1245	.1043	.1460	.1525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 201 / 11 KV AMINABAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.3413	1.5261	1.3375	.3772	.3395	.3582
2	2.13	1.5089	1.6956	1.4403	.3772	.3772	.394
3	2.1795	1.6766	1.8275	1.5424	.3772	.4527	.394
4	2.1605	1.8275	2.0553	1.8442	.415	.4527	.4298
5	2.1605	2.0119	2.2874	2.1216	.4715	.4904	.4607
6	2.2725	2.5149	2.4577	2.2996	.1886	.547	.4207
7	2.8121	3.1855	2.9007	3.1741	.4715	.5281	.3189
8	3.1089	3.1855	3.2442	3.0769	.415	.4715	.3189
9	1.6385	2.5149	2.652	2.5587	.2452	.3395	.2865
10	.2829	.2641	.2987	.2241	.2263	.2641	.2507
11	.2452	.1772	.2614	.1886	3.152	2.8292	3.2861
12		.2481	.2263	.1886	3.1855	2.7639	3.1786
13			.2241	.1886	3.1687	2.8502	3.2442
14	.2075			.1509	3.2693	2.4366	2.982
15	.2263	.1791		.1886		2.7035	2.9165
16	.2829	.2126	.2614	.1867	2.5149	2.7526	2.9492
17	.3395	.2126	.2987	.1886	3.1855	2.7515	2.9165
18	.3584	.3012	.2957	.1886	2.6825	2.3205	2.6216
19	.3772	.3898	.4066	.4668	.4904	.4252	.4108
20	.4715	.3898	.3696	.4715	.5093	.443	.4435
21	.3772	.3544	.3326	.415	.4527	.3982	.4435
22	.3206	.2835	.2957	.3772	.415	.3898	.4108
23	.2829	.2126	.2587	.3772	.3772	.4298	.4108
24	2.0119	1.1736	1.3375	1.2003	.3772	.3395	.3761
Max	3.1089	3.1855	3.2442	3.1741	3.2693	2.8502	3.2861
Min	.2075	.1772	.2241	.1509	.1886	.2641	.2507
Avg	1.1915	1.0984	1.1597	1.0165	1.1889	1.1707	1.2593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 202 / 11 KV WARKHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2103	.1886	1.1145	1.3077	1.491
2			.2149	.1886	1.2209	1.3413	1.6804
3			.2149	.2263	1.3748	1.5089	1.8991
4			.2149	.2263	1.5565	1.9281	2.079
5			.2149	.2641	1.7404	2.1795	2.1879
6			.2328	.2987	1.9662	2.3807	2.2939
7			.2303		2.2939	2.7328	1.9662
8			.2303		2.6216	2.8669	2.4577
9			.1612		2.3266	2.7496	2.572
10			.1132	.1698	.1509		
11	1.8778	2.5549	3.0445	2.7854	.132		
12	3.0849	2.2291	3.1093	2.8807			
13	1.6766	3.0864	3.0769	2.7526			
14	3.0849	3.3913		2.6246			
15	2.7831	3.3234		2.7854			
16	2.9508	3.3196	3.1093	2.6408	.1132		
17	2.7831	2.9504	3.1741	2.7206	.0754		
18	2.0454	2.6216	2.6216	2.5149	.1886		
19			.3018	.2263	.3018		
20		.1612	.3772	.3018	.3206		
21		.2149	.3018	.2829	.3018		
22		.2743	.2641	.1886	.2641		
23		.2865	.2263	.1509	.2263		
24			.2058	.2263	1.1145	1.1736	1.2971
Max	3.0849	3.3913	3.1741	2.8807	2.6216	2.8669	2.572
Min	1.6766	.1612	.1132	.1509	.0754	1.1736	1.2971
Avg	2.5358	2.0345	.9932	1.1735	.9702	2.0169	1.9924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 203 / 11 KV WAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0754	.0895	.1132	.9431	.7545	1.0749
2	.1132	.0566	.0895	.1132	1.0059	.8383	1.1317
3	.1132	.0566	.0895	.1132	1.0774	.9221	1.2346
4	.1132	.0566	.1063	.132	1.1271	1.0059	1.2887
5	.132	.0566	.1063	.132	1.0688	1.1736	1.4255
6	.132	.0566	.124	.132	1.4243	1.3916	1.5402
7	.1132	.0566	.1254	.132		1.643	1.1797
8	.1132	.0566	.1063	.1132	1.4413	1.7436	2.0153
9	.0943	.0566	.0716	.1132	1.2289	1.7269	1.8983
10	.0943	.0754	.0754	.0754	.0943	.0943	.0724
11	1.4922	1.9806	1.7532	1.6712	.0566	.0532	.0566
12	1.7772	1.9376	1.749	1.7532		.0532	
13	1.9616	1.8861	1.5223	1.7185		.0895	
14	1.576	1.8143		1.7711		.0709	
15	1.9281	1.8275		1.7695		.0537	
16	1.8778	1.8107	1.7004	1.6804	.0566	.0716	
17	1.5927	1.8067	1.749	1.6644	.0377	.0709	.0566
18	1.3413	1.6907	1.5729	1.6448	.0566	.0716	.0566
19	.132	.0995	.1509	.0943	.0754	.1075	.0754
20	.132	.1063	.1509	.0943	.1132	.0895	.1132
21	.132	.0895	.132	.0943	.1132	.0905	.0754
22	.1132	.1075	.132	.0754	.0943	.0716	.0754
23	.1132	.1254	.1132	.0566	.0943	.0724	.0754
24	.1132	.0943	.1075	.1132	.9431	.6706	1.0277
Max	1.9616	1.9806	1.7532	1.7711	1.4413	1.7436	2.0153
Min	.0943	.0566	.0716	.0566	.0377	.0532	.0566
Avg	.6423	.6658	.5371	.6404	.5817	.5388	.7618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 204 / 11KV GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.3772	.4298	.3696	.3734	.3772	.4119
2	.4715	.4527	.5194	.3696	.4668	.5281	.4656
3	.5544	.5281	.6089	.4066	.5175	.6413	.5194
4	.5658	.6602	.691	.4435	.7023	.7545	.5959
5	.8871	.7545	.8596	.5853	.8501	.8488	.8505
6	1.1458	1.0374	1.0029	.9145	1.0269	1.0562	1.0029
7	1.1088	1.0751	1.0099		1.0164	1.094	.9922
8		.9808			.8316	.9431	.9214
9	.7655	.9054	.8596		.8413	.8488	.7265
10	.7762	.7545	.6283	.6584	.5914	.6224	.543
11	.6036	.3856	.4066	.5544	.4904	.4607	.4066
12		.2835	.3326	.3361		.4075	
13			.2957	.2801		.3045	
14	.5281			.2641		.3224	
15	.6224	.3086		.1886		.3077	
16	.6413	.3544	.2957	.3326	.4338	.3224	
17	.7545	.4607	.4435	.4251	.3206	.4119	.4435
18	.8299	.567	.5853	.5175	.6413	.4656	.5914
19	.8865	.9214	.9145	.8871	.9054	.8505	.9511
20	.7167	.7973	.6584	.8316	.8488	.8238	.8779
21	.6036	.7164	.5853	.5658	.7545	.5731	.6219
22	.5281	.5138	.4805	.4668	.4715	.4961	.5544
23	.4527	.4656	.4066	.3772	.3772	.4344	.4435
24	.4338	.3772	.3761	.3734	.3772	.3772	.3898
Max	1.1458	1.0751	1.0099	.9145	1.0269	1.094	1.0029
Min	.4338	.2835	.2957	.1886	.3206	.3045	.3898
Avg	.6814	.6217	.5900	.4832	.6419	.5947	.6479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 205 / 11KV MUDDESH WADGAON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 FEEDER Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	.7545	.2149	.823	.1132	.0943	.1448
2	1.5432	1.0898	.1791	.9389	.1132	.1132	.1433
3	1.5261	1.358	.1772	1.0395	.132	.1132	.1417
4	1.6766	1.5089	.1612	1.2266	.132	.132	.1417
5	1.8023	1.6766	.1595	1.4746	.132	.132	.1433
6	1.95	1.861	.1791	1.9109	.1698	.1509	.1595
7	2.3266	2.0119	.1772	2.1862	.1509	.1698	.1612
8	2.4249	1.6766	.2328	2.332	.1132	.1509	.1433
9	2.1026	1.9951	.1791	2.0972	.0754	.0943	.1086
10	.0754	.0754	.0189	.0943	.0566	.0754	.0724
11	.0566	.0716		.0943	2.2801	2.5892	2.4086
12	.0566	.0686		.0566	2.2131	2.7469	2.6235
13	.0754	.0709	.1132	.0566	2.5652	2.5194	1.1736
14	.0566	.0709		.0566	2.3137	2.3922	1.5089
15	.0566	.0709		.0566		2.4577	2.4905
16	.0566	.0716	.132	.0566	2.3472	2.343	2.4291
17	.0566	.0709	.132	.0377	2.5316	2.42	2.4741
18	.0566	.0709	.1132	.0566	2.431	1.9062	2.0809
19	.0943	.0716	.3584	.132	.1509	.1433	.1509
20	.1509	.1063	.1886	.132	.1886	.1629	.132
21	.132	.0886	.1698	.132	.1509	.181	.132
22	.1132	.0886	.1509	.1132	.1132	.1791	.132
23	.0943	.0709	.132	.1132	.1132	.1612	.132
24	1.4413		.823	.7545	.1132	.0943	.1433
Max	2.4249	2.0119	.823	2.332	2.5652	2.7469	2.6235
Min	.0566	.0686	.0189	.0377	.0566	.0754	.0724
Avg	.8076	.6522	.1996	.6655	.8131	.8968	.8071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 201 / 11 KV DONGAON AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2984	.2743	.2652	.4481	.3772	.3772
2	.1715	.2984	.2743	.2652	.4904	.3961	.5658
3	.2572	.3315	.2743	.2984	.5175	.4904	.6413
4	.3429	.3315	.2915	.3149	.5914	.5658	.6413
5	.4191	.4641	.3018	.431	.6104	.7545	.679
6	.4694	.4973	.3812	.4915	.7716	.9054	.811
7	.5801	.5407	.6554	.5571	.8551	.9431	.8488
8	.547	.3978	.5079	.5304	.6299	.7733	.7922
9	.3647	.547	.2949	.5847	.4694	.6036	.6036
10	.2641	.4527	.2641	.3361	.3149	.3772	.3395
11	.2829	.3018	.2263	.2543	.2486	.1802	.1696
12	.3018	.2641	.2452	.2347	.2321	.1638	.1865
13	.2641	.2263	.2452	.2155	.2155	.1844	.1696
14	.2829	.3206	.2263	.218	.2155	.1677	.1696
15	.3018	.2829	.2075	.1989	.1989	.1844	.2035
16	.3584	.2829	.2452		.1989	.2263	.2204
17	.5281	.3018	.3018	.3142	.1989	.2012	.2035
18	.547	.415	.3206	.3361	.2155	.1844	.2035
19	.5658	.5658	.5658	.5601	.5658	.5658	.547
20	.5847	.6036	.6036	.6348	.5847	.547	.6036
21	.5281	.4904	.5658	.547	.547	.5093	.5847
22	.4715	.3772	.4904	.4481	.4715	.4527	.547
23	.3395	.3018	.2683	.4294	.4338	.3772	.5093
24	.1372	.1658	.2915	.2818	.3734	.3772	.3772
Max	.5847	.6036	.6554	.6348	.8551	.9431	.8488
Min	.1372	.1658	.2075	.1989	.1989	.1638	.1696
Avg	.3777	.3775	.3468	.3803	.4333	.4378	.4581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 202 / 11 KV RAIPUR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4641	.3944	.431	.6348	.5281	.5847
2	.3429	.4641	.3429	.4641	.679	.5281	.7167
3	.5144	.4807	.3772	.4641	.7023	.5658	.7545
4	.8573	.4973	.4287	.4752	.7762	.6224	.8488
5	.9221	.5636	.503	.5898	.7969	.7545	.9431
6	1.0059	.6299	.8122	.6554	.9945	.8488	1.1317
7	.9779	.6554	.9831	.6718	.9389	.9242	1.1694
8	.9945	.8192	.8192	.7127	.7127	.7167	1.1317
9	.663	.6413	.5898	.7356	.6203	.6413	.8488
10	.3395	.5658	.3395	.5228	.4973	.3768	.6224
11	.3772	.415	.3395	.3561	.3315	.426	.373
12	.3584	.3772	.3584	.3018	.3149	.4096	.3353
13	.3772	.415	.3018	.2818	.3395	.4024	.3222
14	.3961	.4904	.2641	.3353	.2984	.3856	.2883
15	.3772	.5093	.2641	.3149	.2652	.4024	.3018
16	.4904	.5847	.3018	.3391	.2486	.4191	.3052
17	.547	.5658	.3395	.4066	.2652	.4024	.3052
18	.6036	.679	.4338	.4481	.3149	.285	.3391
19	.9054	.9054	.8865	.7095	.7356	.8676	.6979
20	.9431	.9431	.9431	.7655	.8299	.9808	.7922
21	.811	.7545	.8299	.7545	.7545	.9431	.7545
22	.7545	.6602	.7545	.7095	.7167	.7545	.7167
23	.547	.5658	.3315	.6535	.6413	.6036	.6602
24	.3944	.3978	.3772	.3812	.5975	.6036	.5658
Max	1.0059	.9431	.9831	.7655	.9945	.9808	1.1694
Min	.3395	.3772	.2641	.2818	.2486	.285	.2883
Avg	.6185	.5852	.5132	.5200	.5836	.5997	.6462



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 203 / 11 KV PADALSA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6036	.6413	.6413	.4854	.5636	.5316
2	.6602	.679	.6602	.6413	.5228	.5636	.5487
3	.9431	.7356	.7545	.7167	.5544	.5967	.5144
4	1.226	.9431	.8488	.9054	.6283	.663	.5144
5	1.3203	1.1128	.9431	1.0374	.6104	.8122	.5365
6	1.4335	1.226	1.2449	1.226	.7373	.9116	.7293
7	1.3203	1.3392	1.3769	1.3203	.9221	.9945	1.1469
8	1.1128	1.2449	1.2449	1.1506	1.1271	1.094	1.1305
9	.9242	1.0751	.9054	1.0374	.6371	.9054	.6133
10	.7545	.6036		.5228	.4904	.5093	.4527
11	.7127	.7625	.663	.5935	.3395	.3018	.3584
12	.6464	.663	.6299	.57	.3018	.3395	.3772
13	.5801	.5801		.4973	.3206	.2452	.2075
14	.547	.5636	.5967	.4694	.3395	.2263	.2452
15	.5801	.547	.4973	.4807	.3395	.2452	.2829
16	.6133	.6133	.5281	.5596	.3395	.2641	.3395
17	.6464	.6299	.5658	.6468	.3772	.3772	.3584
18	.6602	.5304	.5847	.6348	.4904	.5658	.5093
19	.9242		.9242	.9522	.9808	1.0374	.7167
20	.9808	.9242	1.0374	1.0082	.8676	1.1506	1.0751
21	.8676	.7922	.8488	.8488	.8299	.7733	1.0185
22	.7733	.7545	.7545	.7282	.7167	.7167	.9054
23	.6979	.6602	.679	.679	.5967	.679	.3988
24	.6602	.6413	.6224	.6413	.4527	.3812	.5144
Max	1.4335	1.3392	1.3769	1.3203	1.1271	1.1506	1.1469
Min	.547	.5304	.4973	.4694	.3018	.2263	.2075
Avg	.8428	.7924	.7978	.7712	.5837	.6216	.5844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 201 / 11 KV ZANZARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0914	.1844	.0943	2.3087	2.0873	2.0873
2	.0995	.0914	.1677	.0754	2.3087	2.0873	2.1032
3	.1174	.0914	.1677	.0754	2.3403	2.0873	2.1376
4	.1341	.1097	.1844	.0754	2.4352	2.1506	2.2245
5	.1509	.1294	.2012	.1698	2.4985	2.2455	2.2405
6	.1677	.1698	.2012	.2075	2.5934	2.6882	2.7526
7	.2012	.2075	.218	.2075	2.7831	2.9412	3.062
8	.1341	.2075	.1844	.2075	3.0045	3.0045	3.1245
9	.1006	.1886	.1677	.1698	2.9412	2.8464	2.7778
10	.0914	3.3532	.1677	.112	.0914	.1097	.132
11	3.2808	3.7891	3.2167	3.3208	.0732	.0566	.0943
12	3.7635	4.0238	3.3208	3.6687	.0549	.0377	.0943
13	3.8268	4.0908	3.4568	3.7635	.0549	.0377	.0754
14	3.9217	4.1579	3.3432	3.637	.0549	.0377	.0566
15	3.7952	3.9903	3.4088	3.4947	.0549	.0377	.0377
16	3.637	3.7891	3.1943	3.4473	.0549	.0377	.0377
17	3.4473	3.4873	3.2007	3.3524	.0732	.0377	.0377
18	3.2891	3.3532	3.0836	2.9412	.0732	.0943	
19	.0914	.1341	.2075	.0924	.0732	.1509	.132
20	.1097	.1509	.1886	.1097	.0914	.1698	.1698
21	.1097	.1677	.1698	.1109	.0914	.132	.132
22	.0914	.1844	.132	.0914	.0732	.0943	.0943
23	.0914	.2012	.0754	.0914	.0732	.0943	.0754
24	.0838	.0914	.2012	.0754	2.2138	2.0557	1.9766
Max	3.9217	4.1579	3.4568	3.7635	3.0045	3.0045	3.1245
Min	.0671	.0914	.0754	.0754	.0549	.0377	.0377
Avg	1.2835	1.5105	1.2102	1.2330	1.1006	1.0551	1.1155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 202 / 11 KV PENDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.4877	.5365	.5376	.0716	.0914	.0754
2	.7042	.4877	.6036	.5312	.0537	.0732	.0754
3	.7377	.503	.6706	.5668	.0537	.0732	.0943
4	.7712	.5487	.7042	.578	.0537	.0914	.0943
5	.8048	.6097	.7377	.6249	.0724	.0914	.1132
6	.8383	.6706	.7712	.6722	.0914	.1097	.132
7	.8718	.7621	.8048	.6964	.1109	.1294	.1132
8	.823	.9145	.8215		.0914	.1109	.0943
9	.8535	.9145	.8383	.7811	.0732	.0914	.0566
10	.0366	.0335	.0503	.0732	.0732	.0914	.0566
11	.0732	.0335	.0754	.0732	.823	.8065	.7811
12	.0732	.0335	.0566	.0549	.9145		.7522
13	.0549	.0503	.0566	.0549	.7926	.7116	.7811
14	.0549	.0503	.0566	.0549	.7926		.7432
15	.0549	.0503		.0549	.7621	.6405	.6882
16	.0549	.0503	.0566	.0549	.7621	.6882	.6642
17	.0549	.0503	.0566	.0549	.7011	.7186	.759
18	.0549	.0503		.0549	.6401	.7042	
19	.0732	.0838	.0754	.0732	.0914	.0754	.0754
20	.0732	.1006	.0754	.1097	.128	.0943	.0943
21	.0732	.1174	.0943	.1097	.1097	.0943	.0943
22	.0549	.1174	.0754	.0914	.0732	.0943	.0754
23	.0549	.1006	.5312	.0914	.1097	.0754	.0754
24	.6036	.4572	.503	.4999	.0724	.0732	.0754
Max	.8718	.9145	.8383	.7811	.9145	.8065	.7811
Min	.0366	.0335	.0503	.0549	.0537	.0732	.0566
Avg	.3550	.3032	.3751	.2824	.3132	.2605	.2854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 203 / 11KV BABARGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.1279	1.2071	1.3592			
2		1.142	1.4754	1.406			
3	2.1125		1.6766	1.4575			
4	2.2131	1.2346	2.079	1.5384			
5	2.3472	1.3748	2.3137	1.7604			
6	2.4143	1.7711	2.5819	2.1872			
7	2.4813	2.372	2.6825	2.3434			
8	2.3472		2.3807	2.4215			
9	2.2466		2.146	2.0557			
11					2.3403	2.4806	2.3434
12					2.5934	2.372	2.3805
13					2.5301	2.2405	2.3365
14					2.451	2.0873	2.2929
15					2.4036	1.9528	2.2138
16					2.3403	1.906	2.1822
17					2.2138	1.8976	2.2138
18					2.0873	1.9204	
23			1.2498				
24	1.6766	1.0364	1.1736	1.2967			
Max	2.4813	2.372	2.6825	2.4215	2.5934	2.4806	2.3805
Min	1.6766	1.0364	1.1736	1.2967	2.0873	1.8976	2.1822
Avg	2.1833	1.4370	1.9060	1.7826	2.3700	2.1072	2.2804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 204 / 11KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0152	.0168	.017	.0152	.0152	.0177
2	.0168	.0152	.0168	.0171	.0152	.0152	.0173
3	.0168	.0152	.0168	.017	.0152	.0152	.017
4	.0168	.0152	.0168	.017	.0152	.0152	.0173
5	.0168	.0152	.0168	.017	.0152	.0152	.017
6	.0335	.0152	.0168	.0164	.0152	.0152	.017
7	.0335	.0152	.0168	.0156	.0152	.0152	.0175
8		.0152	.0297	.0754	.0537	.0537	.0754
9	.0168	.0151	.0671	.0754	.0537	.0732	.0754
10	.0149	.0168	.0671	.0924	.0724	.0732	.0754
11	.0149	.0168	.0747	.0724	.0543	.0754	.0943
12	.0149	.0168	.0566	.0724	.0543	.0566	.0754
13	.0149	.0168	.0566	.0732	.0543	.0566	.0566
14	.0149	.0168	.0566	.0724	.0537	.0754	.0566
15	.0149	.0168	.0566	.0724	.0537	.0943	.0754
16	.0149	.0168	.0566	.0724	.0537	.0943	.0754
17	.0149	.0168	.0747	.0732	.0724	.0943	.0566
18	.0149	.0168	.0943	.0543	.0724	.0754	
19	.0152	.0168	.0532	.0537	.0543	.0732	.0554
20	.0152	.0168	.0566	.0537	.0335	.0549	.0566
21	.0152	.0168	.0554	.0537	.0335	.0373	.0175
22	.0152	.0168	.0373	.0537	.0152	.0187	.0175
23	.0152	.0168		.0152	.0152	.0173	.0175
24	.0168	.0152	.0168	.0156	.0152	.0152	.0173
Max	.0335	.0168	.0943	.0924	.0724	.0943	.0943
Min	.0149	.0151	.0168	.0152	.0152	.0152	.017
Avg	.0172	.0161	.0447	.0487	.0384	.0477	.0443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 047022 / 132 KV SUB-STATION GANGAPUR

Feeder No / Name : 403 / R.G.LIS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.8292
Max	2.8292
Min	2.8292
Avg	2.8292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 201 / 11KV KHULTABAD-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.679	.6173	.7545	.6516	.7202	.7202
2	.7202	.679	.6344	.7545	.6173	.7202	.703
3	.6859	.7545	.6344	.679	.6687	.7545	.6687
4	.703	.7545	.6687	.679	.7545	.7716	.7202
5	.7545	.7202	.703	.7545	.7888	.7716	.7545
6	.7888	.8676	.7545	.8299	.8402	.8059	.8573
7	.823	.9431	.8402	.8676	.8916	.823	.9088
8	.7888	1.0562	.7545	.9054	.8573	.8573	.7888
9	.823	1.0185	.7545	.9054	.8059	.7682	.7545
10	.7545	1.0059	.7202	.9511	.7499	.7682	.583
11	.7202	.9877	.7545	.9145	.7499	.8413	.7545
12	.7373	1.0242	.7202	.9145	.7682	.7865	.8299
13	.7716	.8413	.703	.8413	.7682	.8413	.8299
14	.703	.8048	.703	.823	.6036	.7499	.8299
15	.6859	.7316	.7888	.7865	.7922	.7682	.7545
16	.703	.7499	.7373	.7865	.7682	.7865	.7545
17	.8299	.703	.7922	.7545	.7716	.7545	.7545
18	.8676	.7545	.8676	.7888	.7202	.9431	.8573
19	1.1317	.8402	1.1317	.8916	.9774	1.1317	1.0631
20	1.1317	.823	1.0658	.9259	.9774	1.1317	1.0288
21	.9431	.7373	1.0185	.823	.8573	.9774	1.046
22	.9431	.6859	.9431	.7202	.8916	.9088	.9259
23	.8676	.6687	.8676	.703	.823	.823	.823
24	.703	.7545	.6001	.8299	.6859	.7202	.7716
Max	1.1317	1.0562	1.1317	.9511	.9774	1.1317	1.0631
Min	.6687	.6687	.6001	.679	.6036	.7202	.583
Avg	.8020	.8160	.7823	.8160	.7825	.8302	.8118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 202 / 11 KV SULIBHANJAN AG  
FEEDER Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.6852	.5639	.679	.2743	.2915	.2439
2	.6401	.679	.5487	.679	.2896	.2915	.2439
3	.7316	.679	.6097	.679	.2591	.3086	.2591
4	.9145	.6859	.6249	.7545	.2439	.3429	.2134
5	1.0974	.9431		.8755	.3048	.3772	.2896
6	1.4632	1.2071		1.0185	.3658	.4287	.3048
7	1.9662	2.2634		2.0748	.381	.4115	.381
8	1.9662	2.3388	1.3108	2.7161	.2896	.3086	.2896
9	.1981	1.3717	.1219	1.6975	.1372	.218	.2286
10	.1372	.218	.1029	.1844	.1677	.1677	.2641
11	.1543	.1341	.1372	.1677	1.6263	1.358	1.1317
12	.0857	.1509	.12	.1174	1.5089	1.3413	1.3203
13		.1509	.1543	.1017	1.4251	1.2239	1.3203
14		.1341	.1543	.1006	1.1233	.9389	1.1317
15	.0686	.1174	.1372	.1341	1.1361	.7316	.9088
16	.12	.1341	.12	.1341	1.1065	.9389	.9602
17	.3018	.1067	.1509	.1372	1.0974	1.2449	.9088
18	.2263	.1372	.1886	.1524	.7373	1.0562	.6344
19	.3018	.2439	.3018	.2439	.2572	.2641	.2572
20	.3395	.2591	.3395	.2591	.3086	.3772	.2915
21	.3395	.2134	.2641	.2286	.2915	.2896	.3086
22	.2641	.1829	.2263	.2134	.3086	.2591	.3086
23	.2263	.2134	.2263	.1981	.3086	.2591	.3086
24	.4572	.7545	.5792	.7545	.2134	.2915	.2439
Max	1.9662	2.3388	1.3108	2.7161	1.6263	1.358	1.3203
Min	.0686	.1067	.1029	.1006	.1372	.1677	.2134
Avg	.5690	.5835	.3325	.5959	.5901	.5717	.5314



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 203 / 11 KV T. V. Centre  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0171	.0343	
2						.0343	
3						.0343	
4						.0343	
5			.0171		.0171	.0343	.0343
6		.0381	.0343	.0377	.0343	.0343	.0343
7		.0377	.0343	.0377	.0343	.0343	.0343
8	.0343	.0377	.0343	.0377	.0343	.0343	.0343
9	.0343	.0377	.0343	.0377	.0343	.0335	.0343
10	.0343	.0366	.0343	.0366	.0366	.0366	.0377
11	.0343	.0366	.0343	.0366	.0366	.0366	.0377
12	.0343	.0366	.0343	.0366	.0366	.0366	.0377
13	.0514	.0366	.0514	.0366	.0366	.0366	.0377
14	.0343	.0366	.0514	.0366	.0335	.0366	.0377
15	.0514	.0366	.0514	.0366	.0377	.0366	.0514
16	.0514	.0339	.0514	.0366	.0366	.0366	.0343
17	.0566	.0514	.0377	.0343	.0343	.0377	.0343
18	.0566	.0343	.0377	.0343	.0343	.0377	.0343
19	.0377	.0343	.0377	.0343	.0343	.0377	.0343
20	.0377	.0343	.0377	.0343	.0343	.0377	.0343
21	.0377	.0343	.0377	.0343	.0343	.0343	.0343
22	.0377	.0343	.0377	.0343	.0343	.0343	.0343
23	.0377	.0343	.0377	.0343	.0343	.0343	.0343
24	.0171	.0377	.0343		.0343	.0343	.0343
Max	.0566	.0514	.0514	.0377	.0377	.0377	.0514
Min	.0171	.0339	.0171	.0343	.0171	.0335	.0343
Avg	.0399	.0368	.0381	.0360	.0333	.0355	.0360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 204 / 11KV ELLORA MANDIR  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3807	.3429	.4527	.4458	.4115	.4287
2	.3601	.3772	.2915	.4527	.4973	.4115	.4287
3	.3429	.415	.3258	.4904	.4801	.4458	.5487
4	.4458	.4527	.3429	.5658	.583	.5487	.6173
5	.583	.679	.4115	.6413	.6687	.6173	.6859
6	.7545	.8676	.7545	.7922	.8059	.7373	.7716
7	.823	.8299	.9088	.9431	.823	.8916	.7888
8	.7545	.8676	.7545	.8755	.7545	.703	.7716
9	.6687	.7545	.6687	.8676	.6344	.6401	.7545
10	.6173	.5765	.5144	.7865	.567	.567	
11	.5144	.6401	.4801	.567	.547	.439	.4904
12	.4458	.567	.4115	.5121	.4755	.3292	.3772
13	.4115	.5121	.4287	1.0608	.439	.2743	.3772
14	.4115	.4287	.4115	.5121	.439	.4572	.3772
15	.4973	.4755	.4458	.439	.439	.5121	.4115
16	.4973	.5121	.5658	.439	.439	.439	.4801
17	.6036	.6173	.679	.4458	.4801	.4904	.5487
18	.679	.6687	.8676		.5316	.6413	.6344
19	.7545	.7888	.7613	.4801	.7373	.7545	.7888
20	.7545	.823	.679	.6687	.6173	.7545	.6859
21	.6413	.6859	.6413	.5144	.5658	.583	.6687
22	.5658	.6687	.5658	.4973	.5487	.5487	.583
23	.4904	.5144	.4904	.3772	.463	.4801	.5144
24	.9259	.3772	.4458	.4527	.3944	.4115	.463
Max	.9259	.8676	.9088	1.0608	.823	.8916	.7888
Min	.3429	.3772	.2915	.3772	.3944	.2743	.3772
Avg	.5786	.6033	.5495	.6015	.5574	.5454	.5738

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 205 / 11 KV KASABKHEDA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2641	.2286	.2263	.381	.4287	
2	.2058	.2641	.2439	.2641	.4115	.4801	
3	.1886	.3018	.1981	.2641	.442	.4801	
4	.2229	.3018	.2134	.2641	.5182	.5144	
5	.2572	.3018	.2896	.3018	.5487	.583	
6	.3258	.3395	.2743	.3772	.5792	.6516	
7	.3601	.415	.3201	.3772	.9145	1.0631	
8	.3048	.3772	.2743	.3018	.8078	1.166	
9	.1677	.2641	.1829	.2641	.2743	1.0227	
10	.1372	.2515	.1543	.1844	.1677	.1677	
11	.9774	.8718	.7716	.8383	.1844	.1677	
12	.9774	.8048	.7716	.8048	.1844	.1867	.0377
13	.7545	.6906	.6687	.6706	.1844		.1886
14	.6173	.6203	.583	.5868	.1341	.1509	.1509
15	.6859	.6371	.5658	.5868	.1174	.1174	.1372
16	.7373	.6371	.7167	.57	.1174	.1509	.12
17	.7545	.6249	.7545	.4572	.12	.1886	.1372
18	.7545	.5487	.571		.1543	.1886	.2058
19	.2263	.2743	.3018	.2439	.2229	.2641	.2743
20	.3018	.2134	.3018	.2134	.2229	.2641	.2572
21	.3018	.3258	.2641	.2286	.2058	.1829	.2229
22	.2641	.2915	.2641	.1981	.2229	.1677	.2058
23	.2641	.1886	.2641	.1677	.1715	.1524	.1715
24	.2134	.2641	.2134	.2263	.3201	.4287	
Max	.9774	.8718	.7716	.8383	.9145	1.166	.2743
Min	.1372	.1886	.1543	.1677	.1174	.1174	.0377
Avg	.4245	.4197	.3913	.3747	.3170	.3986	.1758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 206 / 11 KV PALASWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2263	.3048	.2641	.1677	.2401	.1829
2	.3429	.2263	.3963	.2641	.1524	.2401	.1829
3	.4458	.2641	.442	.3045	.1524	.2401	.1981
4	.4973	.3018	.4572	.3018	.1981	.2572	.2134
5	.5144	.3807	.5182	.3807	.2134	.2743	.1677
6	.823	.6036	.5335	.4115	.3353	.2915	.2439
7	.8916	1.0185	.7316	.7545	.3201	.3258	.2896
8		1.0185	.7011	.9054	.2896	.2572	.2439
9	.2058	.7545	.1524	.7545	.1829	.218	.1677
10	.1372	.218	.1543	.1844	.218	.1844	.1886
11	.2401	.3018	.2229	.2012	.788	.503	.4527
12	.2743	.2683	.2229	.2347	.6874	.57	.7545
13	.2915	.2515	.2058	.1677		.5533	.7545
14	.2743	.1677	.1715	.1677	.6203	.5197	
15	.2572	.3018	.2572	.1844	.6203	.4694	.4287
16	.2401	.3018	.3018	.1844	.6203	.5533	.6344
17	.3395	.2134	.2263	.2134	.5487	.6413	.6344
18	.1886	.2134	.1886	.2286	.4287	.4527	.463
19	.2263	.2439	.3018	.2134	.2915	.3018	.3086
20	.3018	.2286	.3018	.1981	.2743	.3018	.2743
21	.3018	.2134	.2641	.2286	.2743	.2439	.2401
22	.3018	.1981	.3018	.1981	.2572	.2439	.2058
23	.2641	.1677	.2263	.1677	.2572	.2134	.2058
24	.2591	.2263	.2896	.2641	.1524	.2401	.2134
Max	.8916	1.0185	.7316	.9054	.788	.6413	.7545
Min	.1372	.1677	.1524	.1677	.1524	.1844	.1677
Avg	.3439	.3463	.3281	.3074	.3500	.3473	.3326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 208 / 11KV CAVES

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0377	.0457	.0754	.0457	.0514	.0457
2	.0457	.0377	.0305	.0686	.0457	.0514	.0457
3	.0457	.0377	.0457	.0754	.0457	.0514	.0514
4	.0457	.0377	.0457	.0754	.0457	.0514	.0457
5	.0457	.0377	.0457	.0754	.0457	.0514	.0457
6	.0457	.0754	.0686	.0754	.0457	.0514	.0305
7	.0457	.0754	.0686	.0754	.061	.0514	.0457
8	.0457	.0754	.0457	.0754	.061	.0343	.0305
9	.0762	.0754	.0762	.0754	.0762	.0335	.0305
10	.0857	.1006	.0857	.0838	.1006	.0335	.0754
11	.1029	.0838	.0857	.0838	.0838	.0335	.0754
12	.1029	.0848	.0686	.0838	.0838	.0671	.0754
13	.0514	.0838	.0857	.0671	.1006	.0671	.0754
14	.0514	.0838	.0686	.0503	.0838	.0838	.0754
15	.0686	.0838	.1029	.0671	.0732	.0671	.0686
16	.0514	.0838	.1029	.0671	.0732	.0335	.0514
17	.0943	.0914	.1132	.061	.0857	.0754	.0686
18	.0943	.0762	.1132	.061	.0686	.0754	.0686
19	.0754	.0762	.1132	.061	.0857	.0377	.0514
20	.0754	.061	.1132	.061	.0686	.0754	.0514
21	.0754	.061	.0754	.061	.0686	.061	.0686
22	.0754	.061	.0754	.061	.0514	.061	.0686
23	.0377	.061	.0754	.061	.0514	.0457	.0514
24	.0457	.0377	.0457	.0754	.0457	.0514	.0457
Max	.1029	.1006	.1132	.0838	.1006	.0838	.0754
Min	.0377	.0377	.0305	.0503	.0457	.0335	.0305
Avg	.0637	.0675	.0749	.0699	.0665	.0540	.0559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 209 / 11kv kagzipura

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.1715	.2263	.2229	.1715	.1715
2	.1543	.2263	.1886	.2263	.2401	.1715	.1715
3	.1543	.2641	.1886	.2641	.2229	.2058	.2743
4	.1886	.1886	.2058	.2641	.2743	.2743	.2915
5	.2229	.1886	.2229	.2641	.3429	.3086	.3429
6	.2915	.2263	.2915	.415	.3658	.4287	.3601
7	.4115	.1886	.4287	.4904	.4115	.4115	.4287
8	.3429	.2641	.2915	.0381	.3772	.2743	.3601
9	.3258	.1829	.3086	.0377	.3086	.2926	.3258
10	.2229		.2572	.0732	.2926	.2926	.3018
11	.2401		.2401	.1829	.2743	.2378	.2641
12	.2401	.2926	.1886	.2926	.2195	.2195	.2263
13	.0514	.3109	.1886	.2195	.2195	.2012	.2263
14	.1715	.2195	.1715	.1646	.2012	.1829	.2263
15	.1886	.2195	.1886	.1829	.2012	.1829	.1886
16	.2229	.2378	.0566	.2195	.2012	.1829	.1886
17	.3018	.2229	.0754	.2401	.2229	.2641	.2401
18	.3395	.2401	.3395	.2572	.2572	.2641	.2743
19	.3772	.3258	.3772	.2743	.3601	.3772	.3772
20	.3772	.3429	.3772	.3258	.3258	.3772	.3429
21	.2641	.3601	.3018	.2743	.2229	.2572	.2743
22	.2641	.3429	.2641	.2572	.2229	.2401	.2401
23	.1886	.2743	.2263	.2401	.1886	.2058	.1886
24	.1715	.1886	.1886	.2263	.2229	.1715	.1886
Max	.4115	.3601	.4287	.4904	.4115	.4287	.4287
Min	.0514	.1829	.0566	.0377	.1886	.1715	.1715
Avg	.2452	.2498	.2391	.2357	.2666	.2582	.2698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 201 / 11KV BAZAR SAWANGI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5914	.3048	.5906	.1334	.0953	.1524
2	.7621	.6468	.381	.6859	.1334	.0953	.1524
3	.9526	.7023	.381	.8002	.1524	.1143	.1524
4	1.3336	.7392	.381	.9335	.1524	.1524	.1905
5	1.6194	1.2012	.9526	.9907	.1905	.1715	.2667
6	1.7147	1.4784	1.6598	1.3146	.381	.2286	.3048
7	1.8861	1.8656	2.0182	1.8861	.4001	.381	.4191
8	1.7909	1.6827	1.829	1.5051			
9	1.1812	1.2197	1.1622				
11					1.6004	1.2437	1.2955
12					1.5242	1.39	1.2193
13					1.4861	1.0974	1.2193
14					1.2384	.9425	1.1431
15					1.0479	.8131	.9335
16					1.1431	.9055	.9145
17					1.1812	.9795	.9907
18					.7621	.6468	.8192
19	.3239	.2477	.2858	.2858	.2096	.2096	.3048
20	.2858	.2286	.3048	.2477	.1905	.2286	.2667
21	.1905	.1905	.2286	.2286	.1715	.1905	.1715
22	.1334	.1524	.1715	.1905	.1334	.1524	.1524
23	.1143	.1334	.2858	.1334	.1143	.1334	.1524
24	.5716	.5525	.2667	.5335	.1334	.0953	.1334
Max	1.8861	1.8656	2.0182	1.8861	1.6004	1.39	1.2955
Min	.1143	.1334	.1715	.1334	.1143	.0953	.1334
Avg	.9081	.7755	.7075	.7376	.5943	.4889	.5407

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 202 / 11 KV. Bodkha AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.2096	.0953	.6668	1.0669	.7392
2	.1143	.1143	.2096	.1143	.7621	1.105	.8686
3	.1143	.1143	.2096	.1143	.8573	1.1812	.961
4	.1524	.1524	.2286	.1334	.8954	1.2765	1.2197
5	.1905	.1905	.2286	.1524	.9145	1.3908	1.3306
6	.2096	.2286	.2096	.1905	1.0479	1.5242	1.4449
7	.2096	.2477		.2096	1.105	1.6956	1.5729
8					1.2765	1.7528	1.7558
9					1.086	1.5242	1.4266
11	1.4815	1.6598	1.8099	1.4861			
12	1.6827	1.773	1.7909	1.6766			
13	1.7741	1.6598	1.2955	1.6766			
14	1.6461	1.5089	1.6385	1.5051			
15	1.5912		1.5623	1.6575			
16	1.6827		1.5813	1.1431			
17	1.5912		1.6004				
18	1.3535		1.4289				
19	.2096	.1715	.1905		.1905	.2096	.1905
20	.1715	.1715	.2286	.1715	.2096	.1905	.2096
21	.1334	.1905	.1524	.1524	.1524	.1905	.1334
22	.1715	.1524	.1143	.1524	.1334	.1524	.1143
23	.1143	.1524	.1143	.5906	.8954	.1524	.8954
24	.0953	.1143	.2096	.1143	.6668	1.0098	.5914
Max	1.7741	1.773	1.8099	1.6766	1.2765	1.7528	1.7558
Min	.0953	.1143	.1143	.0953	.1334	.1524	.1143
Avg	.7040	.5127	.7507	.6298	.7240	.9615	.8969



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 203 / 11 KV. KANATGAON. AG.      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381		.1905	.2096	.1905
2			.0381		.1905	.2096	.1905
3			.0381	.0191	.2096	.2286	.1905
4		.0191	.0381	.0381	.2286	.2477	.2286
5	.0762	.0572	.0381	.0762	.2858	.2858	.2667
6	.0762	.0762	.0381	.0762	.3429	.3429	.3048
7	.0953	.0953		.1143	.381	.362	.381
8					.362	.4382	.4572
9					.2667	.3429	.362
11	.3429		.3239	.362			
12	.3048	.4763	.3048	.3429			
13	.3048	.3048	.2667	.3048			
14	.2477	.2096	.2286	.3048			
15	.2858	.1905	.2096	.2286			
16	.2667	.1715	.2477	.2286			
17	.2286	.2667	.2858	.2286			
18	.2286	.2286	.2286	.1905			
19	.0762	.0953	.0762	.0572	.0762	.0762	.0953
20	.0572	.0762	.0762	.0572	.0572	.0762	.0762
21	.0381	.0572	.0572	.0572		.0572	.0572
22	.0381	.0572	.0381	.0381		.0381	.0381
23	.0381	.0572	.0381	.1715	.2477		.2096
24					.1905	.2286	.1905
Max	.3429	.4763	.3239	.362	.381	.4382	.4572
Min	.0381	.0191	.0381	.0191	.0572	.0381	.0381
Avg	.1691	.1524	.1374	.1609	.2330	.2245	.2159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 204 / 11KV YESGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.362	.3048	.3239	.1334	.0953	.1143
2	.4763	.381	.4572	.3048	.1334	.0953	.1143
3	.4954	.381	.4763	.3429	.1334	.0953	.1143
4	.5716	.4572	.4954	.4001	.1334	.1143	.1143
5	.7621	.5525	.5335	.4572	.1143	.1143	.1143
6	.8573	.6468	.7621	.724	.1143	.1334	.1524
7	.8954	.7392	.8192	.7811	.1143	.1334	.1524
8	.7049		.724	.6478			
9	.4954	.4954	.5335				
10	.4954						
11					.8954	.7023	.6097
12	.4954				.8573	.6283	.6859
13					.7049	.499	.6668
14					.5716	.4763	.5716
15					.4954	.4191	
16					.5525	.4191	.381
17					.5335	.5729	
18					.3239	.4191	.4001
19	.0953	.1143	.0953	.1334	.0762	.1143	.0762
20	.0953	.1143	.0953	.1334	.0953	.1143	.0953
21	.0953	.1143	.0953	.1143	.0762	.1143	.1143
22	.0953	.1143	.0953	.1334	.0762	.1524	.0953
23	.0953	.1143	.0762	.1334	.1143	.1524	.1143
24	.381	.362	.4572	.3048	.1334	.1143	.1524
Max	.8954	.7392	.8192	.7811	.8954	.7023	.6859
Min	.0953	.1143	.0762	.1143	.0762	.0953	.0762
Avg	.4461	.3535	.4014	.3525	.3039	.2704	.2547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 205 / 11KV TAJNAPUR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.2477	.2477	.2286	.2667	.2667
2	.4191	.3429	.381	.2858	.2477	.3048	.2286
3	.4763	.381	.381	.3429	.2477	.3429	.2286
4	.5716	.4572	.4763	.4001	.2667	.4001	.2667
5	.7621	.5906	.5716	.5525	.3048	.4572	.2667
6	.8573	.7392	.724	.6859	.3429		
7	.8764	.8871	.8383	.7811	.362		
8	.7811	.961	.9145	.8573			
9	.5525	.6097	.5335				
11					.3429	.6535	.5525
12					.2858	.5544	.4954
13					.3048	.4481	.4954
14					.4763	.4382	.4572
15					.4191	.3429	.3239
16					.5144	.3429	.3429
17					.4572	.4191	
18					.4191	.3048	.3048
19	.381	.381	.4191	.2858	.4572	.362	.362
20	.3429	.4191	.3429	.2667	.4001	.381	.362
21	.2667	.2477	.2477	.2477	.3429	.362	.3429
22	.2477	.2667	.2096	.2477	.3429	.3239	.3429
23	.2286	.2286	.2286	.2286	.2858	.2858	.362
24	.3429	.2477	.2667	.2477	.2286	.2858	.2667
Max	.8764	.961	.9145	.8573	.5144	.6535	.5525
Min	.2286	.2286	.2096	.2286	.2286	.2667	.2286
Avg	.4991	.4710	.4522	.4055	.3465	.3830	.3482

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 206 / 11KV Yesgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3048	.3048	.3048	.2286	.2858	.3429
2	.2667		.3048	.3429	.2286	.2667	.381
3	.2858	.4191	.3048	.3429	.2858	.3239	.4191
4	.381	.5335	.3048	.4001	.381	.381	.4954
5	.5716	.6668	.5716	.5335	.5716	.4382	.6097
6	.9526	.7621	.8573	.8764	.7621	.8002	.7392
7	.9907	.9717	1.0479	.9717	1.0288	1.0669	1.0164
8	.8764	.9055	.9335	.8573	.9145	.8764	.7947
9	.5716	.6287	.7049	.5335	.724	.5525	.6348
10	.4382	.5716	.362	.381	.4191	.2858	
11	.3239	.381	.2286	.2477	.2667	.2477	.2477
12	.2477	.3048	.1905	.2096	.2096	.2477	.2096
13	.2477	.2096	.2477	.1905	.2096	.2858	.1905
14	.2858	.2096	.2477	.1715	.2286	.2477	.1905
15	.362	.2477	.2286	.1905	.2286	.2096	.2096
16	.4191	.1524	.2286	.2286	.2667	.2286	.2096
17	.4001	.2286	.2477	.2667	.3239	.2858	.2858
18	.5525	.4191	.3429	.362	.4763	.362	.4001
19	.6859	.5525	.6668	.6478	.724	.6161	.6287
20	.4954	.5716	.5335	.6097	.5335	.5335	.5906
21	.4382	.4763	.4001	.5716	.4191	.4572	.4763
22	.362	.381	.362	.381	.362	.381	.362
23	.3048	.3429	.2858	.2286	.3239	.2858	.3429
24	.7811	.2858	.3048	.3239	.2286	.3048	.2667
Max	.9907	.9717	1.0479	.9717	1.0288	1.0669	1.0164
Min	.2477	.1524	.1905	.1715	.2096	.2096	.1905
Avg	.4795	.4577	.4255	.4239	.4311	.4154	.4367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 207 / 11KV VIKAS GINNING EXP  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0191
2		.0381				
3						.0191
4						.0191
5						.0191
6						.0381
8		.0381				
9		.0191	.0381		.0572	.0381
10	.0381	.0572	.0381		.0381	.0381
11	.0381				.0762	.0381
12	.0381				.0191	.0381
14				.0381		.0381
15			.0381	.0381		
16			.0381	.0381		
17	.0572		.0381	.0572		
20					.0191	
22					.0381	
Max	.0572	.0572	.0381	.0572	.0762	.0381
Min	.0381	.0191	.0381	.0381	.0191	.0191
Avg	.0429	.0381	.0381	.0429	.0413	.0305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 208 / Bodhaka Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2667	.2286	.2286	.2477	.2096	.1905
2	.2096	.3048	.2286	.2286	.2477	.1905	.2667
3	.2858	.3429	.2286	.2477	.2667	.1905	.3429
4	.381	.381	.2286	.3239	.3429	.3048	.381
5	.5335	.4572	.3048	.5335	.381	.4001	.5601
6	.7621	.5716	.7621	.743	.5716	.6859	.7282
7	.7811	.8501	.8764	.8573	.8573	.8764	.8501
8	.7621	.7762	.7621	.7049	.724	.7049	.8029
9	.5716	.6287	.5335	.5525	.6668	.6287	.5975
10	.4001	.5716	.362	.362	.4382	.3239	.4001
11	.2667	.3048	.2477	.2286	.2667	.1715	.2096
12	.2096	.2096	.1905	.1524	.1905	.1524	.1524
13	.2096	.1715	.1715	.1524	.1524		.1524
14	.2286	.1524	.1715	.1524	.1524	.1715	.1524
15	.2096	.1524	.1524	.1905	.1524	.1905	.1905
16	.3048	.1715	.2286	.2286	.2096	.1524	.1524
17	.4001	.1524	.3048	.2667	.2667	.2096	.2477
18	.4954	.3239	.381	.3048	.4001	.3048	.3048
19	.6478	.6097	.6668		.6668	.5601	.6097
20	.4954	.6668	.5906	.5906	.5144	.5144	.5525
21	.381	.4191	.4572	.5716	.4382	.4191	.4763
22	.2858	.381	.3048	.3429	.3048	.3048	.3048
23	.2477	.2667	.2477	.2477	.2477	.1905	.2667
24	.2096	.2286	.2286	.2477	.2477	.2286	.1905
Max	.7811	.8501	.8764	.8573	.8573	.8764	.8501
Min	.2096	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.3953	.3901	.3691	.3678	.3731	.3515	.3784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 209 / 11 kv BAZARSAWANGI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524	.1524	.0953	.1143	.0953	.1524
2	.1143	.1905	.1524	.0953	.1143	.1143	.1524
3	.1524	.2286	.1524	.1143	.1334	.1334	.1905
4	.1905	.3048	.1524	.1524	.1524	.1524	.2286
5	.2858	.3429	.1715	.2286	.1905	.2286	.2667
6	.381	.381	.4191	.3429	.2858	.362	.3429
7	.4954	.4191	.4572	.4382	.4763	.4763	.4001
8	.381	.362	.381	.362	.381	.381	.362
9	.3239	.3048	.3048	.2858	.3239	.2858	.3239
10	.2286	.2286	.2096	.2096	.2096	.2096	.1715
11	.1715	.1715	.1524	.1524	.1334	.3239	.1334
12	.1524	.1334	.1143	.1143	.1143	.1334	.1524
13	.1334	.1334	.1334	.1143	.1143	.1334	.1334
14	.1905	.1334	.1143	.1143	.1143	.1334	.1334
15	.1905	.1524	.1334	.1143	.1143	.1524	.1334
16	.1905	.1334	.1524	.1334	.1334	.1524	.1524
17	.2477	.1524	.1715	.1334	.1524	.1905	.2286
18		.2096	.2096	.2286	.2286	.2477	.2667
19	.3429	.3429	.3239	.3239	.3048	.381	.4001
20	.2667	.381	.2858	.3239	.3048	.2858	.3239
21	.2096	.2286	.2286	.3239	.2096	.2286	.2286
22	.1905	.2096	.1524	.1524	.1715	.1905	.1905
23	.1334	.1334	.1524	.1143	.1334	.1334	.1715
24	.1143	.1334	.1524	.1143	.1143	.1143	.1143
Max	.4954	.4191	.4572	.4382	.4763	.4763	.4001
Min	.1143	.1334	.1143	.0953	.1143	.0953	.1143
Avg	.2261	.2318	.2096	.1993	.1969	.2183	.2231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 201 / 11 KV Bhadji AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0701	.2058	.1475
2					.0709	.1715	.1844
3					.0701	.1715	.2204
4					.0701	.1715	.1492
5					.1772	.3561	.2035
6					.2629	.703	.2347
7					.7265	.9431	.6882
8					.6661	.7969	.7545
9					.3601	.5144	.463
11	.7888	.7461	.8139	.7442			
12	.7712	.6859	.6706	.7362			
13	.6836	.6104	.5144	.5959			.0191
14	.5784	.5197	.4409	.4908			
15	.5493	.4748	.4578	.4908			
16	.5493	.4801	.4801	.4908			
17	.631	.6036	.4801	.5083			
18	.3681	.3584	.2804	.298			
24					.0876	.2229	.1526
Max	.7888	.7461	.8139	.7442	.7265	.9431	.7545
Min	.3681	.3584	.2804	.298	.0701	.1715	.0191
Avg	.6150	.5599	.5173	.5444	.2562	.4257	.2925



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 202 / 11KV GADANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4382	.4024	.3521	.3048	.1334	.3018
2	.4115	.443	.4024	.3856	.3048	.1429	.3018
3	.442	.4207	.4024	.39	.3048	.1429	.3206
4	.4572	.5258	.4694	.4917	.3048	.1619	.3206
5	.7468	.6135	.5365	.6104	.3018	.2829	.3206
6	1.0212	.7888	.788	.7377	.3395	.3206	.3018
7	1.387	1.5769	1.5257	1.3094	.2858	.2829	.2452
8	1.3108	1.5947	1.5249	1.3904	.2286	.2075	.2452
9	.8078	.9391	.8139	.9036	.0857	.1698	.1509
10	.1524	.1509	.1132	.1524	.0667	.1132	.0191
11	.1143	.1132	.0943	.0953	1.046	.9496	.1227
12	.0953	.0943	.0754	.0953	1.1317	.9389	.9922
13	.0953	.0943	.0754	.0953	.9088	.7712	1.0341
14	.0953	.0943	.0754	.0953	.7545	.6036	.7362
15	.1143	.0943	.0754	.0953	.7716	.6203	.5609
16	.1132	.0943	.0754	.0953	.7545	.4359	.8413
17	.1509	.0943	.0754	.0953	.703	.6687	.8589
18	.1509	.0943	.0943	.1143	.6173	.4458	.4001
19	.2096	.1886	.1886	.2286	.1143	.2452	.2286
20	.1905	.2263	.2075	.2477	.1238	.2829	.2452
21	.1905	.1886	.1698	.2858	.1334	.2829	.2667
22	.1715	.1698	.1509	.2858	.1334	.3206	.3048
23	.1524	.1698	.1509		.1334	.3206	.2075
24	.3353	.2835		.3521	.3048	.1334	.3018
Max	1.387	1.5947	1.5257	1.3904	1.1317	.9496	1.0341
Min	.0953	.0943	.0754	.0953	.0667	.1132	.0191
Avg	.3874	.3955	.3690	.3872	.4232	.3741	.4012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 203 / 11 KV Bhandegaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1238	.1143	.1238	.1417	.1715	.1187
2	.2134	.1334	.1143	.1238	.1578	.1886	.1526
3	.2134	.1334	.1334	.1334	.1578	.1886	.1677
4	.2286	.1334	.1429	.1429	.1928	.2058	.2035
5	.2591	.1334	.0857	.1524	.3155	.4024	.3052
6	.2591	.0667	.1334	.1524	.4031	.6783	.4359
7	.2439	.0381	.1143	.1429	.6379	.9835	.9892
8	.1829	.0667	.0857	.0953	.8413	.6874	1.0111
9	.1372	.0381	.0667	.0762	.3944	.463	.5487
10	.0667	.0572	.0572	.0572	.0476	.0476	.0476
11	.7011	.6874	.6874	.5784	.0381	.0381	.0286
12	.6201	.5935	.503	.6024	.0381	.0381	.0286
13	.5083	.5087	.4748	.443	.0286	.0286	.0286
14	.3856	.3856	.3944	.3155	.0286	.0381	.0191
15	.3898	.3086	.2486	.3189	.0286	.0457	.0286
16	.443	.4287	.2915	.3189	.0286	.0381	.0191
17	.4075		.3086	.333	.0286	.0381	.0286
18	.2658	.0667	.1543	.1334	.0381	.0476	.0381
19	.0953	.0762	.0953	.0793	.0762	.0857	.0762
20	.0953	.1048	.1238	.0953	.0762	.0857	.0857
21	.1143	.0572	.1143	.0762	.0762	.0762	.0762
22	.1334	.1238	.1334	.1334	.0762	.0667	.0572
23	.1238	.1143	.1334		.0762	.0476	.0476
24	.2286	.1238		.1238	.0762	.1715	.12
Max	.7011	.6874	.6874	.6024	.8413	.9835	1.0111
Min	.0667	.0381	.0572	.0572	.0286	.0286	.0191
Avg	.2721	.1958	.2048	.2066	.1669	.2026	.1943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 204 / 11KV GADANA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1097	.0943	.132	.1097	.0686	.1132
2	.0762	.1097	.0943	.1132	.1097	.0686	.1132
3	.0914	.0914	.1132	.1132	.1097	.0857	.1132
4	.0914	.1463	.132	.1509	.1097	.1029	.1132
5	.1524	.1578	.1509	.1886	.1646	.1698	.1698
6	.1981	.2454	.2641	.2641	.2328	.2075	.2641
7	.2286	.2481	.2641	.3018	.2658	.2641	.3018
8	.1829	.1772	.2452	.2263	.1772	.2075	.2452
9	.1829	.1646	.2075	.1949	.1372	.1886	.1698
10	.128	.132	.0943	.1097	.1029	.0943	.0914
11	.1097	.132	.0943	.128	.0686	.0754	.0732
12	1.2226	.1132	.0754	.1097	.0686	.0754	.0914
13	.0732	.1132	.0566	.0914	.0514	.0754	.0914
14	.0709	.1132	.0566	.0914	.0514		.1097
15	.0732	.132	.0566		.0686	.0566	.1097
16	.1097	.132	.0566	.0886	.0686	.0754	.1097
17	.1063	.1509	.1132	.1646	.0857	.0943	.128
18	.1646	.1886	.1509	.1772	.1029	.1132	.1463
19	.2561	.2829	.2263	.2804	.2229	.2075	.2561
20	.2303	.1886	.2075	.2658	.1886	.2452	.2126
21	.1772	.1698	.1886	.2195	.1715	.1509	.1829
22	.1417	.1509	.1698	.128	.1715	.132	.1402
23	.128	.1132	.132		.1372	.132	.1097
24	.0762	.0914	.0943	.132	.0914	.1029	.1132
Max	1.2226	.2829	.2641	.3018	.2658	.2641	.3018
Min	.0709	.0914	.0566	.0886	.0514	.0566	.0732
Avg	.1812	.1523	.1391	.1669	.1278	.1302	.1487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 205 / 11 KV Takali R.R.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1715	.2452	.2641	.3856	.3772	.431
2	.2134	.1905	.2452	.2641	.3856	.3772	.4641
3	.2134	.2667	.2641	.2641	.3856	.4115	.4641
4	.2134	.2667	.2641	.2829	.3856	.4287	.4807
5	.2439	.2667	.2641	.2829	.4557	.8048	.5304
6	.2439	.2667	.2829	.2829	.6485	1.2763	.788
7	.2286	.3048	.2829	.3018	1.2226	1.5912	1.4586
8	.1829	.3048	.2829	.2829	1.3847	1.6518	1.56
9	.2134	.2667	.2641	.2667	.4115	1.0343	1.0288
10	.2477	.1334	.2452	.2477	.1238	.2641	
11	1.1919	1.5927	1.3272	1.0808	.1238	.2452	.2477
12	1.2094	1.3108	1.2239	1.3112	.1238	.2263	.2477
13	.9991	1.1305	1.326	1.2226	.1238	.2452	.2452
14	1.1919	1.0174	1.1768	.964	.2229		.2477
15	1.2048	.9496	.9945	.9816	.1238	.2452	.2477
16	1.2048	1.166	.9389	1.0454	.1238	.2452	.2477
17	1.5424	.9892	1.0682	.8764	.1238	.2452	.2477
18	.9568	.6783	.57	.6201	.1334	.2452	.2667
19	.2667	.2858	.2829	.2667	.1334	.2641	.2667
20	.2858	.2829	.2829	.2858	.1334	.2641	.2858
21	.2858	.2829	.2829	.2667	.1429	.2641	.2667
22	.2667	.2641	.2641	.2667	.1429	.2641	.2667
23	.2667	.2641	.2641		.1619	.2452	.2477
24	.2134	.2667	.2452	.2641	.3721	.3429	.4287
Max	1.5424	1.5927	1.3272	1.3112	1.3847	1.6518	1.56
Min	.1829	.1334	.2452	.2477	.1238	.2263	.2452
Avg	.5542	.5383	.5370	.5301	.3323	.5026	.4768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 206 / 11 KV TAKALI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1905	.1886	.2075	.2286	.2572	.2075
2	.1829	.2096	.2263	.2075	.2477	.2743	.2452
3	.2134	.2286	.2452	.2452	.2477	.2915	.2829
4	.2439	.3048	.3395	.3584	.2858	.3086	.3395
5	.3963	.5335	.4338	.4715	.5144	.5093	.5093
6	.503	.7049	.679	.7356	.743	.6224	.6979
7	.6097	.8192	.7733	.679	.6859	.7545	.8299
8	.5944	.5335	.7356	.7167	.743	.6602	.7167
9	.503	.4382	.5658	.6287	.5316	.5658	.4904
10	.4001	.2641	.3206	.4191	.3772	.3395	.362
11	.2858	.1886	.2829	.3429	.2572	.2452	.1524
12	.3048	.2263	.1886	.3048	.2229	.1698	.1524
13	.2286	.2075	.1886	.2096	.1715	.1698	.1524
14	.1715		.1698	.1905	.1543	.1698	.1715
15	.2667		.1509	.2286	.1543	.2263	.2858
16	.3475	.1886	.1698	.2667	.1715	.1698	.2286
17	.4207	.1886	.2452	.2667	.2572	.2829	.3429
18	.5121	.1886	.3584	.381		.415	.4191
19	.5906	.6036	.6602	.5906	.6001	.6036	.6478
20	.5525	.5093	.679	.4954	.5144	.5093	.5335
21	.4191	.3772	.3772	.4191	.3429	.3772	.3429
22	.2858	.2641	.3018	.3048	.3429	.3018	.3239
23	.2286	.2263	.2452		.3086	.2452	.2477
24	.1524	.1905	.1886	.2075	.2096	.2743	.2075
Max	.6097	.8192	.7733	.7356	.743	.7545	.8299
Min	.1524	.1886	.1509	.1905	.1543	.1698	.1524
Avg	.3575	.3448	.3631	.3860	.3614	.3643	.3704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 207 / 11 KV Viramgaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2303	.2374	.218	.3429	.1429	.3395
2	.1981	.2481	.2204	.2347	.3429	.1715	.3395
3	.2286	.2629	.2012	.2347	.3429	.181	.3584
4	.2591	.3155	.285	.3052	.3429	.1905	.3772
5	.6249	.5316	.3856	.407	.362	.3772	.3772
6	.8688	.6836	.6613	.6979	.4001	.3772	.3961
7	1.0517	.691	1.2239	1.0277	.362	.3772	.3395
8	1.0212	1.4175	1.2039	1.0343	.2667	.3206	.2641
9	.5487	.8764	.7373	.6733	.1048	.1698	.1886
10	.1715	.0953	.132	.1524	.0762	.1132	.1524
11	.1143	.1509	.0943	.1334	.9431	.7209	.7265
12	.0953	.0943	.0754	.0953	.823	.6036	.6379
13	.0953	.0943	.0754	.0953	.703	.4917	.5609
14	.0953	.0754	.0754	.0701	.5144	.2429	.3366
15	.1143	.0754	.0754	.0762	.5144	.2683	.2804
16	.1334	.0754	.0754	.0762	.4801	.4359	.4572
17	.1334	.0943	.0754	.0953	.4115	.3353	.4908
18	.1715	.1132	.0943	.1143	.3429	.2452	.362
19	.2286	.1886	.1698	.2096	.1238	.2452	.2477
20	.2096	.2075	.1698	.2477	.1334	.2641	.2858
21	.1905	.1698	.1698	.2477	.1429	.3018	.3048
22	.1509	.1509	.132	.2667	.1429	.3584	.3429
23	.1334	.132	.1132		.1524	.3395	.362
24	.1677	.1578	.2374	.2229	.3239	.1715	.3395
Max	1.0517	1.4175	1.2239	1.0343	.9431	.7209	.7265
Min	.0953	.0754	.0754	.0701	.0762	.1132	.1524
Avg	.2995	.2972	.2884	.3016	.3623	.3102	.3695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 208 / 11KV NAKODA GINNING  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0122	.0126	.0126	.0122	.0038	.0126
2	.0152	.0122	.0133	.0126	.0122	.0038	.013
3	.0305	.0122	.0133	.0126	.0122	.0038	.0126
4	.0305	.0122	.0133	.0133	.0122	.0038	.0126
5	.0305	.0122	.0126	.0133	.0122	.0126	.0126
6	.0762	.0122	.0133	.0126	.4999	.0126	.0377
7	.0152	.0122	.0126	.0126	.0122	.0126	.013
8	.0305	.0122	.0126	.0133		.0126	.013
9	.0305	.0122	.0126	.0122	.0038	.0126	.0126
10	.0122	.0133	.0126	.0122	.0038	.0126	.0122
11	.0122	.0133	.0126	.0122	.0038	.0126	.0122
12	.0122	.0133	.0377	.0122	.0038		.0122
13	.0122	.0114	.0126	.0122	.0038	.0133	.0122
14	.0122	.0133	.0126	.0122	.0038	.0126	.0122
15	.0122	.0126	.0126	.0122	.0038	.013	.0122
16	.0122	.0126	.0126	.0122	.0038	.0126	.0122
17	.0122	.0126	.0126	.0122	.0038	.0126	.0122
18	.0122	.0126	.0126	.0122	.0038	.0126	.0122
19	.0122	.0377	.0126	.0122	.0038	.0126	.0122
20	.0061	.0126	.0126	.0122	.0038	.0126	.0122
21	.0061	.0133	.0126	.0122	.0038	.0126	.0122
22	.0061	.0133	.0133	.0122	.0038	.0126	.0122
23	.0122	.0126	.0133		.0038	.0126	.0122
24	.0305	.0122	.0126	.0126	.0122	.0038	.0126
Max	.0762	.0377	.0377	.0133	.4999	.0133	.0377
Min	.0061	.0114	.0126	.0122	.0038	.0038	.0122
Avg	.0197	.0136	.0138	.0124	.0279	.0107	.0135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 209 / 11KV LODHA STONE CRUSHER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0189	.0189	.0189	.0189	.0171	.0189
2	.0152	.0189	.0189	.0189	.0189	.0171	.0189
3	.0152	.0189	.0189	.0189	.0189	.0171	.0189
4	.0152	.0189	.0189	.0189	.0189	.0171	.0189
5	.0152	.0189	.0189	.0189	.0189	.0189	.0189
6	.0152	.0189	.0189	.0189	.0189	.0189	.0189
7	.0152	.0189	.0189	.0189	.0189	.0189	.0189
8	.0152	.0189	.0189	.0189	.0189	.0189	.0189
9	.0152	.0189	.0189	.0189	.0171	.0189	.0189
10	.0189	.0189	.0189	.0189	.0171	.0189	.0189
11	.0189	.0189	.0189	.0189	.0171		.0189
12	.0189	.0189	.0189	.0189	.0171	.0189	.0189
13	.0189	.0189	.0189	.0189	.0171	.0189	.0189
14	.0189	.0189	.0189	.0189	.0171	.0189	.0189
15	.0189	.0189	.0189	.0189	.0171	.0189	.132
16	.0189	.0189	.0189	.0189		.0189	.1132
17	.0189	.0189	.0189	.0189	.0171	.0189	.1646
18	.0189	.0189	.0189	.0189	.0171	.0189	.0189
19	.0189	.0189	.0189	.0189	.0171	.0189	.0189
20	.0189	.0189	.0189	.0189	.0171	.0189	.0189
21	.0189	.0189	.0189	.0189	.0171	.0189	.0189
22	.0189	.0189		.0189	.0171	.0189	.0189
23	.0189	.0189	.0189		.0171	.0189	.0189
24	.0152	.0189	.0189	.0189	.0189	.0171	.0189
Max	.0189	.0189	.0189	.0189	.0189	.0189	.1646
Min	.0152	.0189	.0189	.0189	.0171	.0171	.0189
Avg	.0174	.0189	.0189	.0189	.0178	.0185	.0336



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 210 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286		.2829	.2667	.2572	.2452
2	.2286	.2667	.2641	.3018	.3048	.2915	.2641
3	.2896	.2858	.2829	.3395	.3429	.3258	.3206
4	.3353	.4191	.3961	.4527	.362	.3429	.4527
5	.3658	.7049	.5093	.6036	.5335	.5658	.6224
6	.5792	.8192	.7167	.811	.7621	.7167	.8299
7	.6097	.8573	.7356	.8865	.743	.7733	.8488
8	.5944	.743		.811	.6097	.6224	.7733
9	.442	.6097	.5847	.6097	.4287	.5093	.5658
10	.4191	.1886	.3584	.4382	.2915	.3772	.3048
11	.3048	.3395	.2829	.3429	.2058	.2263	.2477
12	.2667	.2263	.1886	.2667		.1886	.2096
13	.2477	.2263	.2263	.2096	.1715	.1886	.2096
14	.2286	.1886	.2075	.1715	.1372		.2096
15	.3048	.1509	.2075	.1524	.1543	.1886	.1905
16	.4001	.2263	.2263	.2286	.1715	.2263	.2096
17	.4572	.2829	.2452	.2667	.2229	.2263	.2103
18	.5121	.3772		.362	.2915	.3584	.3239
19	.743	.6413	.5847	.7049	.6859	.6979	.7049
20	.6287	.5658	.6602	.6859	.5487	.6413	.6097
21	.4954	.4338		.5716	.4287	.4715	.4954
22	.3429	.3395		.3429	.3429	.3961	.381
23	.2858	.2829	.3584		.3086	.3018	.2858
24	.2439	.2477	.2452	.2641	.2477	.2572	.2641
Max	.743	.8573	.7356	.8865	.7621	.7733	.8488
Min	.2286	.1509	.1886	.1524	.1372	.1886	.1905
Avg	.3981	.4022	.3832	.4394	.3723	.3979	.4075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 201 / 11 KV GALLE BORGAEON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.2096	.2286	.1677	.2439	.2286
2	.2667	.2286	.2096	.2096	.1829	.2591	.2187
3	.2667	.2286	.2096	.2096	.1875	.2812	.2187
4	.2858	.2477	.2477	.2286	.2105	.3125	.1898
5	.3048	.2667	.2858	.2667	.2267	.4049	.3239
6	.3429	.3048	.3429	.3239	.2591	.4858	
7	.362	.3429	.362	.362	.426	.6036	
8	.3048	.3048	.3048	.3429	.4144	.5304	
9	.2477	.2286	.2858	.3048	.2915	.3605	.3688
10	.2286	.2096	.2286	.1823	.2667	.1334	.1524
11	.3978	.4641	.4475	.3647	.2667	.1905	.2096
12	.4144	.4475	.3812	.3978	.2477	.1905	.2286
13	.4144	.4641	.431	.3647	.2477	.2096	.1524
14	.3978	.4641	.4144	.3481	.2477	.1715	.1905
15	.3647	.4641	.4144	.3149	.2096	.1524	.1334
16	.3978	.431	.3812	.3315	.1905	.1905	.1524
17	.3812	.3567	.3315	.3647	.2096	.2477	.1334
18	.3605	.2439	.2818	.3149	.2096	.2096	.2286
19	.3048	.2286	.2286	.2096	.3048	.1905	.3429
20	.2858	.2286	.2286	.2286	.2858	.2096	.0191
21	.2667	.2286	.2096	.1905	.2286	.1905	.2477
22	.2477	.2286	.2477	.1905	.2096	.1715	.2286
23	.2286	.2286	.2477	.1524	.1715	.1715	.2096
24	.2286	.2286	.2286	.2286	.1524	.25	.2134
Max	.4144	.4641	.4475	.3978	.426	.6036	.3688
Min	.2286	.2096	.2096	.1524	.1524	.1334	.0191
Avg	.3145	.3041	.2983	.2775	.2423	.2651	.2091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 202 / 11 KV Akhatwada AG. SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1326	.0914	.104	.1524	.1524	.1524
2	.1094	.1492	.0914	.1067	.1524	.1524	.1524
3	.1406	.1658	.1094	.1372	.1715	.1715	.1715
4	.1875	.1989	.1423	.1562	.2096	.2096	.1905
5	.2267	.2321	.2105	.1898	.2667	.2477	.2096
6	.2591	.3812	.2591	.2429	.3429	.2667	.2286
7	.6718	.5138	.5407	.4915	.3429	.3048	
8	.639	.5801	.4915	.5571	.3239	.2667	
9	.1524		.2591	.3077	.1905	.1524	
10	.1334	.1524	.1334		.1524	.1334	
11	.0572	.1143	.1143		.2824	.3201	.2286
12	.0762	.0762	.0762		.2896	.1067	.2896
13	.0572	.0572	.0953		.2439	.2812	
14		.0572	.0762		.2439	.1981	.1829
15	.0762	.0953	.1143		.25	.1739	.3401
16	.1143	.0953	.1524		.2591	.2896	.2915
17	.1715	.1143	.1524		.2343	.2458	.2984
18	.1715	.1143	.1524		.1372	.1781	.1989
19	.2286	.1905	.1905	.1143	.1715	.2286	.1905
20	.1905	.1905	.2286	.2286	.2286	.2096	.1905
21	.1905	.1715	.1715	.1524	.1524	.1905	.1715
22		.1524	.1524	.1524	.1524	.1905	.1715
23	.1524	.1524	.1524	.1524	.1524	.1905	.1715
24	.0914	.116	.0892	.104	.1524	.1524	.1715
Max	.6718	.5801	.5407	.5571	.3429	.3201	.3401
Min	.0572	.0572	.0762	.104	.1372	.1067	.1524
Avg	.1904	.1828	.1770	.2131	.2190	.2089	.2106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 203 / 11 KV Tisgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.181	.1629	.1629	.1629	.1629
2	.181	.1886	.181	.1629	.1629	.1629	.181
3	.1949	.2058	.181	.1829	.181	.181	.2172
4	.2715	.2743	.2743	.2561	.2561	.2534	.2534
5	.3982	.3601	.3658	.2926	.3109	.3258	.2835
6	.5068	.3944	.5175	.439	.462	.4207	.3681
7	.5121	.4801	.5175	.5041	.462	.499	
8	.4607	.4287	.439	.499	.4344	.4572	
9	.3506	.3772	.2896	.3801	.3189	.3258	
10	.2401	.3086	.2572	.2401	.181	.2229	
11	.1715	.1886	.12	.2743	.12	.1357	
12	.1029	.1715	.12	.1543	.12	.1372	
13		.1543	.12	.1372	.12	.1372	
14		.1372	.1372	.12	.1029	.12	
15	.1886	.1372	.1372	.1029	.12	.1006	
16	.2401	.12	.1372	.12	.12	.1372	.2515
17	.2865	.2058	.1543	.2058	.2229	.1886	.2572
18	.3292	.2804	.2229	.2743	.2804	.2896	.3429
19	.462	.362	.3429	.3429	.3982	.3881	.4287
20	.3475	.3258	.2743	.3429	.3292	.3292	.3772
21	.2715	.2715	.2353		.2715	.2715	.2915
22	.2303	.2715	.2534	.1886	.2126	.2126	.2229
23	.1886	.1991	.2172	.1715	.1907	.1734	.1886
24	.181	.1715	.181	.1086	.1629	.1543	.181
Max	.5121	.4801	.5175	.5041	.462	.499	.4287
Min	.1029	.12	.12	.1029	.1029	.1006	.1629
Avg	.2862	.2577	.2440	.2462	.2376	.2411	.2672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGGAON

Feeder No / Name : 204 / 11 KV Galleborgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1524	.1524	.1334	.1334
2	.1334	.1524	.1334	.1524		.1334	.1524
3	.1524	.1715	.0762	.1715	.1715	.1334	.1905
4	.1715	.1905	.1524	.1715	.1715	.1715	.2286
5	.2286	.2286	.2096	.1905	.2096	.2286	.2667
6	.2667	.2858	.2477		.2858	.2858	.2858
7	.3239	.2858	.3048	.3048	.3429	.3429	.3239
8	.2858	.2477	.2477	.2858	.3048	.3048	.2477
9	.1905	.1905	.2096	.2286	.2286	.2286	.1715
10	.1524	.1524	.1905	.1905	.1905	.1524	.1715
11	.1524	.1524	.1905	.2096	.1905	.1905	.1524
12	.1715	.1524	.1715	.1905	.1524	.1143	.1334
13	.1524	.1524	.1524	.1905	.1715	.1715	.1334
14	.1715	.1334	.1715	.1715	.1524	.1524	.1334
15	.1905	.1334	.1715	.1524	.1524	.1524	.1524
16	.2286	.1524	.1905	.1524	.1715	.1524	.1524
17	.2477	.1524	.1905	.1905	.1524	.1715	.1905
18	.1905	.1715	.2096	.2096	.1905	.1524	.1905
19	.2477	.1905	.2667	.2286	.2096	.2096	.2286
20	.2096	.2096	.2096	.2477	.2286	.2096	.2096
21	.1905	.2096	.2096		.1905	.1905	.1905
22	.1715	.1905	.2096	.2096	.1905	.1905	.1715
23	.1524	.1524	.1715	.1524	.1715	.1524	.1524
24	.1334	.1524	.1334	.1524	.1524	.1334	.1524
Max	.3239	.2858	.3048	.3048	.3429	.3429	.3239
Min	.1334	.1334	.0762	.1524	.1524	.1143	.1334
Avg	.1937	.1810	.1897	.1957	.1971	.1858	.1881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 205 / 11 KV Palasgaon AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1658	.1562	.1406	.1334	.1334	.1524
2	.1423	.1989	.1562	.1562	.0762	.1334	.1524
3	.1423	.2652	.1581	.1739	.1334	.1334	.1524
4	.2372	.3481	.2401	.1943	.1334	.1334	.1524
5	.3239	.4641	.3768	.2267	.1334	.1334	.1524
6	.3887	.7459	.5079	.3563	.1334	.1334	.1334
7	.8421	1.0111	.9667	.8029	.1143	.1334	.1334
8	.9995	1.0111	1.0898	.6874	.0762	.0953	.0953
9	.0572	.5967	.502	.5243	.0572	.0572	.0572
10	.0381	.0572	.0381		.0572	.0572	.0572
11	.0381	.0381	.0381		.6718	.4858	.427
12	.0191	.0381	.0381		.3401	.3239	.6226
13	.0381	.0381	.0191		.583	.5407	
14		.0381	.0381		.5344	.4049	.427
15	.0381	.0381	.0381		.5506	.3401	.5506
16	.0381	.0381	.0381		.5668	.4858	.5668
17	.0381	.0381	.0381		.421	.3725	.4641
18	.0572	.0381	.0191		.3113	.2267	.2984
19	.0762	.0953	.0762	.0572	.0762	.0953	.0572
20	.0953	.1143	.0953	.1143	.0953	.1143	.0953
21	.0953	.0953	.1143		.1143	.1334	.1143
22	.0762	.0953	.0762	.1143	.1334	.1524	.1334
23	.0762	.0762	.0762	.1334	.1334	.1524	.1334
24	.1296	.1492	.1524	.1372	.1334	.1334	.1524
Max	.9995	1.0111	1.0898	.8029	.6718	.5407	.6226
Min	.0191	.0381	.0191	.0572	.0572	.0572	.0572
Avg	.1788	.2414	.2104	.2728	.2380	.2127	.2296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 206 / 11 KV Pimpri AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3321	.3315	.2372	.2688	.1715	.1715	.1524
2	.3321	.3647	.2753	.2846	.1715	.1524	.1524
3	.3239	.4144	.3077	.3077	.1905	.1715	.1715
4	.4049	.4973	.4049	.3563	.1905	.1905	.1905
5	.5344	.6299	.6062	.421	.2096	.2096	.2286
6	.7293	.6796	.6882	.639	.2096	.2286	.2477
7	1.1736	1.0774	1.2239	1.1736	.2477	.2477	
8	1.2071	1.0774	1.2407	.8551	.1905	.1524	
9	.1905	.6299	.7127	.7712	.1524	.0953	
10	.1524	.1143	.0762		.1715	.0572	.0572
11	.0953	.0572	.0572		.9393	.426	.7287
12	.0953	.0762	.0572		.5243	.3401	.852
13	.1143	.0572	.0572		.8848		
14		.0572	.0762		.779	.639	.664
15	.1143	.0762	.0953		.7373	.7377	.788
16	.1334	.0953	.0953		.7293	.7209	.8215
17	.1334	.0572	.0953		.547	.6706	.6962
18	.1334	.0953	.0953		.3978	.4915	.547
19	.2286	.0762	.0953	.0762	.1524	.1905	.1715
20	.1905	.1715	.1524	.1334	.1715	.2096	.2477
21	.1524	.1334	.1334		.1524	.1905	.2286
22	.1334	.1143	.1143	.1143	.1715	.1715	.2096
23	.0953	.0953	.0953	.1905	.1524	.1524	.2096
24	.3563	.3149	.2031	.2688	.1905	.1715	.1524
Max	1.2071	1.0774	1.2407	1.1736	.9393	.7377	.852
Min	.0953	.0572	.0572	.0762	.1524	.0572	.0572
Avg	.3198	.3039	.2998	.4186	.3515	.2952	.3759

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV KANADGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2054	.2054	.2054	.3361	.2829	.1943
2	.1867	.2054	.2054	.2054	.3361	.2829	.1943
3	.2241	.2054	.2427	.2241	.4481	.3395	.2138
4	.3361	.2054	.2801	.2801	.5601	.3772	.2244
5	.3361	.2241	.3361	.3361	.6722	.4715	.3071
6	.3921	.3361	.3734	.3921	.7842	.547	.3315
7	.3921	.3734	.3734	.1494	.7842	.3963	.4321
8	.3921	.3361	.3361	.2801	.6722	.4039	.4115
9	.2801	.2801	.1943	.2241	.6161	.3292	.5533
10	.1509	.2427	.1486	.1867	.1509	.1337	.2427
11	.6036	.503	.4344	.6161	.1132	.0838	.1494
12	.5847	.4239	.378	.6161	.1132	.0972	.1494
13	.5658	.4973	.3662	.3361	.0754	.096	.1307
14	.547	.4694	.3536	.4481	.0377	.0838	.1494
15	.7167	.4694	.3241	.5041	.0566	.0995	.1494
16	.7545	.5087	.3429	.5601	.1132	.0995	.1307
17		.5365	.3772	.5601	.1132	.0995	.1307
18	.4527	.4409	.2953	.6161	.1698	.1189	.1494
19	.415	.2801	.1894	.3361	.2452	.1783	.2801
20	.2452	.2801	.1758	.2241	.2452	.1669	.3361
21	.2263	.2241	.1486	.2241	.2263	.1486	.2241
22	.2075	.2241	.1486	.168	.2075	.1509	.1867
23	.2054	.2054	.1486	.168	.1886	.1448	.1867
24	.168	.2054	.2054	.1486	.3361	.2829	.1943
Max	.7545	.5365	.4344	.6161	.7842	.547	.5533
Min	.1509	.2054	.1486	.1486	.0377	.0838	.1307
Avg	.3726	.3284	.2743	.3337	.3167	.2256	.2355



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 201 / GINNING AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2743	.2772	.2743	.2429	.2743	.2572
2	.2801	.2772	.2686	.2772	.2429	.2743	.2572
3	.2801	.2772	.2801	.2743	.3201	.2772	.2572
4	.2801	.3696	.3734	.3658	.3353	.4477	.3429
5	.4715	.4668	.4668	.462	.4382	.4477	.4287
6	.5658	.5601	.5658	.5601	.6401	.6268	.6001
7	.5658	.5601	.5658	.5601	.7888	.7545	.7716
8	.5658	.5601	.5658	.5601	.6249	.7202	.6783
9	.4287	.4287	.4287	.4715	.463	.463	.5201
10	.2572	.3429	.3429	.3734	.2772	.2772	.3696
11	.4287	.4287	.4287	.3048	.1829	.2772	.1829
12	.4287	.3429	.3429	.3048		.0857	.2543
13	.3429	.2572	.2572	.3048		.0857	.1791
14	.3429	.3429	.2572	.2286		.0857	.1734
15	.2572	.2572	.2572	.2286	.1848	.181	.1753
16	.3715	.2858	.2286	.2286	.1829	.181	.2772
17	.2972	.3525	.2401	.2896	.2801	.2572	.2743
18	.3391	.2934	.2286	.2201	.2801	.2572	.3734
19	.4668	.4668	.4668	.3734	.3734	.3429	.4668
20	.3734	.3734	.3734	.3734	.3734	.3429	.3734
21	.2801	.3696	.2801	.2801	.2772	.2572	.2772
22	.2772	.2801	.2801	.2772	.2715	.2572	.2743
23	.2772	.2772	.2772	.2772	.2743	.2572	.2258
24	.2801	.2743	.2772	.2743	.2401	.2772	.2572
Max	.5658	.5601	.5658	.5601	.7888	.7545	.7716
Min	.2572	.2572	.2286	.2201	.1829	.0857	.1734
Avg	.3641	.3633	.3471	.3393	.3473	.3212	.3436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 202 / 11 KVV- PAL-AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.3582	.3391	.3582	.3734	.3734	.3429
2	.2543	.3201	.3391	.3582	.3734	.3734	.3429
3	.2543	.3353	.3353	.3582	.3734	.3734	.3429
4	.3467	.3353	.3353	.3658	.4668	.3734	.3429
5	.443	.4191	.4382	.4382	.4668	.4715	.3429
6	.4744	.5373	.5316	.5373	.5658	.5658	.5144
7	.8669	.6944	.7888	.8383	.5658	.5658	.5144
8	.9326	.7202	.7716	.7545	.5658	.5658	.5658
9	.5144	.5144	.4287	.4687	.4668	.3734	.5601
10	.3429	.4287	.2572	.3734	.3734	.3734	.3734
11	.2572	.2572	.2572	.2772	.5468	.3858	.4858
12	.2572	.2572	.2572	.2743	.5468	.3048	.463
13	.1715	.2572	.2572	.181	.5468	.3048	.381
14	.2572	.2572	.2572	.2715	.3858	.2286	.301
15	.2572	.2572	.1715	.181	.3048	.2286	.3163
16	.3734	.2658		.181	.3048	.2286	.3201
17	.3658	.2686	.2686	.2715	.3201	.4287	.2401
18	.3734	.3696	.3734	.3696	.3201	.2572	.2515
19	.4715	.4668	.4715	.4668	.3734	.3429	.3772
20	.3772	.4668	.3772	.4668	.3772	.3429	.3772
21	.3772	.3696	.3734	.3734	.3734	.2572	.3772
22	.2801	.3734	.3734	.3734	.3734	.3429	.2801
23	.2801	.3734	.2801	.3696	.3582	.2572	.2801
24	.2486	.3582	.3391	.3582	.2801	.3582	.2572
Max	.9326	.7202	.7888	.8383	.5658	.5658	.5658
Min	.1715	.2572	.1715	.181	.2801	.2286	.2401
Avg	.3762	.3859	.3749	.3861	.4168	.3616	.3729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 203 / 11KV PHULAMBRI GAONTHAN SHEDDABLE URBAN  
FEEDER Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4477	.5487	.5373	.543	.4477	.4287
2	.5487	.4477	.4525	.4477	.4525	.4477	.4287
3	.5487	.4477	.4572	.4477	.4525	.4572	.4287
4	.5487	.4572	.5487	.5487	.543	.4477	.5144
5	.5544	.5373	.6468	.6268	.6135	.6401	.6001
6	.8402	.7316	.8402	.8402	.8402	.7164	.7716
7	1.0374	.9335	1.0374	.9335	1.0374	1.0269	1.0288
8	1.0269	1.0269	1.0269	1.0374	.9431	1.0374	1.1203
9	.8573	.8573	.8573	1.0374	.8316	.9335	.924
10	.7716	.7716	.7716	.823	.7316	.8316	.8145
11	.6859	.8573	.6859	.7316	.7316	.823	.8145
12	.6001	.6859	.6859	.6335	.6335	.724	.6268
13	.6859	.6001	.6859	.6335	.6335	.6401	.6268
14	.6001	.5144	.6001	.543	.6268	.6401	.6135
15	.6859	.6001	.6001	.543	.6335	.6335	.6201
16	.8059	.5373	.6268	.543	.6268	.5373	.6268
17	.7164	.6268	.6268	.6201	.7164	.6001	.6268
18	.7164	.6268	.7164	.6268	.7164	.6859	.8059
19	.823	.8145	.9335	.823	.823	.8573	.9145
20	.7468	.823	.9145	.823	.7316	.7716	.8059
21	.7164	.724	.7164	.724	.7164	.6859	.7545
22	.6268	.6401	.6268	.6335	.6268	.6001	.6268
23	.6268	.5487	.5373	.543	.5373	.6001	.6401
24	.5487	.5373	.5487	.5373	.5487	.4477	.5144
Max	1.0374	1.0269	1.0374	1.0374	1.0374	1.0374	1.1203
Min	.5487	.4477	.4525	.4477	.4525	.4477	.4287
Avg	.7028	.6581	.6955	.6766	.6788	.6764	.6949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 205 / 11 KV DEOGIRI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.181	.1848	.1867	.181	.2972	.2572
2	.181	.2715	.1848	.181	.181	.2858	.2572
3	.1829	.181	.1848	.181	.181	.2972	.2572
4	.1848	.1791	.1867	.181	.1829	.4161	.2572
5	.2801	.2801	.2801	.2829	.2743	.3572	.4287
6	.3772	.2801	.3772	.3772	.3772	.503	.5144
7	.3772	.3734	.3772	.3772	.3734	.6687	.6859
8	.2829	.3734	.3772	.3734		.6706	.663
9	.2572	.2572		.2772		.3858	.4001
10	.3429	.1715		.1829		.1848	.1867
11	.5144	.6001	.6001	.463	.1848	.1829	.1867
12	.5144	.5144	.5144	.4687	.0905		.0914
13	.4287	.5144	.5144	.463	.0857	.0857	.0905
14	.5144	.4287	.4287	.3858	.1829	.0857	.0848
15	.4287	.4287	.4287	.3858	.1848	.0857	.0876
16	.3858	.3715	.381	.3858	.0876	.0857	.0857
17	.3572	.3525	.3715	.2896		.0857	.181
18	.3715	.2667	.381	.282		.0857	.181
19	.2801	.2772	.2801	.2801	.2801	.2572	.2801
20	.2801	.2801	.2801	.2801	.2801	.2572	.2715
21	.181	.1848	.1867	.1867	.1867	.1715	.1867
22	.181	.1848	.181	.1848	.181	.1715	.181
23	.181	.1829	.181	.1791	.2229	.2572	.181
24	.1829	.1867	.1848	.181	.1696	.2972	.3429
Max	.5144	.6001	.6001	.4687	.3772	.6706	.6859
Min	.181	.1715	.181	.1791	.0857	.0857	.0848
Avg	.3104	.3051	.3212	.2923	.2046	.2685	.2641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 206 / 11KV BILDA AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3334	.3715	.3239	.1772	.1296	.1715
2	.3944	.3572	.3601	.3048	.1772	.1181	.1715
3	.3887	.3572	.3887	.3334	.1772	.1181	.1715
4	.3429	.4458	.4534	.3334	.1772	.1943	.2572
5	.5639	.3887	.5563	.4287	.2858	.2667	.3429
6	.743	.643	.8069	.5716	.3763	.381	.5144
7	1.5623	1.1888	1.2308	1.0802	.4458	.4572	.5144
8	1.2498	.8421	.9602	1.1888	.3668	.4572	
9	.6859	.6001	.8573	.6859	.2858	.2858	
10	.2572	.3429	.2572	.3696	.2896	.4344	
11	.1715	.2572	.2572	.1372	1.0936	.8383	.8802
12	.1715	.1715		.1353	.8592	.6859	.6259
13	.1715	.1715		.1715	.6859	.5335	.3715
14	.1715	.1715		.1334	.5335	.4572	.4268
15	.1715	.1715		.1334	.5335	.4572	.3601
16	.1296	.1772	.1715	.1334	.4572	.4572	.4601
17	.1886	.1105	.1715	.1105	.4401	.5144	.4601
18	.2591	.2	.1715	.1715	.3001	.5144	.2591
19	.2705	.2629	.2591	.2439	.2591	.3429	.282
20	.2591	.2667	.2286	.2591	.2591	.3429	.2362
21	.1886	.2058	.1943	.1772	.18	.2572	.1943
22	.1886	.1943	.1943	.1658	.1943	.2572	.1772
23	.3239	.1915	.2591	.1658	.1143	.2572	.18
24	.3887	.4001	.3887	.4001	.0991	.1257	.1715
Max	1.5623	1.1888	1.2308	1.1888	1.0936	.8383	.8802
Min	.1296	.1105	.1715	.1105	.0991	.1181	.1715
Avg	.4013	.3521	.4269	.3399	.3653	.3702	.3442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 207 / 11KV DARI-GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2715	.3658	.362	.3582	.2715	.2572
2	.2715	.2629	.2715	.362	.2715	.2715	.2572
3	.2743	.2629	.2743	.3506	.3582	.2629	.2572
4	.3658	.362	.3658	.4525	.3658	.3696	.3429
5	.5601	.5601	.5601	.5601	.5601	.5544	.4287
6	.8488	.8402	.9431	.8402	.8488	.8316	.6859
7	.9431	.9335	.9431	.9335	.8488	.8316	.7716
8	.8488	.9431	.8488	.8402	.7468	.7392	.7545
9	.6859	.6001	.6859	.7392	.5487	.5487	
10	.5144	.4287	.6516	.5487	.3582	.4525	.4525
11	.3429	.3429	.2572	.3544	.2629	.2629	.2743
12	.3429	.2572	.2572	.2601	.2601	.2572	.2715
13	.2572	.3429	.2572	.2572	.2572	.2601	.1715
14	.2572	.2572	.2572	.2572	.1715	.2572	.1696
15	.3429	.2572	.2572	.1715	.1715	.1715	.2601
16	.362	.3353	.181	.2601	.1715	.2572	.2715
17	.543	.3353	.2715	.3353	.2715	.2572	.2715
18	.6535	.5258	.4382	.4239	.4525	.5144	.462
19	.7468	.7392	.6535	.6468	.6335		.7468
20	.6468	.6468	.6535	.6468	.543	.5144	.6335
21	.4525	.4525	.4525	.4525	.362	.3429	.4525
22	.362	.4572	.362	.362	.362	.3429	.362
23	.2715	.3544	.362	.3582	.2715	.2572	.2772
24	.2743	.2715	.2715	.362	.2715	.2715	.3429
Max	.9431	.9431	.9431	.9335	.8488	.8316	.7716
Min	.2572	.2572	.181	.1715	.1715	.1715	.1696
Avg	.4767	.4600	.4517	.4640	.4053	.3957	.3989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 208 / 11 KV WAREGAON- AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0867	.0876	.0867	.0876	.1886	.0876	.0857
2	.0857	.0876	.1753	.0857	.1867	.0876	.0857
3	.1753	.1753	.1734	.0876	.1867	.1753	.1715
4	.1734	.1753	.1734	.1886		.1753	.1715
5	.1715	.2601	.2572	.1715	.2715	.2629	.2572
6	.3429	.2629	.3429	.2629	.3658	.3658	.3429
7	.3429	.3506	.3429	.3734	.5658	.5144	.6001
8	.3467	.3506	.3467	.3734	.3906	.5258	.5658
9	.2572	.3429	.2572	.2772	.3048	.3906	.4715
10	.2572	.3429	.2572	.2772	.1848	.1829	.1772
11	.2572	.3429		.3048	.0876	.1829	.1753
12	.2572	.2572	.2572	.1524	.0876	.0857	.0876
13	.1715	.1715	.1715	.2286	.0857	.0857	.0876
14	.1715	.1715	.1715	.1524	.0876	.0857	.0905
15	.1715	.0857	.1715	.1524		.0857	.0905
16	.1886	.1791	.1524	.1524		.0857	.0867
17	.1886	.2686	.1753	.0914	.0905	.0857	.0857
18	.1867	.1772	.1886	.181	.1791	.0857	.1867
19	.2601	.2686	.2629	.2629	.2601	.2572	.2572
20	.2601	.2601	.1753	.2601	.1734	.1715	.2572
21	.1753	.1753	.1753	.1734	.1753	.1715	.1753
22	.1753	.1734	.1753	.1753	.1753	.1715	.0876
23	.1753	.1734	.0857	.1867	.0943	.1715	.1753
24	.0867	.0876	.0867	.0857	.1867	.0914	.1715
Max	.3467	.3506	.3467	.3734	.5658	.5258	.6001
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2069	.2178	.2027	.1977	.2061	.1911	.2060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 209 / 11 KV GADEKAR INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0495	.0762	.0619	.0762	.0591	.0762	.0857
2	.0495	.0838	.0657	.08	.0781	.08	.0857
3	.0495	.0762	.0686	.0514	.08	.0762	.0857
4	.0495	.0838	.0705	.0553	.0724	.0629	.0857
5	.0457	.0762	.0676	.0457	.0857	.0572	.0857
6	.0457	.0762	.0781	.0457	.0867	.0667	.0857
7	.0305	.0762	.0667	.0762	.0867	.0762	.0857
8	.0352	.0943	.0495	.0762	.0857	.0762	.0857
9	.0857	.0857	.0857	.0857	.0857	.1867	
10	.0857	.0857	.1715	.1848	.1848	.1848	.181
11	.1715	.0857	.3429	.1848	.1867	.1867	.2743
12	.1715	.0857	.3429	.1848	.0572	.1867	.1848
13	.1715	.0857	.1715	.1829		.0857	.1848
14	.1715	.0857	.1715	.1829	.0857	.1848	.0895
15	.1715	.0857	.1715	.0895	.0857	.1867	.0943
16	.1886	.0857	.2743	.1848		.1848	.1886
17	.1886	.0781	.2743	.0905	.0943	.1715	.1886
18	.0934	.0838	.1715	.0934	.0943	.0857	.0943
19	.0591	.0819	.0705	.0934	.0895	.0857	.0924
20	.0591	.0838	.0457	.0857	.0895	.0857	.0934
21	.0591	.0876	.0724	.0905	.0943	.0857	.0895
22	.0591	.0905	.0857	.0876	.0934	.0857	.0829
23	.0819	.0934	.0762	.0943	.0943	.0857	.0857
24	.0791	.0762	.0753	.0762	.0876	.0705	.0857
Max	.1886	.0943	.3429	.1848	.1867	.1867	.2743
Min	.0305	.0762	.0457	.0457	.0572	.0572	.0829
Avg	.0938	.0835	.1305	.1041	.0935	.1131	.1172



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 202 / 11 KV BORGAON ARJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2515	.3353	.2486	.2829	.1886	.1886
2	.4191	.2515	.3353	.2486	.2829	.1886	.1886
3	.4191	.2515	.503	.2486	.2829	.2829	.1886
4	.503	.3353	.503	.2486	.3772	.2829	.1886
5	.5868	.4191	.6706	.3315	.3772	.3772	.2829
6	.6706	.503	.8383	.4973	.3734	.3772	.3772
7	.8383	.5868	1.0059	.7373	.3772	.4715	.4715
8	.8383	.5868	1.0059	.7373	.2829	.3772	.4715
9	.8383	.503	.8383	.6554	.1886	.2829	.3772
10	.1886	.5658	.5658	.1886	.1886	.1698	.1886
11	.1698	.5658	.1886	.132	.503	.503	.2515
12	.0943	.5658	.0943	.0943	.2515	.503	.2515
13	.0943	.5658	.0943	.0943	.3353	.3353	.3353
14	.0943	.3772	.0943	.0943	.3353	.2515	.503
15	.0943	.3772	.0943	.0943	.3353	.2515	.503
16	.132	.3772	.0943	.1886	.503	.2515	.503
17	.132	.3772	.0943	.1886	.3353	.3353	.503
18	.2829	.5658	.1886	.2829	.3353	.503	.503
19	.2829	1.1317	.2829	.3772	.3772	.1886	.3772
20	.3206	1.1317	.2829	.3772	.3772	.2829	.3772
21	.2263	1.1317	.2452	.3772	.1886	.1886	.3772
22	.1886	.7545	.1886	.2829	.1886	.1886	.2829
23	.1698	.7545	.1886	.2829	.1886	.1886	.2829
24	.4191	.2515	.3353	.2486	.2829	.1886	.1886
Max	.8383	1.1317	1.0059	.7373	.503	.503	.503
Min	.0943	.2515	.0943	.0943	.1886	.1698	.1886
Avg	.3509	.5492	.3778	.3024	.3146	.2983	.3401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 203 / 11 KV ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1886	.7545	.1509	.4191	.2515	.2515
2	.2829	.1698	.7545	.1509	.4191	.2515	.3353
3	.2829	.1698	.7545	.1509	.4191	.2515	.3353
4	.3772	.1698	.9431	.1886	.503	.503	.503
5	.3772	.2641	.9431	.2829	.5868	.5868	.5868
6	.3772	.3584	1.1317	.3772	.6706	.6706	.6706
7	.3772	.3772	1.1317	.3772	.7545	.7545	.8383
8		.3584	1.1317	.3772	.8383	.6706	.7545
9	.1886	.2829	.9431	.2829	.7545	.503	.7545
10	.1886	.7545	.5658	.1886	.1886	.1886	.1886
11	.503	.3353	.503	.4096	.1886	.1886	.1886
12	.4191	.3353	.4144	.503	.132	.1886	.1886
13	.503	.503		.503	.1886	.1886	.1886
14	.4191	.503		.503	.132	.0943	.1886
15	.4191	.6706	.4144	.4191	.132	.0943	.1886
16	.4191	.6706	.4144	.4191		.0943	.1886
17	.503	.503	.4144	.4191	.1886	.0943	.1886
18	.503	.503	.4144	.4191	.1886	.1886	.1886
19	.2641	.5658	.2829	.3772	.1886	.1886	.3772
20	.3584	.9431	.2829	.3772	.3772	.2829	.3772
21	.2829	1.1317	.2452	.3772	.1886	.1886	.3772
22	.1886	.9431	.1886	.2829	.1886	.1886	.2829
23	.1886	.7545	.1886	.2829	.2515	.2515	.2829
24	.2829	.1886	.7545	.1509	.4191	.2515	.2515
Max	.503	1.1317	1.1317	.503	.8383	.7545	.8383
Min	.1886	.1698	.1886	.1509	.132	.0943	.1886
Avg	.3472	.4852	.6169	.3321	.3616	.2965	.3615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 204 / 11 KV PEDGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.503	.3353	.3315	.2452	.1886	.1886
2	.4191	.503	.3353	.3315	.2452	.1886	.1886
3	.4191	.503	.503	.3315	.2829	.1886	.1886
4	.503	.503	.503	.3315	.2829	.2829	.1886
5	.5868	.503	.6706	.4144	.2829	.2829	.3772
6	.5868	.5868	.6706	.5735	.3772	.3772	.3772
7	.6706	.5868	.8383	.6554	.3772	.3772	.3772
8	.6706	.5868	.8383	.6554	.2829	.3772	.3772
9	.6706	.503	.6706	.5735	.1886	.2829	.2829
10	.1886	.5658	.5658	.1886	.1886	.1698	.1886
11	.1698	.5658	.5658	.2829	.503	.3353	
12	.0943	.5658	.0943	.0943	.503	.4191	.4191
13	.0943	.3772	.0943	.0943	.4191	.3353	.503
14	.0943	.3772	.0943	.0943	.4191	.4191	.503
15	.0943	.3772	.0943	.0943	.3353	.4191	
16	.0943	.5658	.0943	.1886	.4191	.4191	
17	.0943	.5658	.0943	.1886	.4191	.503	.503
18	.2829	.5658	.132	.2829	.503	.503	.503
19	.2829	.9431	.2452	.3772	.2829	.1886	.3772
20	.2829	.9431	.2452	.3772	.2829	.1886	.3772
21	.1886	.9431	.2263	.3772	.1886	.1886	.3772
22	.1698	.7545	.1509	.2829	.132	.1886	.2829
23	.132	.7545	.1509	.2829	.1886	.1886	.2829
24	.4191	.503	.3353	.3315	.2829	.1886	.1886
Max	.6706	.9431	.8383	.6554	.503	.503	.503
Min	.0943	.3772	.0943	.0943	.132	.1698	.1886
Avg	.3178	.5894	.3562	.3223	.3180	.3000	.3358

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 206 / 11 KV LOANEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.132	.5658	.1509	.4191	.2515	.2515
2	.2829	.132	.5658	.1509	.4191	.2515	.2515
3	.2829	.0943	.5658	.1509	.4191	.2515	.2515
4	.3772	.132	.7545	.1886	.503	.503	.3353
5	.3772	.2829	.7545	.2829	.5868	.5868	.503
6	.3772	.3206	.9431	.3772	.6706	.6706	.5868
7	.3772	.2829	.9431	.3772	.7545	.7545	.7545
8	.2829	.2641	.9431	.3772	.8383	.8383	.7545
9	.1886	.1886	.7545	.2263	.7545	.503	.7545
10	.1886	.5658	.5658	.1886	.1886	.1698	.1886
11	.503	.3353	.4191	.3277	.1886	.1886	.0943
12	.503	.3353	.3315	.503	.0943	.1886	.0943
13	.4191	.3353	.3315	.503	.0943	.1886	.1886
14	.4191	.503	.3315	.503	.0943	.0943	.1886
15	.4191	.503	.3315	.4191	.0943	.0943	.1886
16	.4191	.503	.3315	.4191	.0943	.0943	.1886
17	.503	.503	.3315	.4191	.0943	.0943	.1886
18	.4191	.503	.3315	.4191	.1886	.1886	.1886
19	.1886	.5658	.2829	.3772	.2829	.2829	.3772
20	.2829	.7545	.2829	.3772	.2829	.2829	.3772
21	.2641	.9431	.2452	.3772	.1886	.1886	.3772
22	.1886	.9431	.1886	.2829	.1698	.1886	.2829
23	.1698	.7545	.1886	.2829	.2515	.2515	.2829
24	.2829	.132	.5658	.1509	.4191	.2515	.2515
Max	.503	.9431	.9431	.503	.8383	.8383	.7545
Min	.1698	.0943	.1886	.1509	.0943	.0943	.0943
Avg	.3333	.4170	.4937	.3263	.3371	.3066	.3292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 201 / 11 kv Bodhegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2572	.2572	.2572	.2572	.5144	.3772
2	.2058	.2572	.2572	.2743	.2743	.5658	.4287
3	.2058	.2572	.2572	.2915	.2915	.6687	.4801
4	.2743	.3429	.3429	.3772	.3772	.7202	.5144
5	.3772	.4115	.4115	.7716	.7202	.823	.6001
6	.463	.4801	.6859	1.1145	1.1145	.8916	.823
7	1.0288	.9259	1.0631	.8402	.9088	.9774	.9088
8	.7716	.6859	.8916	.6001	.6687	.8059	.8916
9	.3086		.5658	.463	.6344	.6516	.6859
10	.4287		.4458	.4115	.3772	.4458	.4108
11	.3772	.3601	.4458	.3086	.4973	.5144	.415
12	.3086	.3772	.3772	.2915	.6687	.4801	.5716
13	.3086	.3429	.2401	.2743	.5144		.6287
14	.3086	.3086	.3086	.2401	.3429	.3772	.4854
15	.3772	.3086	.3086	.2572	.3772	.3429	.381
16	.4287	.2743	.2915	.3086	.5144	.4287	.5716
17	.5144	.2915	.8573	.3086	.6001	.4458	.4287
18	.823	.5487	.3944	.3944		.3258	.3429
19	.7888	.7888	.823	.5487	.7202	.6344	.9431
20	.6859	.6859	.6687	.583	.6516	.6859	.6173
21	.583	.583	.5658	.6173	.6001	.7202	.6348
22	.5487	.5487	.5144	.5487	.5144	.5144	.5906
23	.5487	.2572	.4287	.5144	.4801	.4287	.5415
24	.2058	.2572	.2572	.2743	.3429	.4801	.3429
Max	1.0288	.9259	1.0631	1.1145	1.1145	.9774	.9431
Min	.2058	.2572	.2401	.2401	.2572	.3258	.3429
Avg	.4615	.4341	.4858	.4530	.5412	.5845	.5673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 202 / 11 KV Babra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.2058	.2572	.3086	.3429
2	.1715	.1715	.1715	.2229	.2572	.3601	.3772
3	.1715	.1715	.1715	.2229	.3086	.3944	.4287
4	.2401	.2572	.2572	.3772	.3429	.4458	.5144
5	.3429	.3429	.3429	.4973	.3772	.583	.6001
6	.4287	.4115	.4115	.6001	.4801	.703	.8573
7	.583	.6859	.7202	.6687	1.0117	.8745	1.2346
8	.5144	.5144	.583	.7202	.6344	.6001	.9431
9	.3258	.4115	.2572	.3429	.4973	.4973	1.0117
10	.6859	.7716	.3429	.583	.2572	.2915	.6859
11	.4287	.6001	.2401	.5316	.4973	.1715	.2858
12	.3429	.5144	.2572	.5144	.6001	.2058	.1905
13	.3429	.4801	.3258	.3772	.5144	.2229	
14	.3429	.4801	.2743	.3429	.3772	.2058	.3239
15		.4287	.3086	.3086	.3429	.2572	.2641
16	.5144	.3429	.3429	.3429	.4458	.2572	.2452
17	.6516	.5316	.4287	.3944	.2572	.1715	.2667
18	.7716	.6001	.3258	.4973	.1886	.1715	.1905
19	1.0288	.6859	.7716	.3086	.4115	.7373	1.0288
20	.8573	.8573	.7202	.4287	.4287	.5144	.8573
21	.6516	.6516	.5144	.4801	.3772	.6001	.7356
22	.5487	.5487	.4801	.5487	.3258	.5487	.6478
23	.5487	.5487	.4973	.583	.2915	.4287	.5658
24	.1715	.1715	.1715	.2743	.2915	.2915	.3429
Max	1.0288	.8573	.7716	.7202	1.0117	.8745	1.2346
Min	.1715	.1715	.1715	.2058	.1886	.1715	.1905
Avg	.4712	.4730	.3787	.4322	.4072	.4101	.5626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 203 / 11 Kv Nidhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5144	.3429	.2572	.2572
2	.5144	.5144	.5144	.5144	.3429	.3086	.3086
3	.5144	.5144	.5144	.6687	.3429	.3429	.3429
4	.6001	.7202	.5144	.7373	.3772	.3772	.4287
5	.823	.823	.6173	.8402	.4115	.4287	.6001
6	1.0288	1.0288	.6859	.6687	.4801	.4801	.6859
7	.9259	.9259	.7373	.5487	.6001	.8573	.7373
8	.823	.8573	.6173	.4973	.583	.7545	.8059
9	.7202	.7545	.583	.4287	.4115	.9774	.5658
10	.5144	.4801	.4458	.463	.4458	.4115	.5228
11	.4801	.4458	.5144	.463	.4115	.3429	.3961
12	.5658	.4458	.5487	.4973	.3429	.3086	.381
13	.4801	.4115	.9945	.3944	.3086	.2572	.362
14	.4287	.4115	.4458	.3086	.2572	.2401	.3429
15	.3772	.3772	.4458	.2572	.2401	.5144	.3239
16	.3429	.3772	.9088	.3429	.2572	.4287	.3429
17	.3429		.823	.4287	.3086	.3086	.3772
18	.3086	.2915	.8573	.3086	.4287	.4973	.4854
19	.8573	.8573	.823	.3429	.4973	.7545	.8916
20	.7716	.7716	.6516	.4287	.7545	.6859	.823
21	.6001	.6001	.6173	.5144	.7373	.6516	.6908
22	.5487	.5487	1.0288	.6173	.6859	.6001	.6287
23	.5144	.5144	.4973	.5144	.6173	.5144	.5847
24	.5144	.5144	.5144		.3086	.2229	.2058
Max	1.0288	1.0288	1.0288	.8402	.7545	.9774	.8916
Min	.3086	.2915	.4458	.2572	.2401	.2229	.2058
Avg	.5880	.5957	.6423	.4913	.4372	.4801	.5038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 204 / 11KV LEHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.3772	.3429	.1715	.1715	.2401
2	.3944	.3772	.3772	.3772	.1715	.2058	.2572
3	.3944	.3772	.3772	.4287	.1715	.2572	.2915
4	.5144	.5144	.5144	.5487	.2058	.3086	.3086
5	.6859	.7202	.6859	.7716	.3086	.3429	.3429
6	.8573	.8573	.823	.9431	.4115	.3772	.4287
7	.9774	.823	.9602	1.0288	.463	.4287	.4973
8	.8573		.8402	.7373	.3086	.3944	.4458
9	.6859	.6173	.6001	.583	.2229	.2401	.1886
10	.3772	.463	.4458	.4287	.3086	.2915	.381
11	.4287	.4287	.3258	.3429	.3429	.3429	
12	.3429	.3429	.2572	.4287	.2743	.3772	.2286
13	.3086	.3086	.1715	.4973	.2401	.3429	.2477
14	.2572	.2572	.1543	.3429	.2229	.3086	.2286
15	.2058		.2229	.2572	.2058	.2743	.1715
16	.1715	.1543	.2058	.1372	.2401	.2572	.2096
17	.1715	.1886	.1543	.1543	.2572	.2401	.2286
18	.2058	.1372	.1715	.12	.2915	.3258	.3429
19	.6001	.6001	.7202	.2058	.3772	.583	.6344
20	.5487	.5487	.9431	.3086	.5316	.5487	.6535
21	.5144	1.5432	.6687	.4287	.5144	.5487	.5093
22	.4287	.4287	.5658	.4801	.4458	.6516	.4191
23	.3772	.3772	.3772	.5316	.3772	.5144	.4382
24	.3944	.3772	.3772		.1715	.2058	.2058
Max	.9774	1.5432	.9602	1.0288	.5316	.6516	.6535
Min	.1715	.1372	.1543	.12	.1715	.1715	.1715
Avg	.4623	.4918	.4715	.4533	.3015	.3558	.3435



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 205 / 11KV NAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372	.2401	.3086	.3429
2	.1372		.1372	.1543	.2401	.3429	.3772
3	.1372	.1372	.3429	.3086	.2401	.3772	.4115
4	.2058	.2058	.2743	.3772	.3429	.4287	.4801
5	.2743	.2401	.3086	.4973	.4287	.4973	.5144
6	.3429	.2743	.6516	.7202	.5658	.5658	.6001
7	.7373	.6516	.6859	.5144	.823	.7716	.7716
8	.5144	.5487	.6173	.5658	.463	.583	.5658
9	.3601	.4115	.2229	.3086	.4115	.4287	.4801
10	.2743	.3086	.2572	.2572	***	.1886	.2858
11	.2572	.2058	.1886	.1372	.1543	.1543	.2667
12	.1715	.1715	.1543	.1543	.12	.0514	.2667
13	.1715	.12	.1029	.1029	.0857	.0686	.1905
14	.1715	.0857	.12	.0857	.0514	.0857	.2096
15	.1715	.0857	.0857	.0514	.0857	.1372	.1509
16	.2401	.0514	.3086	.0857	.1372	.1543	.1886
17	.2743	.0514	.1543	.0686	.1543	.1372	.1524
18	.3086	.2401	.1372	.0514	.1715	.0857	.1524
19	.3944	.3944	.4973	.2058	.4115	.3601	.583
20	.3429	.3429	.5658	.3258	.4287	.4287	.4458
21	.2915	.2915	.3772	.4287	.3772	.4801	.3395
22	.2743	.2743	.2915	.4801	.3086	.5144	.362
23	.2743	.2743	.2572	.4287	.2743	.4287	.3239
24	.1372	.1372	.1372	.1372	.3086	.1715	.3429
Max	.7373	.6516	.6859	.7202	15.6207	.7716	.7716
Min	.1372	.0514	.0857	.0514	.0514	.0514	.1509
Avg	.2751	.2453	.2922	.2743	.9352	.3229	.3669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 206 / 11KV KHAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2229	.2229	.4801	.3772
2	.2058	.2058		.2572	.2572	.5144	.4287
3	.2058	.2058	.2058	.2915	.2915	.5487	.4801
4	.2572	.2572	.3086	.3429	.3429	.6516	.4458
5	.3086	.3086	.3772	.3944	.3944	.7545	.5487
6	.3429	.3772	.6001	.6687	.6687		.6859
7	.6173	.6001	.8573	.6516	.8059	.6687	.7888
8	.4801	.4287	.823	.6001	.6687	.7716	.7202
9	.3429	.3086	.5144	.4801	.6001	.583	.8573
10	.4801	.5144	.4801	.4801	.3429	.4115	.5788
11	.3429	.463	.4115	.3086	.4973	.3429	.3961
12	.2743	.3772	.3258	.1715	.5658	.3772	.3429
13	.2401	.3429	.2401	.3086	.5144	.4115	.2667
14	.2058	.3429	.2572	.2572	.3772	.3429	.362
15	.2401	.3086	.823	.1715	.3086	.3086	.2829
16	.5658	.3086	.3258	.3772	.3772	.2915	.3239
17	.6859	.3429	.3772	.4287	.4458	.2915	.3429
18	.823	.4801	.4287	.4801	.3429	.2743	.3048
19	.9602	.9602	.8573	.5144	.7202	.7545	.9431
20	.7716	.7716	.7373	.5487	.7716	.6859	.8573
21	.6001	.6001	.6687	.583	.6173	.6001	.7392
22	.5144	.5144	.5316	.6516	.4801	.5144	.5335
23	.5144	.5144	.4287	.4801	.4973	.5487	.4706
24	.2058	.2058	.2058	.2229	.3429	.4973	.3086
Max	.9602	.9602	.8573	.6687	.8059	.7716	.9431
Min	.2058	.2058	.2058	.1715	.2229	.2743	.2667
Avg	.4330	.4144	.4779	.4122	.4772	.5055	.5161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 201 / 11 kv Shevata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.156	.156	.1578	.156	.2075	.2096	.2263
2	.156	.1578	.1578	.1406	.2075	.2075	.2075
3	.156	.1867	.1753	.1638	.2263	.2263	.2263
4	.2058	.2241	.208	.2103	.3018	.3018	.3018
5	.2883	.25	.2743	.2454	.3772	.3772	.3856
6	.39	.2812	.3561	.2103	.4904	.5601	.6224
7	.4359	.4681	.39	.2932	.5658	.6602	.6979
8	.3978	.3395	.3353	.3041	.4338	.5281	.5658
9	.213	.2614	.1658	.1677	.3772	.415	.415
10	.3018	.2987	.2263	.2641	.2263	.2641	
11	.1509	.1698		.2263	.116	.1781	.1619
12	.0943	.0943	.0943	.1509	.132	.0972	.1619
13	.132	.1132	.0943	.1132	.1063	.0693	.144
14	.1886	.1132	.0566	.0857	.0886	.0671	.1296
15	.2452	.1132	.0943	.1132	.0709	.0686	.0972
16	.2263	.132	.0943	.0943	.1052	.0701	.1296
17	.3961	.132	.1509	.1132	.132	.1052	.1311
18	.5228	.3018	.1928	.2263	.1402	.0937	.1509
19	.5281	.547	.3961	.3206	.3395	.2829	.5658
20	.3584	.3772	.3772	.3018	.2829	.3395	.415
21	.2829	.3206	.3018	.2641	.1886	.2829	.3018
22	.2641	.2641	.2829	.2263	.2075	.2452	.2829
23	.1802	.2452	.2263	.2263	.2075	.2427	.2829
24	.1753	.1543	.1578	.1638	.2075	.2075	.2263
Max	.5281	.547	.3961	.3206	.5658	.6602	.6979
Min	.0943	.0943	.0566	.0857	.0709	.0671	.0972
Avg	.2686	.2376	.2159	.1992	.2391	.2542	.2969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 202 / 11 kv NARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0526	.0526	.0566	.0943	.0953	.1097
2	.0351	.0526	.0526	.0549	.0943	.0943	.104
3	.0351	.0937	.0526	.0678	.132	.132	.1698
4	.052	.1337	.0867	.0848	.2452	.2263	.2452
5	.0857	.1875	.12	.125	.3772	.3772	.3921
6	.1357	.2214	.1543	.1581	.5093	.547	.547
7	.285	.4167	.2204	.3429	.5847	.6036	.5847
8	.2486	.3439	.2012	.333	.4715	.5093	.4755
9	.104	.1753	.0995	.1457	.2829	.3018	.3189
10	.1886	.1886	.1509	.1949	.1698	.1886	.1509
11	.0943	.1132	.0754	.0943	.1417	.1753	.1147
12	.0754	.1132	.0549	.0754	.0566	.0848	.0819
13	.0914	.0754	.0566	.0754	.0532	.1063	.081
14	.0934	.0943	.0678	.0943	.0532	.0876	.0655
15	.0701	.0754	.0943	.0754	.0532	.052	.0648
16	.0566	.0943	.0709	.1132	.0701	.0469	.0655
17	.3018	.0943	.1017	.0943	.1052	.0867	.0983
18	.3395	.1886	.1494	.1698	.0701	.0876	
19	.2263	.4527	.3395	.4338	.4527	.3206	.415
20	.3109	.3395	.3206	.3772	.3395	.3018	.3772
21	.2195	.2263	.2263	.2829	.2075	.2263	.2452
22	.1509	.1698	.1543	.1509	.1698	.1698	.1886
23	.1227	.132	.132	.132	.132	.132	.1509
24	.0351	.0486	.0526	.052	.0943	.0943	.1132
Max	.3395	.4527	.3395	.4338	.5847	.6036	.5847
Min	.0351	.0486	.0526	.052	.0532	.0469	.0648
Avg	.1414	.1702	.1286	.1577	.2067	.2103	.2243

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 203 / 11 kv Pathri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.6036	.5853	.1949	.1949	.2056
2	.5658	.5658	.6036	.6036	.1949	.1949	.2427
3	.6413	.7095	.7167	.7282	.2126	.2126	.2343
4	.8676	.8413	1.0185	.8173	.2804	.2629	.3366
5	1.2826	1.2883	1.2637	1.2826	.4287	.4207	.4359
6	1.6409	1.6598	1.6032	1.6598	.583	.5784	.5601
7	1.6598	1.6409	1.6598	1.6409	.788	.8495	.7907
8	1.6032	1.5844	1.5466	1.4146	.6371	.7202	.8402
9	1.2826	1.226	1.2071	1.2637	.4144	.4733	.4607
10	.7922	.9054	.6979	.7922	.7922	.6413	.4527
11	.4424	.4191	.415	.426	.4904	.4527	.4527
12	.415	.3647	.2429	.4049	.2279	.415	
13	.3467	.2785	.3725	.3077	.2801	.3961	
14	.3563	.2818	.3506	.2915	.415	.3772	.4715
15	.4572	.2818	.3185	.2915	.4527	.4527	.4715
16	.6036	.3239	.3479	.3077	.4715	.3856	.5093
17	.5493	.3201	.3467	.3113	.5281	.3961	.5093
18	.4527	.3441	.2883	.3605	.8299	.7545	.7922
19	1.3769	1.4146	1.1694	1.3203	1.226	1.3769	1.4712
20	1.1317	1.2637	1.226	1.1883	.9808	1.1694	1.1694
21	.9054	.9619	.9619	.8676	.8488	.8048	.8865
22	.7545	.7545	.8676	.7922	.7356	.7545	.7356
23	.6036	.6413	.6447	.679	.6413	.6401	.6602
24	.5847	.5975	.6036	.6036	.1949	.2126	.2058
Max	1.6598	1.6598	1.6598	1.6598	1.226	1.3769	1.4712
Min	.3467	.2785	.2429	.2915	.1949	.1949	.2056
Avg	.8284	.8014	.7948	.7892	.5354	.5474	.5861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 204 / 11kv Wadod Bazar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.1875	.2126	.1989	.4904	.4954	.4904
2	.2126	.2241	.2126	.208	.4904	.4904	.4904
3	.2481	.2572	.2481	.2534	.5658	.5658	.5281
4	.3155	.2824	.3155	.3547	.679	.679	.7167
5	.3814	.4207	.3814	.3704	.8299	.7922	.7537
6	.463	.427	.4801	.426	.9808	.9522	.9808
7	.6952	.6093	.6344	.578	1.1694	1.1883	1.1128
8	.5533	.6348	.5426	.5365	.7167	1.0456	1.0562
9	.4372	.5415	.3856	.5975	.8676	.7922	.8139
10	.6036	.8676	.6224	.6224	.679	.6602	.7468
11	.4904	.6036	.5093	.5847	.3481	.3018	.3688
12	.4527	.6036	.4527	.4904	.3395	.2785	.3315
13	.2641	.5093	.4715	.4338	.2835	.2656	.2984
14	.2641	.4338	.415	.4527	.2481	.2622	.2818
15	.3395	.4338	.4527	.4527	.2303	.2713	.2486
16	.5847	.4904	.4715	.4904	.2804	.2347	.2515
17	.6036	.4527	.4254	.4715	.298	.2294	.2347
18	.7362	.7167	.7167	.679	.3681	.2883	.3429
19	.8865	.7167	.811	.7922	.8676	.8676	.9054
20	.7095	.7167	.7733	.7733	.7545	.7356	.7733
21	.6602	.6979	.6602	.6413	.6602	.7545	.6602
22	.6224	.6036	.6036	.6036	.6036	.6413	.6979
23	.547	.5281	.4218	.547	.5281	.547	.5281
24	.2303	.2241	.2126	.1875	.4904	.4904	.4904
Max	.8865	.8676	.811	.7922	1.1694	1.1883	1.1128
Min	.2126	.1875	.2126	.1875	.2303	.2294	.2347
Avg	.4797	.5076	.4764	.4894	.5737	.5762	.5876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 205 / 11 KV RAJENDRA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2614	.2641	.3018	.2829	.2641	.2987
2	.2641	.2614	.2641	.2804	.2829	.2641	.253
3	.2829	.2614	.2641	.2804	.2829	.2641	.2987
4	.2829	.2347	.2641	.2622	.2829	.2641	.2804
5	.2641	.2454	.2641	.2987	.2829	.2641	.2804
6	.2641	.2614	.2641	.2829	.2829	.2641	.2804
7	.2829	.2561	.2641	.2187	.3018	.2641	.2622
8	.2829	.2641	.3395	.4207	.3772	.3961	.4382
9	.3721	.2507	.415	.4031	.3772	.3395	.5487
10	.3961	.2658	.4338	.4031	.3772	.4527	.4207
11	.3563	.2641	.3932	.4338	.3506	.39	.4338
12	.4024	.2829	.2454	.4527	.3584	.3768	.4715
13	.3961	.2829	.3898	.4527	.3772	.39	.4527
14	.3681	.2829	.415	.4527	.3772	.4294	.4715
15	.3856	.2829	.3353	.4527	.3961	.4031	.4527
16	.415	.2829	.4031	.4527	.3961	.4024	.4527
17	.4338	.2829	.4031	.4527	.3584	.407	.415
18	.3961	.2829	.4338	.4338	.3584	.39	.4338
19	.2294	.2641	.3018	.3018	.2641	.4527	.3395
20	.2614	.2641	.2829	.3018	.2641	.3395	.2829
21	.2641	.2641	.3395	.3018	.2641	.2629	.2829
22	.2829	.2641	.3018	.3018	.2641	.2829	.2829
23	.2829	.2641	.2835	.2829	.2641	.2715	.2829
24	.2829	.2641	.2641	.3018	.2829	.2641	.3018
Max	.4338	.2829	.4338	.4527	.3961	.4527	.5487
Min	.2294	.2347	.2454	.2187	.2641	.2629	.253
Avg	.3214	.2663	.3262	.3553	.3211	.3375	.3633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 201 / 11KV JATEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.168	.1494	.1204	.1505	.1715
2	.1372	.1372	.168	.1494	.1204	.1656	.1715
3	.1372	.1543	.168	.1494	.1505	.1656	.1886
4	.1543	.1886	.1867	.168	.2134	.2258	.2294
5	.1715	.2058	.2054	.1867	.2107	.2591	.2743
6	.1886	.2058	.2241	.2054	.3048	.3637	.3113
7	.1715	.2572	.2054	.2241	.4687	.7362	.5571
8	.1543	.1372	.168	.1494	.4801	.5218	.3734
9	.0686	.1307	.0934	.112	.1505	.3125	.2801
10	.3258	.112	.0934	.0934	.056	.0747	.0934
11	.3429	.3161	.3201	.3734	.056	.056	.056
12	.3429	.3161	.2743	.3734	.056	.056	.056
13	.3772	.301	.2286	.3361	.056	.056	.1307
14	.2743	.2709	.2134	.2987	.056	.056	.1494
15	.2401	.2559	.1981	.2241	.056	.056	.1494
16	.2743	.2559	.2134	.2241	.056	.056	.0934
17	.2572	.286	.2439	.2926	.056	.056	.1097
18	.2229	.2107	.1543	.2195	.0747	.0747	.112
19	.1372	.1307	.1494	.1097	.112	.112	.112
20	.1372	.112	.1307	.1097	.0934	.112	.0934
21	.1372	.1307	.1494	.1097	.0934	.112	.0934
22	.12	.1494	.1494	.112	.0934	.0934	.0934
23	.12	.1494	.1494	.0934	.0747	.0747	.0934
24	.1372	.12	.168	.1494	.1204	.1355	.1543
Max	.3772	.3161	.3201	.3734	.4801	.7362	.5571
Min	.0686	.112	.0934	.0934	.056	.056	.056
Avg	.1986	.1946	.1843	.1922	.1387	.1701	.1728



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 202 / 11KV DHAMANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1505	.1543	.0747	.0934	.0934
2	.1029	.1029	.1656	.1475	.0747	.0934	.0934
3	.1029	.1543	.1656	.1475	.0747	.0934	.0934
4	.1543	.1886	.1806	.1619	.112	.112	.112
5	.2058	.2572	.1981	.1943	.112	.1307	.112
6	.5658	.2915	.2743	.2134	.112	.1307	.1307
7	.6516	.4801	.5921	.5182	.0934	.1307	.1494
8	.4801	.5487	.5121	.3048	.0934	.112	.1307
9	.3086	.3201	.3048	.1867	.0747	.0747	.1307
10	.0514	.0747	.056	.056	.0934	.0934	.056
11	.0343	.056	.056	.056	.3462	.2743	.3734
12	.0343	.0373	.0373	.056	.3462	.2134	.3734
13	.0343	.0373	.0373	.056	.253	.1524	.3361
14	.0343	.0373	.0373	.056	.2372	.1524	.2987
15	.0343	.0373	.0373	.0373	.2372	.1524	.2614
16	.0343	.0373	.0373	.0373	.2656	.2134	.2241
17	.0343	.0373	.0373	.0366	.2187	.2439	.1867
18	.0343	.056	.056		.1505	.1829	.1867
19	.0514	.0747	.0747		.0747	.0747	.056
20	.0686	.0934	.0934		.0934	.0934	.056
21	.0686	.056	.0747	.0366	.0934	.0934	.056
22	.0514	.056	.0747	.056	.0934	.112	.056
23	.1543	.056	.056	.056	.0934	.112	.056
24	.2915	.2572	.1505	.1543	.056	.0934	.0934
Max	.6516	.5487	.5921	.5182	.3462	.2743	.3734
Min	.0343	.0373	.0373	.0366	.056	.0747	.056
Avg	.1529	.1430	.1441	.1297	.1447	.1345	.1548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 203 / 11KV BABHULGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0373	.056	.112	.1505	.1372
2	.0343	.0343	.0373	.056	.112	.1505	.1372
3	.0514		.0373	.0747	.1204	.1505	.1543
4	.0514	.0514	.056	.0934	.1204	.1677	.1543
5	.0686	.0514	.056	.112	.0753	.1677	.1715
6	.0686	.0514	.0747	.112	.1677	.2258	.2294
7	.0686	.0686	.0747	.0747	.3048	.3637	.3601
8	.0514	.0686	.056	.0747	.3281	.4161	.5228
9	.0343	.056	.056	.056	.0301	.3125	.3921
10	.2401	.0373	.0373	.056	.0373	.0373	.056
11	.2572	.2187	.1677	.2926	.0187	.0373	.056
12	.2229	.1957	.1677	.2987	.0187	.0187	.0373
13	.2229	.2408	.1524	.2987	.0187	.0187	
14	.2229	.2107	.1475	.2987	.0187	.0187	
15	.2058	.2107	.1311	.0373	.0187	.0187	.0187
16	.2229	.1957	.1372	.2801	.0187	.0187	.0187
17	.1715	.1806	.1524	.2801	.0187	.0187	.0187
18	.12	.1656	.1524	.2801	.0373	.0373	.0187
19	.0343	.056	.0373	.056	.056	.056	.056
20	.0343	.056	.0373	.056	.056	.056	.056
21	.0343	.0373	.0373	.056	.056	.056	.056
22	.0343	.0373	.056	.056	.056	.0373	.056
23	.0343	.0373	.056	.0373	.056	.0373	.056
24	.0343	.0343	.0373	.056	.0753	.1505	.1543
Max	.2572	.2408	.1677	.2987	.3281	.4161	.5228
Min	.0343	.0343	.0373	.0373	.0187	.0187	.0187
Avg	.1065	.1013	.0830	.1312	.0805	.1134	.1326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 204 / 11 KV JATEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2743	.2801	.2926	.2241	.2801	.2658
2	.3258	.3258	.2801	.2926	.2801	.2801	.2658
3	.6687	.6859	.3174	.3292	.2801	.3174	.2835
4	.7373	.7545	.5228	.4481	.3361	.4481	.4024
5	.8573	.8573	.7282	.7095	.7095	.6979	.7282
6	.9088	.8916	1.0082	.9709	1.0456	.9619	.9709
7	.9945	.9431	1.0374	1.0642	1.226	1.0751	1.1763
8	.6859	.9088	1.0642	.9149	1.0082	1.0829	1.0456
9	.823	.8029	.9335	.8775	.8029	.8589	.7655
10	.4973	.7282	.5975	.5975	.5975	.4481	.5788
11	.3429	.4108	.3658	.4668	.4108	.3292	.2801
12	.2058	.3174	.2561	.2987	.2987	.2561	.2801
13	.2229	.2801	.2103	.2241	.2614	.1949	.1867
14	.3258	.2801	.2103	.2987	.2427	.2126	.1867
15	.3944	.2614	.2229	.2614	.2801	.2303	.1867
16	.4973	.2614	.2926	.2987	.2987	.2378	.2241
17	.6001	.1867	.3475	.2987	.3174	.2743	.3734
18	.6516	.2801	.5601	.5601	.5975	.4668	.5228
19	.6687	.9709	.8402	.7468	.8402	.8589	.8215
20	.7373	.8029	.7468	.5601	.6161	.7282	.7468
21	.4973	.5041	.5601	.4481	.4294	.3547	.5228
22	.3258	.3547	.4024	.3734	.3547	.3174	.3734
23	.3086	.3174	.3109	.2987	.3174	.2926	.2987
24	.2743	.2743	.2987	.3109	.2241	.2801	.2835
Max	.9945	.9709	1.0642	1.0642	1.226	1.0829	1.1763
Min	.2058	.1867	.2103	.2241	.2241	.1949	.1867
Avg	.5358	.5281	.5164	.4976	.5000	.4785	.4904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 205 / 11KV SULTANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1957	.1543	.0747	.0187	.0187
2	.1543	.2572	.1957	.1715	.0747	.0187	.0187
3	.2058	.3258	.1957	.1715	.0747	.0187	.0187
4	.2401	.4287	.2286	.1802	.0747	.0187	.0187
5	.4458	.4973	.2656	.1966	.0747	.0187	.0187
6	.6001	.3429	.286	.2622	.0747	.0187	.0187
7	.6687	.4801	.6483	.4877	.0747	.0187	.0187
8	.4973	.6344	.7011	.5639	.0747	.0187	.0187
9	.3258	.3749	.3048	.3921	.0747	.0187	.0187
10	.0171	.0187	.056	.0187	.0747	.0187	.0187
11	.0171	.0187	.0747	.0187	.301	.3201	.3361
12	.0171	.0187	.0747	.0187	.301	.3048	.3361
13	.0171	.0187	.0747	.0187	.2559	.2743	.3361
14	.0171	.0187	.0747	.0187	.2896	.2134	.3109
15	.0171	.0187	.0747	.0187	.2286	.1677	.2987
16	.0171	.0187	.0747	.0187	.1562	.2134	.3547
17	.0171		.0747	.0187	.1898	.3353	.3292
18	.0171	.0187	.0747	.0373	.2107	.2591	.3361
19	.0171	.0187	.0716	.056	.0187	.0187	.0187
20	.0171	.0187	.0747	.056	.0187	.0187	.0187
21	.0171	.0187	.0747	.0747		.0187	.0187
22	.0171	.0187	.056	.0747	.0187	.0187	.0187
23	.0171		.056	.0747	.0187	.0187	.0187
24	.1715	.1543	.1656	.1543	.0747	.0187	.0187
Max	.6687	.6344	.7011	.5639	.301	.3353	.3547
Min	.0171	.0187	.056	.0187	.0187	.0187	.0187
Avg	.1536	.1761	.1739	.1357	.1230	.0995	.1224

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 201 / 11KV KINGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.298	.2688	.2429	.1886	.1886	.1886
2	.2915	.298	.2656	.2429	.2263	.2263	.1886
3	.3353	.3429	.2915	.2572	.2641	.2263	.2263
4	.4359	.3688	.3241	.3041	.2614	.2641	.2641
5	.4807	.3978	.4268	.4001	.2801	.2829	.2801
6	.5801	.6133	.5647	.5502	.3142	.2829	.3206
7	.9339	.8848	.8543	.8688	.3772	.3018	.3772
8	.9555	.7935	.6144	.7145	.2829	.3206	.3584
9	.5868	.6226	.5502	.602	.1886	.2641	.2801
10	.3206	.3584	.2401	.2957	.2263	.2263	.2427
11	.1509	.2641	.2572	.1867	.5967	.4725	.4572
12	.1886	.1848	.2401	.1494	.583	.4938	.3763
13	.1509	.168	.208	.1494	.5735	.3715	.3201
14	.1698	.1663	.1734	.1307	.4588	.3201	
15	.2075	.1509	.1734	.132	.4752	.2667	.5335
16	.1509	.1478	.1907		.5735	.2743	.5117
17	.2452	.1478	.2601	.1867	.5079	.4134	.4666
18	.2452	.1848		.2402	.4588	.3429	.3048
19	.2829	.3206	.298	.3326	.2641	.2427	.3696
20	.2829	.3326	.2774	.3174	.3018	.2829	.4066
21	.2452	.2801	.2601	.3174	.2829	.2801	.3174
22	.2075	.2427	.2427	.2829	.3018	.2263	.2801
23	.1886	.2054	.1907	.2263	.2263	.2054	.2054
24	.333	.333	.2753	.2429	.1886	.1886	.1886
Max	.9555	.8848	.8543	.8688	.5967	.4938	.5335
Min	.1509	.1478	.1734	.1307	.1886	.1886	.1886
Avg	.3445	.3378	.3238	.3206	.3501	.2902	.3245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 202 / 11KV PIMPALGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.0943	.0714	.0943	.0934	.0943
2	.0943	.0934	.0934	.0724	.0934	.0934	.0943
3	.1307	.0934	.1132	.0857	.1307	.112	.1132
4	.168	.1307	.1509	.1158	.168	.1494	.1509
5	.2218	.1867	.2012	.1593	.2033	.2241	.2263
6	.2743	.2241	.2572	.2172	.2587	.2801	.2829
7	.3292	.3361	.3206	.2606	.2614	.3547	.2743
8	.2743	.2801	.2829	.2286	.2801	.2614	.3206
9	.1848	.2427	.1572	.2561	.2614	.2241	.1663
10	.168	.128	.1143	.1848	.1494	.1509	.1494
11	.112	.1307	.0987	.0924	.1307	.128	.1494
12	.1494	.0943	.0714	.0747	.112	.1132	.0934
13	.112	.0943	.0572	.0747	.112	.0943	.0934
14	.1307	.0943	.0423	.0934	.1307	.0943	.0747
15	.1494	.0943	.0572	.0934	.0934	.0754	.0747
16	.2054	.0943	.0724	.112	.0934	.0754	.0747
17	.2054	.132	.0579	.1109	.112	.0857	.1109
18	.2427	.2075	.0572	.1478	.1867	.1886	.1294
19	.2241	.2229	.1429	.2402	.2427	.2279	.1848
20	.2241	.2401	.1715	.1867	.2054	.2452	.168
21	.1867	.1509	.1572	.1307	.168	.1509	.1307
22	.1307	.132	.1014	.1132	.1307	.128	.112
23	.0934	.1132	.0857	.0943	.112	.1132	.0747
24	.0943	.0934	.0943	.0724	.0754	.0747	.0943
Max	.3292	.3361	.3206	.2606	.2801	.3547	.3206
Min	.0934	.0934	.0423	.0714	.0754	.0747	.0747
Avg	.175	.1543	.1272	.1370	.1586	.1558	.1432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 203 / 11KV GANORI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0943	.0943	.0867	.1595	.1753	.1619
2	.112	.0943	.1294	.1214	.1753	.1753	.1581
3	.1663	.1132	.1478	.1402	.2229	.2103	.2105
4	.2195	.1509	.1886	.1734	.2743	.2629	.2561
5	.2561	.2075	.2452	.2254	.3353	.3481	.3906
6	.3109	.3018	.3018	.2743	.4359	.4475	.578
7	.3292	.3961	.3395	.3121	.4915	.7537	.7621
8	.2896	.3772	.3174	.3121	.6718	.6718	.6687
9	.2926	.2829	.2427	.2926	.4696	.4588	.4748
10	.3018	.3018	.2427	.3292	.1886	.132	.2218
11	.4641	.4572	.5287	.3311	.1509	.1307	.112
12	.5407	.443	.4344	.4254	.1132	.1109	.112
13	.5571	.3755	.4144	.4572	.132	.1307	.112
14	.4807	.3572	.4572	.3963	.132	.0943	.112
15	.5304	.3963	.4923	.3887	.1509		.1307
16	.6226	.3909	.5357		.1509	.132	.2033
17	.5898	.3909	.4489	.426	.1509	.1886	.2033
18	.3605	.3269	.2751	.3401	.1886	.1886	.168
19	.2075	.2241	.1572	.2033	.2263	.2452	.1867
20	.1698	.1867	.208	.2218	.1698	.1886	.1867
21	.132	.132	.1734	.1307	.132	.1886	.1848
22	.1132	.1132	.1214	.1307	.132	.1509	.1867
23	.1132	.1132	.104	.112	.1132	.1132	.1867
24	.112	.1132	.1132	.1029	.1772	.1753	.1718
Max	.6226	.4572	.5357	.4572	.6718	.7537	.7621
Min	.112	.0943	.0943	.0867	.1132	.0943	.112
Avg	.3077	.2642	.2797	.2580	.2310	.2467	.2558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 204 / 11 KV DONGERGAON-SHIRODI SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3155	.3429	.2896	.3206	.3206	.2267
2	.3429	.3086	.3113	.2751	.3206	.3206	.2332
3	.4024	.3353	.3239	.2858	.3361	.3584	.2469
4	.4191	.3647	.3647	.3185	.3547	.3584	.2751
5	.4096	.4096	.431	.3715	.3734	.3961	.2515
6	.4372	.426	.4915	.4344	.3881	.415	.3201
7	.7842	.7287	.5898	.5502	.3961	.4527	.3704
8	.6062	.6062	.5533	.4633	.3961	.3961	.2934
9	.3315	.431	.3475	.4062	.3018	.3584	.3734
10	.3206	.2401	.2743	.2957	.2263	.1829	.3174
11	.3018	.189	.2572	.2987	.3812	.3605	.3688
12	.0754	.1829	.2572	.2801	.3605	.3281	.3315
13	.0754	.1715	.2601	.2286	.3441	.3113	.2881
14	.3018	.1715	.2427	.2286	.3277	.3048	.2753
15	.3018	.2858	.2427	.2286	.3277	.2934	.1802
16	.3018	.2858	.2401	.2286	.3277	.3239	.3401
17	.3206	.2858	.2401	.2667	.3481	.2425	.3401
18	.3206	.3048	.2427	.2858	.3441	.2401	.3563
19	.3395	.2534	.333	.3547	.3395	.2401	.3361
20	.3395	.2715	.3294	.3584	.3584	.2353	.3395
21	.3395	.2743	.3294	.3772	.3584	.2353	.3361
22	.3206	.2572	.2774	.3584	.3584	.2498	.3174
23	.3018	.2267	.2915	.3584	.3395	.2469	.3206
24	.3429	.4031	.3605	.3144	.3206	.3206	.2267
Max	.7842	.7287	.5898	.5502	.3961	.4527	.3734
Min	.0754	.1715	.2401	.2286	.2263	.1829	.1802
Avg	.3492	.3220	.3306	.3274	.3437	.3122	.3027



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 205 / 11 KV WAREGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2241	.2263	.1715	.2241	.2241	.2263
2	.2218	.2241	.2452	.1858	.2587	.2241	.2263
3	.3109	.3174	.3018	.2317	.3142	.2614	.2561
4	.3982	.4481	.4287	.362	.439	.3174	.3086
5	.6024	.7095	.679	.5213	.6516	.5228	.5083
6	.7888	.9522	.8059	.6661	.8859	.8589	.7716
7	.8402	1.0082	.7545	.7819	.8589	1.0456	.7733
8	.6135	.7842	.4527	.695	.6535	.5788	.6036
9	.4706	.6348	.4287	.6335	.6348	.7095	.724
10	.4481	.4287	.2858	.4024	.3361	.3772	.4344
11	.2987	.3395	.2172	.2534	.2241	.2401	.2561
12	.0747	.2058	.1738	.2195	.168	.1966	.2012
13	.0747	.2452	.1572	.2012	.168	.1677	.1646
14	.2614	.1886	.1448	.1829	.1307	.1543	.1646
15	.3361	.1886	.1429	.1646	.056	.1543	.1646
16	.3921	.2263	.1593		.2241	.0732	.2534
17	.5228	.2926	.1593	.2561	.2987	.0701	.2587
18	.6535	.4024	.2751	.3696	.4294	.3584	.4066
19	.8775	.7545	.5858	.7207	.7842	.7167	.7316
20	.6161	.6516	.4572	.7577	.7282	.7545	.7947
21	.5041	.6036	.4572	.4108	.5041	.547	.6767
22	.3361	.4207	.3144	.3547	.3547	.3584	.4024
23	.2614	.2641	.2	.2801	.3361	.2641	.2402
24	.2033	.2054	.2075	.1572	.2241	.2241	.2263
Max	.8775	1.0082	.8059	.7819	.8859	1.0456	.7947
Min	.0747	.1886	.1429	.1572	.056	.0701	.1646
Avg	.4304	.4467	.3442	.3904	.4120	.3916	.4073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 206 / 11 KV WANEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2829	.2829	.2572	.2401	.2804	.2829
2	.2801	.2829	.2829	.2601	.2374	.2804	.3018
3	.3174	.3206	.3206	.2947	.2883	.3601	.3772
4	.3511	.3584	.3584	.3294	.3605	.4115	.3725
5	.3881	.3961	.3961	.3988	.4049	.4641	.4428
6	.439	.4338	.4338	.3988	.4801	.5079	.5468
7	.4805	.4338	.4715	.3185	.5636	.9503	.8383
8	.4251	.3961	.3772	.3121	.7537	.8356	.8025
9	.2614	.2452	.2229	.2427	.4144	.5138	.5335
10	.2263	.2075	.1715	.168	.132	.1509	.168
11	.5636	.4572	.3715	.3963	.1132	.1132	.1307
12	.431	.4199	.362	.4268	.0943	.1132	.0943
13	.426	.3715	.3666	.426	.0754	.0754	.0943
14	.3605	.381	.3715	.3563	.0943	.0754	.0934
15	.4372	.3475	.3909	.2683	.0943	.0754	.0943
16	.5182	.442	.3909	.3521	.0943	.0754	.0943
17	.4588	.3909	.3286	.3315	.1132	.0754	.0934
18	.3812	.381	.2715	.3018	.132	.132	.1494
19	.2829	.2829	.2601	.2241	.2263	.2829	.1867
20	.2829	.2829	.2601	.2614	.2452	.2641	.2452
21	.2829	.2829	.2601	.2075	.2075	.1698	.2054
22	.2829	.2829	.2601	.1698	.1509	.1509	.1886
23	.2829	.2829	.2601	.1698	.1509	.132	.1886
24	.2987	.2829	.2641	.2572	.2743	.2804	.2343
Max	.5636	.4572	.4715	.4268	.7537	.9503	.8383
Min	.2263	.2075	.1715	.168	.0754	.0754	.0934
Avg	.3641	.3436	.3223	.2971	.2475	.2821	.2816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 201 / 11 KV PIRBAWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1991	.2096	.2286	.4191	.2012	.4572
2	.2286	.2204	.2477	.2286	.4763	.2279	.4572
3	.2667	.2543	.2534	.2667	.5144	.2622	.4954
4	.381	.3521	.3155	.3258	.5906	.3041	.6478
5	.4763	.3593	.4115	.4115	.724	.3201	.7621
6	.5144	.3841	.503	.4801	.8573	.3864	.8916
7	.6516	.6241	.6299	.5487	1.105	.4458	1.1431
8	.5658	.5639	.6226	.463	.8954	.8488	.9526
9	.3772	.3125	.3258	.3239	.6668	.6602	.8573
10	.4191	.4954	.4191	.4763	.5906		.5335
11	.3206	.381	.3048	.2858	.2241	.4954	.2812
12	.2829	.3048	.2858	.3239	.1698	.362	.3521
13	.2829	.3239	.1715	.2667	.1486	.3048	.2439
14	.3018	.3239	.1715	.2286	.2656	.381	.2105
15	.3018	.3239		.2667	.253	.3429	.2031
16	.415	.362	.3239	.2858	.213	.3429	.2006
17	.4904	.3048	.3239	.2286	.3018	.362	.2012
18	.5847	.4572	.4001	.1905	.3018	.4191	.2452
19	.7167	.7811	.6287	.6478	.4904	.7621	.7733
20	.6224	.6668	.6478	.6668	.6979	.6668	.7356
21	.4904	.5716	.5335	.5716	.6036	.5525	.6036
22	.4763	.4572	.4763	.5144	.2801	.5335	.5281
23	.4382	.4191	.4191	.4763	.2452	.4954	.4715
24	.2096	.2353	.2096	.2286	.4191	.2427	.4572
Max	.7167	.7811	.6478	.6668	1.105	.8488	1.1431
Min	.2096	.1991	.1715	.1905	.1486	.2012	.2006
Avg	.4185	.4032	.3841	.3723	.4772	.4313	.5294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 202 / 11 KV RANJANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0953	.1905	.1905	.0572	.0343	.0572
2	.1715	.1334	.2477	.2096	.0572	.0678	.0762
3	.2096	.2075	.2858	.2286	.0953	.0995	.1143
4	.362	.4715	.362	.3429	.1063	.116	.1524
5	.4954	.5281	.4763	.5716	.1357	.144	.2286
6	.6287	.6224	.6287	.6097	.1907	.1677	.2572
7	.724	.679	.8192	.743	.2486	.1875	.2915
8	.5335	.6413	.7049	.5525	.2229	.1802	.2858
9	.4954	.5093	.4191	.4191	.1772	.1406	.1334
10	.3048	.3048	.2667	.2477	.3048	.2858	.3429
11	.116	.1227	.1334	.0848	.1886	.1905	.2075
12	.0972	.1017	.1334	.1063	.0754	.1334	.132
13	.0781	.1134	.1143	.0857	.0754	.1143	.1132
14	.08	.1174	.1334	.0983	.1132	.1715	.0754
15	.0983	.12	.0953	.0972	.1132	.1334	.0943
16	.0995	.0995	.1143	.1174	.1509	.1524	.1698
17	.0819	.104	.0953	.0693	.2452	.1143	
18	.1357	.1075	.0953	.0362	.3772	.2096	.2263
19	.5847	.5716	.4382	.4001	.4904	.4191	.4904
20	.4527	.4954	.4001	.5144	.4715	.4001	.4904
21	.3018	.4191	.2858	.4001	.3395	.362	.3239
22	.2667	.2667	.2477	.2858	.1905	.2858	.2286
23	.2096	.2286	.2286	.2858	.1886	.2096	.1715
24	.1905	.1143	.1905	.1905	.0381	.0373	.0572
Max	.724	.679	.8192	.743	.4904	.4191	.4904
Min	.0781	.0953	.0953	.0362	.0381	.0343	.0572
Avg	.2870	.2989	.2961	.2870	.1939	.1815	.2052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 203 / 11 KV GEOVRAI PAIGA SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2829	.3429	.3429	.1524	.1595	.1715
2	.3429	.3206	.381	.3429	.1905	.1865	.1715
3	.381	.415	.4572	.381	.2667	.2294	.1905
4	.5716	.5281	.5335	.4572	.2835	.285	.2743
5	.6859	.5847	.6478	.6859	.3391	.3125	.4115
6	.8002	.7167	.724	.724	.4508	.3658	.5487
7	.8383	.9431	.8002	.7621	.5636	.5281	.6516
8	.6859	.7545	.8383	.8764	.5487	.4458	.6516
9	.5335	.4527	.5335	.6097	.3189	.3353	.4954
10	.4191	.4572	.3429	.3048	.381		.381
11	.3749	.3856	.2667	.3391	.3018	.2286	.2263
12	.3353	.3391	.3429	.3898	.2263	.1905	.1509
13	.2972	.3887	.3429	.3772	.2263	.1143	.1886
14	.2641	.3353	.3429	.2949	.2263	.1524	.1886
15	.3353	.3429	.3048	.2915	.1886	.1524	.1886
16	.3437	.3315	.2286	.3018	.1509	.1524	.1886
17	.3612	.3121	.3048	.2427	.2641	.1905	.1886
18	.2439	.2865	.2286	.181		.2667	.3395
19	.7167	.8383	.6097	.6859	.6413	.5335	.679
20	.5658	.6478	.5335	.5716	.5281	.5335	.5281
21	.415	.4572	.4191	.4572	.3772	.4191	.4191
22	.4001	.381	.381	.4191	.381	.4001	.4001
23	.381	.3429	.381	.381	.3772	.381	.381
24	.3429	.3048	.3429	.3429	.1524	.1663	.1715
Max	.8383	.9431	.8383	.8764	.6413	.5335	.679
Min	.2439	.2829	.2286	.181	.1509	.1143	.1509
Avg	.4574	.4646	.4429	.4484	.3277	.2926	.3411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 201 / 11KV GEVRAE GUNGI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.1677	.3353	.1677	.2263	.1886	.0943
2	.3353	.1677	.3353	.3353	.2263	.3772	.1886
3	.3353	.2515	.3353	.4191	.2829	.3772	.2829
4	.4191	.3353	.3353	.503	.2829	.4715	.3772
5	.4191	.4191	.3353	.503	.2829	.4715	.4715
6	.503	.503	.3353	.503	.5658	.5658	.5658
7	.503	.5868	.4191	.503	.6602	.6602	.6602
8	.503	.503	.4191	.4191	.4715	.4715	.5658
9	.3772	.2515	.3353	.2515	.3772	.3772	.3772
10	.2829	.1886	.1886	.1886	.2263	.1886	.2829
11	.1886	.1886	.1886	.1886	.1677	.1677	.1677
12	.1886	.0943	.0943	.1886	.1677	.1677	.1677
13	.0943	.0943	.0943	.0943	.2515	.1677	.1677
14	.0943	.0943	.0943	.0943	.1677	.1677	.1677
15	.1886	.0943	.0943	.0943	.1677	.1696	.1677
16	.2829	.0943	.1886	.0943	.1677	.1677	.1677
17	.3772	.0943	.1886	.132	.1677	.1677	.1677
18	.4715	.1886	.1886	.1886	.1677	.1677	.1677
19	.4715	.4715	.1886	.3772	.4715	.2829	.4715
20	.3772	.3772	.1886	.2829	.3772	.3772	.3772
21	.1886	.2829	.1886	.2263	.1886	.2829	.1886
22	.1886	.1886	.1886	.2829	.1886	.1886	.1886
23	.0943	.1886	.0943	.2263	.1886	.1886	.1886
24	.0838		.1677		.1886	.0943	
Max	.503	.5868	.4191	.503	.6602	.6602	.6602
Min	.0838	.0943	.0943	.0943	.1677	.0943	.0943
Avg	.3043	.2533	.2301	.2723	.2763	.2878	.2879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 202 / kolte takli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.1677	.503	.2515	.3772	.4715	.3772
2	.4191	.2515	.503	.3353	.3772	.5658	.4715
3	.503	.3353	.5868	.4191	.2829	.5658	.5658
4	.4191	.4191	.503	.4191	.3772	.5658	.6602
5	.4191	.503	.503	.503	.5658	.6602	.7545
6	.503	.5868	.5868	.5868	.7545	.7545	.8488
7	.503	.503	.5868	.503	.8488	.8488	.7545
8	.4191	.4191	.503	.3353	.3772	.7545	.7545
9	.4715	.3353	.503	.2515	.2829	.5658	.5658
10	.3772	.4715	.4715	.2829	.1886	.3772	.4715
11	.3772	.3772	.3772	.3772	.0838	.2515	.1677
12	.2829	.2829	.2829	.3772	.0838	.2515	.2515
13	.3772	.2829	.2829	.2829	.2515	.2515	.2515
14	.3772	.2829	.2829	.2829	.2515	.2515	.2515
15	.3772	.2829	.2829	.3772	.2515	.2515	.2515
16	.4715	.2829	.2829	.3772	.2515	.2515	.2515
17	.5658	.3772	.2829	.3772	.3353	.2515	.2515
18	.6602	.4715	.3772	.5658	.2515	.2543	.2515
19	.6602	.7545	.5658	.8488	.8488	.4715	.6602
20	.5658	.7545	.7545	.7545	.7545	.7545	.7545
21	.5658	.5658	.6602	.6602	.7545	.6602	.5658
22	.4715	.5658	.5658	.6602	.5658	.5658	.5658
23	.3772	.4715	.4715	.5658	.5658	.5658	.5658
24	.1677		.2515		.4715	.4715	
Max	.6602	.7545	.7545	.8488	.8488	.8488	.8488
Min	.1677	.1677	.2515	.2515	.0838	.2515	.1677
Avg	.4479	.4237	.4571	.4519	.4231	.4848	.4898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 201 / FARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.8413	.9145			.7545
2	.9145		.8048	.8383			.7922
3	.9526		.8413	.7621			.8299
4	.9907		.9145	.4191		.8676	.8676
5	1.0288		1.0242	.8764			.9054
6	1.0669	.9945	1.134	1.0669			.9431
7	1.2955		1.2071	1.2574		1.2449	1.3203
8		1.0288	1.1317	1.0288	1.1317	1.0974	1.1317
9		.823	.6859	.823	.9259	.9945	1.0288
10		.7888	.7202	.8573			
11		.7888	.7545	.8573	.5144	.4801	.7202
12		.823	.7545	.8573	.4801	.4458	.823
13		.823	.7888	.8573	.4458	.4458	.9945
14		.8573	.7888	.823	.3772	.4458	.8573
15		.8573	.7545	.823	.4115	.3429	.7888
16		.5316		.8764			
17		.9511		.9145			
18		1.2323		.9907			1.2071
19		1.307		1.105			
20		1.2323		1.2574			1.3169
21		1.1576		.7621			1.2437
22		1.0829					1.1706
23		.9709					1.1203
24	1.0288	.7316	.8779	.9526		.8299	.8676
Max	1.2955	1.307	1.2071	1.2574	1.1317	1.2449	1.3203
Min	.7621	.5316	.6859	.4191	.3772	.3429	.7202
Avg	1.0050	.9434	.8765	.9055	.6124	.7195	.9842



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 202 / 11KV JANGLA GAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.6584				.8299
2	.6097		.6348				.9054
3	.6859		.6722				.9431
4	.724		.695			.8299	1.0185
5	.724		.8048				1.0562
6	.7621		.9511				1.094
7	1.0288		1.0608			.8676	1.0185
8	.5716	.8916	.6859	.8916	.7888	.6516	.6173
9		.7545	.7545	.7202	.3086	.3772	.5144
10		.8573	.823	.7888	.3429	.3772	
11		.9259	.8573	.8916	.3429	.3772	.3772
12		.9945	.9259	.9602	.3772	.3772	.4801
13		.9945	.8573	.9945		.3429	.3429
14		.9945	.823	.9945	.3772	.3429	.3429
15		.9602	.7888	.9602	.3772	.3429	.3086
16				1.0669			.3658
17		.7468		.9526			
18		.8048		.5716			.6219
19		.7682		.724			.7316
20		.7316		.7621			.8048
21		.7316		.4954			.7842
22		.7095					.7316
23		.7095					.695
24	.5716		.6584			.7545	.8299
Max	1.0288	.9945	1.0608	1.0669	.7888	.8676	1.094
Min	.5716	.7095	.6348	.4954	.3086	.3429	.3086
Avg	.6944	.8383	.7907	.8410	.4164	.5128	.7006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 206 / MJP EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0351				.0381
2	.0381		.0351				.0381
3	.0381		.0358				.0381
4	.0381		.0351			.0381	.0381
5	.0381		.0351				.0381
6	.0381		.0351				.0381
7	.0381		.0358				.0381
8		.0038	.0038	.0038	.0038	.0038	.0038
9		.0038	.0038	.0038	.0038	.0038	.0038
10		.0038	.0038	.0038	.0038	.0038	
11		.0038	.0038	.0038	.0038	.0038	.0038
12		.0038	.0038	.0038	.0038	.0038	.0038
13		.0038	.0038	.0038	.0038	.0038	.0038
14		.0038	.0038	.0038	.0038	.0038	.0038
15		.0038	.0038	.0038	.0038	.0038	.0038
16				.0381			
17		.0343		.0381			
18		.0351		.0381			.0351
19		.0351		.0381			.0358
20		.0351					
21		.0358					.0358
22		.0358					.0351
23		.0358					.0351
24	.0381		.0351			.0381	.0381
Max	.0381	.0358	.0358	.0381	.0038	.0381	.0381
Min	.0381	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0381	.0185	.0195	.0152	.0038	.0107	.0254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 207 / AJANTHA CAVES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0351				.0381
2	.0381		.0358				.0381
3	.0381		.0351				.0381
4	.0381		.0351			.0381	.0381
5	.0381		.0351				.0381
6	.0381		.0351				.0381
7	.0381		.0351			.0381	.0381
8		.0038	.0038	.0038	.0038	.0038	.0038
9		.0038	.0038	.0038	.0038	.0038	.0038
10		.0076	.0076	.0076	.0038	.0076	
11		.0076	.0076	.0076	.0038	.0076	.0076
12		.0076	.0076	.0076	.0038	.0686	.0076
13		.0076	.0076	.0076	.0038	.0076	.0076
14		.0076	.0076	.0076	.0038	.0076	.0076
15		.0076	.0076	.0076	.0038	.0076	.0076
16				.0762			
17		.0686		.0762			
18		.0351		.0381			.0351
19		.0351					.0351
20		.0351					.0351
21		.0351					.0351
22		.0351					.0358
23		.0351					.0351
24	.0381		.0351			.0381	.0381
Max	.0381	.0686	.0358	.0762	.0038	.0686	.0381
Min	.0381	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0381	.0222	.0209	.0222	.0038	.0208	.0267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 209 / Tondapur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.5466
2					1.5844
3					1.6221
4				1.5844	1.6975
5					1.8107
6				1.6975	1.8484
9	1.5432	1.4403	1.4403		
10	1.7147	1.5775	1.6461		
11	1.8861	1.7147	1.749		
12	1.9547	1.749	1.8176		
13	1.8861	1.7147	1.7833		
14	1.8519	1.6461	1.749		
15	1.7833	1.6118	1.749		
16			1.9052		
21					.9175
22					1.1469
23					1.2407
24				1.358	1.5466
Max	1.9547	1.749	1.9052	1.6975	1.8484
Min	1.5432	1.4403	1.4403	1.358	.9175
Avg	1.8029	1.6363	1.7299	1.5466	1.4961

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 201 / 11KV BANOTI-AG- FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.9052	1.9052	1.9814	1.8671	1.7528	1.829
2	1.3336	1.8671	1.8671	1.9433	1.8671	1.7909	1.7528
3	1.3717	1.7147	1.829	1.9052	1.9814	1.7909	1.7147
4	1.448	1.6766	1.829	1.8671	1.9433	1.8099	1.6766
5	1.4861	1.6385	1.9052	1.829	1.9433	1.829	1.6766
6	1.5623	1.7528	2.0957		1.9243	1.829	1.7909
21	1.6575	1.6766	1.7909	1.6956	1.6385	1.829	.1524
22	1.829	2.0195	2.0576	1.7528	1.8671	1.9814	
23	1.9814	2.0957	2.0957	1.829	1.7909	1.9814	
24	1.2574	1.9433	2.0005	2.0195	1.829	1.7528	1.9052
Max	1.9814	2.0957	2.0957	2.0195	1.9814	1.9814	1.9052
Min	1.2574	1.6385	1.7909	1.6956	1.6385	1.7528	.1524
Avg	1.5223	1.829	1.9376	1.8692	1.8652	1.8347	1.5623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 202 / 11 KV NANDGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524					
9	1.0288	.9526	1.0669	.8573		1.0669	.5335
10	1.4098	1.4098	***	.9526	1.0288	1.2955	
11	1.6956	1.7147	1.6385	.9907	1.4098	1.5623	1.0288
12	1.5623	1.7909	1.4861	1.3527	1.448	1.6385	
13	1.5623	1.7528	1.5242	1.3717	1.105	1.3717	1.0669
14	1.5623	1.7147	1.3336	1.3717	1.2955	1.3336	1.1431
15	1.5051	1.4098	1.3336	1.3336	1.4098	1.3717	1.2193
16	1.4098	1.3717	1.2955	1.1812	1.2955	1.2955	1.2955
21							.4572
22							.5716
Max	1.6956	1.7909	15.3178	1.3717	1.448	1.6385	1.2955
Min	1.0288	.1524	1.0669	.8573	1.0288	1.0669	.4572
Avg	1.467	1.3633	3.1245	1.1764	1.2846	1.3670	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 203 / 11 K V WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.4191	.381	.4572	.381	.3048
2	.1905		.381	.381	.4763	.4001	.2858
3	.1905		.381	.4572	.4763	.4191	.2858
4	.1905		.3429	.4191	.4763	.4572	.3048
5	.2286		.381	.4572	.4954	.4954	.3429
6	.2667		.5335		.5716	.5335	.5335
11		.5335					
21		.3048	.3429	.3239	.381	.2667	
22		.4954	.4572	.381	.4191	.3429	
23		.5335	.4954	.4191	.4572	.3429	
24	.1524		.4954	.4572	.4191	.381	.3048
Max	.2667	.5335	.5335	.4572	.5716	.5335	.5335
Min	.1524	.3048	.3429	.3239	.381	.2667	.2858
Avg	.2014	.4668	.4229	.4085	.4630	.4020	.3375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 204 / 11 KV BANOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2286	.2286	.2286	.2286	.2286
2	.2096	.2286	.2286	.2286	.2286	.2286	.2286
3	.2667	.2286	.2667	.2667	.2667	.2667	.2667
4	.4191	.381	.4763	.4763	.3429	.3429	.4572
5	.6478	.6668	.7049	.7049	.8573	.6097	.6859
6	.8192	.9145	.9526		.8573	.9145	.8573
7	.8383	.9717	1.0288	.8192	.9717	.9717	.9907
8	.7621	.6478	.8383	.743	.6287	.8383	.7049
9	.5716	.4382	.5906			.4954	.2858
10	.4191	.4763	.3429	.4572	.3429	.381	.3048
11	.3239	.381	.2477	.381	.2286	.2477	
12	.2096	.2858	.2286	.2667	.2286	.1905	.1715
13	.2286	.2286	.2477	.2667	.1334	.1905	.2286
14	.2286	.2477	.2286	.2667	.1905	.2096	.2286
15		.2667	.2477	.2667	.2286	.1905	.2477
16	.3239	.2858	.2477	.2667	.2667	.2096	.2667
17	.4191	.4001	.3239	.2286	.3239	.2477	.362
18	.6478	.4572	.4191	.5716	.5525	.4382	.4954
19	.6859	.8383	.743	.7811	.7621	.7049	.8002
20	.724	.6287	.5335	.724	.5335	.4954	.7621
21	.4001	.4191	.4191	.4954	.381	.381	.362
22	.3239	.3429	.3239	.381	.3239	.3239	.362
23	.2477	.2858	.2667	.2667	.2667	.2667	.2477
24	.2096	.2286	.2477	.2286	.2858	.2477	.2286
Max	.8383	.9717	1.0288	.8192	.9717	.9717	.9907
Min	.2096	.2286	.2286	.2286	.1334	.1905	.1715
Avg	.4407	.4366	.4326	.4235	.4100	.4009	.4249



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 205 / Hanumantkheda gaothan  
feeder Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1905	.1905	.1905	.1905	.1905
2	.1524	.1334	.1905	.1905	.1905	.1905	.1905
3	.2096	.1905	.2096	.2096	.1905	.1905	.2096
4	.3048	.2477	.2667	.2667	.2286	.2286	.2667
5	.362	.2858	.3429	.3429	.3048	.3048	.381
6	.4191	.3429	.3239	.381	.381	.381	.4001
7	.4763	.4191	.4572	.3429	.4572	.4763	.4382
8	.3429	.3429	.3429	.3429	.2858	.362	.362
9	.2477	.2477	.3239	.2667	.2096	.2286	.2477
10	.1524	.2286	.1905	.2286	.2096	.1905	.1334
11	.0762	.1334	.1524	.1715	.1334	.1524	.1143
12	.0762	.1524	.1143	.1334	.1143	.1334	
13	.0762	.1334	.1143	.1524	.1334	.0762	
14	.0762	.1334	.1334	.1524	.1524	.1143	.1524
15	.0953	.1905	.1334	.1524	.1334		.1524
16	.1143	.1524	.1334	.1715	.1524	.0762	.1715
17	.1334	.1905		.2096	.1715	.2096	.2477
18	.1715	.2286	.2858	.3429	.3429	.2286	.2667
19	.2286	.3429	.381	.4001	.381	.4191	.4191
20	.1905	.3429	.3429	.3048	.3048	.3429	.3429
21	.1524	.2858	.2667	.3048	.2667	.2667	.3048
22	.1524	.2477	.2286	.2667	.2286	.2477	.2667
23	.1334	.2286	.2096	.2286	.2096	.2286	.0572
24	.1905	.1334	.1905	.1905	.1905	.1905	.1905
Max	.4763	.4191	.4572	.4001	.4572	.4763	.4382
Min	.0762	.1334	.1143	.1334	.1143	.0762	.0572
Avg	.1945	.2278	.2402	.2477	.2318	.2361	.2503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 206 / Wakdi Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0953	.0953	.0953	.0953	.0762	.0762	.0762
5	.1524	.1334	.1524	.1524	.1524	.1524	.1334
6	.2667	.2477	.2667	.1905	.2286	.1905	.2477
7	.3048	.3239	.3048	.2477	.2858	.2858	.3429
8	.1715	.1715	.1715	.1524	.1524	.1905	.1524
9	.1524	.1715		.1524	.1524	.1334	.1334
10	.1143	.0572	.0762	.0953	.1143	.0762	.0572
11	.0381	.0381	.0381	.0381	.0572	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0572	.0381	.0191	.0381	.0381	.0381	.0381
14	.0572	.0381	.0381	.0381	.0572	.0381	.0572
15	.0381	.0572	.0381	.0381	.0762	.0572	.0572
16	.0381	.0572	.0381	.0572	.0762	.0572	.0572
17	.0762	.0762	.0572	.0572	.0762	.0572	.0572
18	.1334	.1143	.0953	.1143	.0953	.0953	.1143
19	.1715	.2286	.2096	.1905	.2286	.2286	.2286
20	.1334	.1524	.1715	.1715	.1905	.1715	.1905
21	.1143	.1143	.1143	.1143	.0953	.0953	.1143
22	.0953	.0953	.0762	.0953	.0762	.0762	.0953
23	.0572	.0572	.0381	.0572	.0762	.0572	.0572
24	.0381	.0381	.0381	.0191	.0381	.0572	.0572
Max	.3048	.3239	.3048	.2477	.2858	.2858	.3429
Min	.0191	.0381	.0191	.0191	.0381	.0381	.0381
Avg	.1024	.1032	.0961	.0953	.1048	.0977	.1032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 207 / 11 KV GONDEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.6385	1.5242	1.2955	1.2574	1.5623	1.3336
2	1.0288	1.6385	1.4861	1.2384	1.2955	1.5623	1.2955
3	1.0669	1.6385	1.4861	1.1431	1.3336	1.6004	1.2955
4	1.105	1.6385	1.448	1.2193	1.3717	1.6385	1.2955
5	1.1431	1.6575	1.4861	1.2955	1.4098	1.6766	1.3336
6	1.2193	1.4861	1.7147		1.5242	1.7147	1.4098
21	1.2003	1.105	1.105	1.0669	1.1431	1.0669	
22	1.3717	1.4098	1.3336	1.105	1.4861	1.4861	
23	1.6194	1.6004	1.3717	1.1431	1.5623	1.5623	
24	.9526	1.6385	1.5623	1.3336	1.2193	1.5242	1.4289
Max	1.6194	1.6575	1.7147	1.3336	1.5623	1.7147	1.4289
Min	.9526	1.105	1.105	1.0669	1.1431	1.0669	1.2955
Avg	1.1698	1.5451	1.4518	1.2045	1.3603	1.5394	1.3418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 208 / 11 K V HANUMANT KHEDA SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.0098	1.105	1.105	1.1431	1.0288	1.1812	1.0669
10	1.3717	1.2193	1.3336	1.1431	1.0669	1.2955	1.2955
11	1.6194	1.2955	1.6385	1.1431	1.3336	1.3336	1.4098
12	1.7718	1.6766	.9907	1.5051	1.448	1.3717	
13	1.5623	1.7147	1.5242	1.5242	1.3717	1.4098	
14	1.4861	1.5242	1.4861	1.4861	1.3717	1.3717	1.7528
15	1.6575	1.3336	1.4289	1.4098	1.0669		1.7147
16	1.5242	1.4861	1.3717	1.0669	1.0669	1.2955	1.5242
22							.7049
23							.724
Max	1.7718	1.7147	1.6385	1.5242	1.448	1.4098	1.7528
Min	1.0098	1.105	.9907	1.0669	1.0288	1.1812	.7049
Avg	1.5004	1.4194	1.3598	1.3027	1.2193	1.3227	1.2741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 209 / 11 KV GONDEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2667	.2667	.2667	.2858	.2858	.2667
2	.2096	.2667	.2667	.2667	.2858	.2858	.2667
3	.3048	.2667	.3048	.3048	.2858	.3429	.2858
4	.381	.3429	.4191	.4191	.3429	.4954	.3429
5	.5335	.5144	.5716	.5716	.4954	.7049	.5335
6	.6859	.6859	.8002		.7049	.6859	.724
7	.7621	.8383	.9145	.7621	.7621	.8383	.9145
8	.724	.6097	.6097	.6478	.6859	.6097	.4954
9	.4954	.5335	.4954	.4572	.4572	.4572	.3048
10	.4572	.4572	.4191	.381	.4191	.4191	.3048
11	.381	.381	.381	.362	.3429	.3429	.3048
12	.3048	.3429	.3048	.3048	.3429	.381	.2858
13	.3429	.3429	.3048	.3048	.3048	.3429	.2667
14	.362	.3429	.2667	.3048	.3048	.381	.381
15	.381	.3429	.2667	.3048	.381	.3429	.381
16	.4001	.381	.3048	.3429	.3429	.3429	.381
17	.4572	.381	.3048	.3429	.381	.3048	.381
18	.4954	.4572	.381	.4572	.4191	.4191	.4572
19	.5716		.5335	.5335	.5716	.5716	.6478
20	.6097	.6287	.5716	.4954	.4954	.5335	.5335
21	.4572	.4572	.4572	.4191	.4191	.4191	.4572
22		.381	.3048	.3429	.381	.362	.4191
23	.3429	.3429	.2667	.3048	.381	.3048	.381
24	.2286	.2667	.2858	.2286	.2858	.3429	.2667
Max	.7621	.8383	.9145	.7621	.7621	.8383	.9145
Min	.1905	.2667	.2667	.2286	.2858	.2858	.2667
Avg	.4382	.4274	.4168	.3968	.4199	.4382	.4160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 210 / 11 KV Nandgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.0953	.1524	.1334	.1334	.0953
2	.1334	.1143	.0953	.1334	.1334	.1334	.0953
3	.1524	.1143	.1143	.1715	.1334	.1334	.1143
4	.1905	.1334	.1715	.2096	.1334		.1715
5	.1905	.1905	.2096	.2096	.1715	.2667	.3429
6	.381	.2667	.4191	.3048	.2667	.2667	.381
7	.4191	.3429	.4954	.381	.3048	.4572	.4191
8	.3429	.3048	.381	.3429	.2667	.381	.3048
9	.2667	.2477		.2286		.2286	
10	.2286	.1905	.2286	.1905	.1905	.1905	.1905
11	.1334	.1334	.1905	.1524	.1715	.1524	.1524
12	.1143	.0953	.1524	.1334	.1715	.1524	.1524
13	.1143	.0953	.1524	.1334	.1715	.1524	.1524
14	.1143	.0953	.1524	.1143	.1524	.1524	.1334
15	.1143	.0953	.1524	.1143	.1524	.1524	.1524
16	.1334	.1334	.1715	.1143	.1715	.1524	.1905
17	.1524	.1715	.1905	.1143	.2286	.2096	.2286
18	.1905	.2286	.3048	.1524	.3429	.2286	.2667
19	.2667	.4572	.3429	.3048	.4191	.4382	.4191
20	.2477	.4191	.4001	.2858	.3429	.3429	.3048
21	.1715	.2477	.3048	.2286	.2286	.2096	
22	.1524	.1334	.2667	.1905	.2286	.1905	.2667
23	.1334	.0953	.2286	.1524	.1905	.1524	.2286
24	.1524	.1143	.0953	.1905	.1334	.1524	.1143
Max	.4191	.4572	.4954	.381	.4191	.4572	.4191
Min	.1143	.0953	.0953	.1143	.1334	.1334	.0953
Avg	.1929	.1889	.2311	.1961	.2104	.2187	.2217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 201 / 11 K V SOYEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6219	.6584	.695
2				.6219	.6219	.695
3				.7095	.695	.7316
4	.8413				.7316	
5						.9511
6	.9393					1.0974
8	.7522			.7682		
9				.5121	.4961	.4557
10			.439	.5959	.567	.5121
11			.4908	.695	.6219	
12			.6219	.7316	.6584	
13			.6219	.695	.6219	
14			.5853	.6584	.5853	
15			.5853	.5853	.5487	
16			.5258	.5487	.5121	
17			.6584	.6348		
19			.9877			
22					.7316	
23			.6584	.695		
24	.7316	.7316		.6219	.6584	.695
Max	.9393	.7316	.9877	.7682	.7316	1.0974
Min	.7316	.7316	.439	.5121	.4961	.4557
Avg	.8161	.7316	.6175	.6463	.6220	.7291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 202 / 11 K V GALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4755	.5487
2				.439	.439	.5853
3				.4755	.5121	.6219
4				.5121	.5487	
6	.8916	.8764				
8	.6878					.5853
9				.5853	.5487	
10			.6219	.695	.5121	.439
11			.7316	.6584		
12		.5731		.695	.695	
13			.695	.695	.6584	
14			.695	.6584	.6219	
15			.6584		.5853	
16		.6661	.6219	.5853	.5853	
17			.439	.439		
22				.5853		
23			.5121	.5487	.6219	
24	.695	.7468		.5121	.5121	.5487
Max	.8916	.8764	.7316	.695	.695	.6219
Min	.6878	.5731	.439	.439	.439	.439
Avg	.7581	.7156	.6219	.5774	.5628	.5548



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 203 / JARANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2926	.2561	.2926
2				.2561	.2561	.3292
3				.2561	.2926	
4				.3658		
6	.4527	.5281				
8	.3772				.439	
9				.5121	.5487	.6219
10			.6219	.6219	.6219	.5853
11			.7682	.7316	.6584	
12		.6661	.7316	.6584	.695	
13			.695	.695	.695	
14		.7888	.695	.695		
15			.6219			.6219
16		.823	.6584	.5853		.5853
20						.439
21				.439		.4024
23			.2926	.2561	.7316	.3292
24	.2641	.2641		.2926	.2561	.2926
Max	.4527	.823	.7682	.7316	.7316	.6219
Min	.2641	.2641	.2926	.2561	.2561	.2926
Avg	.3647	.6140	.6356	.4755	.4955	.4499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 205 / 11KV LIHA FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
6	.1905	.2218
8	.1524	
12		.5121
16		.5121
24	.1524	.1886
Max	.1905	.5121
Min	.1524	.1886
Avg	.1651	.3587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 202 / 11 kv DEVHARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4854
Max	.4854
Min	.4854
Avg	.4854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 203 / 11 kv MOLKHEDA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		.0562			
24	.1687		.5906	.6859	.5716
Max	.1687	.0562	.5906	.6859	.5716
Min	.1687	.0562	.5906	.6859	.5716
Avg	.1687	.0562	.5906	.6859	.5716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 204 / 11 KV SAWALADBARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0762	.0953	.0953	.0762	.0762	.0762	.0762
Max	.0762	.0953	.0953	.0762	.0762	.0762	.0762
Min	.0762	.0953	.0953	.0762	.0762	.0762	.0762
Avg	.0762	.0953	.0953	.0762	.0762	.0762	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 205 / 11KV Molkheda Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.8944
Max	.8944
Min	.8944
Avg	.8944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 201 / 11 KV KINHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.0669	1.2003	1.6766
2					1.1431	1.1736	1.6766
3					1.2193	1.1736	1.6194
4					1.2384	1.1736	1.5623
5					1.2574	1.1736	1.5242
6					1.1812	1.1736	1.448
9	1.4861	1.5813	1.4419	.9145			
10		1.4413	1.5402	1.0669			
11		1.6221	1.829	1.2193			
12		1.7695	1.7909	1.6004			
13	2.1148	1.7204	1.7147	1.6575			
14	2.0386	1.704	1.6385	1.5813			
15	1.9052	1.5424	1.6004	1.5813			
16	1.7147	1.4746	1.6004	1.5242			
21				.8002	1.2517	1.5623	1.3717
22				.9145	1.3916	1.7528	1.5432
23				.9717	1.358	1.7337	1.6004
24					1.1431	1.3413	1.7147
Max	2.1148	1.7695	1.829	1.6575	1.3916	1.7528	1.7147
Min	1.4861	1.4413	1.4419	.8002	1.0669	1.1736	1.3717
Avg	1.8519	1.6070	1.6445	1.2574	1.2251	1.3458	1.5737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 202 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2667	.2477	.2667	.2477	.2477
2	.2477	.2667	.2667	.2477	.2667	.2477	.2477
3	.2477	.3048	.2858	.3048	.3048	.2858	.2477
4	.2858	.381	.3429	.4001	.3429	.2858	.3429
5	.4763	.4954	.4024	.4763	.381	.3292	.4572
6	.5906	.6478	.4973	.6478	.5716	.5658	.5906
7	.7049	.6097	.6371	.5906	.6478	.5533	.5144
8	.4763	.5716	.5197	.381	.463	.5487	
9	.4954	.5525	.3475	.3239	.2743	.3841	.4001
10	.3239	.4115	.3658	.2667	.3292	.2667	.3429
11	.1905	.1143	.2667	.2286	.2743	.1715	.2286
12	.2096	.2096	.2096	.2096	.2477	.1905	.2286
13	.2286	.1905	.2096	.1905	.1524	.1905	.2286
14	.2096	.2286	.1905	.1905	.2286	.1905	.1524
15	.1905	.2286	.2096	.2096	.2667	.1905	.2096
16	.2286	.2286	.2286	.1905	.2477	.2286	.2286
17	.3239	.2477	.2667	.2667	.2858	.2477	.2667
18	.4382	.3475	.3429	.3239	.3658	.362	.4191
19	.6478	.5144	.4572	.381	.57	.6097	.6478
20	.4954	.5144	.5335	.5144	.4938	.4572	.5144
21	.381	.3429	.362	.381	.3292	.362	.381
22	.3239	.3109	.2858	.2667	.2477	.3239	.3429
23	.2858	.2561	.2477	.2477	.2477	.2667	.2858
24	.2286	.2477	.2667	.2477	.2667	.2477	.2477
Max	.7049	.6478	.6371	.6478	.6478	.6097	.6478
Min	.1905	.1143	.1905	.1905	.1524	.1715	.1524
Avg	.3525	.3529	.3337	.3223	.3363	.3231	.3380



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 203 / 11 KV WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7621	.6173	.6287	.0572	.0572	.0572
2	.6097	.7621	.6173	.6859	.0572	.0572	.0572
3	.6478	.743	.6173	.6859	.0572	.0572	.0572
4	.6668	.7811	.6173	.724	.0572	.0572	.0572
5	.724	.8192	.6516	.8002	.0953	.0572	.0572
6	.7621	.8764	.6371	.7811	.0953	.0572	.0572
7	.0381	.0572	.0762	.0572	.0953	.0572	.0381
8	.0762	.0572	.0762	.0572	.0762	.0572	.0381
9	.0572	.0572	.0762	.0572	.7545	.6859	.5716
10	.0381	.0572	.0572	.0572	.7202	.8002	.8002
11	.0381	.0572	.0572	.0572	.7712	.6859	.9526
12	.0572	.0572	.0572	.0572	.6859	1.0479	.9526
13	.0572	.0762	.0572	.0572	.9389	.9335	.9145
14	.0953	.0572	.0572	.0572	.8048	.8954	.7049
15	.0953	.0572	.0572	.0572	.6859	.8954	.8192
16	.0762	.0762	.0572	.0572	.7377	.8954	.9335
17	.0953	.0762	.0572	.0572	.0572	.0381	.0381
18	.0572	.0762	.0572	.0572	.0572	.0381	.0381
19	.0762	.0762	.0572	.0572	.0572	.0572	.0381
20	.0762	.0572	.0572	.0572	.0572	.0572	.0381
21	.5144	.4115	.4954	.0572	.0572	.0572	.0381
22	.7811	.6371	.5716	.0572	.0572	.0572	.0381
23	.7621	.6173	.5716	.0572	.0572	.0381	.0381
24	.5906	.7621	.6173	.5906	.0572	.0572	.0572
Max	.7811	.8764	.6516	.8002	.9389	1.0479	.9526
Min	.0381	.0572	.0572	.0572	.0572	.0381	.0381
Avg	.3168	.3362	.2863	.2445	.2978	.3207	.3080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 201 / 11Kv Ghosla new SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.381	.5716		.2667	.3048
2	.362	.4191	.5525		.3048	.3429
3	.4001	.4763	.5906		.3429	.4191
4	.4954	.4572	.6097		.381	.4191
5	.7049	.5144	.6478		.5525	.5716
6	.8002	.5716	.6287		.7621	.6668
7	.8192	.8002	.7621		.6478	.724
8	.5144	.5906	.5335		.5716	.6097
9	.4763	.4382	.362	.4572	.5525	.6097
10	.6097	.3429	.2667	.3429	.743	
11	.8573	.2477	.2477	.2667	1.1241	
12	1.0288		.2096	.1905	1.3717	
13	.9335		.1905	.2096	1.2574	
14	.8192		.2096		1.105	
15	.724		.2477	.2477	.9907	
16	.743		.2096	.2667	.8573	
17	.3429		.2286	.2858	.2286	
18	.5144		.3429	.381	.3048	
19	.6287		.5335	.5716	.3429	
20	.4954		.4572	.4954	.4572	
21	.2667		.4191	.4191	.4001	
22	.3239			.381		
23	.3048					
24	.2858	.3239			.2858	.2858
Max	1.0288	.8002	.7621	.5716	1.3717	.724
Min	.2667	.2477	.1905	.1905	.2286	.2858
Avg	.5739	.4636	.4201	.3473	.6296	.4954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 202 / 11Kv Bahulkheda new SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.2477		.6287	.8002
2	.362	.362	.2286		.6668	.8383
3	.4001	.4001	.2667		.6859	.8192
4	.381	.381	.3048		.724	.8573
5	.4001	.4191	.3429		.6859	.8954
6	.4382	.4191	.362		.6478	.9145
7	.4001	.4382	.4001		.4572	.4763
8	.381		.4001		.3048	.4382
9	.6287		.724	.743	.4382	.381
10			.9335	.8192	.3429	
11			1.0098	.8764	.3048	
12			.9717	.9145	.2667	
13			.9145	.8764	.2286	
14			.8383		.2096	
15	1.1812		.8002	.8573	.2286	
16	1.3717		.7621	.8954	.2667	
17	.4382		.2477	.4954	.3239	
18	.4382		.3048	.4763	.362	
19	.381		.381	.4572	.4001	
20	.3239		.362	.4763	.4572	
21	.3048		.3429	.5335	.6859	
22	.2858			.4572		
23	.2667					
24	.3048	.3048			.6097	.7811
Max	1.3717	.4382	1.0098	.9145	.724	.9145
Min	.2667	.3048	.2286	.4572	.2096	.381
Avg	.4743	.3810	.5307	.6829	.4512	.7202

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 203 / 11Kv Jarandi new SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2858		.6668	.8383
2	.4572	.2477		.7621	.8573
3	.5144	.3048		.6668	.9145
4	.5525	.3429		.6859	.8764
5	.6097	.4572		.7049	.8573
6	.6859	.5335		.724	.8383
7	.5716	.5906		.5716	.5906
8	.4954	.4191		.4572	.4763
9	.381	.8573	.724	.3429	.3239
10	.3239	1.0098	.8383	.3048	
11	.2667	.9907	.9526	.2667	
12	.2286	1.0288	1.0288	.1905	
13	.2858	1.105	.9526	.1715	
14	.2667	1.0288	.8764	.1524	
15	.2667	.9907	.8573	.1905	
16	.2667	.8954	.8383	.2286	
17	.2858	.2096	.2477	.2286	
18	.362	.3048	.3429	.2667	
19	.4954	.3429	.4572	.3048	
20	.4572	.3048	.4382	.3429	
21	.4001	.2858	.6097	.6859	
22	.3429		.5906		
23	.2667				
24	.381			.6859	.8002
Max	.6859	1.105	1.0288	.7621	.9145
Min	.2286	.2096	.2477	.1524	.3239
Avg	.3993	.5970	.6968	.4365	.7373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 201 / 11 KV JAWLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
10		.1829
11		.2241
12		.2378
16	.2858	
24	.7925	
Max	.7925	.2378
Min	.2858	.1829
Avg	.5392	.2149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 202 / 11 KV KHAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7287
Max	.7287
Min	.7287
Avg	.7287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 203 / 11 KV PEDAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4763
Max	.4763
Min	.4763
Avg	.4763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 201 / 11 KV WADALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5908	.5723		.5908	2.1969	2.6215	2.5107
2	.5908	.5538		.5908	2.2523	2.5846	2.5846
3	.7015	.6646		.6461	2.3261	2.6584	2.6215
4	1.0338	.8861		.7569	2.4184	2.7692	2.7692
5	1.2369	1.2		1.0523	2.5477	2.88	2.8061
6	1.3661	1.3292		1.2923	2.5846	3.1384	2.88
7	1.4769	1.44		1.3292	1.3661	1.4031	1.4584
8	1.2554	1.134		1.3661	1.2185	1.2923	1.2923
9	2.3631	2.9907		3.1384	.9969	.9969	.8492
10	2.6215	3.1015	3.308	3.2492	.6277	.6277	.6646
11	2.8246	3.3819	3.323	3.1015	.3323	.3508	.2954
12		3.2895	3.3969	3.1569	.2954	.2954	.2585
13	1.1631	3.345	3.3969	3.2307	.2585	.24	
14	1.0708	3.4189	3.323	3.1015	.2954	.24	
15	3.1938	3.3819	3.36	2.9538	.2954		
16	3.2861	3.3265	3.3969	3.0461	.3323	.3323	
17	.96	.3326			.5169	.3692	
18	1.1077	1.0349			.7015	.5169	.48
19	1.2554	1.2567	1.0708	1.1077	1.1815	1.1077	1.1446
20	1.0338	1.0719	1.0338	1.1815	1.1815	1.1815	1.1446
21	.8492	.8871	.8492	2.1046	2.6584	2.1415	2.6584
22	.7015	.6653	.6646	2.1415	2.9169	2.5107	2.8431
23	.5908	.5729	.5908	2.16	2.6954	2.4923	2.88
24	.5908	.5908	.4805	.5908	2.1969	2.6215	2.4738
Max	3.2861	3.4189	3.3969	3.2492	2.9169	3.1384	2.88
Min	.5908	.3326	.4805	.5908	.2585	.24	.2585
Avg	1.3854	1.6845	2.1688	1.9040	1.4331	1.5379	1.8218



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 202 / 11KV NIMDONGRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3877	.3692	.3421	.4062	1.1446	1.5692	1.8092
2	.3692	.3692	.3781	.4062	1.2185	1.5692	1.8092
3	.4985	.48	.3781	.4985	1.2923	1.5877	1.8461
4	.7015	.72	.6301	.72	1.4031	1.6061	1.9384
5	.7938	.7754	.7382	.8677	1.5138	1.6246	2.0308
6	.9046	.8492	.8642	.9231	1.6615	1.9938	2.1969
7	.9231	.9231	.9002	.96	.8677	.8861	.8861
8	.4985	.6277	.6301	.5169	.4615	.4431	.48
9	1.2923	1.8092	1.8904	1.8092	.5169	.48	.5169
10	1.5508	2.1784	2.2325	2.0308	.3692	.3692	.3692
11	1.8461	2.3225	1.9938	2.1415	.2585	.24	.2031
12	2.1784	2.2505	1.9938	1.9569	.1846	.2031	.2031
13	2.1415	1.9985	2.0123	1.9384	.2031	.1846	.2215
14	2.0308	1.7644	1.8092	1.8092	.2031	.1846	.2215
15	1.9754	1.7284	1.8092	1.8277	.1846	.24	.24
16	1.9569	1.7104	1.8831	1.8646	.2031	.2215	.2031
17	.4615	.198	.1846	.2215	.2215	.2215	.24
18	.48	.4321	.2769	.2769	.2769	.24	.3323
19	.6646	.6842	.5169	.5538	.48	.4985	.5169
20	.6092	.4861	.4615	.4985	.4431	.48	
21	.4985	.4501	.4246	1.1446	1.4584	1.5692	1.6615
22	.48	.4321	.4246	1.1815	1.8461	1.9384	1.8831
23	.4062	.3961	.4246	1.1077	1.8646	1.8646	1.8646
24	.3877	.3877	.3601	.4062	1.1077	1.5692	1.8277
Max	2.1784	2.3225	2.2325	2.1415	1.8646	1.9938	2.1969
Min	.3692	.198	.1846	.2215	.1846	.1846	.2031
Avg	1.0015	1.0143	.9816	1.0862	.8077	.9077	1.0218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 203 / 11 KV NANDGIRWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8522	1.0437	.8775	.909	.4364	.4924	.4554
2	.8901	1.0437	.8954	.9469	.4364	.4734	.4364
3	.9279	1.1006	.9313	1.0226	.4934	.5681	.4934
4	1.0037	1.1385	.985	1.0794	.6072	.7007	.6642
5	1.0794	1.2334	1.0208	1.1363	.797	.7575	.778
6	1.1363	1.3093	1.1462	1.2309	1.0057	1.0794	.9867
7	.7954	.9867	.9313	.9279	1.0626	1.0037	1.0626
8	.6818	.816	.7522	.8143	.816	.7954	.8539
9	.6249	.7401	.5552	.6249	1.3473	1.1552	1.0626
10	.4744	.5108	.3761	.4734	1.4232	1.0794	1.1575
11	.3795	.3761	.2651	.3416	1.4393	1.1385	1.1363
12	.3416	.2686	.2651	.3226	1.3635	1.0247	1.1552
13	.3795	.2686	.2841	.3036	1.2878	1.0057	1.212
14	.3985	.2686	.303	.3226	1.1931	1.0057	1.0984
15	.4175	.2507	.3219	.3226	1.0984	.9488	1.0984
16	.4934	.2149	.3219	.3605	1.1363	.9867	1.0794
17	.5313	.3224	.303	.3416	.303	.2657	.3409
18	.5313	.3761	.4545	.4554	.4545	.3605	
19	.7211	.591	.6818	.7401	.6818	.6452	.7386
20	.6831	.6805	.7007	.7021	.7196	.6642	.7007
21	.9298	.8954	.7954	.5693	.5113	.5503	.6249
22	1.1575	1.0566	1.1363	.5313	.5113	.5123	.5871
23	.9867	.985	1.1173	.4934	.4924	.4744	.5303
24	.8143	1.0057	.9492	.8522	.4554	.4924	.4554
Max	1.1575	1.3093	1.1462	1.2309	1.4393	1.1552	1.212
Min	.3416	.2149	.2651	.3036	.303	.2657	.3409
Avg	.7180	.7285	.6821	.6594	.8364	.7575	.8134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 204 / 11KV HIWARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4659	1.9646	1.6389	1.6796	.9027	.9194	.9027
2	1.5012	1.9292	1.7457	1.715	.885	.884	.885
3	1.5012	1.7699	1.9417	1.7503	.9204	.9547	.9912
4	1.5365	1.8053	1.9595	1.768	1.1505	1.0255	1.0974
5	1.5542	1.8761	1.5142	1.8387	1.2036	1.1315	1.2567
6	1.5718	1.9469	1.8704	1.9095	1.2744	1.3437	1.3451
7	1.2716	1.3982	1.3716	1.3967	1.5221	1.5028	1.5221
8	1.2186	1.2567	1.1223			1.2907	1.2567
9	.936	1.2036	.8907		1.9292	1.9448	1.6283
10		1.1328	.7304		2.4956	2.21	1.9823
11		.9797	.6181		2.5106	2.0885	2.1924
12		.8729	.6181	.7939	2.3692	2.177	2.0686
13	.688	.7304	.6005	.7611	2.0863	2.1239	2.0509
14	.6528	.6413	.5828	.7788	1.9979	1.7345	1.8387
15	.7233	.57	.6711	.8142	1.8034	1.7345	1.8387
16	.7763	.7304	.6535	.7965	1.9448	1.6814	1.9095
17	.8997	.8194	.7418	.7965		.6903	
18	.935	.9263	.831	.9027	.9547	.9204	.9901
19	1.0585	1.1579	1.1139	1.0797	1.0608	1.2567	1.1846
20	1.0232	1.0688	1.0608	1.0974	1.0962	1.1151	1.0962
21	1.4996	1.5498	1.3083	1.0266	.9371	.9204	.9371
22	2.1347	2.2089	2.0332	.9381	.9547	1.062	.9547
23	2	1.9951	1.8387	.9381	.9547	.9204	.9547
24	1.4306	1.9469	1.7635	1.6443	.9204	.9371	.9204
Max	2.1347	2.2089	2.0332	1.9095	2.5106	2.21	2.1924
Min	.6528	.57	.5828	.7611	.885	.6903	.885
Avg	1.2561	1.3534	1.2175	1.2213	1.4488	1.3571	1.3828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 205 / 11KV BAHIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.9624	1.7918	1.9052	.8002	.7621	.7621
2	1.7528	1.9052	1.8484	1.9052	.8192	.7621	.7621
3	1.7909	2.0005	1.8861	2.0005	.9335	.9145	.9335
4	1.829	2.2672	1.9993	2.0957	1.0669	.9907	1.0669
5	2.0005	2.4196	2.0559	2.21	1.2003	1.1622	
6	2.1148	2.6673	2.452	2.3243	1.4861	1.4098	1.5051
7	1.4861	1.3908	1.6409		1.5623	1.6766	1.5623
8		1.5051	1.2826	1.4098	1.448	1.1622	1.3717
9	1.0098	.9145	.9997	1.1812	2.0386	2.191	2.0957
10	.7811	.7621	.6224	.8383	2.3434	2.191	2.1338
11	.6478	.6413	.5144	.5525	2.6482	2.3434	2.3624
12	.5906		.4763	.5335	2.6482	2.4196	2.4006
13	.5906	.5847	.5335	.5335	2.553	2.4196	2.3434
14	.5335	.547	.4763	.4954	2.4006	2.2672	2.2481
15	.6097	.4904	.4954	.5144	2.4768	2.0957	2.2291
16	.8954	.5847	.5906	.5525	2.4577	2.2291	2.21
17	.9717	.6602	.6287	.6668	.6859	.5525	.6097
18	1.0479	.8299	.7049	.8002	.8002	.724	.9145
19	1.2003	1.3203	.8954	1.2193	1.0669	1.1622	1.2765
20	1.086	1.2637	.8764	1.2574	1.0669	1.1622	1.2003
21	1.7718	1.7353	1.6575	1.086	.9526	1.0098	1.0479
22	2.2291	2.2257	1.8671	.9717	.8954	.9907	1.0288
23	2.0386	2.0559	1.9814	.8573	.7621	.8192	.9526
24	1.7147	2.0005	1.9239	1.8861	.8383	.7621	.7811
Max	2.2291	2.6673	2.452	2.3243	2.6482	2.4196	2.4006
Min	.5335	.4904	.4763	.4954	.6859	.5525	.6097
Avg	1.3221	1.4232	1.2584	1.2086	1.4980	1.4241	1.4695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 201 / 11 KV WADNER AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0856	1.1646	1.3146	1.1631		.0351	.0775
2	1.0856	1.1646	1.3146	1.1631	.0776	.0351	.0775
3	1.1631	1.2111	1.3146	1.1631	.0776	.0351	.0775
4	1.2407	1.4771	1.3672	1.3182	.0776	.0526	.0775
5	1.3182	1.515	1.4373	1.3182	.0776	.0701	.0775
6	1.3957		1.4899	1.3182	.0932	.1052	.0775
7	.0775	.0776	.0876	.0775	.0932	.0876	.0775
8	.0775	.0932	.1052	.0775	.0776	.0775	.0775
9	.0775	.0311	.1052	.0775	.7764	.9305	1.008
10	.0775	.0311	.0175	.0775	1.3198	1.1631	1.3182
11	.0775	.0351	.0175	.0776	1.4022	1.4733	1.3975
12	.0776	.0351	.0465	.0776		1.5508	1.3198
13	.0776		.0465	.0776		1.3957	1.5527
14	.0466		.0465	.0876	.3506	1.0856	1.5527
15	.0776		.0465	.0776	.5258	.9305	1.4751
16	.0776	.0351	.0775		1.4022	1.0856	1.3975
17	.0776	.0526			.0526	.0775	.0776
18	.0776	.1402	.0775	.0776	.0526	.0775	.0776
19	.0776	.1402	.0775	.0932	.0876	.0775	.0776
20	.0621	.2103	.0876	.0776	.0876	.0876	.0776
21	.7764	1.0517	.964	.0776	.0876	.0876	.0776
22	1.0869	1.2269	1.2269	.0776	.0701	.0876	.0776
23	1.0869	1.3146	1.3146	.0776	.0701	.0876	.0776
24	.9305	1.1646	1.2269	1.1631	.0776	.0351	.0775
Max	1.3957	1.515	1.4899	1.3182	1.4022	1.5508	1.5527
Min	.0466	.0311	.0175	.0775	.0526	.0351	.0775
Avg	.5087	.6086	.6004	.4453	.3303	.4471	.5109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 202 / 11 KV AMBA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9478	1.0517	.9431	.0948	.1052	.0786
2	.9431	.9478	1.0517	1.0217	.0948	.1052	.0786
3	1.1003	.9478	1.1393	1.0217	.1137	.1052	.0786
4	1.2574	1.0426	1.2269	1.336	.1137	.2103	.0786
5	1.4932	1.1374	1.4022	1.4146	.1137	.2629	.0786
6	1.6504	1.327	1.5775	1.5718	.1327	.2629	.0786
7	.0786	.1137	.0876	.0786	.1137	.2629	.0786
8	.0786	.1327	.1402	.0314	.1137	.2043	.0786
9	.0786	.1137	.1402	.0786	1.2322	1.1003	1.1003
10	.0786	.1137	.1753	.0786	1.7061	1.336	1.336
11	.0786	.0876	.1402	.0948	1.8404	1.4146	1.7061
12	.0948	.0876	.0876	.0948	1.8404	1.4146	1.7061
13	.0948	.0876	.0876	.0948	1.9281	1.2574	1.4218
14	.1137	.0876	.0876	.0948	1.9281	.9431	1.4218
15	.0948	.0876	.0876	.0948	1.5775	1.0217	1.4218
16	.1137	.0876	.0876	.0948	1.3146	1.1003	1.327
17	.1137	.1402	.0876	.0948	.0876	.0786	.0948
18	.1137	.1402	.0876	.1137	.0876	.0786	.0948
19	.1137	.2103	.0876	.1137	.0876	.0786	.1137
20	.1137	.2103	.0876	.1137	.0876	.0876	.1327
21	.7583	.8764	.6135	.0948	.0876	.0876	.1137
22	.9478	1.0517	.964	.1137	.0876	.0876	.1137
23	.9478	1.0517	1.0517	.0948	.0876	.0876	.1137
24	1.2622	.9478	1.0517	.9431	.1137	.1052	.0786
Max	1.6504	1.327	1.5775	1.5718	1.9281	1.4146	1.7061
Min	.0786	.0876	.0876	.0314	.0876	.0786	.0786
Avg	.5276	.4991	.5251	.4095	.6244	.4916	.5386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 203 / 11 KV KOLWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.031	.0351	.0774	.6196	1.0517	.9282
2		.031	.0351	.0774	.6196	1.0517	.9282
3		.031	.0351	.0774	.6815	1.0517	1.0517
4		.062	.0351	.0774	.7125	1.1393	1.0829
5		.0774	.0701	.0774	.7435	1.2269	1.1603
6		.0776	.0876	.0774	.7745	1.2795	1.2376
7		.0774	.0876	.0774	.0774	.0876	.0774
8		.0774	.0876	.0774	.0774	.0774	.0774
9	.2321	.697	.964	.9282	.0774	.0774	.0774
10	.3868	.9294	1.1393	1.2376	.0774	.0774	.0774
11	1.0056	1.4899	1.4022	1.4715	.0351	.0774	.0774
12	1.394	1.6651	1.4899	1.7038	.0351	.0774	.0774
13	1.2391	1.5775	1.5775	1.6264	.0351	.0774	.0774
14	1.2391	1.3146	1.5775	1.4715	.0351	.0774	.0774
15	1.3166	1.3146	1.4899	1.394	.0351	.0774	.0774
16	1.3166	1.3146	1.4022	1.1617	.0351	.0774	.0774
17	.0465	.0351	.0876	.0774	.0351	.0774	.0465
18		.0351	.0876	.0774	.0351	.0774	.0774
19		.0701	.0876	.0774	.0526	.0774	.0774
20	.0774	.0701	.0876	.0465	.0526	.0876	.0929
21	.0774	.0876	.0876	.3408	.7011	.7011	.6505
22	.0774	.0876	.0876	.6505	1.0517	1.0517	1.0068
23	.0774	.0876	.0876	.6815	1.0517	1.0517	.9294
24		.031	.0701	.0774	.6196	1.0517	.9282
Max	1.394	1.6651	1.5775	1.7038	1.0517	1.2795	1.2376
Min	.0465	.031	.0351	.0465	.0351	.0774	.0465
Avg	.6528	.4697	.5083	.5685	.3446	.4900	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 204 / 11 KV MUNDWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1052	.2103	.0876	.8764	.8764	1.262
2		.1052	.2103	.0876	.8764	.8764	1.2795
3		.1052	.2103	.0351	.8764	.8764	1.3672
4		.1052	.2279	.0876	.9114	.964	1.4022
5		.1227	.3155	.0876	.964	1.2269	1.5089
6		.1227	.3506	.0876	1.0517	1.3672	1.4373
7		.1227	.3155	.0876	.1227	.1402	.0876
8		.1227	.298	.0876	.1052	.2103	.0876
9		1.2269	1.1043	1.1919	.1052	.1753	.0876
10	1.0517	1.5775	1.1919	1.5424	.0876	.0876	.0876
11		1.6651	1.5249	1.7002	.0876	.0876	.0876
12	1.6651	1.7878	1.6126	1.9281	.0876	.0876	.0876
13	2.0157	1.7528	1.7177	1.7703	.0876	.0876	.0876
14	2.0157	1.595	1.6301	1.7528	.0876	.0876	.0876
15	1.9982	1.4723	1.4022	1.6827	.0876	.0876	.1052
16	1.8755	1.4548	1.2269	1.4899	.1402	.0876	.1052
17	.0876	.0876	.0876	.0876	.1052	.0876	.1052
18	.1227	.0526	.0876	.0876	.1052	.0876	.1052
19	.1402	.3155	.0876	.0876	.1753	.0876	.1052
20	.1052	.2804	.0876	.1227	.2103	.0876	.1052
21	.1052	.2804	.0876	.7362	.7011	.9114	.9816
22	.1052	.2804	.0876	.8589	1.1043	1.1744	1.1919
23	.1052	.2103	.0876	.8413	1.1218	1.2269	1.1568
24		.1052	.2103	.0876	.8764	.964	1.262
Max	2.0157	1.7878	1.7177	1.9281	1.1218	1.3672	1.5089
Min	.0876	.0526	.0876	.0351	.0876	.0876	.0876
Avg	.8764	.6273	.5989	.6923	.4565	.4981	.5909



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 205 / 11KV WADNER GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.303	.3219	.2804	.2841	.2841	.2804	.2841
2	.303	.3219	.2804	.2841	.2841	.2804	.2841
3	.3788	.3219	.298	.3598	.2841	.2804	
4	.5871	.4545	.4207	.5113	.4545	.4207	.6439
5	1.0605	.6439	.6135	.7386	.6452	.5609	1.0226
6	1.1363	.8901	1.0166	.9658	.909	1.0166	1.1173
7	1.0226	.909	1.2445	1.1552	.8711	1.0692	1.1552
8	.8901	.7954	1.0341	1.1173	.7575	1.0416	1.0605
9		.7007	.7888	.8333	.5681	.8143	.7575
10	.4545	.4545	.6135	.4734	.3409	.3977	.4545
11	.2841	.2454	.298	.2273	.1753	.1894	.2083
12	.1704	.1753	.2629	.1894	.1753	.1326	
13	.1894	.1753	.2103	.1704	.1753	.1136	
14	.303	.1753	.2279	.1515	.1928	.1136	
15	.4545	.1578	.1753	.1326	.1753	.1515	
16	.5492	.1753	.1753	.1894	.2454	.1894	
17	.6818	.1753	.2629	.3409	.3155	.3409	.2651
18	.8522	.2629	.5434	.5113	.5434	.5492	.606
19	.606	.631	.8063	.6818	.6135	.9279	.7954
20	.4924	.5609	.5258	.5871	.5959	.5959	.5681
21	.4545	.4382	.4557	.4545	.3856	.5258	.4545
22	.3977	.4207	.4031	.3788	.3856	.4031	.3598
23	.3409	.3506	.3506	.3219	.3155	.3155	.3219
24	.303	.3219	.298	.2841	.2841	.2804	.2841
Max	1.1363	.909	1.2445	1.1552	.909	1.0692	1.1552
Min	.1704	.1578	.1753	.1326	.1753	.1136	.2083
Avg	.5311	.4200	.4828	.4727	.4157	.4580	.5913

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 206 / 11KV KOLWADI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.076	.076	.0701	.095	.095	.0876	.114
2	.076	.076	.0701	.095	.095	.0876	.114
3	.114	.076	.0876	.152	.095	.0876	.1899
4	.1899	.114	.2279	.2469	.1899	.1753	.2849
5	.2849	.2651	.2629	.3419	.2659	.333	.3799
6	.3799	.436	.3681	.3989	.4559	.4031	.3799
7	.4369	.3799	.4031	.3799	.4179	.3856	.3609
8	.3039	.2654	.3155	.3229		.2659	.2659
9	.1899	.2089	.2103	.2089	.171	.2089	.1899
10	.133	.133	.1753	.133	.114	.1132	.133
11	.076	.0876	.0701	.076	.0876	.057	.076
12	.076	.0526	.0526	.057	.0701	.038	.076
13	.076	.0701	.0526	.057	.0526	.038	.038
14	.095	.0526	.0526	.057	.0526	.057	.038
15	.114	.0701	.0701	.076	.0351	.038	.057
16	.171	.0526	.0876		.0526	.057	.057
17	.1899	.0701	.1402		.0701	.076	.095
18	.1899	.1052	.1928		.1052	.133	.1899
19	.2659	.2629	.2629	.3039	.298	.3229	.3039
20	.1899	.1928	.1928	.2659	.2629	.1753	.2089
21	.133	.1227	.1227	.133	.1753	.1402	.133
22	.114	.1052	.1052	.133	.1052	.1052	.114
23	.095	.0876	.0876	.095	.0876	.1227	.095
24	.076	.076	.0701	.095	.095	.0876	.114
Max	.4369	.436	.4031	.3989	.4559	.4031	.3799
Min	.076	.0526	.0526	.057	.0351	.038	.038
Avg	.1686	.1433	.1563	.1773	.1500	.1498	.167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 207 / 11KV AMBA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1478	.1227	.1294	.1478	.1402	.1294
2	.1294	.1478	.1227	.1294	.1478	.1402	.1294
3	.1848	.1478	.1227	.1663	.1478	.1402	.2033
4	.2772	.1848	.1578	.2772	.2218	.1928	.3326
5	.3696	.2957	.2629	.3881	.2957	.2629	.3881
6	.4251	.4435	.3681	.4435	.4251	.3856	.4805
7	.462	.4435	.4557	.4435	.462	.4207	.4805
8	.4066	.3881	.3506	.4251	.3142	.4251	.4251
9	.2957	.2402	.298	.2957	.2402	.2772	.2957
10	.1848	.2402	.1753	.1848	.1663	.1478	.2033
11	.1294	.1402	.0876	.0924	.1052	.0924	.1109
12	.1109	.0701	.0876	.0924	.0876	.0739	.0924
13	.1109	.0701	.0876	.0739	.0701	.0739	.0739
14	.1478	.0876		.0739	.0701		.0739
15	.1848	.0876	.0876	.0924	.0351	.0739	.0924
16	.1663	.1052	.1052	.1109	.1052	.0924	.1109
17	.2218	.1227	.1753	.1478	.1402	.1478	.1663
18	.2772	.2103	.298	.2587	.2454	.2033	.2587
19	.3511	.3155	.3681	.4435	.4031	.3511	.3696
20	.2587	.2103	.2454		.2629	.2629	.2772
21	.1848	.1928	.1928	.2218	.1928	.1928	.2218
22	.1848	.1753	.1578	.1848	.1578	.1578	.1478
23	.1478	.1402	.1402	.1663	.1402	.1402	.1478
24	.5104	.1478	.1227	.1294	.1663	.1402	.1294
Max	.5104	.4435	.4557	.4435	.462	.4251	.4805
Min	.1109	.0701	.0876	.0739	.0351	.0739	.0739
Avg	.2438	.1981	.1997	.2161	.1979	.1972	.2225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 208 / 11KV KALIMATH GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0351	.0377	.0943	.0526	.0377
2	.0377	.0377	.0351	.0377	.0943	.0526	.0377
3	.0566	.0189	.0351	.0566	.0943	.0526	.0566
4	.0754	.0566	.0876	.0754	.0943	.0876	.0943
5	.132	.0943	.1227	.1509	.1509	.1402	.1509
6	.1886	.1698	.1578	.1886	.1886	.1578	.1886
7	.1698	.1698	.1578	.1698	.1886	.1578	.1509
8	.1509	.1698	.1402	.132	.1509	.1509	.1132
9	.132	.1132	.1227	.1132	.1132	.0943	.0754
10	.0566	.1132	.1227	.0943	.0943	.0754	.0566
11	.0377	.0526	.0351	.0566	.1052	.0566	.0377
12	.0189	.0351	.0175	.0566	.0876	.0566	.0377
13	.0377	.0351	.0175	.0566	.0701	.0566	.0189
14	.0566	.0351	.0175	.0566	.0701	.0566	.0189
15	.0754	.0351	.0526	.0754	.0701	.0189	.0189
16	.0943	.0351	.0526	.0754	.0351	.0377	.0377
17	.1132	.0526	.0876	.0943	.0701	.0377	.0377
18	.132	.0526	.1052	.132	.1052	.0754	.0943
19	.1509	.1402	.1402	.1698	.1578	.1132	.1132
20	.132	.0876	.1052	.132	.1402	.0701	.0754
21	.0754	.0876	.0701	.1132	.1227	.0526	.0566
22	.0566	.0701	.0526	.1132	.0701	.0351	.0377
23	.0566	.0351	.0351	.0943	.0526	.0351	.0377
24	.0377	.0377	.0351	.0377	.0943	.0526	.0377
Max	.1886	.1698	.1578	.1886	.1886	.1578	.1886
Min	.0189	.0189	.0175	.0377	.0351	.0189	.0189
Avg	.0880	.0739	.0767	.0967	.1048	.0740	.0676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 201 / 11KV HATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.463	.3258	.4344	.4458	.5407	.7773
2	.4344	.5144	.3439	.4344	.4458	.5243	.8421
3	.5792	.583	.2804	.5068	.463	.583	.8421
4	.7164	.703	.5249	.6516	.583	.6554	.8962
5	1.0029	.9945	1.0679	1.0387	.6859	.7125	.9602
6	1.4327	1.406	1.4632	1.3611	.9945	1.1142	1.0242
7	1.5043	1.5089	1.5424	1.576	1.4575	1.5927	1.5043
8	1.4327	1.2346		1.4327	1.3717	1.4118	1.4327
9	.583	.9431	.7209	.5898	1.0136	.543	1.0745
10	.703	.9831	.8421	.9431	.6516	.724	.6516
11	.9431	.852	.7865	.2229	.4344	.5792	.583
12	.9945	1.0486	.7209	.9602	.5068	.5068	.4973
13	.9431	.852	.6554	.9259	.6584	.4344	.4973
14	.9088	.7209	.5898	.9259	.3544	.362	.4458
15	.9259	.7209	.6554	.6859	.4344	.4344	.4115
16	.9431	.7865	.7209	.6859	.4344	.4344	.3772
17	.703	.5068	.4344	.6001	.543	.5792	.5144
18	.8402	.7011	.7522	.8573	.6516	.788	.6344
19	1.0802	.905	1.0029	.9602	.8589	1.0745	.9945
20	.9602	.9816	.8596	1.0288	.8688	1.1462	1.0288
21	.8059	.724	.724	.5658	.4588	.5243	.8059
22	.703	.5609	.6516	.5144	.5761	.7209	.9431
23	.6516	.5121	.5068	.4973	.5243	.7449	.7716
24	.5068	.5144	.3258	.5068	.463	.5243	.7125
Max	1.5043	1.5089	1.5424	1.576	1.4575	1.5927	1.5043
Min	.4344	.463	.2804	.2229	.3544	.362	.3772
Avg	.8639	.8217	.7173	.7878	.6617	.7190	.8009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 202 / 11 KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2572	.1966	.2486	.2743	.3077	.2534
2	.2347	.2058	.2267	.2984	.2915	.2835	.2534
3	.2818	.1715	.2622	.3481	.3086	.3258	.2896
4	.3149	.1715	.3201	.4096	.3772	.4557	.3439
5	.3647	.5144	.427	.4588	.4801	.567	.5068
6	.3481	.823	.4915	.4424	.6687	.7964	.7421
7	.6878	.5487	.5304	.1646	.823	.8507	.788
8	.6335	.4801	.4706	.6516	.6344	.6335	.6516
9	.4887	.4973	.4163	.5792	.5407	.4752	.4588
10	.4287	.4344	.2534	.3944	.6882	.5243	.4973
11	.2572	.2534	.1629	.823	.7045	.4973	.583
12	.2401	.2481	.128	.2058	.6226	.5079	.4973
13	.2401	.2279	.128	.2058	.639	.4807	.4287
14	.2743	.2715	.1463	.2058	.5735	.4475	.3429
15	.3429	.2172	.1463	.1715	.4752	.4475	.4287
16	.4973		.1097		.4588	.431	.4801
17	.5487		.128	.2058	.3544	.1463	.12
18	.5487	.443	.181	.3772	.2454	.2715	.2229
19	.6859	.4607	.2353	.5487	.4887	.4525	.5658
20	.5144	.4887	.2534	.4973	.4706	.543	.5144
21	.3429	.2458	.1174	.3429	.3439	.3982	.3601
22	.3772	.2458	.1844	.3086	.3258	.3258	.3429
23	.3429	.1991	.2155	.2743	.3077	.2896	.3086
24	.1509	.2915	.1966	.218	.2743	.2896	.2715
Max	.6878	.823	.5304	.823	.823	.8507	.788
Min	.1509	.1715	.1097	.1646	.2454	.1463	.12
Avg	.3895	.3498	.2470	.3644	.4738	.4478	.4272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 203 / 11 KV TAPARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7444	1.989	2.0729	2.0005	.5144	.4344	.543
2	1.7604	1.9204	2.1136	2.0485	.5487	.4706	.5068
3	1.8884	1.8861	2.0083	2.1445	.583	.4706	.5792
4	1.8564	1.9204	2.0972	2.1765	.6859	.4706	.6878
5	1.9364	2.0062	2.0972	2.2405	.7716	.8688	.8238
6	1.9685	2.3148	2.0809	2.2245	1.0117	1.0498	1.0208
7	.7059	.6859	.7421	.7059	.9259	.7421	.788
8	.7701	.7888	.7602	.7522	.8059	.7011	.8507
9	.6154	.7373	.7602	.6878	2.0809	2.2283	2.2885
10	.4458	.6697	.5792	.5316	2.4086	2.343	2.572
11	.4801	.5792	.3439	.4115	2.3266	2.2085	2.6063
12	.5316	.5083	.3801	.3429	2.3967	2.3685	2.6578
13	.5144	.5487	.4344	.3601	2.3805	2.3045	2.5206
14	.5144	.5792	.5068	.3944	2.3266	2.1765	2.2977
15	.6001	.4908		.3429	2.343	2.0965	2.5549
16	.6687	.5609	.5249		2.2939	2.2405	2.692
17	.6001	.5973	.543	.4973	.3439	.362	.3772
18	.6001	.6556	.6878	.6173	.3681	.5068	.5316
19	.7202	.7888	.7421	.823	.6335	.8238	.8573
20	.6344	.7964	.7602	.6344	.6516	.7701	.9088
21	1.8347	2.0809		.7373	.6335	.7164	.7888
22	2.2119	2.2775	2.0645	.6516	.5792	.6154	.6859
23	2.0576	2.0809	1.9524	.6001	.5853	.5792	.6859
24	1.6804	2.0233	2.0729	1.9845	.5487	.3982	.543
Max	2.2119	2.3148	2.1136	2.2405	2.4086	2.3685	2.692
Min	.4458	.4908	.3439	.3429	.3439	.362	.3772
Avg	1.1392	1.2286	1.1966	1.0396	1.1978	1.1644	1.3070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 204 / 11 KV JAITAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2572	.3077	.2896	1.286	1.4091	1.6324
2	.2896	.2743	.3292	.2715	1.286	1.3599	1.6804
3	.3258	.3258	.3658	.2534	1.2689	1.3763	1.6644
4	.3801	.3772	.3982	.3077	1.3032	1.3599	1.6004
5	.4887	.463	.4887	.3801	1.3375	1.3599	1.5364
6	.6154	.4287	.6335	.4163	1.4403	1.4091	1.4723
7	.6516	.4115	.2378	.4344	.3601	.4207	.4887
8	.543	.3258	.1448	.3801	.3258	.3801	.3982
9	1.2803	1.8347	1.7532	1.6164	.2715	.2715	.2534
10	1.6289	1.8515	1.5524	1.6975	.2172	.2172	.1543
11	1.7147	1.8023	1.4563	1.7318	.1267	.2353	.12
12	1.6975	1.6385	1.5043	1.5775	.0905	.2172	.12
13	1.5775	1.4746	1.4243	1.5432	.0934	.181	.1029
14	1.4918	1.4255	1.3283	1.3889	.1267	.1646	.1029
15	1.4918	1.4091	1.2963	1.3546	.1448	.1463	.0857
16	1.4575	1.491	1.4083		.1086	.1646	.0857
17	.2572	.1227	.128	.1029	.1753	.2353	.1372
18	.3258	.2126	.2715	.2401	.2715	.3258	.1886
19	.3944	.4525	.4163	.3601	.5068	.4163	.4115
20	.4115	.443	.4344	.3772	.4525	.4344	.3944
21	.3601	.3982	.3801	1.3717	1.3435	1.3441	1.406
22	.3429	.362	.3439	1.3375	1.4255	1.6004	1.8347
23	.3086	.3658	.3258	1.3203	1.4582	1.5684	1.6289
24	.3077	.2743	.2896	.2715	1.3203	1.4419	1.6004
Max	1.7147	1.8515	1.7532	1.7318	1.4582	1.6004	1.8347
Min	.2572	.1227	.128	.1029	.0905	.1463	.0857
Avg	.7756	.7676	.7174	.8271	.6975	.7516	.7958



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 201 / 11KV JEHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763	.6668	.4763	.3353	.6539	.4374
2	.5335	.4572	.6097	.4572	.3506	.5967	.4268
3	.5335	.5144	.5716	.5335	.381	.6062	.4572
4	.5716	.5716	.6287	.6668	.4687	.6478	.5624
5	.8002	.8573	.9335	.9145	.583	.7042	.7701
6	.9335	1.086	1.1431	1.086	.8048	.7432	.9221
7	1.105	1.1812	1.0288	1.1622	1.0288	.8749	1.1431
8	.9335	.9145	.8002	.9335	.8954	.7099	.9808
9	.3681	.5992	.5765	.5944	.6478	.6036	.7811
10	.3201	.6401	.6401	.703	.3429	.4191	.4191
11	.6249	.7116		.6249	.362	.3048	.3239
12	.6405	.6173	.6562	.6019	.2667	.2858	.3048
13	.5639	.5487	.6478	.5639	.3048	.2858	.3048
14	.5268	.4967	.5344	.5218	.2858	.2667	.2858
15	.4877	.431	.6401	.4586	.2641	.2667	.3239
16	.6093	.5418	.5944	.5155	.2667	.3048	.2858
17	.4696	.3429	.381	.3239	.3395	.362	.381
18	.5144	.5144	.4572	.4382	.5144	.4954	.5335
19	.8383	.8954	.8192	.8573	.724	.8192	.8383
20	.6859	.8002	.8192	.8192	.8002	.7811	.7049
21	.6097	.743	.6478	.3239	.5434	.4696	.4725
22	.6097	.6097	.5716	.3441	.5426	.4973	.4877
23	.5716	.6287	.5906	.3521	.6226	.4801	.5937
24	.6097	.5335	.6478	.5335	.3749	.6706	.4744
Max	1.105	1.1812	1.1431	1.1622	1.0288	.8749	1.1431
Min	.3201	.3429	.381	.3239	.2641	.2667	.2858
Avg	.6264	.6547	.6785	.6169	.5021	.5354	.5506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 202 / 11 KV CHIWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5719	1.0631	.873	.3429	.381	.3429
2	.6481	.5335	1.0166	.9511	.3048	.381	.3048
3	.7499	.6706	1.1043	1.0155	.3048	.4382	.3048
4	.8539	.8124	1.1919	1.0623	.3429	.5335	.381
5	1.0526	.9374	1.2346	1.0974	.4191	.743	.5335
6	1.1797	1.0722	1.3226	1.078	.5716	.8192	.743
7	1.4586	.8002	.4954	.6668	.7811	.8192	.8764
8	1.3763	.6173	.6478	.5906	.6478	.6287	.6979
9	1.166	.4954	.4763	.4572	1.0202	1.2071	.9878
10		.362	.3048	.3239	1.2631	1.278	1.1683
11	.2477	.2858	.1334	.2286	1.2654	1.2631	1.0623
12	.1905	.2667	.1334	.1524	1.2176	1.2003	.8993
13	.2286	.2477	.1143	.1334	1.0648	.7682	.7926
14	.2667	.2667	.1524	.1334	1.0648	.8592	.823
15	.3239	.2477	.1715	.1715	.8745	.9014	.8749
16	.4572	.2096	.1905	.1905	1.0753	.9061	.9297
17	.5906	.2667	.2858	.2096	.1524	.2096	.1524
18	.5906	.2477	.362	.3239	.362	.381	.823
19	.724	.6287	.6287	.6859	.743	.6287	.6668
20	.5716	.5335	.6287	.5716	.7621	.5906	.6097
21	.3437	.7796	.8764	.5144	.5906	.4572	.5144
22	.5335	1.0867	.8592	.4001	.4191	.4191	.4382
23	.5792	1.134	.8535	.381	.4191	.381	.4191
24	.6241		1.0867	.9145	.3429	.4001	.3429
Max	1.4586	1.134	1.3226	1.0974	1.2654	1.278	1.1683
Min	.1905	.2096	.1143	.1334	.1524	.2096	.1524
Avg	.6681	.5684	.6389	.5469	.6813	.6914	.6537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 203 / 11KV NIPANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2031	.4119	.2743	.3048	.4382	.3048
2	.1829	.1875	.4075	.2656	.2858	.4191	.2858
3	.1981	.2286	.443	.301	.2477	.5144	.2858
4	.2343	.2709	.4908	.3437	.2858	.5906	.3429
5	.3163	.3563	.5434	.3593	.381	.7545	.4191
6	.4024	.4062	.5721	.3749	.6097	.7049	.5144
7	.4557	.4001	.3429	.4001	.8002	.6668	.6478
8	.7127	.2134	.4763	.4001	.4763	.5144	.4382
9	.502	.3429	.362	.4954	.3812	.3391	.2949
10	.2477	.3239	.2858	.2858	.5243	.3841	.3749
11	.2096	.2286	.1905	.2286	.5407	.4428	.4115
12	.1905	.1905	.1524	.1715	.5506	.3795	.4816
13	.2096	.1715	.2286	.1524	.4641		.4687
14	.1905	.1905	.2477	.1715	.3593	.2846	.4268
15	.362	.2286	.2286	.1143	.3005	.3239	.3658
16	.4382	.2096	.2477	.2263	.2031	.3479	.3612
17	.4763	.2286	.2858	.2096	.362	.1524	.1406
18	.5144	.3048	.4382	.2667	.2477	.2667	.2667
19	.5525	.4763	.5335	.4954	.5525	.5525	.6097
20	.4954	.362	.4191	.5906	.6097	.4382	.5335
21	.125	.3801	.2096	.4954	.6097	.4572	.4572
22	.1677	.4298	.2267	.4382	.362	.4572	.4572
23	.1829	.4477	.2343	.4001	.381	.381	.381
24	.1718		.4298	.2623	.3429	.4191	.3429
Max	.7127	.4763	.5721	.5906	.8002	.7545	.6478
Min	.125	.1715	.1524	.1143	.2031	.1524	.1406
Avg	.3217	.2948	.3503	.3218	.4243	.4447	.4005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 201 / 11KV CHAPANER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1677	.1886	.2477	.2801	.3772	.2667
2	.1715	.1677	.1715	.2667	.2743	.3772	.362
3	.2058	.3018	.2058	.3048	.3174	.4715	.4382
4	.2058	.3353	.2572	.362	.3734	.5658	.5906
5	.2572	.3688	.2572	.4001	.5415	.6602	.7049
6	.2743	.3856	.3429	.4572	.8589	.8488	.8573
7	.4287	.7468	1.1317	1.1241	1.1203	1.0185	1.105
8	.415	.8962	.9054	.9145	.8589	.9054	.8954
9	.415	.7095	.6602	.724	.3734	.2572	.3429
10	.547	.7545		.5525	.1886	.2572	.362
11	.3734	.9526	.3429	.3361	.2263	.2477	.2347
12	.3921	.9808	.3429	.3361	.2829	.1905	.2347
13	.3921	.3395	.3239	.3174	.2829	.2096	.2347
14	.4108	.7545	.362	.3174	.2075	.2286	.218
15	.5415	.7922	.362	.3361	.2263	.2477	.2012
16	.6161	.3395	.3429	.3547	.2829	.2667	.1677
17	.5415	.3395	.4001	.4481	.381	.3429	.3734
18	.5415	.5658	.5335	.5415	.4715	.4382	.4854
19	.5228	.6413	.7049	.7095	.381	.7811	.5601
20	.5975	.7167	.6287	.5041	.7811	.6859	.7655
21	.1867	.2829	.4382	.4801	.5093	.5335	.4481
22	.1867	.2829	.2667	.4854	.4191	.4382	.4854
23	.1677	.1886	.3048	.3361	.381	.362	.4481
24	.1334	.1715	.1715	.2667	.3048	.2829	.3048
Max	.6161	.9808	1.1317	1.1241	1.1203	1.0185	1.105
Min	.132	.1677	.1715	.2477	.1886	.1905	.1677
Avg	.3607	.5076	.4194	.4635	.4302	.4581	.4620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 202 / 11KV SIRAJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2012	.6859	.724	.3174	.1886	.2286
2	.1715	.2347	.7202	.8192	.3174	.2263	.2667
3	.1715	.3688	.6859	1.0288	.3361	.2263	.2858
4	.2829	.503	.6859	1.2384	.3734	.1886	.381
5	.5144	.5868	.7716	1.3717	.4854	.1886	.5525
6	.7716	.7209	.8745	1.5242	.5228	.3772	.7049
7	1.046	.4694	.6224	.6668	.6161	.7922	.8573
8	1.6575	.4481	.5847	.6287	.6161	.6224	.5906
9	1.2637	.4294	.4338	.4191	.7468	.6602	.6287
10	.3018	.3772	.2641	.3239	.9431	.811	.6859
11	.2801	.3772	.1905	.1867	1.0185	.8764	.6203
12		.4338	.1905	.168	1.1883	.8573	.6371
13	.1867	.2263	.2096	.1867	1.094	.724	.5868
14	.2054	.2263	.2096	.1867	.9808	.5144	.5365
15	.2427	.1886	.1905	.1867	.7922	.6859	.5365
16	.2572	.1886	.1524	.1867	.811	.7811	.6036
17	.3734	.2452	.2477	.2614	.1905	.1715	.1698
18	.4481	.3772	.381	.3361	.2452	.2667	.2801
19	.5228	.5281	.5525	.4108	.1905	.5525	.4481
20	.5601	.5281	.4763	.3734	.5144	.4763	.5788
21	.3174	.6413	.381	.3921	.3961	.4382	.3361
22	.3361	.6602	.5906	.3734	.381	.381	.3547
23	.3361	.7545	.6668	.3361	.2858	.3239	.2614
24	.381	.2667	.7621	.7049	.3239	.2829	.2667
Max	1.6575	.7545	.8745	1.5242	1.1883	.8764	.8573
Min	.1543	.1886	.1524	.168	.1905	.1715	.1698
Avg	.4688	.4159	.4804	.5431	.5703	.4839	.4749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 203 / 11KV TAKLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.7282	.7545	.5716	.57	.7545	.6859
2	.5658	.8962	.7545	.5525	.5765	.8488	.6097
3	.6001	.9335	.8488	.6097	.6104	.8488	.6478
4	.7545	1.0829	.8488	.6478	.6371	.9431	.7049
5	.9242		1.0374	.7049	.7468	1.0374	.7811
6			1.1694	.724	.8962	1.1317	.8573
7				.9526	.8718	1.094	.9526
8		1.0059	.5847	.8573	.9522	1.0751	.8764
9	.7922	.5975	.7167	.8192	.6161	.6602	.6668
10	.5093	.9431	.9054	.8764	.5658	.4715	.4382
11	.5868	1.0374	.8383	.7042	.3395	.362	.2987
12	.7377	.9808	.8383	.6874	.2263	.2477	.2241
13	.7712	.823	.7621	.6371		.2286	
14	.788	.7545	.6859	.6036		.2096	
15	.8048	.7922	.743	.6539		.2667	
16	.8215	.7545	.7621	.6539		.2858	
17	.7209	.2641	.4763	.5601	.4904	.362	.2241
18	.7042	.7545	.5716	.7468	.4904	.4382	.4854
19	.6348	.7733	.6287	.7468	.7621	.8383	.5601
20	.6878	.8299	.6478	.7095	.8002	.8002	.8775
21	.6535	.679	.6287	.5365	.679	.6287	.788
22	.6908	.7621	.6859	.5365	.6668	.8192	.8551
23	.6348	.7621	.724	.57	.7621	.743	.8383
24	.7621		.7621	.6668	.6478	.8488	.724
Max	.9242	1.0829	1.1694	.9526	.9522	1.1317	.9526
Min	.5093	.2641	.4763	.5365	.2263	.2096	.2241
Avg	.7005	.8077	.7554	.6804	.6454	.6643	.6548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 204 / Banshendra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1509	.1698	.2667	.1494	.1886	.1524
2	.0943	.1677	.1886	.3048	.1867	.1886	.1905
3	.1543	.1677	.1886	.3239	.1867	.1886	.2477
4	.1715	.2012	.1886	.362	.2241	.2263	.3048
5	.2058	.2347	.1886	.4001	.2614	.2829	.362
6	.2263	.2347	.2263	.4572	.3086	.415	.4001
7	.3206	.2683	.4527	.4191	.4108	.5281	.5525
8	.4904	.3185	.3584	.381	.3921	.415	.5716
9	.3395	.2427	.2075	.2667	.218	.1886	.1524
10	.1509	.1509	.1698	.1524	.1886	.1509	.4382
11	.1307	.1698	.1334	.112	.3206	.1905	.2683
12	.112	.1698	.0953	.112	.2829	.2286	.2347
13	.112	.2452	.0953	.112	.1886	.2096	.2012
14	.1307	.1886	.1143	.112	.1886	.1334	.1677
15	.1307	.1132	.1143	.112	.1509	.1715	.1509
16	.1494	.132	.1334	.112	.1509	.1524	.2012
17	.2241	.132	.1905	.168	.0953	.0572	.0747
18	.2614	.1886	.2286	.2241	.0953	.0762	.0934
19	.3174	.2452	.2667	.2614	.1905	.362	.1867
20	.3547	.3584	.2286	.2614	.381	.3239	.3361
21	.0747	.1698	.1905	.2614	.3206	.3048	.2801
22	.0934	.1524	.1524	.2427	.1715	.2667	.2801
23	.0934	.1334	.1905	.1867	.1905	.2096	.2427
24	.0953	.1143	.1524	.2096	.1715	.1509	.1905
Max	.4904	.3584	.4527	.4572	.4108	.5281	.5716
Min	.0747	.1132	.0953	.112	.0953	.0572	.0747
Avg	.1887	.1938	.1927	.2426	.2260	.2337	.2617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 205 / 11 KV GUDAMA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1677	.1543	.381	.168	.1132	.1715
2	.1029	.1677	.1509	.4191	.168	.1698	.2096
3	.1372	.2012	.1698	.4572	.2054	.1886	.2667
4	.1715	.2347	.1886	.5525	.2241	.2829	.362
5	.1715	.3018	.2829	.6668	.3361	.3772	.4382
6	.1715	.3185	.415	.7621	.4108	.5658	.5525
7	.4287	.3361	.5093	.4572	.5041	.5281	.5525
8	.7922	.3734	.2641	.4763	.3547	.3772	.362
9	.5281	.2987	.5144	.2858	.3353	.2829	.3429
10	.1886	.1886	.1698	.2096	.1886	.3395	.3429
11	.112	.1132	.1143	.0934	.3206	.381	.285
12	.0934	.1132	.0762	.112	.5658	.362	.285
13	.0747	.1132	.0572	.0934	.5281	.2858	.2347
14	.0747	.0943	.0572	.0934	.3772	.2667	.2012
15	.168	.0943	.0762	.056	.1886	.2858	.1677
16	.2054	.0943	.0953	.056	.3584	.3239	.2515
17	.2801	.132	.1715	.1307	.1698	.1334	.112
18	.3361	.1886	.2667	.2241	.1698	.1715	.1867
19	.2987	.3018	.3048	.3547	.1905	.4001	.2054
20	.2801	.3206	.2667	.2614	.3429	.2667	.2801
21	.1494	.2229	.2286	.2614	.2452	.2286	.2241
22	.1526	.1905	.1905	.2241	.1715	.2096	.2058
23	.1341	.1905	.2286	.1867	.1524	.1905	.2241
24	.0953	.1334	.1886	.3048	.1524	.0754	.1715
Max	.7922	.3734	.5144	.7621	.5658	.5658	.5525
Min	.0747	.0943	.0572	.056	.1524	.0754	.112
Avg	.2184	.2038	.2142	.2967	.2845	.2836	.2765



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 201 / 11kv ANDHANER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.6975	1.8099	1.7918	1.2955	.9335	1.3203
2	1.448	1.7918	1.8099	1.8861	1.2193	1.0269	1.3203
3	1.448	1.8861	1.8099	2.1691	1.1576	1.1203	1.4146
4	1.8099	2.1691	1.9909	2.4143	1.2696	1.307	1.8861
5	1.9909	2.452	1.9909	2.452	1.448	1.6804	2.0748
6	2.1719	2.5274	2.1719	2.5086	2.0452	2.2405	2.1502
7	1.448	1.8107	1.8099	2.0559	2.0576	2.2405	2.3765
8	1.4937	1.8296	1.8671	1.7541	1.9791	1.8671	2.2068
9	1.1203	1.6598	1.307	1.6787	2.0271	1.8099	2.0936
10	1.105	1.2384	.9145	1.0117	2.0814	1.8861	2.1719
11		1.105	.6859	.703	2.0576	1.9427	2.1719
12	.8764	.9907	.5716	.6516	2.1719	1.8861	1.9909
13	.7202	.8192	.6668	.5144	1.9376	1.9427	1.8099
14	.6859	.6859	.5906	.5487	1.8861	1.9427	1.6289
15		.6287	.5525	.5487	1.8671	1.8861	1.8099
16		.5525	.6478		1.8099	1.9239	1.8099
17	1.643	.8215	1.086	.9259			1.1203
18	1.7918	1.1203	1.1317	.9259	1.046	.9774	1.0098
19	1.7737	1.4937	1.5655	1.7164	1.4937	1.4403	1.6632
20	1.6221	1.8671	1.6032	1.6617	1.8671	1.6598	1.587
21	1.6221	1.4937	1.4146	1.587	1.4937	1.4146	1.7147
22	1.7918	1.8099	1.5844	1.363	1.1203	1.3203	1.5242
23	1.8484	1.8099	1.6975	1.307	.9335	1.2826	1.3146
24	1.3717	1.7353	1.8099	1.7918	1.307	.9335	1.2826
Max	2.1719	2.5274	2.1719	2.5086	2.1719	2.2405	2.3765
Min	.6859	.5525	.5525	.5144	.9335	.9335	1.0098
Avg	1.4894	1.4998	1.3787	1.4768	1.6336	1.5941	1.7272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 203 / 11KV GARADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.3395	.5228	.3395	1.4118	2.0538	1.7194
2	.4525	.3395	.4668	.3395	1.448	2.0538	1.7194
3	.4525	.415	.5601	.3772	1.4415	1.9909	1.8099
4	.4525	.4904	.5975	.4904	1.386	1.9909	1.9004
5	.5068	.547	.5975	.5281	1.6263	2.1719	1.9366
6	.543	.5658	.6535	.5658	1.7375	2.3529	1.9366
7	.543	.547	.5601	.5847	.4954	.543	.5973
8	.5601	.5093	.5601	.6224	.5335	.4525	.4344
9	1.448	1.8673	1.448	1.9605	.4954	.5601	.4163
10	1.8099	1.7814	1.9719	2.371	.4854	.5975	.4525
11	2.2291	2.0271	1.9204	2.2672	.4668	.5792	.4525
12	2.552	1.9814	1.9814	2.1033	.4668	.5611	.362
13	2.4006	1.9204	1.9662	2.0729	.4481	.543	.4525
14	2.332	1.7833	1.9662	1.9814	.4108	.543	.543
15	2.0576	1.7528	1.9662		.3734	.5611	.543
16	1.89	1.6766	1.9357		.5601	.5611	
17	.5144	.4001	.5144	.3239	.5601	.543	
18	.5281	.5601	.5093	.4954	.5601	.6154	
19	.5847	.6535	.5658	.5335	.5601	.5792	.381
20	.5093	.5601	.5093	.4382	.6535	.5415	.4954
21	.4527	.5601	.4527	.7468	1.1203	1.7194	1.2955
22	.415	.5601	.4527	.8962	1.8099	1.9909	1.6289
23	.3584	.543	.4338	1.2136	1.9909	2.009	1.828
24	.4715	.3395	.4668	.3772	1.3575	2.1719	2.0452
Max	2.552	2.0271	1.9814	2.371	1.9909	2.3529	2.0452
Min	.3584	.3395	.4338	.3239	.3734	.4525	.362
Avg	1.0215	.9467	.9825	.9831	.9333	1.1786	1.0928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 204 / 11KV KALIMATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7922	.724	.8299	.8402	3.0769	2.8292
2	.7842	.7922	.724	.8299	.7655	3.0769	2.9235
3	.8402	.8299	.8145	.8299	.6668	3.0769	2.8292
4	.9335	.8676	.8688	.8676	.6287	3.0769	2.9424
5	.9335	.9431	.905	.9054	.6668	3.0769	2.8753
6	.9335	1.0374	.905	1.1128	.6344	3.2579	2.8292
7	.7468	.7922	.905	1.0751	.381	.905	.8676
8	.7468	.7922	.5601	.6602	.3429	.7468	.547
9	2.5339	2.8858	2.5339	2.8481	.2667	.362	.415
10	2.8464	2.4387	2.7435	2.915	.1867	.2452	.3734
11	3.3436	2.5606	2.713	2.9492		.2452	.3734
12	3.6199	2.713	2.7435	3.0007		.2829	.3734
13	3.3436	2.8549	2.8045	3.0178	.2058	.2829	.2801
14	2.7606	2.5149	2.8807	2.915	.2401	.2829	.2801
15	2.8978	2.4844	2.7282		.2801	.3018	.2715
16	2.6673	2.4539	2.6673		.1867	.3395	.3734
17	.4001	.2477	.2858	.3258	.3361	.3258	.4668
18	.5658	.3361	.3395	.4287	.3258	.463	.5144
19	.6036	.5601	.7922	.7621	.5601	.3086	.724
20	.7356	.6535	.7356	.743	.7468	.7922	.8192
21	.8299	.9335	.8299	.7545	1.6289	2.4897	1.5089
22	.8299	.9335	.8299	.8029	2.5339	2.9235	2.4577
23	.811	.7468	.8865	.7202	2.8959	3.0178	2.7368
24	.7545	.7922	.724	.8299	.8215	3.0769	3.0178
Max	3.6199	2.8858	2.8807	3.0178	2.8959	3.2579	3.0178
Min	.4001	.2477	.2858	.3258	.1867	.2452	.2715
Avg	1.5087	1.3732	1.4019	1.3693	.7337	1.5014	1.4012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 205 / 11KV GARADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1698	.1494	.1886	.1715	.1494	.1698
2	.1867	.1698	.1494	.2263	.1715	.1494	.1698
3	.2241	.1886	.1867	.3018	.1715	.1867	.1886
4	.2801	.415	.2614	.3584	.1524	.2614	.3395
5	.4668	.4527	.3547	.5281	.4001	.3734	.415
6	.5228	.4715	.4668	.5658	.4572	.5228	.4715
7	.5601	.4527	.5601	.5228	.5525	.5601	.5658
8	.5228	.4527	.4108	.4527	.4191	.5228	.4527
9	.3734	.3018	.3734	.3206	.3239	.3361	.3018
10	.2286	.2858	.3429	.2058	.2829	.1509	.2427
11	.2096	.2667	.1905	.1372	.1543	.1509	.1867
12	.1905	.1905	.1905	.1372	.1372	.1509	.3361
13	.1543	.1524	.1334	.1372	.1372	.1509	.1867
14	.12	.1715	.1334	.1543	.1494	.1509	.1307
15	.1715	.1905	.1334		.1494	.1509	.1494
16	.2286	.1905	.1334		.1494	.1509	.1494
17	.2858	.2054	.1524	.2058	.2614	.1886	.2241
18	.3772	.2987	.2641	.2743	.2915	.3086	.3429
19	.5847	.3734	.3961	.4191	.3734	.3601	.2858
20	.2641	.3361	.2829	.2858	.4108	.2829	.2667
21	.2263	.2801	.2641	.2667	.3361	.2263	.2477
22	.1698	.2241	.2263	.1905	.2614	.2263	.1905
23	.1886	.1867	.1698	.1715	.1867	.1886	.1715
24	.1698	.1698	.1494	.1698	.1715	.1494	.1698
Max	.5847	.4715	.5601	.5658	.5525	.5601	.5658
Min	.12	.1524	.1334	.1372	.1372	.1494	.1307
Avg	.2857	.2749	.2531	.2827	.2613	.2521	.2648

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 206 / 11KV Rail Single Phasing SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	1.2071	1.1765	1.2826	.2286	.2241	.2452
2	.8402	1.2826	1.2308	1.3203	.2477	.2427	.2452
3	.8688	1.358	1.267	1.3957	.2477	.2614	.2829
4	.9955	1.4146	1.267	1.4712	.2858	.3429	.3772
5	1.0498	1.5089	1.267	1.5089	.381	.3734	.4715
6	1.086	1.5278	1.3575	1.5466	.4954	.4668	.5658
7	.4525	.4904	.543	.4715	.5525	.6161	.6602
8	.4668	.4904	.4668	.4338	.4572	.5601	.547
9	.3361	.4338	.3734	.3395	1.0498	1.1765	1.1506
10	.1905	.381	.2858	.1886	1.3575	1.4335	1.3575
11	.1905	.2096	.1334	.1372	1.7147	1.4901	1.3575
12	.1524	.1905		.1372	2.0576	1.5655	1.448
13	.1543	.1524	.1334	.12	1.6804	1.5466	1.3575
14	.1372	.1715	.1143	.0857	1.8099	1.5089	1.3575
15	.1372	.1715	.1334		1.5023	.1509	1.267
16	.3239	.1143	.1715		1.3575	1.3203	1.267
17	.362	.2286	.3429	.1886	.2427	.4801	.112
18	.4904	.2241	.3395	.1886	.1372	.2229	.1715
19	.5847	.4108	.3584	.362	.3361	.2572	.381
20	.3584	.4108	.3921	.381	.4481	.3395	.4001
21	.9054	.9955	1.0374	.2858	.4108	.2641	.3429
22	1.0374	1.267	1.1317	.2477	.362	.2452	.2858
23	1.1128	1.086	1.2826	.2096	.2534	.2452	.2667
24	.724	1.1317	1.1203	1.2826	.1905	.2427	.2452
Max	1.1128	1.5278	1.3575	1.5466	2.0576	1.5655	1.448
Min	.1372	.1143	.1143	.0857	.1372	.1509	.112
Avg	.5749	.7025	.6924	.6175	.7419	.6490	.6735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 201 / 11 KV Deogaon Urban SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.6804	1.5089	.8962	.8684	.9945	1.0117
2	1.6766	1.6804	1.5089	.8779	.8684	.9431	.9774
3	1.7147	1.8671	1.6289	.9877	.9503	.9431	.9602
4	1.9433	2.2405	1.7833	1.0608	1.0774	1.0288	1.046
5	2.4387	2.3152	1.9719	1.3535	1.1469	1.3375	1.2346
6	2.6292	2.5019	2.5206	1.3717	1.4746	1.5775	1.4403
7		2.4646	2.4006	2.5206	2.6673	2.2291	2.4863
8		2.2592	2.0576	2.2218	2.2862	2.1338	2.0576
9	.9945	1.1157	1.0631	1.9791	1.7147	1.8671	1.5604
10	1.0974	1.2517	1.2071	1.7147	1.448	1.3203	1.5242
11	1.1706	1.2346	1.1888	1.467	1.3717	1.2003	1.3908
12	1.2254	1.286	1.262	1.4289	1.4098	1.1488	1.3717
13	1.2437	1.2003	1.1523	1.3336	1.3336	1.1488	1.3717
14	1.1888	1.0631	1.134	1.4098	1.2384	1.1488	1.467
15	1.2437	1.0631	1.134	1.3717	1.3336	1.1488	1.3908
16	1.3535	1.0288	.8779	1.4289	1.4289		1.3717
17	1.6617	1.2346	1.4563	1.467	1.3527		1.5242
18	1.8111	1.3717	1.531	1.6194	1.5813	1.9547	1.6194
19	2.1658	1.8519	2.0538	2.2862	2.0957	2.1948	2.2291
20	2.1098	2.0576	2.0538	2.191	2.0195	2.2119	2.2481
21	2.0725	1.9547	1.0059	1.065	1.0631	1.1831	1.2289
22	1.9418	1.8519	.9511	1.065	1.2003	1.3032	1.2616
23	1.8111	1.6118	.8962	1.0322		1.2003	1.0978
24	1.6956	1.6991	1.5261	.8779	.9339	1.086	1.0802
Max	2.6292	2.5019	2.5206	2.5206	2.6673	2.2291	2.4863
Min	.9945	1.0288	.8779	.8779	.8684	.9431	.9602
Avg	1.6749	1.6619	1.4948	1.4595	1.4289	1.4229	1.4563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 202 / 11KV Mategaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7316	.6173	.2987	.3429	.3048	.1524
2	.583	.7682	.6173	.2801	.3429	.2743	.1524
3	.583	.7682	.6173	.2801	.3429	.2743	.1715
4	.6173	.823	.6173	.3361	.4001	.3086	.1905
5	.6516	.9511	.7716	.3734	.4001	.4115	.2286
6	.7202	.9877	.9259	.4108	.4001	.5144	.2858
7	.4191	.3361	.2286	.3734	.4572	.5335	.3048
8	.3429	.3361	.1715	.3734	.3429	.381	.2
9	.3048	.3361	.1715	.7682	.7373	.6173	.8573
10	.2614	.1429	.2987	.9831	.823	.5658	.8356
11	.2241	.1429	.2987	1.0322	.8916	.5144	.8356
12	.2241	.2572	.2987	.9831	.8573	.823	.8139
13	.1867	.1143	.2987	.8848	.823	.7716	.6882
14	.1867	.1143	.2614	.7373	.8573	.6859	.7045
15	.2241	.1143	.2614	.7373	.7888	.7202	.639
16	.2614	.0953	.2987	.7373	.7545	.6859	.7373
17	.2614	.0953	.2241	.2858	.1905	.0953	.2858
18	.3361	.1429	.2801	.2858	.2286	.1143	.2858
19	.4108	.2	.3921	.3429	.4572	.1905	.4001
20	.4108	.2	.3921	.3429	.4191	.2	.4572
21	.823	.8745	.3734	.3429	.3429	.1905	.4572
22	.8779	1.0288	.3361	.3429	.3048	.1715	.4572
23	.7682	.8573	.3361	.3429		.1715	.4572
24	.6173	.7316	.6859	.2987	.3429	.3772	.1715
Max	.8779	1.0288	.9259	1.0322	.8916	.823	.8573
Min	.1867	.0953	.1715	.2801	.1905	.0953	.1524
Avg	.4547	.4646	.4073	.5073	.5151	.4124	.4487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 203 / 11KV Dhondalgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.9511	.823	.3734	.362	.3086	.1715
2	.823	.9877	.823	.3734	.362	.3086	.1905
3	.823	.9877	.8573	.4108	.4572	.2743	.3601
4	.823	1.0608	.8916	.5228	.4954	.3086	.2191
5	.9259	1.0974	.9431	.7095	.5716	.6173	.2858
6	1.0288	1.1523	1.0802	.7842	.7811	.7373	.6859
7	.7621	.7468	.7202	.8029	.8192	.8192	.7716
8	.6097	.5415	.5658	.5601	.6287	.6478	.5487
9	.381	.4481	.3944	1.134	.8987	.9945	1.0117
10	.2987	.1715	.2987	.9175	.8916	.9602	.9831
11	.2054	.1524	.2054	.9831	.8745	.8402	.8684
12	.1867	.1048	.2054	.8192	.8745	.8573	.852
13	.2241	.1048		.8848	.823	.8402	.8848
14	.2241	.1048		.8192	.7888	.8573	.8684
15	.2801	.1048		.8192	.823	.8402	.8684
16	.8124	.1048	.2054	.7865	.8745	.9088	.8848
17	.3921	.1143	.2614	.2096	.1905	.1048	
18	.4481	.1619	.3734	.3239	.2667	.1334	.2858
19	.5415	.2667	.5415	.5716	.4763	.2477	.5335
20	.5228	.2667	.4668	.4954	.5335	.4458	.5716
21	1.0425	.9259	.3921	.4191	.4382	.2	.4763
22	1.1706	.9774	.3547	.4382	.4191	.2	.4191
23	1.0425	.8745	.3361	.362	.3429	.1905	.381
24	1.2651	.9511	.8402	.3547	.2286	.3086	.181
Max	1.2651	1.1523	1.0802	1.134	.8987	.9945	1.0117
Min	.1867	.1048	.2054	.2096	.1905	.1048	.1715
Avg	.6516	.5567	.5514	.6198	.5926	.5396	.5784



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 205 / 11KV TADPIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.307	1.1488	.9511	.8356	.7202	1.0802
2	1.3336	1.3443	1.2003	.9877	.8356	.7202	1.046
3	1.2955	1.3817	1.2346	1.0608	.9831	.7545	1.0288
4	1.3717	1.4563	1.3546	1.134	.9831	.7888	1.0631
5	1.6385	1.8671	1.6632	1.3169	.9831	1.0631	1.2689
6	1.7909	2.0351	1.749	1.3717	1.2289	1.2689	1.406
7	1.829	1.9978	1.8519	1.7924	1.6004	1.7147	1.5775
8	1.406	1.7924	1.5261	1.5684	1.3908	1.3336	1.3717
9	.9907	1.134	1.1145	1.2883	1.105	1.1431	1.1831
10	1.0608	1.2517	1.1157	.9145	.6859	.7545	.8764
11	1.2071	1.286	1.0974	.724	.6859	.5316	.6668
12	1.2437	1.2003	1.2071	.5906	.6097	.5316	.5716
13	1.2254	1.2003	1.0974	.6859	.5716	.6001	.6097
14	1.2437	1.046	1.0059	.6668	.5716	.583	.5906
15	1.2803	1.1317	.9877	.7049	.5716		.6668
16	1.2986	1.1317	1.134	.6097	.6668	.5144	.6478
17	1.1203	.6001	.5975	.6478	.6097	.6173	.7049
18	1.1576	.8059	.8215	.8383		.8059	.8002
19	1.4563	1.406	1.2136	1.4289	1.2346	1.3375	1.4861
20	1.4937	1.4575	1.3256	1.448	1.2689	1.4403	1.467
21	1.4003	1.2689	.9145	.9831	.7716	1.2346	
22	1.3817	1.1488	.9877	1.065	.7202	1.3717	1.1961
23	1.3443	1.2003	1.0059	.9339		1.2517	.9995
24	1.166	1.307	1.1488	.9511	.8684	.4191	1.1317
Max	1.829	2.0351	1.8519	1.7924	1.6004	1.7147	1.5775
Min	.9907	.6001	.5975	.5906	.5716	.4191	.5716
Avg	1.3307	1.3232	1.1876	1.0277	.8992	.9348	1.0192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 201 / TOWN-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3475	.3429	.0329	.3547	.3429	.0329
2	.3429	.3292	.3429	.3841	.3292	.3429	.0384
3	.3429	.3475	.3429	.0444	.3658	.3429	.0439
4	.3772	.4108	.3772	.0476	.3734	.4115	.053
5	.4115	.4668	.4115	.0554	.4024	.4801	.0585
6	.5487	.5975	.5144	.0567	.5228	.5487	.0658
7	.6173	.6535	.583	.0591	.6348	.6935	.695
8	.583	.6348	.6001	.0585	.6348	.6516	.6348
9	.5853	.6584	.5144	.6348	.583	.5144	.6219
10	.5228	.583	.0348	.5975	.5144	.0441	.5487
11	.4481	.5487	.0348	.4854	.4458	.0476	.5121
12	.4755	.5144	.0384	.4481	.4458	.0402	.4572
13	.4481	.4458	.0329	.3921	.3772	.0439	.4024
14	.4108	.4458	.0329	.362	.3429	.0329	.3734
15	.3696	.3772	.0366	.3547	.3429	.0348	.3734
16	.5228	.3429	.0439	.3734	.3429	.0348	.4024
17	.5487	.3429	.053	.4108	.4115	.0384	.4108
18	.5487	.3772	.0512	.3658	.4115	.0476	.5121
19	.6161	.4801	.0512	.5121	.5144	.0512	.5853
20	.5544	.4801	.0439	.5121	.4801	.0476	.5853
21	.6161	.4458	.0476	.5121	.4458	.0549	.4755
22	.4294	.3772	.0439	.439	.3772	.0439	.3982
23	.3921	.3429	.0402	.4108	.3772	.0402	.4108
24	.3429	.3658	.3429	.0329	.3734	.3429	.0366
Max	.6173	.6584	.6001	.6348	.6348	.6935	.695
Min	.3429	.3292	.0329	.0329	.3292	.0329	.0329
Avg	.4749	.4548	.2066	.3159	.4335	.2197	.3637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 202 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1269	1.1888	1.2136	.1201	1.307	1.3523	.1061
2	1.1443	1.1888	1.2136	.128	1.2803	1.3523	.1035
3	1.1443	1.2071	1.2136	.1353	1.2986	1.387	.1478
4	1.2136	1.251	1.3321	.1405	1.3817	1.4373	.1589
5	1.3523	1.3817	1.4373	.1626	1.4937	1.4723	.1663
6	1.7337	1.5364	1.6651	.1774	1.7924	1.7177	.1885
7	1.9765	1.9753	1.9281	.1885	2.1313	2.1033	.1848
8	1.8724	1.9753	1.6827	.1922	1.9231	1.7177	1.9791
9	1.7177	1.8671	1.5083	1.4632	1.5257	1.4022	1.5684
10	1.4449	1.5604	.1317	1.4937	1.387	.1441	1.4266
11	1.475	1.491	.1257	1.4632	1.3003	.1244	1.3169
12	1.3256	1.491	.1134	1.3169	1.2483	.1207	1.419
13	1.2254	1.3003	.1061	1.2136	1.1789	.128	1.3443
14	1.1888	1.2483	.1183	1.1576	1.2136	.139	1.2323
15	1.2323	1.1443	.1294	1.0974	1.2136	.1244	1.2323
16	1.3443	1.0402	.1427	1.1706	1.2136	.1134	1.3256
17	1.4563	1.1096	.1405	1.2803	1.335	.1353	1.2986
18	1.4632	1.3176	.1368	1.4632	1.387	.161	1.4998
19	1.6278	1.6297	.15	1.7558	1.6297	.1829	2.0725
20	1.6057	1.6297	.1536	1.7551	1.5604	.2012	1.829
21	1.5684	1.4563	.1463	1.643	1.5604	.1756	1.6991
22	1.5844	1.4217	.1427	1.6095	1.4563	.1536	1.6244
23	1.3535	1.2483	.1317	1.4563	1.3523	.1097	1.5497
24	1.1789	1.251	1.2136	.1257	1.2986	1.3523	.1035
Max	1.9765	1.9753	1.9281	1.7558	2.1313	2.1033	2.0725
Min	1.1269	1.0402	.1061	.1201	1.1789	.1097	.1035
Avg	1.4315	1.4130	.6782	.9462	1.4362	.7212	1.0657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 203 / Town 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2987	.3086	.0293	.2926	.3429	.0366
2	.2743	.2926	.3086	.0293	.2987	.3429	.0329
3	.2743	.3206	.1715	.0329	.3109	.3429	.0439
4	.3086	.3292	.3429	.0439	.3361	.3772	.0476
5	.3772	.3921	.3772	.0549	.3734	.4115	.0549
6	.4801	.6535	.4458	.0665	.5975	.4801	.0658
7	.5487	.8048	.6068	.0585	.695	.6173	.0695
8	.6001	.6584	.583	.6722	.7095	.6516	.7095
9	.6348	.7842	.6001	.6348	.6516	.6001	.6219
10	.567	.703	.0549	.6036	.5144	.0585	.6219
11	.4755	.703	.0512	.5601	.4801	.0476	.5853
12	.4668	.6859	.5853	.5601	.4458	.0402	.5041
13	.3395	.5316	.0476	.4668	.3429	.0512	.4108
14	.3292	.4115		.4108	.3429	.0329	.3361
15	.3547	.3772		.3361	.3429	.3921	.3361
16	.3475	.3086	.0517	.3734	.3429	.5788	.439
17	.4024	.3772	.0549	.4108	.4458	.5975	.4854
18	.5853	.5144	.0604	.5487	.5487	.6348	.5601
19	.5853	.5487	.0604	.5975	.6001	.7282	.5487
20	.5121	.4458	.0585	.5121	.4115	.6584	.4854
21	.3921	.3429	.0658	.4207	.4115	.5601	.5041
22	.4108	.3429	.0439	.4108	.3772	.4108	.4294
23	.3841	.3086	.0384	.3734	.3429	.3361	.4108
24	.2743	.3292	.3086	.0305	.3292	.3429	.0329
Max	.6348	.8048	.6068	.6722	.7095	.7282	.7095
Min	.2743	.2926	.0384	.0293	.2926	.0329	.0329
Avg	.4250	.4777	.2376	.3432	.4393	.4015	.3489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 204 / Town 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4024	.4115	.0402	.4294	.4115	.0439
2	.4115	.4108	.4115	.0384	.4294	.4115	.0384
3	.4115	.4207	.4115	.0476	.439	.4458	.0402
4	.4801	.4481	.4458	.0549	.439	.4801	.0476
5	.5144	.439	.4801	.0622	.4854	.5144	.0549
6	.5487	.5853	.5144	.0591	.6161	.5144	.0658
7	.6516	.6219	.6173	.0585	.7095	.6173	.0695
8	.583	.695	.583	.0591	.7095	.6001	.6584
9	.5788	.7468	.5487	.6036	.4294	.5487	.6348
10	.6584	.6859	.0658	.6401	.6173	.0695	.7842
11	.6584	.6859	.0622	.6908	.6173	.0658	.7468
12	.6584	.6173	.0585	.6584	.583	.0622	.6584
13	.6584	.583	.0517	.6036	.583	.0585	.6722
14	.5975	.5487	.0549	.5975	.5487	.0512	.6584
15	.695	.5144	.0476	.5975	.5487	.0549	.6722
16	.6224	.4458	.0439	.5975	.583	.5601	.6219
17	.6584	.4801	.0549	.6348	.5487	.0658	.6348
18	.7468	.5487	.0628	.6348	.6173	.0841	.7095
19	.7682	.6516	.0549	.5853	.7545	.0768	.7682
20	.7095	.583	.0622	.695	.6859	.0695	.695
21	.6161	.5487	.0549	.6219	.6516	.0658	.5853
22	.5601	.4801	.0512	.5487	.5144	.0549	.5975
23	.4854	.4458	.0476	1.2986	.4458	.4755	.5228
24	.4115	.439	.4115	.0384	.4481	.4115	.0384
Max	.7682	.7468	.6173	1.2986	.7545	.6173	.7842
Min	.4115	.4024	.0439	.0384	.4294	.0512	.0384
Avg	.5873	.5428	.2337	.4361	.5598	.2821	.4591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 205 / Ritthi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.9387	2.1132	.1967	.5228	.5658	.0441
2	1.7528	2.0165	2.1132	.1933	.5121	.5658	.0373
3	1.7528	1.9387	2.1132	.1899	.1494	.5658	.053
4	1.8804	1.749	2.1491	.217	.5304	.6413	.0509
5	1.97	1.8656	2.1491	.2289	.5853	.679	.0713
6	1.97	2.1948	2.1849	.2408	.6036	.679	.7095
7	2.6863	.2926	.3772	.0475	.6722	.7167	.0644
8	2.955	.2987	.3772	.0407	.6036	.5281	.5228
9	2.6063	.3292	.4527	.4108	2.0774	2.364	2.3339
10	.4108	.4527	.0373	.4207	2.6505	3.1367	2.9264
11	.4527	.5093	.0402	.4481	3.152	2.9995	3.0247
12	.415	.5658	.0439	.5228		.6173	3.0247
13	.439	.6602	.0384	.5415		2.915	2.8349
14	.5601	.6413	.0348	.5415		2.8292	2.4177
15	.5975	.6413	.0329	.5487			2.6406
16	.6348	.6036	.0384	.5121	2.9797		.2572
17	.6722	.6413	.0549	.5601		.3921	.2801
18	.6219	.6413	.0622	.4481		.5121	.4904
19	.6584	.6036	.0476	.6722	.6602	.5853	.6584
20	.5228	.5281	.0509	.6219	.679	.6348	.6219
21	1.4563	1.4373	.1427	.4755	.6413	.5853	.5853
22	1.7924	2.1491	.1628	.5487	.6036	.5121	.5975
23	1.8671	2.1132	.1865	.5601	.6036	.5121	.6161
24	1.7909	1.7833	2.1132	.2125	.5415	.5658	.0439
Max	2.955	2.1948	2.1849	.6722	3.152	3.1367	3.0247
Min	.4108	.2926	.0329	.0407	.1494	.3921	.0373
Avg	1.3424	1.1081	.7132	.3917	1.0427	1.0956	1.0378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 206 / Industrial

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0732	.1006	.0129	.1097	.0671	.0091
2	.0671	.0732	.0838	.0128	.1097	.0671	.0091
3	.0671	.0732	.0838	.0148	.1097	.0838	.0091
4	.0671	.0747	.0838	.0148	.1097	.0838	.011
5	.0671	.168	.1006	.0111	.128	.1006	.0128
6	.0838	.1097	.1006	.0085	.0914	.1006	.0146
7	.0857	.1463	.0838	.0055	.0732	.0838	.0128
8	.1029	.1097	.1006	.0092	.0914	.1006	.1097
9	.1463	.1097	.1174	.1463	.0838	.1341	.168
10	.2614	.1006	.0185	.1829	.0671	.1494	.2378
11	.112	.0838	.0183	.2195	.0671	.1867	.2012
12	.128	.0671	.0219	.2926	.0671	.2378	.1829
13	.1494	.0838	.0222	.2743		.2378	.1829
14	.1494	.0838	.0238	.2561		.1494	.1867
15	.1463	.0671	.0256	.1646			.1829
16	.1494	.0671	.0259	.1867	.0335		.1463
17	.1494	.0838	.0222	.2054	.0671	.1829	.1867
18	.1097	.0838	.0165	.1494	.0671	.1132	.2012
19	.1463	.1341	.0129	.1097	.0838	.1097	.1463
20	.1463	.1341	.0185	.112	.1006	.1307	.168
21	.1646	.1341	.0185	.112	.1006	.1867	.128
22	.1463	.1006	.0129	.112	.0671	.1646	.0914
23	.1307	.1006	.0129	.0914	.0671	.128	.1097
24	.0671	.0732	.1006	.0119	.112	.0671	.0091
Max	.2614	.168	.1174	.2926	.128	.2378	.2378
Min	.0671	.0671	.0129	.0055	.0335	.0671	.0091
Avg	.1213	.0973	.0511	.1132	.0860	.1303	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 201 / 11KV NAGAD AG(WITH SDT)      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.9433	1.7147	.4001	.5335	.4001	.4191
2	1.8671	1.9052	1.7147	.4191	.5525	.381	.4191
3	1.8671	2.0576	1.7337	.4572	.5525	.4191	.4572
4	1.8671	2.0005	1.7147	.4954	.5335	.4572	.4954
5	1.9052	2.0195	1.829	.6097	.5525	.4572	.5335
6	2.0195	2.2481	1.9052	.6478	.5335	.4763	.6097
7	.4954	.5716	.3239	.6859	.5335	.5335	.6859
8	.5144	.5335	.4191	.7049	.5335	.4572	.6668
9	.5335	.5716	.381	1.9814	2.2862	2.1719	2.2481
10	.4572	.5335	.4001	2.0957	2.3053	2.2291	2.2862
11	.5144	.5335	.5335	2.4958	2.3624	2.2862	1.9052
12	.5525	.5335	.5716	2.4768	2.4387	2.2862	2.191
13	.5335	.5335	.5335	2.2481	2.3815	2.2672	2.1338
14	.5525	.5335	.4763	2.191	2.3053	2.2481	2.0957
15	.5335	.5335	.4954	2.2862	2.2672	2.2862	2.0767
16	.5716	.5335	.4763	2.3243	2.3243	2.191	2.1338
17	.5525	.5335	.5335	.5335	.4572	.4191	.5144
18	.5716	.5335	.6668	.5335	.5335	.4382	.5716
19	.5525	.5335	.6668	.5335	.5144	.5335	.5335
20	.5716	.5335	.6859	.5335	.5335	.5906	.5525
21	1.9624	1.9052	.5716	.5335	.5335	.5716	.5335
22	1.9814	1.9052	.5525	.5335	.4954	.5716	.5716
23	2.0005	1.9052	.5144	.5335	.4572	.5525	.5144
24	2.7892	1.9052	1.9052	.4001	.5525	.4191	.4572
Max	2.7892	2.2481	1.9052	2.4958	2.4387	2.2862	2.2862
Min	.4572	.5335	.3239	.4001	.4572	.381	.4191
Avg	1.1498	1.1392	.8883	1.1106	1.1280	1.0685	1.0669



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 202 / 11KV SAIGAWN AG (WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.3624	2.0957	.724	.5335		.724
2	2.0957	2.4196	2.0957	.6097	.5335		.724
3	2.0957	2.4958	2.1338	.6097	.5525		.7811
4	2.1529	2.4577	2.21	.6859	.5525		.8192
5	2.1719	2.1338	2.2291	.7621	.5525		.8573
6	2.2291	2.6863	2.2862	.8573	.5525		.8573
7	.4954	.5525	.5335	.8954	.5525		.8383
8	.5144	.5716	.5335	.8573	.5335		
9	.5335	.5525	.5335	1.7528	2.6673	3.0483	
10	.5335	.5335	.9335	2.2862		3.2388	2.0386
11	.5525	.5335	.6097	2.5911		3.2579	2.2862
12	.5716	.5335	.5525	2.6292	3.5627	3.2769	3.0293
13	.5335	.5525	.4572	2.6482	3.8104	3.315	3.0674
14	.5144	.5335	.5335	2.6673	3.6389	3.2769	3.0483
15	.5525	.5335	.5335	2.8578	3.658	3.2388	3.1436
16	.5716	.5335	.5335	3.2769	3.5818	3.2388	2.934
17	.5335	.5335	.4572	.5335	.5335	.724	.5716
18	.5525	.5335	.4191	.5335	.5525	.8383	.5525
19	.5144	.5335	.724	.5525	.5335	.9145	.5335
20	.5716	.5335	.8383	.5335		.9717	.5716
21	1.9052	1.7718	.8764	.5335		.9526	.5335
22	2.2862	1.9052	.9145	.5525		.9145	.5144
23	2.3624	1.9052	.9145	.5335		.9335	.5525
24	1.9814	2.4006	1.9814	.8573	.5335		.8573
Max	2.3624	2.6863	2.2862	3.2769	3.8104	3.315	3.1436
Min	.4954	.5335	.4191	.5335	.5335	.724	.5144
Avg	1.2035	1.2543	1.0804	1.3059	1.5242	2.1427	1.3562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 203 / 11 KV BELKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.3048	.2096	.8002	1.1431	1.105	1.1431
2	.1905	.2667	.2286	.8192		1.0669	1.1622
3	.1715	.2286	.2477	.8573	1.2384	1.1622	1.2193
4	.1905	.2286	.3048	1.1431	1.3336	1.2003	1.3336
5	.2096	.2667	.3429	1.3336	1.4098	1.2574	1.4289
6	.2667	.3048	.381	1.5242	1.8671	1.6766	1.5051
7	.3429	.3429	.381	.1905	.381	.2667	.2286
8	.3048	.3048	.381	.2667	.4001	.3048	.2096
9	1.105	1.2193	1.3146	.3048	.4572	.3048	.1715
10	1.5432	1.6385	1.829	.3239	.2667	.2858	.1524
11	1.7147	1.9052	2.0005	.3048	.3429	.3048	.1905
12	2.2862	1.9814	2.2672	.3048	.3048	.362	.2477
13	2.1338	2.0576	2.0957	.2858	.381	.362	.3048
14	1.848	1.9052	2.0005	.2667	.3429	.362	.362
15	1.6956	1.8861	1.8099	.2858	.3429	.381	.4001
16	1.6385	1.848	1.7337	.3048	.3429	.3429	.4191
17	.381		.2286	.3239	.3048	.3048	.4191
18	.2858		.2667	.3429	.3429	.2667	.4382
19	.2477		.2667	.381	.2858	.3048	
20	.3048		.2477	.3048	.2858	.2858	.2858
21	.3239		.5716	.9526	1.0479	.9907	.6287
22	.2858	.2096	.6668	1.1431	1.105	1.1431	1.1431
23	.2096	.1905	.724	1.1812	1.105	1.2193	
24	.1905	.2096	.2096	.7621	1.1812	1.086	1.2384
Max	2.2862	2.0576	2.2672	1.5242	1.8671	1.6766	1.5051
Min	.1715	.1905	.2096	.1905	.2667	.2667	.1524
Avg	.7525	.9105	.8629	.6128	.7049	.6811	.6651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 204 / 11kv Nagad gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1715	.2096	.1905	.1905	.2096
2	.1905	.1524	.1334	.2096	.1905	.1905	.2096
3	.2096	.2477	.1334	.2477	.2096	.1715	.2477
4	.2477	.2858	.1334	.3048	.2286	.2096	.3048
5	.3239	.3239	.1905	.381	.2667	.3048	.3429
6	.4763	.381	.381	.4191	.4954	.3429	.381
7	.5716	.4763	.4763	.4572	.4763	.381	.4191
8	.4382	.4191	.381	.381	.4191	.4191	.381
9	.2858	.3429	.3048	.3429	.362	.3429	.3239
10	.2477	.2667	.3239	.2667	.2477	.2667	.2477
11	.1905	.2096	.2858	.1905	.1905	.2667	.2096
12	.2096	.2667	.2286	.2096	.1905	.2477	.1905
13	.1715	.1715	.2096	.2286	.1905	.2096	.2096
14	.1905	.1715	.2096	.2477	.1715	.1905	.1715
15	.1905	.1715	.2286	.2667	.2096	.1715	.1905
16	.2096	.1715	.2286	.2477	.2096	.1905	.2096
17	.2477	.2096	.2477	.3048	.2096	.2286	.1715
18	.3429	.3048	.3048	.381	.2477	.3048	.2667
19	.4001	.381	.3429	.4001	.381	.381	.4191
20	.381	.3429	.362	.3429	.381	.4191	.3429
21	.3239	.2858	.3048	.3048	.2858	.381	.381
22	.2858	.2667	.2667	.2477	.2667	.3429	.2286
23	.2286	.2286	.2286	.2096	.2096	.2477	.1905
24	.3982	.1905	.2096	.2096	.2096	.1905	.2096
Max	.5716	.4763	.4763	.4572	.4954	.4191	.4191
Min	.1715	.1524	.1334	.1905	.1715	.1715	.1715
Avg	.2897	.2675	.2620	.2921	.2683	.2747	.2691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 205 / 11kv Belkheda gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1334	.1905	.1524	.2096	.1715	.1715
2	.1715	.1334	.1905	.1524	.1905	.1524	.1715
3	.1524	.2096	.2096	.1905	.2286	.1905	.1905
4	.1905	.2477	.2286	.3048	.2286	.2096	.2667
5	.2477	.3048	.3048	.381	.2667	.3048	.3429
6	.4191	.362	.381	.4191	.381	.4572	.4572
7	.5525	.5525	.4954	.4572	.5144	.5335	.5144
8	.4382	.4382	.4191	.381	.4763	.4191	.381
9	.3429	.3239	.3429	.2858	.3429	.2667	.3048
10	.2477	.1905	.1905	.1905	.1715	.1715	.1715
11	.1715	.1715	.1524	.1334	.1143	.1143	.1524
12	.1524	.1334	.1143	.0953	.1143	.0953	.1143
13	.1334	.0953	.1143	.0953	.1143	.0953	.1143
14	.1143	.0953	.0953	.1143	.0953	.1143	.1334
15	.1334	.0953	.1143	.1334	.1143	.1334	.1334
16	.1524	.1334	.1334	.1524	.1143	.1524	.1334
17	.2286	.3048	.1715	.3048	.1524	.1715	.1715
18	.3429	1.5051	.2477	.362	.2667	.2477	.2858
19	.381	.381	.2667	.381	.362	.3239	.362
20	.3048	.3048	.2096	.4001	.381	.2858	.3239
21	.2286	.2286	.1905	.2286	.2477	.2286	.381
22	.1905	.2667	.1715	.1905	.2096		.2096
23	.1715	.3048	.1524	.1905	.1524	.1715	.1905
24	.1715	.1524	.2667	.1524	.1905	.1524	.1715
Max	.5525	1.5051	.4954	.4572	.5144	.5335	.5144
Min	.1143	.0953	.0953	.0953	.0953	.0953	.1143
Avg	.2421	.2945	.2231	.2437	.2350	.2245	.2437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 206 / 11kv saigawan gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.3048	.2286	.2096	.2096	.2096
2		.1715	.3239	.2286	.2286	.1905	.2096
3	.2096	.2477	.3429	.2667	.2477	.2477	.2667
4	.2477	.2858	.362	.3429	.2667	.3048	.3429
5	.3048	.3429	.381	.4191	.2858	.3429	.4001
6	.4572	.4382	.5335	.4954	.381	.4954	.4954
7	.5335	.5716	.5716	.5335	.5716	.4954	.5716
8	.4954	.4954	.4191	.4572	.4763	.381	.4572
9	.3048	.4572	.381	.381	.4001	.2477	.381
10	.2858	.2286	.2286	.2667	.2096	.2096	
11	.2286	.2096	.1905	.1715	.1905	.1905	.2096
12	.1905	.1905	.1905	.1905	.1715	.1905	.1905
13	.1715	.1905	.1905	.1715	.1524	.1905	.1905
14	.1524	.1715	.1715	.1715	.1905	.2096	.1524
15	.1524	.1524	.1905	.1905	.1905	.2096	.1715
16	.1715	.1524	.1905	.2096	.1905	.2096	.2096
17	.3239	.2667	.2096	.3048	.2667	.2286	.2286
18	.381	.4191	.2667	.381	.3048	.2667	.3429
19	.4191	.381	.3048	.4191	.4572	.381	.4001
20	.3429	.4001	.362	.3048	.4954	.3429	.381
21	.2667	.3048	.3048	.2667	.3048	.3048	.4191
22	.2096	.2667	.2667	.2286	.2667	.2286	.2477
23	.2096	.2286	.2286	.2096	.2096	.2096	.2286
24	.1905		.2286	.2286	.1905	.2096	.2096
Max	.5335	.5716	.5716	.5335	.5716	.4954	.5716
Min	.1524	.1524	.1715	.1715	.1524	.1905	.1524
Avg	.2800	.2924	.2977	.2945	.2858	.2707	.3007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 201 / 11 KV NADARPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.6668				
8			.5525	.5847		.4763	
11						.8573	
12	.1509						
14	.132						
15						.9145	
16					.9335		.7811
17						.3048	
19		.381					.362
22						.1905	
23	1.2003						
24			.6668				.1524
Max	1.2003	.381	.6668	.5847	.9335	.9145	.7811
Min	.132	.381	.5525	.5847	.9335	.1905	.1524
Avg	.4944	.381	.6287	.5847	.9335	.5487	.4318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 202 / 11 KV PISHOR Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.3169		1.467	
11						.5716	
12	.6219						
14	.5788						
15						.4954	
16					.4954		.5144
17						.5525	
19		.8954					.9907
22						.8192	
24			.6097				.5716
Max	.6219	.8954	.6097	1.3169	.4954	1.467	.9907
Min	.5788	.8954	.6097	1.3169	.4954	.4954	.5144
Avg	.6004	.8954	.6097	1.3169	.4954	.7811	.6922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 203 / 11kv KOLAMBI AG WITH SDT SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4382	.4382		.4572	
11						.1905	
12	1.643						
14	1.2384						
15						.2286	
16					.2667		.2286
17						.2858	
19		.2667					.3048
22						1.3146	
24			.2286				1.2384
Max	1.643	.2667	.4382	.4382	.2667	1.3146	1.2384
Min	1.2384	.2667	.2286	.4382	.2667	.1905	.2286
Avg	1.4407	.2667	.3334	.4382	.2667	.4953	.5906



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 204 / 11 KV RAMNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.381	.3961		.4382	
11						.8002	
12	.1886						
14	.2075						
15						.6097	
16					.7049		.5716
17						.1524	
19		.362					.3048
22						.2286	
24			.6668				.1715
Max	.2075	.362	.6668	.3961	.7049	.8002	.5716
Min	.1886	.362	.381	.3961	.7049	.1524	.1715
Avg	.1981	.362	.5239	.3961	.7049	.4458	.3493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 205 / 11kv Nadarpur gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.1524			
9					.1524	
11					.0381	
12	.0554					
14	.0549					
15					.0381	
16				.0381		.0381
17					.0572	
19		.1334				.1143
22					.0572	
24			.0381			.0191
<b>Max</b>	<b>.0554</b>	<b>.1334</b>	<b>.1524</b>	<b>.0381</b>	<b>.1524</b>	<b>.1143</b>
<b>Min</b>	<b>.0549</b>	<b>.1334</b>	<b>.0381</b>	<b>.0381</b>	<b>.0381</b>	<b>.0191</b>
<b>Avg</b>	<b>.0552</b>	<b>.1334</b>	<b>.0953</b>	<b>.0381</b>	<b>.0686</b>	<b>.0572</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 206 / 11KV Palashi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 207 / 11KV KOLAMBI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.381		.4382	
11					.1334	
12	.1478					
14	.1646					
15					.1143	
16				.1143		.1334
17					.2096	
19		.4191				.4382
22					.1715	
24			.1334			.1524
Max	.1646	.4191	.381	.1143	.4382	.4382
Min	.1478	.4191	.1334	.1143	.1143	.1334
Avg	.1562	.4191	.2572	.1143	.2134	.2413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 202 / 11 KV WAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5173	.5173	1.5261	1.2069	1.0345	1.0837	1.2003
2	.5173	.6897	1.6556	1.2069	1.2069	1.4449	1.0288
3	.6897	.6897	2.0485	1.3794	1.3794	1.7242	1.2003
4	.8621	.8621	1.9867	1.3794	1.3794	1.8966	1.3717
5	.8592	1.0345	2.3179	1.3748	1.8966	2.069	1.5432
6	1.0345	1.0345	2.5434	1.8966	1.8966	2.069	1.5432
7	1.0345	1.0345	2.4834	1.7242	1.0345	1.0345	1.0288
8	1.0345		1.0174	1.0345	1.0345	1.0345	.8583
9		1.3656	.8535	.515	.8621	.8621	.6866
10		1.1456	.6783		.8621	.6897	
11	1.0345	1.3047	.5173	.515	.6897	.515	
12	1.2069	1.3047	.5173	.3433	.5418	.3433	
13	1.3794	1.1416	.3448	.3433	.5173	.3433	
14	1.3794	.9819	.3448	.3433	.5173	.3433	.1724
15	1.7242	1.1456	.5173	.3433	.3448	.515	.1717
16	1.8966		.5173	.515	.3448	.515	.3433
17	.8621	1.1589	.9934	.515	.515	.6866	.515
18	.8621		.8278	.6897	.6866	.8583	.6866
19	1.0345	.9819	1.0174		.8621	.9441	.8583
20	1.0345	1.1589	1.0345	.8621	.8621	.8573	.8583
21	1.0345	.8535	.8621	.8621	1.1207	1.0288	.8621
22	.8621	.9934	.8621		1.0345	1.2003	.6897
23	.8621	1.0242	.6897	.6897	1	1.286	.6897
24	.5173	.5173	1.1869	1.2069	.5235	.5418	1.286
Max	1.8966	1.3656	2.5434	1.8966	1.8966	2.069	1.5432
Min	.5173	.5173	.3448	.3433	.3448	.3433	.1717
Avg	1.0109	.9971	1.1393	.9022	.9228	.9953	.8797

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 204 / 11 KV TAKLI (A)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5345	.8276	.6443	.8669	1.0114	1.4828	.6936
2	.7931	.8793	.6291	.9211	1.5533	1.6255	.6429
3	.8276	1.0114	.78	1.0114	1.6552	1.9145	.8121
4	.8793	1.0837	.8609	1.2298	1.9867	2.2757	.8797
5	.9656	1.1017	.9437	1.5093	2.1854	2.0951	.9813
6	1.069	1.2643	1.0584	1.3727	2.2757	1.9867	1.032
7	1.0518		1.0596	1.2282	1.0114	1.0114	1.0997
8	.9656		.9603	.9753	.9211	.9392	.9687
9	.5862	1.17	.5121	.4079	.7405	.6502	.5948
10	.6207	1.0852	.39	.3059	.5098	.4419	.3056
11	.6897	1.0174	.3251	.2549	.4419	.3059	.1698
12	.7069	.9835	.2069	.2209	.3059	.2719	.1358
13	.8793	1.0174	.1724	.2039		.1699	.1358
14	.9656	.9768	.1806	.2379		.1529	.1698
15	1.0483	.9819	.219	.2379	.1699	.1699	.1698
16	1.0518	.9934	.289	.2719	.1699	.2039	.2716
17	.6207	.6783	.7209	.3059	.3399	.2719	.3056
18	.8276	.5464	.7616	.4655	.5438	.3909	.4928
19	.8793	.7285	.8113	.8966	.7931	.7987	.9347
20	.8276	.8817	.8276	.8621	.7069	.6804	.7817
21	.5345	.78	.7069	.7225	.6502	.6472	.7587
22	.5173	.7285	.6552	.6552	.6141	.7168	.7069
23	.4828	.7122	.6207	.6141	.5418	.7633	.5173
24	.4483	.6207	.5765	.6863	.6897	.8761	.7613
Max	1.069	1.2643	1.0596	1.5093	2.2757	2.2757	1.0997
Min	.4483	.5464	.1724	.2039	.1699	.1529	.1358
Avg	.7822	.9123	.6213	.6860	.9008	.8684	.5968

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 205 / 11 KV Wadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6552	.6502	.7285	1.9145	1.2282		.8639
2	.5862	.8669	.7947	1.9867	1.77	1.9867	.8473
3	.6207	.9211	.8609	2.1674	1.9867	2.0951	.9636
4	.7069	1.0114	.9437	2.366	2.4202	2.1312	1.0633
5	.9656	1.1017	.9934	2.5466	2.4563	2.1674	1.1463
6	1.1035	1.1535	1.0474	2.9982	2.2757	2.1854	1.1962
7	1.1017	1.2462	1.043	2.7092	1.1017	1.1017	1.1169
8	.9656	1.0174	.8734	2.7092	1.0114	1.0114	1.0002
9	.6863	1.1258	.3914	.4334	.3612	.5599	.6335
10	.7405	1.192	.3146	.3001	.289	.4696	.4334
11	.8669	1.2548	.2167	.2167	.1745	.3612	.3001
12	1.0114	1.1589	.1445	.15	.1445	.289	.1667
13	.5599	1.1869	.1806	.1667	.1445	.1806	.1667
14	1.192	1.17	.1804	.1667	.1445	.15	.2
15	1.1017	1.153	.2167	.15	.1806	.1667	.2
16	1.0476	1.0513		.1834	.1806	.1667	.1834
17	.7405	.6291	.7947		.3334	.2	.2334
18	1.0114	.5132	.8113	.3793	.4668	.4001	.5335
19	1.0645	.6622	.9603	.9934	.9934	.8169	.9669
20	1.0114	.8817	.9211	.8489	.7586	.6811	.8169
21	.9211	.7828	.9031	.7947	.8202	.7476	.8282
22	.6863	.8365	.8669	.7405	.7405	.7974	.7405
23	.6502	.8648	.7405	.6495	.7225	.8971	.7202
24	.4828	.5418	.6457	.8669	.8669	.8669	.9137
Max	1.192	1.2548	1.0474	2.9982	2.4563	2.1854	1.1962
Min	.4828	.5132	.1445	.15	.1445	.15	.1667
Avg	.8533	.9572	.6771	1.1495	.8988	.8882	.6765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 206 / 11 KV NEW NEVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9197	1.9197	.9156	.5759	.6283	.6283	.4773
2	2.1674	2.2687	1.0174	.5934	.6849	.6981	.5727
3	2.1989	2.4607	1.0596	.6283	.8377	.8377	.6522
4	2.2687	2.8116	1.1755	.8377	.89		.8591
5	2.5413	2.897	1.2914	1.0471	1.0093	1.0645	.9863
6	2.7225	3.3333	1.3411	1.082	1.0994	1.0122	1.1136
7	2.7923	.89	1.4569	1.0645	1.0122	1.0471	1.2409
8	2.8097	.5463	1.0889	.9773	.9773	.9773	1.1454
9	.6283	.424	2.649	2.3115	1.7452	1.6754	2.0363
10	.4537	.3973	2.649	2.3907	2.343	2.1291	2.0424
11	.3141	.2168	2.8272	2.5015	2.4432	2.0907	2.0265
12	.2792	.298	2.9319	2.5648	2.5654	2.2687	2.0582
13	.2269	.2283	2.9842	2.549	2.7273	2.1532	2.0582
14	.2094	.2713	3.0715	2.4223	2.7225	2.0899	2.074
15	.1802	.3052	3.1587	2.3748	2.9079	2.0265	2.1532
16	.1802	.3311	2.8097	2.264	2.3734	1.9315	1.8524
17	.6283	.5256	.7947	.2533		.3008	.35
18	.9075	.5935	.8817	.4712	.5091	.4932	.5409
19	.9773	.8278	.9326	.9249	.9075	.7	.8591
20	.6632	.9326	.89	.8377	.7504	.7636	.875
21	1.0645	.7616	.8377	.6108	.5759	.6522	.89
22	1.1174	.6788	.6981	.5934	.5235	.5727	.8019
23	1.1867	.5629	.6283	.5585	.5235	.4932	.7155
24	1.5008	1.3263	.7461	.5585	.5235	.4886	.4613
Max	2.8097	3.3333	3.1587	2.5648	2.9079	2.2687	2.1532
Min	.1802	.2168	.6283	.2533	.5091	.3008	.35
Avg	1.2474	1.0754	1.6182	1.2914	1.3600	1.1780	1.2018



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 201 / 11 KV NACHANWEL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1886	.1715	.1715	.2572	.3429
2	.1143	.1715	.2829	.1715	.1715		.3429
3	.2572	.2572	.2829	.1715	.1715	.3429	.5144
4		.2572	.2829	.2572	.3429	.3429	
5	.2572	.3429	.3429	.3429	.4287	.5144	.6859
6	.3429	.4287	.4287	.3429	.5144	.6859	.7716
7	.3429	.4287	.5144	.4287			
8	.1715	.4287	.3429	.3429			
9	.1715		.2572	.3429			
10		.5144	.3429	.3429			
11	.3429	.5144	.2572	.3429			
12	.4287	.5144	.3429	.3429			
13	.4287	.4287	.3429	.3429	.1715	.1715	
14	.3429	.4287	.3429	.3429	.1715	.1715	.1143
15	.3429	.3429	.3429	.3429	.0171	.1715	.1715
16	.3429	.2572	.3429	.3429	.1715	.1715	.1715
17	.2572	.1715	.1715	.1715	.2572	.1715	.1715
18	.1715	.1715	.1715	.2572	.3429	.2572	.1715
19	.2572	.1715	.3429	.2572	.2572	.3429	.2572
20	.2572	.1715	.2572	.2572	.2572	.3772	.2572
21	.2572	.2572	.1886	.1715	.2572	.1886	.2572
22	.2572	.1715	.1886	.2572	.1715	.1886	.1715
23	.1715	.1715	.1886	.2572	.1715	.2829	.1715
24	.1886	.1715	.1886	.1886	.2572	.2829	
Max	.4287	.5144	.5144	.4287	.5144	.6859	.7716
Min	.1143	.1715	.1715	.1715	.0171	.1715	.1143
Avg	.2671	.3019	.2890	.2829	.2391	.2895	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 202 / 11 KV DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1715	.1886	.1715	.1715	.1715	.0857
2	.1143	.1715	.1886	.1715	.0857	.1715	.0857
3	.1715	.2572	.1886	.1715	.0857	.2572	.0857
4	.2572	.2572	.2829	.2572	.1715		
5		.3429	.4287	.2572		.2572	.1715
6	.2572	.4287	.5144	.3429	.3429	.3429	.2572
7					.3429	.3429	.1715
8					.2572		.1715
9					.1715	.1715	.1715
10					.2572	.1715	.2572
11					.3429	.1715	.2572
12					.3429	.1715	.3429
13	.0857	.0857	.0857	.0857	.3429	.1715	.1715
14	.0857	.1715	.0857	.0857	.1715	.1715	.1715
15	.1715	.1715	.0857	.0857	.1715	.1715	.1715
16	.1715	.1715	.0857	.0857	.1715	.1715	.1715
17	.1715	.1715	.1715	.0857	.0857	.0857	.0857
18	.2572	.1715	.1715	.0857	.1715	.0857	.0857
19	.1715	.1715	.2572	.1715	.1715	.1715	.0857
20	.1715	.0857	.2572	.1715	.1715	.1715	.1715
21	.1715	.1715	.1886	.0857	.1715	.1886	.1715
22	.1715	.1715	.1886	.0857	.1715	.0943	.1715
23	.1715	.1715	.1886	.0857	.1715	.1886	.0857
24	.1886	.1715	.1886	.1886	.0857	.1886	
Max	.2572	.4287	.5144	.3429	.3429	.3429	.3429
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1708	.1953	.2081	.1486	.2013	.1859	.1637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 203 / 11 KV SAROLA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1886	.1715	.1715	.0943	.1143
2	.1715	.1715	.1886	.1715	.1715	.1715	.1143
3		.1715	.2829	.2572		.2572	
4	.2572	.2572	.3772	.3429	.2572	.4287	.1715
5	.3429	.4287	.5144	.3429	.3429	.5144	.2572
6	.3429	.5144	.6859	.4287	.4287		.8573
7					.3429	.2858	.3429
8					.3429	.3429	.2286
9					.1715	.2572	.1715
10					.2572	.1715	.2572
11					.3429	.1715	.2572
12					.3429	.1715	.1715
13	.1715	.1715	.0857	.1715	.3429	.1715	.2572
14	.1715	.1715	.1715	.1715	.1715	.1715	
15	.1715	.2572	.1715	.1715	.1715	.1715	.1143
16	.2572	.1715	.1715	.1715	.1715	.1715	.1715
17	.2572	.1715	.1715	.1715	.0857	.1715	.1715
18	.3429	.2572	.1715	.2572	.1715	.1715	.1715
19	.2572	.1715	.2572	.2572	.1715	.2572	.2572
20	.1715	.1715	.2572	.2572	.2572	.2572	.3429
21	.1715	.2572	.1886	.1715	.1715	.1886	.2572
22	.1715	.1715	.1886	.1715	.1715	.1886	.1715
23	.2572	.1715	.1886	.1715	.1715	.1886	.1715
24	.1886	.1715	.1886	.1886	.1715	.0943	
Max	.3429	.5144	.6859	.4287	.4287	.5144	.8573
Min	.1715	.1715	.0857	.1715	.0857	.0943	.1143
Avg	.2280	.2239	.2472	.2248	.2348	.2204	.2395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 204 / 11KV DONGARGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0943	.0857	.0857	.0857	.0572
2	.0857	.0857	.0943	.0857	.0857	.0857	.0857
3	.1715	.0857	.0943	.1715	.0857	.0857	.1715
4	.3086	.1715	.1715	.1715		.1715	
5	.2572	.1715	.2572	.2572	.2572	.1715	.2572
6	.1715	.3429	.3429	.2572	.3429		.2572
7		.3429	.3429	.3429	.3429	.3429	
8	.2572	.3429	.2572	.2572	.2572	.2572	.1715
9	.1715	.2572	.1715	.1715	.1715		.1715
10		.1715	.0857	.0857	.1715	.0857	.1715
11	.1715	.0857	.0857	.0857	.0857	.0857	.1715
12	.0572	.0857	.0857	.0857	.0572	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0572
14	.0857	.0857	.0857	.0943	.0857	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.1715	.0857	.0857	.0857	.0857	.0857	.0857
17	.1715	.0857	.0857	.0857	.0857	.0857	.0857
18	.2572	.0857	.0857	.1715	.0857	.0857	.0857
19	.3429	.1715	.1715	.1715	.1715	.1715	.1715
20	.2572	.2572	.1886	.2572	.2572	.1886	.2572
21	.0857	.1715	.1886	.1715	.0857	.0943	.0857
22	.0857	.0857	.0943	.0857	.0857	.0943	.0857
23	.0857	.0857	.0943	.0857	.0857	.0943	.0857
24	.18	.0857	.0943	.0943	.0857	.0943	
Max	.3429	.3429	.3429	.3429	.3429	.3429	.2572
Min	.0572	.0857	.0857	.0857	.0572	.0857	.0572
Avg	.1651	.1500	.1429	.1472	.1404	.1231	.132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 205 / 11 kv NACHANWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1886	.1715	.1715	.1143	.1143
2	.1715	.1715	.1886	.1715	.1143	.1143	
3	.2572	.1715	.1886	.2572	.2572	.1715	.2572
4		.4287	.4715	.3429	.3429	.3429	.8573
5	.5144	.6001	.6001			.4001	.6001
6	.6859	.7716	.8573	.6001	.7716	.6859	.5144
7	.8573	.8573	.8573	.7716	.8573	.8573	.5716
8	.6859	.7716	.6859	.6859	.7716	.6859	.4572
9	.6859	.6001	.6001	.5144	.4001	.6001	.4572
10	.2286	.4287	.4287	.4287	.5144		.5144
11	.2858	.3429	.2572	.2572	.2572	.1715	.4287
12	.2572	.2572	.1715	.1715	.2572	.1715	.2572
13	.2572	.1715	.1715	.1715	.1143	.1715	
14	.2572	.1715	.1715	.1715	.1715	.1715	.1715
15	.3429	.1715	.1715	.1715	.1715	.1715	.2572
16	.4287	.1715	.1715	.1715	.2572	.1715	.2572
17	.4287	.2572	.2572	.1715	.2572	.2572	.2572
18	.5144	.4287	.3429	.4287	.3429	.3429	.3429
19	.7716	.7716	.5144	.6001	.6001	.6001	.6859
20	.6001	.6859	.6602	.5144	.7716	.6602	.5144
21	.3429	.4287	.3772	.3429	.3429	.3772	.3429
22	.2572	.2572	.2829	.2572	.2572	.2829	.2572
23	.1715	.1715	.1886	.1715	.1715	.1886	.1715
24	.1886	.1715	.1886	.1886	.1715	.1886	
Max	.8573	.8573	.8573	.7716	.8573	.8573	.8573
Min	.1715	.1715	.1715	.1715	.1143	.1143	.1143
Avg	.4071	.3930	.3747	.3362	.3628	.3434	.3946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 206 / 11 kv SAROLA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0857	.0943	.0857	.0857	.0572	.0857
2	.0857	.0857	.0857	.0857	.0857	.0572	.0857
3	.1715	.0857	.0857	.1715	.1715	.0857	
4	.2572	.1715	.1715	.2572	.2572		.2572
5	.3429	.3429	.2572	.3429	.3429	.3429	.3429
6		.5144	.4287	.4287	.4287	.5144	.5144
7	.5144	.5144	.4287	.4287	.5144	.5144	.3429
8		.5144	.3429	.4287		.4287	
9	.4287	.4287	.3429	.3429	.3429	.3429	.3429
10	.2572	.2572	.1715	.1715	.3429	.1715	.2572
11	.1715	.1715	.0857	.1715	.0857	.0572	.1715
12	.0857	.0857	.0857	.0857	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857	.0572	.0857	.0857
15	.1715	.0857	.0857	.0857	.0857	.0857	.0572
16	.2572	.1715	.0857		.1715	.0857	.0857
17	.3429	.1715	.0857	.0857	.1715	.0857	.0857
18	.4287	.1715	.1715	.2572	.1715	.1715	.1715
19	.5144	.4287	.2572	.3429	.4287	.3429	.2572
20	.4287	.3429	.3772	.2572	.4287	.3772	.3429
21	.2572	.2572	.1886	.1715	.1715	.2829	.1715
22	.1715	.1715	.1886	.1715	.1715	.1886	.1715
23	.0857	.0857	.0943	.1715	.0857	.0943	.0857
24	.0943	.0857	.0943	.0943	.0857	.0943	
Max	.5144	.5144	.4287	.4287	.5144	.5144	.5144
Min	.0572	.0857	.0857	.0857	.0572	.0572	.0572
Avg	.2407	.2250	.1825	.2091	.2112	.2017	.1946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 207 / MOHADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.2572	.0943	.0857	.0857	.0857	.0857
2	.0572	.1715	.1886	.0857	.0857	.0572	.0572
3	.0857	.1715	.1886	.1715	.0857		.0857
4	.1715	.2572	.2829	.1715	.1715	.1715	.0857
5		.3429	.3429	.2572	.1715	.1715	.1715
6	.1715	.2572	.4287	.2572	.2572	2.5892	.1715
7					.2572	.2572	.1143
8					.2572		
9					.1715	.1715	.1715
10					.1715	.1715	.2572
11					.1715	.1715	.2058
12					.1715	.1715	.2572
13	.0572	.0857	.0857	.0857	.1715	.1715	.2572
14	.0857	.0857	.0857	.0857	.1715	.1715	
15	.0857	.0857	.0857	.0857	.1715	.1715	.1143
16	.0857	.0857	.0857	.0857	.1715	.1715	.1715
17	.1715	.0857	.0857	.0857	.1715	.0857	.0857
18	.1715	.1715	.0857	.0857	.1715	.0857	.0857
19	.1715	.1715	.1715	.1715	.0857	.1715	.0857
20	.1715	.1715	.1886	.1715	.0857	.1715	.1715
21	.1715	.1715	.0943	.1715	.0857	.1886	.0857
22	.2572	.0857	.0943	.0857	.0857	.1886	.0857
23	.2572	.0857	.0943	.0857	.0857	.0943	.0857
24	.0943	.2572	.0943	.0943	.0857	.0943	
Max	.2572	.3429	.4287	.2572	.2572	2.5892	.2572
Min	.0572	.0857	.0857	.0857	.0857	.0572	.0572
Avg	.1384	.1667	.1543	.1291	.1500	.2629	.1377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 210 / MOHRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.0943	.1715	.1715	.1715	.1143
2		.1715	.1886	.1715	.1715	.1715	.1143
3	.1715	.1715	.1715	.1715	.1715	.1715	.1715
4	.1715	.2572	.2572	.2572		.3429	.3429
5	.3429	.2572	.2572	.2572	.2286	.5144	.3429
6	.3429	.3429	.3429	.2572	.3429	.6001	.6001
7	.3429	.4287	.4287	.3429			
8	.2572	.3429	.3429	.3429			
9	.2572	.3429	.2572	.3429			
10	.2572	.2572	.3429	.1715			
11		.2572	.3429	.1715			
12	.1715	.2572	.2572	.1715			
13	.2286	.2572	.1715	.1715	.1715	.0857	.0857
14	.2572	.3429	.1715	.1715	.1715	.0857	.0572
15	.3429	.2572	.1715	.1715	.1715	.0857	.0857
16	.3429	.3429	.1715	.1715	.1715	.0857	.0857
17	.2572	.2572	.1715	.1715	.0857	.1715	.0857
18	.2572	.1715	.1715	.1715	.1715	.1715	.1715
19	.2572	.2572	.2829	.1715	.2572	.2572	.3429
20	.3429	.2572	.3772	.2572	.3429	.1886	.2572
21	.1715	.1715	.1886	.1715	.2572	.1886	.1715
22	.1715	.1715	.1886	.2572	.2572	.1886	.1715
23	.0857	.1715	.1886	.2572	.1715	.1886	.1715
24	.1886	.0857	.0943	.1886	.2572	.1886	
Max	.3429	.4287	.4287	.3429	.3429	.6001	.6001
Min	.0857	.0857	.0943	.1715	.0857	.0857	.0572
Avg	.2450	.2501	.2347	.2151	.2101	.2143	.1984



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 201 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8907	.9602	.9602	.2561	.3239	.3239	.2721
2	1.1012	.9602	1.0402	.2561	.3239	.3239	.2721
3	1.0526	.9602	1.1203	.2881	.3239	.381	
4	1.1336	1.1203	1.5203	.3841	.381	.4763	.4801
5	1.166	1.4403	1.5203	.4801	.4763	.5716	.5281
6		1.8084	1.7284		.6287		
7				.6241	.6478		
8					.6668	.6287	
9	.5335	.4961	.5144	1.9204	1.2803	1.7604	1.6032
10	.5525	.4321	.4001	2.0805	1.5203	1.9204	1.749
11	.4001	.3841	.3201	2.1925	1.8244	2.1125	1.9595
12	.4191			2.1765	2.0965	1.9845	2.0081
13	.4763				2.0805	1.9204	1.8785
14	.4763		.4801	1.9919	2.0485	1.8404	1.7814
15	.4382	.2561	.4801	1.9433	1.9524	1.8084	1.7004
16	.4382	.3201	.4801	1.8623	1.9044		1.6194
17	.4954	.5144	.3841	.3048	.2096	.176	
18	.5716	.5525	.4641	.4001	.4572	.4161	.3086
19	.6668	.5716	.6241	.5716	.6287	.5441	.583
20	.4572	.5144	.4641	.5144	.5716	.4321	.463
21	.8002	.8002	.381	.5144	.362	.2881	.3429
22	.8002	.8802	.3361	.4191	.3429	.2881	.3086
23	.8802	.9602	.3201	.381	.3239	.2721	.3086
24	.8097	.9602	.9602	.3201	.381	.3239	.2721
Max	1.166	1.8084	1.7284	2.1925	2.0965	2.1125	2.0081
Min	.4001	.2561	.3201	.2561	.2096	.176	.2721
Avg	.6933	.7838	.7249	.9467	.9065	.8949	.9705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 202 / 11KV NIMBHORA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.2286	1.0669	1.1336	1.406	1.2955
2	.1905	.1905	.2286	1.0669	1.2146	1.406	1.2955
3	.1905	.2286	.2858	1.0669	1.2955	1.406	1.3717
4	.2286	.3048	.3239	1.2803	1.4575	1.4842	1.5203
5	.2858	.381	.381	1.4403	1.5384	1.6404	1.7604
6	.3429	.4001	.4954	1.5684	2.0957	1.7654	1.9204
7	.381	.4572		.3521	.3048	.4572	.381
8	.3048	.4572		.381	.3239	.381	.381
9	1.1336	1.4723	1.668	.2667	.2858	.3429	.2915
10	1.4575	2.0805	1.9271	.1905	.2286	.1905	.2572
11	1.6356	2.2405	2.0805	.1905	.1905	.1905	.1715
12	1.8461	2.2405	2.0805	.1524	.1905	.1905	
13	2.6673	2.0805	2.0005		.1905	.1905	
14	2.5911	1.9204	1.9204	.1143	.2096	.1524	
15	2.572	2.0805	2.0005	.1524	.2477	.1524	
16	2.2862	2.572	2.0005	.1524	.2667	.1905	.1715
17	.2858	.2096	.2286	.1905	.2667	.1524	.2401
18	.3429	.362	.1905	.2286	.2667	.1905	.2058
19	.2477	.381	.3048	.3239	.381	.3048	.3086
20	.1905	.3239	.2286	.3239	.2477	.2667	.2401
21	.1905	.2858	.8573	1.1431	.8583	1.2574	1.1317
22	.1905	.2477	1.0212	1.0526	1.4575	1.6194	1.4575
23	.1905	.2286	1.0212		1.5432	1.2955	1.3765
24	.1905	.1905	.2286	1.0212	1.1336		1.2955
Max	2.6673	2.572	2.0805	1.5684	2.0957	1.7654	1.9204
Min	.1905	.1905	.1905	.1143	.1905	.1524	.1715
Avg	.8671	.8969	.9865	.6239	.7220	.7232	.8537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 203 / 11KV DEVPUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.8002	.8907	.9602	.9602
2	.1905	.1905	.2286	.8002	.8802	.9602	.9602
3	.2286	.2286	.2667	.8802	.9602	.9602	.9602
4	.2858	.3048	.3048	.9602	1.1203	.9602	1.0402
5	.381	.381	.381	1.1203	1.2003	1.0402	1.0402
6	.381	.4382	.4001	1.2003	1.5242		1.1203
7	.4572	.4572	.4001	.4481	.381	.4954	.3201
8	.4572	.3521		.3841	.3429	.2858	.3841
9	.9069	1.2803	1.0364	.381		.2721	.3429
10	.7773	1.6004	1.0526	.1905	.1524	.128	.2743
11	1.2146	1.6004	1.1203	.1143	.1143	.1524	.2058
12	1.1336	1.5203	1.2003	.1143	.1143	.192	
13	1.2146	1.5203	1.3603		.0953	.192	.2743
14	1.2803	1.5546	1.3603	.1524	.1524	.192	.2743
15	1.2003	1.5203	1.3603	.1715	.1524	.192	.2743
16	1.0402	1.5203	1.4403	.1715	.16	.3201	.3429
17	.2477	.1524	.192	.1905	.2286		.3429
18	.381	.2858	.192	.2286	.3239	.192	.4115
19	.381	.3239	.3201	.3048	.4572	.3201	.3601
20	.3048	.2667	.2561	.2286	.3239	.2561	.3429
21	.2286	.2286	.6401	.9526	.6478	.8642	.8573
22	.1905	.1905	.8002	.8802	.3048	1.2003	.9431
23	.1905	.1905	.8002	.8802	.9602	.9602	1.0288
24	.7716	.1905	.1905	.8002	.8802	.9602	.9602
Max	1.2803	1.6004	1.4403	1.2003	1.5242	1.2003	1.1203
Min	.1905	.1524	.1905	.1143	.0953	.128	.2058
Avg	.5848	.6870	.6736	.5372	.5377	.5480	.6096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 204 / 11 KV MEHGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.5716	.0953	.0762	.0762	.0762
2		.6668	.5716	.0762	.0762		.0762
3		.5716	.6668	.0762	.0762	.0762	.0762
4		.6668	.7621	.1143	.0762	.1143	.1143
5		.7287	.9526	.1334	.1143	.1334	.1334
6		.9069	.8259	.1905	.1524	.1524	.1905
7		.1524	.1715	.2286	.1715	.1715	.2286
8		.1334	.1715	.1905	.1905	.1524	.2096
9		.1334	.1143	.8907	1.1431	.6836	.6316
10		.1143	.2858	1.1336	1.0526	.9145	.7287
11		.1524	.1905	1.247	1.2955	1.1812	.8097
12		.1143	.0762	1.2631	1.1012	.9907	.8421
13		.1334	.0762	1.2186	1.0526	.9602	.9393
14	.0953	.1334	.1143	1.2146	1.0526	.9145	.9393
15	.0953	.1143	.1334		1.0202	.9145	.8907
16	.0762	.1334	.1334	1.166	.945	.8993	.8097
17	.1905	.0953	.1143	.0762	.0953	.1143	.0686
18	.2286	.1524	.1143	.0953	.1334	.1524	.0857
19	.1905	.1143	.2286	.1524	.1524	.1905	.1372
20	.1905	.1143	.1524	.1143	.1143	.1524	.12
21	.381	.381	.1524	.0953	.0762	.1143	.0857
22	.381	.4763	.1334	.0762	.0762	.0953	.0857
23	.4763	.5716	.1143	.0762	.0762	.0762	.0686
24	.381	.4763		.0762	.0762	.0762	.0762
Max	.4763	.9069	.9526	1.2631	1.2955	1.1812	.9393
Min	.0762	.0953	.0762	.0762	.0762	.0762	.0686
Avg	.2442	.3214	.2968	.4348	.4332	.4046	.3510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 205 / 11KV NIMBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0762	.0762	.0762	.0572
2	.0572	.0762	.0762	.0762	.0762	.0762	.0572
3	.0953	.0762	.1143	.0953	.0762	.0762	.0953
4	.1143	.1143	.1524	.1524	.1143	.1143	.1143
5	.1524	.1524	.1905	.1905	.1905	.1715	.1905
6	.2096	.2096	.2096	.2286	.2286	.2096	.2286
7	.2667	.2477	.2477	.2667	.2667	.2477	.2667
8	.2477	.2286	.2286	.2096	.2286	.1905	.2286
9		.1715	.1524	.1715	.1905	.1524	.1715
10		.1143	.0953	.1143	.1143	.1143	.12
11	.0953	.1143	.0953	.0572	.0762	.0762	
12	.0953	.0762	.0953	.0572	.0572	.0762	
13		.0572	.0762	.0572	.0572	.0572	
14	.0953	.0572	.0572	.0572	.0572	.0572	
15	.0953	.0572	.0572	.0572	.0762	.0572	
16	.0953	.0572	.0572	.0953	.0953	.0572	.0514
17	.1143	.0762	.0572	.0953	.0953	.0762	.0514
18	.1905	.0953	.1524	.1143	.1334	.1715	.12
19	.1715	.1905	.1905	.1905	.2096	.1905	
20	.1334	.1334	.1524	.1524	.1334	.1905	.1372
21	.0953	.0953	.1143	.1524	.0762	.0953	.0857
22	.0762	.0953	.0953	.1143	.0762	.0762	.0686
23	.0762	.0762	.0762	.0762	.0762	.0762	.0514
24	.0572	.0762	.0762	.0762	.0762	.0762	.0762
Max	.2667	.2477	.2477	.2667	.2667	.2477	.2667
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0514
Avg	.1234	.1135	.1207	.1223	.1191	.1151	.1207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 206 / 11KV WASADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0762	.0762	.0762	.0762	.0762
2	.0953	.0762	.0762	.0762	.0762	.0762	.0762
3	.0953	.0762	.0762	.1143	.1143	.0953	.0953
4	.1143	.0953	.1334	.1524	.1524	.1334	.1143
5	.1524	.1715	.2096	.1905	.1905	.1905	.1905
6	.2667	.2096	.2477	.2477	.2286	.2286	.2477
7	.2858	.2667	.2858	.2858	.2858	.2477	.2858
8	.2858	.2477	.2477	.2667	.2286	.1905	.2477
9	.2096	.1905	.2096	.1905	.1905	.1905	.1543
10	.1715	.1905	.1524	.1334	.1524	.1524	.12
11	.1334	.1524	.1334	.1334	.1143	.0953	.1029
12	.1524			.1143	.0572	.0953	.0686
13	.0953			.0953	.0762	.0953	.0514
14	.0953		.0953	.1334	.0762	.0953	.0686
15	.1524	.1143	.0953	.0953	.0953	.0953	.0686
16	.0953	.1334	.0953	.0953	.0953	.0953	.0857
17	.1524	.1334	.1334	.1143	.1143	.1143	.0514
18	.2096	.1334	.1524	.1905	.1524	.1524	.1029
19	.2096	.1905	.2286	.1905	.2096	.1905	.1886
20	.1905	.1524	.1905	.1143	.1715	.1905	.1543
21	.1524	.1143	.1143	.0762	.0953	.0953	.0857
22	.1143	.1143	.0953	.0762	.0762	.0953	.0857
23	.0762	.0762	.0762	.0762	.0762	.0953	.0686
24	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Max	.2858	.2667	.2858	.2858	.2858	.2477	.2858
Min	.0762	.0762	.0762	.0762	.0572	.0762	.0514
Avg	.1540	.1424	.1455	.1381	.1326	.1318	.1195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 207 / 11KV MEHGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1143	.1143	.1143	.1143	.1143
2	.0953	.0953	.1143	.1143	.1143	.1143	.1143
3	.1524	.1905	.1905	.1905	.1905	.1905	.1143
4		.3048	.3048	.3048	.3048	.3048	.1905
5	.381	.4191	.381	.381	.381	.381	.381
6	.5144	.5144	.4954	.5335	.4763	.5144	.5716
7	.5906	.5906	.5716	.6287	.5716	.6097	.6097
8	.1715	.4954	.4572	.5716	.3429	.5335	.5525
9	.4001	.362	.3239	.381	.2286	.3429	.3429
10	.3048	.2667	.2096	.3048	.1143	.2477	.2058
11	.2096	.1715	.1524	.1715		.1334	.1715
12	.1715	.1334	.0953	.0762	.0953	.0762	
13	.0953	.1334	.0953	.0762	.0953	.0953	.0857
14	.1524	.1334	.1143	.0762	.0953	.0953	.0857
15	.2477	.1334	.1143	.0953	.0953	.1143	.0857
16	.2096	.1524	.1143	.0953	.1143	.1143	.12
17	.3048	.1905	.1143	.1143	.1715		.1372
18	.4001	.1905	.2096	.1715	.2667	.3048	.2058
19	.4001	.3048	.4954	.3048	.4382	.4572	.3772
20	.3239	.381		.3429	.3429	.4001	.2915
21	.2286	.3048	.3429	.2858	.1715	.1905	.1715
22	.1905	.2477	.1524	.2096	.1715	.1715	.1029
23	.1524	.1715	.1143	.1524	.1143	.1524	.1029
24	.0953	.0953	.1143	.1143	.1143	.1143	.1143
Max	.5906	.5906	.5716	.6287	.5716	.6097	.6097
Min	.0953	.0953	.0953	.0762	.0953	.0762	.0857
Avg	.2560	.2532	.2344	.2421	.2228	.2510	.2282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 201 / 11 KV KARANJKHEDA AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0686	.0857	.0953	.7716	.8097	.7926
2	.0953	.0686	.0857	.0953	.8573	.8421	.7926
3	.0953	.0857	.0857	.1143	.9602	.8916	.7926
4	.0953	.0857	.0857	.1143	.9602	.8907	.7926
5	.1143		.0857	.1143	1.0288	.9393	.7926
6	.1143	.0857	.1029	.0953	1.2003	.9393	.9297
7	.1143	.0686	.0514	.0762			
8	.0953	.0686	.0514	.0762			
9	.6478	.7287	.8097	.9393			
10	.7611	.9717	1.085				
11	1.0117	1.166	1.2146	1.1145			
12		1.3927	1.4251				
13	1.4746	1.3927	1.4251	1.1831	.0343		.0191
14		1.2955	1.3927		.0343	.0381	.0381
15	1.5432	1.2955	1.2146	1.2003	.0343	.0381	.0191
16		1.3441	1.2146		.0343	.0162	.0191
17	.0686	.0343	.0381	.0686	.0343	.0381	.0191
18		.0514	.0572		.0343	.0572	.0191
19	.0857	.0514	.0762	.1029	.0514	.0762	.0762
20		.0686	.0762		.0686	.0572	.0762
21	.0686	.0686	.0762	.6859	.6478	.5944	.4877
22		.0857	.0762		.7287	.7621	.6859
23	.0857	.0857	.0953	.823	.7773	.823	.7164
24	.0953	.0686	.0857	.0953	.8573	.8097	.823
Max	1.5432	1.3927	1.4251	1.2003	1.2003	.9393	.9297
Min	.0686	.0343	.0381	.0686	.0343	.0162	.0191
Avg	.3701	.4623	.4582	.4114	.5064	.5072	.4384



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 202 / 11 KV NAGAPUR AG ( WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1372	.12	.1494	.6516	.664	.5792
2	.1494	.1543	.12	.1494	.6687	.664	.5792
3	.168	.1543	.1372	.1494	.6687	.7125	.5639
4	.1867	.1715	.1886	.168	.6859	.7449	.5487
5	.2054	.1886	.2229	.1867	.6859	.6964	.5335
6	.2241	.1715	.2229	.2427	.703	.6802	.6401
7	.2614	.2229	.2058	.2427			
8	.2427	.2058	.2058	.2241			
9	.3725	.6478	.5992	.583			
10	.5506	.7773	.6478				
11	.6859	.8907	.8745	.9259			
12		.9878	.9717				
13	.8916	1.004	.8745	.8573	.0514		.0373
14		.9717	.7449		.0514	.0934	.056
15	.8745	.8097	.6964	.703	.0514	.0934	.0914
16		.7125	.7449		.0686	.0934	.112
17	.1543	.0686	.0747	.0686	.1372	.0934	.1494
18		.1029	.112		.1886	.1307	.2241
19	.1372	.1543	.1867	.1715	.2058	.1867	.2614
20		.1715	.2054		.2058	.2241	.2614
21	.1715	.12	.1494	.4801	.4696	.503	.3963
22		.12	.1307		.5365	.6097	.5792
23	.1715	.12	.1307	.583	.6154	.6401	.5639
24	.1307	.1543	.12	.1494	.6173	.664	.6097
Max	.8916	1.004	.9717	.9259	.703	.7449	.6401
Min	.1307	.0686	.0747	.0686	.0514	.0934	.0373
Avg	.3182	.3841	.3619	.3550	.4035	.4408	.3770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 203 / 11 KV PURANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.823	1.0688	.7621	.1029	.1372	.1494
2	.7316	.8573	1.085	.7621	.12	.1372	.1494
3	.7621	1.0117	1.1336	.7621	.12	.1372	.1494
4	.7621	1.2003	1.166	.7773	.12	.1372	.1494
5	.7926	1.286	1.2793	.8078	.12	.1372	.1494
6	.9145	1.7147	1.2146	1.0059	.12	.1372	.1494
7						.12	.112
8					.0343	.1029	.112
9					.8916	1.2146	.9717
10					1.0562	1.5061	1.1431
11					1.4754	1.7004	1.4251
12		.0514			1.7772	1.6194	1.5384
13	.0686	.0514	.056		1.8442	1.5546	1.4575
14		.0686	.056		1.7604	1.4575	1.2955
15	.12	.0686	.056	.0857	1.6766	1.3927	1.0822
16		.0686	.0187		1.7101	1.3927	1.1584
17		.0686	.0187	.12	.0514	.056	.0187
18		.1029	.056		.0514	.056	.0187
19	.1372	.1029	.0934	.1372	.1029	.112	.1307
20		.1029	.112		.12	.1307	.1307
21	.7888	.9069	.6554	.1372	.12	.1494	.1494
22	.9602	.9717	.7621		.12	.1494	.1494
23	.9945	1.004	.7164	.12	.1372	.1494	.1494
24	.6859	1.0631	1.004	.7621	.1372	.1372	.1494
Max	.9945	1.7147	1.2793	1.0059	1.8442	1.7004	1.5384
Min	.0686	.0514	.0187	.0857	.0343	.056	.0187
Avg	.6500	.6066	.5862	.5200	.5987	.5760	.5037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 204 / 11kv KARANJKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2915	.3174	.3361	.3258	.3174	.3734
2	.4481	.3429	.3734	.3361	.3601	.3547	.4108
3	.4481	.4115	.4481	.3734	.4115	.3921	.4481
4	.5228	.5144	.7095	.4854	.4458	.4854	.5228
5	.7095	.823	.8402	.6535	.6344	.6908	.6908
6	.9522	1.0117	.9149	.8775	.8402	.8775	.9335
7	1.1389	1.1145	1.1016	1.0456	1.0117	1.0269	1.0829
8	.9335	1.0288	1.1389	.9522		.9896	.9335
9	.8215	1.0642	.9149	.8402	.7716	.8589	.7842
10	.7095	.8589	.7655		.7095	.7095	.6722
11	.5487	.7468	.7468	.5487	.7095	.5041	
12		.5601	.4481		.4108		
13	.3429	.3734	.3921	.2915	.3921	.4108	.5228
14		.3361	.3547		.3361	.3734	.4481
15	.3429	.3547	.3734	.2229	.3921	.2987	.112
16		.3921	.3921		.3734	.3547	.4668
17	.3429	.4108	.4854	.4458	.4108	.5041	.5975
18		.5415	.5975		.6722	.8215	.7468
19	.6687	.8775	.8402	.7888	.7655	.9522	.9709
20		.8962	.7095		.6908	.7095	.7842
21	.6516	.5601		.5144	.5041	.5415	.5601
22		.5788	.4294		.3921	.4668	.4481
23	.3772	.4108	.3734	.3429	.3361	.3921	.3921
24	.3547	.3601	.3921	.3361	.2915	.3174	.3734
Max	1.1389	1.1145	1.1389	1.0456	1.0117	1.0269	1.0829
Min	.3429	.2915	.3174	.2229	.2915	.2987	.112
Avg	.5927	.6192	.6113	.5524	.5299	.5804	.6034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 205 / 11KV REULGAON AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7716	.8097	.8078		.0343	.0381
2	.7316	.8573	.8421	.8078	.0343	.0343	.0381
3	.7316	.9431	.8907	.7926	.0171	.0343	.0381
4	.7468	1.0117	.9393	.7773	.0171	.0343	.0381
5	.7621	1.0288	.9717	.7773	.0343	.0343	.0381
6	.7621	1.2003	.9717	.8993	.0171	.0343	.0381
7					.0171	.0343	.0381
8					.0171	.0171	.0381
9					.5316	.9878	.9717
10					.5868	1.1984	1.1431
11				.0514	.6706	1.4251	1.3765
12					1.4754	1.5061	1.2955
13		.0171	.0191	.0343	1.4754	1.4251	1.4251
14		.0171	.0191		1.3748	1.4575	1.326
15	.0343	.0171	.0191	.0343	1.4083	1.2631	1.1584
16		.0171	.0191		1.4586	1.3117	1.1431
17	.0343	.0171	.0191	.0343	.0171	.0191	.0191
18		.0171	.0191		.0171	.0191	.0191
19	.0343	.0171	.0191	.0343	.0171	.0381	.0381
20		.0171	.0191		.0171	.0381	.0381
21	.5487	.664	.5792	.0343	.0171	.0381	.0381
22		.7287	.7926		.0171	.0572	.0381
23	.6516	.7287	.823	.0343	.0171	.0381	.0572
24	.7011	.7202	.7611	.823	.0171	.0171	.0381
Max	.7621	1.2003	.9717	.8993	1.4754	1.5061	1.4251
Min	.0343	.0171	.0191	.0343	.0171	.0171	.0191
Avg	.5392	.4884	.4741	.4245	.4031	.4624	.4346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 206 / CHIMNAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1715	.1867	.2054	.1715	.1867	.2054
2	.2427	.2058	.2241	.2241	.2058	.2241	.2241
3	.2801	.2401	.2614	.2614	.2401	.2427	.2614
4	.3361	.3086	.3361	.3174	.3086	.3361	.3174
5	.4481	.4115	.4481	.4108	.4458	.4854	.3921
6	.5601	.4801	.6161	.5975	.5316	.5601	.5415
7	.6161	.5658	.5975	.5788	.5487	.6161	.6348
8	.4481	.3944	.4481	.4668	.4801	.4854	.4668
9	.3547	.3547	.4108	.2241	.3772	.3921	.3547
10	.2614	.2614	.2801		.3361	.168	.2241
11	.1715	.1867	.168	.1886	.2054	.0934	.112
12		.1307	.112		.0934	.0934	.112
13	.12	.1307	.0934	.12	.112	.0747	.112
14		.1307	.112		.112	.0747	.0934
15	.12	.1307	.112	.1029	.1307	.0934	.0934
16		.1307	.1307		.1307	.0934	.112
17	.1372	.1867	.2054	.1543	.1886	.1307	.1867
18		.2614	.3361		.3174	.2987	.2801
19	.2401	.4481	.4854	.4458	.4481	.4668	.4668
20		.3361	.3921		.3547	.3734	.3429
21	.2915	.2614	.2801	.3258	.2614	.2987	.3174
22		.2054	.2614		.2427	.2427	.2614
23	.1886	.1867	.2241	.1715	.2054	.2241	.2427
24	.2054	.1543	.1494	.2054	.1543	.1867	.2054
Max	.6161	.5658	.6161	.5975	.5487	.6161	.6348
Min	.12	.1307	.0934	.1029	.0934	.0747	.0934
Avg	.2904	.2614	.2863	.2942	.2751	.2684	.2734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 201 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1145
Max	1.1145
Min	1.1145
Avg	1.1145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 203 / 11kV JAMADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 200 / 11 kv Narmada Express

Feeder Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	07-MAR-18
HR	Load (MW)
10	.5601
Max	.5601
Min	.5601
Avg	.5601



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 201 / 11 KV DEULGAON(BZ)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1509			.1509		.1509
2	.0934	.1886	.1509		.1886		.1886
3		.2263			.2263		.2263
4	.1478	.3018	.2829		.2829		.2829
5		.3395			.3772		.3395
6	.2218	.4904	.4904		.4715		.4715
7	.2804	.6036	.5658		.5658		.5658
8	.2715	.4715	.4715	.5658	.4715		.5281
9		.1886	.1638	.1494	.2195		.1886
10	.2829	.1448	.0648	.1663	.1802	1.773	.1372
11	.1509	.1578		.1372	.1638	.1267	
12		.1402	.0648	.0693	.1966	.124	.0791
13	.1509		.0655	.12	.2949	.104	
14	.1132	.1235	.0819	.104	.0819	.0857	.0848
15	.1132		.0655	.0867	.0983	.0848	
16		.1017	.0819	.0716	.0819	.0678	.0701
17	.3206		.081	.1509	.1526	.1509	
18	.3772	.2263		.2263	.1696	.2263	.2263
19	.3961			.3772	.1865		.3772
20	.415	.415		.415	.2035		.415
21	.3772			.3772	.2035		.1865
22	.3395	.2641			.2713		.2035
23	.2829	.2263			.3052		.2374
24	.0739	1.6598	.1886	.2263	.1698	.3391	.1509
Max	.415	1.6598	.5658	.5658	.5658	1.773	.5658
Min	.0739	.1017	.0648	.0693	.0819	.0678	.0701
Avg	.2369	.3379	.2014	.2162	.2381	.3082	.2555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 202 / 11 Kv Kotnandra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.2829			.4715		.5544
2		.2801	.3326		.5914		.6584
3	.7167	.3734			.724		.7602
4		.4066	.6219		.8954		.985
5	1.226	.5544			1.1568		1.1104
6		.9145	.9412		1.406		1.3523
7	1.6975	1.4712	1.5424		1.4146		1.6032
8	1.5466	1.3203	1.6975	1.1317	1.1317		1.5089
9		1.1694	1.2209	1.0374	1.0374		1.3203
10	1.226	.9431	.407	.9431	.3391	.4715	1.0374
11		.4904	.4409	.4715	.4409	.415	
12	.6001	.3772	.5087	.3772	.6104	.3772	.3018
13			.5087	.3772	.5087	.3395	
14	.5182	.3772	.5426	.3395	.5256	.2829	.3018
15			.6783	.2829		.2829	
16	.7186	.3018	.5087	.3018	.5087	.2641	.3395
17	.9054			.3772		.3772	
18	1.1317	.6602		.4527	.6443	.5658	.7545
19	1.4712			1.0562			1.0562
20	1.2449	1.4146		.7545			1.1317
21	.3395	.3658		.3772	.7537		.6554
22	.2829				.7373		.6882
23	.2641	.2957			.4915		.78
24	.415	.2263	.2772	.7545	.3772	.5079	.3772
Max	1.6975	1.4712	1.6975	1.1317	1.4146	.5658	1.6032
Min	.2641	.2263	.2772	.2829	.3391	.2641	.3018
Avg	.8725	.6434	.7306	.6023	.7383	.3884	.8638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 203 / 11 Kv Ghatnandra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	1.1317			1.1317		1.1203
2		1.226	1.1694		1.2449		1.2323
3	.6584	1.307			1.307		1.307
4		1.531	1.4335		1.4003		1.419
5	1.2696	1.6804			1.4712		1.531
6		1.7924	1.7353		1.6804		1.6804
7	1.7558	1.8298	1.8484		1.8298		1.8298
8	1.387	1.6057	1.6975	1.587	1.4937		1.6975
9		.8501	.7865	.724	.9412		1.086
10	1.4712	.8859	.9995	.8328	1.0159	.815	.7122
11		1.1317	1.0814	.787	1.0159	.8573	
12	.9431	1.3717	1.1142	.8429	1.153	.9835	.7287
13			1.0513	.8078	1.0159	.9389	
14	.8676	.9831	1.1191	.8124	1.1142	.8288	.7377
15			1.153	.8097	1.17	.7537	
16	1.1317	1.0159	1.3272	.6802	.8029	.7287	.8573
17	1.3817			1.0456	1.0513	1.094	
18	1.6804	1.3203		1.2883	1.1191	1.4335	1.5466
19	1.8298			1.8484	1.153		1.6804
20	1.8107	1.6975		1.6975	1.0513		1.7924
21	1.6975			1.8107	1.153		1.0174
22	1.5089	1.358			1.2039		1.0513
23	1.4335	1.1694			1.0174		1.1191
24	.4557	1.2449	1.094	1.2883	1.1317	1.0513	1.2323
Max	1.8298	1.8298	1.8484	1.8484	1.8298	1.4335	1.8298
Min	.4557	.8501	.7865	.6802	.8029	.7287	.7122
Avg	1.2791	1.3228	1.2579	1.1242	1.1945	.9485	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 204 / 11 KV SHINDEPHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.2263			.3395		.3734
2		.2829	.2896				.462
3	.8676	.3361			.5121		.5544
4		.4108	.4755		.6335		.6584
5	1.1694	.4668			.7522		.724
6		.5975	.7682		1.0517		.8954
7	1.4335	1.2826	1.3466		1.2449		1.4712
8	1.358	1.2449	1.358	.9431	1.1317		1.3203
9		1.1317	.9326	.7545	.9054		1.0562
10	1.0374	.7922	.4748	.6413	.6104	.5847	.5658
11		.4904	.407	.3772	.5087	.5281	
12	.4049	.3772	.4409	.3395	.4409	.4715	.2829
13			.5087	.3395	.3391	.415	
14	.3953	.3395	.5256	.3018	.407	.3772	.2829
15			.5087	.3395	.3391	.3395	
16	.4744	.415	.3222	.3018	.4239	.4715	.3772
17	.9997			.3772	.5087	.4904	
18	1.1317	.3018		.4904	.6104	.5093	.7922
19	1.2637			.7545	.6443		1.0562
20	1.1317	1.226		.8676	.5087		1.1317
21	.2829			.4715	.5243		.4915
22	.2263	.2587			.5243		.5898
23	.1886	.2926			.4915		.6226
24	.6036	.2263	.2772	.9431	.3395	.5079	.3395
Max	1.4335	1.2826	1.358	.9431	1.2449	.5847	1.4712
Min	.1886	.2263	.2772	.3018	.3391	.3395	.2829
Avg	.7961	.5631	.6168	.5495	.5996	.4695	.7024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 205 / 11 Kv Charner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.2829			.3395		.3772
2		.3772	.3395		.3772		.415
3	.823	.4715			.415		.4715
4		.6602	.5281		.4715		.6036
5	1.1222	.7545			.679		.7545
6		.9808	.9808		.7545		.8676
7	1.1142	.8676	.8488		.7922		.9619
8	1.2146	.7545	.7545	.679	.679		.7545
9		.4801	.7373	.6554	.7042		.5468
10	.4904	.5944	.8817	.703	.6882	.7407	.6859
11		.8802	1.0159	.8907	.7537	.7907	
12	.1509	1.0936	1.1191	.9646	.7461	.8749	.6241
13			.8097	.8383		.7621	
14	.2641	.743	.852	.873	.763	.6097	.6104
15			.6554	.6773	.7865	.5719	
16	.415	.9686	.78	.6923	.7537	.5647	.407
17	.5281			.1509	.5087	.1509	
18	.6036	.3018		.2263	.3391	.1886	.2829
19	.6602			.4715			.4715
20	.7545	.7922		.679	.6443		.5658
21	1.0562			.5658			.6443
22	.5658	.4715			.5243		.5087
23	.4715	.4527			.5087		.6104
24	.4572	.3772	.415	.8676	.4715	.5256	.3772
Max	1.2146	1.0936	1.1191	.9646	.7922	.8749	.9619
Min	.1509	.2829	.3395	.1509	.3391	.1509	.2829
Avg	.6597	.6476	.7656	.6623	.6048	.5780	.5770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 202 / 11Kv Undengaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.4252	.6219	.567	.5194	.285	.3506
2	.443	.4784	.695	.5138	.6154	.3185	.4207
3	.5138	.567	.7682	.6201	.9391	.4024	.5258
4	.6201	.9036	.8779	.8859	1.0517	.4862	.6733
5	.691	1.1999	1.0608	1.0808	1.1517	.6371	.7362
6	.8505	1.2403	1.3352	1.2757	1.3213	.7042	.8939
7	.9816	1.4899	1.2986	1.4706	1.5384	1.2803	1.5424
8	1.0808	1.382	1.262	.5373	1.2445	1.2254	1.134
9	.9671	.7499	.5533	.5959	.5373	.9694	1.0099
10	.7619	.8413	.5316	.5434	.5197	1.134	1.0277
11	.6135	.7377	.6733	.5201	.3856	.9036	
12	.5552	.6706	.6379	.5316	.4862	.8238	.9671
13	.5249	.5533	.7442	.5201	.4359	.7796	.8688
14	.7059	.5197	.7087	.5083	.4359	.6733	.7619
15	.7522	.503	.567	.4835	.5197	.6201	.691
16	.9214	.5197	.6201	.4607		.6836	.7343
17	.9465	.567	.5847	.543		.7442	.7602
18	1.0517	.695	.9036	.6379	1.0608	.8328	.7796
19	1.1393	.7042	1.1517	.8328	.9877	1.0277	1.1163
20	.9991	.8962	1.0099	.815	.9556	.6836	.9114
21	.691	.8048	.8589	.7442	.3658	.4908	.6733
22	.5959	.7499	.691	.7164	.3185	.4733	
23	.5258	.695	.6024	.631	.3018	.4207	.4887
24	.4031	.4908	.695	.5258	.5493	.3018	.3721
Max	1.1393	1.4899	1.3352	1.4706	1.5384	1.2803	1.5424
Min	.3721	.4252	.5316	.4607	.3018	.285	.3506
Avg	.7378	.7660	.8105	.6900	.7382	.7042	.7927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 203 / 11Kv Khedi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2126	.4024	.2658	.333	.439	.2454
2	.2454	.2658	.5197	.2804	.3045	.4755	.2804
3	.2804	.2865	.6874	.3544	.3681	.6219	.333
4	.0358	.3366	.6706	.567	.4508	.695	.5258
5	.4961	.4252	.7377	.6733	.5493	.8048	.5959
6	.7087	.5316	.7209	.7888	.6447	.9328	.7011
7	.9568	.7796	.7316	.9568	.7537	.9145	.9214
8	.6733	.7265	.695	.815	.7282	.8596	.5959
9	.4382	.6024	.695	.7087	.5493	.5533	.5609
10	.3721	.439	.4961	.4477	.3292	.691	.3721
11	.5434	.3292	.3721	.2126	.2378	.7796	.567
12	.5258	.2195	.2658	.2534		.7442	.6556
13	.5548	.2012	.2481	.2279		.6733	.6201
14	.5609	.2561	.2126	.1949		.6201	.591
15	.5375	.2378	.2303	.2103		.567	.5014
16	.5847	.2561	.2126	.2507		.7087	.443
17	.6024	.2926	.2658	.3189		.2835	.3189
18	.5609	.5487	.6836	.4163	.5853	.6485	.4784
19	.6733	.6371	.815	.7087	.6219	.7712	.7796
20	.5138	.4359	.631	.6626	.6401	.631	.7186
21	.3189		.333	.5609	.4938	.4207	.6626
22	.2658	.4024	.2835	.4961	.5487	.3506	.5493
23	.2126	.3521	.2629	.3988	.5487	.298	.4557
24	.2629	.1753	.3688	.2481	.3721	.5121	.2629
Max	.9568	.7796	.815	.9568	.7537	.9328	.9214
Min	.0358	.1753	.2126	.1949	.2378	.2835	.2454
Avg	.4640	.3891	.4809	.4591	.5033	.6248	.5307

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 207 / 11Kv Mandna feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.2658	.4024	.3189	.298	.2683	.2835
2	.3189	.3189	.4755	.3544	.3366	.3018	.2658
3	.3544	.3544	.567	.3366	.3582	.3688	.3544
4	.4252	.5316	.7682	.567	.5493	.4359	.4252
5	.5316	.7442	.9877	.815	.788	.4694	.5258
6	.6024	.9391	1.1157	.9568	1.0317	.5533	.6733
7	.691	.9745	1.0242	1.1163	1.0099	1.0059	1.0517
8	.815	.9568	1.0608	.9036	.9816	.9877	.9465
9	.7265	.5083	.5197	.7796	.4344	.8048	.7796
10	.4908	.4527	.6024	.5375	.3185	.3721	.4607
11	.2601	.4024	.5316	.4075	.3521	.3189	.3582
12	.2303	.3688	.4961	.3856	.4359	.1949	.2804
13	.2481	.4191	.443	.4119	.4191	.1772	.1595
14	.2507	.3018	.3721	.3189	.3521	.1949	.1254
15	.3189	.3521	.3366	.333	.3185	.1772	.1595
16		.3688	.3189	.3121	.3185	.1578	.2149
17	.7265	.3475	.2279	.3012		.1753	.3077
18	.6733	.6036	.7087	.2629	.3109	.6836	.6379
19	.815	.7316	.8682	.3121	.2926	.8413	.8939
20	.6733	.7499	.7087	.3544		.567	.7455
21	.567	.5487	.567	.394	.2378	.4252	.5493
22	.4784	.5121	.4784	.4207	.285	.3506	.3982
23	.3721	.5121	.4252	.3898	.285		.3582
24	.2804	.3189	.439	.3721	.3582	.3018	.3012
Max	.815	.9745	1.1157	1.1163	1.0317	1.0059	1.0517
Min	.2303	.2658	.2279	.2629	.2378	.1578	.1254
Avg	.4832	.5243	.6019	.4859	.4578	.4406	.4690



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 201 / 11Kv Sirsala Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1029	.1543	.1543	.1219	.2591	.2743
2	.2286	.1029	.1543	.1543	.1219	.2286	.2743
3	.2286	.1029	.1543	.1543	.1219	.2286	.3086
4	.2439	.1543	.1715	.1715	.1219	.2286	.3086
5	.2743	.1543	.1715	.1715	.1219	.2591	.3258
6	.3506	.1715	.1715	.1715	.1372	.2591	.5487
7	.1524	.1715	.1715	.1543	.1524	.1372	.1543
8	.1715	.1543	.1543	.1543	.1372	.1341	.1543
9	.1372	.3506	.2401	.2572	.2591	.0914	.1029
10	.1029	.3506	.1677	.2591	.2915	.0762	.0514
11	.1029	.3201	.3048	.2591	.2401	.061	.1715
12	.1029	.3048	.2591	.2286	.2229		.1029
13		.2286	.2743	.2286	.1715	.061	.1029
14	.0857	.2134	.2286	.2134	.1715	.0686	.1372
15	.0857	.1981	.2134	.1829	.2058	.0857	.1372
16	.0857	.2572	.2572	.2134		.0857	.1029
17	.12	.0171	.0857	.0857		.0686	.0857
18	.1029	.1543	.1029	.0857	.1029	.12	.1029
19	.12	.1543	.1543	.1067	.12	.12	.1372
20	.1372	.1372	.1543	.12	.1219	.1372	.1372
21	.12	.1372	.1543	.12	.1981	.2915	.1886
22	.12	.1543	.1543		.2591	.2572	.2229
23	.1543	.1543	.1543		.2591	.2572	.2229
24	.2286	.1029	.1543	.1543	.1219	.2591	.2743
Max	.3506	.3506	.3048	.2591	.2915	.2915	.5487
Min	.0857	.0171	.0857	.0857	.1029	.061	.0514
Avg	.1602	.1812	.1818	.1728	.1719	.1641	.1929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 202 / 11KV HATTI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.1029	.1029	.1219	.0762	.12
2	.0762	.1029	.1029	.1029	.1219	.0762	.12
3	.0857	.1029	.12	.1029		.381	.12
4	.1029	.1543	.1372	.1372	.1219	.0762	.1372
5	.12	.1543	.2401	.2229	.1981	.0762	.1372
6	.1372	.1715	.1029	.3772	.381	.0914	.1543
7	.1543	.1029	.1029	.1029	.12	.1067	.1543
8	.12	.0514	.0857	.1029	.0857	.0762	.12
9	.12	.0762	.0857		.0857	.2439	.1715
10	.1886	.0686	.0457	.0514	.0686	.3285	.1886
11	.1715	.0514	.0457	.0514	.0343	.2439	.2401
12	.3086	.0343	.0457	.0305	.0343	.2439	
13	.2915	.0514	.0343	.0381	.0343	.2439	.2572
14	.2229	.0343	.0343	.0572		.2401	.2572
15	.1543	.0343	.0171	.0514	.0343	.1715	.2229
16	.2229	.0343	.0343	.0514		.1886	.2229
17	.0514	.0343	.0514			.0514	.0343
18	.0514	.0514	.0514	.0514	.0514	.0514	.0686
19	.0857	.0857	.0857	.0514	.0686	.0857	.0857
20	.1029	.1029	.0857	.0457	.061	.0857	.1029
21	.1029	.2229	.1543	.1524	.0762	.12	.1029
22	.1029	.1715	.12		.0762	.12	.12
23	.1029	.1543	.1029		.0762	.12	.1029
24	.0857	.1029	.1543	.1029	.1219	.0762	.12
Max	.3086	.2229	.2401	.3772	.381	.381	.2572
Min	.0514	.0343	.0171	.0305	.0343	.0514	.0343
Avg	.1353	.0939	.0893	.0994	.0987	.1490	.1461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 203 / 11Kv Ambhai Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0171	.0171	.0171	.0191	.0305	.0343
2	.0305	.0171	.0171	.0171	.0191	.0305	.0343
3	.0305	.0171	.0171	.0171	.0191	.0305	.0343
4	.0343	.0171	.0171	.0171	.0191	.0305	.0343
5	.0343	.0171	.0171	.0171	.0191	.0305	.0514
6	.0857	.0171	.0171	.0343	.0191	.0305	.1372
7	.0343	.0171	.0343	.0171	.0191	.0152	.0171
8	.0191	.0171	.0343	.0343	.0191	.0152	.0171
9	.0171	.0457	.0857	.0457	.0305	.0152	.0171
10	.0171	.061	.1524	.0686	.0343	.0191	.0171
11	.0171	.12	.1524	.0914	.0343	.0152	.0171
12	.0171	.1524	.1524	.1067	.0857	.0152	.0171
13		.1524	.1219	.0914	.0857	.0152	.0171
14	.0171	.1372	.0914	.0914	.0686	.0152	.0171
15	.0171	.1219	.0914	.061	.0514	.0171	.1715
16	.0171	.1715	.1029	.0457		.0171	.0114
17	.0171	.0171	.0171	.0191		.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0191	.0152	.0171	.0171
21	.0171	.0171	.0171	.0152	.0152	.0171	.0171
22	.0171	.0171	.0171	.0191	.0305	.0343	.0343
23	.0171	.0171	.0171	.0191	.0305	.0343	.0343
24	.0305	.0171	.0171	.0171	.0191	.0305	.0343
Max	.0857	.1715	.1524	.1067	.0857	.0343	.1715
Min	.0171	.0171	.0171	.0152	.0152	.0152	.0114
Avg	.0247	.0515	.0524	.0382	.0313	.0220	.0347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 204 / 11Kv Chinchpur feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.12	.1372	.12	.1067	.0152	.0171
2	.0191	.12	.1372	.12	.1067	.0152	.0171
3	.0191	.12	.1372	.12	.1067	.0152	.0171
4	.0191	.12	.1372	.1372	.1067	.0152	.0171
5	.0191	.1372	.12	.1715	.1219	.0152	.0171
6	.0191	.2058	.2915	.3429	.3048	.0152	.0171
7	.0191	.0171	.0171	.0171	.0191	.0152	.0171
8	.0191	.0171	.0171	.0191	.0191	.0152	.0171
9	.1543	.0191	.0171	.0191	.0191	.2439	.2401
10	.1715	.0191	.0152	.0191	.0171	.2896	.2743
11	.2229	.0191	.0152	.0171	.0171	.3353	.3772
12	.3086	.0191	.0171	.0171	.0171	.3658	
13	.3429	.0171	.0191	.0191	.0171	.3963	.463
14	.2229	.0191	.0171	.0191	.0171	.3429	.3944
15	.1715	.0191	.0171	.0191	.0171	.3258	.3429
16	.2915	.0171	.0171	.0191		.3429	.2401
17	.0171	.0171	.0171	.0191		.0171	.0171
18	.0171	.0171	.0171	.0191	.0171	.0171	.0171
19	.0171	.0171	.0171	.0191	.0171	.0171	.0171
20	.0171	.0171	.0171	.0191	.0191	.0171	.0171
21	.12	.1715	.1543	.1524	.0171	.0171	.0171
22	.12	.2229	.1886		.0171	.0171	.0171
23	.12	.1715	.1543		.0171	.0171	.0171
24	.0191	.12	.1715	.12	.1067	.0152	.0171
Max	.3429	.2229	.2915	.3429	.3048	.3963	.463
Min	.0171	.0171	.0152	.0171	.0171	.0152	.0171
Avg	.1036	.0733	.0778	.0702	.0557	.1208	.1133

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 205 / 11KV AMBHAI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2572	.2743	.3086	.3048	.3048	.3429
2	.3048	.2572	.2743	.3086	.3048	.3048	.3429
3	.3048	.2572	.2915	.3772	.3048	.3048	.3772
4	.381	.3429	.3772	.4287	.3353	.381	.4115
5	.4572	.5487	.4801	.5487	.4572	.4572	.4801
6	.6097	.6173	.6344	.6344	.5144	.5335	.6516
7	.4572	.2401	.583	.4287	.4572	.3048	.6687
8	.0914	.4458	.2572	.4115	.2439	.3506	.12
9	.3429	.3506	.1372	.381	.2439	.3353	.2229
10	.4801	.3506	.3506	.442	.3772	.3658	.5144
11	.4115	.3048	.3353	.381	.3772	.2743	
12	.4115	.2591	.3048	.3506	.3086	.3048	.3601
13		.2286	.2743	.3048	.3086	.3601	.3429
14	.3429	.3353	.2591	.2743	.3429	.3429	.3258
15	.3772	.3353	.3086	.2439	.3086	.2915	.3944
16	.2915	.4115	.4115	.2743		.463	.4115
17	.4801	.4801	.4287	.3658		.4287	.5144
18	.5658	.5487	.5316	.381	.5144	.5487	.6001
19	.5144	.5144	.5658	.4572	.6173	.5144	.4973
20	.463	.4801	.4801	.4572	.4115	.5144	.463
21	.3944	.3944	.3944	.381	.381	.4458	.3944
22	.3429	.3944	.3601		.3506	.3772	.3772
23	.3258	.3429	.3429		.3048	.3601	.3429
24	.3048	.2572	.3429	.3429	.3048	.3048	.3429
Max	.6097	.6173	.6344	.6344	.6173	.5487	.6687
Min	.0914	.2286	.1372	.2439	.2439	.2743	.12
Avg	.3896	.3731	.3750	.3856	.3670	.3822	.4130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 206 / 11Kv Nanegaon feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.0857	.0857	.0857	.0914	.1219	.12
2	.0762	.0857	.0857	.0857	.0914	.1219	.12
3	.1219	.1029	.0857	.0857	.0914	.1219	.1372
4	.1219	.1029	.0857	.0857	.0914	.1219	.1715
5	.1219	.12	.1029	.0857	.0914	.1372	.1886
6	.1677	.1029	.1029	.0857	.1067	.1524	.4115
7	.0914	.1029	.1029	.0857	.1219	.0914	.12
8	.1219	.1029	.1029	.0686	.1219	.1219	.12
9	.12	.4115	.1372	.1372	.2134		.12
10	.1372	.381	.1677	.1524	.2572	.0914	.0686
11	.1029	.3201	.2591	.2134	.2229	.0762	.0686
12	.0686	.2591	.2286		.2229	.0762	.0686
13		.1829	.2058	.2286	.1886	.0914	.0686
14	.0857	.1372	.1219	.2286	.1886	.0857	.0686
15	.0686	.1067	.1219	.1829	.1543	.1029	.1029
16	.0686	.1543	.1829	.2134		.0857	.12
17	.1029	.0857	.0514	.1029		.0857	.0857
18	.0857	.12	.0857	.0857	.1029	.0857	.1029
19	.12	.0857	.0857	.1067	.12	.0857	.1029
20	.12	.0857	.0857	.12	.0914	.0857	.1029
21	.0857	.0857	.1029	.1067	.1067	.1886	.1886
22	.0857	.0857	.1029		.1219	.2058	.1886
23	.0857	.0857	.1029		.1219	.1715	.12
24	.1219	.0857	.0857	.0857	.0914	.1219	
Max	.1677	.4115	.2591	.2286	.2572	.2058	.4115
Min	.0686	.0857	.0514	.0686	.0914	.0762	.0686
Avg	.1045	.1449	.1201	.1254	.1369	.1144	.1290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 207 / 11Kv Ghatambri Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0343	.0514	.0343	.0457	.0191	.0171
2	.0191	.0343	.0514	.0343	.0457	.0191	.0171
3	.0191	.0343	.0514	.0343	.0457	.0191	.0171
4	.0191	.0343	.0514	.0514	.0457	.0191	.0171
5	.0191	.0343	.0514	.0514	.0457	.0171	.0171
6	.0191	.0514	.0686	.0857	.0762	.0191	.0171
7	.0191	.0171	.0171	.0171	.0191	.0191	.0171
8	.0191	.0171	.0171	.0171	.0191	.0191	.0171
9	.0343	.0191	.0171	.0191	.0191	.0762	.0343
10	.0514	.0152	.0191	.0191	.0171	.0914	.0343
11	.0514	.0152	.0152	.0152	.0171	.1524	.0514
12	.0686	.0191	.0171	.0189	.0171	.1372	.0514
13	.0686	.0191	.0171	.0191	.0171	.1372	.12
14	.12	.0191	.0171	.0191	.0171	.12	.12
15	.1372	.0191	.0171	.0171	.0171	.0686	.12
16	.1543	.0171	.0152	.0191		.0857	.1715
17	.0171	.0171	.0171	.0171		.0171	.0171
18	.0171	.0171	.0171	.0191	.0171	.0171	.0171
19	.0171	.0171	.0171	.0191	.0171	.0171	.0171
20	.0171	.0171	.0171	.0191	.0152	.0171	.0171
21	.0343	.0514	.0171	.061	.0152	.0171	.0171
22	.0343	.0686	.0686		.0191	.0171	.0171
23	.0514	.0514	.0343		.0171	.0171	.0171
24	.0191	.0343	.0514	.0343	.0457	.0173	.0171
Max	.1543	.0686	.0686	.0857	.0762	.1524	.1715
Min	.0171	.0152	.0152	.0152	.0152	.0171	.0171
Avg	.0436	.0281	.0306	.0292	.0278	.0482	.0407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 208 / 11Kv Hatti Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2401	2.6235	.1029	.2439	.2439	.2743
2	.2286	.2401	.2572	.1029	.2439	.2439	.2743
3	.2286	.2401	.2572	.1372	.2439	.2591	.3086
4	.3048	.3429	.3772	.1372	.3048	.381	.4287
5	.4572	.5316	.5144	.2058	.4877	.4877	.5316
6	.6097	.7716	.7373	.2401	.6859	.6859	.9431
7	.5335	.7545	.8745	.2058	.8383	.8383	.9945
8	.381	.7202	.6859	.2058	.5335	.7621	.7716
9	.463	.4877	.5658		.6097	.5792	.5316
10	.3086	.3048	.0914	.4572	.3429	.3506	.3429
11	.1715	.1981	.061	.3048	.2743	.2286	
12	.1715	.1677	.1677	.2134	.1886	.1981	
13	.1543	.1677		.1981	.1886	.1829	.1715
14	.2572	.1677	.1219	.1981	.2401	.2058	.1715
15	.2915	.1677	.1067	.2439	.2401	.1886	.2058
16	.4115	.1886	.1067	.2286		.2401	.1372
17	.3258	.2743	.1715	.2286		.2572	.2743
18	.5658	.4458	.2229	.3048	.4287	.463	.5144
19	.6001	.6516	.4801	.4572	.6001	.6344	.703
20	.4287	.4801	.583	.4572	.4268	.583	.4801
21	.3601	.3772	.1543	.3048	.381	.4115	.3601
22	.3086	.3086	.12		.3201	.3772	.3258
23	.2743	.3086	.1029		.2439	.2915	.2743
24	.2286	.2572	.3086	.1029	.2439	.2439	.2915
Max	.6097	.7716	2.6235	.4572	.8383	.8383	.9945
Min	.1543	.1677	.061	.1029	.1886	.1829	.1372
Avg	.3455	.3664	.4214	.2399	.3778	.3891	.4232



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 201 / 11Kv Jalki Bazar Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5121	.5544	.7316	.9335	.8676	.8962
2	.6154	.5487	.5959	.9145	.9709	.8865	.8775
3	.6516	.567	.6661	1.0242	1.0164	.9335	.8501
4	.7059	.7316	.7975	1.0974	1.1088	1.0829	1.0642
5	.7522	.8048	.9362	1.2071	1.3676	1.4045	
6	.815	.9145	1.0288	1.2437	1.5546	1.8107	1.531
7	1.3306	1.4937	1.3717	1.7177	1.6289	1.7741	1.6991
8	1.1389	1.2883	1.4563	1.1827	1.2403	1.5339	1.6817
9	.1867	.9149	.6722	.2587	.5609	.7392	.4572
10	.2987	.5975	.5041	.5914	.6201	.5853	.5014
11	.3361	.4108	.3734	.4251	.6379	.5792	.5194
12	.3921	.3361	.3511	.3326	.6733	.543	.5373
13	.3326	.3326	.3511	.4066	.7522	.543	.543
14		.3511	.3547	.3511	.7888	.543	.5068
15	.5258	.4294	.4854		.5784	.6036	.5068
16	.8871	.4805	.5228	.5175	.6733	.5373	.5014
17	.9335	.5359	.5788	.6767	.6161	1.1763	.5975
18	1.0456	.5729	.8215	.7392	.8402	.7392	1.0829
19	1.1949	.7762	.8962	1.1203	1.2012	1.1088	1.2136
20	1.1949	1.1016	1.0829	1.307	1.1088	1.2254	1.1203
21	.7095	.5975	.7316	1.2136	1.0829	.9979	.5959
22	.3658	.5258	.7316	1.0829	1.0269	.9896	.6379
23	.3658	.5175	.695	.9979	.9522	.924	.6556
24	.4755		.695		.9335	.8962	.9055
Max	1.3306	1.4937	1.4563	1.7177	1.6289	1.8107	1.6991
Min	.1867	.3326	.3511	.2587	.5609	.5373	.4572
Avg	.6895	.667	.7189	.8700	.9528	.9594	.8471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 202 / 11Kv Shivna Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7783	.8048	.6516	.695	.9979	1.307	.7468
2	.8145	.9145	.7282	.8048	1.1016	1.4003	.7282
3	.8688	1.0242	.8764	.9145	1.1763	1.4937	.7023
4	.9134	1.134	1.0166	.9877	1.2012	1.6263	.8316
5	.985	1.2437	1.1317	1.0974	1.4998	1.7558	.9979
6	1.0517	1.3169	1.283	1.1523	1.7741	1.9204	1.2567
7	2.1033	2.0165	1.9547	2.0911	1.957	2.0485	1.3717
8	1.9204	1.6804	1.9774	1.8298	1.8427	1.9589	1.3306
9	1.4937	1.5684	1.5684	1.6617	.7973	.9511	.6878
10	1.307	1.5123	1.2136	1.2936	.9214	.9328	.7442
11	1.1949	1.531	.8871	1.0082	.9492	.9511	.7796
12	1.0642	1.4415	1.0164	.8131	.964	.905	.7973
13	.823	1.2071	.8215	1.0269	.7522	.7316	.7973
14		1.0059	.8871	1.0269	.8238	.8316	.7796
15	.9922	.9979	.9055		.7973	.8962	.815
16	1.0719	1.0349	1.0642	1.1949	.8238	.7087	.8505
17	1.2323	1.1088	1.0829	1.3169	1.531	1.1203	1.5684
18	1.3817	1.1827	1.2883	1.386	1.7187	1.7924	1.9753
19	1.4937	1.307	1.419	1.4415	1.9204	1.6078	2.0725
20	1.1203	1.423	1.4937	1.4784	1.7372	1.386	1.7924
21	.8029	1.0517	.8048	1.3306	1.531	.8215	.7973
22	.6584	.7762	.8048	1.1763	1.4937	.8215	.8413
23	.7316	.6516	.7316	1.1203	1.419	.7762	.8764
24	.7682		.695		1.0829	1.363	.7392
Max	2.1033	2.0165	1.9774	2.0911	1.957	2.0485	2.0725
Min	.6584	.6516	.6516	.695	.7522	.7087	.6878
Avg	1.1118	1.2146	1.0960	1.2204	1.2839	1.2545	1.0367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 203 / 11Kv Amsari Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.4024	.4115	.3292	.5175	.415	.5041
2	.3511	.439	.5201	.3658	.5544	.4338	.4805
3	.3658	.4755	.6068	.439	.6283	.4904	.4668
4	.4024	.5487	.6661	.5487	.7282	.6036	.5544
5	.4207	.5853	.6952	.6219	.8775	.8299	.6653
6	.4706	.6219	.7545	.6219	.9425	1.0269	.7762
7	1.0082	1.0082	.9465	1.0082	1.0059	.8402	.8316
8	.6535	.4481	.4668	.8962	.5493	.7577	.4715
9	.112	.4481	.1867	.4481	.3544	.5914	.3658
10	.112	.3326	.2054	.4294	.4252	.3142	.2534
11	.112	.2054	.2614	.2033	.362	.2743	.2534
12	.0934	.1848	.2587	.2772	.2534	.2587	.2715
13	.2012	.2241	.2587	.2772	.4344	.2772	.2534
14		.2772	.2218	.2614	.3544	.2743	.2353
15	.443	.2772	.2614		.3721	.2772	.2172
16	.3881	.2587	.2801	.2614	.2743	.443	.2715
17	.5601	.2587	.2801	.4066	.415	.5041	.3772
18	.6348	.2587	.4481	.4668	.4715	.462	.6036
19	.6722	.3326	.5975	.6908	.7095	.7207	.6535
20	.4854	.462	.5975	.7392	.6535	.6908	.5601
21	.3921	.4382	.439	.7095	.6413	.6535	.2658
22	.2926	.4435	.3658	.6535	.6036	.5975	.2481
23	.3292	.3772	.3292	.5788	.5281	.5601	.2427
24	.3658		.3292		.5601	.4527	.2241
Max	1.0082	1.0082	.9465	1.0082	1.0059	1.0269	.8316
Min	.0934	.1848	.1867	.2033	.2534	.2587	.2172
Avg	.3999	.4047	.4328	.5106	.5507	.5312	.4186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 204 / 11Kv Pimpaldari Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.0456	.7842	.7842	.6908	.5975	.7468
2	1.358	1.1203	.8916	.9335	.7392	.6348	.7947
3	1.4335	1.3443	1.1088	1.0456	.8131	.6722	.8686
4	1.5089	1.4937	1.2308	1.1576	.8596	.7095	.8871
5	1.6804	1.531	1.3443	1.2696	.905	.7468	.9328
6	1.848	1.6804	1.419	1.3443	.9145	.8215	.9694
7	2.0698	1.7551	1.531	1.643	1.7002	1.9044	1.6461
8	1.9044	1.7924	1.5893	1.262	1.4937	1.848	1.6095
9	.5121	.8764	.5258	.7712	1.419	1.5524	1.7741
10	.6584	.8939	.6379	.7796	1.3443	1.2936	1.6804
11	.7316	.9214	.567	.7087	1.307	1.2936	1.6057
12	.7499	.9979	.5316	.6379	1.2696	1.2936	1.4937
13	.6767	.7888	.5959	.4961	1.3817	1.3306	1.4563
14		.5609	.4908	.5434	1.2757	1.3491	1.419
15	.6348	.5201	.5258	.6661	1.3443	1.3169	1.3817
16	.6379	.7186	.5487	.5609	1.4335	1.2936	1.4937
17	1.0974	.961	1.307	1.386	1.531	1.4563	1.7177
18	1.3535	1.0349	1.8671	1.6078	1.848	1.7924	1.922
19	1.6057	1.1088	2.2405	1.4784	1.9589	1.7177	2.0165
20	1.8298	1.1949	1.8298	1.4003	1.7741	1.4937	1.9044
21	1.1949	1.2696	1.0456	.7392	.6283	.5914	1.8298
22	1.1203	1.0829	.9335	.5975	.6653	.6283	1.7177
23	1.0456	.7762		.5601	.6722	.6653	1.643
24	.8589		.7468		.6161	.6348	1.5684
Max	2.0698	1.7924	2.2405	1.643	1.9589	1.9044	2.0165
Min	.5121	.5201	.4908	.4961	.6161	.5914	.7468
Avg	1.2166	1.1074	1.0562	.9727	1.1910	1.1516	1.4616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 205 / 11Kv Halda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	1.1203	.7023	1.0456	.4572	.4294	.6283
2	.7356	1.1949	.7282	1.1203	.4938	.4481	.6838
3	.7922	1.307	.7392	1.307	.5544	.4668	.7023
4	.8676	1.531	.7842	1.419	.6036	.5041	.7762
5	1.0082	1.6804	.8029	1.6804	.7023	.5601	.8316
6	1.1576	1.7924	.8131	1.8298	.7392	.6348	.8686
7	1.1203	1.7924	.8501	1.9044	1.1203	1.1576	1.0534
8	1.0269	1.643	.7095	1.8054	.9808	1.0082	.924
9	.7316	.4334	.4607	.4557	.8215	.8402	.8589
10	.7712	.4115	.5258	.3856	.5788	.5658	.5601
11	.8779	.3814	.5959	.4207	.5847	.5975	.547
12		.3467	.7442	.333	.4527	.6161	.5228
13	.9114	.5609	.8063	.3856	.415	.4668	.547
14		.7362	.815	.3856		.5041	.5658
15	.8962	.7712	.8859	.4075		.5415	.6161
16	1.0082	.6241	.8048	.333	.4715	.5975	.5281
17	1.2696	.4805	.8215	.5601	.4904	.8871	.5847
18	1.8298	.5544	1.1949	.6535	.7356	.7392	.8676
19	2.0538	.5601	2.0538	1.358	1.0456	.7733	1.1203
20	2.2405	.7468	1.9044	1.307	.9709	.6979	1.0534
21	1.8298	.8316	1.7924	.9335	.4207	.547	.9997
22	1.6804	.8029	1.4937	.415	.4572	.5359	.9335
23	1.307	.7468	1.2696	.4251	.5041	.5359	.8402
24	1.0456		1.0082		.462	.4668	.7842
Max	2.2405	1.7924	2.0538	1.9044	1.1203	1.1576	1.1203
Min	.7167	.3467	.4607	.333	.415	.4294	.5228
Avg	1.1763	.9152	.9711	.9074	.6392	.6301	.7666

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 206 / 11Kv Digras feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.7468	.8316	.8215	.5359	.4481	.6036
2	1.0374	.9335	.924	1.0082	.5175	.4668	.6468
3	1.0751	1.0082	1.0349	1.1949	.5914	.5041	.6838
4	1.2136	1.1203	1.1576	1.3443	.6283	.5601	.7133
5	1.419	1.2696	1.2197	1.4937	.6838	.5975	.7316
6	1.6244	1.3443	1.307	1.6057	.695	.6722	.7682
7	1.7372	1.4003	1.3817	1.419	1.4377	1.6632	1.4784
8	1.587	1.1949	1.3443	1.0341	1.4003	1.531	1.386
9	.4755	.5895	.3506	.5959	1.1949	.8686	1.363
10	.6036	.5258	.4252	.5847	1.0269	1.0719	1.307
11	.6036	.4801	.4382	.4961	1.0082	1.0269	1.2136
12	.5853	.4681	.4382	.4908	.9997	.8686	1.0829
13	.4961	.443	.3898	.4252	.9619	.9709	1.0269
14		.4207	.4382	.4557	.8962	.9795	.9709
15	.4481	.3772	.3544	.4382	.8215	1.0456	.8962
16	.5175	.4854	.4572	.4382	.9808	1.1088	1.0082
17	.6722	.7947	1.0642	1.0341	1.094	1.1576	1.1576
18	.9709	.8501	1.3443	1.307	1.4003	1.3306	1.4563
19	1.1203	.924	1.4563	1.2696	1.5708	1.251	1.6804
20	1.1203	.924	1.307	1.2883	1.4563	1.1016	1.587
21	1.0829	.9709	1.251	1.1088	.4805	.5041	1.3256
22	.9335	1.0082	1.1203	.4294	.499	.5359	1.2696
23	.8589	.8326	1.0456	.499	.5228	.5544	1.2136
24	.7842		.7842		.5304	.4854	.5853
Max	1.7372	1.4003	1.4563	1.6057	1.5708	1.6632	1.6804
Min	.4481	.3772	.3506	.4252	.4805	.4481	.5853
Avg	.9542	.8310	.9111	.9036	.9139	.8877	1.0898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 207 / Water Supply FDR

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0173	.0173	.0173	.0175	.0171	.0173	.0173
8	.0173	.0347	.0173	.0347		.0173	.0347
9	.0351	.0347	.0173	.0351	.0347	.0343	.0347
10	.0351	.0347	.0173	.0351	.0347	.0343	.0173
11	.0343	.0347	.0173	.0351	.0347	.0343	.0173
12	.0351	.4681	.0173	.0347	.0347	.0343	.0173
13	.0351	.0347	.0173	.0351	.0347	.0343	.0173
14		.0347	.0173	.0347	.0347	.0343	.0347
15	.0351	.0173	.0173	.0347	.0347	.0343	.0347
16	.0343		.0171	.0173	.0343	.0347	.0343
17			.0343	.0347	.0343	.0347	.0343
18			.0343	.0347	.0343	.0347	.0343
Max	.0351	.4681	.0343	.0351	.0347	.0347	.0347
Min	.0173	.0173	.0171	.0173	.0171	.0173	.0173
Avg	.0310	.0790	.0201	.0320	.0330	.0316	.0274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 201 / 11KV BHAVAN (NILLOD)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3982	.3605	.4715	.4115	.407	.4904
2	.362	.4344	.426	.415	.4801	.4578	.4527
3	.3982	.4656	.4588	.5093	.5601	.5256	.5281
4	.4344	.5014	.5087	.7545	.7545	.6443	.7167
5	.4835	.5868	.6104	1.0269	.9945	.9156	.9242
6	.6268	.9054	.9175	1.1576	1.3032	1.1633	1.1576
7	1.4148	1.291	1.3565	1.2883	1.406	1.3565	1.4003
8	1.3957	1.3014	1.1797	1.2449	1.2689	1.2209	1.4003
9	1.1317	1.0562		.543	.6173	.6062	.5197
10	.4801	.6602	.6602	.5197	.5571	.5658	.3768
11	.3086	.4481	.3772	.7716	.5407	.6335	
12	.3601	.2987		.823	.5243	.5197	.426
13	.3086	.3601	.3018	.7545	.4915	.503	.4748
14	.4115	.3086	.3206	.6516	.5087		.3932
15	.4801	.3086	.2829	.5144	.5087		.39
16	.6516	.3086	.3018	.583	.5426		.4578
17	.8488	.3605	.3772	.3086	.3932		.3768
18	1.0185	.5765	.5658	.3944	.5243	.6036	.5256
19	1.3203	1.0322	1.1317	1.0974	.9503	1.0751	1.1203
20	.8676	.9995	.811	.9945	.8356	.9242	.7969
21	.4904	.4917	.6413	.6173	.5898	.6224	.2458
22	.6224	.5087	.6036	.5144	.5243	.6036	.2949
23	.4887	.407	.5658	.4801	.5087	.547	.2785
24	.3439	.3801	.3605	.5281	.4458	.4424	.5093
Max	1.4148	1.3014	1.3565	1.2883	1.406	1.3565	1.4003
Min	.3086	.2987	.2829	.3086	.3932	.407	.2458
Avg	.6495	.5996	.5963	.7068	.6767	.7169	.6199



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 202 / 11 KV BORGAON KH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2826	1.1142	.543	.5144	.4915	.503
2	1.2449	1.3203	1.1469	.5792	.583	.5571	.5365
3	1.2826	1.358	1.1961	.6089	.6516	.5898	.6036
4	1.3957	1.3957	1.2887	.6268	.7545	.6882	.7042
5	1.6598	1.5844	1.4746	.6626	.823	.7701	.7712
6	1.9231	1.8296	1.6278	.8059	.9945	.852	1.0059
7	1.9418	1.8671	1.6956	1.8671	1.7661	1.5074	1.9605
8	1.8298	1.7541	1.5261	1.7541	1.6804	1.6057	1.8484
9	.5365	.6371	.5533	1.2883	1.3375	1.2378	1.363
10		.7712	.6036	.9431	.8848	.9619	.7865
11	.6859	.823	.6036	.6859	.5571	.811	.6226
12	.9088	.8745	.6371	.6173	.5243	.7545	.6226
13	.8573	.8745	.6371	.5316	.5243	.7167	.5898
14	.8745	.7202	.6539	.583	.5426	.6602	.5898
15	.7888	.7716	.6371	.583	.5256	.6602	.5735
16	.823	.7545	.6706	.4801	.5898	.6602	.5735
17	1.2071	.6443	.6602	.583	.7045	.679	.6882
18	1.2449	.8987	.9619	.8745	.9995	.8865	.9835
19	1.6221	1.3108	1.3203	1.4403	1.6244	1.2323	1.4746
20	1.358	1.2452	1.3203	1.3375	1.1469	1.1883	1.4563
21	1.2449	1.1797	.543	.583	.6554	.5365	1.1469
22	1.2826	1.0978	.5973	.583	.5087	.724	1.1142
23	1.2637	1.1142	.543	.5487	.4915	.6878	1.0814
24	1.2071	1.2449	1.0814	.5068	.5144	.4588	.6335
Max	1.9418	1.8671	1.6956	1.8671	1.7661	1.6057	1.9605
Min	.5365	.6371	.543	.4801	.4915	.4588	.503
Avg	1.2343	1.1398	.9622	.8174	.8291	.8299	.9264

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 203 / 11 KV PALASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6697	.6226	1.226	1.166	1.1142	1.3203
2	.6697	.7059	.6554	1.2637	1.166	1.1469	1.358
3	.7059	.724	.7209	1.307	1.2689	1.278	1.4523
4	.7602	.7522	.7701	1.419	1.3375	1.3904	1.5655
5	.8596	.788	.9503	1.8298	1.5089	1.6876	1.8671
6	1.0029	.9221	1.0814	1.7737	1.8004		1.6804
7	1.5844	1.5089	1.5074	1.8858			1.7737
8	1.3203	1.5089	1.3108	1.7177	1.7147	1.6804	1.587
9	1.1506	1.4712	1.1797	.8775	.7716	.7461	.6706
10	.4801	1.3392	.9242	.9221	.8684	.9231	.639
11		.9945	.6036	1.0974	.8684	.9134	.6882
12		.9945	.547	1.166	.8848	.9221	.6226
13		.8745	.7733	.823	.8987	.8718	.6718
14		.823	.6979	1.0288	.852	.6874	.7209
15	1.046	.7202	.8299		.852	.8048	.7701
16	1.4403		.9997	1.166	.8356	.8676	.8192
17	1.773	.8139	.9431	.6516	.5898	.6413	.6348
18	1.9239	1.0978	1.358	.9945	.9175	.9054	1.0513
19	1.587	1.4746	1.6975	1.5089	1.6057	1.5844	1.9044
20	1.5089	1.491	1.5089	1.5089	1.3435	1.5278	1.6804
21	.7545	.5765	1.3392	1.3375	1.2289	1.4146	.5571
22	.8383	.7537	1.3014	1.2346	1.1797	1.3392	.5243
23	.8145	.6226	1.2637	1.2346	1.1469	1.3014	.4588
24	.6335	.724	.5898	1.2449	1.166	1.1142	1.2826
Max	1.9239	1.5089	1.6975	1.8858	1.8004	1.6876	1.9044
Min	.4801	.5765	.547	.6516	.5898	.6413	.4588
Avg	1.0744	.9718	1.0073	1.2704	1.1292	1.1301	1.0959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 204 / 11Kv Bhagawati Agro  
Express Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.018	.0164		.0171	.0171	.0184
2	.0177	.018	.0164		.0171	.0171	.0183
3	.0176	.018	.0164		.0171	.0171	.0183
4	.0177	.0179	.0164		.0171	.0171	.0183
5	.0176	.018	.0164		.0171	.0171	.0183
6	.0176	.018	.0164		.0171	.0171	.0183
7	.0177	.018	.0164		.0171	.0171	.0183
8	.0176	.018	.0164		.0171	.0171	.011
9	.0176	.018	.0164		.0171	.0164	.0183
10	.0171	.018	.0184		.0164	.0184	.034
11	.0171	.0171	.0184		.0164	.0184	.0164
12	.0171	.0171			.0164	.0184	.0328
13	.0171	.0171			.0164	.0184	.0328
14	.0171	.0171			.0164	.0183	.0164
15	.0171	.0171			.0164	.0183	.0328
16	.0171	.0171				.0183	.0341
17	.0176	.0171		.0171		.0184	.017
18	.018	.0164		.0171	.0328	.0183	.034
19	.018	.0164		.0171	.0328	.0183	.0328
20	.018	.0164		.0171	.0164	.0184	.033
21	.018	.0164		.0171	.0171	.0184	.0328
22	.018	.0164		.0171	.0164	.0183	.0328
23	.018	.0164		.0171	.017	.0184	.034
24	.0176	.018	.0164		.0171	.0171	.0183
Max	.018	.018	.0184	.0171	.0328	.0184	.0341
Min	.0171	.0164	.0164	.0171	.0164	.0164	.011
Avg	.0176	.0173	.0167	.0171	.0183	.0178	.0246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 205 / 11Kv Nillod Dharan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0164	.011	.0343	.0171	.011
2			.0164	.011	.0343	.017	.011
3			.0164	.011	.0343	.0341	.011
4			.0164	.011	.0343	.0341	.011
5				.011	.0343	.0341	.011
6					.0187	.0341	
9	.0219	.022					
10	.0514	.022	.022				
11	.0686	.0747	.022				
12	.1029	.0686	.011				
13	.1029	.0686	.022				
14	.0857	.1029	.022				
15	.1029	.0514	.033				
16	.0686	.0343	.011				
20						.892	
21				.0514	.0328	.033	
22			.022	.0514	.0341	.033	
23			.011	.0343	.0328	.0219	
24				.011	.0343	.0164	.022
Max	.1029	.1029	.033	.0514	.0343	.892	.022
Min	.0219	.022	.011	.011	.0187	.0164	.011
Avg	.0756	.0556	.0186	.0226	.0324	.1061	.0128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 201 / 11 KV PALOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.415	.3961		.3353	.4534	.4858
2	.415	.415	.3961	.3772	.3688	.4534	.4858
3	.415	.415	.415	.415	.3856	.4534	.5182
4	.4904	.5658	.547	.4527	.4359	.4858	.5506
5	.5658	.6413	.6602	.4904	.503	.5506	.6478
6	.7167	.7545	.7545	.6036	.4862	.6478	.8097
7	.8299	.8299	.8299	.6979	.7545	.8299	1.0185
8	.7922	.7356	.7545	.679	.6413	.7167	.7545
9	.3768	.6316	.57	.57	.6224	.6224	.6224
10	.4534	.6081	.6706	.6203	.4527	.4527	.4527
11	.7842	.7712	.8048	.7712	.2641	.3395	.3395
12	.9282	.8551	.8383	.7377	.2452	.3018	.2829
13	.9282	.8383	.8215	.8048	.3018	.2641	.2452
14	.8802	.8886	.7545	.57	.3206	.2641	.2263
15	.8482	.7042	.6706	.6371	.3206	.2829	.2452
16	.8162	.7377	.6371	.5365	.3206	.2829	.2641
17	.547	.5281	.3018	.3206	.3018	.2829	.3395
18	.4904		.4527	.3772	.3961	.4715	.4527
19	.547	.5281	.6602	.6224	.5658	.6602	.6036
20	.5658	.5658	.6413	.5658	.5093	.5847	.5658
21	.5281	.4904	.5281	.4694	.3401	.4858	.3688
22	.4527	.415	.4904	.3395	.4372	.5182	.3688
23	.4527	.415	.415	.3688	.421	.5506	.4024
24	.3772	.4527	.3961	.3772	.4024	.4696	.502
Max	.9282	.8886	.8383	.8048	.7545	.8299	1.0185
Min	.3768	.415	.3018	.3206	.2452	.2641	.2263
Avg	.6090	.6175	.6003	.5393	.4222	.4760	.4814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 202 / 11 KV ANWI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3395	.3353	.2429	.2105
2	.3772	.3772	.3772	.3395	.3185	.2591	.2105
3	.3772	.3772	.4338	.3772	.3353	.2591	.2105
4	.4527	.4527	.4527	.415	.3018	.2915	.2429
5	.5281	.5281	.5281	.4904	.3521	.3563	.3563
6	.6602	.679	.7167	.7167	.285	.4858	.421
7	.7167	.7167	.811	.7922	.7733	.7922	.7545
8	.6979	.6979	.6602	.7167	.6224	.6413	.6602
9	.2785	.4049	.3521	.3688	.4338	.4527	.547
10	.3113	.4801	.3856	.3856	.3395	.2829	.3772
11	.3521	.5197	.4359	.4191	.2263	.2641	.3018
12	.4161	.4527	.4694	.4694	.1509	.2641	.2641
13	.5121	.5365	.4527	.4359	.2075	.2263	
14	.5281	.6036	.4024	.4527	.2263	.2263	.2075
15	.5121	.4359	.4191	.4191	.2641	.2263	.1886
16	.5121	.4694	.4024	.3521	.3206	.2263	.2263
17	.4904	.4715	.1698	.1886	.3584	.2641	.3018
18	.547		.3206	.3206	.4715	.3772	.4024
19	.5847	.5847	.5281	.4904	.6036	.5847	.5847
20	.5658	.5281	.4715	.5093	.4715	.5281	.5281
21	.4715	.4715	.4527	.3856	.2105	.2105	.3353
22	.415	.415	.415	.1677	.2267	.2105	.3353
23	.3772	.3961	.3772	.2515	.2267	.2105	.3688
24	.3584	.3772	.3961	.3395	.3353	.2429	.1943
Max	.7167	.7167	.811	.7922	.7733	.7922	.7545
Min	.2785	.3772	.1698	.1677	.1509	.2105	.1886
Avg	.4758	.4936	.4503	.4226	.3499	.3386	.3578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 203 / RAHIMABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5093	.4715	.4527	.4024	.3563	.2915
2	.5093	.5281	.4715	.4527	.4191	.3563	.2915
3	.5093	.5281	.5281	.5281	.3353	.3725	.3239
4	.6036	.8488	.7733	.5658	.4024	.421	.3887
5	.9054	1.0185	.9619	.6413	.3521	.4858	.5344
6		1.094	1.0374	.7922	.4191	.6316	.7125
7			.9431	.9997	.7356	.9054	1.0185
8	1.0751		.9431	.9431	.7733	.9431	.8676
9	.4096	.6154	.4359	.4359	.5093	.6979	.7545
10	.4049	.5506	.503	.4694	.5093	.4527	.4527
11	.4481	.57	.4694	.4694	.2829	.2829	.3772
12	.5441	.5533	.503	.5365	.2263	.2829	.3018
13	.5921	.503	.4527	.4527		.2641	.2452
14	.6081	.5868	.4527	.4694		.3018	.1886
15	.5921	.5365	.4694	.4527	.3584	.3395	.2263
16	.6722	.5365	.4694	.4527	.3018	.3018	.4338
17	.811	.6413	.3018	.3206	.415	.2829	.4904
18	.8676		.4904	.3395	.4715	.3772	.5658
19	.8676	1.0185	.8299	.3961	.6602	.4715	1.0185
20	.7922	.5281	.679	.4715	.4904	.4715	.6979
21	.6413	.6036	.6036	.503	.2591	.2915	.3353
22	.5658	.4715	.547	.285	.3077	.2915	.3353
23	.5093	.4715	.4904	.4359	.3077	.2915	.3688
24	.4904	.5093	.4715	.4527	.4024	.3401	.2915
Max	1.0751	1.094	1.0374	.9997	.7733	.9431	1.0185
Min	.4049	.4715	.3018	.285	.2263	.2641	.1886
Avg	.6331	.6297	.5958	.5133	.4246	.4256	.4797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 204 / ASADI AG MIX

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2263	.2452	.1509	.1509	.1296	.1296
2	.2452	.2263	.2452	.1509	.1677	.1296	.1296
3	.2452	.2263	.2829	.1698	.1677	.1296	.1296
4	.2829	.2641	.3395	.1886	.1844	.1457	.1619
5	.3395	.3395	.3961	.2263	.2347	.2267	.2591
6	.415	.4527	.5093	.2641	.218	.3239	.2915
7	.4715	.4527	.4338	.3395	.415	.4527	.4715
8	.3961	.415	.3772	.415	.3772	.3772	.3772
9	.1966	.1781	.1509	.1341	.1698	.2829	.2829
10	.2429	.192	.1174	.1509	.2075	.1698	.1698
11	.3041	.218	.1677	.1677	.1509	.1132	.1509
12	.3201	.218	.2012	.2012	.1886	.1132	.0943
13	.3201	.2347	.1844	.1677	.1698		.0754
14	.2401	.2347	.1677	.1677	.132	.1132	.0943
15	.16		.1509	.1677	.132	.1509	.0754
16	.2241	.1844	.1341	.1677	.1132	.1509	.0943
17	.2829	.2829	.132	.132	.1132	.1509	.1509
18	.3395		.1509	.0943	.1509	.2075	.1886
19	.3961	.3772	.2641	.2452	.2452	.3395	.3961
20	.3772	.2829	.1886	.2075	.1886	.2829	.3395
21	.3395	.3018	.1698	.1509	.1296	.1781	.2263
22	.2829	.2263	.1509	.1509	.1296	.1619	.2263
23	.2263	.2263	.132	.1509	.1296	.1619	.2641
24	.2452	.2263	.2263	.132	.1509	.1296	.1619
Max	.4715	.4527	.5093	.415	.415	.4527	.4715
Min	.16	.1781	.1174	.0943	.1132	.1132	.0754
Avg	.2974	.2721	.2299	.1872	.1840	.2009	.2059



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 201 / 11 kv Dhawda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1829	.2058	.4075	.2601	.2543	.2374
2	.1886	.2012	.2204	.4334	.2774	.2401	.2713
3	.2075	.2172	.2229	.4458	.3121	.2572	.3222
4	.2263	.2126	.2601	.4862	.3772	.2774	.3521
5	.2829	.2353	.3121	.5533	.4287	.298	.4024
6	.4527	.2534	.5138	.5801	.4917	.4527	.4752
7	.5093	.4904	.4904	.4904	.5093	.4715	.5093
8	.4715	.4527	.4338	.415	.415	.4382	.4715
9	.1254	.3584	.3048	.3395	.3206	.3206	.415
10	.2343	.2286	.2075	.1886	.1715	.2075	.2096
11	.3048	.1715	.1334	.132	.132	.1509	.0762
12	.3658	.0943	.1143	.1132	.0953	.1132	.0572
13	.3201	.0762	.1143		.0762	.132	.0953
14	.2932	.1132	.1143	.132	.0943	.132	.1143
15	.3048	.0943	.1143	.1509	.0754	.1132	.0953
16	.3841	.1132	.1143	.132		.1132	.0953
17	.3018	.1334	.1143	.132	.1698	.132	.1524
18	.3395	.1905	.1334	.1886	.2641	.1886	.1715
19	.4527	.3961	.3772	.3584	.4527	.3395	.3206
20	.3018	.3584	.3772	.3395	.3429	.3206	.3584
21	.1387	.2572	.3163	.2721	.3018	.2881	.2204
22	.1543	.2401	.3224	.3077	.2652	.2561	.2743
23	.1543	.2204	.3366	.2321	.2515	.2241	.2587
24	.2452	.1829	.2058	.3898	.2347	.2347	.2458
Max	.5093	.4904	.5138	.5801	.5093	.4715	.5093
Min	.1254	.0762	.1143	.1132	.0754	.1132	.0572
Avg	.2911	.2281	.2525	.3139	.2748	.2482	.2584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 202 / 11 kv Jambhai

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.2241	.2587	.3292	.2772	.2561	.2772
2	.6602	.2378	.2587	.3475	.3174	.2926	.3174
3	.6979	.2743	.2801	.362	.3547	.3142	.3734
4	.8676	.3077	.2987	.362	.3696	.3511	.4251
5	1.0374	.3475	.3361	.3761	.5175	.3921	.4805
6	1.4003	.4024	.4481	.394	.6219	.5729	.5853
7	1.4563		1.2826	1.2071	1.4335	1.5684	1.4003
8	1.2449		.8764	1.0185	1.094	1.1128	1.1128
9	.4481		.679		1.1128	.9335	.811
10	.298		.6036		.6979	.547	.6224
11	.3189		.4715	.7167	.4572		
12	.2401		.4338	.6224	.415		
13	.2279		.3961	.5658	.4572	.3772	
14	.2328	.6413	.415	.547	.4338	.3584	.4338
15	.3224	.6036	.4338	.5093	.415	.3584	.415
16	.3982	.6287	.4338	.5281	.4382	.3772	.415
17	1.0751	.679	.5093	.4904		.4527	.5093
18	1.2826	.724	.6602	.6602	.8488	.6224	.7356
19	1.4523	.9431	1.0185	1.094	1.1317	.9431	1.2637
20	1.094	.9054	.9054	.9431	.8865	.9808	1.0185
21	.2033	.2378	.2743	.2772	.2926	.2926	.2378
22	.1848	.2195	.2614	.2957	.2715	.2587	.2614
23	.1848	.2195	.2801	.2743	.2534	.2263	.2353
24	.811	.2054	.2402	.2957	.2926	.2353	.2402
Max	1.4563	.9431	1.2826	1.2071	1.4335	1.5684	1.4003
Min	.1848	.2054	.2402	.2743	.2534	.2263	.2353
Avg	.7023	.4589	.5023	.5553	.5822	.5374	.5796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 203 / 11 kv Amthana

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.4904	.547	.5281	.5093	.5525	.5281
2	.3898	.5281	.5658	.5847	.4904	.5658	.547
3	.439	.6224	.6287	.6413	.5281	.6287	.6036
4	.5121	.7922	.7167	.7545	.6602	.724	.679
5	.5487	1.0374	.8865	1.0185	.9242	.8865	.9242
6	.6878	1.2071	1.226	1.2637	1.1694	1.1317	1.226
7	.8859	1.4335	1.4335	1.3769	1.2637	1.4335	1.363
8	.9015	1.2637	1.3392	1.2826	1.1694	1.226	1.3014
9	.7712	.631	.7282	.6762	.5784	.6379	.6602
10	.7167	.7625	.8048	.7127	.57	.6539	.6133
11	.4904	.8356	.779	.779	.6464	.6464	.5571
12	.4527	.8745	.7373	.7865	.6478	.6226	.5441
13	.4527	.8421	.7125	.6478	.6154	.5243	.5761
14	.4715	.7842	.6882	.5668	.639	.5079	.583
15	.5658	.7611	.6554	.4696	.6133	.5079	.5243
16	.7545	.6964	.6154	.4534	.5801	.4973	.4807
17	.9619	.4763	.3584	.3772	.6224	.4904	.4338
18	.8865	.679	.5281	.6413	.6602	.6036	.7922
19	1.226	1.1317	1.0374	.9808	1.0751	.9808	1.2637
20	.9054	.9619	.8865	.9997	.9054	.9431	1.094
21	.811	.811	.811	.7733	.7545	.7733	.8299
22	.6602	.6287	.6602	.6602	.6668	.6413	.6602
23	.547	.5716	.5847	.547	.5658	.547	.5658
24	.3294		.5281	.5658	.5093	.5335	.5281
Max	1.226	1.4335	1.4335	1.3769	1.2637	1.4335	1.363
Min	.3294	.4763	.3584	.3772	.4904	.4904	.4338
Avg	.6551	.8184	.7691	.7537	.7235	.7192	.7450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 204 / 11 kv JOGESHWARI FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5093	.5525	.5281	.5658	.5335	.5847
2	.6516	.547	.5906	.6036	.5847	.5658	.6224
3	.691	.6413	.6413	.679	.6413	.6413	.6602
4	.7265	.7733	.7356	.7733	.7545	.8192	.8676
5	.7537	.9808	.8676	.9997	.9054	.9808	1.094
6	.8322	1.1694	1.1128	1.1694	1.1317	1.2449	1.1694
7	1.2378	1.226		1.1883	1.1694		1.1763
8	1.2689	1.094	1.1883	1.1694	1.094	.9808	1.0374
9	1.0059	.6859	.9088	.9015	.8916	.8309	.8745
10	.7922	.9339	.9496	.7537	.9175	.9448	
11	.6413	1.1305	1.1142	.9393	.9069	.9555	
12	.4904	1.2146	1.1305	.9717	.8802	.9762	.8002
13	.4904	1.1683	1.1174	.9555	.8907	.9282	.8583
14	.4904	1.1336	1.0688	.9393	.8642	.8802	.8848
15	.5281	1.1203		.8745	.8583	.8482	.8907
16	.5847	1.1498	.7449	.8583	.8848	.8259	.8907
17	.6979	.679	.5281	.6036	.5658	.9431	.5658
18	.9242	.9717	.7545	.8299	.8954	.8299	.8488
19	1.1128	1.0562	1.0185	1.094	1.0374	1.0374	1.094
20	.8865	.9054	.9054	.9242	.9431	.8865	.9431
21	.7167	.6979	.7733	.7167	.743	.811	.6979
22	.6413	.6478	.679	.6979	.6602	.6979	.6602
23	.6036	.5658	.5847	.6413	.5847	.6602	.6036
24	.5735	.5658	.5281	.547	.6224	.5525	.6036
Max	1.2689	1.226	1.1883	1.1883	1.1694	1.2449	1.1763
Min	.4904	.5093	.5281	.5281	.5658	.5335	.5658
Avg	.7477	.8987	.8407	.8483	.8330	.8424	.8376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 205 / Kelgaon murdeshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4294	.567	.5973	.4961	.4557	.4477
2	.5281	.4435	.5731	.6268	.5373	.4733	.4525
3	.5658	.462	.591	.6984	.5552	.4961	.5068
4	.679	.4805	.6154	.7265	.591	.5258	.5373
5	.9054	.5304	.6154	.7619	.6268	.5493	.5731
6	1.1506	.5487	.7133	.7973	.7265	.7421	.6201
7	1.3203	1.3203	1.3203	1.1694	1.3203	1.1883	1.1883
8	1.2637	1.1694	1.2071	.9997	1.094	1.1694	1.094
9	.3189	.9431	.9997	.8488	.8865	.9054	.8676
10	.2254	.5658	.6036	.4527	.5847	.6036	.5658
11	.2658	.5144	.4338	.3584	.4715	.5281	.415
12	.463	.4001	.3395	.3772	.381	.4527	.3206
13	.4287	.3772	.3018	.3584	.362	.3772	.3206
14	.3641	.3584	.3018	.3584	.3395	.3961	.3206
15	.3772	.3395	.3206	.3395	.3206	.3961	.3018
16	.4115	.3584	.3018	.3018		.3772	.3018
17	.8488	.4572	.3772	.3772	.4527	.4715	.4338
18	1.0562	.6413	.5093	.6224	.679	.6413	.7356
19	1.1506	1.0185	1.0185	1.0185	.9808	.9431	
20	.8488	.9054	.8299	.9242	.7621	.7167	.8488
21	.2743	.5083	.3856	.3772	.4382	.4075	.2926
22	.3045	.5258	.439	.5426	.4161	.4207	.3547
23	.3544	.5493	.4938	.4801	.4334	.4334	.4294
24	.547	.3841	.5493	.5552	.5028	.4382	.4557
Max	1.3203	1.3203	1.3203	1.1694	1.3203	1.1883	1.1883
Min	.2254	.3395	.3018	.3018	.3206	.3772	.2926
Avg	.6325	.5930	.6003	.6112	.6069	.5879	.5384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 201 / 11 KV LONAWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4108	.4525	.4344	.4481	.7207	.7282
2	.4525	.4668	.4344	.4706	.4854	.7947	.8029
3	.6805	.7095	.5068	.5249	.5601	.961	.9709
4	.8775	.9335	.5068	.6697	.8029	1.262	1.2883
5	1.0208	1.2136	.6089	.7783	1.0829	1.3169	1.3443
6	1.1517	1.4563	.7701	1.0277	1.4003	1.5546	1.587
7	1.2934	1.4937	1.2803	1.3717	1.1576	1.2986	1.1203
8	1.2048		1.1523	1.134	.8029	1.1706	.4294
9	1.0985		.924	.7947	.6535		.4481
10	.9335	.6722	.7207	.6535	.7442		.5601
11	.7468	.6161	.2801	.5228	.6984		.4481
12	.5601	.4805	.2614	.4481	.6805		.5601
13	.3174	.4435	.2427	.4108	.6447		.4854
14	.2987	.462	.3361	.4294	.6447		.5601
15	.3361	.4481	.3547	.5601	.6626		.6535
16	.3734	.5544	.4108	.6348	.6268	.3734	.7095
17	.5788	.4435	.5359	.9335	.961	.4854	.8215
18	1.1576	.7207	1.1888	1.1949	1.0903	.9522	1.0456
19	1.5123	1.2323	1.2803	1.0642	1.2071	1.2696	1.4563
20	1.6057	1.7924	1.3717	1.4003	1.3717	1.1389	1.1389
21	1.3443	.4706	.6626	1.1203	.9979	1.1203	1.1203
22	.9335	.4344	.7164	.7468	.8871	.8402	.8402
23	.8029	.4525	.543	.5601	.6535	.6535	.6535
24	.4163	.4294	.4887	.4525	.4668	.6468	
Max	1.6057	1.7924	1.3717	1.4003	1.4003	1.5546	1.587
Min	.2987	.4108	.2427	.4108	.4481	.3734	.4294
Avg	.8373	.7426	.6679	.7641	.8221	.9741	.8597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 202 / 11 KV ANDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2218	.3982	.3982	.4108	.3361	.3361
2	.2534	.2614	.4163	.4163	.4294	.3921	.3921
3	.5249	.6584	.4525	.5249	.5601	.7762	.7842
4	.6447	.8316	.5068	.6268	.6535	.9795	.9896
5	.6805		.543	.5731	.5975	1.1706	1.1949
6	.6984	1.1706	.5611	.543	1.3817	1.3717	1.4003
7	.6626	.924	1.5912	1.3169	1.1576	.8686	1.1949
8	.6984	1.0082	1.134	1.134	1.1576	.7023	.5601
9	.4477	1.0269	.8131	1.0719	.4108	.3174	.4108
10		.5601	.499	.7468	.4163	.3361	.4108
11	.7842	.5041	.3174	.5601	.4525	.2241	.4108
12	.5601	.4668	.2987	.4481	.3801	.2054	.2987
13	.4668	.4108	.3174	.4108	.3439	.1867	.3361
14	.4294	.3921	.3734	.4294	.3258	.2054	.2987
15	.4481	.4481	.3921	.4668	.2896	.168	.2801
16	.5601	.4854	.4481	.4481	.2172	.2241	.2614
17	.8962	.5359	.5041	.6348	.7023	.5415	.5415
18	.9149	.7842	.9979	.7468	.9979	.9522	.8215
19	1.1763	1.0829	1.0974	.9896	1.0903	1.2136	1.307
20	1.1949	.8589	1.1523	1.1576	1.2437	1.0269	1.0456
21	.5975	.362	.3801	.7842	.9055	.8962	.8962
22	.8215	.3801	.3439	.7468	.8131	.7842	.8215
23	.7095	.3801	.3439	.5601	.6653	.6908	.6908
24	.2172	.2241	.362	.362	.5228	.6283	.4668
Max	1.1949	1.1706	1.5912	1.3169	1.3817	1.3717	1.4003
Min	.2172	.2218	.2987	.362	.2172	.168	.2614
Avg	.6350	.6078	.5935	.6707	.6719	.6333	.6729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 203 / 11 KAV ANDHARI - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2987	.3982	.3801	.3921	.4251	.4294
2	.3077	.3142	.4344	.4344	.4481	.4481	.4481
3	.5373	1.1088	.4525	.6268	.6535	.6468	.6535
4	.6984	.8871	.5068	.6626	.7842	1.0719	.8962
5	.8596	.9335	.6268	.7522	.9335	1.262	1.0456
6	.9214	1.0719	.6626	.7522	1.2696	1.3535	1.3443
7	.8954	.9335	1.2254	1.1888	1.1203		1.2323
8	.7701	.9979	1.1157	.9979	1.307	.9795	.4854
9	.5552	1.1458	.8131	.9055	.4294	.2241	.2427
10	.5601	.4668	.462	.5601	.4706	.2427	.2427
11	.3361	.5041	.3174	.3921	.4344	.1867	.2801
12	.2801	.4805	.3174	.3547	.362	.2054	.3734
13	.2614	.3696	.3547	.3734	.2896	.1494	.3361
14	.3395	.3511	.3921	.3547	.2715	.1494	.3547
15	.3734	.3881	.3361	.3361	.2715	.112	.4108
16	.5228	.4251	.3547	.3921	.2534	.1867	.4481
17	.6908	.4435	.5544	.5601	.6283	.3734	.3921
18	.9709	.7207	.9055	.8402	.7207	.8402	.7282
19	1.2696	1.2382	1.0164	.9522	.924	1.0269	1.1389
20	1.3817	.9055	1.0164	1.0082	1.1888	.9896	1.0082
21	.8589	.362	.362	.8402	.8686	.9335	.9335
22	.8962	.3801	.3258	.3361	.8316	.8402	.8029
23	.7842	.362	.3439	.3547	.7947	.7095	.7095
24	.3077	.3174	.3982	.3982	.4108	.5914	.5228
Max	1.3817	1.2382	1.2254	1.1888	1.307	1.3535	1.3443
Min	.2614	.2987	.3174	.3361	.2534	.112	.2427
Avg	.6528	.6419	.5705	.6147	.6691	.6064	.6441



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 201 / 11 KV INDUSTRIAL EXPRESS SHEDDABLE FEEDER HAVING WEEKLY  
FEED Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1886	.415	.415	.1886	.5281	.3772
2	.2263	.1886	.3772	.415	.1829	.4904	.3772
3	.2263	.1886	.3772	.3772	.1867	.4715	.415
4	.2641	.1886	.3772	.3772	.181	.4715	.4338
5	.2641	.3658	.3772	.415	.3734	.5281	.4527
6	.2829	.3772	.3772	.415	.3734	.5281	.4904
7	.2829	.3772	.3772	.4527	.362	.5975	.4904
8	.3772	.362	.7095	.415	.3506	.8402	.3772
9	.7922	.362	.8589	.5281	.9335	1.1203	.7922
10	.8488	.3734	1.0082	.5281	.905	1.251	.9808
11	.8402	.4527	1.2071	.4715	1.3443	1.2071	.9431
12	.8402	.4294	1.3203	.362	1.2696	1.2449	.9431
13	.8488	.4108	1.2071	.3734	1.2136	1.226	1.1203
14	.5658	.4481	1.2449	.3742	1.2136	1.1694	1.1317
15	.6535	.4108	1.226	.2715	.9335	1.1694	.6335
16	.5601	.3734	1.226	.2715	.5975	1.1317	1.0883
17	.543	.3734	.9808	.2801	.9335	1.0185	1.1203
18	.6535	.3395	.9808	.2715	1.2323	1.094	1.1203
19	.5601	.3772	.9808	.2801	.8962	.8488	1.1203
20	.3734	.415	.679	.2801	.6722	.7167	.6602
21	.415	.415	.3772	.3395	.5093	.9145	.3772
22	.415	.4527	.3658	.3772	.4715	.9335	.3734
23	.3772	.415	.415	.2829	.5658	.4904	.3734
24	.2641	.1886	.3772	.4527	.1886	.5601	.3772
Max	.8488	.4527	1.3203	.5281	1.3443	1.251	1.1317
Min	.2263	.1886	.3658	.2715	.181	.4715	.3734
Avg	.4875	.3531	.7435	.3761	.6699	.8563	.6904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 202 / TILAKNAGAR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4668	.5281	.4706	.4525	.5281	.5068
2	.3982	.4668	.4715	.4706	.4382	.4904	.4706
3	.3982	.4525	.4715	.5068	.4668	.4904	.4706
4	.4706	.4715	.5281	.5068	.4668	.5281	.5068
5	.543	.543	.6535	.543	.724	.7842	.7602
6	.724	.6535	.8962	.724	.905	.8962	.8145
7	.9412	.724	.9335	.7964	.905	.9896	.905
8	.8688	.905	.8402	.7602	.9335	.8962	.8326
9	.724	.724	.7468	.724	.724	.7095	.7602
10	.724	.7468	.6908	.724	.7468	.6722	.724
11	.6535	.7468	.6516	.7468	.6908	.6516	.7468
12	.6535	.6722	.5792	.543	.7095	.6516	.724
13	.5601	.5975	.543	.543	.6722	.6878	.5601
14	.5601	.5975	.543	.543	.7095	.5792	.5601
15	.543	.5601	.5792	.543	.6535	.5792	.6535
16	.5601	.5601	.6154	.543	.5281	.5792	.5601
17	.543	.5601	.6516	.6535	.6535	.6516	.6535
18	.6335	.5975	.724	.6535	.7095	.7602	.7468
19	.7468	.5601	.8145	.7468	.7842	.724	.8402
20	.6535	.5601	.6878	.7468	.7468	.724	.7011
21	.6335	.5601	.724	.6878	.6908	.7468	.724
22	.6516	.5975	.543	.6516	.6348	.7468	.5601
23	.5601	.5601	.543	.5258	.5975	.543	.543
24	.5068	.4668	.5658	.5068	.4525	.5601	
Max	.9412	.905	.9335	.7964	.9335	.9896	.905
Min	.3982	.4525	.4715	.4706	.4382	.4904	.4706
Avg	.6104	.5979	.6469	.6192	.6665	.6738	.6663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 203 / NEW TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4382	.4527	.4805	.4525	.4715	.462
2	.4066	.4668	.415	.4805	.4525	.4904	.4805
3	.4066	.4525	.415	.4805	.4382	.5281	.5175
4	.5175	.4525	.4904	.5175	.4525	.5093	.499
5	.5914	.543	.5975	.5544	.6135	.6535	.6468
6	.8316	.724	.7282	.7392	.7888	.8589	.8316
7	.8501	.905	.8589	.7762	.8764	.9335	.8501
8	.8871	1.1203	.8402	.8871	.8764	1.0269	.924
9	.8501	.905	.8962	.8871	.7888	.8402	.8131
10	.7023	.9955	.8402	.961	.7468	.8589	.8131
11	.5601	.9335	.7392	.7468	.7468	.7392	.7468
12	.6535	.7842	.5914	.6535	.7095	.6283	.7468
13	.543	.7095	.5544	.6335	.7282	.6653	.543
14	.543	.6722	.5544		.6722	.4805	.543
15	.5601	.6722	.5914	.6335	.6348		.5601
16	.543	.6348	.6283		.5975	.6653	.3734
17	.5601	.5975	.7392	.8402	.6535	.6653	
18	.724	.5975	.7392	.8402	.7095	.7392	.7468
19	.8402	.5601	.8316	.8145	.8215	.7392	.8145
20	.7468	.5601	.7392	.7468	.6722	.7392	.724
21	.6653	.5601	.6335	.7023	.6161	.6535	.7023
22	.5544	.5601	.543	.6283	.5975	.6335	.5601
23	.5258	.5601	.5544	.5601	.5281	.5544	.5601
24	.4805	.4525	.4715	.5175	.4525	.4715	.5175
Max	.8871	1.1203	.8962	.961	.8764	1.0269	.924
Min	.4066	.4382	.415	.4805	.4382	.4715	.3734
Avg	.6229	.6607	.6435	.6855	.6511	.6759	.6511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 204 / TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4668	.4527	.4435	.4525	.4904	.4805
2	.4251	.4668	.4527	.4435	.4525	.4527	.4435
3	.4435	.4525	.4904	.4805	.4525	.4904	.4805
4	.4805	.4668	.5601	.4805	.4382	.6036	.5914
5	.5175	.5601	.6535	.5544	.543	.7095	.7023
6	.7392	.6535	.7468	.7392	.724	.8402	.7762
7	.8501	.724	.7842	.7762	.8402	.8589	
8	.7762	.8402	.7842	.8131	.8436	.8962	.8316
9	.5175	.8145	.8402	.7762	.7011	.8215	.7762
10	.7392	.724	.8215	.8131	.7468	.7655	.7392
11	.7468	.7468	.7392	.8145	.7468	.7023	.9335
12	.6535	.6722	.6283	.6535	.7095	.5544	.9335
13	.6661	.5487		.6535	.6722	.5544	.5601
14	.7468	.6348	.924	.6135	.6348	.6653	.5601
15	.7468	.5788	.8316	.6335	.5975	.7392	.6535
16	.7468	.5601	.7392	.6535	.7468	.7392	.7468
17	.7468	.4904	.7392	.7468	.7095	.7392	.7468
18	.8402	.4715	.8131	.724	.7842	.8871	.8402
19	.8145	.5281	.8501	.8145	.8962	.7762	.8402
20	.724	.5228	.7392	.7468	.7095	.7392	.7468
21	.6653	.547	.6468	.7023	.6348	.6535	.7023
22	.6283	.5601	.5544	.6283	.6348	.6135	
23	.5601	.5601	.5175	.543	.5281	.5544	.5601
24	.4805	.4668	.4904	.4805	.4668	.5093	.5544
Max	.8501	.8402	.924	.8145	.8962	.8962	.9335
Min	.4066	.4525	.4527	.4435	.4382	.4527	.4435
Avg	.6526	.5857	.6869	.6554	.6527	.6815	.6909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 206 / 11 KV BALAJINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4668	.4715	.3696	.4382	.4527	.4435
2	.4066	.4525	.4715	.3696	.4525	.4904	.4435
3	.3696	.4668	.4715	.3696	.4525	.4527	.4805
4	.3696	.4525	.5601	.4066	.4382	.5281	.5175
5	.4805	.5601	.6535	.5175	.5258	.6722	.6653
6	.5914	.6335	.7095	.6653	.724	.7468	.7392
7	.7392	.724	.7468	.7392	.6335	.8402	.7762
8	.6468	.8145	.7095	.7023	.6535	.7468	.7762
9	.7023	.8145	.6348	.7023	.6335	.6348	.6468
10	.5544	.6335	.5975	.6653	.6135	.5281	.5544
11	.543	.6173	.4066	.5601	.5601	.5175	.4668
12	.6535	.5658	.4066	.4668	.5601	.3326	.4668
13	.4525	.4668	.3696	.3734	.6348	.3696	.3734
14	.3734	.5228	.3696	.3734	.5975	.3696	.3734
15	.3734	.5228	.4066	.3734	.5601	.3696	.3734
16	.3734	.5228	.4066	.3628	.415	.4066	.362
17	.3734		.4805	.4668	.4904	.4066	.362
18	.5601		.5281	.4668	.5975	.4805	.5601
19	.6535	.4854	.5175	.5601	.5975	.4805	.6335
20	.543	.5601	.5544	.5601	.5281	.5544	.5601
21	.5544	.5601	.5601	.5544	.5281	.5601	.5914
22	.5175	.5658	.5601	.5544	.5281	.5601	
23	.4668	.5281	.4435	.4525	.4904	.4805	.4668
24	.4435	.4668	.4527	.4066	.4668	.4715	.4435
Max	.7392	.8145	.7468	.7392	.724	.8402	.7762
Min	.3696	.4525	.3696	.3628	.415	.3326	.362
Avg	.5062	.5638	.5204	.5016	.5467	.5189	.5251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 202 / YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0572	.0543	.0543	.0572	.056	.0543
2	.056	.0572	.056	.0543	.0572	.056	.0543
3	.0747	.0762	.0747	.0724	.0572	.0747	.0724
4	.1307	.1143	.1307	.1086	.0762	.1307	.1086
5	.181	.1509	.181	.1448		.1867	.181
6	.2054	.2054	.1991	.1991	.1494	.2054	.2172
7	.2427	.2772	.2378	.2172	.2218	.2241	.2534
8	.2241	.1905	.2054	.2172	.1905	.2427	.2353
9	.1867	.2667	.1629	.2172	.1715	.1867	.181
10		.2241	.1086	.1867	.1307	.112	.1463
11	.1143	.168	.0724	.1294	.1307	.112	.0934
12	.0754	.0934	.0543	.0924	.0934	.112	.0732
13		.0747	.0543	.0762	.0724	.056	.0747
14	.0953	.056	.0543	.0572	.0747	.056	.056
15	.1307	.0549	.0724	.0762	.112	.0934	.056
16	.1524	.0747	.0905	.0762	.0934	.0549	.0747
17	.1905	.0914	.0905	.1143	.0934	.1267	
18	.2286	.0934	.1629	.1334	.112	.1448	.1307
19	.1905	.1494	.1629	.1715	.168	.181	.1867
20	.1143	.1307	.1448	.1143	.1307	.1629	.168
21	.0572	.0747	.1086	.0762	.0934	.1086	.112
22	.0572	.056	.0724	.0572	.0732	.0724	.0747
23	.0572	.056	.0543		.0747	.0724	.0747
24	.0747	.0572	.0543		.0572	.0543	
Max	.2427	.2772	.2378	.2172	.2218	.2427	.2534
Min	.056	.0549	.0543	.0543	.0572	.0543	.0543
Avg	.1316	.1188	.1108	.1203	.1083	.1201	.1218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 204 / MAHADEV MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4191	.4854	.5068	.4572	.4854	.543
2	.4854	.4572	.4854	.5249	.4763	.4854	.5792
3	.5601		.5601	.543	.5525	.5601	.6335
4	.6161	.547	.6161	.5792	.6859	.6161	.7602
5	.8962	.6722	.823	.8688	.7621	.8962	1.0136
6	1.251	.7947	1.251	1.1584	1.0974	1.251	1.3213
7	1.307	1.1888	1.2696	1.1584	1.2894	1.3443	1.448
8	1.3443	1.4861	1.251	1.3213	1.467	1.4003	1.3937
9	1.2883	1.6194	1.1584	1.3394	1.3717	1.2254	1.2489
10	1.3336	1.4937	1.3394	1.2803	1.2323	1.2136	1.2323
11	1.086	1.1203	.9231	1.086	1.1203	1.1203	1.1016
12	.8775	1.1403	.8869	.7316	.7468	.8589	.8962
13	.8002	.7468	.724	.7392	.7468	.8215	.7468
14	.7621	.7059	.6154	.6287	.6535	.5975	.5601
15	.6653	.5729	.6516	.6668	.5487	.5415	.6535
16	.7621	.6161	.5973	.7621	.5144	.7282	.6908
17	.8573	.7059	.7783	.8764	.7468	.905	.8775
18	1.0479	.7282	.905	1.0479	.8962	1.0317	.9896
19	1.1812	1.0425	1.0498	1.2003	1.0456	1.086	1.1203
20	.9717	.8413	.905	.9526	.9335	.9412	.9709
21	.7621	.8215	.8688	.8573	.6908	.8145	.8402
22	.7621	.7468	.6516	.8002	.6535	.6878	.7095
23	.6287	.5973	.5973	.6668	.5975	.6335	.6535
24	.5975	.5335	.543		.5335	.543	
Max	1.3443	1.6194	1.3394	1.3394	1.467	1.4003	1.448
Min	.4854	.4191	.4854	.5068	.4572	.4854	.543
Avg	.8887	.8521	.8307	.8825	.8258	.8662	.9124

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 205 / AURANGABAD NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.381	.4668	.3982	.4001	.4668	.4344
2	.4668	.4001	.4668	.4163	.4382	.4668	.4525
3	.4668	.4382	.4668	.4344	.4763	.4668	.4887
4	.5601	.4763	.5601	.4344	.5716	.5601	.5973
5	.6516	.5601	.6722	.6516	.6668	.6722	.724
6	.8215	.7095	.8215	.724	.8573	.8215	.905
7	.724	.961	.7655	.7964	.9231	.8215	.9955
8	.8962	1.1431	.8029	.8326	.9907	.9522	.9774
9	.8402	1.2955	.7964	.8688	1.0288	1.0082	.9412
10		1.1203	.724	.9145	.8383	.9335	.9149
11	1.0288	.9335	.6878	.8871	.8962	.8402	
12	.7468	.9412	.6335	.7023	.6878	.6535	.6348
13		.7362	.5792	.6097	.5975	.5601	.6535
14	.724	.5258	.5068	.5144	.5228	.5228	.5975
15	.6348	.5304	.543	.5335	.5601	.5415	.5601
16	.6668	.5041	.6154	.6097	.5249	.6161	.5975
17	.8002	.5788	.724	.724	.6161	.7602	.6908
18	.9526	.5788	.8688	.8383	.7602	.8145	.8029
19	1.0479	.7655	.905	.9717	.7468	.8869	.9149
20	.8002	.6348	.8326	.7621	.6535	.7964	.8215
21	.7621	.7468	.6878	.6287	.5788	.7059	.7282
22	.6097	.5975	.5973	.5716	.5601	.6154	.57
23	.5144	.5041	.543	.4763	.4694	.5068	.5228
24	.5228	.4382	.4344		.4382	.4887	
Max	1.0479	1.2955	.905	.9717	1.0288	1.0082	.9955
Min	.4668	.381	.4344	.3982	.4001	.4668	.4344
Avg	.7139	.6875	.6542	.6652	.6585	.6866	.7057



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 201 / BHAGOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144	.4801	.3772	.3429	.3429
2		.5487	.5487	.5487	.4115	.3429	.3429
3		.6516	.583	.6173	.4458	.4458	.4458
4		.7202	.7888	.7202	.4801	.5487	.5144
5		.7202	.9259	.7888	.6173	.6859	.5487
6		.7373	1.166	.8916	.7202	.7888	.5487
7		1.3927	1.3717	1.2346	.7202	.7545	.583
8	1.406	1.4091	1.3375	1.406	.7545	.7373	.6859
9	.4801	.3429	.5658	.4458	1.2346	1.0974	1.2003
10	.4801	.3772	.4287	.4115	1.0117	.9835	1.0974
11	.4115	.3772	.3258	.3772	1.0117	.9602	.9602
12	.2572	.3429	.2743	.3429	1.0288	.7202	.8573
13	.2572	.5144		.3429	.823	.6516	.823
14		.5487	.2058	.3086	.8573	.6173	.6859
15	.3429	.3086	.1715	.3086	.8916	.5487	
16	.463	.2743	.2401	.2058	.9602	.6859	.9431
17	.5144	.1715	.3086	.2743	.3086	.4458	.2401
18	.5487	.2743	.3086	.3772	.3086	.3429	.4458
19	.7202	.6859	.6516	.5144	.6687	.5487	.7545
20	.6516	.583	.5487	.583	.5658	.583	.6173
21	.4458	.5487	.4801	.4801	.4115	.5144	.5144
22	.3772	.3772	.3944	.4458	.3772	.4115	.3429
23	.583	.4115	.4973	.4458	.3429	.3429	.3429
24		.4973	.5144	.463	.3429	.3429	.3429
Max	1.406	1.4091	1.3717	1.406	1.2346	1.0974	1.2003
Min	.2572	.1715	.1715	.2058	.3086	.3429	.2401
Avg	.5293	.5554	.5718	.5423	.6530	.6018	.6165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 202 / JATEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9259	.8916	.8916	2.6791	2.0645	2.332
2		.9259	.9259	.8916	2.6113	2.0972	2.3663
3		.9945	.9259	.9945	2.7808	2.2283	2.572
4		1.1317	1.0974	1.0974	2.8147	2.3594	2.572
5		1.2346	1.3032	1.166	2.8826	2.4249	2.6406
6		1.3375	1.3717	1.2689	2.9504	2.4905	2.7435
7			1.4403	1.2346	2.9843	2.9492	2.7435
8	1.2689	1.0631	1.5432	.703	2.6825	2.6216	3.0178
9	1.3032	1.0288	.9259	.7545	1.0288	1.0288	1.1317
10		.9259	.9945	.7888	.8573	.9945	.5144
11	.6859	.8573	.823	.7545	.6516	.6173	.9945
12	.6859	.6859	.7202	.6859		.6859	.8573
13	.6859	.6173	.7202	.5144	.583	.7202	.8573
14	.6859	.6516	.7545	.5144	.6173	.6516	
15	.6516	.6516	.7888	.5144	.6173	.583	.823
16	.6687	.6859	.5487	.3772	.6859	.7545	.9259
17	2.9492	3.5322	3.2114	3.0178	.7202	.7202	1.0288
18	1.5729	3.5269	3.408	3.4252	.8573	.7373	1.0631
19	1.6385	1.5089	3.3425	1.1869	1.4403	1.2003	1.4746
20	1.4419	1.406	1.4403	.9602	1.3032	1.3717	1.4403
21	3.0476	3.8409	1.0974	2.1262	.9259	1.166	1.5432
22	3.2769	3.3913	2.8509	2.9843	.9259	.9259	1.8176
23	2.9492	1.6956	2.7854	2.915	1.8861	1.8861	1.8313
24		2.7199	1.4403	2.4249	2.713	2.0645	2.332
Max	3.2769	3.8409	3.408	3.4252	2.9843	2.9492	3.0178
Min	.6516	.6173	.5487	.3772	.583	.583	.5144
Avg	1.5675	1.5365	1.4730	1.3413	1.6608	1.4726	1.7227

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 203 / MAHALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458	1.0288	.4458	.9945	.5487	1.0288
2		.4458	.9945	.4801	1.0288	.5487	.9259
3		.5487	.9945	.5487	1.0974	.6516	.9259
4		.6516	1.0974	.9259	1.166	.9602	.9259
5		.7545	1.166	.9602	1.3032	1.166	1.0288
6		1.0288	1.3375	1.0288	1.3375	1.2346	1.166
7		1.3032	1.3717	1.166	1.3717	1.3904	1.2003
8	1.0852	1.2003	1.3375	1.0288		1.3717	1.3032
9	1.6956	2.332	2.1262	2.7435	.6859	1.0974	.6173
10	2.4006	2.4006	2.0576	2.572	.7202	1.0288	.2058
11	2.4006	2.4006	2.2291	2.4006	.6859	.8573	.5487
12	2.332	2.3663	2.4006	2.2291	.6173	.5487	.5487
13	2.2291	2.332	2.0576	2.0576	.6516	.5144	
14		2.4691	2.2634	2.1605	.6859	.5144	.6173
15	2.2291	2.2634	2.0576	2.0576	.6859	.5487	.5487
16	2.0576	2.0576	1.989	2.0576	.6516	.583	.6173
17	1.0974	.6516	.6516	.6516	2.3594	2.7435	2.6452
18	1.166	.8916	.8916	.9945	2.1628	2.572	2.3061
19	.8916	1.166	.8916	1.0631	2.1628	2.4006	2.5434
20	.7545	1.406	.823	1.3717	2.0972	2.2291	2.5034
21	.6173	1.2689	.6173	1.3375	1.7695	1.8861	2.1262
22	.5487	.6859	.5487	1.2689	1.6385	1.5432	1.2209
23	.4801	.9602	.4115	1.166	1.3565	1.6461	1.166
24		.4115	1.0288	.4115	.9945	1.166	1.8861
Max	2.4006	2.4691	2.4006	2.7435	2.3594	2.7435	2.6452
Min	.4801	.4115	.4115	.4115	.6173	.5144	.2058
Avg	1.4657	1.3518	1.3489	1.3803	1.2272	1.2396	1.2437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 204 / KATE PIMPLGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.5487	.823		.4801	.4409
2		.823	.6173	.9602		.4801	.4458
3		.9602	.823	1.2346		.5487	.4409
4		1.0631	.9945	1.2346		.6173	.4801
5		1.0974	1.2689	1.2689		.6516	.5087
6		1.4922	1.8652	1.2689		.6859	.5144
7		2.1628	2.2043	2.0972		.5487	.5144
8		1.9662	2.1262	1.704		.4801	.5144
9	.3429	.4115	.5658	.4458		2.0576	1.704
10	.3429	.4458	.5658			2.0008	1.6385
11	.3429	.3429	.4801		1.5432	1.749	1.6385
12	.5487	.3429	.3429		1.3717	1.5432	1.5074
13	.5144	.2743	.5596	.4458	1.3717	1.406	1.4922
14	.3429	.3429	.3772	.4458	1.0288	1.3717	1.3565
15	.3429	.2743	.2572	.2572	1.166	1.2209	1.4922
16	.5487	.3052	.3086	.3429		1.4403	1.4922
17	.4801	.3429		.3429	.4115	.2058	.1715
18	.5487	.4115	.4115	.3772	.4801	.2401	.1715
19	.5487	.583	.5487		.6859	.3429	.4458
20	.5487	.6173	.5487		.6859	.4115	.4458
21	.4527	.4115	.4115		.5487	.4458	.4115
22	.3429	.3086	.3429		.4801	.4458	.4115
23	.6859	.4801	.6516		.4801	.4458	.3772
24	.6859	.6859	.4801	.6859		.4801	.4458
Max	.6859	2.1628	2.2043	2.0972	1.5432	2.0576	1.704
Min	.3429	.2743	.2572	.2572	.4115	.2058	.1715
Avg	.4762	.7027	.7522	.8709	.8545	.8458	.7942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 206 / PANVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516	.9259	1.0288	1.0288	.823	1.0288
2		.7202	.9945	1.0631	1.0288	.8916	1.0288
3		.823	.9602	1.166	1.0631	.8916	1.0288
4		.8916	1.0974	1.2346	1.0631	.9602	1.166
5		.9602	1.1317	1.2346	1.166	.9945	1.2003
6		1.0288	1.3032	1.3717	1.2689	1.0288	1.2003
7		1.2003	1.3375	1.5089	1.2003	1.1317	1.3032
8		1.3032	.9259	1.166	1.0631	1.3717	1.3717
9	2.4006	2.2291	3.6008	3.4294	1.1317	1.166	1.2003
10	1.5261	3.2579	2.7435	3.6008	1.0288	.9259	.6001
11	3.4294	3.6626	3.4294	3.5322	.8573	.9602	1.0974
12	3.3532	3.4294	3.7037	3.4294		1.0288	1.166
13	3.5665	3.6694	3.5665	3.3951		.9602	1.2689
14			3.5608	3.0864	.6859	.9945	
15	3.9438	3.4294	3.4294	3.0178	.7888	1.0974	1.2346
16	1.166		3.4979	3.3608	.823	1.0288	.9259
17	1.1317	1.0288	.9945	.7202	3.4408	3.7723	3.9567
18	1.0974	1.0974	1.3717	.7202	3.6046	3.738	3.7555
19	1.0288	1.5089	.7373	1.0288	1.0974	1.5432	1.5432
20	1.0288	1.3717	1.5089	1.0288	1.1317	1.7147	1.4746
21	1.0631	1.3717	.9602	1.0631	3.0476	3.738	3.7723
22	1.0288	1.5089	1.166	1.166	1.2689	3.4294	3.3196
23	.823	1.166	.8573	1.0288	1.3032	1.7147	3.1893
24		.6516	.9259	1.0288	.9945	1.2003	3.0864
Max	3.9438	3.6694	3.7037	3.6008	3.6046	3.7723	3.9567
Min	.823	.6516	.7373	.7202	.6859	.823	.6001
Avg	1.8991	1.6801	1.8638	1.8504	1.3676	1.5461	1.7791

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 207 / MALISAGAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8916	.9602	.9602	.7202	.9945	1.0288
2		.9259	.9945	.9945	.823	1.1831	1.3717
3		1.0631	.9945	1.0631	1.0631	1.2346	1.4746
4		1.166	.9945	1.166	1.166	1.3032	1.4746
5		1.2003	1.0631	1.2346	1.3032	1.3375	1.6385
6		1.2003	1.0974	1.2689	1.5432	1.4074	1.9334
7		.9602	1.166	1.3032	1.6118	2.1792	2.1605
8		1.0288	.9945	.823	1.4403	1.9334	1.8861
9	1.0288	.8573	.6687	.8573	.8745	.823	.823
10	.6859	.6859	.4801	.6516	.8573	.6173	.6859
11	.6859	.6516	.3601	.5487	.5144	.4801	.5316
12	.5316	.6859	.3429	.3429	.5144	.4115	.4801
13	.4458	.6173		.4801		.4801	.5144
14		.6859	.4801	.4115	.4801	.4458	.5144
15	.5144	.7202	.4458	.6859	.4458	.4458	
16	.5087	.7545		.3429	.4115	.4801	.5316
17	2.0481		2.0972	2.0348	.6001	.6516	.583
18	2.0972	1.6118	2.1136	1.933	.6344	.7888	.6516
19	1.5074	1.9204	1.5402	1.8861	1.166	1.166	1.166
20	1.3413	1.3032	1.3763	1.3375	1.3203	1.3032	1.0974
21	1.2239	1.0974	1.1317	1.153	1.0631	1.2003	1.0631
22	1.1736	.9945	1.0288	1.0974	1.0802	1.0288	1.0288
23	.9774	.9602	1.0631	1.0288	.7888	.8573	1.0288
24		.8916	.9602	.9774	.583	.7888	.8573
Max	2.0972	1.9204	2.1136	2.0348	1.6118	2.1792	2.1605
Min	.4458	.6173	.3429	.3429	.4115	.4115	.4801
Avg	1.055	.9945	1.0161	1.0243	.9132	.9809	1.0663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 208 / SIRASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3904	1.166	.9602	1.0631	.823	1.3032
2		1.4243	1.2003	.9945	1.0974	.8916	1.3717
3		1.4582	1.2346	.9945	1.166	.8916	1.3717
4		1.4582	1.2689	1.0631	1.3032	.9945	1.3717
5		1.4922	1.3032	1.0974	1.3226	1.0631	1.3032
6		1.0288	1.3375	1.1317	1.406	1.0974	1.5432
7		1.2003	1.3717	1.2174	1.4746	1.1488	1.5432
8		.9945	1.166	.9602	1.3032	1.286	1.3375
9	3.4294	3.5837	2.915	3.4294	1.3375	1.286	1.4403
10		3.0864	3.3608	.2058	1.3375	1.3032	1.3717
11	3.4294	3.6008	3.4122	3.0864	1.3032	1.3375	1.2346
12	2.7092	3.4294	3.3608	3.1893		1.4403	1.2003
13	3.4294	3.6008	3.0693	2.915	1.2689	1.3717	1.3032
14	3.4979	1.3717	3.3608	3.0864	1.2003	1.3375	
15	.1715	3.2579	3.3951	2.9492	1.3032	1.3032	1.2517
16	3.6351	1.8861	3.4294	1.3032	1.3717	1.0288	.823
17	1.3032	1.3032		1.2689	3.3425	3.4637	3.6286
18	1.4582	1.166	1.3203	1.5432	3.5555	1.4403	3.5208
19	1.9334	1.3375	1.5261	1.3375	1.2209	3.3608	3.8226
20	1.9498	1.3717	1.3203	1.4746	1.2346	3.1893	3.5208
21	2.0645	1.3717	1.2346	1.5432	1.3717	3.0864	3.0476
22	1.8842	1.3375	1.2003	1.4746	1.4922	2.8464	2.5484
23	1.3599	1.2689	1.0631	1.3717	1.4582	2.6406	2.5034
24		1.3735	1.166	.9602	1.0288	1.3375	2.2634
Max	3.6351	3.6008	3.4294	3.4294	3.5555	3.4637	3.8226
Min	.1715	.9945	1.0631	.2058	1.0288	.823	.823
Avg	2.3039	1.8664	1.9644	1.6482	1.4766	1.6654	1.9403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 209 / CHINCHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8916	.7888	.6173	.7888	.5487	.6516
2		.9602	.823	.823	.823	.5487	.6516
3		1.166	.8573	1.0117	.8573	.6516	.6859
4		1.2689	1.166	1.1488	.9259	.7202	.7888
5		1.3546	1.3032	1.3717	.9945	.823	.9945
6		1.6876	1.8861	1.4232	1.0631	.8573	1.0974
7		2.3594	2.1026	2.13	1.0974	.8573	1.1317
8	2.3663	1.8351	2.0233	1.8023	1.0631	.8059	1.0288
9	.6173	.8573	.6859	.6173	1.6461	1.6804	1.4243
10		.8573	.6859	.5487	1.7147	1.4582	1.4582
11	.5144	.7888	.583	.4458	1.3717	1.3375	1.56
12	.4801	.5487	.6173	.4115	1.5432	1.3375	1.3565
13	.4801	.5487	.583	.4115	1.7147	1.0974	1.2346
14	.4801	.5144	.5487	.3772	1.5432	.8817	1.166
15	.6516	.5426	.6516	.3429	1.5432	.8573	1.3565
16	.6173	.5144	.6859	.3429	1.7147	1.0631	1.166
17	.823	.5487	.5487	.4458	.3429	.9259	.4458
18	1.0288	.6516	.6516	.6516	.5487	.8573	.583
19	.9945	.9259	.8573	.7202	.7373	.9602	.9945
20	.823	.7888	.6516	.7888	.7202	.9602	1.166
21	.6001	.6173	.5144	.823	.583	.8573	1.0974
22	.5487	.6516	.5144	.7888	.6173	.7202	.583
23	.8916	.6516	.6001	.6859	.5316	.6516	.5487
24		.8916	.7202	.6173	.7202	.5487	.6516
Max	2.3663	2.3594	2.1026	2.13	1.7147	1.6804	1.56
Min	.4801	.5144	.5144	.3429	.3429	.5487	.4458
Avg	.7945	.9343	.8771	.8061	1.0502	.9170	.9926



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 201 / LADGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.4746	1.5432	1.6194	1.7404	1.7147	.4668
2	1.4918	1.4746	1.5432	1.6194	1.6575	1.7147	.4668
3	1.4089	1.4746	1.5432	1.6194	1.6575	1.7147	.4668
4	1.4089	1.4746	1.5432	1.6194	1.7404	1.7147	.4668
5	1.4918	1.5565	1.8861	1.7004	1.8233	1.8861	.5601
6	1.5746	1.5565	1.9719	1.7004	1.8023	1.8861	.5601
9							1.9528
10							2.0243
11							2.0243
12							2.1862
13							2.1052
14							2.0243
15							2.0243
16							2.0243
17	.2801	.2572	.2829	.2829	.2572	.2801	.1886
18	.3734	.3429	.2772	.2829	.3429	.3734	.2829
19	.5601	.4287	.4715	.4668	.4287	.4668	.4668
20	.5601	.3429	.4715	.4668	.3429	.5601	.4715
21	1.5623	1.8004	1.7004	1.4918	1.4575	.4668	.4668
22	1.7185	1.8861	1.7814	1.8023	1.8861	.4668	.4715
23	1.5623	1.8861	1.7814	1.8023	1.8861	.4668	.4715
24	1.5089	1.5623	1.7147	1.7814	1.8233	1.7147	.4668
Max	1.7185	1.8861	1.9719	1.8023	1.8861	1.8861	2.1862
Min	.2801	.2572	.2772	.2829	.2572	.2801	.1886
Avg	1.2138	1.2513	1.3223	1.3040	1.3462	1.1019	1.0291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 202 / SAWKHED GANAGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2801	.3429	.3772	.2829	.3429	.9745
2	.2829	.2801	.3429	.3772	.2829	.3429	.9745
3	.2829	.3734	.3429	.3772	.2829	.3429	.9745
4	.2829	.3734	.8573	.3772	.2829	.3429	.9745
5	.2829	.3734	.5144	.5658	.4668	.5144	1.0631
6	.4668	.6401	.6859	.6468	.7392	.6001	1.1469
9	1.0174	1.1469	1.286	1.2955	1.326	1.2003	
10	1.3108	1.3717	1.3765	1.3765	1.4575	1.5565	
11	1.4746	1.5432	1.4575	1.326	1.4575	1.4746	
12	1.5565	1.5432	1.4575	1.4089	1.4575	1.3927	
13	1.4746	1.5432		1.4918	1.3717	1.4746	
14	1.2289	1.4575	1.4575	1.4089	1.3717	1.3927	
15	1.2289	1.4575	1.5384	1.4089	1.3717	1.3108	
16	1.2289	1.4575	1.5384	1.4251		1.3927	
17	.2801	.1715	.1886	.1886	.1715	.1867	.2829
18	.3734	.3429	.2801	.2829	.3429	.3734	.3772
19	.5144	.5144	.4668	.4668	.4287	.5601	.6535
20	.5601	.5144	.4668	.4668	.4287	.4668	.6535
21	.3734	.3429	.3734	.4668	.3429	.9745	.9717
22	.2801	.3429	.3772	.3734	.3429	.9745	1.2955
23	.2801	.3429	.3772	.3734	.3429	.9745	1.2955
24	.2829	.2801	.3429	.3772	.2829	.3429	.9745
Max	1.5565	1.5432	1.5384	1.4918	1.4575	1.5565	1.2955
Min	.2801	.1715	.1886	.1886	.1715	.1867	.2829
Avg	.6976	.7588	.7653	.7663	.7064	.8425	.9009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 203 / PURANGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.6401	.6001	.6401	.5601	.6859	2.0309
2	.7392	.6401	.6859	.7316	.5601	.6859	2.0309
3	.7392	.7316	.8573	.7316	.5601	.6859	2.0309
4	.7392	.7316	1.0288	.8954	.6535	.6859	2.0309
5	.905	.8859	1.2003	.9745	.8316	.8573	2.1872
6	1.086	1.0631	1.1145	1.1393	1.086	1.1145	2.2929
9	2.5911	2.6882	3.0864	3.0769	2.915	3.1722	
10	3.0045	3.0864	3.2388	3.0483	3.2579	3.3208	
11	3.0045	3.2579	3.2388	3.0407	3.3436	3.1626	
12	2.7673	3.2579	3.0769	3.0769	3.2579	3.0045	
13	3.0045	3.2579		2.9607	3.0864	2.9492	
14	2.8464	3.2579	2.672	2.8006	2.915	2.9254	
15	2.8464	3.4294	3.0769	2.834	2.915	2.9254	
16	2.6882	3.4294	3.0769	2.915	3.1722	2.9254	
17	.5601	.6001	.5544	.5601	.5144	.5601	.5144
18	.7316	.6001	.724	.724	.6859	.5601	.7087
19	.9745	.8573	.8764	.905	.8573	.7973	.905
20	.9745	.8573	.724	.8316	1.0288	.8859	1.0517
21	.7316	.6001	.6335	.8316	.6859	2.0557	2.1052
22	.6401	.6001	.6335	.7392	.6859	2.2929	2.5101
23	.6401	.6001	.6401	.7392	.6859	2.372	2.5101
24	.7392	.6401	.6001	.6401	.5601	.6859	2.1872
Max	3.0045	3.4294	3.2388	3.0769	3.3436	3.3208	2.5101
Min	.5601	.6001	.5544	.5601	.5144	.5601	.5144
Avg	1.5315	1.6233	1.5400	1.5835	1.5827	1.7869	1.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 204 / 11KV KAPUS WADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	1.0631	.8573	1.0526	1.1736	1.0288	.3734
2	1.0174	1.0631	.8573	1.0526	1.1736	1.0288	.3734
3	.8383	1.0631	.8573	1.0526	1.1736	1.0288	.4668
4	.8383	.8859	.8573	1.0526	1.1736	1.0288	.4668
5	.9221	1.0631	1.0288	1.1336	1.2574	1.2003	.4668
6	1.0898	1.0631	1.1145	1.1336	1.2574	1.2003	.5601
9							1.2289
10							1.4575
11							1.5384
12							1.6194
13							1.3765
14							1.2955
15							1.2146
16							1.3765
17	.3734	.3429	.2829	.3734	.3429	.2801	.1886
18	.4668	.4287	.462	.3734	.3429	.3734	.1867
19	.4668	.4287	.4668	.4668	.4287	.4668	.4668
20	.4668	.4287	.4668	.4668	.4287	.4668	.4668
21	.8859	.8573	.8907	.7716	.7716	.3734	.4668
22	1.1517	1.1145	1.1336	1.1736	1.0288	.3734	.4668
23	1.1517	1.0288	1.1336	1.1736	1.2003	.3734	.3772
24	1.0174	1.1517	.8573	1.1336	1.1736	1.2003	.3734
Max	1.1517	1.1517	1.1336	1.1736	1.2574	1.2003	1.6194
Min	.3734	.3429	.2829	.3734	.3429	.2801	.1867
Avg	.8360	.8559	.8047	.8865	.9233	.7445	.7640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 205 / 11KV BABHULGAON GANGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3734	.8573	.3772	.3772	.3429	2.0309
2	.3734	.3734	.3429	.3772	.3772	.3429	2.0309
3	.3734	.4668	.3429	.3734	.3772	.3429	2.0309
4	.3734	.4668	.3429	.4668	.4715	.3429	2.0309
5	.6468	.7316	.5144	.6401	.5601	.5144	2.1872
6	.823	.7973	.6859	.8059	.8316	.6859	2.1872
9	2.4291	2.6882	2.915	2.915	3.0045	3.0007	
10	2.8464	3.2579	3.1579	3.1579	3.2579	3.0045	
11	3.0045	3.2579	3.1579	3.0769	3.2579	2.8464	
12	3.0836	3.3436	3.1579	3.0769	3.0864	2.6882	
13	2.8464	3.3436		3.0769	3.0864	2.7673	
14	2.7673	3.2579	3.0769	2.9959	3.0864	2.7673	
15	2.8464	3.2579	3.1579	2.9959	2.915	2.6882	
16	2.6882	3.2579	3.1579	2.9959	2.915	2.5301	
17	.2801	.4287	.2801	.3734	.3429	.1867	.2743
18	.5601	.5144	.3572	.4668	.8573	.2801	.3658
19	.6401	.6001	.6401	.6468	.5144	.4668	.5544
20		.6001	.6401	.6535	.6001	.5601	.5544
21	.4668	.6001	.462	.5601	.5144	2.1348	2.2672
22	.3734	.5144	.462	.4668	.3429	2.2929	2.4291
23	.3734	.3429	.3696	.4668	.3429	2.2929	2.4291
24	.3734	.3734	.3429	.3734	.3772	.3429	2.1091
Max	3.0836	3.3436	3.1579	3.1579	3.2579	3.0045	2.4291
Min	.2801	.3429	.2801	.3734	.3429	.1867	.2743
Avg	1.3594	1.4931	1.3534	1.4245	1.4317	1.5192	1.6772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 206 / BHAOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2939	2.2138	2.572	2.2672	2.2939	2.2291	.8859
2	2.2939	2.2138	2.572	2.2672	2.2939	2.2291	.8859
3	2.2119	2.2138	2.572	2.2672	2.2939	2.2291	.8859
4	2.2119	2.2138	2.572	2.4291	2.2939	2.2291	.8859
5	2.4291	2.372	2.7435	2.4291	2.2939	2.4006	.9831
6	2.5911	2.372	2.7435	2.4291	2.5911	2.7435	1.1469
9							3.0836
10							2.1052
11							2.1052
12							2.0243
13							1.9433
14							1.9433
15							1.9433
16							1.9433
17		.9431	.905	.924	.7716	.8859	.7973
18	.7316	1.2003	1.086	1.086	1.0288	1.0631	.8859
19	1.3108	1.3717	1.3717	1.4022	1.3717	1.3108	1.3717
20	1.3927	1.2003	1.2269	1.2403	1.0288	1.3927	1.2003
21	1.5623	2.4006	2.2672	2.2939	2.4006	1.2289	1.0631
22	2.5301	3.0864	2.5101	2.5101	2.6578	.9745	.8954
23	2.5301	3.0864	2.5101	2.5101	2.572	.8859	.905
24	2.2939	2.5301	2.7435	2.4291	2.4291	2.4006	.8859
Max	2.5911	3.0864	2.7435	2.5101	2.6578	2.7435	3.0836
Min	.7316	.9431	.905	.924	.7716	.8859	.7973
Avg	2.0295	2.1013	2.1711	2.0346	2.0229	1.7288	1.3986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 207 / mhaski

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	1.7185	2.0576	2.1052	2.13	2.0576	.7316
2	1.8233	1.7394	2.0576	2.1052	1.9662	2.0576	.7316
3	1.8233	1.7394	2.0576	2.1052	1.9662	2.0576	.7316
4	2.0481	1.8976	2.0576	2.1862	2.0481	2.0576	.823
5	2.13	2.2138	2.4006	2.2672	2.1862	2.4006	.8859
6	2.4577	2.2138	2.572	2.4291	2.5101	2.572	.9745
9							2.0309
10							2.5911
11							2.672
12							2.5911
13							2.4291
14							2.4291
15							2.3482
16							2.5911
17	.823	.6001	.5544	.7392	.6001	.7973	.4572
18	.823	.8573	.924	.9955	.8573	.8859	.7392
19	.9745	.9431	1.0164	.9955	.9431	.9745	1.0164
20	.8859	.8573	.924	.9145	.8573	.9745	.924
21	1.5623	1.6289	1.5384	1.8233	1.8861	.8859	.924
22	1.9528	2.4863	2.1052	2.13	2.2291	.7316	.7392
23	2.0557	2.2291	2.1052	2.13	2.2291	.7316	.7392
24	1.8233	2.0557	2.0576	2.1052	2.13	2.2291	.7316
Max	2.4577	2.4863	2.572	2.4291	2.5101	2.572	2.672
Min	.823	.6001	.5544	.7392	.6001	.7316	.4572
Avg	1.6433	1.6557	1.7449	1.7880	1.7528	1.5295	1.4014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 201 / NAGAMTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1568
Max	1.1568
Min	1.1568
Avg	1.1568



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 202 / MAHANKALWADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.2696
Max	1.2696
Min	1.2696
Avg	1.2696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 203 / DAGPIMPALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.5149
Max	2.5149
Min	2.5149
Avg	2.5149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 204 / BHAMATHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3734
Max	.3734
Min	.3734
Avg	.3734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 205 / AWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1016
Max	1.1016
Min	1.1016
Avg	1.1016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 201 / 11KV PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947	.924	1.0387	.9745	.7468	.8488	.7468
2	.8316	.924	1.0566	.8859	.924	.8299	.8316
3	.7947	1.0059	1.0631	.8859	1.0164	.9431	.924
4	.8316	1.0974	1.0867	1.0631	1.1888	1.0562	1.0164
5	.7762	1.2803	1.1744	1.4175	1.2803	1.3203	1.0974
6	1.8099	1.4632	1.6126	1.8204	1.3717	1.6975	1.2803
7	1.3717	1.4632	1.1694	1.4327	1.4632	1.5089	1.5546
8	1.0322	1.4003	1.1317	1.267	1.8099	1.3769	1.0974
9	1.0082	1.2936	1.1317	1.086	2.0538	1.0745	1.4003
10	.7392	.7167	.7316	.7316	1.8023	1.6766	1.4632
11	.5601	.7167	.5544	.7468	1.8842	1.8099	1.5729
12	.4668	.7167	.5544	.7762	1.8023	1.6289	1.6461
13	.3734	.6979	.462	.7095	1.6385	1.4632	1.6461
14	.5601	.679	.462	.6722	1.6078	1.4632	1.6651
15	.7468	.6224	.462	.5975	1.6078	1.3717	1.7013
16	.8316	.6224	.5175	.5601	1.6766	1.2803	1.6461
17	.924	.6224	.5544	.5975	.4715	.7468	1.0608
18	1.1888	.6224	.6468	.6348	.7733	.924	1.0974
19	1.2803	1.1694	1.1888	1.39	1.2449	1.1888	1.134
20	1.0974	1.1317	1.0631	1.1888	1.226	1.1888	1.1523
21	.8316	1.086	.9391	.8871	.8676	1.0059	.9694
22	1.4632	1.0498	1.3169	.8316	.8676	.8316	.8316
23	1.2803	1.0317	1.1163	.7577	.811	.8316	.8501
24	.7842	1.0974	1.0208	1.0631	.7392	.8488	.8316
Max	1.8099	1.4632	1.6126	1.8204	2.0538	1.8099	1.7013
Min	.3734	.6224	.462	.5601	.4715	.7468	.7468
Avg	.9324	.9764	.9190	.9574	1.2865	1.2048	1.2174

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 202 / 11KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.6535	.8596	.5373	.924	1.0374	.8316
2	.4287	.6535	.8589	.6268	.8316	1.1128	.924
3	.4668	.8316	.8764	.6268	.8316	1.0374	1.0059
4	.5601	.9145	.8939	.7164	.924	1.1317	1.0974
5	.3734	.924	.8916	1.1641	1.0059	1.3203	1.1888
6	1.2803	1.0974	1.2574	1.5947	1.0974	1.5278	1.3717
7	1.2803	1.2803	1.1317	1.1765	1.3717	1.3769	1.5546
8	.5601	1.1088	1.0374	.9955	1.3756	1.3957	.9145
9	.2035	.924	.9808	.905	1.6632	1.1462	.823
10	.3734	.5281	.5544	.5544	1.4746	1.0898	.8501
11	.2801	.5281		.4854	1.1797	1.0974	.8962
12	.2801	.5093	.3734	.4108	1.1797	1.0974	.8871
13	.1867	.4715	.3734	.4854	1.1603	.924	.924
14	.3734	.4527	.3734	.5228	1.0774	.924	1.0974
15	.5601	.415	.4108	.5601	1.073	.8316	1.1706
16	.5601	.5658	.4108		.9556	.8316	1.2803
17	.5601	.5658	.462	.6348	.3772	.5601	1.2071
18	.7468	.5658	.5544	.6722	.4715	.7468	1.134
19	1.3717	1.1694	1.0425	1.0974	1.1317	1.0974	1.1706
20	1.1888	1.1317	1.1888	1.0974	1.0374	1.0974	1.1523
21	.5601	.6335	.5373	1.0425	.9431	1.0059	1.0349
22	.9145	.724	.7762	1.0059	1.0185	1.0164	1.0349
23	.924	.8145	.5601	1.0242	1.0185	.924	1.0164
24	.4668	.8316	.8238	.5373	.9145	.9431	.924
Max	1.3717	1.2803	1.2574	1.5947	1.6632	1.5278	1.5546
Min	.1867	.415	.3734	.4108	.3772	.5601	.823
Avg	.6236	.7623	.7491	.8032	1.0432	1.0530	1.0621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 203 / 11KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2803	1.2826	1.1765	1.2803	1.7013	1.4632
2	1.2803	1.3717	1.3014	1.2536	1.2803	1.5223	1.5546
3	1.4083	1.3717	1.358	1.3432	1.3717	1.6118	1.6461
4	1.5181	1.3717	1.5089	1.4327	1.4632	1.6832	1.7375
5		1.3717	1.8107	1.5223	1.5384	1.7528	1.9909
6					1.8099	1.858	2.1719
7					1.4632	1.3769	2.2624
8				1.3432		1.3769	1.0974
9	1.7372	2.0328	2.1491	1.9071			1.0974
10	1.8099	2.0271	1.9938	1.9938		.8865	1.0974
11	2.1719	2.0058	1.8204	1.9909	.9431	.8316	.7468
12	.3734	2.0022	1.7337	1.9909	.9242	.7392	.7842
13	2.1719	1.9281	1.6651	1.8099	.9054	.5601	.7468
14	2.1719	1.6956	1.5775	1.9547	.8488	.5601	.7468
15	1.9909	1.5927	1.6651	1.9909	.811	.5601	.7842
16	1.9909	1.5089	1.6651	1.8099	.7733	.6535	.8215
17	.924	.7167	.6468	.9979	.811	.7468	.924
18	1.1888	.7356	.823	1.0974	.9808	.9335	.9979
19	1.5546	1.5844	1.3575	1.2803	1.226	1.1888	1.0974
20	1.4632	1.4146	1.2803	1.1888	1.2826	1.2803	1.4266
21	1.3717	1.226	1.2489	1.0791	1.0442	1.1888	1.39
22	1.2803	1.2071	1.2437	1.1888	1.7556	1.3717	1.8642
23	1.2803	1.1883	1.2071	1.2437	1.8099	1.5546	1.8099
24	1.2437	1.2803	1.2637	1.086	1.2803	1.7909	1.6461
Max	2.1719	2.0328	2.1491	1.9938	1.8099	1.858	2.2624
Min	.3734	.7167	.6468	.9979	.7733	.5601	.7468
Avg	1.5060	1.4721	1.4573	1.4855	1.2192	1.2056	1.3294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 201 / 11kv Darga

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4668	.4668	.4294	.4481	.4239	.4481
2	.4668	.4481	.4239	.4294	.4481	.5087	.4294
3	.4668	.4668	.5087	.4481	.4668	.5935	.4481
4	.4854	.5041	.5087	.4854	.4854	.0653	.4668
5	.499	.5601	.6535	.5415	.499	.5935	.4854
6	.6036	.5975	.5935	.6535	.5853	.7468	.5365
7	.7316	.6535	.6443	.6722	.6335	.7468	.6908
8	.7023	.7282	.5935	.6535	.6219	.6535	.6535
9	.6161	.7095	.6535	.6348	.5729	.5935	.6161
10	.5415	.5935	.7095	.5415	.5087	.6535	.5729
11	.5601	.6535	.6348	.5975	.5087	.6161	.5729
12	.5601	.5935	.5975	.5601	.5087	.5788	.5914
13	.5228	.5087	.4854	.5228	.4239	.5601	.5601
14	.4668	.5601	.4668	.4668	.4239	.5041	.5041
15	.4108	.5601	.4854	.4481	.4239	.5228	.5228
16	.5228	.5087	.547	.4481	.5087	.4294	.5228
17	.5601	.6535	.5601	.5175	.5601	.5601	.5415
18	.6161	.6535	.5415	.5121	.6535	.5975	.6099
19	.7095	.6535	.6722	.6154	.5935	.6348	.6838
20	.6535	.5935	.5788	.6154	.5601	.6161	.6468
21	.5975	.5087	.5788	.5304	.5601	.6036	.6099
22	.5197	.5087	.5975	.499	.4239	.5415	.5975
23	.5601	.4239	.5041	.5041	.4239	.4854	.5415
24	.4854	.4668	.4239	.4668	.4668	.4239	.4668
Max	.7316	.7282	.7095	.6722	.6535	.7468	.6908
Min	.4108	.4239	.4239	.4294	.4239	.0653	.4294
Avg	.5552	.5656	.5596	.5331	.5129	.5522	.5550



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 202 / 11 Rotegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0159	1.2071	1.0174	1.2136	1.0534	.9326	.9709
2	1.0202	1.1949	1.0174	1.1576	1.0719	.9326	.9335
3	1.0402	1.1576	1.2136	1.1949	1.0974	1.0174	1.0082
4	1.0911	1.251	1.307	1.307	1.1946	1.1022	1.1203
5	1.1111	1.3443	1.2717	1.6244	1.4327	1.1022	1.4563
6	1.2334	1.6617	1.4937	1.9605	1.3998	1.1869	1.4003
7	1.387	1.531	1.2717	1.307	1.3321	1.4003	1.419
8	1.3496	1.2136	1.307	1.3256	1.5238	1.2717	1.475
9	1.2357	1.3256	1.0829	1.1949	1.5939	1.5261	1.8111
10	1.1203	1.1869	.8962	1.086	1.5261	1.7737	1.8111
11	1.0269	1.2136	.6908	.8413	1.4413	1.8858	1.7372
12	1.0269	1.0174	.6535	.7762	1.3565	1.531	1.6632
13	.9896	1.0269	.6722	.7577	1.2717	1.5684	1.6057
14	.8962	.9335	.7095	.7577	1.1869	1.4937	1.531
15	.7468	.763	.7545	.7762	1.1022	1.531	1.5684
16	1.1203	.8402	.7842	.8413	1.1022	1.5123	1.643
17	1.307	.6783	.8048	.9593	1.1022	.8962	.7468
18	1.4563	.6783	1.0082	.985	1.0174	1.1016	1.2012
19	1.419	.763	1.3443	1.4883	1.2136	1.5684	1.46
20	1.1949	1.0174	1.2696	1.1919	1.307	1.4563	1.2936
21	1.4937	1.1022	1.0829	1.2403	1.4003	1.3256	1.1643
22	1.4563	1.1869	1.419	1.182	1.2136	1.2136	1.0829
23	1.4003	1.2136	1.3443	1.1222	1.0174	1.1389	1.0082
24	1.0111	1.2883	1.0174	1.2696	1.0791	.9326	.9724
Max	1.4937	1.6617	1.4937	1.9605	1.5939	1.8858	1.8111
Min	.7468	.6783	.6535	.7577	1.0174	.8962	.7468
Avg	1.1729	1.1165	1.0597	1.1484	1.2515	1.3084	1.3368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 203 / 11kv Tilakroad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	.9709	.9335	.8962	1.0082	.9326	.8962
2	1.0456	1.0082	1.0269	.8589	.9896	1.0269	.7655
3	1.0642	.9709	1.0269	.9149	1.0082	1.0174	.7377
4	1.0829	1.0269	1.0174	.9709	1.0269	1.1022	.9709
5	1.1273	1.251	1.1022	1.1016	1.0903	1.1869	1.1203
6	1.3717	1.358	1.1869	1.251	1.4266	1.2717	1.3256
7	1.4842	1.4842	1.3226	1.3443	1.5384	1.4937	1.4937
8	1.4842	1.5655	1.2717	1.363	1.4998	1.4003	1.363
9	1.3352	1.643	1.3256	1.2696	1.386	1.1869	1.2696
10	1.3306	1.3565	1.307	1.1949	1.1869	1.2883	1.1827
11	1.2567	1.2717	1.4003	1.2136	1.1869	1.1576	1.2012
12	1.1949	1.1869	1.2567	1.1763	1.1022	1.1203	1.2382
13	1.1576	1.1022	1.2637	1.1389	1.2136	1.0059	1.2136
14	1.2136	1.0174	1.0829	1.1016	1.1022	1.0829	1.1763
15	1.1203	1.1203	1.0269	1.0642	1.0174	1.0456	1.2136
16	1.2136	.9326	1.1203	1.1016	1.0174	1.1763	1.2696
17	1.3443	1.0174	1.2696	1.1827	1.1022	1.2696	1.307
18	1.4563	1.1022	1.4563	1.2071	1.1869	1.3817	1.4045
19	1.6244	1.1869	1.6057	1.4118	1.2717	1.5684	1.5524
20	1.5123	1.2717	1.4937	1.448	1.1869	1.4563	1.4784
21	1.3817	1.2717	1.3443	1.262	1.1869	1.3256	1.3676
22	1.2883	1.4563	1.1763	1.1273	1.1022	1.2136	1.2696
23	1.1949	1.1022	1.1016	1.1576	1.0174	1.1016	1.1576
24	1.0829	1.1203	.9326	.9335	1.0269	.9326	.905
Max	1.6244	1.643	1.6057	1.448	1.5384	1.5684	1.5524
Min	1.0456	.9326	.9326	.8589	.9896	.9326	.7377
Avg	1.2672	1.1998	1.2105	1.1538	1.1617	1.1977	1.2033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 204 / town 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.7282	.5087	.6535	.7842	.5935	.7095
2	.7095	.7167	.5087	.5975	.7842	.5935	.7468
3	.7282	.6602	.5935	.6348	.8029	.6783	.7842
4	.7468	.6908	.5935	.7095	.8215	.6783	.8029
5	.7762	.7545	.6783	.8402	.8686	.763	.8402
6	.9145	.8865	.763	.9149	.9877	.8478	.9522
7	1.0498	1.0642	.8478	.9522	1.086	1.0269	1.0829
8	.9694	.9335	.9335	.9709	.9694	.9335	.9335
9	.8131	.8402	.7655	.8589	.8501	.763	.8029
10	.7655	.763	.8029	.8215	.6783	.6874	.7842
11	.5601	.6783	.7468	.7842	.6783	.7468	.7842
12	.7468	.6783	.6908	.7655	.5935	.7095	.7468
13	.7095	.5935	.7095	.7095	.5935	.6348	.7545
14	.6908	.5935	.6602	.6348	.5601	.6535	.7167
15	.6535	.5935	.6348	.6535	.5087	.6348	.7167
16	.6348	.5087	.7095	.6348	.5935	.7842	.7545
17	.6908	.5087	.6722	.7392	.7545	.8029	.7545
18	.7095	.5935	.7095	.7499	.8402	1.0082	.8775
19	.9335	.6783	.9709	.9593	.9335	.9774	1.0082
20	.9709	.763	.9335	.9955	.9145	1.1016	1.0456
21	.9149	.763	.9149	.9328	.8402	.9335	1.0082
22	.8402	.8478	.8589	.9425	.7545	.9335	.9431
23	.8029	.8402	.7842	.8775	.5935	.8775	.8865
24	1.1278	.7282	.6783	.7468	.8029	.5935	.7842
Max	1.1278	1.0642	.9709	.9955	1.086	1.1016	1.0829
Min	.5601	.5087	.5087	.5975	.5087	.5935	.7095
Avg	.7995	.7253	.7362	.7950	.7748	.7899	.8425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 205 / pahade express feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.3921	.017	.2987	.4527	.0152	.2054
2	.2241	.3772	.017	.2801	.4527		.1867
3	.2054	.3361	.017	.2614	.4338		.1698
4	.2054	.3174	.017	.2987	.4527		.1867
5	.2218	.3584	.017	.3547	.4715		.1886
6	.2218	.3734	.017	.4294	.4715		.2614
7	.2772	.3734	.017	.4481	.4527		.2801
8	.2427	.2427	.0678	.3547	.4338	.1017	.2614
9	.1494	.0373	.1494	.0373	.2641	.3391	.2241
10	.1307		.1307		.1017	.3921	.1663
11	.168		.112		.1017	.5228	.1663
12	.112		.168		.1017	.3361	.1663
13	.1307		.0934		.1017	.2987	.2054
14	.1307		.0934		.1017	.3361	.2427
15	.1494		.0747		.1017	.3174	.2801
16	.1494		.1307		.1187	.2054	.3734
17	.1494		.1307		.1341	.2241	.4294
18	.1494	.0335	.1494	.0187	.0754	.2801	.4251
19	.168	.0339	.168	.037	.1357	.2614	.4251
20	.4108	.0339	.4108	.1109	.0983	.2427	.4294
21	.4294	.0339	.3921	.3921	.0678	.2054	.3881
22	.3921	.0339	.3734	.3734	.7468	.2427	.4108
23	.3547	.0339	.3921	.4904	.0339	.2801	.4294
24	.2054	.3734	.017	.3547	.4715	.0339	.2241
Max	.4294	.3921	.4108	.4904	.7468	.5228	.4294
Min	.112	.0335	.017	.0187	.0339	.0152	.1663
Avg	.2168	.2115	.1322	.2838	.2657	.2575	.2803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 206 / water supply Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0373	.0339	.0373	.0271	.0339	.0248
2	.0278	.0373	.0339	.0373	.0274	.0339	.0373
3	.0282	.0373	.0339	.056	.0278	.0339	.0373
4	.0274	.0373	.0678	.056	.0412	.0509	.0373
5	.0267	.0373	.0678	.0373	.0533	.0509	.0373
6	.0259	.056	.0678	.0373	.0648	.0678	.0373
7	.0255	.0747	.0678	.0373	.0766	.112	.0373
8	.0251	.0934	.0678	.0373	.0629	.112	.0373
9	.0867	.0373	.056	.132	.0732	.0509	.0934
10	.1307	.0747	.0373	.0754	.0848	.056	.08
11	.1307	.0678	.1494	.0255	.1357	.0373	.0572
12	.112	.0678	.1307	.0259	.0678	.1494	.0229
13	.0747	.0747	.1307	.0263	.0678	.0373	.0229
14	.0373	.0339	.1494	.0267	.0678	.112	.0232
15	.0373	.0339	.1494	.0271	.0747	.1307	.0232
16	.056	.0339	.112	.0274	.0339	.056	.0232
17	.0373	.0339	.0373	.0278	.0339	.0373	.0232
18	.0373	.0339	.0373	.0271	.0339	.0373	.0229
19	.0248	.0339	.0373	.0263	.0339	.0373	.0229
20	.0373	.0339	.0373	.0255	.0339	.0747	.0229
21	.0373	.0339	.0373	.0259	.0373	.0373	.0229
22	.0373	.0339	.0373	.0259	.0339	.0373	.0229
23	.0373	.0339	.0373	.0263	.0339	.0373	.0229
24	.0267	.0373	.0339	.0373	.0267	.0339	.0373
Max	.1307	.0934	.1494	.132	.1357	.1494	.0934
Min	.0248	.0339	.0339	.0255	.0267	.0339	.0229
Avg	.0481	.0462	.0688	.0385	.0523	.0607	.0346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 207 / 11 KV MGM

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2054	.2035	.2427	.2241	.2035	.2054
2	.2241	.2054	.2035	.2241	.2241	.2035	.2054
3	.2241	.1867	.2035	.2241	.2241	.2035	.2054
4	.2241	.2054	.2374	.2427	.2241	.2374	.2427
5	.2427	.2241	.2374	.2801	.2427	.2374	.2614
6	.2587	.2427	.2713	.3174	.2772	.2713	.2801
7	.3292	.2427	.2713	.2987	.2926	.3174	.3361
8	.2926	.2801	.2713	.3174	.2195	.3174	.3018
9	.2402	.2801	.2801	.2614	.2957	.2713	.2987
10	.3174	.2614	.3361	.3174	.2713	.2987	.3142
11	.2987	.2374	.3734	.3174	.3052	.2801	.3696
12	.3734	.2374	.3361	.3174	.2713	.3018	.4066
13	.3361	.2374	.3921	.3734	.2713	.3547	.4108
14	.3734	.2614	.3734	.3174	.2374	.3174	.4108
15	.3361	.2614	.3921	.3361	.2374	.2801	.3734
16	.3547	.2241	.4294	.2801	.2713	.2987	.3734
17	.3734	.2374	.4108	.2957	.3361	.3734	
18	.3921	.2614	.4294	.3292	.3391	.4108	.462
19	.4481	.2543	.4668	.4163	.3734	.4668	.499
20	.3921	.2543	.4108	.362	.3361	.3921	.4435
21	.2801	.2374	.3174	.3109	.2713	.3361	.3511
22	.2614	.2374	.2801	.2772	.2374	.2801	.3361
23	.2614	.2035	.2515	.2801	.2035	.2614	.2987
24	.2427	.2241	.2035	.2614	.2427	.2035	.2054
Max	.4481	.2801	.4668	.4163	.3734	.4668	.499
Min	.2241	.1867	.2035	.2241	.2035	.2035	.2054
Avg	.3042	.2376	.3159	.3000	.2679	.2966	.3301

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 201 / 11 KV CHINCHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.9259	.823	.8048	.5571	.5243	.5735
2	.5144	.9945	.9259	.8048	.5571	.5243	.5735
3	.5487	1.0288	1.0288	.7712	.5571	.5243	.6554
4	.6173	1.2346	1.2346	.8048	.5898	.6554	.6554
5	.823	1.3717	1.406	.8718	.3932	.7373	.8192
6	.9602	1.4403	1.4403	1.1065	.7293	.7865	.8192
7	.7888	.8402	.7888	.8383	.9282	.852	.8192
8	.7545	.8573	.7712	.8718	.8951	.7537	.7865
9	.6878	.583	.6706	.7042	.9282	1.4022	1.0867
10	.4706	.4801	.4024	.503	1.0395	1.6476	1.4022
11	.3772	.4115	.4024	.4359	1.6827	1.5424	1.3375
12	.3429	.3772	.3688	.3932	1.6476	1.4198	1.2003
13	.4115	.4801	.4359	.3605	1.4198	1.3672	1.0974
14	.4801	.5487	.3932	.3605	1.3146	1.3146	1.0631
15	.5487	.5144	.3932	.3605	1.1919	1.2269	1.2003
16	.6516	.4973	.3932	.3605	1.4723	1.2269	1.2689
17	.6859	.4801	.4915	.4915	.3277	.3277	.8573
18	.823	.583	.5898	.6882	.5571	.3605	.583
19	.7545	.6516	.852	.7865	.5898	.4752	.6516
20	.7202	.6344	.7537	.7209	.6882	.6226	.5658
21	.7202	.7202	.6371	.6554	.6554	.5898	.583
22	.9602	.823	.9054	.6226	.5571	.5898	.6344
23	.8916	.8916	.9054	.5571	.5243	.5898	.583
24	.5144	.823	.8573	.8383	.5898	.5243	.5735
Max	.9602	1.4403	1.4403	1.1065	1.6827	1.6476	1.4022
Min	.3429	.3772	.3688	.3605	.3277	.3277	.5658
Avg	.6484	.7580	.7446	.6547	.8497	.8577	.8496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 202 / 11 KV AGARSAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.3772	.4115	.3353	.3277	.6135	.7011
2	.4706	.4115	.4115	.3353	.3277	.5784	.7011
3	.5068	.4287	.4801	.3688	.3605	.7011	.7011
4	.543	.4801	.5487	.4024	.3605	.8764	.8573
5	.5792	.5487	.6173	.4694	.3932	1.0517	1.0517
6	.6878	.6001	.6516	.57	.5243	1.0867	1.1393
7	.724	.4973	.6516	.6371	.431	.4096	.4915
8	.724	.6001	.5365	.503	.3647	.4588	.5079
9	.5658	.8916	.8551	.9054	.3978	.3277	.4096
10	.6859	.9259	1.0395	1.0059	.3315	.2622	.3277
11	.8916	.9602	1.0059	1.0395	.2458	.018	.3086
12	.9431	.9259	.9724	.8951	.213	.1802	.2401
13	.9602	.9602	.8718	.7956	.2622	.1638	.2058
14	.8916	.9431	.7865	.7625	.213	.1638	.1715
15	.9431	.9602	.8192	.7293	.2458	.1475	.1029
16	.9774	.9259	.8848	.8619	.2458	.1802	.12
17	.2058	.1029	.0983	.0983	.2294	.2785	.2572
18	.4115	.4115	.2294	.2949	.2949	.2949	.4115
19	.6173	.5487	.4588	.4588	.3277	.4752	.5487
20	.583	.4801	.4915	.426	.4588	.4424	.5144
21	.4801	.4801	.3688	.3932	.4557	.4801	.4801
22	.4115	.4115	.3688	.3605	.5083	.5258	.583
23	.4115	.4115	.3353	.3277	.5258	.5784	.583
24	.4887	.3772	.4115	.3353	.3605	.6135	.7011
Max	.9774	.9602	1.0395	1.0395	.5258	1.0867	1.1393
Min	.2058	.1029	.0983	.0983	.213	.018	.1029
Avg	.6323	.6108	.5961	.5546	.3502	.4545	.5048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 201 / 11 KV BHAGGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 202 / 11 KV GHAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 205 / 11 KV ROTEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 206 / 11 KV SHELKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 403 / 33 KV VAIJAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8649	4.0329	3.0521	3.8089	4.0329	3.1539	3.4728
2	3.8649	3.9769	3.103	3.5848	3.9769	3.2047	3.3048
3	3.9209	3.8089	3.4082	3.6969	4.0889	3.4591	3.1687
4	4.0889	4.0329	3.6117	4.0329	4.313	3.7643	3.8649
5	4.2135	4.537	3.9169	4.8171	4.7125	3.9678	4.369
6	4.8834	5.1532	4.273	5.5453	5.2675	4.3239	4.8731
7	5.3212	5.4893	4.4256	5.0972	5.4298	5.0452	5.3772
8	5.1578	5.0412	4.7051	5.0412	5.3772	4.5268	4.9851
9	4.5462	4.8731	4.313	4.369	5.1578	4.7308	5.1532
10	4.313	4.7817	4.257	4.0889	4.3239	5.2652	4.9897
11	4.201	4.369	4.0889	3.8089	4.3239	5.1532	4.8788
12	3.1367	4.145	3.8089	3.6408	4.0186	4.7611	4.8234
13	3.9209	3.8089	3.7529	3.5848	3.866	4.537	4.7611
14	3.8089	3.2047	3.5288	3.3608	3.6117	4.481	4.6491
15	3.4728	3.1539	3.4728	3.3048	3.4591	4.481	4.7051
16	4.0889	3.2487	3.7529	3.3608	3.6626	4.481	4.9291
17	4.481	.3103	3.9769	3.7146	3.866	4.201	3.77
18	4.8171	3.3065	4.313	3.8958	4.481	4.8171	4.9897
19	5.3212	3.5608	5.2092	4.9954	4.8171	5.0297	5.655
20	5.1532	3.9678	5.0972	4.8325	4.1712	5.3212	5.3778
21	4.5771	3.9169	4.6491	4.7737	4.0695	4.7611	4.9291
22	4.8731	4.1712	4.7611	4.4907	3.6117	4.425	4.6491
23	4.5931	3.6626	4.425	4.537	3.3065	4.201	4.369
24	3.9209	4.201	3.3065	4.0889	4.145	3.1539	3.3699
Max	5.3212	5.4893	5.2092	5.5453	5.4298	5.3212	5.655
Min	3.1367	.3103	3.0521	3.3048	3.3065	3.1539	3.1687
Avg	4.3559	3.9481	4.0504	4.1863	4.2538	4.3853	4.5589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 201 / shivoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.815	.905	.7796	.5144	.4525	.4961
2	.8869	.8682	.9955	.9568	.6001	.5068	.5316
3	.9955	.9922	1.0498	1.0099	.6516	.5792	.5493
4	1.086	1.0454	1.1403	1.0631	.6859	.6878	.6201
5	1.1584	1.1871	1.1765	1.1694	.7716	.7421	.7087
6	1.267	1.4529	1.4661	1.2403	.8402	.7783	.8328
7	.8688	.7973	.9412		.8573	.9774	.9745
8	.8916	.9391	.9412	.443	.7545	.7421	.7973
9	.8059	.7265	.7421	.2658	1.1584	1.1584	1.0631
10	.4784	.5611	.5316	.1991	1.3575	1.1163	1.1222
11	.5316	.5249	.3721	.1543	1.3213	1.0631	1.0317
12	.443	.5611	.2835	.3429	1.1765		.9593
13	.4252	.543	.2481	.4287	1.1403	.8859	.8145
14	.4075	.4163	.2658	.3944	.9955	.7265	.7421
15	.443	.4525	.3366	.3772	.8939		.8145
16	.567	.5249	.3544	.3944	.9955	.7796	.8507
17	.691	.543	.443	.4801	.3439	.4075	.4287
18	.6201	.5973	.5138	.5658	.4887	.4075	.463
19	.6201	.7059	.5847	.6001	.6335	.5316	.6687
20	.567	.7059	.6024	.703	.5792	.6201	.6344
21	.8328	.8869	.7973	.6687	.543	.5847	.6001
22	.8682	1.1041	.9568	.5487	.5068		.5144
23	.8859	1.086	.8859	.4973	.4525	.5316	.543
24	.7421	.7973	.905	.7619	.4801	.4525	.4784
Max	1.267	1.4529	1.4661	1.2403	1.3575	1.1584	1.1222
Min	.4075	.4163	.2481	.1543	.3439	.4075	.4287
Avg	.7457	.7847	.7266	.6106	.7809	.7015	.7183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 202 / sudamwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6379	.6697	.6733	.5792	.5792	.5493
2	.6516	.6733	.7059	.7087	.6335	.6154	.6024
3	.6859	.7265	.7602	.7973	.6878	.6878	.6733
4	.7202	.7619	.8145	.8682	.724	.7602	.7619
5	.823	.7973	.8869	.9036	.8145	.8688	.8682
6	.905	.9036	.905	.9391	.8869	.9774	.9214
7	.9602	.8682	.9231	.8682	.6687	.6335	.6379
8	.6516	.6201	.6154	.6379	.5144	.6335	.567
9	.4163	.7796	.9955	1.0631	.4801	.4525	.443
10		.9231	1.0454	1.086	.3801	.3544	.3258
11	.8859	.9593	.9568	1.0498	.2896		.3086
12	.9391	.8688	.7973	.9412	.2715	.3189	.3258
13	.7973	.7602	.8682	.362	.2896	.3366	.2915
14	.691	.7059	.7087	.6335	.3077		.2743
15	.7265		.7442	.7602	.3077	.3366	.2743
16	.815	.8869	.8328	.6335	.3258	.3721	.2743
17	.3366	.3258	.2303	.2572	.3439	.4075	.3086
18	.6201	.3258	.3721	.3944	.3982	.4607	
19	.7442	.6878	.7087	.6001	.5792	.6556	.6173
20	.7442	.7602	.7619	.7202	.7783	.691	.6859
21	.7087	.7059	.7796	.3801	.5609	.4961	.724
22	.7087	.7421	.7265	.4525	.7602	.567	.8507
23	.7087	.6878	.691	.5068	.6516	.6379	.724
24	.6344	.6201	.6878	.6733	.5249	.5611	.5493
Max	.9602	.9593	1.0454	1.086	.8869	.9774	.9214
Min	.3366	.3258	.2303	.2572	.2715	.3189	.2743
Avg	.7185	.7273	.7578	.7046	.5316	.5638	.5460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1949	.181	.1949	.0905	.0905	.0709
2	.1715	.1949	.181	.1949	.0905	.0905	.0709
3	.1886	.2126	.1753	.1949	.0905	.1086	.1063
4	.2058	.2126	.1991	.1949	.1086	.1267	.1417
5	.2229	.2303	.2172	.2126	.1086	.1448	.1772
6	.2572	.2303	.2353	.2481	.1086	.1629	.2126
7	.2915	.2835	.2715	.3012	.0857	.1267	.0886
8	.2058	.2658	.2353	.1772	.1715	.1991	.0886
9	.0543	.0709	.0543	.0886	.1029	.1991	.1063
10	.124	.0905	.1595	.181	.0724	.0709	.1029
11	.1949	.1448	.2126	.2172	.0543		.0343
12	.1772	.1448	.1949	.181	.0362		.0514
13	.1595	.181	.1949	.1629	.0543	.0532	.0857
14	.1595	.181	.1063	.1629	.0362	.0532	.1029
15	.1417	.1991	.1417	.1629	.0543	.0709	.1029
16	.1595	.1991	.1772	.1629	.0362	.1063	.0686
17	.0354	.0181	.0354	.0343	.1086	.124	.1029
18	.124	.0362		.0747	.1267	.1949	.1543
19	.2126	.2353	.2126	.1715	.2353	.2126	.2229
20	.2126	.2172	.2303	.2058	.2172	.2658	.2401
21	.2126	.2172	.2126	.0724	.0724	.0886	.0543
22	.2126	.2172	.2126	.0905	.1086	.0709	.0905
23	.2126	.1991	.1949	.0905	.1086	.0709	.0905
24	.2058	.1949	.181	.1949	.0905	.0905	.0709
Max	.2915	.2835	.2715	.3012	.2353	.2658	.2401
Min	.0354	.0181	.0354	.0343	.0362	.0532	.0343
Avg	.1797	.1821	.1833	.1655	.0987	.1237	.1099



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4607	.5068	.443	.3801	.3982	.2835
2	.4801	.4961	.5792	.4252	.362	.4344	.3012
3	.5144	.5138	.5959	.4607	.3982	.4706	.3366
4	.5487	.5316	.6878	.5138	.4525	.5068	.443
5	.6516	.567	.724	.6201	.5068	.6154	.5138
6	.6516	.6201	.7421	.691	.543	.7059	.5847
7	.5144	.6024	.7964	.7442	.5144	.6516	.6024
8	.4115	.443	.5611	.5316	.3601	.543	.4252
9	.181	.2303	.4344	.4961	.3086	.3439	.3012
10	.2658	.3801	.3898	.4887	.1629	1.2403	.2058
11	.3721	.543	.3012	.4525	.1086	.0886	.12
12	.4252	.543	.2835	.362	.0905	.0886	.12
13	.3366	.4344	.2658	.2715	.1086	.1063	.1029
14	.3012	.3982	.2303	.2715	.0724	.0532	.0857
15	.3189	.4344	.2126	.3077	.1086	.0532	.0857
16	.3366	.3439	.3012	.3439	.1086	.0886	.0857
17	.1417	.1267	.0354	.1715	.1448	.124	.1543
18	.3544	.2172	.0709	.2401	.2172	.2126	.3086
19	.4784	.5792	.3544	.3772	.5068	.3189	.5316
20	.567	.5973	.3898	.6001	.5249	.4607	.5658
21	.4784	.5792	.4607	.3258	.3155	.3366	.3982
22	.4784	.5068	.4784	.3258	.4525	.3544	.4887
23	.4784	.4525	.443	.362	.4344	.3544	.4287
24	.463	.4784	.4887	.4607	.3801	.3982	.3012
Max	.6516	.6201	.7964	.7442	.543	1.2403	.6024
Min	.1417	.1267	.0354	.1715	.0724	.0532	.0857
Avg	.4262	.4616	.4306	.4286	.3151	.3729	.3239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 205 / BOLTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8505	.8869	.8328	.6878	.7059	.7265
2	.8916	.8682	.9593	.8505	.724	.7602	.7619
3	.9259	.8505	1.0498	.8505	.8145	.8145	.7973
4	.9945	.8859	1.1584	.9036	.8688	.9412	.8328
5	1.0288	.9214	1.2489	1.0099	.905	1.1222	1.0631
6	1.0288	.9745	1.0136	1.0631	.9412	1.2308	1.3466
7	1.0288	1.0277	1.0679	.8682	1.0117	1.1222	1.1694
8	.7716	.7619	.7421	.6201	.9088	.905	.9745
9	.5068	.9391	.9412	.9745	.6173	.724	.7442
10	.6556	1.0679	1.0631	1.1041	.4163	.3721	.4287
11	1.0099	1.1765	.8859	1.1765	.3077	.3189	.3258
12	.9922	.8326	.8328	.9231	.2534	.2126	.2915
13	.8859	.7602	.7619	.7783	.2896	.2303	.2572
14	.7796	.8507	.5847	.724	.2353	.1949	.3258
15	.9036	.9593	.691	.6878	.2715	.2481	.2896
16	.9214		.7087	.7964	.3077	.2126	.2572
17	.5138	.2534	.2835	.3086	.4344	.3544	.3601
18	.7087	.3258	.443	.3601	.3982	.4075	.4458
19	.9568	.905	.8505	.9259	.7421	.5493	.9259
20	.8859	1.086	.9036	.8916	.7602	.9922	.8573
21	.8505	.9955	.815	.5792	.543	.8505	.6335
22	.7973	.9231	.7619	.6154	.6878	.8859	1.0498
23	.7973	.8688	.7973	.6335	.7783	.8859	.905
24	.8402	.8328	.8869	.8328	.6516	.6878	.7087
Max	1.0288	1.1765	1.2489	1.1765	1.0117	1.2308	1.3466
Min	.5068	.2534	.2835	.3086	.2353	.1949	.2572
Avg	.8555	.8660	.8474	.8046	.6065	.6554	.6866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 206 / BANGLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4607	.6878	.6201	.5487	.5792	.5493
2	.4458	.4961	.7059	.691	.4801	.6154	.5493
3	.5068	.5138	.7059	.7796	.5144	.6516	.6201
4	.543	.5493	.724	.8682	.5487	.6878	.7442
5	.6516	.567	.7421	.9568	.6001	.7421	.7442
6	.8869	.7265	1.0498	1.0808	.6687	.7783	.7619
7	.4801	.4961	.4887	.5138	.823	.8869	.7973
8	.4287	.4607	.4706	.567	.6001	.6516	.6733
9	.3944	.4607	.4887	.5138		.6878	.5847
10	.443	.4706	.3189	.4801	.3366	.6379	.6878
11	.4607	.362	.3012	.3982	.3258	.9036	.9231
12	.4252	.3439	.3366	.362		.9036	.8688
13	.4075	.3258	.3721	.3772	1.086	.8859	.7421
14	.4252	.362	.4607	.3772	.4525	.8328	.6335
15	.4252	.4163	.4607	.3772	.7602	.7087	.6335
16	.5138		.4607	.4287	.8869	.691	.6335
17	.6024	.4887	.4784	.4801	.3077	.2835	.2743
18	.7087	.5611		.5487	.3801	.4961	.4115
19	.7973	.724	.6733	.6516	.6154	.6201	.6001
20	.7265	.7602	.7265	.7373	.7421	.691	.703
21		.5068	.4252	.6344	.6878	.6733	.6516
22	.443	.7964	.5847	.6001	.5611	.6201	.6001
23	.4784	.724	.5847	.5658	.5611	.5847	.5658
24	.4163	.4607	.6697	.6201	.5144	.5792	.567
Max	.8869	.7964	1.0498	1.0808	1.086	.9036	.9231
Min	.3944	.3258	.3012	.362	.3077	.2835	.2743
Avg	.5237	.5232	.5616	.5929	.5910	.6830	.6467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVVOOR

Feeder No / Name : 207 / Ex.BANGLA  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.2303	.1991	.2126	.1991	.2715	.2126
2	.1991	.2303	.1991	.2126	.1991	.2353	.2126
3	.1991	.2303	.1991	.2126	.1991	.1991	.2126
4	.2172	.2303	.1991	.2126	.181	.181	.2126
5	.1991	.2303	.1991	.2126	.181	.1629	.2126
6	.1991	.2126	.1991	.2126	.1991	.1448	.2126
7	.2172	.2126	.1991	.2126	.181	.2353	.2126
8	.362	.2126	.1991	.2126	.1991	.1991	.2126
9	.4163	.2303	.3439	.2126	.2896	.4344	.3012
10	.4075	.2353	.3189	.2172	.4344	.4607	.3077
11	.4252	.2353	.3721	.2172	.3982	.4252	.3439
12	.4252	.2353	.3544	.2172	.3258	.3544	.3439
13	.3544	.2454	.3544	.2353	.3439	.3189	.3258
14	.3012	.2353	.3012	.2172	.3801	.3898	.3258
15	.3366	.2353	.443	.2172	.3077		.3258
16	.3898	.2172	.4607	.2172	.362	.2835	.3258
17	.3012	.1991	.3366	.2172	.2715	.3189	.3801
18	.2658	.1991	.3012	.1991	.3439	.3366	.3077
19	.2658	.1991	.2835	.181	.3439	.2835	.3258
20	.1772	.2172	.2303	.2058	.1991	.1063	.2534
21	.2126	.1991	.2126	.2172	.2103	.2126	.2715
22	.2303	.2172	.2126	.2172	.2172	.2126	.3258
23	.2303	.2172	.2126	.2172	.2715	.2126	.362
24	.1991	.2303	.1991	.2126	.2172	.2896	.2126
Max	.4252	.2454	.4607	.2353	.4344	.4607	.3801
Min	.1772	.1991	.1991	.181	.181	.1063	.2126
Avg	.2804	.2224	.2721	.2133	.2690	.2725	.2808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 208 / KORADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4961	.6697	.4252	.3429	.3801	.3544
2	.4668	.4961	.7059	.5138	.3429	.3982	.3544
3	.5249	.6201	.7421	.6201	.3429	.4344	.3366
4	.5249	.6556	.7783	.691	.3772	.4706	.4075
5	.543	.4075	.8145	.8505	.4287	.5068	.4784
6	.905	.8505	.9774	.8859	.5316	.543	.5138
7	.3601	.4252	.362	.4075	.6001	.5792	.6556
8	.3429	.4961	.4887	.4075	.4801	.4525	.4075
9	.1715	.3721	.3801	.2835	.5792	.7602	.5847
10	.1949	.2715	.2481	.2058	1.0136	.6733	.724
11	.2126	.2896	.1772	.1886	.9412	.7796	.8507
12	.2481	.3077	.124	.1372	.9231	.7442	.7783
13	.1772	.2534	.124	.1372	.8688	.6201	.6335
14	.1772	.2172	.1063	.1372	.7602	.4607	.6697
15	.2126	.2896	.124	.1715	.7186	.5316	.6697
16	.2126		.2126	.2058	.8145	.7087	.6687
17	.2658	.3077	.2481	.2229	.0724	.0709	.1029
18	.4252	.3258	.2835	.2915	.1086	.1595	.2058
19	.5138	.5068	.3898	.3601	.4344	.2658	.4458
20	.3898	.4207	.3898	.4287	.4163	.3898	.3944
21	.4961	.3077	.3544	.3429	.333	.3366	.3429
22	.5138	.6516	.4961	.3429	.362	.3544	.362
23	.5493	.6697	.4607	.3258	.362	.3544	.3429
24	.362	.4961	.6516	.4252	.3258	.362	.3366
Max	.905	.8505	.9774	.8859	1.0136	.7796	.8507
Min	.1715	.2172	.1063	.1372	.0724	.0709	.1029
Avg	.3828	.4406	.4295	.3753	.5200	.4724	.4842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 202 / KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.8573	1.1431	.7545	.6516	.6325	1.2003
2	.7888	.8573	1.0669	.7922	.724	.5573	1.3717
3	.8573	.9145	1.1431	.9619	.8326	.6836	1.4937
4	.8987	1.2003	1.2696	1.0374	.9231	.724	1.448
5	.9774	1.3717	1.4937	1.0562	.9955	.8471	1.7909
6	1.0631	1.4937	1.531	1.094	1.0498	.8977	1.8404
7	1.166	1.4937	1.531	1.1128	1.5089	1.3717	1.1517
8	1.0288	1.4937	1.3957		1.3014	1.166	.9145
9	.6241	1.6804	1.2071	1.3937	1.2826	.8916	
10	1.307	1.6804	1.2851	1.267	.8573	1.0479	1.2384
11	1.3443	1.6766	1.3575	1.1222	.823	.8954	.679
12	1.3672	1.531	1.267	1.0679	.7716	.8573	.7733
13	1.2483	1.5546	1.1222	1.0679	.7888	.8573	.8676
14	1.3969	1.5546	1.1222	1.0498	.7373	.8383	.8676
15	1.4266	1.6057	1.1222	1.0498	.703	.9526	.8676
16	1.4003	1.4937	1.2851	.6878	.7716	.9526	.8299
17	.8954	1.0288	.7545	.7167	.8573	1.0098	1.1694
18	1.1431	.9526	.7167	.7356	.9259	1.1622	1.3957
19	1.4098	1.4289	.7545	.9808	1.0288	1.3717	1.5089
20	1.5242	1.5242	.7733	.9808	.7727	1.5242	1.2826
21	1.3717	1.3336	.8488	.6516	.6773	.5335	1.1222
22	1.3336	1.2765	.7733	.5792	.5647	1.105	.9412
23	1.1431	1.1431	.6859	.6154	.4923	1.2003	1.0317
24	.6687	.9907	1.1431	.7356	.5611	.5268	1.1431
Max	1.5242	1.6804	1.531	1.3937	1.5089	1.5242	1.8404
Min	.6241	.8573	.6859	.5792	.4923	.5268	.679
Avg	1.1294	1.3391	1.1164	.9353	.8584	.9419	1.1708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 203 / DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.6097	.5716	.6036	.3961	.4666	1.2765
2	.5144	.6668	.6668	.6224	.5281	.5068	1.448
3	.583	.6668	.6859	.7167	.6516	.543	1.531
4	.7202	.724	.7621	.8488	.8326	.703	1.6461
5	.7716	.8192	.8954	.9054	.8869	.6836	1.9605
6	.8817	.9907	.9526	.9997	.8688	.6859	1.9978
7	1.0288	.9907	1.105	1.1317	.5658	.583	.5716
8	.9088	.6478	.679	.7733	.6602	.6173	.6287
9	.2675	1.2765	.7468	1.0679	.7167	.4239	.5335
10	1.1431	1.4937	1.086	.9412	.3429	.381	.4954
11	1.1576	1.419	1.1584	.905	.2915	.2858	.1698
12	1.1999	1.3443	1.1222	.8507	.2743	.2667	.1886
13	.8962	1.4003	.9593	.8688	.3086	.2286	.2641
14	1.4045	1.4003	.724	.7602	.3086	.1905	.2829
15	1.3817	.9709	.6878	.6154	.3601	.3048	.3018
16	1.307	.9335	.8869	.7602	.4115	.3239	.3584
17	.3429	.381	.2829	.7545	.5316	.381	.679
18	.5144	.4191	.3584	.7545	.6173	.4382	.7545
19	.724	.8573	.5658	.7733	.7202	.6287	.7922
20	.7621	.8002	.6224	.7545	.5647	.6668	.7167
21	.7621	.7621	.6979	.3018	.5268	.3429	.7602
22	.6668	.6478	.6602		.4755	.9145	.6335
23	.6668	.6097	.6224		.4344	1.1431	.6878
24	.5487	.6097	.5716	.6413	.2452	.4428	1.1431
Max	1.4045	1.4937	1.1584	1.1317	.8869	1.1431	1.9978
Min	.2675	.381	.2829	.3018	.2452	.1905	.1698
Avg	.8181	.8934	.7530	.7887	.5217	.5064	.8259

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 204 / Borsar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	.6097	.724	.5792	.3772	.3944	.381
2	.301	.7621		.7964	.415	.4287	
3	.407	.8192	.7842	.8869	.4904	.4801	.4954
4	.4755	.9907	1.1203	.905	.5658	.5144	.5716
5	.5647	1.307	1.2323	.9412	.5658	.5256	.6097
6	.6081	1.4003	1.3443	.9955	.6036	.6001	.6287
7	.6516	.8048	.7621	.7356	.6224	.6274	.6478
8	.4458	.5601	.4954	.547	.724	.5487	.5144
9	.3429	.3429	.381	.3206	.9955	.8078	.8002
10	.3239	.2667	.1886	.2829	.8619	.9907	.9145
11	.2858	.2858	.1886	.2075	.8745	.8573	.6335
12	.2477	.2858	.1886	.1698	.6984	.7621	.6516
13	.2286	.2667	.0943	.1509	.5285	.8954	.5973
14	.3239	.2286	.2075	.1886	.5053	.6668	.6335
15	.3429	.3048	.2263	.2075	.535	.8573	.6878
16	.381	.381	.2263	.3395	.5573	.7842	.7602
17	.4572	.4191	.2829	.3395	.2743	.3429	.3772
18	.4382	.4572	.3206	.3206	.3258	.2667	.4338
19	.5335	.5335	.7356	.3772	.4801	.4382	.4715
20	.4954	.5144	.679	.4715	.5487	.5335	.4904
21	.4191	.4191	.6224	.3772	.4409	.4763	.3584
22	.4954	.8002	.543	.3772	.3772	.4382	.3206
23	.5144	.7621	.4706	.3395	.3429	.381	.3206
24	.2743	.5716	.6668	.4525	.3206	.3258	.381
Max	.6516	1.4003	1.3443	.9955	.9955	.9907	.9145
Min	.2286	.2286	.0943	.1509	.2743	.2667	.3206
Avg	.4114	.5872	.5428	.4712	.5430	.5810	.5513



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 205 / parsoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	1.4861	1.2193	.7421	.7733	.6783	.9526
2	.8288	1.3443	1.1431	.8688	.8676	.6783	.9907
3	.828	1.419	1.2955	1.094	.9997	.7202	1.0642
4	.873	1.4937	1.3169	1.1222		.8745	1.2323
5	.9214	2.1033	1.4937	1.4118	1.2449	.9945	1.307
6	1.1004	2.1033	1.4373	1.5023	1.4523	1.1043	1.4003
7	.9945	1.307	1.2955	1.226	1.2826	1.2403	1.2071
8	.9259	.9709	1.0082	1.0751	1.1222	.9259	.9907
9	.763	.8192	.9145	1.1317	1.086	1.0848	.8002
10	.8002	.8383	.5658		1.1294	1.4327	.8383
11	.7621	.5716	.6413		1.3466	1.3575	.9955
12		.6668	.3772		1.5432	1.307	1.1041
13	.5906	.6668	.1132		1.2186	1.1576	1.2308
14	.724	.5716	.3772		1.1145	.7621	1.267
15	.8192	.5716	.4715		1.1888	1.4632	1.267
16	.9145	.4954	.6036		1.1294	1.4563	1.3213
17	.8954	.6097	.679	.7922	.6516	.381	.9054
18	1.0288		.7545	.6979	.6859	.7621	1.0562
19	1.105		.9808	.9242	.9945	.9907	1.2637
20	.9526	1.105	1.0374	1.226	.8745	1.1431	.9431
21	.8002	.5335	1.0562	.9997	.7202	1.086	1.0374
22	.6859	.9335	.8507	.7545	.6687	1.0479	.9431
23	.7621		.9412	.7167	.6173	1.0479	.811
24	.7888	1.105		1.0498	.679	.6516	.9526
Max	1.105	2.1033	1.4937	1.5023	1.5432	1.4632	1.4003
Min	.5906	.4954	.1132	.6979	.6173	.381	.8002
Avg	.8501	1.0341	.8945	1.0197	1.0170	1.0145	1.0784

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 206 / KHADI CENTER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.1905	.1886	.0566	.1372	.1524
2	.0381	.1524	.2263	.0566	.125	.1524
3	.0381	.1524	.2263	.0566	.1492	.1905
4	.0381	.1524	.1698	.0566	.1311	.1905
5	.0381	.1143	.1698	.1132	.1355	.1905
6	.0381	.0762	.1509	.132	.1696	.1905
7	.0381	.1715	.0189	.1509	.1619	.1905
8	.0762		.0566	.132	.1715	.0953
9	.0381	.0762	.0189	.0566	.0819	.2858
10	.0381	.181	.0754	.0686	.1524	.3429
11	.0381	.3258	.1132	.0655	.2286	.132
12	.0381	.1448	.1886	.1029	.2286	.1509
13	.0381	.0905	.1886	.1638	.2286	.2075
14	.0381	.181	.1886	.1989	.2096	.2829
15	.0381	.3258	.1698	.3052	.2667	.3395
16	.0381	.3258	.132	.3932	.2858	.3206
17	.0762	.3395	.1886	.2915	.2477	.2829
18	.0953	.3584	.3206	.2058	.1905	.2075
19	.0762	.3206	.1886	.1372	.0953	.0566
20	.1905	.2829	.1509	.1372	.1905	.1886
21	.1905	.2641	.0566	.1492	.1905	.2452
22	.1524	.2829		.0972	.1524	.2263
23	.1524	.2829		.0972	.1524	.2641
24		.1905	.3206		.12	.1524
Max	.1905	.3584	.3206	.3932	.2858	.3429
Min	.0381	.0762	.0189	.0566	.0819	.0566
Avg	.0687	.2166	.1595	.1402	.1751	.2099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 201 / Babhulgaon SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4835	.4854	.4904	.5761	.57	.6001
2	.5658	.5316	.5601	.547	.6081	.6706	.6859
3	.6224	.6805	.6838	.6602	.6722	.7377	.7716
4	.7545	.724	.8413	.8676	.7125	.7956	.8402
5	.8676	.9492	1.0059	1.0242	.7773	.852	.8078
6	1.1317	1.1888	1.1157	1.1157	.852	.9012	.8993
7	1.2986	1.1222	1.2437	1.262	.8596	1.0608	.811
8	.9511	.8954	.7392	.9671	.7701	.823	
9	.6859	.7935	.7537	.9012	.5194	.5729	.6602
10	.8817	.664	.8356	.7773	.3898	.4481	.4715
11	.8192	.8583	.7202	.7935	.3361	.3772	.4294
12	.7773	.8907	.8309	.8097	.2614	.3395	.3734
13	.7287	.8421	.8139	.8356	.2614	.3395	.3921
14	.7042	.8848	.7888	.8097	.3361	.3018	.3734
15	.6964	.8192	.7716	.7611	.3547	.2829	.3734
16	.8192	.8029	.9156	.7682	.3547	.3395	.3898
17	.591		.3395	.3544	.4294	.415	.4477
18	.6878	.3696			.5228	.547	.4835
19	.8779	.8048	.8865	.8145	.8779	.8865	.6878
20	.7522	.8779	.9054	.8962	.7499	.7545	.9145
21	.6984	.7865	.8488	.6878	.8573	.7716	.6562
22	.6089	.6468	.6602	.6081	.7888	.7888	.7125
23	.5316	.5228	.547	.5921	.7468	.6859	.7701
24	.4527	.3898	.4481	.4338	.506	.5487	.5487
Max	1.2986	1.1888	1.2437	1.262	.8779	1.0608	.9145
Min	.4527	.3696	.3395	.3544	.2614	.2829	.3734
Avg	.7498	.7621	.7713	.7729	.5884	.6171	.6130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 202 / Rahegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2658	.2641	.2263	.3521	.4287	.4287
2	.3206	.3224	.3174	.3206	.4001	.5487	.5316
3	.3961	.3761	.4481	.4527	.4428	.6874	.703
4	.4904	.5068	.5359	.5281	.4858	.8048	.8139
5	.6413	.6335	.6219	.6224	.5281	.852	.7926
6	.7167	.7682	.6767	.6602	.5898	.9175	.8688
7	.811	.7682	.7682	.7167	.6036	.6401	.5658
8	.7545	.591	.499	.5138	.4656	.4805	
9	.4287	.5121	.5735	.5668	.3224	.2987	.3395
10	.5144	.4915	.5407	.5441	.2126	.2241	.2829
11	.5376	.6226	.583	.5182	.1867	.2263	.2452
12	.5668	.583	.6001	.4801	.1698	.2263	.2263
13	.5441	.5571	.583	.4428	.1698	.2263	.2263
14	.5506	.5571	.5316	.5121	.2263	.1886	.1886
15	.5668	.5407	.5144		.2452	.1886	.1509
16	.6062	.5735	.5316		.2263	.2263	.2075
17	.3403	.2957	.2263		.2801	.3395	.3018
18		.4066	.3772		.3174	.3584	.3658
19	.6401	.5853	.4904	.4835	.5487	.1886	.5853
20	.543	.6219	.6602	.5853	.5121	.4904	.5194
21	.5014	.5487	.5658	.4161	.4458	.415	.6154
22	.4298	.4481	.3961	.3887	.5144	.4458	.5601
23	.3544	.3921	.3206	.3321	.4694	.4287	.5218
24	.2829	.2481	.2641	.2641	.3163	.3772	.3601
Max	.811	.7682	.7682	.7167	.6036	.9175	.8688
Min	.2829	.2481	.2263	.2263	.1698	.1886	.1509
Avg	.5148	.5090	.4954	.4787	.3763	.4254	.4522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 203 / Nalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2721	.2743	.2743	.2481	.2263	.2641
2	.3086	.3041	.3185	.3258	.2865	.2829	.2829
3	.3258	.3239	.3688	.3944	.3224	.3174	.3395
4	.463	.3521	.4024	.4287	.362	.4108	.4338
5	.6001	.3887	.4424	.5144	.4163	.4668	.4904
6	.6859	.426	.5243	.583	.4755	.5175	.5281
7	.3772	.3801	.3841	.3584	.5304	.5853	.5658
8	.3395	.3582	.3292	.3439	.3582	.3658	
9	.2829	.2686	.2957	.2507	.5668	.426	.4115
10	.2263	.2241	.2263	.2279	.5281	.4858	.4458
11	.2149	.1867	.1886	.1772	.4915	.4801	.4588
12	.1772	.132		.1417	.4588	.4287	.4424
13	.2149	.1509	.1509	.1417	.4588	.4115	.4144
14	.2126	.1509	.1509	.1402	.431	.3944	.3812
15	.2303	.1886	.1132	.1417	.4752	.3429	.3725
16	.2865	.1886	.1886	.1772	.5243	.5144	.4096
17	.3258	.2241	.2263	.1772	.1494	.1132	.1227
18	.362	.2614	.2641		.2241	.1886	.1772
19	.4024	.3696	.2641	.3582	.3658	.4338	.2686
20	.3544	.3292	.4338	.3841	.3292	.3772	.3658
21	.3887	.4207	.5487	.3224	.2957	.3584	.3258
22	.3563	.4115	.4287	.3224	.2427	.2829	.3224
23	.3521	.3086	.3429	.2835	.2054	.2452	.3012
24	.2229	.2372	.2401	.2572	.2303	.2263	.2452
Max	.6859	.426	.5487	.583	.5668	.5853	.5658
Min	.1772	.132	.1132	.1402	.1494	.1132	.1227
Avg	.3320	.2857	.3090	.2924	.3740	.3701	.3639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 204 / AMANSPURWADI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5376	.57	.5658	.2835	.2641	.2829
2	.6516	.6401	.7545	.7545	.3224	.3018	.3018
3	.7373	.7611	.9389	.9326	.394	.3361	.3206
4	.9156	.9069	1.1469	1.17	.4344	.4108	.415
5	.9602	1.0402	1.278	1.2193	.4706	.462	.4527
6	1.0822	1.1469	1.4575	1.3565	.5304	.5121	.4904
7	.3772	.5487	.7316	.5658	.695	.5853	.5093
8	.4338	.5068	.4572	.4706	.4477	.4805	
9	.4715	.3582	.3921	.394	1.0279	.9339	.7621
10	.3395	.2987	.2263	.2149	1.1984	.9717	1.0513
11	.2481	.2241	.2641	.2126	1.1469	1.0669	1.0486
12		.1867	.2641	.1402	1.1142	1.3413	.9995
13		.1886	.2452	.1402	1.1174	.9907	1.0322
14	.2686	.1698	.2452	.1772	1.0688	.9145	1.0814
15	.3189	.1698			1.065	.9907	1.0486
16	.3224	.2427	.2641		1.1142	.9907	1.0978
17		.3511	.3018		.2241	.3584	.2427
18	.362	.4435	.415		.2987	.3772	.3734
19	.4572	.4938	.5281	.3761	.5487		.5068
20	.3761	.4207	.4527	.4572	.4938	.5093	.4298
21	.8421	.8413	.7545	.362	.3696	.415	.394
22	.8097	.9259	.823	.3224	.3174	.3206	.3544
23	.7682	.7716	.5144	.2865	.2801	.2641	.3155
24	.463	.4428	.5487	.5487	.2481	.2641	.2641
Max	1.0822	1.1469	1.4575	1.3565	1.1984	1.3413	1.0978
Min	.2481	.1698	.2263	.1402	.2241	.2641	.2427
Avg	.5597	.5257	.5902	.5334	.6338	.6114	.5989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 205 / dhondalgaon SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2835	.2801	.2829	.3841	.463	.4458
2	.3206	.3582	.3547	.3584	.4161	.5801	.5316
3	.415	.4119	.4854	.5658	.4696	.7209	.7373
4	.5093	.543	.5853	.5658	.5182	.8192	.8648
5	.6602	.6154	.6584	.679	.5601	.9503	.9835
6	.7545	.6805	.7682	.7922	.6226	1.0814	.9907
7	.8488	.823	.8779	.9431	.695	.695	.6413
8	.7167	.724	.5487	.6201	.6154	.6219	
9	.4801	.5992	.7045	.6478	.4298	.3734	.4715
10	.5658	.4915	.6882	.6718	.3224	.3361	.3206
11	.5761	.7045	.6516	.6478	.2987	.3206	.2801
12	.6154	.664	.5658	.5921	.2801	.3018	.2641
13	.6062	.6882	.6001	.5668	.2801	.2829	.2452
14	.5668	.6718	.583	.6154	.2614	.2561	.2641
15	.5441	.6554	.583	.6554	.2614	.2829	.2263
16	.5344	.7125	.6859	.6882	.2987	.3018	.2481
17	.2865	.2402	.2641	.2658	.2987	.3584	.2865
18	.3439	.3511	.3961		.3174	.3772	.3224
19	.5487	.5487	.5281	.5194	.5853	.6036	.6036
20	.5068	.5853	.6224	.5611	.5487	.5281	.543
21	.4656	.5121	.5281	.4001	.6001	.5487	.6718
22	.4477	.4294	.415	.4534	.5487	.5144	.5921
23	.4298	.3734	.3961	.4428	.503	.4973	.5601
24	.3018	.2481	.2801	.2829	.3479	.4115	.4115
Max	.8488	.823	.8779	.9431	.695	1.0814	.9907
Min	.2865	.2402	.2641	.2658	.2614	.2561	.2263
Avg	.5144	.5381	.5438	.5573	.4360	.5094	.5003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 206 / sanjarpurwadi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2881	.3086	.3258	.2126	.2641	.2829
2	.2743	.3163	.4287	.4287	.2507	.2987	.3018
3	.3086	.3521	.6036	.6001	.2686	.3547	.3584
4	.4801	.4534	.7701	.8059	.3258	.4481	.4527
5	.6516	.5441	.8848	.8383	.362	.499	.5281
6	.7202	.6554	1.0159	.9297	.394	.5487	.5658
7	.415	.2715	.1829	.3772	.4572	.5853	.6036
8	.3772	.2507	.3292	.3582	.3403	.2957	
9	.2641	.1595	.1867	.2835	.583	.5243	.5487
10	.2452	.168	.1509	.2658	.5601	.583	.5898
11	.1791	.1494	.1509	.1772	.6226	.5658	.5407
12	.1612	.1132	.1509	.1227		.5144	.4915
13	.1612	.1132	.1132	.1052		.4801	.547
14	.1417	.1132	.1132	.1052	.2743	.5144	.5304
15	.1612	.132	.1132	.1063	.5571	.6173	.4858
16	.1417	.1509	.1509	.1417	.5243	.5658	.5407
17	.2686	.2801	.2452	.1433	.112	.1698	.0876
18	.2715	.3734	.2829		.1494	.2641	.124
19	.3292	.3511	.3018	.2172	.4024	.4338	.2865
20	.3582	.2743	.3961	.2926	.3475	.3772	.3258
21	.3521	.4115	.5487	.2172	.2957	.3395	.2865
22	.3521	.3772	.4458	.1433	.2614	.3018	.2865
23	.3321	.3429	.4115	.1417	.2241	.2641	.2481
24	.2229	.253	.2743	.2743	.1753	.2641	.2641
Max	.7202	.6554	1.0159	.9297	.6226	.6173	.6036
Min	.1417	.1132	.1132	.1052	.112	.1698	.0876
Avg	.3087	.2873	.3567	.3218	.3500	.4197	.4033



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 201 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.631	.6836		.8238	.8238	1.1218
2	.6135	.6485	.7011		.8589	.8413	1.1568
3	.7011	.6661	.7362		.8413	.8939	1.2094
4	.7362	.6661	.7712		.9114	1.0867	1.3321
5	1.0166	.6836	.8063		1.1218	1.4548	1.595
6	1.0166	.7011	.8939		1.5424	1.8404	2.2786
7	1.0517	.8589	.8764		1.0341	1.0517	.7537
8	1.0166	.8764	.8939		.964	.929	.7712
9	.7888	.631	1.6827		.7011		.7888
10	.9816	2.1033	2.0332	2.0157		.5609	.7186
11	1.8054		2.0683	2.0683			.5083
12	1.9982	2.0157	2.0508	2.0157			.4031
13	2.1033	1.7703	1.7878	1.6827		.3856	.3856
14	1.8755	1.893	1.7353	1.4723		.3856	.3506
15	1.8054	1.7528	1.6827	1.3672		.4031	.333
16	1.9105	.4382	1.6651	1.595		.333	.4557
17	.7186	.4382	.4557			.4207	.5258
18	.7537	.8589	.4908	.5258		.4908	.7011
19		.9465	.4908	.8063		.8939	.7888
20		.8764	.8764	.964		.9114	.8939
21		.7888	.5434	.7011		1.0341	.9816
22		.7362	.5609	.8413		1.262	1.3321
23		.6135	1.9982	.8238		1.3321	1.1919
24		.631	.5959		.8238	1.3496	.9114
Max	2.1033	2.1033	2.0683	2.0683	1.5424	1.8404	2.2786
Min	.5959	.4382	.4557	.5258	.7011	.333	.333
Avg	1.1938	.9663	1.1284	1.2984	.9623	.8897	.8954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 202 / WAKLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557	.3856	.4031		.3506	.3506	.3681
2	.4733	.4031	.4207		.4031	.3681	.3856
3	.4908	.4207	.4908		.4382	.3856	.631
4	.5258	.4733	.5434		.5083	.4207	.6836
5	.6836	.6135	.7186		.5434	.5609	.8063
6	.8413	.7186	.7362		.6485	.8413	1.2445
7	.9465	.929	.8238		.8413	.8764	.6661
8	.7186	.7011	.5959		.5434	.6661	.6135
9	.4382	.5609	.7888		.5609		.6661
10	.5784	.5959	.7011	.7011		.5609	
11	.5959	.9465	.7186	.8063		.4382	.6836
12	.8939	.964	.7186	.7712		.4207	
13	.929	.9816	.9816	.7011		.4382	.4207
14	.7362	.9991	1.7002	.6661		.2279	.3856
15	.929	.7362	.7537	.6135		.3506	.4382
16	.9465	.8939	.4733	.7011		.3856	.4908
17		.5083	.4382	.2804		.3681	.5434
18		.5258	.5434	.4908		.4557	.5784
19		.631	.5609	.5959		.5434	.5959
20		.929	.5434	.6661		.5609	.631
21		.8764	.6661	.2804		.4557	.4908
22		.7011	.4382	.3506		.4908	.5959
23		.4031	.4557			.4031	.3856
24		.4031	.4733		.333	.4207	.298
Max	.9465	.9991	1.7002	.8063	.8413	.8764	1.2445
Min	.4382	.3856	.4031	.2804	.333	.2279	.298
Avg	.6989	.6792	.6537	.5865	.5171	.4778	.5729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 203 / Anchalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5258	.5434		.333	.2454	.5784
2	.5258	.5784	.5609		.333	.2629	.5784
3	.6485	.7186	.5784		.3681	.2629	.5959
4	.631	.8063	.631		.4031	.2629	.6135
5	1.3146	.8413	.6661		.4908	.3155	.6661
6	1.0341	.964	.8413		.5959	.4908	1.1919
7	1.0517	.9991	.8589		.8063	.929	.631
8	.8589		.8764		.7362	.6836	.7186
9	.4382	.7537	.7712		.5258		.5434
10	.4207	.8238	.7888	.8413		.4031	.3856
11	.7712	.8589	.7712	.8939		.2804	.3506
12	.929	.8238	.4557	.8063		.2629	.298
13	.9114		.6485	.7011		.2279	.2629
14	.8238			.6485		.2103	.2804
15	.7888		.7011	.5959		.2279	.2629
16	.8238		.7537	.6485		.2629	.3155
17	.4382		.298	.2804		.298	.3681
18	.5258		.3681	.4557		.4557	.5083
19		.8238	.7186	.7186		.6661	.5609
20		.7537	.7712	.6836		.8413	.7186
21		.7011	.7186	.3155		.6135	.5784
22		.7011	.6661	.3155		.7186	.7712
23		.5258	.5784	.3155		.6836	.7186
24		.5434	.631	.631	.3155	.7186	.5434
Max	1.3146	.9991	.8764	.8939	.8063	.929	1.1919
Min	.4207	.5258	.298	.2804	.3155	.2103	.2629
Avg	.7479	.7496	.6607	.5901	.4908	.4489	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 205 / Bhadli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9114	1.1218	1.1218		.4733	.4557	.5609
2	.9465	1.1568	1.1043		.4382	.4382	.5784
3	1.0341	1.1744	1.0867		.4382	.4207	.6661
4	1.0867	1.2269	1.1568		.4908	.4031	.6836
5	1.3146	1.3672	1.3321		.5434	.4207	.6135
6	1.5775	1.5074	1.7177		.631	.4382	.6661
7	.4557		.4733		.5959	.4908	.5434
8	.4733	.5083	.4908		.5434	.5083	.4382
9	.5258	.5258	.5083		1.4022	.4382	1.4899
10	.4733	.5609	.5258	.4557		2.1209	1.6651
11	.4557	.6135	.4908	.5083		2.1209	1.9105
12	.4733	.631	.5258	.4733		1.7528	1.8229
13	.4908	.631	.5434	.4557		1.56	1.6301
14	.4908		.5083	.4382		1.0867	1.595
15	.5083	.7011	.4908	.4382			1.5424
16	.5434		.5083	.4557		1.5074	1.6301
17	.5258	.5434	.5258	.5083		.3681	.4557
18	.5784	.5258	.5434	.5609		.3856	.4733
19		.7011	.5083	.631		.4031	.4908
20		.7712	.7186	.6135		.4382	.5083
21		.6135	.7186	.5434		.4557	.5434
22		1.1218	1.2795	.5258		.4733	.5609
23		1.2269	1.2795	.4908		.4908	.5784
24		1.0517	1.2445	1.2971	.4733	.5083	.6135
Max	1.5775	1.5074	1.7177	1.2971	1.4022	2.1209	1.9105
Min	.4557	.5083	.4733	.4382	.4382	.3681	.4382
Avg	.7147	.8705	.8085	.5597	.6030	.7689	.9275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 206 / 11 kv parala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3681				.4382		
8	.5258	.8063		1.1218	.4382	.5959	1.3672
9	.4733	1.0166	2.0157	2.0157	.5784		1.6827
10	.4557	1.1043		1.1919		.7186	1.6651
11	.8238	.9816		1.3847		1.0867	2.0157
12	.6135	1.1043		1.3321		.9991	1.9281
13	.631	1.1393		1.4548		.8589	1.858
14	.6135	1.2094		1.2795		.929	1.9281
15	1.6126	1.2445		1.2269			1.9456
16	1.858			.9465		1.262	1.9105
17		1.1568		.8939		1.2269	.5258
18		1.1043		.8413		1.1919	.6485
19	1.5074	1.1919		.8939		1.1568	.6485
20		.9816	1.0692	.8063		1.0867	.5609
21		1.1218	.9991	.8939		1.2445	.4733
22		1.6126	1.0867	.9114		1.3847	.5083
23		1.4022	1.2094	.9114		1.4022	.5434
Max	1.858	1.6126	2.0157	2.0157	.5784	1.4022	2.0157
Min	.3681	.8063	.9991	.8063	.4382	.5959	.4733
Avg	.8621	1.1452	1.2760	1.1316	.4849	1.0817	1.2631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 201 / 11 KV GARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3658	.3772	.4908	.6241	.6371	.7545
2	.4508	.2629	.3772	.691	.7499	.6706	.8048
3	.5014	.3544	.4715	.6836	.8505	.7545	.8383
4	.6024	.4668	.4715	.8596	.9036	.9221	1.0059
5	.6836	.443	.5658	.9362	1.0608	1.0059	1.0562
6	.7628	.5601	.6602	1.0692	1.1517	1.0898	1.0898
7	.7282	.543	.5935	.1772	.1402	.823	.8589
8	.6878	.6535	.7545	.2126	.1417	.567	.6348
9	.6935	.5935	.8402	.4784	.2126	.5041	
10	.724	.5935	.8402	.4908	.3294	.5601	.6161
11	.6661	.5601	.5935	.6024	.3547	.3734	.5601
12	.5959	.6104	.4159	.5895	.3361	.2801	.2801
13	.7095	.5087	.5959	.5373	.2614	.2614	.2804
14	.6535	.5087	.5316	.4755	.2427	.2427	.2947
15	.5658	.6443	.4854	.3641	.2987	.2241	.2507
16	.5658	.5935	.6024	.2947	.2801	.2614	.2774
17	.5281	.2543	.6733	.3012	.2987	.2987	.3121
18	.5658	.2543	.7499	.3189	.3361	.3734	.4161
19	.6706	.6783	.691	.3467	.4854	.4668	.4854
20	.5935	.5087	.6241	.3856	.4668		.6068
21	.5601	.4239	.5375	.4508	.4294		.6516
22	.4715	.3734	.4607	.5028	.5228		.6588
23	.4239	.3391	.3641	.5201	.5601	.5365	.6335
24		.4572	.4252	.5434		.5868	.6767
Max	.7628	.6783	.8402	1.0692	1.1517	1.0898	1.0898
Min	.3467	.2543	.3641	.1772	.1402	.2241	.2507
Avg	.5979	.4813	.5709	.5134	.4799	.5447	.6106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 202 / 11 KV MANOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5895	.6335	.6602	.4252	.5959	.7545	.8886
2	.631	.6335	.6602	.4961	.6878	.8383	.9221
3	.6733	.6401	.7167	.7059	.7265	.8383	1.0059
4	.7602	.7316	.7545	.7282	.8688	1.0562	1.1736
5	.8596	.724	.8488	.9328	.9774	1.0898	1.2574
6	.9214	.8402	.9431	1.0719	1.0808	1.1568	1.2407
7	.8859	.8764	.9431	.2126	.124	.9221	1.1888
8	.8413	.924	.7545	.2481	.1753	.6908	.7655
9	.6024		.9431	.6201	.3121	.6161	
10	.6878		.9431	.7108	.5201	.5601	.7468
11	.7282		.9326	.6661	.4481	.4668	.5601
12	.9671	1.4243	.8745	.5959	.3734	.4108	.3734
13	.8488	.9335	.8688	.5068	.3921	.3734	.3641
14	.8488	.8478	.5493	.4656	.3734	.3361	.3814
15	.6706	.8488	.691	.4298	.4481	.3361	.4161
16	.6706	.8402	.7265	.3841	.4481	.4854	.4334
17	.8488	.5601	.8505	.443	.4668	.5415	.5375
18	.8383	.5087	.691	.4681	.5487	.6535	.8871
19	1.0374	.9431	.7265	.5258	.8682	.7973	.9593
20	.9335	.7545	.7888		.8145		1.0576
21	.7545	.6443	.695	.6068	.503		1.0166
22	.5935	.5658	.567	.6415	.5533		.9114
23	.5658	.5601	.2804	.6068	.5868	.9054	.8596
24		.5601	.3121	.5434		.6706	.8505
Max	1.0374	1.4243	.9431	1.0719	1.0808	1.1568	1.2574
Min	.5658	.5087	.2804	.2126	.124	.3361	.3641
Avg	.7721	.7616	.7384	.5668	.5606	.6905	.8173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 203 / 11 KV POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	2.3529	1.8861	.8505	1.0166	.7655	.6535
2	1.0056	2.2539	1.8861	.8764	1.0631	1.1203	.8402
3	1.1163	2.4539	2.0748	.9465	1.1694	1.2803	.9145
4	1.3003	2.4272	2.0748	1.0056	1.0808	1.5769	1.5546
5	1.5257	2.6863	2.2634	1.0631	1.0277	1.5947	1.7364
6	1.9071	2.8349	2.2634	.9036	.9036	1.8861	1.7718
7	1.387	2.9569	1.3203	.8413	.8322	1.8073	1.7703
8	1.3523	1.4899	1.4146	1.4043	.6762	1.4529	1.5181
9	1.2656	1.0343	.5658	1.9071	1.283	1.6004	
10	.1734	1.0343	.5658	1.7337	2.3743	1.4937	1.5242
11	.2804	.2829	.1187	1.6651	1.7071	1.6766	1.5394
12	.4075	.2374	.168	1.7177	1.6613	1.6309	1.6309
13	.3206	.3772	.1772	1.7002	1.6975	1.5242	1.8204
14	.3206	.3391	.1578	1.6827	1.6461	1.5242	1.6476
15	.5658	.2543	.1928	1.6655	1.4373	1.4575	1.6651
16	.9431	.2543	.1417	1.7541	1.4754	1.0059	1.6126
17	1.0059	.6036	.2126	.4784	.4668	.1307	.1417
18	1.1317	.5426	.2481	.6024	.5304	.7095	.6154
19	1.3203	1.1317	.7973	.6241	.9774	1.0631	1.0166
20	1.3565	1.226	1.2403	.7087	1.0425		1.1744
21	1.6766	1.5089	1.0808	.7282	1.0059		1.2445
22	2.0748	1.5089	.8505		.9922		.9328
23	2.0348	1.4146	.7619	.964	.9145	.7468	.8842
24		2.1719	.7265	1.0277		.7468	.8322
Max	2.0748	2.9569	2.2634	1.9071	2.3743	1.8861	1.8204
Min	.1734	.2374	.1187	.4784	.4668	.1307	.1417
Avg	1.0974	1.3907	.9662	1.1674	1.1731	1.2759	1.2627



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 201 / biloni SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0322	1.278	1.3272	1.2654	.9522	.9054	.9335
2	1.0814	1.3108	1.3123	1.2654	.9335	.9054	.9335
3	1.1469	1.3435	1.3603	1.358	.9335	.9054	.9709
4	1.2003	1.4091	1.4251	1.4685	.9709	.9242	.9335
5	1.2803	1.4251	1.4899	1.6248	1.0082	1.0185	.9709
6	1.8244	1.8623	2.1052	2.0309	1.0456	.8488	1.0082
7	.6036	.7842	.7922	.6036	1.0829	.9808	.9335
8	.6908	.9709	1.0456	.7842	.9709	.7922	.9054
9	.8215	1.0082	.9335	.7468	1.8138	1.6667	1.475
10	.8215	1.0269	.8962	.7095	1.8976	1.5242	1.6156
11	.8402	.961	.8402	.6722	1.5432	1.4632	1.4815
12	.7468	.8501	.7468	.5788	1.1149	1.2498	1.3546
13	.6722	.8775	.6535	.6161	1.1736	1.1145	1.2029
14	.7095	.7468	.6535	.6161	1.2323	.873	1.0269
15	.7468	.7468	.6722	.5975	1.3094	.9907	1.0269
16	.8589	.7655	.6722	.7095	1.3546	1.2452	1.278
17	1.0456	.9979	.7095	.4481	.4108	.4668	.4338
18	1.0269	.924	.7842	.7655	.6908	.5975	.4527
19	1.0082	1.0185	.9808	.9522	.9808	1.0829	.4527
20	1.0082	.8676	.8402	.9522	.9242	1.0185	.9997
21	.9172	1.2029	.9659	.9709	.9431	.9808	1.0374
22	1.2334	1.2342	1.0536	1.0642	.9619	.9896	.9997
23	1.2651	1.1888	1.1736	1.0456	.9431	1.0269	.9431
24	.8128	1.1683	1.1584	1.2041	.9896	.9054	.9896
Max	1.8244	1.8623	2.1052	2.0309	1.8976	1.6667	1.6156
Min	.6036	.7468	.6535	.4481	.4108	.4668	.4338
Avg	.9748	1.0820	1.0247	.9604	1.0909	1.0199	1.0150

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 202 / jarul SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.8589	.8402	.8402	.5243	.547	.6478
2	.8775	.8589	.8589	.8402	.5243	.5636	.6478
3	.8775	.8589	.8962	.8775	.5407	.7625	.6478
4	.9149	.8962	.8962	.8962	.5571	.9116	.6802
5	.9709	.9335	.9335	.9149	.5898	1.1105	.8192
6	1.0082	.9896	1.0456	.9335	.6062	1.326	1.0898
7	1.0456	.9709	1.0082	.9335	.5415	.499	.5914
8	.9335	.6722	.7762	.8501	.6535	.6653	.6653
9	.4508	.6718	.9488	1.085	.7095	.7762	.7207
10	.5571	.7968	.6923	1.1336	.6283	.6468	.679
11	.7373	.8592	.6371	.9069	.5359	.6099	.695
12	.8192	.8025	.6001	.8259	.439	.5914	.5853
13	.6718	.6398	.5841	.7865	.4755	.5359	.5041
14	.6299	.6447	.6287	.7537	.4755	.3881	.5601
15	.6133	.6173	.6748	.7373	.4938	.499	.5975
16	.779	.6676	.7133	.8259	.5487	.5792	.7095
17	.3174	.3582	.4656	.3547	.6516	.6697	.8048
18	.7468	.4525	.6767	.5788	.7499	.695	.8779
19	.8215	.9795	.8962	.7655	.8501	.8871	.9335
20	.8775	.9425	.961	.8775	.8962	.9055	.8316
21	.8589	.9055	.9709	.583	.583	.6554	.6642
22	.8215	.924	.9335	.5533	.7042	.6722	.7611
23	.8215	.8501	.8775	.5344	.6154	.6167	.6081
24	.9149	.8029	.8316	.8402	.5243	.583	.6325
Max	1.0456	.9896	1.0456	1.1336	.8962	1.326	1.0898
Min	.3174	.3582	.4656	.3547	.439	.3881	.5041
Avg	.7893	.7898	.8061	.8012	.6008	.6957	.7064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 203 / lakh khandala SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4854	.5281	.4715	.4752	.5304	.6401
2	.4904	.4854	.5281	.4715	.4752	.5967	.6401
3	.4904	.4854	.547	.4904	.4915	.6464	.6722
4	.5093	.4854	.5658	.5093	.5243	.8097	.7042
5	.547	.5228	.6036	.5658	.5571	1.0364	.8223
6	.5847	.5228	.6602	.6036	.6802	1.4575	1.0242
7	.6413	.6161	.5847	.547	.1494	.1886	.1886
8	.4904	.3921	.3584	.4338	.2801	.3018	.3395
9	.3311	.8029	.7922		.3174	.3206	.3018
10	.6062	.8855	.7613	.8907	.2987	.3361	.3018
11	.4424	.8993	.6859	.8097	.2801	.2641	.2452
12	.8848	.8535	.6001	.7773	.2614	.1886	.2263
13	.8029	.7371	.5201	.7209	.2801	.2263	.2427
14	.7459	.5201	.5658	.6882	.2801	.2452	.2614
15	.6796	.5952	.6607	.6554	.2957	.2263	.2801
16	.8619	.7034	.7468	.7611	.2957	.2801	.3361
17	.1494	.1867	.1509	.1494	.3326	.3511	.3961
18	.3361	.2641	.2829	.2241	.3511	.3881	.415
19	.5041	.4527	.4338	.3361	.3772	.415	.4527
20	.4668	.5093	.4527	.3921	.3772	.3772	.415
21	.4854	.5093	.4715	.3467	.5487	.4725	.4755
22	.4854	.547	.4715	.503	.6952	.602	.6706
23	.4854	.5658	.4715	.4696	.535	.5992	.5639
24	.5093	.4854	.547	.4715	.4752	.5182	.6401
Max	.8848	.8993	.7922	.8907	.6952	1.4575	1.0242
Min	.1494	.1867	.1509	.1494	.1494	.1886	.1886
Avg	.5425	.5630	.5413	.5343	.4014	.4741	.4690

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044109 / 33 KV Khandala

Feeder No / Name : 201 / 11 KV JANEFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2263	.2263	.3605	.3932	.3441
2	.2829	.2263	.2641	.2263	.3932	.4096	.4096
3	.2641	.2641	.2641	.2263	.4424	.4696	.4588
4	.3018	.3206	.2829	.1886	.5243	.4801	.5243
5	.3018	.3772	.3018	.1886	.5735	.6241	.6882
6	.3206	.3395	.3206	.1886	.6226	.7362	.7537
7	.2263	.2641	.3772	.1886	.0754	.0754	.0754
8	.3018	.1698	.3206	.2263	.2829	.1886	.2263
9	.3018	.4915	.5079	.4999	.2263	.2263	.1698
10	.4915	.6882	.6226	.703	.1509	.1132	.1886
11	.5898	.7537	.6062	.6554	.1509	.0754	.1509
12	.639	.6241	.5571	.5079	.1509	.0754	.1509
13	.5898	.5898	.4915	.4588	.1132	.0943	.1509
14	.4588	.5155	.4481	.426	.0754	.0943	.1132
15	.4752	.6081	.4428	.5079	.1132	.0943	.1509
16	.5898	.5937	.5571	.6226	.1132	.0943	.1698
17	.1132	.1132	.0377	.0943	.1509	.1509	.1509
18	.1886	.132		.1132	.1886	.1886	.1509
19	.2452	.1886	.2263	.2263	.2641	.3206	.3772
20	.2829	.2829	.2641	.2829	.3206	.3584	.3395
21	.3206	.3206	.2641	.213	.3563	.2949	.285
22	.3018	.3584	.2641	.2458	.5182	.3277	.3018
23	.2641	.2263	.2641	.2949	.5898	.3277	.2984
24	.2641	.2263	.2263	.2949		.5735	.3605
Max	.639	.7537	.6226	.703	.6226	.7362	.7537
Min	.1132	.1132	.0377	.0943	.0754	.0754	.0754
Avg	.3492	.3709	.3538	.3253	.2938	.2828	.2912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044109 / 33 KV Khandala

Feeder No / Name : 202 / 11 KV BHAVARBEN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.5735	.6554	.4801	.2263	.2452	.2452
2	.3277	.5898	.6802	.4801	.2263	.2641	.2452
3	.4096	.6882	.6802	.4801	.2829	.3018	.2829
4	.5243	.8192		.6562	.4338	.3395	.3395
5	.6554	1.0722	.6882	.8436		.3772	.3772
6	.6562	1.278	1.0364	1.0623	.4715	.415	.3961
7	.132	.1509	.1132	.061	.415	.4338	.4527
8	.132	.1698	.1509	.2452	.2452	.2452	.1886
9	.1966	.2075	.2075	.2641	.8162	.9175	.7045
10	.1886	.3018	.1698	.2452	1.0279	.9012	.9555
11	.1698	.2263	.1509	.1886	.9842	.8192	.8421
12	.2263	.2641	.1698	.1509	.8749	.664	.6478
13	.2075	.2829	.1509	.1509	.7811	.5407	.583
14	.1886	.2452	.1509	.1698		.3932	.547
15	.2263	.2263	.132	.1698	.5535	.4424	.6299
16	.2452	.2452	.2263	.1698	.6154	.4915	.663
17	.2829	.3018	.1509	.2263	.0754	.1132	.1132
18	.3018	.3395	.2641	.2829	.0754	.1698	.1132
19	.3395	.3395	.3018	.034	.2641	.2641	.3361
20	.3772	.3018	.3018	.3206	.3584	.3018	.2987
21	.3605	.3605	.4531	.2829	.3584	.3584	.3174
22	.4915	.5898	.5624	.2641	.3772	.3206	.2987
23	.5735	.5735	.5937	.2263	.3395	.3206	.2987
24	.2622	.6062	.4915	.2263		.3018	.2641
Max	.6562	1.278	1.0364	1.0623	1.0279	.9175	.9555
Min	.132	.1509	.1132	.034	.0754	.1132	.1132
Avg	.3238	.4481	.3688	.3200	.4668	.4142	.4225