

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 201 / 11 KV SAJAPUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1052	.1448	.132	.0377	.0351	.0328
2	.1132	.1052	.1448	.1132	.0377	.0351	.0339
3	.1509	.1402	.1646	.1509	.0377	.0526	.0339
4	.1886	.2103	.1991	.1886		.0526	.0509
5	.2641	.2629	.2534	.2452	.0747	.0876	.0678
6	.3584	.3155	.3506	.3395	.112		.0934
7	.415	.3856	.3734	.415	.1646	.1402	.2035
8	.3206	.333	.2829	.3772	.1646	.1578	.1696
9	.1802	.2743	.1463	.3018	.0934	.0876	.1187
10	.0701	.0514	.0754	.0351	.1052	.112	.0754
11	.0351	.0732	.0655	.0526	.0526	.0732	1.7353
12	.0526	.0549	.7701	.0351	.0526	.0943	.0943
13	.0526	.0339	.0566	.0351	.0351	.056	.0943
14	.0351	.0339	.0655	.0351		.0732	.0377
15	.0351	.0366	.0492	.0351	.0701	.0732	.0377
16	.0351	.0328	.0492	.0747	.0526	.128	.1132
17	.0351	.0509	.0492	.1227	.1227	.0732	.0943
18	.1402	.0549	.1132	.1886	.1052	.1097	.1132
19	.2454	.2195	.2829	.2801	.2279	.2743	.2641
20	.2454	.2195	.3018	.2801	.2629	.2715	.2452
21	.2103	.1646	.2075	.2054	.1753	.2012	.1698
22		.1494	.1698	.1698	.1578	.181	.132
23		.112	.1509	.1698	.1227	.1494	.132
24	.1494	.1402	.1017	.1132	.0373	.1052	.0362
Max	.415	.3856	.7701	.415	.2629	.2743	1.7353
Min	.0351	.0328	.0492	.0351	.0351	.0351	.0328
Avg	.1575	.1483	.1904	.1707	.1047	.1141	.1741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 202 / 11KV DAULATABAD FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5466	1.4022	1.3756	1.4712	.5721	.5959	.6274
2	1.5089	1.4373	1.3575	1.4335	.5548	.6135	.6104
3	1.531		1.4266	1.4901	.5487	.6135	.6154
4	1.6598		1.5912	1.6032	.6001	.7011	.6274
5	1.773		1.6827	1.7541	.6859	.7011	.6613
6	2.1691		1.8823	2.0182	.7716	1.0517	.78
7	2.3388	2.226	2.0485	2.2445	.9431	1.1043	1.0004
8	2.2799	2.4188	2.1176	2.3765	1.0288	1.1568	1.1191
9	2.1098	2.4691	1.8839	2.2068	.8916	1.0517	.9326
10	.9114	1.0631	.9431	1.0117	1.7528	.9145	1.7353
11	.8764	.9665	.7537	.9259	1.5424	1.8673	.1735
12	.8413	.8669	.7701	.8402	1.2269	1.6644	1.6409
13	.7537	.7122	.6882	.8589	1.4899	1.5684	1.5844
14	.7011	.583	.7045	.8238		1.448	1.4146
15	.7011	.6783	.7701	.7362	1.3847	1.4563	1.4712
16	.7362	.7209	.7373	.823	1.4548	1.5912	1.4335
17	.7362	.78	.7865	.8551	1.56	1.7558	1.6598
18	1.7177	1.6278	1.773	1.9204	1.6827	1.643	1.6787
19	1.9806	1.8991	2.2257	2.2314	2.0858	2.1033	2.1502
20	1.9806	2.1399	2.2257	2.1765	2.2085	2.3594	2.2634
21	1.9456	2.0119	2.0559	2.1033	2.1033	2.0452	2.0748
22		1.7924	1.8673	1.9204	1.8755	1.9231	1.9418
23		1.5912	1.6975	1.7375	1.7703	1.7551	1.7353
24	1.5684	1.4373	1.39	1.5278	.5721		.6697
Max	2.3388	2.4691	2.2257	2.3765	2.2085	2.3594	2.2634
Min	.7011	.583	.6882	.7362	.5487	.5959	.1735
Avg	1.4712	1.4412	1.4481	1.5454	1.2742	1.3776	1.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 203 / 11KV FATIYABAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2785	.2454	.2561	.2294	.8215	.7011	.7602
2	.2949	.2629	.2458	.2458	.8589	.7186	.7602
3	.2622	.2804	.2372	.3018	.9335	.7537	.7964
4	.2949	.298	.2458	.2785	.9896	.8764	.8326
5	.2785	.298	.3113	.3395	1.0456	.8939	.9231
6	.4096	.3506	.3605	.4854	1.1576	.8764	1.0317
7	.8029	.8238	.5426	.7922	1.1389	1.0166	1.2254
8	.7865	.8063	.5596	.7373	.7842	.8589	.8779
9	.4915	.6718	.5426	.5735	.7468	.6485	.7468
10	.7011	.6584	.5658	.4908	.4733	.6783	.5079
11	.4733	.5304	.5281	.5959		.5853	.5079
12	.3155	.4572	.4715	.7095	.5784	.5182	.4915
13	.4908	.4207	.5281	.6348	.5609	.4917	.4096
14	.4382	.4572	.5281	.5959		.4424	.4715
15		.4207		.5609	.5083	.4525	.3961
16		.4887	.5093	.6135	.5434	.5426	.415
17		.6036	.5281	.6908	.4733	.5571	.4915
18	.7888	.5853	.6979	.7468	.7011	.6697	.6036
19	.8764	.9242	.9431	.9709	.929	.9328	1.1016
20		.9328	.9997	1.0269	.9991	1.0642	.9054
21	.8238	.7964	.8775	.9522	.8764	.9522	.9431
22		.7316	.8299	.9335	.7888	.9054	.9054
23		.6908	.6554	.8402	.7011	.8048	.811
24	.2949	.2279	.2374	.2294	.8215	.7011	.7602
Max	.8764	.9328	.9997	1.0269	1.1576	1.0642	1.2254
Min	.2622	.2279	.2372	.2294	.4733	.4424	.3961
Avg	.5057	.5401	.5305	.6073	.7923	.7351	.7365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 204 / PARAS INDUSTRIAL Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	17-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
3	***		
20			1.3203
21		3.4139	
Max	12.0336	3.4139	1.3203
Min	12.0336	3.4139	1.3203
Avg	12.0336	3.4139	1.3203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 205 / ASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2279	.2374	.2294	.5975	.5434	.7621
2	.213	.2454	.2374	.2427	.5601	.5609	.7811
3	.2458	.2629	.2629	.2458	.6161	.6135	.8192
4	.3361	.2629	.2785	.3206	.6535	.7011	.8676
5	.3277	.3155	.3391	.3277	.8402	.8413	1.0185
6	.3932	.3155	.39	.4588	.9896	.8764	1.1812
7	.6882	.6135	.5426	.6226	1.0829	1.0517	1.1241
8	.6226	.5083	.6554	.6062	.9709	.8589	.9526
9	.6161	.4917	.5079	.4915	.7655	.7362	.8383
10	.4733	.5658	.5093	.4207	.4031	.39	.3768
11	.3856	.4572	.5093		.4031	.407	.3961
12	.3681	.381	.3561		.3856		.3277
13	.3856	.4001	.3605		.1402	.4239	.3772
14		.415	.415			.4096	.3277
15	.3856	.3961	.415	.2454	.3155	.4239	.3768
16	.4207	.4382	.415	.5434	.5083	.4239	.3605
17	.4031	.4715	.4481	.6161	.4557	.4239	.3932
18	.5083	.5906	.5093	.6535	.6485	.6859	.547
19	.7888	.8192	.8676	.8589	.7888	.9526	.8029
20	.7888	.8954	.8865	.8962		1.0185	.9054
21	.7362	.743	.503	.7842	.8764	.9526	.8488
22		.6668	.679	.7282	.7537	.9145	.2263
23		.5906	.6224	.6908	.7537	.8192	.679
24	.2294	.2279	.2374	.2458	.6535	.7011	.7621
Max	.7888	.8954	.8865	.8962	1.0829	1.0517	1.1812
Min	.213	.2279	.2374	.2294	.1402	.39	.2263
Avg	.4546	.4709	.4660	.5114	.6437	.6839	.6688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 206 / 11 KV JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8063	.8383	.8589	.4557	.6135	.4409
2	.8865	.8413	.8299	.8962	.4908	.6135	.4409
3	.9431	.8764	.8326	1.0269	.5201	.631	.4748
4	1.226	.8764	.8676	1.1317	.5487	.6661	.5087
5	1.3203	1.2269	1.2071	1.2826	.6173	.6661	.6226
6		1.1919	1.358		.6706	1.1218	.7122
7	1.4335	1.1919	1.3394	1.1949	.9259	1.1568	1.153
8	1.358	.9816	1.3014	1.358	.8573	1.1568	1.0852
9	1.1203	.8573	.9907	1.0562	.583	.8063	.6443
10	.2279	.4409	.5281	.6516	.5959	.724	.6036
11	.5258	.407	.4915	.5258	.4908	.5716	.5658
12	.4207	.426		.5144	.4557	.4572	.5281
13	.4908	.373	.426	.5144	.4207	.4954	.4527
14	.4557	.407	.426	.5258		.4706	.4527
15	.3506	.3052	.4904	.5959	.4207	.4572	.426
16	.4557	.4748	.5571	.5258	.4908	.4904	.4904
17	.4557	.5087	.4915	.5258	.5258	.6097	.5281
18	.7011	.7167	.6413	.6348	.298	.6097	.6036
19	.5959	1.1431	1.1317	1.0829	.9465	1.105	1.1317
20	1.0166	1.2574	2.2257	1.1949	1.1218	1.3717	1.3203
21	1.0166	1.1431	1.0456	1.1203	1.0517	1.2574	1.3203
22		1.0669	.9054	.9709	.9465	1.105	.9808
23		.8764	.8676	.9335	.9114	.9145	.9054
24	.8962	.8063	.8383	.8299	.4207	.8764	.4458
Max	1.4335	1.2574	2.2257	1.358	1.1218	1.3717	1.3203
Min	.2279	.3052	.426	.5144	.298	.4572	.426
Avg	.7983	.8001	.8970	.8675	.6420	.7895	.7016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 207 / SHAHAPUR BANJARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2103	.2374	.2785	.4854	.5434	.4715
2		.2103	.2374	.2458	.4854	.5434	.4572
3	.2294	.2279	.2429	.2785	.5228	.5609	.4763
4	.2458	.2804	.2743	.3277	.5601	.6135	.5093
5	.2622	.298	.3222	.3605	.7282	.6661	.7049
6	.3768	.3506	.3801	.4904	.8215	.7362	.8002
7	.5735	.5784	.5487	.5571	.7655	.7362	.7545
8	.5571	.5784	.5935	.6226	.5601	.4733	.6478
9	.3932	.4409	.3953	.4752	.4108	.333	.4572
10	.3506	.2286	.4481	.4207	.3856	.3052	.2949
11	.298	.2829	.2641	.3681	.2454	.3561	.3932
12	.2454	.2743	.2452	.3361	.2454		.3605
13	.2454	.2263	.2263	.2454	.3681	.39	.3734
14	.2454	.439	.2263	.2629		.3932	.3932
15	.2103	.1905		.2454	.3506	.4239	
16	.2103	.2096	.2801	.2454	.4382	.4239	.3441
17	.2454	.2829	.2829	.2987	.298	.4239	
18	.3681	.4001	.2641	.3734		.3429	
19	.4908		.547	.5975	.5083	.4572	.6036
20	.4908	.6224	.5658	.6348		.547	.6036
21	.5434	.5716	.8215	.5601	.5784	.5716	.6413
22		.4763	.4527	.5041	.4733	.5335	
23		.4338	.3772	.4854	.4382	.4572	.415
24	.2458	.2804	.2374	.213	.4481	.4207	.439
Max	.5735	.6224	.8215	.6348	.8215	.7362	.8002
Min	.1966	.1905	.2263	.213	.2454	.3052	.2949
Avg	.3345	.3519	.3683	.3928	.4818	.4892	.5070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 208 / Paper Mill (Saptashrungi) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2103	.3222	.2614	.2772	.1928	.2054
2	.2241	.1928	.3439	.2452	.2957	.2103	.1991
3	.1802	.2279	.2883	.2241	.3142	.2103	.1867
4	.1966	.3155	.2561	.2054	.2957	.1928	.2172
5	.1966	.3155	.2172	.1802	.2772	.1928	.2054
6	.2829	.2103	.2172	.213	.2587	.2103	.1867
7	.2801	.2103	.1865	.2427	.2402	.2103	.1829
8	.2801	.1753	.2378	.3921	.2587	.2279	.2543
9	.3174	.3658	.2172	.2987	.2587	.3155	.3174
10	.3681	.3658	.3174	.298	.3681	.4024	.3734
11	.4207	.3361	.4338	.3801	.2279	.4938	
12	.4031	.3292		.3681	.2103	.4481	.3361
13	.298	.2012	.426	.2279	.3681	.3292	.3605
14	.2629	.1829	.3584	.298		.3292	.3174
15		.2195		.3506	.3506	.3475	.2987
16	.2103	.1646	.4294	.1928	.4207	.3475	.3961
17	.2103	.1829	.3772	.2507	.2804	.3982	.3772
18	.3681		.2987	.3142	.2454	.3109	.3547
19	.298	.3109	.2641	.2926	.4908	.3109	.2614
20	.298	.2172	.2641	.3258		.2378	.1886
21	.298	.2427	.2452	.362	.298	.2534	.2641
22		.2561	.2075	.2957	.2454	.2641	.3206
23	.2804	.3547	.2801	.3326	.2279	.2427	.415
24			.3475		.2957	.2103	.2534
Max	.4207	.3658	.4338	.3921	.4908	.4938	.415
Min	.1802	.1646	.1865	.1802	.2103	.1928	.1829
Avg	.2809	.2540	.2971	.2849	.2957	.2870	.2814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 201 / 11KV Chowka Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2096	.2286	.2286	.2667	.1905	.2286
2	.2286	.2286	.2286	.2286	.2667	.2096	.2286
3	.3048	.2477	.3048	.2858	.3048	.2286	.2858
4	.381	.2667	.4572	.381	.362	.3048	.381
5	.5335	.3429	.5716	.4763	.4954	.381	.5144
6	.6859	.5716	.6478	.724	.6668	.5335	.6478
7	.8002	.8573	.8192	.724	.8002	.7621	.8192
8	.6859	.7621	.743	.6668	.6859	.6668	.7049
9	.5716	.6859	.6668	.6478	.5716	.5906	.5906
10	.4572	.4954	.4191	.381	.3429	.4954	.4572
11	.3048	.381	.2858	.3048	.3048	.4001	.2858
12	.2858	.2858	.2667	.2858	.2667	.3239	.2477
13	.2667	.2477	.2667	.2286		.2858	.2477
14	.2667	.2477	.2096		.2096	.2858	.2286
15	.2667		.2286		.2286	.2667	.2286
16	.2667		.2286		.2477	.2477	.1524
17	.3048	.2858	.2667		.2667	.2667	.2858
18	.4191	.4572	.3239		.4572	.362	.4191
19	.6097	.7049	.6859	.5906	.5335	.5335	.6287
20	.5144	.6668	.5716	.4954	.381	.6097	.5716
21	.4382	.5144	.4191	.4001	.381	.5144	.4954
22	.362	.4191	.3429	.3429	.3048	.381	.381
23	.3048	.3239	.2667	.2858	.2667	.2858	.3429
24	.2286	.3048	.2477	.2667	.2667	.1905	.2477
Max	.8002	.8573	.8192	.724	.8002	.7621	.8192
Min	.2286	.2096	.2096	.2286	.2096	.1905	.1524
Avg	.4056	.4321	.4041	.4181	.386	.3882	.4009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 202 / 11 KV SAWANGI Ag

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4382	.4191	.4001	.5906	.4763	.4763
2	.4572	.4382		.4001	.5906	.5144	.4763
3	.4763	.4572	.4763	.4763	.6287	.5335	.5335
4	.5335	.5144	.5144	.5716	.6668	.5335	.5716
5	.5716	.5335	.5716	.6287	6.973	.5335	.6287
6	.5716	.5716	.5716	.6668	.724	.5716	.6668
7					1.5623	1.4861	1.5242
8					1.6194	1.5623	1.5432
9					1.105	1.7147	1.6194
10	.9526	1.086	1.086	1.2955			.4763
11	1.0479	1.0479	1.0669	1.0669			.4763
12	1.0479	.9526	.9526	.9907	.5335	.5716	.5335
13	1.0288	.8573	.8764	.9526	.4763	.5716	.5716
14	.8573	.7621	.6478		.5335	.5335	.5525
15	.724	.6668	.724		.5335	.5525	.5525
16	.8573	.6668	.8573		.5716	.5716	.5716
17	.8764	.6097	.8764		.5716	.5716	.5716
18	.5335	.4763	.4382		.5716	.5716	.5716
19	.5716	.5716	.6287	.5716	.5716	.5716	.5716
20	.5716	.5716	.5906	.5716	.5716	.5716	.5716
21	.5335	.5716	.5525	.5716	.5716	.5144	.5525
22	.5144	.5335	.4572	.5716	.5144	.4763	.5335
23	.4572	.4954	.4382	.5716	.4191	.4572	.4954
24	.4763	.4382	.4572	.4001	.5716	.4763	.5144
Max	1.0479	1.086	1.086	1.2955	6.973	1.7147	1.6194
Min	.4382	.4382	.4191	.4001	.4191	.4572	.4763
Avg	.6714	.6315	.6602	.6692	.9760	.6790	.6732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 203 / 11 KV CHOWKA Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1334	.1524	.1143	.1143	.0953	.0953
2	.1905	.1334	.1524	.1143	.1143	.0953	.0953
3	.2477	.1334	.1905	.1143	.1334	.1143	.0953
4	.2858	.1524	.2286	.1334	.1334	.1143	.1143
5	.3239	.1905	.2477	.1334	.1524	.1334	.1334
6	.3239	.381	.2858	.2667	.1715	.1334	.1524
7	.6478	.5716	.5716	.6478	.2286	.1905	.1715
8	.5335	.6097	.4954	.6097	.1905	.1334	.1715
9	.4763	.4954	.362	.5335	.1715	.0953	.1334
10	.2286	.1715	.1715	.2286	.362	.3048	.381
11	.1905	.1334	.0762	.1905	.4572	.381	.4191
12		.1143	.0381	.1524	.5335	.3429	.4191
13		.1143	.0762	.1334	.4763	.3048	.381
14	.0953	.0953	.1143		.4382	.2858	.3048
15	.0953	.0953	.0762		.362	.2477	.2858
16	.0953	.1334	.0762		.3429	.2858	.2858
17	.0953	.1334	.1143		.362	.362	.381
18	.1143	.1143	.1334		.1524	.1334	.1715
19	.1334	.1715	.1905	.1715	.1715	.1524	.1334
20	.1524	.1334	.1143	.1905	.1524	.1524	.1143
21	.1905	.1143	.0953	.1715	.1334	.1143	.0953
22	.1715	.1143	.0762	.1524	.1143	.0953	.0953
23	.1334	.0953	.0762	.1334	.0953	.0953	.0953
24	.1905	.1334	.1715	.1143	.1143	.0953	.0953
Max	.6478	.6097	.5716	.6478	.5335	.381	.4191
Min	.0953	.0953	.0381	.1143	.0953	.0953	.0953
Avg	.2321	.1945	.1786	.2266	.2366	.1858	.2009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 204 / Lingdari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.1143	.0762	.0953
2	.0762	.0762	.0762	.0762	.1143	.0762	.0953
3	.0953	.0762	.1143	.0953	.1143	.0762	.0953
4	.1334	.0762	.1524	.0953	.1334	.0953	.1143
5	.1524	.0762	.1905	.1143	.1334	.0953	.1143
6	.1905	.1334	.2096	.1143	.1334	.0953	.1143
7	.2286	.2286	.2286	.2096	.1905	.1334	.2477
8	.2286	.1524	.2096	.2286	.1905	.0953	.1905
9	.1715	.1715	.1524	.1905	.1715	.1524	.1524
10	.1524	.0953	.1524	.1715	.1334	.0762	.0953
11	.1524	.0953	.1715	.1524	.1143	.0953	.0953
12	.1524	.0953	.1715	.1334	.0953		.0953
13	.1334	.0953	.1905	.0953	.1143		.0953
14	.1334	.0953	.1715		.0953		
15	.1334		.1334		.0953	.1334	.0953
16	.1334		.2477		.0953	.0953	.0953
17	.1334	.1715	.0762		.0953	.0953	.0953
18	.1524	.1524	.0762		.1143	.1334	.1334
19	.1334	.1524	.1524	.1715	.1334	.1143	.1715
20	.1143	.1715	.0572	.1715	.1334	.1715	.1524
21	.0953	.1524	.1143	.1524	.1524	.1334	.1334
22	.0953	.1143	.0953	.1334	.1143	.1143	.1143
23	.0762	.0953	.0762	.1143	.0953	.0953	.0953
24	.0953	.0762	.0762	.0762	.1143	.0762	.0953
Max	.2286	.2286	.2477	.2286	.1905	.1715	.2477
Min	.0762	.0762	.0572	.0762	.0953	.0762	.0953
Avg	.1350	.1195	.1405	.1354	.1246	.1062	.1210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 205 / Sawangi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9145	.9526	.9526	1.1431	.9526	.9526
2	1.0669	.9526	.9526	.9526	1.1431	.9526	.9526
3	1.1622	1.105	1.1812	1.086	1.2193	1.105	1.1812
4	1.3336	1.2955	1.3336	1.2574	1.4289	1.2955	1.3336
5	1.6956	1.3336	1.5813	1.4098	1.5432	1.5623	1.6385
6	1.9052	1.7147	1.829	1.7147	1.829	1.6766	1.8671
7	1.9624	1.9052	2.0576	2.0195	2.0576	1.8671	1.7718
8	1.9433	1.9433	1.6766	1.7718	1.9052	1.7147	1.8099
9	1.7147	1.7528	1.6194	1.7147	1.5242	1.6385	1.4861
10	1.1431	1.5432	1.1431	1.3717	1.1812	1.2384	1.1812
11	.8573	1.086	.8002	1.105	.9526	1.0098	.9526
12	.6859	.8573	.7049	.9907	.8383	.8383	.8573
13	.6097	.8192	.6478	.9145	.8002	.8573	.8002
14	.7049	.8002	.6668		.7621	.8383	.8002
15	.8383	.8002	.7811		.8002	.8192	.8192
16	.8573	.9526	.8002		.9145	.8573	.8192
17	1.1431	1.086	1.086		1.105	.9526	1.0479
18	1.3336	1.1812	1.2955		1.3717	1.4098	1.467
19	1.829	1.6956	1.7909	2.0957	1.7147	1.7528	1.8099
20	1.4861	1.6194	1.6194	1.8099	1.5242	1.6194	1.6956
21	1.2955	1.448	1.2765	1.5432	1.3336	1.4861	1.4289
22	.9526	1.3336	1.1431	1.3336	1.2955	1.1812	1.2384
23	.9145	1.1431	1.0098	1.2384	1.1431	1.0669	1.1431
24	1.0669	.9145	1.0288	.9526	1.1431	.9907	.9907
Max	1.9624	1.9433	2.0576	2.0957	2.0576	1.8671	1.8671
Min	.6097	.8002	.6478	.9145	.7621	.8192	.8002
Avg	1.2312	1.2582	1.2074	1.3808	1.2781	1.2368	1.2519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 206 / 11 KV Tuljapur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.2667	.3429	.2858	.2096	.2286
2	.2858	.2667	.2667	.3429	2.9531	.2096	.2286
3	.2858	.2858	.2858	.362	.2858	.2286	.2477
4	.3048	.2858	.3239	.381	.2858	.2286	.2858
5	.3239	.3048	.381	.4001	.2858	.2477	.3048
6	.3429	.3429	.4191	.4001	.2858	.3048	.4001
7	.3429	.4572	.4382	.4191	.2858	.3429	.381
8	.2667	.4382	.4001	.4191	.2858	.3048	.4382
9	.7811	.6097	.724	.4382	.6478	.5716	1.086
10	.8573	.0381	1.0479	.362	1.2384	.8573	1.4098
11	1.0098	.0381	1.3908	.362	1.2955	1.086	1.7528
12		1.1431	1.2384	.3048	1.2193	1.2955	1.6194
13		1.4289	1.2003	.3048	.9907	1.2003	1.3336
14	1.2384	1.0479	.8002		.5335	.9526	1.2384
15	1.4861	.4763	1.0288		1.3336	.9907	1.3146
16	1.5623	.8764	1.0288		1.4098	1.5432	1.3336
17	1.2193	1.0669	1.2955		1.3717	1.0669	1.1431
18	1.1812	.8764			1.3336	.9526	1.0479
19	.5716	.5144	.5144	.381	.5716	.4572	.4954
20	.5144	.3239	.4191	.2858	.5335	.3429	.4954
21	.4382	.2858	.4191	.2858	.4382	.381	.4763
22	.362	.2858	.4001	.2858	.3429	.4191	.4382
23	.3048	.2667	.4001	.2858	.3048	.381	.3429
24	.2858	.2858	.2858	.4001	.2858	.2858	.3048
Max	1.5623	1.4289	1.3908	.4382	2.9531	1.5432	1.7528
Min	.2667	.0381	.2667	.2858	.2858	.2096	.2286
Avg	.6486	.5088	.6511	.3560	.7835	.6192	.7645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 207 / 11 KV Unique Stone crusher SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0381	.0381	.0381	.0191	.0381
2		.0191	.0381	.0381	.0381	.0191	.0381
3		.0191	.0381	.0381	.0381	.0191	.0381
4		.0191	.0381	.0381	.0381	.0191	.0381
5		.0191	.0381	.0381	.0381	.0191	.0381
6		.0191	.0381	.0381	.0381	.0191	.0381
7		.0381	.0572	.0381	.0381	.0381	.0381
8		.0191	.0381	.0381	.0381	.0191	.0381
9		.0381	.1524	.0191	.0191	.0381	.1143
10		.1715	.1524	.0191	.0191	.0762	.1715
11		.1524	.0572	.0191	.0191	.0381	.1905
12		.1524	.0953	.0191	.0381	.0381	.1334
13		.1524	.1143	.0191	.1143	.0381	.0762
14		.1524	.1334		.0572	.0381	.1143
15		.0572	.0572		.0381	.0381	.1524
16	.0381	.1524	.0572		.0381	.0381	.1715
17	.1334	.0762	.0572		.0381	.0762	.2286
18	.0762	.0953	.0762		.0191	.1143	.2096
19	.0381	.0572	.0572	.0381	.0191	.0572	.1905
20	.0191	.0381	.0572	.0381	.0191	.0572	.0953
21	.0191	.0381	.0572	.0381	.0191	.0381	.0572
22	.0191	.0381	.0381	.0381	.0191	.0381	.0381
23	.0191	.0381	.0381		.0191	.0381	.0381
24		.0191	.0381	.0381	.0381	.0191	.0381
Max	.1334	.1715	.1524	.0381	.1143	.1143	.2286
Min	.0191	.0191	.0381	.0191	.0191	.0191	.0381
Avg	.0453	.0667	.0651	.0328	.0349	.0397	.0969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 201 / 11KV GROWTH CENTRE I

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9907	.7316	.6401	.8573	.9907	.9328
2	.9907	.9907	.695	.6249	.8573	.9526	1.0059
3	.9526	.9526	.6584	.6097	.9145	.9526	.9511
4	.9526	1.0479	.7499	.6401	.9526	.9907	.8962
5	1.0288	1.105	.8413	.6859	1.0479	1.0288	.9877
6	1.0669		.9328	.7164	1.0669	1.0669	1.0608
7	1.2003	1.1622	1.0242	.9602	1.086	1.1431	1.1157
8	1.0669	1.2574	1.0242	.9907	1.105	1.0669	1.0242
9	1.0098	1.2193	.823	.9907	.8954	.8573	.8413
10	.7049	.823	.5487	.8764	.7621	.6584	.6668
11	.6478	.6401	.503	.6859	.6859	.567	.6668
12	.6097	.7316	.4725	.6287	.6097	.6219	.6668
13	.5906	.6036	.4973	.6097	.6097	.6036	.6478
14	.5716	.4755	.4458	.5906	.6287	.5853	.6668
15	.5906	.4755	.4287	.5716	.6478	.6219	.6859
16	.5525	.4572	.4287	.6097	.6478	.6219	.724
17	.6097	.567	.5487	.6668	.6859	.6401	.7621
18	.6859	.6219	.6097	.6859	.7621	.6584	
19	.8954	.8596	.7011	.8764	1.0288	.823	1.2003
20	.9717	.8596	.7621	.9526	1.0669	1.0425	1.1431
21	1.0288	.8413	.8745	1.0098	.9907	1.0242	1.0669
22	1.0098	.7682	.7621	1.0288	1.1431	1.0242	1.0669
23	1.0669	.7316	.7011	.9717	1.0669	1.0425	1.0669
24	1.0098	1.0288	.7316	.6859	.9145	.9907	.9694
Max	1.2003	1.2574	1.0242	1.0288	1.1431	1.1431	1.2003
Min	.5525	.4572	.4287	.5716	.6097	.567	.6478
Avg	.8669	.8352	.6873	.7629	.8764	.8573	.9051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 202 / 11KV A.S.CLUB FEEDER Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.128	.0343	.0381	.0572	.0732
2	.0572	.0572	.0914	.0686	.0381	.0572	.0732
3	.0572	.1143	.0732	.1029	.0762	.0762	.1097
4	.0762	.1715	.0732	.1372	.1334	.0762	.1097
5	.1143	.2858	.128	.1372	.1715	.1905	.1646
6	.1524	.4191	.2195	.12	.2096	.2667	.2743
7	.1524	.4572	.3658	.2572	.3048	.3429	.5853
8	.1334	.362	.1829	.3601	.381	.6097	.5487
9	.1524	.2286	.0914	.0686	.3429	.5906	.5487
10	.2858	.0914		.1143	.1524	.0914	.2096
11	.4191	.0732	.1029	.0953	.1143	.0914	.1524
12	.3239	.0732	.1372	.0953	.1143	.0732	.1715
13	.362	.0549	.1543	.0572	.1334	.0914	.1334
14	.381	.0366	.1715	.0381	.1715	.0914	
15	.1905	.0549	.2229	.0762	.1143	.0914	.1143
16	.1905	.0732	.2915	.0953	.1524	.0914	.1143
17	.1715	.0732	.1715	.0762	.1334	.0732	.1524
18	.0953	.0549	.1715	.0381	.1524	.0549	.1715
19	.1334	.128	.1715	.0953		.128	.1524
20	.1334	.128	.1372	.1143	.1334	.1463	.1143
21	.1143	.0914	.0857	.1143	.1143	.0914	.0762
22	.1143	.0914	.0857	.0953	.0762	.0914	.0572
23	.0953	.0914	.0686	.0381	.0572	.128	.0572
24	.0762	.0572	.1463	.0343	.0381	.0572	.0732
Max	.4191	.4572	.3658	.3601	.381	.6097	.5853
Min	.0572	.0366	.0686	.0343	.0381	.0549	.0572
Avg	.1683	.1386	.1509	.1027	.1458	.1525	.1842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 203 / 11KV P.M.CHORDIA FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1715	.0183	.0686	.0572	.0572	.0732
2	.0381	.1524	.0183	.0514	.0381	.0381	.0732
3	.0381	.0762	.0183	.0514	.0381	.0381	.0732
4	.0381	.0572	.0183	.0686	.0191	.0381	.0732
5	.0381	.0381	.0183	.0514	.0191	.0381	.0732
6	.0381	.0381	.0183	.0343	.0191	.0381	.0732
7	.0381	.0191	.0183	.0514	.0191	.0381	.0732
8	.0762	.0762	.0183	.0686	.0191	.0191	.0914
9	.0762	.1334	.2926	.1543	.0572	.0191	.0732
10	.2096	.0914	.2915	.4001	.0572	.1097	.381
11	.3429	.0732	.2743	.3048	.0762	.128	.3429
12	.3048	.1097	.1886	.1524	.0762	.3841	.381
13	.2096	.0732	.1715	.1905	.1524	.1463	.4001
14	.1334	.0754	.1715	.0953	.2096	.3109	.381
15	.3048	.128	.2229	.0191	.2667	.2561	.3429
16	.1905	.128	.2915	.3429	.1524	.4024	.3429
17	.2286	.0183	.3258	.1334	.1905	.2195	.2858
18	.1143	.128	.1715	.2286	.2667	.3292	.3239
19	.0381	.0183	.0857	.0953	.1524	.3292	.0381
20	.1143	.0183	.0171	.0762	.2286	.0914	.0381
21	.1715	.0366	.0171	.0572	.1524	.0914	.0762
22	.2477	.0183	.0343	.0572	.1905	.0732	.0953
23	.1905	.0183	.0514	.0762	.0572	.0732	.1524
24	.0572	.1905	.0183	.0514	.0572	.1143	
Max	.3429	.1905	.3258	.4001	.2667	.4024	.4001
Min	.0381	.0183	.0171	.0191	.0191	.0191	.0381
Avg	.1373	.0787	.1155	.1200	.1072	.1410	.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 204 / 11KV Growth Center II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3292	.2743	.3048	.362	.3658
2	.3429	.3429	.3292	.2915	.3048	.362	.3658
3	.3429	.3239	.3475	.2572	.3429	.3429	.3658
4	.362	.362	.3475	.2572	.362	.362	.3658
5	.381	.381	.3658	.2915	.381	.381	.3658
6	.381	.381	.3658	.2915	.4001	.381	.3841
7	.4001	.4001	.3841	.3086	.381	.381	.4024
8	.362	.4001	.3658	.3258	.4001	.381	.3658
9	.3239	.3239	.3109	.3086	.381	.3048	.2743
10	.362	.3292	.3086	.3048	.3429	.2378	.2286
11	.381	.2743	.2572	.2477	.2667	.3109	.2667
12	.3429	.3109	.2401	.2477	.2286	.2926	.2667
13	.2858	.2743	.2401	.2667	.2286	.2926	.2667
14	.2477	.2378	.2401	.2667	.2477	.2561	.2858
15	.2858	.2561	.2229	.2667	.2477	.2926	.3048
16	.2477	.2378	.2058	.2477	.2667	.2926	.3048
17	.2858	.2012	.2401	.2858	.2858	.2561	.3048
18	.2667	.2743	.3086	.2858	.3429	.2743	.2858
19	.3239	.3475	.3429	.4001	.381	.3658	.4001
20	.381	.3658	.3258	.4191	.4572	.439	.4001
21	.4001	.3658	.3258	.4382	.4572	.4024	.4001
22	.4001	.3658	.3086	.381	.4382	.439	.4572
23	.381	.3292	.2915	.3429	.4382	.3841	.4191
24	.362	.362	.3292	.2743	.3239	.362	.3841
Max	.4001	.4001	.3841	.4382	.4572	.439	.4572
Min	.2477	.2012	.2058	.2477	.2286	.2378	.2286
Avg	.3413	.3246	.3055	.3034	.3421	.3398	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 205 / 11KV Sara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9243	1.8671	1.6278	1.3565	1.9052	1.9433	1.7375
2	1.9814	1.829	1.7193	1.3108	1.8671	1.9433	1.6644
3	2.1338	1.9052	1.829	1.2498	2.191	2.0005	1.7741
4	2.4768	2.3053	2.1399	1.3717	2.5149	2.21	2.0119
5	2.7625	2.6673	2.4508	1.6461	3.1436	2.5911	2.4508
6	3.1436	3.1436	2.6886	2.0729	3.3913	2.934	2.7801
7	3.4675	3.2388	3.091	2.271	3.4865	3.3532	3.1093
8	3.0483	3.0674	2.5972	2.6978	2.8197	2.8578	2.4691
9	2.3815		2.2131		2.3243	2.2291	2.0485
10	1.848	1.9387	1.5089		2.0957	2.0119	1.8861
11	1.6194	1.5729	1.4327	1.829	1.829	1.8473	1.6956
12	1.4289	1.2803	1.4022	2.4958	1.4861	1.6095	1.4861
13	1.448	1.3535	1.387	2.21	1.4861		1.5242
14	1.4098		1.387	1.9243	1.5242	1.8107	1.6004
15	1.5051		1.5089	1.829		1.7193	1.6385
16	1.5242		1.2955	1.9052		1.6278	1.7147
17	1.6004		1.4632	1.9433	1.829	1.7193	1.7147
18	2.0576		1.5699	2.1338	2.2862	1.8839	2.0005
19	2.4768		2.0729	2.7054	2.9531	2.2314	2.4387
20	2.6292	2.6703	1.8442	2.572	2.9912	2.524	2.5911
21	2.4577	2.4143	1.8138	2.4577	2.7625	2.2497	2.5149
22	2.2291	2.1033	1.5394	2.3815	2.4768	2.1399	2.3815
23	2.0005	1.8107	1.4784	2.0957	2.1148	1.9936	2.0957
24	1.9243	1.9052	1.6644	1.387	1.9814	1.9624	1.8107
Max	3.4675	3.2388	3.091	2.7054	3.4865	3.3532	3.1093
Min	1.4098	1.2803	1.2955	1.2498	1.4861	1.6095	1.4861
Avg	2.1449	2.1808	1.8219	1.9930	2.3391	2.1475	2.0475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 206 / 11KV South City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4191	.3658	.3258	.4191	.4382	.3841
2	.4572	.4191	.4024	.3086	.381	.4382	.4572
3	.4572	.381	.3841	.3086	.4763	.4572	.4938
4	.4954	.4763	.439	.3429	.5144	.4954	.5304
5	.5335	.5335	.4938	.3601	.5906	.4954	.567
6	.5335	.5716	.5304	.3601	.6287	.6097	.6219
7	.6859	.6287	.6036	.4801	.6287	.6859	.6584
8	.6478	.5716	.5853	.4725	.5716	.6478	.567
9		.5906	.5487	.4725	.5335	.5335	.4755
10	.4954	.4755	.463	.5335	.5335	.4024	.5144
11	.5335	.4572	.4287	.4954	.4954	.4024	.4763
12	.4763	.4207	.3429	.4954	.4954	.4755	.4954
13	.4572	.3658	.3601	.5144	.4954	.4024	.4572
14	.4572	.3292	.3772	.5144	.4001	.4207	.4763
15	.4954	.4024	.3601	.4763	.381		.4954
16	.4191	.3841	.3429	.4382	.4572	.4572	.4954
17	.4954	.4572	.4115	.4382	.4954	.439	.5716
18	.5144	.4755	.4572	.4572	.4954	.4207	.5525
19	.6097	.4938	.4877	.5525	.6097	.6036	.6097
20	.6478	.5304	.4725	.5716	.6097	.5487	.5906
21	.6097	.4572	.4268	.5335	.6478	.5487	.5906
22	.4954	.4207	.3944	.5144	.5335	.4755	.5335
23	.4572	.3841	.3772	.4572	.5144	.4755	.5144
24	.4954	.4382	.3841	.3429	.4382	.4763	.439
Max	.6859	.6287	.6036	.5716	.6478	.6859	.6584
Min	.4191	.3292	.3429	.3086	.381	.4024	.3841
Avg	.5194	.4618	.4350	.4486	.5144	.4935	.5237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 209 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.1431	.7316	.9297	1.0098	1.2955	1.0059
2	.9526	1.1431	.6767	.9145	.9526	1.2955	1.0791
3	1.0288	1.105	.7133	.884	.9145	1.2193	.9328
4	1.0288	1.0288	.7316	.8535	.9526	1.2193	.8779
5	1.0288	1.0288	.7682	.8535	1.0098	1.1812	.8413
6	1.0669	.9717	.8048	.823	1.0669	1.1812	.9694
7	1.2193	.9907	.823	1.0212	1.0288	1.2384	1.0425
8	1.3146	.8573	1.1157	1.0669	1.4861	1.2765	1.262
9	2.0576	.8383	2.0485	.7773	1.848	2.0767	1.9936
10	2.2291	.823	1.7985	2.0767	1.9433	2.3411	2.0957
11	2.5149	.7865	1.6766	2.1719	1.9814	2.396	2.3624
12	2.0767	.7682	1.6613	1.9433	2.0005	2.3045	2.0576
13	1.9052	.7316	1.6461	1.7718	2.2481	1.9753	2.21
14	2.2291	.7133	1.6461	2.21	2.3815	2.268	2.2862
15	2.21	.7133	1.6461	2.0005	2.2862	2.0668	1.9433
16	2.0957	.695	1.6613	1.9052	2.1338	2.3411	2.2481
17	2.0005	.7133	1.5546	1.5242	2.2481	2.0485	2.4006
18	1.7147	.7499	1.4327	1.3717	2.0767	2.0302	2.4768
19	1.3717	.7865	1.2193	1.2765	1.2003	.9511	1.8671
20	1.2955	.7316	1.0364	1.1241	1.2384	1.3535	1.4098
21	1.1812	.7499	.8535	.9145	1.3336	1.0425	1.105
22	1.0669	.7682	.884	1.0098	.9907	1.1706	1.3146
23	1.1622	.7682	.884	1.0669	1.0479	1.0425	1.2193
24	.9907	1.1812	.7682	.8993	1.0479	1.2765	1.0791
Max	2.5149	1.1812	2.0485	2.21	2.3815	2.396	2.4768
Min	.9526	.695	.6767	.7773	.9145	.9511	.8413
Avg	1.5289	.8661	1.1993	1.3079	1.5178	1.6080	1.5867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 201 / 11 KV Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.362	.3189	.3224	.3403	.3544	.3366
2	.3258	.3439	.3189	.3012	.3224	.3544	.3189
3	.3391	.3761	.3366	.3544	.3012	.3721	.3189
4	.373	.4119	.3721	.3856	.3189	.4031	.3544
5	.4024	.443	.4207	.4382	.3506	.4382	.4207
6	.4359	.5316	.5609	.5028	.5258	.5083	.4733
7	.5801	.5847	.5784	.6068	.7455	.4908	.5609
8	.5138	.583	.5784	.8059	.7108	.4733	.5258
9	.5197	.567	.5083	.7362	.7011	.4557	.7108
10	.6516	.7282	.6762	.6859	.6935	.6415	.6687
11	.5083	.6415	.6516	.5144	.6762	.6762	.5548
12	.4252	.3814	.6516	.39	.3681	.4334	.4382
13	.3721	.333	.6203	.373	.4031	.4207	.4287
14	.394	.2947	.6299	.3688	.4334	.4207	.4287
15	.4119	.3294	.503	.3353	.4508	.4508	.5144
16	.4119	.3856	.4287	.3222	.3988	.4161	.6203
17	.4119	.3681	.4161	.3601	.3988	.3772	.3353
18	.4835	.4207	.4656	.3814	.443	.4557	.4334
19	.7522	.7011	.5083	.5721	.7186	.7011	.7362
20	.6805	.6836	.4681	.7011	.7712	.7186	.6805
21	.4835	.631	.4382	.5609		.4557	.6268
22	.4298	.4207	.3898	.4607	.4557	.4252	.4163
23	.3982	.333	.3582	.4075	.3898	.3898	.4024
24	.3429	.362	.3366	.3189	.3582	.3721	.3544
Max	.7522	.7282	.6762	.8059	.7712	.7186	.7362
Min	.3258	.2947	.3189	.3012	.3012	.3544	.3189
Avg	.4572	.4674	.4806	.4669	.4903	.4669	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 202 / 11 KV Patoda Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.3258	.2507	.2241	.2686	.2328	.2686
2	.9088	.3403	.2507	.2452	.2507	.2149	.2686
3	.9156	.3439	.2865	.2641	.2658	.2149	.2865
4	.9326	.3761	.3224	.2801	.2835	.2507	.2865
5	.9389	.4252	.3544	.3174	.3155	.3012	.3366
6	.9724	.4075	.443	.4108	.3506	.3544	.4075
7	.9945	.4607	.4607	.5041	.4161	.3898	.443
8	1.1437	.463	.443	.5041	.3814	.3898	.3898
9	1.1233	.443	.3898	.4108	.333	.3544	.3506
10	.2743	1.0974	1.2517	1.3032	1.166	1.046	1.0513
11	.3155	1.2346	1.3032	1.3032	1.3203	1.0802	1.0402
12	.3012	1.2689	1.3375	1.3056	1.3176	1.0974	1.0288
13	.3189	1.2483	1.291	1.2887	1.3003	1.0749	1.0802
14	.3045	1.2003	1.2431	1.2574	1.2174	1.0749	1.1145
15	.2865	1.2174	1.2071	1.2071	1.1831	1.0117	1.0631
16	.3045	1.2656	1.2174	1.1869	1.1488	1.0288	1.0227
17	.3224	1.2136	1.1789	1.166	1.1145	1.0004	1.0059
18	.3403	.2481	.3174	.3121	.2149	.2303	.3361
19	.3761	.3544	.3734	.3467	.3544	.3189	.3734
20	.3582	.3366	.3361	.3681		.3544	.4668
21	.3403	.3012	.2801	.333		.3189	.3734
22	.3403	.2835	.2801	.3189	.2481	.2865	.3018
23	.3258	.2658	.2452	.3012	.2328	.2865	.2641
24	.9088	.3258	.2507	.2054	.2686	.2328	.2686
Max	1.1437	1.2689	1.3375	1.3056	1.3203	1.0974	1.1145
Min	.2743	.2481	.2452	.2054	.2149	.2149	.2641
Avg	.5933	.6436	.6381	.6402	.6342	.5477	.5762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 203 / WALDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173						
2	.6516						
3	.6783						
4	.7122						
5	.7377						
6	.8048						
7	.8951						
8	.8951						
9	.8383						
10		.7202	1.0631	1.046	.9602	.8916	
11		.8916	1.2346	1.2346		.9945	1.0749
12		.9259	1.2346	1.2887	1.0749	.9945	1.1145
13		.9709	1.2239	1.2548	.9015	.8322	1.0631
14		.9602	1.1934	1.2071	.823	.7628	1.0288
15		1.0631	1.1736	1.1065	.9259	.7888	1.0631
16		1.1789	1.166	.9496	.8573	.8573	1.0562
17		.9362	1.0923	1.1317	.8916	.5087	.9556
24	.5487						
Max	.8951	1.1789	1.2346	1.2887	1.0749	.9945	1.1145
Min	.5487	.7202	1.0631	.9496	.823	.5087	.9556
Avg	.7379	.9559	1.1727	1.1524	.9192	.8288	1.0509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 201 / Adgaon(Sarak)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2458	.2622	.2949	.1802	.1475	.1638
2	.2622	.2458	.2622	.2949	.1802	.1475	.1638
3	.2622	.2458	.3277	.3277	.1802	.1638	.1802
4	.3277	.3277	.426	.3605	.1966	.1638	.1802
5	.5243	.5735	.5079	.3932	.1966	.1638	.1802
6	.7373	.8192	.5898	.7209	.2294	.1802	.1966
7	1.2616	1.1797		1.2944	.1966	.1802	.1966
8	1.2146	.9831	.9995	1.1305	.1638	.1311	.1638
9	.7209	.7045	.3605	.7701	.1311	.1147	.1638
10	.1147	.1311	.1147	.1475	.7373	.6554	.8192
11	.0983		.0983	.1147	.8192	.6554	.7537
12	.0819	.0983	.0983	.0819	.7701	.6554	.6718
13	.0819	.0819	.0983	.0819	.6062	.4915	
14	.0819	.0819	.0983	.0819	.6226	.4915	
15	.0819	.0819	.0983	.0819	.639		
16	.0655	.0983	.0983		.6718	.3768	
17	.0655	.0983	.0819		.6062	.6882	1.0159
18	.0983	.1147	.0983		.0983	.1147	.1311
19	.1147	.1638	.1311	.1802	.1638	.1475	.1147
20	.1638	.1638	.1802	.1802	.1802	.1638	.1311
21	.1802	.1638	.1638	.1802	.1638	.1638	.1638
22	.1638	.1475	.1638	.1802	.1638	.1638	.1638
23		.1311	.1475	.1638	.1638	.1638	.2294
24	.2622	.2294	.2294	.2949	.1638	.1475	.1638
Max	1.2616	1.1797	.9995	1.2944	.8192	.6882	1.0159
Min	.0655	.0819	.0819	.0819	.0983	.1147	.1147
Avg	.3142	.3092	.2451	.3503	.3427	.2814	.2974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 202 / Mandki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.0819	.1006	.0983	.2458	.2486	.2469
2	.128	.0819	.1006	.0983	.2458	.2486	.2469
3	.128	.0819	.1006	.0983	.2458	.2818	.2812
4	.128	.0819	.1341	.0983	.3277	.2984	.3281
5	.1463	.0983	.1509	.0983	.4096	.3149	.3749
6	.1829	.1147	.1865	.128	.5407	.421	.5851
7	.1991	.0983	.1509	.1463	.9667	1.1174	1.186
8	.1463	.0983	.1677	.1463	.9831	1.0526	1.1305
9	.0819	.1372	.1174	.1463	.6371	.8124	.9717
10	.7373	.547	.6154	.5571	.0514	.0762	.0819
11	.852	.639	.6882	.8192	.0671	.0572	.0655
12	.8192	.6478	.7373	.5898	.0829	.0572	.0492
13	.7373	.583	.7865	.7373	.1174	.0572	
14	.6226	.5182	.8356	.7373	.1174		
15	.5243	.5344	.6718	.7373	.1174		
16	.4424	.5668	.6554		.0838	.0572	
17	.3768	.6154	.6554		.0838	.0381	.0492
18	.0983	.1357	.0983		.1174	.0572	.0492
19	.0983	.1715	.0983	.1267	.1174	.0953	.0492
20	.1311	.1543	.0983	.1448	.1341	.0953	.0983
21	.1147	.1509	.0983	.1463	.1509	.0953	.0819
22	.0983	.1509	.0983	.1448	.1509	.0953	.0819
23		.1844	.0983	.1267	.1174	.0953	.1147
24	.1463	.0819	.1174	.0983	.2785	.2486	.2469
Max	.852	.6478	.8356	.8192	.9831	1.1174	1.186
Min	.0819	.0819	.0983	.0983	.0514	.0381	.0492
Avg	.3073	.2732	.3151	.2869	.2663	.2691	.3160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 203 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.7499	.6173	.695	.7499	.7202	.7316
2	.6767	.7316	.6173	.695	.7499	.7202	.7316
3	.6767	.7316	.6935	.7682	.7499	.8402	.8131
4	.7133	.8779	.7975	.8779	.9145	.9114	.924
5	.9145	.9145	1.0029	.9511	1.0974	1.0745	1.0269
6	1.0974	1.2071	1.3769	1.39	1.2803	1.4523	1.3769
7	1.2851	1.2254	1.4335	1.4998	1.2803	1.4901	1.1883
8	1.1706		1.3256	1.2986	1.2071	1.2197	1.0829
9	.9877	1.1765	.9955	1.0791	.964	.9979	.7865
10	.7682	.8939	.703	.9145	.6859	.7762	.7316
11	.567	.6516	.6401	.823	.583	.6468	.6767
12	.5487	.6001		.6767	.5487	.6036	.567
13	.5121	.5487	.5121	.5121	.5658	.5487	
14	.5121	.5316	.5121	.5121	.5658	.567	
15	.5304	.5487	.5487	.5121	.5487		
16	.5304	.583	.5487		.5487	.7207	
17	.5487	.6859	.6036		.703	.7762	.8413
18	.823	.8149	.7316		.7888	.9335	.9877
19	.9694	1.1584	1.0059	1.262	1.2254	1.2071	1.0974
20	.9145	1.0924	1.0974	1.134	1.1706	1.2449	1.1523
21	.9145	.9114	.9328	.9511	.964	.9709	1.0242
22	.8779	.7888	.823	.8779	.9465	.9896	.9328
23		.6687	.7316	.823	.7975	.8413	.8413
24	.7133	.7499	.6344	.695	.7682	.7545	.7682
Max	1.2851	1.2254	1.4335	1.4998	1.2803	1.4901	1.3769
Min	.5121	.5316	.5121	.5121	.5487	.5487	.567
Avg	.7795	.8192	.8211	.9023	.8502	.9134	.9141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 204 / 11 KV Jatwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3887	.3887	.3887	.5344	.502	.4858
2	.3932	.3932	.3887	.3887	.5344	.502	.4858
3	.3887	.3887	.4858	.3887	.5344	.5344	.502
4	.4858	.4424	.5344	.4372	.5344	.5344	.5182
5	.6316		.6316	.4372	.583	.5506	.5506
6	.9717		.6802	.6316	.6316	.6316	.6478
7	1.2289	.4858	1.3927		.6802	.7449	.7773
8	1.2146	1.166	1.5061	.4096	.6316	.7287	.7449
9	.8259	1.004	1.0202	.4372	.6802	.6478	.6316
10	.583	.502	.583	.1943	.4372	.5992	.7773
11	.5344	.502		.1475	.4372	.4049	.8259
12	.5344	.502		.0983	1.3279	.8097	.9717
13	.5344	.502	.5344	.0972	1.3441	.8421	.8259
14	.5344	.502	.4858	.0983	1.3441	.7935	.7287
15	.4858	.5344	.4534	.4858	1.3603	.8259	.7773
16	.4858	.5668	.4858		1.3765	.8745	.8259
17	.4858	.5506	.5344		1.0688	.8583	.6802
18	.583	.6316	.5344		.5506	.5182	.583
19	.6316	.6802	.6802	.6802	.6478	.583	.6802
20	.6802	.6316	.6316	.6316	.5992	.6154	.6316
21	.583	.583	.583	.5898	.5344	.5668	.583
22	.5344	.502	.5344	.583	.4858	.5182	.5344
23		.502	.5344	.5407	.502	.5182	.4858
24	.3887	.3887	.4049	.3887	.5407	.502	.502
Max	1.2289	1.166	1.5061	.6802	1.3765	.8745	.9717
Min	.3887	.3887	.3887	.0972	.4372	.4049	.4858
Avg	.6134	.5614	.6367	.4027	.7459	.6336	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 201 / 11 Kv Sajapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8764	.4108	.6859	.6097	.3734	.4458
2	.8059	.9335	.4294	.6687	.5716	.3734	.4115
3	.7716	.9145	.4108	.6859	.6478	.3361	.4287
4	.823	.9717	.4481	.703	.5716	.3547	.4115
5	.8573	.8002	.4668	.703	.5906	.3734	.3944
6	.9602	.8383	.5041	.7716	.5716	.3921	.4287
7	.5487	.9145	.5228	.8059	.5716	.5228	.5316
8	.5144	.9907	.7655	.7545	.5525	.5487	.503
9	.583	.9149	.4854	.9717	.4108	.4294	.4268
10	.4954	.3734	.3048	.9335	.7655	.7716	.6859
11	.381	.3361	.3353	.7621	.7655	.6859	.6859
12	.4001	.3174	.381	.4191	.7468		.6516
13	.4191	.3361	.3048	.3429	.7468		.6859
14	.4191	.3174	.2743	.3429	.5601	.703	.6344
15	.4001		.3506	.3048	.4108	.6859	.6173
16	.381	.8215	.1677	.4001	.2054	.6859	.6173
17	.3429	.3174	.2743	.4191	.7655	.6859	.6687
18	.724	.8962	.583	.8573	.8589	.823	.6859
19	.8764	.5975	.3772	.9145	.9896	.8745	.8573
20	.9717	.6161	.8916	.9717	.8775	.9431	.9088
21	.9907	.5601	.7888	1.0288	.8402	.9774	.9602
22	.9717	.5228	.8573	.9526	.7468	.9602	.9602
23	.9526	.4854	.823	.9145	.6099	.9431	.9088
24	.8916	.9145	.4481	.7716	.724	.4108	.5144
Max	.9907	.9907	.8916	1.0288	.9896	.9774	.9602
Min	.3429	.3174	.1677	.3048	.2054	.3361	.3944
Avg	.6808	.6768	.4836	.7119	.6546	.6297	.6260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 202 / 11kv Karodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.381	.7468	.3086	.3361	.2987	.2229
2	.3601	.3429	.6535	.3429	.3921	.3174	.2572
3	.3944	.381	.5788	.3772	.4108	.2801	.2229
4	.4458	.4191	.5601	.3944	.3881	.2987	.2229
5	.5144	.4572	.6535	.4801	.3734	.3174	.2401
6	.6344	.4191	.7468	.6001	.3361	.3361	.3258
7	.6001	.4763	.8029	.6859	.3174	.3944	.4458
8	.583	.4954	1.3252	1.3393	.3547	.5228	.463
9	.463	.4481	1.1462	.5716	.3361	.4481	.3506
10	.381	.2614	.2591	.4954	.3734	.4115	.3601
11	.2286	.3361	.2439	.4572	.3361	.3429	.6172
12	.2667	.2987	.2439	.381	.3174	.2743	.2572
13	.3048	.2801	.2439	.3048	.2987	.2572	.2743
14	.2667	.2614	.2286	.2858		.2572	.2572
15	.2286	.2427	.2286	.2667	.2241	.2572	.2572
16	.3239	.3734	.2286	.3429	.2427	.2572	.2915
17	.2096	.4108	.2286	.2858	.3921	.3601	.1715
18	.4954		.3258	.4191	.4481	.4458	.3601
19	.6097	.6535	.5487	.4572	.5975	.5144	.5144
20	.5335	.6161	.5144	.4382	.5601	.4801	.5316
21	.4382	.7095	.3944	.4763	.5228	.4287	.4287
22	.4191	.7655	.3429	.4191	.3921	.3944	.3772
23	.381	.8029	.3429	.381	.2614	.3772	.3601
24	.3429	.4001	.7468	.3258	.3921	.2801	.2058
Max	.6344	.8029	1.3252	1.3393	.5975	.5228	.6172
Min	.2096	.2427	.2286	.2667	.2241	.2572	.1715
Avg	.4077	.4449	.5140	.4515	.3741	.3563	.3340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 203 / 11 kv INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.743	.3361	.4458	.4001	.4668	.6097
2	.5144	.7621	.3174	.4287	.4382	.4481	.5792
3	.463	.8002	.2987	.4115	.3734	.4668	.6001
4	.4458	.7621	.2987	.4458	.3921	.4854	.5487
5	.463	.6097	.2987	.4287	.3361	.5041	.4877
6	.4458	.5335	.3361	.4115	.4481	.5175	.442
7	.4115	.4191	.3547	.4287	.5281	.5601	.4801
8	.6173	.381	.6535	.6001	.5601	.8029	.6344
9	1.046	.4108	.7655	.724	.9335		.8916
10	1.1812		.9431	.743	1.1016	.8535	.9431
11	1.3336	.2614	.9431	.7811		.884	1.2346
12	1.2193	.3734	.9088	.8002		.8993	.9431
13	.9526	.3734	.8745	.7621		.8535	.7888
14	1.2193	.3921	.8573	.8002		.7316	.9774
15	1.2955	.4481	1.0288	.8573		.7468	1.0631
16	1.3527	.3921	1.0802	.8764		.7621	1.0288
17	1.2765	.3734	1.0288	.8002		.8078	1.0288
18	1.2193	.3547	.9602	.9717		.8383	
19	1.2003	.4481	.8059	.7811		.8383	.8573
20	.7049	.6722	.7202	.724	.9335	.7773	.7716
21	.6859	.5601	.583	.5144	.8589	.6554	.583
22	.743	.5228	.6687	.5335	.6908	.6554	.6344
23	.7811	.4854	.5487	.4954	.5415	.6554	.5658
24	.5658	.7811	.3734	.4801	.4191	.5041	.6401
Max	1.3527	.8002	1.0802	.9717	1.1016	.8993	1.2346
Min	.4115	.2614	.2987	.4115	.3361	.4481	.442
Avg	.8756	.5156	.6660	.6352	.5970	.6832	.7536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 201 / 11 KV SUKHNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.1905	.1905	.1143	.0953	.1143
2	.2286	.1905	.1905	.1905	.1143	.0953	.1143
3	.2667	.1905	.1905	.1905	.1143	.1905	.1334
4	.2858	.2858	.2858	.2858	.1334	.1905	.1524
5	.381	.381	.381	.381	.1905	.2858	.2096
6	.4763	.4763	.4763	.5716	.2667	.381	.2667
7				.381	.381	.4763	.4191
8				.2858	.4001	.4763	.4572
9	.4763	.1905	.4763	.2286	.3239	.381	.381
10	.3048	.2858	.381	.381	.1905	.2667	.1905
11	.381	.2286	.2858	.362	.1905	.1905	.1905
12	.2286	.2477	.2858	.381	.1905	.1524	.1905
13	.381	.2667	.2286		.1905	.1334	.1905
14	.3048	.2858	.2286	.2858	.1905	.1524	.1905
15	.381	.2477	.2286	.2667	.1905	.1334	.1905
16	.381	.2477	.2858	.362	.1905	.1715	.1905
17	.381	.3048	.381	.3429	.1905	.1715	.1905
18	.2858	.381	.2286	.3048	.2858	.381	.0191
19	.381	.381	.381	.3429	.2858	.4191	.4763
20	.381	.2858	.381	.362	.381	.4001	.381
21	.2858	.2858	.2858	.2477	.2858	.3239	.2858
22	.2286	.2858	.2667	.2667	.2858	.2477	.2286
23	.1905	.1905	.2667	.2286	.1905	.2286	.2286
24	.2286	.1905	.1905	.1905	.1143	.0953	.1524
Max	.4763	.4763	.4763	.5716	.4001	.4763	.4763
Min	.1905	.1905	.1905	.1905	.1143	.0953	.0191
Avg	.3213	.2737	.2953	.3056	.2246	.2516	.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 202 / 11 KV KHODEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1905	.1905	.2858	.2858	.2858
2	.1715	.1524	.1905	.1905	.2858	.2858	.2858
3	.1905	.1905	.1905	.2286	.3429	.381	.381
4	.2096	.1905	.1905	.2858	.4001	.4763	.4191
5	.2667	.2286	.2858	.2858	.5525	.5716	.6097
6	.3048	.2858	.381	.2858	.6097	.5716	.5906
7	.3429	.381	.381				
8	.381	.4763	.381	.381			
9	.3048	.381	.2858	.381			
10	.381	.2858	.1905		.2858	.2667	.2858
11	.2858	.2477	.1905	.3429	.381	.2477	.2286
12	.2858	.2667	.1905	.2858	.381	.2286	.2286
13	.1905	.1905	.2286	.2096	.2858	.1905	.1905
14	.1905	.1905	.1905	.2477	.1905	.2096	.1905
15	.1905	.2286	.1905	.1143	.1905	.1715	.1905
16	.2286	.2286	.2858	.1524	.1905	.2477	.1905
17	.2858	.2858		.2286	.2858	.2286	.1905
18	.381	.381	.4763	.2667	.2858	.381	.381
19	.381	.4763	.5716	.5335	.381	.4572	.381
20	.381	.381	.4763	.381	.381	.381	.381
21	.381	.381	.381	.3429	.381	.3429	.381
22	.2858	.2858	.3048	.3239	.2858	.2858	.2858
23	.1524	.2858	.2858	.3048	.2858	.2667	.2858
24	.1715	.1524	.1905	.1905	.2858	.2858	.2858
Max	.381	.4763	.5716	.5335	.6097	.5716	.6097
Min	.1524	.1524	.1905	.1143	.1905	.1715	.1905
Avg	.2715	.2794	.2883	.2797	.3311	.3221	.3166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 203 / 11 KV MURADABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.5716	.5716	.5716	.5144	.4763	.5716
2	.7811	.5716	.6668	.5716	.5144		
3	.9145	.5716	.7621	.9526	.5716	.5716	.6097
4	1.0669	.9526	.9526	1.1431	.6097	.6668	.6287
5	1.1241	1.1431	1.2384		.724	.7621	.5906
6	1.2574	1.3336	1.1431	1.448	.8573	.9526	.8002
7				1.2384	1.1622	1.1431	1.3336
8		.1905		1.1431	1.105	1.1431	1.4098
9	.8764	.5716	.7621	1.1431	.8954	.9526	.4191
10	.8573	.6668	.8573	.7621	.5716	.6859	.381
11	.9526	.4191	.9526	1.0288	.381	.4954	.381
12	.7621	.8573	.8573	.8764	.2858	.381	.381
13	.5716		.7621	.8383	.2858	.4191	.381
14	.5716	.6478	.7621	.8573	.2858	.4191	.2858
15	.7621	.7621	.7621	.8002	.2858	.4382	.2858
16	.9526	.7621	.8573	1.0288	.381	.5144	.2858
17	.7621	.7811	.7621	.9526	.4763	.5525	.381
18	.7621	.9526		.5906	.5716	.6668	.5716
19	.9526	1.1431	1.1431	1.0098	.8573	1.086	1.1431
20	.9526	.9526	1.1431	1.0288	.9526	.9335	1.1431
21	.7621	.7621	.9526	.8764	.9526	.8573	.7621
22	.7621	.7621	.8002	.7811	.9526	.8002	.7621
23	.5716	.6668	.724	.724	.7621	.724	.7621
24	.7811	.5716	.5716	.5716	.5144	.5716	.5525
Max	1.2574	1.3336	1.2384	1.448	1.1622	1.1431	1.4098
Min	.5716	.1905	.5716	.5716	.2858	.381	.2858
Avg	.8426	.7552	.8573	.9104	.6446	.7049	.6444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 204 / 11 KV RAJAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.7621	.8573	.8573	1.4289	1.3336	1.4289
2	.3429	.8573	.8573	.8573	1.5242	1.3336	1.4289
3	.381	.8573	.9526	.8573	1.7147	1.7147	1.7147
4	.4001	1.0479	1.1431	1.1431	1.9433	2.0957	1.8671
5	.6097	1.5242	1.5242	1.1431	2.4006	2.6673	2.6673
6	.8192	2.2862	2.0957	2.0957	3.0864	1.1431	3.2007
7	1.0479	2.6673	2.9531	2.6673			
8	1.0288	2.9531	2.4768	2.8578			
9	.743	2.6673	2.0957	1.9052			
10	1.5242	2.0005	1.5242		1.5242	2.2862	1.9052
11	1.7147		1.3336	2.0576	2.572	2.2291	
12	1.2384	1.467	1.3336	1.6956	2.572	2.4006	1.9052
13	1.3336	1.1431	1.1431	1.448	2.2862	1.9814	1.7147
14	1.3336	1.105		1.3336			1.5242
15	1.3336	1.1431			2.0957	1.6004	1.5242
16	1.4289	.9145		1.7337	2.4768	1.7147	1.7147
17	1.7147	1.6194	1.7147	1.9624	2.7625	1.9433	1.3336
18	2.6673	2.6673	2.6673	2.3243	2.572	2.2862	2.0005
19	2.6673	3.0483	3.0483	3.0674	2.9531	2.3815	3.2388
20	2.2862	2.4768	2.6673	2.572	2.4768	1.9052	2.6673
21	1.9052	1.9052	2.0005	2.1719	2.9531	2.0005	.381
22	1.7147	1.5242	1.5242	1.8671	1.7147	2.0195	1.9052
23	.7621	1.4289	1.4861	1.6766	1.5242	1.7528	1.5242
24	.381	.7621	.7621	.9526	1.467	1.5242	1.5242
Max	2.6673	3.0483	3.0483	3.0674	3.0864	2.6673	3.2388
Min	.3429	.7621	.7621	.8573	1.4289	1.1431	.381
Avg	1.2384	1.6882	1.7219	1.7840	2.2024	1.9157	1.8585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 205 / 11 KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763	.381	.4763	.6859	.5716	.743
2	.5716	.4763	.4763	.4763	.724	.6668	.7621
3	.5716	.4763	.4763	.4763	.7621	.7621	.9526
4	.5716	.5716	.5716	.4763		1.2384	1.0479
5	.6668	.6668	.6668	.5716	1.3527	1.5242	1.448
6	.8573	.7621	.7621	1.2384	1.7147	1.7147	1.848
7	1.4289	1.4289	1.0479	1.5242			
8	1.3146	1.4289	.9526	1.3908			
9	1.1431	1.3336		.7621			
10	.9526	.5716	.6668	1.1431	.7621	1.0669	.8573
11	.5716	.4763	.5716		.9526	.9145	.7621
12	.5716	.381	1.7147	.8002	.9526	.8002	.381
13	.5716	.4763	.4763	.6478	.7621	.724	.5716
14	.5716	.4954		.6287	.7621	.6859	
15	.5716	.4572		.5716	.7621	.5335	.8573
16	.4763	.5716	.5716	.6097	.9526	.724	.9526
17	.7621	.6668	.9526		.9526	.9907	.9526
18	1.1431	1.1431	.9526	1.086	1.0479	1.1431	.8573
19	1.1431	1.3336	1.4289	1.4861	1.4289	1.6385	1.5242
20	1.1431	1.0479	1.1431	1.2003	1.1431	1.3527	1.3336
21	.9526	.9526	.8573	1.0479	1.0479	1.105	.9526
22	.7621	.7621	.7621	.8764	.9526	.8764	.8573
23	.381	.6668		.8002	.7621	.7621	.7621
24	.5716	.4763	.5716	.5716	.724	.5716	.724
Max	1.4289	1.4289	1.7147	1.5242	1.7147	1.7147	1.848
Min	.381	.381	.381	.4763	.6859	.5335	.381
Avg	.7851	.7541	.8002	.8574	.9602	.9699	.9574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 206 / EHV THAPTI TANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.381	.5335	.8002	.6668	.724
2	.5335		.381	.4763	.8002	.5716	.724
3	.5716	.4763	.4763	.4763	.8002	.7621	.7621
4	.6478		.7621	.6668	.8383	.9526	.8383
5	.8383		.9526	.7621	.9907	1.0479	1.0669
6	1.105		.9526	.9526	1.105	1.3336	1.2574
7	1.105		1.1431		1.6004	1.7147	1.9052
8	1.105	1.0479		1.0288	1.7147	1.5242	1.9814
9	.8764	.6668		.4763	1.5242	1.3336	1.5623
10	1.1431	1.1431	1.2384	.5716	.4763	.5335	.381
11	1.6194	1.0288	1.6194	1.5242	.381	.4191	
12	1.7147		1.7147	1.6004	.381	.381	
13	1.6194	.0381	1.8099	2.0576	.4763	.5335	.4763
14	1.6194	.0381	1.7147	2.0195	.381	.4572	.381
15			1.6194	1.7528		.4572	.4763
16		.0381		1.9052	.381	.381	.4763
17	1.5242	.0762	.1905	1.829	.5716	.5716	.4763
18	.5716	.0762	.6668	.6478	.5716	.724	.6668
19	.7621	.9526	.5716	.8383	.7621	.9145	1.0479
20	.7621	.9526	.5716	.8383	.9526	1.0288	.8573
21	.5716	.7621	.4763	.724	.7621	.7621	.5716
22	.5716	.5716	.6097	.5716	.5716	.5335	.5716
23	.4763	.5716	.5335	.4954	.4763	.4572	.5716
24	.5335	.4763	.381	.4763	.8002	.5716	.724
Max	1.7147	1.1431	1.8099	2.0576	1.7147	1.7147	1.9814
Min	.4763	.0381	.1905	.4763	.381	.381	.381
Avg	.9457	.5573	.8936	1.0098	.7878	.7764	.8409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 207 / ANTERWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5716		.5716	.381	.381	
2	.5525	.5716	.6668	.5716	.4191	.381	
3	.6859	.5716	.7621	.6668	.4572	.5716	
4	.8192	.7621	.8573	.7621	.5335	.7621	
5	1.0098	1.0479	1.0479	1.1431	.6668	.8573	
6	1.2955	1.3336	1.2384	1.3336	.8002	1.3336	
7				1.1431	1.1431	1.5242	
8				1.0479	1.2765	1.3336	
9	.9717	.4763	.9526	1.0479	1.086	1.2384	
10	.7621	.7621	.7621	.7621	.5716	.6287	
11	.9526	.6668	.7621	.9526	.381	.4763	
12	1.1431	.8573	.9526	1.105	.381	.3429	
13	1.2384	.8573	1.0479	1.086	.2858	.4001	
14	1.1431	.8002	1.1431	1.1431	.4763	.4191	.6668
15	1.0479	.8192	1.1431	1.1812	.4763		
16	.9526	.8573	1.1431	1.2955	.5716		
17	.7621	.8383	.9526	1.1622	.5716		.6668
18	.7621	.9526	.6668	.5525	.6668		.9526
19	.9526	1.1431	1.1431	.9145	1.1431	1.105	1.3336
20	.8573	.7621	.8573	.8192	.9526		.9526
21	.7621	.7621	.7621	.7621	.7621		.7621
22	.5716	.5716	.5335	.6478	.7621		.6668
23	.5716	.4763	.5335	.5906	.5716		.5716
24	.5525	.5716	.5716	.5716	.4001	.381	
Max	1.2955	1.3336	1.2384	1.3336	1.2765	1.5242	1.3336
Min	.5525	.4763	.5335	.5525	.2858	.3429	.5716
Avg	.8599	.7742	.8809	.9097	.6557	.7585	.8216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 201 / 11 KV KARMAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.0754	.0377	.1844	.1844	.218
2	.1132	.132	.1132	.0943	.1844	.2012	.2347
3	.1132	.132	.1132	.0943	.1844	.1844	.2347
4	.1509	.1509	.1509	.1509	.2012	.2012	.2683
5	.1886	.1886	.1886	.1886	.2347	.2347	.3018
6	.2075	.2263	.2263	.1886	.3395	.3018	.3353
7	.2452	.2263	.2263	.2452	.4024	.4191	
8	.2075	.2263		.2263	.4359	.4527	.4694
9	.1509	.132	.2263	.1886	.3688	.3688	.4024
10	.3521	.3353	.3688	.5365	.1509	.132	.1509
11	.3353	.3018	.4359	.4024	.1132	.132	.0754
12	.3521	.285	.3688	.4359	.1132	.0377	.0754
13	.3353	.3018	.3353	.4024	.1132	.1132	.0943
14	.3185	.285	.3353	.4024	.0943	.0943	.0943
15	.3353	.3353	.3353	.4359	.1132	.0943	.0943
16	.3018	.3018	.2683	.4694	.0754	.0943	.1132
17	.3018	.2515	.2683	.3688	.0943	.1132	.1132
18	.0754	.1132	.1132	.132	.1509	.1132	.1509
19	.1509	.1867	.1886	.1509	.1886	.1509	.1886
20	.1886	.1886	.1886	.1698	.2263	.2263	.2075
21	.1509	.1509	.1886	.1509	.1886	.1886	.1509
22	.132	.0377	.1509	.132	.1509	.1509	.1132
23	.132	.0754	.1132	.1132	.1132	.0754	.0943
24	.1132	.132	.0754	.0943	.1844	.2012	.218
Max	.3521	.3353	.4359	.5365	.4359	.4527	.4694
Min	.0754	.0377	.0754	.0377	.0754	.0377	.0754
Avg	.2111	.2012	.2198	.2421	.1919	.1861	.1913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 202 / 11 KV GADHE JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6036	.5365	.6036	.9808	.9808	1.0185
2	.6036	.57	.5365	.6371	1.0185	.9431	1.2826
3	.6036	.57	.6706	.6036	1.0562	.9808	1.358
4	.6036	.5365	.9724	.7712	1.2071	1.0562	1.6598
5	.9054	.8048	1.073	1.0898	1.6975	1.226	1.9239
6	1.1736	1.073	1.1736	1.2742	2.1125	1.6032	1.9616
7	2.0119	1.6095		2.2298	1.9993	1.7918	
8	1.8778	1.8442		1.9784	1.773	1.7541	1.5466
9	1.4419	1.1401	1.1736	1.773	1.4335	1.4335	1.2449
10	.9808	.9054	1.1317	1.2071	1.4419	1.1145	1.1736
11	.7545	.5658		1.094	1.5089	1.0117	1.2071
12	.6036	.6602	.7922	.8299	1.4083	1.0059	1.3077
13	.5658	.679	.6413	.7545	1.3413	1.1568	1.1065
14	.547	.4715	.679	.7545	1.0898	1.0059	.9389
15	.547	.5281	.6413	.9431	1.073	.9221	.9724
16	.6413	.5658	.7922	.7922	1.1065	.8383	1.0395
17	.7922	.7922	.8676	.9054	1.1065	1.073	.788
18	1.0562	.9054	.9997	1.0185	.8488	.8299	1.1317
19	1.6221	1.5844	1.6032	1.5089	1.358	1.4146	1.5278
20	1.3203	1.4712	1.4335	1.4712	1.5089	1.5844	1.5278
21	1.2449	1.1694	1.2071	1.2071	1.226	1.2449	1.3203
22	1.1317	.9431	1.0374	1.1317	1.094	1.1317	1.1317
23	1.0185	.8299	.9431	1.0562	.9808	1.0185	1.0562
24	.6036	.6036	.503	.6371	.9808	.9431	.9431
Max	2.0119	1.8442	1.6032	2.2298	2.1125	1.7918	1.9616
Min	.547	.4715	.503	.6036	.8488	.8299	.788
Avg	.9689	.8928	.9242	1.0947	1.3063	1.1694	1.2682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 203 / 11 KV SHEKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.2742	.9054	1.1736	.9808	.9431	.9808
2	1.4083	1.2742	.9054	1.2071	.9808	.9808	.9431
3	1.4083	1.2742	.9724	1.1736	1.0185	1.0374	1.094
4	1.4419	1.2742	1.1401	1.2071	1.0374	1.1317	1.4335
5	1.6095	1.4754	1.4754	1.4754	1.2449	1.358	1.5089
6	1.7772	1.6766	1.7436	1.8442	1.5089	1.5466	1.5466
7	2.8166	2.5987	2.4813	2.9172	1.6032	1.7164	
8	3.219	2.7496		2.7664	1.3957	1.5466	1.7353
9	2.6155	2.2969	2.2131	2.2466	1.1317	1.3014	1.2071
10	.9431	.8488	.9808	.9808		2.4691	2.4646
11	.8488	.6602	.7545	1.0185	2.6825	2.7435	2.7831
12	.7356	.547	.5658	.7545	1.2071	2.5149	2.6825
13	.6602	.4904	.679	.9054	2.649	2.5149	2.6155
14	.7545	.5281	.7545	.7922	2.4813	2.4143	2.3137
15	.811	.5658	.7167	.9054	2.5819	2.3472	2.0454
16	.6413	.6413	.7167	.8676	2.6825	2.3472	2.2801
17	.8299	.7167		.7167	2.6825	2.2801	2.1963
18	.9997	.7922	.9054	.9054	.8488	.9054	1.1736
19	1.3957	1.358	1.4712	1.358	.9431	1.4146	1.3413
20	1.5226	1.094	1.358	1.4335	1.3957	1.5466	1.4003
21	1.0185	1.0185	1.226	1.2449	1.226	1.4712	1.0751
22	1.0185	.9808	1.0374	1.1317	1.094	1.1694	1.0751
23	1.0185	.7922	.9431	1.0562	.9808	.9808	1.0562
24	1.3748	1.2742	.8718	1.2071	.9808	.9808	.9808
Max	3.219	2.7496	2.4813	2.9172	2.6825	2.7435	2.7831
Min	.6413	.4904	.5658	.7167	.8488	.9054	.9431
Avg	1.3449	1.1751	1.1281	1.3037	1.5364	1.6526	1.6493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 205 / 11 KV GOLATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1694	1.0185	1.1317	.6706	.7042	.8048
2	1.2449	1.2181	1.1317	1.1694	.7042	.6706	.8383
3	1.3203	1.2826	1.4712	1.1317	.7042	.7042	.9054
4	1.4335	1.3769	1.6598	1.3014	.7209	.7545	1.1401
5	1.8861	1.8861	1.8484	1.8673	1.0059	.9724	1.2742
6	2.3011	2.2634	2.1125	2.1125	1.3077	1.3413	1.3413
7	2.2634	2.2634	2.2257	2.3765	1.7101	1.9281	
8	1.9239	1.9993		2.0748	2.0454	2.0957	2.2466
9	1.358		1.3957	1.5466	1.4419	1.7604	1.7436
10	1.6766	1.5089	1.2071	1.5424	.7922	.7167	.5281
11	1.5927	1.0059	1.4754	1.7101	.6036	.679	.415
12	1.5089	1.1401	1.5226	1.7436	.6036	.679	.7545
13	1.5089	1.1065	1.5424	1.5424	.679	.7167	.7922
14	1.2574	1.0059		1.3748	.6036	.7167	.7167
15	1.3413	1.0059	1.2071	1.4083	.7167	.7167	.7167
16	1.2071	.8886	1.4083	1.576	.7167	.7545	.8299
17	1.1736	.7377	1.4083	1.2742	.7922	.7545	.8865
18	.9054	.8676	.9431	.9808	1.0374	1.094	1.3203
19	1.8107	1.5844	1.6975	1.773	1.7353	1.5466	1.7164
20	1.7353	1.6221	1.6787	1.6598	1.6975	1.6975	1.8861
21	1.4335	1.2449	1.5089	1.4335	1.4712	1.4335	1.4335
22	1.3957	1.1317	1.3957	1.5466	1.4146	1.2826	1.4335
23	1.2071	1.0562	1.1883	1.2071	1.1883	1.1317	1.1694
24	1.2071	1.1694	.9808	1.1694	.6706	.7209	.7545
Max	2.3011	2.2634	2.2257	2.3765	2.0454	2.0957	2.2466
Min	.9054	.7377	.9431	.9808	.6036	.6706	.415
Avg	1.4958	1.3276	1.4558	1.5272	1.0431	1.0655	1.1151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 206 / 11 Kv Mirza industrial SHEDDABLE FEEDER HAVING WEEKLY
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	
8	.0377	.0377		.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0381	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0366	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0381	.0377	.0377	.0377
Min	.0377	.0366	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 201 / 11 KV SHENDRA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.06	.6859	.6859	.0686	1.2689	1.286	.1372
2	.0686	.6859	.6859	.0686	1.2689	1.286	.1372
3	.0857	.7202	.6859	.0772	1.2689	1.286	.1543
4	.1029	.8573	.8573	.1029	1.3717	1.5432	.1886
5	.12	.9602	1.0288	.1294	1.749	1.8004	.1886
6	.1286	1.3717	1.2517	.1372	2.2634	2.2291	.2229
7	.1715	1.8861	1.5432	.2229		2.2291	.2229
8	.1715	1.749	1.8004	.2229	1.3717	2.1434	.1972
9	1.4746	1.6289	.1629	.1715	1.0288	.18	1.5432
10	1.2689	1.2003	.1406	1.6118	.7373		1.0288
11	.6516	1.0288	.1115	1.3717	1.6804	.12	1.4403
12	.9259	.8573	.1029	1.2003	1.6289	.1372	
13	.9945	.7716	.0789	.583	1.5775	.1372	1.2346
14	.9259	.7716	.0789	.5487		.1543	1.3032
15	.9259	.7716	.0789	.583	1.5089	.1372	1.3717
16	.9259	.7716	.0857	.583	1.4575	.1372	1.4746
17	.9602		.12	1.2346	1.4575	.1543	1.4746
18	1.3032	1.286	.12	1.3375	1.0288	.1423	1.2346
19	1.7833	1.8004	.18	1.7833	1.7147	.1886	1.7833
20	1.5432		.1715	1.7147	1.7147	.1886	1.7661
21	1.5089	1.4575	.1543	1.6461	1.6289	.1629	1.7147
22	1.3717	1.3717	.1286	1.4403	1.4575	.1475	1.5432
23	1.2689	1.286	.12	1.3717	1.3717	.1423	1.3717
24	.06	.6859	.6859		1.2689	1.286	.1372
Max	1.7833	1.8861	1.8004	1.7833	2.2634	2.2291	1.7833
Min	.06	.6859	.0789	.0686	.7373	.12	.1372
Avg	.7834	1.1184	.4608	.7918	1.4466	.7486	.9509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 202 / 11 KV MAHALPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.6859	.6859	.0686	.6173	.6001	.06
2	.0686	.6859	.6859	.0772	.6173	.6001	.06
3	.0857	.7545	.7716	.0943	.6173	.6516	.0686
4	.1029	.9259	.8573	.1115	.6516	.7716	.0857
5	.12	1.166	1.0288	.1286	.6859	.8573	.1029
6	.1286	1.3032	1.286	.1372	.8573	1.0288	.1029
7	.1457	1.3717	1.286	.1543	1.3717	1.3717	.1457
8	.1543	1.4403	1.1145	.1286	1.2346	1.4575	.1543
9	.9602	1.3717	.0789	1.2003	1.2003	.1132	1.3717
10	.6859	.823	.0772	1.0288	.7716	.8573	
11	.823	.8573	.0772	1.0974	.6859	.0686	
12	.8916	.8573		1.0974	.6001	.0514	
13	.7888	.7716	.0257	1.0631	.5487		.583
14	.7545	.6859	.0772	.9259	.5144		.5487
15		.6859	.0772	.8573	.5144	.06	.5144
16		.6859	.1029	.8916	.5144	.0686	.4801
17	.8916	.6859	.1029	1.0288	.5487	.0686	.583
18	.7888	.7716	.0686	.8573	.6001	.0772	.7545
19	1.2346	1.1145	.1115	1.166	1.2003	.1029	1.2689
20	1.0288	1.0288	.1029	1.0974	1.2003	.12	1.2003
21	.8916	.9431	.0943	1.0288	1.0288	.1029	1.2689
22	.8573	.8573	.0772	.9259	.9431	.0857	1.0288
23	.8573	.823	.0772	.8573	.8573	.0772	.8916
24	.0686	.6859	.6859	.0686	.6173	.6001	.06
Max	1.2346	1.4403	1.286	1.2003	1.3717	1.4575	1.3717
Min	.0686	.6859	.0257	.0686	.5144	.0514	.06
Avg	.5635	.9159	.4153	.6705	.7916	.4451	.5397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 203 / 11 KV BHALGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9602	.9431	.0943	1.4746	1.4575	.1457
2	.1029	.9602	.9431	.0943	1.4746	1.4575	.1457
3	1.286	1.0288	.9431	.1029	1.4746	1.5432	.1715
4	.1457	1.2003	1.0288	.1372	1.7147	1.8861	.2229
5	.1715	1.3032	1.3717	.1715	2.0576	2.0576	.2401
6	.1972	1.989	1.286	.1886	2.4691	2.3148	.2572
7	.2229	2.2291	2.0576	.2658	2.4006	2.2291	2.7435
8	.2572	2.4348	2.452	.2486	2.332	2.0576	.2229
9	2.0919	1.6289	.2058	2.1948	1.5432	.1886	1.8861
10	1.3717	1.3717	.1372	1.7147	2.0576		1.6804
11	.9602	1.2003	.12	1.5775	2.0576		2.0919
12	.9945	1.0288	.1115	1.3717	2.0576	.1886	2.0233
13	.5144	.9431	.1029	1.2003	1.9204	.2658	2.1605
14	.5144	.8573	.1029	1.0974	1.5432	.2572	1.9547
15	.9259	.8573	.1029	1.0631	1.9204	.2229	1.7147
16	1.0288	1.0288	.1029	1.0288	1.9719	.2229	1.6461
17	1.166	1.0288	.1115	1.2003	1.9719	.2143	1.3375
18	1.406	1.3717	.12	1.406	1.2003	.1423	1.3203
19	2.1262	2.3148	.2229	2.0233	2.2291	.1886	2.1605
20	1.9547	1.9547	.1886	1.9547	2.0576	1.9071	1.0288
21	1.8519	1.8861	.18	1.8519	1.8861	.1886	2.0576
22	1.7147	1.7147	.1372	1.7147	1.7147	.1715	1.8861
23	1.5432	1.5432	.1286	1.6118	1.6289	.1543	1.4403
24	.0943	.9602	.9431	.0943	1.4746	1.4575	.1457
Max	2.1262	2.4348	2.452	2.1948	2.4691	2.3148	2.7435
Min	.0943	.8573	.1029	.0943	1.2003	.1423	.1457
Avg	.9827	1.4082	.5851	1.0170	1.8597	.9443	1.2785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 205 / 11KV Om Gajanan Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.0171	.1543	.1372	.0154
2	.012	.1029	.12	.0137	.1372	.1372	.0137
3	.0103	.1029	.12	.012	.1372	.1372	.012
4	.0103	.1029	.1029	.0103	.0686	.12	.0103
5	.0086	.0686	.0857	.0069	.0514	.1029	.0069
6	.0086	.0514	.0686	.0069	.0514	.0686	.0069
7	.0069	.0343	.0686	.0069	.0514	.0686	.0069
8	.0137	.0686	.0686	.012	.0686	.0686	.0086
9	.1715	.0857	.0206	.12	.0857	.0154	.5144
10	.2229	.12	.0206	.1372	.1372	.2229	.1886
11	.2401	.2058	.0257	.1543	.1886	.0206	.2572
12	.3601	.2915	.0257	.1886	.2572	.0206	.2401
13	.3258	.2743	.0189	.1543	.2743	.2058	.1715
14	.3429	.1372	.0206	.1715	.2572	.0206	.2058
15	.3429	.1715	.0171	.1886	.2229	.0257	.2401
16	.3601	.1715	.0171	.1715	.2229	.0257	.1715
17	.3429	.1715	.0171	.12	.1886	.0154	.2401
18	.3086	.2058	.0309	.1886	.1715	.0257	.2401
19	.0857	.0857	.0171	.0857	.1543	.0154	.12
20	.1715	.1715	.0171	.1715	.1715	.0137	.1543
21	.1715	.1715	.0137	.1886	.2058	.0137	.1372
22	.1715	.1372	.0137	.1715	.2058	.0171	.12
23	.1372	.12	.0206	.1543	.1715	.0171	.2229
24	.0137	.1372	.1372	.0171	.1543	.1372	.0154
Max	.3601	.2915	.1372	.1886	.2743	.2229	.5144
Min	.0069	.0343	.0137	.0069	.0514	.0137	.0069
Avg	.1657	.1386	.0502	.1029	.1579	.0689	.1383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 206 / 11 Kv R. K. Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0051	.0343	.0343	.0034	.0343	.0343	.0034
2	.0051	.0343	.0343	.0034	.0343	.0343	.0034
3	.0051	.0343	.0343	.0034	.0343	.0514	.0034
4	.0034	.0343	.0343	.0034	.0343	.0514	.0034
5	.0034	.0343	.0343	.0034	.0343	.0514	.0034
6	.0034	.0514	.0343	.0034	.0343	.0514	.0034
7	.0069	.0686	.0514	.0051	.0514	.0514	.0069
8	.0069	.0514	.0514	.0069	.0514	.0514	.0069
9	.0857	.0514	.0051	.0514	.0514	.0069	.0686
10	.0686	.0514	.0051	.0514	.0514	.0686	.0686
11	.1029	.0514	.0069	.0514	.0686	.0069	.0686
12	.1029	.0514	.0051	.0686	.0686	.0069	
13	.0857	.0686	.0051	.0514	.0686		.0343
14	.0686	.0686	.0051	.0514	.0686		.0686
15	.0514	.0514	.0051	.0514	.0686	.0051	.0686
16	.0686	.0514	.0051	.0514	.0514	.0051	.0686
17	.0514		.0034	.0343	.0514	.0051	.0514
18	.0514	.0514	.0034	.0514	.0343	.0051	.0686
19	.0686	.0514	.0051	.0514	.0514	.0051	.0686
20	.0857	.0514	.0051	.0514	.0514	.0051	.0686
21	.0857	.0343	.0034	.0514	.0514	.0051	.0686
22	.0686	.0343	.0034	.0514	.0514	.0051	.0686
23	.0514	.0343	.0051	.0343	.0343	.0051	.0686
24	.0051	.0343	.0343	.0343	.0343	.0343	.0034
Max	.1029	.0686	.0514	.0686	.0686	.0686	.0686
Min	.0034	.0343	.0034	.0034	.0343	.0051	.0034
Avg	.0476	.0470	.0173	.0342	.0486	.0248	.0412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 208 / 11 kv Omicron

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-MAR-18
HR	Load (MW)
8	.0069
Max	.0069
Min	.0069
Avg	.0069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 201 / 11KV HARMAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.6194	1.0479	1.1431	.8383	1.6004	1.105
2	1.4098	1.5813	.9526	1.1431	.8002	1.5242	1.0479
3	1.3717	1.4861	.9526	1.1431	.7621	1.467	1.0479
4	1.3717	1.3527	.9907	.9907	.7621	1.3717	1.0669
5	1.3336	1.105	.9526	.9907	.7621	1.2955	1.0669
6	1.3336	.8573	.9526	.9526	.6859	1.2384	1.0669
7	1.2955	1.0479	.9907	.8954	.9145	1.5051	1.105
8	1.6766	1.3146	1.3336	1.3527	1.5623	1.9052	1.1812
9	1.9052	1.5051	1.6385	1.3717	1.7147	1.7718	1.3717
10	2.2481	1.5623	1.6004	1.1812	1.6385	2.3243	1.4289
11	2.1338	1.6194	1.5242	1.3717	1.7909	1.9052	1.5242
12	1.9433	1.5242	1.5242	1.0288	1.7147	1.8099	1.5242
13	1.848	1.448	1.5432	1.105	1.6194	2.0957	1.5623
14	1.7147	1.5242	1.6194	1.0288	1.7337	2.1338	1.5623
15	1.8099	1.5623	1.7337	1.0479	1.848	1.9052	1.5242
16	1.8861	1.5623	1.7147	1.0669	1.8861	1.7528	1.4098
17	1.9433	1.5623	1.6194	1.1812	1.8861	1.8099	1.4289
18	1.9814	1.5242	1.5432	.9526	1.7909	1.7528	1.4289
19	1.9624	1.5242	1.3717	1.0288	1.6766	1.7147	1.3336
20	1.8099	1.3717	1.1431	1.1431	1.6385	1.6194	1.3336
21	1.6766	1.3336	1.3336	1.2574	1.6385	1.3336	1.2384
22	1.5242	1.2384	1.467	.9907	1.8099	1.2384	1.2193
23	1.4861	1.1431	1.448	1.105	1.7528	1.1431	1.3336
24	1.448	1.5242	1.1431	1.4289	.8764	1.6766	1.1431
Max	2.2481	1.6194	1.7337	1.4289	1.8861	2.3243	1.5623
Min	1.2955	.8573	.9526	.8954	.6859	1.1431	1.0479
Avg	1.6885	1.4122	1.3392	1.1209	1.4210	1.6623	1.2939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 202 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0669	.6097	1.0479	.9907	1.2765	.8002
2	.8573	1.0098	.5716	.9526	.9907	1.2193	.7621
3	.8573	.9907	.5716	.9526	.9526	1.1431	.7621
4	.8383	.9526	.5716	.9526	.9526	1.086	.724
5	.8383	.9145	.6097	.9145	.9145	1.0098	.724
6	.8383	.8954	.6097	.8383	.9145	.9526	.7621
7	.8383	.7621	.5716	.7621	.7621	1.0098	.7621
8	.8764	.6478	.7621	.8002	1.0669	1.0669	.9145
9	1.2955	.8383	1.3336	.9145	1.448	1.2765	1.2384
10	1.6004	.8573	1.4861	1.2574	1.6766	1.4861	1.3336
11	1.7528	.8573	1.6385	1.5242	1.5813	1.7147	1.4098
12	1.848	.8002	1.7147	1.3336	1.6194	1.8099	1.6194
13	1.6766	.7621	1.7528	1.2193	1.6194	1.7147	1.6194
14	1.5432	.7621	1.8099	1.3717	1.7909	1.5242	1.6575
15	1.5623	.7621	1.8861	1.6385	1.9624	1.6194	1.7147
16	1.6004	.6859	1.8671	1.6766	1.829	1.6194	1.7718
17	1.5623	.6668	1.7147	1.3717	1.7147	1.7147	1.7718
18	1.5051	.6859	1.6004	1.1812	1.5813	1.5242	1.7337
19	1.3527	.7621	1.5242	.9526	1.4289	1.3336	1.7147
20	1.3717	.7621	1.3336	1.0669	1.4861	1.1431	1.5242
21	1.3717	.6668	1.3336	1.1431	1.5623	.9526	1.3908
22	1.2003	.6668	1.2765	1.2193	1.448	.9907	1.2384
23	1.1812	.6668	1.2384	1.1431	1.4098	.9526	1.105
24	.8764	1.1431	.5716	1.1812	1.2193	1.3527	.8573
Max	1.848	1.1431	1.8861	1.6766	1.9624	1.8099	1.7718
Min	.8383	.6478	.5716	.7621	.7621	.9526	.724
Avg	1.2543	.8161	1.2066	1.1423	1.3718	1.3122	1.2463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 203 / 11KV KUMBHEPHAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3547	.381	.4191	.4527	.3547	.4191
2	.4715	.3511	.4191	.381	.4527	.3734	.4763
3	.4715	.3734	.4763	.4191	.4904	.4108	.4954
4	.5093	.4108	.5716	.5335	.5281	.4854	.5716
5	.5281	.5041	.6859	.6097	.6602	.5601	.5716
6	.6224	.6161	.7621	.6859	.7356	.6161	.6097
7	.8299	.6722	.7621	.743	.7545	.5975	.6668
8	.6602	.7095	.724	.6668	.5847	.5788	.5716
9	.811	.7282	.724	.6097	.6979	.7095	.6478
10	.6722	.6859	.6908	.7545	.6908	.724	.6348
11	.679	.6668	.7095	.6979	.5975	.6859	.6161
12	.6602	.6097	.6722	.7167	.6535	.6859	.6348
13	.6161	.5716	.6161	.7167	.6908	.6668	.6161
14	.5601	.5335	.5601	.6036	.6722	.6097	.6161
15	.6161	.5335	.4294	.6602	.6348	.6668	.5975
16	.6535		.5601	.7545	.6722	.6859	.5975
17	.6348		.5601	.8299	.7095	.7621	.6348
18	.6348		.7655	.8488	.6722	.8002	.7282
19	.6348	.6097	.6722	.7733	.6161	.6859	.6722
20	.5601	.6097	.5975	.6036	.5601	.6668	.6722
21	.4668	.5716	.5601	.5658	.5041	.6668	.5975
22	.4294	.4954	.5415	.5281	.4854	.5716	.5601
23	.4108	.381	.4854	.5093	.4481	.4763	.4854
24	.4527	.3734	.381	.4191	.4715	.3921	.4191
Max	.8299	.7282	.7655	.8488	.7545	.8002	.7282
Min	.4108	.3511	.381	.381	.4481	.3547	.4191
Avg	.5849	.5410	.5962	.6271	.6015	.6014	.5880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 204 / 11KV BALIRAJA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.4289	1.0479	1.3717	1.2193	1.6385	1.105
2	1.4861	1.3908	1.0479	1.3336	1.2193	1.5623	1.0669
3	1.4861	1.3336	1.0479	1.3336	1.2003	1.467	1.0669
4	1.4098	1.2955	1.105	1.3336	1.2003	1.3908	1.1431
5	1.3336	1.2574	1.105	1.2384	1.2003	1.3336	1.105
6	1.2574	1.2384	1.1431	1.2384	1.1812	1.2574	1.105
7	1.1812	1.1431	1.1431	1.2003	1.1812	1.2384	1.1431
8	1.3336	1.0288	1.2955	1.086	1.2955	1.2384	1.1812
9	1.6766	1.2003	1.7147	1.1431	1.5623	1.6766	1.6194
10	2.2862	1.3717	1.9814	1.3336	2.0957	2.1338	1.9052
11	2.3053	1.4289	2.3243	1.5623	2.572	2.4768	1.9052
12	2.3434	1.4289	2.3815	1.105	2.4958	2.5911	2.191
13	2.3624	1.4289	2.4006	1.2574	2.4006	2.2862	2.2862
14	2.3243	1.3717	2.4006	1.105	2.4768	2.0957	2.3815
15	2.2862	1.4289	2.4768	1.5242	2.553	2.0957	2.3624
16	2.1719	1.4289	2.4387	1.7528	2.572	1.9052	2.2862
17	2.0767	1.4289	2.4387	1.4098	2.6101	1.9052	2.0957
18	2.0005	1.3336	1.7337	1.3336	2.1338	1.3336	1.5623
19	2.0005	1.2384	1.7147	1.0288	1.7147	1.1812	1.5623
20	1.829	1.1431	1.6194	1.0669	1.829	1.2384	1.5242
21	1.4861	1.105	1.6004	1.105	1.9814	1.1812	1.5242
22	1.467	1.105	1.5623	1.105	1.7718	1.1431	1.5813
23	1.4861	1.1431	1.4861	1.2955	1.7528	1.105	1.6194
24	1.5242	1.448	1.105	1.4861	1.2574	1.7147	
Max	2.3624	1.448	2.4768	1.7528	2.6101	2.5911	2.3815
Min	1.1812	1.0288	1.0479	1.0288	1.1812	1.105	1.0669
Avg	1.7766	1.2979	1.6798	1.2812	1.8115	1.6329	1.6227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 205 / 11KV VAISHNAVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.4481	.3429	.6859	.5281	.5335	.5716
2	.6287	.4066	.381	.6859	.5281	.5525	.5716
3	.6287	.3734	.4572	.6287	.5658	.5601	.5716
4	.5716	.3547	.4572	.6287	.5658		.6097
5	.5716	.3361	.4763	.6287	.5847	.5975	.6097
6	.5716	.3174	.4763	.6287	.6036	.6161	.5716
7	.5716	.2801	.5335	.6097	.6413	.6348	.6097
8	.6859	.2402	.4763	.6859	.5658	.6348	.6668
9	.811	.2402	.724	.6859	.9054	.8383	.8764
10	.9526	.2286	.7922	.7545	.9526	.8573	.7922
11	.9526	.2286	.8488	.9054	.8573	.9526	.7922
12	.9526	.2858	.8488	1.0185	.8383	.9526	.7356
13	.9145	.2858	.8488	.6602	.8192	.9526	.7356
14	.8192	.2667	.9808	.9054	.8192	.9907	.7356
15	.8573	.2667	.9808	.9054	.8002	.9526	.679
16	.8764	.3429	.9619	.9054	.8383	.9907	.6224
17	.7545	.3429	.9054	.8488	.8573	.9526	.679
18	.6161	.3429	.9054	.7356	.8002	.9145	.7356
19	.5601	.3429	.7922	.7356	.7356	.8573	.679
20	.5975	.3429	.7356	.7356	.7356	.8764	.6224
21	.6348	.381	.679	.7356	.7356	.7621	.6036
22	.5601	.381	.6224	.6413	.5601	.6668	.6036
23	.5415	.381	.6602	.5847	.5415	.6668	.5658
24	.6287	.5041	.381	.6668	.5281	.5228	.6097
Max	.9526	.5041	.9808	1.0185	.9526	.9907	.8764
Min	.5415	.2286	.3429	.5847	.5281	.5228	.5658
Avg	.7037	.3300	.6778	.7336	.7045	.7755	.6604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 206 / 11KV SUSHMA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7049	.4763	.6859	.4763	.724	.6097
2	.5144		.4572	.6478	.4763	.7167	.6097
3	.5144	.415	.4572	.6478	.4572	.679	.5716
4	.5335	.4904		.6097	.4572	.6224	.5716
5	.5335	.5658	.4763	.5716	.4572	.6036	.6097
6	.5335	.6224	.4954	.5716	.4954	.5847	.6097
7	.5335	.5906	.4954	.5525	.4954	.6859	.6668
8	.7811	.5525	.6668	.6478	.6859	.7621	.8002
9	.7621	.5281	.9526	.6668	1.0288	1.2955	1.3717
10	1.0098	.4954	1.3336	1.1431	1.2384	.9907	1.4289
11	1.2193	.4954	1.4098	.9526	.9145	1.1431	1.4289
12	1.3527	.4763	1.3336	1.105	.8573	1.1431	1.5242
13	1.2765	.4763	1.0479	.724	.8002	1.1812	1.2384
14	1.1431	.4191	1.1431	1.1431	.9145	1.2384	1.105
15	1.3336	.4191	1.5242	1.105	1.0098	1.2193	1.2955
16	1.5051	.4191	1.5242	1.0288	1.2765	1.2384	1.3717
17	1.467	.4191	1.448	.724	1.467	1.2384	1.1431
18	1.4289	.5716	1.3336	.9145	1.2384	.9526	.9907
19	.8573	.6097	.9526	.9145	.9335	.7621	.8573
20	.743	.5716	.6478	.4572	.8383	.7621	.8002
21	.6161	.4954	.6668	.4191	.724	.724	.7811
22	.6668	.4763	.6668	.4572	.7621	.6859	.8192
23	.6859	.4763	.743	.4954	.7621	.6668	.8192
24	.5144	.6859	.4954	.743	.4954	.743	.6097
Max	1.5051	.7049	1.5242	1.1431	1.467	1.2955	1.5242
Min	.5144	.415	.4572	.4191	.4572	.5847	.5716
Avg	.8767	.5207	.9021	.747	.8026	.8901	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 207 / 11KV Aurangabad Jalna

TollWays Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.124	.0953	.0514	.0566	.124	.0953
2	.0377	.112	.0953	.0514	.0566	.1052	.0953
3	.0377	.1029	.0953	.0343	.0566	.1052	.0762
4	.0377	.0857	.0953	.0305	.0377	.1029	.0762
5	.0377	.0838	.0953	.0305	.0377	.0678	.0381
6	.0377	.0497	.0953	.0267	.0377	.0497	.0381
7	.0377	.0191	.0953	.0267	.0377	.0221	.0381
8	.0377	.0133	.0762	.0381	.0377	.0362	.0381
9	.0377	.0141	.0381	.0381	.0377	.0244	.0381
10	.0175	.0381	.0305	.0377	.0373	.0381	.0343
11	.0164	.0381	.0305	.0377	.037	.0381	.0305
12	.0149	.0381	.0267	.0377	.0343	.0381	.0305
13	.0076	.0381	.0267	.0377	.0328	.0381	.0229
14	.0038	.0381	.0229	.0377	.0229	.0381	.0191
15	.0114	.0381	.0229	.0377	.016	.0381	.0229
16	.0213	.0381	.0229	.0377	.0286	.0381	.0229
17	.0305	.0381	.0267	.0377	.0351	.0381	.0305
18	.0354	.0762	.0305	.0377	.0905	.0381	.0343
19	.0358	.0762	.0343	.0377	.1132	.0762	.0305
20	.0724	.0762	.0343	.0566	.1267	.0762	.0343
21	.1075	.0762	.0343	.0566	.12	.0953	.0514
22	.1029	.0762	.0343	.0566	.116	.0953	.0514
23	.1267	.0762	.0514	.0377	.12	.0953	.0514
24	.0566	.1227	.0953	.0686	.0566	.1227	.0953
Max	.1267	.124	.0953	.0686	.1267	.124	.0953
Min	.0038	.0133	.0229	.0267	.016	.0221	.0191
Avg	.0425	.0621	.0544	.0409	.0576	.0642	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 201 / LADSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.3258	1.086	.5792	.4144	.4163	.543
2	.8688	.3801	1.086	.6154	.4801	.4525	.5249
3	.905	.4525	1.1584	.6878	.9116	.5611	.5068
4	.9955	.5068	1.086	.724	.4144	.6697	.6154
5	.9955	.5792	.905	.7602	.5801	.7783	.724
6	1.086	.6697	1.0136	.7783	.9116	.9955	.8326
7	1.086	.7421	.7421	1.1403	.7459	1.1222	1.1403
8	1.1222	.905	.905	1.1222	.663	1.0498	.905
9	.8145	.5611	.5611	.9593		.6878	.6878
10	.7421	.7964		.905	.4973	.7059	
11	.6516	.6878		.9231	.5801	.8145	
12	.6154	.6722	.6878		.6878	.7421	
13	.5611	.6154	.6516		.6697	.7602	
14	.5249	.6154	.724		.7059	.724	
15	.4887	.5068	.7602		.7421	.7059	
16	.5068	.5792	.724		.7602	.6878	
17	.6335	.6516	.7421		.7602	.7964	
18	.8688	.905	.905		.8688	.8688	
19	.905	.9231	1.0136		1.0498	1.0136	
20	.9412		1.0498		.905	.8145	
21	.905	1.0136	.905		.8145	.724	
22	.7421		.8326		.7059	.6154	
23	.3258		.724		.4887	.5792	
24	.8326	.3077	1.1222	.6878		.3801	.543
Max	1.1222	1.0136	1.1584	1.1403	1.0498	1.1222	1.1403
Min	.3258	.3077	.5611	.5792	.4144	.3801	.5068
Avg	.7896	.6379	.8811	.8236	.6981	.7361	.7023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 202 / 11 KV ANJANDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.8507	.7421	.724	.3315		.3982
2	.724	.9774	.7964	.7964	.4144		.3982
3	.724	1.2851	.8869	.8326	.4973		.3801
4	.724	1.4842	.9774	.905	.663		.4344
5	.7602	1.7737	1.0136	.9593	.8288		.543
6	.7602	1.8461	1.0136	1.0136	.9945		.6154
7	.7964	1.9004	1.086	1.0679	.663		.6516
8	.7964	1.9547	1.6289	.8326	.4973	.6697	.543
9	.7964	2.0271	1.7918	.7602	.3315	.3801	.5249
10			.4344	.543	.9945	1.3575	
11			.3801	.4706	1.1603	1.4661	
12			.362		1.3575	1.1584	
13		.362	.3258		1.3756		
14	.3801	.3982	.2896		1.4118		
15	.3982	.3982	.2896		1.3756	1.086	
16	.3801	.4706	.3258		1.3575	1.2489	
17	.4344		.3801			1.2851	
18	.4887	.5068	.4706		.4163	.543	
19	.5611	.5611	.543		.5792	.6154	
20	.6335		.6516		.5249	.543	
21	.5249		.543		.4525	.5068	
22	.3982		.4344			.4706	
23	.5249		.3801			.4706	
24	.7059	.7602	.7421	.6878			.4344
Max	.7964	2.0271	1.7918	1.0679	1.4118	1.4661	.6516
Min	.3801	.362	.2896	.4706	.3315	.3801	.3801
Avg	.6109	1.0973	.6870	.7994	.8114	.8429	.4923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 203 / 11 KV PIMPALKHUTTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3439	.362	.3258	.3315	.5611	.5249
2	.362	.3801	.3258	.2896	.3315	.5792	.6335
3	.362	.4525	.3258	.2534	.3315	.6697	.724
4	.4344	.4887	.3439	.362	.3315	.7783	.7602
5	.5068	.5068	.362	.5068	.4144	.8145	.8869
6	.543	.5611		.7421	.4973	.9231	.9774
7	.543	.6335	.3801	.6878	.5801	1.0317	1.086
8	.6154	.6697	.4344	.6154	.7459	1.086	.905
9	.5249	.4887	.5068	.5249	.8288	.6335	.7783
10	.5792	.362	.6516	.6154	.3315	.2353	
11	.6154	.4525	.724	.7602	.1658	.1629	
12	.6154	.4887	.8507		.1448	.1267	
13		.4525	.8869		.1448	.1448	
14	.5792	.4163	.9774		.1448	.181	
15	.5249	.4344	.905		.1629	.181	
16	.5611	.5249	.724		.1629	.1629	
17	.6154		.6154		.1629	.2172	
18	.3439	.3439	.362		.3801	.2715	
19	.4525	.543	.543		.543	.5068	
20	.5249	.7468	.6154		.4525	.5249	
21	.4525	.8326	.543		.3982	.4525	
22	.4163	.4163	.5068		.4163	.3801	
23	.362		.4706		.4887	.3801	
24	.3801	.3258	.362			.5249	.5249
Max	.6154	.8326	.9774	.7602	.8288	1.086	1.086
Min	.3439	.3258	.3258	.2534	.1448	.1267	.5249
Avg	.4903	.4939	.5556	.5167	.3692	.4804	.7801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 204 / SAYYAIDPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3258	.362	.543	.5801	.6516	.724
2	.4344	.3439	.4207	.5792	.7459	.724	.7964
3	.4706	.3801	.4344	.6154	.9116	.7602	.905
4	.5068	.4525	.5068	.6516	.9945	.7964	.8688
5	.543	.5792	.6516	.8326	.9116	1.1041	1.267
6	.7964	.8688	.8869	1.0679	.9602		1.6289
7	1.086	.9955	1.3756	1.3213	1.326	1.5384	1.9547
8	1.1403	1.1765	1.2851	1.2308	1.5746	.5792	1.8823
9	.9955	.9231	.9774	1.0317	1.7604	1.5203	1.828
10	1.267	1.1765	1.086	1.1584		.6516	
11	1.647	1.267	1.1584	1.828	.3315	.3982	
12	1.6289	1.3032	1.6832		.2534	.3077	
13	1.6289	1.3575	1.9004		.2534	.2715	
14	1.5927	1.1584	1.7375		.2534	.2896	
15	1.4842	1.2851	1.6289		.2534	.2896	
16	1.3575	1.3937	1.5203		.3077	.2896	
17	1.1946	1.4842	1.448		.3801		
18	.5068	.4887	.4706		.5611	.4706	
19	.6516	.8145	.724		.724	.7964	
20	.7421	.724	1.0136		.6154	.905	
21	.5792	.6154	.7964		.5249	.724	
22	.4706	.4706	.724		.4706	.4706	
23	.3801		.6878		.6154	.4344	
24	.3982	.3258	.362	.543		.6154	.6516
Max	1.647	1.4842	1.9004	1.828	1.7604	1.5384	1.9547
Min	.3801	.3258	.362	.543	.2534	.2715	.6516
Avg	.9125	.8657	.9934	.9502	.6959	.6631	1.2507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 205 / 11 KV Hatmali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.3801	.3982	.543	.4973	.6516	.7964
2	.543	.4525	.362	.5792	.5801	.6878	.8688
3	.543	.4887	.362	.6154	.663	.7602	.905
4	.6335	.5611	.4706	.6878	.7459	.9955	.9774
5	.6335	.6335	.724	.7602	.9116	1.1041	1.086
6	.724	.7421	.905	1.0498	1.0774	1.3937	1.6289
7	.905		1.1584	.9593	1.1603	1.7375	1.8823
8	1.0498	.9231	.9231	1.0136	1.2431	1.5023	1.267
9	1.5384	.724	.724	.7602	1.4089	.9412	1.2308
10	1.267	.6335	.8326	.9774	.4973	.4344	
11	1.1041	.7602	.9774	1.1584	.3315	.7282	
12	1.086	.8145	1.0679		.2534	.2172	
13	1.0317	.8326	1.1222		.2353	.2172	
14	.9774	.6878	1.1946		.2172	.2172	
15	.9231	.7421	1.086		.2715	.181	
16	.9412	.8507	.9774		.3077	.1629	
17	.8507		.8688		.3077	.2896	
18	.362	.3982	.362		.5068	.3077	
19	.6878	.7602	.6516		.7964	.724	
20	.7964	.8688	.7783		.5792	.9231	
21	.6878	.7964	.724		.5249	.6516	
22	.543	.5249	.5792		.4706	.4887	
23	.3982		.543		.5792	.4706	
24	.4525	.362	.3982	.5068		.6335	.6878
Max	1.5384	.9231	1.1946	1.1584	1.4089	1.7375	1.8823
Min	.362	.362	.362	.5068	.2172	.1629	.6878
Avg	.7972	.6637	.7579	.8009	.6159	.6842	1.1330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 206 / BHAKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8145	.6516	.724	.1658	.3077	.2534
2	.8326	.8507	.8326	.7783	.1658	.3077	.2172
3	.905	.8688	.8507	.8326	.2486	.3258	.2172
4	1.086	.9412	1.0679	.9774	.3315	.3258	.181
5	1.2851	1.1222	1.1706	1.0136	.4144	.3439	.2715
6	1.6289	1.2489	1.4661	1.0498	.4973	.3801	.4344
7	1.7737	1.448	1.7556	1.7375	.5801	.5792	.5611
8	1.828	1.6651	1.448	1.6289	.4144	.3982	.4887
9	1.5384	1.3937	1.1584	1.3937	.3315	.3982	.3982
10	.362	.2715	.2534	.362	.2486	.905	
11	.1991	.2172	.181	.2715	1.326	1.2489	
12	.181	.181	.1448		1.3937	1.4045	
13	.181	.181	.1629		1.3756	1.2308	
14	.181	.181	.0905		1.3032		
15	.1629	.1629	.0905		1.2489	1.1041	
16	.1629		.1086		1.1765	1.1222	
17	.181		.181		1.1222	1.3394	
18	.362	.3439	.3077		.3077	.1267	
19	.3982	.5068	.4163		.4706	.3077	
20		.4706	.5068		.3801		
21	.362	.3982	.4344		.3258	.362	
22	.3258	.3077	.362		.3077	.2715	
23	.5792		.3258		.2172	.2534	
24	.5792	.8145	.6516	.6516		.3077	.2534
Max	1.828	1.6651	1.7556	1.7375	1.3937	1.4045	.5611
Min	.1629	.1629	.0905	.2715	.1658	.1267	.181
Avg	.6878	.6852	.6091	.9517	.6241	.6068	.3276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 201 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.0343	.0343	.3429	.0257	.0257	.2572
2	.4287	.0343	.0429	.3429	.0257	.0257	.2572
3	.5144	.0429	.0514	.4287	.0257	.0343	.2572
4	.6001	.0514	.06	.6001	.0343	.0343	.3429
5	.6859	.0686	.0772	.6859	.0343	.0343	.3429
6					.06	.06	.5144
7					.0686	.0772	.8573
8					.06	.0857	.9431
9	.5144	.0514	.0514	.5144	.0686	.06	.5144
10	.3429	.0429	.0429	.0429	.0171	.0257	.1715
11	.0514	.0429	.5144	.0429	.0171	.1715	.0171
12	.0686	.0514	.5144	.06	.0086	.1715	.0171
13	.06	.0514	.5144	.06	.0171	.1715	.0171
14	.06	.06	.5144	.0514	.0171	.1715	.0171
15	.06	.06	.4287	.06	.0171		.0171
16	.06	.0514	.6001	.06	.0171	.1715	.0171
17	.0686	.0514	.5144	.06	.0171	.2572	.0343
18	.0257	.0257	.1715	.0514	.0257	.3429	.0257
19	.0514	.06	.5144	.0514	.0514	.5144	.06
20	.0514	.06	.5144	.0514	.0514	.5144	.06
21	.0514	.0514	.4287	.0429	.0514	.4287	.0514
22	.0429	.0429	.4287	.0429	.0429	.4287	.0429
23	.0429	.0343	.3429	.0429	.0429	.3429	.0343
24	.4287	.0343	.0343	.3429	.0257	.0257	.2572
Max	.6859	.0686	.6001	.6859	.0686	.5144	.9431
Min	.0257	.0257	.0343	.0429	.0086	.0257	.0171
Avg	.2209	.0478	.3046	.1894	.0343	.1815	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 202 / EKLAHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857	.1286	.12	1.2003
2	.0857		.0086	.0857	.12	.1286	1.1145
3	.0857		.0171	.0857	.12	.1286	1.1145
4	.1715		.0171	.1715	.12	.1372	1.2003
5	.2572		.0257	.2572	.12	.1372	1.2003
6					.1457	.1715	1.6289
7					.1543	.18	1.8861
8					.18	.1886	1.9719
9	.1715	.0257	.0257	.1715	.1715	.18	1.7147
10	1.8004	.1715	.1629	.1715	.0086	.0171	.1715
11	.1886	.1715	1.8004	.1886	.0086	.0857	.0086
12	.1972	.1715	1.8004	.1886	.0086	.0857	.0086
13	.1715	.1715	1.7147	.18	.0086	.0857	.0086
14	.1543	.18	1.6289	.1715	.0086	.0857	.0086
15	.1715	.18	1.6289	.1715	.0086	.0857	.0086
16	.1715	.1715	1.7147	.18	.0086	.0857	.0086
17	.1715	.18	1.6289	.1886	.0086	.0857	.0086
18	.0171	.0086	.0857	.0171	.0086	.1715	.0171
19	.0171	.0171	.1715	.0171	.0171	.1715	.0171
20	.0171	.0171	.1715	.0171	.0171	.1715	.0171
21	.0171	.0171	.1715	.0171	.0171	.1715	.0171
22	.0171	.0171	.1715	.0171	.0171	.1715	.0171
23	.0171	.0086	.1715	.0171	.0171	.1715	.0086
24	.0857	.0171	.0086	.0857	.1286	.12	1.2003
Max	1.8004	.18	1.8004	.2572	.18	.1886	1.9719
Min	.0171	.0086	.0086	.0171	.0086	.0171	.0086
Avg	.1939	.0903	.6254	.1184	.0647	.1307	.6066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 203 / CHITEPIMPALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.1629	.1715	1.5432	.06	.0686	.6859
2	1.6289	.1629	.1715	1.5432	.0686	.0772	.6859
3	1.7147	.1715	.18	1.6289	.0857	.0943	.7716
4	1.8004	.1715	.1886	1.7147	.1115	.1115	.9431
5	1.9719	.18	.18	1.8004	.1286	.1372	1.286
6	2.3148	.2401	.2058	2.1434			
7	2.7435		.2229	2.4863			
8	2.8292	.2401	.2658	2.4006			
9	2.572	.2401	.2229	2.1434	.12	.1286	1.1145
10	.9431	.0686	.0857	.1029	.2315	.2229	2.2291
11	.06	.06	.6859	.0943	.2572	2.4863	.2572
12	.06	.0686	.6001	.0857	.2572	2.1434	.2572
13	.0514	.0686	.5144	.0686			
14	.0514	.06	.5144	.06	.2401	1.8861	.2315
15	.0514	.0686	.5144	.06	.2572	2.2291	.2401
16	.06	.0514	.5144	.0686	.2572	2.4863	.2401
17	.06	.0514	.6859	.0772	.2229	2.0576	.2315
18	.0943	.0857	.8573	.0857	.1029	.8573	.0686
19	.1286	.0943	1.286	.1029	.1286	1.1145	.1372
20	.1029	.1115	1.0288	.0943	.1286	1.1145	.1286
21	.0943	.0772	.7716		.1029	1.0288	.1029
22	.0857	.0686	.6859	.0772	.0857	.8573	.0857
23	.0686	.06	.6001	.0686	.0686	.6859	.0772
24	1.5432	.1715	.1543	1.5432	.06	.0686	.6859
Max	2.8292	.2401	1.286	2.4863	.2572	2.4863	2.2291
Min	.0514	.0514	.0857	.06	.06	.0686	.0686
Avg	.9406	.1189	.4712	.8693	.1488	.9928	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 204 / pachod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.0686	.0943	.8573	.0514	.06	.5144
2	1.0288	.0857	.1029	.8573	.06	.06	.5144
3	1.1145	.1115	.1115	.9431	.06	.0686	.6001
4	1.2003	.12	.1115	1.1145	.0772	.0772	.7716
5	1.286	.12	.12	1.2003	.0857	.0857	.8573
6	1.8004	.1715	.18	1.8004			
7	1.9719	.2143	.2058	2.0576			
8	1.8004	.2058	.2058	2.2291			
9	1.5432	.1886	.1886	1.8861	.0857	.0686	.8573
10	.6001	.06	.06	.0772			
11	.0343	.0429	.4287	.06	.1372	1.8004	.18
12	.0343	.0343	.3429	.0514	.1372	1.9719	.2143
13	.0343	.0343	.3429	.0514	.12	1.8004	.1886
14	.0343	.0429	.3429	.0429	.1372	1.8861	.1886
15	.0343	.0429	.3429	.0429	.1543	1.8004	.18
16	.0429	.0343	.3429	.0514	.2058	1.7147	.1715
17	.0429	.0429	.4287	.0514	.18	1.8004	.1715
18	.0514	.06	.5144	.06	.0514	.5144	.06
19	.0772	.0686	.6859	.0686	.0772	.7716	.0772
20	.0686	.0772	.6859	.0686	.0857	.8573	.0857
21	.06	.0514	.6001	.06	.0686	.6859	.0686
22	.0514	.0514	.5144	.06	.06	.6001	.06
23	.0514	.0429	.5144	.0514	.06	.5144	.0514
24	1.0288	.0772	.0857	.8573	.0514	.0514	.5144
Max	1.9719	.2143	.6859	2.2291	.2058	1.9719	.8573
Min	.0343	.0343	.06	.0429	.0514	.0514	.0514
Avg	.6259	.0854	.3147	.6083	.0973	.8595	.3163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 205 / Pimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.0857	.0772	.6859	.0429	.0343	.3429
2	.8573	.0857	.0772	.6859	.0429	.0429	.3429
3	.8573	.0943	.0857	.7716	.0429	.0429	.3429
4	.9431	.1029	.0857	.9431	.0514	.0514	.4287
5	1.1145	.1115	.0943	1.0288	.0514	.0514	.5144
6					.0686	.06	.6001
7					.0686	.0686	.6859
8					.0686	.06	.6859
9	1.2003	.1115	.1115	1.2003	.0514	.0514	.5144
10	.5144	.0514	.0514	.06	.0772	.0857	.7716
11	.0514	.0514	.5144	.06	.0686	.6859	.0772
12	.0514	.0429	.5144	.0514	.0686	.7716	.0772
13	.0514	.0429	.4287	.0514	.0686	.6859	
14	.0514	.0514	.4287	.0514	.0686	.6859	.0772
15	.0514	.0514	.4287	.0514	.0686	.6859	.0686
16	.0514	.0429	.5144	.0514	.0686	.6859	.0686
17	.0514	.0429	.4287	.0514	.0686	.6859	.0772
18	.0857	.0772	.7716		.0857	.7716	.0943
19	.12	.0943	1.0288		.1115	1.0288	.12
20	.1029	.1115	.9431	.1115	.12	1.1145	.1115
21	.1029	.0943	.9431	.1029	.1029	1.0288	.1115
22	.1029	.0857	.8573	.0943	.0943	1.0288	.0943
23	.0943	.0772	.7716	.0857	.0857	.8573	.0857
24	.8573	.0857	.0686	.6859	.0429	.0343	.3429
Max	1.2003	.1115	1.0288	1.2003	.12	1.1145	.7716
Min	.0514	.0429	.0514	.0514	.0429	.0343	.0686
Avg	.3890	.0759	.4393	.3592	.0704	.4708	.2885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 206 / Bafana feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857	.0086	.0086	.0857
2	.0857	.0086	.0086	.0857	.0086	.0086	.0857
3	.0857	.0086	.0086	.0857	.0086	.0086	.0857
4	.0857	.0086	.0086	.0857	.0086	.0086	.0857
5	.0857	.0086	.0086	.0857	.0086	.0086	.0857
6	.0857	.0086	.0086	.0857	.0086	.0086	.0857
7	.0857	.0086	.0086	.0857	.0086	.0086	.0857
8	.0857		.0086	.0857	.0086	.0086	.0857
9	.0857	.0086	.0086	.0857	.0086	.0086	.0857
10	.0857	.0086	.0086	.0086	.0086	.0086	.0857
11	.0171	.0086	.0857	.0086	.0086	.0857	.0086
12	.0171	.0086	.0857	.0086	.0086	.0857	.0086
13	.0171	.0086	.0857	.0086	.0086	.0857	.0086
14	.0171	.0086	.0857	.0086	.0086	.0857	.0086
15	.0086	.0086	.0857	.0086	.0086	.0857	.0086
16	.0086	.0086	.0857	.0086	.0086	.0857	.0086
17	.0086	.0086	.0857	.0086	.0086	.0857	.0086
18	.0086	.0086	.0857	.0086	.0086	.0857	.0086
19	.0086	.0086	.0857	.0086	.0086	.0857	.0086
20	.0086	.0086	.0857	.0086	.0086	.0857	.0086
21	.0086	.0086	.0857	.0086	.0086	.0857	.0086
22	.0086	.0086	.0857	.0086	.0086	.0857	.0086
23	.0086	.0086	.0857	.0086	.0086	.0857	.0086
24	.0857	.0086	.0086	.0857	.0086	.0086	.0857
Max	.0857	.0086	.0857	.0857	.0086	.0857	.0857
Min	.0086	.0086	.0086	.0086	.0086	.0086	.0086
Avg	.0454	.0086	.0504	.0407	.0086	.0504	.0439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 207 / Ambikarpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857	.0171	.0343	.1715
2	.0857	.0086	.0086	.0857	.0171	.0429	.1715
3	.0857	.0086	.0086	.0857	.0171	.0429	.1715
4	.0857	.0086	.0086	.0857	.0257	.0429	.2572
5	.0857	.0086	.0086	.0857	.0257	.0429	.2572
6					.0343	.0514	.3429
7					.0514	.06	.4287
8					.06	.06	.5144
9	.0857	.0086	.0086	.0857	.0514	.0514	.5144
10	.2572	.0257	.0343	.0257	.0086	.0086	.0857
11	.0343	.0343	.3429	.0429	.0086	.0857	.0086
12	.0343	.0429	.4287	.0514	.0086	.0857	.0086
13	.0429	.0514	.4287	.0514	.0086	.0857	.0086
14	.0429	.06	.4287	.0514	.0086	.0857	.0086
15	.0429	.0514	.3429	.0514	.0086	.0857	.0086
16	.0514	.0514	.4287	.0514	.0086	.0857	.0086
17	.0514	.0514	.5144	.06	.0086	.0857	.0086
18	.0086	.0086	.0857	.0086	.0086	.0857	.0086
19	.0086	.0086	.0857	.0086	.0171	.0857	.0086
20	.0086	.0086	.0857	.0086	.0171	.0857	.0086
21	.0086	.0086	.0857	.0086	.0086	.0857	.0086
22	.0086	.0086	.0857	.0086	.0086	.0857	.0086
23	.0086	.0086	.0857	.0086	.0343	.0857	.0086
24	.0857	.0086	.0086		.0171	.0343	.1715
Max	.2572	.06	.5144	.0857	.06	.0857	.5144
Min	.0086	.0086	.0086	.0086	.0086	.0086	.0086
Avg	.0576	.0229	.1678	.0476	.02	.0661	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 201 / GANDHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7655	.583	.7167	.7655	.4458	.4294
2	.7356	.7655	.6516	.6979	.7655	.4458	.6036
3	.7282	.7842	.7373	.7356	.7842	.5487	.6602
4	.8676	.7842	.8402	.8589	.9335	.6173	.7356
5	.9997	.9335	1.0802	1.1389	1.307	.703	.8488
6	1.386	1.1389	1.2174	1.4003	1.3443	.9431	1.0456
7	1.4045	1.307	1.3032	1.2567	1.307	1.2346	1.1827
8	1.2567	1.307	1.2689	1.386	1.1763	1.166	1.1576
9	1.166	1.1763	1.0631	1.0802	1.1389	.6516	1.1088
10	.8059	.7888	.7545	.8059	.8402	.9259	.9259
11	.7888	.6344	.7888	.7373	.7373	.8745	.6687
12	.7716	.6687	.8059	.7716	.703		
13	.703	.8402	.7373	.6687	.5316	.583	
14	.6344	.583	.7373	.6173	.5144	.6173	.5487
15	.6173	.6344	.6173	.5487	.5658	.583	.4973
16	.7716	.6859	.7373	.6516	.5658	.6173	.5658
17	.8402	.8059	.7842		.583	.7202	.6516
18	1.0269	.8916	.9619	.9709	.8745	.6722	.7716
19	1.1203	1.1488	1.0562	1.0269	1.0802	1.2136	1.0288
20	1.0456	1.0288	.9808	.9335	1.0288	1.1389	.9774
21	.8402	.7716	.8299	.9335	.8916	.8413	.9774
22	.7655	.703	.7655	.7655	.7716	.7865	.7202
23		.6344	.7167	.7655	.6859	.7499	.6859
24	.7095	.7655	.5144	.7356	.7655	.4115	.3174
Max	1.4045	1.307	1.3032	1.4003	1.3443	1.2346	1.1827
Min	.6173	.583	.5144	.5487	.5144	.4115	.3174
Avg	.8998	.8561	.8555	.8784	.8609	.7605	.7777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 202 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4108	.2572	.2452	.5788	.5487	.5788
2	.4481	.4108	.3086	.2614	.5788	.583	.5601
3	.4251	.4854	.3601	.3547	.6535	.6001	.6224
4	.7207	.5975	.4801	.4668	.6335	.6687	.7356
5	.7577	.7468		.7207	.6335	.7716	.8589
6	.9054	1.0269	.6173	.8131	.6516	1.0631	1.1389
7	1.3306	1.0269	1.0288	1.0903	.7602	1.1488	1.2936
8	1.2567	.9896		1.2567	.8215	1.0288	1.1576
9	.8916	.9896	.7202	.9602	.7783	.7888	.9055
10	.9602	.4801	.583		.7716	.6516	.6859
11	.5487	.4801	.4458		.703	.6344	.8059
12	.4287	.5144	.5316	.5316	.7202		
13	.4115	.3601	.5487	.5144	.703	.4973	.8059
14	.4801	.3429	.7716	.5144	.6173	.823	.6516
15	.463	.3258	.703	.5316	.7373	.8402	.8059
16	.463	.4115	.8745	.3772	.823	.8402	.6516
17	.6161	.463	.499		.7202	.8402	.6344
18	.8215	.5658	.7133	.5975	.6001	1.0059	.6344
19	.9335	.9602	.679	.7282	.7716	1.0608	.9431
20	.9335	.9088	.6219	.8402	.7888	.9328	.9259
21	.6535		.6219	.7655	.7373	.7133	.8059
22	.6535	.583	.5975	.5788	.6516	.6767	.6173
23		.5144	.5415	.5788		.5853	.5487
24	.3547	.4108	.2058	.2641	.5788	.5658	.5601
Max	1.3306	1.0269	1.0288	1.2567	.823	1.1488	1.2936
Min	.3547	.3258	.2058	.2452	.5788	.4973	.5487
Avg	.6901	.6089	.5777	.6186	.6962	.7769	.7795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 203 / SINDHON BINDHON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9335	.5144	.7842	.5601	.3772	.4481
2	.9242	.9335	.5658	.811	.5601	.3944	.4668
3	1.0562	.9335	.6344	.9149	.8402	.4287	.5093
4	1.1389	.9709	.7716	1.0349	.8402	.4801	.547
5	1.2752	1.0456	.8916	1.1643	.8962	.4973	.7282
6	1.3817	1.1203	1.0631	1.3491	.9709	.6859	1.0829
7	1.6448	1.2136	1.4403	1.6817	1.2883	.8745	1.2197
8	1.6263	1.4377	1.4575	1.7372	1.3394	.8745	1.0903
9	1.166	.9896	1.2346	1.4746	1.3032	.6344	.7577
10	.4973	.3429	.4973	.5316	.823	.9774	1.046
11	.4801	.3921	.5144	.4973	.823	.7202	.8916
12	.2058	.4287	.4801	.3429	.8059	.7202	
13	.2572	.3601	.4973	.3772	.8402	1.046	1.0288
14	.2915	.463	.6687	.3429	.8573	1.0117	1.1145
15	.3086	.5144	.6859	.2743		1.0117	1.1145
16	.8059	.5316	.6859	.3086		.8745	1.1488
17	.4108	.4115	.2987			1.0117	1.046
18	.6908	.583	.7356	.5788		1.0242	.6173
19	.7468	.823	.6908	.5975	.6344	.8779	.9088
20	.5788	.6173	.4854	.6161	.583	.7133	.7888
21	.4294			.5601	.5144	.6584	.583
22	.4294	.3944	.4481	.4668	.4115	.4938	.4801
23		.3258	.3772	.4668	.3772	.4572	.4115
24	.8962	.8962	.4801	.7282	.5601	.3772	.4294
Max	1.6448	1.4377	1.4575	1.7372	1.3394	1.046	1.2197
Min	.2058	.3258	.2987	.2743	.3772	.3772	.4115
Avg	.7886	.7244	.7008	.767	.7914	.7176	.8026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 204 / 11 KV EXP.MAHANANDA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.112	.0686	.0943	.0934	.0686	.0747
2	.0934	.112	.0686	.0943	.0934	.0686	.0754
3	.0754	.112	.0686	.0934	.0934	.0514	.0754
4	.0739	.0934	.0343	.0747	.0934	.0343	.0566
5	.056	.0934	.0343	.0754	.056	.0343	.0566
6	.056	.0934	.0343	.0566	.0373	.0514	.056
7	.037	.056	.0343	.0554	.056	.0514	.0554
8	.0554	.0747		.0554	.056		.0554
9	.0857	.0747	.0514	.1029	.0934	.0686	.1109
10	.1029	.1029	.1029	.1029	.12	.12	.1029
11	.1029	.1029	.12	.0857	.1543	.0857	.0686
12	.12	.1029	.1029	.1029	.0857	.0686	
13	.0686	.0686		.1029	.0686	.0686	.0686
14	.0686	.0686	.0857	.1029	.1029	.1029	.0857
15	.12	.12	.0857	.0857	.1372	.1372	.1029
16	.12	.1029	.1029	.0857	.1029	.1029	.1029
17	.1307	.1029	.1132		.0857	.12	.1029
18	.1307	.0686	.128	.0934	.1029	.1463	.1029
19	.1307	.0686	.1307	.0934	.0686	.128	.0514
20	.1307	.0514	.1494	.0934	.0514	.1097	.0686
21	.0934	.0857	.1086	.0747	.0857	.1097	.0857
22	.0934	.0686	.0934	.0747	.0857	.0914	.0857
23		.0686	.0943	.0747		.0914	.0686
24	.0934	.112	.0686	.0943	.0934	.0686	.0747
Max	.1307	.12	.1494	.1029	.1543	.1463	.1109
Min	.037	.0514	.0343	.0554	.0373	.0343	.0514
Avg	.0927	.0882	.0855	.0856	.0877	.0861	.0778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 205 / PRATIK METAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1867	.1355	.132	.168	.1543	.1494
2	.1294	.1867	.1149	.132	.168	.1492	.1494
3	.132	.1867	.1235	.1478	.168	.1423	.1509
4	.132	.1867	.1097	.1509	.168	.144	.1509
5	.112	.1867	.0943	.1494	.168	.1406	.1494
6	.112	.168	.096	.1494	.1307	.2058	.1494
7	.1663	.168	.1217	.1478	.1494	.2229	.1848
8	.1109	.168		.1848	.1494	.1886	.2033
9	.2469	.1867	.4115		.2054	.7545	.3511
10	.4115	.2058	.7202	.703	.7888	.6687	.4115
11	.3944	.1886	.4973	.5487	1.0974	.8402	.5487
12	.5316	.1886	1.2174	.3258	.6173	1.1488	
13	.5658	.1715	.6001	.6173	.6001	.4973	.6687
14	.5658	.1372	.463	.8573	.4115	.7202	.5316
15	.7716	.1543	.9602	.9774	.703	1.3032	.6859
16	.6687	.1715	.7888	.4458	.9774	1.1488	1.3203
17	1.0456	.1543	.9431		.9774	.7202	1.3203
18	.8029	.168	.9149	.8962	.9088	1.0242	.9774
19	.7468	.1166		.8402	.3772	.3475	.7888
20	.168	.1029	.2427	.2241	.2058	.3658	.5487
21	.168	.1029	.2012	.112	.2058	.2926	.2229
22	.1867	.12	.112	.1307	.1475	.2054	.1269
23			.132	.1307	.1578	.2427	.1149
24	.1494	.1867	.12		.168	.1578	.168
Max	1.0456	.2058	1.2174	.9774	1.0974	1.3032	1.3203
Min	.1109	.1029	.0943	.112	.1307	.1406	.1149
Avg	.3674	.1649	.4145	.3811	.4091	.4911	.4380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 206 / 11 KV MGM FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0171	.0189	.0131	.0257	.0373
2	.0373	.0187	.0137	.0189	.0131	.0223	.0189
3	.0185	.0187	.0137	.0187	.0131	.024	.0189
4	.0187	.028	.0103		.0112	.0206	.0189
5	.0373	.0373	.012	.0189	.0112	.0206	.0377
6	.0187	.0373	.0103	.0185			.0187
7	.0185	.0373	.0206	.0185	.0187	.0291	.0373
8	.037	.0373		.0185	.0187	.0343	.0185
9	.0343	.0373	.012	.012	.0373	.0343	.037
10	.0343	.0171	.0171	.0257	.0171	.0343	.0343
11	.0343	.0171	.0343	.0171	.0514	.0343	.0686
12	.0514	.0343	.0343	.0274	.0514	.0514	
13	.0343	.0343	.0343	.0267	.0686	.0343	.0686
14	.0343	.0514	.0343	.0257	.0686	.0343	.0686
15	.0343	.0514	.0343	.0223	.0514	.0343	.0514
16	.0343	.0343	.0343	.0309	.0514	.0514	.0514
17	.0373	.0343	.0377	.0171	.0171	.0171	.0171
18	.0187	.0257	.0183	.0187	.0257	.0183	.0274
19	.0187	.0137	.0183	.0187	.0223	.0366	.024
20	.0187	.0137	.0183	.0187	.0171	.0183	.0206
21	.0168		.0183	.0187	.0257	.0366	.0223
22	.0168	.0137	.0189	.0168	.0154	.0183	.0171
23		.0154	.0189	.0131		.0373	.0343
24	.0373	.0187	.0171	.0189	.0131	.0257	.0373
Max	.0514	.0514	.0377	.0309	.0686	.0514	.0686
Min	.0168	.0137	.0103	.012	.0112	.0171	.0171
Avg	.0287	.0281	.0217	.0200	.0288	.0301	.0342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 201 / Khodegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.7167	.6224	.6979	.6468	.394	.362
2	.679	.6602	.6224	.7167	.6401	.3982	.3801
3	.7356	.7167	.6036	.7167	.6219	.5121	.4572
4	.8488	.7545	.6602	.7922	.543	.5487	.4572
5	.9431	.9619	.7167	.9054	.5731	.631	.6661
6	1.1317	1.094	.8029	.9997	.6099	.763	1.0774
7	1.1317	1.1949	1.0059	1.1506	1.1568	1.2742	1.2071
8	.9997	1.0278	.8402	.9054	1.1744	1.0526	1.3413
9	.7356	.811	.6602	.7356	.8718	.6882	.8785
10	.6539	.6104	.6173	.7969	.2263	.3961	.4668
11	.8139	.5784	.6687	.8383	.3584	.3395	.3395
12	.763	.6859	.7373	.8886		.4715	.3395
13	.7122	.7209	.7202	.7773		.4527	.3584
14	.6874	.6706	.7373	.5376	.3961	.4338	1.8484
15		.5868		.6325	.4715	.4715	.415
16		.6706	.7202	.7907		.4904	.415
17	.8383		.9602	.7287	.4715	.5281	.415
18	.7095		.7167	.679	.7545	.5975	.6224
19	.9709		.8299	.9808	.9431	.9054	.9431
20	.9054	1.0374	.9054	.8676	.9054	.9808	.9808
21	.8676	.8488	.8299	.7922	.8299	.8488	.7922
22		.7167	.7922	.7545		.7545	.7545
23	.7545	.6602	.7545	.6979	.7545	.679	.6413
24	.7167	.7545	.6602	.6979	.6653	.3582	.3856
Max	1.1317	1.1949	1.0059	1.1506	1.1744	1.2742	1.8484
Min	.6539	.5784	.6036	.5376	.2263	.3395	.3395
Avg	.8236	.7847	.7472	.7950	.6807	.6237	.6894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 202 / Kachner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.5853	.543	.6001	.5658	.4904	.5658
2	.2658	.5853	.5068	.6001	.6036	.4715	.5281
3	.3544	.5228	.5121	.6001	.6979	.4715	.4715
4	.4835	.5228	.5121	.6173	.8488	.7167	.415
5	.5731	.5258	.4961	.6516	.9808	1.0562	.7095
6	.6878	.5493	.4917	.7545	1.2637	1.2136	1.2696
7	.7011	.9724	.852	1.0117		1.3769	
8	1.0923	.9221	.7526	.9088	1.226	1.226	1.3014
9	.8573	.9054	.8048	.7716	1.1694	1.094	
10	.7167	.679	.6979	.7545	.7122	.6173	.7011
11		.4904	.5847	.6602	.9221	.4458	.7291
12			.547	.6224	.8886	.7362	.7291
13	.5281	.3206	.5281	.5847	.7291	.6859	.5596
14	.4904	.5658	.5281	.547	.6783	.5256	.3391
15	.5281	.6036	.4527	.5847			
16	.6224	.6602	.5658	.6224	.8048	.7122	.7122
17	.7655	.7545	.7922	.7167	.8139	.7122	.6516
18	1.1576	1.0082	.9149	.9431	.8029	.7095	.8775
19	1.307	1.358	1.0269	1.1694	1.2826	1.1827	1.2136
20	1.1317	1.1694	1.0456	.9808	1.0059	1.1203	1.1949
21	.8676	.8488	.7842	.7922	.7733	.8488	1.0082
22	.7167	.5658	.6348	.6602	.679	.6602	.8029
23	.5847	.4904	.5658	.5847	.5658	.5847	.547
24	.2629	.6335	.5258	.583	.5658	.5228	.5658
Max	1.307	1.358	1.0456	1.1694	1.2826	1.3769	1.3014
Min	.2629	.3206	.4527	.547	.5658	.4458	.3391
Avg	.6799	.7061	.6527	.7217	.8446	.7905	.7568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 203 / Gadiwat

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7116	.7545	.5868	.8402	.5281	.4904	.415
2	.7522	.7545	.6706	.8402	.5093	.4715	.415
3	.8322	.6882	.5365	1.0395	.5658	.4715	.3772
4	.8907	.7773	.6371	1.4083	.6036	.5975	.3772
5	.9717	.8421	.6874	1.4582	.6979	.7167	.4715
6	1.2452	.9069	.8097	1.8023	.7545	.8676	.8962
7	1.9227	1.4746	1.4842	1.8679	.6413	.9054	.7682
8	1.1603	1.4754	1.3546	1.8023	.5658	.7922	.6468
9	1.1248	1.3763	1.2498	1.3748	4.6965	.6036	.5281
10	.4854	.4527	.3206	.5093	1.3077	1.1401	1.0059
11	.2263	.2957	.2641	.4527	1.5074	1.1797	1.1736
12			.2641	.3772			1.3203
13			.2452	.3772	1.4922	1.3108	
14	.3018	.3018	.1886	.3772	1.4419	1.4251	
15	.2957		.1886	.3772	1.5402	1.278	1.2803
16	.3018	.3772	.2263	.3961	1.5971	1.3108	1.278
17	.3361	.4527		.4338	1.4299	1.3108	1.1869
18	.4481	.415	.547	.5281	.4481	.4108	.4527
19	.7545	.7167	.679	.7356	.6602	.6283	
20	.6413	.6602	.7167	.6413	.6036	.7167	.4338
21	.5281	.5281	.6036	.5658	.5914	.6036	.415
22	.4904	.4527	.547	.547	.5658	.5658	.4904
23	.4527	.415	.4904	.5281	.4904	.4904	.5847
24	.7116	.8478	.5365	.823	.5281	.4904	.4904
Max	1.9227	1.4754	1.4842	1.8679	4.6965	1.4251	1.3203
Min	.2263	.2957	.1886	.3772	.4481	.4108	.3772
Avg	.7084	.7126	.6015	.8376	1.0333	.8164	.7146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 204 / 11 Kv Power Grid

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18
HR	Load (MW)	Load (MW)
14	.3018	
22		1.7164
Max	.3018	1.7164
Min	.3018	1.7164
Avg	.3018	1.7164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 205 / 11 KV Shri 1008 Chintamani NON SHEDDABLE EXPRESS HV FEEDERS
Jai Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-MAR-18
HR	Load (MW)
22	1.6032
Max	1.6032
Min	1.6032
Avg	1.6032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 201 / 11KV Hiwara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5144	.5144	.5087	.4287	.5144	.4458
2	.5144	.6001	.6001	.6001	.4115	.5144	.463
3	.5658	.6001	.6001	.6859	.4287	.5487	.4973
4	.5935	.6859	.6104	.8573	.4973	.4801	.5596
5	.6783	1.0631	.6104	1.0288	.6613	.4801	.6104
6	.763	1.2689	.6952	1.1145	.8309	.5658	.8139
7	1.3748	1.4746	1.286	1.4918	.7042	.7712	.78
8	1.4251	1.6461		1.4922	.57	.5365	.57
9	1.166	1.2887	1.0288	1.3904	.4409	.4239	.407
10	.2743	.2572	.2915	.373	1.0174	.8478	1.0288
11	.1543	.1372	.1886	.3353	1.2548	1.0174	1.0288
12	.1543	.1029	.1715	.3086	1.3056	.8648	1.0288
13	.1715	.1357	.1715	.2204	1.1869	.8573	.9945
14	.1886	.1357	.1886	.2374	.9835	.7202	.9088
15		.1696	.1886	.2204	.9835	.7373	.9431
16		.1696	.1886	.2204	.9835	.8309	.9945
17	.1696	.1715	.2401	.2515	.8573	.9156	.8916
18	.3222	.3429	.3086	.3086	.4801	.2572	
19	.5316	.4801	.4917	.5256	.5144	.5144	.5487
20	.5316	.5487	.463	.5087	.4801	.5721	.5087
21	.5144		.4458	.5087	.4801	.4801	.4973
22	.4973	.4239	.4458	.5144	.4801	.4801	.4801
23	.3601	.407	.4239	.4801	.5658	.463	.4409
24	.4239	.463	.4287	.4801	.4458		.463
Max	1.4251	1.6461	1.286	1.4922	1.3056	1.0174	1.0288
Min	.1543	.1029	.1715	.2204	.4115	.2572	.407
Avg	.5389	.5690	.4601	.6110	.7080	.6258	.6915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 202 / 11KV KARMAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	.8478	.8916	1.0288	.3944	.4801	.4115
2	1.0288	.9431	.8573	1.0288	.4287	.4801	.4287
3	1.0631	1.0288	.9945	1.1145	.463	.4801	.463
4	1.153	1.0174	1.0513	1.2003	.5144	.5144	.5087
5	1.3226	1.3717	1.1869	1.286	.5596	.5144	.5596
6	1.5261	1.5261	1.3735	1.4403	.6104	.6516	.6613
7	1.6263	1.7318	1.5947	1.7147	.6371	.8551	.8309
8	1.5592	1.5947		1.5091	.7712	.7545	.7042
9	1.4232	1.406	1.286	1.3226	.6443		.6613
10	.5765	.6173	.6001	.5935	1.153	1.1361	1.166
11	.5487	.6001	.6274	.6371	1.0174	1.0852	1.1145
12	.5765	.5487		.583	.9496	1.0852	.9835
13	.5426	.5426	.6104	.5596	1.0174	1.0288	1.0288
14	.5487	.5596	.6001	.5426	1.0852	1.0631	1.0852
15	.5144	.5765	.5765	.5765	1.153	1.0288	1.0974
16	.583	.5765	.6001	.6613	1.2209	1.0174	1.1065
17	.6344	.6001	.5658	.57	1.1488	1.1191	1.2003
18	1.17	.8573		1.046	1.286	1.1317	1.286
19	1.3717	1.166	1.7126	1.4074	1.5432	1.4746	1.3889
20	1.406	1.3375	1.6289	1.4074	1.4575	1.5083	1.3413
21	1.286		1.3565	1.3226	1.3717	1.406	1.3717
22	1.2003	1.1191	1.2209	1.286	1.3375	1.286	1.2742
23	1.1191	1.0004	1.0631	1.1831	.4458	1.2003	1.2039
24	1.1022	.9431	.9602		.4115		.4287
Max	1.6263	1.7318	1.7126	1.7147	1.5432	1.5083	1.3889
Min	.5144	.5426	.5658	.5426	.3944	.4801	.4115
Avg	1.0401	.9788	1.0171	1.0444	.9009	.9682	.9294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 203 / 11KV Ladgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.5144	.5487	.5144	.5487	.6859
2	.6173	.5144	.5144	.5935	.5658	.5487	.7373
3	.6344	.5087	.6001	.6001	.6173	.6859	.7716
4	.6613	.5935	.7122	.6783	.6859	.7716	.8817
5	.763	.6859	.8817	.8573	.8139	.8573	.9496
6	1.0004	.8402	.9496	.9665	.8817	.9431	1.0174
7	.9389	.9496	.9431	.9088	1.1736	1.2407	1.3226
8	.8383	.8139		.5426	1.073	.8551	1.291
9	.6173	.5658	.5658	.6443	.8987	.9156	1.0852
10	.8916	.9259	.8745	1.0174	.5087	.407	.3856
11	1.0513	1.0288	.8648	1.073	.407	.3222	.3353
12	1.1022	.9774	.9774		.373	.3391	.2915
13	.9665	.9156	.8916	1.153	.373	.3429	.3353
14	.9774	.8478	.8478	1.1022	.3391	.3429	.3688
15	1.0004	.8817	.8309	.9156	.3391	.3772	.3772
16	.9602	.9326	.7373	.9326	.3391	.373	.3856
17	.8573	.7888	.8573	.9556	.4115	.407	.4801
18	.4801	.5144	.4409	.4801	.5144	.4801	.5144
19	.7545	.6173	.7202	.6952	.6859	.703	.5658
20	.6443	.7202	.6859	.6783	.6516	.7455	.5658
21	.6443		.6344	.6613	.6516	.6516	.5868
22	.6516	.6104	.6104	.6516	.6173	.6001	.57
23	.6104	.5596	.6173	.6173	.5658	.583	.6001
24	.6443	.5487	.583	.5487	.5144		.6516
Max	1.1022	1.0288	.9774	1.153	1.1736	1.2407	1.3226
Min	.4801	.5087	.4409	.4801	.3391	.3222	.2915
Avg	.7878	.7329	.7328	.7749	.6048	.6105	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 201 / 11KV DUDHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.502	.4862	.4534	.5344	.7701	.6964
2	.5407	.5344	.4973	.4858	.5668	.7701	.6478
3	.5735	.5668	.5365	.502	.5992	.9175	.7125
4	.6226	.5992	.6226	.6478	.6478	.9831	.7935
5	.7373	.7449	.7701	.8097	.7287	1.0159	1.0526
6	1.0486	1.085	.9945	1.0202	.8907	1.5546	1.3765
7	1.1633	1.1822	1.1469	1.0526	1.2308	2.0317	
8	1.0159	1.004	.9175	1.0526	1.3441	1.9006	1.8299
9	.8684	.7449	.8356	.8745	1.0526	1.3599	1.3117
10	1.2955	.9878	1.3599	1.3272	.4372	.5243	.3077
11	1.4575	.9555	1.4575	1.4255	.2915	.3239	.2915
12	1.4575	1.278	1.5384	1.4575	.3441	.3239	.2429
13	1.3603	1.1469	1.3441	.8907	.2458	.3563	.2915
14	1.166	1.0322	1.2146	1.2955	.2622	.3077	.3077
15	1.1174	1.1142	1.1174	1.3279	.2949	.3239	.3239
16	1.166	1.1469	1.1984	1.3765	.3277	.3239	.3401
17	1.1012	1.065	1.166	.7287	.3768	.3239	.3563
18	.4858	.4144	.3563	.4858	.4049	.3563	.4696
19	.7611	.7701	.7611	.6964	.8029	.6964	.7449
20	.7611	.7209	.7773	.7287	.7701	.7125	.788
21	.6316	.6173	.5506	.6316	.6882	.664	.6478
22	.583	.5407	.4534	.5668	.5898	.583	.5992
23	.5182	.4973	.502	.5344	.5182	.4858	.4858
24	.4915	.502	.4588	.4858	.5344	.7701	.7125
Max	1.4575	1.278	1.5384	1.4575	1.3441	2.0317	1.8299
Min	.4858	.4144	.3563	.4534	.2458	.3077	.2429
Avg	.8937	.8230	.8776	.8691	.6035	.7658	.6665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 202 / 11KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8619	.7545	.8619	.8785	.9389	.8453
2	.8383	.8288	.7716	.8619	.9116	.9389	.8785
3	.8718	.7956	.788	.8785	.9614	.9724	.9614
4	.9221	.8122	.9389	.9945	1.0277	1.0898	1.0608
5	1.0059	1.0608	1.0898	1.1934	1.1437	1.3413	1.2431
6	1.4251	1.3923	1.2929	1.5083	1.1934	1.4255	1.4089
7	2.4478	2.1879	2.0645	2.1879	1.2597	1.3413	
8	2.3472	2.0719	2.3137	2.0719	.9282	1.0059	.9448
9	1.6933	1.4918	1.4586	1.5415	.8619	.779	.7459
10	.5801	.5304	.4359		1.5746	1.5927	1.442
11	.3481	.3018	.3149		1.7833	1.442	1.5083
12	.3315	.3018	.2652	.4144	1.6933	.9945	1.3426
13	.3149	.3018	.2818	.3978	1.4419	.8951	1.2431
14	.2984	.3018	.2486	.3812	1.3375	.9945	1.2597
15	.3149	.2515	.2652	.3978	1.3077	.9945	1.2597
16	.3481	.3018	.2818	.4144	1.4419	1.0277	1.2431
17	.4144	.3277	.3315	.431	1.2407	1.21	1.1768
18	.4807	.3812	.3647	.5138	.4475	.431	.3647
19	.8122	.8029		.8453	.9503	.8785	.8288
20	.8785	.8886	.9448	.9614	.9389	.9779	.8785
21	.8619	.8402	.8288	.9116	.9602	.8951	.9116
22	.8288	.788	.8122	.8619	.9389	.9116	.8951
23	.7625	.7716	.7625	.9116	.9054	.8288	.7956
24	.8383	.8785	.8215	.9116	.8951	.8886	.8619
Max	2.4478	2.1879	2.3137	2.1879	1.7833	1.5927	1.5083
Min	.2984	.2515	.2486	.3812	.4475	.431	.3647
Avg	.8668	.8114	.8014	.9297	1.1260	1.0331	1.0478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 201 / BIDKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0857	.1257	.1715
2					.1029	.1619	.1715
3					.12	.1524	.2058
4					.1372	.1562	.1715
5					.1543	.1619	.2058
6					.2229	.1858	.2401
7					.2915	.3906	.3086
8					.2915	.4858	.5144
9					.2743	.4049	.1715
10	.3601	.2429	.3391	.3258			
11	.4287	.3239		.3601			
12	.5144	.4049	.4409	.3944			
13	.5144	.4049	.407	.4115			
14	.5144	.4096	.4409	.4458			
15	.4801	.4049	.373	.4973			
16	.4458	.4049	.407	.5487			
17	.4458	.4049	.4748	.5487			
24					.0857	.1067	.1715
Max	.5144	.4096	.4748	.5487	.2915	.4858	.5144
Min	.3601	.2429	.3391	.3258	.0857	.1067	.1715
Avg	.4630	.3751	.4118	.4415	.1766	.2332	.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 202 / INDUSTRIAL STONE CRUSHER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3086	.4668	.2713	.2572	.3734	.3772
2	.3391	.3086	.5601	.3391	.2572	.3734	.3429
3	.373	.3258	.6535	.4409	.2915	.5601	.4115
4	.407	.3429	.3734	.4748	.3258	.5601	.3772
5	.3391	.3429	.3734	.373	.3429	.5601	.3429
6	.3391	.3429	.5658	.6443	.3601	.4668	.4458
7	.2035	.3429	.5601	.7122	.3772	.6535	.3086
8	.3391	.3772	.1886	.5426	.3944	.4668	.1715
9	.3391	.3086	.3734	.1696	.2915	.1867	.5144
10	.6173	.4049	.6443	.3086	.7468	.1715	.3601
11	.7202	.3734	.407	.2915	.8402	.4801	.4801
12	.8402	.3734		.2743	.2801	.3772	.6173
13	.7202	.2801	.3391	.2572	.3772	.4115	.4287
14	.6173	.2801	.2035	.2915	.3734	.3772	.2572
15	.7545	.2801	.5765	.3258	.3734	.3086	.3601
16	.8916	.6535	.5426	.3429	.4668	.3429	.463
17	.7373	.9335	.5426	.3429	.4668	.2743	.583
18	.5487	.9335	.8139	.3601	.5601	.5487	.463
19	.3429	.9335	.9156	.3601	.5601	.4458	.3601
20	.3429	.5601	.6443	.3258	.5601	.3429	.2572
21	.3429	.5601	.2204	.2915	.3734	.3772	.2572
22	.3429	.4668	.3052	.2572	.3734	.3429	.2572
23	.3429	.4668	.2374	.2572	.2801	.3086	.2572
24	.5426	.3086	.4668	.407	.2572	.3734	.3429
Max	.8916	.9335	.9156	.7122	.8402	.6535	.6173
Min	.2035	.2801	.1886	.1696	.2572	.1715	.1715
Avg	.4884	.4504	.4771	.3609	.4078	.4035	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 203 / LAKHEGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2058	.2143	.2374			
2	.2374	.2058	.2229	.2713			
3	.2713	.2572	.2229	.3052			
4	.2713	.2915	.2229	.3391			
5	.3052	.3258	.2972	.3391			
6	.5426	.6859	.3715	.5426			
7	1.153	1.0288	.8907	1.153			
8	1.1869	1.0288	1.0526	1.0513			
9	.8478	.4458	1.0269	.7461			
10			.9326		.703	.6859	.6173
11					.8097	.8573	.7202
12					.8907	.823	.823
13					.9717	.8573	.7716
14					.9717	1.0288	.7373
15					.8097	.823	.7545
16					.8697	.6859	.7716
17					.8097	.7888	.7888
24	.2713	.6859	.2229	.2713			
Max	1.1869	1.0288	1.0526	1.153	.9717	1.0288	.823
Min	.2374	.2058	.2143	.2374	.703	.6859	.6173
Avg	.5324	.5161	.5161	.5256	.8545	.8188	.7480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 204 / PANGRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409	.3429	.3239	.2713			
2	.4409	.3772	.3734	.3391			
3	.4409	.4458	.3239	.407			
4	.4409	.4801	.3715	.4748			
5	.4409	.5144	.4858	.5087			
6	.6104	.8745	.5201	.6104			
7	1.4922	1.2346	1.2146	1.3226			
8	1.153	1.3717	1.2955	1.2548			
9	1.0174	1.0288	1.2136	1.0174			
10			1.1022		.9717	1.0288	.8402
11						.8916	.9774
12					.8097	.8573	1.1317
13					.8097	.823	1.1145
14					.9717	1.0288	1.0974
15					1.2146	.9259	1.1488
16					1.1336	.9602	1.0288
17					1.1336	1.0288	.9259
24	.4409	.3086	.3239	.3052			
Max	1.4922	1.3717	1.2955	1.3226	1.2146	1.0288	1.1488
Min	.4409	.3086	.3239	.2713	.8097	.823	.8402
Avg	.6918	.6979	.6862	.6511	1.0064	.9431	1.0331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 205 / NILAJGAON Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2058	.3048	.6516
2					.2572	.3239	.6516
3					.3086	.3239	.6859
4					.3429	.4858	.6859
5					.3944	.4858	.7202
6					.6687	.6097	.7888
7					.9602	1.6194	1.5432
8					1.0802	1.6194	1.8861
9					.5316	1.2955	1.2003
10		.7468	.8478	.9774			
11		.9374	1.3565	1.1317			
12		1.2955		1.286			
13		1.2146	1.3565	1.4575			
14		1.4003	1.3565	1.4575			
15	1.9547	1.1336	.7122	1.4403			
16	2.0233	.9717	1.1191	.5658			
17	1.5261	1.1336	1.3565	.4801			
18			1.3565				
24				1.3565	.2058	.2429	.2743
Max	2.0233	1.4003	1.3565	1.4575	1.0802	1.6194	1.8861
Min	1.5261	.7468	.7122	.4801	.2058	.2429	.2743
Avg	1.8347	1.1042	1.1827	1.1281	.4955	.7311	.9088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 207 / INDUSTRIAL BIDKIN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2058	.1867	.407	.2401	.2801	.1715
2	.3052	.2058	1.8671	.407	.2401	.2801	.1715
3	.2713	.2401	.1867	.3391	.2572	.2801	.1715
4	.2713	.2572	.1867	.2713	.2572	.2801	.2058
5	.3391	.2743	.1867	.3391	.2743	.2801	.1715
6	.3052	.2743	.2801	.3391	.2915	.4668	.3086
7	.373	.2572	.2801	.4748	.2915	.4668	.3429
8	.5087	.3086	.3734	.4409	.4115	.4668	.3772
9	.4748	.3086	.5087	.5426	.5658	.5601	.4801
10	.5487	.2801	.5426	.4801	.5658	.5144	.463
11	.4115	.2801	.5765	.5144	.5601	.6173	.4458
12	.2915	.2801	.4409	.5487	.3734	.4115	.4458
13	.3601	.2801	.4409	.6001	.4668	.4458	.4973
14	.4115	.2801	.4409	.6001	.4668	.3772	.5316
15	.4115	.2801	.4748	.583	.5601	.4458	.5144
16	.4115	.1867	.5087	.583	.4668	.4801	.4801
17	.4801	.1867	.6104	.4287	.3734	.4801	.4458
18	.3944	.1867	.5087	.3944	.4668	.3429	.3944
19	.3086	.1867	.2713	.3772	.362	.3429	.3429
20	.2915	.1867	.3052	.3429	.3734	.3086	.2915
21	.2743	.1867	.3052	.3086	.3734	.3429	.2572
22	.2401	.2801	.3052	.2743	.3734	.3429	.2572
23	.2058	.2801	.2374	.2401	.5601	.3086	.2229
24	.407	.2058	.1867	.3052	.2401	.3734	.2743
Max	.5487	.3086	1.8671	.6001	.5658	.6173	.5316
Min	.2058	.1867	.1867	.2401	.2401	.2801	.1715
Avg	.3598	.2458	.4255	.4226	.3922	.3956	.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 209 / BIDKIN Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	1.3717	1.1203	1.2209	1.3717	1.4937	1.3717
2	1.5261	1.3717	1.307	1.3226	1.5432	1.4937	1.3717
3	1.6956	1.6804	1.587	1.4582	1.8004	1.6804	1.5432
4	1.933	2.1605	2.0538	1.8991	1.9547	2.0538	1.8861
5	2.34	2.4177	2.7073		2.572	2.8006	2.4006
6	1.6617	1.6804	1.7737	1.5939	1.6289	1.7918	2.915
7	.7122	1.5947	1.7737	1.5261	1.6975	1.6804	2.4006
8	1.5939	.703	.9335	.9835	1.5947	1.6804	.8916
9	1.1869	.6001	2.0538	.9496	.8745	2.4272	1.6118
10	1.2174	2.1472	1.7635	2.3834	1.8671	1.5432	1.6975
11	.9431	1.4003	1.2548	1.989		.583	1.3203
12	.6687	1.0269	.9835	1.5775	1.0269	.5487	.9259
13	.7716	1.0269	.9156	1.2346	.9335	.6516	.8916
14	.9602	1.0269	.9156	1.2689	.9335	.6859	.8573
15	.9774	1.1203	.9835	1.3032	1.0269	.8573	1.0802
16	.9945	1.0269	1.2887	1.3546	1.4003	.9945	1.3032
17	1.5947	1.4003	1.56	1.6118	1.7737	1.6118	1.5432
18	2.1091	2.1472	1.9669	1.8176	2.1472	1.8176	1.8519
19	2.6406	2.8006	2.6452		2.7349	2.4691	2.1605
20	2.1605	2.4272	2.0348	1.6804	2.8006	2.0576	2.4691
21	1.6632	1.9605	1.7635	1.5432		1.8861	2.4006
22	1.5432	1.4937	1.56	1.4746	1.6804	1.5432	1.8004
23	1.4575	1.1203	1.2548	1.2003	1.6804	1.6118	1.5432
24	1.2887	1.3717	.8916	1.2209	1.2003	1.4937	1.3717
Max	2.6406	2.8006	2.7073	2.3834	2.8006	2.8006	2.915
Min	.6687	.6001	.8916	.9496	.8745	.5487	.8573
Avg	1.4582	1.5449	1.5455	1.4825	1.6474	1.5607	1.6504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 210 / Bidkin Town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1191	1.2003	1.1203	1.0174	1.5432	1.2136	1.1317
2	1.1191	1.2003	1.1203	1.0852	1.3717	1.307	1.2003
3	1.153	1.2689	1.307	1.1191	1.3717	1.4937	1.3717
4	1.1869	1.3717	1.4003	1.1869	1.4232	1.6804	1.6118
5	1.5261	1.4746	1.587	1.4582	1.4575	1.7737	2.0576
6	2.2043	1.9204	2.1472	2.1365	1.8861	2.3339	2.2291
7	2.3061	2.3663	2.4272	2.1026	2.3148	2.6139	2.3663
8	2.0008	2.1091	2.2405	1.9669	2.1091		2.0233
9	1.8313	1.9204	2.0538	1.7974	1.8347	2.5206	1.8861
10	1.6632	1.8671	1.6956	1.749	1.7737	1.8861	1.6804
11	1.3375	1.587	1.4243	1.5261	1.6804	1.6804	1.3717
12	1.0117	1.4003	1.3226	1.3032	1.307	1.166	1.0802
13	1.046	1.4003	1.0174	1.0974	1.4937	1.2003	.9774
14	1.0974	1.4003	.8139	.9774	1.4937	1.0288	.8745
15	1.1831	1.4003	.8139	.8573		.9259	.8573
16	1.2689	1.307	.8478	.7373	1.4003	.9945	.8402
17	1.1317	1.4003	.9835	.8745	1.4937	1.0288	.823
18	1.5604	1.7737	1.7295	1.3546	1.8671	1.8176	1.2174
19	2.0062	2.0538	2.0348	1.8519	2.2405	2.0576	1.6118
20	1.7661	1.6804	1.6956	1.9204	2.4272	1.6804	2.0233
21	1.5261	1.4937	1.4582	1.8861	1.9605	1.6118	1.7833
22	1.4575	1.307	1.2887	1.749	1.587	1.3717	1.6461
23	1.3717	1.1203	1.1022	1.6461	1.4003	1.2689	1.3717
24	1.1869	1.286	1.0269	1.0513	1.5432	1.4003	1.3032
Max	2.3061	2.3663	2.4272	2.1365	2.4272	2.6139	2.3663
Min	1.0117	1.1203	.8139	.7373	1.307	.9259	.823
Avg	1.4609	1.5546	1.4441	1.4355	1.6948	1.5676	1.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 201 / BARANAGAR I

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.6859	.4572	.7468	.6535		
2		.823	.4572		.6535		
3	1.2136	.8573	.4572	.8402	.6535		
4	1.307	.8573	.4877	.9335	.7468		
5	1.4937	1.0288	.5487	1.2136	.7468		
6	1.6057	1.2003	.6097	1.307	.7468		
7	2.9874	2.332	1.9814	2.4272	1.6057		
8	2.2405	2.0576	1.829	1.9605	1.4937		
9	1.8671	1.0059	1.0669	1.7737	1.4003		
10					1.2136	1.2136	1.2136
11					1.307	1.7737	1.2955
12					1.8671	1.6804	1.2193
13					1.7737	1.6804	1.5242
14					1.587	1.4937	1.3717
15					1.643	1.587	1.1431
16					1.587	1.6804	1.6766
17					1.6804	1.587	1.4937
24	.9335	.6516	.4572	.7468	.7468		
Max	2.9874	2.332	1.9814	2.4272	1.8671	1.7737	1.6766
Min	.9335	.6516	.4572	.7468	.6535	1.2136	1.1431
Avg	1.6202	1.1500	.8352	1.3277	1.2281	1.5870	1.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 202 / BARANAGAR II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1715	.415	.2801	.2801	.6535	.5601
2	.2801	.1715	.415	.2801	.2801	.7468	.5601
3	.2801	.1715	.415	.2801	.2801	.9335	.5601
4	.2614	.1715	.415	.2801	.2801	1.1203	.6535
5	.2614	.1715	.4338	.2801	.2801	1.307	.8402
6	.2614	.1715	.4527	.2801	.2801	1.9605	
7	.2614	.1715	.4904	.2801	.2614	2.7073	2.4272
8		.1715	.4715	.2801	.2614	2.4272	2.3339
9		.1715		.2801	.2427	1.6804	1.4937
10	1.0269	.6859	1.4175	1.0269	.2427	.2801	.2801
11	1.0829	.823	2.2032	1.4937	.2241	.2801	.2829
12	1.4746	1.3717	2.0538	1.6289	.2241	.2801	.2829
13	1.3717	1.5242	1.8671	1.4403	.2241	.2801	.2829
14	1.3717	1.6004	1.6804	1.5123	.2241	.2801	.2829
15	1.3717	1.6766	1.8671	1.4937	.2241	.2801	.2829
16	1.2689	1.6004	1.7737	1.4937	.2427	.2801	.2829
17	1.0974		1.4937	1.6804	.2801	.2801	.2829
18	.2401	.3734	.2801	.2801	.2801	.2801	.2829
19	.2743	.415	.2801	.2858	.2801	.2801	.2829
20	.2743	.4527	.2987	.2801	.2801	.2801	.2829
21	.2743	.4338	.2801	.2801	.2801	.2801	.3018
22	.2743	.415	.2801	.2801	.2801	.2801	.3018
23	.2743	.415	.2801		.2801	.2801	
24	.2801	.1715	.415	.2801	.2801	.5716	.5601
Max	1.4746	1.6766	2.2032	1.6804	.2801	2.7073	2.4272
Min	.2401	.1715	.2801	.2801	.2241	.2801	.2801
Avg	.6292	.5870	.8687	.6947	.2622	.7512	.6228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 203 / 11 KV KAPUS WADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4481	.2614	.3734	.1867		
2	.4668	.4854	.2614	.3734	.2241		
3	.4854	.4854	.2614	.4668	.2801		
4	.4854	.4854	.2801	.5041	.2801		
5	.5228	.5228	.3361	.5601	.2801		
6	.5228	.5228	.3734	.5601	.2801		
7	.9335	.4481	.8962	.9335	.2801		
8	.9335	.5228	.8402	.9335	.3734		
9	.8962	.4854	.6535	.9335	.4668		
10					.5601	.5601	.6535
11					.6161	.6535	.7468
12					.6535	.6535	.7468
13					.5601	.7468	
14					.5041	.6535	
15					.4668	.6535	
16					.5975	.7468	
17					.5601	.7468	
24	.4668	.4481	.3174	.2801			
Max	.9335	.5228	.8962	.9335	.6535	.7468	.7468
Min	.4668	.4481	.2614	.2801	.1867	.5601	.6535
Avg	.618	.4854	.4481	.5919	.4218	.6768	.7157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 204 / 11 kv Balanagar Gaothan
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	.9431	.8962	1.0269	.9335	.9335	1.0269
2	1.0269	.9431	.9709	1.1203	1.0269	1.0269	1.1203
3	1.1203	1.0288	1.0642	1.1203	1.0269	1.0269	1.1203
4	1.2136	1.166	1.2136	1.307	1.2136	1.2136	1.4003
5	1.8671	1.7147	1.6804	1.7737	1.4937	1.4003	1.8671
6	2.4272	1.8519	2.5393	2.5206	2.4832	2.4272	2.6139
7		1.8519	2.4272		2.8006	2.4272	2.6139
8			2.2405		2.2405	2.1472	
9		1.6118	2.0538	2.5206	2.0538	2.0538	1.9605
10	1.6244	1.3717	1.4003	2.2405	1.363	1.307	1.4003
11	1.0288		1.1203	1.587	1.0269	.8775	.8402
12	.7545	1.0082	.7468	.6859	.6859	.7468	.8402
13	.823		.7468	.8745	.7468	.8402	.7095
14	.7202		.8402	.8775	.7716	.7468	.6722
15	.6859	.8962	.8402	.9335	.7468	.8402	
16	.7202	1.0082	.8402	.9335	.9335	.9335	.8775
17	1.2003	1.307	1.1203	1.307	1.307	1.2136	1.1949
18	1.5432	1.8111	1.587	1.6244	1.9791	1.4937	1.531
19	1.8519	2.2965	2.2405	1.9605	1.8671	2.3339	2.0538
20	1.5432	1.6991	1.8671	1.587	1.6804	1.9605	1.8298
21	1.1317	1.2136	1.307	1.2136	1.307	1.307	1.2323
22	.9945	.9896	1.1203	1.0642	1.0456	1.1203	1.0829
23	.9259	.8962	.9335		.9896	1.0269	.9709
24	.9335	.8573	.8589	1.0269	.9335	.9335	1.0269
Max	2.4272	2.2965	2.5393	2.5206	2.8006	2.4272	2.6139
Min	.6859	.8573	.7468	.6859	.6859	.7468	.6722
Avg	1.1982	1.3233	1.3606	1.3955	1.3607	1.3474	1.3630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 205 / Ginning

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1715		.1867	.1867	.1867
2	.1867	.1715		.1867	.1867	.1867
3	.1867	.1715		.1867	.1867	.1867
4	.1867	.1715		.1867	.1867	.1867
5	.1867	.1715		.1867	.1867	.1867
6	.1867	.1715		.1867	.1867	.1867
7	.1867	.1715		.1867	.3734	.2054
8	.1867	.1715		.1867	.3734	.2801
9	.1867	.1715		.2572	.3734	.3734
10	.2801	.1715		.2572	.3734	.3734
11	.2572	.1029		.2801	.3734	.3772
12	.2572			.2801	.3361	.3772
13	.2401		.2572	.2801	.3361	.2829
14	.2572		.2801	.2801	.2801	.1886
15	.2401		.2801	.2801	.2801	.1886
16	.2572		.2801	.2801	.2801	.1886
17	.2401		.2801	.2801	.2801	.1886
18	.2572		.2801	.2801	.2801	.1886
19	.2572		.2801	.1867	.2801	.0377
20	.2572		.2801	.1867	.2614	.0377
21	.2572		.0934	.1867	.2614	.0377
22	.1715		.1867	.1867	.1867	.0566
23	.1715			.1867	.2801	.1132
24	.1867	.1715		.1715	.1867	.1867
Max	.2801	.1715	.2801	.2801	.3734	.3772
Min	.1715	.1029	.0934	.1715	.1867	.0377
Avg	.2195	.1658	.2498	.2231	.2715	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 206 / kherda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8402	.7468
2					.8589	.8402
3					.8775	.8402
4					.9335	.9335
5					1.0269	1.1203
6					1.2323	1.2136
7					1.6804	1.8671
8					1.4003	2.2405
9					1.1203	1.7737
10	1.251	.7888	.9145	1.307		
11	1.3717	.9259	1.1949	1.4003		
12	1.406	.8993	1.307	1.2003		
13	1.3717	.8688	1.4937	1.4918		
14	1.4746	.8383	1.4937	1.587		
15	1.3717	.9602	1.307	1.587		
16	1.4746	1.0212	1.4003	1.587		
17	1.2003	.945	1.1203	1.307		
24					.8029	.6535
Max	1.4746	1.0212	1.4937	1.587	1.6804	2.2405
Min	1.2003	.7888	.9145	1.2003	.8029	.6535
Avg	1.3652	.9059	1.2789	1.4334	1.0773	1.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 201 / 11 KV HARSHI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0754	.0754	.2667	.1269	.213
2	.0953		.0754	.0754	.2667	.1158	.2294
3	.0762	.0762	.0754	.0754	.2667	.1269	.2458
4	.0762	.0762	.0754	.0754	.2858	.1486	.2622
5					.2858	.1524	.2785
6					.3239	.1486	.2949
7					.381	.6554	.6882
8					.4382	.7099	.6478
9					.5144	.4458	.3113
10	.3666	.3395	.3605	.4954			
11	.3384	.3725	.3932	.5716			
12	.4607	.5506	.3932	.6097			
13	.3858	.502	.4096	.6668			
14	.4012	.4534	.4588	.6668	.0191	.0189	.0191
15	.3395	.421	.5571	.6859	.0191	.0189	.0191
16	.3353	.4372	.5407	.724	.0191	.0189	.0381
17	.3185	.4588	.5243	.6097	.0191	.0189	.0381
18	.0381	.0377	.0566	.0381	.0572	.0377	.0381
19	.0572	.0943	.0566	.0381	.0943	.0377	.0572
20	.0625	.0943	.0754	.0572	.0953	.0566	.0762
21	.0762	.0943	.0754	.0762	.0762	.0566	.0572
22	.0762	.0754	.0754	.0572	.0762	.0566	.0762
23	.0762	.0754	.0754	.0762	.0572	.0566	.0572
24	.0953	.0572	.0754	.0754	.2667	.1646	.1966
Max	.4607	.5506	.5571	.724	.5144	.7099	.6882
Min	.0381	.0377	.0566	.0381	.0191	.0189	.0191
Avg	.1975	.2374	.2331	.3026	.1914	.1586	.1922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 202 / 11KV DADEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.2675	.4144	.2458	.1143	.1143	.1886
2	.7621	.2743	.431	.2785	.1143	.1307	.1886
3	.8573	.3239	.4807	.3605	.0953	.132	.1886
4	.9717	.3605	.5407	.4588	.1143	.1494	.1698
5	1.0479	.4161	.5898	.5243			
6	1.2193	.6081	.664	.6554			
7	1.4098	1.6004	1.4864	1.4251			
8	1.6575	1.6667	1.6049	1.3441			
9	1.829	1.3077	1.3916	1.2955			
10					.9991	.8002	.9907
11					1.0848	1.0526	1.0288
12					1.142	1.085	1.2193
13					.9877	1.1174	1.105
14	.0191	.0189	.0189	.0191	.884	1.004	.9907
15	.0191	.0191	.0189	.0191	.9511	.8421	1.0479
16	.0191	.0377	.0189	.0381	.9431	.8745	1.105
17	.0191	.0377	.0189	.0381	1.0997	.9231	1.1812
18	.1174	.0754	.0377	.0572	.0943	.0943	.0381
19	.1509	.1867	.0943	.0762	.1341	.1132	.0572
20	.168	.2054	.1132	.1143	.1509	.1698	.0953
21	.1174	.168	.1132	.1715	.1509	.1698	.1143
22	.1143	.132	.132	.1715	.1509	.1886	.1524
23	.0838	.1132	.132	.1524	.1341	.1886	.1524
24	.6097	.2256	.3856	.213	.1143	.1334	
Max	1.829	1.6667	1.6049	1.4251	1.142	1.1174	1.2193
Min	.0191	.0189	.0189	.0191	.0943	.0943	.0381
Avg	.5958	.4022	.4344	.3829	.4979	.4886	.5563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 203 / 11KV KUTUBKHEDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0381	.0754	.0754	.2858		.213
2	.0762	.0381	.0754	.0754	.3048		.2458
3	.0953	.0381	.0754	.0754	.3048		.2785
4	.0953	.0381	.0754	.0754	.3429		.3113
5					.362		.3605
6					.381		.5735
7					.4382		1.004
8					.5144		.9393
9					.724		.7287
10	.6241	.3963	.5243	.7049			
11	.7282		.5243	.724			
12	.7133	.6081	.6226	.7811			
13		.5535	.6718	.8192			
14	.6874	.5376	.639	.9145	.0191	.0189	.0191
15	.639	.5441	.6226	.8764	.0191	.0189	.0191
16	.6371	.5693	.639	.8954	.0191	.0189	.0191
17	.5639	.6081	.6718	.8954	.0191	.0377	.0381
18	.0762	.0381	.0754	.0572	.0381	.0377	.0381
19	.0747	.0754	.0754	.0762	.0762	.0566	.0381
20	.0953	.0754	.0754	.0762		.0566	.0572
21	.0762	.0754	.0754	.0762		.0566	.0572
22	.0762	.0754	.0754	.0572		.0566	.0762
23	.061	.0754	.0754	.0572		.0566	.0572
24	.0953	.0566	.0754	.0754	.2858		.1966
Max	.7282	.6081	.6718	.9145	.724	.0566	1.004
Min	.061	.0381	.0754	.0572	.0191	.0189	.0191
Avg	.3061	.2467	.3024	.3888	.2584	.0415	.2635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 204 / 11KV DAWARWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.1738	.1658	.213	.0572	.0381	.0377
2	.4001	.2054	.1844	.2294	.0572	.0381	.0377
3	.4382	.2439	.2155	.2785	.0762	.0381	.0377
4	.4954	.2881	.2486	.3113	.0572	.0381	.0377
5	.5525	.3277	.2622	.3441			
6	.6668	.4481	.2949	.3605			
7	.724	.4784	.6316	.6802			
8	.7621	.8482	.8855	.7045			
9	.8002	.7042	.7287	.7125			
10					.6706	.4012	.6478
11					.8025	.7537	.724
12					.7819	.6964	.8954
13					.7819	.6802	.8192
14	.0191	.0191	.0189	.0191	.7876	.6964	.7621
15	.0191	.0191	.0189	.0191	.7095	.6802	.7811
16	.0191	.0191	.0189	.0191	.6687	.7125	.8192
17	.0191		.0189	.0381	.7253	.7537	.8192
18	.0191	.0377	.0189	.0381	.0191	.0377	.0381
19	.0381	.0377	.0189	.0762	.0335		.0381
20	.0572	.0377	.0377	.0572	.0381	.0377	.0572
21	.0377	.0377	.0377	.0762	.0381	.0377	.0762
22	.0381	.0377	.0377	.0762	.0381	.0377	.0762
23	.0381	.0191	.0377	.0953	.0381	.0377	.0762
24	.381	.1635	.1326	.1802	.0381	.0381	.0377
Max	.8002	.8482	.8855	.7125	.8025	.7537	.8954
Min	.0191	.0191	.0189	.0191	.0191	.0377	.0377
Avg	.2953	.2182	.2007	.2264	.3378	.3196	.3589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 205 / 11 KV NANDAR AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953		.1132	.0943	.8573	.7811	.4588
2	.1143		.1132	.0943	.9145	.7727	.639
3	.1143		.1132	.0754	.9907	.8025	.7373
4	.0953		.1132	.0754	1.0288	.8109	.8356
5					1.105	.8619	1.004
6					1.1812	.9659	1.0526
7					1.2193	1.3603	1.4575
8					1.3146	1.5074	1.5546
9					1.3717	1.0031	1.4413
10	1.7532		1.4575	1.7147	.1524	.4161	
11	1.6598	1.6164	1.5708	1.9243			
12	1.709	1.7654	1.7976	2.0005			
13	1.7532	1.7185	1.8623	2.0576			
14	.3681	1.656	1.8299	2.0957	.0191	.0189	.0381
15	1.5901	1.7236	1.8138	2.1719	.0191	.0189	.0381
16	1.6347	1.6716	1.7976	2.2862	.0191	.0189	.0381
17	1.5638	1.6821	1.7652	2.0957	.0191	.0189	.0572
18	.112	.0754	.0754	.0572	.0754	.0377	.0572
19	.132	.1307	.0754	.0572	.0762	.0377	.0572
20	.112	.1494	.0732	.0762	.0838	.0377	.0762
21	.112	.1307	.0754	.0762	.0754	.0377	.0762
22	.1132	.132	.0754	.0762	.0566	.0377	.0762
23	.1006	.132	.0943	.0953	.0549	.0377	.0953
24	.0953		.132	.0943	.8192	.7727	.3605
Max	1.7532	1.7654	1.8623	2.2862	1.3717	1.5074	1.5546
Min	.0953	.0754	.0732	.0572	.0191	.0189	.0381
Avg	.6962	.9680	.7868	.9062	.5454	.4932	.5076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 206 / 11 KV GFSS-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3048	.3018	.2949	.381	.2606	.3441
2	.4382	.3521	.3149	.3441	.4382	.2378	.3768
3	.5335	.3567	.3481	.3768	.4954	.2743	.4096
4	.6097	.5079	.3932	.5243	.724	.4062	.5182
5	.9145	.5639	.5898	.6882	.9717	.7042	.6964
6	1.1812	1.0364	.9555	1.004	1.2384	.9297	.9555
7	1.3717	1.1405	1.2498	1.2146	1.2955	1.1797	1.1498
8	1.2955	1.1043	.9804	1.166	1.1812	1.1279	
9	1.2384	1.0159	.9231	1.1012	1.086	.9686	.5898
10			.5898	1.1241	.5407	.5761	.8002
11	.5487	.5344	.4096	.9145	.3864	.4588	.6097
12	.4161		.3605	.7811	.3481	.3932	.4572
13	.3841	.2949		.6859	.3041	.3277	.4001
14	.3593	.2915		.6097	.2972	.3441	.381
15		.3201	.3605	.5335	.2572	.3441	.4572
16	.4049		.5281	.4763	.3567	.4096	.4763
17	.5647	.502	.4858	.3429	.4877	.4588	.5525
18	.7343	.6562	.6718	.4763	.5201	.639	.6287
19	.9602	.9878	.8421	.6097	.8535	.9555	.7621
20	.7108	.7042	.6802	.7621	.7727	.7773	.8002
21	.4801	.4534	.4752	.5906	.4687	.5243	.7049
22	.4001	.3725	.4096	.4954	.4191	.4588	.5335
23	.3353	.3077	.3605	.4191	.3418	.3932	.4001
24	.4001	.3125	.2984	.3277	.381	.2972	.3605
Max	1.3717	1.1405	1.2498	1.2146	1.2955	1.1797	1.1498
Min	.3353	.2915	.2984	.2949	.2572	.2378	.3441
Avg	.6673	.5771	.5695	.6610	.6061	.5603	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 207 / 11 KV GFSS-II FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.1989	.2012	.2785	.3429	.1738	.2785
2	.3048	.2294	.218	.3113	.4001	.208	.3113
3	.4001	.2915	.2515	.3441	.5144	.2675	.3441
4	.4572	.4049	.3149	.4588	.5525	.3715	.4588
5	.6668	.5121	.5182	.5079	.6097	.4904	.5243
6	.8764	.6874	.7935	.6718	.8383	.6036	.6554
7	.9907	.9145	.8697	.8848	.8002	.8962	.8745
8	.9145	.8535	.8381	.8029	.7621	.8322	.7773
9	.8573	.7343	.664	.664	.7621	.6249	.6882
10	.4161	.4725	.5407	.6668		.4531	.724
11	.2721	.3041	.3113	.5716	.2229		.4572
12	.1833	.1943	.2458	.4572	.1981	.2458	.381
13	.1692	.1619	.1966	.3429	.1646	.1966	.3048
14	.1646	.1638	.1802	.3429	.1783	.1802	.2667
15	.1829	.1638	.1638	.3048	.1593	.1966	.3048
16	.1966	.1844	.2458	.381	.1734	.2458	.2858
17	.3201	.2458	.3113	.4382	.2591	.2785	.3048
18	.4572	.421	.5243	.5144	.333	.5079	.4572
19	.6241	.7042	.6718	.6097	.578	.6554	.5335
20	.4725	.4902	.5243	.5716	.4359	.6226	.6097
21	.3041	.3239	.3441	.381	.3395	.5243	.4191
22	.2439	.2753	.3277	.3429	.2591	.4588	.381
23	.1974	.2321	.3113	.2858	.2229	.3605	.2858
24	.2858	.2012	.218	.2949	.2858	.2187	.3113
Max	.9907	.9145	.8697	.8848	.8383	.8962	.8745
Min	.1646	.1619	.1638	.2785	.1593	.1738	.2667
Avg	.4268	.3902	.4078	.4762	.4084	.4180	.4558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 201 / 11KV NATH MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9619		.7522	.7682	.7888	.8413	.9054
2	.9431		.7602	.7682	.7802	.823	.8676
3	.9054		.7783	.8048	.8063	.8596	.9054
4	.9149		.8048	.8596	.8596	.8779	.9522
5	1.0164		.8413	.8962	.9877	1.0242	1.0456
6	1.1088		.9335	.9877	1.1203	1.1706	1.1458
7	1.2752		1.0642	1.0425	1.1949	1.2437	1.1827
8	1.134		.9709	1.0974	1.0349	1.1157	1.1157
9	1.1157		.8686	1.0425		1.0425	.9511
10	.9511	.9145	.9145	.9511	.9979	1.0059	.9511
11	.905	.8413	.8779	.9877	.9145	.9412	.8048
12	.905	.7865	.8145	.9231	.8596	.8507	.8326
13	.7421	.8048	.7783	.8326	.8596	.8688	.8413
14	.7783	.7499	.7602	.8413	.7602	.8507	.823
15	.8326	.6767	.8413	.8145		.8326	.8145
16	.8326	.7682	.9145	.7802	1.0608	.905	.8326
17	.8238	.7973	.8962	.9114	.9511	.9145	.8596
18	1.0867			1.0867	1.1706	.9877	.9145
19	1.2934	1.2894	1.0791	1.2894	1.3535	1.2382	1.3121
20	1.262	1.2489	1.2803	1.1999	1.3169	1.4415	1.423
21	1.0517	1.1104	1.262	1.1218	1.134	1.2752	1.2012
22		1.0136	1.0791	1.1163	1.0974	1.1576	1.1283
23	.9214	.9774	.9694	1.0454	.9877	1.0456	.9922
24	.9431	.8859	.8145	.8413	.8764	.9328	.9431
Max	1.2934	1.2894	1.2803	1.2894	1.3535	1.4415	1.423
Min	.7421	.6767	.7522	.7682	.7602	.823	.8048
Avg	.9871	.9189	.9155	.9587	.9960	1.0103	.9894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 204 / 11 KV OPEN JAIL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0934	.0914	2.4615	2.4129	1.9044
2	.0754		.0934	.0914	2.4615	2.4453	2.0729
3	.0754		.112	.0914	2.4291	2.4615	2.17
4	.0754		.112	.0914	2.4453	2.4129	2.251
5	.0943		.112	.0732	2.3967	2.251	2.17
6	.0754		.112	.0549	2.4905	2.5587	2.251
7	.0754		.112	.0732	2.8673	2.5749	2.3922
8	.0754		.112	.0732	2.8837	2.5911	2.4413
9	.0754		.0934	.1097	2.8841	2.5263	2.4741
10	.0884	.2012	3.4311	3.4642	.0754	.0377	.0566
11	.1326	.2561	.1326	3.2985	.0566	.0377	.0377
12	.1326	.2561	.1326	3.4974	.0377	.0377	.0377
13	.1658	.2561	.1768	3.3482	.0377	.0377	.0377
14	.1658	.2561	.1658	3.3979	.0377	.0377	.0377
15	.1437	2.2186	3.0769	3.4808		.0377	.0377
16	.1768	2.8502	3.3198	3.4244	.0377	.0377	.0377
17	.1684	2.9656	3.4494	3.2278	.0732	.0566	.0377
18	.0747	.0924	.0732	.056	.0732	.0754	.0566
19	.0934	.0914	.0732	.0934		.1132	.0943
20	.0934	.112	.0732	.1063	.0732	.1132	.0943
21	.0934	.112	.0732	.112	.0732	.1132	.0754
22		.112	.0732	.0934	.0732	.0754	.0924
23	.0934	.1307	.0732	.112	.0732	.0754	.0934
24	.0754	.0739	.0934	.0914	2.4453	2.1862	2.0005
Max	.1768	2.9656	3.4494	3.4974	2.8841	2.5911	2.4741
Min	.0747	.0739	.0732	.0549	.0377	.0377	.0377
Avg	.1055	.6656	.6404	1.1897	1.2040	1.0545	.9564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 205 / 11 KV CHANGATPURI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375		1.3748	1.4575	.0732	.0914	.1132
2	1.6766		1.406	1.5223	.0732	.0914	.1132
3	1.7284		1.5023	1.4575	.0739	.0914	.1132
4	1.7901		1.531	1.6194	.0732	.0914	.1132
5	1.8122		1.6762	1.749	.0732	.0914	.1132
6	2.0557		1.7166	1.7652	.0924	.0732	.1132
7	2.3525		2.0891	2.2672	.0934	.1097	.1132
8	2.9172		2.1376		.1109	.1097	.0754
9	2.2672		2.1052	2.2996	.1132	.1097	.0754
10	.1132				2.251	2.5888	2.3365
11	.0754	.0549	.0566		2.4577	2.6707	2.8841
12	.0943	.0549	.0943		2.6189	2.8841	2.8344
13	.0943	.0732	.0943		2.9338	2.9508	2.8841
14	.0566	.0732	.0943		2.7681	2.8509	2.9007
15	.0377	.0732	.0943			2.8178	2.8178
16	.0566	.0549	.0732		2.7018	2.8841	2.7681
17	.0732	.0732	.0549		2.4291	2.8178	2.8012
18	.0732	.0914	.0732		.1097	.132	.0754
19	.0914	.1097	.0732	.0732	.1097	.1509	.132
20	.0549	.1086	.0732	.0732	.1097	.132	.1698
21	.0549	.1097	.0914	.0724	.1097	.132	.1132
22		.112	.1097	.0914	.1097	.1132	.0934
23	.1463	.0905	.1097	.0905	.1097	.1132	.0934
24	1.6156	1.174	1.3108	1.3765	.0732	.1097	.1132
Max	2.9172	1.174	2.1376	2.2996	2.9338	2.9508	2.9007
Min	.0377	.0549	.0549	.0724	.0732	.0732	.0754
Avg	.9120	.1610	.7801	1.1368	.8551	1.0086	.9984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 206 / 11kV Telwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.112	.1097	1.3748	1.3603	1.2963
2	.1132		.112	.1097	1.3592	1.3441	1.3889
3	.1132		.112	.128	1.3916	1.3441	1.4043
4	.1132		.112	.128	1.3916	1.3603	1.4506
5	.1132		.112	.1097	1.4074	1.5181	1.5154
6	.132		.1307	.128	1.5061	1.7814	1.7029
7	.132		.1307	.128	1.7328	1.8138	1.7869
8	.1132		.1307	.128	1.7764	1.8138	1.7497
9	.0943		.112	.128	1.7976	1.7976	1.7869
10	2.1445	1.8461	1.9845		.0943	.1132	.0566
11	2.5888	2.0891	2.1538		.0754	.1132	.0566
12	2.5425	2.1538	2.3266	1.8947	.0566	.0943	.0566
13			2.3868	1.3889	.0943	.0754	.0566
14		2.2672	2.3868		.0754	.0754	.0566
15	2.7018	2.2348	2.2672	1.358		.0754	.0566
16	2.7199	2.251		1.4864	.0754	.0943	.0566
17	2.5232	2.2186		1.866	.0732	.1132	
18	.132	.1097		.112	.0732	.132	
19	.1494	.128		.1307	.0732	.1886	
20	.1307	.128	.1097	.1307	.128	.1698	.132
21	.1307	.1307	.1097	.1307	.0732	.1698	.1132
22		.1147	.128	.112	.0732	.132	.1307
23	.1494	.1086	.128	.1132	.1097	.132	.0934
24	.1132	.0934	.112	.1097	1.3904	1.247	1.2037
Max	2.7199	2.2672	2.3868	1.8947	1.7976	1.8138	1.7869
Min	.0943	.0934	.1097	.1097	.0566	.0754	.0566
Avg	.8126	1.1338	.7579	.4729	.7045	.7108	.7691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 207 / 11kV Nath Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0171	.0183	.0175	.0183	.0189
2	.0189		.0171	.0183	.0171	.0183	.0189
3	.0189		.0187	.0183	.0171	.0183	.0189
4	.0189		.0175	.0183	.0171	.0183	.0189
5	.0189		.0175	.0183	.0171	.0732	.0189
6	.0189		.0175	.0183	.0175	.0183	.0189
7	.0189		.0175	.0183	.0173	.0183	.0189
8	.0189		.0175	.0183	.0173	.0183	.0189
9	.0189		.0173	.0183	.0189	.0183	.0189
10	.0189	.0183	.0189	.0189	.0189	.0189	.0189
11	.0189	.0183	.0189	.0189	.0189	.0189	.0189
12	.0189	.0183	.0189	.0189	.0189	.0189	.0189
13	.0189	.0183	.0189	.0189	.0189	.0189	.0189
14	.0189	.0183	.0189	.0189	.0189	.0189	.0189
15	.0189	.0183	.0189	.0189		.0189	.0189
16	.0189	.0183	.0183	.0171	.0189	.0189	.0189
17	.0173	.0171	.0183	.0171	.0183	.0189	.0189
18	.0175		.0183	.0175	.0183	.0189	.0189
19	.0173	.0175	.0183	.0175	.0183	.0189	.0189
20	.0171	.0175	.0183	.0187	.0183	.0189	.0189
21	.0187		.0183	.0171	.0183	.0189	.0189
22		.0171	.0183	.0171	.0183	.0189	.0171
23	.0171	.0175	.0183	.0171	.0183	.0189	
24	.0189		.0171	.0183	.0171	.0183	.0189
Max	.0189	.0183	.0189	.0189	.0189	.0732	.0189
Min	.0171	.0171	.0171	.0171	.0171	.0183	.0171
Avg	.0185	.0179	.0181	.0182	.0181	.0209	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 208 / 11kV Urban Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547		.4755	.4938	.5304	.5304	.547
2	.547		.4938	.4938	.5304	.5304	.5658
3	.5847		.5914	.4938	.5788	.5853	.6224
4	.6602		.724	.7682	.6908	.695	.7167
5	1.0642		1.0456	1.0608	1.0082	1.0242	1.0829
6	1.5708		1.475	1.5181	1.4377	1.5546	1.6078
7	1.6817		1.7924	1.6278	1.7551	1.7375	1.7926
8	1.5893		1.6991	1.701	1.587	1.5546	1.6078
9	1.39		1.419	1.5364	1.386	1.39	1.3352
10	.9979	1.1157	.9877	1.4632	.9328	1.1157	.8779
11	.7499	.8048	.6584	1.3535		.7499	.6335
12	.5611	.6584	.5792	1.134	.6036	.6335	.5973
13	.5249	.6036	.543	.9145	.543	.5611	.5973
14	.5249	.5304	.5249	.724	.4887	.543	.5792
15	.543	.5121	.4887	.6154		.5068	.543
16	.5853	.5304	.567	.6036	.5792	.5611	.6219
17	.7499	.695	.6401	.7023	.6036	.6401	
18	.9709	.9425	1.0608	.8131	.8962	.8686	1.0059
19		1.4045	1.2986	.9709	1.2803	1.3676	1.5154
20	1.1203	1.2136	1.0974	.8775	1.2254	1.2012	1.251
21	.8402	.7842	.7865	.691	.7133	.8589	.8775
22		.6099	.6584	.7207	.6584	.7282	.6908
23	.8316	.5228	.5487	.5975	.567	.6161	.5914
24	.5658	.5487	.4854	.4938	.5487	.5304	.5847
Max	1.6817	1.4045	1.7924	1.701	1.7551	1.7375	1.7926
Min	.5249	.5121	.4755	.4938	.4887	.5068	.543
Avg	.8728	.7651	.8600	.9320	.8702	.8785	.9063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 209 / 11KV GHARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7901		1.6404	1.8461	.0905	.0914	.0943
2	1.7747		1.6404	1.8299		.0914	.0943
3	1.8056		1.656	1.8623	.1097	.0914	.0943
4	1.8519		1.7078	1.8623	.1097	.0914	.0943
5	1.8519		1.7394	1.8461	.1267	.0914	.0943
6	1.9372		1.7814	1.8947	.1294	.0914	.0943
7	2.2653		2.1214	2.17	.1307	.1097	.0943
8	2.4615		2.2996	2.251	.1307	.128	.0754
9	2.0805		2.2447	2.17	.132	.128	.0754
10	.0566	.0732	.0377	.0754	2.3922	2.6216	2.5069
11	.0566	.0549		.0566	2.5692	2.7035	2.8178
12	.0566	.0549	.0377	.0377	2.6852	2.7362	3.0498
13	.0566	.0549	.0377	.0377	2.7018	2.9338	2.9007
14	.0566	.0549	.0377	.0566	2.6852	2.9338	2.7018
15	.0566	.0549	.0943	.0754		2.9504	2.967
16	.0566	.0549	.0549	.0747	2.7349	2.9504	2.9504
17	.0549	.056	.0549	.0747	2.672	2.6355	2.4697
18	.0549	.056	.0549	.0934	.0914	.0943	.0377
19		.0549	.0549	.0934	.0914	.0943	.0754
20	.0739	.0934	.1097	.1075	.0914	.0943	.0754
21	.0747	.0934	.1097	.1086	.0549	.0943	.0754
22		.0747	.0732	.0732	.0549	.0754	.0747
23	.0732	.0739	.0732	.0914	.0732	.0754	.056
24	1.7901	1.656	1.6091	1.8299	.0905	.0914	.0566
Max	2.4615	1.656	2.2996	2.251	2.7349	2.9504	3.0498
Min	.0549	.0549	.0377	.0377	.0549	.0754	.0377
Avg	.9244	.1707	.8379	.8591	.9067	.9999	.9844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 201 / 11KV DHORKIN GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.1886	.1886	.2801	.1886	.1886	.2987
2	.2987	.1886	.1886	.2801	.1886	.1886	.2987
3	.3734	.1886	.1886	.3734	.1886	.1886	.3734
4	.5041	.3772	.3772	.4668	.1886	.3772	.4668
5	.5975	.5658	.5658	.5601	.2829	.5658	.6161
6	.8215	.7545	.7545	.7468	.5658	.6602	.7842
7	.8029	.7545	.8488	.7842	.6602	.7545	.7468
8	.7468	.7545	.6602	.7468	.6602	.6535	.7095
9	.5601	.6535	.6535	.6348	.5601	.5601	.5975
10	.4668	.4668	.4668	.5601	.3734	.4668	.4481
11	.3734	.3734	.3734	.4668	.3734	.3772	.3734
12	.2801	.2801	.3361	.3734	.2801	.3772	.2987
13	.2801	.2801	.3174	.2801	.2801	.2829	.2801
14	.2801	.2801	.2987	.2801	.2801	.2987	.2987
15	.2801	.2801	.2987	.2801	.2801	.3361	.2987
16	.2801	.2801	.2987	.2801	.2801	.3734	.3734
17	.3734	.3734	.3361	.3734	2.838	.4294	.3734
18	.5601	.4668	.4668	.4668	.4668	.5601	.4668
19	.6602	.4715	.6161	.5658	.5658	.6722	.7468
20	.5658	.5658	.5601	.4715	.4715	.6535	.8402
21	.3772	.3772	.4294	.3772	.3772	.4481	.4668
22	.3772	.2829	.3734	.3772	.3772	.3921	.4668
23	.2829	.2829	.3361	.2829	.3772	.3361	.3734
24	.3361	.1886	.6602	.2987	.1886	.1886	.2987
Max	.8215	.7545	.8488	.7842	2.838	.7545	.8402
Min	.2801	.1886	.1886	.2801	.1886	.1886	.2801
Avg	.4491	.4032	.4414	.4420	.4706	.4304	.4707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 202 / 11KV DHORKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4214	.3048	.3048	.381	.1905	.1905	.1334
2	.4214	.3048	.3048	.381	.1905	.1905	.1334
3	.4515	.3048	.3048	.3963	.1905	.1905	.1143
4	.4666	.381	.4904	.4268	.1905	.1905	.1143
5	.4816	.4115	.3963	.4877	.1905	.1905	.1143
6	.602	.4572	.442	.5639	.1905	.1905	.1524
7	.873	.7316	.7316		.1905	.0762	
8	1.0084	.8383	.8993	.1981			
9	.9031	.8688	.8078	.1829			
10					.8688	.8383	.8905
11					1.1431	.9145	1.0155
12					1.1431	.9602	1.0936
13					1.0669	.9145	1.1469
14					.7621	.8962	.9686
15					.9602	.9602	.9804
16					1.0517	1.0402	1.0311
17					.9755	1.0402	.9998
19	.1524	.1698	.2096	.2096	.1905	.1715	.0934
20	.1524	.1715	.1524	.1905	.1905	.1905	.2241
21	.2096	.1715	.1715	.1905	.1905	.1905	.2241
22	.3429	.1715	.1715	.1905	.1905	.1905	.1867
23	.2096	.1715	.1524	.1905	.1905	.1715	.1867
24	.3913	.3048	.2286	.3506	.1905	.1905	.1524
Max	1.0084	.8688	.8993	.5639	1.1431	1.0402	1.1469
Min	.1524	.1698	.1524	.1829	.1905	.0762	.0934
Avg	.4725	.3842	.3845	.3100	.4975	.4709	.4978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 203 / 11KV KARKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0566	.0747	.1372	.1524	.1235
2	.0747	.0754	.0566	.0747	.1372	.1524	.1235
3	.0747	.0754	.0566	.0747	.1372	.1905	.1391
4	.0747	.0754	.0943	.0934	.1372	.1524	.1391
5	.0747	.0754	.0754	.0934	.1372	.1905	.1113
6	.0934	.0943	.0754	.0934	.1524	.1981	.1858
7		.1132	.1132		.2439	.5182	.4344
8		.1132	.0943		.2743	.5201	.5569
9		.0754			.2317	.4161	.3909
10	.3001	.1593	.2172	.2229			
11	.4199	.2896	.5228	.3864			
12	.4054	.362	.4199	.4054			
13	.4489	.3765	.4054	.4458			
14	.4633	.431	.4144	.4161			
15	.4489	.4012	.3338	.3475			
16	.3765	.4161	.4054	.3185			
17	.3041	.4904	.4371	.4458			
19	.0377	.0754	.0747	.0754	.1132	.0876	.0747
20	.0943	.0754	.0747	.0566	.0943	.0934	.0934
21	.0943	.0754	.0747	.0566	.0754	.0934	.0934
22	.0943	.0754	.0747	.0566	.0762	.0934	.0934
23	.0943	.0754	.0747	.0572	.0754	.0934	.0934
24	.0739	.0754	.0754	.0747	.1524	.1524	.1235
Max	.4633	.4904	.5228	.4458	.2743	.5201	.5569
Min	.0377	.0754	.0566	.0566	.0754	.0876	.0747
Avg	.2061	.1805	.1922	.1935	.1450	.2070	.1851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 204 / 11KV DHANGAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.4746	1.4746	1.406	.0754	.0754	.0747
2	1.6194	1.4746	1.4746	1.406	.0754	.0566	.0747
3	1.668	1.4746	1.4746	1.4217	.0754	.0754	.0934
4	1.7004	1.5565	1.4746	1.439	.0754	.0754	.0934
5	1.7328	1.5729	1.5238	1.4723	.0754	.0754	.0934
6	1.9433	1.8187	1.6876	1.4883	.0754	.0754	.0934
7	2.2939	2.452	1.9006	1.7604	.0754	.0754	
8	2.4249	2.1792	2.0481	1.8724			
9	2.2939	1.8679	1.8244	1.8299			
10					2.0317	2.1956	2.2119
11					2.343	2.4577	2.4577
12					2.3758	2.5396	2.4905
13					2.2939	2.4577	2.5396
14					2.4741	2.332	2.4905
15					2.4249	2.2996	2.4577
16					2.5396	2.2834	2.4577
17					2.4905	2.2348	2.3758
19	.0943	.0943	.0373	.0566	.0943	.0905	.0934
20	.0943	.0943	.0747	.0566	.0943	.0934	.0934
21	.0943	.0754	.112	.0566	.0754	.0934	.0934
22	.0943	.0754	.112	.0754	.0754	.0934	.0934
23	.0943	.0754	.0934	.0754	.0754	.0934	.0934
24	1.6385	1.6385	1.4746	1.406	.0754	.0754	.0934
Max	2.4249	2.452	2.0481	1.8724	2.5396	2.5396	2.5396
Min	.0943	.0754	.0373	.0566	.0754	.0566	.0747
Avg	1.2937	1.1950	1.1191	1.0548	.9520	.9452	1.0282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.132	.0754	.0914	.0754	.1509	.1307
2	.0924	.132	.0754	.0914	.0943	.1509	.1307
3	.0924	.1509	.0754	.1109	.0943	.1509	.1494
4	.0895	.1886	.0754	.1109	.0943	.1509	.1494
5	.0924	.0566	.0754	.1307	.0943	.0943	.1307
6	.0924	.0566	.0754	.1307	.0943	.0943	.1494
7	.0924	.0377	.0754	.0914	.0566	.1886	.0895
8	.0924	.0566	.0754	.1109	.0754	.0934	.0655
9	.1494	.112	.056	.1698	.1494	.112	.0905
10	.1307	.0747	.056	.1698	.1494	.1494	.0747
11	.1307	.0747	.0429	.1494	.1867	.1509	.112
12	.1307	.0747	.0423	.168	.1494	.1509	.168
13	.1307	.0747	.0412	.168	.1494	.0943	.1867
14	.1307	.0747	.04	.1307	.1494	.0762	.2241
15	.1867	.056	.0457	.168	.1307	.1132	.2801
16	.168	.0934	.0452	.168	.2241	.1334	.1867
17	.1867	.056	.0457	.168	.2054	.1715	.2241
18	.1867	.056	.0469	.1307	.168	.1524	.168
19	.0132	.0566	.0747	.132	.1886	.112	.2801
20	.132	.0566	.0732	.1886	.1509	.0732	.2427
21	.2075	.0754	.0732	.0754	.1509	.0671	.4108
22	.132	.0754	.0732	.0762	.1509	.1307	.1867
23	.0377	.0754	.0732	.0754	.1509	.112	.1867
24	.0924	.0377	.0754	.0732	.0754	.1509	.1307
Max	.2075	.1886	.0754	.1886	.2241	.1886	.4108
Min	.0132	.0377	.04	.0732	.0566	.0671	.0655
Avg	.1201	.0806	.0628	.1283	.1337	.1260	.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 211 / NANDALGAON AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1524	.1524	.1505
2					.381	.1524	.1505
3					.1524	.2829	.1806
4					.1524	.3048	.1957
5					.1524	.08	.2258
6					.2439	.3658	.2709
7					.4115	.6249	.6472
8					.4877	.6401	.6472
9					.4572	.5487	.587
10	.3763	.3906	.4572	.4967			
11		.6562	.6171	.6562			
12	.5944	.6562	.6923	.6706			
13	.6401	.7811	.6321	.703		.2452	
14		.7811	.5719	.6718			
15		.5937	.5719	.6401			
16		.5937	.6472	.6718			
17	.6859	.5487	.5418	.6706			
24						.1524	.1505
Max	.6859	.7811	.6923	.703	.4877	.6401	.6472
Min	.3763	.3906	.4572	.4967	.1524	.08	.1505
Avg	.5742	.6252	.5914	.6476	.2879	.3227	.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 212 / 11KV KARKIN GAOTHAN FEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1886	.1886	.2614	.1886	.1886	.2801
2	.2801	.1886	.1886	.2614	.1886	.1886	.2801
3	.3734	.1886	.1886	.3361	.1886	.3772	.3734
4	.4294	.3772	.1886	.3734	.1886	.3772	.4668
5	.4668	.5847	.5658	.4668	.3772	.4715	.5601
6	.6161	.6979	.7356	.5975	.4904	.6224	.6908
7	.5975	.7167	.7733	.7095	.6036	.7733	.7468
8	.7095	.679	.679	.6722	.4527	.7468	.6348
9	.5601	.6161	.5975	.6722	.4294	.5601	.5041
10	.4108	.3921	.4668	.5601	.3361	.4294	.3734
11		.2614	.2614	.4854	.2801	.3018	.2427
12	.168	.2427	.2427	.3361	.2614	.2263	.1867
13	.2241	.1867	.2241	.2801	.2614	.2427	.1867
14	.2241	.1867	.1867	.2801	.2241	.2241	.2241
15	.2241	.1867	.2241	.2614	.2427	.2427	.2241
16	.2241	.2241	.2427	.2801	.2427	.2801	.2801
17	.3361	.3174	.6722	.3361	.3361	.3361	.3734
18	.5228	.4481	.4108	.4481	.4668	.3921	.4668
19	.6413	.5281	.5788	.5658	.5658	.5415	.6535
20	.547	.5658	.5041	.4527	.415	.5415	.5601
21	.3772	.3395	.3734	.3772	.3772	.3921	.4108
22	.3395	.3018	.3361	.3206	.3772	.3547	.3361
23	.3395	.2641	.2987	.2829	.2829	.3174	.3361
24	.2801	.1886	.1886	.2801	.1886	.1886	.2801
Max	.7095	.7167	.7733	.7095	.6036	.7733	.7468
Min	.168	.1867	.1867	.2614	.1886	.1886	.1867
Avg	.3988	.3696	.3882	.4124	.3319	.3882	.4030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 201 / 11KV Ranjangaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.3086	.3048	.2401	.3258	.3048
2	.3048	.3086	.3086	.3048	.2743	.3258	.3048
3	.3048	.3086	.3086	.3048	.2743	.3429	.3048
4	.3658	.3772	.3772	.3658	.3429	.5068	.3963
5	.6401	.8402	.7059	.6401	.7716	.7392	.6401
6	.7926	.9945	1.0164	.823	.9259	1.0829	.823
7	.7468	1.0117	.9896	.8688	1.0117	1.0269	.884
8	.6706	.8916	.8871	.7773	.8916	.8871	
9	.6097	.5144	.8501	.7773	.7545	.8686	
10	.6001	.543	.5182	.8402	.5973	.5335	.4973
11	.5144	.4706	.3506	.4973	.3506	.3963	.4801
12	.4287	.3772	.3201	.4287	.3429	.3506	.4115
13	.3601	.3429	.2591	.3772	.3258	.3353	.3429
14	.3086	.2896	.2591	.3086	.3086	.3353	.3086
15	.2915	.3601	.2591	.3258	.3601	.3353	.2915
16	.3258	.3944	.3048	.3601	.4163	.3353	.3429
17	.4115	.5249		.4287	.5249	.4115	.4801
18	.6344	.6697	.5335	.6516	.6154	.6249	.7716
19	.7716	.8686	.7468	.7545	.924	.7926	.9088
20	.6859	.6335	.5487	.6001	.6335	.6401	.6859
21	.4801	.4887	.4268	.5144	.5068	.4725	.4801
22	.4287	.3944	.3658	.4458	.4525	.3658	.3944
23	.3772	.3429	.3353	.3772	.3601	.3506	.3601
24	.3048	.3429	.3258	.3201	.2915	.3429	.3353
Max	.7926	1.0117	1.0164	.8688	1.0117	1.0829	.9088
Min	.2915	.2896	.2591	.3048	.2401	.3258	.2915
Avg	.4860	.5264	.4916	.5165	.5207	.5304	.4886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 202 / Marhola

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1067	.1029	.1219	.7316	.5639	.6401
2	.1372	.1067	.1029	.1219	.7316	.5639	.6401
3	.1372	.1219	.1029	.1219	.7621	.5792	.6401
4	.1372	.1524	.12	.1372	.7773	.6097	.7011
5	.1829	.1829	.1886	.1524	.7773	.6401	.7926
6	.2439	.1829	.2229	.1829	.823	.6859	.9145
7	.2896	.2134	.2401	.2134	.8535	1.0822	1.0669
8			.2058	.1829	.9755	1.1888	
9		.1677	.1715	.1829	.945	1.0974	
10	.9602	.7926	.9145	1.0212	.1372	.1372	.0914
11	.9907	.8535	1.0669	1.0669	.1029	.0914	.0914
12	1.0059	.8535	1.1736	1.0669	.1029	.0914	.0762
13	1.0364	.9061	1.0669	1.1126	.1029	.1067	.0762
14	1.0059	.9145	1.0669	1.1279	.12	.1067	.0762
15	1.0364	.9602	1.0669	1.0974	.1372	.1067	.0762
16	.9755	.9907	1.0669	1.1279	.12	.1067	.0914
17	.945	1.0212	1.0212	1.0974	.1029	.1219	.0914
18	.0914	.0857	.0914	.1524	.12	.1524	.1372
19	.1067	.1886	.1677	.2134	.1886	.1677	.1677
20	.1219	.1715	.1677	.1677	.1524	.1677	.1524
21	.1219	.12	.1524	.1219	.1219	.1372	.1372
22	.1067	.1029	.1372	.1372	.1372	.1219	.1219
23	.0914	.1029	.1219	.1372	.12	.1219	.1067
24	.1372	.1067	.1029	.1067	.6859	.5487	.6401
Max	1.0364	1.0212	1.1736	1.1279	.9755	1.1888	1.0669
Min	.0914	.0857	.0914	.1067	.1029	.0914	.0762
Avg	.4545	.4089	.4518	.4655	.4095	.3874	.3422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 203 / Shekta

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.3658	.3658	.2743	.0305	.0514	.0572
2	.3963	.3658	.3658	.2743	.0305	.0514	.0572
3	.3963	.381	.3506	.2743	.0305	.0514	.0572
4	.3963	.381	.3506	.2743	.0457	.0514	.0572
5	.3963	.4115	.3658	.3048	.0457	.0686	.0572
6	.4268	.4115	.3658	.3658	.061	.0686	.0572
7	.4877	.4268	.381	.4268	.0762	.0686	.0572
8	.4877	.442	.3658	.4268	.0762	.0857	
9	.4268	.442	.3506	.3353	.0762	.0514	
10	.0457	.0857	.0381	.061	.2896	.442	.3658
11	.0305	.0343	.0572	.0457	.381	.503	.3963
12	.0305	.0343	.0572	.0457	.442	.5182	.4268
13	.0305	.0343	.0572	.0305	.4268	.4725	.4572
14	.0152	.0343	.0572	.0305	.4572	.4572	.4877
15	.0152	.0514	.0572	.0305	.4877	.4572	.5182
16	.0305	.0514	.0572	.0305	.4877	.4572	.4877
17	.0305	.0514	.0572	.0305	.4725	.4115	.4725
18	.0457	.0514	.061	.0457	.0514	.0572	.0457
19	.061	.1029	.0762	.061	.0857	.0953	.0762
20	.061	.0686	.0762	.0457	.0857	.0762	.0762
21	.0457	.0514	.0572	.0457	.0686	.061	.0914
22	.0457	.0514	.0572	.0457	.0686	.0572	.0762
23	.0457	.0514	.0572	.0457	.0514	.0572	.0762
24	.3963	.3201	.3201	.2743	.0305	.0514	.0572
Max	.4877	.442	.381	.4268	.4877	.5182	.5182
Min	.0152	.0343	.0381	.0305	.0305	.0514	.0457
Avg	.1975	.1959	.1836	.1594	.1816	.1968	.2051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 204 / AURANGPURWADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2498	1.3603	1.2803	.1829	.1677	.2286
2	1.2803	1.2498	1.3592	1.2803	.1524	.1677	.2286
3	1.2803	1.2803	1.3904	1.2803	.1524	.1677	.2286
4	1.3108	1.3108	1.4723	1.3108	.1677	.1829	.2439
5	1.3717	1.3565	1.5524	1.3717	.1677	.1981	.2439
6	1.5546	1.5546	1.6324	1.4937	.1829	.2134	.2439
7	1.7375	1.8442	2.1285	1.8138	.1981	.2591	.3048
8	2.0424	1.9966	2.1285	1.768	.2134		
9	1.829	1.7833	1.8404	1.5851	.2134		
10	.1372	.1677	.1219	.1677	1.6484	2.0271	1.7375
11	.1372	.1524	.1219	.1677	2.1052	2.0576	1.768
12	.1219	.1372	.1067	.1524	2.2186	2.1795	1.8138
13	.1219		.0914	.1524	2.251		1.829
14	.1219		.0914	.1372	2.2672	2.2558	1.8138
15	.1219		.0914	.1524	2.2996	2.332	1.7985
16	.1524		.0914	.1981	2.2348	2.2253	1.8442
17	.1981		.1372	.2286	2.1214	2.21	1.89
18	.1829		.1981	.2286	.1981		.2134
19	.1829	.1981	.1829	.2286	.2439		.2439
20	.1981	.2134	.1829	.2286			
21	.1981	.2134	.1829	.2286			
22	.1829	.1829	.1829	.2134	.1829	.2286	.2286
23	.1829	.1677	.1829	.1829	.1677	.2286	.2439
24	1.2803	1.2193	1.2498	1.2651	.1829	.1677	.2286
Max	2.0424	1.9966	2.1285	1.8138	2.2996	2.332	1.89
Min	.1219	.1372	.0914	.1372	.1524	.1677	.2134
Avg	.7170	.9043	.7533	.7132	.8978	1.0158	.8688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 205 / DARGHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0152	.0152	.0305			1.4937
2	.0191	.0152	.0152	.0381			1.4937
3	.0191	.0152	.0152	.0381			1.4937
4	.0191	.0152	.0152	.0381			1.5546
5	.0191	.0152	.0152	.0381			1.6156
6	.0191	.0152	.0152	.0381			1.6766
7	.0191	.0152	.0152	.0305			1.7375
8	.0191	.0152	.0152	.0191			
9	.0191	.0152	.0152	.0191			
10	1.9052	1.6484		1.5546			.0152
11	1.9662	1.9524		1.5851			.0152
12	1.9204	2.0005	1.7833	1.6004			.0152
13	1.8747	1.9524	1.89	1.6156	.0152		.0152
14	1.829	1.829	1.8595	1.6766	.0152	.0191	.0152
15	1.768	1.8724	1.829	2.0119	.0152	.0191	.0152
16	1.6766	1.7604	1.8138	1.7528	.0152	.0191	.0152
17	1.5851	1.6484	1.6918	1.5546	.0152	.0191	.0152
18	.0152	.0152	.0191	.0152	.0152	.0191	.0152
19	.0152	.0152	.0191	.0152	.0152	.0191	.0152
20	.0152	.0152	.0191	.0152	.0152	.0191	.0152
21	.0152	.0152	.0191	.0152	.0152	.0191	.0152
22	.0152	.0152	.0191	.0152	.0152	.0191	.0152
23	.0152	.0152	.0381	.0152	.0152	.0191	.0152
24	.0191	.0152	.0152	.0381			1.4937
Max	1.9662	2.0005	1.89	2.0119	.0152	.0191	1.7375
Min	.0152	.0152	.0152	.0152	.0152	.0191	.0152
Avg	.6170	.6211	.5070	.5738	.0152	.0191	.5805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 201 / Wadwali
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18	19-MAR-18
HR	Load (MW)	Load (MW)
1		.0549
2		.0549
3		.0549
4		.0716
5		.0895
6		.1075
7		.0914
8		.0886
9		.0709
10	.0354	1.5242
11	.0709	1.6461
12	.0716	1.776
13	.0716	1.7071
14	.0532	1.6461
15	.0532	1.7071
16	.0532	1.768
17	.0532	1.768
18	.0709	
19	.0716	
24		.0532
Max	.0716	1.776
Min	.0354	.0532
Avg	.0605	.7933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 202 / Anantpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18	19-MAR-18
HR	Load (MW)	Load (MW)
1		.6554
2		.6706
3		.6706
4		.7011
5		.7316
6		.8993
7		1.0364
8		1.1589
9		1.1736
10	1.3717	.0354
11	1.5242	.0354
12	1.5851	.0177
13	1.5242	.0177
14	1.4352	.0177
15	1.3904	.0183
16	1.2963	.0177
17	1.2803	.0183
18	.0173	
19	.0354	
24		.6401
Max	1.5851	1.1736
Min	.0173	.0177
Avg	1.1460	.4731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 203 / Apegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18	19-MAR-18
HR	Load (MW)	Load (MW)
1		.5792
2		.5944
3		.6097
4		.6249
5		.6401
6		.6554
7		.6859
8		.7164
9		.7164
10	.9755	.0177
11	.9755	.0183
12	.9755	.0183
13	1.0536	.0183
14	1.1111	.0183
15	1.1092	.0177
16	1.0669	.0183
17	.945	.0183
18	.0179	
19	.0179	
24		.5719
Max	1.1111	.7164
Min	.0179	.0177
Avg	.8248	.3633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 204 / WADWALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-MAR-18	19-MAR-18
HR	Load (MW)	Load (MW)
1		.362
2		.3761
3		.4656
4		.5973
5		1.0242
6		1.2178
7		1.2536
8		1.3969
9		.3841
10	1.0208	.7186
11	.8238	.6135
12	.9511	.4854
13	.6089	.5138
14	.591	.4557
15	.6024	.4961
16	.6401	
17	.567	
18	.6089	
19	.7602	
24		.3658
Max	1.0208	1.3969
Min	.567	.362
Avg	.7174	.6704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 205 / 11kvWAGHADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18
HR	Load (MW)
10	.0175
11	.0179
12	.0179
13	.0173
14	.0358
15	.0358
17	.0358
18	.0347
19	.0183
Max	.0358
Min	.0173
Avg	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 208 / 11KV Naigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18
HR	Load (MW)
10	.0175
11	.0173
12	.0173
13	.0175
14	.0177
15	.0018
16	.0177
17	.0175
18	.0179
19	.0175
20	.0177
Max	.0179
Min	.0018
Avg	.0161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 209 / 11KV Maigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	18-MAR-18
HR	Load (MW)
10	1.0517
11	1.0822
12	1.0974
13	1.0364
15	1.1431
16	1.1888
17	1.1584
Max	1.1888
Min	1.0364
Avg	1.1083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 201 / UDYOGMITRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	1.0288	1.1016	1.0277	.8573	1.2323	1.1641
2	1.0745	1.0288	1.1016	.9922	.8573	1.2136	1.1641
3	1.1104	.9945	1.1203	.9922	.8573	1.2696	1.1462
4	1.1462	.9945	1.1203	.9922	.8573	1.3443	1.134
5	1.182	1.0288	1.1389	1.0099	.8573	1.2883	1.1641
6	1.182	1.0288	1.1389	.9922	.8573	1.2323	1.1283
7	1.2178	.9431	1.1389	.9568	.8916	1.1763	1.1641
8	1.2178	.9431	1.2323	.9214	.9774	1.3443	1.2536
9	1.3432	1.0288	1.2323	.9568	1.0288	1.419	1.1641
10	1.0288	1.2323	1.2178	.9922	1.363	1.3432	1.4377
11	1.1145	1.1949	1.2894	.9945	1.3817	1.3432	1.643
12	1.166	1.1949	1.2536	.9431	1.419	1.4327	1.643
13	1.2003	1.1576	1.1462	.8916	1.2323	1.2178	1.5684
14	.9313	1.251	1.2178	.9259	1.4563	1.2894	1.5684
15	1.2003	1.2323	1.2178	.9259	1.419	1.3432	1.5684
16	1.1145		1.3611	.9431	1.643	1.3611	1.5684
17	1.1145	1.0829	1.2536	.8916	1.4937	1.3969	1.4937
18	1.1145	1.1576	1.1462	.8573	1.419	1.2536	1.2883
19	1.0288	1.0829	1.0745	.8573	1.2136	1.1462	1.1576
20	1.0974	1.0164	1.0745	.8573	1.251	1.1104	1.1949
21	1.0288	1.0349	1.0387	.8573	1.307	1.1462	1.2323
22	.9945	1.0456	1.0277	.8573	1.307	1.1641	1.2696
23	.9431	1.0456	1.0277	.8573	1.3443	1.1462	1.2696
24	1.0745	.9431	1.1016	1.0631	.8573	1.2136	1.1462
Max	1.3432	1.251	1.3611	1.0631	1.643	1.4327	1.643
Min	.9313	.9431	1.0277	.8573	.8573	1.1104	1.1283
Avg	1.1125	1.0735	1.1572	.9398	1.1729	1.2678	1.3138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 202 / NAIGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8859		.7468	.8859	.8573		.8859
2	.8859	.8573	.7282	.8505	.8573	.7716	.8505
3	.9214	.9431	.7468	.8505	.823	.8402	.8505
4	.9568	.9431	.8589	.8859	.8573	.7095	.8859
5	1.0631	.9945	1.0269	.9745	.9945	1.0269	.9745
6	1.3496	1.286	1.5684	1.3289	1.2346	1.419	1.4685
7	1.5947	1.286	1.6991	1.4327	1.406	1.587	1.5223
8	1.5384	1.3432	1.6244	1.3253	1.3375	1.419	1.4327
9	1.5384	1.166	1.5123	1.3432	1.3717	1.643	1.3253
10	1.379	1.1949	1.3969	1.1104	1.3256	1.3969	1.363
11	1.166	1.1203	1.3432	.9945	1.307	1.2894	1.307
12	1.2346	.8589	1.1999	.8916	1.2696	1.1999	1.2136
13	1.1641		1.1641	.9259	.9522		.8962
14	1.1104	.7655	.9671	.9088	1.1576		1.0456
15	1.0631	.7842	1.0745	.8916	1.1389	1.1999	1.1203
16	1.1145	.8029	1.1999	.9259	1.2696	1.2894	1.3256
17	1.2346	.8029	1.2536	1.0288	1.2696	1.2894	1.2323
18	1.3432	.9335	1.2536	1.1145	1.2696	1.2536	1.2696
19	1.3432		1.3432	1.2346	1.307	1.3969	1.5123
20	1.0745	1.1016	1.1641	1.0288			1.307
21	.9602	.8775	1.0387	.9602		1.0029	1.1576
22	.9431	.8215	.9922	.9431		.9568	.9335
23	.9431	.7282	.9568	.8954		.9568	.9522
24	.8859	.9431	.7282	.9214	.8573	.8589	.8859
Max	1.5947	1.3432	1.6991	1.4327	1.406	1.643	1.5223
Min	.8859	.7282	.7282	.8505	.823	.7095	.8505
Avg	1.1539	.9788	1.1495	1.0272	1.1432	1.1754	1.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 203 / 11 KV CHITEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9259	.7316	.8413	.823	.9145	.9114
2	.9709	.9259	.7468	.8413	.7888	.9145	.8764
3	1.0056	.9259	.7682	.8063	.7888	.9145	.8413
4	1.0749	.9945	.8501	.9465	.9602	.9145	.9465
5	1.1443	1.2003	1.0349	1.1568	1.0288	1.1576	1.1919
6	1.387	1.6461	1.307	1.5775	1.3717	1.7177	1.701
7	1.7337	1.749	1.6057	1.6655	1.7147	1.8671	1.6301
8		1.6461	1.643	1.7364	1.5775	1.6804	1.5592
9		1.406	1.4937	1.5592	1.4746	1.3817	1.5238
10	1.2346	1.2696	1.4175	1.4175	1.4937	1.4175	1.3817
11	1.166	1.1203	1.2403	1.2689	1.4937	1.4529	1.3817
12	1.166	.9709	1.134	.9945	1.4563	1.2048	1.2323
13	.9945	.8962	.9922	.8916	1.1949	1.0631	1.0082
14	.9602	.9335	1.0631	.9945	1.2696	1.0631	1.1203
15	.9945	.9709	1.0277	1.0288	1.307	1.2048	1.1949
16	1.0631	.9709	1.134	1.0974	1.4563	1.2048	1.2696
17	1.0974	1.0829	1.1694	1.0974	1.4937	1.3112	1.1949
18	1.2689	1.1949	1.3112	1.0974	1.5684	1.3466	1.4563
19	1.4403	1.4563	1.5592	1.2689	1.6804	1.5238	1.6804
20	1.3717	1.2323	1.3112	1.2003	1.4937	1.4175	1.5684
21	1.166	1.0829	1.1871	1.0974	1.3443	1.3466	1.4563
22	1.0288	.924	1.0517	.9602	1.2323	1.1218	1.307
23	.9602	.8871	.9816	.8916	1.0349	1.0166	1.1949
24	1.0056	.9602	.7392	.8764	.823	.9145	.9465
Max	1.7337	1.749	1.643	1.7364	1.7147	1.8671	1.701
Min	.9602	.8871	.7316	.8063	.7888	.9145	.8413
Avg	1.1457	1.1405	1.1459	1.1381	1.2863	1.2530	1.2740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 205 / 11 KV CHITEGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.6859	.5487	.7796	.4801	.695	.7796
2	.6661	.6859	.5487	.7796	.4801	.695	.7796
3	.6485	.6859	.5853	.7619	.4801	.695	.7619
4	.6661	.6859	.5853	.7619	.4801	.695	.7265
5	.6836	.6859	.6036	.7619	.5487	.7316	.7087
6	.6485	.7545	.6219	.7442	.583	.7316	.7442
7	.6135	.6859	.6767	.7087	.6516	.7682	.815
8	.7973	.583	.8686	.8505	.6859	.8779	.9214
9	1.0745	.6859	1.2323	.9214	.9945	1.3443	1.1104
10	1.3546	.9149	1.2894	1.1462	1.643	1.4685	1.6991
11	1.6289	.8962	1.6118	1.2346	1.643	1.5223	1.8298
12	1.406	.7762	1.3611	1.2003	1.1203	1.7013	1.8298
13	1.2346	.6036	1.2536	1.0288	1.419	1.4327	1.7364
14	1.5775	.6401	1.4685	1.2346	1.6244	1.6118	1.7177
15	1.5775	.7392	1.4327	1.2346	1.587	1.6118	1.6804
16	1.7833	.8589	1.4685	1.2346	1.9791	1.576	1.7364
17	1.7147	.8402	1.4685	1.0974	1.8298	1.6651	1.6244
18	1.4575	.5853	1.0745	.8573	1.5684	1.4864	1.2883
19	.823	.5853	.9313	.7716	.9149	.8954	.9709
20	.7202	.5853	.8505	.7202	.7392	.815	.9335
21	.6859	.5487	.7973	.583	.695	.7973	.8589
22	.6859	.5487	.7619	.5658	.695	.7973	.8589
23	.6859	.5487	.7442	.5487	.695	.7796	.7947
24	.6836	.6859	.567	.7619	.4801	.695	.7973
Max	1.7833	.9149	1.6118	1.2346	1.9791	1.7013	1.8298
Min	.6135	.5487	.5487	.5487	.4801	.695	.7087
Avg	1.0201	.6873	.9730	.8871	1.0007	1.0870	1.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 201 / RAPDRP NEW KAWSAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5068	.4344	.4344	.439	.5611	.5729
2	.543	.5068	.4163	.4344	.4572	.543	.5544
3	.5249	.4887	.4344	.4163	.4755	.5068	.5175
4	.5792	.543	.4887	.4525	.5487	.5068	.5175
5	.6335	.6335	.543	.6878	.6219	.543	.6838
6	.7783	.7783	.6697	.7421	.7682	.8145	.8131
7	.905	.8507	.7602	.7059	.8779	.905	.8871
8	.7602	.6697	.724	.7602	.724	.6335	.7207
9	.6335	.6878	.6878	.7059	.5792	.5611	.5914
10	.543	.6516	.5068	.6584	.5249	.5249	.5359
11	.5068	.543	.4706	.5487	.5068	.4525	.5544
12	.4706	.4706	.4887	.5487	.4887	.4344	.4706
13	.5068	.3982	.4344	.5487	.4887	.4163	.4887
14	.4344	.3982	.4344	.5487	.4887	.4525	.4706
15	.4525	.3982	.4344	.4938	.4706	.4887	.4706
16	.5068	.3982	.4706	.4755	.543	.4887	.5068
17	.4706	.4525	.4706	.5121	.543	.5068	.6335
18	.543	.4887	.5792	.5304	.5973	.5611	.6335
19	.6335	.6516	.6697	.5487	.724	.6878	.7602
20	.6154	.5792	.6154	.5853	.7421	.6878	.7602
21	.6516	.5611	.5792	.5487	.724	.6878	.6697
22		.5249	.5611	.6219	.6878	.6335	.6154
23	.5792	.5068	.543	.5853	.5973	.5792	.5973
24	.543	.5249	.4525	.4887	.5068	.5611	.543
Max	.905	.8507	.7602	.7602	.8779	.905	.8871
Min	.4344	.3982	.4163	.4163	.439	.4163	.4706
Avg	.5808	.5505	.5362	.5660	.5886	.5724	.6070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 202 / RAPDRP POWER HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.7783	.6697		.7865	.8326	.8688
2	.7964	.7783	.6697	.6516	.8048	.543	.7964
3	.7783	.7964	.6516	.6516	.7865	.8326	.8326
4	.8326	1.0136	.724	.6878		.8145	.8145
5	.9955	.9774	.8326	.7602	.9328	.8507	.9593
6	1.1765	1.1946	.9955	1.0498	1.0425	1.0679	1.086
7	1.3213	1.2851	1.1765	1.1041	1.2803	1.3394	1.3575
8	1.3213	1.1946	1.2851	1.2127	1.3032	1.3032	1.2851
9	1.3213	1.1946	1.1946	1.1584	1.1584	1.1765	1.1041
10	1.0136	1.1765	1.0136	1.0974	1.0136	1.086	1.086
11	.9774	1.1222	.9774	1.0974	.9593	1.0136	1.0136
12	.9774	1.0679		1.134	.9231	.9955	.9412
13	.9412	.9593		.9694	.7602	.8688	.9774
14	.8145	.8145	1.0498	.9145	.8326	.8688	.9412
15	.8688	.7421	1.0136	.823	.9412	.8869	.9412
16	1.0136	.7421	1.0317	.8413	.9955	.9593	.9412
17	1.0136	.7783	1.0498	.8779	1.0498	.9774	1.0498
18	1.1222	1.0136	1.1041	.9328	1.267	1.086	.9955
19	1.2127	1.1946	1.2489	1.2254	1.3756	1.3032	1.3032
20	1.086	1.2851	1.1584	1.1888	1.2489	1.2851	1.3394
21	1.0498	1.0317	1.1222	1.0974	1.1765	1.1765	1.1765
22		.8507	1.0498	1.0059	.9955	1.0679	.905
23	.9412	.7964	.8507	.8962	.905	.9231	.9774
24	.8326	.8145	.724	.7602	.7783	.8507	.905
Max	1.3213	1.2851	1.2851	1.2254	1.3756	1.3394	1.3575
Min	.7783	.7421	.6516	.6516	.7602	.543	.7964
Avg	1.0097	.9834	.9815	.9625	1.0138	1.0046	1.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11 KV JAMGAON FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317						
2	1.1317						
3	1.166						
4	1.2003						
5	1.2003						
6	1.2174						
7	1.5947						
8	1.5604						
9							.0343
11							1.5775
12							1.9204
13							1.989
14							2.1285
15							.0343
16				.0343			
17		.0343			.0171	.0171	.0171
18					.0171	1.1145	.0171
19		.0343		.0514		.0343	.0343
20					.0343	.0343	.0343
21		.0686				.0343	.0343
22		.0514		.0343		.0343	.0343
23		.0857				.0343	.0514
24	1.1317		.9259				.0343
Max	1.5947	.0857	.9259	.0514	.0343	1.1145	2.1285
Min	1.1317	.0343	.9259	.0343	.0171	.0171	.0171
Avg	1.2594	.0549	.9259	.04	.0228	.1862	.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11 KV MANJARI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029						
2	.1029						
3	.1029						
4	.12						
5	.1543						
6	.1886						
9							1.9204
12							.0343
16		2.0576		2.4348			.0343
17		2.1605	.7202	2.0576		.0343	.0343
18		1.5089	1.286	1.166	.0514	.0343	.0514
19			.1029	.12		.1029	.1029
20		.0514				.12	.12
21		.0857				.0686	.0857
22		.1029		.0514		.0514	.0686
23		.12	.1029			.0514	.0514
24	.1029		.12				.9774
Max	.1886	2.1605	1.286	2.4348	.0514	.12	1.9204
Min	.1029	.0514	.1029	.0514	.0514	.0343	.0343
Avg	.1249	.8696	.4664	1.1660	.0514	.0661	.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11 KV MALUNJA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576						
2	2.0576						
3	2.1605						
4	2.1605						
5	2.1948						
6	2.2805						
7	2.8635						
8	2.692						
9							.1886
10							.1372
12							.0857
14							.1715
15							2.7092
16				.1715			3.0007
17		.1715	.2229		2.7092	2.0576	2.572
18			.2401	.1029	2.8121	1.9204	2.5549
19		.2743	.2743	.0857	.2743	.2915	.2915
20		.2572	.3429	.2572	.2743	.3086	.2915
21		.2058	.2915	.2058		.3086	.3258
22		.1715	.1715	.2401		.3086	.3258
23			.1886	.2401		.3086	.3086
24	1.9033		1.8176				.2915
Max	2.8635	.2743	1.8176	.2572	2.8121	2.0576	3.0007
Min	1.9033	.1715	.1715	.0857	.2743	.2915	.0857
Avg	2.2634	.2161	.4437	.1862	1.5175	.7863	.9468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / TOWN I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573						
2	.8573						
3	.8916						
4	.9259						
5	1.1317						
6	1.4403						
7	1.5432						
8	1.4232						
9							1.2689
10							1.0631
12							1.1317
13							2.9835
14							3.0864
15							3.0521
16		.9602		1.0288			1.0974
17		.9259	1.0631	1.0631	2.0576	1.1488	1.0802
18		1.166	1.166	1.0974	1.8347	1.2346	1.2346
19		1.2517	1.3375	1.2346	1.3032	1.5261	1.5089
20		1.2689	1.286	1.2003	1.5432	1.406	1.4575
21		1.1145	1.1317	1.1145		1.2346	1.2517
22		1.0288	1.0288	1.0288		1.1488	1.1488
23		.8573	.9088	.9259		1.0117	1.0631
24	.8573		.7888				.9602
Max	1.5432	1.2689	1.3375	1.2346	2.0576	1.5261	3.0864
Min	.8573	.8573	.7888	.9259	1.3032	1.0117	.9602
Avg	1.1031	1.0717	1.0888	1.0867	1.6847	1.2444	1.5592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 205 / TOWN II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463						
2	.463						
3	.4801						
4	.5144						
5	.583						
6	.7373						
7	.8745						
8	.8745						
9							.7202
10							.6859
11							.6859
12							.6173
13							.5658
14							.5658
15							.5144
16		.583		.5658			.6001
17		.6001	.6001	.6173	.6859	.6344	.6687
18		.6516	.7202	.6859	.7373	.703	.6173
19		.7716	.7888	.7373	.8059	.9088	.7545
20		.6859	.7373	.7373	.7716	.7716	.7716
21		.6173	.6516	.6001		.6859	.6859
22		.5144	.5487	.5658		.6001	.6001
23		.4287	.4801	.5144		.5316	.5487
24	.4801		.3944	.4458			.4973
Max	.8745	.7716	.7888	.7373	.8059	.9088	.7716
Min	.463	.4287	.3944	.4458	.6859	.5316	.4973
Avg	.6078	.6066	.6152	.6077	.7502	.6908	.6312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 206 / TOWN III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401						
2	.2401						
3	.2572						
4	.2915						
5	.3429						
6	.4287						
7	.5658						
8	.5144						
9							.4287
10							.3772
11							.3772
12							.3429
13							.3086
14							.3429
15							.2915
16		.3086		.3429			.3086
17		.3429	.3429	.3429	.3429	.3429	.3944
18		.3429	.3772	.3944	.3944	.3772	.4115
19		.3429	.3772	.4287	.5144	.4287	.4801
20		.3772	.4287	.3772	.4115	.3772	.4287
21		.3086	.3429	.2915		.3429	.3772
22		.2743	.2915	.3429		.3086	.3258
23		.2401	.2572	.2743		.2743	.3086
24	.2572		.2401	.2572			.2572
Max	.5658	.3772	.4287	.4287	.5144	.4287	.4801
Min	.2401	.2401	.2401	.2572	.3429	.2743	.2572
Avg	.3487	.3172	.3322	.3391	.4158	.3503	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 207 / 11 KV WARKHED FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	16-MAR-18	17-MAR-18	18-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				1.2346
16	.7545		.6001	
17	.7202	.9602	.6173	
18		.9602	.5144	
24				.9774
Max	.7545	.9602	.6173	1.2346
Min	.7202	.9602	.5144	.9774
Avg	.7374	.9602	.5773	1.106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 208 / 11 kv NAWABPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115						
2	.4115						
3	.4458						
4	.6516						
5	.9259						
6	1.0631						
9							.8573
10							.6001
11							.3944
12							.3429
14							.3429
16		.4801		.4458			.3772
17		.5144	.5658	.583	.4115	.5316	.4801
18			.6859		.6173	.6001	.6173
19		.9431	1.166	.5144	1.0631	1.0974	1.1145
20		1.1317	.9945	.583	.9945	1.0802	1.1831
21		.8573	.823	.5144		.7888	.8573
22		.6516	.7202	.4458		.6516	.6344
23			.6001	.3944		.583	.5487
24	.4115		.463	.5144			.5316
Max	1.0631	1.1317	1.166	.583	1.0631	1.0974	1.1831
Min	.4115	.4801	.463	.3944	.4115	.5316	.3429
Avg	.6173	.7630	.7523	.4994	.7716	.7618	.6344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 209 / 11KV NEW INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258						
2	.3086						
3	.3086						
4	.2743						
5	.1886						
6	.1886						
7	.1886						
9							.1715
10							.1715
11							.2915
12							.2401
13							.2401
14							.2743
15							.0857
16		.1715		.0686			.0857
17		.1886	.0686	.0514	.0857	.0686	.0686
18		.1372	.0343	.0514	.0857	.0686	
19		.1029	.0686		.0686	.0686	.1029
20		.1372		.1715	.1029	.1372	.1543
21		.1029	.0686			.1372	.1715
22		.1715	.12	.1715		.1543	.1715
23		.1715	.1543	.2401		.12	.2058
24	.3258		.2572	.1372			.1543
Max	.3258	.1886	.2572	.2401	.1029	.1543	.2915
Min	.1886	.1029	.0343	.0514	.0686	.0686	.0686
Avg	.2636	.1479	.1102	.1274	.0857	.1078	.1726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 201 / 11KV TURKABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5335		.0762		.0762
2		.6097	.5335		.1143		.0762
3		.6478	.5716		.1143		.0762
4		.6859	.5716		.0762		.0762
5		.7621	.6097		.0762		.1143
6		.7621	.583		.0762		.1143
7		.8002	.823		.0762		.1143
8		.7621			.0381		.0762
9	.5487	.7621	.6516		.0381		.0381
10	.0762	.0381	.0762	.1143	.0381	.0762	.0381
11	.1143	.0381	.0762	.0762	.6859	.6173	.5487
12	.1143	.0381	.0762	.0762	.724	.6001	.583
13	.1524	.0381	.0762	.1143	.7621	.5487	.5487
14	.1524	.0381	.0762	.1143		.5487	.583
15	.1143	.0381	.0762	.0762		.5658	.5487
16	.1143	.0381	.0191	.0762		.583	.583
17	.1524	.0381	.0191	.1143		.6478	.583
18	.1524	.0381	.0762	.1143		.4954	.5487
19	.1143	.0762		.0762		.0381	.1143
20	.1143	.0762		.0762		.0572	.1143
21	.0762	.0572		.1143		.0762	.0762
22	.0762	.0381		.1143		.0762	.0762
23	.0762	.0381		.0762		.0762	.0381
24			.5335		.0762		.0762
Max	.5487	.8002	.823	.1143	.7621	.6478	.583
Min	.0762	.0381	.0191	.0762	.0381	.0381	.0381
Avg	.1433	.3040	.3324	.0953	.2123	.3576	.2426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 202 / 11 KV SHIVRAI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0953		1.2574		1.1431
2	.0762	.0953	.0953		1.4098		1.1812
3	.0953	.1143	.0953		1.5242		1.2193
4	.0953	.1143	.1143		1.6385		1.2955
5	.0953	.1524	.1524		1.7147		1.4098
6	.0953	.1524	.1524		1.7909		1.3717
7	.0953	.1524	.1334		1.7147		1.6804
8	.1143	.1143	.1334		1.5089		1.6804
9	.1143	.0953	.1143		1.2003		1.4403
10	.1143	.0953	1.6194	.1143	.0762	.1143	.1143
11	1.5432	1.9814	1.6194	1.5432	.0762	.0762	.0953
12	1.7147	2.0576	1.8861	1.8176	.0762	.0762	.0762
13	1.9814	1.8861	2.0957	1.8861	.0762	.0762	.0953
14	1.749	1.8004	2.0576	1.8861		.0762	.0762
15	1.9433	1.749	1.9814	1.8176		.0572	.0762
16	1.9052	1.7318	1.9052	1.7147		.0572	.0953
17	1.829	1.7147	1.9052	1.5089		.0762	.1143
18	1.7147	1.5775	1.9052	1.3717		.0762	.1143
19	.1143	.1905		.0953		.1334	.1143
20	.1143	.1334		.0762		.1143	.0953
21	.0762	.1143		.0762		.0953	.0953
22	.0762	.1143		.0572		.0762	.0762
23	.0953	.0953		.0572		.0762	.0762
24	.0953		.0953		1.1812		1.1431
Max	1.9814	2.0576	2.0957	1.8861	1.7909	.1334	1.6804
Min	.0762	.0953	.0953	.0572	.0762	.0572	.0762
Avg	.6635	.7099	.9556	1.0016	1.0890	.0844	.6200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 203 / 11 KV DAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1143		.1905		.2667
2	.2286	.2286	.1143		.2286		.2667
3	.2286	.2667	.1524		.2286		.3048
4	.2477	.3048	.1905		.2667		.3429
5	.3048	.3429	.2286		.2667		.4191
6	.3048	.381	.2667		.3048		.4801
7	.3048	.3048	.3239		.381		.6173
8	.362	.1905	.2286		.4191		.6687
9	.2667	.1524	.1905		.4572		.5144
10	.3048	.1524	.1905	.3048	.0762	.1524	.1524
11	.4801	.362	.3429	.3429	.0762	.1524	.1524
12	.5144	.3429	.3429	.4458	.0762	.1143	.1905
13	.4458	.3429	.362	.4115	.0762	.0762	.1905
14	.3772	.3429	.381	.3772		.0762	.1524
15	.3429	.3429	.381	.4115		.0762	.1524
16	.3086	.3258		.3772		.0953	.1905
17		.3086	.362	.3429		.0953	.2286
18		.3048	.3239	.3086		.1334	.3048
19	.1524	.2667		.381		.2667	
20	.1905	.1905		.3429		.2286	.381
21	.1715	.1524		.3048		.1905	.3429
22	.1715	.1524		.2286		.1334	.3048
23	.1524	.1143		.1905		.1143	.1905
24	.1715		.1143		.1905		.2667
Max	.5144	.381	.381	.4458	.4572	.2667	.6687
Min	.1524	.1143	.1143	.1905	.0762	.0762	.1524
Avg	.2872	.2636	.2561	.3407	.2313	.1361	.3079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 204 / 11 KV MANGEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6173	.6097		.0191		.0762
2	.8764	.6859	.6097		.0191		.0762
3	.9526	.8383	.6097		.0191		.0762
4	.9907	.9145	.6478		.0191		.0762
5	1.0669	.9602	.724		.0191		.0762
6	1.0669	1.0288	.7202		.0191		.1143
7	1.1431	1.0631	.8745		.0191		.0572
8	1.2193	1.0974	.8573		.0381		.0572
9	.8745	1.1317	.823		.0381		.0572
10	.0191	.0191	.0191	.0381	.0381	.0381	.0572
11	.0191	.0191	.0191	.0191	.9526	1.0631	.9602
12	.0191	.0191	.0191	.0191	.9907	1.0974	1.0288
13	.0191	.0191	.0191	.0191	1.1241	.9431	.8916
14	.0191	.0191	.0191	.0191		.9088	.9259
15	.0191	.0191	.0191	.0191		.8916	1.0669
16	.0191	.0191	.0191	.0191		.8573	1.1431
17	.0191	.0191	.0191	.0191		.8402	1.0669
18	.0191	.0191	.0191	.0191		.8192	.9526
19	.0191	.0762		.0191		.0381	.0762
20	.0191	.0572		.0191		.0381	.0762
21	.0191	.0381		.0191		.0572	.0762
22	.0191	.0381		.0191		.0762	.0381
23	.0191	.0381		.0191		.0762	.0381
24	.724		.5716		.0191		.0762
Max	1.2193	1.1317	.8745	.0381	1.1241	1.0974	1.1431
Min	.0191	.0191	.0191	.0191	.0191	.0381	.0381
Avg	.4143	.3807	.3800	.0205	.2382	.5532	.3809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 205 / 11 kv DAHEGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.8192		.6097		.8192
2	.6859	.7621	.8002		.6859		.8192
3	.724	.8764	.8764		.7621		.9145
4	.9145	.9526	1.0288		.8764		1.0288
5	1.1812	1.2574	1.2955		1.2574		1.3717
6	1.3908	1.7147	1.7528		1.6766		1.9052
7	1.6385	2.0005	1.9052		1.9433		1.6632
8	1.9814	1.7147	1.7528		1.9052		1.6461
9	1.5813	1.6766	1.467		1.7528		1.5432
10	1.5242	1.1812	1.1812	1.5242	1.1431	1.2193	1.448
11	1.2574	.9526		1.448	.8573	.9907	.8764
12	1.1431	.8002	.724	1.3336	.8764	.8002	.7621
13	.8764	.7049	.7621	1.2574	.7621	.743	.6859
14	.7621	.724	.7621	1.1431		.743	.7621
15	.724	.8002	.8192	1.0669		.743	.8764
16	.8764	.9335	1.0669	1.1431		.8002	.7621
17		.9907	1.1431	1.1431		.9717	.9526
18		1.2955	1.2384	1.2574		1.2955	.9602
19	1.5242	1.7528		1.448		1.6766	1.3336
20	1.7528	1.4289		1.5242		1.5242	1.448
21	1.448	1.1812		1.3336		1.1812	1.3336
22	1.3336	1.0288		1.2574		.9526	.9526
23	.8764	.8192		.8764		.8383	.7621
24	.5716		.8192		.5716		.8192
Max	1.9814	2.0005	1.9052	1.5242	1.9433	1.6766	1.9052
Min	.5716	.6859	.724	.8764	.5716	.743	.6859
Avg	1.1535	1.1406	1.1230	1.2683	1.1200	1.0343	1.1019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 206 / 11 KV TURKABAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.7621		.5716		.8192
2		.6859	.7621		.6097		.8192
3		.7621	.8002		.6478		.9526
4		1.0669	.9145		.7621		1.0288
5		1.1431	.9526		1.0669		1.3336
6		1.6766	1.7147		1.2574		1.5775
7		1.9052	1.9814		1.7147		1.7318
8		1.7147			1.6766		1.406
9	1.4098	1.5623	1.3336		1.5242		1.2193
10	1.3336	1.0288	1.1431	1.3336	1.1812	1.086	1.1431
11	1.1431	.7049	.724	1.3336	.6478	.7621	1.0669
12	1.0669	.6478	.6859	1.2574	.5716	.6668	.7621
13	.9526	.6097	.5716	1.1431	.4954	.6097	.6859
14	.8764	.6097	.5335	1.0669		.6097	.7621
15	.7621	.6287	.4954	.9526		.5716	.8002
16	.8764	.6478	.724	.8764		.743	.9526
17	1.0669	.8002	.8764	1.0669		.8383	1.0669
18	1.2574	1.0669	1.0669	1.1431		1.105	1.1431
19	1.3336	1.7718		1.448		1.6385	1.448
20	1.5242	1.3717		1.5242		1.3336	1.5242
21		1.0669		1.2574		1.105	1.3336
22	1.2574	.9526		1.1431		.9145	.8764
23	.7621	.8002		.7621		.8192	.7621
24			.7621		.6859		.8192
Max	1.5242	1.9052	1.9814	1.5242	1.7147	1.6385	1.7318
Min	.7621	.5716	.4954	.7621	.4954	.5716	.6859
Avg	1.1159	1.0346	.9336	1.1649	.9581	.9145	1.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 207 / 11 KV YESGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0381		.3048		.3048
2		.0381	.0381		.3429		.3429
3		.0381	.0381		.381		.381
4		.0381	.0381		.4191		.381
5		.0381	.0381		.4191		.4191
6		.0762	.0762		.381		.5335
7		.0762	.0381		.4572		.8192
8		.0381			.4191		.7888
9	.0381	.0381	.0381		.381		.5316
10	.0381	.0381	.0381	.0381	.0191	.0381	.0381
11	.3429	1.086	.4763	.3429	.0191	.0381	.0762
12	.4458	.6859	.4954	.4458	.0191	.0381	.0762
13	.4115	.5716	.4954	.4801	.0191	.0381	.0381
14	.4115	.5487	.4954	.5144		.0381	.0572
15	.3772	.5658	.5335	.4801		.0381	.0572
16	.3772	.5658	.4954	.4458		.0381	.0762
17	.3429	.5316	.4954	.3772		.0381	.0762
18	.3429	.4973	.4763	.3429		.0381	.0762
19	.0381	.1143		.0762		.0572	.0572
20	.0381	.0762		.0381		.0572	.0572
21	.0381	.0762		.0381		.0572	.0381
22	.0381	.0572		.0381		.0381	.0381
23	.0381	.0381		.0381		.0381	.0381
24			.0381		.2667		.3048
Max	.4458	1.086	.5335	.5144	.4572	.0572	.8192
Min	.0381	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.2212	.2553	.2435	.2640	.2749	.0422	.2336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 208 / 11KV ARYANSH IND FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.6097		.5716		.5335
2		.5716	.5906		.6097		.5335
3		.4954	.5906		.6097		.5335
4			.6097		.6097		.5335
5		.5335	.6097		.6478		.5525
6		.5335	.6478		.6859		.5525
7		.5716	.6859		.6859		.5525
8		.6097	.8002		.8764		.6097
9	.8192	.6478	.8383		.9526		.8573
10	.7621	.6097	.7621	.6859	.9526	.8764	.8764
11	.7621	.362	.8954	.7621	.9145	.8383	.8764
12	.8002	.2667	.8002	.8383	.9145	.8002	.9145
13	.9145	.2286	.8764	.9526	.9145	.8192	.8764
14	.9526	.2286	.9145	.9526		.724	.724
15	.9907	.2286	.9717	.9907		.6097	.6478
16	.9526	.2286	.8764	.9526		.9526	.6478
17	.8002	.2286	.7621	.8764		1.105	.6859
18	.7621	.2477	.381	.7621		.8383	.7621
19	.7621	.2667		.724		.2858	.6859
20	.7621	.4954		.6859		.2477	.5716
21	.724	.5716		.6859		.2286	.4572
22	.6859	.6097		.6478		.2286	.381
23	.6097	.6097		.6097		.2286	.4954
24			.6097		.5716		.5335
Max	.9907	.6478	.9717	.9907	.9526	1.105	.9145
Min	.6097	.2286	.381	.6097	.5716	.2286	.381
Avg	.8040	.4382	.728	.7948	.7512	.6274	.6414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 209 / SAVERA IND FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.6478		.7621		.6097
2		.5716	.6478		.7621		.6097
3		.5716	.6668		.8002		.6287
4		.6097	.6859		.8002		.6287
5		.6097	.6859		.8383		.6478
6		.6478	.724		.8764		.7621
7		.6859	.7621		.9145		.8764
8		.6097	.8002		.8764		1.1622
9	.9907	.5716	.7621		.7621		1.0479
10	1.0288	.4763	.7621	1.0288	.724	.9526	1.0669
11	.9907	.4382	.9907	.9907	.6478	1.0669	1.105
12	.9907	.381	.9526	1.0288	.724	1.0479	1.1431
13	.9526	.3239	.8764	.9907	1.2384	1.0669	1.0669
14	.9526	.3429	.8192	.9526		1.0479	1.1431
15	.9526	.3429	.8954	.9907		1.0288	1.2574
16	1.0669	.362	.9526	.9907		1.0669	1.2574
17	1.1431	.4191	.9907	1.0288		1.1241	1.1812
18	1.1812	.7049	.9335	1.0288		1.105	1.1431
19	1.0669	.6859		.9907		.9907	1.0669
20	.9526	.6668		.9526		.8573	.9526
21	.8764	.6668		.9526		.8002	.8764
22	.7621	.6668		.8764		.724	.724
23	.6859	.6668		.8383		.6097	.6097
24			.6668		.724	.724	.6097
Max	1.1812	.7049	.9907	1.0288	1.2384	1.1241	1.2574
Min	.6859	.3239	.6478	.8383	.6478	.6097	.6097
Avg	.9729	.5475	.8012	.9744	.8179	.9475	.9240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 201 / 11 KV SHENDURWADA 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.7545		.6413	1.0136	1.3969	1.2536
2	.7167	.7545		.6602	.9955	1.3969	1.2536
3	.8488	.8402		.7167	1.086	1.4175	1.3432
4	1.0374	1.0269		.8488	1.1765	1.5061	1.4175
5	1.226	1.2136		1.226	1.2536	1.5775	1.4175
6	1.4146	1.5497		1.4146	1.2536	1.6301	1.4352
7	1.6032	1.307	1.4377	1.5089	1.2894	1.6644	1.543
8	1.4335	1.1203		1.4523	1.3432	1.5415	1.5238
9	1.094	.9896		1.2637	.7545	.9709	1.0829
10	.7545	.7545		1.0751	.679	.7545	.7545
11	.6602			.9808	.6602	.6224	.5847
12	.5281			.9054	.6413	.6224	.6036
13	.547			.8488	.5658	.5658	.5847
14	.5281			.7545	.5658	.5847	.5658
15	.5658			.7167	.5281	.6036	.5658
16	.547			.6224	.5658	.6413	
17	1.3969			1.4883			.679
18	1.5061			1.5238	.9896	.6224	.6979
19				1.4883	1.363	1.251	1.1203
20	1.4706			1.4175	1.1203	1.4003	1.5497
21	1.2894			1.3432	1.2323	1.0269	1.307
22	1.1946			1.1765	.9335	1.1576	1.0456
23	1.1765			1.086	.8402	.9335	.8676
24	1.134	1.1584			1.0317	.811	.8299
Max	1.6032	1.5497	1.4377	1.5238	1.363	1.6644	1.5497
Min	.5281	.7545	1.4377	.6224	.5281	.5658	.5658
Avg	1.0145	1.0427	1.4377	1.0939	.9514	1.0739	1.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 202 / 11 KV SAWAKHEDA 1 SINGLE PHASING
 PHASHING Feeder KV- 11 /
 OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1867	.1509	1.989	1.6644	1.7833
2	.1886	.1886	.1867	.1509	1.989	1.6991	1.8821
3	.2263	.1886	.1867	.1509	1.9784	1.6991	1.95
4	.2829	.2641	.2241	.1886	1.9784	1.7147	1.989
5	.3395	.3395	.2241	.2829	1.9281	1.7295	.0343
6	.415	.3772	.2263	.3395	1.9281	1.7295	1.7002
7	.4527	.4715	.2241	.3772	1.9845	1.7635	1.7318
8	.4527	.3772		.3772	1.989	1.7635	1.7164
9	.4527	.3395		.3395		.2829	.3772
10	.3395	.2641		.2829		.2452	.2829
11	.3018			.2263		.1886	
12	.1886			.1886		.1886	
13	.1886	.1886		.1886	.1886	.1886	
14	.1886	.1886		.1886	.1886	.1886	
15	.1886	.1886		.1886	.1886	.1886	.1886
16	.1886	.1886		.2263	.1886	.1886	.1886
17	1.7465	1.8861		2.3034	.2263	.2263	.1886
18	1.8442	1.8004		2.4097	.056	.2641	.3018
19	1.7804	1.8004		2.3388	.3395	.3018	.3395
20	1.7147	1.7661		2.3034	.3018	.2452	.2829
21	1.7295	1.7661		2.268	.2641	.2075	.2263
22	1.7147	1.7661		2.2148	.2263	.1886	.2075
23	1.6301	1.7147		2.1849	.2075	.1886	.1886
24	1.8427	1.6126	1.7147		2.1491	.1886	.1886
Max	1.8442	1.8861	1.7147	2.4097	2.1491	1.7635	1.989
Min	.1886	.1886	.1867	.1509	.056	.1886	.0343
Avg	.7744	.8121	.3967	.8639	1.0145	.7181	.7874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 203 / 11 KV MAHALAXMIKHEDA(LIS- SINGLE PHASING
I) 1 Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.6476	1.5432	1.97	1.2696	1.307	1.6804
2	1.7909	1.7147	1.5432	1.949	1.2136	1.4937	1.8671
3	1.949	1.8442	1.5432	2.0376	1.4937	1.6804	2.1472
4	2.1262	1.989	1.8004	2.1262	1.8671	2.2405	2.3899
5	2.3034	2.0553	1.8861	2.3034	2.0538	2.5206	2.6139
6	2.4806	2.0885	1.9719	2.4539	2.2405		
7	2.6578	2.3967	2.3491	2.6292	2.5086		
8	2.516	2.4129		2.3211			
9	1.8107	1.9978		1.8296		2.3537	2.3537
10	1.1203	1.363		1.6598		2.1548	2.1051
11	.7545			1.3014	1.5775	1.9951	2.0885
12	.7356			.9054	1.9951	1.7465	2.0119
13	.7167	1.1203			1.989	1.7833	1.9784
14	.7356	1.1203			2.0719	1.8004	1.9784
15	.7356	1.0374		1.094	2.0885	1.8313	1.9616
16	.8299	1.0374		1.0185	2.0388	1.8991	1.9448
17	1.1016	1.4003		1.226		1.0082	.7167
18	1.6617	1.9605		1.3769	1.307		1.307
19	2.5206	2.0538		1.8861	2.5019	2.2405	2.4459
20	2.1098	2.1472		2.2634	2.2779	2.4646	2.6513
21	1.587	2.0538		2.0748	1.8671	1.8858	2.2405
22	1.4563	1.9605		1.6975	1.6804	1.587	1.5684
23	1.2883	1.4937		1.5089	1.4003	1.4563	1.307
24	1.3203	1.2696	1.4937		1.358	1.2696	1.3256
Max	2.6578	2.4129	2.3491	2.6292	2.5086	2.5206	2.6513
Min	.7167	1.0374	1.4937	.9054	1.2136	1.0082	.7167
Avg	1.5807	1.7348	1.7664	1.7920	1.8400	1.8359	1.9373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 204 / 11KV MUKTESHWAR HT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.056	.0566	.0566	.056	.056	.056
2	.0566	.056	.0566	.0566	.0566	.056	.056
3	.0566	.056	.0566	.0566	.056	.056	.056
4	.0566	.056	.0566	.0566	.056	.056	.056
5	.0566	.056	.0566	.0566	.056	.056	.056
6	.0566	.056	.0566	.0566	.056	.056	.056
7	.0566	.0747	.0566	.0754	.0566	.0747	.0747
8	.0566	.0747		.0566	.0747	.0747	.0747
9	.0566	.0747		.0754	.056	.0747	.0747
10	.0747	.0747		.0754	.056	.0934	.0747
11	.0747			.0754	.056	.0934	.1294
12	.0747			.1132	.056	.1294	.1294
13	.0747	.0754		.1509	.056	.1294	.1294
14	.0934	.0943		.1509	.056	.1294	.1478
15	.0934	.0943		.1509	.056	.1294	.1294
16	.0934	.0943		.1132	.056	.1294	.1294
17	.0747	.0943		.132	.056	.1294	.1294
18	.0747	.0943		.132	.056	.1294	.0747
19	.0747	.0754		.0754	.056	.0747	.0747
20	.0747	.0754		.0566	.0747	.056	.0747
21	.0747	.0754		.0566	.056	.056	.056
22	.056	.0754		.0566	.056	.056	.056
23	.056	.0566		.0566	.056	.056	.056
24	.0566	.056	.0566		.0566	.056	.056
Max	.0934	.0943	.0566	.1509	.0747	.1294	.1478
Min	.056	.056	.0566	.0566	.056	.056	.056
Avg	.0679	.0725	.0566	.0845	.0576	.0836	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 205 / 11KV LIS II 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	.0943		1.7718	.1509	.132	.0943
2	1.97	.0943		1.7718		.132	.0943
3	2.1262	.0943		1.949		.1509	.132
4	2.392	.1509		2.1262		.1886	.1886
5	2.4806	.1886		2.2148		.2641	.2641
6	2.4806	.1886		2.392		.3018	.3584
7	2.4629	.2075	2.3663	2.4274		.3395	.3772
8	2.3743	.1698		2.3565		.2075	.2452
9	.2829	.1886		.3018		2.4417	2.556
10	.1886	.0943		.2829		2.7664	2.7854
11	.132			.2452	1.989	3.0498	3.1131
12	.0943			.1886	2.1792	2.9172	2.9984
13	.0943				2.5101	2.967	3.0148
14	.0943				2.5926	3.0333	2.9984
15	.0943			.132	2.5766	3.0498	2.982
16	.0943			.1132	2.5606	3.0167	2.9656
17	.0943			.1132	.0754	.0943	.0943
18	.1509			.1509	.1509	.0943	
19	.3206			.1886	.3018	.1698	
20	.2641			.2263	.2829	.3206	.132
21	.1509			.1886	.2263	.2452	.0943
22	.1509			.1698	.1886	.2263	.0943
23	.132			.1509	.1886	.1698	.0943
24	.1132	.132			.1509	.1509	.1698
Max	2.4806	.2075	2.3663	2.4274	2.5926	3.0498	3.1131
Min	.0943	.0943	2.3663	.1132	.0754	.0943	.0943
Avg	.8554	.1457	2.3663	.9267	1.0750	1.1012	1.1749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 206 / 11KV GURUDHANORA 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2452		.2263	.2263	.2263	.2829
2	.2263	.2452		.2263	.2263	.2641	.3772
3	.2829	.2641		.2641	.2829	.3206	.4715
4	.3772	.2829		.3772	.3395	.3772	.6602
5	.4715	.4715		.4715	.4715	.6413	.7545
6	.5658	.8402		.7545	.6602	.7922	.8488
7	.7545	.9149	.924	.811	.7167	.8775	.7545
8	.6224	.6602		.679	.7545	.679	.5847
9	1.5592	1.595		1.5592	.3772	.4715	.3961
10	1.647	1.5415		1.5415	.2829	.3584	.2641
11	1.6301			1.5415	.2263	.2075	.1886
12	1.6126			1.5238	.2075	.1509	
13	1.5592			1.5061	.1886	.1509	
14	1.4175			1.5061	.1886	.1509	
15	1.3432			1.5061	.1886	.1509	
16	1.2536			1.5061	.1886	.132	
17	.2641			.2829	1.5592	.7023	1.6991
18	.4527			.3584	1.5775	.823	1.647
19	.6979			.3772	1.6476	.823	1.9616
20	.3961			.4715	1.5238	1.6301	1.9281
21	.3206			.3772	1.4529	1.595	1.8778
22	.3018			.3395	1.3998	1.4175	1.869
23	.3206			.2829	1.3611	1.4352	1.8004
24	.2829	.3018			.2829	1.3432	1.4148
Max	1.647	1.595	.924	1.5592	1.6476	1.6301	1.9616
Min	.2263	.2452	.924	.2263	.1886	.132	.1886
Avg	.7744	.6693	.924	.8039	.6805	.6550	1.0411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 207 / 11 KV DHAMORI (BK) SINGLE PHASING
 1PHASING Feeder KV- 11 /
 OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.1509	.1509	.1509	.0943	.1132
2	.0943	.0943	.1463	.1509	.1509	.0934	.1132
3	.0943	.0943	.1463	.1509	.132	.0943	.1132
4	.1132	.1509	.1509	.1698	.1132	.0943	.132
5	.132	.2263	.1886	.1886	.132	.1698	.2075
6	.132	.2829		.2263	.132	.1886	.2829
7	.132	.3206	.1867	.2263	.132	.132	.2641
8	.132	.2641		.0943	.1132	.1132	.2075
9	1.8427	1.7465		1.825	.1132	.1698	.1698
10	1.7974	1.7147		1.8073	.1132	.132	.1509
11	1.7295			1.7718	.0943	.0943	.1132
12	1.7147			1.7896	.0943	.1029	.1132
13	1.6991	1.829		1.7718	.0943	.1132	.0943
14	1.6126	1.7741		1.7364	.0943	.1132	.0943
15	1.6126	1.7741		1.6832	.0943	.1132	.0943
16	1.647	1.7187		1.6476	.1132	.1132	.0943
17	.1886	.1886		.132	1.8778	1.8861	1.749
18	.1886	.1886		.1509	1.8482	1.9033	1.7147
19	.2452	.1886		.1886	1.9113	1.8347	1.7147
20	.2263	.1886		.2263	1.7974	1.7318	1.6991
21	.2263	.1886		.2263	1.647	1.6124	1.6297
22	.2075	.1886		.1886	1.4175	1.6297	1.5592
23	.1886	.1886		.1886	1.3998	1.5415	1.4175
24	.2263	.1886	.1829		.1886	1.3611	1.4352
Max	1.8427	1.829	.1886	1.825	1.9113	1.9033	1.749
Min	.0943	.0943	.1463	.0943	.0943	.0934	.0943
Avg	.6782	.6179	.1647	.7257	.5815	.6430	.6365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 201 / 11 KV SAWANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.1431	.5975	.6668	.8002		.7621
2	.9526	1.2384	.4481	.7621	.7811		.7621
3	1.0479	1.2955	.6584	.9526	.6478		.7621
4	1.1431	1.1431	.6878	1.0479	.8002		.8383
5	1.2384	1.2384	.6859	1.1431	.7621		.9145
6	1.3336	1.2384	.7545	1.2384	.7621		1.0669
7	1.5242	1.2955	.9496	1.3336	.8002		1.2574
8	1.3527	1.3336	1.0486	1.4289	.9145		.9907
9	1.2384	1.0486	.9175	1.3336	.9526		.8764
10	1.0479	1.0669	1.0669	1.2384	.9526		1.0479
11	1.1431	.8383	.9526	.7621	.9526	.8192	.9526
12	1.1431	.7621	.8573	.8002	.9526	.6783	.8954
13		.7621	.8954	.9145	.8573	.6478	.8573
14	1.1431	.7621	.9335	.9526	.7621	.6154	.9145
15		.7621	.9526	.9145	.7621	.6478	.9526
16	.9145	.8002	1.0098	.9526	.7621	.7125	.9526
17	.9526	.8764	1.0479		.7621	.7209	
18	.9907	1.0288	1.1431		.9526	.7865	
19	1.0669	1.3336	1.0288	1.1431	.9526	1.2574	
20	1.0479	1.2574	.9907	.9907	.9526	1.3336	
21	1.086	1.0669	.9526	.9526	.9526	1.2574	
22	1.1431	1.0288	.8573	.9145	1.0479	.9526	
23	1.3336	.9526	.7621	.8002	.8573	.8383	
24	.8573	1.2384	.6348	.743	.7621		.8383
Max	1.5242	1.3336	1.1431	1.4289	1.0479	1.3336	1.2574
Min	.8573	.7621	.4481	.6668	.6478	.6154	.7621
Avg	1.1163	1.0630	.8681	.9994	.8526	.8667	.9201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 202 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0479	.7468	.7621	.7621		.8215
2	.8954	1.105	.7842	.8192	.8192		.8215
3	.9526	1.086	.8215	.8573	.8002		.8589
4	1.0288	1.1622	.8688	.9526	.9145		.8501
5	1.0669	1.105	.9145	.9907	1.0479		.9145
6	1.105	1.1431	1.0242	1.0669	1.1812		1.0242
7	1.2955	1.2384	1.1706	1.2003	1.1812		1.1043
8	1.1431	1.3336	1.0974	1.2384	1.1622		1.0136
9	.9526	.9412	1.0242	1.1812	.8573		1.0136
10	.9526	.724	.7316	1.105		.7316	
11	.8573	.7602	.7621	.9145		.6878	
12	.8002	.7602	.8764	.8573		.6878	
13	.9907	.724	.8954	.9145		.6516	
14	.7621	.7964	.8573	.8954		.6878	
15	.7621	.7964	.8954	.9526		.7164	
16	.8573	.8326	1.0288	.9526		.8326	
17	.8573	.9774	.9907	1.105		.8688	
18	1.0479	1.086	1.0669	1.1431		.9412	
19	1.1431	1.1946	1.3336	1.2384		1.1946	
20	.9526	1.086	1.1812	1.2955		1.1584	
21	1.0479	.9511	1.0288	1.3336		1.0974	
22	1.105	.8962	.9526	1.1431		.9511	
23	1.1431	.7468	.8573	1.0479		.8779	
24	.8573	1.1431	.7468	.8002	.8002		.8215
Max	1.2955	1.3336	1.3336	1.3336	1.1812	1.1946	1.1043
Min	.7621	.724	.7316	.7621	.7621	.6516	.8215
Avg	.9764	.9849	.9440	1.0320	.9526	.8632	.9244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 203 / 11 KV RAIPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.8002	.381	.4191	.381		.4954
2	.4763	.8383	.4191	.4763	.3429		.4954
3	.6859	.8764		.5716	.4763		.5335
4	.5335	.9526		.5335	.6859		.6097
5	.5716	.9145		.5716	.8573		.7621
6	.6097	.7621	.5335	.5906	.9145		.8764
7	.6097	.7621	.5898	.9526	.7621		.8383
8	.8573	.8002	.7209	1.0288	.6859		.6478
9	.7049	.4954	.7621	.7621	.5335		.4954
10	.724	.5716	.2286	.4191			
11	.9335	.2286	.1524	.381		.4915	
12	.1905	.1905	.1334	.0191		.4481	
13	.2286	.1905	.1143	.3048		.421	
14	.4191	.1524	.1143	.2667		.4161	
15	.1524	.1524	.1143	.1905		.4534	
16	.2286	.1905	.1905	.2286		.4858	
17	.2286	.1905	.2858	.2667		.4915	
18	.5335	.2286	.3048	.4763		.4915	
19	.6097	.6097	.5335	.5716		.7621	
20	.5716	.6859	.6097	.5335		.6859	
21	.6097	.5716	.5716	.6097		.5716	
22	.724	.4954	.5144	.5716		.5716	
23	.6668	.4191	.4572	.4763		.4954	
24	.5716	.7621	.381	.4191			.4954
Max	.9335	.9526	.7621	1.0288	.9145	.7621	.8764
Min	.0381	.1524	.1143	.0191	.3429	.4161	.4954
Avg	.5200	.5351	.3863	.4850	.6266	.5220	.6249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 204 / 11 KV MALIWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.2384	.5716	.5716	.724		.4481
2	.9526	1.2955	.6097	.8573	.8002		.4755
3	1.1431	1.2384	.7621	1.0479	.9145		.5487
4	1.3336	1.3336	1.0669	1.2384	.7621		.5487
5	1.4289	1.3717	1.2574	1.3336	.8002		.5853
6	1.4861	1.5242	1.5242	1.4289	.8573		.5792
7		1.2384	1.3336	1.5051	.8002		.9259
8	1.2955	1.1431	1.1431	1.2574	.7621		.9602
9	.9145	.8764	.8676	.9907	.6097		.6104
10	.9145	.7621	.6097	.8383			
11	.9335	.8002	.5335	.8383		.3048	
12	.9526	.4748	.4954	.5335		.3048	
13	.4954	.4409	.4572	.5525		.3048	
14	.4191	.407	.381	.4763		.2667	
15	.381	.3391	.381	.4191		.3048	
16	.4191	.3391	.4001	.4191		.3429	
17	.6668	.3391	.4763	.4763		.3772	
18	.7621	.3391	.4572	.6668		.4572	
19	.9907	.8383	.8764	.8002		1.0669	
20	.9526	.9526	1.0288	.7811	.7811	.9431	
21	.9907	.8383	.8764	.7621	.7621	.8764	
22	.9907	.724	.7621	.8002	.8002	.7621	
23	1.1431	.6097	.5906	.8192	.8192	.6478	
24	.6668	1.2384	.5716	.5144	.7621		.4481
Max	1.4861	1.5242	1.5242	1.5051	.9145	1.0669	.9602
Min	.381	.3391	.381	.4191	.6097	.2667	.4481
Avg	.9128	.8626	.7514	.8303	.7825	.5353	.6130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 206 / 11 kv GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.1334	.0572	.0762		.0572
2	.0572	.0572	.1334	.0572	.0762		.0572
3	.0572	.0762	.1334	.0572	.0762		.0572
4	.0572	.0762	.1334	.0572	.0762		.0572
5	.0572	.0762	.1334	.0572	.0762		.0572
6	.0572	.0762	.1524	.0572	.0762		.0572
7	.0572	.0762	.1524	.0572	.0762		.0572
8	.0572	.0762	.0762	.0762	.0762		.0572
9	.0572	.0572	.0762		.0762		.0572
10	.0572	.0572	.0381	.0572			
11	.0572	.0572	.0572			.0572	
12	.0572	.0572	.0572	.0381		.0572	
13	.0572	.0572	.0572	.0381		.0572	
14	.0762	.0572	.0572	.0381		.0572	
15		.0572	.0572	.0381		.0572	
16	.0762	.0572	.0572	.0572		.0572	
17	.0572		.0572	.0572		.0572	
18	.0572	.0572	.0572	.0572		.0572	
19	.0572	.0572	.0572	.0762		.0572	
20	.0572	.0762	.0572	.0572		.0572	
21	.0572	.1524	.0572	.0572		.0572	
22		.1524	.0572	.0572		.0572	
23	.0762	.1334	.0572	.0762		.0572	
24	.0572	.0762	.1334	.0572	.0762		.0572
Max	.0762	.1524	.1524	.0762	.0762	.0572	.0572
Min	.0572	.0572	.0381	.0381	.0762	.0572	.0572
Avg	.0598	.0762	.0850	.0563	.0762	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 208 / SULTANABAD AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.2667	.3239	.5525		.3429
2		.8002	.2667	.381	.5716		.3429
3		.8192	.2926	.4191	.5335		.381
4		.7621	.3086	.4572	.5144		.4191
5		.724	.3429	.4382	.5906		.4572
6	.4954	.6287	.407	.4382	.6287		.5716
7	.6859	.724	.4915	.6859	.5716		.6097
8	.7621	.7621	.6783	.743	.4763		.5716
9	.6668	.381	.6104	.6859	.3048		
10	.1905	.2667	.381	.362			
11	.1715	.2286	.1524	.2858		.5087	
12	.1524	.1905	.1143	.1905		.4534	
13	.1143	.1524	.1524	.1524		.421	
14	.1334	.1524	.1524	.1334		.421	
15		.1524	.1524	.1143		.4161	
16	.1524	.1524	.1524	.1524		.4534	
17	.2477	.1905	.1715	.1905		.4858	
18	.3429	.2667	.2477	.381		.4915	
19	.5144	.4572	.4191	.4572		.4572	
20	.5716	.4572	.5144	.5716		.381	
21	.6668	.3429	.3048	.6097		.3429	
22	.7621	.2667	.2667	.5716		.3429	
23	.7621	.2667	.2096	.4763		.3048	
24		.7811	.2667	.4191	.5335		.3048
Max	.7621	.8573	.6783	.743	.6287	.5087	.6097
Min	.1143	.1524	.1143	.1143	.3048	.3048	.3048
Avg	.4348	.4493	.3051	.4017	.5278	.4215	.4445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 201 / 11 KV SILLEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.724	.7316	.6201
2	.0953	.0953	.0953	.0953	.724	.7316	.6935
3	.0953	.0953	.0953	.0953	.8059	.9145	.6935
4	.0953	.0953	.0953	.0953	.7973	1.0745	.8573
5	.0953	.0953	.0953	.0953	.8764	1.1641	1.0174
6	.0953	.0953	.0953	.0953	1.0288	1.2536	1.1736
7	.0953	.0953		.0953	1.1022	1.3146	1.2431
8	.0953	.0953	.0476	.0953	1.1603	1.2003	1.3413
9	.0476	.0476	.0476	.0476	.8669	1.0517	1.1269
10	.0476	.0476	.0953	.0953	.0953	.0476	.0476
11	1.1022	1.0402	1.0174	1.0402	.0476	.0476	.0476
12	1.0031	.9536	1.0174	1.0631	.0953	.0476	.0476
13	1.0174	.8573	.9221	.9431	.0476	.0476	.0476
14	.9431	.8478	.8478	.8383	.0476	.0476	.0476
15		.8383	.8383	.8383	.0476	.0476	.0476
16	.8764	.8478	.9326	.8383	.0476	.0476	.0476
17	.9431	.8669	.9326	.9536	.0476	.0476	.0476
18	.9431	.8669	.9431	.8669	.0476		.0476
19	.0953	.1905	.0953	.0476	.0476	.0476	.0476
20	.0953	.0953	.0953	.0476	.0476	.0476	.0476
21	.0953	.0953	.0953	.0476	.0476	.0476	.0476
22	.0953	.0953	.0953	.0476	.0476	.0476	.0476
23	.0953	.0953	.0953	.0476	.0476	.0476	.0476
24	.0953	.0953	.0953	.0953	.724	.7316	.6201
Max	1.1022	1.0402	1.0174	1.0631	1.1603	1.3146	1.3413
Min	.0476	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.3590	.3601	.3820	.3592	.3988	.4690	.4189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 202 / 11KV MALUNJA (BK) AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8859	.8478	.8859	.8954	.1905	.0953	.1905
2	.8859	.8478	.8859	.8954	.1905	.0953	.1905
3	.9536	1.0059	1.0402	1.0631	.1905	.0953	.1905
4	1.3717	1.4251	1.2003	1.3003	.1905	.0953	.1905
5	1.6956	1.4918	1.5261	1.4575	.2858	.1429	.2858
6	1.8442	1.5746	1.6766	1.8861	.2858	.1905	.2858
7	2.0719	1.7404	1.989	2.0576	.381	.1905	.2858
8	2.4006	2.1195	2.1052	2.0319	.2858	.1429	.2858
9	2.1672	1.2041	1.9281	1.8652	.2858	.1429	.1905
10	.1905	.1429		.1429	.1905	.0953	.1905
11	.0953	.1905	.0953	.2858	1.9071	1.8204	1.8861
12	.0476	.0953	.0476	.2858	2.3405	2.0157	1.9719
13	.0476	.0953	.0476	.1905	2.1795	1.9071	1.9719
14	.0476	.0953	.0476	.0953	2.0119	1.8004	1.8861
15		.0953	.0476	.0953	1.8861	1.7337	1.8861
16	.0476	.0953	.0476	.0953	1.8861	1.7528	1.4899
17	.0476	.0953	.0476	.0953	1.8442	1.9281	1.5432
18	.0476	.0953	.0476	.0953	1.7147	1.7528	1.5432
19	.0476	.2858	.0476	.2858	.1429	.2858	.1429
20	.0953		.0953	.2858	.1429	.2858	.1429
21	.0953	.2858	.0953	.2858	.1429	.2858	.1429
22	.0953	.1905	.0953	.2858	.0953	.2858	.0953
23	.0953	.1905	.0953	.1905	.0953	.1905	.0953
24	.8954	.8478	.8859	.9145	.1905	.0953	.1905
Max	2.4006	2.1195	2.1052	2.0576	2.3405	2.0157	1.9719
Min	.0476	.0953	.0476	.0953	.0953	.0953	.0953
Avg	.7031	.6547	.6513	.7118	.7940	.7261	.7198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 203 / 11 KV GAJGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3201	.3467	.3125	.1905	.0953	.0953
2	.3544	.3201	.3467	.3125	.1905	.0953	.0953
3	.4334	.3715	.4239	.3858	.1905	.0953	.0953
4	.4287	.3715	.4239	.4687	.1905	.0953	.0953
5	.5087	.4458	.4973	.5401	.1905	.1905	.0953
6	.663	.5335	.6554	.6097	.1905	.1905	.1905
7	.7287	.5639	.7287	.6859	.1905	.1905	.1905
8	.8002	.6773	.703	.7526	.0953	.1905	.1905
9	.7202	.381	.6249	.6859	.0953	.0953	.0953
10	.0953	.0953	.0953	.1905	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.6068	.4001	.5601
12	.0953	.0953	.0953	.0953	.6001	.4115	.5601
13	.0953	.0953	.0953	.0953	.5601	.4001	.5601
14	.0953	.0953	.0953	.0953	.5601	.3429	.3125
15	.0953	.0953	.0953	.0953	.5601	.3525	.3906
16		.0953	.0953	.0953	.4801	.4458	.4801
17	.0953	.0953	.0953	.0953	.4801	.3715	.5601
18	.0953	.0953	.0953	.0953	.5601	.4572	.5601
19	.0953	.0953	.0953	.1905	.0953	.0953	.0953
20	.0953	.0953	.0953	.1905	.0953	.0953	.0953
21	.0953	.0953	.0953	.1905	.0953	.0953	.0953
22	.0953	.0953	.0953	.1905	.0953	.0953	.0953
23	.0953	.0953	.0953	.1905	.0953	.0953	.0953
24	.3544	.3201	.3467	.3163	.1905	.0953	.0953
Max	.8002	.6773	.7287	.7526	.6068	.4572	.5601
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.2863	.2350	.2680	.2906	.2789	.2120	.2414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 204 / 11 KV KATEPIMPALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.6173	.7087	.6325	.2858	.2858	.2858
2	.7087	.6173	.7087	.6325	.2858	.2858	.2858
3	.7888	.6944	.8669	.8592	.2858	.2858	.2858
4	.8573	.7621	1.0288	.9374	.2858	.2858	.2858
5	1.1736	1.0669	1.1736	1.1574	.2858	.381	.2858
6	1.4089	1.0669	1.4089	1.2193	.381	.381	.381
7	1.6385	1.1431	1.6385	1.448	.381	.381	.381
8	1.7814	1.3717	1.7814	1.6004	.381	.381	.381
9	1.4575	.8916	1.2146	1.3546	.2858	.2858	.2858
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	1.387	1.186	1.3927
12	.1905	.1905	.1905	.1905	1.7337	1.2146	1.3108
13	.1905	.1905	.1905	.1905	1.4746	.9717	1.1469
14	.1905	.1905	.1905	.1905	1.3108	.9717	1.065
15	.1905	.1905	.1905	.0953	1.1469	.9717	1.1469
16	.1905	.1905	.1905	.1905	1.2289	1.1603	1.1469
17	.1905	.1905	.1905	.1905	1.1469	1.4089	1.065
18	.1905	.1905	.1905	.1905	1.1469	1.2431	1.065
19	.1905	.2858	.1905	.2858	.2858	.2858	.2858
20	.1905	.381	.1905	.2858	.381	.2858	.381
21	.1905	.381	.1905	.2858	.381	.2858	.381
22	.2858	.2858	.2858	.2858	.2858	.2858	.381
23	.2858	.1905	.2858	.2858	.2858	.2858	.381
24	.7087	.6249	.7087	.6325	.2858	.2858	.2858
Max	1.7814	1.3717	1.7814	1.6004	1.7337	1.4089	1.3927
Min	.1905	.1905	.1905	.0953	.1905	.1905	.1905
Avg	.5871	.5040	.5874	.5634	.6471	.5828	.6035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 205 / 11 KV SHILLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5201	.5316	.5316	.5316	.5144	.5316
2	.6201	.5201	.7164	.5258	.5316	.5144	.5316
3	.8145	.7802	.905	.7888	.7164	.7011	.8059
4	1.2936	1.1022	1.1088	.9431	1.1088	1.0745	1.086
5	1.4937	1.3565	1.4937	1.2003	1.4003	1.4937	1.4937
6	1.7918	1.5089	1.7918	1.3565	1.7918	1.7918	1.7918
7	1.7918	1.6766	1.6975	1.6108	1.7918	1.7918	1.7918
8	1.4937	1.4413	1.4937	1.3717	1.4003	1.587	1.2936
9	1.2012	1.1869	1.1088	1.2136	1.1088	1.0974	1.086
10	.8145	.8669	.7164	1.0402	.8145	.8954	.7164
11		.5316	.5258	.8145	.7164	.5316	.5144
12		.3506	.5144	.7164	.5316	.443	.4287
13	.5144	.3506	.4191	.5316	.4287	.5316	.4287
14	.4334	.3506	.4191	.5316	.4287	.5316	.4287
15		.0857	.4334	.5316	.4287	.5316	.4287
16	.4239	.443	.4334	.5316	.5144	.5316	.4287
17	.5868	.6268	.5201	.6268	.5144	.6268	.5258
18	.6783	.7164	.7011	.7164	.6135	.6268	.6268
19	.6706	1.2012	.823	1.2012	1.1203	1.1088	1.2136
20	.763	1.2936	.7802	1.2012	1.1203	1.2936	1.0974
21	.7716	.905	.8669	.905	.9145	.905	.8954
22	.6783	.7164	.7316	.7164	.7011	.7164	.7164
23	.5935	.5316	.5316	.5316	.6135	.6268	.6135
24	.5316	.5201	.5316	.5316	.5316	.5144	.5316
Max	1.7918	1.6766	1.7918	1.6108	1.7918	1.7918	1.7918
Min	.4239	.0857	.4191	.5258	.4287	.443	.4287
Avg	.8806	.8160	.8248	.8612	.8489	.8742	.8336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 206 / 11 KV Shahapur AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.1429	.2858	.1429	.3544	.3734	.3544
2	.2858	.1429	.2858	.1429	.3544	.3658	.3544
3	.2858	.1429	.2858	.1429	.4382	.4572	.4334
4	.2858	.1429	.2858	.1429	.5201	.6268	.5087
5	.2858	.1429	.2858	.1429	.6859	.8059	.5868
6	.381	.1429	.381	.1429	.8478	.8764	.663
7	.381	.1905	.381	.1905	.9221	.964	.8288
8	.381	.1429	.381	.1429	.9116	.964	.9221
9	.2858		.2858	.1429	.6935	.8764	.7888
10	.1905	.0953	.1905	.1429	.0953	.0953	.0953
11	.6859	.6201	.6706	.7973	.0953	.0953	.0476
12	.6859	.6201	.6706	.7087	.0953	.0953	.0476
13	.7011	.6201	.602	.7011	.0476	.0953	.0476
14	.7087	.6135	.5868	.5868	.0476	.0953	.0476
15	.6783	.6135	.5868	.6135	.0476	.0953	.0476
16	.6783	.6201	.7011	.6135	.0476	.0953	.0476
17	.5868	.7011	.6783	.6135	.0476	.0953	.0476
18	.5868	.7011	.6859	.6135	.0476	.0953	.0476
19	.0953	.2858	.0953	.1905	.1429	.2858	.0953
20	.0953	.2858	.0953	.1905	.1429	.1905	.1429
21	.1429	.2858	.1429	.1905	.1429	.1905	.0953
22	.1429	.2858	.1429	.1905	.0953	.1905	.0953
23	.1429	.2858	.1429	.1905	.0953	.0953	.1905
24	.2858	.1429	.2858	.1429	.3582	.3734	.3544
Max	.7087	.7011	.7011	.7973	.9221	.964	.9221
Min	.0953	.0953	.0953	.1429	.0476	.0953	.0476
Avg	.3861	.3464	.3806	.3258	.3032	.3539	.2871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 207 / 11 KV Wadali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0953	.1905	.0953	.3544	.3734	.5316
2	.1905	.0953	.1905	.0953	.3544	.3658	.5316
3	.1905	.0953	.1905	.0953	.3544	.4572	.7011
4	.1905	.0953	.1905	.0953	.7011	.7164	.8669
5	.1905	.0953	.1905	.0953	.8573	.985	1.0174
6	.1905	.1429	.2858	.0953	1.0059	1.2003	1.1736
7	.1905	.1429	.2858	.1429	1.1603	1.3413	1.326
8	.1905	.0953	.1905	.1429	1.1603	1.286	1.4251
9	.1905	.0476	.1905	.0953	1.0517	1.2003	1.0517
10	.0953	.0476	.0953	.0476	.0953	.0476	.0953
11	1.1022	.8669	1.1869	1.0174	.0953	.0953	.0476
12	1.1869	.964	1.2003	1.0288	.0953	.0953	.0476
13	1.2003	.8764	1.1603	1.0174	.0476	.0953	.0476
14	1.1869	.7973	.9116	.9116	.0476	.0953	.0476
15	1.1736	.8764	1.0288	.9536	.0476	.0953	.0476
16	1.1736	.8764	1.0288	.964	.0476	.0953	.0476
17	1.0898	.964	1.0402	1.0517	.0476	.0953	.0476
18	1.0174	.8764	.9431	.8764	.0476	.0953	.0476
19	.0953	.0953	.0953	.0953	.0953	.1905	.0953
20	.0953	.1905	.0953	.0953	.0953	.1905	.0953
21	.0953	.1905	.0953	.0953	.0476	.1905	.0953
22	.0953	.1905	.0953	.0953	.0476	.1905	.0953
23	.0953	.1905	.0953	.0953	.0476	.0953	.0953
24	.1905	.0953	.1905	.0953		.3734	.5316
Max	1.2003	.964	1.2003	1.0517	1.1603	1.3413	1.4251
Min	.0953	.0476	.0953	.0476	.0476	.0476	.0476
Avg	.4836	.3751	.4653	.3914	.3437	.4153	.4212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 208 / 11 KV Katepimpalgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2543	.2658	.2772	.2658	.2572	.2658
2	.2658	.2515	.2658	.2772	.2658	.2572	.2658
3	.3582	.2515	.3582	.3658	.3582	.3506	.3582
4	.543	.4191	.543	.543	.543	.5373	.543
5	.7392	.5087	.6401	.6335	.7392	.7316	1.1088
6	.8402	.6001	.8402	.7087	.8402	.8402	.8402
7	.8402	.7545	.8402	.7716	.8402	.8402	.8402
8	.6468	.6706	.7392	.6001	.6468	.7468	.7392
9	.543	.5087	.543	.5935	.4525	.5487	.543
10	.0876	.3391	.4477	.4239	.3582	.4477	.3582
11	.2601	.2658	.2686	.4477	.3582	.2658	.2572
12	.1753	.1753	.1696	.3582	.2658	.1753	.2572
13	.181	.1753	.1715	.2658	.2572	.1753	.2572
14	.1715	.1753	.2572	.2658	.2572	.1753	.1715
15	.1772	.1753	.2601	.2658	.2572	.1753	.2572
16	.2601	.2658	.2572	.2658	.2572	.2658	.2572
17	.3391	.2658	.2515	.3582	.2572	.2658	.2572
18	.4239	.3582	.3658	.3582	.3506	.2658	.3506
19	.4287	.5544	.3506	.6468	.6535	.543	.6535
20	.3467	.6535	.3506	.5544	.5487	.6468	.6401
21	.3391	.4525	.4382	.4525	.4477	.543	.5373
22	.2543	.3582	.3658	.3582	.3506	.4477	.4382
23	.2515	.2658	.3658	.2658	.2572	.3582	.3429
24	.2658	.2258	.2658	.2772	.2658	.2572	.2658
Max	.8402	.7545	.8402	.7716	.8402	.8402	1.1088
Min	.0876	.1753	.1696	.2658	.2572	.1753	.1715
Avg	.3752	.3719	.4009	.4306	.4206	.4216	.4502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 201 / 11KV JAMGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6578	1.6232	2.4459	2.1262	1.5684	1.363	1.4003
2	3.1687	1.7147	2.5206	2.2291	1.6244	1.4377	1.4377
3	2.8807	2.572	2.4006	2.4006	1.643	1.4937	1.4937
4	2.915	2.7092	2.894	2.572		1.5684	1.531
5	2.915	2.8292	1.8061	2.7435		1.643	1.5684
6	2.9835	2.915	1.8861	2.8292			
7	2.0348	3.263	3.2114	2.9835			
8	3.0864		2.8978	2.7263			
9	2.8978		2.7435	2.5549			
10	.823		.5601	.9431	.9602		
11			.5228	.9088	2.8464		3.5101
12		.6722	.4668		3.035		3.4168
13		.4108	.4854		3.2065	2.8481	3.4541
14		.3734	.4668		3.0007	2.8635	3.3794
15			.5228		2.8978	3.4139	3.2861
16		.6161			3.0178	3.1379	3.4355
17					3.0007	3.4728	3.2579
18					3.0007	3.5475	3.5475
19	2.1472	1.643	1.5684	1.7737	1.4146	1.2696	1.2883
20	1.1203	1.251	1.587	1.7177	1.2517	1.475	1.307
21	1.2136	1.1576	1.2323	1.6804	1.2517	1.531	1.419
22	1.307	1.1576	1.2323	1.7177	1.2517	1.5123	1.363
23	1.251	1.0642	1.1576	1.6057	.8116	1.4003	1.3817
24	2.3491	2.332	2.2805	2.0748	1.5684	1.3443	1.3443
Max	3.1687	3.263	3.2114	2.9835	3.2065	3.5475	3.5475
Min	.823	.3734	.4668	.9088	.8116	1.2696	1.2883
Avg	2.2344	1.6650	1.6614	2.0934	2.0751	2.0778	2.2538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 202 / 11KV L.I.S. FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6578	2.5206	2.7446	2.5206	.2241	.2427	.1867
2	2.7092	2.6235	2.6063	2.5377	.2241	.2427	.1867
3	2.7435	2.9801	2.7435	2.572	.2614	.2427	.2054
4	1.8747	2.7949	2.7778	2.7435	.2614	.2614	.1867
5	1.8747	3.1121	2.8292	2.8292	.2987	.2801	.2054
6	2.915	2.9492	2.9492	2.8464	.2987	.2987	.3174
7	3.155	1.989	3.2861	2.8635	.3921	.2987	.3961
8	3.3265		2.7263	2.8121	.3961	.2987	.2286
9	3.3436		2.692	2.7949	.3258	.3584	.3086
10	.3547		.2614	.4294	.2058	.3258	.4115
11	.3086	.1886	.2614	.3361	3.0007	3.4294	3.4808
12	.3361	.3361	.3361	.3921	3.4294	3.6008	4.2438
13	.3361	.3547	.3361	.3174	3.6694	3.6866	4.2816
14	.3174	.3361	.3086	.3547	3.6866	3.7037	3.858
15		.3734	.3361	.3921	3.6866	2.1491	2.4463
16	.2987	.3734	.3361	.4294	3.4465	3.7037	3.7209
17	.2987	.4481	.3734	.3921	3.275	3.9209	3.7529
18	.2801	.3921	.3734	.3174	3.275	3.9396	3.5475
19	.3361	.3734	.3734	.3921	.4115	.3547	
20	.3174	.3547	.3174	.2987	.4115	.2987	.2614
21	.2987	.2987	.2801	.2801	.3601	.2987	.2427
22	.2987	.2801	.2054	.2614	.3086	.2801	.2241
23	.2427	.2427	.1867	.2427	.2743	.2241	.168
24	2.6578	2.5034	2.4177	2.4863	.1867	.2614	.2241
Max	3.3436	3.1121	3.2861	2.8635	3.6866	3.9396	4.2816
Min	.2427	.1886	.1867	.2427	.1867	.2241	.168
Avg	1.3601	1.2298	1.3358	1.3267	1.3463	1.3626	1.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 203 / 11KV NEVARGAON 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.547	.4801	.5415	1.9204	1.9547	2.0233
2	.5658	.5144	.3429	.5601	1.9204	1.9547	2.1262
3	.5658	.5658	.5658	.6348	1.9547	2.0233	2.1948
4	.6516	.6516	.7095	.6908	1.989	2.0576	2.4253
5	.4572	.9431	.7888	.8962	2.0233	2.0919	2.332
6	.9431	.8745	.9259	1.0456	2.2779	2.1262	2.6063
7	1.046	1.0974	1.046	1.1949	2.4006	2.4348	3.2253
8	.8916		.6744	1.0642	2.572	2.5377	2.8464
9	.8402		.7202	.8775	2.4691	2.4143	2.7092
10	.5228		.4481	.8402		.463	.3429
11	2.6513	2.6578	3.0994	3.1554	.3086	.5144	.4115
12	3.3794	3.0247	2.95	2.915	.3258	.3258	.3258
13	2.7778	3.1367	2.9874	3.1741	.3258	.2515	.3258
14	2.8597	3.0434	3.006	3.2301	.3429	.3772	.4287
15	2.4006	3.062	2.6406	3.2487	.3429	.3258	.4115
16	2.9127	3.1927	3.035	3.0007	.3258	.3601	.4287
17	3.1741	2.9321	2.9835	2.8807	.4338	.5144	.4854
18	2.915	2.8121	2.9664	2.7263	.4715	.5415	.5228
19	.9709	1.0082	1.1016	.8059	.7716	.8402	.8215
20	.8589	.8775	.8962	.8402	.7545	.7468	.7655
21	.7842	.7282	.6908	.6348	.4344	.6535	.6161
22	.6535	.6348	.6348	.5975	.5658	.5788	.5601
23	.5788	.5601	.5601	.5228	.4904	.5228	.5601
24	.5316	.4801	.4801	.5415	1.8861	1.8004	2.1538
Max	3.3794	3.1927	3.0994	3.2487	2.572	2.5377	3.2253
Min	.4572	.4801	.3429	.5228	.3086	.2515	.3258
Avg	1.4360	1.5878	1.4472	1.5258	1.1873	1.1838	1.3187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0514	.056	.056	.0747	.112
2	.0762	.0343	.0343	.056	.056	.0934	.0747
3	.0572	.0343	.056	.056	.0934	.056	.056
4	.0953	.0377	.0343	.056	.056	.0747	.056
5	.0857	.0686	.0514	.056	.056	.0373	.056
6	.0343	.0457	.0857	.056	.056	.056	.056
7	.0572	.12	.0857	.056	.1494	.112	.0934
8	.0381		.0343	.056	.0514	.056	.0566
9	.0343		.0343	.056	.2058	.0514	.0343
10	.0754		.056	.0747	.0857	.1029	.0377
11	.0747	.0514	.056	.0373	.1543	.12	.0343
12	.1867	.0747	.0934	.0747	.0686	.0514	.0343
13	.1867	.112	.0747	.056	.1715	.12	.0377
14	.168	.168	.0373	.1307	.1494	.0514	.0514
15	.0747	.168	.056	.1307	.12	.0686	.0514
16	.056	.112	.112	.056	.0686	.132	.0343
17	.112	.0934	.056	.168	.1698	.1494	.056
18	.056	.0747	.0747	.168	.0566	.0747	.056
19	.112	.1867	.0934	.0373	.0377	.056	.1307
20	.056	.056	.056	.112	.0514	.112	.0747
21	.0747	.112	.056	.0373	.1372	.0747	.056
22	.112	.112	.0373	.1307	.0566	.1307	.112
23	.056	.056	.112	.0373	.0514	.2054	.0934
24	.1334	.0686	.0572	.056	.1494	.056	.0747
Max	.1867	.1867	.112	.168	.2058	.2054	.1307
Min	.0343	.0343	.0343	.0373	.0377	.0373	.0343
Avg	.0867	.0875	.0623	.0754	.0962	.0882	.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 205 / 11Kv KANADGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2172	.2987	.2427	2.3663	2.4863	2.3663
2	.2172	.3429	.3361	.2801	2.3663	2.4863	2.6063
3	.3601	.3772	.4108	.3174	2.4006	2.6787	2.6787
4	.3086	.3086	.4458	.4668	2.4691	2.7511	2.572
5	.6516	.6001	.5487	.6348	2.5377	2.8597	2.6578
6	.7716	.6687	.6344	.7282	2.6749	2.7435	3.0407
7	.8059	.8059	.7373	.8215	2.915	2.7949	3.4139
8			.4344	.7282	2.9492	2.8635	3.4139
9				.6516	2.8464	2.7435	3.2819
10	.3921		.2987		.2572		.5144
11	3.2861	2.999	3.3234		.2058		.3601
12	3.5848	3.0434	3.4915	3.035	.1029	.2263	.1886
13	3.275	3.1367	3.3981	3.035	.1715	.1886	.1886
14	3.5294	3.6595	3.1036	3.1893	.1543	.1886	.1886
15	3.1036	3.2922	3.035	3.3436	.1543	.1886	
16	3.2407	3.4168	3.2065	3.275	.1886	.2263	.1867
17	3.1722	3.1207	3.5294	3.2236	.3429	.2987	.4108
18	3.0178	3.0864	3.2236	3.0864	.3601	.3361	
19	.6348	.6908	.5487	.6722	.4801	.5975	.6535
20	.5415	.5788	.4668	.5228	.4973	.5601	.5975
21	.4854	.4108	.3734	.4481	.3601	.4481	.4481
22	.4294	.3361	.3174	.3921	.3429	.3921	.3734
23	.3734	.3361	.2614	.3361	.3429	.2614	.3361
24	.3086	.3086	.2743	.2427	2.2977	2.452	2.3148
Max	3.5848	3.6595	3.5294	3.3436	2.9492	2.8635	3.4139
Min	.2172	.2172	.2614	.2427	.1029	.1886	.1867
Avg	1.4908	1.5113	1.4217	1.3488	1.2410	1.3987	1.4906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 206 / 11 KV NEW LIS SHANTAI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4481	.4481	.2715	.3439	.362
2	.3601		.4715	.4668	.2715	.3258	.362
3	.3601		.4715	.4668	.2801	.3258	.362
4	.2743		.4715	.4668	.2896	.3258	.362
5	.4115		.4287	.4668	.2896	.3439	.362
6	.4287		.4715	.4668	.2896	.3439	.3801
7	.2858		.4458	.4668	.2896	.3077	.3601
8	.3601		.3368	.4668	.2987	.3258	.3429
9	.4527		.4458	.4338	.3018	.3395	.3429
10	.4294		.4854	.3944	.3772	.3584	.3601
11	.4294		.5228	.4287	.3772	.3584	.3601
12	.4481		.5041	.3944	.3772	.3258	.4527
13	.4163		.4854	.2915	.3944	.3601	.4115
14	.4163		.4854	.2172	.4294	.415	.3395
23	.2054		.4163	.2801	.3258	.3734	.3077
24	.3429	.1886		.4481	.2715	.3439	.362
Max	.4527	.1886	.5228	.4668	.4294	.415	.4527
Min	.2054	.1886	.3368	.2172	.2715	.3077	.3077
Avg	.3728	.1886	.4594	.4127	.3209	.3448	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 207 / 11KV BAGADI Ag 1-PHASING SINGLE PHASING
FEEDE Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3395	.3258	.3547	.5611	.7373	.7964
2	.3429	.3258	.3429	.3921	.5973	.7545	.7888
3	.3429	.3601	.4108	.4668	.6335	.7888	.8573
4	.2743	.4115	.2743	.5228	.6516	.823	.9088
5	.463	.5093	.5041	.5975	.7202	.8916	.9602
6	.6687	.6001	.5658	.6722	.7716	.9088	1.0288
7	.4687	.6001	.6344	.7468	1.046	1.0802	1.363
8	.5144		.583	.6535	1.046	1.1317	1.2346
9	.4854			.6535	.9945	1.1145	1.1317
10	.2987		.3547	.5975	.2058		.4115
11	1.1203	.9774	.9896	1.1145	.1372		.3086
12	1.0317	1.0456	1.0269	1.2136	.1543		.1715
13	.9602	1.0082	1.0456	1.1145	.1715		.1715
14		.8589	1.1203	1.0631	.1715		.1715
15	.9945	.9709	.9774	1.0974	.1715		.1715
16	1.1145	.9896	1.1203	1.0288	.1886	.2229	.2058
17	1.046	.9259	1.0802	1.0288	.2401	.2614	.2614
18	1.0117	.9088	1.0456	1.1222	.3086	.2987	.2987
19	.4458	.5975	.6535	.5975	.5228	.5415	.5228
20	.4481	.5041	.5228	.5228	.463	.4854	.4854
21	.4108	.3961	.4108	.4668	.4115	.4294	.3944
22	.362	.3547	.4108	.4294	.3772	.4294	.3921
23	.3361	.3547	.3734	.3734	.415	.3734	.3734
24	.3258	.3395	.3258	.3547	.543	.703	.724
Max	1.1203	1.0456	1.1203	1.2136	1.046	1.1317	1.363
Min	.2743	.3258	.2743	.3547	.1372	.2229	.1715
Avg	.6011	.6371	.6565	.7160	.4793	.6653	.5889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 201 / 11 KV BHENDALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762	.0953	.0953	2.0957	1.9433	1.9052
2	.1524	.0762	.0953	.1143	1.9052	1.9433	1.9052
3	.1524	.0762	.0953	.1143	1.9052	2.0576	1.9433
4	.1524	.0762	.0953	.1143	1.9433	2.0957	1.9433
5	.1334	.0762	.0953	.1143	1.9433	2.0957	1.9814
6	.1334	.0762	.0953	.1143	1.9433	2.1338	1.9814
7	.1334	.0762	.0953	.0762	2.0576	2.1338	2.0195
8	.0953		.0953	.0762	2.0386	2.1719	2.0195
9	.1143	.0762	.0953	.0762	1.9624	2.0957	1.9624
10	.1334	.0762	2.2862	.0762	.1143	.0762	.0762
11	2.4958		2.2862	2.4006	.0953	.0762	.0572
12	2.5339	1.1431	2.4387	2.6292	.0762	.0572	.0572
13	2.5339	2.5149	2.4768	2.5911	.0762	.0572	.0762
14	2.553	2.5149	2.5339	2.5911	.0762	.0572	.0762
15	2.4577	2.6292	2.6292	2.572	.0762	.0762	.0762
16	2.553	2.5149	2.6673	2.5911	.0572	.0762	.0762
17	2.5911	2.5149	2.6673	2.553	.0762	.0762	.0762
18	2.4958	2.4387	2.572	2.5339	.0762	.0762	.0762
19	.0953	.0953	.0953	.1715	.0953	.0953	.0953
20	.0953	.0953	.0953	.1524	.0953	.0953	.0953
21	.0953	.0953	.0953	.1524	.0953	.0953	.0953
22	.0762	.0953	.0762	.1524	.0762	.0762	.0953
23	.0762	.0953	.0762	.1334		.0762	.0953
24	.1905	.0762	.0953	.0762	1.6766	1.9052	1.9052
Max	2.5911	2.6292	2.6673	2.6292	2.0957	2.1719	2.0195
Min	.0762	.0762	.0762	.0762	.0572	.0572	.0572
Avg	.9248	.7959	.9979	.9280	.8938	.9018	.8621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 202 / 11 DHOREGAON FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2286	.5335	.2667	.5335	.3048	.2286
2	.3239	.2667	.5335	.3048	.381	.3429	.2667
3	.3239	.2667	.5335	.3048	.381	.3429	.3048
4	.381	.3048	.5335	.3429	.381	.381	.3048
5	.4572	.3048	.5335	.381	.381	.381	.3048
6	.5144	.381	.5335	.381	.381	.4191	.3429
7	.5144	.381	.4572	.4572	.381	.4191	.381
8	.4001		.5335	.381	.4382	.381	
9	3.5056	3.5056	3.5246	3.0483	.3429	.3048	.3048
10	3.5056	3.5437	3.6199	3.0483	.2477	.2667	.2286
11	3.5818		3.6199	3.3913	.1905	.1524	.1524
12	3.5818		3.5056	3.2769	.1905	.1524	.1524
13	3.6199	3.5437	3.4294	3.2388		.1524	.1524
14	3.4294	3.5437	3.4294	3.315	.1524	.1524	.1524
15	3.5437	3.5437	3.4294	3.2769	.1524	.1524	.1524
16	3.3532	3.6199	3.4294	3.2198		.1524	.1524
17	.1524	.3048	.1524	.381	3.1245	2.7816	3.3532
18	.3048	.5335	.3048	.4001	3.2007	2.2862	3.4675
19	.381	.5335	.381	.4954	3.1245	3.0102	3.5437
20	.381	.5335	.381	.4191	3.0483	3.0102	3.5056
21	.381	2.2862	.381	.4191	3.0102	2.9721	3.2007
22	.3429	.5335	.3429	.381	2.8578	3.1626	3.2007
23	.3048	.5335	.3048	.4191	2.7435	3.0483	3.0483
24	.381	.2667	.5335	.2667	.381	2.7054	2.9721
Max	3.6199	3.6199	3.6199	3.3913	3.2007	3.1626	3.5437
Min	.1524	.2286	.1524	.2667	.1524	.1524	.1524
Avg	1.4162	1.3790	1.4567	1.3257	1.1829	1.1431	1.2988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 203 / 11 KV AMALNER FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1143	.1905	.1143	1.7147	1.2574	1.2574
2	.2096	.1143	.1905	.1143	1.7528	1.2574	1.2574
3	.2096	.1143	.1905	.1524	1.7528	1.2955	1.2955
4	.2096	.1524	.1905	.1524	1.7528	1.2955	1.2955
5	.2096	.1524	.2667	.1905	1.6766	1.3336	1.3336
6	.2096	.1524	.2667	.1905	1.7147	1.3336	1.3336
7	.2096	.1524	.2667	.1905	1.7528	1.3717	1.5623
8	.2667		.2667	.1905	1.829	1.4098	1.6766
9	.2096	.1905	.2667	.1905	.1715	.1524	.1524
10	.2286	.1905	.1905	.1905	.1905	.1524	.1524
11	.1524		.1524	.1524	.1143	.0762	.1524
12	.1143	.1905		.1905	.1143	.0762	.1524
13	.1143	.1905	.1524	.1905	.1524	.0762	.1524
14	.1143	.1524	.1524	.1524	.1524	.0762	.1143
15	.1524	.1524	.0762	.1524	.1524	.0762	.1524
16	.1143	.1524	.0762	.1715	.1143	.1143	.1524
17	2.2862	2.2862	2.21	2.1719	.0762	.1143	.1524
18	2.2862	2.2862	2.2862	2.1338	.1143	.1143	.1524
19	2.21	2.2862	2.21	2.2481	.2286	.1524	.1524
20	2.0957	2.2862	2.1338	2.2481	.1524	.1524	.1524
21	2.0576	2.2862	2.0576	2.2862	.1524	.1524	.1524
22	2.0576	2.0957	2.0195	2.21	.1524	.1143	.1524
23	1.9814	2.0957	1.9052	1.9814	.1524	.1143	.1143
24	2.0195	1.9052	2.0957	1.8671	1.9433	.1524	.1143
Max	2.2862	2.2862	2.2862	2.2862	1.9433	1.4098	1.6766
Min	.1143	.1143	.0762	.1143	.0762	.0762	.1143
Avg	.8303	.8954	.8615	.8264	.7533	.5176	.5557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 204 / 11 KV GANESHWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2858	.2667	.3239	.2667	.3048
2	.2667	.2286	.2858	.2667	.3239	.3048	.3048
3	.2667	.2667	.4763	.3048	.3239	.3429	.3429
4	.3239	.2667	.5335	.3048	.381	.381	.3429
5	.4763	.4191	.5716	.4191	.4954	.4191	.4191
6	.5716	.8192	.724	.7621	.6668	.5525	.6097
7	.6097	.724	.7621	.8383	.743	.6859	.7621
8	.6859	.3048	.6668	.8764	.6478	.8764	.8764
9	.6668	.6859	.6097	.7621	.724	.6859	.6859
10	.5906	.5906	.4763	.724	.5525	.5525	.4572
11	.3239		.4001	.6859	.4572	.381	.381
12	.3048	.2858	.3048	.4572	.381	.2667	.3048
13	.2667	.2858	.2667	.4191	.381	.2286	.3239
14	.2286	.2858	.2667	.362	.3429	.2096	.3429
15	.3239	.3239	.2667	.4001	.3048	.3429	.3429
16	.3048	.3239	.3048	.381	.362	.362	.381
17	.4191	.3239	.4382	.381	.4191	.4382	.4001
18	.5906	.5716	.4763	.4572	.5335	.4572	.5335
19	.724	.6668	.7049	.5525	.743	.724	.724
20	.6859	.724	.6478	.5716	.6859	.6859	.6859
21	.4572	.4763	.4191	.4001	.5335	.4572	.4763
22	.381	.381	.3429	.362	.381	.381	.4191
23	.3048	.2858	.3048	.3429	.3429	.3429	.3429
24	.2858		.2858	.2667	.3429	.2667	.2667
Max	.724	.8192	.7621	.8764	.743	.8764	.8764
Min	.2286	.2286	.2667	.2667	.3048	.2096	.2667
Avg	.4303	.4304	.4509	.4818	.4747	.4422	.4596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 205 / 11kv Kokan agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.3429	.5525	.4001	.4001	.4191	.4191
2	.4954	.381	.5525	.381	.4382	.4191	.4572
3	.4954	.381	.5525	.4191	.4572	.4001	.381
4	.5335	.362	.5525	.381	.4191	.381	.381
5	.5335	.381	.6668	.4001	.381	.4191	.4191
6	.6478	.362	.8573		.6097	.4954	.4572
7	.6478	.362	.9717	.362	.5716	.6097	.4954
8	.7621		.9907	.6287	.8002	.7621	.743
9	1.0098	.5525	1.0288	.7049	.9526	.5144	.9526
10	1.3146	1.0288	1.2574	.7621	1.2003	1.0479	1.4861
11	1.2384		1.4098	.9145	1.4098	1.0669	1.5813
12	1.1431	1.1431	1.2955	.8573	1.3717	.8573	1.3717
13	1.0479	.8764	1.2003	.8192	1.3336	.7621	1.3336
14	.8764	1.4098	1.2955	1.0479	1.2955	.743	1.0098
15	1.105	.9145	1.1431	.9907	1.5051	.7621	1.2955
16	.9526	.7621	.9145	.8573	1.467	.8954	1.3336
17	1.0669	.7621	.8954	.8192	1.0669	.6668	1.2193
18	.8002	.6287	.6668	.7049	.8002	.5716	.9145
19	.724	.743	.6478	.6668	.7621	.6287	.7621
20	.6859	.743	.6097	.5716	.6478	.6097	.6859
21	.6097	.6668	.5716	.5335	.5525	.5716	.6668
22	.5716	.5716	.5525	.381	.4954	.5525	.6097
23	.5716	.5525	.5335	.4382	.4572	.5716	.6097
24	.5716	.4954	.5525	.5525	.4001	.4191	.5716
Max	1.3146	1.4098	1.4098	1.0479	1.5051	1.0669	1.5813
Min	.4954	.3429	.5335	.362	.381	.381	.381
Avg	.7875	.6556	.8446	.6345	.8248	.6311	.8399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 206 / 11 KV GALNEEMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.448	1.3717	1.2955	.0381	.0572	.0191
2	1.3336	1.3336	1.3717	1.2955	.0381	.0572	.0191
3	1.3336	1.3336	1.4289	1.3336	.0381	.0572	.0381
4	1.4098	1.3717	1.4289	1.3717	.0381	.0572	.0381
5	1.5432	1.3717	1.5242	1.3717	.0381	.0762	.0381
6	1.5432	1.448	1.5242	1.448	.0381		.0381
7	1.5813	1.5242	1.5242	1.5623	.0381	.0762	.0381
8	1.5432		1.5242	1.5623	.0381	.0762	.0381
9	1.5242	1.5242	.1524	1.5623	.0381	.0762	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	1.5242	1.5242	1.7909
12	.0381	.0381	.0381	.0381	1.8671	1.7147	1.829
13	.0381	.0381	.0381	.0381	1.8671	1.6385	1.829
14	.0381	.0381	.0381	.0381	1.9052	1.6385	1.7528
15	.0381	.0381	.0381	.0381	2.0195	1.5623	1.6766
16	.0381	.0381	.0381	.0381	2.0576	1.5623	1.6766
17	.0381	.0381	.0381	.0381	1.7147	1.5813	1.829
18	.0381	.0381	.0381	.0381	1.7147	1.6956	1.8671
19	.0381	.0381	.0572	.0381	.0762	.0762	.0381
20	.0381		.0572	.0381	.0762	.0762	.0381
21	.0381	.0381	.0572	.0381	.0762	.0762	.0381
22	.0381	.0381	.0381	.0381	.0762	.0381	.0381
23	.0381	.0381	.0572	.0381	.0572	.0381	.0381
24	1.3336	1.3717	1.3717	1.3336	.0381	.0572	.0381
Max	1.5813	1.5242	1.5242	1.5623	2.0576	1.7147	1.8671
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0191
Avg	.6255	.601	.5763	.6112	.6438	.6022	.6176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 207 / 11Kv Lakhmapur Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.5242		1.6766	.1905	.1905	.1905
2	1.5813	1.6004		1.7147	.1905	.1905	.1905
3	1.6956	1.6766		1.7528	.1905	.1905	.1905
4	1.6956	1.7147		1.7528	.1905	.1905	.1905
5	1.8671	1.7528		1.7147	.1715	.2286	.2286
6	1.8671	1.8671		1.7528	.1715	.2286	.2286
7	1.9624	1.8671		1.829	.1715	.2286	.2286
8	1.9814			1.829	.2096	.2286	.2286
9	.3429	.1905	.1524	.2286	2.191	2.1719	2.4768
10	.1715	.1905	.1524	.2286	.1905	2.4768	2.5911
11	.1143		.1524	.1524	2.3624	2.4387	2.4768
12	.1143	.1905	.0762	.1334	2.2481	2.4387	2.4768
13	.1143	.1905	.0762	.1334	2.2481	2.5911	2.5149
14	.1143	.1524		.1143	2.2481	2.5911	2.5911
15	.1143	.1143	.0762	.1334	2.21	2.553	2.5911
16	.1143	.1143	.0762	.1143	2.2481	2.553	2.6673
17	.1143	.1524	.1143	.1334	.0762	.1524	.1143
18	.1524	.1905	.1524	.1715	.1143	.1143	.1143
19	.1524	.2667	.2286	.2096	.2286	.1905	.2286
20	.1524	.2667	.2286	.1905	.1905	.2286	.2286
21	.1905	.2667	.2286	.1905	.1905	.2286	.2286
22	.1524	.1905	.1905	.1905	.1905	.1905	.2286
23	.1524	.1905	.1905	.1905	.1524	.1524	.2286
24	.1905	.1524		.1905	.1905	.1524	.1524
Max	1.9814	1.8671	.2286	1.829	2.3624	2.5911	2.6673
Min	.1143	.1143	.0762	.1143	.0762	.1143	.1143
Avg	.6946	.6737	.1497	.6970	.7819	.9542	.9828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 208 / 11 kv MAUJABAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7049	.8764	.7621
2					.7621	.8764	.8002
3					.8764	.9526	.8002
4					.9526	1.0669	.8764
5						1.1431	.8764
6					1.1431	1.2765	.9526
7					1.3527	1.2955	1.1431
8					1.3146	1.3336	1.2574
9					1.1812	.5906	1.105
10			1.2384				
11	1.2384		1.2384	1.2193			
12	1.3336	1.0479	1.3336	1.3336			
13	1.4289	.9526	1.3336	1.2955			
14	1.448	.7621	1.3336	.9526			
15	1.3717	1.5623	1.2955	1.0479			
16	1.3717	1.5242	1.2765	1.2955			
17	1.0669	1.5242	1.2765	1.2384			
18	1.2955	1.3336	1.1431	.7621			
24					.7049	.6859	.7621
Max	1.448	1.5623	1.3336	1.3336	1.3527	1.3336	1.2574
Min	1.0669	.7621	1.1431	.7621	.7049	.5906	.7621
Avg	1.3193	1.2438	1.2744	1.1431	.9992	1.0098	.9336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 209 / 11 KV BHIVDHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.7621	.8002	.7621	.8573	.8383	.8383
2	.8192	.8002	.8002	.8002	.8383	.8764	.8764
3	.8192	.8764	.8002	.8764	.8954	.9145	.9526
4	1.2193	.9907	1.3336	.9526	.9717	.9526	1.0669
5	1.2955	1.1431	1.6194	1.105	1.2765	1.0669	1.1812
6	1.3908	1.9052	2.0005	1.829	1.7528	1.2955	1.6766
7	.5716	1.9814	2.0005	2.0957	2.0005	1.9433	2.0195
8	1.6385		2.0576	1.9814	1.829	1.829	1.9433
9	1.6956	1.9052	1.5242		1.5051		1.5051
10	1.4289	1.3336	1.1241	1.0288	1.1622	1.2574	1.1431
11	.9145		.8954	1.1622	.8764	.9145	.8192
12	.6859	1.1431	.8002	1.105		.6859	.724
13		1.2574	.7621	1.1431		.6859	.7049
14	.743	.743	.5716	.8192	.8764	.7049	.743
15	.8002	.8002	.6859	.8573	.8764	.724	.743
16	.8383	.9335	.7811	.8573	.8764	.8002	.7621
17	1.0669	1.0479	.9907	.8002	.9526	.8764	.8002
18	1.3527	1.2384	1.2765	1.3146	1.1812	1.105	.9145
19	1.829	1.6194	1.7147	1.5623	1.5242	1.7147	1.829
20	1.7147	1.8099	1.6766	1.467	1.829	1.6766	1.7147
21	1.105	1.1431	1.1431	1.086	1.6004	1.2193	1.2574
22	.8764	.9907	.9145	.8573	1.1431	1.0669	.9907
23	.8002	.8192	.8383	.9526	.9145	.8764	.8764
24	.8192	.7621	.8002	.7621	.8573	.8764	.8002
Max	1.829	1.9814	2.0576	2.0957	2.0005	1.9433	2.0195
Min	.5716	.743	.5716	.7621	.8383	.6859	.7049
Avg	1.0976	1.1821	1.1630	1.1381	1.2089	1.0827	1.1201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 201 / NARAYANPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.132	.12	.1307	1.7604	1.17	1.8461
2	.12	.132	.12	.1307	1.7604	1.4582	1.9109
3	.12	.132	.12	.1494	1.7764	1.6385	2.0405
4	.12	.1509	.12	.1867	1.8351	1.8652	2.1376
5	.1372	.1698	.12	.1867	1.8896	2.1195	2.2672
6	.1543	.2075	.1372	.2054	2.0222	2.2043	2.3967
7	.1543	.1886	.1543	.2054	2.2708	2.5265	2.5101
8	.1372	.1867	.1372	.1867	.0747	2.5604	2.5749
9	.1372		.112	.1494	.056	2.7633	2.5101
10	.0857	.112	.112	.0943		.0914	.112
11	2.7831	2.6355	2.0348	3.0045		.0914	.112
12	2.9096	2.6355	3.5475	2.9729			
13	2.7673		3.12	2.878		.061	.1307
14	2.8018	2.6355	3.4168	3.3981		.061	.1307
15	2.5775	2.4863	2.9001	3.0001		.0762	.0754
16	2.332	2.0485	2.2775	2.7018		.0762	.0754
17	2.0809	1.8404	2.0809	2.2447	.0754	.0762	.0754
18	1.9109	1.8299	1.9547	2.2546	.112	.0762	.0747
19	.168	.1029	.1494	.1307	.1307	.0914	.112
20	.1494	.1372	.1494	.1524	.1307	.0914	.112
21	.1509	.12	.1307	.132		.1067	.1132
22	.1494	.12	.112	.1307	.056	.1067	.1029
23	.132	.12	.112	.1307	.056	.1067	.0857
24	.12	.1307	.12	.0914	1.7284	.8478	1.8138
Max	2.9096	2.6355	3.5475	3.3981	2.2708	2.7633	2.5749
Min	.0857	.1029	.112	.0914	.056	.061	.0747
Avg	.9292	.8297	.9733	1.0353	.9834	.8811	1.0139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 202 / RANJANGAON S.P.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3899	2.2965	2.0725	1.8671	2.3525	1.8671	2.3899
2	2.3525	2.2634	2.0165	1.9993	2.3525	2.3525	2.5019
3	2.3525	2.2405	2.0165	2.2405	2.3899	2.5393	2.7633
4	2.4272	2.4143	2.2032	2.4646	2.6886	2.8006	3.062
5	2.6513	2.7538	2.6326	2.7633	3.0556	3.3234	3.3608
6	3.5848	3.4705	3.0994	2.9874	3.3196	3.5848	3.5475
7	3.4728	3.3951	3.0807	3.2487	3.2065	3.2861	3.2114
8	2.8006	2.9801	2.5766	2.9127	2.7538	2.7633	2.6139
9	2.4086	2.5274	2.1691	2.5393	2.3765	2.3525	2.2779
10	2.0725	1.9791	1.9605	2.3525	1.9993	2.1658	2.0748
11	1.9239	1.7372	1.9418	2.3525	2.1285	2.1285	1.9993
12	1.7353	1.4937	1.8671		2.0165	2.1472	2.1125
13	1.7551	1.5524	1.9418	2.4646	2.0538	2.0538	2.0538
14	1.8298	1.5154	1.9044	2.3899	2.0911	2.0538	2.0911
15	1.7551	1.6263	1.9044	2.2779	1.9791	2.0538	2.1285
16	2.0538	1.6263	1.9791	2.2634	2.1658	2.0538	2.1658
17	2.1502	1.6263	2.1658	2.3388	2.2779		2.2405
18	2.3011	1.8296	2.4646	2.4143	2.3765	2.0911	2.3011
19	3.0178	2.3525	3.0178	2.9047	3.062	2.3152	2.8292
20	3.0933	2.6513	3.0247	3.2442	3.3234	2.5393	3.1687
21	3.0556	2.5766	2.9127	3.1121	3.0247	2.726	3.131
22	2.7633	2.4646	2.7073	2.9801		2.95	2.9127
23	2.5652	2.1845	2.2405	2.6139	2.7161	2.6513	2.6139
24	2.4272	2.3152	2.0725	2.0538	2.3899	2.2405	2.2779
Max	3.5848	3.4705	3.0994	3.2487	3.3234	3.5848	3.5475
Min	1.7353	1.4937	1.8671	1.8671	1.9791	1.8671	1.9993
Avg	2.4558	2.2447	2.3322	2.5559	2.5261	2.4800	2.5762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 203 / PIMPARKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3018	.2452	.2987	.3018	.3018	.2614
2	.2829	.2829	.2452	.3361	.2829	.3361	.2614
3	.2829	.2829	.2452	.4108	.2829	.3734	.2987
4	.3206	.3206	.2641	.4854	.3395	.4854	.3361
5	.3961	.4382	.3584	.5228	.4338	.4904	.4108
6	.4715	.5525	.4904	.5601	.5281	.5228	.4854
7	.5093	.5906	.5281	.5788	.547	.5601	.5601
8	.5093	.6097	.5281	.5975	.547	.547	.5041
9	.4527	.5335	.4294	.5228	.4527	.4668	.4294
10	.3921	.415	.3361	.5093	.4108	.4294	.3772
11	.4191	.4108	.3361	.4527	.3921	.3921	.3584
12	.3584	.3734	.3547	.3772	.3361	.3547	.3772
13	.3174	.2241	.3174	.3395	.3174	.3174	.3395
14	.2801	.2801	.2801	.3206	.2987	.3174	.2858
15	.2641	.2801	.3018	.3174	.3018	.3361	.2987
16	.3395	.2957	.2987	.3361	.2987	.3361	.3361
17	.3772	.3361	.1829	.3734	.3547	.3734	.3696
18	.4108	.3361	.4338	.4294	.4108	.4108	.4187
19	.4715	.415	.415	.5093	.5601	.4481	.5093
20	.4338	.3961	.4115	.4572	.4854	.4481	.4904
21	.3961	.3772	.4108	.4191		.4108	.4338
22	.3584	.3584	.3734	.362	.3734	.3734	2.9127
23	.3395	.2829	.3395	.3429	.3395	.3361	2.6139
24	.2075	.3018	.2641	.2987	.3018	.2987	.2987
Max	.5093	.6097	.5281	.5975	.5601	.5601	2.9127
Min	.2075	.2241	.1829	.2987	.2829	.2987	.2614
Avg	.3697	.3748	.3496	.4232	.3868	.4028	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 204 / JOGESHWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9619	.8962	.8488	.9335	.9522	.9335	.9522
2	.9619	.8501	.8488	1.0269	.961	1.0829	.8962
3	.9619	.8501	.811	1.2696	.961	1.2883	1.0456
4	1.0374	.9979	.8488	1.307	1.1088	1.419	1.1949
5	1.3203	1.2382	1.0374	1.419	1.3392	1.6032	1.3443
6	1.6221	1.3817	1.4523	1.4937	1.6409	1.587	1.587
7	1.6221	1.4712	1.4146	1.5497	1.6221	1.4003	1.5684
8	1.3769	1.3392	1.2449	1.4003	1.4712		1.4003
9	1.1763	1.1883	1.0269	1.2136	1.1506	1.2136	1.0642
10	.8402	.9522	1.0082	.9896	1.0082	.9896	1.0185
11	.7095	.7947	.9335	1.0269	.8775	.9335	.9522
12	.7023	.6722	.8029	1.0269	.8402	.8775	.8962
13	***	.6908	.8029	.9896	.8402	.8215	.8402
14	.7545	.6535	.6535	.9242	1.0374	.8215	.8686
15	.7356	.6535	.8029	.9054	.8402	.8402	.9522
16	.7922	.6468	.8402	.9619	.8402	.8402	.9522
17	.8676	.7655	.8402	.9808	1.0082	.9896	.9997
18	.9088	.7655	1.0269	1.0185	1.0269	1.0456	1.0562
19	1.2826	1.0374	1.1128	1.1763	1.4003	1.1016	1.0562
20	1.226	1.0374	1.1145	1.2637	1.3817	1.2696	1.3957
21	1.2071	1.0185	1.251	1.2136		1.3443	1.3392
22	1.0751	.9054	1.1949	1.1016	1.2136	1.251	1.1389
23	.9808	.8488	1.1203	1.0456	1.1203	1.1389	1.0456
24	.9997	.9149	.8488	1.0269	1.0082	1.0269	.9896
Max	134.6332	1.4712	1.4523	1.5497	1.6409	1.6032	1.587
Min	.7023	.6468	.6535	.9054	.8402	.8215	.8402
Avg	6.6148	.9404	.9953	1.1360	1.1152	1.1226	1.1064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 205 / 11 kv NANDEDA gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1389	1.0082	1.0642	1.0269	1.2136	1.1203	1.1576
2	1.1763	.9795	1.0829	1.1203	1.1949	1.2323	1.307
3	1.1949	.9955	1.1203	1.307	1.2883	1.307	1.643
4	1.3443	1.2489	1.2883	1.4937	1.4377	1.6057	1.7924
5	1.9605	1.7013	1.7924	2.0165	1.8298	1.8671	1.9418
6	2.1472	2.1068	2.1658	2.0538	2.2634	2.3011	2.2032
7	2.2592	2.3011	2.1845	2.3712	2.1313	2.4086	2.2779
8	2.0165	1.905	2.0165	2.1472	1.8484	1.9605	1.9605
9	1.4563	1.6787		1.8298	1.6221	1.6244	1.587
10	1.2752	1.4335	1.363	1.6804	1.2136	1.363	1.2826
11	.9511	.9979	1.1203	1.4377	1.1949	1.2696	1.1883
12	.8488	.8962	.9522	1.3256	1.1016	1.0829	1.094
13	.8029	.8596	.8589	1.1203	1.0269	.9709	1.0456
14	.7733	.8413	.9335	1.1203	1.0185	1.0082	1.0829
15	.8676	.9145	.9149	1.1576	1.0288	1.0829	1.0456
16	.9709		1.1016	1.1763	1.1389	1.1576	1.1389
17	1.2071			1.2826	1.2136	1.2883	1.2071
18	1.5278	1.6817	1.531	1.475		1.3443	1.307
19	1.9044	1.8858	1.4937	1.7924	1.9791	1.419	1.8296
20	1.7181	1.6244	1.6991	1.5497	1.9239	1.531	1.5844
21	1.4712	1.419	1.475	1.4901		1.419	1.4901
22	1.2637	1.2323	1.307	1.3957	1.4003	1.3443	1.3443
23	1.1883	1.0642	1.2323	1.2696	1.251	1.2696	1.251
24	1.1576	1.0269	1.0642	1.1203		1.1203	1.0082
Max	2.2592	2.3011	2.1845	2.3712	2.2634	2.4086	2.2779
Min	.7733	.8413	.8589	1.0269	1.0185	.9709	1.0082
Avg	1.3593	1.3547	1.3528	1.49	1.4438	1.4207	1.4488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 206 / 11 KV Waluj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3535	1.3817	1.1706	1.1203	1.4003	1.419	1.419
2	1.3535	1.363	1.1706	1.419	1.3676	1.6057	1.531
3	1.39	1.4003	1.1888	1.6617	1.6278	1.8484	1.8298
4	1.6095	1.6617	1.2986	1.8298	1.8656	2.0538	2.0911
5	2.2314	2.4709	2.1253	2.0538	2.2177	2.5463	2.5019
6	2.8753		2.782	2.5463	2.8858	2.9313	2.8193
7	3.2487	3.3196	3.006	3.0178	2.9801	3.0807	3.1181
8	2.9687	2.7778	2.838	2.9874	2.7349	2.7073	2.726
9	2.6242	2.8292	2.5274	2.8193	2.2068	2.4272	2.0538
10	1.9404	2.1313	1.9605		1.905	2.1658	1.9993
11		1.5893	1.6787		1.6991	2.0165	1.8111
12		1.4969	1.4523		1.4901		1.5708
13		1.3306	1.2883		1.4563	1.8111	1.4266
14		1.4449	1.4003		1.5466	1.7177	1.3394
15	1.5466	1.3717	1.4563		1.5497	1.6804	1.4937
16	1.5466	1.4632	1.6057			1.6057	1.6804
17	1.6617	1.6448	1.7737		2.0911	1.9231	1.773
18	2.3954	1.848	2.2779		2.4832	2.0165	2.0936
19	2.6406	2.3899	2.2405		2.8006	2.0911	2.7161
20	2.0062	1.9605	2.2779		2.2405	2.0165	2.2068
21	1.8858	1.7187	1.9978			1.9418	1.9805
22	1.773	1.4998	1.8671		1.7541	1.8298	1.7741
23	1.5278	1.2254	1.6617		1.5684	1.531	1.4969
24	1.39	1.419	1.1888	1.4937		1.4937	1.4563
Max	3.2487	3.3196	3.006	3.0178	2.9801	3.0807	3.1181
Min	1.3535	1.2254	1.1706	1.1203	1.3676	1.419	1.3394
Avg	1.9984	1.8147	1.8431	2.0949	1.9939	2.0200	1.9545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 207 / 11 KV Ghanegaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9762	.8775	.7773	1.1203	.2452	.2241	.1829
2	.9762	.7274	.8179		.2477	.2614	.2134
3	1.0242	.7748	.8642	1.419	.2829	.2987	.2439
4	1.0562	.8223	.9061	1.307	.3429	.3361	.3048
5	1.1683	1.0364	1.0155	1.6057	.4382	.3734	.3658
6	1.5061	1.2616	1.2809	1.6804	.5335	.4108	.3963
7	1.9826	1.6604	1.7004	1.8111	.4904	.4294	.3963
8	2.0553	1.757	1.749	1.8858	.4572	.4108	.3658
9	1.8067	1.6409	1.7924	1.5497	.3584	.2743	.2743
10	.2134	.3018	.3361	.2987	.3048	.2286	.2667
11	.2427	.1467	.2241	.2614	1.9605	1.0364	1.7553
12	.2033	.1334	.1867		2.1845	1.4251	1.8185
13	.2096	.12	.168	.2427	2.0538	1.6518	1.7078
14	.1886	.1334	.1867	.2427	1.8484	1.6032	1.668
15	.1886	.1334	.1867	.2614	1.9418	1.5546	1.587
16	.2094		.168		2.0351	1.5061	1.704
17	.2263				2.0165	1.6842	1.7368
18	.2263	.1867	.2263		1.643	1.5546	1.5581
19	.3395	.2	.3206		.3547	.2743	.362
20	.3206	.2534			.3547	.2439	.381
21	.2915	.2401	.2801			.2286	.3206
22	.2829	.2134	.2987		.2801	.2286	.2134
23	.2427	.1867	.2241		.2427	.2134	.2
24	.9602	.7432	.7316	.9335		.9335	.1829
Max	2.0553	1.757	1.7924	1.8858	2.1845	1.6842	1.8185
Min	.1886	.12	.168	.2427	.2427	.2134	.1829
Avg	.7041	.6159	.6564	1.0442	.9371	.7244	.7586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 208 / 11 KV East West Industri SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5975	.415	.3734	.5544	.3361	.6722
2	.5281	.6036	.3772	.4108	.5716	.2987	.6722
3	.5658	.5658	.2641	.4481	.5975	.2241	.6348
4	.5281	.5716	.3772	.3772	.6097	.4527	
5	.5281	.5716	.3772	.3361	.5716	.4481	.6348
6	.5658	.4572	.4527	.4481	.5335	.5658	.6348
7	.5658	.4572	.4904	.4481	.5716	.4481	.5228
8	.7545	.4108	.5281	.6722	.6478	.7095	.5975
9	.7468	.5601	.7468	.5975	.9145	.8962	.7468
10	1.0082	.6348	.9054	.7468	1.1812	.9709	.9709
11	.8962	.3772	.8962	.7095	1.1694	1.0082	1.3443
12	1.0745	.5281	.8962	.7095	.9709	1.0456	1.0829
13	.7842	.415	.6722	.7095	.9709	1.0829	1.0185
14	.9709	.4904	.8215	.6859	1.1576	1.0829	1.0185
15	1.0288	.5281	.9335	.6859	1.1694	1.0456	1.2071
16	1.0185	.5281	.9709	.6097	1.0082	1.0456	1.1431
17	.9709	.5281	.9709	.6348	1.2449	.9335	1.105
18	.5975	.4527	.679	.6478	.8215	.8962	.7621
19	.5601	.4527	.5144	.4904	.9335	.7842	.6859
20	.4904	.4527	.6722	.5716		.7095	.6859
21	.5335	.415	.4338	.5716		.6722	.724
22	.6097	.4527	.5975	.5975	.2241	.5975	.7922
23	.6478	.4527	.5601	.5716	.2987	.7095	.7922
24	.4527	.5716	.4904	.5658	.5658	.2614	.6722
Max	1.0745	.6348	.9709	.7468	1.2449	1.0829	1.3443
Min	.4527	.3772	.2641	.3361	.2241	.2241	.5228
Avg	.7065	.5031	.6268	.5675	.7858	.7177	.8313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 201 / 11 KV GAJGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0953	.1143	.1143	.4024	.381	.2858
2	.128	.0953	.1143	.1143	.4755	.381	.3429
3	.128	.1143	.1143	.1334	.439	.4763	.381
4	.1132	.1143	.1334	.1524	.5304	.5335	.4572
5	.1463	.1524	.1334	.1715	.4755	.6287	.4572
6	.1463	.1715	.1524	.1715	.4527	.724	.4954
7	.128	.1524	.1524	.1524	.5304	.8002	.6668
8	.0732	.1334	.1334	.1524	.439	.8002	.7621
9	.0549	.1143	.0953	.0953	.4191	.7621	.6668
10	.0572	.0953	.381	.1097	.0762	.0191	.0953
11	.381	.5144	.4763	.5121	.0381	.0572	.0762
12	.5716	.5898	.724	.691	.0381	.0572	.0572
13	.6668	.5668	.724	.6413	.0381	.0572	.0572
14	.6668	.5441	.5144	.6036	.0381	.0381	.0572
15	.6478	.5182	.381	.7133	.0381	.0381	.0381
16	.6478	.5144	.3429	.679	.0381	.0381	.0381
17	.6287	.463	.381	.695	.0381	.0381	.0572
18	.6097	.3944	.4763	.6767	.0572	.0381	.0572
19	.1334	.0953	.0572	.1097	.0953	.0572	.0953
20	.1334	.1143	.0762	.128	.0953	.0762	.1143
21	.1143	.1143	.0762	.0914	.0953	.0762	.1143
22	.1143	.1143	.0953	.0732	.0953	.0762	.1143
23	.0953	.1132	.0953	.0732	.0953	.0762	.1143
24	.132	.0953	.0943	.0953	.2926	.381	.1905
Max	.6668	.5898	.724	.7133	.5304	.8002	.7621
Min	.0549	.0953	.0572	.0732	.0381	.0191	.0381
Avg	.2763	.2496	.2516	.2979	.2222	.2755	.2413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 202 / 11 kv RANJANGAON POL AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.5716	.5487	.724	.4755	.4572	.4763
2	.8299	.6668	.6001	.724	.5487	.4572	.4763
3	1.0242	.7621	.6001	.7621	.6413	.4763	.4763
4	.9877	.8573	.6706	.7621	.6401	.4954	.4763
5	1.0791	.9526	.8097	.7621	.6219	.5335	.4382
6	1.0608	1.105	.8907	1.0479	.695	.5716	.381
7	1.1706	1.1812	1.004	1.0479	.6401	.5335	.381
8	1.134	1.1431	.9602	1.0288	.439	.4763	.381
9	1.1694	1.0479	.7907	.7621	.4191	.381	.381
10	.2286	.381	.3429	.2012	.381	.381	.2858
11	.2286	.2667	.381	.2561	.8764	.7621	.6478
12	.1905	.2263	.381	.2926	.9907	.8573	.6882
13	.1905	.2614	.381	.2561	.9526	.8002	.6802
14	.1905	.2641		.2926	.8764	.7621	.6478
15	.1905	.2477	.381	.2743	.8764	.7811	.5601
16	.1905	.2829	.381		.8383	.8002	.5243
17	.1905	.3239	.381	.2561	.8383	.8192	.5735
18	.2286		.381	.3109	.8002	.7621	.4801
19	.3048	.4763	.381	.3658	.381	.3429	.5093
20	.3048	.5716	.381	.5304	.4382	.381	.5658
21	.3429	.5716	.381	.5487	.4763	.4191	.5658
22	.3429	.5335	.381	.5487	.4763	.4382	.5716
23	.3429	.4763	.4763	.5487	.4572	.4763	.5144
24	.7316	.5716	.5144	.6097	.5487	.4572	.4763
Max	1.1706	1.1812	1.004	1.0479	.9907	.8573	.6882
Min	.1905	.2263	.3429	.2012	.381	.3429	.2858
Avg	.5578	.5975	.5391	.5614	.6387	.5676	.5066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 204 / 11 KV RAJANGAON POL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2667	.2772	.2858	.3658	.2667	.2667
2	.3475	.3048	.2772	.3429	.4024	.3048	.3048
3	.3658	.381	.3109	.4191	.4755	.381	.3429
4	.5304	.4763	.3658	.4191	.5658	.4763	.381
5	.5487	.5525	.4572	.4382	.7133	.5716	.4191
6	.6224	.6287	.6036	.5121	.695	.6668	.5335
7	.5487	.5335	.6219	.5487	.7133	.6097	.5144
8	.439	.4954	.5544	.5853	.6401	.5335	.4954
9	.3292	.4382	.4572	.4938	.5716	.4191	.3239
10	.2858	.3658	.3658	.3658	.4191	.3658	.2195
11	.2286	.2587	.3292	.2012	.2096	.3429	.1829
12	.1905	.1478	.1829	.2195	.1905	.1715	.1463
13	.1524		.1829	.2561	.1905	.1646	.1294
14	.1524	.1478	.1646	.2075	.1905	.1463	.1294
15	.1524	.1829	.1829		.1905	.1524	.1478
16	.1905	.2195	.1829		.2096	.1663	.1463
17	.2286	.2378	.2195	.3658	.2286	.2195	.1848
18	.3048		.3292	.3292	.2858		.2743
19	.4954	.3292	.4572	.3658	.4572	.2195	.4572
20	.4763	.4572	.439	.4024	.4191	.2926	.5544
21	.3429	.4024	.4207	.3658	.381	.3658	.3658
22	.3048	.2926	.2772	.2743	.3048	.2926	.2743
23	.2858	.2587	.2587	.2561	.2858	.2561	.2772
24	.2012	.2667	.2587	.2218	.2195	.2667	.2561
Max	.6224	.6287	.6219	.5853	.7133	.6668	.5544
Min	.1524	.1478	.1646	.2012	.1905	.1463	.1294
Avg	.3356	.3475	.3407	.3580	.3885	.3327	.3053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3048	.2195	.4191	.1463	.0953	.1334
2	.3658	.381	.2572	.4191	.1698	.0953	.1334
3	.4024	.4763	.2572	.4382	.1646	.1143	.1143
4	.439	.5335	.3353	.4382	.1463	.1334	.1143
5	.4755	.6097	.4096	.4382	.1646	.1334	.1143
6	.4938	.6859	.4858	.5716	.1829	.1524	.1715
7	.5487	.7621	.5506	.5716	.1646	.1524	.1715
8	.5487	.7621	.4858	.5716	.0549	.1143	.1715
9	.5853	.724	.4001	.6478	.0381	.0953	.0953
10	.0191	.0953	.0381	.0732	.0381	.0953	.0762
11	.0191	.0762	.0381	.0366	.5906	.4191	.4287
12	.0191	.0381	.0381	.0366	.6668	.4763	.4372
13	.0191	.0381	.0381	.0549	.6668	.4763	.4049
14	.0191	.0381	.0381	.0549	.6287	.4572	.4049
15	.0191	.0381		.0732	.5906	.4763	.3932
16	.0191	.0381		.0732	.5906	.4763	.3932
17	.0191	.0381	.0572	.0914	.5716	.5335	.4191
18	.0191	.0572	.0572	.1097	.5335	.4382	.3944
19	.0762	.1143	.0953	.1463	.1334	.0953	.0762
20	.0953	.1143	.1143	.1646	.1334	.1143	.0943
21	.0953	.1143	.1143	.1463	.1524	.1143	.1132
22	.0953	.1143	.1143	.1646	.1334	.1524	.1143
23	.0762	.0953	.1143	.1463	.1143	.1334	.0953
24	.2012	.3048	.1372	.2667	.1698	.0953	.1334
Max	.5853	.7621	.5506	.6478	.6668	.5335	.4372
Min	.0191	.0381	.0381	.0366	.0381	.0953	.0762
Avg	.2068	.2731	.1998	.2564	.2894	.2350	.2166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 206 / 11 KV GAWALI SHIWARA AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953	.1143	.1132	.1143	.0953
2		.0762	.0953	.1143	.1132	.1143	.1143
3		.0953	.0953	.1143	.1463	.1524	.1143
4		.1143	.1143	.1143	.1698	.1905	.1334
5		.1334	.1334	.1143	.1698	.2286	.1334
6		.1524	.1334	.1143	.1829	.2667	.1334
7		.1715	.1524	.1143	.1829	.3048	.1905
8		.1334	.0943	.1143	.2743	.2858	.2477
9		.0953	.0762	.0953	.3429	.2286	.2096
10	.0572	.0762	.0953	.0914	.0953	.0381	.0762
11	.1524	.1715	.1905	.1463	.0572	.0381	.0572
12	.1905	.2058	.2096	.1646	.0572	.0381	.0381
13	.2286	.2058	.1715	.1463	.0572	.0381	.0381
14	.2286	.1886	.1715	.1886	.0572	.0381	.0381
15	.2096	.1715	.1905	.1463	.0572	.0381	.0381
16	.1905	.1715	.1905	.1463	.0762	.0381	.0381
17	.1905	.1715	.1905	.1646	.0953	.0381	.0381
18	.1715	.1402	.1524	.1463	.1334	.0381	.0572
19	.1334	.0953	.0381	.1097	.1143	.0572	.0762
20	.1143	.1143	.0381	.128	.0953	.0572	.0953
21	.0953	.1143	.0572	.1097	.0762	.0572	.0953
22	.0953	.1143	.0762	.0549	.0762	.0572	.0953
23	.0762	.0953	.0762	.0549	.0762	.0572	.0953
24		.0762	.0953	.0762	.1463	.1143	.0572
Max	.2286	.2058	.2096	.1886	.3429	.3048	.2477
Min	.0572	.0762	.0381	.0549	.0572	.0381	.0381
Avg	.1524	.1317	.1222	.1202	.1236	.1096	.0961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 207 / 11KV KBS INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.0189	.0191	.0381
2		.0191	.0191	.0191	.0183	.0191	.0381
3		.0191	.0191	.0191	.0189	.0191	.0381
4		.0191	.0191	.0191	.0183	.0191	.0381
5		.0191	.0191	.0191	.0183	.0191	.0381
6		.0191	.0191	.0191	.0183	.0191	.0381
7		.0191	.0191	.0191	.0183	.0191	.0381
8		.0191	.0191	.0191	.0183	.0762	.0381
9		.0191	.0191	.0191	.0191	.0762	.0572
10	.0191	.0191	.0191	.0183	.0191	.0191	.056
11	.0191	.0191	.0191	.0183	.0191	.0191	.056
12	.0191	.0191	.0191	.0189	.0381	.0381	.0373
13	.0191	.0191	.0191	.0183	.0381	.0191	.056
14	.0191	.0191	.0191	.0183	.0381	.0381	.056
15	.0191	.0191	.0191	.0183	.0381	.0191	.0373
16	.0191	.0191	.0191	.0183	.0381	.0381	.0373
17	.0191	.0191	.0191	.0183	.0381	.0381	.0373
18	.0191	.0191	.0191	.0183	.0381	.0191	.0373
19	.0191	.0191	.0191	.0183	.0381	.0191	.0191
20	.0191	.0191	.0191	.0183	.0381	.0381	.0191
21	.0191	.0191	.0191	.0189	.0381	.0381	.0191
22	.0191	.0191	.0191	.0183	.0191	.0381	.0191
23	.0191	.0191	.0191	.0183	.0191	.0381	.0191
24		.0191	.0191	.0191	.0183	.0191	.0381
Max	.0191	.0191	.0191	.0191	.0381	.0762	.0572
Min	.0191	.0191	.0191	.0183	.0183	.0191	.0191
Avg	.0191	.0191	.0191	.0187	.0268	.0302	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 208 / Dhananjay auto
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.112	.1143	.2075	.1715	.0953
2		.2096	.1494	.1143	.1829	.1715	.0953
3		.2096	.1478	.1143	.2012	.1715	.0953
4		.2096	.168	.1143	.1829	.1715	.1143
5		.2096	.168	.1143	.2075	.1715	.0953
6		.2096	.168	.1524	.2263	.1715	.0762
7		.2096	.1886	.1524	.2195	.1715	.0953
8		.1334	.1524	.1905	.2195	.1715	.1143
9		.1334	.1307	.1905	.1334	.1715	.0953
10	.1143	.1494	.1334	.1829	.1334	.1524	.1143
11	.1143	.1494	.1334	.2012	.1334	.0953	.1494
12	.1143	.1307	.1334	.2012	.1715	.0762	.1494
13	.1715	.1524	.1715	.1829	.1715	.0762	.1334
14	.1715	.168	.1715	.1829	.1715	.0572	.1334
15	.1715	.1372	.1334	.1829	.1715	.0572	.1524
16	.1715	.1307	.0953	.1829	.1715	.0572	.1524
17	.1715	.1494	.0953	.1886	.1715	.0572	.1143
18	.1715	.112	.0953	.2075	.1715	.0762	.1334
19	.2096	.1334	.0953	.1829	.0953	.0953	.1143
20	.2096	.1334	.0953	.1829	.0953	.0953	.1143
21	.2096	.1143	.0953	.2012	.0953	.0953	.0953
22	.2096	.1143	.0953	.2195	.0953	.0953	.0953
23	.2096	.1334	.0953	.1829	.0953	.0953	.1143
24		.2096	.1334	.0953	.1829	.1715	.0953
Max	.2096	.2096	.1886	.2195	.2263	.1715	.1524
Min	.1143	.112	.0953	.0953	.0953	.0572	.0762
Avg	.1729	.1605	.1316	.1681	.1628	.1207	.1141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 201 / 11 KV AMINABAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	1.0288	1.1568	1.2003	.3224	.3696	.4298
2		1.2003	1.3077	1.4251	.3224	.3696	.4298
3		1.3077	1.3916	1.6194	.1791	.4066	.4298
4	1.5089	1.5089	1.5089	1.7604	.197	.4435	.4706
5	1.8442	2.1548	1.6766	2.0243	.3582	.4805	.5194
6	2.1795	2.6216	2.3472	2.2119	.4961	.5121	.5194
7	3.0346	2.9473		3.1089	.3224		
8			3.0178	3.1131	.3761		
9	2.6825		2.8502	2.4577	.2507		
10	.3206		.2641	.3772	.2149	.1886	.2534
11	.2263	.3206	.2075	.3224	2.9508	2.8292	2.6825
12	.1886	.2263	.1886	.2865	2.0119	2.915	2.7161
13	.1867	.2452	.1886	.2658	2.8166	2.7978	2.5316
14	.2241		.1509	.2481	1.8023	2.3472	2.1795
15	.1867	.2641	.1509	.2658	2.6852	2.3205	2.0119
16	.2241	.2452	.1509	.2835	2.753	2.4905	2.3472
17	.2241	.2452	.2452	.2835	2.7206	2.5396	2.5149
18	.2614	.2829	.3395	.3189	2.2996	2.2119	2.1795
19	.4435	.4904		.4298	.3696	.3761	.3772
20	.4066	.5281	.4338	.4252	.4066	.5014	.5093
21	.3696	.3772	.3395	.394	.3734	.4656	.4527
22	.3696	.2829	.2263	.394	.3696	.4477	.3772
23	.3326	.2263	.1886	.3898	.3326	.4298	.3395
24	1.0898	1.0288	1.0059	1.0898	.3582	.3326	.394
Max	3.0346	2.9473	3.0178	3.1131	2.9508	2.915	2.7161
Min	.1867	.2263	.1509	.2481	.1791	.1886	.2534
Avg	.8283	.8766	.8790	1.0290	1.0537	1.2274	1.1745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 202 / 11 KV WARKHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2452	.2452	.9602	1.1317	1.1401
2	.1886	.2641	.2641	.2829	1.0454	1.2071	1.2574
3	.2075	.2263	.2829	.2829	1.0974	1.3413	1.3592
4	.2263	.2641	.3018	.2829	1.2378	1.5089	1.5546
5	.2452	.3018	.3206	.3395	1.3413	1.6907	1.8023
6	.2641	.3772	.3206	.3772	1.6244	2.0222	2.1862
7	.2829				2.3205	2.5911	2.6235
8	.2452				2.6543	2.7206	2.7854
9	.1698		.1132	.1886	2.2377	2.4249	2.4863
10	.1509		.1132	.1886		.1886	.1791
11	2.9797	2.5484	2.3472	2.7435		.1433	.2075
12	2.9473	2.5819	3.0407	3.12			.1886
13	3.2065	1.8945	2.8807	2.8502			.1886
14	3.1093	2.8166	2.6216	2.6852			.2075
15	2.7854	2.5987	2.7664	2.7349			.2641
16	2.7206	2.649	2.5606	2.9165			.2452
17	2.6216	2.6155	2.8121	2.8502	.1509		.2641
18	2.5888	2.3807	2.4577	2.2939	.1867	.2149	.2829
19		.2641	.3206	.2835	.2241	.2195	.3772
20	.3734	.3206	.4108	.3045	.2241	.2865	.2452
21	.3734	.2829	.3772	.2865	.2241	.2686	.2263
22	.3361	.2829	.3395	.2507	.3547	.2149	.2075
23	.2614	.2452	.2829	.197	.1509	.1772	.1886
24	.2263	.2614	.2452	.2452	.823	.9945	1.0631
Max	3.2065	2.8166	3.0407	3.12	2.6543	2.7206	2.7854
Min	.1509	.2263	.1132	.1886	.1509	.1433	.1791
Avg	1.1608	1.1701	1.1557	1.1795	.9916	1.0748	.8971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 203 / 11 KV WAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0754	.132	.9259	.8916	1.0631
2	.0566	.0754	.0943	.132	.9496	.9945	1.073
3	.0754	.0943	.0943	.132	1.0174	1.0395	1.1142
4	.0754	.0943	.1132	.132	1.0227	1.1065	1.1797
5	.0943	.132	.1132	.1509	1.0608	1.2266	1.2793
6	.0943	.1509	.132	.1509	1.1271	1.4091	1.3603
7	.0943	.1509	.1132	.1509	1.6575	1.8351	1.8023
8	.0754		.0943	.132	1.8564	1.8299	1.9006
9	.0377		.0754	.0943	1.6278	1.6385	1.7147
10	.0566		.0377	.0754	.0716	.0566	.0537
11	1.4899	1.4251	1.8515	1.8519	.0377	.0537	.0566
12	.8192		1.8351	1.7295	.0377		.0377
13	1.6518			1.6598	.0377		.0377
14	1.5708			1.5415	.0377		.0566
15	1.6712			1.6385	.0377		.0377
16	1.6194	1.0562	1.8343	1.6221	.0377		.0377
17	1.4746	1.8107	2.2119	1.5927	.0377		.0754
18	1.3599	1.3077	1.7004	1.4754	.0377	.0362	.0943
19		.0754	.0943	.0709	.0566	.0716	.1132
20	.0943	.0754	.1509	.0895	.0754	.0716	.1132
21	.0943	.1132	.132	.0895	.0754	.0537	.0943
22	.0943	.1132	.132	.0905	.0754	.0537	.0943
23	.0754	.0943	.132	.0716	.0754	.0537	.0754
24	.0566	.0754	.0754	.132	.8916	.823	.9602
Max	1.6712	1.8107	2.2119	1.8519	1.8564	1.8351	1.9006
Min	.0377	.0754	.0377	.0709	.0377	.0362	.0377
Avg	.5560	.4070	.5282	.6224	.5362	.7358	.6011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 204 / 11KV GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.3696	.3772	.4715	.4252	.4066	.4477
2	.5658	.3734	.5658	.4668	.4656	.4066	.4961
3	.6413	.4527	.7545	.6468	.5373	.4805	.5731
4	.679	.5544	.8676	.8402	.6447	.5487	.6447
5	.8676	.695	.9431	.961	.8505	.695	.8238
6	1.094	1.0608	1.1317	1.004	1.0985	1.0242	1.086
7	1.0185	1.0974			1.0631	1.0974	1.0924
8					.8505	.9145	.8145
9	1.0751		.9997	.8596	.7343	.8413	.788
10	.7545		.7733	.924	.5373	.5914	.5731
11	.4435	.5658	.4435	.6733	.2957	.1433	.4904
12	.3696	.3584	.3734	.5316	.2587	.1791	.4338
13	.2957	.3018	.3696	.4656	.2587	.1791	.3961
14	.2587	.415	.3326	.3982	.2587	.2865	.3206
15	.2957	.3395	.2957	.394	.2957	.2835	.3395
16	.2587	.2452	.2772	.4656	.3326	.4252	.3772
17	.3696	.4527	.4938	.5316	.4066	.4252	.4715
18	.5487	.5658	.6401	.5731	.6653	.4961	.4904
19	.9145	.9431		.8059	.9145	.8505	.9054
20	.7682	.9054	.9055	.7973	.8779	.7796	.9808
21	.5487	.6036	.7023	.5373	.7316	.6024	.6413
22	.4435	.547	.5975	.5014	.5544	.5316	.5281
23	.4066	.4527	.5281	.4656	.4805	.4458	.415
24	.4527	.4066	.3772	.4715	.394	.4066	.4298
Max	1.094	1.0974	1.1317	1.004	1.0985	1.0974	1.0924
Min	.2587	.2452	.2772	.394	.2587	.1433	.3206
Avg	.5871	.5574	.6071	.6266	.5805	.5434	.6066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 205 / 11KV MUDDESH WADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9892	.9259	.9221	1.065	.124	.1509	.1417
2	1.0562	.9602	1.0898	1.065	.1254	.1509	.1417
3	1.1401	.9724	1.1736	1.1469	.1433	.1509	.1417
4	1.4146	1.0395	1.3077	1.2146	.1433	.1698	.1433
5	1.3916	1.094	1.3748	1.3108	.1595	.1867	.1433
6	1.6598	1.2289	1.4922	1.4255	.1772	.1867	.1629
7	2.0957	1.8623	2.0957	2.1765	.1417	.1509	.1612
8	2.1963		2.146	2.1032	.1433	.1698	.1433
9	2.0287		1.9448	1.8679	.0724	.1132	.1254
10	.0943		.0754	.1132	.0716	.0754	.0716
11	.0566	.0754	.0566	.0895	2.2045	2.4863	1.8945
12	.0566	.0566	.0566	.0895	2.2874	2.4587	2.079
13	.0566	.0566	.0566	.0895	1.6385		2.0454
14	.0566	.0566	.0566	.0886	.6859		2.1628
15	.0377	.0566	.0566	.0716	1.1271		
16	.0377	.0566	.0566	.0716			2.2466
17	.0377	.0377	.0566	.0716	2.2283	2.5034	2.5149
18	.0566	.0566	.0566	.0716	2.0972	2.332	2.6993
19	.1132	.1132	.1132	.1433	.1509	.1791	.1509
20	.1132	.132	.1509	.1448	.1698	.1791	.2263
21	.1132	.132	.132	.1433	.1698	.1612	.1886
22	.1132	.0943	.0754	.1433	.1698	.1612	.132
23	.0943	.0754	.0754	.1267	.1509	.1433	.0754
24	.9221	.8916	.8383	1.0288	.124	.1509	.1448
Max	2.1963	1.8623	2.146	2.1765	2.2874	2.5034	2.6993
Min	.0377	.0377	.0566	.0716	.0716	.0754	.0716
Avg	.6638	.4750	.6442	.6609	.6307	.6130	.7799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 201 / 11 KV DONGAON AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.2572	.2486	.3018	.4715	.4527
2	.1715	.2241	.2572	.2486	.4527	.4715	.4527
3	.1886		.2915	.2818	.5093	.547	.4904
4	.2058	.2772	.3814	.3315	.5658	.6413	.4904
5	.2229	.2713		.431	.6224	.7356	.5658
6	.5304	.3353	.503	.4973	.8299	.7922	.7545
7	.5636	.5801	.5197	.5407	.8488	.9054	.9431
8	.4973	.4862	.4694	.4424	.679	.5658	.7356
9	.3315	.373	.3353	.3605	.4527	.4904	.4904
10	.3353	.3395	.3395	.4338	.2641	.2321	.2984
11	.2713	.3395	.2263	.3772	.2543	.1989	.2515
12	.2155	.2641	.2263	.3395	.2374	.1823	.2204
13	.2012	.2075	.2075	.3206	.218	.1989	.2012
14	.1989	.2075	.2263	.3018	.2347	.1658	.1509
15	.2883	.2075	.2452	.3206	.218	.1823	.1658
16	.1989	.2641	.2641	.3395	.218	.1989	.2012
17	.2374	.2829	.3018	.3772	.2347	.2321	.2035
18		.3206	.415	.3395	.2641	.2155	.2587
19	.6722	.547	.5658	.6036	.3772	.6036	.5415
20	.6161	.6036	.6413	.6413	.4715	.7167	.6908
21	.5041	.547	.547	.5658	.4904	.547	.547
22	.4527	.4715	.4904	.4338	.4527	.4904	.4904
23	.3961	.2058	.4527	.3772	.415	.4527	.4481
24	.1715	.1867	.2229	.1989	.3206	.3772	.4527
Max	.6722	.6036	.6413	.6413	.8488	.9054	.9431
Min	.1715	.1867	.2075	.1989	.218	.1658	.1509
Avg	.3330	.3369	.3646	.3897	.4139	.4423	.4374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 202 / 11 KV RAIPUR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2614	.3258	.2984	.3395	.5658	.5658
2	.3601	.2987	.3429	.3149	.6036	.5658	.679
3	.3429	.3142	.373	.3481	.6413	.6036	.7545
4	.4287	.3326	.463	.4715	.6979	.6979	.8488
5	.4527	.3222	.5426	.5636	.7545	.7545	.9054
6	.7373	.3521	.57	.6299	1.0185	.9242	.9431
7	.8676	.5636	.7293	.7459	1.1317	1.0751	1.0562
8	.7373	.7042	.663	.6718	.9431	.8299	.8299
9	.6554	.5426	.6203	.5079	.5658	.6979	.679
10	.4024	.3772	.5281	.6602	.415	.3647	.3315
11	.3052	.415	.5281	.5658	.4191	.3772	.3185
12		.3584	.2641	.547	.4359	.3978	.2543
13	.3481	.3772	.2829	.5658	.4527	.431	.2347
14	.2818	.3395	.3018	.5093	.4359	.3978	.3018
15	.2883	.3395	.3018	.3772	.4024	.3812	.2984
16	.2818	.3772	.3584	.415	.3768	.3647	.285
17	.3391	.3772	.3772	.4527	.3688	.3315	.407
18		.415	.5093	.4715	.415	.3647	.3142
19	.8962	.6036	.6224	.811	.4338	.4904	.7282
20	.8029	.7356	.811	.7545	.547	.9242	.9709
21	.6908	.6979	.7167	.7167	.6413	.811	.8029
22	.6413	.6602	.679	.6979	.6413	.679	.7468
23	.5847	.5895	.6413	.5658	.6224	.6413	.6908
24	.3429	.2427	.2572	.2486	.5093	.5658	.6224
Max	.8962	.7356	.811	.811	1.1317	1.0751	1.0562
Min	.2818	.2427	.2572	.2486	.3395	.3315	.2347
Avg	.5059	.4416	.4921	.5380	.5755	.5932	.6070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 203 / 11 KV PADALSA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.6535	.7545	.6413	.4458	.4578	.4973
2	.7545	.6908	.8299	.6413	.4973	.5087	.5967
3	.8488	.7392	.8865	.8488	.5144	.5935	.7459
4	.9431	.8871	.9431	.9431	.5658	.6539	.8288
5	1.0374	.8648	1.0751	1.0374	.5967	.6706	1.0374
6	1.5089	1.1568	1.1694	1.1694	.639	.7956	.9831
7	1.5655	1.3426	1.3957	1.2826	.9339	.9116	1.0978
8	1.5089	1.1736	1.3203	1.1883	1.1506	.8383	1.1142
9	1.0185	.8817	1.0185	1.1128	.4752	.7545	.6718
10	.5365	.6979	.7733	.9431	.3206		.2984
11	.5765	.7122	.6299	.663	.2641		.2012
12	.4807		.4973	.6796	.2829		.1865
13	.3353	.57	.4641	.663	.3018		.1677
14	.5801	.4578	.4641	.4973	.3395	.3018	.2347
15	.5765	.4191	.4475	.5304	.3584	.3018	.2984
16	.5304	.4694	.431	.547	.3772	.2652	.3353
17	.4917	.4527	.431	.5801	.4527	.2818	.3222
18	.5415	.4359	.4807	.4807	.547	.3395	.4066
19	1.0456	.6979	.7167	.9997	.6413	.9431	.9335
20	1.0642	.7922	1.1128	1.1317	.7545	1.226	1.1949
21	.7468	.6979	.7545	.7545	.8299	.9431	.7655
22	.7545	.6979	.6979	.6979	.7922	.8299	.7095
23	.6979	.6602	.6602	.6602	.4287	.7545	.6722
24	.5658	.6535	.6413	.6413	.4287	.4458	.3812
Max	1.5655	1.3426	1.3957	1.2826	1.1506	1.226	1.1949
Min	.3353	.4191	.431	.4807	.2641	.2652	.1677
Avg	.8039	.7306	.7748	.8056	.5391	.6409	.6117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 201 / 11 KV ZANZARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.0914	.0924	.0754	2.1605	2.3472	2.3137
2	.1509	.0914	.0924	.0754	2.1605	2.7161	2.6825
3	.1677	.0914	.1109	.0754	2.2405	2.9172	2.8837
4	.1844	.1097	.1307	.0943	2.2455	3.0178	3.0849
5	.2012	.1509	.1494	.0943	2.2405	3.0514	3.2861
6	.1677	.1886	.2075	.1509	2.6406	3.0849	3.3532
7	.1677	.2263	.2452	.1698	3.2007	3.1855	3.4537
8	.1677	.1886	.1886	.1886		3.2023	3.3532
9	.1677	.1509	.1509	.1509		3.219	3.3196
10	.1677	.1307	.112	.0754		.0671	.1006
11	3.1943		3.0152	3.3208	.0335	.0671	.0924
12	3.4789		1.5813	3.2891	.0335	.0838	.0732
13	3.4473	2.8464	3.3589	3.1626	.0671	.1006	.1097
14	3.4156	3.1943	3.2808	3.1558	.0671	.0671	.0732
15	3.5105	3.2891	3.4789	3.3608	.0671		.0732
16	3.3208	3.0994	3.4214	3.4408	.0671		.0732
17	3.2259	3.0836	3.3901	3.1626	.081	.0671	.0914
18	2.9412	3.0361	3.2259	2.9371	.0838	.1006	.1109
19	.1109	.1307	.1698	.0754	.1174	.1174	
20	.1509	.1698	.1698	.1132	.1341	.1341	.1307
21	.1698	.132	.1698	.1509	.1509	.1509	.1109
22	.1307	.112	.1132	.1132	.1677	.1677	.1109
23	.1109	.0934	.1132	.1132	.1844	.1844	.0739
24	.1341	.0914	.0924	.0754	1.8747	2.2466	2.2298
Max	3.5105	3.2891	3.4789	3.4408	3.2007	3.219	3.4537
Min	.1109	.0914	.0924	.0754	.0335	.0671	.0732
Avg	1.2091	.9408	1.1275	1.1509	.9532	1.3771	1.3559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 202 / 11 KV PENDAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.381	.3658	.5247	.0754	.0671	.0671
2	.6036	.381	.3658	.5441	.0754	.0671	.0503
3	.6371	.3963	.3963	.5121	.0754	.0671	.0335
4	.6706	.4268	.4268	.5281	.0943	.0671	.0671
5	.7042	.4877	.4877	.5121	.1132	.0838	.0671
6	.7377	.5487	.6097	.6241	.132	.0838	.0838
7	.7712	.6097	.6706	.7202	.1132	.1006	.0838
8	.8048	.6401	.7926	.7522	.0943	.0838	.0671
9	.7712	.6097	.7621	.6882	.0943	.0671	.0503
10	.0503	.1109	.0934	.0566	.0754	.1006	.0503
11	.0549		.0566	.0377	.6706	.7042	.7926
12	.0549		.0566	.0377	.7042	.7377	.8535
13	.0549	.0549	.0377	.0377	.7209	.8048	.7011
14	.0549	.0549	.0377	.0377	.7377	.8383	.6401
15	.0549	.0549	.0377		.8048	.8048	.6097
16	.0549	.0549	.0377	.0377	.7712	.7712	.6859
17	.0549	.0549	.0377	.0377	.7377	.7545	.7011
18	.0549	.0549	.0566	.0566	.7042	.7377	.6706
19	.0549	.0554	.0943	.0943	.0671	.0671	.0914
20	.0732	.0554	.0943	.0943	.0838	.0838	.1294
21	.0732	.0747	.0754		.1006	.1006	.1109
22	.0732	.0739	.0754	.0943	.0838	.1006	.1109
23	.0739	.0924	.0566	.0943	.1006	.1006	.0924
24	.5365	.3353	.3353	.5155	.0754	.0838	.0838
Max	.8048	.6401	.7926	.7522	.8048	.8383	.8535
Min	.0503	.0549	.0377	.0377	.0671	.0671	.0335
Avg	.3185	.2549	.2525	.3017	.3044	.3116	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 203 / 11KV BABARGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.0364	.945	1.0437			
2	1.9113	1.0364	.945	1.0753			
3	2.2131	1.0974	1.0059	1.0936			
4	2.3137	1.1584	1.1111	1.1385			
5	2.4143	1.406	1.4685	1.2498			
6	2.4813	2.1822	1.866	1.9204			
7	2.5149	2.4036	2.2138	2.5301			
8	2.5484	2.372	2.8464	2.4646			
9	2.5149	2.372	2.6882	2.2929			
11					2.2801	2.1795	2.4352
12					2.364	2.5149	2.5301
13					2.4478	2.5819	2.372
14					2.5149	2.649	2.3087
15					2.5149	2.5819	2.2138
16					2.3137	2.5484	2.3403
17					2.2131	2.5149	2.4036
18					2.1795	2.4478	2.3087
24	1.3603	.9145	.9145	1.0936			
Max	2.5484	2.4036	2.8464	2.5301	2.5149	2.649	2.5301
Min	1.3603	.9145	.9145	1.0437	2.1795	2.1795	2.2138
Avg	2.1781	1.5979	1.6004	1.5903	2.3535	2.5023	2.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 204 / 11KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0152	.0152	.0177	.0175	.0168	.0168
2	.0168	.0152	.0152	.0173	.0177	.0168	.0168
3	.0168	.0152	.0152	.0175	.0175	.0168	.0168
4	.0168	.0152	.0152	.0175	.0175	.0168	.0168
5	.0168	.0152	.0152	.0175	.0175	.0168	.0168
6	.0168	.0152	.0152	.0076	.0175	.0168	.0168
7	.0168	.0335	.0152	.0181	.0175	.0162	.0168
8	.0671	.0152	.0537	.056	.0566	.0503	.0168
9	.0671	.0152	.0732	.0754	.0566	.0838	.0335
10	.0671	.0152	.0543	.0754	.0566	.1006	.0503
11	.0724		.0943	.0747	.0503	.1006	.0335
12	.0724		.0943	.0754	.0671	.1006	.0335
13	.0724	.0152	.0943	.0754	.0838	.1006	.0335
14	.0724	.0152	.0943	.0754	.0838	.0838	.0335
15	.0724	.0152	.0943	.0754	.0838	.0671	.0335
16	.0914	.0152	.0943	.0754	.0838	.0671	.0335
17	.0914	.0152	.0943	.0754	.0838	.0671	.0335
18	.1494	.0152	.0549	.0754	.0838	.0671	.0335
19	.1109	.0152	.0754	.0754	.0671	.0335	.0335
20	.0335	.0152	.0177	.0362	.0503	.0335	.0152
21	.0335	.0152	.0177	.0351	.0335	.0335	.0152
22	.0335	.0152	.0181	.0366	.0335	.0335	.0152
23	.0335	.0152	.0177	.0175	.0335	.0168	.0152
24	.0168	.0335	.0152	.0173	.0175	.0168	.0168
Max	.1494	.0335	.0943	.0754	.0838	.1006	.0503
Min	.0168	.0152	.0152	.0076	.0175	.0162	.0152
Avg	.0531	.0169	.0485	.0475	.0478	.0489	.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 201 / 11KV KHULTABAD-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.7545	.6344	.6859	.6859	.7865	.7545
2	.7373	.7545	.6344	.6687	.6859	.7316	.7545
3	.7545	.7716	.6516	.6859	.703	.7316	.7545
4	.7716	.7716	.6859	.7202	.7373	.7316	.7922
5	.823	.823	.6859	.7888	.7545	.7682	.8676
6	.8745	.8573	.7202	.8402	.8059	.8779	1.0185
7	.8402	.9259	.7202	.8573	.9431	.9877	1.0185
8	.8573	.9431	.703	.8573	.8745	.9877	.9431
9	.8916	.9259	.7545	.8573	.9259	.9511	.9431
10	.8299	.9431	.7545		.8059	.7888	.6344
11	.8299	.9431	.7545	1.1317	.7545	.7545	.583
12	.8676	.7545	.7545	.9431	.823	.7716	.5658
13	.7545	.7545	.8299	.9431	.7716	.8402	.7373
14	.7545	.7545	.7545	.8299	.8402	.823	.6344
15	.7545	.679		.7545	.7373		.7202
16		.679		.8299	.7545		.7545
17	.703	.6516	.7888	.7202	.8779	1.1317	.7716
18	.703	.6859	.7888	.7888	.8779	1.0185	.823
19	.9431	.823	.9945	1.0288	1.0791	1.2071	.8573
20	.9774	.9088	1.0117	.8916	1.0974	1.1317	.8916
21	.8745	.8059	.9431	.823	1.134	1.1317	.7888
22	.8573	.7888	.8916	.8059	.9496	.9431	.7545
23	.8059	.6859	.823	.8059	.8962	.9516	.7202
24	.7888	.7545	.6344	.7545	.7716	.7316	.8676
Max	.9774	.9431	1.0117	1.1317	1.134	1.2071	1.0185
Min	.703	.6516	.6344	.6687	.6859	.7316	.5658
Avg	.8144	.7975	.7688	.8266	.8453	.8990	.7896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 202 / 11 KV SULIBHANJAN AG
FEEDER Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3944		.3658	.1829	.3353	.3395
2	.4287	.3944	.4115	.4572	.1677	.3353	.3395
3	.4287	.4287	.4287	.4877	.1981	.3353	.3772
4	.583	.5487	.5487	.5487	.2286	.3353	.3772
5	.7202		.9259	.5944	.2591	.3688	.415
6	.9602		1.4403	.8383	.3048	.4191	.4527
7	1.6289	.6859	1.7318	1.5394	.4268	.4191	.4527
8	1.989	1.7833	1.8347	1.8595	.3201	.3521	.3018
9	1.3717	1.3889	.823	1.1126	.1677	.218	.2641
10	.2058	.2263	.2641		.1715	.1543	.12
11	.1886	.0754	.2263	.2263	1.5604	1.3375	1.3717
12	.1509	.0754	.1509	.1886	1.5089	1.2517	1.1317
13	.1509	.1132	.1132	.1132	1.2346	.9602	.823
14	.1509	.1132	.1132	.1132	1.0802	.8573	.6859
15	.1509	.1132		.1509	1.1317	.6859	.4973
16	.1509	.1132		.1886	1.0631	.8916	.703
17	.1372	.12	.1067	.1677	1.3256	1.1317	.823
18	.1715	.12	.1067	.1524	.8718	.7545	.6249
19	.2915	.1715	.2743	.2896	.285		.2439
20	.2572	.2401	.2743	.2134	.3391	.3772	.3201
21	.2401	.2229	.2286	.2286	.3856	.3772	.3048
22	.2058	.2058	.1829	.1981	.3521	.3772	.2439
23	.1886	.1886	.1829	.1981	.3353	.3426	.2286
24	.4458	.3944	.4115	.3506	.1677	.3185	.3395
Max	1.989	1.7833	1.8347	1.8595	1.5604	1.3375	1.3717
Min	.1372	.0754	.1067	.1132	.1677	.1543	.12
Avg	.4851	.3690	.5133	.4601	.5862	.5624	.4909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 203 / 11 KV T. V. Centre
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343	.0343	.0171		
2		.0343	.0343		.0343		
3		.0343	.0343				
4	.0343	.0343	.0343				
5	.0343	.0343	.0343	.0171	.0171		
6	.0343	.0343	.0343	.0343	.0343	.0366	.0377
7	.0343	.0343	.0343	.0343	.0343	.0377	.0377
8	.0343	.0343	.0343	.0343	.0343	.0366	.0377
9	.0343	.0343	.0343	.0343	.0343	.0366	.0377
10	.0566	.0566	.0377		.0343	.0343	.0343
11	.0514	.0377	.0566	.0566	.0343	.0343	.0857
12	.0566	.0377	.0566	.0377	.0514	.0343	.0343
13	.0514	.0343	.0566	.0377	.0514	.0343	.0514
14	.0377	.0377	.0377	.0377	.0514	.0343	.0514
15	.0377	.0377		.0377	.0514	.0514	.0514
16	.0343	.0377		.0377	.0514	.0514	.0514
17	.0343	.0343	.0343	.0343	.0366	.0377	.0514
18	.0343	.0343	.0343	.0343	.0366	.0377	.0343
19	.0514	.0343	.0343	.0343	.0335	.0377	.0343
20	.0343	.0343	.0343	.0343	.0366	.0377	.0343
21	.0343	.0343	.0343	.0343	.0366	.0377	.0343
22	.0343	.0343	.0343	.0343	.0366	.0377	.0343
23	.0343	.0343	.0343	.0343	.0366	.0377	.0343
24	.0343	.0343	.0343	.0343	.0343	.0366	.0377
Max	.0566	.0566	.0566	.0566	.0514	.0514	.0857
Min	.0343	.0343	.0343	.0171	.0171	.0343	.0343
Avg	.0392	.0359	.0377	.0354	.0372	.0380	.0424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 204 / 11KV ELLORA MANDIR
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4458	.4287	.3258	.4458	.4755	.4527
2	.463	.4458	.4287	.3429	.3772	.4755	.4568
3	.5144	.4801	.4801	.3601	.4115	.4755	.4904
4	.583	.5487	.5144	.4458	.4973	.4755	.4904
5	.6516	.6173	.583	.6173	.583	.5853	.679
6	.8059	.7373	.7716	.7545	.823	.8596	.8676
7	.8745	.823	.8573	.9088	.8573	.9877	.9808
8	.7373	.8059	.703	.7373	.7545	.7682	.8299
9	.6001	.7545	.6001	.6859	.6516	.6401	.7922
10	.5658	.7545	.5658	.5658	.4973	.5487	.5487
11	.3772	.679	.4904	.5658	1.166	.4801	.4287
12	.3772	.7545	.3772	.4904	.5487	.5144	.4115
13	.3772	.5658	.3772	.4904	.4458	.4287	.4115
14	.3772	.3772	.3772	.3772	.4801	.583	.4287
15	.3772	.3772		.3772	.5487	.4458	.4458
16	.3772	.415		.3772	.583	.583	.4801
17	.6687	.4458	.7373	.5144	.6584	.6413	.5316
18	.7373	.583	.7373	.6344	.6584	.5658	.5487
19	.7716	.6516	.7202	.703	.7865	.8676	.6687
20	.6516	.6859	.703	.7202	.7499	.8299	.6859
21	.5658	.5487	.6001	.7545	.695	.679	.6173
22	.5144	.4973	.5316	.6173	.6219	.6091	.5144
23	.4801	.463	.4973	.4973	.5487	.5658	.4973
24	.4801	.4458	.4287	.4458	.3429	.5487	.4904
Max	.8745	.823	.8573	.9088	1.166	.9877	.9808
Min	.3772	.3772	.3772	.3258	.3429	.4287	.4115
Avg	.5580	.5793	.5686	.5546	.6139	.6097	.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 205 / 11 KV KASABKHEDA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2058	.1524	.3048	.3201	.4527
2	.2743	.2058	.2058	.1677	.3658	.4024	.4568
3	.2229	.2401	.2058	.1981	.442	.4024	.4949
4	.2229	.2572	.2401	.2134	.5182	.4024	.4458
5	.2572	.2743	.2572	.2439	.7468	.5197	.5658
6	.3086	.2915	.2915	.2286	.8535	.59	.679
7	.3429	.3086	.3086	.2743	.884	1.0395	1.2071
8	.2915	.2915	.2572	.2591	.8078	1.0395	1.2449
9	.2058	.2401	.2229	.1981	.1524	.6706	.8676
10	.1886	.1886	.1886	.1886	.1543	.1543	.1372
11	1.1317	.9431	.9431	.9431	.12	.1372	
12	.9431	.7545	.8299	.8676	.12	.12	
13	.8299	.7545	.7545	.8299	.1372	.12	
14	.7545	.679	.679	.7545	.12	.12	.1886
15	.5658	.679		.7545	.12	.1372	.1886
16	.5658	.679		.7613	.1341	.1372	.1543
17	.5144	.6001	.6097	.5487	.1509	.1715	.0914
18	.4458	.583	.5335	.503	.1677	.1886	.1219
19	.2572	.2058	.2134	.2134	.2515	.2641	.1677
20	.2743	.2229	.1981	.2286	.2515	.3018	.1981
21	.2401	.2058	.2134	.1981	.2347	.2641	.2134
22	.2229	.2229	.2134	.1829	.2012	.2641	.2439
23	.2058	.2058	.1829	.1677	.1844	.2263	.1981
24	.2229	.2058	.2058	.1677	.2896	.1844	.4904
Max	1.1317	.9431	.9431	.9431	.884	1.0395	1.2449
Min	.1886	.1886	.1829	.1524	.12	.12	.0914
Avg	.4047	.3935	.3618	.3852	.3214	.3407	.4194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 206 / 11 KV PALASWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.2012	.2012	.2515	.1509	.218	.2284
2	.218	.2012	.2012	.2683	.1677	.218	.2263
3	.218	.2012	.2713	.285	.2054	.218	.2641
4	.2347	.2683	.2347	.3018	.218	.218	.2641
5	.218	.3018	.5365	.3185	.2347	.2713	.3395
6	.3856	.4359	.6036	.3961	.2683	.017	.3807
7	.7377	.5533	.7122	.5197	.3185	.3185	.3772
8	.5533	.7545	.8048	.7545	.218	.2347	.3018
9	.4694	.5197	.57	.1844	.2035	.1844	.2263
10	.1677	.1677	.1696	.1677	.1677	.12	.1543
11	.1677	.1341	.1677	.1677	.5533	.4801	.6516
12	.1677	.1677	.1696	.1677	.6874	.4973	.6344
13	.2012	.1677	.1677	.1677	.5868	.5316	.5658
14	.2347	.1677	.1341	.1677	.5533	.4801	.4801
15	.285	.285		.1677	.506		.4115
16	.1677	.1852		.1677	.57	.5487	.6001
17	.1844	.2012	.1341	.1844	.5197	.6036	.6036
18	.1677	.218	.1844	.1844	.373	.3772	.4917
19	.3185	.218	.2347	.2713	.2515	.3018	.2347
20	.2683	.2347	.2683	.218	.285	.3018	.218
21	.3018	.2347	.285	.1865	.2204	.2641	.2035
22	.2515	.2347	.2347	.1677	.2347	.2641	.1865
23	.285	.2012	.218	.1696	.2012	.2263	.2054
24	.2347	.2012	.2012	.285	.1509	.2204	.2263
Max	.7377	.7545	.8048	.7545	.6874	.6036	.6516
Min	.1677	.1341	.1341	.1677	.1509	.017	.1543
Avg	.2773	.2690	.3048	.2550	.3269	.3093	.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 208 / 11KV CAVES

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0514	.0457	.0457	.0503	.0377
2	.0514	.1029	.0514	.0457	.0305	.0503	.0377
3	.0514	.0514	.0514	.0457	.0457	.0509	.0377
4	.0514	.0514	.0514	.0457	.0457	.0509	.0377
5	.0686	.0514	.0514	.0457	.0457	.0503	.0754
6	.0686	.0514	.0514	.061	.061	.0503	.0754
7	.0514	.0514	.0514	.0457	.0457	.0549	.0754
8	.0514	.0514	.0514	.0457	.0457	.0335	.0377
9	.0686	.0686	.0514	.061	.0762	.0509	.0686
10	.0943	.0943	.0754		.0686	.0686	.0857
11	.0943	.0686	.0943	.0943	.0857	.0514	.0686
12	.0943	.0754	.0094	.1132	.0686	.0686	.0857
13	.0943	.0754	.0094	.1132	.0686	.0686	.0857
14	.0754	.0754		.0754	.0857	.0857	.0514
15	.0754	.0377		.0754	.0686	.0686	.0857
16	.0754	.0377		.0754	.0686	.0514	.0514
17	.1029	.0514	.0762	.061	.0838	.0754	.0762
18	.0514	.0514	.061	.0762	.0671	.0754	.0762
19	.0686	.0514	.061	.061	.0838	.0754	.0457
20	.0686	.0514	.0457	.0457	.0838	.0754	.0762
21	.0514	.0514	.0457	.061	.0671	.0754	.0762
22	.0686	.0514	.0457	.0457	.0503	.0754	.061
23	.0514	.0514	.0457	.0457	.0503	.0754	.0457
24	.0514	.0514	.0514	.0457	.0457	.0503	.0377
Max	.1029	.1029	.0943	.1132	.0857	.0857	.0857
Min	.0514	.0377	.0094	.0457	.0305	.0335	.0377
Avg	.0687	.0586	.0516	.0622	.0620	.0618	.0622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 209 / 11kv kagzipura

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.1886	.1886	.2229	.2012	.1886
2	.2229	.2058	.1886	.2229	.2401	.2012	.2263
3	.2229	.2401	.1886	.2058	.1886	.2012	.2263
4	.2401	.2743	.2401	.2401	.2229	.2012	.2641
5	.3086	.3086	.3086	.2743	.3086	.3292	.3018
6	.4287	.3601	.3601	.3772	.3258	.4207	.4904
7	.4801	.4458	.4287	.4115	.4287	.5121	.3772
8	.4287	.4115	.3258	.4115	.2743	.3856	.3807
9	.3429	.2915	.3429	.3429	.3429	.2378	.3018
10	.3018	.3772	.3772		.1886	.2401	.2401
11	.2641	.2401	.2641	.3772	.2401	.2572	.2401
12	.2641	.1886	.2641	.3018	.2401	.2572	.2058
13	.1886	.1886	.2641	.2641	.2058	.2572	.1372
14	.1886	.1886	.1886	.2641	.1715	.2058	.2058
15	.1886	.1886		.2641	.1886	.1886	.1715
16	.1886	.1886		.2263	.2058	.2743	.1886
17	.2058	.2058	.2572	.3258	.2561	.2641	.2229
18	.2572	.2572	.2743	.3086	.2743	1.3957	.3086
19	.3772	.3086	.3601	.3048	.3841	.415	.3429
20	.3429	.3258	.3429	.3601	.3841	.3807	.3772
21	.2401	.2229	.2915	.3429	.3292	.3206	.3086
22	.2401	.2229	.2401	.3429	.2926	.2263	.3258
23	.2229	.2058	.2058	.2743	.2378	.1886	.2743
24	.2058	.2058	.1886	.1886	.2229	.1829	.1886
Max	.4801	.4458	.4287	.4115	.4287	1.3957	.4904
Min	.1886	.1886	.1886	.1886	.1715	.1829	.1372
Avg	.2732	.2608	.2768	.2965	.2657	.3227	.2706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 201 / 11KV BAZAR SAWANGI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.2858	.4954	.381	.1143	.0953	
2	.6668	.3239	.5335	.724	.0953	.0953	
3	.6668	.4572	.5544	.5716	.0953	.0953	
4	.7621	.5525	.5914	.6668	.1143	.1143	
5	.9526	.724	.7392	1.1431	.1524	.1524	
6	1.105	.9335	1.1088	1.5242	.2477	.2667	
7	1.7353	1.4098	1.6461	1.6975	.3429	.381	
8	1.6032	1.3717	1.5912	1.6409			
9	1.1694	.9526	1.0719	1.105			
11					1.5242	1.262	1.1694
12					1.467	1.1827	1.1317
13					1.3717	.5601	.7922
14					1.2384	.9055	.8488
15					1.0669	.8316	.9431
16					1.0288	.8871	.8002
17					.9907	.9979	.8573
18					.6097	.5729	.724
19	.3048	.2477	.2286	.3429	.3429		.2286
20	.3429	.2667		.2477	.2667		.2667
21	.1905	.1715	.1715	.1905	.1905		.2096
22	.1715	.1334	.1524	.1715	.1905		.1524
23	.2286	.1143	.1334	.1715	.1143		.1334
24	.4191	.3048	.4572	.3429	.1143	.1143	
Max	1.7353	1.4098	1.6461	1.6975	1.5242	1.262	1.1694
Min	.1715	.1143	.1334	.1715	.0953	.0953	.1334
Avg	.7260	.5500	.6768	.7281	.5561	.5322	.6352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 202 / 11 KV. Bodkha AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1143	.1524	.1334	.9145	.9145	.961
2	.2096	.1334	.1524	.0762	.9717	.9717	1.0164
3	.2096	.1524	.1905	.1143	1.0098	.9907	1.1088
4	.2096	.2096	.2286	.1143	1.105	1.086	1.1458
5	.2096		.2667	.1715	1.1812	1.2955	1.2936
6	.3048		.3048	.2096	1.3717	1.3908	1.4632
7	.3048		.3048		1.467	1.6004	1.701
8					1.6194	1.7337	1.7924
9					1.2765	1.2384	1.5546
11	1.5432	1.1706	1.4146	1.6385			
12	1.848	1.2986	1.6032	1.7718			
13	1.8099	1.3352		1.6004			
14	1.5242	1.2986	1.5466	1.5813			
15	1.6575	1.3169	1.5089	1.5623			
16	1.4861	1.3169	1.5089	1.5242			
17	1.5051	1.2437	1.4712	1.5051			
18	1.2384	1.2986	1.4712	1.3336			
19	.1905	.2286	.1715	.1905	.2096		.3048
20	.2096	.2096	.2096	.2096	.1524		.3429
21	.1715	.1905	.1524	.1524	.1524		.1524
22	.1334	.1905	.1524	.1905	.1524		.1524
23	.1143	.1524	.1524	.8383	.7811		.1715
24	.2096	.1334	.1524	.1524	.8764	.8764	.8871
Max	1.848	1.3352	1.6032	1.7718	1.6194	1.7337	1.7924
Min	.1143	.1143	.1524	.0762	.1524	.8764	.1524
Avg	.7285	.6663	.6558	.7535	.8827	1.2098	.9365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 203 / 11 KV. KANATGAON. AG. SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381				.1334		.1524
2	.0381				.1143	.1524	.1524
3	.0381				.1334	.1715	.1905
4	.0381	.0381	.0381		.1715	.1715	.1905
5	.0381	.0572	.0572	.0381	.2286	.2286	.1905
6	.0381	.0572	.0762	.0381	.3048	.3239	.2286
7	.0381	.0953	.0953		.362	.4191	.3239
8					.381	.381	.362
9					.2858	.3429	.2858
11	.362	.3429	.381	.3048			
12	.3239	.2667	.3048	.2667			
13	.2667	.2096	.2667	.2477			
14	.2286	.2286	.2096	.2477			
15	.2286	.1715	.1524	.2096			
16	.2858	.2096	.1905	.2477			
17	.2286	.2286	.3048	.2858			
18	.2096	.2286	.2096	.1905			
19	.0572	.0762	.0572	.0572	.0762		.0572
20	.0381	.0572	.0381	.0572	.1143		.0381
21		.0381	.0572		.1143		
22					.1143		
23				.1524	.1334		
24					.1334	.1334	.1524
Max	.362	.3429	.381	.3048	.381	.4191	.362
Min	.0381	.0381	.0381	.0381	.0762	.1334	.0381
Avg	.1468	.1537	.1626	.1803	.1867	.2583	.1937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 204 / 11KV YESGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2477	.3048	.3048	.0762	.0762	
2	.3429	.2858	.3429	.3429	.0762	.0572	
3	.3429	.3239	.381	.3429	.0953	.0572	
4	.4191	.362	.4191	.2858	.1143	.0762	
5	.4191	.4954	.4763	.3048	.1143	.0953	
6	.6097	.5716	.5335	.4191	.1143	.1143	
7	.9145	.6287	.7207	.6668	.1143	.1143	
8	.6478	.6668	.7095	.6668			
9	.5716	.4572	.4481	.5716			
11					.7049	.5228	.4572
12					.6668	.6283	
13					.5716	.5601	
14					.4572	.4191	.3429
15					.5335	.381	.5335
16					.5335	.4382	.5716
17					.4954	.4572	.5716
18					.4001	.3048	.4763
19	.0953	.0762		.0953	.0953		.0762
20	.1143	.0953	.0381	.0953	.1143		.0953
21	.1143	.1143	.0572	.0953	.0953		.0953
22	.1143	.1143	.0381	.1143	.1143		.0953
23	.2667	.1143	.0381	.1143	.0762		.1143
24	.2858	.2667	.2858	.5335	.0953	.0953	
Max	.9145	.6668	.7207	.6668	.7049	.6283	.5716
Min	.0953	.0762	.0381	.0953	.0762	.0572	.0762
Avg	.3696	.3213	.3424	.3302	.2695	.2748	.3118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 205 / 11KV TAJNAPUR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2858	.3239	.2667	.3429	.3429	
2	.4191	.3429	.362	.2667	.3239	.3239	
3	.4191	.381	.4191	.2858	.3239	.3048	
4	.4191	.4001	.5335	.381	.362	.3429	
5	.381	.4763	.6097	.5716	.4191	.362	
6	.7621	.5335	.7023	.6097		.4001	
7	.8002	.5525	.7762	.724		.4382	
8	.8002	.743	.7577	.8573			
9	.5716	.4954	.5975	.6668			
11					.6668	.4854	.4191
12					.5716	.3921	.4763
13					.4954	.381	.4572
14					.4382	.3429	.4763
15					.362	.2667	.3429
16					.362	.362	.381
17					.381	.381	.4572
18					.3048	.3429	.4572
19	.4191	.3048	.3048	.381	.381		.2667
20	.362	.4001	.381	.4001	.4001		.3048
21	.3048	.2858	.2858	.3429	.3429		.3429
22	.2667	.2667	.2667	.3429	.3048		.362
23	.2286	.2286	.2286	.3239	.362		.381
24	.3048	.2477	.2858	.2667	.362	.3429	
Max	.8002	.743	.7762	.8573	.6668	.4854	.4763
Min	.2286	.2286	.2286	.2667	.3048	.2667	.2667
Avg	.4534	.3963	.4556	.4458	.3951	.3632	.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 206 / 11KV Yesgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.3239	.3048	.3048	.2858	.3048
2	.2858	.3048	.381	.3048	.3048	.2858	.381
3	.3048	.3429	.4572	.3048	.3239	.3048	.4191
4	.2858	.4001	.5716	.3048	.362	.3429	.4954
5	.4191	.5335	.6468	.3048	.4572	.4382	.5716
6	.8002	.743	.7392	.7621	.6097	.7049	.6668
7	.8002	.9717	.8871	.8954	.9145	.8573	.9896
8	.8383	.8573	.7655	.8573	.6859	.7049	.7282
9	.5716	.5716	.6348	.5906	.4763	.5144	.4763
10	.4001	.381	.5716	.4954	.3048	.3239	.381
11	.2667	.2858	.4191	.5144	.2477	.2286	.2477
12	.2667	.2286	.381		.2286	.2096	
13	.2477	.2286	.2286	.4001	.2286	.2286	
14	.2096	.2096	.2096	.3239	.2286	.1905	.2286
15	.2286	.2096	.2286	.2858	.2477	.2096	.2667
16	.2286	.2477	.2286	.2858	.2477	.2477	.2667
17	.2477	.2667	.2667	.3048	.2477	.2477	.2667
18	.4763	.362	.4191	.3239	.362	.362	.3429
19	.6478	.6668		.6668	.6097	.5788	.5716
20	.5144	.6668	.6668	.5716	.5335	.6161	.6668
21	.4001	.4382	.4763	.4954	.4382	.4572	.4763
22	.362	.362	.381	.4191	.4001	.4191	.381
23	.3239	.3239	.3429	.3239	.3429	.362	.362
24	.2858	.3239	.2858	.3048	.3429	.3048	.2667
Max	.8383	.9717	.8871	.8954	.9145	.8573	.9896
Min	.2096	.2096	.2096	.2858	.2286	.1905	.2286
Avg	.4041	.4255	.4571	.4498	.3937	.3927	.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 207 / 11KV VIKAS GINNING EXP
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381				.0381		
2	.0381						
7	.0381					.0953	.0953
8	.1715				.0953		.1143
9	.1524	.0762		.1143	.0953	.0953	.0953
10	.0953	.0953		.1334	.0381		.0953
11	.0953	.0953		.1143	.1524	.0762	.0953
12	.0762	.0762			.0191	.0762	.0953
13		.0953			.0381		.0762
14	.0762		.0381	.0762	.0381		.0381
15	.1143			.1143	.0381	.1143	
16	.0953		.1143	.1334	.0381	.0953	
17	.0953		.1524	.1524	.0191	.0762	.0762
18	.1143		.1524	.1143		.0953	.0381
19	.0381		.1143	.0953		.0381	
23				.0381			
24					.0381		
Max	.1715	.0953	.1524	.1524	.1524	.1143	.1143
Min	.0381	.0762	.0381	.0381	.0191	.0381	.0381
Avg	.0885	.0877	.1143	.1086	.0540	.0847	.0819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 208 / Bodhaka Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.3048	.2286	.2286	.2286	.3048
2	.2667	.1905	.381	.2667	.2477	.2286	.3429
3	.2286	.2096	.4572	.2667	.2858	.2667	.4191
4		.2477	.5335	.2667	.362	.362	.4572
5	.2286	.3429	.6097	.381	.4382	.4382	.5544
6	.6097	.5335	.724	.7621	.6859	.6097	.6468
7	.8002	.8573	.8383	.8764	.8954	.8192	
8	.6478	.743	.7095	.8383	.6478	.5716	.6535
9	.5335	.5335	.5335	.6287	.5335	.4191	.5335
10	.4001	.4001	.381	.5335	.3239	.2477	.381
11	.1905	.2286	.1905	.4001	.2667	.2667	.2858
12	.2286	.1905	.1905	.3048	.1905	.2286	.2096
13	.2096	.1524	.1715	.2286	.2096	.1905	.1715
14		.1524	.1524	.2286	.1524	.1715	.2096
15	.2477	.1524	.1905	.1905	.2096	.1905	.2286
16	.2096	.1715	.2096	.1905	.2286	.1905	.2286
17	.3239	.1905	.2286	.2286	.2858	.2096	.2477
18	.3429	.3048	.1905	.3429	.3239	.381	.3239
19	.6668	.5906	.5335	.6478	.5525	.4954	.5335
20	.5335	.5906	.5716	.5525	.3429	.6161	.6097
21	.4191	.4191	.381	.4001	.4191	.4382	.4572
22	.3429	.3239	.3429	.3239	.3239	.3429	.381
23	.2477	.2667	.2858	.2858	.2667	.2667	.2858
24	.2667	.2477	.2286	.2286	.2667	.2477	.2286
Max	.8002	.8573	.8383	.8764	.8954	.8192	.6535
Min	.1905	.1524	.1524	.1905	.1524	.1715	.1715
Avg	.3732	.3445	.3892	.4001	.3620	.3511	.3780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 209 / 11 kv BAZARSAWANGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1524	.1334	.1715	.1143	.1905
2	.1524	.1143	.1905	.1524	.1524	.1143	.2667
3	.1524	.1334	.2667	.1524	.1905	.1334	.3048
4	.1524	.1715	.3048	.1524	.2096	.1715	.3429
5	.1524	.2667	.3429	.1524	.2858	.2667	.381
6	.2096	.3429	.381	.4191	.362	.362	.4191
7	.4191	.4191	.4763	.4572	.4191	.4382	.4763
8	.3429	.3239	.362	.381	.3239	.3239	.3429
9	.2858	.2286	.2667	.3239	.2096	.2667	.2858
10	.1905	.1715	.2096	.2858	.1524	.1905	.2096
11	.1334	.1524	.1524	.2286	.1524	.1524	.1334
12	.1334	.0953	.1524	.1905	.1334	.1143	.1143
13	.1143	.1143	.1334	.1905	.1524	.1334	.1143
14	.1143	.1143	.1334	.1524	.1524	.1524	.1143
15	.1524	.1143	.1143	.1524	.1334	.1334	.1334
16	.1715	.1143	.1143	.1524	.1524	.1334	.1334
17	.1905	.1334	.1334	.1524	.1524	.1334	.1334
18	.2096	.1715	.1905	.2096	.1905	.2096	.1905
19	.3429	.3239	.3048	.3239	.3429	.3239	.3429
20	.3048	.3429	.3429	.2858	.3048	.381	.381
21	.1905	.1905	.2096	.2286	.2477	.2286	.2477
22	.1524	.1524	.1715	.1905	.1905	.2096	.2096
23	.1334	.1334	.1524	.1715	.1715	.1715	.1715
24	.2096	.1334	.1143	.1524	.1905	.1524	.1334
Max	.4191	.4191	.4763	.4572	.4191	.4382	.4763
Min	.1143	.0953	.1143	.1334	.1334	.1143	.1143
Avg	.1985	.1905	.2239	.2246	.2143	.2088	.2405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 201 / 11 KV Bhadji AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2229	.1829	.1174
2					.2915	.2286	.1006
3					.3429	.2743	.0838
4					.3772	.381	.0838
5					.463	.5487	.1677
6					.5658	.6249	.3391
7					.6859	.7011	.3561
8					.4115	.7164	.8573
9					.2134	.503	.4973
11	.6173	.5493	.4578	.5765			
12	.583	.5493	.5256	.5144			
13	.5144	.4075	.4917	.4287			
14	.4287	.3506	.39	.4801			
15	.4115	.3292	.3561	.5144			
16	.3772	.3544	.3018	.5144			
17	.3601	.4382	.4527	.5316			
18	.2401	.2835	.2883	.3086			
24					.1886	.1524	.116
Max	.6173	.5493	.5256	.5765	.6859	.7164	.8573
Min	.2401	.2835	.2883	.3086	.1886	.1524	.0838
Avg	.4415	.4078	.408	.4836	.3763	.4313	.2719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 202 / 11KV GADANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3086		.2984	.1143	.2591	.3018
2	.3315	.3429	.3189	.2984	.1143	.2286	.3018
3	.3315	.3429	.3189	.3315	.1334	.1981	.3018
4	.3647	.3601	.3506	.4024	.1334	.1981	.3206
5	.4807	.5487	.439	.4359	.1429	.2591	.3206
6	.763	.823	.5784	.6036	.1429	.2439	.3395
7	1.2887	.9602	1.3112	1.1065	.1429	.2286	.2829
8	1.358	1.3717	1.2574	1.2407	.1677	.1981	.1886
9	.9259		.7545	.8478	.1219	.1372	.1509
10	.0762	.124	.0943	.1698	.0914	.1132	.1143
11	.0762	.0762	.9054	.1509	.9297	1.0774	.8589
12	.0381	.0572	.0566	.0667		.9614	.8764
13	.0381	.0572	.0754	.0667		.7712	.6661
14	.0381	.0762	.0754	.0667		.6539	.567
15	.0381	.0762	.0754	.0572		.6036	.4557
16	.0381	.0762	.0754	.0476	1.0059	.5636	.5493
17	.0476	.0762	.0943	.0476	.8078	.7209	.6379
18	.0667	.0953	.1132	.0476	.5182	.6224	.4607
19	.0857		.1698	.1048	.1372	.1698	.1715
20	.0953	.2096	.2263	.1143	.2286	.2452	.2286
21	.1143	.1905	.1886	.1334	.2286	.2641	.1334
22	.1143	.1715	.1698	.1429	.2743	.2829	.2667
23	.1048	.1334	.1509	.1524	.2743	.3018	.3048
24	.3584	.2743	.298	.3052	.1429	.2591	.3018
Max	1.358	1.3717	1.3112	1.2407	1.0059	1.0774	.8764
Min	.0381	.0572	.0566	.0476	.0914	.1132	.1143
Avg	.3125	.3069	.3521	.3016	.2926	.3984	.3792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 203 / 11 KV Bhandegaon AG.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1238	.1334	.1334	.2401	.2286	.1174
2	.1334	.1238	.1334	.1334	.3086	.2591	.1509
3	.1334	.1238	.1429	.1524	.3086	.2743	.1677
4	.1429	.1238	.1429	.1524	.4115	.3353	.218
5	.1715	.1238	.1524	.1524	.6001	.4877	.3185
6	.1715	.1238	.1524	.1619	.6859	.5792	.4191
7	.1238	.1238	.1547	.1619	.7888	.6706	.3961
8	.1048	.0953	.0762	.0857	.5335	.7316	.1372
9	.0762		.0572	.0857	.3506	.5182	.0686
10	.0476	.0381	.0381	.0762	.0762	.0476	
11	.463	.4207	.5426	.5087	.061	.0286	
12	.463	.3898	.4024	.5144	.061	.0286	.0381
13	.4115	.2629	.3222	.4458	.0457	.0286	.0381
14	.3601	.2804	.2543	.463	.0457	.0286	.0381
15	.3944	.3189	.2229	.3772	.061	.0286	.0381
16	.4115	.3012	.3222	.3429	.061	.0286	.0286
17	.4287	.3366	.373	.4115	.061	.0286	.0381
18	.2229	.2303	.2515	.2401	.0762	.0286	.0476
19	.0953	.1227	.0667	.0857	.1219	.0476	.0762
20	.1048	.0953	.0953	.0857	.1372	.0095	.0857
21	.1238	.2103	.1048	.0857	.1524	.0762	.0572
22	.1238	.1429	.1143	.0762	.1067	.0667	.1524
23	.1238	.1429	.1238	.0667	.1067	.0572	.0572
24	.1334	.1238	.1334	.1238	.1715	.1372	.1147
Max	.463	.4207	.5426	.5144	.7888	.7316	.4191
Min	.0476	.0381	.0381	.0667	.0457	.0095	.0286
Avg	.2124	.1904	.1880	.2135	.2322	.1981	.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 204 / 11KV GADANA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1029	.0914	.1132	.1029	.0914	.1132
2	.132	.1029	.1097	.1132	.1029	.0914	.1132
3	.132	.1029	.1097	.1132	.12	.1067	.132
4	.1509	.1029	.128	.132	.1372	.1524	.1509
5	.1886	.1372	.1612	.1698	.1543	.1677	
6	.2829	.2401	.2481	.2641	.1886	.2286	.2641
7	.2075	.2401	.2126	.2263	.2743	.1677	.2263
8	.2075	.2058	.1886	.2075	.1829	.1219	.2075
9	.1698		.1132	.1698	.1219	.1219	.1698
10	.1029	.0914	.1132	.1698	.0762	.1132	.0914
11	.1029	.1097	.0943	.1132	.061	.0754	.0914
12	.0857	.0732	.0754	.1029	.061	.0943	.0549
13	.0857	.0914	.0943	.0857	.0457	.0943	.0549
14	.0857	.0732	.1132	.0857	.061	.0943	
15	.0857	.0732	.1132	.0857	.0762	.0754	.0549
16	.1029	.0732	.1132	.1029	.0762	.0754	.0549
17	.1029	.0914	.1132	.1029	.0762	.0943	.0914
18	.1543	.1097	.2263	.1715	.0914	.1132	.1463
19	.2401	.2126	.2452	.2401	.1829	.2075	.1949
20	.2058	.2378	.2641	.2058	.1677	.2641	.2481
21	.1715	.1829	.1886	.1715	.1372	.2075	.2126
22	.1543	.128	.1509	.1543	.1219	.1698	.1646
23	.1543	.1097	.132	.1372	.1219	.132	.1463
24	.132	.1372	.0914	.1132	.1372	.1067	.132
Max	.2829	.2401	.2641	.2641	.2743	.2641	.2641
Min	.0857	.0732	.0754	.0857	.0457	.0754	.0549
Avg	.1487	.1317	.1455	.1480	.1199	.1320	.1416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 205 / 11 KV Takali R.R.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.1334	.0762	.2641	.2572	.3048	.3481
2	.2641	.1334	.2667	.2641	.3086	.3353	.3521
3	.2641	.1334	.2667	.2641	.3601	.381	.3353
4	.2641	.1334	.2667	.2641	.4115	.6859	.3353
5	.2829	.1334	.2667	.2829	.6687	.884	.3688
6	.3018	.1429	.2667	.2641	.9945	1.0364	.6874
7	.2829	.1429	.2858	.2829	1.1831	1.2955	1.5257
8	.2829	.1429	.2829	.2829	.8688	1.4784	1.4746
9	.2641		.2452	.2641	.6401	1.0212	1.1488
10	.1238	.2667	.2641	.2641	.1981		.2477
11	.8059	.8589	.9496	.9724	.1829		.2477
12	.9431	1.134	.9724	1.1488	.1829	.2452	.2477
13	.8745	.5083	.7969	1.2346	.1829	.2452	.2477
14	.8573	.7619	.6613	1.1145	.1677	.2452	.2477
15	.8573	.7186	.7122	1.0288		.2452	.2477
16	.823	.8505	.8648	.9774	.1829	.2452	.2286
17	.7716	.8682	.8987	.823	.1981	.2452	.2378
18	.463	.443	.6036	.5658	.1981	.2452	.2477
19	.1334	.2454	.2452	.1334	.2134	.2641	.2477
20	.1334	.2858	.2641	.1334	.2134	.2829	.2667
21	.1429	.2667	.2641	.1334	.2134	.2641	.2667
22	.1429	.2667	.2641	.1334	.2134	.2641	.2477
23	.1429	.2667	.2641	.1334	.1981	.2641	.2477
24	.2641	.1334	.2667	.2641	.2572	.3353	.3647
Max	.9431	1.134	.9724	1.2346	1.1831	1.4784	1.5257
Min	.1238	.1334	.0762	.1334	.1677	.2452	.2286
Avg	.4146	.3900	.4381	.4789	.3694	.4915	.4341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 206 / 11 KV TAKALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2572	.1715	.2075	.2058	.1829	.2641
2	.2829	.2572	.1905	.2452	.2401	.1677	.3018
3	.3018		.2096	.2641	.3086	.2286	.3018
4	.3584	.2915	.3048	.3961	.463	.3353	.3395
5	.5093	.3944	.4001	.5281	.5144	.5335	.5093
6	.7545	.5144	.5906	.7167	.6001	.5792	.5658
7	.7545	.583	.724		.6859	.6097	.8676
8	.679	.5487	.6979	.7167	.4877	.5792	.7167
9	.6036		.547	.6413	.3963	.4572	.4904
10	.3429	.381	.3206	.415	.2286	.3206	.3048
11	.2401	.2667	.2452	.3395	.1677	.2829	.1715
12	.2058	.1905	.2075	.2572	.1524	.2263	.1715
13	.1886	.1524	.1698	.2058	.1524	.1886	.1334
14	.1715	.1143	.1698	.2058	.1677	.132	.0762
15	.1886	.1143	.1509	.2229	.1677	.132	.2096
16	.2229	.1524		.2229	.1829	.132	.1905
17	.2572	.2096	.2829	.2572	.2134	.2829	.2667
18	.4115	.362	.415	.3772	.2743	.3395	.381
19	.5487	.6097	.6036	.5658	.5335	.547	.6097
20	.463	.5525	.5658	.463	.4268	.6036	.5716
21	.1905	.4191	.3206	.3429	.3353	.4338	.4572
22	.3086	.2858	.2829	.2572	.2286	.2829	.3048
23	.2572	.1905	.2452	.2229	.2134	.2452	.2477
24	.2263	.2229	.1715	.2075	.2058	.1981	.2263
Max	.7545	.6097	.724	.7167	.6859	.6097	.8676
Min	.1715	.1143	.1509	.2058	.1524	.132	.0762
Avg	.3622	.3214	.3473	.3599	.3147	.3342	.3616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 207 / 11 KV Viramgaon AG.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2401	.1772	.1966	.1619	.2743	.3206
2	.1886	.2401	.2126	.1966	.1429	.2591	.3206
3	.2572	.2572	.2303	.1989	.1429	.2591	.3395
4	.2915	.2915	.3189	.2984	.1429	.2896	.3584
5	.39	.3944	.443	.3647	.1619	.2896	.3584
6	.5935	.6687	.5959	.5636	.1619	.2743	.3961
7	1.0227	.4858	1.0808	1.073	.1524	.2743	.3018
8	.8478	.9602	1.0513	.8987	.2286	.1981	.2452
9	.6173		.6443	.6344	.1219	.1524	.1509
10	.0476	.1524	.0943	.1698	.0762	.0754	.1143
11	.0381	.0762	.0754	.1132	.8078	.6796	.7442
12	.0476	.0381	.0566	.0572	.7621	.5636	.5959
13	.0286	.0572	.0566	.0572	.6401	.503	.443
14	.0286	.0381	.0566	.0476	.5792	.3521	.3856
15	.0286	.0572	.0566	.0476	.4877	.3688	.333
16	.0286	.0762	.0566	.0381	.3353	.407	.3856
17	.0514	.0762	.0566	.0476	.3658	.4024	.3856
18	.0572	.0953	.0943	.0572	.3201	.3018	.4031
19	.1715	.1715	.1698	.1143	.2134	.1886	.2096
20	.0953	.1905	.2263	.1143	.2134	.2452	.2477
21	.0762	.1524	.1698	.1238	.2134	.2829	.2667
22	.0762	.1334	.132	.1429	.2743	.3206	.3048
23	.0762	.0953	.1132	.1619	.2896	.3395	.3239
24	.1715	.2229	.1715	.2035	.1619	.2896	.3206
Max	1.0227	.9602	1.0808	1.073	.8078	.6796	.7442
Min	.0286	.0381	.0566	.0381	.0762	.0754	.1143
Avg	.2259	.2248	.2642	.2467	.2982	.3163	.3440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 208 / 11KV NAKODA GINNING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0126	.0038	.0122	.0126	.0038	.0305	.0126
2	.0126	.0038	.0122	.0126	.0038	.0305	.0126
3	.0133	.0038	.0122	.0133	.0038	.0305	.0126
4	.0133	.0038	.0122	.0126	.0038	.0305	.0126
5	.0133	.0038	.0122	.0126	.0038	.0305	.0126
6	.0133	.0038	.0122	.0126	.0038	.0305	.0126
7	.0133	.0038	.0122	.0126	.0038	.0305	.0126
8	.0133	.0038	.0126	.0126	.0305	.0305	.0126
9	.0126		.0126	.0133	.0305	.0305	.0377
10	.0038	.0377	.0126	.0133	.0305	.0126	.0122
11	.0038	.0122	.0133	.0126	.0762	.0126	.0366
12	.0038	.0122	.0133	.0038	.0305	.0126	.0122
13	.0038	.0122	.0126	.0038	.0305	.0126	.0122
14	.0038	.0122	.0133	.0038	.0305	.0133	.0122
15	.0038	.0122	.0133	.0038	.0305	.0126	.0122
16	.0038	.0122	.0126	.0038	.0305	.0126	.0122
17	.0038	.0076	.0126	.0038	.0305	.0126	.0122
18	.0038	.0122	.0126	.0038	.0305	.0126	.0122
19	.0038	.0122	.0133	.0038	.0305	.0126	.0122
20	.0038	.0122	.0133	.0038	.0305	.0126	.0122
21	.0038	.0122	.0126	.0038	.0305	.0126	.0122
22	.0038	.0122	.0126	.0038	.0305	.0126	.0122
23	.0038	.0122	.0126	.0038	.0305	.0126	.0122
24	.0126	.0038	.0122	.0126	.0038	.0305	.0126
Max	.0133	.0377	.0133	.0133	.0762	.0305	.0377
Min	.0038	.0038	.0122	.0038	.0038	.0126	.0122
Avg	.0076	.0098	.0126	.0083	.0235	.0201	.0144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 209 / 11KV LODHA STONE CRUSHER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0171	.0189	.0189	.0171	.0152	.0189
2	.0189	.0171	.0189	.0189	.0171	.0152	.0189
3	.0189	.0171	.0189	.0189	.0171	.0152	.0377
4	.0189	.0171	.0189	.0189	.0171	.0152	.0189
5	.0189	.0171	.0189	.0189	.0171	.0152	.0189
6	.0189	.0171	.0189	.0189	.0171	.0152	.0189
7	.0189	.0171	.0183	.0189	.0171	.0152	.0189
8	.0189	.0171	.0189	.0189	.0152	.0152	.0189
9	.0189		.0189	.0189	.0152	.0152	.0189
10	.0171	.0183	.0189	.0189	.0152	.0189	.0189
11	.0171	.0189	.0189	.0063	.0152	.0189	.0189
12	.0171	.0189	.0189	.0171	.0305	.0189	.0189
13	.0171	.0189	.0189	.0171	.0152	.0189	.0189
14	.0171		.0189	.0171	.0152	.0189	.0189
15	.0171	.0189	.0189	.0171	.0152	.0189	.0189
16	.0171	.0189	.0189	.0857	.0152	.0189	.0189
17	.0171	.0189	.0189	.0171	.0152	.0189	.0189
18	.0171	.0189	.0189	.0171	.0152	.0189	.0189
19	.0171	.0189	.0189	.0171	.0152	.0189	.0189
20	.0171	.0189	.0189	.0171	.0152	.0189	.0189
21	.0171	.0183	.0189	.0171	.0152	.0189	.0189
22	.0171	.0189	.0189	.0171	.0152	.0189	.0189
23	.0171	.0183	.0189	.0171	.0152	.0189	.0189
24	.0189	.0171	.0189	.0189	.0171	.0152	.0189
Max	.0189	.0189	.0189	.0857	.0305	.0189	.0377
Min	.0171	.0171	.0183	.0063	.0152	.0152	.0189
Avg	.0179	.0181	.0189	.0203	.0165	.0174	.0197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 210 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2572	.1905	.2641	.2058	.1829	.2641
2	.3395	.3086	.2477	.2829	.2572	.2286	.3206
3	.3961	.3429	.2858	.3206	.3086	.2743	.3772
4	.4338	.3429	.381	.5281	.3601	.381	.4338
5	.5658	.4287	.5525	.5847	.5144	.4877	.5093
6	.811	.583	.8002	.8299	.6344	.5792	.7167
7	.8299	.7716	.8192	.811	.6859	.7011	.7733
8	.7545	.703	.679	.7545	.5335	.5944	.6602
9	.6602		5.4698	.679	.4572	.4877	.5093
10	.3772	.3429	.3018	.5847	.3048	.3584	.3048
11	.2572	.2286	.2829	.4715	.2286	.3018	.3048
12	.2058	.2096	.2075	.3429	.1829	.2641	.2477
13	.1886	.2096	.1886	.3086	.1524	.2452	.1524
14	.1715	.1524	.1886	.2572	.1524	.2075	.1715
15	.1886	.1334	.1698	.2229	.1677	.1886	.1905
16	.2058	.1715	.1886	.2058	.1677	.1886	.2667
17	.2229	.1905		.2229	.2286	.2641	.2858
18	.3772	.3239	.3395	.3429	.3048	.1886	.3429
19	.6859	.3239	.415	.6001	.4877	.5847	.5906
20	.583	.6668	.5658	.5144	.503	.6979	.6478
21	.4287	.5335	.5093	.4287	.4725	.5658	.4954
22	.3429	.362	.415	.3429	.3048	.4527	.0762
23	.3086	.3048	.3018	.2915	.2743	.3206	.3048
24	.2829	.2572	.2477	.2452	.2229	.2591	.2452
Max	.8299	.7716	5.4698	.8299	.6859	.7011	.7733
Min	.1715	.1334	.1698	.2058	.1524	.1829	.0762
Avg	.4133	.3543	.5977	.4349	.3380	.3752	.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 201 / 11 KV GALLE BORGAEON AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.2096	.2286	.2155	.1875	.1718
2	.2286	.1905	.2096	.2286	.2321	.1875	.1739
3	.2286		.2286	.2477	.2486	.1943	.1943
4	.2477		.2477	.2667	.2818	.2429	.2105
5	.2858		.2667	.2858	.3149	.2915	.2267
6	.3429		.3429	.3239	.3812	.3239	.2591
7	.3429		.3048	.362	.5138	.583	.4915
8	.3048		.2858	.3239	.4641	.5506	.5735
9	.2477		.2286	.2858	.3315	.3932	.3163
10	.1715		.2096	.2286	.1143	.1905	.1524
11	.3481		.3681	.4641	.0953	.1524	.1334
12	.3647		.5079	.3647	.1524	.1524	.1524
13	.431	.2984	.4641	.4973	.1524	.1715	.1524
14	.4144	.3812	.426		.1334	.1334	.1905
15	.431	.431			.1905	.1715	.1715
16	.3812	.4144	.4111		.1524	.1905	
17	.3481	.2652	.4858	.431	.1143	.1905	.1143
18	.2652	.362	.3658	.3812	.1905	.2096	.2096
19	.2858	.2286	.1905	.2286	.1905	.2096	.1905
20	.2667	.2858	.2667	.2477	.2477	.2477	.3048
21	.2286	.2286	.2286	.1905	.2286	.1905	.2477
22	.2286	.2667	.2667	.2096	.1905	.2096	.2096
23	.2096	.2477	.2477	.1905	.1715	.1905	.1905
24	.2096	.1905	.2096	.2286	.2155	.2031	.1677
Max	.431	.431	.5079	.4973	.5138	.583	.5735
Min	.1715	.1905	.1905	.1905	.0953	.1334	.1143
Avg	.2934	.2844	.3032	.2960	.2301	.2403	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 202 / 11 KV Akhatwada AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.1326	.1143	.1715	.1715	.1715
2	.0937	.0937	.1326	.1067	.1715	.1715	.1905
3	.1265		.1492	.125	.1715	.2096	.1905
4	.1781		.1658	.1562	.1905	.2286	.2286
5	.1943		.1989	.1898	.2096	.2667	.2477
6	.2267		.2652	.2214	.2477	.3239	.2667
7	.502		.5801	.3725	.2858	.3429	.2667
8	.5079		.6133	.5506	.2286	.2858	.2286
9	.3077		.2818	.3481	.1334	.1905	.1715
10	.1143		.1143	.1715	.1143	.1905	.1524
11	.0572		.0762	.1524	.2486	.2818	.2652
12			.0572	.1143	.3315		.1989
13		.1658	.0762	.0762	.3647	.2486	.1823
14		.1143	.0762	.0953	.3315	.1989	.1658
15		.1334		.0762	.2321	.1989	.1658
16			.0762	.1143	.2155	.1989	.1658
17		.1143	.0953	.1524	.2134	.253	.1989
18	.1524	.1524	.1143	.1143	.1677	.1457	.1658
19	.2286	.2096	.2286	.1905	.1905	.1524	.1715
20	.1905	.2286	.2286	.2096	.1905	.1715	.2096
21	.1524	.1905	.1715	.1715	.1715	.1715	.1905
22	.1524	.1524	.1715	.1715	.1715	.1524	.1715
23	.1334	.1334	.1524	.1524	.1715	.1715	.1715
24	.0914	.0914	.1326	.1143	.1715	.1715	.1715
Max	.5079	.2286	.6133	.5506	.3647	.3429	.2667
Min	.0572	.0914	.0572	.0762	.1143	.1457	.1524
Avg	.1945	.1439	.1865	.1776	.2124	.2130	.1962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 203 / 11 KV Tisgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1629	.1715	.181	.1715	.1991	.2012
2	.1848	.1646	.1715	.2012	.1886	.1991	.2012
3	.2033		.1715	.2195	.1886	.1991	.2012
4	.2534		.2058	.2743	.2058	.2715	.2743
5	.3801		.3086	.3841	.2401	.3841	.3801
6	.4344		.3772	.4706	.3772	.439	.4344
7	.4163		.4287	.5138	.463	.4572	.4706
8	.4163		.3429	.4163	.4115	.3801	.4075
9	.3439		.2915	.3086	.3258	.3366	.3366
10	.2401		.1715	.2572	.1715	.1886	.2058
11	.2058			.1543	.1372	.1372	.1543
12	.1715		.1029	.1715	.12		.1372
13	.1543	.1715	.1524	.1715	.1372	.12	.12
14	.1372	.1372	.1524	.1715	.1372	.1029	.12
15	.1372	.1372		.1029	.12	.12	.1029
16	.1372	.1715	.1886	.1886	.12	.12	.1017
17	.2229	.1886	.2572	.2347	.2058	.1372	.116
18	.2743	.2572	.3258	.3772	.3258	.2347	.218
19	.3772	.463	.4706	.3772		.3801	.4572
20	.3077	.3772	.3801	.2572	.1629	.3439	.3601
21	.2534	.2743	.2561	.2572	.2987	.2772	.2743
22	.2195	.2229	.2195	.2058	.2987	.2402	.2229
23	.181	.1886	.2012	.1715	.2241	.2054	.1886
24	.1867	.1629	.1715	.181	.1715	.2172	.2033
Max	.4344	.463	.4706	.5138	.463	.4572	.4706
Min	.1372	.1372	.1029	.1029	.12	.1029	.1017
Avg	.2511	.2200	.2509	.2604	.2262	.2474	.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 204 / 11 KV Galleborgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1524	.1715	.1524	.1524	.1524
2	.1905	.1524	.1524	.1524	.1524	.1524	.1524
3	.1905		.1715	.1524	.1524	.1524	.1524
4	.2096		.1905	.1715	.1715	.1905	.1905
5	.2286		.2286	.2096	.1905	.2477	.2477
6	.2667		.2667	.2667	.2667	.2858	.3048
7	.3048		.3239	.3429	.3048	.3048	.3048
8	.2858		.2667	.2477	.2858	.2477	.2477
9	.2096		.2286	.2286	.1905	.1715	.1715
10	.1905		.1334	.2477	.1524	.1524	.1524
11	.1905		.1524	.1905	.2096	.1524	.1524
12	.1905		.1715	.1905	.1334	.1143	.1334
13	.1905	.2096	.1524	.1524	.1334	.1334	.1334
14	.1905	.2286	.1524	.1524	.1524	.1334	.1334
15	.1715	.2096		.1334	.1334	.1524	.1524
16	.1524	.1905	.1524	.1524	.1524	.1715	.1334
17		.1905	.1905	.1524	.1334	.1905	.1715
18	.1905	.1905	.2096	.1524	.1715	.1715	.1905
19	.3239	.2477	.2667	.2477	.3048	.2477	.2477
20	.2667	.2286	.2858	.2477	.2286	.2477	.2667
21	.1905	.2096	.2286	.2286	.2096	.2286	.2477
22	.1715	.2096	.1905	.1905	.1905	.1905	.2286
23	.1524	.1715	.1715	.1715	.1905	.1715	.1715
24	.1715	.1524	.1524	.1715	.1524	.1715	.1524
Max	.3239	.2477	.3239	.3429	.3048	.3048	.3048
Min	.1524	.1524	.1334	.1334	.1334	.1143	.1334
Avg	.2096	.1960	.1996	.1969	.1881	.1889	.1913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 205 / 11 KV Palasgaon AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1423	.1265	.1326	.1265	.1524	.1524	.1334
2	.1423	.1265	.1326	.1423	.1524	.1524	.1334
3	.16		.2155	.1581	.1524	.1524	.1524
4	.1943		.2984	.2429	.1524	.1524	.1524
5	.2429		.3315	.3239	.1524	.1524	.1524
6	.3239		.4144	.3887	.1334	.1715	.1524
7	.9231		1.0442	.8583	.1143	.1143	.1334
8	.9389		.9448	.8745	.0762	.0953	.0762
9	.502		.5304	.5636	.0572	.0572	.0572
10	.0381		.0381	.0572	.0572	.0381	.0381
11	.0191		.0381	.0572	.5344	.3978	.5304
12	.0191		.0381	.0572	.6882		.4144
13	.0191	.3812	.0381	.0572	.4801	.4641	.3315
14	.0191	.0381	.0381	.0572	.5182	.3725	.2818
15	.0191	.0572		.0381	.426	.3321	.3315
16	.0191	.0381	.0953	.0191	.421	.3163	.3725
17	.0572	.0191	.0953	.0191	.3725	.3725	.3978
18	.0381	.0191	.0953	.0572	.2915	.2105	.2984
19	.0953	.0572	.1524	.1143	.0762	.1143	.0953
20	.1143	.0953	.1715	.1143	.1143	.1334	.1143
21	.1143	.0953		.1334	.1334	.1524	.1143
22	.0953	.0762	.1524	.1334	.1524	.1524	.1334
23	.0953	.0762	.1524	.1524	.1524	.1334	.1334
24	.1581	.125	.116	.1265	.1524	.1524	.1334
Max	.9389	.3812	1.0442	.8745	.6882	.4641	.5304
Min	.0191	.0191	.0381	.0191	.0572	.0381	.0381
Avg	.1871	.0951	.2393	.2030	.2381	.1975	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 206 / 11 KV Pimpri AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.2753	.3481	.2846	.1524	.1715	.2096
2	.2753	.2753	.3481	.3077	.1524	.1715	.2096
3	.2949		.3812	.3401	.1524	.1715	.2096
4	.3605		.4144	.4049	.1715	.1905	.2286
5	.4915		.4973	.5668	.2096	.2096	.2286
6	.6203		.6796	.7045	.2667	.2477	.2477
7	1.3077		1.2266	1.2574	.2286	.3048	.2858
8	1.1065		1.1603	1.1233	.1905	.1524	.1905
9	.7625		.8288	.7459	.0953	.1143	.1143
10	.0572		.1715	.1334	.0762	.0953	.0762
11	.0381		.0953	.0762	.8192	.8453	.7127
12	.0572		.0762	.0762	.9054		.6796
13	.0381	.5967	.0572	.0572	.9145	.7209	.6133
14	.0381	.0953	.0572	.0572	.6554	.6554	.547
15	.0381	.1143		.0572	.6802	.5801	.4973
16	.0381	.0762	.0762	.0762	.6226	.547	.3725
17	.0572	.0572	.0572	.0953	.6554	.4694	.4475
18	.0762	.0572	.0762	.1143	.3978	.3353	.3978
19	.1905	.1905	.1524	.1905	.1524	.1334	.1334
20	.1905	.1905	.1905	.1715	.2286	.2477	.2477
21	.1143	.1905	.1524	.1715	.2096	.2096	.2096
22	.1143	.1524	.1143	.1524	.2096	.2096	.1905
23	.1143	.1524	.0953	.1524	.1905	.2096	.1524
24	.2591	.2753	.3481	.2688	.1524	.1905	.2096
Max	1.3077	.5967	1.2266	1.2574	.9145	.8453	.7127
Min	.0381	.0572	.0572	.0572	.0762	.0953	.0762
Avg	.2872	.1928	.3306	.3161	.3537	.3123	.3088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV KANADGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1337	.1867	.1867	.153	.2829	.2801	.0429
2	.1337	.1867	.1867	.153	.2829	.2801	.1943
3	.1486	.2241	.1867	.153	.3395	.3361	.1915
4	.1669	.2801	.2241	.1623	.3772	.3921	.2195
5	.1943	.3361	.2801	.2073	.4715	.5601	.2515
6	.2515	.3361	.3921	.2561	.6602	.8402	.2972
7	.2195	.3734	.3921	.2599	.7545	.9522	.5014
8	.1943	.3174	.3361	.2317	.6908	.9522	.426
9	.2054	.2987	.3361	.2073	.3547	.3544	
10	.168	.2241	.1337	.3206	.168	.1189	.0566
11	.3856	.3921	.317	.5658	.112	.1006	.0377
12	.5935	.4481	.3292	.5281	.056	.1006	.0377
13	.6104	.4481	.2808	.4715	.056	.1006	.0377
14		.3921	.3307	.4715	.112	.1006	.0366
15	.3887	.4481	.3426	.4715	.112	.1006	.0366
16	.4641	.4481	.3307	.4715	.112	.1006	.0377
17	.4001	.5041	.3898	.6602	.112	.1006	.0377
18	.3561	.4481	.2936	.4904	.168		.0366
19	.2801	.2801	.1758	.2641	.3361		.132
20	.2801	.2801	.1943	.2263	.2801		.132
21	.2241	.2241	.1448	.1886	.2241	.1337	.1132
22	.2054	.2241	.1488	.1886	.2241	.1337	.0943
23	.1867	.1867	.1488	.1886	.2054	.1593	.0838
24	.1337	.1867	.1867	.153	.2829	.2801	.1943
Max	.6104	.5041	.3921	.6602	.7545	.9522	.5014
Min	.1337	.1867	.1337	.153	.056	.1006	.0366
Avg	.2750	.3198	.2612	.3102	.2823	.3084	.1404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 201 / GINNING AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2772	.2743	.2743	.2458	.2286	.2686
2	.2772	.2772	.2772	.2743	.3201	.2286	.2515
3	.2801	.3734	.2772	.2772	.3201	.2286	.2515
4	.3772	.3696	.3734	.2772	.3429	.3048	.3201
5	.4715	.462	.3734	.3696	.4382	.381	.4191
6	.5658	.5601	.5658	.5601	.5487	.4687	.4801
7	.5658	.5601	.5658	.5601	.7802	.6249	.6859
8	.5658	.5601	.4668	.4715	.6001	.5468	.6706
9	.4287	.3429	.3429	.4668	.4287	.4287	.5144
10	.2572	.2572	.2572	.3734	.1715	.1715	.2572
11	.3429		.3429	.381	.1715	.1715	.1715
12	.2572	.2572	.2572	.3048	.1715	.2572	.1715
13	.3429	.3429	.3429	.3048	.1715	.2572	.1715
14	.2572	.2572	.2572		.1715	.0857	.1715
15	.2572	.0857	.1715	.0857	.1791	.2572	.1715
16	.2515	.0914	.2515	.1715	.181	.1829	.1734
17	.2201	.1315	.2286	.1334	.2772	.2715	.1677
18	.2201	.301	.2401	.2143	.1848	.2801	.2601
19	.4668	.462	.3734	.1867	.3734	.3734	.4572
20	.3734	.4668	.3734	.3734	.3734	.3734	.462
21	.3658	.2772	.3696	.3696	.3734	.3734	.362
22	.2772	.2772	.2743	.2686	.3734	.2743	.2686
23	.2772	.2743	.2772	.2772	.2772	.2686	.2658
24	.2772	.2772	.2772	.2743	.2486	.2286	.2686
Max	.5658	.5601	.5658	.5601	.7802	.6249	.6859
Min	.2201	.0857	.1715	.0857	.1715	.0857	.1677
Avg	.3439	.3279	.3255	.3152	.3218	.3028	.3192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 202 / 11 KVV- PAL-AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3582	.2572	.3353	.2801		.2801
2	.3467	.3582	.2543	.3353	.2801		.2801
3	.3467	.3582	.3353	.3201	.3734		.3734
4	.3506	.3353	.3429	.3353	.3772		.3734
5	.443	.4001	.4334	.4001	.4715		.4668
6	.6401	.4801	.543	.503	.5658		.5658
7	.7973	.8059	.8764	.7545	.5658		.5658
8	.7716	.7621	.9431	.7116	.5658		.5658
9	.6001	.6001	.5144	.4687	.3429		.4287
10	.2572	.2572	.3429	.3734	.3429		.2572
11	.1715	.1715	.2572	.3734	.6001		.5144
12	.1715	.1715	.2572	.2772	.4287	.2572	.3429
13	.1715	.1715	.1715	.2772	.4287	.2572	.3429
14	.1715	.1715	.1715		.3429	.3429	.3429
15	.1715	.1715	.1715	.2772	.3048	.3429	.3429
16	.1829	.0914	.1829	.2715	.3048	.3201	.4049
17	.1867	.1753	.2772	.3696	.3048	.4001	.4001
18	.2801	.2686	.2829	.362	.3048	.2401	.3048
19	.4715	.4715	.4715	.4668	.3734	.3772	.3658
20	.3772	.4715	.3772	.3734	.3734	.3772	.3734
21	.3772	.3734	.3772	.3734	.3734	.3772	.3734
22	.2829	.3696	.3772	.3734		.3734	.2743
23	.2686	.3734	.2515	.3734		.3734	.2801
24	.3467	.2686	.2543	.2515	.3734		.3734
Max	.7973	.8059	.9431	.7545	.6001	.4001	.5658
Min	.1715	.0914	.1715	.2515	.2801	.2401	.2572
Avg	.3555	.3515	.3635	.3894	.3945	.3366	.3831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 203 / 11KV PHULAMBRI GAONTHAN SHEDDABLE URBAN
FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5373	.4572	.5373	.543	.5373	.5373
2	.5487	.5373	.4572	.5373	.543	.543	.5373
3	.5487	.5373	.4572	.5373	.543	.543	.5373
4	.5487	.5373	.4572	.5487	.5487	.6335	.5258
5	.6468	.6268	.5544	.6401	.6468	.7392	.6268
6	.8402	.8059	.7545	.7316	.8402	.8316	.8402
7	1.0374	1.0374	1.0374	1.0374	1.0374	1.0374	1.0374
8	1.0269	1.0269	.9431	.9335	.924	.9431	1.0269
9	.7716	.7716	.7716	.9335	.7716	.7716	.8573
10	.7716	.7716	.7716	.8316	.7716	.8573	.7716
11	.6859	.6859	.6001	.823	.7716	.7716	.6859
12	.6859	.6001	.6001	.7316	.6859	.6859	.6001
13	.6001	.6001	.6001	.7316	.6859	.6859	.6001
14	.6001	.5144	.6001		.6859	.6859	.6001
15	.6001	.5144	.6001	.7316	.724	.6859	.6001
16		.6268	.6268	.6268	.724	.7164	.7164
17	.7164	.6135	.7164	.7011	.823	.7164	.7087
18	.8059	.7087	.8059	.7011	.823	.8059	.7011
19	.8059	.724	.9145	.8954	.9431	1.0269	.8954
20	.8316	.7392	.823	.9145	.9335	.924	.9145
21	.823	.6401	.7164	.823	.8316	.823	.823
22	.7316	.6268	.7164	.7316	.823	.7164	.7316
23	.6268	.5487	.6268	.6335	.823	.6268	.6335
24	.5487	.5373	.4572	.5373	.6335	.6401	.5373
Max	1.0374	1.0374	1.0374	1.0374	1.0374	1.0374	1.0374
Min	.5487	.5144	.4572	.5373	.543	.5373	.5258
Avg	.7109	.6612	.6694	.7326	.7533	.7478	.7102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 205 / 11 KV DEOGIRI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1867	.1791	.181	.2115		.2972
2	.1829	.1715	.181	.181	.2058		.2972
3	.1829	.1753	.1848	.181	.2058		.2858
4	.2801	.181	.1867	.2801	.2286		.2972
5	.2829	.2801	.2801	.2801	.3201		.3572
6	.3772	.2715	.3772	.3772	.5144		.4458
7	.3772	.3772	.3772	.2801	.6783		.6687
8	.3772	.2801	.3772	.2801	.5801		.5944
9	.2572	.1715	.2572	.2801	.4287		.6001
10	.1715	.1715	.1715	.1848	.1715		.1715
11	.5144	.5144	.6001	.3906	.0857		.0857
12	.5144	.5144	.4287	.4744		.5144	.0857
13	.4287	.4287	.4287	.3906		.3429	.0857
14	.4287	.3429	.3429		.0857		.0857
15	.4287	.3429	.3429	.3858	.0857	.1715	.1715
16	.2972	.3048	.3048	.381	.0857	.181	.1772
17	.2858	.2743	.3048	.3572	.0857	.0905	.1772
18	.2934	.2896	.282	.2591	.0876	.181	.1772
19	.181	.1867	.2801	.1829	.2801	.2801	.2772
20	.1867	.2801	.2801	.1848	.2801	.2801	.2801
21	.1867	.1829	.181	.181	.1848	.1848	.2686
22	.1867	.181	.181	.181	.181	.1867	.1829
23	.181	.181	.181	.181		.2229	.181
24	.1829	.181	.181	.181	.2143		.2229
Max	.5144	.5144	.6001	.4744	.6783	.5144	.6687
Min	.1715	.1715	.1715	.181	.0857	.0905	.0857
Avg	.2903	.2696	.2871	.2711	.2477	.2396	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 206 / 11KV BILDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2858	.2953	.3239	.1772	.2143	.1334
2	.3239	.2972	.2953	.3382	.16	.2143	.141
3	.3239	.2972	.3601	.3382	.1772		.1524
4	.4058	.2667	.4601	.3429	.2	.2972	.2
5	.4801	.4458	.5335	.4001	.2705	.5258	.2972
6	.643	.5201	.6173	.4734	.3763	.4344	.4458
7	1.1288	.9659	1.0536	1.0822	.4572	.4344	.4572
8	.9783	1.0669	1.0536	1.1717	.362	.362	.381
9	.6859	.7716	.6001	.703	.3429	.3429	.3429
10	.2572	.3429	.1715	.2972	.5144	.2572	.4287
11	.1715	.1715	.1715	.2172	1.2003	.7716	.7716
12	.1715	.1715	.1715	.2143	.7716	.8573	.6001
13	.1715	.1715	.1715	.2143	.6859	.5144	.5144
14	.1715	.1715	.1715		.6001	.4287	.4287
15	.1715	.1715	.1715	.141	.381	.4287	.4287
16	.1486	.1296	.1524	.1124	.4572	.3334	.4601
17	.2286	.1105	.0953	.1029	.5335	.4287	.5563
18	.2286	.1276	.1143	.1715	.381	.2667	.3429
19	.2782	.2515	.282	.1829	.2972	.2782	.2782
20	.2629	.3334	.2743	.1829	.2972	.282	.2743
21	.2286	.18	.1943	.1772	.2143	.2086	.1886
22	.2	.2	.1943	.1772	.2143	.2	.18
23	.2972	.1772	.2286	.1743	.2115	.12	
24	.3048	.2858	.2858	.2953	.18	.2086	.1391
Max	1.1288	1.0669	1.0536	1.1717	1.2003	.8573	.7716
Min	.1486	.1105	.0953	.1029	.16	.12	.1334
Avg	.3577	.3297	.3383	.3406	.3943	.3656	.3540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 207 / 11KV DARI-GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.2715	.2686	.2715	.362	.1715	.2715
2	.362	.2715	.2686	.2715	.362	.1715	.2629
3	.3658		.2686	.2772	.362	.1715	.3506
4	.4572		.3696	.3696	.4572	.1715	.462
5	.5601		.4668	.5544	.5658	.2686	.6468
6	.8488	.543	.8488	.8402	.8488	.462	.9335
7	.9431	1.0269	.9431	.9431	.9431	.4715	.9335
8	.8402	.8402	.8488	.8402	.8488	.3696	.8402
9	.6859	.6001	.6859	.7392	.6001	.3429	.6001
10	.4287	.5144	.4287	.6401	.4287	.3429	.3429
11	.2572	.3429	.1715	.4525	.3429	.1715	.2572
12	.2572	.2572	.1715	.3582	.2572	.1715	.2572
13	.1715	.2572	.1715	.3544	.2572	.2572	.2572
14	.1715	.1715	.1715		.3429	.3429	.2572
15	.2572	.1715	.1715	.2629	.2601	.4287	.2572
16	.2715	.2572	.181	.3429	.2572	.2715	.2601
17	.362	.2486	.2715	.3315	.2572	.362	.2543
18	.462	.4287	.543	.4239	.3544	.4525	.3429
19	.7468	.7392	.7468	.6268	.6468	.7468	.6468
20	.6468	.7468	.6468	.5544	.6535	.7392	.6535
21	.543	.4572	.4525	.4525	.4525	.462	.4572
22	.362	.362	.362	.362		.362	.3582
23	.2715	.2686	.362	.362		.362	.3506
24	.3582	.2715	.2686	.2715	.362	.1715	.2715
Max	.9431	1.0269	.9431	.9431	.9431	.7468	.9335
Min	.1715	.1715	.1715	.2629	.2572	.1715	.2543
Avg	.4579	.4308	.4204	.4740	.4647	.3435	.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 208 / 11 KV WAREGAON- AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.1715	.0876	.0857	.1886	.1524	.0876
2	.0876	.1753	.0876	.0876	.1867	.1524	.0857
3	.1734	.1715	.0876	.1753	.1867	.1524	.0857
4	.1753	.1715	.1772	.1753	.1867	.1524	.1715
5	.2601	.2629	.1772	.1753	.2743	.2286	.2629
6	.3467	.3467	.2658	.2601	.3658	.3086	.3582
7	.3467	.4382	.3429	.3467	.5658	.4687	.5258
8	.1734	.3506	.3506	.2801	.4715	.4687	.5144
9	.2572	.2572	.2572	.2801	.2572	.3429	.3429
10		.1715	.1715	.1829	.1715	.2572	.0857
11	.2572	.2572	.1715	.2286	.1715	.0857	.0857
12	.2572	.2572	.1715	.2286	.0857	.1715	.0857
13	.2572	.1715	.1715	.1524	.0857	.0857	.0857
14	.1715	.1715	.0857		.0857	.0857	.0857
15	.1715	.2572	.0857	.1524	.0857	.0857	.0857
16	.2115	.1753	.1715	.1753	.0857	.0857	.0895
17	.2515	.2258	.1715	.0876	.0857	.0857	.0905
18	.2829	.1772	.1715	.1867	.0857	.1772	.0924
19	.1734	.181	.1734	.2629	.2801	.2629	.2686
20	.1715	.2629	.2601	.2601	.2801	.2629	.2601
21	.1715	.1772	.1715	.1734	.1848	.1753	.1753
22	.1715	.0886	.1715	.1753	.1848	.0876	.1753
23	.0857	.0886	.0886	.1753	.181	.0876	.0876
24	.0876	.0857	.0876	.0857	.1886	.181	.0876
Max	.3467	.4382	.3506	.3467	.5658	.4687	.5258
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2013	.2122	.1733	.1910	.2052	.1919	.1782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 209 / 11 KV GADEKAR INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1791	.1829	.1886	.0905	.0857	.0762
2	.1829	.1791	.1791	.1867	.1886	.0857	.0514
3	.1867	.1867	.1829	.1867	.1886	.0857	.0514
4	.1867	.1867	.1867	.1867	.1867	.0857	.0762
5	.1886	.1886	.1886	.1886	.1886	.0857	.0762
6	.1886	.1886	.1886	.1886	.1753	.0857	.0514
7	.1886	.1867	.1886	.1886	.1791	.0857	.061
8	.1886	.0934	.1886	.1867	.1886	.0857	.0762
9	.1715	.1715	.1715	.1886	.1715	.1715	.0857
10	.1715	.1715	.1715	.2829	.2572	.1715	.2572
11	.1715	.1715	.2572	.2829	.2572	.1715	.3429
12	.1715	.1715	.1715	.2829	.2572	.1715	.2572
13	.1715	.1715	.1715	.1848	.1715	.1715	.1715
14	.1715	.1715	.1715		.1715	.1715	.1715
15	.1715	.1715	.1715	.2801	.1867	.1715	.1715
16	.1886	.2686	.1886	.2829	.2829	.1886	.2772
17	.1886	.1867	.1886	.1886	.2829	.1867	.1886
18	.1886	.1848	.1886	.0867	.1867	.0629	.1886
19	.1886	.0876	.0553	.0781	.1848	.0381	.0857
20	.1886	.1829	.0934	.1886	.1848	.0762	.0934
21	.1886	.2486	.0943	.1867	.1848	.0572	.1886
22	.1886	.2772	.1886	.1848	.1829	.0686	.0943
23	.1791	.1829	.1886	.1867	.0857	.0705	.0876
24	.1886	.1886	.1829	.1867	.1886	.0857	.0457
Max	.1886	.2772	.2572	.2829	.2829	.1886	.3429
Min	.0934	.0876	.0553	.0781	.0857	.0381	.0457
Avg	.1789	.1832	.1725	.1988	.1926	.1134	.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 202 / 11 KV BORGAON ARJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.503	.4191	.2515	.1886	.0943	.2829
2	.2515	.503	.4191	.2515	.1886	.0943	.2829
3	.2515	.503	.4191	.2515	.2829	.0943	.3772
4	.3353	.6706	.4191	.3353	.2829	.0943	.3772
5	.4191	.6706	.503	.5868	.3772	.1886	.3772
6	.7545	.8383	.503	.6706	.3772		.3772
7	.8383	.8383	.5868	.6706	.3772		.4715
8	.8383	.8383	.6706	.6706	.3772		.3772
9	.503	.6706	.6706	.5868	.3772		.2829
10	.1886	.1886	.1886	.1886	.1886		.1886
11	.1886	.1886	.1886	.1886	.503		.503
12	.1886	.1886	.132	.1886	.3353		.4191
13	.1886	.1886	.0943	.1886	.3353		.4191
14	.132	.1886	.0943	.1886	.2515	.4191	.2515
15	.132	.1886	.0943	.0943	.2515	.4191	.2515
16	.132	.1886	.0943	.1886	.2515	.503	.3353
17	.1886	.1886	.132	.1886	.3353		.2515
18	.2452	.2829	.1698	.2829	.4191	.2829	.3353
19	.3206	.3772	.3584	.2829	.2829		.3206
20	.3772	.3772	.3206	.3772	.1886	.3772	.3206
21	.3206	.3772	.2829	.3772	.1886	.3772	.2829
22	.3206	.3772	.3584	.2829		.2829	.2641
23	.2452	.2829	.2515	.2829	.1886	.1886	.1886
24	.2515	.503	.4191	.2515	.1886	.0943	.2829
Max	.8383	.8383	.6706	.6706	.503	.503	.503
Min	.132	.1886	.0943	.0943	.1886	.0943	.1886
Avg	.3276	.4218	.3246	.3261	.2929	.2507	.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 203 / 11 KV ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1886	.2829	.1509	.503	.2515	.2515
2	.1698	.1886	.2829	.132	.503	.2515	.3353
3	.1509	.2452	.2829	.132	.503	.2515	.503
4	.2263	.3206	.2829	.2452	.6706	.2515	.6706
5	.3584	.3772	.3772	.3772	.6706	.2515	.7545
6	.3584	.3772	.3772	.3772	.8383		.8383
7	.3772	.3772	.3772	.3395	.8383		.7545
8	.3584	.3772	.2829	.3395	.8383		.7545
9	.2829	.3206	.1886	.3206	.6706		.503
10	.1886	.2452	.1886	.2452	.1886		.1886
11	.5658	.503	.503	.3353	.1886		.1886
12	.503	.503	.503	.503	.1698		.132
13	.503	.503	.4191	.503	.1698		.132
14	.4191		.4191	.4191	.1698		
15	.4191		.3353	.4191	.1698		.132
16	.4191	.503	.3353	.503	.1509		
17	.503	.503	.4191	.503	.1886		.132
18	.503	.503	.4191	.503	.1886	.1886	.2641
19	.1886	.3772	.3206	.3206	.1886	.2829	.2829
20	.3206	.3772	.2829	.3772	.3772	.3772	.3206
21	.3206	.3772	.2641	.3772	.2829	.3772	.3206
22	.2452	.3772	.132	.3206		.2829	.2263
23	.2452	.2829	.1886	.1886	.0943	.0943	.2263
24	.1886	.1886	.2829	.1509	.503	.2012	.2515
Max	.5658	.503	.503	.503	.8383	.3772	.8383
Min	.132	.1886	.132	.132	.0943	.0943	.132
Avg	.3311	.3644	.3228	.3368	.3942	.2552	.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 204 / 11 KV PEDGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3353		.3353	.1886	.0943	.1886
2	.3353	.3353		.3353	.1886	.0943	.1886
3	.3353			.3353	.2452	.0943	.2829
4	.3353			.3353	.2452	.0943	.2829
5	.4191			.4191	.3206	.0943	.2829
6	.503	.4191		.503	.3772		.3772
7	.5868	.6706	.503	.503	.3772		.3772
8	.503	.6706	.503	.503	.3772		.2829
9	.4191	.6706	.6706	.503	.3206		.2829
10	.1509	.1886	.1886	.1886	.1886		.1886
11	.1886	.1886	.1886	.1886	.503		.503
12	.1886	.1886	.132	.1886	.4191		.4191
13	.1509	.1886	.0943	.1886	.4191		.4191
14	.132	.1886	.0943	.1509	.4191	.4191	.3353
15	.132		.0943	.132	.4191	.4191	.3353
16	.132	.1886	.0943	.1886	.3353	.503	.3353
17	.1886	.1886	.132	.1886	.4191	.503	.3353
18	.1886	.2829	.1698	.2452	.4191	.503	.503
19	.2452	.3772	.2829	.3206	.2829	.3772	.2829
20	.3206	.3772	.1886	.3772	.1886	.3772	.2641
21	.3206	.3772	.2641	.3772	.1886	.3772	.3206
22	.3206	.3772	.1698	.3206		.2829	.3206
23	.2452	.2829	.503	.2452	.1509	.1886	.1886
24	.3353	.3353		.503	.1886	.0943	.1886
Max	.5868	.6706	.6706	.503	.503	.503	.503
Min	.132	.1886	.0943	.132	.1509	.0943	.1886
Avg	.2922	.3416	.2514	.3157	.3122	.2823	.3119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 206 / 11 KV LOANEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.2829	.0943	.3353	.1677	.2515
2	.0943	.132	.2829	.0943	.3353	.1677	.2515
3	.0943	.1886	.2829	.0943	.3353	.1677	.2515
4	.1886	.1886	.2829	.1886	.503	.1677	.3353
5	.3206	.2452	.3772	.3395	.503	.1677	.4191
6	.3395	.2452	.3772	.3395	.6706		.503
7	.3395	.3206	.3772	.3395	.6706		.7545
8	.2829	.3206	.2829	.3206	.6706		.6706
9	.2452	.2452	.1886	.2452	.503		.5868
10	.1509	.1886	.1886	.1886	.1886		.1886
11	.503	.3353	.503	.3353	.132		.1886
12	.503	.503	.4191	.4191	.0943		.132
13	.3353	.503	.3353	.503	.0943		
14	.3353	.503	.3353	.503	.0943	.1886	
15	.3353	.503	.2515	.4191	.0943	.1886	.0943
16	.4191	.4191	.2515	.503	.0943	.1886	.0943
17	.4191	.4191	.3353	.503	.0943	.1886	.0943
18	.4191	.4191	.4191	.503	.0943	.1886	.1698
19	.1886	.3772	.2829	.2452	.2829	.2829	.2641
20	.2452	.3772	.2641	.3206	.2829	.3772	.2829
21		.3772	.2263	.3206	.2829	.3772	.2641
22		.3772	.132	.2452		.2829	.1886
23		.2829	.1698	.2452	.0377	.0943	.1886
24	.132	.132	.2829	.2829	.3353	.1677	.1677
Max	.503	.503	.503	.503	.6706	.3772	.7545
Min	.0943	.132	.132	.0943	.0377	.0943	.0943
Avg	.2850	.3223	.2971	.3164	.2926	.2102	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 201 / 11 kv Bodhegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2058	.2058	.2229	.5716	.5144	.5144
2	.2286	.2058	.2229	.2229	.6097	.5487	.5487
3	.2858	.2572	.2743	.2572	.6668	.6001	.6001
4	.3361	.3086	.3258	.3429	.7095	.6516	.6344
5	.3395	.3086	.3772	.4287	.7621	.6859	.6687
6	.4287	.4287	.4973	.6001	1.0082	.9259	.9431
7	.8402	.583	.6516	.7373	1.086	.9602	.9774
8	.9259		.6859	.8402	.8573	.8059	.7716
9	.6161	.2058	.4458	.4458	.724	.583	.5658
10	.381	.703	.3601	.5316	.4115	.3429	.3429
11	.2477	.1715	.4287	.4763	.5144	.3772	.4191
12	.3048	.2058	.3429	.4572	.5316	.3944	.4191
13	.2829	.2058	.3086	.381	.5144	.3944	.3048
14	.2614	.2229	.2743	.3429	.4801	.3944	.3429
15	.2286	.1886	.2572	.3429	.4801	.4115	.3239
16	.2401	.2229	.2401	.362	.4801	.4115	.4572
17		.2572	.2743	.362	.4458	.4115	.4108
18	.4458	.3258	.3258	.4001	.2401	.2743	.415
19	.6344	.4458	.4973	.7655	.703	.7202	.6668
20	.7202	.5658	.7202	.7621	.6859	.6859	.7545
21	.6173	.6001	.6516	.6722	.6173	.6173	.7095
22	.5144	.4287	.4973	.5487	.5487	.5487	.5611
23	.4801	.2058	.463	.5906	.5316	.5144	.5525
24	.1905	.1715	.1715	.2058	.5716	.5144	.4801
Max	.9259	.703	.7202	.8402	1.086	.9602	.9774
Min	.1905	.1715	.1715	.2058	.2401	.2743	.3048
Avg	.4252	.3228	.3958	.4708	.6146	.5537	.5577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 202 / 11 KV Babra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.2058	.2229	.6097	.5487	.5144
2	.2286	.2058	.2058	.2572	.6668	.6001	.5487
3	.2667	.2401	.2572	.3258	.724	.6516	.6173
4	.2987	.2743	.3772	.4973	.7842	.7202	.7202
5	.3086	.3086	.4458	.6687	.7964	.7545	.7716
6	.3982	.3772	.6687	.7888	.9259	.9259	.823
7	.5601	.5487	.6859	.9431	1.166	.8573	.9259
8	.6535	.3429	.5144	.583	.5144	.6859	.7202
9	.6535	.1715	.4458	.4115	.9526	.3429	.3429
10	.3361	.3429	.3429	.8059	.5144	.2915	.2915
11	.362	.3258	.3429	.5716	.3086	.1372	.2096
12	.2858	.3086	.3086	.4908	.2572	.1543	.3239
13	.2858	.3086	.2743	.5601	.2572	.1715	.2667
14	.3048	.3258	.2572	.5792	.2572	.2058	.2858
15	.1905	.3429	.3258	.6535	.2401	.1715	.3048
16	.3772	.3258	.3429	.6161	.2401	.1715	.2667
17	.3429	.3429	.3772	.5144	.2401	.1715	.2801
18	.6344	.3429	.4801	.6668	.2058	.1715	.2534
19	.9774	.6001	.6516	.9955	.9431	.6859	.9526
20	.8573	.6001	.7373	.6859	.6859	.6516	1.0288
21	.6516	.4973	.5487	.6722	.6173	.6001	.7621
22	.5144	.4287	.4801	.6036	.5487	.5487	.5788
23	.5144	.2743	.3429	.6097	.5487	.5144	.5716
24	.1524	.1372	.1543	.2229	.5716	.5144	.4801
Max	.9774	.6001	.7373	.9955	1.166	.9259	1.0288
Min	.1524	.1372	.1543	.2229	.2058	.1372	.2096
Avg	.4311	.3394	.4072	.5811	.5657	.4687	.5350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 203 / 11 Kv Nidhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.5658	.6001	.5658	.2096	.1886	.1715
2	.6859	.6173	.6001	.583	.2477	.2229	.2058
3	.7621	.6859	.6687	.6687	.2858	.2572	.2572
4	.8402	.7716	.7716	.823	.3361	.3086	.2915
5	1.0456	.9602	.9431	.9602	.3734	.3429	.3429
6	1.0374	.9431	.9602	.9431	.362	.3429	.6001
7	.9945	.7716	.9431	.6516	.6173	.6173	.8573
8	.8402	.8059	.4801	.4801	.056	.5658	.6687
9	.6154	.823	.6344	.4115	.4191	.3601	.463
10	.5415	.4973	.3772	.3086	.4115	.4287	.463
11	.4001	.3772	.4458	.4572	.3429	.4115	.362
12	.4191	.3429	.4973	.4668	.2915	.3944	.3239
13	.381	.3086	.5487	.4954	.2915	.4115	.2858
14	.3429	.2743	.5144	.4191	.2915	.3944	.3239
15	.4001	.2401	.4801	.362	.3086	.3772	.3048
16	.3429	.2915	.4287	.4108	.3086	.3429	.3239
17	.2572	.2572	.4458	.3601	.3086	.3086	.3734
18	.2058	.7545	.4973	.3239	.3429	.4287	.4525
19	.823	.5144	.5944	.8326	.7888	.7202	.724
20	.8573	.7202	.7716	.8029	.7373	.6859	.8402
21	.6859	.7716	.6687	.6859	.6859	.6516	.7095
22	.6001	.6687	.6001	.6584	.6173	.6001	.6413
23	.5487	.4287	.5487	.6287	.5658	.5144	.6287
24	.5716	.5144	.4973	.4458	.1905	.1715	.1372
Max	1.0456	.9602	.9602	.9602	.7888	.7202	.8573
Min	.2058	.2401	.3772	.3086	.056	.1715	.1372
Avg	.6178	.5794	.6049	.5727	.3913	.4187	.4480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 204 / 11KV LEHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3772	.3429	.3772	.1715	.1543	.1372
2	.4763	.4287	.3944	.3772	.1905	.1715	.1715
3	.5716	.5144	.4287	.4458	.1905	.1715	.2058
4	.6161	.5658	.4973	.5487	.2241	.2058	.2401
5	.6908	.6344	.6001	.6344	.2743	.2743	.2743
6	.7545	.7545	.6344	.7716	.362	.3429	.3086
7	.8573	.9259	.7888	.823	.4668	.4287	.4287
8	.7888	.7888	.7545	.7545	.4191	.4115	.463
9	.6668	.6173	.463	.6001	.2667	.3086	.2743
10	.3361	.2058	.3429	.3086	.3429	.2915	.3601
11	.2096	.2743	.3772	.3174	.1715	.3086	.2477
12	.2286	.1543	.3429	.2715	.1372	.2743	.2286
13	.1905	.1543	.3086	.2054	.2572	.2401	.1524
14	.2096	.2058	.2743	.1991	.2743	.2572	.1905
15	.1715	.1715	.3258	.2286	.3086	.2743	.2477
16	.1372	.2572	.2743	.2286	.3086	.2058	.2286
17	.1372	.2401	.2058	.168	.2401	.2229	.2427
18	.1372	.1715	.3258	.4382	.3086	.2401	
19	.5316	.3258	.4115	.5601	.5144	.5487	.5906
20	.6173	.3772	.4973	.5228	.4801	.5144	.5658
21	.5144	.4458	.5144	.4904	.4458	.4801	.5601
22	.3944	.4287	.4115	.4481	.4115	.4287	.4954
23	.3944	.3429	.3772	.4382	.3944	.3429	.4382
24	.381	.3429	.3601	.3772	.1715	.1543	.12
Max	.8573	.9259	.7888	.823	.5144	.5487	.5906
Min	.1372	.1543	.2058	.168	.1372	.1543	.12
Avg	.4347	.4044	.4272	.4389	.3055	.3022	.3118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 205 / 11KV NAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1715	.2058	.3429	.3086	.2572
2	.1905	.1715	.1886	.2229	.3429	.3086	.3086
3	.2241	.2058	.2229	.2572	.381	.3429	.3772
4	.2401	.2401	.2572	.4973	.4108	.3772	.4115
5	.2572	.2572	.4973		.3944	.3944	.4801
6	.4668	.4287	.6001	.6516	.7842	.7202	.6001
7	.6173	.4801	.6687	.6859	.8326	.7373	.703
8	.583	.5658	.6344	.583	.6001	.6173	.583
9	.3944	.3086	.2915	.2743	.381	.3601	.3772
10	.2641	.1886	.1715	.3601	.12	.0514	.1715
11	.1334	.1715	.1543	.381	.2743	.2058	.1905
12	.1143	.1543	.1543	.2801	.3086	.2401	.2667
13	.1334	.1372	.0857	.2614	.2743	.2401	.1905
14	.1524	.1029	.0686	.2241	.2743	.2401	.1905
15	.0953	.0857	.0857	.1886	.2401	.2572	.1524
16	.1029	.1029	.1029	.1524	.2401	.2572	.2096
17	.12	.1372	.12	.1524	.2401	.2572	.1867
18	.2572	.1372	.2572	.1524	.1715	.12	.1494
19	.4801	.2058	.3258	.463	.463	.4287	.4572
20	.463	.2572	.4973	.3921	.3601	.3772	.5658
21	.3772	.3258	.4458	.3429	.3429	.3429	.4481
22	.2915	.2058	.3258	.3018	.2743	.2743	.3174
23	.2743	.2572	.2915	.3239	.2915	.2915	.3048
24	.1905	.1715	.2401	.1886	.3429	.3086	.2572
Max	.6173	.5658	.6687	.6859	.8326	.7373	.703
Min	.0953	.0857	.0686	.1524	.12	.0514	.1494
Avg	.2756	.2279	.2858	.3279	.3620	.3358	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 206 / 11KV KHAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2743	.2572	.2572	.4954	.4458	.4287
2	.3429	.3086	.3258	.2401	.5335	.4801	.463
3	.3429	.3086	.3429	.2401	.6097	.5487	.5144
4	.4191	.3772	.3944	.3258	.743	.6687	.6173
5	.4481	.4115	.4801	.4973	.8326	.7888	.6516
6	.5975		.5658	.6687	1.0829	.9945	.6859
7	.7716	.6344	.6687	.823	1.0829	.9945	.7373
8	.6859	.5144	.583	.6344	.6348	.583	.7545
9	.5041	.3772	.2915	.4115	.6097	.5658	.4973
10	.547	.3086	.3772	.5658	.4115	.2743	.2915
11	.4191	.2743	.3429	.4954	.3086	.2743	.4001
12	.2858	.2572	.3086	.4191	.2401	.2743	.3429
13	.2858	.2743	.2572	.381	.2401	.2915	.3048
14	.2477	.2401	.2743	.4191	.2743	.2915	.2667
15	.2667	.2743	.2401	.4954	.2743	.2915	.2096
16	.2572	.2915	.2572	.6097	.3086	.2915	.3048
17	.3429	.3258	.3258	.6097	.3086	.2915	.3077
18	.4973	.3772	.3944	.5716	.2572	.3258	.2801
19	.7888	.5487	1.0117	.7468	.6859	.6859	.8764
20	.7888	.6001	.6687	.5658		.5487	.8059
21	.6859	.6687	.5487	.5601	.5144	.5144	.7282
22	.4801	.4973	.4458	.5281	.4801	.4801	.5068
23	.4458	.3429	.9088	.5144	.463	.4287	.4954
24	.3048	.2743	.2572	.2743	.4763	.4287	.3772
Max	.7888	.6687	1.0117	.823	1.0829	.9945	.8764
Min	.2477	.2401	.2401	.2401	.2401	.2743	.2096
Avg	.4609	.3809	.4387	.4939	.5160	.4901	.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 201 / 11 kv Shevata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.124	.1214	.124	.2263	.2452	.2477
2	.1387	.1417	.1214	.124	.2263	.2452	.2452
3	.1341	.1402	.1214	.1227	.2641	.2452	.2452
4	.1296	.1753	.1543	.1578	.3361	.3395	.3018
5	.1562	.2103	.1865	.1928	.4715	.4715	.4527
6	.213	.2774	.2543	.2804	.5847	.6979	.679
7	.3206	.3814	.3353	.3121	.6979	.7356	.7545
8	.2454	.3601	.3978	.3429	.6535	.6224	.5847
9	.1494	.2401	.1823	.2427	.415	.415	.4338
10	.1886	.1698	.2263	.3018	.2263	.2829	.1886
11	.132	.1132	.132	.1509	.1457	.1402	.1543
12	.0754	.1132	.0566	.1509	.1326	.1402	.1875
13	.0566	.0754	.0754	.1886	.1326	.1402	.1235
14	.0566	.0943	.0943	.2263	.1326	.1402	.1509
15	.0566	.0943	.0943	.2452	.116	.1402	.1147
16	.0943	.0943	.1132	.2263	.1326	.1227	.0995
17	.132	.1132	.132	.2829	.1326	.1402	.2126
18	.2452	.2263	.2452	.2263	.1509	.1214	.1619
19	.415	.5093	.4904	.3772	.4904	.4527	.4527
20	.3584	.4904	.3584	.3584	.3395	.3584	.547
21	.3018	.3584	.2641	.2829	.3018	.2641	.3018
22	.2829	.2829	.2452	.3018	.2829	.2641	.2263
23	.2641	.2641	.2263	.2829	.2641	.2641	.2263
24	.1677	.1417	.1214	.124	.2263	.2641	.2452
Max	.415	.5093	.4904	.3772	.6979	.7356	.7545
Min	.0566	.0754	.0566	.1227	.116	.1214	.0995
Avg	.1852	.2163	.1979	.2344	.2951	.3022	.3057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 202 / 11 kv NARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0532	.0526	.0532	.1132	.132	.1143
2	.0549	.0532	.0526	.0532	.1132	.132	.1132
3	.056	.0526	.0526	.0701	.1402	.132	.132
4	.1017	.0876	.0693	.0876	.2641	.1886	.1886
5	.1753	.104	.1029	.1052	.3772	.3018	.3018
6	.2012	.1387	.0848	.1227	.5093	.5093	.5281
7	.3932	.1928	.218	.2427	.5658	.5847	.5658
8	.373	.1543	.1658	.1715	.3961	.4715	.4527
9	.2743	.0686	.0829	.0867	.2263	.3206	.2075
10	.1698	.0943	.132	.2075	.1509	.1698	.132
11	.0943	.0754	.0566	.1509	.1311	.0701	.08
12	.0754	.0566	.0754	.1509	.0671	.0701	.0914
13	.0754	.0566	.0754	.1509	.0671	.0701	.0876
14	.0754	.0754	.0754	.1509	.0503	.0876	.0526
15	.0754	.0754	.0754	.132	.0671	.0701	.056
16	.0754	.0754	.0754	.132	.0838	.0701	.048
17	.132	.0943	.0943	.1132	.1006	.1052	.081
18	.2263	.1509	.2075	.1698	.0509	.0867	
19	.3772	.415	.3961	.3772	.3961	.3961	.415
20	.2829	.3584	.3018	.3206	.3206	.3395	.415
21	.2075	.2452	.2452	.2263	.2829	.2452	.2641
22	.1698	.1509	.1698	.1698	.1886	.1886	.1886
23	.132	.1132	.1132	.132	.1509	.132	.1509
24	.0503	.0532	.0526	.0532	.1132	.1509	.1132
Max	.3932	.415	.3961	.3772	.5658	.5847	.5658
Min	.0469	.0526	.0526	.0532	.0503	.0701	.048
Avg	.1623	.1248	.1262	.1513	.2053	.2094	.2078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 203 / 11 kv Pathri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6668	.547	.547	.2378	.2507	.2481
2	.6602	.679	.547	.5658	.2401	.2507	.2481
3	.7575	.7167	.6036	.6036	.2458	.2686	.2658
4	1.0374	1.0374	.8676	.9054	.3561	.3189	.3155
5	1.3392	1.358	1.3014	1.2826	.4424	.4508	.4854
6	1.6787	1.6598	1.6598	1.6598	.5735	.583	.7202
7	1.5466	1.5089	1.6598	1.6598	.7522	.6783	.9259
8	1.4335	1.5089	1.5466	1.4146	.664	.6539	.6687
9	1.1317	1.2071	1.1128	1.2826	.4588	.4973	.5028
10	.6979	.6413	.7356	1.1128	.7167	.6979	.6413
11	.4252	.3544	.3856	.3932	.547	.415	.415
12	.3856	.2947	.3506	.3563	.3961	.3961	.415
13	.333	.2591	.3155	.3281	.3961	.3961	.3772
14	.298	.2846	.298	.3277	.4338	.3961	.4527
15	.2629	.2401	.3121	.3239	.4715	.4338	.4715
16	.3506	.2721	.3467	.3593	.5093	.4715	.4904
17	.333	.3077	.3988	.4115	.5847	.5658	.5658
18	.3506	.2785	.3467	.3077	.7922	.5847	.6224
19	1.3014	1.4335	1.4335	1.226	1.4335	1.2637	1.2371
20	1.094	1.2826	1.1128	1.1506	1.2071	1.1128	1.3957
21	.8299	.9054	.9054	.9431	.9619	.9808	1.0185
22	.7545	.7167	.7545	.2641	.7733	.8299	.7545
23	.6979	.6036	.6602	.6979	.6602	.7167	.6104
24	.6602	.6602	.5658	.6036	.2347	.2561	.2658
Max	1.6787	1.6598	1.6598	1.6598	1.4335	1.2637	1.3957
Min	.2629	.2401	.298	.2641	.2347	.2507	.2481
Avg	.7925	.7865	.7820	.7803	.5870	.5612	.5881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 204 / 11kv Wadod Bazar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.2303	.1949	.1949	.4904	.4715	.4954
2	.218	.2481	.1949	.2126	.4904	.4715	.4904
3	.2515	.2804	.2303	.2454	.5658	.5281	.5281
4	.3018	.3155	.2804	.2804	.6535	.6413	.6224
5	.3772	.3681	.3258	.333	.7682	.7922	.8299
6	.3858	.4681	.3944	.4733	1.0562	.9431	1.0562
7	.5365	.6068	.4409	.6588	1.094	1.1694	.8676
8	.5609	.583	.4917	.463	.9808	.9054	.7356
9	.3887	.4115	.3018	.3988	.7922	.7545	.8676
10	.3688	.6224	.6036	.6224	.6602	.6036	.6602
11	.4904	.5658	.4904	.547	.3856	.333	.3239
12	.4715	.5093	.4338	.5658	.3391	.298	.3155
13	.4527	.4527	.4527	.5281	.3052	.2804	.2801
14	.415	.415	.4527	.5281	.285	.2454	.2454
15	.3961	.3961	.4715	.4904	.2713	.2629	.2652
16	.4904	.4338	.5093	.5093	.2543	.2804	.2429
17	.5847	.4904	.5658	.3395	.3391	.2804	.3086
18	.7167	.6036	.679	.7167	.3086	.2774	.3429
19	.8676	.8676	.8299	.8299	.8676	.8299	.9054
20	.7167	.7733	.7545	.7545	.7733	.7545	.811
21	.6036	.6224	.679	.6602	.7167	.679	.6979
22	.5658	.547	.5847	.6036	.5847	.6224	.6413
23	.4904	.4904	.4904	.5658	.5093	.5658	.5658
24	.2229	.2303	.2126	.2126	.5281	.4904	.5281
Max	.8676	.8676	.8299	.8299	1.094	1.1694	1.0562
Min	.2105	.2303	.1949	.1949	.2543	.2454	.2429
Avg	.4618	.4805	.4610	.4889	.5842	.5617	.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 205 / 11 KV RAJENDRA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.4527	.2452	.4338	.2641	.2641	.2829
2	.2829	.4527	.2452	.4527	.2454	.2641	.2829
3	.2658	.4715	.2641	.4338	.2614	.2641	.2829
4	.2829	.4527	.2641	.415	.2454	.2641	.3018
5	.2629	.3772	.2641	.415	.2561	.2641	.3018
6	.2629	.3206	.2829	.3206	.2347	.2641	.3018
7	.2829	.3206	.2641	.2829	.2614	.2641	.2829
8	.2614	.3018	.415	.4527	.3395	.3961	.3772
9	.2454	.2829	.4338	.3772	.3395	.3961	.3961
10	.2374	.2641	.3584	.3584	.3584	.3961	.4338
11	.2641	.2829	.4338	.2591	.3395	.3772	.4338
12	.2829	.2629	.4338	.3856	.3584	.3772	
13	.2829	.2658	.3772	.4207	.3395	.3772	.2883
14	.2641	.2829	.3395	.2812	.3395	.3772	.3012
15	.2829	.2452	.3772	.3584	.3018	.3772	.2713
16	.2829	.2829	.415	.3361	.3772		.2987
17	.3018	.2829	.415	.3222	.3584	.3584	.2829
18	.3206	.2641	.415	.3155	.3395	.3584	
19	.2829	.2452	.415	.2658	.2641	.3018	.4108
20	.3772	.2452	.3961	.2374	.2641	.2829	.3018
21	.4527	.2452	.3772	.2641	.2641	.2829	.2829
22	.4715	.2641	.3961	.2641	.2641	.2829	.2829
23	.4904	.2641	.3961	.2829	.2641	.2829	.2804
24	.2343	.4715	.2452	.415	.2641	.2641	.2829
Max	.4904	.4715	.4338	.4527	.3772	.3961	.4338
Min	.2343	.2452	.2452	.2374	.2347	.2641	.2713
Avg	.3024	.3167	.3529	.3479	.2977	.3190	.3165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 201 / 11KV JATEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.168	.1494	.1494	.1543	.168	.0857
2	.1494	.1867	.1494	.1494	.1543	.168	.1656
3	.168	.1867	.1494	.1867	.1543	.168	.1806
4	.168	.1867	.168	.2241	.1715		.1957
5	.1867	.2054	.1867		.1802		.2286
6	.2054	.2427	.2054	.2241	.2591		.4586
7	.1867	.2054	.1867	.2241	.5121	.301	.6081
8	.1494	.1494	.1307	.1494	.4572	.301	.4801
9	.0934	.0934	.0732	.0934	.2195	.1957	.2286
10	.0934	.0934	.0943	.0934	.0549	.056	.1715
11	.301	.2286	.2195	.3201	.0549	.056	.0343
12	.2896	.2286	.2195	.3048	.0549	.0747	.1029
13	.301	.2134	.2195	.2743	.0549	.0373	.0857
14	.2408	.1981	.2195	.2286	.0549	.0503	.0857
15	.2258	.1829	.2195	.2439	.0549	.056	.12
16	.2439	.2134	.2012	.3048	.0549	.056	.0343
17	.2258	.2439	.2012	.2743	.0549	.056	.1029
18	.1806	.1677	.2012	.2286	.0549	.0373	.0686
19	.0934	.112	.1463	.0934	.0914	.0934	.0857
20	.1307	.112	.1463	.112	.1463	.112	.1029
21	.1307	.132	.1463	.112	.1463	.0934	.0857
22	.1494	.1307	.1463	.0934	.1463	.0934	.0857
23	.1494	.1307	.1463	.0934	.0934	.0934	.0857
24	.1494	.1867	.1307	.1494	.1372	.112	.1505
Max	.301	.2439	.2195	.3201	.5121	.301	.6081
Min	.0934	.0934	.0732	.0934	.0549	.0373	.0343
Avg	.1817	.1749	.1690	.1881	.1466	.1133	.1681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 202 / 11KV DHAMANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1355	.1054	.1029	.0934	.0934	.056	.112
2	.1355	.1204	.1029	.0934	.0934	.056	.112
3	.1505	.1355	.1029	.0934	.0934	.056	.112
4	.1656	.1524	.12	.0934	.0934	.0934	.112
5	.1829	.1718	.1311	.0934	.112	.0934	.1307
6	.2006	.2896	.1802	.0934	.112	.0934	.1307
7	.4902	.5281	.381	.5228	.1097	.0934	.1307
8	.4321	.4687	.3201	.5601	.0914	.0934	.1307
9	.2559	.2408	.2743	.381	.0914	.056	.0747
10	.056	.0747	.0549	.0373	.0914	.056	.0686
11	.0373	.056	.0549	.056	.3658	.2591	.4572
12	.0373	.0373	.0549	.056	.4024	.2258	.5639
13	.0373	.0373	.0549	.056	.3292	.2408	.442
14	.0373	.0373	.0549	.056	.3292	.3161	.3201
15	.0373	.0373	.0549	.0373	.2561	.1656	.4268
16	.056	.0373	.0549	.0373	.2561	.2258	.4268
17	.056	.0373	.0549	.0373	.2561	.2709	.5182
18	.056	.056	.0549	.0373	.2195	.286	.3201
19	.0934	.0934	.0914	.0747	.0914	.056	.0857
20	.0934	.0934	.0914	.0934	.1097	.0838	.0857
21	.0747	.0747	.0914	.0373	.1097	.0934	.0857
22	.0747	.0747	.0914	.0934	.0914	.0934	.0857
23	.056	.056	.0934	.0934	.0914	.112	.0857
24	.0753	.1054	.1029	.0934	.0934	.0934	.112
Max	.4902	.5281	.381	.5601	.4024	.3161	.5639
Min	.0373	.0373	.0549	.0373	.0914	.056	.0686
Avg	.1261	.1300	.1155	.1217	.1660	.1362	.2137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 203 / 11KV BABHULGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0373	.0686	.0934	.1054
2	.0373	.0373	.0373	.0373	.0686	.1463	.1054
3	.0373	.0373	.0373	.056	.0857	.1463	.1204
4	.056	.056	.056	.056	.0819	.1829	.1204
5	.056	.056	.056	.056	.0983	.2195	.1219
6	.056	.056	.0732	.056	.1296	.3395	.253
7	.0747	.0747	.0732	.056	.3475	.2709	.3953
8	.056	.0747	.0747	.056	.3292	.2709	.3479
9	.0373	.056	.0732	.056	.2926	.2408	.2439
10	.0373	.0373	.0373	.0373	.0366	.0373	.0343
11	.1355	.1829	.2241	.1829	.0366	.0187	.0514
12	.1957	.2134	.2241	.2439	.0366	.0187	.0343
13	.1656	.1524	.2801	.2439	.0366	.0187	.0171
14	.1656	.1524	.2987	.2743	.0366	.0187	.0171
15	.1656	.1677	.2241	.2286	.0366	.0187	.0343
16	.1656	.1677	.1829	.1981	.0366		.0343
17	.2107	.1829	.1829	.2439	.0366	.0187	.0514
18	.1656	.1524	.2195	.1524	.0366	.0187	.0343
19	.0187	.056	.0549	.056	.0366	.0373	.0343
20	.0373	.056	.0549	.056	.0366	.0373	.0343
21	.056	.056	.0549	.0373	.0366	.0373	.0343
22	.056	.056	.0366	.0373	.0366	.0373	.0343
23	.0373	.056	.0549	.0373	.0366	.0373	.0343
24	.0373	.0373	.0373	.056	.0686	.0732	.1355
Max	.2107	.2134	.2987	.2743	.3475	.3395	.3953
Min	.0187	.0373	.0366	.0373	.0366	.0187	.0171
Avg	.0874	.0922	.1119	.1063	.0868	.1017	.1012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 204 / 11 KV JATEGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2987	.2835	.2241	.3012	.2195	.2987
2	.2987	.2987	.2835		.298	.2743	.2987
3	.3174	.3174	.3109	.3361	.3189	.3361	.3174
4	.4294	.4108	.4294	.5601	.4481	.5601	.4108
5	.7095	.6722	.6348	.8962	.5975	.7468	.6535
6	.9808	.9896	.8962	.9709	.9896	.9709	.9808
7	1.1128	.9431	1.0082	1.0456	.9511	1.0082	.9522
8	.9619	.9619	.9149	.8962	.8413	.8402	.8589
9	.6348	.8029	.7095	.7842	.6584	.5975	.6535
10	.4481	.4938	.3921	.5975	.2926	.4481	.5914
11	.3174	.333	.2801	.381	.2195	.3361	.5304
12	.2218	.2103	.2241	.2743	.2195	.2241	.567
13	.1829	.2279	.2241	.2743	.3292	.2241	.4525
14	.1829	.2103	.2241	.3048	.3292	.2427	.362
15	.2012	.2103	.2241	.3658	.2195	.2614	.4887
16	.2561	.2279	.2195	.3841	.2195	.2987	.5552
17	.3174	.2454	.2926	.3841	.2926	.3361	.6154
18	.4854	.4755	.5121	.5228	.439	.4108	.6099
19	.8029	.9149	.7316	.7282	.5487	.7468	.7842
20	.6535	.7842	.5228	.6161	.7682	.7468	.7316
21	.4481	.5601	.4668	.4481	.4755	.4024	.4887
22	.3547	.3292	.3734	.3658	.3658	.3547	.3439
23	.3174	.2801	.2987	.3109	.2987	.2987	.2865
24	.2987	.3174	.2658	.2614	.3109	.2241	.2987
Max	1.1128	.9896	1.0082	1.0456	.9896	1.0082	.9808
Min	.1829	.2103	.2195	.2241	.2195	.2195	.2865
Avg	.4680	.4798	.4468	.5188	.4472	.4629	.5471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 205 / 11KV SULTANWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1204	.1204		.1867	.0187	.0549	.0187
2	.1204	.1355		.1867	.0187	.0549	.0187
3	.1204	.1355		.1867	.0187	.056	.0187
4	.1372			.2801	.0187	.0549	.0187
5	.1562			.2801	.0187	.0934	.0187
6	.2214			.3361	.0187	.0934	.0187
7	.4999			.7865	.0183	.0452	.0187
8	.6241	.5312		.8029	.0183	.0452	.0187
9	.2709	.301		.3048	.0183	.0301	.0187
10		.0187		.0187	.0183	.0187	.0171
11	.0187	.0187		.0187	.3475		.2591
12	.0187	.0187		.0187	.3475		.2743
13	.0187	.0187		.0187	.3292		.2591
14	.0187	.0187		.0187	.3292		.1981
15	.0187	.0187		.0187	.2743		.2286
16	.0187	.0187		.0187	.3292	.2709	.2439
17	.0187	.0187		.0187	.3292	.3612	.3048
18	.0187	.0187	.0183	.0187	.2743	.286	.2743
19	.0187	.0187	.0183	.0187	.0183	.0187	.0171
20	.0187	.0187	.0183	.0187	.0183	.0187	.0171
21	.0187	.0187	.0183	.0187	.0183	.0187	.0171
22	.0187	.0187	.0183	.0187	.0183	.0187	
23	.0187	.0187	.0187	.0187	.0549	.0187	.0171
24	.1204	.1204	.1543	.1867	.0187	.0549	.0187
Max	.6241	.5312	.1543	.8029	.3475	.3612	.3048
Min	.0187	.0187	.0183	.0187	.0183	.0187	.0171
Avg	.1145	.0803	.0378	.1583	.1205	.0849	.1006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 201 / 11KV KINGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.2458	.2115	.3506	.1886	.1734	.1886
2	.2688	.2785	.2429	.3601	.2263	.2058	.1886
3	.2656	.3163	.2858	.4024	.2263	.208	.1886
4	.3749	.3953	.362	.3978	.2614	.2427	.2263
5	.4687	.427	.3909	.4475	.2801	.2601	.2641
6	.5639	.5335	.5068	.4915	.3326	.3121	.2641
7	.7727	.8278	.7819	.8288	.4458	.3467	.3961
8	.6371	.7716	.7287	.7125	.4115		.3961
9	.4877	.4858	.5792	.5243	.2058	.3121	.2641
10	.2427	.1429	.1886	.2614	.1907	.2829	.1867
11	.1886	.1204	.1698	.1867	.4344	.431	.3353
12	.132	.12	.132		.3948	.3768	.4268
13	.1132	.1214	.1509		.3715	.426	.3763
14	.1132	.12	.1509	.1509	.3475	.3277	.2896
15	.1886	.1204	.1509	.1494	.3858	.3481	.3161
16	.2241	.12	.2075	.1867	.4287	.2984	.3048
17	.2241	.1715	.1698	.2801	.4287	.4641	.3201
18	.2241	.1886	.1509	.3174	.4489	.4641	.3612
19	.2614	.2427	.1886	.2829	.3429	.3018	.3734
20	.3734	.3467	.3206	.2641	.2401	.3206	.4481
21	.3361	.3121	.2829	.2075	.2401	.2829	.4481
22	.2829	.2572	.2452	.1886	.208	.2263	.3772
23	.2829	.2601	.2075	.1886	.1715	.2263	.2641
24	.2688	.3277	.2858	.3506	.1886	.1734	.2263
Max	.7727	.8278	.7819	.8288	.4489	.4641	.4481
Min	.1132	.12	.132	.1494	.1715	.1734	.1867
Avg	.3145	.3022	.2955	.3423	.3084	.3048	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 202 / 11KV PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0705	.0934	.1132		
2	.0943	.0943	.0857	.0934	.1132		.0934
3	.1097	.0943	.0705	.0934	.132		.112
4	.1509	.132	.1	.1494	.1867		.168
5	.2195	.1867	.1448	.2054	.2218		.2054
6	.2743	.2614	.2	.2801	.2957		.2987
7	.3206	.2054	.2429	.2801	.2572		.3174
8	.2641	.1715	.2429	.2614	.2143		.2241
9	.2241	.1286	.1448	.2427	.1593		.2054
10	.1494	.0579	.1494	.1867	.1286		.2218
11	.0934	.0579	.112	.1867	.1014	.1867	.1848
12	.0934	.0579	.1307	.1307	.0846	.1307	.1494
13	.0934	.0572	.0934	.1307	.0714		.1494
14	.0934	.0572	.0934	.112	.0714	.1307	.1494
15	.0934	.0857	.0934	.112	.0869	.112	.1494
16	.0934	.0869	.112	.112	.1014	.112	.1494
17	.1307	.1014	.0747	.168	.1158	.1307	.1848
18	.168	.1143	.168	.1867	.1429	.168	.2427
19	.1867	.1448	.2241	.2427	.1738	.2801	.2402
20	.2054	.2	.2054	.2241	.1448	.2801	.2241
21	.1886	.1429	.1494	.1886	.1448	.2241	.1867
22	.1509	.1158	.1494	.1886		.1494	.1867
23	.1132	.0857	.1307	.1886		.112	.1698
24	.1132	.1132	.0714	.0934	.132		.0934
Max	.3206	.2614	.2429	.2801	.2957	.2801	.3174
Min	.0934	.0572	.0705	.0934	.0714	.112	.0934
Avg	.1549	.1186	.1358	.1730	.1451	.1680	.1872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 203 / 11KV GANORI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132		.1029	.1132	.1715	.1429	.1753
2	.1509	.132	.1054	.1132	.1865	.1448	.1753
3	.1698	.1509	.1372	.1509	.2204	.1882	.2058
4	.2075		.1734	.2075	.285	.2462	.2683
5	.2452		.2229	.2452	.3353	.2896	.3315
6	.3018		.3086	.3395	.3932	.4344	.3978
7	.3292	.3109	.3258	.3584	.5858	.6001	.8421
8	.3206	.2947	.3086	.3772	.5001		.7287
9	.2926	.1907	.1957	.2829	.362	.3858	.5243
10	.2218	.2058	.1658	.2743	.1448	.132	.1494
11	.4115	.4001	.2949	.4115	.1372	.1132	.1307
12	.4904	.3475	.426	.4365	.1214	.1132	.112
13	.4572	.3858	.426	.4694	.12	.1132	.1307
14	.3593	.3765	.3932	.4064	.12	.1132	.1307
15	.3321	.3765	.3605	.4064	.1054	.1132	.1307
16	.3321		.5506	.3963	.1372	.1132	.1307
17	.3163	.3475	.3768	.3963	.12	.132	.1294
18	.3239	.3001	.3149	.3605	.1715	.1509	.1294
19	.2772	.2258	.2263	.2054	.1715	.2075	.2241
20	.2241	.1806	.2075	.2054	.1448	.1886	.2054
21	.1867	.1734	.132	.1886	.1372	.1509	.1867
22	.168	.156	.1132	.1509	.1227	.132	.1698
23	.1307	.1214	.1132	.1509	.1214	.1132	.1132
24	.1132	.1132	.0869	.1132	.1772	.1448	.1753
Max	.4904	.4001	.5506	.4694	.5858	.6001	.8421
Min	.1132	.1132	.0869	.1132	.1054	.1132	.112
Avg	.2706	.2521	.2528	.2817	.2122	.1940	.2457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 204 / 11 KV DONGERGAON-SHIRODI SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3113	.3721	.2961	.3601	.3395	.3121	.3206
2	.3113	.3721	.3144	.3601	.3584	.3258	.3206
3	.3563	.394	.3144	.3856	.3584	.3258	.3206
4	.4024		.3286	.3856	.3772	.3429	.3584
5	.4534		.4344	.4144	.3921	.3772	.3961
6	.5658		.5068	.4144	.4108	.3641	.415
7	.6478		.5937	.583	.4287	.3772	.5281
8	.6299	.4572	.5287	.5243	.3429	.3429	.415
9	.3725	.3144	.4199	.3978	.2559	.2915	.3584
10	.3206	.2743	.3018	.3547	.2743		.3018
11	.362	.2572	.2829	.3206	.362	.3315	.3113
12	.362	.2427	.2829	.3018	.3286	.3277	.3277
13	.362	.2572	.2829	.3018	.3185	.3149	.3239
14	.362	.2572	.2829	.2829	.3475	.3315	.3201
15	.3584	.2401	.2829	.2829	.2858	.3812	.3201
16		.2401	.2641	.2829	.3041	.3978	.3277
17	.3584	.2601	.2829	.3018	.3475	.3315	.3441
18	.3772	.2572	.2829	.3174	.3161	.3481	.3605
19	.3961	.3258	.3584	.3547	.2751	.3395	.3734
20	.415	.3258	.3584	.3547	.3258	.3584	.3584
21	.3961	.3086	.3395	.3584	.3086	.3584	.3584
22	.3772	.2947	.3206	.3584	.2601	.3584	.3584
23	.3772	.3121	.3206	.3584	.208	.3395	.3584
24	.3605	.3721	.2858		.3395	.3086	.3206
Max	.6478	.4572	.5937	.583	.4287	.3978	.5281
Min	.3113	.2401	.2641	.2829	.208	.2915	.3018
Avg	.4015	.3068	.3444	.3633	.3277	.3429	.3541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 205 / 11 KV WAREGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2614	.2	.2614	.2801	.2115	.2801
2	.2452	.2801	.2143	.2614	.3174	.2429	.2801
3	.3109	.2801	.2286	.3361	.4481	.3429	.3547
4	.5281	.4435	.3475	.5041	.7207	.5573	.4108
5	.6516	.6653	.5144	.6722	.8048	.5716	.5975
6	.8779	.9511	.7145	.8029	.8688	.6081	.8215
7	.7922	.8413	.6371	.6535	.6859	.8215	.8215
8	.4904	.4572	.5144	.5041	.5792	.5792	.5041
9	.6219	.5502	.4199	.6348	.4923	.5975	.3921
10	.4207	.2896	.3547	.5487	.2429	.3547	
11	.2218	.1882	.2054	.3881	.1738	.2241	
12	.1478	.2606	.168	.2402	.1572	.2241	
13	.1478	.1269	.1494	.2033	.1429	.1867	
14	.1294	.1143	.0747	.2033	.0714	.1867	.3142
15	.1294	.1303	.0747	.1867	.0724	.112	.2772
16	.1829	.1448	.0747	.1867	.1448	.1867	.1867
17	.2614	.2027	.2614	.2587	.2429	.2614	.2801
18	.3921	.2896	.3547	.4066	.2606	.2987	.3881
19	.7762	.6287	.7655	.6838	.6081	.7842	.7316
20	.7023	.6144	.8215	.6283	.5937	.7282	.5729
21	.5041	.4001	.5601	.4854	.4572	.5975	.5041
22	.3734	.2896	.4108	.4108	.3475	.4668	.3734
23	.2614	.2	.2987	.2801	.2572	.3174	.3174
24	.2195	.2614	.2027	.2614	.2801	.2172	.2801
Max	.8779	.9511	.8215	.8029	.8688	.8215	.8215
Min	.1294	.1143	.0747	.1867	.0714	.112	.1867
Avg	.4006	.3696	.3570	.4168	.3854	.4033	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 206 / 11 KV WANEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2401	.2641	.2572	.2143	.2915
2	.2829	.2829	.2258	.2641	.2515	.2172	.285
3	.3018	.2987	.2317	.3018	.285	.2429	.3481
4	.3395	.3547	.3258	.3018	.3277	.2858	.3932
5	.3584	.3547	.3258	.3584	.3725	.3286	.4424
6	.415	.3921	.3601	.3961	.5281	.4652	.5571
7	.4338	.4294	.4287	.4527	.7145	.6716	.8259
8	.3584	.3258	.3258	.3395	.6661	.5144	.7773
9	.2614	.2254	.2058	.2641	.362	.4904	.4915
10	.1509	.156	.1492	.168	.12	.1132	.1307
11	.3906	.3715	.3768	.4572	.104	.0943	.1132
12	.3953	.333	.3605	.442	.0857	.0754	.1132
13		.2715	.3605	.4374	.0857	.0943	.0943
14	.3601	.2896	.3113	.381	.0857	.132	.0943
15	.3441	.2896	.2155	.381	.1029	.132	.0943
16	.3725	.2896	.4144	.3963	.1029	.1509	.0943
17	.3321	.3909	.4475	.3913	.1029	.0754	.1132
18	.4096	.3763	.3812	.3932	.12	.0943	.1132
19	.3174	.3601	.3018	.2241	.1543	.2263	.1886
20	.2829	.2743	.2829	.2614	.1715	.2452	.2452
21	.2829	.2572	.2829	.3206	.1886	.2075	.2263
22	.2641	.2427	.2829	.3206	.1715	.1509	.1886
23	.2641	.2401	.2829	.3206	.1543	.1509	.1886
24	.2641	.2641	.2401	.2641	.3258	.2751	.298
Max	.4338	.4294	.4475	.4572	.7145	.6716	.8259
Min	.1509	.156	.1492	.168	.0857	.0754	.0943
Avg	.3237	.3056	.3067	.3376	.2434	.2353	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 201 / 11 KV PIRBAWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2286	.2172	.2477	.4001	.3772	.4572
2	.3429	.2667	.2401	.2858	.4001	.4338	.4954
3	.4001	.3048	.2883	.3429	.4191	.5281	.5906
4	.4525	.3772	.2984	.3582	.5335	.679	.6668
5	.4784	.5144	.3277	.3988	.6097	.9054	.7621
6	.5087	.5487	.4752	.4801	.8002	1.0562	.8954
7	.5801	.6668	.4481	.5533	.9717	.9997	1.0479
8	.4534	.5316	.4687	.4049	.8383	.7545	.8192
9	.3467	.2915	.4144	.2883	.5525	.4961	.5716
10	.4191	.4001	.3395	.5144	.3239	.362	.3429
11	.381	.2641	.2667	.362	.2818	.1753	.2286
12	.2667	.2829	.2096	.3429	.2241	.1715	.2667
13	.2858	.2829	.2286	.3239	.2439	.1658	.2477
14	.2858	.2641	.2477	.4382	.1823	.1907	.2858
15	.2858	.2829	.3048	.4382	.2105	.1966	.2096
16	.2477	.2075	.3239	.4382	.2401	.2515	.2477
17	.2858	.3018	.381	.4382	.2515	.2454	.2667
18	.4572	.3961	.4191	.4382	.2035	.2229	.2667
19	.5525	.7167	.7049		.7167	.6859	.6859
20	.5716	.6413	.6478	.5525	.6413	.6668	.6287
21	.4763	.4715	.5716	.4763	.5281	.5716	.5335
22	.4763	.3961	.4763	.4572	.4904	.5144	.5144
23	.4001	.3584	.4382	.4382	.4572	.4382	.4382
24	.3048	.2286	.1867	.2477	.4191	.3429	.4382
Max	.5801	.7167	.7049	.5533	.9717	1.0562	1.0479
Min	.2477	.2075	.1867	.2477	.1823	.1658	.2096
Avg	.3985	.3844	.3719	.4029	.4558	.4763	.4961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 202 / 11 KV RANJANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1886	.1905	.0762	.0373	.0381
2	.2096	.1905	.2452	.2477	.0762	.0366	.0572
3	.2667	.2286	.2829	.2858	.0762	.0686	.0543
4	.381	.2667	.3395	.381	.0953	.0848	.0693
5	.5335	.381	.3772	.4572	.1334	.0995	.1017
6	.6287	.5716	.6224	.5525	.1524	.1311	.1174
7	.8002	.5716	.6036	.6668	.1524	.0972	.1475
8	.5335	.4572	.4527	.4572	.1524	.1219	.1526
9	.4382	.362	.3206	.4191	.0762	.08	.1227
10	.2096	.1715	.2263	.2858	.2477	.2286	.1715
11	.0572	.0332	.0532	.0762	.1509	.1334	.1334
12	.0572	.0339	.0693	.0953	.2075	.1524	.0953
13	.0953	.0166	.0343	.0572	.2452	.1715	.1143
14	.0572	.0678	.0332	.0572	.1509	.1334	.0762
15	.0381	.0339	.0335	.0572	.2641	.1524	.0953
16	.0572	.0514	.0655		.2263	.1334	.1143
17	.0762	.0701	.081	.1143	.2075	.1524	
18	.0762	.0914	.0686	.0762	.2263	.1524	.1905
19	.5525	.3961	.5335	.4572	.3584	.362	.4382
20	.4382	.4527	.4954	.4191	.3961	.362	.5525
21	.3048	.2829	.362	.3429	.3584	.2858	.362
22	.2667	.2075	.2858	.2667	.2829	.2477	.2858
23	.2096	.1886	.2096	.2096	.1886	.1905	.1905
24	.1905	.1905	.1524	.1905	.0762	.056	.0381
Max	.8002	.5716	.6224	.6668	.3961	.362	.5525
Min	.0381	.0166	.0332	.0572	.0762	.0366	.0381
Avg	.2779	.2295	.2557	.2767	.1907	.1530	.1617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 203 / 11 KV GEOVRAI PAIGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3206	.3429	.1905	.1829	.1905
2	.381	.3429	.3395	.381	.1905	.1715	.2667
3	.4572	.381	.415	.4572	.2096	.2347	.2896
4	.4954	.4954	.547	.5335	.2286	.3149	.3467
5	.6478	.6097	.7545	.6859	.4191	.3841	.4748
6	.7621	.8002	.9431	.8383	.4572	.4268	.5365
7	.9907	.9145	.9808	.9907	.6097	.535	.6882
8	.8383	.8383	.8676	.8002	.5335	.535	.6104
9	.5716	.6478	.5658	.6478	.3429	.3521	.4557
10	.381	.4572	.3395	.4954	.3048	.3429	.3048
11	.3429	.2561	.2126	.3429	.2263	.1905	.1905
12	.3086	.25	.2774	.4191	.1509	.1524	.2286
13	.381	.25	.2743	.381	.1886	.1524	.1905
14	.4191	.1943	.3315	.3429	.1886	.1524	.1905
15	.3048	.2321	.3018	.3048	.1509	.2286	.1905
16	.2286	.2321	.2949	.4572	.2263	.2286	.1905
17	.3048	.3052	.3239	.3429	.2641	.2286	.1524
18	.3048	.2804	.2743	.3429	.3018	.2667	.3048
19	.7621	.6036	.6859	.5716	.6413	.5335	.724
20	.5716	.7545	.6859	.5335	.679	.6097	1.0288
21	.4572	.4527	.4954	.4572	.415	.4954	.8383
22	.381	.3772	.381	.4191	.3961	.4191	.724
23	.381	.3395	.3429	.381	.3772	.3429	.6478
24	.3429	.3429	.3048	.3429	.1905	.2033	.1905
Max	.9907	.9145	.9808	.9907	.679	.6097	1.0288
Min	.2286	.1943	.2126	.3048	.1509	.1524	.1524
Avg	.4733	.4459	.4692	.4922	.3285	.3202	.4148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 201 / 11KV GEVRAE GUNGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2515	.1677	.1677	.2829	.1886	.1886
2	.2515	.2515	.2515	.3353	.3772	.2829	.2829
3	.3353	.3353	.3353	.4191	.2829	.3772	.3772
4	.5868	.3353	.4191	.503	.1886	.4715	.4715
5	.503	.4191	.503	.5868	.3772	.4715	.5658
6	.2515	.4191	.5868	.503	.4715	.5658	.6602
7	.503	.503	.4191	.503	.5658	.6602	.6602
8	.3353	.4191	.3353	.2515	.4715	.1886	.4715
9	.3048	.2515	.2515	.1677	.3395	.1886	.3772
10	.2829	.2829	.2829	.2829	.1677	.1886	.1886
11	.0943	.1886	.0943	.1886	.1677	.1677	.1677
12	.0943	.0943	.0094	.0943	.1677	.1677	.1677
13	.0943	.0943	.0943	.1886	.1677	.1677	.1677
14	.0943	.0943	.0943	.0943	.1677	.1677	.1677
15	.0943	.0943	.0943	.0943	.1677	.1677	.2515
16	.0943	.0943	.0943	.1886	.1677	.1677	.0838
17	.0943	.1886	.0943	.2829	.1677	.1677	.1677
18	.3772	.2829	.1886	.2829	.0838	.1677	.1677
19	.4715	.3772	.3772	.2829	.1886	.2829	.5658
20	.3772	.2829	.3772	.2829	.1886	.3772	.4715
21	.1886	.1886	.2829	.3772	.1886	.2829	.3772
22	.1886	.1886	.1886	.1886	.1886	.1886	.3772
23	.1886	.0943	.0943	.1886	.1886	.1886	.1886
24	.0838	.1677		.2515	.1886	.1886	
Max	.5868	.503	.5868	.5868	.5658	.6602	.6602
Min	.0838	.0943	.0094	.0943	.0838	.1677	.0838
Avg	.2594	.2458	.2451	.2794	.2464	.2681	.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 202 / kolte takli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3353	.2515	.2515	.4715	.3772	.3772
2	.3353	.3353	.3353	.3353	.7545	.4715	.4715
3	.4191	.3353	.3353	.4191	.6602	.5658	.5658
4	.503	.503	.4191	.3353	.6602	.6602	.6602
5	.4191	.5868	.503	.503	.7545	.7545	.7545
6	.2515	.6706	.503	.3353	.7545	.8488	.7545
7	.4191	.3353	.3353	.3353	.7545	.9431	.8488
8	.2515	.2515	.2515	.3353	.5658	.5658	.5658
9	.1677	.1677	.1677	.3353	.5658		.4715
10	.2829	.3772	.3772	.5658	.1677		.3772
11	.2829	.2829	.0943	.4715	.2515	.1677	.3353
12	.2829		.0943	.4715	.2515	.1677	.2515
13	.2829	.1886	.0943	.4715	.2515	.1677	.2515
14	.2829	.1886	.1886	.4715	.2515	.1677	.5868
15	.2829	.1886	.2829	.4715	.2515	.0838	.503
16	.2829	.1886	.2829	.3772	.1677	.0838	
17	.2829	.2829	.2829	.5658	.1677	.0838	
18	.3772	.4715	.4715	.3772	.1677		
19	.7545	.5658	.6602	.4715	.2829		
20	.3772	.4715	.8488	.6602	.5658	.5658	
21	.4715	.3772	.5658	.6602	.6602	.5658	
22	.5658	.3772	.4715	.5658	.5658	.5658	
23	.3772	.3772	.4715	.5658	.5658	.4715	
24	.1677	.2515		.3353	.4715	.3772	
Max	.7545	.6706	.8488	.6602	.7545	.9431	.8488
Min	.1677	.1677	.0943	.2515	.1677	.0838	.2515
Avg	.3523	.3526	.3604	.4453	.4576	.4328	.5183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 201 / FARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9526		.9877	.7621	.4527	
2	.9145	.9145		.9145	.8002	.4904	
3	.9526	.9907		.9145	.8383	.5281	
4	.9907	1.0669		.8779	.8383	.5658	
5	1.0288	1.2193		.9511	.8764	.6036	
6	1.1431	1.2955		1.0608	.8764	.6036	
7	1.3336	1.2955		1.2323	1.1431	1.3203	
8	1.2574	1.1317	1.0974	1.0631		1.1317	1.0288
9	.7621	.7202	.6859	.6859		1.0288	.9259
10	.7621	.7202	.6516	.7202		.9602	.8573
11	.6859	.6859	.6516	.7545		.8916	.8573
12	.7621	.6859	.6173	.7888		.8573	.823
13	.8383	.6516	.6516	.7202		.8573	.8573
14	.8764	.6859	.6516	.6859		.823	.823
15		.6173	.6173	.6516		.823	.7888
16		.679	.6584	.724	.9431	.8779	.9526
17		.7922	.8413	.9526	1.0185	.8779	.9526
18			1.1576	1.1812	1.094	.9145	.9907
19			1.1706	1.1812	1.1317	1.2437	1.105
20			1.2696	1.2574	1.3203	1.307	1.2574
21			1.2071	.7621	.4904	.5853	1.3336
22			1.1706	.8764		.6584	1.2955
23			1.0974	.7621		.695	1.105
24	1.0288	1.0288			.7621	.5281	
Max	1.3336	1.2955	1.2696	1.2574	1.3203	1.3203	1.3336
Min	.6859	.6173	.6173	.6516	.4904	.4527	.7888
Avg	.9526	.8963	.8873	.9003	.9211	.8177	.9971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 202 / 11KV JANGLA GAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716		.5975	.5716	.3772	
2		.5716		.5487	.6097	.415	
3	.6097	.6097		.5487	.6478	.4527	
4	.6478	.6478		.6219	.6859	.5658	
5	.8383	.7621		.695	.8383	.6036	
6	.9145	.9145		.7682	.8383	.6413	
7	.9907	.9526		.8048	.6478	.5281	
8	.8383	.6859	.7545	.583		.4458	.4801
9	.6859	.7545	.583	.7545		.4115	.4801
10	.7621	.823	.6173	.7888		.3429	.4115
11	.8383	.823	.6516	.8573		.3429	.4115
12	.8764	.8573		.9945		.3772	.4458
13	.9526	.823	.8916	.8916		.3772	.3772
14	.9907	.823	.9259	.8573		.3772	.3772
15		.6173	1.0288	.823		.3772	.3429
16		.7922	1.0608	.6097		.3582	.4572
17		.415	.5121	.6097			.5335
18			.6219	.724		.0358	.6097
19			.7842	.8002		.8048	.7621
20			.7316	.7621		.7316	.9526
21			.695	.5716		.5601	.9145
22			.6219	.6097		.5487	.8002
23			.6219	.5716		.5121	.724
24	.6478	.6097		.6219	.6097	.3772	
Max	.9907	.9526	1.0608	.9945	.8383	.8048	.9526
Min	.6097	.415	.5121	.5487	.5716	.0358	.3429
Avg	.8002	.7252	.7401	.7090	.6811	.4593	.5675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 206 / MJP EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0328		
2	.0381	.0381		.0328		
3	.0381	.0381		.0335		
4	.0381	.0381		.0328	.0381	
5	.0381	.0381		.0328		
6	.0381	.0381		.0328		
7	.0381	.0381		.0335	.0381	
8	.0381	.0038	.0038	.0038	.0038	.0038
9	.0381	.0038	.0038	.0038	.0038	.0038
10	.0381	.0038	.0038	.0038	.0038	.0038
11	.0381	.0038	.0038	.0038	.0038	.0038
12	.0381	.0038	.0038	.0038	.0038	.0038
13	.0381	.0038	.0038	.0038	.0038	.0038
14	.0381	.0038	.0038	.0038	.0038	.0038
15		.0038	.0038	.0038	.0038	.0038
16		.0381	.0351	.0381		
17		.0381	.0358	.0381		
18			.0366	.0381		
19				.0381	.0351	
20			.0358	.0381	.0366	
21			.0358	.0381	.0358	
22			.0351	.0381	.0351	
23			.0351	.0381	.0351	
24	.0381	.0381		.0312	.0381	
Max	.0381	.0381	.0366	.0381	.0381	.0038
Min	.0381	.0038	.0038	.0038	.0038	.0038
Avg	.0381	.0229	.0186	.0249	.0202	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 207 / AJANTHA CAVES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0328			
2	.0381	.0381			.0381		
3	.0381	.0381			.0381		
4		.0381			.0381	.0381	
5	.0381	.0381			.0381		
6	.0381	.0381		.0328	.0381		
7	.0381	.0381		.0328	.0381	.0381	
8	.0381	.0038	.0038	.0343	.0381	.0343	.0038
9	.0381	.0038	.0038	.0038		.0343	.0038
10	.0762	.0076	.0076	.0076		.0076	.0076
11	.0762	.0076	.0076	.0076		.0076	.0076
12	.0762	.0076	.0076	.0076		.0076	.0076
13	.0762	.0076	.0076	.0076		.0076	.0076
14	.0762	.0076	.0076	.0076		.0076	.0076
15		.0076	.0076	.0076		.0076	.0076
16		.0762	.0732	.0762		.0701	.0762
17		.0762	.0366	.0381		.0701	.0762
18			.0366	.0381		.0351	.0381
19			.0366	.0381		.0366	.0381
20			.0366	.0381		.0366	.0381
21			.0366	.0381		.0366	.0381
22			.0366	.0381		.0351	.0381
23			.0366	.0381		.0366	.0381
24	.0381	.0381		.0328	.0381	.0381	
Max	.0762	.0762	.0732	.0762	.0381	.0701	.0762
Min	.0381	.0038	.0038	.0038	.0381	.0076	.0038
Avg	.0517	.0284	.0239	.0279	.0381	.0308	.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 209 / Tondapur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.5623	1.3032	1.2346	1.3375	
10	1.7147	1.406	1.2689	1.4403	
11	1.829	1.4022	1.3032	1.5775	
12	1.6766	1.6804	1.3375	1.6804	
13	1.6385	1.5432	1.3032	1.6461	
14	1.6385	1.4746	1.3032	1.6118	
15	1.6004	1.2003	1.3032	1.5775	
16	1.5623	1.2826		1.7147	
21				1.1812	1.1431
22				1.1431	1.105
23				1.1812	1.1431
Max	1.829	1.6804	1.3375	1.7147	1.1431
Min	1.5623	1.2003	1.2346	1.1431	1.105
Avg	1.6528	1.4116	1.2934	1.4628	1.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 201 / 11KV BANOTI-AG- FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1812	1.4289	1.4098	1.9052	.8764	1.6004
2		1.1812	1.3336	1.4098	1.9052	.8764	1.5623
3		1.1812	1.2955	1.3336	1.9433	.9526	1.5242
4		1.2193	1.2955	1.3717	1.9433	1.0288	1.5242
5		1.2574	1.2955	1.448	1.9624	1.0669	1.5623
6		1.2955	1.4861	1.5242	1.9433	1.2574	1.6385
9	1.8099						
10	2.0195						
11	2.2291						
12	2.0957						
13	1.9052						
14	2.0576						
15	2.0195						
16	1.9433						
21	1.0669	1.3336	1.6004		1.2955	1.448	1.7147
22	1.1431	1.6004	1.7147	1.8671	1.2574	1.7909	2.0576
23	1.1812	1.6004	1.7528	1.8671	1.2193	1.7909	2.0576
24		1.1812	1.5242	1.6385	1.8861	1.1812	1.7147
Max	2.2291	1.6004	1.7528	1.8671	1.9624	1.7909	2.0576
Min	1.0669	1.1812	1.2955	1.3336	1.2193	.8764	1.5242
Avg	1.7701	1.3031	1.4727	1.5411	1.7261	1.2270	1.6957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 202 / 11 KV NANDGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859						
2	.6859						
3	.7621						
4	.8002						
5	.8764						
6	1.0288						
9		.9907	1.2384	1.0669	.9145	.6478	.9145
10		1.2955	1.4098	1.2574	1.2193	.7621	1.0288
11		1.5242	1.4098	1.448	1.2574	1.0288	1.0288
12		1.5623	1.6004	1.4861	1.2955	.9907	.9526
13			1.2574	1.3336	1.2574	.9145	.9907
14		.9907	1.2955	1.1431	1.0669	.7621	.9526
15			1.2574	1.0288	1.105	.7621	.9145
16		.8383	1.1812	.8764	.9526	.8383	
24	1.0288						
Max	1.0288	1.5623	1.6004	1.4861	1.2955	1.0288	1.0288
Min	.6859	.8383	1.1812	.8764	.9145	.6478	.9145
Avg	.8383	1.2003	1.3312	1.2050	1.1336	.8383	.9689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 203 / 11 K V WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1905	.1905	.4191	.0381	.2286
2		.1524	.1524	.1905	.4572	.0381	.1905
3		.1524	.1524	.2286	.4572	.0381	.1905
4		.1524	.1905	.2667	.4954	.0762	.2286
5		.1715	.2667	.3429	.4954	.0762	.2667
6		.2477	.381	.4572	.5335	.0762	.4191
9	.2858						
10	.3429						
11	.381						
12	.4572						
13	.4954						
14	.4763						
15	.4763						
16	.4763						
21	.1524	.1905	.2667	.3048		.2286	
22	.1334	.2286	.3048	.381		.2667	
23	.1524	.2667	.3048	.381	.0381	.3048	
24		.1524	.1905	.2667	.4001	.0381	.2667
Max	.4954	.2667	.381	.4572	.5335	.3048	.4191
Min	.1334	.1524	.1524	.1905	.0381	.0381	.1905
Avg	.3481	.1867	.2400	.3010	.412	.1181	.2558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 204 / 11 KV BANOTI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2096	.2096	.1905	.1905	.1905
2	.2286	.2286	.2096	.2286	.2096	.2286	.1905
3	.3429	.2286	.2477	.3048	.2286	.3429	.2286
4	.4191	.3429	.4763	.4954	.381	.4191	.3239
5	.6668	.5716	.724	.6859	.6478	.6859	.4572
6	.8764	.8383	.9145	.9145	.8192	.9145	.6287
7	.8002	.9335	.9526	1.0479	.8383	.8764	.6287
8	.5716	.7811	.7049	.724	.6668	.6859	.4763
9	.2286	.4572	.4572	.6668	.4572	.4191	.2477
10	.362	.3429	.3429	.5716	.3429	.3429	
11	.2477	.2286	.2667	.4954	.2096	.2286	
12	.1905	.1715	.2286	.381	.2096	.1905	.1715
13	.1715	.1334	.2096	.2477	.1905	.1524	.1524
14	.2096	.2096	.2096	.2286	.2096	.1524	.1905
15	.2286		.1524	.2477	.1905	.1334	.1905
16	.2667	.2096	.2286	.2477	.1905	.1524	
17	.4191	.2096	.2667	.3239	.3048		.1905
18	.5716	.5906	.4572	.4382	.4954	.3048	.3048
19	.7621	.7811	.8192	.6859		.5335	.6859
20	.5335	.6287	.6859	.5335	.6287		.4763
21	.381	.4191	.381	.4001	.4572	.3429	.2477
22	.3239	.381	.3048	.3239	.3429	.2858	.2477
23	.2858	.2667	.2286	.2286	.2667	.2096	.2096
24	.2286	.2286	.2286	.1905	.1905	.1905	.1905
Max	.8764	.9335	.9526	1.0479	.8383	.9145	.6859
Min	.1715	.1334	.1524	.1905	.1905	.1334	.1524
Avg	.3961	.4092	.4128	.4509	.3769	.3628	.3157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 205 / Hanumantkheda gaothan
feeder Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1715	.1143	.1143	.1524	.1905
2	.1524	.1715	.1715	.1334	.1334	.1905	.1715
3	.2286	.1715	.1905	.1524	.1524	.2286	.1905
4	.2667	.2096	.2286	.1905	.1905	.2667	.2286
5	.3048	.3048	.3239	.2286	.2286	.3429	.3048
6	.381	.4572	.4191	.3048	.3048	.381	.4763
7	.4191	.362	.4382	.4572	.5144	.4001	.4382
8	.3048	.4001	.362	.4191	.381	.3429	.2477
9	.2096	.2667	.3048	.362	.2667	.2667	.2477
10		.1524	.1143	.2858	.1524		.1905
11		.1143	.0762	.2477	.1143		.1524
12	.1334	.1334	.1143	.1905	.1143		.1334
13	.1143	.0953	.1334	.1334	.1143		
14	.1143	.1143	.1143	.1334	.1143	.1143	.1524
15	.1334		.1334	.1334	.0953	.0953	.1524
16	.1334	.1524	.1524	.1524	.1143	.1143	
17	.2667	.1905	.1905	.1715	.1524		
18	.3429	.3429		.2286	.2286	.1905	.1524
19	.3429	.362	.4191	.3048			.3048
20	.3048	.3429	.381	.2858	.3429		.3048
21	.2096	.2477	.2667	.2286	.1905	.2477	.2477
22	.1905	.2286	.2286	.2096	.2286	.2286	.2096
23	.1715	.1905	.2096	.1905	.2096	.2096	.1715
24	.1524	.1715	.1715	.1905	.1524	.1905	.1905
Max	.4191	.4572	.4382	.4572	.5144	.4001	.4763
Min	.1143	.0953	.0762	.1143	.0953	.0953	.1334
Avg	.2286	.2328	.2311	.2270	.2004	.2331	.2313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 206 / Wakdi Gaothan feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0381	.0381	.0381	.0572
2	.0381	.0381	.0572	.0381	.0381	.0381	.0572
3	.0762	.0381	.0572	.0762	.0762	.0762	.0572
4	.1143	.0762	.0762	.0953	.0953	.1143	.0762
5	.1334	.1524	.1334	.1905	.1905	.1524	.1524
6	.1905	.2286	.2667	.2667	.2477	.2667	.2858
7	.3048	.3048	.3048	.3048	.2667	.3429	.3048
8	.1143	.1524	.2096	.2096	.2286	.2286	.1905
9	.1143	.1143	.1715	.1905	.1143	.1715	.1334
10	.0762	.0572	.0762	.1143	.0762	.1143	.0762
11	.0381	.0381	.0572	.0953		.0762	.0572
12	.0381	.0381	.0381	.0762	.0572	.0572	.0381
13	.0381	.0381	.0381	.0572	.0381	.0572	.0381
14	.0191	.0381	.0572	.0381	.0572	.0572	.0572
15	.0381		.0572	.0572	.0762	.0762	.0572
16	.0572	.0381	.0572	.0572	.0762	.0762	
17	.0762	.0381	.0762	.0572	.0572		
18	.0953	.0953	.0953	.0762	.1143	.0953	.0572
19	.1905	.1905	.1905	.1524		.2096	.1905
20	.1524	.1905	.2286	.1524	.2096	.2096	.1905
21	.0953	.1143	.1143	.0953	.1143	.1334	.1143
22	.0953	.0953	.0762	.0953	.1143	.0953	.0953
23	.0762	.0762	.0381	.0572	.0762	.0762	
24	.0381	.0381	.0572	.0191	.0381	.0381	.0572
Max	.3048	.3048	.3048	.3048	.2667	.3429	.3048
Min	.0191	.0381	.0381	.0191	.0381	.0381	.0381
Avg	.0937	.0969	.1080	.1088	.1091	.1218	.1116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 207 / 11 KV GONDEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0098	1.1812	1.2193	1.2955	.7621	1.3336
2		1.0098	1.1431	1.2193	1.2955	.7621	1.2955
3		1.0288	1.1431	1.2574	1.3717	.8002	1.2574
4		1.0288	1.1431	1.2765	1.448	.8383	1.2574
5		1.0288	1.1812	1.2955	1.4861	.8764	1.2955
6		1.0669	1.4098	1.448	1.5242	.9526	1.448
9	1.2955						
10	1.4861						
11	1.5242			1.3717			
12	1.6385						
13	1.7337						
14	1.7528						
15	1.7147						
16	1.6385						
21	.8764	.9907	1.0669	1.0669		1.105	1.1431
22	1.0098	1.3336	1.3336	1.2574	.9145	1.4861	1.1812
23	1.0098	1.2955	1.2955	1.2574	.9526	1.5242	1.5242
24		1.0098	1.2193	1.2193	1.2765	.8764	1.448
Max	1.7528	1.3336	1.4098	1.448	1.5242	1.5242	1.5242
Min	.8764	.9907	1.0669	1.0669	.9145	.7621	1.1431
Avg	1.4255	1.0803	1.2117	1.2626	1.2850	.9983	1.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 208 / 11 K V HANUMANT KHEDA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383						
2	.8383						
3	.8764						
4	.9145						
5	.9526						
6	1.1812						
9		1.2193	1.2193	1.3336	1.2193		
10		1.5242	1.3336	1.4098	1.0669		
11		1.6385	1.5242	1.3717	1.0288		
12		1.7147	1.4098	1.3336	.9907	.6859	
13		1.6385	1.2955	1.1431	1.2955	.6859	
14		1.5242	1.4098	1.1431	1.105	.6097	
15			1.3336	1.1431	1.1431	.6097	.9145
16			1.2574	1.105	1.1431	.6478	
24	.9907						
Max	1.1812	1.7147	1.5242	1.4098	1.2955	.6859	.9145
Min	.8383	1.2193	1.2193	1.105	.9907	.6097	.9145
Avg	.9417	1.5432	1.3479	1.2479	1.1241	.6478	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 209 / 11 KV GONDEGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2477	.1905	.1905	.1905	.2667
2	.2667	.2286	.2477	.2286	.2286	.2286	.2667
3	.3048	.2286	.2667	.2667	.2667	.3048	.3048
4	.381	.3429	.3048	.3429	.3429	.381	.4572
5	.4954	.5335	.4572	.4572	.4572	.5335	.5716
6	.6859	.724	.724	.7621	.6859	.7621	.8002
7	.7621	.8764	.8002	.7621	.8002	.8002	.8383
8	.5716	.6287	.5716	.6097	.4954	.5335	.6097
9	.3048	.3429	.4572	.4954	.4191	.4191	.4572
10	.3048	.3429	.381	.4572	.3048	.381	.381
11	.3048	.3429	.3429	.4191		.381	.3048
12	.3048	.3048	.3048	.381	.381	.3429	.3048
13	.2667	.2286	.3048	.381	.381	.3048	.3429
14	.3429	.2667	.3429	.381	.381	.3048	.3048
15	.3239		.3048	.381	.3429	.3048	.3429
16	.3239	.3429	.3048		.3429	.3429	
17	.3429	.3429	.381	.3429	.381		.3048
18	.381	.4191	.4191	.3429	.5335	.4572	.4191
19	.5335	.6097	.5716	.4572		.6097	.4954
20	.4572	.6097	.5335	.4954	.6478	.6478	.6097
21	.381	.4572	.4572	.381	.2667	.5335	.4954
22	.3429	.4191	.381	.381	.3048	.4572	.4572
23	.2667	.3048	.2667	.3429	.2667	.4191	.3429
24	.2667	.2286	.2667	.2286	.3048	.1905	.2858
Max	.7621	.8764	.8002	.7621	.8002	.8002	.8383
Min	.1905	.2286	.2477	.1905	.1905	.1905	.2667
Avg	.3794	.4067	.4017	.4125	.3966	.4274	.4332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 210 / 11 KV Nandgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.1143	.1334	.1334	.1524	.1143
2	.1334	.1143	.1143	.1143	.1334	.1905	.1143
3	.1905	.1143	.1334	.1524	.1524	.2667	.1334
4	.2667	.1524	.1905	.2096	.2096	.3048	.1905
5	.3429	.1905	.2858	.2667	.2667	.3429	.2477
6	.4191	.3048	.381	.3429	.3429	.381	.4001
7	.4572	.3239	.4001	.381	.4191	.4191	.362
8	.3429	.3048	.362	.4191	.381	.381	.3048
9	.2667	.2286	.3429	.381	.3048	.1905	.2667
10	.2477	.1905	.1524	.3048	.1905	.1524	.2286
11		.1524	.1143	.2667	.1334	.1524	
12	.1905	.1524	.1143	.2286	.1524	.1143	.1524
13	.1715	.1334	.1143	.1905	.1334	.1143	
14	.1334	.1334	.1143	.1524	.1143	.1143	.1524
15	.1334		.1334	.1524	.1334	.1143	.1524
16	.1334	.1334	.1524	.1715	.1334	.1143	
17	.2286	.1905	.2096	.1905	.1524		.1524
18	.3048	.3048	.3048	.2286	.2667	.2096	.1905
19	.3239	.381	.4191	.3429		.4382	.3048
20	.2858	.4382	.381	.2858	.3429	.4001	.3048
21	.2096	.2096	.3048	.2286	.2286	.2858	.2667
22	.1905	.1905	.2667	.1905	.1905	.2286	.2286
23	.1524	.1524	.2286	.1524	.1524	.1715	***
24	.1905	.1334	.1143	.1905	.1334	.1524	.1334
Max	.4572	.4382	.4191	.4191	.4191	.4382	19.0329
Min	.1334	.1143	.1143	.1143	.1143	.1143	.1143
Avg	.2369	.2063	.2270	.2365	.2087	.2344	1.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 203 / 11 kv MOLKHEDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	19-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)
24	.4191	.4572
Max	.4191	.4572
Min	.4191	.4572
Avg	.4191	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 204 / 11 KV SAWALADBARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0762	.0953	.0953	.0953	.0953	.1143
Max	.0762	.0953	.0953	.0953	.0953	.1143
Min	.0762	.0953	.0953	.0953	.0953	.1143
Avg	.0762	.0953	.0953	.0953	.0953	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 201 / 11 KV KINHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.086	.9717	1.0288
2					1.086	.9717	1.0059
3					1.086	.9717	1.0059
4					1.086	.9717	1.0059
5					1.1241	.9717	.9945
6					1.1622	.9717	.9945
9	.4191	1.3375	1.1145	1.5089			
10	1.4089	1.5623	1.4419	1.6876			
11	1.4255	1.6385	1.4746	1.6575			
12	1.3592	1.7718	1.4754	1.9243			
13	1.358	1.829	1.5089	1.8099			
14	1.3748	1.5242	1.358	1.7718			
15	1.3757		1.3717	1.6194			
16	1.3032	1.4861	1.3889	1.6004			
21				1.105		.9431	1.3336
22				1.1431	.9717	1.1317	1.6575
23				1.1241	.9717	1.073	1.6385
24					1.105	.9717	1.0288
Max	1.4255	1.829	1.5089	1.9243	1.1622	1.1317	1.6575
Min	.4191	1.3375	1.1145	1.105	.9717	.9431	.9945
Avg	1.2531	1.5928	1.3917	1.5411	1.0754	.9950	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 202 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2477	.2477	.2477	.2286	.2477
2	.2286	.2477	.2477	.2477	.2477	.2286	.2477
3	.2286	.2858	.2477	.2858	.2858	.2667	.2858
4	.2667	.3429	.2858	.3429	.381	.3048	.3429
5	.362	.4024	.4191	.4024	.4382	.381	.4382
6	.6478	.6173	.6478	.6516	.6478	.5716	.6344
7	.6287	.6203	.5906	.6516	.6859	.5335	.5121
8	.5716	.5487	.4755	.5316	.4382	.2477	.439
9	.4191	.4207	.3658	.4755	.4382	.381	.439
10	.3292	.3048	.2286	.4207	.3239	.2096	.2858
11	.2241	.2667	.2286	.362	.2286	.1715	.2286
12	.2096	.2096	.1905	.2858	.1905	.1715	.2096
13	.1905	.2096	.1905	.2096	.1905	.1715	.2096
14	.1905	.2096	.1905	.2096	.1905	.1715	.2096
15	.2096		.2096	.2096	.1905	.1905	.2096
16	.2477	.1905	.2096		.2096	.2096	.2096
17	.3048	.1905	.2477	.2667	.2477		.2477
18	.4572	.4382	.3429	.3048	.362	.2477	.2858
19		.5906	.5316	.5335		.4973	.5716
20	.3601	.5716	.5083	.4382	.5144	.4572	.6287
21	.3239	.3429	.3658	.362	.3239	.3475	.5335
22	.3048	.3048	.3239	.2858	.2858	.3109	.3048
23	.2477	.2667	.2667	.2667	.2477	.2667	.2667
24	.2286	.2477	.2477	.2477	.2477	.2286	.2667
Max	.6478	.6203	.6478	.6516	.6859	.5716	.6344
Min	.1905	.1905	.1905	.2096	.1905	.1715	.2096
Avg	.3222	.3512	.3254	.3582	.3289	.2954	.3439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 203 / 11 KV WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.583	.6287	.6516	.0572	.0572	.0572
2	.6668	.583	.6478	.6516	.0572	.0572	.0572
3	.743	.6173	.6478	.6859	.0572	.0572	.0572
4	.743	.6173	.6668	.7202	.0572	.0572	.0572
5	.7811	.6706	.743	.7712	.0572	.0572	.0762
6	.8192	.7712	.9145	.8383	.0572	.0572	.0762
7	.0572	.0953	.0762	.0953	.0762	.0572	.0953
8	.0572	.0762	.0762	.0953	.0762	.0762	.1143
9	.0572	.0762	.0572	.0953	.7621	.4763	.6584
10	.0572	.0762	.0572	.0762	1.0098	.5906	.8764
11	.0572	.0572	.0572	.0572	1.1241	.6554	.9145
12	.0572	.0572	.0762	.0572	1.0098	.7537	.8954
13	.0762	.0572	.0572	.0381	.8002	.8097	.9145
14	.0572	.0572	.0572	.0572	.7621	.7287	.8764
15	.0572		.0762	.0572	.8002	.7373	.8954
16	.0572	.0572	.0762	.0762	.8192	.7373	.9335
17	.0572	.0572	.0572	.0762	.0572		.0572
18	.0953	.0762	.0572	.0762	.0572	.0762	.0572
19	.0572	.0762	.0762	.0762		.0762	.0572
20	.0572	.0762	.0953	.0762	.0572	.0762	.0572
21	.5487	.5716	.5144	.0762	.0572	.0572	
22	.583	.6287	.7202	.0572	.0572	.0572	
23	.5487	.6287	.6859	.0572	.0572	.0572	.0572
24	.6668	.583	.6287	.6859	.0572	.0572	.0572
Max	.8192	.7712	.9145	.8383	1.1241	.8097	.9335
Min	.0572	.0572	.0572	.0381	.0572	.0572	.0572
Avg	.3177	.3109	.3229	.2586	.3471	.2793	.3590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 201 / 11Kv Ghosla new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.4763	.3239	.3429	.3429
2		.3048	.381	.362	.381	.362
3		.2286	.362	.4191	.4572	.4001
4		.2667	.4572	.5144	.5144	.6478
5		.3048	.4954	.6097	.5906	.724
6		.4763	.5525	.7811	.743	.8192
7		.6478	.7621	.7621	.7621	.724
8		.4572	.6287	.5525	.4954	.5716
9		.381	.5525	.5335	.362	.6668
10	.3239	.3239	.4763	.9335	.5525	.724
11		.1905	.3239	.9907	.5525	.8383
12		.2096	.2286	1.1812	.6287	.7811
13	.2858	.2286	.2286	.9907	.6097	
14	.2667	.2286	.2096	.8954		.7811
15	.2286	.2477	.2286	.743		.6097
16	.2477	.2667	.2096	.8002		.6287
17	.2667		.2477	.2477		.2667
18	.381	.3239	.3239	.3429		.3239
19	.4954	.4191	.5716	.6097		.7621
20	.5525	.5335	.4572	.4954		
21	.2667	.4763	.4572			
22	.2477	.5716	.4001	.362		
23	.2858		.362	.3239		
24		.3048	.5335	.3239	.3048	.381
Max	.5525	.6478	.7621	1.1812	.7621	.8383
Min	.2286	.1905	.2096	.2477	.3048	.2667
Avg	.3207	.3481	.4136	.6130	.5212	.5976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 202 / 11Kv Bahulkheda new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3429	.4572		.6097
2		.362	.362	.4954		.6287
3		.381	.381	.5335		.5906
4		.4191	.4382	.6097		.724
5		.4572	.5144			.8002
6		.4954	.5716			.8954
7		.5335	.4572			.5335
8		.4763	.4572			.6478
9		.8383	.743		.5716	.5335
10	1.1812	.9526	.8954	.5335	.8764	.4191
11	1.2574	1.105	.9335	.5335	.9145	.4763
12	1.3336	1.0669	1.086	.5525	.4382	.4954
13	1.2574	1.0288	1.0288	.5525	.4954	.5525
14	1.2003	.9526	.9907	.5335		.5335
15	1.1431	.8954	.8573	.5335		.362
16	1.0288	.8383	.8192	.5525		.5525
17	.3239		.5716	.5716		.6668
18	.381	.362	.724			.6287
19	.4572	.381	.7811	.7811		.8573
20	.4382	.4001	.724	.7049		
21	.4001	.381	.5144			
22	.381	.4001	.5335	.6859		
23	.3429		.4572			
24		.3239	.3048	.4191		.5906
Max	1.3336	1.105	1.086	.7811	.9145	.8954
Min	.3239	.3239	.3048	.4191	.4382	.362
Avg	.7947	.6088	.6454	.5656	.6592	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 203 / 11Kv Jarandi new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.4001	.4191	.5906
2			.3239	.4382	.4572	.5335
3		.362	.3429	.4191	.4763	.6478
4		.4191	.4191	.4572	.5144	.724
5		.4954	.5335	.5144	.5716	.8002
6		.5525	.5906	.5525	.6287	.8383
7		.6097	.6097	.5716	.5525	.5716
8		.4382	.4763	.4382	.4382	.4572
9		.5906	.4572	.3239	.362	.3429
10	.743	.7049	.8002	.2858	.2477	.2667
11	.8192	.7811	.9335	.2096	.2286	.2286
12	.9145	.8192	.9907	.2667	.2286	.2477
13	.9335	.8573	.9526	.2477	.2286	.2858
14	.9145	.9145	.9335	.2667		
15	.7621	.8954	.8954	.2667		.2477
16	.6478	.8764	.8383	.2477		.2477
17	.2477		.2667	.2667		.2858
18	.3429	.3429	.3239	.3429		.3429
19	.4382	.381	.4763	.5144		.5525
20	.381	.4382	.4572	.4191		
21	.3429	.381	.4763			
22		.362	.4382	.4382		
23			.4191	.4191		
24			.2858	.381	.381	.6097
Max	.9335	.9145	.9907	.5716	.6287	.8383
Min	.2477	.3429	.2667	.2096	.2286	.2286
Avg	.6239	.5906	.5644	.3777	.4096	.4643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 201 / 11 KV WADALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5908	.5908	.5175	2.4	2.2892	2.8061
2	.5914	.5908	.6646	.5544	2.4	2.3631	2.8431
3	.6468	.7385	.7754	.7207	2.4738	2.4	2.88
4	.8871	.9785	.9415	1.0349		2.5107	2.9538
5	1.0903	1.1815	1.2	1.2567	2.6954	2.6215	3.0277
6	1.2197	1.2923	1.3108	1.3676	3.0277	2.8061	3.2123
7	1.3306	1.4769	1.44	1.4415	1.3661	1.1815	
8	1.1458	1.2554	1.2185	1.2197	1.2185	1.1261	.8123
9	3.0678	2.9907	2.88	3.1047	.8123	.96	.96
10	3.2895	2.6769	3.0092	3.6591	.5538	.5908	.5169
11	3.2861	2.8061	3.2895	3.4707	.2954	.5169	.3326
12	3.2861	2.88	3.3634	3.3969	.2585	.3323	.3142
13	3.1384	2.88	3.1602	3.1384	.24	.2954	.2587
14	2.6215	2.7507	3.0308	3.2123	.3323	.3323	.3326
15	2.9169		2.8645	3.2123	.2954	.3692	.3326
16	2.9907	2.8061	3.0678	3.2123	.3323	.3692	
17	.48	.3508	.3326	.4062	.3323		
18	.6277	.4431	.5359	.5538	.48		
19	1.2185	1.0338	1.1458	.96	.9785		
20	1.0708	1.2554	1.2752	1.0708	.96	1.1077	
21	.8492	.8492	.8316	2.5477	2.0308	3.2123	2.7536
22	.7385	.7385	.7392	2.5846	2.4369	3.0646	3.0678
23	.5908	.6646	.6283	2.5107	2.3446	2.9538	2.846
24	.5544	.5908	.6277	.5544	2.4369	2.3077	2.8061
Max	3.2895	2.9907	3.3634	3.6591	3.0277	3.2123	3.2123
Min	.48	.3508	.3326	.4062	.24	.2954	.2587
Avg	1.5914	1.4705	1.6218	1.9045	1.3348	1.6053	1.8365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 202 / 11KV NIMDONGRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3692	.3508	.3241	.96	1.1446	1.4031
2	.3601	.3692	.3508	.3421	.96	1.1815	1.3661
3	.3961	.4985	.48	.4321	.9785	1.2923	1.44
4	.5221	.6461	.6277	.6301	.9969	1.5138	1.5692
5	.6301	.7938	.7754	.7382	1.1446	1.7538	1.6984
6	.8102	.9415	.8861	.8642	1.44	1.9384	1.8461
7	.9542	.9046	.96	.9182	.8677	.8861	.8861
8	.4681	.48	.4431	.5041	.4246	.4431	.4615
9	1.6564	1.4769	1.5877	1.5123	.48	.5169	.4615
10	1.7824	1.8092	1.6615		.3877	.2954	.3323
11	1.8461	1.8092	1.8184	1.9015	.24	.2031	.1655
12	1.7538	1.8461	1.6564	1.7908	.1846	.1846	
13	1.6246	1.6984	1.6204	1.7723	.1662		
14	1.5508	1.4769	1.8724	1.6615	.2031	.2031	
15	1.5877	1.5138	1.6744	1.7354	.1846	.2031	
16	1.6246	1.5877	1.6564	1.7908	.2031	.2031	.2022
17	.2585	.1846	.198	.24	.2215	.2031	.2926
18	.3508	.2769	.2521	.2585	.2585	.2215	.3292
19	.5723	.4985	.5401	.5169	.4985	.5723	.567
20	.4615	.72	.5941	.5169	.48		.695
21	.48	.5354	.5041	1.0708	1.2	1.5323	1.701
22	.4431	.48	.4501	1.0154	1.3661	1.5323	1.8937
23	.3877	.3877	.3601	.9969	1.2554	1.5877	1.5664
24		.3692	.3692	.3241	.9969	1.2	1.4031
Max	1.8461	1.8461	1.8724	1.9015	1.44	1.9384	1.8937
Min	.2585	.1846	.198	.24	.1662	.1846	.1655
Avg	.9079	.9031	.9037	.9503	.6708	.8551	1.014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 203 / 11 KV NANDGIRWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.7196	.9488	.8596	.4924	.4554	.5303
2	.8417	.7196	.9108	.8775	.4734	.4364	.5303
3	.8954	.7575	.9678	.9313	.5303	.5503	.6249
4	.9671	.8333	1.0247	.985	.6249	.6831	.7764
5	1.0745	.9469	1.1006	1.0566	.8143	.797	.8901
6	1.182	1.0984	1.1765	1.182	1.0605	.9488	.9848
7	.9134	.909	1.0057	.8417	.909	.8349	.9848
8	.6805	.7764	.797	.7164	.6818	.6831	.7386
9	.5731	.606	.5882	.6268	1.2499	1.0816	1.1931
10	.4298	.4373	.4175	.5373	1.4232	1.1955	1.2688
11		.3323	.3045	.5492	1.3663	1.2878	1.219
12	.3788	.303	.2686	.4166	1.4422	1.212	1.1645
13	.303	.2846	.2328	.3598	1.3473	1.1931	1.1281
14	.2841	.2651	.2328	.3409	1.2714	1.0416	1.0007
15	.303		.3045	.3409	1.2524	1.1552	1.0802
16	.3219	.3219	.3403	.3219	1.3473	1.1363	
17	.3788	.3138	.3045	.3598	.3226	.4356	
18		.4166	.394	.3977	.4175	.3977	
19		.6249	.6089	.6249	.6452	.606	
20	.5871	.7021	.6447	.7007	.6831	.7007	
21	.7196	.8711	.7522	.5871	.5882	.5681	.6368
22	.8711	1.1385	1.1283	.5681	.5503	.5681	.6004
23	.7954	1.0057	1.0208	.5303	.5123	.5113	.543
24	.8954	.7196	.9848	.9313	.4924	.4934	.5303
Max	1.182	1.1385	1.1765	1.182	1.4422	1.2878	1.2688
Min	.2841	.2651	.2328	.3219	.3226	.3977	.5303
Avg	.6788	.6567	.6858	.6518	.8541	.7905	.8645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 204 / 11KV HIWARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.336	1.4851	1.9095	1.4785	.9204	.884	.9558
2	1.4073	1.4498	1.768	1.5142	.885	.9194	.9558
3	1.4429		1.7503	1.6032	.9558	1.0608	1.0266
4	1.5498		1.768	1.7457	1.0266	1.1846	1.1151
5	1.6032		1.8564	1.8348	1.1859	1.273	1.2213
6	1.6745		1.9271	1.6389	1.4159	1.3791	1.2744
7	1.4607		1.326	1.4073	1.5044	1.5205	1.4336
8	1.3716		1.0962	1.2113	1.292	1.273	1.0974
9	1.1044		.9547		1.8407	1.8211	1.7699
10	.8551		.7956	1.0332	2.3161	1.9802	1.8938
11	.7072		.6235	.8319	2.2631	1.9115	1.6363
12	.6188		.6413	.7788	2.21	1.9115	1.6375
13	.5834			.7788	1.9979	1.7876	1.6278
14	.6188		.5344	.7788	1.8034	1.6814	1.6461
15	.7072		.6235	.7426	1.768	1.5044	
16	.7603	.8133	.5878	.7434	1.8564	1.5221	
17	.8133	.884	.7304	.8673	.7956	.708	
18	.9547	.9724	.8194	.9027	.884	.7611	
19		1.1328	1.0722	1.0797	1.1492	1.1328	
20	.9901	1.1139	1.1757	1.0974	1.0785	1.2213	
21	1.2553	1.5205	1.5854	1.0089	1.0078	1.0089	1.1163
22	1.6973	2.2124	1.9595	.9735	1.0078	.9912	1.0425
23	1.6443	1.9979	1.7814	.9381	.9194	.9912	1.0332
24	1.4785	1.4851	1.9625	1.621	.9204	.9017	.9558
Max	1.6973	2.2124	1.9625	1.8348	2.3161	1.9802	1.8938
Min	.5834	.8133	.5344	.7426	.7956	.708	.9558
Avg	1.1580	1.3697	1.2717	1.1570	1.3752	1.3054	1.3022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 205 / 11KV BAHIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7541	1.448	1.9243	1.7164	.8573	.8764	.9145
2	1.7918	1.4098	1.9052	1.7353	.8573	.8573	.9145
3	1.8484	1.4098	1.9433	1.7918	1.0098	.9526	1.0669
4	1.9805	1.5242	2.0195	1.8861	1.1622	1.1812	1.1812
5	2.037	1.6766	2.0957	1.9427	1.3146	1.4098	1.4098
6	2.2445	1.7528	2.1529	2.0182	1.5051	1.6004	1.5813
7	1.5466		1.5051	1.5278	1.6004	1.5051	1.7909
8	1.2449		1.3527	1.3957	1.2574	1.3146	1.3908
9	.9997	1.086	1.086	1.1506	1.7528	1.9243	1.9624
10	.7733	.8573	.6668	.5658	2.1338	2.0195	2.0195
11	.4763		.4527	.7811	2.191	2.2672	2.0936
12	.362		.4527	.7811	2.1529	.6097	2.0748
13	.4572	.5335	.3772	.6668	2.3243	1.9433	1.9805
14	.4191	.5716	.3961	.6097	2.191	1.9814	1.9993
15	.4763	.5906	.5281	.6097	2.21	2.0195	1.9805
16	.5144	.6097	.6036	.6859	2.191	1.5242	1.8484
17		.6668	.6979	.6668	.6097	.6097	.6979
18	.743	.8002	.7922	.8383	.724	.7621	.8865
19	1.1812	1.0479	1.1128	1.0479	1.0669	1.1812	1.1506
20	1.0479	1.2003	1.226	1.0669		1.2765	1.2826
21	1.5813	1.7147	1.7918	.9717	1.1431	1.0479	.9808
22	1.5813	1.8671	2.037	.9717	1.105	1.086	1.0185
23	1.4861	1.9243	1.9805	.9145	.9335	.9717	.811
24	1.905	1.448	1.9052	1.8484	.8573	.8764	.9335
Max	2.2445	1.9243	2.1529	2.0182	2.3243	2.2672	2.0936
Min	.362	.5335	.3772	.5658	.6097	.6097	.6979
Avg	1.2370	1.2070	1.2919	1.1746	1.4413	1.3249	1.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 201 / 11 KV WADNER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0856	.853	1.0869	1.2269	.0775		.0526
2	1.0856	.853	1.0869	1.2269	.0775		.0526
3	1.0856	.853	1.1646	1.2269	.0775		.0526
4	1.0856	.853	1.1646	1.3146	.0775		.0701
5	1.1631	.9305	1.1646	1.4022	.0775		.0876
6	1.2407	1.008	1.1646	1.4022	.0775		.0876
7	.0775	.0775	.0776	.0876	.0775		.0876
8	.0775	.0775	.0776	.0876	.0775		.0775
9	.0775	.0775	.0776		1.1603		1.0856
10		.0775	.0776	.0876	1.3957		1.3182
11		.0776	.0876	.0775	1.3975		1.3182
12		.0466	.0351	.0775	1.5527		1.3957
13			.0701	.0775	1.4751	1.2269	1.5508
14		.0311	.0351	.0775	1.5527		1.4733
15		.0311	.0701	.0775	1.5527	1.2269	1.4733
16		.0311	.0876	.0775	1.4751	1.6651	1.3957
17		.0776	.0876	.0775	.0311	.0526	.0775
18	.0775	.0776	.1753		.0311	.0526	.0775
19	.0775	.0776	.1402	.0775	.0311	.0351	.0775
20	.0876	.0776	.1402	.0876		.0351	.0775
21	.4382	.854	1.0517	.0876		.0876	.0876
22	.8764	1.0093	1.2269	.0876		.0701	.0876
23	.964	1.1646	1.3146	.0876		.0701	.0876
24	1.0856	.853	1.1646	1.2269	.0775		.0351
Max	1.2407	1.1646	1.3146	1.4022	1.5527	1.6651	1.5508
Min	.0775	.0311	.0351	.0775	.0311	.0351	.0351
Avg	.6616	.4378	.5346	.4664	.6176	.4522	.5078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 202 / 11 KV AMBA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8645	.9478	.8764	.0786	.1137	.1578
2	.9431	.8645	.9478	.8764	.0786	.1137	.1578
3	.9431	.8645	.9858	.9114	.0786	.0948	.1753
4	1.0217	.8645	1.0426	1.0517	.0786	.0948	.1753
5	1.1003	.9431	1.2322	1.3146	.0786	.0948	.2279
6	1.1003	1.1003	1.327	1.3146	.0786	.1137	.2279
7	.0786	.0786	.1137	.0876	.0786	.1137	.2103
8	.0786	.0786	.1137	.1402	.0786	.0948	.1886
9	.0786	.0786	.0948		.0786	.7583	1.1003
10	.0786	.0786	.0951	.0876	1.4146	.9858	1.1003
11	.0786	.0948	.0876	.1257	1.8957	1.0517	1.1003
12	.0786	.0776	.1402	.0786	1.2322	1.1393	1.2574
13	.0786	.0948	.0876	.0786	1.327	1.3146	1.2574
14	.0786	.0948	.1052	.0786	1.1374	1.0517	1.1788
15	.0786	.0948	.1052	.0786	1.4218	1.0517	1.1003
16	.0786		.1402	.0786	1.4218	1.2269	1.0217
17	.0786	.0948	.1402	.0786	.0948	.0876	.0786
18	.0786	.1137	.1753	.0786	.0948	.0876	.0786
19	.0786	.1327	.2103	.0786	.0948	.0876	.0786
20	.0876	.1327	.1753	.0876	.0948	.0876	.0786
21	.7888	.8531	.8764	.0876	.0948	.0876	.0876
22	.964	.9099	.8764	.0876	.0948	.1402	.0876
23	.964	.9478	.8764	.0876	.0948	.1753	.0876
24	.9431	.8645	.9478	.8764	.0786	.0948	.1402
Max	1.1003	1.1003	1.327	1.3146	1.8957	1.3146	1.2574
Min	.0786	.0776	.0876	.0786	.0786	.0876	.0786
Avg	.4509	.4488	.4935	.3757	.4708	.4276	.4731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 203 / 11 KV KOLWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0774	.0774	.0465	.0351	.8509	.7745	.8764
2	.0774	.0774	.0465	.0351	.8509	.7745	.8764
3	.0786	.0774	.0465	.0351	.8509	.7745	.8764
4	.0774		.062	.0351	.9282	.8054	.929
5	.0774	.0774	.0774	.0351	1.0829	.8519	1.0517
6	.0774	.0774	.0774	.0351	1.1603	.8984	1.0517
7	.0774	.0774	.0774	.0876		.0774	.0876
8	.0774	.0774	.0774	.0876		.031	.0774
9	.6962	.7735	.8519			.031	.0774
10	.9282	.8509	1.0842	1.0517		.0465	.0774
11	1.1603	1.0068	1.3146	.9282		.0351	.0774
12		1.166	1.3146	1.2376		.0351	.0774
13	1.0056	1.0842	1.3146	1.0829		.0351	.0774
14	1.0056	1.0842	1.2269	1.1603	.031	.0351	.0774
15	1.0829	1.0068	1.2269	1.1603	.0465	.0351	.0774
16	1.0829	.9294	1.1393	1.0056	.0465	.0351	.0774
17	.0774	.031	.0876	.0774	.0465	.0876	.0774
18	.0774	.031	.0526	.0774	.0465	.0876	
19	.0774	.0774	.0526	.0774	.062	.0876	.0774
20	.0876	.0774	.0876	.0876	.062	.7888	.0774
21	.0876	.0774	.0876	.3506	.3872	.4382	.4382
22	.0876	.031	.0701	.8764	.7745	1.0517	.964
23	.0876	.031	.0701	.8764	.7745	1.0517	.964
24	.0774	.0774	.0465	.0701	.8509	.7745	1.1393
Max	1.1603	1.166	1.3146	1.2376	1.1603	1.0517	1.1393
Min	.0774	.031	.0465	.0351	.031	.031	.0774
Avg	.3584	.3860	.4391	.4568	.5207	.4018	.4428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 204 / 11 KV MUNDWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0876	.0943	.1052	.8939	.0526	1.1393
2	.0876	.0876	.0943	.1402	.964	.0526	1.1393
3	.0876	.0876	.0943	.1052	.964	.0526	1.1919
4	.1227	.0876	.1132	.1578	1.0517	.0876	1.2269
5	.1402	.1227	.1698	.3155	1.3146	.0876	1.3146
6	.1578	.1402	.1509	.3506	1.4198	.0876	1.2971
7	.0876	.1578	.132	.3506	.0876	.0351	.1402
8	.0876	.1052	.1227	.3681	.0876	.0175	.3155
9	1.0517	1.0692	1.0166		.0876	.0351	.3506
10	1.3672	1.1744	1.3146	1.3496	.0876	.0876	.0774
11	1.4022	1.3672	1.4022	1.56	.0876	.0876	.0876
12	1.4548	1.4899	1.5249	1.6301	.0876	.1753	.0876
13	1.4198	1.4373	1.4022	1.2094	.0876	.2804	.0876
14	1.3146	1.3146	1.3321	1.3146	.0876	.2279	.0876
15	1.3146	1.3146	1.2269	1.5424	.0876	.2279	.0876
16	1.3847	1.262	1.2269	1.4723	.0876	.2279	.0876
17	.0876	.0876	.1402	.0876	.1052	.3155	.0876
18	.0876	.1052		.0876	.1402	.3506	.0876
19	.0876	.1402		.0876	.1402	.1753	.0876
20	.0876	.1227	.2804	.0876		.1753	.0876
21	.0876	.1052	.2804	.6661		.7888	.8063
22	.0876	.0876	.2103	.7712	.0701	1.2269	.9991
23	.0876	.0876	.2103	.8413	.0526	1.262	1.0867
24	.0876	.0876	.0876	.1402	.8589	.0876	1.1393
Max	1.4548	1.4899	1.5249	1.6301	1.4198	1.262	1.3146
Min	.0876	.0876	.0876	.0876	.0526	.0175	.0774
Avg	.5112	.5054	.5740	.6409	.4023	.2585	.5458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 205 / 11KV WADNER GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3219	.2841	.303	.2804	.3409	.3219	.2629
2	.3219	.2841	.303	.2804	.3409	.3219	.2629
3	.3788	.3409	.2841	.2804	.3977	.3219	.2804
4	.7386	.4734	.3788	.4207	.6628	.6439	.4207
5	1.0226	.7954	.6439	.7011	.8522	.8333	.7362
6	1.212	1.0984	.909	.9991	1.0605	.9848	.9816
7	1.0794	1.1363	.9469	.929	1.0984	.9848	.9991
8	.9469	.9658	.7764	.8238	.8333	.7386	.8901
9	.7196	.7764	.5303		.6439	.5681	.5303
10	.3788	.3977	.2083	.5258	.3409	.303	
11	.2083	.1894	.1052	.3788	.2083	.1402	
12	.1515	.0947	.1227	.303	.1136	.1052	
13	.1326	.0947	.1227	.2083	.1326	.1052	
14	.1326	.0947	.0876	.2083	.1326	.1052	.1326
15	.1326	.1136	.0876	.2083	.1326	.0876	.1515
16	.1894	.1704	.0876	.2462	.1515	.1227	.1515
17	.3977	.1894	.3155		.2651	.2629	.2651
18	.6439	.3409		.5681	.5113	.4382	.3977
19	.7954	.7007	.6135	.7575	.6818	.6485	.7196
20	.5434	.6439	.7362	.5609	.5681	.6661	.8333
21	.4908	.4356	.5258	.4733	.4924	.4733	.5434
22	.3681	.3788	.4207	.4207	.3598	.4031	.4207
23	.298	.303	.3155	.3155	.3219	.2804	.298
24	.3409	.2841	.303	.2804	.3409	.3219	.2629
Max	1.212	1.1363	.9469	.9991	1.0984	.9848	.9991
Min	.1326	.0947	.0876	.2083	.1136	.0876	.1326
Avg	.4977	.4411	.3968	.4623	.4577	.4243	.4770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 206 / 11KV KOLWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.114	.095	.095	.0876	.095	.057	.1052
2	.114	.095	.095	.0876	.095	.057	.1052
3	.171	.152	.114	.0876	.152	.057	.1052
4	.2659	.2469	.1899	.1753	.2469	.095	.1928
5	.3609	.3419	.2659	.298	.3229	.1899	.298
6	.4369	.3799	.4179	.3856	.3799	.2849	.3681
7	.3989	.3989	.3799	.2629	.3609	.2469	.298
8	.3229	.2849	.2659	.2804	.2279		.2279
9	.171	.152	.133		.171	.1899	.133
10	.095	.095	.095	.1402	.133	.133	.095
11	.038	.057	.0526	.133	.076	.0701	.076
12	.057	.038	.0351	.133	.076	.0701	.057
13	.038	.038	.0526	.076	.057	.0351	.057
14	.038		.0526	.057	.038	.0526	.057
15	.038	.038	.0526	.057	.057	.0526	.057
16	.057	.038	.0701	.076	.057	.0351	.076
17	.076	.057	.0526	.114	.076	.0701	.076
18	.2089	.114	.0876	.171	.133	.1052	.114
19	.2659	.2279	.2804	.2659	.2659	.2279	.1899
20	.1402	.2469	.1928	.2103	.171	.1227	.2469
21	.1227	.133	.1227	.1402	.095	.1052	.1402
22	.1052	.114	.1227	.1052	.076	.1052	.1227
23	.0876		.0876	.0876	.076	.1052	.1052
24	.114	.095	.095	.0876	.095	.057	.1052
Max	.4369	.3989	.4179	.3856	.3799	.2849	.3681
Min	.038	.038	.0351	.057	.038	.0351	.057
Avg	.1599	.1563	.1420	.153	.1472	.1098	.1420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 207 / 11KV AMBA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1509	.1294	.1227	.1478	.1478	.1402
2	.1663	.1478		.1227	.1478	.1478	.1402
3	.2033	.1848		.1402	.2402	.1478	.1402
4	.2772	.2772	.1478	.1753	.3326	.1848	.1928
5	.3696	.3696	.2587	.2454	.3881	.2587	.2629
6	.4066	.4251	.3881	.4557	.4435	.4251	.4031
7	.4805	.4805	.4805	.4557	.462	.4251	.4382
8	.4435	.3881	.4251	.3155	.3142	.2587	.3881
9	.1663	.2957	.2957		.2587	.2402	.2033
10	.0924	.2033	.1663	.1753	.1478	.1109	.1294
11	.0739	.0924	.1052	.2218	.1109	.0701	.0924
12	.0924	.0924	.0876	.1478		.0351	.0739
13	.0924	.0924	.0876	.1109		.0175	
14	.0739	.0739	.0701	.1109	.0554	.0351	
15	.0924	.0739	.0701	.1294	.0739	.0526	
16	.0924	.0739	.0876	.1109	.0924	.0876	
17	.1663	.1109	.1227	.1663	.1109	.1402	
18	.2587	.2033	.1753	.2957	.1928	.1928	.1663
19	.3326	.3696	.333	.3326	.3511	.298	.2587
20	.2279	.3142	.298	.2103		.2454	.3511
21	.1928	.2033	.1928	.1928	.2218	.1928	.1928
22	.1402	.1663	.1753	.1753	.1848	.1578	.1578
23	.1402	.1294	.1227	.1402	.1478	.1402	.1578
24	.1478	.1478	.1294	.1227	.1478	.1478	.1402
Max	.4805	.4805	.4805	.4557	.462	.4251	.4382
Min	.0739	.0739	.0701	.1109	.0554	.0175	.0739
Avg	.2032	.2111	.1977	.2033	.2177	.1733	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 208 / 11KV KALIMATH GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0351	.0377	.0377	.0351
2	.0377	.0377	.0377	.0351	.0377	.0377	.0351
3	.0566	.0566	.0377	.0351	.0566	.0377	.0351
4	.0943	.0754	.0754	.0701	.0754	.0566	.0701
5	.132	.1132	.0943	.1052	.1132	.0754	.1227
6	.132	.1509	.132	.1227	.1509	.132	.1402
7	.1509	.132	.132	.1227	.132	.1509	.1227
8	.1132	.1132	.132	.1052	.1132	.0943	.1132
9	.0943	.1132	.0943		.0943	.1132	.0943
10	.0754	.0754	.0566	.0876	.0566	.0754	.0566
11	.0189	.0377	.0175	.0754	.0189	.0175	.0377
12	.0189	.0189	.0175	.0566	.0189	.0175	.0189
13	.0189	.0189	.0175	.0377	.0189	.0175	.0189
14	.0189	.0189	.0175	.0189	.0189	.0175	.0189
15	.0189	.0189	.0175	.0189	.0189	.0175	.0189
16	.0189	.0189	.0351	.0189	.0189	.0175	.0189
17	.0377	.0189	.0351	.0377	.0189	.0175	.0189
18	.0754	.0377	.0351	.0943	.0377	.0351	.0377
19	.1132	.1132	.1402	.0943	.0943	.1052	.0943
20	.0701	.0943	.1052	.0701	.0754	.0876	.1132
21	.0526	.0566	.0526	.0526	.0566	.0701	.0526
22	.0351	.0566	.0526	.0526	.0566	.0351	.0526
23	.0351	.0377	.0351	.0351	.0377	.0351	.0351
24	.0377	.0377	.0377	.0351	.0377	.0377	.0351
Max	.1509	.1509	.1402	.1227	.1509	.1509	.1402
Min	.0189	.0189	.0175	.0189	.0189	.0175	.0189
Avg	.0623	.0621	.0602	.0616	.0582	.0558	.0582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 201 / 11KV HATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.5068	.3982	.4163	.3601	.3429	.4424
2	.5068	.5068	.4344	.4706	.3429	.3772	.4588
3	.543	.5792	.5792	.5121	.3429	.4115	.4915
4	.8869	.6516	.6516		.4801	.4458	.5898
5	1.1584	.8596	.9313		.6173	.6859	.6554
6	1.4632	1.3611	1.2894	1.448	1.046	.9602	1.1142
7	1.5203	1.5043	1.576	1.5203	1.406	1.4403	1.5203
8	1.448	1.3611	1.3611	1.3032	1.2346	1.2346	1.3032
9	.9175	.7773	.7773	.7865	.4973	.9602	.9313
10	.9393	.8421	.7209	1.0974	.4801	.905	.724
11	.9069	.6478	.7209	.9774	.4801	.4961	.4344
12	.8421	.6882	.7461	.9259	.4115	.5068	.5068
13	.8192	.6554	.6554	.8916	.4287	.5068	.4706
14	.7773	.5898	.5898	.7888	.4115	.5068	.4344
15	.8192	.6154	.5898	.703	.4115		.3982
16	.7865	.5898	.6554	.8573	.4287		.3982
17	.5068	.4344	.6878	.4115	.4458	.6516	.4344
18	.6516	.5792	.5792	.6859	.5658	.724	.5792
19	1.0029	1.0029	.9412	.9602	.8916	1.1584	1.0029
20	.9313	.8596	1.0136	.8745	.9602	.9412	1.0745
21	.788	.724	.7964	.4458	.3429	.7209	
22	.6516	.6516	.5792	.4287	.3429	.7209	.5506
23	.6154	.5068	.5068	.4287	.3601	.5243	.583
24	.4525	.5792	.4344	.4163	.3944	.3429	.4578
Max	1.5203	1.5043	1.576	1.5203	1.406	1.4403	1.5203
Min	.4525	.4344	.3982	.4115	.3429	.3429	.3982
Avg	.8502	.7531	.7590	.7886	.5701	.7075	.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 202 / 11 KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2347	.218	.213	.2743	.2743	.2172
2	.2785	.2683	.2515	.2294	.2915	.2743	.2353
3	.3113	.2984	.2515	.2458	.3258	.2915	.2534
4	.3932	.3812	.2347	.2949	.4287	.3258	.2896
5	.4588	.4641	.3812	.3441	.6001	.5144	.5959
6	.6882	.639	.6062	.6882	.8402	.7545	.8326
7	.6554	.788	.6878	.5735	.8916	.7545	.9231
8	.6516	.7421	.6335	.6516	.583	.5316	.6335
9	.6335	.6335	.5249	.6516	.4973	.4115	.4024
10	.4344	.3982	.3258	.6001	.6859	.3277	.5407
11	.3077	.2353	.2534	.583	.3258	.5079	.4752
12	.2353	.181	.1991	.4287	.5658	.4915	.502
13	.2715	.1463	.1629	.3086	.5658	.4752	.4096
14	.2896	.1097	.181	.2743	.583	.3768	.3605
15	.2353	.128	.1646	.2572	.4973	.3932	.3932
16	.181	.1646	.1629	.2229	.5487	.4424	.421
17	.1991	.2012	.181	.2058	.1372	.1227	.181
18	.2896	.3258	.3077	.2572	.2743	.2172	.2172
19	.6154	.543	.6401	.463	.463	.5792	.543
20	.5611	.5792	.5973	.4801	.5144	.5068	.5068
21	.2486	.218	.2622	.3772	.4115	.3801	.4525
22	.2321	.2515	.3277	.3429	.3429	.3113	.3801
23	.2515	.2515	.2458	.3086	.2915	.3077	.3258
24	.2622	.2515	.2347	.2294	.2743	.2915	.2172
Max	.6882	.788	.6878	.6882	.8916	.7545	.9231
Min	.181	.1097	.1629	.2058	.1372	.1227	.181
Avg	.3728	.3514	.3348	.3846	.4672	.4110	.4295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 203 / 11 KV TAPARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0972	1.9524	1.7924	2.0317	.5316	.463	.5068
2	2.0481	1.9685	1.7284	2.0153	.583	.5144	.5249
3	1.9662	1.9364	1.7604	1.9662	.6516	.6001	.543
4	1.9006	1.9204	1.6804	1.8842	.7716	.6516	.7602
5	1.8515	1.9524	1.8884	1.9334	.8916	.8059	1.0317
6	2.0645	1.9204	2.0005	2.13	.9431	.9945	1.1222
7	.6335	.7059	.5611	.5973	.823	.703	.7602
8	.7796	.788	.8775	.5792	.6173	.6687	.6335
9	.7602	.6878	.7421	.7783	2.4348	.4287	2.2725
10	.6697	.6335	.6154	.6516	2.4691		2.5926
11	.5258	.4706	.5068	.7202	2.5034	1.9662	
12	.5249	.4344	.5249	.6516	2.452	2.2119	2.3365
13	.4887	.3982		.5658	2.4006	2.2283	2.3685
14	.4525	.3801		.5487	2.1605	2.2283	2.3205
15	.4706	.4525		.5316	2.5206	2.3102	2.3365
16	.4525	.4887	.6154	.583	2.4691	2.3758	2.3045
17	.5068	.4887	.5973	.6516	.3258	.3982	.3982
18	.6154	.6335	.5792	.6173	.4287	.4344	.4344
19	.7701	.8238	.724	.823		.724	.8238
20	.6878	.7522	.6697	.7888		.7421	.8954
21	1.8724	1.7924	1.8023	.703	.703	.7602	.8596
22	1.9685	1.8244	2.0481	.6516	.6344	.7602	.8059
23	1.9524	1.7924	2.0809	.6001	.5316	.6697	.7522
24	2.13	1.9204	1.7604	2.0317	.5658	.463	.5068
Max	2.13	1.9685	2.0809	2.13	2.5206	2.3758	2.5926
Min	.4525	.3801	.5068	.5316	.3258	.3982	.3982
Avg	1.1746	1.1299	1.2169	1.0431	1.2915	1.0479	1.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 204 / 11 KV JAITAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2715	.2353	.2172	1.3375	1.3546	1.4255
2	.3258	.3077	.2715	.2353	1.3032	1.3203	1.4091
3	.362	.3439	.3439	.2896	1.2346	1.2003	1.3927
4	.5068	.4163	.362	.3801	1.3375	1.1831	1.3763
5	.5792	.5068	.4706	.4887	1.4232	1.286	1.3927
6	.543	.5611	.543	.543	1.5947	1.4575	1.5565
7	.4706	.5609	.5792	.5792	.3772	.4458	.2534
8	.2896	.3982	.4163	.362	.2915	.3944	.2353
9	1.5074	1.6004	1.5844	1.5402	.2058	.3258	.2534
10	1.4243	1.5844	1.4413	1.6975	.1715	.2534	.181
11	1.3763	1.4563	1.4582	1.6118	.1029	.1448	.1463
12	1.4243	1.3763	1.4255	1.5432	.1029	.1086	.128
13	1.3443	1.2963	1.4255	1.4403	.1029	.1086	.128
14	1.2643	1.3603	1.4091	1.4575	.1029	.1267	.1646
15	1.2803	1.2963	1.3108	1.4746	.1543	.1267	.1463
16	1.247	1.2146	1.4091	1.5261	.12	.1448	.1646
17	.1463	.1463	.1991	.1715	.2058	.181	.1646
18	.2353	.2353	.181	.1886	.2401	.181	.2172
19	.4163	.3439	.4163	.4115		.4163	.4344
20	.3801	.4706	.3932	.3772	.3944	.4344	.3982
21	.3439	.3258	.3439	1.3032	1.0802	1.3927	1.3123
22	.2896	.3077	.3475	1.3717	1.3203	1.6876	1.3763
23	.2534	.2715	.3439	1.4403	1.4575	1.4419	1.4243
24	.3109	.2715	.2534	.3439	1.3717	1.406	1.4091
Max	1.5074	1.6004	1.5844	1.6975	1.5947	1.6876	1.5565
Min	.1463	.1463	.181	.1715	.1029	.1086	.128
Avg	.6929	.7052	.7152	.8748	.6971	.7134	.7121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 201 / 11KV JEHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.4763	.4763	.3605	.3441	.3125	.5937
2	.6224	.4954	.5525	.4572	.3479	.3125	.6097
3	.6413	.5335	.5716	.5571	.3887	.3479	.7373
4	.724	.6478	.724	.639	.4096	.4534	.8421
5	.8299	.8573	.8573	.9145	.4752	.5182	.9061
6	1.0562	1.0669	1.0669	.9374	.5624	.6718	.9686
7	1.086	1.105	.9907	1.1241	1.0288	.9145	
8	.8002	.9335	.8192	.9717	.8192	.7621	.7049
9	.6562	.503	.5335		.6097	.6287	.4954
10	.7186	.6249	.7125	.8356	.4572	.4572	.3429
11	.6859	.5944	.6958	.6882		.3239	
12	.5624	.5468	.6154	.6133		.3048	.2286
13	.5556	.4877	.5601	.7621		.3239	.3239
14	.5182	.4687	.5344	.6226	.381	.3239	.2858
15	.5668	.503	.4586	.5571	.3239	.3429	.2858
16	.5182	.5639	.5992	.6478	.362	.3048	.3429
17	.2778	.3429	.362	.381	.381	.362	.362
18	.6287	.4572		.724	.4382	.4191	.4001
19	.8383	.8764	.8573	.724	.6668	.8192	
20	.724	.8383	.8002	.6668	.4382	.8573	.8573
21	.6478	.6097	.7049	.3149	.3048	.6287	.4961
22	.5716	.5906	.6478	.3277	.3353	.5944	.583
23	.5335	.5716	.5906	.3441	.3395	.4877	.4902
24	.6097	.4954	.5335	.4001	.381	.3201	.5468
Max	1.086	1.105	1.0669	1.1241	1.0288	.9145	.9686
Min	.2778	.3429	.362	.3149	.3048	.3048	.2286
Avg	.6660	.6329	.6637	.6335	.4664	.4913	.5430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 202 / 11 KV CHIWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8436	.7811	.8122	.3048	.3429	.2858
2	.7459	.8025	.7926	.7865	.3429	.3048	.3239
3	.8259	.7811	.8592	.8551	.362	.3048	.381
4	.9231	.852	.9393	.9665	.381	.3429	.4191
5	1.0082	.8592	.9602	1.0802	.4572	.4191	.4382
6	1.0911	.7811	.953	1.1869	.5525	.4763	.4572
7	.743	.7049	.724	.8002	.4954	.5335	.381
8	.4191	.5906	.5906	.5906	.381	.381	.3048
9	.362	.4382	.2858		.8002	.8855	.9217
10		.2858	.1334	.381	1.2955	1.0753	.9145
11	.2286	.2096	.1143	.4001	.427	1.0669	.9442
12	.1715	.2286	.1715	.2667	1.0688	.9686	.8855
13	.1905	.1715	.1524	.2096	1.2146	.9393	.9014
14	.2096	.1905	.1715	.1905	1.0526	.8539	.7343
15	.2477	.2096	.1715	.1715	.9962	.8124	.8381
16	.2667	.2286	.1905	.2096	.9762	.8436	.9717
17	.362	.2858	.3239	.2477	.2096	.2286	.1524
18	.4763	.381	.4001	.3429	.4001	.3048	.2286
19	.7049	.6478	.6668	.6859	.4763	.5144	.6097
20	.4954	.7049	.6478	.5525	.381	.4763	.6478
21			.7455	.2477	.381	.2477	.5335
22		.8592	.8573	.2858	.4001	.2477	.3429
23	.884	.8749	.9326	.2858	.381	.3429	.362
24	.9054	.8592	.823	.9088	.3048	.3429	.3239
Max	1.0911	.8749	.9602	1.1869	1.2955	1.0753	.9717
Min	.1715	.1715	.1143	.1715	.2096	.2286	.1524
Avg	.5722	.5561	.5578	.5419	.5851	.5523	.5543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 203 / 11KV NIPANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.3239	.3048	.2204	.4763	.381	.3429
2	.2667	.2778	.3353	.2347	.4763	.3429	.3239
3	.2622	.3125	.3887	.285	.4954	.3429	.362
4	.2915	.3437	.4534	.362	.5144	.381	.381
5	.3401	.3506	.4687	.362	.5716	.4763	.5716
6	.4001	.3749	.503	.426	.6478	.5525	.724
7	.4191	.4572	.4001	.6478	.6668	.7049	.5716
8	.4001	.4191	.4191	.4572	.5525	.4191	.4763
9	.3429	.4382	.381		.5079	.2949	.3125
10	.2477	.2667	.3048		.5079	.3395	.3963
11	.1143	.1905	.2096	.3932	.5441	.4843	.4268
12	.1334	.1524	.1524	.3149	.4801	.442	.3913
13	.2096	.1524	.1524	.2458	.4001	.4062	.4214
14	.2096	.1524	.1715	.1802	.4001	.3395	.2824
15	.1905	.1524	.1905	.1658	.3637	.3125	.3161
16	.1715	.1905	.2096	.1658	.3725	.3281	.3353
17	.2858	.1905	.2286	.2452	.1524	.1905	.1905
18	.3239	.2477	.3239	.3239	.2667	.1715	.2096
19	.5335	.4572	.5144	.4382	.5525	.5716	.4572
20	.4763	.5144	.5906	.4763	.381	.5906	.6287
21	.2006	.3048	.2279	.4763	.4763	.4572	.4954
22	.2343	.3048	.3467	.4763	.4763	.4572	.4382
23	.2591	.3437	.2401	.4763	.4572	.4382	.4572
24	.3222	.2743	.3241	.2204	.4572	.4191	.381
Max	.5335	.5144	.5906	.6478	.6668	.7049	.724
Min	.1143	.1524	.1524	.1658	.1524	.1715	.1905
Avg	.2869	.2997	.3267	.3452	.4665	.4101	.4122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 201 / 11KV CHAPANER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1905	.2012	.1886	.2801	.2858	.2829
2	.2829	.1905	.2012	.2829	.3361	.381	.2829
3	.2829	.2096	.2347	.2829	.3734	.5335	.3772
4	.3206	.2477	.3018	.3018	.5228	.6478	.4715
5	.3772	.2858	.3018	.3772	.5601	.7811	.4715
6	.415	.3239	.3185	.415	.7282	.8383	.8488
7	1.226	1.1241	.9892	1.0562	1.0082	1.105	1.0751
8	.8676	.9335	.7842	.8488	.7842	.8383	.811
9	.6859	.6478	.7095	.8299	.2515	.3239	.5658
10	.5658	.5144	.3772	.7356	.2683	.2477	
11	.381	.3174	.415	.5041	.2667	.2263	.2452
12	.3239	.3361	.3206	.5041	.2096	.3206	.3206
13	.3048	.3174	.3206	.4481			.3048
14	.3239	.3174	.3395	.3547	.2096	.2452	.3048
15	.2858	.3174	.3772	.3361	.2286	.2263	.2858
16	.3239	.2915	.3395	.3361	.2477	.2829	.2667
17	.4001	.3547	.415	.3734	.381		.362
18	.4763	.4108	.5658	.4294	.4382	.2829	.4382
19	.7049	.4481	.679	.5975	.6859		.7621
20	.5906	.8029	.1886	.6722	.724	.8299	.8383
21	.2096	.2515	.2829	.4108	.6287	.6036	.5906
22	.2286	.2683	.1886	.4294	.4763	.1886	.5335
23	.2096	.2683	.1886	.2858	.4001	.2263	.4382
24	.3018	.1905	.2286	.2286	.2858	.3429	.1886
Max	1.226	1.1241	.9892	1.0562	1.0082	1.105	1.0751
Min	.2096	.1905	.1886	.1886	.2096	.1886	.1886
Avg	.4322	.3983	.3862	.4679	.4476	.4647	.4811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 202 / 11KV SIRAJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.381	.3353	.1886	.3361	.2477	.2829
2	.547	.4382	.3521	.2263	.3361	.2858	.1886
3	.6036	.5144	.4024	.3584	.3734	.4001	.2829
4	.6602	.5906	.503	.4715	.4481	.4572	.3772
5	.7545	.6859	.5365	.5658	.5228	.5716	.679
6	.9997	.8954	.7712	1.0185	.6348	.6478	.679
7	.6036	.6097	.4877	.6224	.7655	.743	.6979
8	.5658	.5716	.7095	.6224	.6348	.4572	.6036
9	.415	.362	.3734	.5093	.7377	.6287	.6602
10	.3395	.2667	.1886		.9221	.7811	.6602
11	.2858	.1867	.2263		1.0288	.7733	.7167
12	.1905	.168	.1698		.9526	.7167	.6602
13	.1334	.168	.1698			.5658	.5716
14	.1143	.168	.1698		.6478	.5847	.5144
15	.1524	.168	.2075	.1867	.7049	.5847	.4954
16	.1905	.168	.2075	.2054	.8954	.6224	.5144
17	.2858	.181	.2075	.2241	.1715	.3584	.1524
18	.4001	.2427	.3772	.2801	.2286	.3584	.2096
19	.5525	.4668	.5658	.3734	.4572	.3584	.4572
20	.4763	.6161	.3772	.5415	.4954	.5658	.6287
21	.4001	.3353	.4338	.3361	.5144	.4191	.4572
22	.4763	.0369	.2829	.3547	.381	.3772	.4001
23	.4001	.3688	.1886	.3361	.3239	.2829	.3429
24	.4715	.3429	.3239	.1905	.2858	.2858	.2858
Max	.9997	.8954	.7712	1.0185	1.0288	.7811	.7167
Min	.1143	.0369	.1698	.1867	.1715	.2477	.1524
Avg	.4371	.3722	.3570	.4006	.5565	.5031	.4799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 203 / 11KV TAKLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6287	.6348	.6602	.6371	.6859	.5658
2	.8299	.743	.7095	.5658	.7468	.724	.5658
3	.8488	1.0288	.9149	.6602	.6706	.7811	.6602
4	.9431	1.1241	1.1317	.7545	.7377	.8764	.8488
5	1.1128	1.1812		.9431	.8048	.9526	.8488
6		1.1431			.9054	.9717	1.0374
7		1.1431	.6722		.6706	.8192	.9808
8	.9808	.9335	.6348		.6908	.724	
9	.7716	.9717	.7842	.8865	.3361	.5906	.4904
10	.8488	.9145	.6602	.8551	.3361	.4382	.3772
11	.9335	.6706	.6602	.7042	.3048	.3206	.3395
12	.6859	.0687	.6979		.2096	.3584	.3584
13	.6668	.6371	.7545	.6706		.2829	.3048
14	.6859	.6539	.7545	.6203	.2286	.3395	.2858
15	.7049	.6874	.7733	.6706	.2477	.3206	.3239
16	.6668	.7042	.8676	.7209	.2667	.2829	.3429
17	.4572	.2801	.2829	.2241		.5658	.381
18	.5906	.3734		.2801	.4001	.5658	.4382
19	.9145	.7095	.7167	.6535	.9335	.5658	.724
20	.8002	.8775	.6602	.7468	.8192	.7167	
21	.7621	.7468	.7167	.6371	.724	.6036	.6859
22	.724	.7095	.6602	.6706	.9526	.5658	.9145
23	.6478	.5906	.7545	.9145	.8764	.6036	.9526
24	.5658	.5906	.6478	.7621	.724	.8192	.6036
Max	1.1128	1.1812	1.1317	.9431	.9526	.9717	1.0374
Min	.4572	.0687	.2829	.2241	.2096	.2829	.2858
Avg	.7680	.7547	.7185	.6800	.6011	.6031	.5923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 204 / Banshendra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1524	.1341	.1509	.1867	.1715	.1886
2	.1698	.1524	.1341	.1698	.1867	.2096	.1886
3	.1886	.1715	.1677	.3772	.2241	.2477	.1886
4	.1886	.1905	.1844	.3772	.2987	.3429	.3772
5	.1886	.2286	.218	.3772	.3361	.4382	.4715
6	.2829	.2477	.2347	.2641	.4108	.4954	.4715
7	.4338	.4191	.3921	.415	.5415	.5335	.5093
8	.3772	.3429	.3361	.3584	.3547	.3429	.3584
9	.2263	.2858	.2241	.2829	.2347	.2096	.1886
10	.1509	.1524	.1886	.2427	.2347	.2286	.1886
11	.1334	.1307	.2263	.1867	.2667	.2829	.2829
12	.1334		.1886	.1494	.2477	.2263	.1698
13	.0953		.1509		.2286	.1886	.0953
14	.1143	.0934	.1132		.2286	.1509	.1143
15	.0953	.1097	.1132		.2477	.1886	.1524
16	.0953	.112	.1132	.1494	.2096	.2263	.2096
17	.1524	.168	.132	.168	.1143	.1886	.0953
18	.1905	.112	.132	.2054	.1143	.1886	.1334
19	.3239	.1867	.1698	.2241	.2667	.2452	.2858
20	.3239	.2801	.0754	.3361	.362	.3772	.381
21	.1905	.2012	.0754	.2801	.3429	.2829	.3048
22	.1334	.1341	.0953	.2801	.2667	.1886	.2477
23	.1334	.1174	.1143	.2241	.2286	.1886	.2096
24	.1886	.1143	.1334	.1524	.1905	.1905	.2263
Max	.4338	.4191	.3921	.415	.5415	.5335	.5093
Min	.0953	.0934	.0754	.1494	.1143	.1509	.0953
Avg	.1942	.1865	.1686	.2558	.2635	.2639	.2516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 205 / 11 KV GUDAMA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1677	.1715	.168	.1905	.2829
2	.2263	.2286	.1844	.1905	.168	.2858	.1886
3	.3772	.2858	.2347	.2263	.1867	.362	.1886
4	.415	.3429	.2515	.3772	.2614	.4382	.1886
5	.415	.4001	.3018	.415	.3734	.5144	.2829
6	.5281	.4572	.3048	.6036	.4481	.5906	.5847
7	.4904	.4954	.4359	.415	.5041	.4763	.3772
8	.3772	.4001	.3734	.3772	.3547	.362	.2263
9	.2829	.2667	.2801	.3584	.3353	.2477	.2263
10	.0943	.1334	.1886	.2801	.3688	.3048	.2263
11	.0762	.0934	.132	.168	.4382	.2452	.2829
12	.0381	.0747	.132	.168	.4572	.2263	.2263
13	.0381	.056	.132	.112	.4572	.1886	.0762
14	.0572	.0549	.1132	.0934	.362	.2263	.1524
15	.0572		.0754	.1307	.3048	.2641	.1524
16	.0762	.0514	.0566	.1494	.2858	.2829	.1715
17	.1334	.0934	.1132	.1867	.1143	.1886	.1143
18	.2286	.0934	.1886	.2241	.1715	.2263	.1143
19	.3429	.2241	.3772	.2427	.3048	.1886	.2667
20	.2858	.3361	.0943	.2801	.362	.3584	.381
21	.1905	.1677	.0754	.2427	.3239	.2452	.2477
22		.1677	.0754	.2241	.2858	.1886	.2096
23	.1905	.1509	.0754	.2054	.2096	.1886	.1905
24	.1886	.1715	.1715	.1905	.1715	.1715	.1886
Max	.5281	.4954	.4359	.6036	.5041	.5906	.5847
Min	.0381	.0514	.0566	.0934	.1143	.1715	.0762
Avg	.2296	.2146	.1890	.2514	.3090	.2901	.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 201 / 11kv ANDHANER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4118	1.6975	1.267	.9955	.724	1.1694
2	1.448	1.3575	1.6975	1.267	.905	.543	1.1694
3	1.6289	1.267	1.7918	1.267	.905	.724	1.358
4	1.6289	1.6289	2.0748	1.448	1.1088	.905	1.9719
5	1.8099	1.8099	2.0748	1.8099	1.2346	1.448	1.7918
6	1.8099	2.0633	2.1502	1.8099	1.7737	1.8099	1.8861
7	1.8099	1.9004	1.9993	1.8099	1.9204	1.9909	2.0748
8	1.8099	1.5746	1.8861	1.9433	1.6832	1.6289	1.8107
9	1.6804	1.3032	1.3546	1.8099	1.9004	1.8099	2.037
10	1.0751	.7922	.724	1.2071	2.0271		1.9993
11	.5487	.7922	.4525	1.0974	2.0814	1.6461	1.7661
12	.2401	.6036	.362	.8745	1.8519	1.8519	1.7147
13	.2058	.6036	.362		1.7833	1.9719	1.5775
14	.2572	.547	.3258	.6687	1.8861	2.0576	1.7147
15	.3601	.8573	.4973	.5658	1.8861	2.1776	1.7737
16	.4287	.6173	.2743	.5144	1.8861	1.5261	1.7013
17	.4801	.3772	.4287	.703	.6516		1.4937
18	.8402	.9431	.4973	.9145	.905		1.6804
19	1.5775	1.2517	1.3717	1.467	1.448		1.5123
20	1.4377	1.4918	1.8099	1.307		1.8861	1.4937
21	1.4563	1.7164	1.448	1.2323	1.448	1.6975	1.307
22	1.5708	1.6787	1.448	1.1431	1.086	1.6032	1.2136
23	1.5497	1.6787	1.448	1.829	.905	.9808	1.086
24	1.448	1.4118	1.6975	1.448	1.0269	.724	.9808
Max	1.8099	2.0633	2.1502	1.9433	2.0814	2.1776	2.0748
Min	.2058	.3772	.2743	.5144	.6516	.543	.9808
Avg	1.1896	1.2366	1.2447	1.2784	1.4478	1.4853	1.5952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 203 / 11KV GARADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.3429	.3395	.4525	1.1765	1.086	1.2826
2	.4525	.3048	.3395	.4668	1.086	1.086	1.358
3	.4525	.2858	.3395	.4854	1.086	1.086	1.5089
4	.4525	.3239	.415	.5601	1.1765	1.267	1.6032
5	.5601	.381	.4904	.5601	1.2308	1.267	1.8861
6	.543	.4763	.5281	.5601	1.2489	1.267	2.0748
7	.543	.4572	.5658	.5601	.4763	.4525	.679
8	.543	.4382	.4954	.4763	.4382	.3982	.4338
9	1.6289	1.6289	1.7318	1.9909	.3982	.362	.3584
10	2.0748	2.0748	2.1719	2.0243	.3439	.2572	.2641
11	1.6461		2.3529	2.1434	.2715	.2743	.2858
12	2.0405	2.2634	2.3529	2.1948	.2915	.3258	.2858
13	1.9204	2.4331	2.3529	2.1605	.3258	.381	.3048
14	1.9719	1.9427	2.1719	2.0919	.3429	.3944	.3429
15	2.1434	1.9719	2.0233	2.0405	.3429	.4458	.381
16	2.6406	2.1434	1.9376	1.9719	.3944	.3429	.381
17	.3258	.2401	1.1145	.2915	.3429	.4458	.381
18	.3086	.3601	1.046	.3429	.4525	.4973	.4191
19	.2743	.4458	.583	.4191	.4525	.6687	.4572
20	.362	.4287	.543	.4001		.6602	.4191
21	.3239	.3772	.543	.9054		.9808	1.2136
22	.3429	.415	.4525	1.0829	.7602	1.1317	1.3575
23	.3429	.415	.4525	1.1949	.905	1.2637	1.448
24	.4525	.3429	.3772	.4706	1.2308	1.086	1.2826
Max	2.6406	2.4331	2.3529	2.1948	1.2489	1.267	2.0748
Min	.2743	.2401	.3395	.2915	.2715	.2572	.2641
Avg	.9499	.8910	1.0717	1.0770	.6716	.7261	.8503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 204 / 11KV KALIMATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.7545	.7922	.724	1.9204	1.448	1.8484
2	.543	.7545	.7922	.724	1.9204	1.448	1.8861
3	.543	.5716	.7922	.724	1.9909	1.448	1.8861
4	.724	.7621	.8299	.724	1.9719	1.6289	2.0814
5	.8145	.8002	.9054	.8145	1.829	1.8099	2.452
6	.8145	.8002	.9431	.905	1.9662	1.9909	1.7541
7	.8145	.8383	.9997	.905	.7811	.362	.7545
8	.4525	.5335	.6602	.6668	.7049	.362	.5093
9	1.7147	2.6235	2.6406	3.0769	.4706	.2715	.3206
10	2.6673	3.4894	3.4389	2.4844	.2715		.2641
11	2.8807	3.5082	3.6199	2.7949			.2477
12	2.8292	3.3008	3.4389	3.2236	.3086		.2858
13	3.2922	3.3573	3.2579	2.9492	.2572		.3239
14	2.6406	3.0178	3.2579	2.8292	.3429		.2915
15	2.9492	2.8292	2.5034	2.8292	.3429		.2858
16	2.7206	2.6749	2.8121	2.8292	.4801		.2858
17	.5716	.2915	.4115		.3601	.5316	.2801
18	.4763	.4287	.4287	.3601	.543	.4973	.3734
19	.463	.6344	.7545	.7049	.724	.6687	
20	.7922	.7545	.8145	.6668		.8676	.4382
21	.8764	.8299	.724	1.8004		1.7918	.7621
22	.8573	.8299	.724	2.0328		1.8861	
23	.8192	.8299	.724	2.1472	1.448	2.1502	1.8461
24	.724	.7922	.7922	.724	1.989	1.448	2.1502
Max	3.2922	3.5082	3.6199	3.2236	1.9909	2.1502	2.452
Min	.4525	.2915	.4115	.3601	.2572	.2715	.2477
Avg	1.3551	1.5003	1.5441	1.6365	1.0311	1.2124	.9694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 205 / 11KV GARADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1524	.1698	.1524	.1524	.1494	.1886
2	.1867	.1524	.1698	.1494	.1524	.1867	.1886
3	.2241	.1524	.2263	.1494	.1334	.1867	.2263
4	.2614	.1905	.2263	.2241	.1905	.2614	.3395
5	.3361	.3429	.4715	.4108	.2858	.3361	.3772
6	.4668	.4191	.4904	.5228	.4763	.5228	.4904
7	.5975	.5335	.5281	.5601	.4954	.5601	.547
8	.4668	.4001	.415	.4763	.362	.3734	.415
9	.381	.2477	.2572	.362	.3174	.3734	.2829
10	.2096	.1509	.2614	.2286	.2427	.1715	.1886
11	.1372	.1509	.1867	.2058	.2427	.1372	.1524
12	.1543	.1698	.1494	.1372	.1715	.1029	.1334
13	.1372	.1698	.1494	.12	.1543	.12	.1143
14	.1143	.1509	.1448	.1372	.1543	.1372	.1029
15	.12	.12	.12	.1372	.1543	.1372	.1334
16	.1372	.1543	.1372	.1543	.0686	.1543	.1334
17	.1886	.1886	.2058	.1715	.168	.2229	.1334
18	.2743	.2572	.1886	.2058	.2614	.2572	.2286
19	.3086	.3086	.3258	.362	.3734	.2743	.3239
20	.2667	.2572	.3982	.381		.2829	.2858
21	.2286	.2263	.3258	.2477	.2614	.2263	.2667
22	.1905	.1509	.2896	.2096	.2054	.2263	.2286
23	.1715	.1509	.181	.1715	.1494	.1698	.1905
24	.1494	.1524	.1698	.168	.1524	.1494	.1698
Max	.5975	.5335	.5281	.5601	.4954	.5601	.547
Min	.1143	.12	.12	.12	.0686	.1029	.1029
Avg	.2441	.2229	.2578	.2519	.2315	.2383	.2434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 206 / 11KV Rail Single Phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.8145	1.0185	.9955	.2286	.181	.1886
2	1.086	.8145	1.0185	1.086	.2096	.2172	.1886
3	1.086	.7316	1.0562	1.1765	.1905	.2715	.1886
4	1.1765	.8688	1.094	1.267	.2477	.3258	.3018
5	1.3032	1.2003	1.1317	1.3575	.3048	.362	.415
6	1.3575	1.3375	1.1506	1.3575	.4954	.4525	.4904
7	.543	.5041	.4904	.543	.6287	.543	.5281
8	.4525	.4715	.4904	.5228	.4382	.543	.4338
9	.381	.3239	.3086	.4525	1.1222	1.1203	1.1317
10	.2286	.1886	.2896	.2858	.9945	.9945	1.2449
11	.1715	.1886	.2715	.2572	1.3575	1.2346	1.2003
12	.1029	.0943	.181	.0857	1.267	1.2003	1.2003
13	.0857	.0943	.1629	.12	1.2517	1.166	1.1488
14	.12	.0943	.1629	.12	1.3575	1.1145	1.0974
15	.0857	.1029	.1372	.1524	1.286	1.0974	1.0631
16	.12	.0857	.1029	.1886	1.3717	1.0288	.8573
17	.1372	.1372	.1372	.1715	.1372		.1905
18	.3086	.2058	.1543	.2058	.2896		.1905
19	.3429	.2572	.3086	.3429	.362		.1524
20	.362	.4287	.3982	.381		.415	.1905
21	.381	.9997	.905	.2477	.2534	.3395	.1905
22	.7316	.9997	1.086	.2477	.2172	.3018	.2096
23	.7964	.9997	1.086	.2477	.181	.2477	.2096
24	.905	.724	1.0185	1.086	.2286	.181	.1886
Max	1.3575	1.3375	1.1506	1.3575	1.3717	1.2346	1.2449
Min	.0857	.0857	.1029	.0857	.1372	.181	.1524
Avg	.5487	.5278	.5900	.5374	.6270	.6351	.5500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 201 / 11 KV Deogaon Urban SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.5432	1.6244	.8192	.9259	1.0059	.9503
2	1.8099	1.5604	1.643	.7865	.9088	1.0059	.9503
3	1.9052	1.6975	1.7177	.7865	.9431	1.0242	.9831
4	2.0957	1.8004	1.9605	.9012	.9945	1.0974	1.065
5	2.6673	2.0576	2.3525	1.0159	1.1145	1.4632	1.0978
6	2.6673	2.4006	2.4832	1.3927	1.5432	1.6461	1.4091
7	2.6673	2.4006	2.4086	2.4768	2.4006	2.5019	
8	2.2862	2.0576	2.0725	2.2862	1.989	2.0165	2.553
9	.852	1.0288	1.0059	1.749	1.5432	1.6194	1.5432
10	1.0288	1.1523	.9012	1.5604	1.5123	1.3717	1.3032
11	1.046	1.134	.9831	1.4575	1.4377	1.4098	1.1488
12	.9774	1.1888	1.0814	1.3546	1.419	1.3908	1.166
13	1.046	1.134	1.1469	1.3032	1.3817	1.3908	1.2346
14	1.0288	.9694	.9831	1.2517	1.419	1.086	1.286
15	.9259	.9694	1.0486	1.2346	1.419	1.1241	1.2689
16	.9431	.9328	.9503	1.2689	1.475	1.1431	1.3375
17	1.1831	1.4377	1.2955	1.286	1.587		1.286
18	1.3375	1.7177	1.5242	1.4746	1.7177	1.8099	1.3375
19	1.749	1.7177	2.0005	1.7318	2.2405	2.191	1.9033
20	1.9376	1.9605	2.2672	2.0062	2.2405	2.3434	2.1605
21	1.749	1.9044	.9503	1.1317	1.0974	1.1469	1.2003
22	1.7833	1.8298	.9831	1.1488	1.3352	1.2616	1.3375
23	1.6804	1.7364	.9012	1.0802	1.0974	1.065	1.1317
24	1.9052	1.5947	1.6244	.8192	.9945	1.0242	.9503
Max	2.6673	2.4006	2.4832	2.4768	2.4006	2.5019	2.553
Min	.852	.9328	.9012	.7865	.9088	1.0059	.9503
Avg	1.6292	1.5803	1.4962	1.3468	1.4474	1.4408	1.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 202 / 11KV Mategaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.639	.6173	.6219	.2286	.1429	.2801	.2858
2	.6882	.6173	.6584	.2286	.1429	.2801	.2858
3	.7373	.6173	.695	.2286	.1429	.2987	.2858
4	.7373	.6173	.7316	.3429	.1715	.2987	.3429
5	.7373	.6859	.7682	.4001	.2	.3361	.4001
6	.8848	.823	.8048	.4001	.2858	.4108	.4001
7	.4001	.2286	.4108	.4572	.2382	.4108	.4572
8	.4001	.2	.3361	.3429	.2	.3921	.3429
9	.3429	.1715	.3361	.8573	.823	.7373	.7716
10	.1429	.2987	.2286	1.0288	.8779	.8356	.7716
11	.1143	.2987	.2286	.9774	.823	.7865	.6859
12	.0953	.2801	.2667	.8916	.7682	.7373	.7202
13	.0953	.2801	.1905	.9259	.8048	.639	.6687
14	.0953	.2801	.1905	.8745	.8048	.639	.6859
15	.1143	.2801	.1905	.8573	.7865	.5898	.7202
16	.0953	.2614	.1905	.8916	.8413	.639	.7202
17	.1715	.2801	.1905	.0953	.2987	.2286	.0953
18	.1429	.3361	.2858	.0953	.2987	.2286	.0953
19	.2	.3361	.4001	.2	.4108	.3429	.2286
20	.2	.3361	.4001	.2	.4108	.4001	.2286
21	.6859	.6584	.4001	.1715	.4108	.4001	.1905
22	.7716	.6584	.2858	.1715	.3734	.2858	.1715
23	.6859	.6584	.2858	.1715	.3734	.2858	.1715
24	.6882	.6173	.6219	.2286	.1429	.2987	.2858
Max	.8848	.823	.8048	1.0288	.8779	.8356	.7716
Min	.0953	.1715	.1905	.0953	.1429	.2286	.0953
Avg	.4111	.4349	.4050	.4695	.4489	.4492	.4172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 203 / 11KV Dhondalgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7045	.8059	.823	.3429	.1905	.3921	.362
2	.7373	.8059	.8413	.3429	.1905	.3921	.362
3	.7373	.8059	.8413	.4191	.1905	.3921	.4191
4	.8192	.823	.9145	.4572	.2191	.4854	.5335
5	.8684	.8745	.9877	.5335	.2953	.7842	.5906
6	.9831	1.046		.8002	.6859	.8402	.8383
7	.8002	.3715	.7468	.8764	.7545	.7282	.8192
8	.5906	.2953	.5415		.2953	.6161	.5335
9	.4382	.1715	.4481	1.046	1.0117	.9012	1.0117
10	.1238	.2427	.2667	1.0974	1.0608	.852	1.0117
11	.0953	.1867	.2096	.9945	.9694	.852	.9088
12	.0953	.168	.1905	.9259	.9145	.9012	.8745
13	.0857	.1867	.1905	.9774	.8596	.8192	.8573
14	.0857	.168	.1905	.9431	.8779	.8848	.8059
15	.0762	.168	.1715	.9602	.9145	.8356	.823
16	.0857	.1494	.1905	1.0288	.8962	.852	.8916
17	.1143	.2054	.2286	.1143	.2054	.2286	.1048
18	.1619	.3734	.3239	.1238	.3547	.2477	.1334
19	.2382	.4668	.4954	.2382	.4854	.4191	.2191
20	.2477	.4108	.5335	.2667	.4854	.5525	.2858
21	.9602	.823	.4382	.2191	.4854	.4001	.2191
22	.9259	.823	.381	.2	.3921	.4382	.2
23	.8573	.823	.362	.1905	.3734	.4001	.181
24	.7865	.823	.823	.3429	.1715	.3734	.362
Max	.9831	1.046	.9877	1.0974	1.0608	.9012	1.0117
Min	.0762	.1494	.1715	.1143	.1715	.2286	.1048
Avg	.4841	.5007	.4843	.5844	.5533	.6078	.5562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 205 / 11KV TADPIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.1488	1.2136	.7373	.8059	1.0059	.9831
2	1.3336	1.1488	1.2323	.6882	.7716	1.0059	.9831
3	1.3717	1.166	1.2696	.7373	.823	1.0608	.9831
4	1.4289	1.2174	1.307	.8192	.8402	1.134	1.0159
5	1.8099	1.5089	1.8298	.8192	.9774	1.4632	1.0159
6	1.9624	1.6804	1.9418	1.065	1.286	1.4998	1.3599
7	1.9243	1.5947	1.7924	1.5623	1.4575	1.6804	1.448
8	1.4289	1.286	1.531	1.3717	1.1317	1.2696	1.3336
9	1.1431	1.046	.7316	1.1145	.7888	.9907	.8916
10	1.1831	.9877	1.1142	.9774		.8192	.7202
11	1.1317		1.0159	.8916	.6722	.6287	.503
12	1.0631	1.1157	1.0159	.7545	.6908	.5906	.5182
13	1.0974	1.134	.9831	.6516	.6535	.6478	.5182
14	1.1488	1.1157	.9831	.6001	.6535	.6668	.5639
15	1.166	1.1706	.9995		.6535	.6668	.5639
16	1.166	1.2437		.6344	.7095	.6478	
17	.6516	.5601	.6478	.6344	.7095	.6859	.5639
18		1.0082		.823	.8402	1.0479	.6687
19	1.406	1.4563	1.4289	1.2517		1.1812	1.166
20	1.3889	1.4003	1.5242	1.2689	1.307	1.5623	1.4403
21	1.046	1.3256	.7701	.9774	.823	1.065	1.0631
22	1.2174	1.3256	.7701	1.0288	1.0829	1.1469	1.1831
23	1.166	1.307	.8192	.9088	1.134	1.1469	1.0802
24	1.3336	1.1317	1.2136	.7373	.8402	1.0425	.9831
Max	1.9624	1.6804	1.9418	1.5623	1.4575	1.6804	1.448
Min	.6516	.5601	.6478	.6001	.6535	.5906	.503
Avg	1.3001	1.2208	1.1879	.9154	.8933	1.0274	.9370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 201 / TOWN-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.0384	.3361	.0384	.3429	.3921	.3772
2	.3961	.0329	.3361	.0366	.3429	.3961	.3772
3	.3841	.0512	.3475	.0439	.3429	.3921	.4115
4	.415	.0439	.3734	.0476	.4115	.4108	.4115
5	.5121	.0476	.4854	.0549	.4287	.4108	.4801
6	.6219	.0585	.5487	.0585	.4801	.6161	.5144
7	.6584	.0658	.6908	.0622	.6935	.6584	.6173
8	.6348	.0732	.6584	.0604	.695	.7282	.6516
9		.5487	.5975	.0585	.5853	.5487	
10	.0512	.4801	.0549	.583	.5975	.4458	.0585
11	.0457	.5144	.0476	.583	.5121	.4458	.0439
12	.0476	.3086	.0402	.5144	.439	.4458	.0348
13	.0439	.2743	.0366	.4115	.4294	.4115	.0329
14	.0384	.2572	.0329	.3429	.3734	.3772	.0329
15	.0329	.2401	.0329	.3086	.3734	.3772	.0348
16	.0329	.2229	.0384	.3086	.4024	.3772	.0384
17	.0329	.4207	.0476	.3429	.4207	.4115	.0476
18	.0439	.4755	.0512	.4458	.5228	.4458	.0439
19	.0444	.5487	.0549	.5316	.5975	.5144	.0402
20	.053	.5228	.0585	.5144	.567	.5487	.0439
21	.0452	.4854	.0549	.4801	.439	.5144	.0549
22	.0439	.4108	.0476	.3429	.4108	.4115	.0512
23	.0384	.3658	.0384	.3429	.4108	.3772	.0402
24	.3734	.0366	.3292	.0366	.3429	.4108	.3772
Max	.6584	.5487	.6908	.583	.695	.7282	.6516
Min	.0329	.0329	.0329	.0366	.3429	.3772	.0329
Avg	.2158	.2718	.2225	.2729	.4651	.4612	.2094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 202 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.419	.139	1.2323	.1134	1.283	1.4003	1.3176
2	1.4146	.1463	1.2136	.1134	1.283	1.3535	1.3176
3	1.3717	.1536	1.2136	.1201	1.3176	1.3535	1.387
4	1.4003	.15	1.2071	.1441	1.387	1.3817	1.387
5	1.6095	.1975	1.7558	.1885	1.439	1.7558	1.4723
6	2.0538	.2122	1.9204	.2033	1.5604	2.0851	1.7177
7	2.1948	.2085	2.1216	.2218	1.9418	2.3152	2.1491
8	1.9022	.1975	1.9791	.1774	1.8858	2.3594	1.8404
9	.1719	1.387	1.6057	.1478	1.7193	1.491	1.643
10	.1478	1.4563	.1441	1.5257	1.531	1.4217	.128
11	.1463	1.387	.1317	1.5257	1.531	1.4217	.1244
12	.1353	1.3003	.1183	1.387	1.1203	1.335	.1189
13	.1134	1.2136	.0998	1.3176	1.134	1.3523	.1183
14	.1061	1.0749	.0961	1.283	1.3256	1.2483	.1146
15	.1207	1.0749	.1061	1.283	1.358	1.2346	.1183
16	.1171	1.0402	.1189	1.283	1.3817	1.335	.1109
17	.1317	1.251	.1294	1.3176	1.531	1.387	.1127
18	.1573	1.2986	.1405	1.387	1.643	1.387	.1405
19	.1866	1.7177	.1536	1.6827	1.9044	1.6827	.1829
20	.1792	1.643	.1683	1.6827	1.7924	1.7177	.2125
21	.1552	1.5181	.161	1.5775	1.6827	1.6644	.2181
22	.1441	1.4632	.1317	1.4723	1.643	1.595	.17
23	1.3676	1.307	.1097	1.387	1.4937	1.4217	.1552
24	1.4563	.1368	1.2696	.1171	1.283	1.419	1.3176
Max	2.1948	1.7177	2.1216	1.6827	1.9418	2.3594	2.1491
Min	.1061	.1368	.0961	.1134	1.1203	1.2346	.1109
Avg	.7584	.9031	.722	.9024	1.5072	1.5466	.7323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 203 / Town 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.0622	.4755	.0585	.5487	.5487	.4801
2	.4108	.0585	.4755	.0573	.5144	.5228	.4458
3	.3921	.0658	.4024	.0604	.4115	.439	.4115
4	.3734	.0695	.3361	.0658	.4115	.4108	.3772
5	.4854	.0732	.4854	.0658	.3772	.5601	.3772
6	.6219	.0768	.5975	.0622	.4287	.6219	.4115
7	.6722	.0805	.6348	.0622	.6935	.7095	.583
8	.7468	.0878	.7095	.0658	.7842	.7316	.6173
9	.0732	.7202	.6722	.6584	.7316	.6516	.6584
10	.0658	.6859	.0622	.4801	.7095	.5487	.0585
11	.0457	.6935	.0512	.5487	.7282	.5144	.0512
12	.0384	.6859	.0512	.5487	.5601	.4458	.0439
13	.0439	.6516	.0476	.4801	.5093	.3429	.0457
14	.0366	.4115	.0528	.3772	.439	.3086	.0402
15	.0329	.3429	.0476	.3429	.4108	.3086	.0439
16	.0439	.3429	.0512	.3429	.4481	.3772	.0384
17	.053	.439	.0549	.4801	.4481	.4458	.0457
18	.0622	.5853	.0622	.6173	.7842	.5658	.0658
19	.0622	.8048	.0732	.7975	.7842	.7282	.0768
20	.0713	.7095	.0658	.7282	.7468	.6859	.0805
21	.0695	.6219	.0622	.6859	.5975	.6516	.0841
22	.0658	.6348	.0585	.6173	.5853	.583	.0732
23	.567	.6348	.0585	.583	.6584	.5487	.0549
24	.6722	.0622	.5487	.0622	.5487	.5975	.4801
Max	.7468	.8048	.7095	.7975	.7842	.7316	.6584
Min	.0329	.0585	.0476	.0573	.3772	.3086	.0384
Avg	.2564	.4000	.2557	.3687	.5775	.5354	.2352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 204 / Town 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.0476	.4294	.0402	.4115	.4668	.4458
2	.4668	.0384	.4108	.0402	.4115	.439	.4458
3	.4854	.0402	.415	.0476	.4115	.439	.4801
4	.4854	.0512	.4024	.0512	.4458	.4755	.5144
5	.5975	.0585	.5121	.0622	.4801	.6348	.5144
6	.6219	.0622	.6036	.0658	.5144	.6767	.5487
7	.6722	.0658	.6584	.0658	.6173	.7167	.6173
8	.7095	.0585	.6584	.0622	.6219	.6348	.6173
9	.064	.583	.5228	.0622	.6219	.583	
10	.0658	.7282	.0549	.6859	.7095	.6173	.0549
11	.0622	.5487	.0585	.6687	.7468	.6173	.0512
12	.0628	.5487	.0658	.6687	.6584	.6722	.0658
13	.0585	.4458	.0549	.6173	.695	.6001	.0658
14	.0658	.4287	.0585	.5487	.7095	.6173	.0622
15	.0567	.5487	.0585	.583	.7095	.6173	.0585
16	.0585	.5487	.0585	.583	.7095	.6516	.0665
17	.0622	.5601	.0622	.583	.6584	.6173	.0702
18	.0695	.6219	.0658	.583	.7468	.6516	.0713
19	.0658	.7468	.0732	.7282	.8048	.7282	.0805
20	.0768	.7167	.0768	.6935	.7316	.6859	.0585
21	.0604	.5975	.0695	.7095	.5975	.6516	.0732
22	.0549	.5601	.0512	.4801	.5487	.6173	.5601
23	.0457	.5228	.0476	.4801	.5658	.5144	.0512
24	.4755	.0439	.4755	.0439	.4115	.4755	.4458
Max	.7095	.7468	.6584	.7282	.8048	.7282	.6173
Min	.0457	.0384	.0476	.0402	.4115	.439	.0512
Avg	.2465	.3822	.2477	.3814	.6058	.6001	.2617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 205 / Ritthi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	.2103	1.7147	.1865	.5601	.5415	.5144
2	1.8861	.1866	1.7147	.1865	.5487	.5121	.5144
3	1.869	.192	1.6804	.1967	.5487	.4938	.5658
4	1.8519	.2122	1.5775	.2136	.6219	.4854	.6036
5	2.0576	.2158	1.9719	.2238	.6401	.5415	.6413
6	2.1948	.2012	2.1262	.212	.6584	.5487	.6413
7	.3018	.0329	.2743	.0356	.7316	.567	.6602
8	.3361	.0305	.3772	.415	.4481	.3658	.4527
9	.3734	.3018	.3547	.3772	2.3411	1.7909	
10	.0475	.415	.0384	.5281	2.7435	2.0416	.2357
11	.0512	.4715	.0439	.5281		2.0058	.251
12	.0457	.4904	.0402	.5658		2.0774	.2577
13	.0384	.4904	.0439	.4904	1.8861	2.1262	.251
14	.0439	.5281	.0476	.5281	2.0911	2.2207	.2543
15	.0476	.5281	.0402	.5658	2.1948	2.2207	.2543
16	.0512	.5658	.0476	.5658	2.1948	2.2207	.2408
17	.0476	.5601	.0512	.6036	.2401	.2263	.022
18	.0402	.6722	.053	.6413	.3658	.415	.0407
19	.0512	.5788	.0585	.6602	.4024		.0526
20	.0543	.5228	.0622	.6173	.4481	.6413	.0549
21	.139	1.6787	.1573	.679	.5121	.6036	.0622
22	.139	1.7833	.1975	.6413	.5228	.6036	.0622
23	.1594	1.7833	.2286	.6036	.5487	.6036	.0585
24	2.0576	.2012	1.8176	.2181	.5487	.5601	.5658
Max	2.1948	1.7833	2.1262	.679	2.7435	2.2207	.6602
Min	.0384	.0305	.0384	.0356	.2401	.2263	.022
Avg	.6607	.5355	.6133	.4368	.9908	1.0614	.3155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 206 / Industrial SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.011	.1463	.0129	.128	.1494	.1509
2	.0732	.011	.1494	.0129	.1307	.1463	.1509
3	.0732	.0128	.168	.0166	.1097	.168	.1509
4	.0914	.0165	.1867	.0166	.1097	.168	.1677
5	.0914	.0183	.2012	.0166	.128	.1867	.2401
6	.0934	.0183	.2195	.0185	.1307	.2054	.2401
7	.0914	.0165	.2195	.0146	.112	.2195	.2229
8	.128	.0111	.2241	.0146	.112	.1463	.2229
9	.0148	.1509	.2241	.0146	.1463	.1341	.2427
10	.0146	.1844	.0219	.1174	.1097	.2012	.0296
11	.0165	.1174	.0183	.2401	.0934	.2058	.0333
12	.0128	.2012	.0165	.2058	.0934	.2572	.0314
13	.0146	.2012	.0183	.2058	.112	.2743	.0296
14	.0146	.218	.0183	.1174	.112	.2572	.0333
15	.0219	.2012	.0183	.2401	.112	.2572	.0333
16	.0183	.1844	.0165	.2401	.0914	.2401	.0314
17	.0183	.2195	.0146	.2401	.1097	.2401	.0277
18	.0165	.1494	.0219	.2572	.1097	.1341	.0222
19	.0185	.1463	.0219	.1715	.128	.1006	.0185
20	.0183	.2561	.0219	.1174	.128	.1509	.0185
21	.0165	.168	.0165	.1372	.1307	.1509	.0185
22	.0183	.2012	.0165	.1543	.1463	.1509	.0185
23	.0129	.168	.0146	.1372	.1307	.1677	.0183
24	.0934	.0111	.1494	.0129	.1307	.1494	.1509
Max	.128	.2561	.2241	.2572	.1463	.2743	.2427
Min	.0128	.011	.0146	.0129	.0914	.1006	.0183
Avg	.0441	.1206	.0893	.1139	.1185	.1859	.0960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 201 / 11KV NAGAD AG(WITH SDT)

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	1.9052	1.9624	.5144	.5144	.3429	.5525
2	2.0957	2.0005	1.9814	.5144	.5335	.3429	.5335
3	2.0767	2.0005	1.9052	.5716	.5335	.362	.5335
4	2.0767	2.0957	1.9433	.5335	.5335	.4001	.5525
5	2.1529	2.0957	1.9052	.5525	.5335	.4382	.5525
6	2.1719	1.9814	1.8861	.5144	.5335	.4954	.5525
7	.5335	.6287	.5335	.5716	.5525		.5335
8	.5525	.6287	.4954	.5525	.5335		.5525
9	.4572	.5716	.4572	1.5242	2.5149		2.4577
10	.4572	.2477	.381	2.2481	2.5339	1.3336	2.572
11	.5335	.2667	.4572	2.3624	2.4768	1.4861	2.8006
12	.5716	.4572	.4954	2.3815	2.3243		2.6101
13	.5335	.4001	.381	2.5339	2.3243	2.1719	2.4768
14	.4572	.4191	.4572	2.4006	2.3053	2.2672	2.4196
15	.4954	.4382	.4382	2.2672	2.2862	2.4006	2.3815
16	.5335	.4572	.5144	2.191	2.2672	2.4006	2.2672
17	.5716	.2667	.5335	.5335	.5335		.4954
18	.6097	.4954	.5716	.5525	.5525		.5335
19	.5716	.4954	.5525	.5335	.5525	.4572	.5525
20	.5525	.4572	.5716	.5335		.5525	.5716
21	1.7528	1.848	.5144	.5335		.5335	.5525
22	1.8099	1.8861	.4954	.5335	.4191	.5335	.5716
23	1.7909	1.9243	.4572	.5335	.4382	.5335	.5335
24	2.1148	1.8861	1.9624	.5144	.5335	.381	.5335
Max	2.1719	2.0957	1.9814	2.5339	2.5339	2.4006	2.8006
Min	.4572	.2477	.381	.5144	.4191	.3429	.4954
Avg	1.1487	1.0772	.9105	1.1042	1.1968	.9685	1.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 202 / 11KV SAIGAWN AG (WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2481	1.8099	2.1148	.5335	.5335	.3239	.5525
2	2.2481	1.8671	2.1529	.5144	.5335	.3239	.5335
3	2.3053	2.0005	2.0957	.5716	.5335	.3429	.5335
4	2.2291	2.191	2.0767	.5525	.5335	.3429	.5525
5	2.2862	2.2862	2.191	.5525	.5525	.381	.5525
6	2.3624	2.4577	2.3053	.5716	.5525	.4382	.5525
7	.5144	.6478	.5335	.5716	.5525	.381	.5335
8	.5335	.7621	.5335	.5335	.5335	.3429	.5525
9	.5144	.8192	.5144	2.191	2.8006	1.7909	2.3434
10	.724	.5335	.5525	2.8197	3.3341	2.1338	2.4196
11	.7811	.4954	.5335	2.5911	3.3722	2.4387	2.572
12	.8192	.5335	.5335	3.4294	3.3532	2.4196	2.9721
13	.8383	.5335	.5525	3.5818	3.2007	2.4387	3.0102
14	.8954	.5525	.5716	3.3722	2.8959	2.4387	3.0483
15	.9526	.4572	.5716	3.3532	2.8006	2.4387	3.0293
16	.8573	.5144	.5525	3.3722	2.6673		2.3053
17	.7621	.5335	.5335	.5144	.724		.5335
18	.6668	.5144	.5716	.5335	.8002	.5335	.5716
19	.7049	.5335	.381	.5335	.724	.5525	.5335
20	.7621	.4954	.4001	.5525		.5525	.5525
21	1.6194	1.9814	.5144	.5335		.5525	.5335
22	1.8099	2.0576	.5525	.5335	.3429	.5335	.5716
23	1.9814	2.0957	.5335	.5335	.4001	.5335	.5335
24	2.191	2.0957	2.1148	.4763	.5335	.3429	.5335
Max	2.3624	2.4577	2.3053	3.5818	3.3722	2.4387	3.0483
Min	.5144	.4572	.381	.4763	.3429	.3239	.5335
Avg	1.3170	1.1987	.9995	1.3884	1.4670	1.0262	1.2678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 203 / 11 KV BELKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1143	.9717	1.1431	1.0479	1.0479
2	.1524	.1524	.1143	1.0288	1.1431	1.105	1.0669
3	.1905	.1715	.1524	.9335	1.3336	1.1431	1.086
4	.2096	.1905	.1905	.8573	1.4289	1.3146	1.1241
5	.2477	.2286	.2096		1.7147	1.4289	1.3336
6	.3429	.2667	.2667	1.3336	1.9052	1.5242	1.4098
7	.3048	.3239	.3048	.3239	.381	.3239	.381
8	.2667	.3048	.3048	.381	.381	.2477	.362
9	1.4289	1.5432	1.6004	.3239	.3239	.1905	.3048
10	1.6194	1.8099	1.9433	.3429	.3048	.2286	.1905
11	1.8099	1.848	2.0957	.3429	.3429	.2477	.3239
12	1.9052	1.9814	2.3434	.3239	.381	.2477	.3048
13	1.8099	1.8671	2.2291	.3239	.4001	.2667	.3429
14		1.6385	1.9052	.3048	.4191	.2477	.362
15	1.6956	1.3336	1.9433	.3239	.4191	.2286	.4001
16	1.448	1.467	2.0005	.3048	.381	.2477	.2667
17	.2096	.1905	.2286	.3239	.362	.2667	.2477
18	.2477	.2477	.2667	.362	.3239	.3048	.2858
19	.2667		.2858	.381	.3048	.362	.362
20	.2477	.1905	.2477	.4001		.381	.3429
21	.2096	.1524	.6668	1.0288		1.1241	.7621
22	.1905	.1524		1.1431	.8573	1.2193	1.3336
23	.1715	.1334	.8954	1.1622	.9907	1.1812	1.2765
24	.1524	.1715	.1334	.9526	1.2003	1.0098	1.1812
Max	1.9052	1.9814	2.3434	1.3336	1.9052	1.5242	1.4098
Min	.1524	.1334	.1143	.3048	.3048	.1905	.1905
Avg	.6643	.7182	.8888	.6163	.7473	.6621	.6708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 204 / 11kv Nagad gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1905	.1715	.1715	.2096	.1905
2	.1715	.1715	.1905	.1905	.1715	.2096	.2096
3	.1905	.1905	.2096	.2477	.1905	.2286	.2286
4	.2096	.2667	.2477	.3048	.2096	.3048	.2667
5	.3048	.3429	.3048	.3048	.3048	.381	.381
6	.4763	.4001	.4382	.381	.4191	.4001	.4763
7	.4954	.4954	.4954	.5144	.4382	.4382	.4572
8	.4001	.381	.3429	.4382	.3239	.381	.4001
9	.2858	.2667	.2667	.4001	.2667	.2858	.3048
10	.2477	.2477	.2667	.3429	.2477	.2667	.2286
11	.1905	.2477	.2286	.3048	.2286	.1905	.2286
12	.1524	.1905	.1905	.2667	.2286	.1905	.1905
13	.1524	.1715	.1905	.1905	.2477	.1905	.1905
14	.1715	.2477	.2096	.1715	.2286	.1334	.1715
15	.1524	.2477	.1905	.1905	.2286	.1715	.1715
16	.1905	.1905	.2096	.1524	.2477		.2667
17	.2286	.2477	.2096	.1334	.2667	.2286	.2286
18	.2667	.2477	.2286	.2286	.2858		.2858
19	.2858	.4001	.3429	.3048	.3429	.362	.4382
20	.3048	.4191	.381	.381		.4191	.4001
21	.2667	.3048	.4382	.2858		.362	.362
22	.2286	.2667	.2667	.2667	.381	.2858	.2858
23	.2096	.2477	.2286	.2477	.2477	.2477	.2286
24	.1905	.1715	.2096	.1905	.2286	.2286	.2096
Max	.4954	.4954	.4954	.5144	.4382	.4382	.4763
Min	.1524	.1715	.1905	.1334	.1715	.1334	.1715
Avg	.2477	.2723	.2699	.2755	.2685	.2780	.2834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 205 / 11kv Belkheda gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1524	.1905	.1905	.2096
2	.1715	.1715	.1715	.1715	.2096	.1905	.2286
3	.1905	.1905	.1905	.2286	.2286	.2096	.2477
4	.2477	.2667	.2477	.2667	.2667	.3048	.2667
5	.3048	.3429	.3048	.3048	.362	.3429	.3048
6	.4382	.4001	.4382	.381	.5335	.4191	.5144
7	.5144	.4954	.5716	.4954	.4572	.4954	.5335
8	.381	.4001	.4382	.4382	.4001	.362	.4191
9	.3048	.2858	.2667	.3429	.2858	.1905	.2477
10	.1715	.2096	.1524	.3048	.1715	.1524	
11	.1143	.1524	.1334	.1905	.1334		.1334
12	.0953	.1143	.1143	.1715	.1143		.1143
13	.0953	.0953	.1334	.1334	.1143		.1143
14	.0762	.1143	.1143	.1334	.1143	.1143	.1334
15	.0762	.1334	.1334	.0953	.1143	.1143	.1334
16	.1334	.1334	.1524	.1524	.1143	.1334	
17	.1715	.1715	.1715	.1715	.1334	.1905	.1715
18	.2667		.2096	.2096	.2096	.2286	.1905
19	.3429	.4382	.2667	.381	.3048	.2858	.381
20	.2667	.381	.362	.3429		.381	.3429
21	.2096	.2477	.381	.2286		.362	.3048
22	.1905	.2477	.2096	.2096	.2286	.1905	.2286
23	.1715	.1905	.1905	.1905	.1905	.1905	.1905
24	.1715	.1715	.1715	.1715	.1905	.1905	.1905
Max	.5144	.4954	.5716	.4954	.5335	.4954	.5335
Min	.0762	.0953	.1143	.0953	.1143	.1143	.1143
Avg	.2199	.2402	.2374	.2445	.2304	.2495	.2546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 206 / 11kv saigawan gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1905	.1715	.2286	.2286	.2286
2		.2096	.1905	.1715	.2477	.2286	.2286
3		.2286	.2477	.2667	.2667	.2667	.2477
4		.3429	.3048	.3048	.3048	.3429	.3048
5		.4191	.3429	.3429	.4763	.4191	.381
6		.4954	.4954	.4191	.5716	.4572	.5525
7		.5716	.5335	.5335	.5144	.5335	.5525
8	.3048	.4572	.4191	.4763	.4382		.5335
9	.2477	.362	.2477	.381	.3239		.2858
10	.2096		.2667	.3429	.1905		.2286
11	.1905	.1905	.2286	.2286	.1905		.2286
12	.1905	.1524	.1905	.2096	.1905		.2477
13	.1905	.1905	.1715	.1905	.1905		.1905
14	.1715	.1524	.1715	.1715	.2096	.2096	.1715
15	.1715	.1524	.1905	.1715	.2096	.1905	.1905
16	.2096	.1715	.1905	.1905	.2096		.2096
17	.3048	.1905	.2096	.2286	.2286		.1905
18	.3429	.2667	.2286		.2667	.2667	.2286
19	.381	.4954	.3239	.381	.3429	.362	.4191
20	.4001	.4191	.381	.4001		.4191	.4001
21	.3429	.2667	.4191	.2667		.3048	.362
22	.2667	.2477	.2667	.2477	.2667	.2286	.2667
23	.2286	.2477	.2286	.2286	.2286	.2286	.2477
24		.2096	.2096	.1905	.2286	.2286	.2286
Max	.4001	.5716	.5335	.5335	.5716	.5335	.5525
Min	.1715	.1524	.1715	.1715	.1905	.1905	.1715
Avg	.2596	.2891	.2770	.2833	.2875	.3072	.2969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 201 / 11 KV NADARPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.5716			.5144		
9		.4001			.7621	
11	.6097		.1143			
12			.1905			.9335
13			.2096			
14					.7811	
18					.2096	
20			.3429			
24		.6097		.1905		.1905
Max	.6097	.6097	.3429	.5144	.7811	.9335
Min	.5716	.4001	.1143	.1905	.2096	.1905
Avg	.5907	.5049	.2143	.3525	.5843	.562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 202 / 11 KV PISHOR Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716						
6			1.4098				
7	.9335						
9						.9335	
11				.724			
12				.724			.5335
13				.6859			
14		.4191				.5525	
18						.7621	
20				.8383			
24			.5906		.5716		.6668
Max	.9335	.4191	1.4098	.8383	.5716	.9335	.6668
Min	.5716	.4191	.5906	.6859	.5716	.5525	.5335
Avg	.7526	.4191	1.0002	.7431	.5716	.7494	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 203 / 11kv KOLAMBI AG WITH SDT SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905						
7	.5144				.4191		
8			.4382				
9						.4572	
11				1.0098			
12				.9145			.2858
13				.8764			
14		.8383				.1905	
18						.3048	
20				.2858			
24			.1905		.5716		
Max	.5144	.8383	.4382	1.0098	.5716	.4572	.2858
Min	.1905	.8383	.1905	.2858	.4191	.1905	.2858
Avg	.3525	.8383	.3144	.7716	.4954	.3175	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 204 / 11 KV RAMNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097						
7	.381				.5335		
8			.3429				
9						.743	
11				.2477			
12				.2286			.7811
13				.2096			
14		.1905				.5716	
18						.2286	
20				.2667			
24			.5716		.1905		.1905
Max	.6097	.1905	.5716	.2667	.5335	.743	.7811
Min	.381	.1905	.3429	.2096	.1905	.2286	.1905
Avg	.4954	.1905	.4573	.2382	.362	.5144	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 205 / 11kv Nadarpur gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191						
7	.1905				.1715		
8			.1334				
9						.0762	
11				.0953			
12				.0762			.0381
13				.0381			
14		.0381				.0381	
18						.0572	
20				.0953			
24			.0381		.0191		.0572
Max	.1905	.0381	.1334	.0953	.1715	.0762	.0572
Min	.0191	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.1048	.0381	.0858	.0762	.0953	.0572	.0477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 207 / 11KV KOLAMBI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143						
7	.5335				.5335		
8			.362				
9						.2858	
11				.1524			
12				.1524			.1334
13				.1715			
14		.1524				.1715	
18						.3048	
20				.2858			
24			.1524		.1524		.1715
Max	.5335	.1524	.362	.2858	.5335	.3048	.1715
Min	.1143	.1524	.1524	.1524	.1524	.1715	.1334
Avg	.3239	.1524	.2572	.1905	.3430	.2540	.1525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 201 / 11 KV CHINCHOLI (LI)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAR-18	20-MAR-18
HR	Load (MW)	Load (MW)
8	.538	
9	.6013	
17		.6371
19		.745
Max	.6013	.745
Min	.538	.6371
Avg	.5697	.6911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 202 / 11 KV WAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6897	.845	.8973	.8621	.5173	.6897
2	.6783	.6897	1.0139	1.0122	1.0345	.8276	.6897
3	.8478	.8621	1.0139	1.1721	1.3794		1.0345
4	1.0174	.8621	1.1829	1.2026	1.5518	.6897	1.3794
5	1.0174	1.0345	1.3519	1.4849	1.7242	1.0345	1.3794
6	.9934	1.0345	1.3519	1.3477	1.7242	1.0345	1.2069
7	1.1869	1.0345	.845	.7583	1.0345	1.0345	1.0345
8	.8535	1.1856	.845		1.0345	.8621	.6897
9	.6897	1.355	.9934		.8621		.6897
10	.6897	1.5244	.8535	.5173	.6897	.6897	.6897
11	.8621	1.6937	.8478	.5173	.515	.6897	
12	1.0345	1.609	.8535	.1724	.515	.8276	.5173
13	1.0345	1.5244	.9934	.1724	.3433	.6241	.3448
14	1.0345	1.355	.8278	.3448	.3433	.5087	.2586
15	1.2069	1.1856	.8535	.3448	.515	.4967	.2586
16	1.2069	1.1009	.8278	.5173	.515	.6622	.3448
17	.8621	.5081	.6783	.6897	.6866	.6783	.5173
18	1.0345	.6866	.8278	.6897	.8621		.5173
19	1.0345	.8583	.9934	.8621	.8621	1.0265	.6897
20	.8621	.8583	1.1949	1.0345	.8621	1.0277	.8621
21	.8621	.7605	1.0174	1.0345		.8621	1.0345
22	.8621	.845	.8478	.8621	.5173	.8621	1.0345
23	.5173	.845	1.0242	.6897	.3448	.8276	.6897
24	.6783	.6897	.9295	1.0174	.5173	.5173	.5173
Max	1.2069	1.6937	1.3519	1.4849	1.7242	1.0345	1.3794
Min	.5173	.5081	.6783	.1724	.3433	.4967	.2586
Avg	.9060	1.0330	.9589	.7882	.8390	.7762	.7422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 204 / 11 KV TAKLI (A)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5292	.6118	.7106	.8685	.8276		.6207
2	.7461	.6798	.7106	.9158	1.138		1.0518
3	.8478	.6968	.9813	.9584	1.3104		1.3966
4	.9665	.9517	1.0489	1.0109	1.4263		1.4828
5	1.0174	.9857	1.0997	1.192	1.6552		1.6552
6	1.0852	1.0537	1.0828	1.0673	1.6552		1.6897
7	1.153	1.0367	1.1504	.6643	1.1035		
8	1.0513	.7138		.7828	1.0345	.5173	
9	.8276	.7782	.2318	.7637	.3621		.4483
10	.8276	.8459	.2649	.3003	.3793	.6552	.3251
11	.8793	.8628	.1987	.2069	.2549	.3966	.2759
12	.928	.9136	.1656	.1724	.2039	.3276	.2167
13	.8104	.8797	.1696		.1699	.1964	.1724
14	1.0518	.8463			.1869	.2204	.1724
15	1.138	.8629	.1656		.2209	.2204	.1897
16	1.0518	.8469		.2759	.2549	.2219	.1724
17	1.0345			.3104	.2719		.2759
18	.7069			.4483	.3793		.5862
19	.9656			.8308	.9311		.8276
20	1	.6798	.9437	1.0104	.9656	.7285	.9656
21	.7069	.5245	.78	1.1017		.6897	.7069
22	.6207	.5583	.693	.8642		.6897	.569
23	.5843	.6429	.6589	.596		.6552	.5
24	.4748	.5438	.6767	.723	.6207		.5173
Max	1.153	1.0537	1.1504	1.192	1.6552	.7285	1.6897
Min	.4748	.5245	.1656	.1724	.1699	.1964	.1724
Avg	.8752	.7865	.6518	.7173	.7311	.4599	.6736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 205 / 11 KV Wadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5256	.5168	.5974	.9156	1.5533	.6321	.8669
2	.6443	.8002	.7136	.8471	1.7339	.7044	1.77
3	.78	.9335	.9293	.9065	1.9145	1.0114	1.9145
4	.894	1.0169	1.0123	1.0212	1.9867	1.2462	1.9867
5	1.0343	1.0669	1.1284	1.037	2.1989	1.3004	2.1854
6	1.0852	1.1336	1.0952	1.1264	2.1674	1.4088	2.2757
7	1.1267	1.1836	1.062	1.0632	1.138	1.1559	1.1559
8	.9326	.7301	.9957	.8242	1.1017	1.0837	1.1006
9	.9624	.7467	.1656	.8242	.4696	.7947	.4363
10	1.0518	.7633	.1656	.3251	.4696	.7225	.3781
11	1.0114	.8131	.1656	.2167	.2167	.4696	.1806
12	.8276	.7799	.2035	.1804	.1834	.4696	.1806
13	.8642	.8297	.1987	.18	.1667	.2347	.1445
14	1.0082	.7965	.149	.2167	.15	.2347	.1445
15	1.1198	.7467	.1696	.289	.1667	.2374	.1806
16	.5599	.697	.1696	.3251	.2	.2439	.1806
17	.5599	.2834	.407	.4681	.2667	.7947	.6502
18	.7405	.6001	.78	.5418	.4515	.9156	.8669
19		.9836	.9106	.7405	.9065	.9603	1.0114
20		.6335	.8987	1.0082	1.0114	.9156	1.1017
21	.9211	.4149	.6013	.8669	.9211	1.0476	.8669
22	.7405	.4978	.5498	.6502	.578	1.0971	.7405
23	.6863	.5642	.5182	.6863	.5418	1.1163	.7225
24	.4748	.5001	.5974	.7773	.8308	.6141	1.2282
Max	1.1267	1.1836	1.1284	1.1264	2.1989	1.4088	2.2757
Min	.4748	.2834	.149	.18	.15	.2347	.1445
Avg	.8432	.7513	.5910	.6682	.8885	.8088	.9279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 206 / 11 KV NEW NEVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1026	1.7415	.3818	.4877	.6283	.5061	.5759
2	2.2213	1.9949	.4454	.6706	.8377	.5585	.6624
3	2.2185	2.1532	.5727	.7926	.89	.6981	.6981
4	2.34	2.549	.7159	.9511		.8551	.8377
5	2.3908	2.2323	.8909	.9957	.9773	1.0645	.89
6	2.4247	2.1532	1.0818	1.0669	1.1867	1.2216	1.082
7	2.4078	1.0818	1.1136	1.17	1.1169	1.1867	1.0645
8		.6682	.9227	.9511	1.0994	1.0471	.9773
9	.6283	.5409	2.7152	2.0656	1.9197	1.8499	1.623
10	.5934	.3659	2.7152	2.5479	1.9197	1.8499	2.0244
11	.3141	.2864	2.649	2.8097	2.1373	1.9197	2.1116
12	.2094	.2386	2.5165	2.4607	2.1057	2.2513	2.3734
13	.1745	.2068	2.4338	2.4607	2.0582	1.9662	2.3734
14	.1745	.1909	2.2934	2.3211	1.9315	2.1026	2.3385
15	.2094	.2227	2.3739	2.1989	1.8524	1.8821	2.3036
16	.3316	.2386	2.3569	2.0942	1.8049	1.6309	2.1989
17	.3316	.4295	.5765	.541	.3182	.671	.6981
18	.6981	.5568	.8139	.6283	.4014	.7285	.8377
19	.9773	.9704	.7285	.8377	.9773	.8023	.9773
20	.8377	.7795	.7511	.9773	1.0122	.9496	.89
21	.8377	.5409	.4487	.89	.9075	.8377	.8551
22	1.0645	.4295	.4193	.8368	.7504	.7155	.7155
23	1.1867	.3977	.4268	.6283	.578	.6632	.6632
24	2.0856	1.2032	.3659	.4268	.4686	.4886	.5418
Max	2.4247	2.549	2.7152	2.8097	2.1373	2.2513	2.3734
Min	.1745	.1909	.3659	.4268	.3182	.4886	.5418
Avg	1.1635	.9239	1.2796	1.3254	1.2121	1.1853	1.2631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 201 / 11 KV NACHANWEL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1886	.1715	.1715	.1715
2	.1715	.1715	.1715	.1886		.1715	
3		.1715	.2572	.2829	.1715		.2572
4	.2572	.2572	.2572	.2572	.2572	.3429	.2286
5	.3429	.3429	.3429	.2572	.3429	.4287	.4287
6	.3429	.3429	.3429	.3429		.4001	.6001
7	.3429	.4287	.4287	.4287	.4287	.2572	.2572
8		.3429	.3429	.4287	.1715		
9	.3429	.3429	.2572	.3429	.1143	.2572	.1715
10	.3429	.3429	.2572	.4287	.1715		.1715
11	.3429	.3429	.3429	.5144	.1143	.3429	.1715
12	.3429	.4287	.5144	.5144		.1715	.1715
13	.3429	.3429	.4287	.3429	.1715		.1715
14	.3429	.3429	.4287	.3429	.1715	.1715	.1715
15	.2572	.3429	.3429	.3429	.1715	.1143	.1715
16	.2572	.2572	.2572	.2572	.1715	.1715	.1715
17	.1715	.1715	.1715	.2572	.1715	.1715	.2572
18	.1715	.1715	.1715	.1715	.1715	.1715	.1715
19	.2572	.0857	.1715	.1715	.2572	.1715	.1715
20	.2572	.1715	.2572	.1715	.2572	.2572	.1715
21	.1886	.1715	.2572	.1715		.1715	.2572
22	.1886	.1715	.1715	.1886	.1715	.1715	.1715
23	.1886	.1715	.1715	.1886	.1715	.1715	.1715
24	.1715	.1886	.1715	.1886	.1886	.1715	
Max	.3429	.4287	.5144	.5144	.4287	.4287	.6001
Min	.1715	.0857	.1715	.1715	.1143	.1143	.1715
Avg	.2634	.2615	.2786	.2904	.2009	.2229	.2232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 202 / 11 KV DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1715	.0857	.1886	.1143	.0886	.0857
2		.1715	.1715	.1886	.4572		.1715
3	.1715	.1715	.1715	.2829		.0857	.1715
4	.2286	.2572	.2572	.3429	.1715	.0857	
5	.4287	.3429	.4287	.3429	.2572	.0286	.2572
6	.3429	.4287	.2572	.5144	.3429	.1715	.3429
7	.2572	.5144	.2572	.2572	.2286		.4287
8		.3429	.1715	.1715		.2572	.2286
9	.2572	.2572	.0857	.2572	.1715	.1715	
10	.1715	.0857		.0857	.2572	.2572	.1715
11	.0857	.0857	.0857	.0857	.2572	.2572	.2572
12	.0857	.0857	.0857	.0857	.1715		.2572
13	.0857	.0857	.0857	.0857		.2572	.2572
14	.0857	.0857	.0857	.0857	.0857	.1715	.2572
15	.0857	.0857	.0857	.0857	.0857	.1715	.1715
16	.0857	.0857	.0857	.0857	.1715	.1715	.1715
17	.0857	.1715	.0857	.1715	.0857	.1715	.1715
18	.1715	.1715	.1715	.1715	.1715	.1715	.1715
19	.2572	.0857	.1715	.1715	.1715	.1715	.0857
20	.2572	.0857	.0857	.1715	.2572	.2572	.0857
21	.1715	.1715	.1715	.1715	.1715	.2572	.1715
22	.1886	.1715	.1715	.1886	.0857	.1715	.1715
23	.1886	.0857	.1715	.1886	.0857	.1715	.0857
24	.1715	.1886	.0857	.0943	.1886	.0857	
Max	.4287	.5144	.4287	.5144	.4572	.2572	.4287
Min	.0857	.0857	.0857	.0857	.0857	.0286	.0857
Avg	.1808	.1829	.1528	.1865	.1900	.1730	.1987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 203 / 11 KV SAROLA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1886	.1715	.1715	.0857
2	.2572	.1715	.1715	.1715	.1143	.1143	.0857
3	.3429	.1715	.1715	.2572	.3086	.1143	
4	.5144	.2572	.2572	.2572			.1715
5	.5487	.3429	.3429	.3429	.2572	.3429	.2572
6	.6859	.5144	.5144	.5144	.3429	.2286	
7		.6001	.3429	.3429	.3429	.4287	.4287
8		.3429	.3429	.3429	.2572	.3429	.3429
9	.3429	.3429	.3429	.3429			.3429
10	.1715	.1715	.1715	.2572	.2572	.1715	.2572
11	.1715	.1715	.0857	.1715	.2572	.1715	.2572
12	.0857	.0857	.0857	.1715	.2572	.1715	.2572
13	.0857	.0857	.0857	.1715	.1715	.1143	.1715
14	.0857	.0857	.0857	.0857	.1715		.1715
15	.0857	.0857	.0857	.0857	.1143	.1715	.1715
16	.0857	.0857	.0857	.0857	.1715	.1715	.0857
17	.0857	.0857	.0857	.1715	.0857	.1715	.0857
18	.1715	.0857	.1715	.1715	.2572	.1715	.1715
19	.3429	.1715	.1715	.2572	.3429	.2572	.2572
20	.3429	.2572	.2572	.2572	.3429	.2572	.2572
21	.1715	.2572	.1715	.1715	.2572	.2572	.2572
22	.1886	.1715	.1715	.1886	.1715	.1715	.1715
23	.1886	.1715	.1715	.1886	.1715	.1715	.1715
24	.2572	.1886	.1715	.1886	.1886	.1715	
Max	.6859	.6001	.5144	.5144	.3429	.4287	.4287
Min	.0857	.0857	.0857	.0857	.0857	.1143	.0857
Avg	.2447	.2115	.1965	.2243	.2278	.2069	.2123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 204 / 11KV DONGARGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0943	.0857	.0857	.0857
2	.0572	.0857	.0857	.0943	.0572	.0572	.0857
3	.0857	.0857	.0857	.0943	.0857	.0857	
4	.1715	.1715	.1715	.1886	.1143		.1715
5	.2572	.1715	.2572	.1886	.1143	.1143	.1715
6	.3429	.2572	.2572	.2572		.2572	.2572
7	.2286	.2572	.3429	.3429	.2572	.2572	.3429
8		.2572	.2572	.2572	.1715		.2572
9	.1715	.1715	.1715	.1715		.1715	.1715
10	.0857	.1715	.1715	.1715	.0857	.1715	.0857
11	.0857	.0857	.0857	.0857	.0572	.0857	.0857
12	.0857	.0857	.0857	.0857	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857	.0572	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0572	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857	.0857	.0857	.0857	.0857
18	.0857	.0857	.0857	.0857	.1715	.1715	.1715
19	.2572	.1715	.1715	.0857	.2572	.2572	.2572
20	.1715	.2572	.2572	.1715	.2572	.2572	.2572
21	.1886	.1715	.1715	.0857	.1715	.1715	.1715
22	.0943	.0857	.0857	.0943	.0857	.0857	.0857
23	.0943	.0857	.0857	.0943	.0857	.0857	.0857
24	.0857	.0943	.0857	.0943	.0943	.0905	
Max	.3429	.2572	.3429	.3429	.2572	.2572	.3429
Min	.0572	.0857	.0857	.0857	.0572	.0572	.0857
Avg	.1332	.1361	.1429	.1322	.1199	.1314	.1481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 205 / 11 kv NACHANWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1886	.1715	.1715	.1715
2		.1715	.1715	.1886	.1143	.1715	.1143
3	.2572	.2572	.2572	.1886	.2572		.1715
4	.3429	.3429	.4287	.3429		.1143	
5	.6001	.5144	.6001	.6001	.3429	.5258	.6859
6	.6859	.6859	.7716	.7716	.4572	.5144	.8573
7	.7716	.9431	.8573	.8573		.5144	.7716
8	.7716	.6859	.7716	.8573	.4572	.5144	.6859
9	.4572	.5144	.6001	.6859	.5144	.4001	.6001
10	.4287	.4287	.4287	.5144	.3429		.3429
11	.2572	.2572	.2572	.3429	.2572	.2572	.2572
12	.1715	.1715	.2572	.3429	.2572	.2572	.1715
13	.1715	.1715	.1715			.1715	.1715
14	.1715	.1715	.1715		.1715	.1143	.1715
15	.1715	.0857	.1715		.1715	.1715	.1715
16	.1715	.1715	.1715	.1715	.1715	.1715	.1715
17	.2572	.1715	.1715	.1715	.2572	.2572	.2572
18	.4287	.4287	.3429	.2572	.4287	.4287	.4287
19	.6859	.6859	.7716	.5144	.6859	.7716	.7716
20	.5144	.7716		.5144	.6859	.7716	.7716
21	.3772	.4287	.4287	.3429	.4287	.4287	.4287
22	.1886	.3429	.2572	.2829	.2572	.2572	.2572
23	.1886	.2572	.1715	.1886	.2572	.1715	.1715
24	.1715	.1886	.1715	.1886	.1886	.1715	
Max	.7716	.9431	.8573	.8573	.6859	.7716	.8573
Min	.1715	.0857	.1715	.1715	.1143	.1143	.1143
Avg	.3658	.3758	.3728	.4054	.3274	.3331	.3910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 206 / 11 kv SAROLA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.0857	.0943	.0572	.0572	.0857
2	.0857	.0857	.0857	.0857		.0572	
3		.0857	.0857	.0857	.0857	.0857	.0857
4	.2572	.1715	.1715	.1715	.1715	.1143	.1715
5	.4287	.3429	.3429	.2572	.3429	.2572	.4287
6	.5144	.4287	.4287	.4287	.5144		.5144
7	.5144	.5144	.5144	.5144	.5144	.5144	
8	.5144	.4287	.5144	.5144	1.0288	.4287	.4287
9	.4287	.4287	.3429	.4287	.2286	.3429	.1715
10	.2572	.3429	.2572	.3429			.1715
11	.1715	.1715	.1715	.1715	.0857		.1715
12	.0857	.0857	.0857	.1715	.0572		.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857		.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.1715
16	.0857	.0857	.0857	.0857	.0857	.0857	.1715
17	.0857	.1715	.1715	.1715	.0857	.0857	.1715
18	.1715	.4287	.2572	.1715	.1734	.2572	.3429
19	.3429	.5144	.4287	.3429	.3429	.4287	.5144
20	.3429	.4287	.4287	.3429	.3429	.5144	.4287
21	.1886	.2572	.2572	.3429	.1715	.1715	.1715
22	.0943	.1715	.1715	.1886	.0857	.0857	.1715
23	.0943	.1715	.0857	.0943	.0857	.0857	.0857
24	.1715	.0943	.0857	.0943	.0943	.0857	
Max	.5144	.5144	.5144	.5144	1.0288	.5144	.5144
Min	.0857	.0857	.0857	.0857	.0572	.0572	.0857
Avg	.2251	.2433	.2215	.2233	.2250	.1958	.2245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 207 / MOHADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1715	.1715		.0572	.0857	.0572
2	.1715	.1715	.1715		.0572		.0857
3	.1715	.1715	.1715	.0943	.0572	.0857	
4	.2058	.2572	.2572	.1715	.1143	.1715	.0857
5		.3429	.3429	.1715		.1715	.1143
6	.4287	.3429	.4287	.3429	.1715		.2572
7	.1715	.4287	.1715	.1715	.1715	.2572	.1715
8	.1715	.1715	.1715	.1715	.1715	.2572	.1715
9	.1715	.1715	.1715	.1715	.1715	.2572	.2572
10	.1715	.0857	.0857	.1715		.1715	.2572
11	.0857	.0857	.0857	.1715	.1143	.1715	.2572
12	.0857	.0857	.0857	.1715	.1143	.1143	.1715
13	.0857	.0857	.0857	.1715	.1715	.1715	.1715
14	.0857	.0857	.0857	.1715	.1715	.0857	.1715
15	.0857	.0857	.0857	.1715	.1143	.0857	.1715
16	.0857	.0857	.0857		.1715	.0857	.0857
17	.0857	.0857	.0857		.0857	.0857	.0857
18	.1715	.0857	.0857	.0857	.1715	.0857	.0857
19	.1715	.1715	.0857	.1715	.1715	.0857	.0857
20	.1715	.0857	.0857	.1715	.1715	.0857	.0857
21	.1886	.0857	.0857	.1715		.1715	.0857
22	.1886	.0857	.0857	.1886	.0857	.0857	.0857
23	.1886	.0857		.1886	.0857	.0857	.0857
24	.1715	.1886	.1715		.1886	.0857	
Max	.4287	.4287	.4287	.3429	.1886	.2572	.2572
Min	.0857	.0857	.0857	.0857	.0572	.0857	.0572
Avg	.1578	.1543	.1454	.1737	.1328	.1338	.1403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 210 / MOHRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.0857	.0943	.1143	.1143	.1715
2	.1715	.1715	.1715	.1715		.1143	.1715
3	.2572	.1715	.1715	.1715	.1715		.3429
4		.2572	.2572	.2572	.2572	.3429	.3429
5	.3429	.3429	.2572	.2829	.2286	.5144	
6	.3429	.3429	.3429	.3429	.4287	.6001	.6001
7	.2286	.4287	.4287	.4287	.5144		.2572
8	.3429	.3429	.4287	.4287	.1143	.1715	
9	.2572	.3429	.2572	.3429		.1715	.2572
10	.2572	.2572	.2572	.3429	.1715	.1715	.0857
11	.1715	.2572	.2572	.3429	.1143	.0857	.0857
12	.1715	.2572	.2572	.3429	.1715	.0857	.0857
13	.1715	.2572	.2572	.3429	.1715		.0857
14	.1715	.2572	.3429	.2572		.0857	.0857
15	.1715	.2572	.1715	.2572	.0857	.0857	.0857
16	.1715	.1715	.2572	.2572	.0857	.0857	.0857
17	.1715	.0857	.1715	.0857	.0857	.0857	.0857
18	.1715	.1715	.0857	.0857	.2572	.1715	.1715
19	.2572	.1715	.1715	.1715	.2572	.2572	.2572
20	.3429	.2572	.2572	.1715	.1715	.2572	.2572
21	.1715	.1715	.1715	.1715	.1715	.1715	.1715
22	.1886	.1715	.1715	.1886	.1715	.1715	.1715
23	.1886	.0857	.1715	.1886	.0857	.1715	.1715
24	.1715	.1715	.0857	.0943	.1886	.1715	
Max	.3429	.4287	.4287	.4287	.5144	.6001	.6001
Min	.1715	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2202	.2322	.2286	.2426	.1913	.1946	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 201 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.9602	1.1336	.5716	.2401	.2561	.2572
2	1.0402	.9602	1.2146	.5716	.2401	.2561	.2743
3	1.1203	1.0402	1.2955	.4763	.4001	.3201	.3429
4	1.2803	1.1203	1.3765	.6668	.4801	.3201	.4287
5	1.3603	1.2803	1.4575	.5906	.5121	.5121	.6173
6	1.7284	1.5203	.362	.6859	.5761	.5441	.5921
7			.381	.5716	.6081	.5441	.5441
8			.9717		.5121	.4961	.5281
9	.4801	.5487	.6097	.1715	1.6804	1.166	1.1203
10	.5761	.463	.5906	.1715	1.8564	1.4089	1.8084
11	.2721	.3429	.3239	1.7147	1.8404	1.3765	1.7604
12	.2721	.3258	.362	1.7814	1.7924	1.3279	1.8564
13	.2881	.2915		1.6194	1.7604	1.3117	1.7604
14	.2881	.2572		1.4575	1.6004	1.5061	1.7604
15	.2561	.2572	.2286	1.6194	1.6324	1.5061	1.6804
16	.2881	.2401	.381	1.7976	1.6964	1.4899	1.6804
17	.3201	.2572	.381	.2591	.128	.2743	.192
18	.3841	.5144	.4763	.3239	.2721	.2915	.2721
19	.4641	.6001	.3048	.4287	.4801	.5487	.4801
20	.3521	.5144	.4001	.3944	.3841	.583	.4801
21	.7522	1.1145	.4191	.3086	.2561	.3239	.3201
22	1.0082	1.1336	.4763	.2572	.2721	.2572	.3041
23	1.0082	1.1336	.4001	.2572	.2721	.2572	
24	1.0526	.9602	1.0936	.5144	.2572	.2561	.2572
Max	1.7284	1.5203	1.4575	1.7976	1.8564	1.5061	1.8564
Min	.2561	.2401	.2286	.1715	.128	.2561	.192
Avg	.7106	.7198	.6654	.7483	.8229	.7139	.8399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 202 / 11KV NIMBHORA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.2096	.7287	.9602	.282	.7287
2	.1905	.1524	.2096	.9555	.9602	.282	.7287
3	.1905	.1524	.1905	.9069	1.0402	.381	.7811
4	.2858	.1905	.2286	.9717	1.1203	.5121	.8592
5	.362	.2286	.2858	1.2146	1.2163	.5761	.9717
6	.381	.1905	.362	1.4575	1.6324	.9602	1.2323
7	.3429	.4191	.381	.381	.4191	.3429	.4382
8	.3048	.3048	.9717	.2858	.3429	.2477	.2858
9	1.9052	1.2955	.8097	.1715	.2667		.1905
10	1.8404	1.749	1.7652	.1715	.1905	.1905	.1905
11	1.9204	1.7814	2.1376	.1715	.2286	.1905	.1905
12	2.0005	1.7976	2.1214	.1543	.2286	.1905	.1524
13	1.9204	1.7976	1.8623	.1715	.2286	.1905	.1143
14	1.9204	1.7814	1.7814	.1715	.2286	.1715	.1143
15	1.7604	1.7814	1.8623	.1715	.2286	.1715	.1143
16	1.7604	1.6842	1.9109	.1715	.2286	.1886	.1334
17	.1334	.0857		.2401	.2286	.1715	.1524
18		.1715	.5716		.2667	.1372	.2286
19	.2667	.2572	.5716	.1715	.2667	.2743	.3048
20	.1524	.2058	.5906	.1372		.1886	.3048
21	.1524	.1715	.7049	.8907	.381	.6001	.9602
22	.1524	.1715	.7621	1.0288	.2667	.6859	1.1203
23	.1524	.1715	.8573	.9717	.2553	.7287	
24	.1715	.1524	.1715	.5992	.9717	.282	.7287
Max	2.0005	1.7976	2.1376	1.4575	1.6324	.9602	1.2323
Min	.1334	.0857	.1715	.1372	.1905	.1372	.1143
Avg	.8025	.7019	.9269	.5346	.5286	.3455	.4794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 203 / 11KV DEVPUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.16	.1905	.7449	.8002	.4001	.5144
2	.2858	.16	.1905	.8907	.8002	.4001	.6001
3	.2858	.192	.3048	.9431	.8322	.4801	.6478
4	.3201	.2561	.3429	.8583	.8802	.5601	.7287
5	.3841	.3201	.381	.8421	.8962	.6401	.8583
6	.3841	.3841	.4572	.8259	1.0242	.8002	1.0242
7	.4481	.3841	.4572	.1905	.381	.3201	.3841
8	.3841	.3201	1.1336	.0953	.3841	.3201	.2561
9	1.3603	.9878	.9717	.2743	.2561	.5335	.2561
10	1.3603	1.2955	1.0526	.2743	.3201	.2591	.192
11	1.3603	1.2631	1.0288	.3429	.2561	.2286	.128
12	1.2803	1.2308	.8745	.2743	.3201	.2286	.192
13	1.2163	1.0623	.8097	.3429	.3201	.3048	.192
14	1.1523		.9231	.2743	.2561		.192
15	1.1523			.3429			.2561
16	1.2003	1.0364	.9717	.3429	.2561	.1372	.381
17	.192	.3239	.2858	.2743	.3201	.2058	.2561
18	.2561	.4115	.1905	.3429	.3841	.2058	.3201
19	.3841	.4115	.2286	.3429	.4481	.4115	.3201
20	.192	.4115	.1905	.2743		.3429	.3201
21	.192	.2743	.2096	.8097	.4001	.4287	.6562
22	.192	.2058	.9717	.8421	.4001	.5144	.8802
23	.16	.1715	.8097	.8421	.4001	.4858	
24	.2572	.16	.1715		.8421	.4001	.5144
Max	1.3603	1.2955	1.1336	.9431	1.0242	.8002	1.0242
Min	.16	.16	.1715	.0953	.2561	.1372	.128
Avg	.61	.5192	.5716	.5038	.5081	.3913	.4378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 204 / 11 KV MEHGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3191	.5716	.5716	.1524	.0953	.0762	.0857
2	.3191	.4001	.4858	.1334	.0953	.0762	.0857
3	.3887	.423	.4999	.1334	.0953	.0953	.0857
4	.423	.4652	.5668	.1334	.1334	.1143	.1029
5	.4793	.5075	.5668	.1334	.1524	.1334	.12
6	.7164	.578	.6478	.1334	.1715	.1715	.1524
7	.1905	.0987	.1715	.1715	.1905	.1715	.1524
8	.1715	.1334	.1715	.0953	.1524	.1143	.1524
9	.1334	.1372	.1143	.9717	.7331	.4801	.5716
10	.0953	.1029	.1143	1.004	.8882	.5992	.6626
11	.0953	.0857	.1334	1.0364	.9602	.6478	.743
12	.1524	.0857	.1143	1.1012	1.2003	.6964	.7613
13	.144	.12	.0762	1.1317	1.1431	.7287	.7613
14	.1715	.0857	.0762	1.1145	1.0098	.7287	.727
15		.0857	.0953	1.0288	.8383	.8573	.7407
16	.1143	.0857	.0953	1.0288	.8642	.8097	.7407
17	.1905	.1029	.0953		.0953	.0648	.0953
18	.1334	.1029	.0953	.0857	.1143	.0648	
19	.1715	.1543	.1524	.1029	.1334	.12	.1524
20	.1334	.1543	.0953	.12	.1143	.12	.1524
21	.4001	.5144	.1143	.0857	.0953	.0857	.0953
22	.6097	.4858	.1334	.0857	.0953	.0857	.0953
23	.5906	.4858	.1524	.0857	.0953	.0857	
24	.4287	.4001	.4858	.1715	.0857	.0762	.0857
Max	.7164	.578	.6478	1.1317	1.2003	.8573	.7613
Min	.0953	.0857	.0762	.0857	.0857	.0648	.0857
Avg	.2857	.2653	.2427	.4452	.3980	.3001	.3328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 205 / 11KV NIMBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0953	.0953	.0953	.0572	.0572	.0686
2	.0572	.0953	.0953	.1143	.0572	.0572	.0686
3	.0762	.1143	.1143	.1715	.0762	.0953	.0857
4	.0953	.1905	.2096	.1905	.1143	.1524	.12
5	.1334	.2667	.2286	.2286	.1524	.1905	.1543
6	.2096	.3048	.3048	.3429	.2286	.2286	.2286
7	.2858	.362	.3239	.2858	.2858	.2477	.2858
8	.2667	.3239	.3239	.2096	.2096	.2286	.1905
9	.1905	.2401	.2096	.1715	.1905	.1715	.1905
10	.1524	.1543	.1715	.1715	.1143	.1029	.0953
11	.0953	.12	.1715	.1372	.0762	.0857	.0762
12	.0762	.0857	.0762	.12	.0572	.0514	.0762
13	.0762	.0857	.0953	.0857	.0572	.0514	.0762
14	.0572		.0953	.0857	.0572	.0514	.0572
15	.0572		.0953	.0857	.0572	.0514	.0572
16	.0572		.0953	.0514	.0572	.0514	
17	.0953		.1905	.0857	.0953	.0686	.0572
18			.2667	.0857	.1334	.0686	.1334
19	.3048		.3048	.12	.2286	.1886	.2096
20	.2286		.0953	.1029		.1715	.1905
21	.1524		.1334	.0857	.0762	.12	.1143
22	.1334		.1143	.0686	.0762	.0857	.0762
23	.1143		.0953	.0514	.0572	.0686	.0762
24	.0514	.0953	.0953	.1334	.0514	.0572	.0686
Max	.3048	.362	.3239	.3429	.2858	.2477	.2858
Min	.0514	.0857	.0762	.0514	.0514	.0514	.0572
Avg	.1315	.1810	.1667	.1367	.1116	.1126	.1199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 206 / 11KV WASADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0953	.1715	.0953	.0762	.0857
2	.0762	.0953	.0953	.1524	.0953	.0762	.0857
3	.0953	.1334	.1143	.1715	.1143	.0953	.1029
4	.1334	.1715	.0953	.1143	.1524	.1524	.1372
5	.1715	.1905	.1905	.1905	.1715	.1905	.1543
6	.2286	.2286	.2286	.2286	.2477	.2286	.2286
7	.2477	.2858	.2667	.2477	.2667	.3048	.2667
8	.2477	.2286	.2286	.2477	.2286	.2477	.2286
9	.2096	.1905	.1715	.1715	.1715	.1715	.2286
10	.1334	.1334	.1143	.1715	.1524	.1029	.1524
11	.1143	.1143	.0953	.1543	.0953	.0857	.1143
12	.0953	.0953		.1372	.0953	.0857	.1143
13	.0762	.0762		.0857	.0953	.0857	.1143
14	.1143	.0953		.0857	.1143	.0857	.1143
15	.1524	.0953	.0953	.0857	.0572	.0857	.0953
16	.0953	.0953	.0953	.0857	.0953	.1029	.0953
17	.1143	.0953		.1372	.0953	.1029	.1334
18	.1334	.1334	.1334	.1543	.1334	.12	.1334
19	.2477	.2096	.2096	.1715	.1905	.2229	.1905
20	.2286	.2096	.0953	.1372	.1524	.2572	.2096
21	.1715	.1524	.1143	.1372	.0953	.1715	.2096
22	.1905	.1143	.1143	.1029	.0953	.12	.1524
23	.1334	.0953	.1334	.0857	.0953	.0857	.1334
24	.0686	.0953	.0953	.1715	.0857	.0762	.0857
Max	.2477	.2858	.2667	.2477	.2667	.3048	.2667
Min	.0686	.0762	.0953	.0857	.0572	.0762	.0857
Avg	.1481	.1429	.1391	.1500	.1330	.1389	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 207 / 11KV MEHGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.3429	.1143	.1143	.1029
2	.1143	.1143	.1143	.2667	.1143	.1143	.1029
3	.1143	.1524	.1524	.2667	.1905	.1905	.12
4	.2858	.3048	.2286	.4763	.2858	.3048	.2572
5	.362		.381	.5335	.362	.381	.3772
6	.381	.5525	.5144	.5525	.4954	.5144	.5335
7	.5906	.6097	.5716	.5335	.5906	.6097	.5335
8	.5335	.4954	.4763	.4763	.4763	.4763	.4382
9	.381	.381	.3429	.3429	.362	.3258	.3429
10	.1905	.2667	.3429	.3429	.2477	.2058	.2477
11	.1143	.2096	.1715	.2915	.1524	.12	.1143
12	.0953	.0953	.1143		.0953	.0857	.1143
13	.0762	.0953	.0953		.1143	.0686	.1143
14	.0953	.0953	.1334		.1334		.1143
15	.1143	.0953		.1372			.1143
16	.1334	.0953	.1715	.1029	.1334	.0686	.1143
17	.1715	.1143	.2858		.1524	.0857	.1524
18	.2667	.1905	.381	.1715	.2096	.1715	
19	.4763	.381	.4572	.3429	.4382	.3601	.4191
20	.3239	.381	.1905	.2401	.3048	.4115	.381
21	.1905	.2858	.2096	.1543	.1715	.2572	.2286
22	.1524	.2096	.2096	.12	.1334	.1372	.1524
23	.1334	.1143	.1715	.1029	.1143	.1029	.1334
24	.1029	.1143	.1143	.2096	.1029	.1143	.1029
Max	.5906	.6097	.5716	.5525	.5906	.6097	.5335
Min	.0762	.0953	.0953	.1029	.0953	.0686	.1029
Avg	.2297	.2377	.2584	.3004	.2389	.2373	.2309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 201 / 11 KV KARANJKHEDA AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0953	.0857	.6001	.6859	.8907
2	.0857	.0686	.0953	.0857	.6687	.7716	.8907
3	.0857	.0686	.0953	.0857	.7716	.7888	.9717
4	.0857	.0686	.1143	.1029	.8573	.8059	1.0526
5	.0857	.0686	.1143	.1029	.9602	.8573	1.0526
6	.0857	.0686	.1143	.1029	1.0117	.9431	1.166
7	.0857	.0686	.0953	.0686		1.1145	
8	.0857	.0686	.0953	.0686			
9	.2591	.7935	.6859	.8421	.0171		
10		.9717	.6554				
11	.4049	1.0364	.8383	.9259			
12	.3887	1.1888	1.085	1.0288			
13	1.0526	1.0669	1.1336	1.2003	.0171	.0171	.0191
14	1.2308	1.0669	1.166	1.2003	.0171	.0171	.0191
15	1.2308	1.0059	1.166	1.2346	.0171	.0171	.0191
16	1.1336	.945	1.1822	1.2003	.0686	.0171	.0191
17	.0343	.0381	.0343	.061	.0171	.0514	
18	.0514	.0381	.0686	.0514	.0686	.0686	.0191
19	.0686	.0572	.0686	.0171	.0171	.0686	.0381
20	.0686	.0953	.0857	.0171	.0686	.0514	.0762
21	.0686	.0953	.0857	.5144	.4287	.6478	.6706
22	.0686	.0953	.1029	.6173	.5144	.7611	.8535
23	.0686	.0953	.1029	.6173	.6001	.8097	.8383
24	.0857	.0686	.0953	.1029	.0857	.6859	.8097
Max	1.2308	1.1888	1.1822	1.2346	1.0117	1.1145	1.166
Min	.0343	.0381	.0343	.0171	.0171	.0171	.0191
Avg	.3000	.3836	.3907	.4493	.3583	.4832	.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 202 / 11 KV NAGAPUR AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1494	.1543	.5144	.0857	.4858
2	.1543	.1372	.1663	.1543	.5487	.6001	.5182
3	.1543	.1372	.1867	.1715	.583	.6173	.5506
4	.1715	.1372	.1848	.1715	.6173	.6516	.6348
5	.1715	.1372	.1867	.1715	.5316	.6687	.6478
6	.1715	.1715	.2033	.1886	.5316	.6859	.7125
7	.1715	.1886	.2241	.1715		.7716	
8	.1715	.12	.1867	.1372			
9	.4858	.4534	.6097	.5668			
10	.6154	.4534	.6802	.6516			
11	.664	.6401	.7449	.7888			
12	.583	.6859	.7611	.8573	.0171		.0671
13	.7773	.5735	.6802	.7202	.0686	.0514	.0829
14	.7935	.5487	.6154	.6516	.0686	.0514	.0838
15	.664	.6097	.5506	.583	.0857	.0514	.0924
16	.6478	.6249	.6478	.6859	.0686	.0514	.0838
17	.0857	.0924	.0857	.1372	.0686	.0686	.112
18	.12	.1307	.1372	.12	.1029	.12	.0995
19	.1715	.168	.1715	.12	.1715	.1372	.1844
20	.1715	.1341	.1886	.12	.12	.1543	.1867
21	.1715	.1494	.1372	.3601	.4115	.3772	.381
22	.1372	.1307	.1029	.4458	.4287	.4534	.5182
23	.12	.1307	.1029	.4801	.4287	.4534	.4877
24	.1029	.12	.1494	.1029	.4973	.4973	.4696
Max	.7935	.6859	.7611	.8573	.6173	.7716	.7125
Min	.0857	.0924	.0857	.1029	.0171	.0514	.0671
Avg	.3180	.2838	.3272	.3630	.3087	.3446	.3368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 203 / 11 KV PURANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	.8097	.7773	.8907	.12	.0857	.12
2	1.0688	.8421	.7621	.9393	.1029	.12	.12
3	1.0688	.9393		.9717	.1029	.0857	.12
4	1.1336	.9717	.7621	.9717	.1029	.0857	.12
5	1.166	1.0688	.7621	1.004	.1029	.0686	.12
6	1.1984	1.2793	1.0059	1.0688	.1372	.0686	.1307
7					.1372	.1029	.12
8					1.2689	.0857	.1029
9					1.3203	.6859	.8421
10					1.3717	.9393	1.1012
11					1.3889	.9555	1.0669
12					1.5261	1.1498	1.0974
13	.0514	.0373	.0514		1.4575	1.1984	1.0669
14	.0514	.0187	.0486		1.3717	1.004	1.0794
15	.0514	.0187	.0514	.0514	1.3717	.9231	1.0526
16	.0514	.0187	.0514	.0686	1.406	.9717	1.1174
17	.0857	.0187	.0514	.0514	.0686	.0686	.0187
18	.0857	.056	.0857	.0857	.1029	.0686	.0187
19	.0857	.0747	.1029	.0857	.1029	.0686	.0747
20	.0857	.0934	.1029	.0857	.1029	.1029	.112
21	.5992	.6706	.7125	.0857	.1029	.1029	.1307
22	.6802	.7926	.9069	.0857	.1029	.12	.1307
23	.7449	.7926	.9393	.0857	.1029	.12	.1494
24	1.0364	.7449	.7773	.9393	.1029	.1029	.12
Max	1.1984	1.2793	1.0059	1.0688	1.5261	1.1984	1.1174
Min	.0514	.0187	.0486	.0514	.0686	.0686	.0187
Avg	.5721	.5138	.4677	.4669	.5866	.3869	.4222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 204 / 11kv KARANJKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.3734	.3734	.3429	.3429	.3734
2	.4481	.4481	.4108	.4108	.3772	.3601	.3921
3	.4854	.4854	.4481	.4481	.4115	.5144	.4854
4	.5228	.5041	.5228	.5228	.6516	.5144	.5228
5	.6908	.7095	.6908	.6908	.8402	.703	.5975
6	.8962	.9149	.9335	.9335	1.0117	.7202	.8962
7	1.0829	1.0642	1.0456	1.1016	1.0117	.8745	1.1203
8	.9335	.8589	.9522	1.0269	.9431	.9431	.9896
9	.8215	.7468	.7842	.7611	.8402	.7202	.8962
10				.7545	.7545		.7282
11	.5601	.6602	.5228	.4801	.6516	.5601	.4854
12	.4108	.503	.4668	.3429	.3429	.5041	.4024
13	.3734	.4527	.4108	.3601	.3258	.3547	.3521
14	.3547	.3734	.3734	.3429	.3086	.3547	.4108
15	.3734	.3734	.3921	.2915	.2743	.3547	.3521
16	.4854	.3734	.3921	.2915	.3258	.3734	.4108
17	.5415	.4854	.5228	.3429	.3601	.4668	.4294
18	.6348	.5975	.6722	.4458	.5144	.5601	.5601
19	.8402	.8402	.7468	.5487	.7202	.8589	.7625
20	.7842	.7468	.8402	.7202	.6859	.8775	.9335
21	.4108	.5601	.5975	.703		.6908	.5788
22	.3734	.4191	.4854	.5487		.5228	.5041
23	.3361	.4481	.4481	.3429	.3601	.3921	.4668
24	.4108	.3734	.4108	.4108	.3086	.3429	.3734
Max	1.0829	1.0642	1.0456	1.1016	1.0117	.9431	1.1203
Min	.3361	.3734	.3734	.2915	.2743	.3429	.3521
Avg	.5731	.5804	.5845	.5498	.5620	.5611	.5843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 205 / 11KV REULGAON AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.664	.6706	.7125	.0343	.0171	.0171
2	.7773	.664	.6706	.7287	.0171	.0171	.0171
3	.7773	.7449	.6706	.7287			.0171
4	.8097	.7449	.6706	.7611	.0171	.0171	.0171
5	.7125	.7773		.7287	.0857	.0171	.0171
6	.6964	.7935	.823	.8745	.0343	.0171	.0171
7						.0171	.0171
8						.0171	.0171
9					.703	.6859	.9717
10					.8573		1.1012
11					1.0117	.9717	1.0669
12					1.0288	1.1984	.9145
13	.0171	.0191	.0171	.0171	1.1145	1.1336	1.0974
14	.0171	.0191	.0171	.0171	1.1145	1.247	1.2193
15	.0171	.0191	.0171	.0171	1.1145	1.2308	1.2193
16	.0171	.0191	.0171		1.286	1.1336	1.1736
17	.0171	.0191	.0171		1.286	.0162	.0191
18	.0171	.0191	.0171	.0171	.0343	.0171	.0191
19	.0171	.0191	.0171	.0171		.0171	.0191
20	.0171	.0191	.0171	.0173	.0171	.0171	.0191
21	.4858	.5335	.6802	.0171	.0171	.0171	.0191
22	.5182	.6401	.7449	.0171	.0343	.0171	.0381
23	.583	.6554	.7611	.0171	.0343	.0171	.0191
24	.7773	.6478	.6706	.7611	.0171	.0171	.0171
Max	.8097	.7935	.823	.8745	1.286	1.247	1.2193
Min	.0171	.0191	.0171	.0171	.0171	.0162	.0171
Avg	.3918	.3899	.3823	.3406	.4930	.3571	.3779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 206 / CHIMNAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.1867	.1867	.1715	.1715	.1867
2	.2241	.2241	.2241	.2241	.2058	.2058	.2241
3	.2614	.2614	.2614	.2614	.2401	.2401	.2614
4	.3361	.3361	.2683	.2987	.2401	.2743	.2987
5	.4108	.4108	.3734	.3734	.3086	.3429	.3734
6	.5601	.5601	.5415	.5415	.4973	.4801	.5415
7	.5975	.4481	.5415	.5601	.5316	.5487	.5601
8	.4854	.3361	.4108	.3361	.4458	.5144	.4481
9	.3361	.3361	.3361	.3361	.3086	.3772	.3547
10	.2054	.2054	.1989	.1715	.1715	.2054	.2241
11	.1307	.3361	.1307	.12	.1715	.1307	.168
12	.112	.1307	.0934	.0857	.1372	.0934	.112
13	.112	.0838		.1372	.1543	.0934	.0924
14	.112	.1307	.112	.1543	.1543	.0934	.112
15	.0934	.0934	.1307	.12	.1372	.112	.1006
16	.1307	.1494	.1307	.2058		.112	.1006
17	.1867	.1341	.168	.2401	.12	.112	.1509
18	.2801	.2587	.2614	.2743	.12	.168	.2054
19	.4481	.3856	.4294	.3086	.1372	.3547	.4108
20	.3921	.3921	.4668	.3258	.2058	.3921	.4108
21	.2987	.2614	.2801	.2743	.2401	.2987	.2987
22	.2427	.2614	.2614	.2401	.2572	.2801	.2801
23	.2241	.2241	.2241	.2229	.2401	.2054	.2427
24	.2054	.2054	.2054	.2054	.2058	.1886	.168
Max	.5975	.5601	.5415	.5601	.5316	.5487	.5601
Min	.0934	.0838	.0934	.0857	.12	.0934	.0924
Avg	.2746	.2654	.2712	.2585	.2349	.2498	.2636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 201 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8916	.6516	.7373	.8573		1.1317
2	.7716	1.0288	.7202	.7888	.9431		1.166
3	1.0288	1.166	.823	.8573	1.5432		1.2346
4	1.3546	1.5089	1.0631	1.2346	2.0576		1.5947
5		1.4403	1.3717	1.6804	2.6063		2.2291
6		1.3717	1.8004	2.2634	2.8292		2.8292
7	.7202	1.4575	2.5377	2.5206			2.6063
8			1.5947	1.749	1.5089		2.0576
9	1.286	1.0802	.9945	1.286	1.5432	1.2003	1.4403
10	1.0802	1.0288	.6001	1.2517	.5144		.6687
11	1.2003	1.046	.3944	.9431	.4287	.6859	
12	1.2517	1.0802	.3429	.6173	.3944	.6173	
13	.9602	1.0974	.463	.5487	.4115		
14	.823	1.166	.6001	.5144	.4287		.6001
15	.823	.9945	.7545	.5487	.4287	.7202	.6344
16	.823	.9945	.7373	.6001	.463	.9431	.6859
17	1.1145	.9259	.8059	.7202	.3429	.8573	.5487
18	1.3375	1.2003	1.166	.8402	.6687	1.2689	.6859
19	1.4575	2.1091	1.7661	1.8004	1.8004	1.749	1.2003
20	1.6975	1.989	1.749	1.5432	1.8347	1.8519	2.2119
21	1.3717	.6687	.9774	1.0631		1.3717	.9945
22	1.0631	.583	.823	1.0288		1.3546	1.0288
23	.8916	.5144	.7545	.8573		1.2003	1.0288
24	.8573	.8916	.6001	.7373	.6001		1.1145
Max	1.6975	2.1091	2.5377	2.5206	2.8292	1.8519	2.8292
Min	.7202	.5144	.3429	.5144	.3429	.6173	.5487
Avg	1.0802	1.1406	1.0038	1.1138	1.1103	1.1517	1.3187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 203 / 11kv JAMADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.6173	.6173	.7202	.7716	.703
2	.9431	.8916	.6173	.6173	.8573	.8573	.703
3	1.0802	1.1145	.6344	.6516	.9945	.8573	.7373
4	1.2003	1.6289	.9431	1.0631	1.286	.9088	1.1145
5	2.6578	2.0576	1.4403	1.5432	1.406	2.0576	1.6804
6		2.4863	2.0748	2.1605	1.7147	1.8861	2.2462
7	3.5837	2.0062	2.2119	2.1434	1.9719	1.9547	2.1605
8		1.4575	1.5432	1.7661	1.3032	1.286	1.5604
9		1.2003	1.6118	1.5775	1.1145		1.0802
10	.823	.6859	1.8004	2.0233	1.0288	1.1488	1.1145
11	.4287	.4287	1.7318	1.8347	1.286	.9602	1.1145
12	.3944	.3601	2.0919	1.7147		.9088	1.2003
13	.3429	.3086	2.1262	1.5432	1.3203	.8745	1.2003
14	.3429	.2743	1.9204	1.3889	1.3032	.9088	1.1145
15	.3429	.3601	1.5604	1.4575	1.4232	.8573	1.1145
16	.3601	.5144	1.8519	1.4918	1.2003	.9945	1.2003
17	.4287	.6687		.6516	.6859	.6859	.5144
18	.7716	1.0288	1.1488	.6859	.703	.8916	.583
19	1.0631	1.5432	1.6289	1.1831	1.166	1.4575	.9945
20	1.2517	1.5604	1.4575	1.166	1.4918	1.6804	1.8347
21	.9431	.9945	1.046	1.1145		1.166	1.1317
22	.8573	.8745	.8573	.6859	.9088	.9774	.8916
23	.8573	.703	.6859	.6859	.8573	.7716	.7716
24	.7716	.8573	.6516	.6516	.7202	.703	.7373
Max	3.5837	2.4863	2.2119	2.1605	1.9719	2.0576	2.2462
Min	.3429	.2743	.6173	.6173	.6859	.6859	.5144
Avg	.9667	1.0359	1.4023	1.2674	1.1574	1.1116	1.1460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 201 / 11 KV DEULGAON(BZ)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934		.0848	.3052		.1132	
2	.0934	.3018		.2713		.132	.0113
3	.1109		.1357	.3391	.2829	.1698	
4	.1848	.3961		.373		.2263	.2829
5	.2195			.373		.2829	
6	.2534	.5281	.4409	.39	.3772	.415	.5281
7	.5658		.5087	.4409		.5658	.5658
8	.4904	.5281		.4917		.4715	.4904
9	.415		.1475	.1311	.1463	.1848	
10		.1463		.1296	.124	.1463	.0324
11	.2263	.1357	.0983	.0983	.104		.0492
12	.3018	.116	.0819	.0819	.0876	.1075	.0328
13			.0983		.0716		
14	.3018	.1006	.0983	.1311	.0886	.0876	
15			.1311	.1147	.1052	.0886	.0328
16	.3018	.1017	.1311	.1296	.0686	.1063	
17			.1357	.2035	.1132		.1187
18	.3395	.1886		.2204	.1886	.2263	.2713
19		.3018	.3052	.2713	.3772	.2641	.2035
20	.3772	.415		.3052	.2641	.3395	.3052
21			.2543				
22	.3772	.2263		.373		.2263	.373
23	.415	.1509	.407	.39		.1509	.407
24	.0934	.4338	.1132	.407	.3391	.0943	.0094
Max	.5658	.5281	.5087	.4917	.3772	.5658	.5658
Min	.0934	.1006	.0819	.0819	.0686	.0876	.0094
Avg	.2867	.2714	.1983	.2714	.1825	.2200	.2321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 202 / 11 Kv Kotnandra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679		.2949	.9069		.6602	
2	.7922		.3605			.7095	.5853
3	1.0374		.4096	.8745	.6882	.7842	
4	1.1694		.5243	.9831		.924	1.0164
5	1.4335			.9878		1.0974	
6	1.6032		.6554		.6249	1.1694	1.1517
7	1.6221			.6478		1.6221	1.6032
8	1.5089		1.3904			1.5089	1.4335
9	.7619			.5898	.679	1.1317	.9326
10	.7045		.5087		.415	.8488	
11	.7373	.3395	.4409	.6443	.2829		.6783
12	.7865	.3018	.5087	.6783	.3018	.3018	.7122
13	1.1191		.6443		.2829		
14	1.0513	.3018		.5087	.3772	.2829	
15		.2829	.763		.3961	.3018	.6882
16	.8356			.3391	.3772	.2829	
17		1.0513	.7122		.3395		.6783
18	1.1191	.6602		.6443	.7167	1.226	.4858
19		.5087	.8478		1.2449	1.358	
20	.5426	1.5466		.5426	1.0374	1.226	.5087
21	.6104		.9496	.5571			.5898
22	.5935	.5487				.3696	.7537
23	.6226	.5914	1.0343	.5243		.4024	.9503
24	.7545		.3696	.9831	.5407	.5658	.462
Max	1.6221	1.5466	1.3904	.9878	1.2449	1.6221	1.6032
Min	.5426	.2829	.2949	.3391	.2829	.2829	.462
Avg	.9564	.6133	.6509	.6941	.5536	.8387	.8269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 203 / 11 Kv Ghatnandra SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535		.9326	.5087		.9335	
2	.7316	1.1694		1.0174		1.1317	.9808
3	.823		1.1022		.8589	1.2323	
4	1.0498	1.3392		1.1191		1.307	1.4712
5	1.1462		1.4582			1.4563	
6	1.2003	1.3203	1.56		1.1576	1.6057	1.7353
7	1.8298			1.2039		1.8298	1.7918
8	1.6804	1.7918	1.6278	.6443		1.7364	1.7541
9	1.531		1.0814	.6554	.5853	1.8298	.6478
10	.8648	.7888		.8259	.6935		
11		.8859	.6607		.7969		.7865
12	1.0513	1.0513	.8356	1.0688	.8383	.5426	.8097
13	1.1191		1.0814		.8619		
14	1.153	.9831	1.1142	1.0159	.7712	.5182	.9496
15	1.1869		1.1469		.7045	.5898	
16	1.2039	.6401	1.1797	1.0159	.6962	.5487	.8745
17	1.2209		1.2039	1.0174	.9335		.78
18		1.226			1.2323	1.4335	1.0513
19			1.1191		1.8298		
20	1.2039	1.7918		1.2209	1.4937	1.5466	1.153
21	1.2887		1.1869	1.153			
22	1.2717	1.358	1.2125			1.226	1.2209
23	1.0513	1.226	1.0159	1.153		1.0562	1.2209
24	.5487	.7922	1.0374	1.0513	1.1022	.9335	.9808
Max	1.8298	1.7918	1.6278	1.2209	1.8298	1.8298	1.7918
Min	.5487	.6401	.6607	.5087	.5853	.5182	.6478
Avg	1.1338	1.1689	1.1420	.9781	.9704	1.1921	1.1380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 204 / 11 KV SHINDEPHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036		.2622	.6554		.2829	
2	.679	.8145	.3277	.852		.2801	.3292
3	.8488			.7449	.7522	.3734	
4	1.0562	.9496	.426	.7865		.462	.4706
5	1.2449			1.0159		.5544	
6	1.4712	.9488	.5571	1.0159	.6562	.6584	.823
7	1.4335		.2987			.8676	1.4335
8	1.1317	1.358	1.0174	.8684		1.2449	1.226
9				.5087	.7545	1.1883	.8478
10	.5087	.8488	.2035	.6783	.679	.9431	
11		.415		.7122	.6036		.2713
12	.6478	.3018	.2883		.5281	.3772	.3391
13			.3391	.763	.4904		
14	.7116	.3395	.78		.3961	.3206	.4239
15			.8139	.6104	.3395	.3018	
16	.7449	.2829		.5087	.3772	.1132	.5087
17			.3391	.6104	.3772		.2713
18	1.1883	.6036			.679	.8488	.5087
19			.3391	.6783	1.094	1.1317	
20	1.1883	1.3203			.9619	1.0374	.6443
21			.426	.763			
22	.7316	.3292	.5898			.3292	.5898
23	.8501	.2772	.6554	.6952		.2896	.6554
24	.6602	.823	.2987	.7537	.6554	.3018	.2772
Max	1.4712	1.358	1.0174	1.0159	1.094	1.2449	1.4335
Min	.5087	.2772	.2035	.5087	.3395	.1132	.2713
Avg	.9236	.6866	.4684	.7345	.6230	.5953	.6012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 205 / 11 Kv Charner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108		.2713	.2713			
2	.462		.3391				.3772
3	.6089			.3391	.3018		
4	.7202		.4409				.6413
5	.7712			.407			
6	.8802		.7122		.415		.8676
7	.8488			.4915			.9054
8	.7545		.3391		.811		.7545
9	.6036		1.0513	.7449			.2915
10	.3052		1.0814	.7287			
11	.3391	1.0623	1.0159	.7865			.9175
12		1.0185	1.0322	.9717			
13	.5596		.6554		.6773	.3144	
14	.5765	.9145	1.0322	1.0159	.6661		.852
15			.7537		.6455	.4401	.8745
16	.6443	.6325		.6554	.5944	.3913	
17	.5087			.7122	.1886		.1865
18	.5596	.2641	.78		.3395	.3772	.3052
19	.5765	.6602		.6104	.5281	.4904	
20	.5596	.7167	.6952		.5658	.5658	.2543
21				.5426			
22	.5935	.4715	.7291	.5426		.4715	.2543
23	.6783	.4904	.2713	.5765		.3772	.3391
24	.3856		.3395	.3391	.5596		.3395
Max	.8802	1.0623	1.0814	1.0159	.811	.5658	.9175
Min	.3052	.2641	.2713	.2713	.1886	.3144	.1865
Avg	.5879	.6923	.6788	.6085	.5244	.4285	.5440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 201 / 11Kv Golegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.2378	.3012	.1734	.2012
2	.2172	.2743	.3189	.1949	.2561
3	.2481	.3658	.3366	.2507	.3292
4	.3155	.439	.3681	.3506	.439
5	.4835	.4755	.4733	.443	.5304
6	.6335	.5304	.5609	.631	.6584
7	.6379	.567	.4557		.567
8	.6379	.4207	.3681		.4961
9	.4706		.4908		.4607
10	.3475	.5138	.3721	.4359	.4607
11	.2012	.4607	.333	.3521	.4252
12	.3475	.4961	.2658	.285	.3721
13	.2012	.3801	.2481	.2347	
14	.1829	.3189	.2601	.2683	.2804
15	.1829	.3012	.2454	.3018	.3189
16	.2195	.3544	.2254	.2683	.3681
17	.2561	.4075	.2835	.3109	.3403
18	.3475	.6379		.3475	.5434
19	.4572	.8063	.5552	.4938	.7796
20	.439	.6733		.439	.567
21	.3109	.4784		.3292	.4075
22	.3292	.4207	.2804	.2561	.3366
23	.2561	.3544	.208	.2012	.2658
24	.2303	.2195	.3366	.1949	.2195
Max	.6379	.8063	.5609	.631	.7796
Min	.1829	.2195	.208	.1734	.2012
Avg	.3396	.4406	.3470	.3220	.4184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 202 / 11Kv Undengaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3681	.3366	.6036	.5138	.5014	.6219
2	.4024	.4252	.3721	.695	.5258	.5609	.695
3	.4694	.5316	.3982	.7316	.567	.6733	.7865
4	.57	.7087	.4908	.8779	.9036	.7362	.9877
5	.6874	.8505	.6379	1.1706	1.1517	.7975	1.1706
6	.7545	1.0808	.7888	1.5729	1.3998	1.2757	1.3717
7	1.4815	1.6301	1.8267	1.5729	1.5061	1.3643	1.6461
8	1.2986	1.2269	1.6817	1.2437	1.1517	1.1919	1.2437
9	1.0808	1.0985	1.2894	.8551	.5847	.4854	.57
10	.4908	.6089	1.1523	.9391	.4607	.4191	.6556
11	.5609			.7796	.4854	.3856	.5316
12	.5258			.8505	.4207	.3856	.4382
13	.631	.9231	.8962	.7265	.3814	.3856	.3856
14	.7011	.7164	.6767	.6201		.4024	.4961
15	.6733	.6836	.7865	.5847	.4733	.4191	.5609
16	.7712	.7265	.8779	.6733	.5028	.4359	.631
17	.6201	.7164	.8048	.7619	.567	.6036	.631
18	.8413	.9036	.9877	1.0099		.6219	.9134
19	1.0808	1.0317	1.0608	1.1517	1.3032	1.0242	1.086
20	.6836	.6733	1.0608	.9036		.8779	.8596
21	.6201	.4477	.9511	.7011	.7783	.8048	.5258
22	.5258	.3982	.8413	.6556	.6733	.7499	.4784
23	.4784	.3506	.6584	.6024	.5895	.7316	.4252
24	.3353	.4252	.3155	.6584	.5316	.5316	.7133
Max	1.4815	1.6301	1.8267	1.5729	1.5061	1.3643	1.6461
Min	.3018	.3506	.3155	.5847	.3814	.3856	.3856
Avg	.6911	.7512	.8587	.8726	.7367	.6819	.7677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 203 / 11Kv Khedi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.2658	.2507	.3018	.3506	.2481	.4024
2	.5487	.3189	.2658	.3688	.3721	.2629	.4359
3	.6219	.3544	.298	.4359	.4207	.2865	.503
4	.7133	.5493	.4207	.503	.5258	.3366	.5365
5	.8048	.6024	.6661	.6371	.6661	.4252	.57
6	.8962	.7087	.9568	.8048	.7712	.5028	.6036
7	.9511	.7973	.8596	.7316	.631	.6135	.7682
8	.8413	.7087	.8149	.695	.4908	.5847	.6401
9	.4961	.5493	.5847	.567		.4835	.5853
10	.567	.5258	.5365	.4607	.2835	.3109	.3155
11	.6733	.5375	.5533	.2454	.1791	.3109	.2629
12	.6201	.6201	.503	.2103	.1949	.2195	.2103
13	.5784	.5609	.4862	.0177	.181	.2012	.1578
14	.5959	.5194	.4862	.2804	.1791	.1829	
15	.4961	.4961	.9556	.3189	.1791		
16	.5316	.4508	.5365	.3506	.1772		
17	.3721	.2353	.2743	.4207	.2865		
18	.631		.4938	.6836			.5609
19	.815	.8238	.823	.7796	.7059		.815
20	.6733	.6661	.4778	.6135			.5194
21	.4784	.5258	.3856	.5258	.3856	.4359	.3721
22	.3721	.4835	.3521	.4382	.3506	.57	.3189
23	.3366	.3856	.3688	.4031	.3155	.4694	.2835
24	.4938	.2835	.3045	.3353	.3721	.2804	.4359
Max	.9511	.8238	.9568	.8048	.7712	.6135	.815
Min	.3366	.2353	.2507	.0177	.1772	.1829	.1578
Avg	.6077	.5204	.5273	.4637	.3818	.3736	.4649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 205 / 11Kv Panwadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4359	.3721	.4252	.4694
2	.4075	.503	.4252	.4382	.57
3		.57	.4961	.4961	.6371
4	.6024	.7545	.7087	.6516	.8048
5	.8238	.8886	.8505	.8596	.4862
6	.9362	.9724	.9922	1.0498	1.1233
7	.7619	.9328	.9391	.9745	.9511
8	.815	.9328	.691	.815	.8779
9	.5959	.823	.5316		.6036
10	.4862	.6201	.3761	.4938	.4557
11	.4359	.4075		.3475	.333
12	.6203	.3544	.3045	.3109	.3155
13	.7042	.3366	.3366	.3475	.333
14	.6203	.2658	.3801	.3841	.4252
15	.5868	.333	.3403	.3841	.3681
16	.57	.3898	.3077		.4908
17	.439	.6984	.4344	.4024	.5847
18	.6401	.8505		.5304	.8063
19	.7865	1.0631	.8505	.8048	1.0341
20	.695	.6733		.6219	.8413
21		.5138	.591	.503	.7087
22	.503	.4477	.5552	.5197	.5792
23	.5197	.4163	.5068	.503	.5138
24	.4557	.4694	.3544	.4607	.503
Max	.9362	1.0631	.9922	1.0498	1.1233
Min	.3856	.2658	.3045	.3109	.3155
Avg	.6087	.6105	.5402	.5602	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 207 / 11Kv Mandna feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.3189	.2303	.439	.3366	.3761	.3841
2	.2683	.3544	.2896	.5121	.3189	.4075	.439
3	.3521	.3721	.3189	.5487	.3544	.4557	.5121
4	.4694	.4784	.4207	.695	.567	.5611	.7133
5	.6371	.5493	.5014	.7865	.7442	.7701	1.0059
6	.6371	.6733	.5493	.9328	.8764	.7973	1.1157
7	1.0608	.8505	.9955	1.0425	.9568	1.0317	1.134
8	.9877	.7087	.8954	.9328	.7087	.8764	.7133
9	.7265	.6379	.6447	.5197	.3898	.2835	.3856
10	.4607	.3189	.439	.4075	.3856	.3018	.4784
11	.3189	.1629	.2195	.443	.4031	.2683	.4207
12	.2126	.1753	.1646	.4784	.298	.3018	.3681
13		.1417	.1646	.4252	.2865	.3521	.3506
14			.1646	.3721	.3012	.3185	.298
15	.1753	.1949	.2012	.3544	.2658	.2515	.2629
16	.2303	.2658	.2195	.3012	.2254	.2515	.3544
17	.3544	.3045	.2378	.4607	.3189	.2378	.4784
18	.567	.5014	.4755	.6733		.4572	.6024
19	.691	.8507	.7682	.8505	.7522	.8779	.9231
20	.5138	.6447	.7499	.7442		.695	.6805
21	.2658	.2427	.5853	.5847	.6485	.5487	.4835
22	.2303	.2715	.6036	.4784	.5731	.567	.443
23	.2481	.2507	.5121	.4075	.4706	.4755	.4075
24	.2515	.2658	.2103	.4572	.3544	.4252	.439
Max	1.0608	.8507	.9955	1.0425	.9568	1.0317	1.134
Min	.1753	.1417	.1646	.3012	.2254	.2378	.2629
Avg	.4497	.4146	.4401	.5770	.4789	.4954	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 201 / 11Kv Sirsala Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2229	.1372	.1543	.1372	.1543
2	.2229	.2572	.2229	.1372	.1715	.1372	.1543
3		.3086	.2229	.1372	.1715	.1372	.1543
4	.2572	.3086	.2572	.1372	.1715	.1543	.1543
5	.2572	.3258		.1372	.2058	.1543	.1543
6	.2572	.5144	.463	.1372	.1886	.1543	.1543
7	.1372	.1543	.12	.12	.1715	.2058	.1543
8	.1372	.1372	.1029	.12	.12	.1715	.1372
9	.1029	.1372	.0686	.3429	.2915	.2401	.2743
10	.0857	.1029	.0686	.3258	.2572	.2572	.3258
11	.0686	.0857	.0762	.3772	.2401	.2058	.2915
12	.0686	.0857		.2572	.2401	.1886	.2229
13		.0857		.3086	.2058		.2229
14		.0857		.2915	.1543		.2229
15		.0686	.0686	.2401	.2058		.2058
16	.0857	.0857	.0686	.2229	.2401	.2572	.2401
17	.0857	.0857	.0857	.1029	.0857	.1029	.0857
18	.1029	.1029	.0857	.12	.1372	.12	.1029
19	.12	.1372	.1029	.1372		.12	.12
20	.1372	.12	.1372	.1372	.12	.1372	.1372
21	.2572	.2401	.1543	.1715	.1372	.1543	.2743
22	.2572	.2401	.1372	.1715	.1372	.1543	.2915
23	.2401	.2743	.1372	.1715	.1372	.1543	.2743
24	.2572	.2401	.2229	.1372	.1543	.1372	.1372
Max	.2572	.5144	.463	.3772	.2915	.2572	.3258
Min	.0686	.0686	.0686	.1029	.0857	.1029	.0857
Avg	.1698	.1850	.1513	.1908	.1782	.1658	.1936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 202 / 11KV HATTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.1029	.1715	.1372		
2	.1029	.1029	.1029	.1715	.1372		
3	.1029	.12	.1029	.1715	.1543		
4	.1029	.12	.1029	.2058	.2058		
5	.12	.12	.12	.3086	.2401		
6	.1372	.1372	.1543	.3944	.5658		
7	.1029	.12	.1372	.1372	.12		
8	.1029	.1029	.1029	.1029	.1029		
9	.2229	.2058	.1524	.1029	.0686		
10	.2229	.1543		.0686	.0514		
11	.1715	.1715		.0514	.0343		
12	.1886	.2058		.0514	.0343		.0171
13	.1715	.2058		.0514	.0343		.0171
14	.1715	.1715		.0171	.0343		.0343
15	.12	.1715		.0514	.0343		.0514
16	.1372	.2229			.0343		.0514
17	.0514	.0514		.0514	.0343		.0686
18	.0514	.0514		.0514	.0343		.0514
19	.0857	.0857	.0762	.0857	.0857		.0686
20	.0857	.1029	.0857	.1029			.0686
21	.0857	.1029	.1372	.12		.0686	.0857
22	.1029	.1029	.1372	.1372		.1715	.1029
23	.1029	.1029	.1524	.1372			.1029
24	.12	.1029	.1029	.1715	.1372		
Max	.2229	.2229	.1543	.3944	.5658	.1715	.1029
Min	.0514	.0514	.0762	.0171	.0343	.0686	.0171
Avg	.1243	.1308	.118	.1267	.1140	.1201	.06

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 203 / 11Kv Ambhai Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.0343	.0171	.0171	.0171	.0191
2	.0514	.0343	.0343	.0171	.0171	.0171	.0191
3	.0514	.0343	.0343	.0171	.0171	.0171	.0191
4	.0686	.0343	.0514	.0171	.0171	.0171	.0191
5	.0686	.0514	.0686	.0171	.0171	.0171	.0191
6	.1029	.0514	.0857	.0171	.0171	.0171	.0191
7	.0171	.0171	.0171	.0171	.0171	.0171	.0191
8	.0171	.0171	.0171	.0171	.0171	.0171	.0191
9	.0171	.0171	.0171	.0686	.0171	.0171	.0514
10	.0171	.0171	.0152	.0857	.0686	.0171	.0686
11	.0171	.0171	.0152	.1029	.12		.12
12	.0171	.0171		.1029	.1029		.0686
13		.0171		.1029	.1029		.0514
14		.0171		.0857	.0857		.0343
15		.0171	.0152	.0857	.0857		.0514
16	.0171	.0171	.0191	.0686	.0686	.0171	.0514
17	.0171	.0171	.0191	.0171	.0171	.0171	.0343
18	.0343	.0171	.0191	.0171	.0171	.0171	.0343
19	.0343	.0171	.0191	.0171	.0171	.0171	.0171
20	.0171	.0171	.0191	.0171	.0171	.0171	.0171
21	.0343	.0343	.0191	.0171	.0171	.0171	.0343
22	.0343	.0343	.0191	.0171	.0171	.0171	.0343
23	.0343	.0343	.0191	.0171	.0171	.0171	.0343
24	.0686	.0343	.0343	.0171	.0171	.0171	.0191
Max	.1029	.0514	.0857	.1029	.12	.0171	.12
Min	.0171	.0171	.0152	.0171	.0171	.0171	.0171
Avg	.0375	.0257	.0282	.0407	.0385	.0171	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 204 / 11Kv Chinchpur feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0857	.1029	.0686	.1067
2	.0171	.0171	.0171	.0857	.1029	.0686	.0914
3	.0171	.0171	.0171	.0857	.12	.0686	.0914
4	.0171	.0171	.0171	.1029	.12	.0686	.0914
5	.0171	.0171	.0171	.1543	.1543	.0857	.0914
6	.0171	.0171	.0171	.1886	.4973	.1372	.1981
7	.0171	.0171	.0171	.0171	.0171	.0171	.0152
8	.0171	.0171	.0171		.0171		.0191
9	.1029	.1372	.1372	.0171	.0171	.0171	.0171
10	.2229	.2229	.2058	.0171	.0171	.0171	.0171
11	.3258	.2915	.2915	.0171	.0171	.0171	.0171
12	.3772	.3086	.3048	.0171	.0171	.0171	.0171
13	.2743	.2915	.2591	.0171	.0171	.0171	.0171
14	.2572	.2058	.2286	.0171	.0171	.0171	.0171
15	.2229	.2229	.2286	.0171	.0171	.0171	.0171
16	.2401	.2401	.2591		.0171	.0171	.0171
17	.0171	.0171	.0191	.0171	.0171	.0171	.0171
18	.0171	.0171	.0191	.0171	.0171	.0171	.0171
19	.0171	.0171	.0191	.0171	.0171	.0171	.0171
20	.0171	.0171	.0191	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.12	.0171	.0686	.0171
22	.0171	.2743	.061	.1372	.0857	.12	.0171
23	.0171	.0171	.0762	.1372	.0857	.12	.0171
24	.0171	.0171	.0171	.0857	.1372	.0686	.1067
Max	.3772	.3086	.3048	.1886	.4973	.1372	.1981
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0152
Avg	.0957	.1021	.0958	.0631	.0693	.0477	.0445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 205 / 11KV AMBHAI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086	.2915	.3086	.3258	.3086	.2743
2	.2915	.3086	.2915	.3086	.3258	.3086	.2743
3	.3086	.3258	.3086	.3086	.3258	.3086	.2743
4	.3086	.4115	.3429	.3429	.4115	.3429	.3353
5	.4287	.4801	.4287	.4801	.4973	.4287	.4572
6	.5144	.4973	.6173	.6173	.4973	.4973	.5792
7	.2915	.3944	.3944	.3772	.2058	.2915	.4268
8	.2572	.1372	.3429	.2572	.2401	.1372	.3506
9	.3601	.2058	.4268	.3429	.3944	.3944	.5144
10	.3601	.4287	.381	.5144	.463	.3429	.4287
11	.2572	.2058	.3772	.463	.3944	.3086	.3429
12	.1886	.1886		.4115	.3429	.2572	.3086
13		.1715		.3258	.3258		.2915
14		.1372		.3429	.3429		.3086
15		.2572	.381	.3601	.3258		.3258
16	.2915	.3258	.3353	.4458	.1715	.3944	.3258
17	.3601	.3429	.2743	.2401	.2401	.463	.3772
18	.4287	.5144	.381	.4287	.3429	.5144	.4801
19	.4287	.5144	.4115	.5316	.5144	.583	.4287
20	.3429	.463	.4115	.4287	.3944	.5487	.463
21	.3258	.4115	.3658	.3944		.4287	.3772
22	.3258	.3429	.3353	.3772	.3429	.3772	.3429
23	.3086	.3258	.2743	.3601	.3086	.3429	.3258
24	.3086	.3086	.3258	.3086	.3429	.3086	.2743
Max	.5144	.5144	.6173	.6173	.5144	.583	.5792
Min	.1886	.1372	.2743	.2401	.1715	.1372	.2743
Avg	.3323	.3337	.3666	.3865	.3511	.3756	.3703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 206 / 11Kv Nanegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.12	.12	.1029	.0857		.12
2	.1715	.12	.12	.1029	.0857		.1543
3	.1715	.1372	.12	.1029	.0857		.12
4	.2058	.1372	.1372	.1029	.0857		.12
5	.2058	.1543	.1715	.1029	.1029	.0343	.12
6	.2572	.2743	.2401	.1029	.12	.0514	.1029
7	.1715	.1543	.1715	.1029	.1372	.0514	.12
8	.1372	.1372	.0857	.1029	.1029	.0514	.0762
9	.12	.1372	.0983	.3944	.1886	.0171	.12
10	.1029	.12	.0857	.2915	.1715	.0171	.1715
11	.1029	.0857	.0914	.2743	.2401	.0171	.1715
12	.0686	.0857		.1372	.1886	.0171	.0686
13		.0857		.1543	.1886		.0686
14		.0857		.1886	.1715		.0686
15		.0686	.12	.2401			.0686
16	.0686	.0857	.1029	.1715		.1029	.1372
17	.0686	.0857	.0914	.0686		.0857	.0514
18	.0686	.1029	.1029	.0686	.12	.1029	.0514
19	.0857	.1029	.1029	.1029	.12	.1029	.0857
20	.1029	.1029	.1029	.1029	.0857	.1029	.0857
21	.2229	.1543	.1029	.1029		.1029	.0686
22	.1715	.1543	.1029	.1029		.12	.1029
23	.1543	.1543	.1029	.1029		.12	.1029
24	.1715	.1372	.12	.1029	.1029		.12
Max	.2572	.2743	.2401	.3944	.2401	.12	.1715
Min	.0686	.0686	.0857	.0686	.0857	.0171	.0514
Avg	.1429	.1243	.1187	.1429	.1324	.0686	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 207 / 11Kv Ghatambri Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0343	.0343	.0343	.0305
2	.0171	.0171	.0171	.0343	.0343	.0343	.0305
3	.0171	.0171	.0171	.0343	.0343	.0343	.0312
4	.0171	.0171	.0171	.0343	.0343	.0343	.0305
5	.0171	.0171	.0171	.0343	.0514	.0343	.0305
6	.0171	.0171	.0171	.0514	.12	.0514	.0305
7	.0171	.0171	.0171	.0171	.0171	.0171	.0191
8	.0171	.0171	.0171	.0171	.0171	.0171	.0191
9	.0171	.0343	.061	.0171	.0171	.0171	.0171
10	.0514	.0686	.0762	.0171	.0171	.0171	.0171
11	.0857	.0686	.061	.0171	.0171	.0171	.0171
12	.1029	.0686	.0762	.0171	.0171	.0171	.0171
13	.12	.0857	.0762	.0171	.0171	.0171	.0171
14	.12	.1372	.0762	.0171	.0171	.0171	.0171
15	.12	.12	.0457	.0171	.0171	.0171	.0171
16	.12	.12	.0762		.0171	.0171	.0171
17	.0171	.0171	.0152	.0171	.0171	.0171	.0171
18	.0171	.0171	.0191	.0171	.0171	.0171	.0171
19	.0171	.0171	.0191	.0171	.0171	.0171	.0171
20	.0171	.0171	.0191	.0171	.0171	.0171	.0171
21	.0171	.0171	.0305	.0514	.0171	.0343	.0171
22	.0171	.0171	.0305	.0514	.0343	.0514	.0171
23	.0171	.0171	.0305	.0514	.0514	.0343	.0171
24	.0171	.0114	.0171	.0343	.0343	.0514	.0305
Max	.12	.1372	.0762	.0514	.12	.0514	.0312
Min	.0171	.0114	.0152	.0171	.0171	.0171	.0171
Avg	.0421	.0405	.0361	.0276	.0285	.0264	.0212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 208 / 11Kv Hatti Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2915	.2572	.2743	.3086		.2591
2	.2915	.2915	.2572	.2743	.3086		.2591
3	.2915	.3086	.3429	.2743	.3086		.2743
4	.3429	.4287	.5144	.3429	.3772		.381
5	.5144	.583	.6859	.5144	.6516		.5335
6	.8402	.9088	.823	.7202	.8573		.6859
7	.9259	.9602	.8573	.823			.6097
8	.7545	.583	.6859	.6516	.6859		.4877
9	.6687	.583	.4572	.6516	.5144	.6001	.3429
10	.3601	.3086	.2286	.4115	.3086	.4287	.1543
11	.2401	.1715	.1677	.3258	.2401	.2743	.1543
12	.2058	.1543	.1677	.2915	.1543	.1886	.1543
13	.1543	.1543	.1677	.2401	.1886	.1715	.1715
14	.1886	.1372	.1677	.2401	.1886	.1543	.1543
15	.1886	.1372	.1677	.3086	.2058	.1715	.1543
16	.2058	.1372	.1677		.2058	.1886	.1886
17	.3429	.2229	.1981	.3944	.3601	.2229	.2401
18	.5487	.3772	.381	.4801	.5316	.4287	.2915
19	.6173	.7545	.381	.6001	.6687	.583	.6516
20	.3772	.5144	.4572	.4287		.6001	.6173
21	.3258	.3429	.5639	.3944		.4115	.4115
22	.3086	.3086	.3201	.3772		.3429	.3429
23	.2743	.2743	.2743	.3086		.2915	.2915
24	.2915	.2743	.2572	.2743	.3086		.2591
Max	.9259	.9602	.8573	.823	.8573	.6001	.6859
Min	.1543	.1372	.1677	.2401	.1543	.1543	.1543
Avg	.3979	.3837	.3729	.4175	.3881	.3372	.3363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 204 / 11Kv Pimpaldari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962		1.358	1.2323	.7023	.4805	.439
2	.8775	.9335	1.3203	1.2696	.7392	.5175	.5487
3	1.1506	1.0082	1.4335	1.3443	.7392	.5544	.6584
4	1.251	1.1763	1.5684	1.419	.7682	.5914	.6584
5	1.3443	1.4563	1.7924	1.531	.7762	.6219	.695
6	1.419	1.5154	1.9791	1.6057	.7947	.695	.9511
7	1.643	1.6263	2.0698	1.643	1.3306	2.0698	1.7364
8	1.5684	1.6263	1.9791	1.5684	1.4937	1.8671	
9	1.2567	.6653	.4755	1.2048	1.2012	1.3443	1.5154
10	1.1888	.7316	.6584	.9465	1.1458	1.307	1.4415
11	.6653	.7602	.5121	.6661	1.0985	1.1949	1.1763
12	.7023	.7392	.5121	.6335	1.0349	.9709	1.1088
13	.5487	.6878	.4755	.5731	.8501	.9709	1.0456
14	.5914	.6219	.5121	.4961	.9134	.9709	1.0164
15	.6584	.5853	.5121	.4784	1.2048	.9335	1.0829
16	.5121	.5068	.5487	.4607	1.4937	.9335	.961
17	1.5524	1.307	1.531	1.4335	1.4937	1.0829	.9979
18	1.4937	1.643	1.7924	1.643	2.0165	1.1203	1.1088
19	1.4415	2.1068	2.0538	1.4937		1.8298	1.2382
20	1.3443	1.7372	2.0538	1.4784	1.885	1.8298	1.2883
21	1.1273	1.531	1.531	.6283		.2926	1.1088
22	.924	1.4937	1.0456	.6468	.5544	.3292	1.0829
23	.9055	1.419	1.1203	.6838	.5228	.3544	1.0642
24	.9709	.9149	1.1203		.7023	.4024	
Max	1.643	2.1068	2.0698	1.643	2.0165	2.0698	1.7364
Min	.5121	.5068	.4755	.4607	.5228	.2926	.439
Avg	1.0847	1.1649	1.2481	1.0904	1.0664	.9694	1.042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 205 / 11Kv Halda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.7468	.7922	.7468	.5359	.3326	.6379
2	.7468	.7468	.7545	.8215	.5175	.3696	.695
3	.8402	.9335	.811	1.0082	.5914	.4024	.5853
4	.8865	.9808	.9054	1.1949	.5853	.4706	.5853
5	.9242	1.0642	1.0269	1.3443	.6468	.5731	.8779
6	1.0829	1.1273	1.1576	1.6804	.6283	.6733	.7316
7	1.2696	1.1643	1.1949	2.0165	.7842	.9896	1.7924
8	.9335	.9896	1.0829	1.6057	.8775	.7655	
9	.7762	.4525	.5121	.8413	.5228		1.1763
10	.7392	.4908	.6219	.6661	.4294		1.1203
11	.4572	.4508	.5487	.4207	.3681		.4481
12	.4755	.4115	.6219	.4075	.4854		.4904
13	.4251	.4287	.6219	.3856	.5041	.6722	.3961
14	.439		.6219	.3898	.4607	.7095	.2218
15	.499	.4161	.695	.3721	.4607	.8215	.2614
16	.5175	.4115	.7682	.3721	.5093	.905	.5281
17	.5601	.5041	1.0456	.5975	.5601	.8589	.6908
18	1.0642	.6722	1.307	.8029	.8029	1.307	.9335
19	1.3014	1.1203	1.8298	.9808		1.643	1.0269
20	1.1576	.9979	1.9044	1.0642	.8402	1.7924	.9335
21	1.0534	.9149	1.8298	.5601		.3658	.8775
22	.9055	.8775	1.7551	.5544	.3898	.439	.679
23	.8299	.8402	1.2696	.5914	.3658	.4755	.6602
24	.8402	.811	1.0829		.5729	.5487	
Max	1.3014	1.1643	1.9044	2.0165	.8775	1.7924	1.7924
Min	.4251	.4115	.5121	.3721	.3658	.3326	.2218
Avg	.8121	.7632	1.0317	.8446	.5654	.7558	.7432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 206 / 11Kv Digras feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	.9335	1.0374	.9709	.5914	.3881	.3898
2	1.1506	.9709	1.0185	1.0456	.6283	.4251	.4755
3	1.1203	1.0829	1.1317	1.1576	.6401	.4572	.3544
4	1.1389		1.3203	1.2323	.6697	.5121	.567
5	1.1016		1.4003	1.307	.6805	.5973	.695
6	1.0829		1.531	1.3443	.6878	.6878	.5853
7	1.4003		1.7002	1.4563	.961	1.7177	1.363
8	1.307	1.5708	1.587	1.363	1.0829	1.5708	
9		.4835	.3658	.8764	1.0534	.9335	.9335
10	.823	.567	.439	.7362	1.0642	.8962	.8775
11	.7207	.5316	.5121	.5609	.9671	.7468	1.1203
12	.695	.5304	.5853	.4961	.8775	.7095	.9979
13	.4066	.4607	.6219	.4477	1.0269	.7095	.9335
14	.4066		.695	.4477	.9391	.6722	.9522
15	.462	.4477	.6219	.4961		.6722	.9335
16	.5175	.4252	.5853	.5493	.9335	.6722	.9709
17	1.1203	1.0642	1.0082	1.1203	1.0829	.7095	.924
18	1.4563	1.2323	1.2883	1.363	1.475	.9709	1.4784
19	1.475	1.6263	1.419	1.4003		1.1203	1.5893
20	1.3443	1.4563	1.4937	1.2936	1.4937	1.419	1.4937
21	1.2883	1.2136	1.3817	.5175			1.307
22	1.226	1.1576	1.2323	.5544	.4706	.3292	.8775
23	1.1203	1.1203	1.1203	.5359	.4298	.3544	.8402
24	1.1763	1.0082	1.0456		.5544	.4024	
Max	1.475	1.6263	1.7002	1.4563	1.4937	1.7177	1.5893
Min	.4066	.4252	.3658	.4477	.4298	.3292	.3544
Avg	1.0303	.9412	1.0476	.9249	.8719	.7684	.9391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 207 / Water Supply FDR

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1372
6					.0171		
7	.0173	.0171	.0171	.0171	.0173		.0171
8	.0173	.0343	.0343	.0171	.0343		
9	.0173	.0343	.0343	.0347	.0347	.0343	.0347
10	.0347	.0343	.0343	.0347	.0347	.0343	.0347
11	.0343	.0343	.0343	.0347		.0343	.0173
12	.0347	.0343	.0343	.0347	.0347	.0343	.0347
13	.0347	.0343	.0343	.0347	.0347	.0343	.0347
14	.0347	.0343	.0343		.0347	.0343	.0347
15		.0343	.0343		.0173	.0343	.0347
16		.0343	.0343		.0173	.0373	.0343
17		.0343	.0343		.0173	.0343	.0343
18		.0343	.0171		.0173	.0171	.0343
19			.1372				
Max	.0347	.0343	.1372	.0347	.0347	.0373	.1372
Min	.0173	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0281	.0329	.0396	.0297	.0260	.0329	.0402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 201 / 11KV BHAVAN (NILLOD)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.3258	.2949	.3086	.362	.4801	.4801
2	.5087	.3258	.3277	.3086	.3982	.4801	.4801
3	.5765	.362	.407	.4115	.4344	.5144	.4801
4	.7461	.3982	.5087	.6516	.4706	1.0082	.583
5	.9835	.4298	.5243	.823	.6154	.9259	.9945
6	1.3565	.5426	.6783	.9945	.9955		1.3523
7	1.3904	1.3957	1.3226	1.3756	1.5089		1.4746
8	1.3056	1.3392	1.2209	1.1789	1.3014		1.2174
9	.5426		.9665	.7202	1.0374		.6516
10			.5765	.8745	.6413		.6516
11	.4862	.4578		.6602	.3605		.7209
12	.7209	.3921	.1991	.547	.3052		.5533
13	.6539	.2294		.5093	.2785		.503
14	.5801	.2294	.3801	.4904	.2949	.7545	.6371
15	.547	.2622	.3258	.5281	.3441	.703	.5868
16	.4973	.3222	.362	.6036	.3113	.7202	.6036
17	.3772	.3605	.3801	.5847	.3768	.3086	.3206
18	.6979	.3605	.543	.6602	.4915	.4801	.4904
19	1.1694	.9995	1.0288	1.0642	.9339	1.1317	1.0562
20	.9619	.9175	.9602	.8488	.8192	1.0802	1.1128
21	.3258	.3605	.3601	.4338	.5407	.6859	.7167
22	.3258	.407	.3944	.362		.5895	.6224
23	.3077	.3277	.3601	.3439	.5243	.5144	.5847
24	.4748	.2896	.2949	.3086	.3258	.4588	.4801
Max	1.3904	1.3957	1.3226	1.3756	1.5089	1.1317	1.4746
Min	.3077	.2294	.1991	.3086	.2785	.3086	.3206
Avg	.6961	.5016	.5644	.6497	.5944	.6772	.7231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 202 / 11 KV BORGAON KH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5765	1.3203	1.1469	1.1789	1.3203	.4801	.5144
2	.6104	1.358	1.2378	1.2136	1.358	.583	.583
3	.7291	1.3957	1.3226	1.283	1.3957	.6859	.6516
4	.763	1.5089	1.3108	1.387	1.4523	.823	.6859
5	.8139	1.7353	1.5402	1.6124	1.6787	1.0974	.7202
6	.8987	1.9605	1.6876	1.8204	1.9805		.823
7		2.0351	1.7204		1.9427		1.5089
8	1.2452	1.9239	1.6108	1.7857	1.6975		1.0974
9	1.4937	.8383	.6226	.823	.6706		.823
10		.8048	.639	.7545	.6036		.547
11	.7733	.9149	.7716	.5868	.6226		.415
12	.679	.8817	.8745	.6371	.5898		.3584
13		.7045	.823	.7042			.3961
14		.6952	.7202	.6371	.5898	.823	.3961
15	.6036	.6554	.6859	.7209	.5735	.7545	.4338
16	.7356	.5571	.6516	.7209	.5407	.7545	.4527
17	.9054	.6554	.6516	.9242	.6882	.7545	.4715
18	1.2449	.8848	.9774	1.0562	.8356	.9945	1.0185
19	1.5655	1.4419	1.4403	1.4937	1.4243	1.5089	1.5089
20	1.2826		1.3889	1.4335	1.3435	1.5089	1.5089
21	1.3769	1.2209	1.1789	1.3203	.4588	1.5257	.788
22	1.3014	1.1869	1.2308	1.3014		.583	.7701
23	1.2826	1.153	1.166	1.2826	.4424	.583	.724
24	.6104	1.2826	1.1191	1.2308	1.2826	.426	.583
Max	1.5655	2.0351	1.7204	1.8204	1.9805	1.5257	1.5089
Min	.5765	.5571	.6226	.5868	.4424	.426	.3584
Avg	.9746	1.1789	1.1049	1.1264	1.0678	.8679	.7408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 203 / 11 KV PALASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142	.6447	.5571	.6516	.6697	1.0974	1.166
2	1.1869	.6984	.5898	.6516	.7059	1.166	1.2003
3	1.3056	.7343	.6443	.6859	.7421	1.2346	1.2689
4	1.4582	.7783	.8029	.7545	.7783	1.3375	1.387
5	1.9044	.8059	.823	.9945	.8326	1.6118	1.5257
6		.7969	.8962	1.2346	1.3253		1.8004
7	1.7924	1.7353	1.4419	.7545	1.6409		
8	1.5769	1.5684	1.2548	1.3717	1.4901		1.6118
9	.6443	1.3203	1.0852	1.3032			.7716
10		.9431	.9709	1.0288			.823
11	.6203	.6226	.583	1.0374			.8488
12	.8886	.5898	.583	.8299			.8048
13	.8383	.5407	.5068	.9619			.788
14	.8288	.5407	.6516	.8488	.6443	.9259	.8551
15	.8551	.5571	.724	1.0185	.7373	1.0974	.8383
16	.7293	.5596	.8145	1.0374	.7537	1.0974	.8886
17	.6979	.5898	.9231	1.0374	.8684	.7545	.9054
18	1.226	.8356	1.1765	1.2071	.9503	.9259	.9808
19	1.7164	1.4419	1.6461	1.6244	1.5238	1.3375	1.4335
20	1.5466	1.4746	1.5089	1.5089	1.3272	1.5947	1.7164
21	.6154	.6104	.6516	.5973	1.1961	1.387	1.5278
22	.7602	.7468	.823	.6335		1.3523	1.358
23	.6878	.5898	.6859	.6697	1.1469	1.2346	1.3203
24	1.153	.6335	.5571	.6516	.6335	1.1142	1.166
Max	1.9044	1.7353	1.6461	1.6244	1.6409	1.6118	1.8004
Min	.6154	.5407	.5068	.5973	.6335	.7545	.7716
Avg	1.0976	.8483	.8709	.9623	.9981	1.2043	1.1733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 204 / 11Kv Bhagawati Agro
Express Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0173	.0171	.0171
2		.0171	.0171	.0173	.0171	.0171
3		.0164	.0171	.0173	.0171	.0171
4		.017	.0171	.0173	.0171	.0171
5		.0171	.0171	.0173	.0171	.0171
6		.0164	.0171	.0173		.0171
7		.0171	.0171	.0173		.0171
8		.0171	.0171	.0173		.0171
9		.0171	.0171	.0173		.0171
10		.0821	.0171	.0173		.0171
11		.0171	.0178	.0164		.0173
12		.0171	.0179	.0171		.0172
13	.0341	.0171	.0179	.0171		.0173
14	.0164	.0171	.011	.0171	.0171	.0173
15	.0165	.0171	.018	.0164	.0171	.0173
16	.0341	.0171	.018	.0164	.0171	.0169
17	.085	.0171	.0179	.0164	.0171	.0168
18	.085	.0171	.018	.0164	.0171	.0169
19	.0938	.0171	.0173	.0171	.0171	.0167
20	.0164	.0171	.0173	.0164	.0171	.0167
21	.0164	.0171	.0173	.0171	.0171	.0167
22	.0164	.0171	.0173		.0171	.0167
23	.0164	.0171	.0173	.0171	.0171	.0167
24		.0164	.0171	.0173	.0171	.0171
Max	.0938	.0821	.018	.0173	.0171	.0173
Min	.0164	.0164	.011	.0164	.0171	.0167
Avg	.0391	.0197	.0171	.0170	.0171	.0170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 205 / 11Kv Nillod Dharan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171						.0171
2	.0171					.0171	.0171
3	.0171					.0171	.0171
4	.0171					.0343	.0171
5	.0341					.0343	.0171
6	.0341						.0343
9		.0329	.0375	.0686	.0219		
10		.0549	.0659	.0514	.0439		
11		.0853	.0857	.0219	.0512		
12		.0853	.1029	.0439	.0512		
13		.0682	.0514	.044	.0341		
14		.0512	.0514	.0357	.0341		
15		.0341	.0857	.0219	.0341		
16		.0341	.0343	.0219	.0341		
18				.7023			
21						.0343	.011
22						.0343	.0219
23					.0171	.0343	.011
24	.0171					.0171	.0171
Max	.0341	.0853	.1029	.7023	.0512	.0343	.0343
Min	.0171	.0329	.0343	.0219	.0171	.0171	.011
Avg	.0220	.0558	.0644	.1124	.0357	.0279	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 201 / 11 KV PALOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.3605	.3772	.4527	.4715	.3395	.3239
2	.421	.3605	.3772	.4527	.4715	.3395	.3239
3	.4534	.3605	.3772	.4527	.4715	.3772	.3563
4	.5182	.3932	.3961	.5281	.5658	.415	.3887
5	.583	.5668	.5281	.6413	.679	.5281	.4534
6	.7287	.6081	.6413	.7545	.7545	.7167	.583
7	.8299	.8676	.7167	.7545	.7545	.8299	.7922
8	.6154	.7356	.6224	.7167	.6602	.7356	.7922
9	.6036	.6602	.5344	.5992	.4424	.502	.5658
10	.415	.415	.8259	.6562	.6539	.5668	.3772
11	.2641	.2452	.8259	.7202	.7042	.6478	.2829
12	.2641	.2263	.9231	.7522	.8048	.7449	.2641
13	.2263	.2075	.8642	.6882	.7712	.6478	
14	.2263	.2641	.7682	.5992	.7042	.583	
15	.2263	.2452	.6964	.5735	.6036	.6154	
16	.2829	.2641	.6964	.5182	.5868	.6154	
17	.3584	.3395	.2263	.3395	.3772	.3018	.3395
18	.4904	.3772	.415	.4904	.4715	.3961	.4904
19	.6413	.5847	.6036	.6224	.6413	.679	.6602
20	.6036	.5658	.6036	.6036	.5658	.6224	.6602
21	.3277	.5281	.5093	.5847	.5281	.2429	.3563
22	.3605	.4715	.4715	.4904	.415	.2591	.502
23	.3768	.4338	.4715	.4904	.3772	.2915	.502
24	.421	.3768	.3961	.4527	.4715	.3772	.3239
Max	.8299	.8676	.9231	.7545	.8048	.8299	.7922
Min	.2263	.2075	.2263	.3395	.3772	.2429	.2641
Avg	.4441	.4357	.5778	.5806	.5811	.5156	.4669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 202 / 11 KV ANWI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.2458	.3961	.415	.4527	.3206	.1619
2	.1943	.2622	.3961	.415	.4527	.3206	.1619
3	.2105	.2622	.3772	.415	.4527	.3395	.1943
4	.2429	.2622	.4527	.4904	.5281	.3772	.2267
5	.3239	.3277	.5281	.6413	.6036	.4904	.2915
6	.5182	.3725	.7167	.679	.679	.679	.3725
7	.7922	.7356	.7733	.6602	.679	.7733	.7922
8	.6602	.6413	.6413	.5847	.5847	.679	.679
9	.3772	.5658	.3725	.3887	.2622	.3401	.415
10	.3018	.3584	.3887	.3887	.2683	.3563	.3395
11	.2452	.2829	.4049	.4161	.3353	.3725	.2829
12	.2263	.2075	.4372	.421	.4024	.3887	.2829
13	.2075	.1698	.4696	.3887	.3688	.3563	.2829
14	.2263	.2641	.421	.4752	.3521	.3563	.2829
15	.2263	.2829	.3077	.421	.3353	.3239	.2829
16	.2641	.2075	.4372	.3277	.3018	.3239	.2829
17	.3018	.2829	.1886	.2075	.3395	.2075	.2829
18	.4904	.3206	.3772	.2452	.4338	.3018	.3584
19	.5847	.5281	.5847	.415	.547	.6036	.5658
20	.5658	.5658	.5658	.5281	.4904	.5658	.6224
21	.2452	.4527	.4338	.4904	.4527	.1943	.2915
22	.2458	.3961	.415	.4715	.3772	.1943	.2915
23	.2458	.3584	.415	.4527	.3395	.1781	.2915
24	.1943	.2458	.3395	.415	.4527	.3395	.1619
Max	.7922	.7356	.7733	.679	.679	.7733	.7922
Min	.1943	.1698	.1886	.2075	.2622	.1781	.1619
Avg	.3369	.3583	.4517	.4480	.4371	.3909	.3416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 203 / RAHIMABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3605	.3961	.4527	.4904	.415	.3239
2	.3239	.3605	.3772	.4527	.4904	.4527	.3239
3	.3563	.3605	.415	.4527	.4904	.4715	.3563
4	.421	.4096	.4527	.679	.6036	.6036	.3887
5	.583	.5243	.5658	.9054	.9054	.7545	.4858
6	.7287	.5898	1.0751	1.094	1.0374		.5992
7	.9431		.9997		1.0185	.9431	
8	.8865	1.0751	.9619		.9619	1.0374	.9808
9	.679	.9054	.5344	.5182	.3887	.4534	.7167
10	.3772	.4527	.4372	.4372	.3688	.4372	.3772
11	.3018	.2452	.5992	.5344	.4024	.421	.2829
12	.2263	.2263	.5506	.421	.4359	.502	.2829
13	.3018	.2075	.4858	.502	.4024	.4534	.3018
14	.3018	.2075	.502	.4534	.3856	.4372	.3206
15	.2829	.2263	.502	.4588	.4024	.4372	.3395
16	.3018	.2263	.4696	.426	.4191	.421	.3772
17	.3772	.3961	.2641	.4534	.3772	.3395	.3018
18	.5281	.4527	.4527	.6224	.5658	.4527	.415
19	.679	.6602	.9242	.7922	.9431	.9619	.679
20	.6036	.7167	.8676	.7545	.6602	.7922	.6413
21	.3113	.547	.4715	.4715	.5281	.3563	.2753
22	.3605	.4904	.4715	.4715	.4904	.3563	.3239
23	.3605	.4338	.4527	.4715	.4527	.3239	.2753
24	.3239	.3605	.3961	.4527	.4904	.415	.3239
Max	.9431	1.0751	1.0751	1.094	1.0374	1.0374	.9808
Min	.2263	.2075	.2641	.421	.3688	.3239	.2753
Avg	.4535	.4537	.5677	.5581	.5713	.5321	.4214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 204 / ASADI AG MIX

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1638	.1886	.2263	.2263	.1698	.1296
2	.1134	.1638	.1886	.2263	.2263	.1886	.1296
3	.1296	.1638	.2263	.2263	.2263	.2075	.1296
4	.1619	.1802	.2263	.2829	.2641	.2263	.1619
5	.1943	.2294	.2641	.3772	.3395	.3018	.2105
6	.2915	.2622	.4338	.4527	.4527	.3772	.2591
7	.2829	.4527	.4715	.4715	.4527	.4715	.4715
8	.3584	.3772	.3584	.3772	.3772	.415	.4338
9	.2641	.3206	.1619	.1943	.1475	.1457	.3018
10	.1886	.1886	.2105	.1781	.2347	.1619	.1698
11	.0943	.132	.2591	.1781	.2012	.1943	.0943
12	.1132	.0943	.2105	.1619	.1677	.2105	.0943
13	.0754	.1132	.2267	.176	.1509	.1943	.132
14	.0754	.1132	.2241	.1781	.1509	.1943	.132
15	.0754	.1132	.1943	.1781	.1341	.1619	.1132
16	.0943	.1132	.1619	.1619	.1509	.1296	.132
17	.1509	.0943	.0943	.1509	.1698	.1509	.1509
18	.1886	.1509	.2075	.2452	.1886	.1886	.1698
19	.3584	.2829	.3395	.3395	.3206	.3772	.3018
20	.2829	.3206	.3395	.3395	.2829	.3395	.3961
21	.1638	.2829	.2641	.2641	.2452	.1296	.1296
22	.1802	.2075	.2263	.2263	.2263	.1296	.1943
23	.1802	.1698	.2263	.2263	.1886	.1296	.1619
24	.1134	.1802	.1698	.2263	.2263	.1698	.1296
Max	.3584	.4527	.4715	.4715	.4527	.4715	.4715
Min	.0754	.0943	.0943	.1509	.1341	.1296	.0943
Avg	.1769	.2029	.2447	.2527	.2396	.2235	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 201 / 11 kv Dhawda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1907	.1677	.2429	.2374		.218
2	.1698	.2103	.1886	.2321	.2543		.218
3	.1886	.2103	.2058	.2713	.285		.2321
4	.2263	.2454	.208	.3149	.3315		.2515
5	.3395	.2629	.2303	.3605	.3978		.2713
6	.4904	.2947	.3641	.4475	.4862		.2818
7	.5281	.547	.5093	.4904	.5281		.4715
8	.4527	.4527	.4527	.4338	.4715		.415
9	.3125	.3018	.2096	.3584	.3018		.3239
10	.2675	.1698	.1886	.2641	.1715		.1886
11	.3018		.132	.1886	.1143		.1509
12	.2782	.1334	.1132	.1509	.0953		.1132
13	.2643	.1132	.1132	.132	.0953		.0943
14	.2572	.0953	.1132	.132	.1143		.0943
15	.2526	.0943	.0943	.1509	.0953		.1132
16	.3086	.0754	.1132	.1886	.1524		.132
17	.1509	.0953	.132	.2263	.1715		.1132
18	.2641	.1698	.1698	.2829	.1715		.1698
19	.3772	.3961	.3961	.3772	.3584	.2829	.3584
20	.3395	.415	.3772	.3961	.3772	.3772	.3395
21	.1543	.1966	.2881	.2294		.2347	.1886
22	.1715	.1658	.253	.2652		.2155	.1174
23	.1543	.1492	.2214	.218		.1989	.1269
24	.2075	.1734	.1509	.2241	.2347		.1989
Max	.5281	.547	.5093	.4904	.5281	.3772	.4715
Min	.1509	.0754	.0943	.132	.0953	.1989	.0943
Avg	.2769	.2243	.2247	.2741	.2593	.2618	.2159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 202 / 11 kv Jambhai

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.2772	.3696	.2865	.2686		.3439
2	.6413	.3326	.4108	.3258	.3077		.362
3	.6602	.3696	.4251	.3841			.4024
4	.7167	.439	.4435	.4435	.394		.4435
5	.9619	.5121	.4854	.6401	.5014		.5228
6	1.4563	.5611	.6535	.7964	.7133		.7282
7	1.475	1.475		1.4377	1.4523		1.4563
8	1.094	1.363		1.307	1.2449		1.3957
9	.4382	1.1128	1.1506	1.1506	.9242	.8488	1.1317
10	.2804	.6602	.7356	.9431	.7167	.811	.6036
11	.2105	.5093	.4668	.8299	.4904		.5093
12	.2214	.4382	.4108	.679	.4904	.4904	.415
13	.2006	.4191	.3734	.6722	.4527	.4715	.4527
14	.1875	.4338	.3921	.6348	.4338	.5281	.4904
15	.1852	.4763	.415	.6348	.4338	.5281	.547
16	.2561	.4338	.4527	.6161	.4904	.5093	.5281
17	.5847	.5144	.5658	.6602	.5658	.5658	.547
18	1.0562	.7545	.8488	.811	.8488	.811	.5658
19	1.1317	1.3817	1.4563	1.2696	1.2826	1.2637	1.0374
20	1.0185	1.3203	1.2449	1.0185	1.0562	1.2449	1.1128
21	.2865	.3881	.4207	.3185		.4024	.4298
22	.2715	.3658	.3475	.2835		.362	.4656
23	.2772	.3658	.2957	.2481		.3475	.4557
24	.7545	.2743	.3511	.3077	.2686		.3292
Max	1.475	1.475	1.4563	1.4377	1.4523	1.2637	1.4563
Min	.1852	.2743	.2957	.2481	.2686	.3475	.3292
Avg	.6269	.6324	.5780	.6958	.6668	.6560	.6365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 203 / 11 kv Amthana

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.5281	.5335	.5093	.5093	.4904	.5525
2	.4887	.5658	.5525	.5281	.5281	.5281	.5281
3	.5194	.6036	.5847	.5658	.5658	.5658	.5716
4	.5731	.679	.724	.679	.6413	.679	.6859
5	.6447	.9054	.8299	.9242	.9709		.9242
6	.7265	1.2696	1.2637	1.363	1.307		1.2826
7	1.2883	1.3392	1.4335	1.4377	1.3256		1.4146
8	1.251	1.4003	1.3392	1.2883	1.2883		1.226
9	.9619	.631	.6485	.7442	.6379		.5959
10	.5658	.5801	.6104	.8048	.6274		.6036
11	.415	.639	.7701	.8987	.5898	.5967	.6133
12	.3961	.7287	.7537	.8139	.639	.5407	.6299
13	.3772	.6882	.7701	.7712		.6133	.5868
14	.3961	.6478	.6882	.7293		.5506	.5765
15	.3772	.6241	.6299	.663		.4973	.6036
16	.4527	.5441	.639	.6062		.4424	.4641
17	.5658	.4527	.4715	.6413	.5658	.415	.4715
18	.8299	.6224	.5847	.6036	.6602	.5281	.6224
19	1.1694	1.1317	1.2071	.8488	1.1506	.7922	1.1694
20	.9242	1.1128	.9808	.8865	1.1128	.9054	1.094
21	.811	.811	.811	.811		.8299	.8676
22	.6602	.743	.6602	.6602	.6602	.7545	.6979
23	.5281	.6413	.5281	.5658	.547	.6602	.6036
24	.4835	.547	.5658	.5093	.5281	.5093	.5716
Max	1.2883	1.4003	1.4335	1.4377	1.3256	.9054	1.4146
Min	.3772	.4527	.4715	.5093	.5093	.415	.4641
Avg	.6615	.7682	.7742	.7856	.7818	.6055	.7482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 204 / 11 kv JOGESHWARI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6068	.6413	.5847	.6413	.6602		.6097
2	.6241	.6224		.6602	.6979		.6287
3	.6588	.6602		.7167	.7356		.7167
4	.7202	.7922		.7842	.8029		.9335
5	.7545	1.0374		.8589	1.0642		1.0562
6	.8309	1.1763		1.2323	1.2696		1.2637
7	1.1576	1.1016		1.2136	1.2136		
8	1.1949	1.1694		1.1389	1.094		1.1506
9	1.0642	.8383		.9496	.8745		.8648
10	.679	.9831		.9724	.9054		.8048
11	.4715	1.0774	.6796	1.0395	.9831	.57	.8551
12	.4668	1.1305	.9614	1.1568	.8619	.4527	.9282
13	.4481	.9667	1.1469	1.0898	.7293	.6718	.8288
14	.4108	.9231	1.0814	1.0442	.5967	.6325	.7545
15	.3734	.9069	.9717	1.0277	.6539	.6478	.7377
16	.4294	.8642	.9995	.9389	.7202	.7042	.7122
17	.5847		.6602	.9896	.5847	.547	
18	.9808		.8676	.9522	.7922	.811	
19		1.226	1.1883	1.1016	.9997	1.0562	.8676
20	.9619	1.0562	1.0185	.9242	1.0751	1.0374	1.0751
21	.7356	.7545	.7922	.7733		.7922	.8299
22	.6979	.7167	.7356	.7356		.7356	.7167
23	.6602	.6859	.679	.7167		.6979	.679
24	.7202	.6413	.6413	.6602	.679		.6413
Max	1.1949	1.226	1.1883	1.2323	1.2696	1.0562	1.2637
Min	.3734	.6224	.5847	.6413	.5847	.4527	.6097
Avg	.7058	.9078	.8672	.9299	.8568	.7197	.8407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 205 / Kelgaon murdeshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.3109	.3772	.3982	.394	.2427	.2772
2	.5093	.3439	.4161	.439	.4163	.2801	.2987
3	.547	.3658	.4382	.5121	.4961	.2772	.2957
4	.679	.4024	.443	.5249	.5083	.2957	.3292
5	.9242	.439	.4887	.5973	.5959	.4887	.3801
6	1.1317	.4525	.6099	.6447	.6733	.5792	.5611
7	1.2826	1.2637	1.3014	1.2883	1.2323	1.1506	1.2449
8	1.1128	1.1128	1.094	1.1694	.9242	1.0185	1.1317
9	.4298	.9242	.8488	.9997	.7545	.811	.8954
10	.3681	.5093	.4904	.7545	.5281	.5093	.5281
11	.3688	.3584	.3395	.6036	.3018	.3429	.415
12	.3521	.2477	.3395	.5658	.2829		.3018
13	.3353	.2263	.3584	.5281	.2829	.3018	.2829
14	.3018	.2477	.3395	.547	.2829		.2641
15	.2818	.2667	.3584	.5658	.2641		.2829
16	.2804	.2641	.3395	.5847	.2829	.3584	.3206
17	.4715	.3206	.415	.5658	.3395		.3395
18	.811	.6224	.547	.5658	.6224		.4904
19	1.0562	.9619	1.094	.9242	.9431	.9431	.9431
20	.7545	.9242	.9431	.7922	.9242	.7922	.8676
21	.2378	.3353	.3582	.3185		.2054	.3366
22	.2715	.3222	.3582	.4031	.168	.2427	.4075
23	.3045	.3391	.3366	.4207	.1867	.2402	.4031
24	.5281	.3258	.3601	.3582	.4075	.2427	.2587
Max	1.2826	1.2637	1.3014	1.2883	1.2323	1.1506	1.2449
Min	.2378	.2263	.3366	.3185	.168	.2054	.2587
Avg	.5778	.4953	.5414	.6280	.5136	.4907	.4940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 201 / 11 KV LONAWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.6089	.4108	.4108	.8316	.6099	.6161
2	.8962	.6984	.4294	.4207	.8871	.7023	.7842
3	.6838	.7973	.4668	.5121	.8871	.8686	.9522
4	.9522	1.0277	.5975	.8029	1.0349	1.0903	1.1016
5	1.1389	1.0631	.8029	.9896	1.1157	1.1888	1.2136
6	1.2752	1.0454	.9896	1.643	1.3352	1.3717	1.307
7	1.419		1.643	1.3491	1.2986	1.2803	1.1576
8	1.307	1.0349	1.363	.9335	.961	1.0791	.8962
9	.9522	.961	1.1576	.7468	.8238	.7468	.7468
10	.7282	.7282	.8215	.7023	.7164	.7095	.8402
11	.4481	.4108	.5601	.6468	.6805	.8962	.5788
12	.3547	.3361	.4481	.4854	.6626	.7095	.5788
13	.3547	.3174	.4854	.462	.6447	.5601	.5788
14	.3734	.3174	.4481	.5041	.5611	.4668	.5601
15	.4294	.3361	.4854	.4481	.543	.5601	.5415
16	.4854	.3734	.5228	.4294	.5249	.7095	.5228
17	.5041	.4108	.5601	.5041	.9425	.7468	.4668
18	.9055	.5788	.7468	1.0269	.9979	.8402	.5788
19	1.5181	1.2136		1.307	1.2071	1.1949	1.1576
20	1.5546	1.3443		1.0974	1.0534	1.1203	1.587
21	.591	.5228		1.0164	.961	.9709	1.251
22	.591	.5041		.7947	.8316	.8402	1.0269
23	.5552	.4668		.8871	.6283	.6348	.7842
24	.2987	.6089	.4108		.8316	.6099	.6161
Max	1.5546	1.3443	1.643	1.643	1.3352	1.3717	1.587
Min	.2987	.3174	.4108	.4108	.5249	.4668	.4668
Avg	.7951	.6829	.7026	.7878	.8734	.8545	.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 202 / 11 KV ANDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3077	.3174	.3174	.7392	.6283	.6348
2	.3361	.3439	.3174	.3174	.7577	.6653	.6722
3	.3921	.3982	.3547	.3547	.7762	.7207	.7468
4	.5601	.6626	.4854	.4854	.8316	.8871	.9335
5	1.1389	.6984	.6535	.6468	.8686	.9425	1.1949
6	.9055	.6805	.7655	.7577	.9425	1.0164	1.3817
7	1.1203	1.2071	1.5497	1.643	1.0164	.9979	1.1949
8	.9149	.9795	1.4003	1.1203	.8686	1.1888	.9896
9	.6535	.7392	1.0269	1.1016	.3439	.4668	.3361
10		.7655	.7095	1.0456	.3077	.2801	.3174
11		.5601	.7095	.9149	.3258	.3361	.2241
12		.4668	.5601	.6224	.2896	.3734	.2054
13		.3921	.4481	.4854	.2534		.0187
14		.3921	.4481	.5041	.2353		.1867
15		.4108	.5228	.5041	.2172	.2987	.2054
16	.3921	.4294	.4854	.5359	.2715	.2801	.2241
17	.4854	.4481	.4668	.5788	.8316	.3361	.4854
18	.7023	.6535	.6535	.9149	.9425	.7282	.6161
19	1.2986	1.0082		1.1763	1.0974	1.1203	1.0829
20	1.3717	1.2323		1.0164	1.0349	1.0456	1.2136
21	.3801	.4108		.924	.9055	.9149	.9149
22	.362	.3921		.8501	.7762	.7842	.7095
23	.3258	.3547		.7762	.6283	.6348	.6348
24	.2957	.2896	.3174		.7392	.6468	.6535
Max	1.3717	1.2323	1.5497	1.643	1.0974	1.1888	1.3817
Min	.2957	.2896	.3174	.3174	.2172	.2801	.0187
Avg	.6640	.5926	.6417	.7649	.6667	.6951	.6574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 203 / 11 KAV ANDHARI - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2715	.3547	.3511	.7577	.7207	.7282
2	.3361	.3077	.3547	.3547	.7762	.7762	.7842
3	.3734	.3801	.3921	.3921	.8316	.8871	.8962
4	.6535	.6268	.5415	.5415	.924	.9979	1.0082
5	.8962	.6447	.7655	.9709	1.134	1.134	1.1949
6	1.2696	.6089	.9709	1.6617	1.2437	1.262	1.2696
7	1.3256	1.1706	1.6617	1.3443	1.3717	1.2803	1.0829
8	1.1576	.961	1.3443	1.0082	.961	1.134	.8962
9	.7468	.9425	.9522	.8402	.3439	.3921	.3361
10		.6535	.5788	.8029	.3982		.3361
11		.4108	.5601	.6535	.4344	.2801	.4108
12		.3174	.4481	.4527	.4344	.3361	.3921
13		.2614	.3734	.4108	.4525		.3921
14		.2987	.3361	.3921	.3982		.4108
15		.3361	.3547	.3921	.3439	.3734	.3921
16	.4108	.3734	.3921	.4108	.4525	.3174	.3734
17	.4854	.4108	.4108	.5601	.7947	.2614	.4294
18	.6468	.5975	.5975	1.0269	.9055	.7095	.4904
19	1.2803	1.1203		1.1389	1.0974	1.0642	1.0269
20	1.39	1.419		1.0903	.9979	1.1203	1.307
21	.3077	.3361		.9795	.961	.9709	1.0456
22	.3258	.3174		.8131	.8686	.8775	.8402
23	.2896	.3361		.7392	.7207	.7282	.7095
24	.2801	.2715	.3547		.7577	.7023	.7095
Max	1.39	1.419	1.6617	1.6617	1.3717	1.2803	1.307
Min	.2801	.2614	.3361	.3511	.3439	.2614	.3361
Avg	.693	.5572	.6181	.7534	.7651	.7774	.7276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 201 / 11 KV INDUSTRIAL EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
FEED Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	.3772	.3772	.3395	.3395	.415
2	.3018	.3734	.3395	.3734	.3395	.2987	.3772
3	.3018	.3734	.3018	.3734	.3395	.3018	.3772
4	.3206	.3772	.3018	.3734	.3395	.2987	.3772
5	.3395	.3734	.3361	.3734	.3395	.3361	.415
6	.3584	.3772	.4108	.4715	.3772	.3547	.4527
7	.3584	.3734	.462	.4715	.3772	.3696	.4527
8	.4527	.3734	.4854	.362	.415	.3734	.4904
9	.8488	.543	.7655	.3772	.679	.3921	.5281
10	.9808	.6653	.9335	.3772	.7167	.4854	.5658
11	.9335	.6722	.924	.3772	.4854	.4527	.543
12	.9335	.7095	.9425	.3772	.6653	.4527	.543
13	.905	.6161	.9335	.3772	.7095	.415	.543
14	.7468	.4668	.924	.3772	.6653	.415	
15	.6535	.5544	.8402	.415	.6283	.415	.5601
16	.8402	.6838	.8402	.3772	.6653	.4527	.362
17	.9335	.6722	.6535	.3395	.6722	.4527	.3734
18	.7468	.6722	.543	.3395	.5601	.4527	.362
19	.7468	.5228	.4668	.3395	.4435	.415	.4525
20	.4668	.3174	.3734	.2804	.4481	.4904	.362
21	.4904	.3734	.5658	.3734	.3361	.3772	.3772
22	.3772	.4108	.5658	.3734	.4294	.3734	.3772
23	.3734	.3772	.4525	.3395	.3772	.415	.3734
24	.3326	.3772	.3772	.4525	.3395		.415
Max	.9808	.7095	.9425	.4715	.7167	.4904	.5658
Min	.3018	.3174	.3018	.2804	.3361	.2987	.362
Avg	.5868	.4847	.5882	.3779	.4870	.3969	.4389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 202 / TILAKNAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.5658	.5601	.543	.5658	.5792
2	.543	.5601	.5658	.5601	.5068	.5658	.543
3	.543	.5601	.6036	.543	.5068	.5658	.543
4	.6154	.5601	.6036	.543	.5068	.6535	.5792
5	.6516	.7468	.7095	.5258		.7095	.6516
6	.8145	.7888	.7577	.7468		.8402	.8326
7	.9412	.9335	.8402	.8402	.5068	.9709	.9412
8	.8326	.8402	.9431	.9335		.8402	.8688
9	.724	.7468	.7468	.724	.8326	.7655	.7392
10	.6516	.7095	.7095	.724	1.0498	.7023	.724
11	.5601	.7468	.6283	.6878	.8871	.6516	.6335
12	.5601	.6722	.5544	.6154	.7762	.6878	.543
13	.5601	.5228	.5544	.5792	.6722	.5792	.543
14	.5601	.4668	.5415	.543	.6722	.5792	
15	.4677	.462	.5601	.5792	.7023	.6516	.5258
16	.543	.5544	.5601	.5792	.7282	.6516	.7468
17	.5601	.6722	.6535	.6154	.7842	.724	.7468
18	.5601	.6908	.6535	.724	.7655	.7392	.724
19	.9335	.7468	.8402	.7602	.8871	.8501	.8145
20	.7468	.7095	.7468	.7842	.8589	.8688	.8145
21	.724	.6908	.724	.724	.8029	.6335	.7602
22	.6516	.6535	.6878	.7468	.7468	.5601	.7602
23	.5601	.6036	.5601	.5792	.7095	.5792	.543
24	.5792	.5601	.5658		.543	.5658	.5792
Max	.9412	.9335	.9431	.9335	1.0498	.9709	.9412
Min	.4677	.462	.5415	.5258	.5068	.5601	.5258
Avg	.6428	.6559	.6615	.6617	.7137	.6876	.6842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 203 / NEW TOWN 2 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5618	.4715	.5601	.4805	.4904	.5175
2	.5175	.5601	.4715	.543	.4805	.4904	.5175
3	.5544	.543	.5281	.5601	.5175	.4904	.5175
4	.5914	.5658	.5281	.5601	.5175	.5281	.5914
5	.6283	.7468	.5975	.6535	.6653	.6602	.7023
6	.8131	.8402	.6535	.724	.7392		.8131
7	.8501	.8402	.7577	.7468	.8131		.8501
8	.924	.8402	.7468	.724	.8316		.8501
9	.8316	.9335	.7282	.7468	.8131		.8501
10	.7762	.8215	.7392	.7011	.7762	.5544	.7762
11	.6535	.7655	.5359	.6653	.7207	.4251	.7468
12	.6335	.7468	.5415	.6283	.6348		.724
13	.543	.5975	.4435	.6283	.5228		.543
14	.543	.3734	.5415	.5914	.5175	.7392	
15	.4525	.3696	.4668	.5175	.5914	.7392	.5601
16	.4525	.3326	.4692	.5544	.5975	.7392	.543
17	.5601	.5041	.6535	.5914	.6348	.7023	.6535
18	.5601	.5788	.6535	.7392	.7468	.7392	.7468
19	.7468	.5975	.724	.7762	.8402	.8501	.8402
20	.6335	.5975	.6535	.6348	.6722	.7392	.724
21	.6283	.5415	.5544	.5601	.6413	.6335	.6283
22	.5544	.5041	.5544	.5601	.5601	.5601	.5544
23	.4668	.4715	.4525	.5544	.5228	.5544	.543
24	.5175	.5601	.4527		.4805	.4904	.5175
Max	.924	.9335	.7577	.7762	.8402	.8501	.8501
Min	.4525	.3326	.4435	.5175	.4805	.4251	.5175
Avg	.6229	.6164	.5800	.6313	.6382	.6181	.6657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 204 / TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5447	.5093	.5601	.5544	.5658	.5914
2	.5175	.5601	.5093	.5601	.5544	.5658	.5544
3	.5359	.5601	.5093	.5601	.5544	.5658	.5544
4	.5544	.5601	.5658	.5601	.5544	.6413	.6283
5	.6653	.6335	.5975	.6335	.6653	.6535	.7023
6	.7762	.8402	.6099	.6335	.7762	.6908	.7762
7	.8501	.9335	.6468	.724	.8131	.7282	.924
8	.7762	.9335	.7095	.8402	.7392	.5975	.8871
9	.7392	.8145	.5228	.8402	.7392	.5975	.8501
10	.7392	.8215	.6283	.7468	.7392	.5914	.7762
11	.6335	.8029	.4805	.7392	.7577	.6653	.724
12	.6535	.7468	.4805	.7392	.6653	.5914	.7468
13	.6335	.6722	.4435	.6283	.7095	.5914	.8402
14	.7095	.5601	.5544	.6468	.6535	.7392	
15	.6878	.5544	.5601	.6653	.7023	.7392	.724
16	.6535	.5914	.543	.6653	.7095	.7392	.7011
17	.724	.6535	.7468	.6653	.8029	.7392	.8402
18	.8402	.7095	.8402	.7762	.8589	.7392	.8145
19	.8402	.8402	.9335	.8871	.8962	.924	.905
20	.7468	.7468	.724	.7011	.8029	.8501	.8145
21	.6283	.5788	.6653	.7468	.6908		.7762
22	.5914	.5601	.5544	.7468	.6348	.724	.7392
23	.5601	.5281	.5601	.6283	.6036	.6468	.7468
24	.5175	.5601	.5093	.5601	.5544	.5658	.5914
Max	.8501	.9335	.9335	.8871	.8962	.924	.924
Min	.5175	.5281	.4435	.5601	.5544	.5658	.5544
Avg	.6705	.6794	.6002	.6856	.6972	.6718	.7482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 206 / 11 KV BALAJINAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.3772	.415	.362	.4805	.4904	.4805
2	.4805	.3734	.415	.3734	.462	.4904	.4805
3	.5175	.3734	.4715	.3506	.4435	.4904	.4805
4	.5544		.5228	.362	.4435	.5228	.5175
5	.6653	.5601	.5975	.4668	.5175	.5975	.5914
6	.7392	.724	.6722	.543	.6468	.7095	.7023
7	.7392	.8402	.7392	.7468	.7392	.8029	.7392
8	.7392	.724	.6908	.7468	.6653	.6722	.7023
9	.6468	.6335	.5601	.5601	.5914	.5975	.6283
10	.5544	.6722	.499	.5601	.5914	.5175	.5544
11	.4668	.5601	.4435	.5175	.4481	.5175	.3734
12	.3734	.4668	.3696	.5175	.4108	.3696	.3734
13	.362	.3361	.3361	.4066	.3734	.3326	.362
14	.362	.2801	.3734	.4066	.3547	.3696	
15	.3734	.3142	.3734	.3696	.4066	.3696	.362
16	.3734	.2402	.362	.4066	.4108	.3696	.3734
17	.3734	.3921	.362	.4435	.4854	.4435	.3734
18	.5601	.4854	.4668	.5914	.5788	.4805	.3734
19	.5601	.5788	.5601	.6283	.6348	.5544	.6335
20	.543	.5601	.543	.5601	.5601	.5544	.6335
21	.5175	.4854	.5544	.5601	.5601	.543	.5544
22	.5175	.4668	.5175	.5601	.5415	.5601	.5544
23	.3734	.4527	.4525	.5175	.5281	.5175	.543
24	.4805	.3734	.415		.4805	.4904	.4805
Max	.7392	.8402	.7392	.7468	.7392	.8029	.7392
Min	.362	.2402	.3361	.3506	.3547	.3326	.362
Avg	.5147	.4900	.4880	.5025	.5148	.5151	.5160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 202 / YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0543	.0503	.0572	.0503	.0543	.0503
2	.0572	.0543	.0503	.0572	.0503	.0543	.056
3	.0762		.0747	.0762	.0671	.0724	.0671
4	.0934	.0905	.0914	.1143	.0838	.1086	.1097
5	.1848	.1629	.1677	.1509	.1677	.1629	.1341
6	.2402	.181	.218	.2033	.218	.1991	.2054
7	.2743	.2172	.2427	.2561	.2561	.2353	.2561
8	.1494		.2012	.1448	.2012	.2353	.218
9	.2286		.1509	.1905	.1844		.2012
10	.181	.1341	.1143	.1829	.1448	.1006	.1848
11	.1267	.0671		.1646	.1086	.1174	.128
12	.0905	.0747	.0747	.088	.0905	.0671	.1086
13	.0543	.0671	.0747	.044	.0724	.0503	.0953
14	.0543	.0503	.056	.0497	.0543	.0503	.0747
15	.0543	.0503	.0572	.0503	.0724	.0838	.0549
16	.0724	.0838	.0747	.0671	.0739	.1006	.0739
17	.1086	.0838	.1294	.0838	.168	.1174	.1524
18	.1267	.1006	.1905	.1174	.1524	.1174	.1334
19	.1267	.1174	.1905	.1677	.2286	.1677	.1905
20	.1086	.1006	.1524	.1677	.181	.1677	.1143
21	.0905	.0838	.1143	.0838	.1448	.1677	.0762
22	.0724	.0732	.0762		.1086	.0671	.0572
23	.0543	.0549	.0572			.0503	.0762
24	.0543		.0503	.0572	.0543		.0503
Max	.2743	.2172	.2427	.2561	.2561	.2353	.2561
Min	.0543	.0503	.0503	.044	.0503	.0503	.0503
Avg	.1140	.0951	.1156	.1170	.1275	.1158	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 204 / MAHADEV MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.543	.4527	.4382	.4527	.6154	.4294
2	.5716	.543	.503	.4763	.503	.6154	.4668
3	.6859	.6335	.6036	.4954	.6036	.6697	.4854
4	.7621	.724	.6706	.5906	.6706	.724	.5197
5	.8131	1.0136	.7377	.6653		.905	.6722
6	1.1222	1.3937	1.0395	.8596	1.134	1.1765	.788
7	1.3289	1.4118	1.1233	1.1222	1.2742	1.2127	1.3256
8	1.2936		1.0898	1.3676	1.307	1.1765	1.0059
9	1.4098		1.2696	1.4289	1.1904		1.0608
10	1.1584	1.2742	1.1431	1.0269	1.2308	1.1568	
11	.9774	1.0898	.9425	1.0242	1.086	1.1736	1.086
12	.7783	.9892	.7316	.8589	.905	.8551	.8596
13	.724	.7377	.6838	.7468	.724	.5533	.7621
14	.5973	.5533	.6401	.7282	.6878	.503	.6036
15	.5973	.4938	.6516	.5868	.6335	.5365	.5731
16	.6154	.4207	.7316	.7042	.7316	.5935	.7316
17	.8326	.5868	.8507	.7042	.9145	.7042	.8954
18	1.0136	.7209	1.0479	1.0059	1.0479	.8718	1.0479
19	1.0317	1.0642	1.1812	.9995	1.0669	1.1389	1.3336
20	1.0136	1.0456	.9907	1.0227	.905	1.1389	1.105
21	.8326	.7712	.8954	.7377	.7964	.8215	.8573
22	.724	.6706	.7621		.724	.7468	.7621
23	.6335	.6535	.6668			.6535	.6859
24	.543		.503	.5716	.6516		.5601
Max	1.4098	1.4118	1.2696	1.4289	1.307	1.2127	1.3336
Min	.5144	.4207	.4527	.4382	.4527	.503	.4294
Avg	.8573	.8254	.8297	.8255	.8746	.8428	.8094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 205 / AURANGABAD NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4887	.4024	.362	.4024	.5249	.3185
2	.5144	.4887	.4527	.381	.4527	.5249	.3353
3	.5716	.5068	.5601	.4191	.503	.543	.3688
4	.6097	.6335	.5975	.4954	.5365	.5792	.4359
5	.7392	.724	.6706	.5716	.6706	.724	.503
6	.8413	.8326	.7712	.7392	.7712	.7602	.6706
7	.9231	.8688	.7095	.9511	.8402	.8326	.7042
8	.9795		.788	1.0242	.9054	.8145	.8048
9	.9907		.9335	.9717	.8718		.8886
10	.905	1.0059	.8002	.9522	.8869	.7545	.8779
11	.7602	.788		.8029	.8145	.6706	.823
12	.724	.6539	.5914	.7282	.6697	.5197	.6516
13	.6335	.4359	.5914	.5975	.5792	.5365	
14	.543	.4527	.567	.6161	.6154	.5788	
15	.5792	.4024	.6036	.4862	.5973	.57	.6219
16	.6335	.3856	.6401	.5533	.6335	.5868	.7023
17	.724	.4862	.7392	.6535	.724	.6706	.7621
18	.7602	.6203	.9526	.5868	.8383	.8048	.8954
19	.7964	.7377	.9907	.7377	.8764	.7377	.9526
20	.724	.6706	.7811	.8048	.724	.7377	.8954
21	.6878	.6371	.7049	.6203	.6697	.6203	.6287
22	.5792		.6097		.6335	.5365	.6668
23	.5068	.4694	.4763			.4191	.5716
24	.4887		.4527	.4572	.6154		.4024
Max	.9907	1.0059	.9907	1.0242	.9054	.8326	.9526
Min	.4572	.3856	.4024	.362	.4024	.4191	.3185
Avg	.6947	.6144	.6690	.6596	.6883	.6385	.6582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 201 / BHAGOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4801	.1715	.4458	.5144	.3429	.5144
2	.3772	.4115	.1715	.4801	.4801	.3086	.6722
3	.3772	.4458	.1715	.5487	.4801	.3429	.8573
4	.4115	.4801	.1715	.6173	.5144	.4458	.9259
5	.6173	.4115	.1715	.6859	.5487	.6516	1.166
6	.6687		.2058	.7545	.5487	.7202	1.3032
7	.7202		.2058	.7888	1.0288	1.0974	1.406
8	.7545		.1886	.7202	1.0288	1.166	1.2689
9	.4115		.3086	.6859	.4458	.4801	.2058
10	.3772			.703			
11				.5316			
12	.2401		.3429	.2743		.2401	
13	.2401		.3429	.2572	.3086	.2401	.2058
14	.2401	.1372	.3086	.2058	.2743	.2058	.2229
15	.2401	.1372	.2401	.2058	.2058	.2401	.2058
16		.1372	.2743	.2743	.2401	.2743	.3086
17		.4287	1.5089	1.2689	.3429	.2743	.3429
18	1.2003	.3772	1.4403	1.2887	.3429	.3086	.5487
19	1.0974	.4458	1.0974	.6516	.6859	.4115	.6859
20	1.0288	.3944	.9602	.7545	.6173	.4458	.6173
21	.8573	.2572	.7545	.7202	.4458	.4458	.5144
22	.583	.2401	.6516	.6516	.4115	.3772	.4801
23	.5487	.2058	.6173	.583	.4115	.4801	.4801
24	.4801	.5144	.1715	.4458	.5487	.3772	.4409
Max	1.2003	.5144	1.5089	1.2887	1.0288	1.166	1.406
Min	.2401	.1372	.1715	.2058	.2058	.2058	.2058
Avg	.5642	.3440	.4762	.6060	.4964	.4489	.6368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 202 / JATEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.7373	.9602	.823	1.166	.7545	1.3717
2	.9602	.823	.9945	1.0288	1.2003	.7888	1.3565
3	1.0288	.8916	1.0631	1.0974	1.2346	.823	1.3032
4	1.166	.9259	1.3032	1.166	1.2689	.9602	1.3032
5	1.3032	.9945	1.406	1.2003	1.3375	1.3375	1.2003
6	1.4746		1.4403	1.2689	1.3717	1.406	1.2887
7	1.3375		1.406	1.3375	1.3032	1.4746	1.3717
8	1.2003		1.3717	.9945	1.3717	1.5089	1.3032
9	3.2526		2.8166	2.6871	.8573	1.166	1.2346
10	3.152	1.5432	2.6155	2.9492	.7888	1.0631	
11	2.6825		2.5149	2.8509		.9945	.5487
12	2.5095	2.4006	2.4756	2.2939			.5144
13	2.4417	2.5377	2.4348	2.2611			.4801
14	2.3137	2.332	2.2977	2.0317			.4801
15	2.332	2.2634	2.2382	2.13			.5144
16	2.1026	2.2291	2.3739	2.13			.4458
17			.7202	.4458		2.915	2.8121
18			.7888	.7202	2.7199	2.7435	2.7469
19	1.0974	1.3565	1.166	1.166	2.6216	2.915	2.7435
20	1.3375	1.5261	1.0288	1.2346	2.556	2.8121	2.5034
21	1.3032	1.0288	.9602	1.2003	2.13	2.4006	2.1704
22	.9945	1.0288	.9259	1.166	2.0972	2.1948	2.1365
23	.9259	.9945	.9259	1.1317	1.8351	2.0576	2.0348
24	.9259	.8573	.9602	.7545	1.166	1.704	1.9547
Max	3.2526	2.5377	2.8166	2.9492	2.7199	2.915	2.8121
Min	.9259	.7373	.7202	.4458	.7888	.7545	.4458
Avg	1.6728	1.4394	1.5495	1.5029	1.5898	1.6852	1.4704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 203 / MAHALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.9945	1.2887	1.166	1.1317	.6173	.9156
2	1.0974	.9602	1.3226	1.3032	1.0974	.6859	.9259
3	1.0974	.9602	1.4582	1.5089	1.1317	.7202	1.0288
4	1.406	1.0288	1.5074	1.8861	1.166	.823	1.166
5	1.9006	1.166	1.5729	2.1948	1.3032	1.166	1.166
6	2.0972		1.704	2.4006	1.3375	1.2346	1.153
7	2.2283		2.2611	2.5377	1.3717	1.2346	1.2003
8	2.3594		2.3594	2.7435	1.3375	1.2346	1.166
9	1.0974		.9945	1.0974	1.8861	2.1026	1.9006
10	.6859	1.0288	.8573	.8916	1.7147	2.0919	
11	.6104		.583	.9602	2.0576	1.8176	2.0972
12	.5487	1.0288	.4801	.7888	1.8861	1.749	2.1628
13	.5487	1.0288	.4801	.6173	2.0576	1.749	1.9662
14	.5487		.4458	.6173	1.8861	1.7833	1.3565
15	.583		.4458			1.6804	1.9334
16	.583	.6859			1.9662	1.2548	1.9989
17					.6859	.6859	.583
18	1.166			.9602	.823	.6859	1.166
19	1.2689	1.166	1.2003	1.3032	.8916	.9945	1.3375
20	1.3717	1.3717	1.2003	1.3717	1.0288	1.0288	1.3375
21	1.2346	.8916	1.166	1.3717	.823	1.0974	1.3032
22	1.0974	.7202	1.0288	1.3032	.7202	.9945	1.2689
23	1.0513	.9602	1.3717	1.2689	.6859	.8573	1.2003
24	.9945	1.0174	1.2209	1.166	1.166	.6173	.9156
Max	2.3594	1.3717	2.3594	2.7435	2.0576	2.1026	2.1628
Min	.5487	.6859	.4458	.6173	.6859	.6173	.583
Avg	1.1582	1.0006	1.1880	1.4028	1.3111	1.2044	1.3587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 204 / KATE PIMPLGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.5144	.2743	.4458	.5487	.5487	.6859
2	.1715	.4801	.2743	.4458	.583	.583	.6859
3	.2058		.2743	.4458	.6173	.6516	.9259
4	.2401		.3086	.4458	.6516	.7888	1.166
5	.3772		.3086	.4801	.7888	.9945	1.3032
6	.4801		.3086	.4801	.9259	1.166	1.3717
7	.583		.4108	.4801	1.4746	1.5729	1.7147
8	.6173		.4115	.6516	1.4582	1.704	2.0576
9	.4115		.3772	.4801	.4458	.4115	.2058
10	.3429		.3429	.4115	.3429	.3429	
11	.3086		.2743	.3429	.3429	.2743	
12	.3086		.2058	.2743	.3429	.1715	
13	.2401		.2058	.2058	.3086	.1715	.2058
14	.2058		.2058	.2058	.3086	.1715	.2058
15	.1715	.2058	.1715	.2058	.2743	.1715	.2743
16	.1372	.2058	.1372	.1715	.2743	.1715	.2058
17	1.704	1.704	1.3717	1.7147	.4115	.2058	.2743
18	1.6278	1.7695	1.7147	1.7635	.4115	.4458	.4115
19	1.4746	1.5074	1.5432	1.5432	.4801	.4458	.5487
20	1.166	1.153	1.3375	1.1317	.4801	.4801	.4458
21	.9602	.9602	1.166	1.0288	.3429	.5144	.4115
22	.823	.8916	1.0288	.9259	.2743	.4458	.3429
23	.6173	.823	1.0288	.6516	.5487	.6104	.5144
24	.8916	.5487	.6859	.823	.6173	.5487	.6173
Max	1.704	1.7695	1.7147	1.7635	1.4746	1.704	2.0576
Min	.1372	.2058	.1372	.1715	.2743	.1715	.2058
Avg	.5932	.8970	.5987	.6565	.5523	.5664	.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 206 / PANVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7368	1.7635	1.9334	2.4006	1.0974	1.0974	1.0631
2	1.7695	1.7974	1.9334	2.5034	1.0974	1.0631	1.0631
3	1.8023	1.749	1.9989	2.7092	1.1317	1.0631	1.166
4	2.0972	1.5775	2.0972	2.8292	1.166	1.166	1.2003
5	2.556	1.8652	2.0972	2.9492	1.166	1.3032	1.2346
6	2.8182		2.13	3.0178	1.2003	1.3375	1.2689
7	.4801		2.7526	3.0864	1.3375	1.3717	1.3032
8	.5487		2.6871	2.8807	1.0974	1.0288	1.2689
9	.6516		1.2003	.6173	3.0864	3.3608	2.8837
10	.6173	.6859	1.0974	.8573	3.4294	3.2556	
11	.5487		1.0288	1.0288	3.4637	2.7435	3.1786
12	.5144	.8573	.9602	.9945	3.1893	2.7435	3.2114
13	.5487	.8916	.9945	.9602	3.0864	2.7092	2.556
14	.583	.8573	1.0288	.9602	2.9835		2.556
15	.6173	.823	1.0631		2.7435		2.556
16	.6516	.823			3.1131	1.5261	2.556
17					.7202	1.0288	.7545
18				1.2003	.9602	1.2689	1.0974
19	1.166	1.4403	1.166	1.3032	1.2003	1.2003	1.3032
20	1.3032	1.4403	1.1317	1.3375	1.2003	1.2346	1.3375
21	1.2003	1.166	1.2003	1.3032	1.2003	1.2003	1.3032
22	.9945	1.0974	.9945	1.2346	1.2003	1.2346	1.166
23	1.4746	1.6057	1.5432	1.166	1.1317	1.1869	1.0974
24	1.6712	1.749	1.9006	2.1948	1.0974	1.0974	1.0631
Max	2.8182	1.8652	2.7526	3.0864	3.4637	3.3608	3.2114
Min	.4801	.6859	.9602	.6173	.7202	1.0288	.7545
Avg	1.1978	1.3053	1.5685	1.7874	1.7958	1.6010	1.6604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 207 / MALISAGAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0631	1.2003	1.2003	1.0974	1.166	.8573
2	1.2003	1.0974	1.2346	1.2003	1.166	1.2003	.8573
3	1.2517	1.0974	1.2346	1.2003	1.2689	1.2346	1.166
4	1.3375	1.2689	1.3375	1.166	1.3032	1.3032	1.3032
5	1.5089	1.166	1.3032	1.2346	1.3226	1.3375	1.3032
6	1.543		1.286	1.2346		1.0631	1.2003
7	1.4582		1.2346	1.2003	1.2887	.9945	1.2003
8	1.2346		1.1317	1.2003	1.0174	.9602	1.2346
9	1.5089		1.166	1.6057	1.0288	.9259	1.166
10	1.3375	1.0288		1.4746			
11			1.4922	1.166			
12	.9259	1.2003	1.5089	1.0631		.583	
13	1.1191		1.3565	.9945	.6859	.5487	.6173
14	1.0631	1.166	1.2548	.7545	.6173	.5144	.583
15	1.166	1.3717	1.0974	1.0288	.4801	.5487	.5487
16		1.4746	1.3565	1.0974	.6173	.6173	.583
17		.6859	.9259		1.7368	1.3717	1.3565
18	.7888	.7888	.78	.8573	1.5893	1.6118	1.5261
19	.9945	1.3203	.9259	1.166	1.3435	1.4746	1.5939
20	1.166	1.2346	1.0631	1.2003	1.2517	1.2003	1.2689
21	1.3375	1.2003	1.0974	1.166	1.0631	1.0288	1.0852
22	1.3032	1.286	1.0974	1.1317	1.0631	.9945	1.0631
23	1.2346	1.2689	1.0631	1.0631	.9088	.9259	.9945
24	1.166	1.166	1.2003	1.0631	1.0974	.8916	.8573
Max	1.543	1.4746	1.5089	1.6057	1.7368	1.6118	1.5939
Min	.7888	.6859	.78	.7545	.4801	.5144	.5487
Avg	1.2291	1.1603	1.1890	1.1508	1.0974	1.0226	1.0650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 208 / SIRASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4922	1.4403	1.4922	1.8861	.9945	1.0288	1.0974
2	1.4746	1.3032	1.6278	2.0576	1.0631	1.046	1.0852
3	1.6385	.9945	1.6057	2.332	1.0974	1.0631	1.166
4	2.0645	1.0631	1.7368	2.5377	1.1317	1.2689	1.2003
5	2.2611	1.153	1.8351	2.6406	1.166	1.3375	1.2689
6	2.4086		1.9006	2.7778	1.2346	1.3717	1.3032
7	2.4249		2.4249	2.915	1.3375	1.3375	1.3375
8	2.5069		2.4905	2.6216	1.2689	1.1488	1.0288
9	1.2689	.823	1.3375	.9431	1.8861	3.3265	2.7526
10	1.166	.823	1.2689	1.1488	3.0864	3.1893	
11	1.166		1.2346	1.1145	3.2236	3.2217	
12			1.2346	1.166	3.2922		2.9001
13			1.2003	.9431	3.2579	2.4348	2.556
14				.9602	3.0521	2.572	1.3565
15	1.2689		1.3032	.9602	2.7435	2.7496	2.0481
16	1.3375		1.406	1.0974	2.4577	2.8502	3.0476
17	1.3032		1.2003	1.0974	.823	1.0288	1.3375
18		1.3375	1.2003	1.0117	1.0288	1.0288	1.3375
19	1.0974	1.6876	1.2346	1.3375	1.166	1.0974	
20	1.3375	.6859	1.2346	1.2346	1.1317	1.0631	1.3375
21	1.3032	.9431	1.2003	1.2689	.9945	1.2003	1.3717
22	.8573	.8916	1.0288	1.166	.9945	.9259	1.3032
23	1.2689	1.3375	1.5432	1.1317	1.0288	.9602	1.2689
24	1.3904	1.2887	1.4582	1.7147	1.0974	1.0631	1.0852
Max	2.5069	1.6876	2.4905	2.915	3.2922	3.3265	3.0476
Min	.8573	.6859	1.0288	.9431	.823	.9259	1.0288
Avg	1.5518	1.1266	1.4869	1.5860	1.6899	1.6658	1.5805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 209 / CHINCHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6516	.4801	.4801	.6859	.5658	.7888
2	.6173	.583	.4801	.6173	.6516	.5658	.8573
3	.6516	.5487	.5487	.6173	.6173	.6173	.8573
4	.7202	.7888	.7888	.6859	.6173	.823	.9945
5	.9602	.823	.823	.9259	.7202	1.0117	1.2003
6	1.0802		.8916	1.0631	.7545	1.166	1.3226
7	1.166		.9945	1.0288	1.5432	1.4083	1.8023
8	.9602		1.0288	.9945	1.6278	1.4922	2.3922
9	.823	.5144	.9602	.9602		.6516	.3772
10	.823	.5144	.5487	1.0288		.5487	
11	.7202		.4458	.823	.6516	.4458	
12		.6516	.3429	.5487	.6516	.3772	.4115
13		.6173	.3772	.5144	.5487	.3772	.3429
14		.6173		.4115	.5144	.3429	.3429
15	.2743	.583	.4115	.3429	.4458	.4115	.3429
16	.3086	.5144	.4458	.3772	.4801	.4801	.4115
17	1.2346	1.3375	1.8861	1.6804	.5316	.4458	.583
18	1.6461	1.2346	1.749	1.6289	.6173	.5487	.6516
19	1.5089	1.6108	1.5432	1.2003	1.0631	.7888	
20	1.2689	.8573	1.3032	.9259	.8916	.823	.9945
21	1.166	.7545	.8573	.8916	.7373	.7545	.7545
22	.6859	.7202	.7545	.9602	.7373	.6859	.7202
23	.6859	.6173	.6859	.9259	.5487	.6859	.7202
24	.7202	.6859	.4801	.4801	.7888	.5316	.5144
Max	1.6461	1.6108	1.8861	1.6804	1.6278	1.4922	2.3922
Min	.2743	.5144	.3429	.3429	.4458	.3429	.3429
Avg	.8859	.7613	.8186	.8380	.7466	.6896	.8277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 210 / LAKSHMI AGRO FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	20-MAR-18
HR	Load (MW)
17	.1524
19	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 201 / LADGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.1736	1.2003	1.4575	1.5623	1.6194	.3429
2	1.4251	1.0059	1.2003	1.4575	1.5623	1.6194	.3429
3	1.4251	1.0059	1.2003	1.4575	1.5623	1.6194	.3429
4	1.4251	1.0059	1.2003	1.4575	1.5623	1.6194	.3429
5	1.5089	1.1736	1.3717	1.6194	1.5623	1.7004	.5144
6	1.5746	1.5089	1.5432	1.6194	1.5623	1.7004	.6001
7	.5601	.7468	.4287	.4668	.5601	.4668	.4287
8	.4668	.6001	.4287	.2829	.4668	.3772	.3429
9	.4668						1.8861
10							2.0243
12							2.1052
13							2.2672
14							2.2672
15							2.1862
16							2.0481
17	.2829	.3429	.2829	.3734	.2829	.2572	.2829
18	.3772	.2572	.2829	.3734	.3734	.2572	.3772
19	.4668	.3429	.3696	.5601	.3696	.4287	1.0164
20	.3772	.4287	.3734	.4668	.3696	.4287	.4668
21	1.1022	1.3717	1.6194	1.5565	1.6194	.3429	.3772
22	1.6575	1.3717	1.7004	1.7185	1.8623	.3429	.3772
23	1.3413	1.3717	1.7004	1.7185	1.8623	.3429	.3772
24	1.6385	1.1736	1.2003	1.4575	1.7185	1.7814	.3429
Max	1.6575	1.5089	1.7004	1.7185	1.8623	1.7814	2.2672
Min	.2829	.2572	.2829	.2829	.2829	.2572	.2829
Avg	1.0356	.9301	1.0064	1.1277	1.1787	.9315	.9417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 202 / SAWKHED GANAGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829	.3429	.3772	.2801	.3772	.6859
2	.2829	.2829	.3429	.3772	.2801	.3772	.6859
3	.2829	.2829	.3429	.3772		.3772	.6859
4	.2829	.2829	.3429	.4668	.3734	.4715	.6859
5	.3734	.2829	.3429	.5601	.4668	.5601	.8573
6	.5601	.5601	.5144	.6468	.6401	.6468	1.0288
7	.6535	.6468	.5144	.5544	.6401	.7316	.5144
8	.3772	.5601	.4287	.5544	.5601	.5544	.5144
9	1.3413		.4287	1.3765	1.2289	1.2955	
10	1.6385	1.286	.4287	1.4746	1.2146	1.3717	
11	1.6385	1.286	.4287	1.4746	1.2955	1.3717	
12	1.3413	1.286	.4287	1.4746	1.2955	1.5432	
13	1.6385	1.286	1.3765	1.3927	1.3765	1.5432	
14	1.6385	1.286	1.4575	1.4746	1.3765	1.5432	
15	1.6385	1.286	1.4575	1.4746	1.3765	1.3717	
16	1.4918	1.286	1.4575	1.3927	1.2955	1.3717	
17	.2829	.1715	.1886	.1867	.1886	.2572	.1886
18	.3772	.2572	.2829	.2801	.2801	.2572	.1886
19	.4668	.3429	.462	.4668	.462	.4287	.3734
20	.3772	.5144	.5544	.5601	.5544	.4287	.4668
21	.3772	.3429	.3734	.3734	.3734	.6859	.6859
22	.3772	.3429	.3734	.3734	.3734	.8573	.763
23	.2829	.3429	.3772	.3734	.3772	.6859	.763
24	.2829	.2829	.3429	.3734	.3734	.3772	.6859
Max	1.6385	1.286	1.4575	1.4746	1.3765	1.5432	1.0288
Min	.2829	.1715	.1886	.1867	.1886	.2572	.1886
Avg	.7620	.6427	.5663	.7682	.7253	.8119	.6109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 203 / PURANGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.5658	.6001		.7316	.6401	2.0576
2	.7316	.5658	.6001	.6401	.7316	.6401	2.0576
3	.7316	.5658	.6001	.6401	.7316	.6401	2.0576
4	.7316	.6535	.6859	.724	.823	.8059	2.0576
5	.905	.7392	.8573	.9745	.8859	.8859	
6	.905	1.0059	1.0288	1.1393	1.0631	1.0517	2.572
7	1.086	1.0974	1.0288	.985	1.0631	1.0517	1.0288
8	.905	.905	.8573	.905	.7973	.8059	.8573
9	3.0769	2.5101	2.8292	2.5911	.7316	2.1862	
10	3.1245	2.7435	2.753	.7316	3.0483	2.572	
11	.724	2.7435	2.834	2.5606	3.0483	3.1722	
12		3.0007	2.7435	2.8006	2.1052	3.0864	
13	3.1245	3.0007	2.7435	2.8006	2.1862	3.0864	
14	3.0464	3.0007	2.7435	2.8006	2.1862	2.915	
15	3.1626	2.915	2.7435	2.7206	2.1862	2.915	
16	3.0045	2.915	2.753	2.6882	2.1862	2.7435	
17	.6535	.5144	.6468	.5601	.4477	.3429	.1886
18	.8316	.6859	.7164	.7316	.543	.5144	.5601
19	1.0745	.8573	.8764	.9145	.8059	.8573	.7392
20	.905	1.0288	.964	.9745	.8059	.9431	.905
21	.823	.6001	.7164	.7316	.6335	2.2291	2.1795
22	.6468	.6001	.6335	.7316	.6335	2.4006	2.4291
23	.6535	.6001	.6335	.7316	.6335	2.4006	2.4291
24	.7392	.5658	.6001	.6401	.7316	.6401	2.0576
Max	3.1626	3.0007	2.834	2.8006	3.0483	3.1722	2.572
Min	.6468	.5144	.6001	.5601	.4477	.3429	.1886
Avg	1.4127	1.4325	1.4245	1.3790	1.2392	1.6469	1.6118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 204 / 11KV KAPUS WADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6001	.7716	.8097	.8859	.8097	.3429
2	.6859	.5144	.7716	.8097	.8859	.8097	.3429
3	.6859	.6001	.7716	.8097	.8859	.8097	.3429
4	.7716	.6859	.7716	.8097	.8859	.8907	.5144
5	.8573	.7716	.8573	.8907	.8859	.8907	.6001
6	1.1022	1.1022	1.1145	.8907	1.0631	.8907	.6001
7	.4668	.5601	.4801	.5544	.6401	.462	.4287
8	.4668	.4715	.3429	.4668	.5601	.4668	.3429
9	.4668						.9431
10							1.2574
12							1.3413
13							1.3413
14							1.326
15							1.2574
16							1.2574
17	.2829	.3429	.3734	.3734	.3696	.3429	.2829
18	.4715	.5144	.3696	.5487	.462	.4287	.3772
19	.5544	.5144	.6468	.6401	.5487	.5144	.4668
20	.4668	.5144	.6268	.5601	.6335	.6001	.4668
21	.6001	.6859	.7287	.7316	.6478	.4287	.3772
22	.8573	.9431	.9717	.8859	.8907	.4801	.3772
23	.6859	.8573	.9717	.8859	.8907	.3429	.3772
24	.8573	.6535	.7716	.8097	.8859	.8907	.3429
Max	1.1022	1.1022	1.1145	.8907	1.0631	.8907	1.3413
Min	.2829	.3429	.3429	.3734	.3696	.3429	.2829
Avg	.6450	.6457	.7088	.7173	.7514	.6287	.6655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 205 / 11KV BABHULGAON GANGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2829	.3429	.3696	.3734	.3734	1.5432
2	.3772	.2829	.3429	.3696	.3734	.3734	1.5432
3	.3772	.2829	.3429	.3696	.3734	.3734	1.5432
4	.3772	.2829	.3429	.462	.4668	.4668	1.5432
5	.4668	.2829	.5144	.6401	.6401	.5544	1.7147
6	.5601		.6859	.724	.7316	.724	2.0576
7	.6535	.8316	.6859	.543	.5601	.5544	.5144
8	.3772	.7392	.6859	.462	.4668	.4668	.3429
9	2.915		2.6578	2.672	2.5301	2.5101	
10	3.0464	2.915	2.7435	2.6882	2.834	2.915	
11	3.0464	2.915	2.834	2.9254	2.834	3.0007	
12	3.0045	3.0007	2.753	2.8464	2.834	2.915	
13	2.9683	2.915	2.672	2.7673	2.753	2.7435	
14	3.0407	2.915	2.672	2.8464	2.753	2.7435	
15	3.0407	2.915	2.672	2.7673	2.753	2.7435	
16	2.8464	2.915	2.672	2.6882	2.753	2.6578	
17	.3772	.2572	.2772	.2801	.2743	.3429	.2829
18	.5601	.3429	.3658	.3734	.3658	.3429	.3772
19	.6468	.5144	.6268	.5601	.6335	.5144	.5601
20	.5601	.6001	.6268	.5601	.6401	.5144	.6468
21	.4668	.4287	.4572	.4668	.462	1.8004	2.13
22	.3772	.3429	.462	.3734	.462	2.0576	2.4006
23	.2829	.3429	.462	.3734	.462	1.8861	2.2672
24	.3772	.2829	.3429	.3696	.3734	.3734	1.5432
Max	3.0464	3.0007	2.834	2.9254	2.834	3.0007	2.4006
Min	.2829	.2572	.2772	.2801	.2743	.3429	.2829
Avg	1.2968	1.2085	1.2184	1.2291	1.2376	1.4145	1.3132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 206 / BHAOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1052	1.6385	2.0576	2.2672	1.7394	2.1052	.8573
2	2.1052	1.6385	2.0576	2.2672	1.5813	2.1052	.8573
3	2.1052	1.6385	2.0576	2.2672	1.5813	2.1052	.8573
4	2.1052	1.6385	2.0576	2.2672	1.5813	2.2672	1.0288
5	2.3482	1.8023	2.7435	2.4291	1.8976	2.4291	1.2003
6	2.753	2.2672	3.0864	2.5911	2.372	2.5911	1.4575
7	1.086	1.086	1.0288	1.3003	1.1469	1.3003	1.2003
8	1.0745	1.086	1.1145	1.1393	1.0631	1.1641	1.0288
9	1.086						3.1722
10							3.0464
12							2.672
13							2.5606
14							2.4806
15							2.5101
16							2.3482
17	.905	.7716		.7973	.8954	.6859	.8316
18	1.086	.9431	.9745	.9831	1.0631	.9431	1.0974
19	1.3146	1.0288	1.1269	1.1469	1.2136	1.2003	1.2403
20	1.2269	1.286	1.3003	1.2289	1.3146	1.3717	1.3289
21	1.8233	1.8861	2.1862	1.7604	2.0243	1.0288	1.1765
22	2.1862	2.572	2.5101	1.8976	2.5101	1.0288	1.0745
23	1.9433	2.572	2.4291	1.8976	2.5101	.8573	.9955
24	2.2672	1.8023	2.4006	2.2672	1.8976	2.2672	.8573
Max	2.753	2.572	3.0864	2.5911	2.5101	2.5911	3.1722
Min	.905	.7716	.9745	.7973	.8954	.6859	.8316
Avg	1.7365	1.6036	1.9421	1.7817	1.6495	1.5907	1.5600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 207 / mhaski

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.5089	1.4575	1.9433	1.4746	1.6194	.5144
2	1.6385	1.3413	1.4575	1.9433	1.4746	1.6194	.5144
3	1.6385	1.1736	1.4575	1.9433	1.4746	1.6194	.5144
4	1.8023		1.4575	2.0243	1.4746	1.6194	.5144
5	2.13		1.5432	2.0243	1.4746	1.8623	.5144
6	2.4291		1.7147	2.1862	1.8185	2.0243	.8573
7	.6468		.6859	.905	.9745	.9145	.6859
8	.7316		.6001	.7316	.8859	.7316	.5144
9	.7392	1.3413					2.7435
10							2.9683
12							1.4251
13							.181
14							.181
15							2.4291
16							2.5911
17	.4715	.5144	.823	.6401	.7316	.6859	.4715
18	.7392	.6001	.7316	.9145	.905	.6859	.7392
19	.9955	.9431	.985	.9145	.985	.6859	.9955
20	.8316	.8573	.9745	.7316	.8145	.6859	.905
21	1.3413	1.0288	1.3765	1.0174	1.1336	.6859	.7392
22	1.6575	1.3717	2.1052	1.5623	1.7004	.5144	.7392
23	1.8023	1.3717	2.1052	1.5623	1.7004	.5144	.7316
24	1.9433	1.8023	1.3717	1.9433	1.5623	1.6194	.5144
Max	2.4291	1.8023	2.1052	2.1862	1.8185	2.0243	2.9683
Min	.4715	.5144	.6001	.6401	.7316	.5144	.181
Avg	1.3633	1.1545	1.3029	1.4367	1.2865	1.1305	.9993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 201 / 11KV PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8954	.7468	.9922	.6535	.823	1.0374
2	.7888	.8954	.8402	1.0166	.6535	.9145	1.1317
3	.7011	.6268	.8316	1.0517	.8402	.9145	1.2071
4	1.1393	.6268	.9145	1.0802	1.0974	1.0059	1.226
5	1.286	.8059	1.0059	1.073	1.2803	1.0974	1.3203
6	1.3916		1.3717	1.0898	1.3717	1.267	1.4146
7	.9431		1.0974	1.3769	1.4632	1.3575	1.4146
8	.9431		.924	1.1401	.924	1.086	1.1317
9	.9242		.8316	1.0395	1.848	1.3289	1.1694
10	.5544		.5658	.924	1.8204	1.5947	
11	.3734		.5281	.7468	1.3146	1.3765	
12	.2829		.5281	.5601	1.7337	1.1336	
13	.2829	.3734	.5093	.4668	1.6651	1.1603	.543
14	.2829	.3734	.4904	.3734	1.5775	1.1961	1.4899
15	.3772	.5601	.5093	.3734	1.4899	1.2929	1.5775
16	.4668	.5601	.5281	.5601	1.4899	1.2929	1.5775
17	.5544	.5601	.5281	.7468	.462	.5658	.5544
18	.6401	.6535	.6602	.924	.6468		.6468
19	1.086	1.0974	1.2071	1.0974	1.1888		.8316
20	1.086	1.0059	1.1317	1.0059	1.1888	1.1317	1.086
21	.9955	.9145	1.0185	.924	1.0974	1.0374	.9145
22	1.0059	.924	.9955	.924	.8316	.9431	.8686
23	1.0059	1.0164	.985	.8316	.8131	.8488	.8402
24	.905	.985	1.0059	.9671	.7468	.823	.8488
Max	1.3916	1.0974	1.3717	1.3769	1.848	1.5947	1.5775
Min	.2829	.3734	.4904	.3734	.462	.5658	.543
Avg	.7872	.7573	.8231	.8869	1.1749	1.0996	1.0872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 202 / 11KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.543	.6535	.7343	.5601	.9145	.9431
2	.7316	.4525	.6535	.7343	.5601	1.0059	1.0374
3	.6805	.5373	.6535	.8859	.6535	1.0059	1.1317
4	.7888	.4477	.7468	1.0517	.8316	1.086	1.1694
5	.964	.6335	.8402	1.1218	.924	1.086	1.226
6	1.1919		1.2803	1.0898	1.0974	1.3575	1.4146
7	1.1317		1.0974	1.2574	1.3717	1.4327	1.5278
8	.8488		.924	1.2071		1.0059	1.2637
9	.8316		.8316	1.1317	1.0974	.8954	.985
10	.5601	.8954		.924	1.0631	1.0745	1.0745
11	.462		.415	.7392	.7973	.9503	1.0745
12	.3734	.3734		.5601	.7973	.6962	.8059
13	.3734	.3734	.3772	.4668	.8859	.6962	.7164
14	.3734	.3734	.4338	.3734	.9745	.6882	.8059
15	.2829		.4527	.3734	.9745	.6962	.8059
16			.4904	.5601	1.0631	.7127	.8859
17	.5544	.5601	.5658	.7468	.3734	.4715	.4668
18	.6401	.6535	1.2071	.8402	.5544		.6468
19	1.086	1.1888	1.2071	.924	.8316		.9145
20	.9955	1.0974	.8488	1.0974	1.0974	1.2384	1.0059
21	.6268	.7095	.5636	1.0059	1.0974	1.0374	.9145
22	.6535	.7468	.6516	1.0059	.9145	1.0374	.924
23	.6535	.8402	.724	1.0059	1.0059	1.0374	.8871
24	.8402	.543	.6535	.7059	.8402	.9145	1.0185
Max	1.1919	1.1888	1.2803	1.2574	1.3717	1.4327	1.5278
Min	.2829	.3734	.3772	.3734	.3734	.4715	.4668
Avg	.7163	.6452	.7396	.8560	.8855	.9564	.9852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 203 / 11KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	1.1641	1.1888	1.3203	1.0974	1.2403	1.4842
2	1.3203	1.2536	1.2803	1.3769	1.0974	1.3289	1.4685
3	1.4335	1.3432	1.448	1.3769	1.0974	1.3146	1.5061
4	1.6032	1.3432	1.4632	1.3769	1.3717	1.4175	1.4899
5	1.6221	1.4327	1.6461	1.3957	1.4632	1.5061	1.5775
6			1.6461	1.4146	1.6461	1.7528	2.1293
7				1.5089	1.6461		1.5089
8				1.3245			1.3203
9	1.6766			1.5592		1.086	1.1888
10	1.7337	1.5775	1.4918	1.8099	.924	.905	.7392
11	1.5775		1.7901	1.8099	.3772	.679	.6468
12	1.4899	.7468	1.5912	1.7375	.7392	.679	.5544
13	1.4899	1.8099	1.4918	1.6461	.6468	.679	.5544
14	1.4899	1.8099	1.4089	1.4632	.5544	.6036	.5544
15	1.5775	1.6289	1.4251	1.4632	.6468	.6036	.6468
16	1.4899	1.6289	1.3413	1.4632	.6468	.6036	.6468
17	.6468	.7468	.7922	.8316	.7392	.7167	.7392
18	.823	.8402	.9808	1.0059	.9145	.9808	.9145
19	1.4327	1.4632	1.5089	1.1888	1.3432	1.6032	1.3432
20	1.4327	1.4632	1.3203	1.3717	1.4327	1.2449	1.4327
21	1.2127	1.3575	1.094	1.3717	1.4175	1.448	1.1517
22	1.1888	1.3717	1.1128	1.2803	1.5415	1.5384	1.5546
23	1.2803	1.2803	1.2637	1.2803	1.4632	1.6289	1.5546
24	1.226	1.2536	1.1888	1.2637	1.0974	1.3289	1.5775
Max	1.7337	1.8099	1.7901	1.8099	1.6461	1.7528	2.1293
Min	.6468	.7468	.7922	.8316	.3772	.6036	.5544
Avg	1.3797	1.3429	1.3559	1.4017	1.0865	1.1313	1.1785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 201 / 11kv Darga

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4668	.4668	.4239	.5228	.5281	.5415
2	.5041	.4668	.4668	.4239	.4668	.4904	.5415
3	.5415	.4668	.4668	.5087	.5041	.4904	.5415
4	.5914	.5228	.4854	.5735	.5601	.5658	.5601
5	.7282	.6413	.5228	.5935	.5788	.6224	.5914
6	.7655	.7167	.5729	.6783	.6348	.679	.7316
7	.7842	.7356	.6767	.6783	.7282	.7282	.7964
8	.7282	.7733	.6401	.6783	.6722	.7468	.7133
9		.7095	.5729	.7095	.5975	.7095	.6722
10		.6535	.5087	.7095	.5975	.6908	.5935
11	.8215	.6161	.5087	.6535	.5975	.6348	.5935
12	.7095	.6161	.5087	.5975	.6036	.6348	.5935
13	.6348	.6348	.5087	.5415	.5658	.5975	.5087
14	.5601	.5041	.5087	.5228	.5658	.4854	.5087
15	.5601	.4854	.5087	.5601	.4904	.5228	.0424
16	.5041	.4854	.5087	.5975	.5847	.5041	.5087
17	.5544	.5415	.5935	.5788	.6413	.5975	.5087
18	.6283	.5975	.5935	.6535	.6722	.6161	.5935
19	.6653	.6653	.5935	.7842	.7095	.6653	.5935
20	.6099	.6584	.5087	.7468	.7095	.7207	.6783
21	.5729	.6468	.5087	.6908	.7095	.6468	.5935
22	.5729	.5788	.5087	.5792	.6535	.6535	.5935
23	.5175	.5415	.4239	.5788	.6036	.6161	.5087
24	.5415	.4805	.4854	.4239	.5601	.5658	.5601
Max	.8215	.7733	.6767	.7842	.7282	.7468	.7964
Min	.5041	.4668	.4239	.4239	.4668	.4854	.0424
Avg	.6193	.5919	.527	.6036	.6054	.6130	.5695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 202 / 11 Rotegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.7468	.7293	.6783	1.0269	1.1506	1.1458
2	.7282	.7468	.7045	.6783	.9709	1.1317	1.1458
3	.7842	.8962	.7287	.8402	1.1694	1.1317	1.1827
4	.9335	1.0642	.7682	.8478	1.4563	1.2071	1.262
5	1.1949	1.6598	.8905	.9326	1.5655	1.226	1.448
6	1.5123	1.6975	1.0974	1.0174	1.4563	1.2637	1.1462
7	1.4937	1.5655	1.2656	1.0174	1.4146	1.4377	1.3643
8	1.0269	1.3392	1.1919	1.1869	1.475	1.2696	1.0056
9	1.4377	1.0425	1.1946	1.2136	1.1203	1.1744	1.0852
10	1.2136	.9055	1.0174	1.3256	1.1763	1.2689	1.0174
11			1.0174	1.2696	1.2136	1.2071	.9326
12			.9326	1.1203	1.2826		.9326
13			.8478	1.0269	1.2449		.763
14			.763	.8775	1.2449	.7975	.763
15	.9808		.763	.8029	1.2071	.823	.8478
16	.9054		.8478	.8402	1.3203	.8413	.8478
17	1.0829		.8478	.9709	1.4335	.8954	.9326
18	1.2136	1.0974	.9326	1.0456	1.4563	.9568	1.0174
19	1.3443	1.3213	1.0174	1.3256	1.531	1.4198	1.1022
20	1.1949	1.4842	.9326	1.2696	1.419	1.1163	1.1869
21	1.0082	.9991	.9326	1.2136	1.307	.9492	1.1022
22	.9979	1.046	.8478	1.1088	1.2696	1.4118	1.0174
23	.924	.9156	.763	.9896	1.2449	1.2986	.9326
24	.8029	.7577	.7545	.763	1.1203	1.1883	1.1827
Max	1.5123	1.6975	1.2656	1.3256	1.5655	1.4377	1.448
Min	.7282	.7468	.7045	.6783	.9709	.7975	.763
Avg	1.0773	1.1344	.9078	1.0151	1.2969	1.1439	1.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 203 / 11kv Tilakroad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9709	.9335	.763	.9709	1.094	1.1203
2	.9522	.9335	.9335	.763	.9335	1.0374	1.1203
3	.9149	.9335	.9522	.8478	.9979	1.0374	1.1389
4	.9896	1.1576	.9709	.9326	1.1203	1.2826	1.1576
5	1.1949	1.2826	1.0534	1.0174	1.1949	1.4335	1.2382
6	1.4377	1.3957	1.3169	1.1022	1.363	1.5278	1.39
7	1.5684	1.4335	1.5023	1.2717	1.4937	1.6244	1.5023
8	1.363	1.358	1.4449	1.4146	1.4146	1.5123	1.3352
9	1.3256	1.1949	1.2012	1.1869	1.2136	1.3817	1.2752
10	1.2936	1.1389	1.2136	1.363	1.1203	1.251	1.1022
11	1.2752	1.2136	1.1022	1.2696	1.0829	1.2136	1.1022
12	1.2382	1.1016	1.0174	1.1576	1.0642	1.1016	1.1022
13	1.1949	1.0829	1.0174	1.1576	1.1203	1.1016	1.1022
14	1.1203	.9709	1.0174	1.1389	1.1883	1.1016	1.1022
15	1.0829	.9335	.9326	1.0829	1.226	1.1203	1.0174
16	1.0456	1.0082	1.0174	1.1576	1.2826	1.1389	1.0174
17	1.2696	1.0082	1.0174	1.1389	1.3203	1.1949	1.1022
18	1.419	1.0719	1.1022	1.1949	1.419	1.2883	1.1869
19	1.531	1.39	1.1869	1.419	1.5497	1.5893	1.1869
20	1.419	1.3575	1.2717	1.4563	1.4937	1.5912	1.2717
21	1.2883	1.2254	1.1869	1.4003	1.419	1.4083	1.1869
22	1.1643	1.1273	.9145	1.307	1.307	1.3491	1.1869
23	1.0534	1.0456	.9326	1.073	1.1883	1.251	1.1022
24	1.1016	.9979	.9709	.9326	1.0829	1.1317	1.1389
Max	1.5684	1.4335	1.5023	1.4563	1.5497	1.6244	1.5023
Min	.9149	.9335	.9145	.763	.9335	1.0374	1.0174
Avg	1.2188	1.1389	1.0921	1.1479	1.2320	1.2818	1.1744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 204 / town 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7842	.7282	.5935	.7468	.8589	.8589
2	.6908	.7468	.7282	.6535	.7095	.8402	.8402
3	.7282	.7468	.7468	.6783	.7468	.8488	.8589
4	.8215	.8962	.7655	.6783	.7842	.9054	.8775
5	.9522	1.0185	.8501	.763	.8299	.9808	.924
6	1.0829	1.094	.9328	.8478	.9522	1.0562	.9877
7	1.0456	1.1694	1.1041	.9326	1.0642	1.1763	1.0679
8	.8962	1.0374	.9145	.8478	.8962	.9896	.9145
9	.7655	.8589	.7577	.8402	.8215	.8775	.8131
10	.7468	.7468	.6783	.7468	.7762	.7842	.6783
11	.7468	.7468	.7468	.7095	.7392	.7842	.6783
12	.7095	.6722	.5935	.8029	.7207	.7655	.6783
13	.679	.6722	.6535	.7468	.7282	.7095	.5935
14	.679	.6722	.6783	.7095	.6908	.6908	.5935
15	.6413	.6722	.0754	.6722	.6722	.7468	.6783
16	.6413	.6722	.7468	.7095	.7468	.7655	.6783
17	.7468	.6722	.763	.7095	.8589		.8402
18	.8962	.6653	.763	.7282	.9335	.8402	.8478
19	.9709	.8962	.8478	.9896	.9709	.9425	.9326
20	.9709	.9694	.8478	1.0082	.9979	1.0242	.8478
21	.9335	.924	.763	.9709	1.0349	.9877	.8478
22	.8871	.8775	.763	.9335	.9795	.9979	.8478
23	.8316	.7842	.6783	.9149	.9335	.9335	.763
24	.8402	.7947	.7468	.6783	.8402	.8775	.8775
Max	1.0829	1.1694	1.1041	1.0082	1.0642	1.1763	1.0679
Min	.6413	.6653	.0754	.5935	.6722	.6908	.5935
Avg	.8188	.8246	.7447	.7861	.8406	.8862	.8136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 205 / pahade express feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3547	.3395	.2713	.3361	.0189	.2054
2	.2987	.3547	.3395	.2713	.3174	.0189	.1867
3	.3174	.3547	.3584	.2713	.3395	.0189	.1867
4	.3361	.3547	.3584	.3052	.3547	.0189	.2054
5	.3921	.3395	.3547	.3052	.3734	.0189	.2054
6	.3734	.3395	.3511	.3391	.3206	.0189	.2218
7	.3921	.3395	.3326	.3052	.2427	.0187	.2033
8	.3734	.3584	.3174	.3052	.168	.0187	.2054
9	.4108	.3174	.3361	.2713	.1867	.1494	.3361
10	.4108	.3734	.3391	.3174	.1867	.1867	.3052
11	.3734	.3361	.3052	.2801	.1494	.2241	.2713
12	.3734	.3361	.2713	.2801	.1494	.1494	.2713
13	.3772	.3361	.2374	.2987	.1509	.1494	.3052
14	.3772	.3547	.2543	.3174	.1132	.168	.3391
15	.3584	.3174	.2543	.2801	.0189	.2054	.3052
16	.3584	.3174	.2713	.2241	.0189	.3361	.3052
17	.3547	.3921	.3052	.3547	.0189	.2241	.3391
18	.3734	.4066	.3052	.3361	.0187	.2427	.3391
19	.4108	.3174	.3052	.3547	.0187	.2402	.3391
20	.3734	.3734	.2713	.3361	.0187	.2957	.3391
21	.3547	.3734	.2713	.3547	.0373	.2241	.3391
22	.3511	.3921	.2713	.3921	.0373	.2614	.3391
23	.3511	.3921	.2713	.3734	.0189	.2241	.3052
24	.3547	.3511	.3584	.2987	.3547	.0189	.2054
Max	.4108	.4066	.3584	.3921	.3734	.3361	.3391
Min	.2987	.3174	.2374	.2241	.0187	.0187	.1867
Avg	.3660	.3534	.3075	.3101	.1646	.1438	.2752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 206 / water supply Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0225	.0274	.0339	.0366	.0229	.0286
2	.0187	.0225	.0278	.0339	.0373	.0229	.0293
3	.0747	.0225	.0286	.0339	.056	.0229	.0297
4	.0934	.0225	.0278	.0678	.0373	.0457	.0579
5	.1307	.0221	.0947	.0678	.0373	.0686	.0974
6	.168	.0221	.1052	.1017	.0373	.0914	.1353
7	.168	.0221	.1021	.1021	.0373	.1012	.1315
8	.1494	.0221	.1238	.1357	.0373	.1124	.1149
9	.1307	.0814	.1341	.1357	.0373	.1181	.1115
10	.08	.0945	.1526	.0747	.0229	.1219	.1357
11	.0572	.0732	.1017	.0373	.0229	.0503	.1017
12	.0457	.0251	.1017	.0373	.0229	.0394	.0339
13	.0457	.0255	.0678	.056	.0229	.0389	.0509
14	.0457	.0263	.0678	.0373	.0229	.0394	.0509
15	.0457	.0271	.0509	.0373	.0229	.0533	.0339
16	.0457	.0274	.0509	.056	.0229	.0274	.0339
17	.0337	.0282	.0339	.0373	.0229	.0282	.0377
18	.0337	.0286	.0339	.0248	.0225	.0286	.0509
19	.0225	.0282	.0373	.0248	.0225	.0293	.0509
20	.0225	.0274	.0339	.0259	.0225	.029	.0509
21	.0225	.0267	.0373	.0373	.0225	.0282	.0339
22	.0221	.0271	.0339	.0373	.0225	.0274	.0339
23	.0221	.0274	.0339	.0248	.0229	.0278	.0339
24	.0373	.0221	.0278	.0339	.0373	.0229	.0282
Max	.168	.0945	.1526	.1357	.056	.1219	.1357
Min	.0187	.0221	.0274	.0248	.0225	.0229	.0282
Avg	.0647	.0323	.0640	.0539	.0296	.0499	.0624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 207 / 11 KV MGM

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2241	.2035	.2427	.2452	.2614
2	.2054	.2241	.2241	.2241	.2241	.2263	.2614
3	.2241	.2241	.2241	.2241	.2054	.2263	.2614
4	.2614	.2614	.2241	.2374	.2427	.2641	.2801
5	.2801	.3018	.2427	.2374	.2427	.2641	.3174
6	.3174	.3395	.2587	.2713	.2801	.2829	.3696
7	.3361	.3395	.2926	.2713	.3547	.3361	.3292
8	.3361	.3206	.2587	.2543	.2801	.2801	.3142
9	.2801	.3174	.2801	.2543	.2614	.2987	.2614
10	.3361	.3734	.2374	.3361	.2987	.3361	.2713
11	.3772	.3921	.2713	.2829	.3547	.3921	.2713
12	.3961	.3921	.3052	.3174	.3961	.3921	.2401
13	.3961	.3921	.2713	.2683	.3961	.3921	.2713
14	.3772	.3174	.2204	.3174	.4338	.3734	.3772
15	.3772	.2614	.2713	.3174	.4338	.3547	.3391
16	.3584	.3174	.3326	.3361	.4715	.3734	.3734
17	.3734	.4108	.3052	.3174	.5281	.3547	.3052
18	.4108	.3881	.3052	.3361	.5228	.4108	.3052
19	.4481	.4755	.3391	.3921	.5041	.462	.3391
20	.3734	.4024	.3391	.3734	.4481	.4572	.3391
21	.3361	.3142	.3052	.3185	.3734	.3475	.3052
22	.3326	.2987	.2713	.3174	.3361	.3142	.3052
23	.2772	.2801	.2374	.2987	.3018	.3174	.3052
24	.2614	.2587	.2427	.2374	.2641	.2829	.2801
Max	.4481	.4755	.3391	.3921	.5281	.462	.3772
Min	.2054	.2241	.2204	.2035	.2054	.2263	.2401
Avg	.3290	.3261	.2702	.2893	.3499	.3327	.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 201 / 11 KV CHINCHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5636	.6962	.964	.5735	.4801	.4588
2	.823	.5636	.6299	.964	.5735	.4801	.4588
3	.9259	.5967	.5967	.964	.5735	.5144	.4915
4	1.1317	.5967	.5967	1.0517	.6554	.5487	.5571
5	1.3375	.5304	.5967	1.0517	.6882	.583	.6226
6	1.4575		.9282	1.0517	.7537	.6859	.7209
7	.7888		.7293	.6882	.8192		.8619
8	.7293		.6882	.7202	.5898	.6516	.7625
9	.6299		.5898	.6554	1.1568	.8916	1.0608
10	.5138	.3932	.4915	.5243	1.4022	1.3375	1.326
11	.431		.426	.4915	1.5432	1.094	1.2597
12	.3605	.3605	.3277	.4588	1.4232	1.1603	1.1603
13	.3315	.3277	.3277	.3605	1.3375	1.0608	1.0277
14	.3277	.3277	.3605	.3277	1.2689	.9614	.8951
15	.3605	.2622	.2622	.3605	1.2346	.9282	.7956
16	.3978	.3932	.3932	.3932	1.2517	1.0277	.9282
17	.6882	.4973	.4458	.4915	.4115	.3277	.3277
18	.4915	.4973	.5243	.4588	.4801	.3932	.4915
19	.7537	.6882	.6554	.6882	.6516	.5571	.6882
20		.7209	.6882	.6554	.7202	.7209	.7209
21	.5571	.8951	.5959	.5898	.6516	.5898	.6554
22	.5898	.9614	.8764	.5898	.583	.5571	.6226
23	.5571	.8951	.8764	.5898	.5487	.5243	.5898
24	.823	.5636	.8288	.8764	.5898	.5144	.4588
Max	1.4575	.9614	.9282	1.0517	1.5432	1.3375	1.326
Min	.3277	.2622	.2622	.3277	.4115	.3277	.3277
Avg	.6853	.5597	.5888	.6653	.8534	.7213	.7476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 202 / 11 KV AGARSAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3932	.3978	.4915	.4382	.6173	.431
2	.4801	.3932	.3978	.4915	.4382	.6687	.431
3	.4801	.3932	.3978	.4915	.4382	.6516	.431
4	.5144	.426	.431	.5735	.4908	.823	.4641
5	.583	.4588	.4973	.6554	.5258	.8916	.5304
6	.6516		.5636	.6718	.5258	1.0631	.7625
7	.7373		.6962	.7373	.4752	.4115	.4641
8			.6299	.6344	.4588	.4973	.4641
9	1.0059		.8619	.8764	.3768	.3086	.3978
10	1.0059	.6962	.9282	1.0517	.2458	.2915	
11	.8383		.8589	.7186	.2058	.1966	.2984
12	.8383	.8288	.8939	.7186	.1715	.1966	.2321
13	.7042	.7956	.8063	.7011	.1715	.1989	.1989
14	.7293	.7293	.7186	.6135	.2058	.1989	.1989
15	.6299	.7956	.7186	.7011	.2058	.2321	.1989
16	.6706	.8619	.8939	.7888	.2743	.3315	.2321
17	.1311	.1989	.1886	.1475	.2743	.2984	.2652
18	.1966	.1966	.2622	.1802	.2915	.3315	.3315
19	.4641	.4915	.4588	.4588	.5316	.4973	.431
20		.5898	.6226	.4588	.5144	.5636	.4973
21	.4588	.5304	.5079	.4382	.5487	.431	.5304
22	.426	.4641	.4915	.3856	.6173	.4973	.6299
23	.431	.431	.4915	.3856	.583	.4641	.5636
24	.4801	.3932	.3978	.4915	.3856	.5487	.4641
Max	1.0059	.8619	.9282	1.0517	.6173	1.0631	.7625
Min	.1311	.1966	.1886	.1475	.1715	.1966	.1989
Avg	.5880	.5299	.5880	.5776	.3914	.4671	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 403 / 33 KV VAIJAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6408	3.6214	3.5288	2.7469	3.8649	3.9609	4.201
2	3.4168	3.5648	3.5288	2.7469	3.6969	3.7529	4.145
3	3.5288	3.678	3.5848	3.3065	3.9769	3.7529	4.257
4	4.0329	4.313	3.7529	3.6626	4.537	4.257	4.425
5	4.8731	5.2092	4.2135	3.9169	4.7611	4.5931	4.8788
6	5.6573	5.6013	4.8834	4.3747	5.0412	4.9291	5.048
7	5.8253	5.6013	5.3755	4.6799	5.3212	5.4893	5.4298
8	4.8731	5.1532	4.9411	4.6799	4.9291	4.9851	4.7188
9	4.369	4.5931	4.5462	4.3239	4.201	4.768	4.7125
10	4.145	4.369	4.0695	4.8731	4.201	4.768	4.1204
11	3.6969	3.4168	3.9678	4.481	4.201	4.8171	4.313
12	3.5288	3.1367	3.7643	4.313	4.201	3.0807	3.8152
13	3.3048	3.1367	3.5099	4.0889	4.2438	3.0247	3.5608
14	3.1927	2.8275	3.5608	3.9209	4.3004	3.7529	4.1307
15	4.0329	2.6886	3.4591	3.8089	4.1307	3.9209	3.6626
16	3.9043	2.8006	3.7134	4.0889	4.4702	4.0889	.3866
17	4.4702	3.0807	3.866	4.0889	4.8663	3.3608	3.866
18	5.036	4.269	4.0186	4.313	5.0412	4.3799	4.1712
19	5.4887	5.1029	4.3239	5.3212	5.3212	5.3772	4.4765
20	5.036	5.2669	4.2221	5.2652	5.1532	5.2126	4.7817
21	4.537	4.4993	3.9678	4.9851	4.9291	4.6091	2.2634
22	4.369	4.4353	3.7134	4.7051	4.5931	5.0452	4.3239
23	4.0329	4.0889	3.3573	4.369	4.357	4.7051	3.9169
24	3.9769	3.6969	3.6969	3.3573	4.257	3.9609	4.257
Max	5.8253	5.6013	5.3755	5.3212	5.3212	5.4893	5.4298
Min	3.1927	2.6886	3.3573	2.7469	3.6969	3.0247	.3866
Avg	4.2904	4.0896	3.9819	4.1841	4.5248	4.3580	4.0776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 201 / shivoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9593	.7602	.8551	.8507	.5316	.543	.4287
2	1.0136	.7602	.8383	.9412	.5316	.5792	.4801
3	1.0679	.8145	.8215	1.0317	.567	.6154	.5487
4	1.1765	.905	.8718	1.1041	.6556	.6697	.6687
5	1.2489	.9593	.9054	1.1765	.7265	.724	.7202
6	1.448	1.1041	1.2407	1.448	.8328	.8145	.8402
7	.9412	.8402	.9391	.9774	.9036	.8869	.9259
8	.8869	.6344	.8682	.8507	.7087	.6697	.6859
9	.4973	.5144	.6201	.724	1.0059	1.0679	1.1403
10	.4115	.5316	.4163	.6154		1.1222	.9412
11	.3772	.4252	.3982	.5138	.9774	1.0679	.8869
12	.2915	.2658	.4344	.443	.7783	.9955	.905
13	.2915	.2658	.4525	.3898	.7602	.7964	.8869
14	.3258	.2481	.4344	.4075	.7421	.8869	.8507
15	.3601	.3544	.362	.3721	.7421	.8145	.6335
16	.3429	.3898	.362	.4252	.9231	.905	.7059
17	.2572	.443	.4887	.6024	.5249	.3772	.3772
18	.463	.5847	.3439	.6556	.4887	.4801	
19	.5144	.7087	.724	.7087	.6697	.6001	.6344
20	.583	.6201	.7059	.691	.724	.6001	.6001
21	.7783	.7545	.7964	.6201	.5959	.583	
22	.8869	.788	.9774	.567	.6154	.5144	.5487
23	.8688	.8215	.9412	.5316	.5611	.4973	.5144
24	.9593	.8145	1.0277	.8145	.5138	.5249	.4801
Max	1.448	1.1041	1.2407	1.448	1.0059	1.1222	1.1403
Min	.2572	.2481	.3439	.3721	.4887	.3772	.3772
Avg	.7063	.6378	.7011	.7276	.6991	.7223	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 202 / sudamwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6697	.5487	.6024	.6878	.3353	.4887	.3982
2	.7059	.6001	.6201	.7059	.503	.4887	.4525
3	.7421	.6687	.6201	.7602	.5365	.5068	.5068
4	.7964	.8402	.6556	.8145	.6556	.5249	.6335
5	.8326	.7888	.7087	.8869	.6706	.543	.724
6	.9593	.8745	.9214	.8869	.9389	.8326	.9774
7	.8326	.8573	.7973	.8688	.6201	.5792	.4287
8	.5792	.7716	.4784	.6335	.5847	.4525	.4115
9	.9231	.6697	.6203	.3982	.4252	.4163	.2743
10	.905		.362	.9412		.3429	.3429
11	.8688	.7209	.7783	.7377	.362	.3086	.4458
12	.7964	.7712	.7059	.6371	.3439	.3086	.3601
13	.724	.5365	.6516	.503	.3258	.2743	.3772
14	.6335	.4694	.5249	.5365	.3077	.3086	.4458
15	.6335	.5365	.5249	.6036	.2896	.3429	.3944
16	.6516	.5533	.6335	.5533	.2896	.3258	.3772
17	.2572	.2303	.3077	.2303	.3982	.3429	.3429
18	.3601	.3366	.2715	.3544	.3982	.4287	.3772
19	.7202	.6379	.5792	.6024	.5611	.5144	.5487
20	.7716	.6733	.7783	.6733	.7421	.7202	.7545
21	.703	.6733	.7059	.3521	.4525	.4163	.4525
22	.6859	.6379	.724	.3521	.6335	.4163	.4525
23	.6001	.6201	.6697	.3521	.5068	.4525	.4163
24	.6516	.5144	.5847	.6697	.3185	.4706	.362
Max	.9593	.8745	.9214	.9412	.9389	.8326	.9774
Min	.2572	.2303	.2715	.2303	.2896	.2743	.2743
Avg	.7085	.6318	.6178	.6142	.4869	.4503	.4690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1715	.1417	.181	.0709	.1086	.1448
2	.1629	.1715	.1417	.1991	.0671	.1086	.1629
3	.1629	.2058	.1595	.1991	.0838	.1086	.1629
4	.181	.2229	.1595	.2172	.1509	.1267	.181
5	.2172	.2229	.1772	.2172	.1677	.1267	.181
6	.2534	.2743	.2303	.2534	.1844	.1448	.1991
7	.2172	.2572	.2481	.3258	.124	.0905	.1372
8	.1629	.1715	.1949	.1991	.1417	.1267	.1372
9	.0724	.0857	.0838	.1086	.1417	.0543	.0857
10	.1448	.0838	.1267	.0905		.0514	.0686
11	.181	.1677	.1629	.2012	.0543	.0514	.0686
12	.181	.1174	.181	.1844	.0543	.0343	.0343
13	.181	.1341	.1267	.1509	.0362	.0686	.0343
14	.1991	.1341	.1448	.1341	.0362	.0514	.0343
15	.1629	.1677	.1448	.1341	.0362	.0514	.0343
16	.1448	.1677	.1448	.1417	.0543	.0686	.0514
17	.2229	.0354	.0362	.0532	.1267	.0686	.0857
18	.0857	.0886	.0905	.0886	.1267	.1372	.1372
19	.2058	.1417	.1448	.1772	.1991	.1715	.1715
20	.2058	.1949	.2353	.1949	.2353	.2058	.2229
21	.2058	.2126	.1991	.0838	.1086	.1448	.0905
22	.1886	.1949	.1991	.0838	.1267	.1448	.0905
23	.1543	.1772	.1629	.0671	.1086	.1267	.1267
24	.1629	.1543	.1772	.181	.0671	.1086	.1448
Max	.2534	.2743	.2481	.3258	.2353	.2058	.2229
Min	.0724	.0354	.0362	.0532	.0362	.0343	.0343
Avg	.1758	.1648	.1589	.1611	.1088	.1034	.1161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.5144	.443	.4163	.2683	.2534	.3258
2	.4706	.5144	.4252	.4344	.2683	.2534	.3258
3	.5068	.5144	.4784	.4525		.2715	.362
4	.543	.5487	.5138	.4887		.3077	.362
5	.6154	.6001	.5847	.4887		.3258	.3982
6	.8869	.6859	.6556	.543		.4163	.4706
7	.6878	.6344	.5493	.5792		.4706	.4287
8	.5249	.5144	.3189	.362		.3077	.2915
9	.4887	.4163	.3521	.4557		.2534	.1372
10	.4887	.1677	.3077	.4887		.1372	.1372
11	.543	.3688	.3258	.3185		.1372	.1029
12	.4525	.3521	.3258	.285		.1372	.0514
13	.3982	.3185	.3258	.2515		.0857	.0857
14		.3521		.2515		.1029	.1029
15	.3982	.3353	.362	.2683		.12	.0857
16	.3801	.3018	.298	.285		.0686	.1029
17	.1543	.0886	.0905	.0709	.1629	.12	.12
18	.3258	.1772	.2172	.2126	.3077	.2058	.1543
19	.3772	.4784	.3801	.3898	.3801	.3429	.4458
20	.4801	.5847	.5249	.4252	.4887	.5144	.4973
21	.463	.4784	.4163	.2683	.3258	.3982	.3439
22	.4458	.4607	.5068	.285	.3982	.3982	.3439
23	.4287	.3544	.4525	.3018	.3077	.362	.2715
24	.4344	.4801	.4607	.4163	.2683	.2534	.3439
Max	.8869	.6859	.6556	.5792	.4887	.5144	.4973
Min	.1543	.0886	.0905	.0709	.1629	.0686	.0514
Avg	.4752	.4267	.4050	.3641	.3176	.2601	.2621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 205 / BOLTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8507	.7545	.8505	.9593	.57	.7421	.6335
2	.905	.823	.7973	.9231	.6036	.7602	.6878
3	.9774	.9431	.7796	.8869	.6539	.7602	.7783
4	1.0498	.9945	.7796	.8688	.7545	.7964	.9231
5	1.1403	1.0288	.7619	.8507	1.0059	.8326	.9955
6	.8507	1.0288	.7796	.9774	1.2574	1.1765	1.1946
7	.905	1.0288	.9391	1.0136	1.0631	1.0498	1.0679
8		.7202	.6556	.8688	.7796	.8326	.7888
9	1.086	.9593	.788	.9412	.567	.5792	.6687
10	1.1403	.9724	.9774	1.2127		.3429	.5316
11	1.2489	.9221	.8869	.9556		.2572	.3258
12	.3258	.7042	.7783	.8048		.2572	.3258
13	.9412	.6874	.7783	.7209	.2715		.3258
14	.8507	.7377		.7377	.3258	.2743	.3429
15	.9231	.7377	.8145	.7042	.362	.2915	.3601
16	.9774	.8383	.9593	.8551	.3982	.3086	.3086
17	.3944	.2481	.3077	.3366	.362	.3429	.3429
18	.5658	.5493	.4344	.5316	.3982	.4801	.4115
19	.8916	.8505	.6697	.8328	.7783	.5144	.7545
20	.7716	.9568	1.0317	.9214	.9231	.9602	1.0117
21	.8059	.8505	.905	.57	.6697	.7783	.8869
22	.7545	.8505	.8507	.5868	.8326	.8145	.8869
23	.7545	.8682	.8688	.5868	.7783	.7783	.7602
24	.8507	.7202	.8505	.9412	.57	.724	.6878
Max	1.2489	1.0288	1.0317	1.2127	1.2574	1.1765	1.1946
Min	.3258	.2481	.3077	.3366	.2715	.2572	.3086
Avg	.8679	.8240	.7932	.8162	.6631	.6371	.6667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVVOOR

Feeder No / Name : 206 / BANGLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.4525	.6706	.4887	.567	.5973	.5487
2	.6516	.4525	.7209	.4887	.6024	.6154	.6001
3	.6878	.5068	.7545	.5068	.5847	.6516	.6516
4	.724	.362	.7712	.5249	.6024	.6878	.6859
5	.7421	.4706	.8048	.543	.691	.7059	.7202
6	1.0136	.6516	.8215	.8869	.7619	.7964	.7716
7	.5249	.6001	.4252	.5249	.7973	.7964	.7373
8	.5973	.5144	.4607	.543	.5138	.6154	.5658
9	.4287	.4287	.4784	.5068	.6371	.7783	.3077
10	.4287	.4252	.3982	.5068		.905	.5792
11	.3944	.3898		.4252	.9231	.9231	.724
12	.3429	.3544	.5068		.9412	.8326	.6335
13	.3086	.3189	.4706			.6878	.7602
14	.3086	.3012		.4252	.8413	.6335	.5973
15	.3429	.3898	.4525	.443	1.0498	.6878	1.1041
16	.3772	.4252	.5249	.4784	.9593	.7602	.5792
17	.463	.443	.5792	.5316	.3982	.2743	.2229
18	.6001	.5493	.4525	.5847	.4706	.3258	.3429
19	.6001	.7265	.6697	.7442	.7059	.5144	.6001
20	.6516	.6379	.6878	.7087	.7421	.6687	.7716
21	.3944	.4191	.4525	.6201	.724	.6001	.6344
22	.5611	.503	.6516	.6201	.6697	.5658	.6344
23	.543	.57	.5792	.6201	.5792	.5487	.6001
24	.5973	.5068	.6203	.4706	.567	.5792	.5144
Max	1.0136	.7265	.8215	.8869	1.0498	.9231	1.1041
Min	.3086	.3012	.3982	.4252	.3982	.2743	.2229
Avg	.5375	.4750	.5888	.5542	.6968	.6563	.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOR

Feeder No / Name : 207 / Ex.BANGLA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.181	.1006	.1267	.218	.2353	.1991
2	.2534	.181	.1006	.1267	.218	.2353	.2172
3	.2534	.181	.1006	.1448	.218	.2353	.2172
4	.2534	.1629		.1448	.2012	.2172	.2534
5	.2534	.1629		.1629	.218	.2172	.2715
6	.2715	.2353		.1448	.2012	.2353	.2896
7	.3258	.2353		.1448	.2012	.2172	.2172
8	.3439	.3077		.1448	.218	.2896	.2353
9	.4163	1.0136		.2353	.503	.3982	.2896
10	.8145	.9221		.2353		.4525	.3982
11	.7783	.8886		.218	.5792	.5611	.4525
12	.724	.8551	.2172	.218	.5792	.543	.4525
13	.6878	.788	.6154	.218	.4887	.4525	.3801
14	.5792	.6203	.5973	.218	.4887	.5611	.4525
15	.5611	.6036	.5973	.218	.4706	.543	
16	.5611	.6539	.5973	.2515	.6516	.5249	
17	.5068	.57	.5792	.2012	.6878	.6516	.362
18	.4525	.503	.543	.2012	.724	.543	.5068
19	.362	.4527	.5792	.2012	.6154	.4706	.3982
20	.1991	.285	.4525	.218	.3258	.2172	.3801
21	.1991	.2012	.2353	.218	.2172	.1448	.3439
22	.1991	.1006	.2534	.218	.2172	.1448	.3439
23	.1991	.1006	.2353	.218	.2353	.1991	.3077
24	.2534	.1991	.1006	.1267	.218	.2353	.1991
Max	.8145	1.0136	.6154	.2515	.724	.6516	.5068
Min	.1991	.1006	.1006	.1267	.2012	.1448	.1991
Avg	.4042	.4335	.3691	.1898	.3781	.3552	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 208 / KORADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.3801	.503	.4887	.3721	.362	.3258
2	.543	.3982	.5197	.5249	.3721	.3982	.3429
3	.5792	.3982	.5868	.5611	.4075	.4344	.3429
4	.6154	.4525	.5868	.5973	.4784	.5068	.3772
5	.6335	.5068	.6379	.6154	.5138	.543	.4287
6	.7783		.6203	.7783	.5493	.5611	.4973
7	.362		.443	.4525	.5493	.5792	.4973
8			.3898	.4525	.4075	.3982	.3772
9	.2743		.2481	.3258	.503	.5068	.4163
10	.2058	.1063	.1448	.3258		.2353	.4525
11	.1715	.1949	.1629	.2303	.7602	.5611	.543
12	.1543	.1949	.1629	.1772	.7964	.5068	.543
13	.1372	.2126	.1086	.1772	.6335	.543	.4525
14		.2126		.1417	.6154	.3982	.4525
15	.1372	.2658	.1629	.1417		.2715	.4163
16	.1372	.2126	.181	.2126	.5792	.2715	.3258
17	.1715	.2481	.181	.2126	.0905	.0857	.1029
18	.3429	.3721	.2715	.3012	.1267	.1372	.1372
19	.3429	.4784	.4344	.5138	.3258	.1886	.3601
20	.3258	.443	.3982	.4252	.4706	.4287	.4287
21	.3086	.3856	.3982	.3898	.4163	.3429	.3429
22	.3982		.5249	.3721	.3982	.3429	.3429
23	.3982	.443	.5249	.3544	.3982	.3258	.3429
24	.4706	.362	.4862	.4706	.3544	.362	.3086
Max	.7783	.5068	.6379	.7783	.7964	.5792	.543
Min	.1372	.1063	.1086	.1417	.0905	.0857	.1029
Avg	.3634	.3299	.3773	.3851	.4599	.3871	.3816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 202 / KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.6602	.7716	1.0456	.724	.6241	1.0059
2	1.0456	.7167	.7888	1.0456	.724	.6081	1.0059
3	1.1949	1.0374	.8573	1.0456	.7964	.7573	1.0059
4	1.307	1.1694	.8745	1.1949	.8507	.8916	1.073
5	1.419	1.1488	1.0631	1.307	1.0136	1.0288	1.1736
6	1.4937	1.3203	1.1488	1.4937	1.1222	1.39	1.3413
7	1.307	1.6221	1.1831	1.307	1.2826	1.1831	1.307
8	1.1203	1.1317	.8916	1.1203	.7545	.8916	1.1203
9	.9389	1.1765	1.0402	.8383	.7922	.7888	1.0456
10	1.1222	1.0402	1.0059	1.1041	.823	.0373	.9808
11	1.1765	1.0715	1.073	1.3394	.8573	.0373	.9431
12	1.267	1.07	1.0059	1.086	.7888	.8589	.9808
13	1.2308	.9002	.9389	1.0136	.823	1.0082	.9808
14	1.1765	.8322	.9054	.9593	.9088	.9335	.7545
15	1.1584	.7727	1.0059	1.086	.9259	.8962	.7356
16	.6697	.8025	1.1065	1.267	.9774	.7712	.7167
17	.7545	.8573		.7545	1.0288	.9335	.9808
18	.9808	.8916	1.0456	.8488	1.0974	1.1203	1.1317
19	.9808	.9602	1.1949	.8865	.9945	1.2323	1.1317
20	.9431	1.046	1.307	.9997	.8573	1.307	.9054
21	.7922	.9774	1.2323	.6335	.7545	.6706	1.0136
22	.7545	.8573	1.1203	.5973	.6249	1.0059	.905
23	.7356	.823	1.0456	.724	.5796	1.0059	.8688
24	1.1203	.7167	.7888	1.0456	.6878	.5719	1.0059
Max	1.4937	1.6221	1.307	1.4937	1.2826	1.39	1.3413
Min	.6697	.6602	.7716	.5973	.5796	.0373	.7167
Avg	1.0754	.9834	1.0172	1.0310	.8662	.8564	1.0047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 203 / DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5658	.5601	.5228	.724	.6097	1.0059
2	.5601	.5487	.5601	.5228	.7421	.6241	1.0059
3	.5601	.7545	.7095	.5228	.7964	.7282	1.0059
4	.6722	.8676	.7655	.6722	.905	.7876	1.073
5	.7468	.9431	.8962	.7468	.9412	.8688	1.1736
6	.9709	.9619	1.0456	.9335	1.0136	1.0715	1.2407
7	1.0082	1.0374	.9709	.8962	.5847	.5487	.5228
8	.7468	.6036	.7468	.6722	.5658	.4115	.3734
9	.6036	.8145	.9054	.7712	.4715	.3429	.3734
10	1.267	.7133	1.073		.2743	.3361	.3018
11	1.1403	.6573	1.1401		.2229	.1867	.3018
12	.9412	.5858	1.0059	.543	.2058	.3361	.2829
13	.7602	.5944	.8383	.6516	.2401	.2987	.2641
14	.6878	.5502	.7712	.6697	.2743	.2987	.3206
15	.7783	.6241	.8383	1.0679	.3086	.2987	.3772
16	.4887	.5068	.9054	1.267	.3429	.2987	.3772
17	.5658	.3086		.3018	.3772	.3361	.4527
18	.6224	.4458	.4481	.6036	.4409	.4854	.679
19	.7356	.583	.4854	.679	.5765	.6348	.7922
20	.5658	.6516	.7468	.7545	.5144	.7468	.8865
21	.6602	.6535	.7468	.4163	.463	.6706	.5973
22	.6224	.5601	.6722	.5068	.4725	.8048	.543
23	.6036	.5601	.5601	.5973	.5719	.8383	.543
24	.5601	.5658	.5601	.4854	.5611	.535	.8383
Max	1.267	1.0374	1.1401	1.267	1.0136	1.0715	1.2407
Min	.4887	.3086	.4481	.3018	.2058	.1867	.2641
Avg	.7262	.6524	.7805	.6729	.5246	.5458	.6388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 204 / Borsar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.2263	.208	.57	.3772	.3429	.3734
2	.6036	.2452	.2378	.57	.3961	.3601	.3734
3	.6036	.3077	.2606	.57	.4527	.3944	.3734
4	.6371	.4344	.2972	.6036	.5093	.3944	.4481
5	.6706	.5611	.5647	.6706	.5658	.4409	.5601
6	.7545	.6878	.724	.7377	.0566	.5144	.6722
7	.6722	.6979	.6516	.6722	.6413	.583	.6348
8	.5601	.3772	.4973	.5601	.7922	.3944	.4854
9	.4854	.2452	.2743	.4854	.9242	.5944	.6706
10	.5658	.2058	.2614	.1886	.6836	.6036	.7602
11	.6036	.2058	.1867	.3018	.5937	.57	.724
12		.1886	.1867	.2829	.639	.503	.7602
13	.1132	.1715	.1867	.2452	.5144	.4359	.543
14	.1698	.1715	.1867	.2263	.4161	.4694	.543
15	.1886	.1696	.1867	.1886	.5053	.503	.5611
16	.2075	.1543	.1867	.2075	.4633	.57	.5792
17	.3772	.2401		.3018	.2743	.3734	
18	.3961		.2987	.5658	.3086	.3734	.4338
19	.4338	.4115	.3734	.415	.4458	.4481	.4904
20	.415	.6516	.5601	.4458	.5316	.5601	.5281
21	.5658	.4572	.4359	.3961	.3391	.4854	.547
22	.4706	.3658	.57	.3772	.3086	.3734	.3772
23	.4344	.3121	.57	.3206	.3052	.3734	.3772
24	.6036	.3395	.2408	.57	.3395	.3258	.3734
Max	.7545	.6979	.724	.7377	.9242	.6036	.7602
Min	.1132	.1543	.1867	.1886	.0566	.3258	.3734
Avg	.4842	.3403	.3542	.4364	.4743	.4578	.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 205 / parsoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	.543	.587	.6371	.9054	.639	.7468
2	1.1736	.4887	.6241	.6371	1.0374	.8097	.7468
3	1.1736	.6878	.643	.6371	1.1694	.8642	.7468
4	1.1736	.8507	.743	.6706	1.3203	1.0159	.8962
5	1.1736	.9231	.9214	.7377	1.3203	1.0105	1.1949
6	1.2071	.9774	1.057	.8048	1.358		1.3817
7	1.0059	1.2449	1.1145	1.1203	1.3203	.9945	1.4563
8	1.0456	1.0374	.9945	1.0082	1.3394	.8916	1.1203
9	.9335	.9808	.7888	.7468	1.5384	.9145	1.073
10	.4904	.583	.7468	.7545	1.1888	1.2742	1.1222
11	.5281	.4973	.5601	.8488	1.2163	1.3413	1.086
12	.5281	.4801	.5228	.7545	1.174	1.1736	.9593
13		.4458	.4854	.679	1.0105	1.073	.8688
14	.4904	.4239	.4854	.6036	.2606	1.073	.905
15	.5847	.4458	.4854	.5847	.8619	1.073	1.0498
16	.4715	.3052	.5601	.5847	1.0084	1.1736	1.1946
17	.9242	.1715		.2075	.6859	.6722	1.1694
18	.9997	.1372	.7468	.5281	.6516	.8215	1.1317
19	1.2826	1.0288	.8962	.9997	.8745	.9335	1.1317
20	.9431	.9088	1.1203	1.2071	1.0117	1.1949	1.0374
21	.905	.68	.503	.9242	.8916	1.0456	.8488
22	.6878	.6097	.6371	.7167	.7316	.9335	.7733
23	.6335	.5624	.6371	.8299	.7274	.8589	.6859
24	1.1736	.543	.4268	.57	.7545	.602	.7468
Max	1.2826	1.2449	1.1203	1.2071	1.5384	1.3413	1.4563
Min	.4715	.1372	.4268	.2075	.2606	.602	.6859
Avg	.9001	.6482	.7081	.7414	1.0149	.9732	1.0031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 206 / KHADI CENTER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1658	.3353	.1132	.116	.1341
2		.0189	.1989	.3353	.1132	.0903	.2347
3		.0377	.2429	.3353	.1509	.1311	.2347
4		.0566	.2374	.3353	.0686	.1715	.2347
5		.0754	.2035	.3353	.0754	.1677	.2347
6		.1132	.1492	.3353	.1132	.2006	.2347
7		.132	.1696	.2347	.0189	.0686	.2683
8		.1886	.1357	.1677	.0189	.0686	.0671
9		.2452	.1017	.1341	.132	.1475	.0671
10		.426	.3353	.1886	.3277	.1677	.0754
11		.5426	.4024	.2452	.3913	.0671	.4344
12		.5668	.503	.2452	.4588	.2347	.3982
13		.6154	.503	.2452	.3887	.4359	.3801
14		.663	.503	.2452	.3913	.503	.543
15		.5898	.503	.1886	.3086	.503	.5611
16		.5765	.503	.0943	.1966	.503	.5792
17		.4801		.1886	.1715	.4854	.543
18		.2743	.1341	.1886	.1715	.4359	.4344
19		.1029	.1341	.1698	.1715	.1006	.0754
20		.1966	.1341	.1698	.1029	.1006	.0754
21		.2818	.3353	.132	.0328	.1341	.12
22		.2785	.3353	.132	.0305	.1341	.132
23		.2591	.3353	.1132	.0655	.1341	.1132
24	.2515		.1715	.3353	.0754	.0857	.1341
Max	.2515	.663	.503	.3353	.4588	.503	.5792
Min	.2515	.0189	.1017	.0943	.0189	.0671	.0671
Avg	.2515	.3055	.2799	.2262	.1704	.2161	.2629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 201 / Babhulgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4477	.4527	.4854	.443	.4287	.5441	.6706
2	.5373	.5281	.5415		.5144	.6478	.7377
3	.6335	.7545	.6468	.5373	.6859	.6882	.7865
4	.7164	.8676	.7499	.6089	.7716	.7373	.852
5	.8326	.9054	.8596	.724	.8817	.7773	.9393
6	1.0059	.9431	.9511	.9694		.8684	1.004
7	1.0136	.9242	.9877	1.0242	.9431	.8779	1.0242
8	.8238	.8488	.7499	.7522	.811	.6154	.823
9	.8259	.8745	.7373	.7773	.5014	.4656	.5487
10	.8745	.8402	.7865	.8848	.3544	.3544	.3734
11	.8402	.7865	.7362	.8916	.2658	.2614	.3395
12	.7202	.7537	.7865	.8573	.2454	.2987	.2829
13	.7888	.7865	.7287	.8402	.2481	.2801	.3018
14	.7888	.7373	.6882	.8478	.3012	.2987	.2641
15	.7545	.7127	.6802	.8478	.3045	.2614	.2829
16	.703	.6962	.8192	.8817	.3403	.2801	.3018
17	.3772	.3326	.3189	.3772	.4119	.3511	.415
18	.5658	.4435	.5014	.415	.4706	.4755	.4715
19	.8488	.6401	.7783	.5658	.6878	.6401	.6036
20	.5658	.8048	.8413	.6413	.823	.5359	.5281
21	.7545	.6401	.5792	.6859	.7773	.7202	.703
22	.6224	.5359	.5014	.7716	.7202	.788	.7888
23	.5658	.4481	.3898	.6001	.6483	.8215	.8059
24	.3898	.415	.4294	.3898	.3772	.4744	.583
Max	1.0136	.9431	.9877	1.0242	.9431	.8779	1.0242
Min	.3772	.3326	.3189	.3772	.2454	.2614	.2641
Avg	.7082	.6947	.6781	.7102	.5441	.5443	.6013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 202 / Rahegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.3018	.3018	.3045	.3429	.3521	.4458
2	.3403	.3395	.3361	.3403	.5144	.4001	.503
3	.3761	.3961	.3734	.3982	.5144	.4534	.6036
4	.4163	.4338	.4251	.443	.6344	.5243	.6874
5	.5014	.5281	.4938	.5194	.6859	.6478	.7537
6	.6036	.5658	.567	.6401	.7373	.7373	.8192
7	.5611	.6413	.6219	.6154	.547	.6219	.6219
8	.3761	.3772	.4024	.394	.3961	.4163	.5121
9	.4641	.6001	.5571	.5992	.3258	.2507	.4207
10	.5735	.5316	.5735	.6718	.2507		.2241
11	.6001			.6344	.1433		.2263
12	.5316	.4588		.6001	.1417	.1132	
13	.5144	.4973			.1595	.1509	
14	.6173	.5304		.6001	.1772	.1886	.2263
15	.6001	.5636	.5921	.5144	.1791	.1509	.2452
16	.5144	.6062	.6316	.6516	.1417	.1886	.2452
17	.2452	.2218		.2829	.2481	.2614	.2641
18	.2829	.2772	.2686	.3395	.3258	.3921	.3018
19	.3772	.439	.4344	.415	.4525	.499	.4904
20	.5281	.5487	.5121	.3772	.5487	.3734	.3584
21	.4715	.4207	.4525	.5144		.5316	.5144
22	.3584	.3142	.3761	.583	.4961	.6173	.6173
23	.2641	.2614	.3189	.4287	.4744	.6687	.583
24	.2454	.2452	.2641	.2629	.2743	.3163	.4115
Max	.6173	.6413	.6316	.6718	.7373	.7373	.8192
Min	.2452	.2218	.2641	.2629	.1417	.1132	.2241
Avg	.4436	.4391	.4475	.4839	.3788	.4025	.4580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 203 / Nalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3086	.3086	.2846	.2641	.2865	.3018
2	.3725	.3944	.3353	.3361	.3018	.3224	.2987
3	.4001	.4287	.3856	.3521	.3206	.3721	.3361
4	.4049	.463	.4424	.3887	.3584	.4119	.3658
5	.4424	.5144	.5079	.421	.3772	.4344	.4024
6	.4752	.5316	.5735	.4588	.4338	.4706	.4572
7	.3109	.3206	.3841	.4024	.5093	.5487	.4938
8	.3077	.3018	.3475	.3403	.2829	.3582	.3841
9	.2149	.2263	.2987	.2835	.4858	.3521	.4096
10	.1772	.1886	.2263	.2686	.4321	.4752	.3978
11	.1132	.1509	.1772	.2641	.3681	.4144	.4115
12	.1509	.1132	.1753	.2452	.4001	.3978	.3944
13	.1132	.132	.1063	.2263	.3725	.4144	.3772
14	.1132	.1132	.1052	.1886	.3681	.3978	.3429
15	.132	.1132	.1417	.1509	.3887	.3481	.4115
16	.1509	.1494	.1433	.1509	.4588	.3185	.4287
17	.1886	.168	.1772	.1886	.1791	.1867	.1886
18	.3395	.2054	.2686	.2263		.2241	.3018
19	.3772	.2561	.3258	.3395	.3258	.2587	.3395
20	.2641	.3109	.3658	.3772	.3841	.3174	.415
21	.3258	.3429	.3725	.3206	.3258	.3734	.3584
22	.4115	.3772	.3361	.2641	.3224	.3174	.3018
23	.3772	.3429	.3005	.2263	.2835	.2641	.3018
24	.253	.2743	.3086	.25	.2263	.2481	.2641
Max	.4752	.5316	.5735	.4588	.5093	.5487	.4938
Min	.1132	.1132	.1052	.1509	.1791	.1867	.1886
Avg	.2807	.2803	.2964	.2898	.3552	.3547	.3619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 204 / AMANSPURWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6516	.6001	.5601	.3206	.2865	.3018
2	.6802	.6859	.7377	.6478	.3395	.3258	.3395
3	.7682	.7888	.8215	.6882	.3772	.3761	.4108
4	.8421	.8573	.8848	.8097	.415	.4163	.4668
5	.9175	.9326	1.0159	.9667	.5281	.4525	.499
6	1.0322	1.1191	1.1797	1.1305	.5658	.5487	.5487
7	.3658	.3772	.4938	.4024	.6413	.6219	.6036
8	.362	.4527	.3658	.3403	.4715	.394	.4755
9		.3772	.2241	.2658	.9831	.9393	1.1797
10		.3395	.1886	.2126	.9231	1.0978	1.1012
11	.1886	.2263			1.0402	1.0814	.9145
12	.2641	.1698	.2303		1.004	.9995	
13		.1509	.1753	.2641	.8002	.9945	
14		.1509	.1753	.2452	.9069	1.0159	.9145
15		.1509	.2126	.2263	.8962	.9831	.8383
16	.3018	.1867	.2149	.2452	1.065	.9831	.7621
17	.3206	.2402		.2829	.1772	.2241	.3395
18	.3772	.2957	.3224	.3395	.2686	.2801	.3584
19	.3584		.3982	.415	.3258	.3142	.2829
20	.3018	.4024	.439	.5658	.5121	.3881	.415
21	.5144	.7202	.8097	.4527	.4163	.3547	.3395
22	.6173	.8573	.8421	.3772	.362	.3361	.3018
23	.5487	.703	.7682	.3395	.3224	.2829	.3018
24	.5441	.5487	.5487	.506	.2829	.2658	.2641
Max	1.0322	1.1191	1.1797	1.1305	1.065	1.0978	1.1797
Min	.1886	.1509	.1753	.2126	.1772	.2241	.2641
Avg	.5238	.4950	.5295	.4674	.5810	.5818	.5436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 205 / dhondalgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045	.3206	.3206	.3224	.3258	.3681	.5144
2	.3544	.3584	.3547	.3582	.5316	.4111	.6036
3	.394	.415	.4108	.4119	.5658	.4801	.7042
4	.4525	.4715	.4805	.5068	.6516	.5506	.7701
5	.5792	.5658	.6036	.6401	.7202	.639	.8356
6	.7133	.6602	.6767	.724	.8987	.7865	.8907
7	.8145	.8488	.7682	.8048	.5658	.6697	.695
8	.6516	.5658	.6219		.4715	.5373	.5487
9	.664	.583	.5898	.639	.3582	.3224	.4755
10	.6882	.6001	.6226	.7701	.2658	.3224	.3361
11		.5801	.5921	.8059	.2454	.3206	.2829
12	.703	.5967	.583	.6859	.2686	.3018	.2452
13	.703	.5636	.5344	.6001	.2686		.2641
14	.6516	.5304	.5441	.4287	.2481	.3206	.3018
15	.5144	.5636	.583		.2454	.2829	.2641
16	.4287	.5898	.6554	.703	.2658	.3206	.2829
17	.2452	.2033	.2126	.2641	.2658	.3734	.3018
18	.3018	.2587	.3582	.2829	.3045	.4481	.3018
19	.415	.4755	.5068	.4338	.4344	.5121	.5281
20	.5658	.567	.5487	.4904	.5853	.4108	.3961
21	.4904	.4938	.4656	.5487	.5668	.5144	.5487
22	.415	.4668	.4477	.6173	.5121	.6001	.6001
23	.3018	.3734	.3898	.5144	.4744	.703	.5487
24	.2658	.2829	.2829	.2835	.2743	.3479	.4801
Max	.8145	.8488	.7682	.8059	.8987	.7865	.8907
Min	.2452	.2033	.2126	.2641	.2454	.2829	.2452
Avg	.5051	.4973	.5064	.538	.4298	.4584	.4883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 206 / sanjarpurwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3258	.3772	.3201	.2641	.2103	.2641
2	.3795	.4115	.4191	.3725	.2829	.2658	.3018
3	.4161	.463	.4862	.4001	.3018	.3045	.3018
4	.4534	.4973	.6036	.4858	.3395	.3258	.3361
5	.5735	.5658	.7373	.6226	.3584	.3582	.3658
6	.6554	.6859	.8848	.7373	.415	.4344	.4024
7	.2126	.3018	.1829	.2126	.4715	.5853	.439
8	.2686	.2641	.3109	.2896	.2641	.3224	.3658
9	.1595	.2263	.2614	.2865	.583	.3521	.4424
10	.1417	.1886	.1886	.2126	.5735	.421	.4807
11	.1132	.1509	.2103	.2452	.5121		.5144
12	.1509	.1132	.1791	.2263	.5281	.4807	
13	.1132	.132	.1402	.1886	.5182	.4475	.4801
14	.1132	.1132	.1063	.1886	.5182	.4144	.463
15	.1509	.1132	.1417	.1509	.4801	.4144	.4801
16	.1509	.1494	.1063	.1509	.5344	.4424	.5144
17	.1886	.1867	.1433	.1886	.1417	.1494	.1886
18	.3395	.2427	.2481	.2263	.1433	.1867	.3395
19	.415	.2743	.3045	.3584		.2218	.3772
20	.2829	.3292	.3475	.415	.2172	.3361	.3961
21	.3429	.3429	.3521	.3395	.2743	.2614	.3395
22	.4287	.3772	.3521	.2829	.2507	.2801	.2829
23	.4115	.3429	.3163	.1886	.2303	.2263	.2641
24	.2846	.3086	.3258	.2688	.2263	.2126	.2641
Max	.6554	.6859	.8848	.7373	.583	.5853	.5144
Min	.1132	.1132	.1063	.1509	.1417	.1494	.1886
Avg	.2944	.2961	.3219	.3066	.3665	.3328	.3741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 201 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.7878	1.262	1.4022	1.6651
10			1.858	
11			1.893	
12			1.9456	
13			1.7703	
14			1.6827	
15			1.4899	
Max	1.7878	1.262	1.9456	1.6651
Min	1.7878	1.262	1.4022	1.6651
Avg	1.7878	1.262	1.7202	1.6651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 202 / WAKLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.7537	.7712	.7186	.7712
10			.8063	
11			.5959	
12			.6661	
13			.7186	
14			.631	
15			.6661	
16			.6661	
Max	.7537	.7712	.8063	.7712
Min	.7537	.7712	.5959	.7712
Avg	.7537	.7712	.6836	.7712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 203 / Anchalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.8238	.6485	.6661	.7712
10			.6485	
11			.631	
12			.6135	
13			.631	
14			.6485	
15			.6485	
Max	.8238	.6485	.6661	.7712
Min	.8238	.6485	.6135	.7712
Avg	.8238	.6485	.6410	.7712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 204 / Mauli Ginning
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-MAR-18	17-MAR-18
HR	Load (MW)	Load (MW)
9	.0175	
12		.0175
Max	.0175	.0175
Min	.0175	.0175
Avg	.0175	.0175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 205 / Bhadli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.4908	.5258	.5609	.5434
10			.5434	
11			.5784	
12			.5784	
13			.5959	
14			.6135	
15			.631	
Max	.4908	.5258	.631	.5434
Min	.4908	.5258	.5434	.5434
Avg	.4908	.5258	.5859	.5434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 206 / 11 kv parala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.6476	1.5074	.631	1.0166
10			.6485	
11			.6661	
12			.7362	
13			.7712	
15			1.7353	
16			.7362	
Max	1.6476	1.5074	1.7353	1.0166
Min	1.6476	1.5074	.631	1.0166
Avg	1.6476	1.5074	.8464	1.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 201 / 11 KV GARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4252	.3547	1.1999	1.1317	.7468	.503
2		.4607	.3734	1.2403	1.1317	.7545	
3		.5316	.5601	1.3394	1.226	.8488	
4		.6379	.6535	1.4327	1.1022	.9431	
5		.788	.7468	1.3253	1.1022	1.1317	
6		.8505	.8145	1.0924	1.1869	1.1203	
7	.7973	.7265	.8326	.8413	.6783	.7468	.6706
8	.5975	.5847	.6516	.6068	.5087	.5658	.5868
9	.6706	.4961	.5365	1.283	.4239	.5658	.4481
10	.5365	.5316	.5868		.3391	.3772	.2614
11	.503	.5847	.57		.2801	.2829	.208
12	.5548	.4024	.5847		.3734		.2481
13	.5895	.4191	.5201	.3018	.2829	.2614	.1772
14	.5434	.4862	.5548	.2829	.2801	.2614	.2126
15	.4961	.503	.5373	.2641	.2241	.2801	.3366
16	.5316	.4694	.5895	.2829	.2801	.3174	.3366
17	.2601	.2054	.2601	.3772	.2829		.3544
18	.3189	.2801	.4961	.4715	.3391	.3734	
19	.4854	.5601	.5375	.5658		.5601	.3721
20	.567	.6535	.5895	.5281	.6535		.3544
21	.4908	.5973	.6379	.5658	.5658		.5316
22	.3814	.5601	.7164	.5658	.6602		.5895
23	.3121	.4668	.8322	.6602	.5658	.6203	.6762
24	.3467		1.0166		.6602		.7362
Max	.7973	.8505	1.0166	1.4327	1.226	1.1317	.7362
Min	.2601	.2054	.2601	.2641	.2241	.2614	.1772
Avg	.4924	.5313	.6064	.7614	.6208	.5977	.4224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 202 / 11 KV MANOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.7265	.7316	1.4632	1.1317	.9431	.9221
2		.8322	.823	1.4883	1.0174	1.1317	
3		.8859	.9145	1.5769	1.3203	1.1317	
4		.9214	.9431	1.6655	1.5089	1.3203	
5		1.1694	1.0631	1.5947	1.3565	1.3203	
6		1.134	1.0974	1.2403	1.2717	1.5089	
7	1.0631	1.0631	1.0242	1.0277	.6783	.8488	.7545
8	.9214	1.0166	.7499	.6836	.6783	.7545	.6036
9	.7545	.9036	.6371		.4239	.5658	.5975
10	.7209	.8589	.6706		.5087	.4668	.4294
11	.6706	.8596	.9145		.6602	.5658	.3189
12	.7796		.9412		.5658		.1772
13	.8413	.8383	.9362	.4715	.5601	.3361	.2126
14	.7343	.7377	.8322	.5658	.6602	.4481	.3189
15	.6661	.7545	.7796	.5658	.5658	.4481	.3658
16	.6135	.6706	.7282	.3772	.4668	.5041	.4252
17	.362	.2427	.3155	.5281	.3772	.5228	.4961
18	.4607		.9214	.5658	.5658	.5601	.6379
19	.5493	.8589	1.0454	.9431	.6602	1.0974	.7442
20	.7265	1.0631	1.2437	.7545	.6602		.9214
21	.9745	1.0059	1.0402	.8488	.7545		.8413
22	.6733	.9145	1.2536	.8488	.6783		.964
23	.5493	.695	1.2971	.8488	.6602	1.0059	1.0288
24	.6588		1.382		.763	.6535	1.0867
Max	1.0631	1.1694	1.382	1.6655	1.5089	1.5089	1.0867
Min	.362	.2427	.3155	.3772	.3772	.3361	.1772
Avg	.7009	.8644	.9286	.9504	.7706	.8067	.6235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 203 / 11 KV POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.5947	1.1401	1.2536	.6783	.8488	.7468
2		1.7364	1.4251	1.3253	.6783	.7545	
3		2.0199	1.8442	1.3696	.8488	.7545	
4		2.4451	2.0119	1.7013	.763	.6602	
5		2.5312	2.3472	1.949	1.1317	.7545	
6		2.7995	2.2969	1.7718	1.0174	.6602	
7	1.6461	1.5364	1.4922	1.949	1.307	1.1317	1.5947
8	1.6194	1.134	1.291		1.3203	1.3203	1.2226
9	1.2403	1.1919	1.1888		1.8861	1.6975	1.5592
10	.7468	1.1041	.823		1.95	1.6975	1.4419
11	.5601	1.0056	.2054		1.8861	1.5261	1.6124
12	.1829	.2801	.3109		1.6975		1.6832
13	.1063	.2241	.2658	2.2405	1.6975	1.2955	1.7551
14	.0886	.168	.1949	1.8652	1.587	1.1736	1.595
15	.1063	.1867	.1663	2.0348	1.5089	1.0898	1.1963
16	.124	.1867	.1433	1.6108	1.3203	1.073	1.0166
17	.3721	.2987	.6089	.6783	.7545	.2987	.3121
18	.4854	.4668	.8779	.8488	.679	.3734	.4161
19	.6135	1.4352	1.258	1.5089	1.226	1.2803	1.0402
20	.8505	1.4175	1.5203	1.3203	1.1317		1.1104
21	1.134	1.0059	1.4175	.9431	1.226		1.0402
22	1.0985	1.0898	1.3112	.8488	1.226		.9015
23	1.0808	1.1233	1.2048	.8402	.9431	.6201	.8322
24	1.1706		1.2048		.763	.9431	.5201
Max	1.6461	2.7995	2.3472	2.2405	1.95	1.6975	1.7551
Min	.0886	.168	.1433	.6783	.6783	.2987	.3121
Avg	.7623	1.1731	1.1063	1.4477	1.2178	.9977	1.1367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 201 / biloni SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.1012	.9374	1.0311	.8299	.9431	.7545
2	1.0242	1.1174	1.1336	1.0623	.8299	.9431	.7545
3	.9602	1.166	1.2186	1.0623	.8676	.9808	.7922
4	1.0562	1.2334	1.2498	1.0936	.9054	1.0185	.8299
5	1.1385	1.4074	1.2811	1.1873	.9431	1.0562	.8488
6	1.4842	1.5813	1.3443	1.3916	.9619	1.0562	1.094
7	.7167	.6413	.6413	.7545	.9431	.9431	.8865
8	.8775	.679	.6979	.9431	.7545	1.0669	.7167
9	.8299	.679	.8962	.9522	1.531	1.1431	1.1589
10	.7167		.7095	1.0082	1.4784	1.3094	1.0269
11	.6602	.6413	.6908	.8775	.7621	1.1888	.8741
12	.5975	.5281	.5228	.7468	1.0837	1.0105	.8623
13	.5228	.5847	.4715	.7095	.9859	.9023	.8623
14	.5601	.6413	.4904	.6722	1.0364	.7735	.8484
15	.6036	.7095	.5788	.6348	1.0364	.8093	.8368
16	.6413	.6602	.6348	.5975	1.0562	.7956	.823
17	.6602	.7545	.7577	.5975	.3772	.3361	.3361
18	.679	.8589	.7842	.6722	.7468	.3921	.3547
19	.6979	.8865	.9431	.8299	.7733	.7095	
20	.7167	.8402	.8865	.9997	.9054	.8488	.8865
21	.6308	.7133	.8128	.8865	.8865	.8299	.811
22	.695	1.0467	.9934	.8488	.8299	.8299	.8299
23	.7573	.9374	.9907	.8488	.8676	.811	.811
24	1.0402	.873	.8592	.9907	.8299	.8676	.7733
Max	1.4842	1.5813	1.3443	1.3916	1.531	1.3094	1.1589
Min	.5228	.5281	.4715	.5975	.3772	.3361	.3361
Avg	.8045	.8818	.8553	.8916	.9259	.8986	.8162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 202 / jarul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.7842	.9335	.8589	.6299	.7499	.5304
2	.8589	.7842	.9709	.8775	.6299	.7811	.5304
3	.8589	.8029	1.0082	.8962	.6464	.8749	.547
4	.8962	.8215	1.0082	.8962	.6464	.9061	.5801
5	.9709	.8402	1.0082	.9335	.6796	.9602	.663
6	1.0829	.8962	1.0349	.9896	.9614	.9922	1.1768
7	.8402	.9335	.9709	1.0456	.5544	.4294	.3511
8	.7392	.6348	.6908		.6348	.462	.4435
9	.6859	.5944	.703	.9259	.6348	.5359	.5175
10	.7335	.6405	.6706	.9389	.6722	.4066	.4805
11	.6859	.639	.695	.7287	.6099	.499	.4805
12	.6398	.6226	.6287	.5841	.5914	.499	.5121
13	.5952	.6093	.5216	.612	.5304	.4938	.4938
14	.5521	.5498	.5075	.6859	.5121	.4755	.4755
15	.5106	.5498	.5563	.7145	.4854	.499	.4525
16	.4778	.6097	.6954		.5853	.4344	.4344
17	.2774	.3189	.4706	.4024	.6767	.6653	.6089
18	.4024	.8589	.5487	.5121	.7392	.591	.6335
19	.5175	.8775	.7392	.7207	.8316	.8316	.6653
20	.7842	.8686	.8871	.9522	.8215	.7947	.8131
21	.8402	.8501	.9335	.5138	.5792	.7127	.3864
22	.8402	.8871	.8962	.5636	.7186	.7209	.5312
23	.8402	.8871	.8775	.6133	.6167	.6299	.5937
24	.8316	.8215	.8589	.8589	.663	.6642	.5533
Max	1.0829	.9335	1.0349	1.0456	.9614	.9922	1.1768
Min	.2774	.3189	.4706	.4024	.4854	.4066	.3511
Avg	.7217	.7368	.7840	.7648	.6521	.6504	.5606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 203 / lakh khandala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4715	.5281	.5281	.5201	.7499	.583
2	.4904	.4715	.5281	.5281	.5498	.8002	.6478
3	.4904	.4715	.5281	.5281	.5944	.8322	.6802
4	.8865	.4904	.5658	.5658	.6401	.9602	.7125
5	.5658	.4904	.5658	.6036	.7468	.9602	.8097
6	.6036	.5093	.5847	.6602	.945	1.0364	1.2643
7	.5847	.5281	.5601	.6413	.1132	.132	.0754
8	.3018	.3018		.3395	.2801	.1619	.2614
9	.6308	.5213	.8069	.8322	.3018	.2263	.2829
10	.751	.7095	.8002	.4938	.3018	.2452	.2263
11	.7034	.7579	.7472	.5487	.2452	.2829	.1509
12	.6704	.6539	.6537	.6676	.2402	.3206	.2241
13	.6382	.7164	.6135	.7093	.2075	.2829	.2241
14	.6287	.6539	.6173	.744	.2587	.2075	.2054
15	.6161	.6539	.631	.7846	.2772	.3174	.2033
16	.5944	.6219	.727	.8387	.2957	.2772	.1848
17	.0709	.0754	.2054	.0943	.3961	.3395	.2957
18	.1867	.3018	.2829	.1478	.3772	.3734	.3174
19	.2829	.3772	.4715	.2801	.3772	.4527	.3395
20	.3961	.415	.4715	.415	.3961	.3961	.415
21	.4527	.4715	.4715	.3715	.6401	.5304	.5155
22	.4715	.4904	.5093	.4012	.6516	.6299	.6562
23	.5093	.4904	.5093	.4458	.6562	.57	.7202
24	.4904	.4904	.5093	.5093	.4904	.7042	.5571
Max	.8865	.7579	.8069	.8387	.945	1.0364	1.2643
Min	.0709	.0754	.2054	.0943	.1132	.132	.0754
Avg	.5211	.5056	.5604	.5283	.4376	.4912	.4397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044109 / 33 KV Khandala

Feeder No / Name : 201 / 11 KV JANEFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.1886	.2263	.3605	.3605	.5716
2	.2641	.2263	.1886	.2263	.3277	.3932	.5228
3	.2641	.2452	.1886	.2641	.3605	.426	.5601
4	.2829	.2641	.2263	.2829	.3768	.4748	.5601
5	.3018	.2641	.2241	.3018	.4588	.5571	.6478
6	.3018	.2829	.2614	.2263	.5407	.639	.7095
7	.2263	.3018	.3429	.1886	.0943	.0943	.0381
8	.2263	.2263	.2096	.1886	.1509	.1509	.1715
9	.5243	.3768	.5975	.5243	.1509	.1132	.1524
10	.5571	.5853	.5668	.6062	.1509	.1334	.0943
11	.7865	.6219	.639	.5571	.0943	.1334	.0943
12	.6554	.6219	.5921	.4915	.0943	.1143	.1132
13	.5571	.5853	.5571	.4588	.0943	.1524	.1132
14	.4915	.5601	.4752	.4915	.1509	.1524	.1132
15	.4915	.5601	.5087	.4752	.1509	.1524	.1132
16	.4915	.5975	.5898	.4588	.1132	.1715	.1132
17	.0943	.1143	.0754	.0943	.1509	.1905	.132
18	.132	.1143	.1132	.1132	.1698	.2667	.1698
19	.2829	.2286	.2263	.2263	.2263	.2858	.2263
20	.3018	.2667	.3395	.3018	.2641	.3048	.2641
21	.2829	.2286	.2829	.2949	.2785	.381	.2622
22	.2829	.2286	.2829	.3605	.3768	.381	.3113
23	.2452	.3048	.3018	.4096	.426	.4191	.3605
24	.2641	.2263	.2858	.2829	.4096	.4424	.4572
Max	.7865	.6219	.639	.6062	.5407	.639	.7095
Min	.0943	.1143	.0754	.0943	.0943	.0943	.0381
Avg	.3556	.3441	.3443	.3355	.2488	.2871	.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAR-18 and 21-MAR-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044109 / 33 KV Khandala

Feeder No / Name : 202 / 11 KV BHAVARBEN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAR-18	16-MAR-18	17-MAR-18	18-MAR-18	19-MAR-18	20-MAR-18	21-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.4752	.7468	.4785	.2263	.2641	.1905
2	.4915	.5243	.6535	.4915	.2263	.3018	.1905
3	.5243	.5243	.6722	.5243	.2641	.3206	.2286
4	.5243	.5898	.7842	.5898	.3206	.3584	.2286
5	.6226	.6226	.9335	.639	.3961	.415	.2286
6	.6882	.6554	.9955	.852	.4527	.3772	.3048
7	.0754	.132	.1132	.0754	.4527	.3584	.3429
8	.1509	.2263	.1905	.0754	.1509	.132	.2477
9	.1886	.2263	.2667	.2263	.7865	.6062	.6805
10	.1886	.3174	.2801	.2263	.9175	.6535	.7209
11	.2263	.3361	.2263	.2452	.8684	.6535	.5898
12	.2263	.3361	.2829	.2263	.6554	.6838	.5407
13	.1886	.2614	.2641	.1886	.5735	.6348	.4915
14	.1886	.2241	.2641	.2075	.4915	.6348	.4424
15	.1509	.2241	.2829	.2452	.4588	.6348	.3932
16	.1698	.2614	.3018	.2075	.4588	.5975	.4588
17	.2075	.1715	.3206	.2263	.0754	.2286	.1132
18	.2641	.1715	.3584	.2641	.0754	.1524	.1698
19	.3206	.3429	.2263	.2829	.1886	.2096	.2641
20	.3584	.381	.2641	.2829	.2829	.2286	.2829
21	.2785	.4191	.2622	.2452	.3395	.2286	.2829
22	.3605	.4954	.3932	.2263	.3206	.3048	.2452
23	.4096	.5716	.4915	.2263	.3018	.3048	.2263
24	.6554	.4424	.5228	.4915	.2263	.2641	.2667
Max	.6882	.6554	.9955	.852	.9175	.6838	.7209
Min	.0754	.132	.1132	.0754	.0754	.132	.1132
Avg	.3299	.3722	.4207	.3227	.3963	.3978	.3388