

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 201 / 11 KV MIDC I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.3243		2.3243	2.0957	2.0005	1.9052
2	2.0386	2.191		2.3053	2.0005	2.0005	1.8671
3	2.0386	2.0957		2.3053	1.9052	1.9052	1.829
4	2.0005	2.0005		2.2862	1.9052	1.8099	1.8099
5	1.9052	2.0005		2.21	1.8099	1.8099	1.7337
6	1.8861	1.9052		2.0957		1.7147	1.5432
7	1.9052	1.829		1.8671	1.6004	1.6385	1.9052
8	1.9624	2.0005		1.829	1.8099	1.5623	1.9052
9	2.191	2.1338	2.0576	1.9052	2.0957	1.3336	1.9433
10	2.3815	2.3243	2.3815	1.9052	2.2862	1.3336	1.9433
11	2.572	2.2862	2.4006	1.9052	2.6292	1.2955	2.0005
12	2.4196	2.2862	2.0576	1.8099	2.4196	1.2574	2.0195
13	2.2862	2.3053	2.0386	1.7147	2.4196		2.0195
14	2.1338	2.2862	2.3815	1.9052	2.3815		2.0957
15	2.2862	2.2862	2.5339	2.0767	2.3243		2.2481
16	2.553	2.3243	2.8578	2.191	2.3243		2.3243
17	2.7435	2.4768	2.8769	2.4196	2.2862		2.3815
18	2.6673	2.6673	2.8769	2.572	2.3434		2.4768
19	2.572	2.4768	2.5339	2.7435	2.4006		2.572
20	2.572	2.3815	2.572	2.572	2.2862		2.6673
21	2.6101	2.3815	2.553	2.3243	2.191		2.6673
22	2.5149	.1307	2.572	2.21	2.191		2.7435
23	2.5149	2.3053	2.2481	2.21	2.0957		2.572
24	2.0005	2.4387	2.3053	2.5149	2.2481	2.0576	1.9433
Max	2.7435	2.6673	2.8769	2.7435	2.6292	2.0576	2.7435
Min	1.8861	.1307	2.0386	1.7147	1.6004	1.2574	1.5432
Avg	2.2839	2.1599	2.4530	2.1751	2.1761	1.6707	2.1299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 202 / 11 KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524		.1905	.1905	.381	
2	.1905	.0953		.1905	.1905	.2858	
3	.1905	.0953		.1905	.1905	.2858	
4	.1905	.1905		.2286	.1905	.2858	
5	.1905	.1905		.1905	.1905	.3429	
6	.1905	.1905		.1905		.3429	
7	.1905	.1905			.1905	.381	
8	.1905	.1905			.2858	.381	
9	.2858	.1905	.2858	.1905	.2858	.2858	
10	.2858	.1905	.381	.2858	.381		
11	.381	.2858	.4763	.381	.381		
12	.381	.2858	.5335	.2858	.5716		
13	.381	.381	.3048	.2858	.5716		
14	.381	.381	.381	.2858	.7621		.6668
15	.381	.381	.3429	.381	.7621		.4763
16	.381	.1905	.4763	.2858	.5716		.4763
17	.381	.1905	.4572	.1905	.381		.381
18	.381	.1905	.4954	.1905	.381		.381
19	.381	.1905	.2858	.1905	.381		.381
20	.381	.1905	.4763	.2858	.381		.381
21	.381	.1905	.1905	.2858	.381		.3429
22	.2858	.1905	.2286	.381	.381		.381
23	.2858	.1905	.2286	.2858	.381		.2858
24	.1905	.1905	.1905	.3239	.1905	.381	
Max	.381	.381	.5335	.381	.7621	.381	.6668
Min	.1905	.0953	.1905	.1905	.1905	.2858	.2858
Avg	.2937	.2127	.3584	.2589	.3727	.3353	.4153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 203 / 11 KV TAKALGHAT (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0288		1.105	1.1431	1.3336	1.2955
2	1.1431	.9145		1.105	1.0479	1.2384	1.2955
3	1.1431	.8383		1.105	.9526	1.2384	1.3336
4	1.105	.8383		.9526	.9526	1.105	1.3336
5	1.0669	.7621		.9526	.9526	1.0479	1.1431
6	1.0669	.7621		.8192		1.0479	.8002
7	.8573	.7621		.7621	.7621	.9526	.7811
8	.8764	.7621		.724	.7621	.7621	.7621
9	.8002	.7621	.5716	.724	.7621		.8573
10	.8002	.7621	.6668	.7621	.7621		.8573
11	.7621	.7621	.8573	.7621	.7621		.9526
12	.8573	.7621	.8573	.8573	.7621		.9526
13	.8573	.7621	.9526	.9526	.7621		.9526
14	.9526	.8573	.9145	.9526	.7621		.9526
15	.9526	.8573	.8573	.9526	.7621		.9526
16	.9526	.9526	.7621	.8573	.7621		.9526
17	.9526	.8573	.8573	.7621			.9526
18	1.0479	.7621	.8954	.8573	.9526		.9526
19	1.1812	.8573	.9145	.9526	.9526		.9526
20	1.2765	.8573	1.1241	1.0479	1.0479		1.1431
21	1.3336	.9526	1.105	1.1812	1.1431		1.1431
22	1.2384	.9526	1.105	1.2765	1.2193		1.3336
23	1.2384	.9526	1.0288	1.1431	1.2193		1.3336
24	1.467	1.1431	.9526	1.0669	1.1431	1.3336	1.2384
Max	1.467	1.1431	1.1241	1.2765	1.2193	1.3336	1.3336
Min	.7621	.7621	.5716	.724	.7621	.7621	.7621
Avg	1.0447	.8534	.9014	.9431	.9249	1.1177	1.0510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 204 / 11 KV MIDC III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.724		.7049	.5716	.6097	.6859
2	.5716	.724		.7049	.4763	.6097	.7049
3	.5716	.6097		.6668	.5335	.5716	.6668
4	.5716	.6097		.6859	.5335	.5716	.7621
5	.5716	.5716		.6859	.5335	.5335	.7811
6	.5716	.5716		.7049		.5335	.8192
7	.5716	.6478		.7049	.5906	.5525	.9526
8	.6097	.7621	.5335	.7049	.6859	.5716	.9717
9	.724	.8383	.5335	.8573	.7621	.5716	1.086
10	.8573	.9145	.5144	.9526	.8383	.5906	1.2384
11	.9526	.8573	.7621	1.086	.8954	.5716	1.3336
12	1.0479	.8573	.8573	1.0288	.9526	.5144	1.4289
13	1.0479	.7811	.8383	1.0288	.9526		1.5432
14	1.105	.8954	1.1812	1.1431	.9907		1.4289
15	1.105	.9907	1.2003	1.2574	.9907		1.3336
16	1.1431	1.086	1.2003	1.1812	.9526		1.2384
17	1.1431	1.0288	1.2003	1.1812	.9335		1.086
18	1.0288	.9526	.8573	.9717	.8573		.9526
19	.8573	.8573	.8192	.7811	.7049		.8192
20	.8002	.8573	.6859	.724	.6668		.8192
21	.743	.8002	.7049	.724	.6097		.8002
22	.724	.743	.724	.6668	.6097		.8002
23	.724	.6668	.743	.6097	.6668		.7621
24	.8002	.7621	.6097	.7049	.6097	.6859	.8573
Max	1.1431	1.086	1.2003	1.2574	.9907	.6859	1.5432
Min	.5716	.5716	.5144	.6097	.4763	.5144	.6668
Avg	.8105	.7962	.8215	.8526	.7356	.5760	.9947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 205 / 11 KV MIDC IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9526		.7621	.8002	.724	
2	1.0479	.8573		.7621	.724	.7621	
3	1.0479	.8573		.743	.6668	.7621	
4	1.0288	.7621		.7621	.6668	.8573	
5	1.0288	.7621		.8002	.724	.8573	
6	1.0288	.7621		.8192		.8954	
7	1.0479	.6668		.6859	.8383	.8954	
8	.8192	.8002	.9526	.6668	.9907	.5716	
9	.9526	.9526	.9526	.8002	1.1431	.6668	
10	1.0479	1.1241	1.0669	.9526	1.2384	.6668	
11	1.2003	1.1431	1.1241	1.1241	1.3717	.8573	
12	1.2384	1.1431	1.0479	1.0479	1.2384		
13	1.2384	1.2193	1.0288	1.0098	1.1431		
14	1.2574	1.1431	1.0479	1.086	1.105		.4763
15	1.3336	1.1431	1.3527	1.1812	1.1431		.7621
16	1.3336	1.1241	1.3336	1.1431	1.1431		.9526
17	1.448	1.0669	1.0479	1.0098	1.1812		1.086
18	1.3336	1.0669	1.0479	.9907	.9526		
19	1.2193	1.0288	1.0288	.9335	.7621		1.105
20	1.0479	1.0288	.9526	.8573	.7621		1.0288
21	.9335	.9145	.743	.8573	.6668		1.0288
22	.9907	.9145	.7621	.8002	.6668		1.0479
23	.9907	.9526	.7811	.8002	.724		
24	1.086	1.0288	.9717	.8573	.8383	.724	
Max	1.448	1.2193	1.3527	1.1812	1.3717	.8954	1.105
Min	.8192	.6668	.743	.6668	.6668	.5716	.4763
Avg	1.1145	.9756	1.0142	.8939	.9344	.7700	.9359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 206 / 11 KV MIDC VI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8954		.743	.7621	.7621	.5716
2	.724	.8573		.743	.7621	.7621	.7621
3	.724	.8573		.724	.724	.6668	.5716
4	.724	.7621		.7621	.724	.6097	.5335
5	.7621	.7621		.743	.7621	.6097	.5335
6	.7621	.8002		.7621		.5335	.5716
7	.7811	.7621			.8383	.5335	.6097
8	.7621	.8573			.8573	.5335	.6668
9	.8573	.9145	.7621	.8573	.8573		.7621
10	.9526	.9907	.9526	.9145	.9145		.8002
11	1.0669	1.0479	1.0479	.9907	.9145		.8573
12	.9526	1.0479	1.0479	.9526	.9526		.8573
13	.8573	1.0669	.8573	.9907	.9526		.9145
14	.7621	1.1431	.9526	1.0479	.9907		.9526
15	.9717	1.2193	1.0098	1.1431	.9526		.9526
16	1.2384	1.2955	1.0479	1.2574	.9526		.9907
17	1.3717	1.2384	1.1431	1.3717	.9907		.9907
18	1.2384	1.1431	1.2384	1.2384	.9907		.9717
19	1.1431		.9526	1.0669	.9145		.9907
20	1.0479	1.1431	.9526	1.0288	.8573		.8573
21	.9907	1.1431	.9145	1.0288	.8573		.8573
22	.9717	1.1431	.8002	.9907	.8002		.7621
23	.9717	1.0669	.7621	.8573	.8002		.8573
24	.8573	.9907	.9907	.7621	.7621	.8383	.8573
Max	1.3717	1.2955	1.2384	1.3717	.9907	.8383	.9907
Min	.724	.7621	.7621	.724	.724	.5335	.5335
Avg	.9272	1.0064	.9645	.9535	.8648	.6499	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 207 / 11 KV MIDC VII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6287		.6097	.6478	.5906	
2	.743	.5716		.6097	.6097	.5335	
3	.724	.5716		.5716	.5716	.5335	
4	.7049	.5144		.5716	.5716	.4763	
5	.724	.5144		.5716	.6097	.4763	
6	.724	.4763		.5716		.5716	
7	.724	.4763		.5716	.6668	.5716	
8	.5525	.6097		.5906	.7621	.5525	
9	.724	.743	.5716	.724	.8192		
10	.9145	.8383	.9526	.8573	.8192		
11	1.1241	.9526	1.1812	.9335	.8954		
12	1.0479	.9526	1.2003	.8573	.9526		
13		1.0479	.9335	.724	.9526		
14	1.0098	1.105	1.0479	.7621	1.0288		1.1241
15	1.1431	1.105	1.2003	.8192	.9526		1.0479
16	1.1431	1.1812	1.1812	.9526	.8573		1.0288
17	1.2003	1.0479	1.0669	1.0098			1.086
18	1.0479	.9526	.7621	.8573	.4763		.8573
19	.9145	.8573	.6859	.6097	.7811		.724
20	.7621	.7621	.6097	.6097	.6668		.6668
21	.6097	.7621	.6287	.6859	.6097		.6668
22	.6668	.6859	.6097	.6859	.6097		.5716
23	.6668	.6668	.6668	.6668	.5906		.6287
24	.724	.7049	.6668	.6859	.6859	.5906	
Max	1.2003	1.1812	1.2003	1.0098	1.0288	.5906	1.1241
Min	.5525	.4763	.5716	.5716	.4763	.4763	.5716
Avg	.8408	.7803	.8728	.7129	.7335	.5441	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 208 / 11KV MIDC No.VIII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.4098		1.3717		.7621	
2	1.3336	1.3336		1.3717		.7621	
3	1.2384	1.2384		1.2955		.7621	
4	1.2574	1.2384		1.2955		.7621	
5	1.2955	1.1431		1.2384		.7621	
6	1.2955	1.0288		1.1812		.7621	
7	1.2384	.9526		1.2003		.7621	
8	1.2384	1.3336		1.2193		.7621	
9	1.5242	1.7147	1.4289	1.5242			
10	1.8099	1.9052	1.829	1.9052			
11	2.4768	1.9052	1.9243	2.2862			
12	2.4196	1.9052	1.9052	2.0957			
13	2.4196	1.9052	1.6194	1.7147			
14	2.4768	2.0005	1.8099	2.0957			2.0957
15	2.3815	2.0005	2.0576	2.2862			2.191
16	2.3815	2.0957	2.0576	2.3815			2.2862
17	2.2862	2.0005	2.191	2.4768			2.3815
18	1.9052	1.9052	1.4861				1.9052
19	1.8099	1.6766	1.448				1.5242
20	1.6575	1.5242	1.467				1.6194
21	1.5242	1.4289	1.448		.7621		1.6194
22	1.5242	1.3336	1.2574		.7621		1.7147
23	1.5242	1.3336	1.2574		.7621		1.6194
24	1.5623	1.5242	1.3336	1.4861		.7621	
Max	2.4768	2.0957	2.191	2.4768	.7621	.7621	2.3815
Min	1.2384	.9526	1.2574	1.1812	.7621	.7621	1.5242
Avg	1.7464	1.5766	1.6575	1.6903	.7621	.7621	1.8957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 209 / 11 KV MIDC IX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0479		1.1431	.9526	1.0479	
2	.8954	.9907		1.1622	.9526	.9907	
3	.8954	.8954		1.1622	.8573	.9907	
4	.9145	.8383		1.1812	.8573	.9145	
5	.9526	.8383		1.1622	.9526	.8573	
6	1.0098	.7621		1.1812	.9526	.8573	
7	1.0479	.7621		.9526	.9526	.7621	
8	.9145	.8383		.9526	1.0479		
9	1.0479	.9335	.9526	1.0479	1.1812		
10	1.1431	1.0479	.9907	1.1431	1.2384		
11	1.2384	1.105	.9907	1.2193	1.3146		
12	1.1431	1.105	.9526	1.1622	1.2384		
13	1.1431	1.1812	1.1431	1.1622	1.2384		
14	.9526	1.1812	1.1431	1.2003	1.1431		1.4861
15	1.086	1.1431	.9335	1.2003	1.3336		1.3717
16	1.2384	1.1431	1.3336	1.3717	1.3336		1.3717
17	1.3336	1.0479	1.3527	1.6766	1.5242		1.4098
18	1.3336	.9907	.9526	1.4289	1.2955		1.2384
19	1.2193	.9526	.9335	1.2765	1.0098		1.0479
20	1.105	.9526	.9526	1.1431	1.0479		.9907
21	.9526	.9907	.9717	1.0288	1.0479		1.0288
22	.9526	.9907	.9907	.9526	1.1241		1.0479
23	.9526	1.0098	.9907	.9526	1.1431		.9526
24	.9145	.9526	1.0098	1.0288	.9907	1.1241	
Max	1.3336	1.1812	1.3527	1.6766	1.5242	1.1241	1.4861
Min	.8954	.7621	.9335	.9526	.8573	.7621	.9526
Avg	1.0542	.9875	1.0371	1.1622	1.1138	.9431	1.1946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 210 / TAKALGHAT(AG)
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1524
2	.1524				.1524
3	.1524				.1524
8				.1905	
9				.2096	
10				.2096	
11				.2286	.2286
12	.1905		.2096	.2096	.2286
13	.2286		.2286	.1905	.2096
14	.2667		.1905		.2286
15	.1905		.0953		.2286
16	.1905				.2858
17					.2858
18					.1905
19					.1905
20					.1905
21		.1715			.1905
22		.1524			.1715
23		.1524			.1715
24	.1524				.1524
Max	.2667	.1715	.2286	.2286	.2858
Min	.1524	.1524	.0953	.1905	.1524
Avg	.1905	.1588	.181	.2064	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 201 / 11 KV MOHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.7147	1.3717	1.8861	1.7147	1.8861	1.8861
2		1.7147	1.2003	1.8861	1.8671	1.8861	1.7147
3		1.8861	1.3717	1.7147	1.7147	1.7147	1.7147
4		1.7147	1.2003	1.7147	1.5432	1.5432	1.5432
5		1.7147	1.2003	1.3717	1.3717	1.3717	1.5432
6		1.6289	1.2003	1.2003	1.3717		1.3717
7	2.0576		1.0288	1.2003		1.3717	1.3717
8	1.7147	.3429	1.2003	1.0288	1.2003	1.2003	1.2003
9	1.3717	1.5432		1.2003	1.2003	1.2003	1.2003
10	1.2003	1.3717	1.2003	1.2003	1.2003	1.2003	1.2003
11	.8573	1.3717	1.2003	1.2003	1.2003	1.2003	1.7147
12	1.3717	1.2003	1.2003	1.3717		1.2003	1.5432
13	1.7147	1.2003	1.2003	1.3717	1.3717	1.2003	1.7147
14	1.7147	1.3717	1.2003	1.3717	1.3717	1.5432	1.7147
15	1.8861	1.5432	1.3717	1.3717	1.3717		1.7147
16	1.7147	1.5432	1.3717	1.3717	1.3717		1.7147
17	1.8861	1.3717	1.3717	1.5432		1.2003	1.7147
18	1.8861	1.2003		1.2003		1.2003	1.7147
19	1.5432		1.5432	1.5432		1.5432	1.8861
20	1.5432		1.5432	1.7147	1.5432	1.7147	1.8861
21	1.8861	1.3717	1.5432	1.7147	1.7147	1.8861	2.0576
22	1.8861	1.3717	1.5432	1.7147	1.8861	2.0576	2.0576
23	1.8861	1.3717	1.5432	1.7147	1.8861	2.0576	1.8861
24	2.0576	1.7147	1.3717	1.7147	1.7147	1.8861	2.0576
Max	2.0576	1.8861	1.5432	1.8861	1.8861	2.0576	2.0576
Min	.8573	.3429	1.0288	1.0288	1.2003	1.2003	1.2003
Avg	1.6876	1.4411	1.3172	1.4718	1.5061	1.5269	1.6718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 202 / 11 KV BUTIBORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.9431	.8573	.8573	1.2003	1.2003	1.2003
2	1.0288	.8573	.823	.8573	1.2003	1.0288	1.1145
3	1.0288	.9088	.823	.8573	1.2003	1.2003	1.2003
4	1.2003	.8916	.7888	.7716	1.0288	1.0288	1.0288
5	1.0288	.8573	.7716	.7716	1.1145	.8573	1.0288
6	.8573	.8573	.7202	.7716	.8402	.8573	.9602
7	.7888	.6859	.7373	.6859	.6859	.8573	.8916
8	.6859	.6859	.7716	.7545	.6859	.823	.8573
9	.6859	.7545	.7545	.6859	.6859	.823	
10	.7888	.5144	.7716	.6097	.6859	.7716	.8573
11	.8573	.6859	.7716		.6859	.6859	1.7146
12	.8573	.8059	.7545	.8573	.6859	.7202	2.0234
13	.8573	.8402	.7202	.9431	.7716	.6859	1.0288
14	1.8004	.8573	.6859	.9431	.8573	.6859	.9431
15	.9431	1.0288	.6859	.8573	.8573	.7202	.8573
16	1.0288	.9431	.703	.8573	.8573	.7545	.8573
17		.9088	.7716	.823		.823	1.0288
18	1.2003	.8573		.7545		.8916	1.0288
19	.8916		.8573	.9431		1.0288	1.2003
20	.9431		.9431	1.0117	1.2003	1.2003	1.2003
21	1.2003		.9431	1.2003	1.2003	1.3717	1.3717
22	1.2346		.9774	1.2174	1.2003	1.4232	1.4232
23	1.2003	.8573	.9431	1.2003	1.286	1.3717	1.3717
24	1.2003	1.1145	.8573	.9431	1.2003	1.2003	1.3717
Max	1.8004	1.1145	.9774	1.2174	1.286	1.4232	2.0234
Min	.6859	.5144	.6859	.6097	.6859	.6859	.8573
Avg	1.0221	.8428	.8014	.8771	.9586	.9588	1.1548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 203 / 11 KV BORKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	.3429	.6859		1.2003	1.2003
2		1.0288	.3429	.7716	.2058	1.0288	1.0288
3		.9431	.3429	.7716	.6859	1.0288	1.0288
4		.8573	.3429	.6859	.6859	.8573	1.0288
5		.8573	.3429	.6859	.5144	1.0288	.9431
6		.6859	.3429		.5144	1.0288	1.0288
7	.4801	.6859	.3429	.3429		1.0288	.9431
8	.5144		.3429	.3429	.5144	.9431	.8573
9	.5144		.3429	.3429	.8573	1.0288	.6859
10	.5144	.5144	.3429	.5144	1.0288	1.0288	1.0288
11	.5144	.6001	.3429	.4287	1.0288	1.0288	.5144
12	.8573	.8573	.3429	.8573	1.0288	1.0288	.4458
13	.3944	.8573	.3429	.8573	1.0288	.8573	
14	.5144	.8573	.3944	.8573	.8573	1.0288	.5658
15	.5144		.3944	.8573	2.4006		.6001
16	.6859	.6859	.3772	1.0288	1.3717		
17		.8573		.8573		1.0288	
18	1.0288	.8573		1.0288		1.0288	.5144
19	1.0288		.5144	.8573		1.2003	.6001
20	1.0288			1.2003		1.2003	.5144
21	1.0288		.3429	1.2003	.6859	1.2003	.5144
22	1.0288		.3429	1.2003	1.2003	1.3717	1.2003
23	1.0288	.3429	1.2003	1.2003	1.2003	1.3717	1.2003
24		1.0288	.3429	.6001	1.2003	1.2003	1.3717
Max	1.0288	1.0288	1.2003	1.2003	2.4006	1.3717	1.3717
Min	.3944	.3429	.3429	.3429	.2058	.8573	.4458
Avg	.7298	.7968	.3984	.7902	.9450	1.0795	.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 205 / 11 KV AIR II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5144	.5144	.6001	.5658	.5487	.5487
2	.5144	.5487	.4801	.6001	.5487	.5144	.5144
3	.5144	.5144	.5144	.5144	.5487	.5144	.4801
4	.5487	.4973	.4801	.5144	.5658	.5487	.5144
5	.5144	.5144	.5144	.5144	.5658		.5487
6	.5144	.5144	.4801	.5144	.5658	.5487	.5144
7	.1715	.12	.1372	.1372	.1372	.1715	.1715
8	.1372	.1372	.1372	.12	.1372	.1372	.1372
9	.1372	.1372	.1372	.1372	.1372	.1372	.1372
10	.1372	.1372	.1372	.1372	.1372	.12	.1543
11	.1372	.12	.12	.1372	.1372	.12	.1543
12	.1372	.12	.12	.1372	.1372	.1372	.1543
13		.12	.12	.1372	.1372	.1543	.1372
14		.12	.12	.1372	.1543	.1372	.1543
15		.12	.2229	.1372	.1715	.1372	.1543
16		.12	.2229	.1372	.2058	.1372	.1543
17		.12		.1372		.1715	.1543
18	.5487	.12		.12		.2058	.4287
19	.5487			.4973		.3429	.4287
20	.5144			.4973	.463	.3772	.5144
21	.5487	.4801	.4973	.4973	.4458	.4287	.5316
22	.5658	.4458	.4973	.3944	.5144	.4973	.5658
23	.5487		.4801	.3772	.5658	.463	.5487
24	.5144	.5144	.5144	.5487	.5658	.5487	.4458
Max	.5658	.5487	.5144	.6001	.5658	.5487	.5658
Min	.1372	.12	.12	.12	.1372	.12	.1372
Avg	.4106	.2874	.3224	.3201	.3527	.3087	.3437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 206 / 11 KV W.T.PLANT FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5144	.2572	.4287	.3086	.4801	.4904
2	.3429	.5487	.2743	.4287	.3429	.4458	.4115
3	.3086	.5658	.2743	.3429	.3772	.4458	.4115
4	.2915	.5144	.2572	.3429	.3772	.4287	.3772
5	.2572	.5144	.2915	.3258	.3258	.4287	.3258
6	.2058	.4973	.2915	.3258	.3258	.4115	.2401
7	.2915	.1886	.3086	.2915	.3086	.3772	.2229
8	.3429	.1886	.3086	.2915	.3086	.3772	.2229
9	.3429	.2229	.3429	.3429	.2915	.3429	.2401
10	.5487	.2058	.3772	.5316	.5144	.3429	.4801
11	.6859	.2401	.4115	.3601	.5144	.3258	.3258
12	.8573	.2401	.4115	.6001	.5144		.2229
13	.6516	.2743	.4115	.7716	.6001		.5316
14	.5144	.2743	.4287		.7202	.2058	.5487
15	.5658	.3258	.2743	.703	.7716	.2058	.6516
16	.4115	.3772	.2058	.7202	.7716	.3772	.4287
17		.4801	.2572	.583		.3772	.4287
18	.5487	.5144		.4801		.3429	.4287
19	.5487		.463	.5144		.3772	.3944
20	.5487		.2743	.5316	.3086	.4287	.3772
21	.5144	.5144	.2401	.5316	.3429	.4287	.3601
22	.5487	.2572	.2401	.2401	.3601	.463	.4458
23	.5144	.2401	.2572	.3086	.463	.4458	.4287
24	.4115	.5144	.2572	.2915	.3086	.4115	.463
Max	.8573	.5658	.463	.7716	.7716	.4801	.6516
Min	.2058	.1886	.2058	.2401	.2915	.2058	.2229
Avg	.4622	.3733	.3094	.4473	.4360	.3850	.3941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 208 / 11 KV RAMADAM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429				.4458	.2058
2		.3772				.4115	.2229
3		.3601				.4115	.2058
4		.3429				.3772	.2058
5		.3944				.3772	.5487
6		.3772				.3601	.2229
7		.3429				.3772	.2058
8						.3772	.2058
9				.0171		.3601	.2058
10				.0171		.2915	.2058
11			.3772	.0171		.1715	.2229
12			.4973	.0171		.2058	.2572
13	.4973		.4801			.2058	.3258
14	.5144	.3258	.4801			.0171	.2572
15	.5487	.4287				.0171	.2058
16		.4458		.0171		.1886	.2229
17		.4801		.0171		.2743	.2058
18	.4287	.4801				.3429	.2058
19	.5144			.0171		.3086	.2743
20	.5144			.0171	.463	.2572	.2572
21	.4973		.0171	.0171	.2401	.2572	.2229
22	.4801		.0171	.0171	.2572	.2058	.2229
23	.463		.0171	.0171	.5144	.2058	.2401
24	.4458	.4287		.0171		.4801	.2058
Max	.5487	.4801	.4973	.0171	.5144	.4801	.5487
Min	.4115	.3258	.0171	.0171	.2401	.0171	.2058
Avg	.4832	.3944	.2694	.0171	.3687	.2886	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 401 / 33 KV BELA

Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	3.0864	1.286	3.0864	2.0576	.7716	2.0576
2	2.1605	3.3436	1.4403	3.0864	2.1605	.7202	1.9547
3	2.1605	3.6008	1.6461	2.8292	2.1091	.7202	1.9547
4	2.0576	3.0864	1.8004	2.572	2.0576	.6173	1.8004
5	1.8519	2.8292	1.9547	2.0576	1.8004	.6173	1.9805
6	1.6461	2.572	2.0576	3.2922	1.5947	.6173	1.6461
7	1.9547	2.8292	2.1605	3.6008	.0514	.7202	1.6461
8	2.1605	2.5206	1.9547	2.9836		.7716	1.8004
9	2.4691	2.572	1.9547	1.4918	.9259	.9259	2.2634
10	2.4691	3.3436	1.8519	1.6975	2.3148	1.286	2.4691
11	2.572	3.0864	2.1605	1.9033	2.3148	1.5432	3.5494
12	2.8292	1.9033	2.3148	1.9033	2.3148	.5144	2.572
13	3.6008	1.8004	2.0576	1.6461	2.8292	.0514	2.6749
14	2.572	1.6461	1.6975	1.6975	2.8292	.0514	3.1893
15	2.572	1.8004	1.9033	1.9547	2.8292	.0514	3.7037
16	2.572	1.8004	2.3148	1.7924	2.8292	.5144	1.8004
17		1.8519	2.572	1.5947		1.1317	2.0576
18	3.1893	1.6461		1.6461		1.4403	2.8292
19	3.2407		2.5206	1.6461		1.5432	2.8292
20	3.3436		1.8004	2.0576	.6173	1.6461	2.572
21	3.6008		2.572	2.0576	1.0288	1.6461	2.572
22	3.6523		2.9321	1.0802	1.1317	1.8519	2.5206
23	3.6008	.6173	2.8292	1.1317	.7716	2.3148	2.4691
24		3.3436	1.0288	2.8292	2.0576	.7716	2.1605
Max	3.6523	3.6008	2.9321	3.6008	2.8292	2.3148	3.7037
Min	1.6461	.6173	1.0288	1.0802	.0514	.0514	1.6461
Avg	2.6749	2.4640	2.0352	2.1516	1.8313	.9516	2.3780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 402 / 33 KV VARRON AUTO

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4115	.463	.4115	.463	.463	.463
2	.463	.4115	.463	.4115	.463	.463	.463
3	.463	.4115	.463	.4115	.463	.463	.463
4	.463	.4115	.463	.4115	.463	.463	.463
5	.463	.4115	.463	.4115	.463	.463	.463
6	.463	.4115	.463	.4115	.463	.463	.463
7	.463	.4115	.463	.4115	.4115	.4115	.4115
8	.463	.4115	.4115	.4115	.4115	.4115	.4115
9	.463	.4115	.4115	.4115	.4115	.4115	.4115
10	.4115	.4115	.4115	.4115	.4115	.4115	.4115
11	.4115	.4115	.4115	.4115	.4115	.4115	.4115
12	.463	.4115	.4115	.463	.4115	.4115	.4115
13	.463	.4115	.4115	.4115	.4115	.4115	.4115
14	.463	.4115	.4115	.463	.4115	.4115	.4115
15	.463	.4115	.4115	.4115	.4115	.4115	.4115
16	.463	.4115	.4115	.463	.4115	.4115	.4115
17		.463	.4115	.4115		.4115	.4115
18	.4115	.463		.4115		.4115	.4115
19	.4115		.4115	.463		.463	.4115
20	.4115		.4115	.463	.4115	.463	.4115
21	.4115	.463	.4115	.463	.4115	.463	.4115
22	.4115	.463	.4115	.463	.4115	.463	.4115
23	.4115	.463	.4115	.463	.463	.463	.463
24	.463	.4115	.463	.4115	.463	.463	.463
Max	.463	.463	.463	.463	.463	.463	.463
Min	.4115	.4115	.4115	.4115	.4115	.4115	.4115
Avg	.4451	.4232	.4294	.4287	.4311	.4373	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0762	.0747	.0762	.0693	.0762	.0747
2	.0747	.0762	.0747	.0762	.0648	.0762	.0747
3	.0648	.0762	.0747	.0762	.0747	.0762	.0747
4	.0671	.0762	.0747	.0762	.0648	.0762	.0747
5	.0648	.0762	.0747	.0762	.0648	.0762	.0747
6	.0648	.0762	.0747	.0762	.0648	.0762	.0747
7	.0648	.0762	.056	.0762	.0648	.0762	.056
8	.0648	.0762	.056	.0762	.0648	.0762	.0747
9	.0648	.0762	.0747	.0762	.0648	.0953	.056
10		.0953	.0747	.0762	.0648	.0762	.056
11	.0572	.0747	.0762	.0724	.0762	.0747	.0572
12	.0762	.0747	.0762	.0747	.0572	.056	.0572
13	.0572	.0747	.0762	.0747	.0572	.056	.0572
14	.0572	.0747	.0762	.0747	.0572	.056	.0572
15	.0572	.056	.0762	.0648	.0572	.056	.0572
16	.0572	.056	.0762	.0747	.0572	.056	.0572
17	.0572	.056	.0762		.0572	.056	.0762
18	.0572	.056	.0762		.0572	.056	.0762
19	.0572	.0747	.0762	.0648	.0572	.056	.0762
20	.0762	.0747	.0762	.0747	.0762	.0747	.0762
21	.0762		.0762	.0671	.0762	.0747	.0572
22	.0762	.0747	.0762	.0648	.0762	.0747	.0572
23	.0762	.0747	.0762	.0648	.0762	.0747	.0572
24	.0648	.0762	.0747	.0762	.0648	.0762	.0747
Max	.0762	.0953	.0762	.0762	.0762	.0953	.0762
Min	.0572	.056	.056	.0648	.0572	.056	.056
Avg	.0656	.0730	.0740	.0732	.0652	.0700	.0661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 201 / 11 KV MOHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964	.8383	.6722	.6478	.7468	.8573	.8775
2	.6964	.8192	.6722	.6478	.7095	.8383	.8402
3	.7468	.8002	.6535	.6478	.7095	.8192	.7842
4	.7468	.7811	.6535	.6287	.6722	.8002	.7468
5	.7095	.743	.6161	.6287	.6722	.743	.6535
6	.7095	.7049	.6161	.6097	.6535	.6859	.6348
7	.6722	.6287	.6348	.5716	.6348	.6668	.6535
8	.5975	.6097	.6722	.5716	.6161	.6478	.6722
9	.4481	.6668	.6535	.6668	.6722	.6668	.7095
10	.3887	.6859	.5975	.6097	.7095	.6668	.7468
11	.4191	.7095	.4954	.4016	.6287	.6535	.7621
12	.4382	.6535	.5716	.5975	.6478	.6722	.8192
13	.4191	.6535	.6097	.502	.5716	.6722	.8383
14	.6859	.6722	.6478	.5548	.6287	.7095	.724
15	.8764	.7095	.5716	.5788	.6097	.7095	.8002
16	.8764	.7842	.5335	.6535	.6097	.3921	.8383
17	.8573	.7842	.5335	.5601	.7049	.3921	.8764
18	.5716	.6722	.5335	.5415	.6097	.5601	.7811
19	.7049	.7095	.4954	.6335	.6859	.6535	.5335
20	.8954	.8029	.5716	.724	.8764	.8215	.8764
21	.8192		.6097	.7468	.8954	.8402	.9907
22	.9145	.4854	.6859		.9145	.9149	.9907
23	.9145	.5601	.6668	.7282	.9145	.9522	1.0098
24	.8402	.8764	.6722	.6478	.7468	.8954	.9149
Max	.9145	.8764	.6859	.7468	.9145	.9522	1.0098
Min	.3887	.4854	.4954	.4016	.5716	.3921	.5335
Avg	.6977	.7109	.6100	.6131	.7017	.7180	.7948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 202 / 11 KV CICR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0762	.0747	.0762	.0747	.0762	.0747
2	.0693	.0762	.0747	.0762	.0724	.0762	.0747
3	.0648	.0762	.0747	.0762	.0747	.0762	.0747
4	.0648	.0762	.056	.0572	.0747	.0762	.0747
5	.0747	.0762	.056	.0572	.0724	.0762	.056
6	.0747	.0572	.056	.0572	.0747	.0762	.056
7	.0747	.0572	.056	.0572	.056	.0572	.056
8	.0724	.0572	.056	.0572	.0486	.0572	.056
9	.2267	.1143	.056	.0953	.0934	.1524	.1494
10	.2347	.1143	.056	.2667	.2987	.2858	.2987
11	.2858	.0747	.0381	.2801	.2858	.2801	.3429
12	.3239	.0747	.0381	.2987	.3048	.3174	.3239
13	.3048	.056	.0381	.3174	.2667	.2614	.2477
14	.3429	.056	.0381	.2987	.2667	.2987	.3239
15	.2477	.0747	.0572	.2713	.2667	.2801	.3048
16	.2096	.056	.0572	.2427	.2286	.2614	.2667
17	.0572	.056	.0572	.1494	.0953	.0747	.0762
18	.0572	.056	.0572	.056	.0762	.056	.0762
19	.0572	.056	.0572	.056	.0762	.0747	.0762
20	.0762	.056	.0572	.0503	.0762	.0747	.0762
21	.0762		.0572	.0543	.0762	.0747	.0762
22	.0953	.0747	.0572	.056	.0572	.0747	.0762
23	.0762	.0747	.0572	.056	.0762	.0747	.0762
24	.0747	.0762	.0747	.0572	.0486	.0762	.0747
Max	.3429	.1143	.0747	.3174	.3048	.3174	.3429
Min	.0572	.056	.0381	.0503	.0486	.056	.056
Avg	.1382	.0706	.0566	.1300	.1309	.1371	.1412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 203 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1524	.2801	.2286	.2427	.1524	.2241
2	.2427	.1524	.2987	.2096	.2241	.1905	.2241
3	.1867	.1524	.2987	.1905	.1867	.1715	.2054
4	.1448	.1334	.2614	.1905	.1494	.1524	.2054
5	.1494	.1334	.1867	.1905	.112	.1143	.1867
6	.1307	.1334	.1307	.1524	.112	.0953	.168
7	.112	.0953	.112	.1143	.0934	.0762	.168
8	.0867	.0762	.112	.1143	.0934	.0762	.0934
9	.0972	.1143	.112	.1143	.0905	.0762	.0747
10	.0972	.1143	.0934	.0953	.0934	.0953	.112
11	.1524	.1307	.1524	.112	.0953	.1307	.1334
12	.1905	.1867	.1524	.1307	.1524	.1307	.1334
13	.1334	.1867	.1334	.1189	.1334	.1494	.1524
14	.1143	.112	.1334	.1457	.1143	.112	.1715
15	.1334	.1494	.1715	.1494	.1334	.1307	.1524
16	.1334	.1494	.1715	.112	.1524	.1494	.1143
17	.1715	.168	.1143	.112	.1334	.1494	.1143
18	.1143	.168	.1143	.112	.1143	.0934	.1143
19	.1143	.1307	.1143	.112	.0953	.0934	.0953
20	.1524	.168	.1143	.1267	.0953	.0934	.1143
21	.1524		.1334	.181	.1334	.1494	.1143
22	.1905	.2987	.1524	.0905	.2858	.1494	.1905
23	.1524	.2987	.2477	.2801	.3048	.2801	.1715
24	.1867	.3048	.2801	.1334	2.6699	.2858	.1867
Max	.2427	.3048	.2987	.2801	2.6699	.2858	.2241
Min	.0867	.0762	.0934	.0905	.0905	.0762	.0747
Avg	.1485	.1613	.1696	.1465	.2505	.1374	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 204 / 11 K V JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4572	.7842	.5335	.4108	.4572	.4854
2	.4854	.4382	.7842	.5335	.3921	.4572	.4668
3	.4854	.4191	.7655	.4954	.4108	.4382	.4294
4	.4668	.4001	.7655	.4572	.4294	.4191	.4108
5	.4481	.381	.7655	.4572	.3921	.4001	.3734
6	.4481	.3429	.7468	.4572	.3734	.381	.3734
7	.4108	.4191	.7655	.4572	.3361	.362	.3734
8	.3734	.4382	.7655	.381	.3361	.4191	.2987
9	.4668	.4191	.3734	.381	.3734	.362	.4481
10	.4049	.4954	.4481	.3048	.3734	.4191	.4668
11	.5335	.4668	.4572	.4294	.3429	.4108	.5335
12	.4191	.5228	.4572	.4481	.4191	1.1203	.1905
13	.5716	.3734	.4572	.2429	.4382	1.1203	.2286
14	.4001	.4481	.4572	.2452	.4001	1.5123	.2286
15	.5716	.4108	.4572	.2614	.4191	1.5123	.2286
16	.6859	.5228	.4572	.5975	.4572	1.531	.2286
17	.5716	.5975	.1905	.5601	.4382	1.5123	.2286
18	.5144	.5601	.1905	.4481	.5144	.3921	.1905
19	.4001	.5975	.381		.5144	.5228	.1905
20	.4954	.5975	.4191	.4681	.5716	.5415	.2286
21	.5335		.4191	.4668	.5716	.5415	.2286
22	.5335		.4572	.4887	.5144	.5601	.2286
23	.5335	.6535	.4572	.4668	.4954	.5228	.2286
24	.5228	.5144	.7655	.4572	.4108	.4763	.5041
Max	.6859	.6535	.7842	.5975	.5716	1.531	.5335
Min	.3734	.3429	.1905	.2429	.3361	.362	.1905
Avg	.4916	.4762	.5411	.4364	.4306	.6830	.3247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 205 / 11 Kv MJP W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0572	.056	.0572	.0648	.0572	.056
2	.0648	.0572	.056	.0572	.0648	.0572	.056
3	.0648	.0572	.056	.0572	.0747	.0572	.056
4	.0747	.0572	.056	.0572	.0747	.0572	.056
5	.0648	.0572	.056	.0572	.0747	.0572	.056
6	.1134	.0572	.056	.0572	.0747	.0572	.056
7	.8029	.0572	.056	.0572	.0648	.0572	.056
8	.0747	.0572	.056	.0572	.0648	.1143	.0747
9	.1	.1143	.056	.0762	.112	.2286	.112
10	.1134	.1143	.112	.2286	.112	.2286	.0747
11	.2286	.2241	.1143	.1867	.2286	.2241	.0762
12	.2286	.2241	.1143	.1867	.2286	.056	.0762
13	.2286	.2241	.1143	.1781	.1143	.112	.0762
14	.2286	.2241	.1143	.1619	.0572	.112	.0762
15	.0572	.056	.0762	.1867	.0572	.0747	.0762
16	.1143	.056	.0762	.081	.0572	.056	.0762
17	.1143	.056	.0762	.081	.0572	.056	.0762
18	.1143	.056	.0762	.0905	.0572	.2054	.0762
19	.0572	.056	.0762	.0714	.0572	.2054	.2286
20	.0572	.056	.0762	.0648	.0572	.0747	.0762
21	.0572		.0762	.0648	.0572	.0747	.0762
22	.0572	.056	.0762	.0648	.0572	.056	.0762
23	.0572	.056	.0762	.0648	.0572	.056	.0762
24	.0648	.0572	.056	.0762	.0648	.0572	.056
Max	.8029	.2241	.1143	.2286	.2286	.2286	.2286
Min	.0572	.056	.056	.0572	.0572	.056	.056
Avg	.1339	.0908	.0756	.0967	.0829	.0997	.0772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 401 / 33 KV INCOMMER

Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3014	1.3146	1.7364		1.3014	1.4289	1.2883
12				1.7364			
16	2.0576	1.6244		1.8107	1.5432	2.4086	
22	1.8861				1.8861	1.7924	
24	1.7924	1.8861	1.9044		1.6409	1.8861	1.7924
Max	2.0576	1.8861	1.9044	1.8107	1.8861	2.4086	1.7924
Min	1.3014	1.3146	1.7364	1.7364	1.3014	1.4289	1.2883
Avg	1.7594	1.6084	1.8204	1.7736	1.5929	1.879	1.5404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 402 / 33 KV TRANSFORMER NO-I

Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	12-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.743		.8002
16	1.2003		.9717	
22	1.2003		1.2574	
24		1.2574		1.2574
Max	1.2003	1.2574	1.2574	1.2574
Min	1.2003	.743	.9717	.8002
Avg	1.2003	1.0002	1.1146	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 403 / 33 KV TRANSFORMER NO-II

Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	12-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.5716		.6287
16	.8573		.5716	
22	.6859		.6287	
24		.6287		.6287
Max	.8573	.6287	.6287	.6287
Min	.6859	.5716	.5716	.6287
Avg	.7716	.6002	.6002	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572	.0572	.0572	.0572	.0572	.0572
7	.0381	.0381	.0572	.0381	.0381	.0381	.0572
8	.0381	.0381	.0572	.0572	.0381	.0381	.0381
9	.0381	.0381	.0572	.0572	.0381	.0381	.0381
10	.0381	.0572	.0572	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381	.0381
12	.0572	.0381	.0572	.0572	.0381	.0381	.0191
13	.0381	.0381	.0381	.0572	.0572	.0381	.0381
14	.0381	.0381	.0381	.0572	.0572	.0381	.0381
15	.0381		.0381	.0572	.0572	.0381	.0572
16	.0381	.0381	.0381	.0572	.0572	.0381	.0191
17	.0381	.0381	.0381	.0572	.0572	.0381	.0572
18	.0381	.0381	.0381	.0572	.0572	.0381	.0381
19	.0381		.0381	.0572	.0381	.0381	.0381
20	.0381	.0572	.0572	.0572	.0572	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0381	.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0381	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0381
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0191
Avg	.0469	.0485	.0508	.0548	.0516	.0453	.0464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 201 / CIDCO Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763	.381	.2858	.381	.5716	.5716
2	.5716	.4763	.381	.2858	.381	.5716	.5716
3	.5716	.381	.381	.1905	.381	.5716	.5716
4	.4763	.381	.381	.1905	.381	.4763	.381
5		.381	.381	.1905	.2858	.381	.381
6	.381	.2858	.381	.1905	.1905	.381	.381
7	.2858	.2858	.2858	.1905	.1905	.2858	.381
8	.2858	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.2858	.1905
11	.1905	.1905	.1905	.1905	.1905	.2858	.2858
12	.1905	.1905	.1905	.1905	.2858	.2858	.381
13	.2858	.1905		.2858	.2858	.381	.381
14	.381	.2858	.1905	.2858	.2858	.381	.381
15	.381	.2858	.1905	.2858	.381	.381	.381
16	.381	.381	.1905	.2858	.381	.381	.381
17	.381	.381	.1905	.1905	.2858	.381	.381
18	.1905	.2858	.381	.1905	.1905	.2858	.381
19	.381	.381	.2858	.381	.2858	.381	.381
20	.381	.381	.2858	.381	.381	.381	.4763
21	.381	.381	.381	.381	.381	.4763	.4763
22	.4763	.381	.381	.381	.5716	.5716	.5716
23	.4763	.381	.381	.381	.5716	.5716	.5716
24	.5716	.4763	.381	.381	.381	.5716	.5716
Max	.5716	.4763	.381	.381	.5716	.5716	.5716
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.3727	.3255	.2940	.2620	.3175	.4009	.4088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 202 / MIDC Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6668	.5716	.381	.5716	.7621	.6668
2	.7621	.6668	.5716	.2858	.5716	.7621	.6668
3	.7621	.5716	.5716	.2858	.5716	.6668	.6668
4	.6668	.4763	.5716	.381	.5716	.5716	.5716
5	.5716	.4763	.5716	.381	.4763	.4763	.5716
6	.381	.381	.5716	.381	.381	.381	.4763
7	.381	.381	.381	.381	.381	.381	.381
8	.381	.381	.381	.381	.381	.381	.381
9	.381	.381	.381	.381	.381	.381	.381
10	.381	.381	.2858	.381	.381	.381	.381
11	.4763	.381	.2858	.381	.381	.381	.5716
12	.4763	.381	.2858	.381	.4763	.5716	.5716
13	.5716	.381	.381	.4763	.5716	.5716	.5716
14	.5716	.381	.381	.4763	.5716	.5716	.5716
15	.5716	.381	.381	.4763	.5716	.5716	.5716
16	.5716	.381	.381	.4763	.5716	.5716	.5716
17	.5716	.381	.381	.381	.4763	.5716	.5716
18	.381	.381	.381	.381	.381	.381	.381
19	.4763	.381	.381	.5716	.4763	.4763	.381
20	.5716	.381	.381	.5716	.5716	.5716	.6668
21	.5716		.381	.5716	.5716	.6668	.9717
22	.5716	.381	.4763	.5716	.7621	.7621	.7621
23	.6668	.381	.381	.5716	.7621	.7621	.7621
24	.7621	.6668	.5716	.381	.5716	.7621	.7621
Max	.7621	.6668	.5716	.5716	.7621	.7621	.9717
Min	.381	.381	.2858	.2858	.381	.381	.381
Avg	.5517	.4349	.4287	.4287	.516	.5557	.5763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 203 / Satgaon Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	.5716	.7049	.8192	.9145	.8764
2	.7621	.7049	.5716	.6859	.7811	.9145	.8573
3	.724	.7049	.5716	.6668	.7621	.8192	.8383
4	.6668	.6668	.5716	.6287	.7049	.7811	.7811
5	.5906	.5716	.5335	.5906	.6478	.724	.7621
6	.5716	.4763	.4954	.5525	.5906	.6859	.6287
7	.4954	.4191	.4763	.4954	.4954	.5906	.5144
8	.4763	.4382	.4382	.4572	.4763	.5335	.5335
9	.4382	.4191	.4191	.4954	.4954	.4954	.4763
10	.4382	.4191	.381	.4572	.5144	.5525	.5144
11	.4382	.4382	.381	.4763	.5335	.5335	.5716
12	.4572	.4001	.3048	.4954	.5525	.5716	.5906
13	.4572	.4954	.381	.4763	.5525	.5906	.6287
14	.4763	.2477	.381	.4954	.5335	.5716	.6668
15	.5525	.2667	.381	.5144	.5525	.5716	.6478
16	.5525	.2477	.362	.4954	.5716	.5716	.6287
17	.4954	.5144	.2667	.4763	.5335	.5144	.5144
18	.4572	.4382	.4191	.4572	.4954	.4954	.5144
19	.5716	.5716	.6287	.6097	.6668	.5335	.5906
20	.6668	.5716	.6668	.4763	.8573	.724	.8764
21	.7049		.724	.8383	.9526	.8954	.9717
22	.7811	.6097	.724	.8573	.9717	.9526	.9907
23	.7811	.5716	.7049	.8192	.9526	.9335	.9717
24	.8383	.7621	.5906	.724	.8383	.9526	.8954
Max	.8383	.7621	.724	.8573	.9717	.9526	.9907
Min	.4382	.2477	.2667	.4572	.4763	.4954	.4763
Avg	.5914	.5094	.4977	.5811	.6605	.6843	.7018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 201 / 11 KV Dongargaon feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5041		.3921	.4458	.4706	.4854
2		.5041		.3921	.3944	.4572	.4854
3		.5041		.3921	.3429	.4251	.4668
4		.4854		.3734	.3429	.3921	.4481
5		.4481		.3734	.3086	.3734	.4294
6		.4108		.3547	.3086	.3921	.3921
7		.3734		.3361	.3429	.3982	.3921
8		.3734		.3361	.3772	.3881	.4668
9		.4108	.3439	.3174	.3772	.3841	.4108
10	.4287	.4854	.3734	.3086	.3944	.4294	.5041
11	.4481	.5175	.3142	.3086	.4207	.4668	.463
12	.6348	.4525	.3361		.4024		.4801
13	.5041	.4805	.3174	.3258	.4024		.5144
14	.5415	.4207	.3547	.3086	.4938		.5144
15	.5415	.4887	.3547	.3429	.5068		.5487
16	.4481	.5487	.3547	.3944	.5068		.5487
17	.5415	.499	.3361	.463	.4835		.5487
18	.4108	.4435	.3547	.4458	.4656	.4108	.5144
19	.5041	.5487	.3921	.4458	.4298	.4481	.5144
20	.5228	.5487	.4294	.463	.5121	.5228	.4801
21	.5228		.4294	.6687	.5304	.5228	.4801
22	.5415		.4108	.5144	.5068	.5228	.463
23	.5228		.4108	.4801	.4835	.5175	.463
24	.463	.5041		.3921	.4801	.4656	
Max	.6348	.5487	.4294	.6687	.5304	.5228	.5487
Min	.4108	.3734	.3142	.3086	.3086	.3734	.3921
Avg	.5051	.4739	.3675	.3969	.4275	.4438	.4789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 202 / 11 KV Dhuti feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987		.2427	.12	.1829	.2987
2		.2987		.2427	.1029	.1663	.2987
3		.2987		.2241	.1029	.1478	.2987
4		.2801		.2241	.0857	.1478	.2801
5		.2427		.2241	.12	.1463	.2614
6		.1867		.2241	.1372	.1646	.2427
7		.2402		.2427	.1372	.1646	.2427
8		.2241		.1848	.1715	.1063	.2587
9		.2054	.112	.1867	.1372	.2012	.2033
10	.1029	.1867	.112		.1372	.2054	.2218
11	.168	.1463	.0747	.1715	.1928	.1494	.1886
12	.1494	.1629	.0924	.1715	.2103		.2229
13	.168	.1646	.1494	.1543	.197		.2572
14	.1494	.1478	.112	.1372	.197		.2401
15	.1867	.1629	.112	.1543	.1991		.2401
16	.1867	.181	.0934	.1715	.2534		.2229
17	.1867	.181		.1886	.208		.2058
18	.1494	.1991		.0514	.1734	.1848	.2229
19	.2241	.2743	.2241	.0514	.2601	.2427	.2401
20	.2987	.2561	.2614	.0514	.3326	.2801	.2572
21	.2987		.2614		.2481	.3174	.3086
22	.3174		.2241	.0857	.2353	.2987	.2915
23	.2987		.2427	.0857	.2195	.3142	.2915
24	.1372	.2957		.2427	.12	.2012	.2957
Max	.3174	.2987	.2614	.2427	.3326	.3174	.3086
Min	.1029	.1463	.0747	.0514	.0857	.1063	.1886
Avg	.2015	.2207	.1594	.1688	.1791	.2012	.2538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 203 / 11 kv Swapnil Agro

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.056	.0171	.4744	.3921
2		.0187		.0187	.0171	.4744	.3921
3		.0187		.0373	.0171	.4586	.4108
4		.0187		.0187	.0171	.4428	.4066
5		.0187		.0187	.0171	.4428	.4294
6		.0373		.0187	.0171	.4586	.4481
7		.0187		.0187	.0171	.463	.4668
8		.0187		.037	.0171	.4744	.0187
9		.0373	.0171	.0187	.0171	.3321	.0373
10	.0343	.4294	.0187	.0171	.0171	.4294	.3921
11	.4294	.3563	.0373	.0171	.0158	.2957	.4287
12	.4294	.0332	.0187	.0171	.0158		.4115
13	.4525	.0166	.0373	.0171	.0158		.3772
14	.3547	.0166	.0187	.0171	.0316		.3429
15	.4108	.017	.0187	.0171	.0351		.3601
16	.4108	.017	.0187	.0171	.0362		.3772
17	.4108	.0166	.0187	.0171	.0158		.3772
18	.056	.0166			.0158	.0373	.3429
19	.0187	.016	.056		.0158	.3174	.3429
20	.056	.016	.0377		.2846	.3361	.3772
21	.0373		.0373		.3978	.4435	.3772
22	.0187		.0739		.5228	.4435	.3772
23	.0185		.0373		.4586	.3511	.3601
24	.3429	.0187		.0566	.0171	.4586	.4108
Max	.4525	.4294	.0739	.0566	.5228	.4744	.4668
Min	.0185	.016	.0171	.0171	.0158	.0373	.0187
Avg	.2321	.0560	.0319	.0242	.0854	.3963	.3607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 205 / Mohagaon (Gaothan)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934		.0924	.12	.1109	.112
2		.0747		.0934	.1029	.0924	.112
3		.0747		.0924	.1029	.0754	.112
4		.0747		.112	.0857	.0754	.112
5		.0739		.0934	.12	.0943	.112
6		.0747		.112	.1029	.0943	.1109
7		.056		.1294	.1715	.112	.112
8		.112		.1463	.1715	.1663	.2241
9		.1307	.0724	.112	.1029	.2218	.168
10	.1029	.1307	.0373	.1029	.0857	.2054	.1867
11	.1307	.1417	.1494	.1029	.0934	.2241	.1543
12	.1494	.1646	.1494	.1029	.0934		.1715
13	.1509	.1578	.112	.12	.0747		.1715
14	.1494	.1829	.1494	.1372	.0934		.1886
15	.1494	.1448	.1307	.12	.0905		.1886
16	.1867	.1227	.1494	.12	.0943		.1886
17	.1494	.1646	.0934	.1029	.0953		.1886
18	.0934	.2195	.0934		.0953	.0934	.1715
19	.1494	.2378	.1307		.1132	.1663	.1715
20	.1494	.2743	.1307		.2075	.1494	.1886
21	.1494		.1307		.1417	.1663	.1886
22	.1494		.1294		.1307	.1294	.1715
23	.0934		.1109		.1307	.112	.1372
24	.0686	.0924		.0934	.12	.112	.1307
Max	.1867	.2743	.1494	.1463	.2075	.2241	.2241
Min	.0686	.056	.0373	.0924	.0747	.0754	.1109
Avg	.1348	.1333	.1179	.1103	.1142	.1334	.1572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 400 / 33 KV PANJARI(INCOMMER)

Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4003	.3326	1.2323	1.1317	1.8107	4.537
2		1.386	.3326	1.2323	1.0288	1.7541	4.481
3		1.3443	.3361	1.2323	.9259	1.5844	4.369
4		1.3443	.3361	1.2323	.8745	1.5844	4.257
5		1.2883	.3961	1.1763	.9259	1.6575	4.0472
6		1.1643	.3961	1.1203	.9259	1.7147	3.5288
7		1.1088	.4001	1.0642	.9774	1.5203	3.2487
8		1.1203		1.0642	1.0288	1.5432	2.9127
9		1.1763	.9774	.8871	.9774	1.6975	2.7166
10	.9774	1.6804	1.9044	.6687	1.0288	1.7364	3.3265
11	1.6244	1.7558	2.0164	.7716	1.2574	1.6804	3.2407
12	1.6804	1.2752	1.9044	.9259	1.2574		3.3951
13	1.7364	1.1946	1.0082	.9259	1.2003	.5041	3.0864
14	1.6804	1.1946	1.0642	1.0288	1.2574	.4481	3.7037
15	1.7364	1.3032	1.1203	1.0288	1.3014	.5601	3.9609
16	1.8484	1.3717	1.0642	1.1831	1.3575	.5041	4.2696
17	1.8484	1.4266	.8402	1.286	1.4146	.6161	4.6296
18	1.0642	1.4815	1.0082	1.3889	1.3717	1.2323	4.1152
19	1.4563	1.6632	1.2883	1.5432	1.5432	1.7364	3.858
20	1.6244	1.6804	1.3443	1.3889	1.9605	1.9044	4.6296
21	1.5123	.168	1.3443	1.2346	1.9204	2.0165	4.6811
22	1.6244	.2241	1.2883	1.286	1.9004	1.9605	4.5268
23	1.5123	.2801	1.2883	1.2346	1.9433	1.9044	4.3724
24	1.3375	1.4003	.2772	1.2323	1.1317	1.8861	1.9044
Max	1.8484	1.7558	2.0164	1.5432	1.9605	2.0165	4.6811
Min	.9774	.168	.2772	.6687	.8745	.4481	1.9044
Avg	1.5509	1.2264	.9682	1.1404	1.2768	1.4590	3.8249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 402 / 33 KV Dongargaon-VRINDAVAN
i/c Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.3395	.4481	.4115	.4527	.5601
2		.4481	.3395	.4481	.4115	.4527	.5041
3		.4481	.3395	.5041	.3601	.3961	.5041
4		.4481	.3395	.5041	.3601	.4527	.5041
5		.4481	.3961	.5041	.3601	.5093	.4481
6		.3921	.3961	.3921	.3086	.5093	.3921
7		.3921	.3961	.3361	.3086	.3395	.3921
8		.3361		.3361	.4115	.2829	.3921
9			.4527	.2801	.3601	.4527	.3361
10	.3086	.3921	.3921	.2058	.3086	.4481	.3361
11	.3921	.5716	.3921	.3086	.4527	.5601	.3601
12	.3361	.4527	.3361	.3086	.4527		.3601
13	.3921	.3961	.3921	.2058	.4527	.5041	.4115
14	.4481	.4344	.4481	.4115	.3961	.4481	.4156
15	.3921	.5093	.5041	.4115	.4344	.5544	.4115
16	.5658	.5093	.4481	.463	.4344	.5041	.5144
17	.5041	.5658	.3961	.5144	.5658	.6161	.5658
18	.2801	.6224	.3361	.7202	.5658	.5041	.7716
19	.5041	.5658	.5041	.823	.679	.5601	.823
20	.5601	.5658	.4481	.5658	.6224	.6161	1.0288
21	.5041	.1698	.4481	.5144	.5658	.5601	1.0288
22	.5601	.2263	.4481	.5144	.5601	.5601	.9259
23	.5601	.2829	.499	.463	.5093	.5601	.823
24	.3086	.4435	.2829	.4481	.4115	.5093	.5601
Max	.5658	.6224	.5041	.823	.679	.6161	1.0288
Min	.2801	.1698	.2829	.2058	.3086	.2829	.3361
Avg	.4411	.4378	.4032	.4430	.4460	.4936	.5571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 200 / MIHAN STATION T/F
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0179	.0171	.0187		.0175	.0171
2	.0171	.0179	.0171	.0187	.0179	.0175	.0171
3	.0171	.0179	.0171	.0187	.0179	.0175	.0171
4	.0171	.0179	.0171	.0187	.0179	.0171	.0183
5	.0171	.0179	.0171	.0187	.0179	.0171	.0183
6	.0171	.0179	.0171	.0187	.0179	.0171	.0183
7	.0171	.0179		.0187	.0179	.0175	.0183
8	.0171	.0179	.0171	.0187	.0179	.0175	.0373
9	.0171	.0173	.0171	.0177	.0175	.0175	.0171
10	.0179	.0175	.0187	.0179	.0175	.0187	.0187
11	.0179	.0171	.0187	.0179	.0171	.0187	.0187
12	.0179	.0171	.0187	.0179	.0171	.0187	.0187
13	.0179	.0171	.0187	.0179	.0175	.0187	.0187
14	.0179	.0171	.0187	.0179	.0175	.0187	.0187
15	.0179	.0171	.0187	.0179	.0175	.0187	.0187
16	.0179	.0171	.0187	.0179	.0175	.0187	.0187
17	.0179	.0171	.0187	.0179	.0175	.0187	.0187
18	.0179	.0171	.0187	.0179	.0175	.0171	.0187
19	.0179	.0171	.0187	.0179	.0175	.0171	.0187
20	.0179	.0171	.0177	.0179	.0175	.0171	.0187
21	.0179	.0171	.0173		.0175	.0171	.0187
22	.0175	.0171	.0187	.0175	.0175	.0187	.0187
23	.0175	.0171	.0175	.0179	.0175	.0171	.0187
24	.0171	.0177	.0171	.0187	.0179	.0175	.0171
Max	.0179	.0179	.0187	.0187	.0179	.0187	.0373
Min	.0171	.0171	.0171	.0175	.0171	.0171	.0171
Avg	.0175	.0174	.0179	.0182	.0176	.0178	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 201 / Mihan-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4632	.9335	1.307	1.4632	1.5384	1.5546
2	1.4937	1.4266	1.1203	1.1203	1.4266	1.4632	1.5546
3	1.4266	1.4266	1.1203	1.1203	1.3717	1.448	1.4937
4	1.3169	1.3717	1.0974	.9335	1.2803	1.4632	1.4937
5	1.3717	1.2803	1.0974	.9335	1.2803	1.3717	1.4003
6	1.0974	1.2071	.9335	.9335	1.2803	1.0974	1.2136
7	1.1203	.9511		.9335	1.134	1.1765	1.307
8	1.2136	1.0974	.9335	1.1203	1.1706	1.2308	1.307
9	1.2803	1.086	1.0269	1.267	1.3032	1.3032	1.4937
10	1.4998	1.1946	1.0269	1.4266	1.4266	1.4937	1.6975
11	1.7558	1.5546	1.4003	1.6095		1.6804	1.6804
12	1.7924	1.5546	1.307	1.4632	1.6095	1.6804	1.6804
13	1.4632	1.5546	.7468	1.3169	1.7375	1.6804	1.7737
14	1.7924	1.6461	.7468	1.4632	1.7737	1.6804	1.8671
15	1.829	1.5546	1.1203	1.6095	1.7737	1.6804	1.8671
16	1.6461	1.1888		1.6827	1.6651	1.6804	1.8671
17	1.829	1.134	.7468	1.6461	1.5203	1.4937	1.8671
18	1.5364	1.2803	.9335	1.3169	1.5927	1.4632	1.4937
19	1.9204	1.531	1.307	1.7193	1.7013	1.6804	1.9605
20	1.9753	1.6804	1.267	1.6827	1.7924	1.8671	2.0165
21	1.829		1.3032		1.9004	1.8099	2.0165
22	1.6289		1.307	1.6651	2.1719	1.9605	1.6804
23	1.5565	.9335	1.267	1.4998	1.6827	1.8671	1.7737
24	1.4937	1.5364	.9335	1.307	1.448	1.6289	1.6461
Max	1.9753	1.6804	1.4003	1.7193	2.1719	1.9605	2.0165
Min	1.0974	.9335	.7468	.9335	1.134	1.0974	1.2136
Avg	1.5568	1.3479	1.0762	1.3512	1.5437	1.5600	1.6544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 202 / Mihan-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0373	.0373	.0366	.0351	.0373
2	.0373	.0366	.0373	.0373	.0366	.0351	.0373
3	.0366	.0366	.0366	.0373	.0366	.0358	.0373
4	.0366	.0366	.0366	.0373	.0366	.0366	.0373
5	.0366	.0366	.0366	.0373	.0366	.0366	.0366
6	.0366	.0366	.0373	.0373	.0366	.037	.0366
7	.0366	.0366		.0373	.0366	.0351	.0366
8	.0366	.0366	.0366	.0373	.0366	.0351	.0373
9	.0366	.0354	.0362	.0354	.0526	.0343	.0366
10	.0377	.0351	.0373	.0366	.0351	.0373	.0373
11	.0366	.0366	.0373	.0366	.0366	.0373	.0373
12	.0366	.0366	.0373	.0366	.0366	.0373	.0373
13	.0366	.0366	.0373	.0366	.0351	.0373	.0373
14	.0366	.0366	.0373	.0366	.0351	.0373	.0373
15	.0366	.0366	.0373	.0366	.0358	.0373	.0373
16	.0366	.0366	.0373	.0366	.0362	.0373	.0377
17	.0366	.0366	.0373	.0366	.0351	.0373	.0373
18	.0366	.0366	.0373	.0366	.0351	.0366	.056
19	.0366	.0366	.0373	.0366	.0351	.0366	.0373
20	.0366	.0366	.0358	.0366	.0351	.0366	.0373
21	.0366	.0366	.0358		.0354	.0366	.0373
22	.0351	.0373	.0373	.0351	.0351	.0373	.0373
23	.0354	.0366	.0351	.0351	.0351	.0366	.0373
24	.0366	.0362	.0373	.0373	.0351	.0351	.0366
Max	.0377	.0373	.0373	.0373	.0526	.0373	.056
Min	.0351	.0351	.0351	.0351	.0351	.0343	.0366
Avg	.0366	.0365	.0369	.0367	.0365	.0364	.0380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 203 / Mihan-III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.1948	1.7375	1.307	1.6461	2.1948	.0549
2	1.829	2.1216	1.6461	1.307	1.6095	2.1132	.0549
3	1.829	2.0119	1.6461	1.1203	1.5364	2.0119	.0549
4	1.7375	1.829	1.6461	1.1203	1.4998	1.829	.0549
5	1.6827	1.7375	1.6095	1.1203	1.4449	1.7375	.0549
6	1.4632	1.6095	1.2803	1.1203	1.3717	1.6461	.0549
7	1.3717	1.39		1.307	1.3535	1.3717	.0549
8	1.2803	1.2803	1.2803		1.4266	1.3032	.056
9	1.4266	1.3535	1.2803		1.4118	1.4998	.0549
10	1.4632	1.2803	1.4937	.0549	1.6289	1.6804	.056
11	1.5364	1.5546	1.6804	.0549	1.6827	1.6804	.056
12	1.6095	1.6095	1.6804	.0549	1.6461	1.6804	.056
13	1.6461	1.6461	1.6804	.0549	1.7558	1.7737	.056
14	1.7924	1.829	1.6804	.0549	1.7737	1.6804	.056
15	2.0119	1.9753	1.6804	.0549	1.7551	1.6804	.056
16	2.0485	1.9753	1.4937	.0549	1.9004	1.8671	.056
17	2.0119	1.7375	1.307	.0549	1.7737		.056
18	1.5729	1.6461	1.307	.0549	1.7924		.056
19	1.6461	1.6832	1.4937	1.8656	1.8461	.0549	.056
20	1.9753	1.829	1.448	1.829	2.0119	.0549	.056
21	1.9753	1.4632	1.5364		1.949	.0549	.056
22	2.0119	1.4632	1.4937	1.829	2.268	.0566	.056
23	2.1719	1.6461	1.4632	1.9204	2.3777	.0549	.056
24	2.1948	2.2314	1.829	1.4937	1.829	2.1948	.0549
Max	2.1948	2.2314	1.829	1.9204	2.3777	2.1948	.056
Min	1.2803	1.2803	1.2803	.0549	1.3535	.0549	.0549
Avg	1.7625	1.7124	1.5389	.8492	1.7205	1.3737	.0556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 205 / Mahindra Boomdale

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0549	.0549	.056	.0549	.0532	.0549
2	.0549	.0549	.0549	.056	.0549	.0537	.0549
3	.0549	.0549	.0549	.056	.0549	.0543	.0549
4	.0549	.0549	.0549	.056	.0549	.0549	.0549
5	.0549	.0549	.0549	.056	.0549	.0549	.0549
6	.0549	.0549	.0366	.056	.0549	.0554	.0549
7	.0549	.0549		.056	.0549	.0724	.0549
8	.0549	.0549	.0549	.056	.0549	.0526	.056
9	.0549	.0526	.0549	.0526	.0526	.0526	.0549
10	.0549	.0526	.056	.0549	.0526	.056	.056
11	.0549	.0549	.056	.0549	.0549	.056	.056
12	.0549	.0549	.056	.0549	.0549	.056	.056
13	.0549	.0549	.056	.0549	.0532	.056	.056
14	.0549	.0549	.056	.0549	.052	.056	.056
15	.0549	.0549	.056	.0549	.0526	.056	.056
16	.0549	.0549	.056	.0549	.0543	.056	.056
17	.0549	.0549	.056	.0549	.0543	.056	.056
18	.0549	.0549	.056	.0549	.0543	.0549	.056
19	.0549	.0549	.056	.0549	.0526	.0532	.056
20	.0549	.0549	.0537	.0549	.0526	.0549	.056
21	.0549	.0549	.0537		.0526	.0549	.056
22	.0543	.0549	.056	.0526	.0526	.0566	.056
23	.0532	.0549	.0526	.0543	.0532	.0549	.056
24	.1097	.0526	.0549	.056	.0554	.0526	.0549
Max	.1097	.0549	.056	.056	.0554	.0724	.056
Min	.0532	.0526	.0366	.0526	.052	.0526	.0549
Avg	.0571	.0546	.0544	.0551	.0539	.0556	.0556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 200 / S/STN TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3921	.2743	.3921	.3921	.3841	.3921
2	.3921	.3921	.2743	.3921	.3921	.3841	.3921
3	.3921	.3921		.168	.3921	.3841	.3921
4	.3921	.3921	.3841	.3921	.3921	.3841	.3921
5	.3921	.3921	.3841	.2801	.3921	.3841	.3921
6	.3921	.2801	.2743	.2801	.2801	.3292	.3921
7	.2801	.2801	.2743	.2801	.2801	.2743	.2801
8	.2801	.2801	.2743	.2801	.2801	.2743	.2801
9	.2801	.2801	.3921	.2801	.2801	.2743	.2801
10	.2801	.2743	.3921	.2801	.2801	.2801	.2801
11	.2801	.2743	.2801	.2801	.2743	.2801	.2801
12	.2801	.2743	.2801	.2801	.2743	.2801	.2801
13	.2801	.2743	.2801	.2801	.2743	.2801	.2801
14	.2801	.2743	.2801	.2801	.2743	.2801	.2801
15	.2801	.2743	.2801	.2801	.2743	.2801	.2801
16	.2801	.2743	.2801	.2801	.2743	.2801	.2801
17	.2801	.2801	.2801	.2801	.2743	.2801	.2801
18	.2801	.2801	.2801	.2801	.2743	.2801	.2801
19	.2801	.2801	.2801	.2801	.2743	.2801	.2801
20	.3921			.3921	.3841	.3921	.3921
21	.3841	.3921		.3921	.3841	.3921	.3921
22	.3921	.3921		.3921	.3841	.3921	.3921
23	.3921	.3841	.3921	.3921	.3841	.3921	.3921
24	.3921	.3921	.3841	.3921	.3921	.3841	.3921
Max	.3921	.3921	.3921	.3921	.3921	.3921	.3921
Min	.2801	.2743	.2743	.168	.2743	.2743	.2801
Avg	.3311	.3218	.3111	.3128	.3233	.3261	.3314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 201 / SANDESH CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.0549	.0373	.0373	.0549	.056
2	.056	.056	.0914	.0373	.0373	.0549	.056
3	.0373	.056	.0549	.0373	.0373	.0549	.056
4	.0373	.056	.0549	.0373	.0373	.0366	.0373
5	.0373	.0373	.0366	.0373	.0373	.0549	.0373
6	.0373	.0373	.0366	.0373	.0373	.0366	.0373
7	.0373	.0373	.0366	.0373	.0373	.0366	.0373
8	.056	.0373	.0183	.0373	.0373	.0366	.0373
9	.0373	.056	.0373	.0373	.0373	.0366	.056
10	.0187	.0366	.0373	.0373	.056	.0373	.056
11	.0373	.0366	.0373	.0373	.0366	.0373	.0373
12	.0187	.0366	.0373	.0373	.0366	.0373	.0373
13	.0181	.0366	.0373	.0187	.0366	.0373	.0373
14	.0187	.0366	.0373	.0373	.0183	.0373	.0373
15		.0366		.0373	.0366	.0373	.0373
16		.0366	.0373	.0373	.0366	.0373	.0373
17		.0373	.0187	.0373	.0366	.0373	.0373
18		.0373	.0187	.0187	.0366	.0187	.0187
19		.056	.0373	.0373	.0366	.0373	.0187
20	.056			.0373	.0366	.0373	.0373
21	.0549	.0373		.056	.0366	.056	.056
22	.056	.0373		.0373	.0549	.056	.056
23	.056	.0549	.0373	.056	.0549	.056	.056
24	.056	.056	.0366		.056	.0549	.056
Max	.056	.056	.0914	.056	.056	.056	.056
Min	.0181	.0366	.0183	.0187	.0183	.0187	.0187
Avg	.0412	.0435	.0397	.0373	.0392	.0424	.0428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 202 / JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3921	.3658	.2614	.3547	.2743	.4108
2	.3734	.3921	.3658	.2614	.3547	.2561	.3921
3	.3734	.3734	.3475	.2614	.3547	.2561	.3921
4	.3361	.3547	.3292	.2427	.3547	.2378	.3921
5	.3361	.3547	.3109	.2427	.3547	.2378	.3547
6	.2801	.3547	.2926	.2427	.3174	.2378	.3547
7	.2801	.2987	.2926	.2427	.3174	.2561	.2801
8	.2614	.2987	.2743	.2241	.2987	.2378	.2427
9	.3174	.2801	.3361	.2241	.2987	.2561	.2614
10	.3174	.3292	.2614	.2054	.2427	.3361	.2614
11	.2987	.3475	.2614	.2801	.2378	.2987	.2241
12	.2241	.3658	.2054	.2427	.2195		.4294
13	.2427	.3109	.2427	.2614	.3109	.2987	.3921
14	.2241	.2926	.2241	.2614	.1646	.2427	.3547
15	.2801	.3109		.1867	.2561	.2054	.5415
16	.3734	.3475	.2987	.3921	.3292	.2801	.7095
17	.4163	.3734	.2801	.3921	.3658	.4294	.8962
18	.3921	.3921	.2987	.4294	.439	.4481	.9709
19	.5228	.4481	.3361	.4854	.4572	.4481	.8215
20	.4668			.4481	.4572	.4668	.9149
21	.4481	.2614		.4481	.439	.4668	.8589
22	.4294	.2801		.4294	.4207	.4294	.8589
23	.4108		.3734	.3921	.0549	.4294	.7468
24	.2801	.4108	.2926	.3361	.3734	.3841	.4294
Max	.5228	.4481	.3734	.4854	.4572	.4668	.9709
Min	.2241	.2614	.2054	.1867	.0549	.2054	.2241
Avg	.3449	.3441	.2995	.3081	.3239	.3223	.5205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 200 / SUB STATION T/F

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)
1	.0191	
2	.0191	
3	.0191	
4	.0191	
5	.0191	
6	.0191	
7	.0191	
10	.0191	
17		.0191
18		.0191
19		.0191
22		.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 201 / 11 KV C ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4527	.4001	.4572	.4904	.4572	.3239
2	.4954	.4338	.3429	.4191	.4715	.4763	.3429
3	.4954	.4338	.3429	.381	.4904	.4382	.3429
4	.4572	.415	.362	.381	.4904	.4001	.3239
5	.4572	.415	.3429	.4191	.4904	.381	.3429
6	.4572	.3961	.362	.381	.4904	.362	.3239
7	.4191	.4527	.381	.381	.4904	.362	.3239
8	.4338	.4527	.4001	.4572	.5281	.3429	.4001
9	.5847	.5658	.5144	.6287	.6979	.362	.5525
10	.7049	.7922	.7049	.7621	.7167	.3239	.5716
11	.7733	.7811	.6668	.811	.7545	.3048	.7733
12	.6979	.7049	.6097	.6602	.7621	.3048	
13	.5093	.6478	.724	.6036	.724	.3048	.6602
14	.5847	.6859	.7621	.6602	.7049	.3048	.6979
15	.679	.8192	.8002	.8488	.8002	.3239	.7733
16	.7167	.724	.7049	.7545	.7621	.3239	.8865
17	.679	.6287	.5906	.6979	.6287	.3239	.8002
18	.6413		.4572	.6602	.5525	.3239	.6668
19	.4527	.4763	.4763	.415	.5335	.3239	.5335
20	.3961	.5525	.4191	.4715	.4954	.3239	
21	.415	.3429	.381	.4338	.4763	.3429	.5093
22	.3961	.4001	.4572	.4715	.5144	.3429	.4572
23	.4527	.5144	.4572	.4715	.4763	.362	.5281
24	.4904	.4527	.3429	.4191	.4715	.4572	.3239
Max	.7733	.8192	.8002	.8488	.8002	.4763	.8865
Min	.3961	.3429	.3429	.381	.4715	.3048	.3239
Avg	.5369	.5452	.5001	.5436	.5839	.3572	.5209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 202 / 11 KV D ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.4146	1.448	1.1431	1.2826	1.3717	.8954
2	1.5242	1.3769	1.4098	1.086	1.2637	1.2765	.8573
3	1.4289	1.3392	1.4861	1.0479	1.226	1.2574	.9526
4	1.4289	1.3203	1.448	1.1431	1.2071	1.2765	.8954
5	1.4289	1.3014	1.5051	1.0479	1.2071	1.2955	.8573
6	1.4289	1.4523	1.5813	1.086	1.358	1.3146	.8192
7	1.5242	1.8296	1.6194	1.105	1.4712	1.105	.7811
8	1.9616	1.9805	1.4861	1.4289	1.0374	1.2574	1.0479
9	2.2822	2.2257	1.8099	1.4861	1.8484	1.2193	1.4289
10	2.3624	2.5086	1.9433	1.8099		1.5623	1.848
11	2.4897	2.4387	1.8099	1.773	1.6032	1.3717	1.7918
12	2.5274	2.5911	1.6575	1.7541	2.191	1.448	1.8296
13	2.1879	2.2672	1.9433	1.6598	2.0957	1.5051	
14	2.3011	2.3434	2.0386	1.7164	2.4006	1.6575	1.5466
15	2.32	2.1148	2.1529	1.6598	2.6673	1.6385	1.5466
16	2.3577	2.1529	1.7718	1.7541	.8954	1.3336	1.4901
17	2.0182	1.2955	1.4098	1.6787	1.829	1.1622	1.4289
18	1.7918	1.6575	1.2003	1.5844	2.1529	.9526	1.4098
19	1.8673	1.8099	1.3908	1.5466	2.2481	1.0288	1.5432
20	1.5089	1.6385	1.2003	1.3957	.6478	.9526	
21	1.5278	1.2955	1.0669	1.5278	1.0098	.7621	1.3769
22	1.3014	1.5813	.9907	1.5466	1.1622	.8002	1.3908
23	1.5089	1.4861	1.1431	1.5089	1.2955	1.0479	1.3957
24	1.5089	1.4523	1.5051	1.105	1.3203	1.3336	.8383
Max	2.5274	2.5911	2.1529	1.8099	2.6673	1.6575	1.848
Min	1.3014	1.2955	.9907	1.0479	.6478	.7621	.7811
Avg	1.8380	1.7864	1.5424	1.4415	1.5400	1.2471	1.2714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 205 / 11 KV FOOD PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0374	1.0669	1.2765	1.226	.9907	.8573
2	.9526	1.0374	1.0669	1.1431	1.1506	1.086	.8573
3	.9526	.9997	1.0479	1.1812	1.0374	1.0479	.8764
4	.9145	.9997	1.0288	1.105	.9997	1.0098	.8573
5	.8764	.9997	1.0098	1.0479	.9619	.9907	.8954
6	.8764	.9808	.9907	1.086	.9619	.8573	.9526
7	.9526	1.0185	1.0098	1.105	1.0374	.7811	1.0669
8	1.2449	1.2071	1.0669	1.5623	1.3392	.8954	1.2765
9	1.6221	1.3769	1.2765	1.6575	1.6032	.8954	1.467
10	1.8861	1.8673	1.6766	1.7718	1.6221		1.5432
11	1.7918	1.6766	1.7528	1.8296	1.7164	.0953	1.6409
12	1.6975	1.7909	1.7337	1.9805	1.7718	.4954	1.6975
13	1.7164	1.7528	1.6385	1.9239	1.6956	.7811	1.7918
14	1.5844	1.7718	1.8099	1.905	1.7147	1.0098	1.8107
15	1.773	1.6766	1.848	1.8107	1.9433	.8764	1.7353
16	1.773	1.7718	1.8671	1.8107	1.6004	1.0479	1.8296
17	1.8484	1.7147	1.7147	1.8296	1.8099	1.0098	1.848
18	1.7164	1.6575	1.6385	1.7164	1.5623	1.086	1.829
19	1.4901	1.6194	1.7909	1.6598	1.4098	1.0098	1.5623
20	1.358	1.4289	1.6194	1.4335	1.2955	1.0288	
21	1.4901	1.4289	1.5242	1.4712	1.448	.9907	1.358
22	1.4335	1.3908	1.6385	1.4335	1.2003	.9526	1.4098
23	1.1694	1.3336	1.5623	1.2449	1.2003	.8764	
24	1.094	1.0562	1.105	1.5242	1.2826	1.0479	.8954
Max	1.8861	1.8673	1.8671	1.9805	1.9433	1.086	1.848
Min	.8764	.9808	.9907	1.0479	.9619	.0953	.8573
Avg	1.3851	1.3998	1.4368	1.5212	1.3996	.9071	1.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 206 / 11 KV T ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6602	.7049	.7049	.6602	.743	.2477
2	.6097	.6413	.7049	.6668	.6413	.6478	.2286
3	.5716	.6224	.6859	.5716	.6413	.6668	.2286
4	.5716	.6036	.6668	.5144	.6224	.6859	.2286
5	.5716	.5847	.6287	.5335	.6224	.724	.2477
6	.5716	.5847	.5906	.4763	.5847	.6668	.2286
7	.5906	.5847	.5716	.4954	.547	.5906	.2477
8	.6979	.5658	.4954	.5144	.6224	.3239	.3239
9	.8299	.679	.724	.6478	.7356	.3239	.5335
10	1.105	.9242	.9145	.7811	.9619	.3239	.8764
11	1.094	1.1431	.8573	.811	.9808	.3429	.9808
12	1.0185	1.7909	.8192	.811	.8573	.2858	.7922
13	.9054	.8573	.8192	.6979	.9335	.2858	.8676
14	1.0374	.5906	.8573	.8299	.8954	.3048	.7922
15	1.1317	1.0288	.8954	.8299	1.0288	.0953	.8299
16	1.0185	.9335	.8002	.7545	.9335	.2858	.8299
17	1.1128	.5144	.9145	.8676	1.2003	.2667	.8002
18	1.0374	.8002	.8192	.8676	.8383	.2667	.7049
19	.8299	.7811	.724	.6602	.6668	.2667	.6097
20	.811	.7811	.7049	.6979	.6668	.2858	.4527
21	.8488	.9145	.6859	.6979	.7049	.2667	.5281
22	.6602	.7621	.743	.7167	.743	.2667	.4954
23	.5658	.5906	.6478	.6036	.5716	.2096	.3772
24		.679	.8002	.6859	.6979	.6097	.2667
Max	1.1317	1.7909	.9145	.8676	1.2003	.743	.9808
Min	.5658	.5144	.4954	.4763	.547	.0953	.2286
Avg	.8174	.7757	.7406	.6849	.7649	.4057	.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 200 / S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1128	.1097	.1097	.1097	.1097	.1113	.1097
2	.1128	.1097		.1097	.1097	.1097	.1097
3	.1128	.1097	.1097	.1097	.1097	.1052	.1158
4	.1128	.1097	.1097	.1097	.1097	.1052	.1158
5	.1128	.1097	.1097	.1097	.1097	.1097	.1158
18				.1128			
19			.1158	.1128	.1067		
20	.1097	.1128	.1158	.1128	.1189	.1097	.1113
21	.1097			.1128	.1204	.1097	.1113
22	.1097		.1097	.1097	.1189	.1097	.1052
23	.1097	.1097	.1097	.1372	.1174	.1097	.1052
24		.1097	.1097	.1097	.1143		.1097
Max	.1128	.1128	.1158	.1372	.1204	.1113	.1158
Min	.1097	.1097	.1097	.1097	.1067	.1052	.1052
Avg	.1114	.1101	.1111	.1130	.1132	.1089	.1110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 201 / VRINDAVAN FEEDER NO. I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0448	.0709	.0566	.0523	.0411	.0541	.0717
2	.0429	.0635	.0528	.0504	.0411	.0485	.0698
3	.0467	.056	.0509	.0504	.0541	.0411	.0604
4	.0467	.0509	.0472	.0485	.053	.0373	.0528
5	.0485	.0472	.0472	.0467	.0579	.0411	.0453
6	.0485	.0528	.0472	.0467	.0504	.0336	.0415
7	.0392	.0434	.0453	.0429	.0392	.0355	.0472
8	.0448	.0396	.0415	.0355	.0373	.0373	.049
9	.0597	.0566	.0453	.0467	.0467	.0822	.0604
10	.0672	.0717	.0566	.0523	.0485	.0803	.083
11	.0998	.1043	.049	.0485	.0616	.0952	.1075
12	.1109	.1097	.0528	.0635	.0766	.084	.1169
13	.1083	.0914	.056	.0672	.099	.0887	.1151
14	.0887	.0805	.0709	.0672	.1008	.0981	.1207
15	.0869	.075	.0822	.0691	.099	.0943	.1188
16	.0998	.0914	.0747	.0672	.1008	.1075	.1283
17	.1008	.0695	.0597	.0822	.1008	.1019	.1037
18	.0523	.0914	.0523	.0691	.0896	.0859	.083
19	.0803	.0868	.056	.0803	.0934	.0859	.0943
20	.0709	.0792	.0672	.0597	.0859	.0747	.0773
21	.0803		.0653	.0766	.0766	.0717	.0717
22	.084		.0597	.0766	.0747	.083	.0905
23	.0878	.0622	.056	.0747	.0709	.0773	.083
24		.084	.0604	.0541	.0635		.0754
Max	.1109	.1097	.0822	.0822	.1008	.1075	.1283
Min	.0392	.0396	.0415	.0355	.0373	.0336	.0415
Avg	.0713	.0717	.0564	.0595	.0693	.0713	.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 203 / VRINDAVAN FEEDER NO. III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0717	.0647	.0384	.0439	.0695	.0658	.0672
2	.0736	.0665	.0384	.0421	.0732	.0622	.0635
3	.083	.0622	.0402	.0421	.075	.0713	.0653
4	.083	.0604	.0384	.0402	.0713	.0768	.0709
5	.0868	.0677	.0549	.0549	.0732	.0805	.0747
6	.0849	.075	.0713	.064	.0768	.0732	.0784
7	.0604	.0688	.0512	.0549	.064	.0658	.0747
8	.0472	.0507	.053	.0476	.0439	.0457	.0467
9	.0392	.0362	.0604	.0494	.0494	.086	.0467
10	.0415	.0507	.0604	.0494	.0512	.0604	.0429
11	.0784	.067	.0677	.0494	.0512	.0549	.084
12	.0504	.0742	.064	.0512	.053	.0805	.0747
13	.0485	.067	.0622	.0512	.053	.1039	.0728
14	.0672	.0652	.0622	.053	.0585	.0806	.0766
15	.0784	.0615	.0585	.0549	.0786	.0752	.0934
16	.1139	.0841	.0549	.0658	.086		.112
17	.0739	.0604	.0439	.0658	.0768	.0681	.084
18	.0277	.0329	.0402	.0457	.0622	.0681	.0485
19	.0739	.0501	.0457	.0402	.0476	.0615	.0635
20	.0499	.0579	.0494	.0457	.0512	.0537	.0504
21	.0462		.0457	.0439	.0567	.056	.0504
22	.0499		.0402	.0439	.0457	.0411	.0467
23	.048	.038	.0457	.0549	.0494	.0485	.0523
24		.0554	.0384	.0457	.053		.0728
Max	.1139	.0841	.0713	.0658	.086	.1039	.112
Min	.0277	.0329	.0384	.0402	.0439	.0411	.0429
Avg	.0642	.0598	.0511	.0500	.0613	.0673	.0672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 201 / 11KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4801	.3772	.3429	.4115	.4287	.4973
2	.4287	.4801	.3601	.3086	.3944	.4287	.463
3	.4287	.463	.3601	.3086	.3429	.4115	.4287
4	.3944	.4458	.3429	.2572	.3086	.4115	.4287
5	.3772	.4458	.3258	.2401	.3086	.4115	.3944
6	.3601	.2743	.3086	.2058	.2743	.3258	
7	.3086	.2743	.3086	.2229	.2401	.3086	.3258
8	.4115		.3258	.2401	.2743	.3258	.5316
9	.4287	.3086	.3258	.2743	.2743	.4287	.6516
10	.4458	.3429	.3944	.3086	.3772	.4801	.6859
11	.4287	.3601	.3429	.2915	.3601	.463	.6173
12	.4287	.2915	.3258	.3429	.3258		
13	.4458	.2915	.3258	.3258	.3429		.6001
14	.4287	.2774	.3086	.3429	.3429		.6687
15	.4458		.3086	.3429	.3258		.6173
16	.4801	.3988	.2915	.3086	.3258		.6173
17	.4801		.2915	.2915	.2915		.6687
18	.3772		.2713	.2572	.2915		.583
19	.3772		.3086	.2915	.2915	.463	.4973
20			.3601	.3258	.4115	.5658	.5487
21				.4287	.463	.5487	.5144
22	.5144		.3944	.4458	.4458	.5487	.5487
23	.5316		.3772	.4458	.463	.5144	.5487
24	.4973	.4973		.3429	.4115	.463	.5144
Max	.5316	.4973	.3944	.4458	.463	.5658	.6859
Min	.3086	.2743	.2713	.2058	.2401	.3086	.3258
Avg	.4318	.3754	.3334	.3122	.3458	.4428	.5433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 202 / Kanholibara - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029		.0857	.0686	.0686	.1029	.1029
2	.0857		.0857	.0686	.0686	.1029	.0857
3	.0857	.0857	.0686	.0514	.0514	.1029	.0686
4	.0686	.0857	.0686	.0514	.0514	.0857	.0686
5	.0514	.0857	.0686	.0343	.0514	.0857	.0686
6	.0514	.0686	.0514	.0343	.0514	.0343	.0514
7	.0514	.0514	.0514	.0514	.0514	.0343	.0514
8	.0514	.0343	.0514	.0343	.0514	.0343	.0343
9	.0686	.0343	.0514	.0514	.0343	.0343	.0857
10	.12	.0343	.0514	.0343	.0343	.0686	.0857
11	.0514	.0514	.0514	.0343	.0343	.0514	.0857
12		.0497	.0514	.0514	.0343		
13	.0514	.0671	.0514	.0514	.0343		.1029
14	.0857	.0655	.0686	.0514	.0514		.1029
15	.0857		.0514	.0514	.0514		.0857
16	.0857	.0819	.0514	.0686	.0686		.0686
17	.0686		.0514	.0514	.0514		.0514
18	.0514		.0514	.0343	.0514		.0514
19	.0686		.0686	.0686	.0514		.0686
20			.0857	.0857	.0857	.1029	.0857
21			.0857	.1029	.1029	.1029	.1029
22	.1029		.0857	.1029	.1029	.1029	.12
23	.1029		.0857	.0857	.1029	.1029	.12
24	.1029	.1029		.0857	.0686	.1029	
Max	.12	.1029	.0857	.1029	.1029	.1029	.12
Min	.0514	.0343	.0514	.0343	.0343	.0343	.0343
Avg	.0759	.0642	.0641	.0586	.0586	.0782	.0795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 203 / 11 KV GUMGAON - SPARE- SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	.8817	.6783	.6783	.763	.9496	1.0682
2	.9835	.8478	.6443	.6443	.7291	.9156	1.0174
3	.9326	.8139	.5935	.5765	.6443	.8987	.9835
4	.8478	.7969	.5765	.5765	.6443	.8817	.9326
5	.763	.78		.5144	.6274	.8817	.8478
6	.6952	.5935	.4748	.4458	.6274	.7122	.78
7	.5426	.5256	.4409	.463	.5765	.5935	.7461
8	.5935	.6443	.5426	.4409	.6274	.6783	.8139
9	.5426	.5426	.5596	.4917	.6104	.6613	.8166
10	.5935	.5426	.5087	.5256	.6443	.763	.9156
11	.6783	.6783	.5087	.5596	.6443	.7291	.8478
12	.6443	.6443	.5426	.4578	.6613	.763	
13	.7461	.6706	.5935	.4239	.6274	.763	1.0852
14	.7969	.6706	.6443	.373	.6274		1.153
15	.7969		.6001	.4578	.6274		1.1191
16	.7969		.5256	.6274	.6783		
17	.8309		.5087	.5596	.6613		
18	.5935		.4578	.5765	.5765	.7716	
19	.6104		.6443	.6952	.6783	.8478	.7291
20			.6783	.7969	.9326	.9665	1.0513
21			.7291	.9156	.9835	1.1022	1.1869
22	.9665		.7291	.9156	1.0513	1.1022	1.2209
23	.9496		.7122	.8817	1.0174	1.0852	1.1869
24	1.0682	.9156		.6783	.8478	1.0004	1.0631
Max	1.0682	.9156	.7291	.9156	1.0513	1.1022	1.2209
Min	.5426	.5256	.4409	.373	.5765	.5935	.7291
Avg	.7723	.7032	.5861	.5948	.7129	.8533	.9783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 205 / 11 KV NARAYANA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0572			
9		.0572		.1143	
10		.0572	.1334	.1143	.1143
11		.1143	.1143		.1143
12		.1334			.0762
13			.1143		
14	.1143		.1143	.1143	
15			.1143	.1143	
16			.1143	.1143	
17			.1143	.1143	
Max	.1143	.1334	.1334	.1143	.1143
Min	.1143	.0572	.1143	.1143	.0762
Avg	.1143	.0839	.1170	.1143	.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 206 / R.R.R Water works Boregaon NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0381	.0381		.0381
2	.0381	.0381		.0377	.0381		.0381
3	.0381	.0381		.0381	.0381		.0381
4	.0381	.0381		.0381	.0381		.0381
5	.0381	.0381		.0381	.0381		.0381
6	.0381	.0381		.0381	.0381		.0381
7	.0381	.0381		.0381	.0381		.0381
8	.0381	.0381		.0381	.0381		.0381
9	.0381	.0381		.0381			.0381
10	.0381	.0381		.0381	.0381		.0381
11	.0381	.0381		.0381	.0381		.0381
12	.0381			.0381	.0381		
13	.0381		.0381	.0381			
14		.0381	.0381				.0381
15			.0381	.0381			.0381
16			.0381	.0381			.0381
17	.0381		.0381	.0381			.0381
18	.0381		.0381	.0381		.0381	.0381
19	.0381		.0381	.0381		.0381	.0381
20			.0381	.0381		.0381	.0381
21			.0381	.0381		.0381	.0381
22	.0381		.0377	.0381		.0381	.0381
23	.0381		.0377	.0381		.0381	.0381
24	.0381	.0381		.0381	.0381		.0381
Max	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0377	.0377	.0381	.0381	.0381
Avg	.0381	.0381	.0380	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 207 / 11 KV Industrial Sawangi SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715		.1905	.1905	.1905	.1715
2	.1905	.1715		.1715	.1715	.1905	.1905
3	.1715	.1715		.1715	.1715	.1905	.1905
4	.1715	.1715		.1715	.1715	.1905	.1905
5	.1715	.1715		.1715	.1905	.1905	.1905
6	.1715	.1905		.1715	.2096	.1905	.1905
7	.1905	.1524		.1905	.2096	.1905	.1715
8	.2477	.1905		.2641	.2477	.1905	.2286
9	.2096	.2286		.3429	.3429	.4954	.4763
10	.5144	.2286		.8764	.7811	.6668	1.0669
11	.7621	1.0098	.7621	.8002	.8002	.8573	.9526
12	.7621	.8002	.7621	.6097	.6287	.6097	
13	.381	.6668	.4191	.3429	.4001		.381
14	.4763	.3429	.6097	.4191	.9526		.2477
15	.2477		.6413	.9145	.9335		.5906
16	.8002		1.6385	.9145	1.0669		.4954
17	.5906		.4954	.8573	.9717	1.0669	.4763
18	.5525		.4572	.4763	.8002		.2286
19	.7811		.4572	.2858	.8192	.9907	.5906
20			.381	.5525	.4572	.6097	.4954
21			.2286	.9335	.3048	.1905	.1905
22	.1715		.2286	.4191	.5716	.2286	.1905
23	.1715		.2096	.381	.362	.2286	.1905
24	.1905	.1715		.2096	.1905	.362	.2096
Max	.8002	1.0098	1.6385	.9335	1.0669	1.0669	1.0669
Min	.1715	.1524	.2096	.1715	.1715	.1905	.1715
Avg	.3689	.3226	.5608	.4516	.4977	.4121	.3612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 208 / 11 KV Jagruteshwar

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4668	.1307			.3734	.4108
9	.3921	.3174	.4481		.4668	.3734
10	.4294	.3174	.4481	.2987	.2241	.2987
11	.4668	.2987	.2614	.4108	.4481	.3734
12	.4854	.3881	.4294	.2987	.2987	
13		.3326			.2987	
14			.2801			
15	.4481		.4668	.3734		.2241
16	.3174		.3361	.2987		.2241
17	.2427			.1867		
18			.4481	.3921	.3734	.3734
19	.2241					
Max	.4854	.3881	.4668	.4108	.4668	.4108
Min	.2241	.1307	.2614	.1867	.2241	.2241
Avg	.3859	.2975	.3898	.3227	.3547	.3254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 402 / 33 KV Abhijit MADC

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1143	.1143
2	.1143	.1143	.1143	.1143	.1143	.1143	.1143
3	.1143		.1143	.1143	.1143	.1143	.1143
4	.1143	.1143	.1143	.1143	.1143	.1143	.1143
5	.1143		.1143	.1143	.1143	.1143	.1143
6	.1143		.1143	.1143	.1143	.1143	.1143
7	.1143	.1143	.1143	.1143	.1143	.1143	.1143
8	.1143	.1143	.1143	.1143	.1143	.1143	.1143
9	.1143	.1143	.1143	.1143	.1143	.1143	.1143
10	.1143	1.1431	.1143	.1143	.1143	.1143	.1143
11	.1143	1.4289	.1143	.1143	.1143	.1143	.1143
12	.1143	1.6575	.1143	.1143	.1143	.1143	
13	.1143	1.6004	.1143	.1143	.1143	.1143	.1143
14	.1143	1.5432	.1143	.1143	.1143		.1143
15	.1143			.1143	.1143		.1143
16	.1143	.1143	.1143	.1143	.1143		.1143
17	.1143		.1143	.1143	.1143	.1143	.1143
18	.1143		.1143	.1143	.1143	.1143	.1143
19	.1143		.1143	.1143	.1143	.1143	.1143
20			.1143	.1143		.1143	.1143
21			.1143	.1143	.1143	.1143	.1143
22	.1143		.1143	.1143	.1143	.1143	.1143
23	.1143		.1143	.1143	.1143	.1143	.1143
24	.1143	.1143		.1143	.1143	.1143	.1143
Max	.1143	1.6575	.1143	.1143	.1143	.1143	.1143
Min	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Avg	.1143	.6375	.1143	.1143	.1143	.1143	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 201 / 11 kV Mohagaon Ag Sep

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1326	.0995	.0332	.0647	.1159	.116
2	.0838	.1196	.0995	.0332	.0647	.3146	.1147
3	.0838	.118	.0829	.0332	.0647	.1159	.116
4	.0838	.116	.0829	.0332	.0647	.1324	.116
5	.0838	.1147	.0829	.0332	.0647	.1492	.1147
6	.0838	.116	.0829	.0332	.0647	.1658	.0983
7	.0838	.081	.0829	.0332	.0647	.1658	.0655
8	.2012	.1326	.0829	.0332	.0971	.1159	.3018
9	.2515	.1492	.116	.0332	.0485	.1159	.4409
10	.285	.1326	.0829	.0332	.0485	.0662	.407
11	.2652	.1492	.0663		.0331	.0819	.3964
12	.2652	.1326	.0663	.0485	.0659	.0819	.3969
13	.285	.0995	.0663	.0971	.0496	.0829	.413
14	.2515	.116	.0663	.0971	.0661	.0995	.3964
15	.2321	.0995	.0663	.0809	.0661	.0983	.3799
16	.0819	.0663	.0497	.0647	.0661	.0819	.0658
17	.0819	.0663	.0497	.0647	.0496	.0663	.0658
18	.0983	.0497	.0829	.0647	.0661	.0655	.0822
19	.1326	.0995	.0995		.0827	.0995	.1151
20	.126	.0995		.0809	.1158	.1425	.148
21	.121	.0995		.0809	.1158	.1492	.148
22	.1177	.1294		.0809	.1324	.1409	.148
23	.116	.116		.0809	.1324	.1359	.148
24	.1311	.1326	.116	.0332	.0971	.1159	.116
Max	.285	.1492	.116	.0971	.1324	.3146	.4409
Min	.0819	.0497	.0497	.0332	.0331	.0655	.0655
Avg	.1512	.1112	.0812	.0548	.0744	.1208	.2046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 202 / 11 kV Hingna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.97	1.8656	1.5139	1.3253	1.5565	1.8023	1.957
2	1.8625	1.7924	1.4779	1.2894	1.4842	1.7122	1.9204
3	1.8088	1.7193	1.4419	1.2536	1.448	1.6221	1.8473
4	1.6118	1.5746	1.3698	1.2357	1.3575	1.55	1.7558
5	1.5402	1.4842	1.2977	1.1999	1.3032	1.4779	1.5927
6	1.2894	1.3756	1.2076	1.1641	1.2308	1.3878	1.5023
7	1.2178	1.1765	1.1355	1.1641	1.1971	1.2436	1.3213
8	1.1104	1.1403	1.0453	1.0566	1.1245	1.1535	1.2127
9	1.1283	1.086	1.0273	1.0924	1.1765	1.2076	1.3032
10	1.1641	1.1222	1.0273	1.1462	1.1584	1.2256	1.267
11	1.267	1.1163	1.0208	1.174	1.2436	1.2851	1.5139
12	1.3394	1.2076	1.0745	1.2101	1.2616	1.3575	1.55
13	1.4083	1.2851	1.1283	1.2643	1.2796	1.4118	1.586
14	1.5729	1.1971	1.1462	1.2643	1.2977	1.6095	1.8384
15	1.6278	1.1888	1.1641	1.3365	1.3337	1.5729	1.8384
16	1.6461	1.3185	1.1462	1.3004	1.4058	1.6095	1.8203
17	1.3937	1.2385		1.1198	1.3157	1.5729	1.6762
18	.1086	1.2643		1.2475	1.3337	1.3575	1.4959
19	1.4661	1.5139	1.3432	1.5203	1.4238	1.3756	1.6041
20	1.5912	1.532	1.4685	1.6289	1.7843	1.6827	1.8744
21	1.6644	1.2616	1.4327		1.7843	1.9022	1.9826
22	1.7924	1.4058	1.3969	1.6651	1.8564	1.9753	2.0907
23	1.8473	1.532	1.3611	1.6651	1.8924	2.0851	2.1808
24	2.0058	1.8656	1.532	1.3432	1.5927	1.8924	2.0119
Max	2.0058	1.8656	1.532	1.6651	1.8924	2.0851	2.1808
Min	.1086	1.086	1.0208	1.0566	1.1245	1.1535	1.2127
Avg	1.4764	1.3860	1.2618	1.2899	1.4101	1.5447	1.6976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 203 / 11 KV Industrial
Wanadongari Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6478	.6668	.6668	.6668	.6287	.4191
2	.6478	.6097	.6668	.6668	.6668	.6668	.4001
3	.6478	.6478	.6478	.6478	.6668	.6668	.381
4	.6097	.6478	.6287	.6478	.6668	.6478	.381
5	.6097	.6668	.6478	.6097	.5716	.6287	.4001
6	.6097	.6668	.6097	.6097	.4763	.6097	.4001
7	.6097	.4001	.6287	.6478	.5716	.6097	.4001
8	.6478	.6668	.6478	.6859	.6287	.4001	.4001
9	.7811	.6478	.6287	.724	.5716	.362	.6478
10	.8573	.7811	.6287	.7621	.4763	.362	.743
11	.8192	.8002	.7621	.8192	1.3146	.381	.8383
12	.7811	.724	.724	.7811	.724	.1905	.8002
13	.7621	.7811	.743	.8192	.743	.1143	
14	.7811	.8002	.6859	.6668	.724	.4191	.7621
15	.7621	.7621	.724	.7621	.724	.4001	.9145
16	.7811	.743	.6668	.743	.6859	.381	.7621
17	.8764	.724	.6859	.6668	.6859	.381	.8192
18	.724	.7621	.6478	.6668	.6097	.381	.6668
19	.6859	.6668	.6668	.6668	.6097	.4001	.743
20	.6859	.6668	.6859	.6097	.6478	.4001	.6668
21	.724	.6859	.724	.6478	.724	.4572	.7621
22	.6859	.6668	.6859	.6287	.7049	.4572	.7621
23	.6287	.6478	.6668	.6287	.6668	.4572	.8192
24	.6668	.6668	.6668	.6668	.6287	.6287	.4191
Max	.8764	.8002	.7621	.8192	1.3146	.6668	.9145
Min	.6097	.4001	.6097	.6097	.4763	.1143	.381
Avg	.7105	.6867	.6724	.6851	.6732	.4596	.6221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 204 / 11 kV Sangam Ag Sep

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.0648	.0483	.032	.0492	.1126	.0648
2	.064	.0648	.0483	.032	.0492	.1126	.0648
3	.064	.0648	.0483	.032	.0492	.1126	.0648
4	.064	.0648	.0483	.032	.0492	.1286	.0688
5	.064	.0648	.0483	.032	.0492	.1447	.0819
6	.064	.0648	.0483	.032	.0492	.1608	.0819
7	.064	.0486	.0322	.032	.0819	.193	.081
8	.2241	.0983	.0644	.032	.0819	.1769	.3812
9	.2241	.081	.0483	.032	.0328	.048	.431
10	.2401	.0512	.0483	.032	.0328	.048	.5138
11	.2458	.0321	.048		.0484	.0486	.4176
12	.2294	.0322			.0322	.0486	.4015
13	.2294	.1288			.0321	.0486	.3855
14	.2294	.1449	.048		.0321	.0655	.3855
15	.1943	.1932	.048		.0321	.0486	.3855
16	.081	.0644	.048		.0321	.0502	.0642
17	.048	.0644			.0482	.048	.0803
18	.0486	.0651			.0482	.0486	.0803
19	.0655	.0644	.032	.0658	.0642	.081	.0803
20	.0648	.0644		.0658	.0482	.081	.0964
21	.068	.0483		.0658	.0642	.081	.0803
22	.0648	.0483		.0658	.1126	.0648	.0803
23	.0648	.0483		.0658	.1126	.0648	.0642
24	.064	.0655	.0483	.032	.0655	.0965	.0655
Max	.2458	.1932	.0644	.0658	.1126	.193	.5138
Min	.048	.0321	.032	.032	.0321	.048	.0642
Avg	.1181	.0722	.0472	.0426	.0541	.0881	.1876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 205 / 11 kV Amar/Rajiv Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7737	1.5524	1.2803	1.086	1.3306	1.6644	1.7372
2	1.7194	1.4632	1.267	1.0679	1.2936	1.5912	1.6632
3	1.6289	1.3717	1.2308	1.0498	1.2197	1.4998	1.5708
4	1.5927	1.2803	1.1765	1.0498	1.1458	1.4083	1.4632
5	1.448	1.2254	1.1283	1.0136	1.1088	1.3352	1.39
6	1.2851	2.673	1.0745	.9774	1.0903	1.2803	1.2803
7	1.086	.9511	1.0387	.9412	1.0903	1.0974	1.134
8	1.0498	1.0242	.9214	.9593	1.0164	1.1041	1.0608
9	1.0136	.9145	.9214	.9774	.9877	1.0208	1.0425
10	.9774	1.8099	.9214	1.0136	.9694	.985	2.1719
11	1.0608	.9134	.9593	.9694	.9671	1.0608	.9313
12	1.134	.9134	1.086	.9328	1.0208	1.0974	1.1104
13	1.1462	1.0029	1.2851	.8048	.9671	1.1458	1.2308
14	1.2803	1.1104	1.2489	1.0059	1.0745	1.2382	1.3394
15	1.3535	1.182	1.1765	1.0425	1.0387	1.2803	1.3394
16	1.2752	1.2178	1.1041	1.0242	1.0924	1.3169	1.3756
17	1.2437	1.1283	1.0498	.823	1.0566	1.1888	1.2127
18	.9694	1.0387		.9511	1.0029	1.0349	1.1641
19	1.2197	1.2357	1.0317	1.2936	1.1104		1.2357
20	1.3676	1.2178	1.2308	1.3306	1.4632	1.4784	1.5364
21	1.4937	.985	1.2127	1.5154	1.5927	1.6078	1.7193
22	1.531	1.0208	1.1765	1.5154	1.701	1.848	1.9774
23	1.5684	1.0566	1.1403	1.4415	1.7926	1.885	1.9404
24	1.8461	1.6078	1.3032	1.1041	1.3676	1.7193	1.8111
Max	1.8461	2.673	1.3032	1.5154	1.7926	1.885	2.1719
Min	.9694	.9134	.9214	.8048	.9671	.985	.9313
Avg	1.3360	1.2457	1.1289	1.0788	1.1875	1.3430	1.4349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 206 / 11 kV Mahajanwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8461	1.7177	1.39	1.2127	1.419	1.8298	1.9044
2	1.7737	1.6244	1.3535	1.1765	1.3443	1.7372	1.8671
3	1.6289	1.531	1.2803	1.1041	1.307	1.6632	1.7737
4	1.4661	1.4377	1.2308	1.086	1.2323	1.5708	1.643
5	1.3394	1.3443	1.1946	1.0498	1.1949	1.4784	1.4784
6	1.2489	1.2883	1.1584	1.0317	1.1203	1.3121	1.3491
7	1.1946	1.1643	1.0679	1.0317	1.1413	1.2254	1.2696
8	1.1041	1.0456	1.0387	1.0136	1.1225	1.0745	1.2136
9	1.086	1.0082	1.0029	.9955	1.0082	1.0745	1.1389
10	1.0498	1.0456	.9671	.9774	1.0829	1.0745	1.1203
11	1.1576	1.0498	.9313	1.0082	1.0317	1.1389	1.1222
12	1.2136	1.1222	.9492	1.0456	1.086	1.1949	1.1765
13	1.2696	1.1104	.9774	1.1016	1.1222	1.251	1.3575
14	1.3817	1.2127	.985	1.0829	1.1403	1.3817	1.4632
15	1.4563	1.1999	1.0136	1.1389	1.1584	1.307	1.5181
16	1.419	1.2127	.9955	1.1763	1.1946	1.2012	1.4661
17	1.2696	1.0745	1.0136	.9709	1.1222	1.1763	1.3937
18	1.0829	1.1041	.9774	1.0642	1.086	1.1389	1.2127
19	1.4003	1.2178	1.086	1.4937	1.1946	1.2323	1.3213
20	1.4937	1.2536	1.2308	1.531	1.701	1.6244	1.7372
21	1.6057	1.2715	1.267	1.531	1.7558	1.8671	1.9035
22	1.7364	1.3611	1.2851	1.5123	1.848	1.9978	2.0513
23	1.8111	1.4327	1.2489	1.5684	1.9231	2.0725	2.1437
24	1.9004	1.7737	1.4083	1.2308	1.475	1.8665	1.9605
Max	1.9004	1.7737	1.4083	1.5684	1.9231	2.0725	2.1437
Min	1.0498	1.0082	.9313	.9709	1.0082	1.0745	1.1203
Avg	1.4140	1.2752	1.1272	1.1723	1.2838	1.4371	1.5244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 207 / 11 kV Mohagaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3881	.3392	.3206	.3395	.3772	.3511
2	.3734	.3696	.3203	.2987	.3395	.3584	.3326
3	.3361	.3292	.3018	.2987	.3395	.3206	.3326
4	.3361	.3109	.3018	.2987	.3018	.3018	.3109
5	.2987	.2926	.2829	.2829	.2641	.2829	.2926
6	.2801	.2743	.2641	.2829	.2452	.2641	.2743
7	.2241	.1829	.1886	.2452	.2075	.1886	.2378
8	.2427	.2172	.2263	.2614	.2075	.2261	.2926
9	.2801	.2561	.2075	.3224	.2073	.2829	.3292
10	.3361	.2743	.2829	.4163	.2452	.3018	.3475
11	.3142	.2824	.2641	.4715	.245	.3142	.4899
12	.2957	.245	.3772	.4715	.245	.3292	.4899
13	.2926	.2635	.3801	.3772	.245	.3292	.3957
14	.3326	.3012	.3395	.3006	.2826	.3658	.4522
15	.3658	.2824	.2829	.263	.245	.4207	.4334
16	.3109	.4141	.415	.2442	.2261	.4938	.4145
17	.3109	.3576	.3772	.3018	.245	.462	.4522
18	.2926	.3953	.3258	.2263	.245	.4066	.6218
19	.3292	.3388	.3018	.2829		.2743	.3203
20	.3921	.3576	.3018	.3206	.415	.3881	.3957
21	.3734	.3392	.2829	.3772	.3772	.3881	.4334
22	.3734	.3388	.3206	.3961	.415	.4108	.4522
23	.3734	.3388	.3395	.3772	.3961	.3547	.4522
24	.4294	.3658	.3392	.3395	.3584	.3772	.3511
Max	.4294	.4141	.415	.4715	.415	.4938	.6218
Min	.2241	.1829	.1886	.2263	.2073	.1886	.2378
Avg	.3286	.3132	.3068	.3241	.2886	.3425	.3857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 208 / 11 kV Sangam

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.394	.3901	.3045	.3727	.4259	.4108
2	.3077	.3841	.3715	.2865	.3727	.4074	.3734
3	.3045	.3658	.3344	.2865	.3727	.4074	.3696
4	.3403	.3292	.3522	.2686	.3727	.3715	.3475
5	.362	.3292	.3151	.2715	.3361	.3529	.3258
6	.3801	.3109	.2781	.2715	.2801	.3344	.3077
7	.394	.2534	.2772	.2507	.2801	.2778	.2715
8	.3224	.2896	.2561	.2328	.2987	.2213	.2715
9	.362	.3077	.3077	.2507	.2972	.2561	.2715
10	.4163	.3439	.2521	.2715	.3158	.2715	.3439
11	.3801	.3439	.2686	.3096	.3669	.2743	1.1352
12	.3292	.3809	.2507	.3125	.3639	.3258	.3841
13	.2926	.3109	.2686	.2574	.3439	.3841	.4572
14	.2743	.3666	.2865	.239	.3077	.181	.5304
15	.2743	.3309	.3045	.2942	.2911	.3258	.4943
16	.3801	.3309	.2865	.2758	.3639	.3982	.4028
17	.3258	.2534	.2715	.2229	.3096	.362	.3833
18	.2149	.2363	.2149	.0929	.2561	.3439	.3801
19	.3258	.3708	.2686	.3715	.3116	.3077	.362
20	.4207	.3704		.3715	.4426	.2926	.4625
21	.4207	.2786	.3258	.4087	.4611	.5175	.518
22	.4251	.3344	.3439	.4087	.462	.4024	.5212
23	.4108	.4087	.3258	.4087	.462	.4435	.5026
24	.4887	.4207	.3901	.3224	.3715	.4444	.4207
Max	.4887	.4207	.3901	.4087	.462	.5175	1.1352
Min	.2149	.2363	.2149	.0929	.2561	.181	.2715
Avg	.3531	.3352	.3018	.2913	.3505	.3471	.4270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362] BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 402 / 33 kV Abhijeet MADC
Feeder KV- 33 / OUTGOING

DATE	09-JUN-18	11-JUN-18
HR	Load (MW)	Load (MW)
9		.9134
10	.0057	
11	2.7321	
12	2.2403	
13	1.9691	
14	1.3675	
15	1.7503	
Max	2.7321	.9134
Min	.0057	.9134
Avg	1.6775	.9134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 202 / 11 KV Issasani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2883	1.2765		.8962	1.0903	1.363	1.4415
2	1.1949	1.2193		.8676	1.0642	1.2883	1.3306
3	1.1643	1.1431		.8488	1.0164	1.2136	1.2567
4	1.1576	1.105		.8299	.9795	1.1317	1.2197
5	1.1389	1.0288		.811		1.0642	1.1458
6	.9425	.9717		.811	.8501	.9997	1.0719
7	.8775	.8764		.7922	.7762	.9054	.9709
8	.7842	.7621	.8383	.8029	.8686	.8029	.8131
9	.7207	.7621	.8192	.7842	.924	.7842	.8029
10	.8002	.7621	.724	.8192	.8573	.8383	.8002
11	.8383	.7811	.743	.8192	.8383	.8383	.9526
12	.8573	.8573	.8002	.8573	.8383	.9717	1.0098
13	.8192	.9145	.8573	.8954	.8954	1.0288	1.086
14	.9526	.8954	.8954	.9145	.8764	1.086	1.2003
15	1.1241	.9717	.8954	.9526	.9145	1.1431	1.2193
16	1.1241	1.0098	.6668	.9145	.9717	1.1431	1.2193
17	.9526	.9717	.7811	.8383	.9526	.9717	1.1431
18	.743	.8131	.7947	.7577	.8029	.9145	.9619
19	.8954	.924	.8775	.9055	.8775	1.0479	1.0082
20	1.086		.9619	1.1088	1.2382	1.3336	1.2696
21	1.2193		1.0185	1.1827	1.4003	1.4045	1.4937
22	1.3336		1.0374		1.4563	1.5524	1.6244
23	1.3717		.9896	1.1827	1.5123	1.5893	1.6409
24	1.4003	1.3336		.9335	1.1273	1.419	1.5154
Max	1.4003	1.3336	1.0374	1.1827	1.5123	1.5893	1.6409
Min	.7207	.7621	.6668	.7577	.7762	.7842	.8002
Avg	1.0328	.9690	.8563	.8924	1.0056	1.1181	1.1749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 203 / 11 KV Bhimnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6409	1.5242		1.0374	1.2382	1.5339	1.643
2	1.5844	1.448		1.0185	1.2012	1.4937	1.5708
3	1.4937	1.3908		1.0185	1.1458	1.4563	1.4937
4	1.4377	1.3336		.9808	1.1088	1.3817	1.4415
5	1.3817	1.2574		.9808	1.1016	1.2826	1.3306
6	1.1763	1.2003		.9997	1.0719	1.2071	1.2382
7	1.0269	1.0098		.9054	1.0642	1.1883	1.2012
8	1.0269		.9907	.8775	.9979	1.1576	1.0534
9	1.0903	1.1241	1.0288	.9335	1.1622	1.2136	1.1273
10	1.2765	1.1241	1.086	1.0479	1.3146		1.3908
11	1.4098	1.1812	1.0479	1.1622	1.3336	1.4861	1.4861
12	1.5051		1.0669	1.2193	1.4098	1.4289	1.5242
13	1.448	1.3146	1.0479	1.448	1.4861	1.5051	1.6766
14	1.448	1.4098	1.0288	1.448	1.5432	1.7147	1.7718
15	1.6385	1.4098	.9907	1.5242	1.5623	1.829	1.848
16	1.6194	1.5051	.5335	1.5242	1.6004	1.829	1.848
17	1.1241	1.4098	.6097	1.3908	1.4861	1.6575	1.6385
18	1.1241	1.1273	.9808	1.1273	1.1576	1.3146	1.3392
19	1.2765	1.2752	1.0903	1.2012	1.1458	1.3717	1.251
20	1.467		1.1576	1.3676	1.531	1.6194	1.5497
21	1.5813		1.1763	1.386	1.643	1.7372	1.6991
22	1.6575		1.1694	1.423	1.6804	1.7741	1.7924
23	1.6194		1.1016	1.3676	1.6991	1.5893	1.7737
24	1.6804	1.5813		1.0642	1.2752	1.5708	1.7177
Max	1.6804	1.5813	1.1763	1.5242	1.6991	1.829	1.848
Min	1.0269	1.0098	.5335	.8775	.9979	1.1576	1.0534
Avg	1.4056	1.3126	1.0067	1.1856	1.3317	1.4931	1.5169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164841 / 33/11 KV KANHOLIBARA

Feeder No / Name : 201 / 11 KV DEVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.1677	.1981		.1829	.1829
2	.1981	.1829	.1829	.1829		.1829	.1829
3	.1829	.1829	.1524	.1677		.1524	.1829
4	.1829	.1677	.1829	.1524		.1524	.1677
5	.1829	.1524	.1219	.1829		.1372	.1677
6	.1524	.1372	.1372	.1219		.1372	.1677
7	.1219	.1219	.1219	.0914		.1219	.2134
8	.1219	.1219	.1067	.0914		.1524	.3048
9	.1219	.1372	.1219	.0762		.2134	.3506
10	.1219	.1677	.1372	.061		.1677	.3506
11	.1219	.1524	.1067	.0914		.2134	.381
12	.1524	.1372	.1067	.1219		.2439	.4115
13	.1677	.1067	.1219			.2134	.4268
14	.1677	.1372	.1067	.1524		.2439	.381
15	.2134	.1677	.0914	.1677		.2743	.3963
16	.2134	.1677	.0762	.1524		.3048	.4268
17	.1981	.1981	.061	.1372		.3506	.4115
18	.1677	.2286	.1219	.1829		.3201	.4572
19	.1524	.1677	.1219		.1524	.2439	.3963
20	.1372	.2134	.1524		.1829	.3048	.3353
21	.1677	.1677	.1829		.2286	.2743	.2896
22	.1829	.1981	.1981		.2134	.2591	
23	.1981	.1829	.1829		.2134	.2286	.3048
24	.1829	.1829	.1981	.1829		.2134	.2134
Max	.2134	.2286	.1981	.1981	.2286	.3506	.4572
Min	.1219	.1067	.061	.061	.1524	.1219	.1677
Avg	.1664	.1651	.1359	.1397	.1981	.2204	.3088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164841 / 33/11 KV KANHOLIBARA

Feeder No / Name : 202 / 11 KV KHADAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1829		.1524		.1524	.061
2	.1677	.1829		.1677		.1524	.061
3	.1677	.1829				.1372	.061
4	.1677	.1677					.061
5	.1524	.1372					.061
6	.1219						.061
7	.1067			.1219		.1219	.1372
8	.1067			.1067		.1372	.2134
9	.1677	.0914		.1067		.1829	.1981
10	.1067	.1067		.1524		.1524	.1829
11	.1219	.1067	.1524	.1219		.1981	.3201
12	.1524	.1067	.1524	.1524		.1829	.442
13	.1829	.1219	.1677	.1524			.4268
14		.1219	.1372	.1372		.1829	
15	.1524	.1219	.1524	.1524			.3963
16	.1524		.1219	.1677			.3658
17	.1372	.1372	.1067	.1524		.3201	.3506
18			.1067	.1372		.2896	.3658
19	.1372	.1677	.1372		.1372	.2591	.3353
20	.1677	.1677	.1524		.1677	.2439	.3201
21	.1829	.1372	.1524		.2134	.2591	.3048
22	.1981	.1372	.1677		.1981	.2439	
23	.1981		.1677		.1829		.2591
24	.1524	.1981		.1524		.1829	
Max	.1981	.1981	.1677	.1677	.2134	.3201	.442
Min	.1067	.0914	.1067	.1067	.1372	.1219	.061
Avg	.1524	.1431	.1442	.1423	.1799	.1999	.2373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164841 / 33/11 KV KANHOLIBARA

Feeder No / Name : 203 / 11 KV KANHOLIBARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.7316	.7316	.7621	.7316	.7316
2	.7316	.7316	.7468	.7468	.7316	.7316	.7316
3	.7316	.7316	.7468	.7316	.7164	.7316	.7316
4	.7316	.7316	.7316	.7468	.7468	.7316	.7316
5	.7316	.7316	.7316	.7164	.7164	.7316	.7164
6	.7316	.7468	.7468	.7468	.7316	.7316	.7164
7	.7164	.7468	.7316	.7316	.7468	.7164	.7011
8	.7011	.7316	.7316	.7164	.7468	.7164	.7011
9	.6859	.7316	.7164	.7011		.7164	
10	.6706	.7164	.7164	.7011		.6859	.6706
11	.6859	.7316	.7011	.7164		.6859	.7011
12	.6859	.7316	.7316	.7316		.6706	.6859
13	.6859	.7316	.7164	.7164		.6859	.7011
14	.7011	.7316	.7011	.7164		.6706	.7011
15	.7011	.7316	.7316	.7316		.6859	.6859
16	.6859	.7316	.7011	.7164		.6859	.6706
17	.6859		.7316	.7316		.6706	.6859
18	.7011	.7011	.7164	.7468		.6859	.6706
19	.7164	.7316	.7621	.7621	.7316	.7164	.7011
20	.7468	.7621	.7621	.7773	.7468	.7468	.7316
21	.7468	.7621	.7621	.7773	.7621	.7468	.7621
22	.7468	.7621	.7621	.7621	.7468	.7316	
23	.7316	.7316	.7468	.7621	.7316	.7316	.7468
24	.7316	.7316	.7468	.7468	.7773	.7316	.7316
Max	.7468	.7621	.7621	.7773	.7773	.7468	.7621
Min	.6706	.7011	.7011	.7011	.7164	.6706	.6706
Avg	.7132	.7349	.7335	.7360	.7425	.7113	.7094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164841 / 33/11 KV KANHOLIBARA

Feeder No / Name : 204 / 11 KV INDUSTRIAL

KANHOLIBARA Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.2743	.061	.1981		.0914	.0762
2	.061	.2743	.0762	.1524		.0914	.061
3	.0457	.3353	.061	.1372		.0762	.061
4	.0305	.2896	.061	.1219		.0762	.0457
5	.0305	.2286	.0762	.1372		.0762	.061
6	.1372		.2439	.1067		.061	.0914
7	.2591		.0762	.0914		.0762	.061
8	.061	.0152	.061	.061		.0457	.0457
9	.0457		.061	.0762		.061	.061
10	.0457		.061	.0762		.0762	.0762
11	.0305		.061	.061		.0762	.1067
12	.0152	***	.2439			.0762	.1829
13	.0152	.0305	.0914			.0914	.1372
14		.0305	.1067			.061	.1219
15	.0152	.0457	.1829			.0914	.1981
16	.0152		.3048			.061	.1219
17	.0152		.1219			.0762	.1067
18	.0152	.061	.3048			.0762	.0914
19	.0152		.0762		.0762	.0762	.1067
20	.0152	.1067	.0762		.061	.0914	.0914
21	.1372	.0914	.0762		.0914	.061	.0762
22	.2134	.0762	.0762		.061	.0762	
23	.0914	.0762	.0762		.0914	.0914	.061
24	.1981	.2439	.0762	.2286		.0914	.0914
Max	.2591	92.3793	.3048	.2286	.0914	.0914	.1981
Min	.0152	.0152	.061	.061	.061	.0457	.0457
Avg	.0689	5.9099	.1130	.1207	.0762	.0762	.0928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 200 / Station Transformer

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0983	.04	.0419	.0411	.0972	.0392
2	.04	.1017	.0419	.0419	.0411	.0983	.0392
3	.04	.0819	.0419	.0419	.0411	.0972	.0373
4	.0419	.081	.04	.0419	.0429	.1017	.0373
5	.0419	.1017	.04	.0419	.0411	.0972	.0373
6	.0419	.0339	.04	.0419	.0411	.0324	.0392
7	.0419	.0328	.0419	.04	.0392	.0328	.0392
8	.0419	.0339	.0419	.04	.0373	.0328	.0392
9	.04	.0339	.0419	.04	.04	.0328	.0579
10	.0381	.0339		.0339	.0373	.0373	.056
11	.0373	.0381	.0373	.0339		.0373	.056
12	.0373	.0381	.0392	.0339	.0355	.0373	.056
13	.0373	.0381	.0373	.0339	.0355		.0381
14	.0373	.0362	.0373	.0339	.0355		.0373
15	.0373	.0362	.0373	.0339	.0343		.0373
16	.0373	.0362	.0373	.0339	.0336	.0373	.0373
17	.0339	.0362	.04		.0322	.0373	.0362
18		.0362	.04	.0373	.0305	.0373	.0362
19	.0339	.0381	.04	.0392	.0339	.0392	.0362
20	.1017	.04	.04	.0373	.0339	.0373	.0362
21	.1017	.04	.04	.0373	.0324	.0373	.0362
22	.1017	.04	.04	.0411	.0328	.0355	.0362
23		.04	.04	.0373		.0355	.0362
24	.0381	.1017	.04	.04	.0411		.0355
Max	.1017	.1017	.0419	.0419	.0429	.1017	.0579
Min	.0339	.0328	.0373	.0339	.0305	.0324	.0355
Avg	.0473	.0512	.0398	.0382	.0370	.0516	.0405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 201 / Dainik Bhaskar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	.7049	.7049	.8192	.8954	.8002
2	.8192	.724	.7621	.6859	.8383	.8573	.7621
3	.724	.6668	.6859	.6668	.8002	.8002	.7811
4	.6478	.5906		.6478	.7621	.7621	.724
5	.5716	.5525	.5906	.5906	.724	.743	.6859
6	.6097	.5906	.5335	.6097	.6859	.6287	.5906
7	.5906	.5906	.5906	.6287	.6859	.6097	.5525
8	.7049	.5906	.5716	.5906	.6478	.5144	.5716
9	.9335	.6859	.724	.724	.743	.4954	.7621
10	1.448	1.2574		1.1241	1.105	.7621	
11	1.4289	1.4098	1.0098	1.3908	1.467		1.3336
12	1.5813	1.5242	.9335	1.5813	1.448		1.448
13	1.2384	1.2765	.9526	1.3527	1.3908		1.1431
14	1.448	1.5242	1.0098		1.3908		1.467
15	1.6004	1.448	.9717	1.4861	1.6575		1.5242
16	1.6385	1.6766	1.0288	1.5813	1.6194	1.0288	1.6575
17	1.6004	1.3908	.8954		1.3527	.8383	1.5242
18		1.6004	.8954	1.2574	1.2003	.9335	1.2574
19	.8954	1.1431	.8192	.9717	1.0669	.7049	1.105
20	.8002	.743	.6668	.8002	.8764	.7049	.8573
21	.6859	.6478	.6287	.724	.7621	.6859	.724
22		.724	.6859	.7811		.6287	.8002
23		.8002	.8383	.8954		.8192	.8192
24	.743	.743	.6859	.7049	.8002	.8383	.6859
Max	1.6385	1.6766	1.0288	1.5813	1.6575	1.0288	1.6575
Min	.5716	.5525	.5335	.5906	.6478	.4954	.5525
Avg	1.0243	.9859	.7811	.9318	1.0383	.7500	.9816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 202 / 11 kV RC PLASTO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.8671	2.0195	2.1719	1.8671	1.9433	1.9814
2	1.9052	1.7718	1.9052	2.1338	1.9052	2.0005	1.9433
3	1.8671	1.7147	1.9433	2.0957	2.1338	1.9243	1.9052
4	1.829	1.6766	1.8671	2.1338	2.0957	1.8861	1.9814
5	1.7147	1.7718	1.9814	2.0576	2.0195	1.9814	1.8671
6	1.9052	1.829	1.8671	2.0957	1.9052	1.7528	1.9052
7	1.6766	1.5242	1.6766	2.0576	1.829	1.7528	1.8671
8	1.7147	1.6766	1.6766	1.5242	1.7147	1.5623	1.8671
9	2.0005	1.6766		2.2862	1.829	2.0005	2.0576
10	1.9052	1.9814		2.2862	2.2481		
11	2.3243	1.829	1.9052	2.21	2.1338		1.7528
12	2.2481	1.8671	1.7147	1.7528	1.9052		1.9814
13	2.7435	1.7147	1.7528	1.5242	1.9052		1.8671
14	1.448	1.6766	1.9052	2.1338	1.829		1.9814
15	1.8671	1.9814	2.191	2.0195	1.9052		1.9814
16	2.2481	2.0576	2.1719	2.0767	2.0576	1.9814	2.1719
17	2.2481	2.0957	2.21		1.9814	1.9052	2.21
18		1.9814	2.191	2.1719	2.0576	1.9814	1.9052
19	1.9243	2.0576	2.1338	2.1338	2.1529	1.9052	1.8671
20	1.9814	1.6385	1.9814	1.8671	1.9052	1.7528	1.8671
21	2.0576	1.6004	1.9814	1.6766	1.9814	1.829	1.9052
22	1.9243	1.8671	2.0576	1.9052	2.1529	1.9814	2.21
23		1.8671	2.191	1.9052		1.9814	1.9433
24	1.9814	1.9052	1.7147	2.1338	1.7147	1.9052	1.9052
Max	2.7435	2.0957	2.21	2.2862	2.2481	2.0005	2.21
Min	1.448	1.5242	1.6766	1.5242	1.7147	1.5623	1.7528
Avg	1.9754	1.8179	1.9563	2.0154	1.9665	1.8904	1.9532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 203 / 11KV Rukmini Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764		.8383	.9907	.8002	.8002	.724
2	.9145		.8002	.9145	.8192	.8192	.7621
3	.8954		.8192	.8764	.8002	.7621	.724
4	.8764		.8002	.8383	.7621	.7049	.7811
5	.9145		.7811	.7811	.743	.724	.6859
6	.8764		.8002	.8573	.724	.6668	.5716
7	.9145		.6859	.8002	.743	.6668	.724
8	.9526		.9335	.8192	.9335	.6287	.8002
9	2.0005			1.1622	1.086	.6478	.9145
10	1.9624	1.9243		1.2193	1.3717		1.448
11	1.467	1.3908	1.0098	1.467	1.3336		1.6575
12		2.3624	1.6766	1.448	1.5623		2.191
13		1.3527	1.4861	1.9624	1.6575		1.467
14		1.7147	2.3624	1.8671	1.3336		1.5623
15		1.448	1.2955	1.5432	1.8671		1.5432
16		2.3243	1.3336	2.0005	1.3527	.743	1.9243
17		1.4289	1.3717		1.6956	.8002	1.7528
18		2.2481	1.0479	1.4289	2.1148	.724	2.1719
19		1.9624	1.0098	1.1241	.9526	.724	1.3908
20		.9145	.7811	.9526	1.0098	.724	.8764
21		.8002	.724	.7621	.7621	.6859	.8383
22		.8573	.8573	.8192	.8002	.8764	.9907
23		.8764	1.0288	.8954		.7811	1.0288
24	.8002		.8002	.9907	.8002	.6668	.724
Max	2.0005	2.3624	2.3624	2.0005	2.1148	.8764	2.191
Min	.8002	.8002	.6859	.7621	.724	.6287	.5716
Avg	1.1209	1.5432	1.0565	1.1531	1.1315	.7303	1.1773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 200 / Station T/F

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.1715		.1715
14	.1715	.1715			
15				.1715	
Max	.1715	.1715	.1715	.1715	.1715
Min	.1715	.1715	.1715	.1715	.1715
Avg	.1715	.1715	.1715	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL-II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			1.2003		1.2003
14	1.2003	1.2003			
15				1.2003	
Max	1.2003	1.2003	1.2003	1.2003	1.2003
Min	1.2003	1.2003	1.2003	1.2003	1.2003
Avg	1.2003	1.2003	1.2003	1.2003	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 209 / 11 KV MANKAPUR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.8573		.8573
14	.8573	.8573			
15				.8573	
Max	.8573	.8573	.8573	.8573	.8573
Min	.8573	.8573	.8573	.8573	.8573
Avg	.8573	.8573	.8573	.8573	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 210 / 11 KV HINGNA-I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			1.2003		1.2003
14	1.2003	1.2003			
15				1.2003	
Max	1.2003	1.2003	1.2003	1.2003	1.2003
Min	1.2003	1.2003	1.2003	1.2003	1.2003
Avg	1.2003	1.2003	1.2003	1.2003	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 211 / 11 KV HINGNA-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			2.3148		2.3148
14	2.3148	2.3148			
15				2.3148	
Max	2.3148	2.3148	2.3148	2.3148	2.3148
Min	2.3148	2.3148	2.3148	2.3148	2.3148
Avg	2.3148	2.3148	2.3148	2.3148	2.3148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 214 / 11 kv Urban-II

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.5144		.5144
14	.5144	.5144			
15				.5144	
Max	.5144	.5144	.5144	.5144	.5144
Min	.5144	.5144	.5144	.5144	.5144
Avg	.5144	.5144	.5144	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 216 / 11 KV INDUSTRIAL-I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			1.5432		1.5432
14	1.5432	1.5432			
15				1.5432	
Max	1.5432	1.5432	1.5432	1.5432	1.5432
Min	1.5432	1.5432	1.5432	1.5432	1.5432
Avg	1.5432	1.5432	1.5432	1.5432	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 217 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.6859		.6859
14	.6859	.6859			
15				.6859	
Max	.6859	.6859	.6859	.6859	.6859
Min	.6859	.6859	.6859	.6859	.6859
Avg	.6859	.6859	.6859	.6859	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 219 / 11 KV ABC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.6859		.6859
14	.6859	.6859			
15				.6859	
Max	.6859	.6859	.6859	.6859	.6859
Min	.6859	.6859	.6859	.6859	.6859
Avg	.6859	.6859	.6859	.6859	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 201 / Suvarna Laghu Udyog(SLU)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	.1486	1.8671	1.6766	1.4861	1.7147	.9145
2	1.7528	.1429	1.7528	1.5813	1.4861	1.6766	.8764
3	1.7147	.1543	1.6575	1.6194		1.6385	.9335
4	1.6766	.1696	1.7909	1.5242	1.4289	1.6004	.8954
5	1.6194	.1619	1.7337	1.4289	1.4098	1.5623	.9526
6	1.5623	.1372	1.6194	1.3527	1.4098	1.5242	.9145
7	1.3717	.1257	1.5623	1.2574	1.5432	1.105	.8573
8	1.8861	.1791	2.0386	1.6004	1.7147	.743	1.4861
9	1.848	.1981	2.0005	1.7147	1.7718	.743	1.7337
10	.1886	2.0005	.2	1.7147	2.0576	.743	.1772
11	.2229	2.191	.221	1.9433	2.191	.7621	.1715
12	.1829	2.0005	.1753	1.9624	1.9243	.724	.1791
13	.2229	1.9052	.2172	1.8861	2.1338	.8002	.1791
14	.202	1.829	.2077	1.8861	2.1719	.6859	.1734
15	.202	2.0195	.8993	1.7147	1.848	.6478	.1829
16	.2267	2.1529	.1981	1.8861	2.1529	.6287	.2134
17	.2134	2.0195	.2191	1.8671	2.0767	.724	.2
18	.2134	2.0005	.2058	1.8861	2.1338	.6097	.2039
19	.1619	1.9433	.1753	1.3717	1.7909	.5335	.2058
20	.1715	1.7147	1.5242	1.4289	1.6575	.5716	.202
21	.1658	1.7528	1.6194	1.467	1.4861	.6287	.181
22	.1619	1.6004	1.6194	1.5051	1.6194	.6668	.1677
23	.1486	1.7528	1.7147	.3429	1.848	.8573	.1734
24	1.7909	.1543	1.9052	1.6004	1.4861	1.7528	.8764
Max	1.8861	2.191	2.0386	1.9624	2.191	1.7528	1.7337
Min	.1486	.1257	.1753	.3429	1.4098	.5335	.1677
Avg	.8192	1.1856	1.1302	1.5924	1.7751	.9852	.5438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 202 / Berar Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	.0495	1.3957	.743	.9717	.7621	.3395
2	1.2003	.0857	1.1694	.9717	1.086	.724	.3206
3	1.1431	.0724	.9808	.6668	.9526	.6668	.3584
4	1.0288	.0533	1.1883	.8573	.8954	.5716	.3018
5	.9717	.0667	.811	.8573	.743	.4191	.3395
6	.8002	.0686	.679	.7621	.5716	.3048	.3206
7	.3429	.0572	.547	.4382	.6097	.3048	.3584
8	.9335	.12	1.6409	1.1241	1.2003	.2858	1.2071
9	1.9243	.0934	1.8673	2.0576	1.2003	.2263	1.226
10	.1372	1.8861	.1581	1.467	.5906	.2829	.1429
11	.1886	1.6221	.1791	1.7147	.6478	.3018	.1543
12	.1715	1.6975	.1486	1.2765	1.6194	.4338	.1162
13	.1791	1.7353	.1829	1.7147	1.2384	.3206	.1143
14	.0934	1.2449	.101	1.3717	1.2574		.0419
15	.1257	.7621	.0857	.5906	.6478		.0457
16	.0686	.7356	.0972	.6859	.4954		.0553
17	.0724	.7356	.0629	.6859	.7049		.0438
18	.0857	.6413	.0572	.6859	.6478		.0381
19	.0762	.5847	.0629	.5144	.5906	.3584	.04
20	.0686	.547	.4572	.5144	.5335	.3395	.0457
21	.0514	.4338	.4763	.5525	.362	.3584	.0495
22	.0457	.4527	.5525	.743	.4191	.3395	.04
23	.0495	.7167	.4191	.8192	.4763	.3206	.0343
24	1.086	.0553	1.5466	.5335	.9335	.5906	.3206
Max	1.9243	1.8861	1.8673	2.0576	1.6194	.7621	1.226
Min	.0457	.0495	.0572	.4382	.362	.2263	.0343
Avg	.5003	.6049	.6194	.9312	.8081	.4164	.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 203 / Varsha feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.0686	.7621	.7049	.6287	.8002	.5144
2	.6668	.0724	.724	.6478	.5716	.7621	.5335
3	.6668	.0648	.7049	.6478	.4572	.724	.4954
4	.6859	.061	.6478	.6859	.4572	.743	.5335
5	.6859	.0667	.6097	.743	.5144	.724	.5144
6	.6859	.0743	.6668	.6478	.6668	.724	.5335
7	.724	.0724	.724	.7049	.724	.7049	.5525
8	.6668	.6859	.7621	.5906	.6859	.6859	.6668
9	.724	.7811	.7621	.6859	.8573	.4382	.6668
10	.0857	1.1431	.0972	.9335	.9145	.4572	.0914
11	.1029	1.1622	.0972	1.0288	.9335	.4382	.101
12	.0953	.9907	.0934	.9526	1.0098		.0934
13	.0953	1.105	.0953	.8573	1.0098		.1029
14	.1029	1.2003	.101	.9526	1.0669		.1143
15	.1029	1.0098	.0972	1.086	1.0479		.1067
16	.1029	1.105	.101	1.0669	1.0669		.1086
17	.1105	1.1241	.0953	1.0669	1.0479	.4191	.1105
18	.0914	1.0669	.8573	.9526	.9717	.4001	.101
19	.0838	.9907	.8954	.8192	.9526	.381	.0838
20	.0743	.7621	.7621	.743	.7621	.4382	.0857
21	.0686	.6478	.6097	.724	.7811	.4572	.0762
22	.0686	.7049	.6668	.724	.7049	.4954	.0667
23	.0686	.724	.7049	.7049	.7621	.4572	.0648
24	.6668	.0667	.743	.6668	.6668	.7811	.5335
Max	.724	1.2003	.8954	1.086	1.0669	.8002	.6668
Min	.0686	.061	.0934	.5906	.4572	.381	.0648
Avg	.3372	.6563	.5158	.8057	.8026	.5806	.2855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 204 / SANVIJAY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.061	.679	.5335	.6859	.6668	.4001
2	.6478	.0591	.6602	.5335	.6859	.6097	.381
3	.6097	.061	.6979	.4954	.6478	.5716	.381
4	.5716	.0572	.6413	.4572	.5716	.5335	.4001
5	.5716	.0572	.6036	.4191	.5525	.4763	.362
6	.5335	.0514	.5281	.4572	.4954	.4191	.4382
7	.6478	.0514		.4763	.5335	.381	.5335
8	.6668	.5716	.547	.6287	.5716	.4001	.5144
9	.7621	.724	.5847	.6859	.6859	.362	.6287
10	.0991	1.0288	.0914	.9526	.9335	.4191	.0762
11	.0953	.8954	.0876	.8573	.7621	.4763	.0724
12	.0914	1.0479	.0895	.8002	.7811		.0724
13	.08	.7811	.0743	.6859	.6478		.0781
14	.0953	1.0098	.0914	.9526	.8383		.0857
15	.0857	.8002	.0857	.6859	.7049		.061
16	.0857	1.086	.0857	.9335	.8573		.0914
17	.1181	1.086	.0895	.9145	.8192	.3239	.08
18	.1029	1.0185	.724	.9145	.8002	.362	.0781
19	.101	.9242	.6859	.8002	.7049	.4191	.08
20	.0686	.7733	.5906	.6287	.5716	.4382	.0762
21		.7356	.5906	.6287	.5525	.4572	.0686
22	.0762	.6979	.5906	.6287	.6668	.4382	.0686
23	.0743	.6602	.5906	.7049	.7049	.4191	.0629
24	.6478	.0648	.6859	.5906	.6859	.6859	.4191
Max	.7621	1.086	.724	.9526	.9335	.6859	.6287
Min	.0686	.0514	.0743	.4191	.4954	.3239	.061
Avg	.3252	.5960	.4389	.6819	.6859	.4663	.2296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 205 / CANDICO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	.1543	1.4289	1.448	1.3717	1.6004	1.2003
2	1.6766	.16	1.3527	1.4098	1.3717	1.5623	1.1812
3	1.6004	.1524	1.3336	1.4861	1.3336	1.5242	1.1812
4	1.6004	.1486	1.2955	1.4289	1.3336	1.4289	1.1622
5	1.6194	.1562	1.3336	1.4098	1.2955	1.3717	1.2003
6	1.6766	.1638	1.3717	1.3717	1.2955	1.3336	1.1812
7	1.7528	.1467	1.4289	1.2003	1.3336	1.3527	1.1812
8	1.9624	1.7147	1.5432	1.448	1.6766	1.1241	1.1622
9	2.1338	2.0576	1.7147	1.829	2.1719	1.1241	1.7909
10	.2877	2.8197	.2343	2.6101	2.6292	1.1431	.202
11	.301	2.8006	.2362	2.7625	2.7625	1.1622	.2248
12	.3429	2.6673	.2534	3.0293	3.315	1.1812	.2572
13	.3029	2.2291	.2286	2.8197	2.7054	1.1622	.2572
14	.3239	2.7816	.2629	3.2579	2.7625	1.1812	.2858
15	.2896	2.7625	.2572	3.2007	2.8197	.9907	.2896
16	.3753	3.1817	.2934	3.2579	2.6292	1.086	.2877
17	.3239	2.8959	.2705	3.2198	2.6673		.2953
18	.3125	2.6101	2.5911	2.7244	2.6863		.261
19	.2667	2.3815	2.4196	2.572	2.191	1.1622	.2267
20	.202	2.0767	1.829	2.1148	1.9052	1.1431	.1981
21	.1715	1.448	1.5242	2.0957	1.4289	1.1431	.1715
22	.1677	1.2955	1.5242	2.1338	1.4861	1.1622	.1562
23	.1543	1.2384	1.5051	1.3717	1.5242	1.2003	.1448
24	1.7147	.1562	1.3527	1.5242	1.3717	1.5623	1.2003
Max	2.1338	3.1817	2.5911	3.2579	3.315	1.6004	1.7909
Min	.1543	.1467	.2286	1.2003	1.2955	.9907	.1448
Avg	.8848	1.5916	1.1494	2.1553	2.0028	1.2592	.6541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 201 / Temple Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4108	.3361	.2801	.3395	.3961	.4481
2	.3772	.3772	.3361	.2801	.3395	.3961	.4481
3	.3961	.3921	.3361	.2801	.3206	.3961	.4481
4	.3961	.3921	.2801	.2614	.2987	.3772	.3734
5	.3961	.3772	.2801	.2614	.3206	.3772	.3734
6	.3361	.3174	.2427	.2427	.2801	.3395	.3361
7	.2801	.2801	.2452	.2263	.2452	.2829	.2987
8	.2801	.2614	.2427	.2427	.2452	.2614	.3048
9	.2614	.2614	.2427	.2614		.2772	.2427
10	.3584	.3018	.2614	.3361	.3395	.3174	.3174
11	.5281	.3018	.3921	.5601	.5975	.4668	.6224
12	.7282	.3018		.7392	.7468	.7468	.7392
13	.7468	.7392	.5975	.8131	.8131	.8215	.8215
14	.8215	.8131	.5975	.8871	.8871	.8871	.8962
15	.8871	.8871	.5601	.8871	.8871	.961	.961
16	.8962	.8215	.5601	.8131	.8215	.8871	.961
17	.961	.8871	.5788	.8131		.961	.961
18	.8779	.9709		.8871		.9694	.8871
19	.961	.9979		.8871		.9979	1.0164
20	.961	.8413		.9055		1.0164	.9896
21	.7655	.5093		.6602		.8589	.8589
22	.4108	.3326		.3921		.4854	.5175
23	.3921	.3326		.3584		.4668	.4481
24	.4294	.3361		.2801	.3395	.3961	.4481
Max	.961	.9979	.5975	.9055	.8871	1.0164	1.0164
Min	.2614	.2614	.2427	.2263	.2452	.2614	.2427
Avg	.5782	.5185	.3806	.5232	.4888	.5976	.6133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 202 / Station Transformer No I SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0514	.0343	.0343	.0343
2	.0343	.0343	.0343	.0514	.0343	.0343	.0343
3	.0343	.0343	.0343	.0514	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0171	.0343	.0343	.0171	.0171
6	.0343	.0343	.0171	.0171	.0343	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171		.0171	.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0373	.1086	.0344	.0366	.0537	.0171	.0566
12	.0905	.0905	.0514	.0747	.0895	.0514	.0895
13	.1097	.1086	.0686	.0747	.0905	.0905	.0905
14	.1097	.1086	.0686	.0914	.0895	.0905	.1086
15	.0914	.1086	.0686	.0895	.1075	.0905	.1097
16	.0914	.1086	.0347	.1086	.1052	.1086	.1097
17	.1097	.1097	.0686	.1075		.1086	.1097
18	.1086	.1254		.1086		.1075	.1086
19	.1267	.1417		.1254		.1254	.1433
20	.1267	.1075		.1254		.1402	.1433
21	.1086	.1075		.1075		.1417	.124
22	.0686	.0554		.0526		.0754	.056
23	.0347	.0549		.0343		.0377	.0514
24	.0343	.0343		.0457	.0343	.0332	.037
Max	.1267	.1417	.0686	.1254	.1075	.1417	.1433
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0634	.0685	.0373	.0621	.0517	.0608	.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 203 / Station Transformer No II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0566	.0377	.0381	.0566	.0377	.0381
2	.0754	.0566	.0377	.0381	.0566	.0377	.0381
3	.0572	.0566	.0377	.0381	.0566	.0377	.0381
4	.0572	.0572	.0377	.0381	.0572	.0377	.0381
5	.0572	.0566	.0377	.0381	.0566	.0373	.0381
6	.0572	.0572	.0377	.0381	.0572	.0373	.0572
7	.0572	.0572	.0377	.0373	.0572	.056	.0572
8	.0572	.0566	.0377	.0381	.0566	.0381	.0572
9	.0572	.0572	.0381	.0381	.0566	.0566	.0381
10	.0943	.0754	.0381	.0566	.0754	.0566	.0566
11	.1509	.1307	.0762	.1509	.1307	.0934	.1698
12	.2033	.2054	.1463	.1848	.2056	.2054	.2241
13	.2054	.1867	.1463	.1848	.2241	.2241	.2218
14	.2241	.1848	.1478	.2054	.2218	.2241	.2241
15	.2402	.1848	.1478	.2054	.2218	.2195	.2241
16	.2218	.1829	.1307	.2195	.2033	.2012	.2241
17	.2218		.1494	.2033		.2033	.2402
18	.1991	.181		.168		.1646	.2033
19	.2012	.1991		.2033		.1848	.2218
20	.2012	.1829		.1848		.1848	.2218
21	.1867	.1307		.1867		.1848	.1867
22	.1132	.0754		.0943		.0943	.1307
23	.0762	.0566		.0754		.0572	.0762
24	.0572	.0377		.0381	.0566	.0377	.0381
Max	.2402	.2054	.1494	.2195	.2241	.2241	.2402
Min	.0572	.0377	.0377	.0373	.0566	.0373	.0381
Avg	.1304	.1098	.0778	.1126	.1089	.1130	.1277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 207 / Zero Mile

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7392	.6979	.679	.7282	.7442	.7619
2	.7282	.7282	.6979	.679	.7282	.7442	.7619
3	.7282	.7282	.6979	.679	.7095	.7442	.7619
4	.7468	.7282	.679	.679	.7282	.724	.7265
5	.7356	.7167	.6722	.6516	.6979	.724	.7265
6	.6908	.7282		.6516	.6859	.7133	.7059
7	.679	.6979	.6908	.6767	.6859	.695	.7207
8	.679	.679	.6722	.6535	.6859	.7023	.7207
9	.7049	.679	.6722	.7282	.724	.7282	.7421
10	.7964	.7356	.6908	.7733	.8299	.7545	1.0679
11		.7545	.6908	.961	.9431	.8299	1.0349
12	1.0242	.8299	.7167	.9511	.9511	.8779	.9511
13	1.0242	.7392	.6241	.9511	.9114	.9511	.9511
14	1.0242	.7762	.7167	.961	.9511	.9511	.9511
15	1.0242	.788	.7167	.961	.9511	.9511	.961
16	1.0242	.7712	.679	.9511	.9412	.9412	.961
17	1.0242		.6722	.8688		.9412	.9412
18	.8596			.8326		.8505	.8505
19	.8417			.7888		.7975	.8505
20	.7802			.7716		.8063	.815
21	.7522			.7392		.7796	.7362
22	.7577			.7468		.788	.788
23	.7392			.7392		.7619	.7442
24	.7282	.7207		.679	.7095	.7442	.7619
Max	1.0242	.8299	.7167	.961	.9511	.9511	1.0679
Min	.679	.679	.6241	.6516	.6859	.695	.7059
Avg	.8175	.7376	.6867	.7814	.7978	.8019	.8331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 209 / 11 KV Mure Memorial

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0701	.0867	.0686	.0857	.0857	.1052
2	.0914	.0701	.0867	.0686	.0686	.0857	.1052
3	.0724	.0886	.0867	.0686	.0857	.0857	
4	.0914	.0701	.0867	.0686	.0857	.0686	.0857
5	.0724	.0701	.0857	.0686	.0686	.0686	.0857
6	.0724	.0701	.0857	.0686	.0686	.0686	.0857
7	.0724	.0693	.0857	.0686	.0686	.0686	.0686
8	.0686	.0686	.0857	.0686	.0686	.0857	.0686
9	.0876	.0876	.0857	.0857		.1494	.0867
10	.132	.132	.0876	.132	.1509	.1494	.1698
11	.2075	.1509	.1052	.1886	.1698	.112	.2263
12	.2829	.1698	.1063	.2614	.2263	.0924	.2452
13	.2641	.1509	.1075	.2614	.2263	.2477	.2286
14	.2641	.132	.1075	.2614	.2452	.2286	.2286
15		.1307	.1075	.2801	.2452	.2075	.2667
16	.2641	.1307	.1052	.2452	.2266	.2286	.2667
17	.2614	.1698	.0905	.2452		.2286	.2641
18	.1886	.1307		.1524		.1698	.1886
19	.132	.056		.1307		.1509	.1509
20	.1307	.1097		.1086		.1294	.1086
21	.1097	.1063		.1109		.1097	.1086
22	.0886	.104		.0867		.1075	.1075
23	.0886	.0857		.0867		.1063	.0867
24	.0914	.0867		.0633	.0857	.0857	.1052
Max	.2829	.1698	.1075	.2801	.2452	.2477	.2667
Min	.0686	.056	.0857	.0633	.0686	.0686	.0686
Avg	.1402	.1046	.0937	.1354	.1360	.1300	.1497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 211 / 11KV Variety Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.056	.0373	.0377	.0377	.056	
2	.0747	.056	.0373	.0377	.0377	.056	
3	.056	.0377	.0373	.0377	.0373	.056	
4	.0747	.056	.0377	.0374	.0377	.0373	
5	.056	.056	.0377	.0373	.0373	.0373	
6	.056	.056		.0373	.0373	.0373	
7	.0373	.0377	.0381	.0373	.0373	.0549	
8	.0377	.0377	.0377	.037	.0373	.0377	
9	.056	.0377	.0566	.0373	.0377	.0377	.0566
10	.0566	.0566	.0377	.0377	.0554	.0554	.0566
11	.0754	.056	.0377	.0747	.0739	.056	.0747
12	.0924	.0943	.0543	.0739	.0924	.0747	.0747
13	.1109	.0943	.0739	.0739	.0914	.1097	.0747
14	.1109	.0924	.0914	.0924	.0924	.1097	.0934
15	.112	.0747	.0914	.1109	.1109	.1109	.112
16	.1132	.0934	.0739	.0747	.1109	.0934	.112
17	.0943	.0747	.0739	.0934		.0934	.056
18	.0747	.0754		.0747		.0747	.0943
19	.0934	.0943		.0754		.0943	.0934
20	.0934	.0747		.0943		.112	.0943
21	.0943	.056		.0754		.0943	.0943
22	.0754	.0566		.0566		.0747	.0747
23	.0566	.0373		.0566		.0572	.0754
24	.0747	.0373		.0377	.0566	.056	.0566
Max	.1132	.0943	.0914	.1109	.1109	.112	.112
Min	.0373	.0373	.0373	.037	.0373	.0373	.056
Avg	.0771	.0625	.0534	.0600	.0601	.0699	.0809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 201 / 11 KV YASHWANT STEDIUUM SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4287	.3734	.3018	.3734	.4715	.3772
2	.4715	.415	.3734	.2829	.3734	.4715	.3772
3	.4715	.3772	.2801	.2829	.2801	.3772	.3734
4	.415	.3772	.2801	.2829	.2801	.3772	.2801
5	.415	.3772	.2801	.2452	.2801	.6535	.2801
6	.415	.3772	.2801	.2452	.2801	.6535	.2801
7	.415	.3772	.2801	.2452	.2801	.6535	.2801
8	.3734	.3772	.3734	.3395	.3734	.6535	.3734
9	.4668	.415	.3734		.3734	.5601	.4668
10	.4668	.4715	.3734	.2829	.4338	.5601	.4715
11	.5601	.5658		.3772	.5658	.5601	.7167
12	.6535	.6224		.4287	.6036	.4668	.6602
13	.6535	.6602		.4715	.6602	.6979	.7545
14	.7468	.7545		.4715	.6602	.6602	.7545
15	.7468	.695	.4668	.5093	.6602	.7545	.7545
16	.7468	.7922	.3734	.6224	.6979	.7167	.7545
17	.7545	.7468	.3772	.6224	.6602		.7545
18	.6602	.6535	.4338		.6602		.6602
19	.6602	.6535	.4338	.5658	.6602		.6602
20	.5658	.4668	.3772	.5658	.6602		.6602
21	.5658	.4715	.3395	.5658	.5658		.6036
22	.4715	.4668		.4715	.5658		.6036
23	.4715	.3734	.3395	.4668	.4715		.6036
24	.5093	.4715	.3734	.3018	.3734	.4715	
Max	.7545	.7922	.4668	.6224	.6979	.7545	.7545
Min	.3734	.3734	.2801	.2452	.2801	.3772	.2801
Avg	.5494	.5161	.3570	.4068	.4914	.5741	.5435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 202 / 11 KV PUSHPAKUNJ FDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8488	.7468	.7545	.7468	.8488	.7468
2	.8488	.8488	.7468	.7545	.7468	.8488	.7545
3	.7545	.7545	.6535	.6979	.7468	.7545	.7545
4	.7545	.7545	.6535	.6979	.6535	.7545	.7545
5	.7545	.7545	.6535	.6602	.7468	1.0269	.7468
6	.7167	.7545	.7468	.6602	.7468	.9335	.7545
7	.811	.7545	.7468	.7167	.7468	.9335	.7468
8	.8402	.7545	.8402	.7716	.6535	.9335	.8402
9	1.1203	.8488	.7545		.7468	.9335	.8402
10	.8402	.9431	.7468	.9431	.8488	.9335	1.3203
11	1.1203	1.0374		.8488	.9431	.9335	.9431
12	1.1203	1.0751		1.0288	1.0374	.8402	1.0374
13	1.2136	1.0374		1.0374	1.0374	1.094	1.0374
14	1.2136	1.094		1.0059	1.0374	1.1317	1.1317
15	1.2136	1.094	.8402	.9431	1.0374	1.1317	1.1317
16	1.2136	1.094	.7468	1.0374	1.0374	1.1317	1.1317
17	1.226	1.1203	.7545	.9431	1.1317		1.6975
18	1.0374	1.0269	.7167		1.0374		1.0374
19	1.0374	1.0269	.8488	.8488	.9431		1.0374
20	1.0374	.9335	.7545	.9431	.9431		1.0374
21	.9431	.9335	.7545	.8488	.8488		.9431
22	.8488	.9335	.8488	.8488	.9431		.9431
23	.9431	.9335	.8488	.8402	.9431		1.0374
24	.8488	.8488	.7468	.7865	.9431	.9431	
Max	1.226	1.1203	.8488	1.0374	1.1317	1.1317	1.6975
Min	.7167	.7545	.6535	.6602	.6535	.7545	.7468
Avg	.9711	.9252	.7575	.8462	.8853	.9475	.9741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 203 / 11 KV PRESS FDR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.0943		.1132	.0934	.0943	.0934
2	.132	.0943		.0943	.0934	.0943	.0934
3	.0943	.0943		.0943	.0934	.0943	.0934
4	.0943	.0943		.0943	.0934	.0943	.0934
5	.0943	.0943		.0943	.0934	.3734	.0934
6	.0943	.0943		.0943	.0934	.2801	
7	.0943	.0943	.0934	.0943	.0934	.2801	.0934
8	.0934	.0943	.0934	.0943	.0934	.1867	.0934
9	.0934	.0943	.0934		.0934	.1867	.0934
10	.1867	.1886	.0934	.1886	.1886	.1307	.1886
11	.2801	.3018		.2572	.2641	.1494	.2829
12	.3734	.3395		.3772	.3395	.1307	.3772
13	.3734	.3772		.3772	.3772	.5281	.3772
14	.3734	.3772		.3772	.3772		.3772
15	.4668	.3772	.1307	.415	.415	.3772	.3772
16	.4668	.3772	.0934	.3772	.3772	.3772	.3772
17	.3772	.3734	.0943	.3395	.3772		.3772
18	.3395	.2801	.1132		.3772		.3395
19	.2829	.2801	.1132	.1886	.2829		.2829
20	.2263	.1867	.128	.1886	.2829		.2075
21	.1886	.1307	.1132	.1509	.1886		.1886
22	.1509	.0934	.1132	.132	.1509		.1509
23	.1132	.0934	.1132	.0934	.132		
24	.1509	.0943	.0934	.1132	.0934	.0943	
Max	.4668	.3772	.1307	.415	.415	.5281	.3772
Min	.0934	.0934	.0934	.0934	.0934	.0943	.0934
Avg	.2197	.1966	.1057	.1977	.2110	.2170	.2215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 204 / 11 KV VIJAYANAND FDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.7545	.7468	.6602	.7468	.8488	.8402
2	.8488	.6979	.7468	.6602	.7468	.7545	.8402
3	.7545	.6602	.6535	.6602	.6535	.7545	.8402
4	.7545	.6602	.6535	.6224	.6535	.7545	.7468
5	.7167	.6602	.6535	.6224	.6535	1.4003	.7468
6	.6979	.6602	.6535	.6224	.6535	1.307	
7	.6979	.6602	.6535	.5658	.5601	1.1203	.6535
8	.6908	.6602	.5601	.5658	.6535	1.0269	.6535
9	.6535	.6602	.5601		.7468	1.0269	.8402
10	.8402	.8865	.6602	.8488	.9431	.9335	.9431
11	1.0269	1.1317		1.1317	1.1317	.9335	1.0374
12	1.307	1.2826		1.226	1.3203	.8402	1.3203
13	1.4003	1.3203		1.3203	1.3203	1.4146	1.4146
14	1.4937	1.3203		1.3203	1.4146	1.4146	1.5089
15	1.4937	1.3203	.6535	1.3203	1.3769	1.4146	1.5089
16	1.587	1.358	.6535	1.3203	1.4146	1.4146	1.5089
17	1.4146	1.3443	.6602	1.226	1.3203	1.4146	1.5089
18	1.226	1.1203	.6602		1.226		1.226
19	1.3203	1.2136	.7545	1.1317	1.226		1.3203
20	1.226	.9335	.7545	1.0374	1.1317		1.226
21	.9431	.8402	.7545	.9431	1.0374		1.1317
22	.8488	.7468	.7545	.8488	.9431		1.0374
23	.8573	.7468	.7167	.8402	.9431		1.0374
24	.9431	.8488	.7468	.6602		.8488	
Max	1.587	1.358	.7545	1.3203	1.4146	1.4146	1.5089
Min	.6535	.6602	.5601	.5658	.5601	.7545	.6535
Avg	1.0246	.9370	.6825	.9161	.9920	1.0902	1.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 205 / 11KV CHHOTI DHANTOLI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.0934	.0943	.0373	.0943	.0943
2	.1509	.132	.0934	.0943	.0934	.0943	.0934
3	.1509	.132	.0934	.0943	.0934	.0943	.0934
4	.1509	.132	.0934	.0943	.0934	.0943	.0943
5	.1509	.132	.0934	.0943	.0934	.1867	.0934
6	.1132	.132		.0943	.0943	.1867	.0943
7	.1132	.132	.0934	.0943	.0934	.1867	.0934
8	.112	.0943	.0934	.0943	.0934	.0934	.0934
9	.0934	.0943	.0934		.0934	.1867	.1867
10	.1307	.1509	.0934	.1886	.1886	.1307	.1886
11	.1867	.1509		.1886	.1886	.1886	.1886
12	.1867	.2263		.2829	.2263	.1307	.2829
13	.1867	.2452			.2263	.2829	.2829
14	.2801	.2195		.2829	.2263	.2829	.2829
15	.2801	.2263	.1307	.2829	.2641	.2829	.2829
16	.2801	.2452	.0934	.2263	.2263	.3018	.2829
17	.2829	.2427	.0914	.2263	.2829		.2829
18	.1886	.1307	.0943		.2263		.2452
19	.1886	.1494	.0943	.1886	.1886		.2263
20	.1509	.1307	.1463	.1509	.1886		.1886
21	.1509	.0934	.0943	.0943	.1509		.1886
22	.132	.0934	.0943	.0943	.1509		.1886
23	.132		.0943	.0934	.1509		.1886
24	.1509	.132	.0934	.0914	.0934	.132	
Max	.2829	.2452	.1463	.2829	.2829	.3018	.2829
Min	.0934	.0934	.0914	.0914	.0373	.0934	.0934
Avg	.1706	.1543	.0983	.1498	.1569	.1735	.1842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 201 / 11 KV DEO NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.4854	.6535	.6535
2	.5601		.4854	.5975	.6161
3	.5601		.4668	.5975	.5975
4	.5228		.4294	.5975	.5601
5	.4668		.4108	.5975	.5228
6	.4108		.3734	.5601	.4854
7	.3734		.4108	.4481	.4481
8	.3734		.4108	.4481	.4481
9	.4108		.3734	.4481	.4481
10	.4668		.4294	.4668	.4854
11			.4572	.5041	.5601
12			.4572	.5228	.5975
13			.5487	.6161	.6535
14			.5487	.6535	.7095
15			.567	.6535	.7095
16			.567	.6535	.6535
17			.5853	.6908	.6908
18		.5601	.5853	.6348	.6535
19		.5975	.6697	.6535	.7095
20		.6161	.6584	.7095	.7095
21		.6161	.6335	.6535	.7095
22		.5975		.6535	.7468
23		.5601		.7095	.7468
24	.6161		.5228	.6348	.7095
Max	.6161	.6161	.6697	.7095	.7468
Min	.3734	.5601	.3734	.4481	.4481
Avg	.4871	.5912	.5035	.5983	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 202 / 11 KV NERI NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772		.2402	.2614	.2587
2	.2772		.2402	.2614	.2587
3	.2772		.2218	.2241	.2587
4	.2587		.2218	.2241	.2587
5	.2614		.1848	.2241	.2402
6	.2218		.1848	.2241	.2402
7	.1848		.2218	.2241	.2218
8	.1848		.2402	.2241	.2772
9	.2427		.2587	.2614	.2957
10	.499		.499	.5228	.5175
11			.3772	.5175	.5544
12			.5847	.5175	.6348
13			.5658	.5601	.5975
14			.5281	.5601	.5601
15			.5658	.5228	.5975
16			.547	.5175	.5601
17			.5658	.5175	.5601
18		.3696	.4715	.4251	.4668
19		.3326	.3206	.3142	.2801
20		.2587	.2743	.3142	.2801
21		.2587	.2772	.2587	.2801
22		.2587		.2587	.2614
23		.2587	.2801	.2587	.2801
24	.2772		.2402	.2614	.2587
Max	.499	.3696	.5847	.5601	.6348
Min	.1848	.2587	.1848	.2241	.2218
Avg	.2693	.2895	.3527	.3523	.3750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 203 / 11KV ORANGE CITY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7468	.6161	.5975	.6535	.7468	.8029
2	.7468	.7468	.5975	.5975	.6161	.7468	.7842
3	.7468	.7468	.5975	.5975	.5975	.7468	.7468
4	.7095	.6535	.5601	.5975	.5601	.6348	.7095
5	.6535	.6535	.5601	.5601	.4668	.6348	.6535
6	.5601	.5975	.5601	.5601	.4108	.6348	.5601
7	.4668	.5041	.4668	.5041	.4294	.4668	.5041
8	.4854	.5041	.4668	.5228	.4668	.5041	.5041
9	.5601	.5228	.4668	.5228	.5041	.4668	.5041
10	.5975	.5228	.4854	.5228	.5228	.5601	.5601
11	.5601	.6348	.5041	.5228	.6535	.6348	.6161
12	.6348	.6535	.5228	.5975	.7282	.6535	.6348
13	.6908	.6908	.5228		.6908	.6535	.7095
14	.6908	.6908	.5228	.6535	.6722	.7468	.7468
15	.7468	.6908	.5041	.7095	.6722	.7468	.7842
16	.8215	.7095	.5041	.7095	.6535	.7468	.7842
17	.7468	.7282	.5228	.6535	.6535	.6908	.7468
18	.6535	.6535	.5228	.6161	.6348	.6535	.7468
19	.6908	.7095	.5601	.6535	.6535	.7468	.6535
20	.6908	.6535	.5975	.6535	.7468	.7468	.7468
21	.7095	.6535	.5601	.7095	.7842	.7468	.7468
22	.7468	.6535	.6348	.7468		.8402	.8215
23	.7468	.6535	.5975	.7095	.8215	.8589	.8962
24	.8029	.7468	.6161	.5975	.6535	.8029	.8402
Max	.8215	.7468	.6348	.7468	.8215	.8589	.8962
Min	.4668	.5041	.4668	.5041	.4108	.4668	.5041
Avg	.6768	.6550	.5446	.6137	.6194	.6838	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 204 / 11KV JAIL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747		.0747	.0934	.0747
2	.0747		.0747	.0934	.0747
3	.0747		.0747	.0934	.0747
4	.0747		.0747	.0747	.0747
5	.056		.056	.0747	.056
6	.0373		.056	.0747	.056
7	.0373		.0373	.056	.0373
8	.056		.056	.0373	.056
9	.0934		.0747	.0934	.0747
10	.0747		.0747	.0934	.0747
11			.0762	.0934	.0747
12			.0754	.0747	.0747
13			.0754	.0747	.0934
14			.0754	.0747	.0934
15			.0754	.056	.0747
16			.0754	.056	.0747
17			.0572	.056	.0747
18		.0747	.0754	.056	.0747
19		.0747	.0943	.0747	.0747
20		.0747	.0924	.0747	.0934
21		.0747	.0934	.0747	.0934
22		.0747		.0747	.0934
23		.0747		.0747	.0934
24	.0747		.0747	.0934	.0747
Max	.0934	.0747	.0943	.0934	.0934
Min	.0373	.0747	.0373	.0373	.0373
Avg	.0662	.0747	.0725	.0747	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 205 / 11KV KANCHPURA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947		.6468	.7468	.961
2	.7762		.6653	.7468	.924
3	.7392		.6468	.7095	.8871
4	.7023		.6468	.7095	.8316
5	.6838		.6099	.7095	.7392
6	.6468		.5914	.7095	.7023
7	.6283		.5914	.6535	.6838
8	.6099		.6099	.6535	.7023
9	.6838		.6468	.6722	.7392
10	.6838		.7762	.7468	.8131
11			.8299	.8029	.8686
12			.8488	.8402	.8962
13			.8488	.9335	.8962
14			.8676	.924	.9335
15			.9054	.924	1.0269
16			.9242	.924	1.0082
17			.8865	.8871	1.0082
18		.7392	.8488	.8029	.8962
19		.7762	.8402	.8316	.9335
20		.7762		.8871	.9335
21		.7762	.8962	.924	.9335
22		.7762		.924	1.0082
23		.7762		.9795	1.0269
24	.8131		.7023	.8402	.961
Max	.8131	.7762	.9242	.9795	1.0269
Min	.6099	.7392	.5914	.6535	.6838
Avg	.7056	.7700	.7538	.8118	.8881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 206 / 11 KV SAI MANDIR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029		.6348	.7095	.7468
2	.7842		.6161	.7095	.7468
3	.7468		.5975	.7095	.7095
4	.7095		.5975	.7095	.6535
5	.6908		.5601	.6348	.6535
6	.6535		.5228	.6348	.6161
7	.5975		.5228	.5601	.5975
8	.6161		.5601	.5601	.5975
9	.6348		.5975	.5601	.5975
10	.7468		.6722	.6161	.7095
11			.7842	.7095	.8029
12			.7282	.7468	.7842
13			.7655	.7468	.8215
14			.7733	.8775	.8402
15			.8299	.8962	.8962
16			.8215	.8962	.8962
17			.8029	.8215	.8589
18		.7842	.7842	.8215	.8402
19		.8215	.8131	.7842	.8402
20		.8215	.8131	.8402	.8589
21		.8402	.7655	.8402	.8402
22		.7842		.7842	.8402
23		.6908		.8029	.8215
24	.7842		.6722	.7095	.7468
Max	.8029	.8402	.8299	.8962	.8962
Min	.5975	.6908	.5228	.5601	.5975
Avg	.7061	.7904	.6925	.7367	.7632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 201 / 11 KV HAMP YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1827	1.1157	.9055	.8131	.9795	1.1523	1.2254
2	1.1273	1.0242	.8871	.7947	.9055	1.0974	1.1888
3	1.1088	1.0425	.8871	.7947	.8686	1.0608	1.134
4	1.0349	.9145	.8688	.7602	.8402	.9955	1.0608
5	.9774	.8596	.7783	.7602	.7842	.9231	.9877
6	.8869	.823	.7392	.7392	.7282	.8145	.8779
7	.7964	.7865	.6468	.7167	.6468	.724	.7682
8	.7023	.7499	.7207	.6838	.7207	.7499	.7316
9	.7602	.7499	.7602	.7947	.823	.8779	.8596
10	.9425	.9335	.724	.9134	.9145	.9328	1.0164
11	1.0317		.7421	.985	1.0974	1.1157	1.1273
12	1.1643	1.0425	.7421	1.0924	1.0608	1.134	1.1827
13	1.1643	1.0425	.7783	1.0566	1.1706	1.1706	1.2012
14	1.2936	.9694	.7964	1.182	1.1888	1.2803	1.2936
15	1.3937	1.1458	.7964	1.182	1.2254	1.3352	1.4415
16	1.423	1.1458	.724	1.2536	1.2012	1.3717	1.4415
17	1.3352	1.1273	.724	1.0349	1.1827	1.2936	1.419
18	1.134	1.0534	.7602	.8871	1.1273	1.2012	1.2136
19	1.1157	1.2197	.8869	1.2567	1.1827	1.2012	1.3256
20	1.2071	1.0719	.8869	1.2197	1.2197	1.1827	1.307
21	1.2437	.961	.905	1.1273	1.1827	1.2567	1.3443
22	1.2071	1.0164	.8686	1.1273	1.2752	1.3169	1.3443
23	1.2437	.9795	.9055	1.0349	1.2803	1.3535	1.4563
24	1.2936	1.1523	.9795	.8316	1.0164	1.1888	1.3535
Max	1.423	1.2197	.9795	1.2567	1.2803	1.3717	1.4563
Min	.7023	.7499	.6468	.6838	.6468	.724	.7316
Avg	1.1154	.9968	.8089	.9601	1.0259	1.1138	1.1792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 202 / 11KV Chichabhawan
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1616		.9391	.7619	.7973	1.0985	1.2226
2	2.0022		.8682	.7796	.7796	.9922	1.1517
3	1.8959		.8505	.7442	.7619	.9391	1.0454
4	1.8427		.7888	.7011	.7202	.8939	.964
5	1.7002		.8063	.7011	.6859	.7975	.9114
6	1.5249		.7619	.7087	.6687	.7712	.8505
7	1.3672		.7265	.7265	.6379	.7712	.7619
8	1.4706		.7442	.7619	.6733	.7442	.7619
9	1.4022		.7796	.7442	.6762		.7186
10	1.5769		.7802	.703	.6935		.691
11			.8149	.7373	.7888		.8328
12			.7975	.8059	.7888	.8916	.8328
13			.8149	.7545	.8059	.9774	.9568
14		.9391	.7975	.7716	.8402	1.0117	.9922
15		.9922	.8149	.8059	.8745	1.0808	1.0631
16		1.0099	.7455	.8402	.9922	1.1488	1.134
17		1.0454	.7628	.8682	.8682	1.0277	1.0808
18		.9568	.8149	.815	.823	.8745	1.0099
19		1.134	.8842	.9568	.9431	.9431	1.0498
20		1.0454	.9189	.9979	1.0117	1.1694	1.1222
21		.9922	.9015	.9568	1.0117	1.1488	1.1765
22		.9745	.9391	.9745	1.0974	1.258	1.3032
23		.9036	.7796	.8505	1.2048	1.3466	1.448
24	2.3211		.8328	.7973	.8505	1.1517	1.3112
Max	2.3211	1.134	.9391	.9979	1.2048	1.3466	1.448
Min	1.3672	.9036	.7265	.7011	.6379	.7442	.691
Avg	1.7514	.9993	.8193	.8027	.8331	1.0018	1.0163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 204 / 11KV AJNI O/G
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.6972	2.1879	2.0182	
2		2.6406	2.2068	1.9805	
3		2.5463	2.1879	1.9239	
4		2.452	2.0748	1.8861	
5		2.2257	2.0559	1.8296	
6		1.9805	1.8484	1.8296	
7		1.9616	1.7918	1.8673	
8		2.037	1.8107	1.905	
9			1.9427	2.1502	
10	2.452	2.0182	2.0559	2.5019	
11	3.0556	2.5086	2.0936	2.7915	
12	3.0933	2.7726	2.1313	2.9801	
13	3.3573	2.9235	2.1502	3.0556	2.452
14	3.3008	2.9047	2.2822	2.9424	3.3385
15	3.6403	2.9235	2.2257	3.2819	3.546
16	3.8289	2.9047	1.9805	3.1687	
17	3.6214	2.9235	1.9805	3.0744	
18	3.1687	2.7538	2.0182		
19	3.1687	3.0744	2.3954		
20	2.9801	2.0936	2.452		
21	2.9235	2.4897	2.3954		
22	2.9801	2.32	2.32		
23	2.999	2.3954	2.2445		
24		2.8669	2.3388	2.1691	
Max	3.8289	3.0744	2.452	3.2819	3.546
Min	2.452	1.9616	1.7918	1.8296	2.452
Avg	3.1836	2.5397	2.1321	2.4087	3.1122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 205 / 11 KV NAVJEEVAN COLONY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.924	.7392	.7207	.7762	1.0498	1.1765
2	.9511	.9055	.7023	.6653	.7577	1.0136	1.086
3	.9145	.8686	.7023	.6468	.7023	.905	1.0498
4	.8413	.7392	.6516	.6154	.6908	.8326	.9593
5	.7421	.6653	.5973	.5792	.6722	.7602	.8688
6	.6697	.6283	.5729	.5544	.6161	.724	.7783
7	.6154	.6283	.5544	.5359	.5729	.6697	.6878
8	.6036	.5914	.5544	.6099	.5729	.6516	.7059
9	.6154	.6283	.5544	.6099	.6767	.695	.695
10	.695	.6722	.6089	.7316	.7133	.8145	.8501
11	.7783	.7392	.5194	.8048	.9145	.8869	.9425
12	.7865	.7947	.6089	.8779	.9328	.8869	.9979
13	1.086	.7947	.6089	.9145	.9511	.9593	1.0719
14	1.1157	.8131	.6447	.9511	.9877	1.0317	1.1088
15	1.2489	.9055	.6268	.9694	.9694	1.0679	1.1273
16	1.2437	.9055	.5373	.9877	1.0349	1.0498	1.1458
17	1.1827	.8048	.5552	.8871	.9979	.9795	1.1389
18	.7207	.7316	.6268	.7577	.8686	.924	1.0082
19	.8501	.8413	.8238	.9795	.9425	.9979	1.0642
20	.8686	.7865	.8238	.924	1.0349	1.0719	1.0269
21	.8871	.7499	.7343	.9425	1.0164	1.0719	1.1016
22	.9795	.7865	.7762	.9425	1.0534	1.086	1.2136
23	.9795	.7577	.8686	.924	1.1584	1.3032	1.1949
24	1.0791	2.1807	.7577	.7577	.9425	1.1765	1.2382
Max	1.2489	2.1807	.8686	.9877	1.1584	1.3032	1.2382
Min	.6036	.5914	.5194	.5359	.5729	.6516	.6878
Avg	.8934	.8268	.6563	.7871	.8565	.9421	1.0099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 206 / 11 KV PANDEY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0485	.7577	.6283		.9877	1.0608
2		1.9387	.7023	.6283	.6838	.8962	1.0242
3		1.8656	.6838	.5914	.6283	.823	.9328
4		1.829		.543	.6161	.788	.8962
5		1.7558	.8145	.543	.6161	.7421	.8326
6		1.4815		.5175	.5228	.6878	.7316
7		1.3535	.6283	.5175	.5729	.6335	.6219
8		1.3352	.6838	.6099	.6653	.6767	.6584
9		1.4083	.6036	.6653	.7421	.7059	.724
10		1.531	.6268	.7602	.8326	.8145	.7392
11		1.6827	.6984	.8507	.905	.9412	.9979
12		1.8656	.6984	.9231	.9412	.9412	1.0903
13		1.9022	.6805	.9593	.9412	1.0136	1.1088
14		1.0059	.6984	.905	.9774	.9955	1.1088
15	1.1946	1.0164	.7164	.9593	1.0136	1.1584	1.2567
16	1.1765	1.0719	.6268	.9593	.9979	1.1403	1.2567
17	1.0791	.9593	.5731	.961	1.0349	1.0719	1.1576
18	2.0668	.8869	.6268	.8871	.9425	.961	1.1016
19	2.1033	.9774	.6984	.8871	.9795	.9795	1.1016
20	2.1948	.9694	.7343	.8501	1.0349	1.0534	1.1763
21	2.0851	.8326	.7164	.8686	.9979	1.0164	1.1016
22	2.1582	.7964	1.6632	.8501	1.0719	1.1157	1.2323
23	2.2131	.7947	.7023	.8316	1.0974	1.2254	1.307
24		2.1582	.7947	.7023	.7577	1.0608	1.1706
Max	2.2131	2.1582	1.6632	.961	1.0974	1.2254	1.307
Min	1.0791	.7947	.5731	.5175	.5228	.6335	.6219
Avg	1.8079	1.3944	.7331	.7666	.851	.9346	1.0162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 207 / 11 KV Wireless

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5415	.3734	.2987	.3174	.4481	.4668
2	.4668	.4854	.4108	.3174		.3921	.4294
3	.4294	.4668	.3361	.2427	.2772	.3921	.4024
4	.4108	.4108	.362	.2172	.2561	.3439	.3841
5	.3801	.3734	.3439	.2172	.2378	.3258	.3292
6	.3439	.3361	.3142	.2561	.2427	.3077	.3174
7	.3077	.2614	.2801	.2561	.2427	.2715	.2987
8	.3547	.3174	.2614	.2402	.2218	.2614	.2987
9	.3258	.3174	.2987	.2427	.2427	.2427	.2378
10	.3921	.3292	.3292	.2427	.2614	.2614	.2614
11	.4163	.4108	.3292	.2378	.2801	.2743	.2801
12	.1494	.4481	.3292	.2743	.2561	.2743	.2957
13	1.086	.4668	.3547	.2926	.2743	.3109	.2957
14	1.6244	.4481	.3475	.2743	.2743	.3109	.3547
15	1.5746	.499	.3292	.2926	.2926	.3475	.3921
16	1.6057	.5175	.3174	.2926	.3142	.3658	.3696
17	1.5497	.5041	.1646	.2772	.2772	.3326	.3547
18	.4481	.4294		.2587	.2587	.3326	.3174
19	.4668	.5415	.3109	.3326	.3142	.3142	.3361
20	.5601	.5228	.3292	.3511	.3511	.3881	.3921
21	.4854	.4481		.3511	.3881	.3881	.4108
22	.5415	.4668	.1867	.3696	.4066	.4294	.5228
23	.5788	.5041	.1867	.3696	.5228	.5228	.5975
24	.6535	.5415	.4481		.3511	.4668	.5228
Max	1.6244	.5415	.4481	.3696	.5228	.5228	.5975
Min	.1494	.2614	.1646	.2172	.2218	.2427	.2378
Avg	.6562	.4412	.3156	.2828	.2983	.3460	.3695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 211 / 11KV Congressnagar-I
outgoing Feeder KV- 11 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	1.1694	1.1506	1.0562	1.1317	1.3392	1.3769
2	1.1506	1.1128	1.094	.9619	1.0751	1.226	1.3014
3	1.1694	1.1128	.9808	.9054	.9808	1.1317	1.226
4	1.1506	.9431	.9431	.8676	.9431	1.0562	1.0608
5	1.0751	.9431	.9431	.8299	.9242	1.0185	1.094
6	1.0751	.9431	.8865	.8299	.9619	1.0185	1.0374
7	1.1317	.9997	.8488	.8676	.9242	1.0185	.9997
8	1.2071	1.0185	1.0185	.9619	1.0562	.9997	1.1317
9	1.2826	1.2071	1.1317	1.0374	1.1883	1.2071	1.226
10	1.4901	1.3014	1.1694	1.226	1.2449	1.3769	1.3203
11	1.6221	1.4901	.9619	1.1883	1.4901	1.4523	1.4901
12	1.7164	1.5655	1.226	1.4523	1.5278	1.5844	1.5466
13	1.8484	1.7541	1.1694	1.4901	1.5655	1.7164	1.7164
14	2.0559	1.7918	1.2449	1.4901	1.5844	1.6787	1.7541
15	2.0559	1.7541	1.2826	1.5844	1.6221	1.7918	1.9239
16	1.9993	1.905	1.1317	1.7164	1.6975	1.7918	1.8673
17	1.9616	1.7353	1.1506	1.5466	1.6221	1.6409	1.773
18	1.6598	1.6409	1.0374	1.2637	1.5278	1.5844	1.6409
19	1.5844	1.6221	1.1694	1.2449	1.5089	1.5655	1.6032
20	1.5655	1.4335	1.1883	1.4146	1.4712	1.5466	1.7353
21	1.4335	1.2637	1.094	1.3392	1.4523	1.5466	1.5089
22	1.3957	1.2637	.9997	1.2826	1.4335	1.358	1.5278
23	1.2637	1.3203	1.226	1.4335	1.4335	1.6032	1.6409
24	1.3769	1.2826	1.2826	1.1694	1.1883	1.4146	1.4712
Max	2.0559	1.905	1.2826	1.7164	1.6975	1.7918	1.9239
Min	1.0751	.9431	.8488	.8299	.9242	.9997	.9997
Avg	1.4806	1.3572	1.0971	1.2150	1.3148	1.4028	1.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATRAPATI

Feeder No / Name : 212 / 11KV chatrapati-
Congressnagar Feeder KV- 11 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	.9997	.8676	.8299	.8865	1.0374	1.094
2	.9808	.9619	.811	.8299	.7922	.9431	1.0562
3	.9054	.9054	.8488	.7356	.811	.9431	.9619
4	.8865	.8299	.7545	.7167	.7545	.8488	.9242
5	.8676	.7922	.6979	.7167	.7167	.8299	.8865
6	.8299	.7922	.6602	.679	.7167	.7922	.8299
7	.811	.7545	.6602	.6602	.7167	.7922	.7733
8	.7545	.7545	.6602	.7356	.7922	.811	.811
9	.8865	.811	.7167	.8488	.9242	.9242	.9431
10	1.1883	1.0562	.7922	1.094	1.1506	1.1317	1.2449
11	1.5844	1.5655	.8488	1.4523	1.5844	1.5844	1.6787
12	1.8673	1.7918	.9054	1.7164	1.8107	1.8484	1.9805
13	2.0559	1.8673	.8865	1.7918	1.9805	2.0559	1.9805
14	2.1313	1.8296	.9054	1.9427	2.037	1.9805	2.1125
15	2.1502	1.8484	.9808	1.9993	1.9993	2.0748	2.1313
16	2.3765	1.9427	.811	3.1687	1.9805	2.1125	2.2634
17	2.1313	1.8673	.8299	1.6787	1.9239	1.9616	2.0748
18	.6413	1.6221	.8488	1.4901	1.773	1.7918	1.9239
19	1.6975	1.6598	.9619	1.5466	1.6975	1.7164	1.8107
20	1.4523	1.3014	.9242	1.3392	1.4335	1.4901	1.5655
21	1.2071	1.0562	.9054	1.1694	1.358	1.358	1.3769
22	1.1317	.9431	.8865	1.1317	1.1506	1.2826	1.3014
23	1.1694	.9431	.9054	1.0374	1.226	1.2826	1.358
24	1.1506	1.0562	.9431	.8488	.9997	1.1317	1.1883
Max	2.3765	1.9427	.9808	3.1687	2.037	2.1125	2.2634
Min	.6413	.7545	.6602	.6602	.7167	.7922	.7733
Avg	1.3274	1.248	.8339	1.2566	1.3007	1.3635	1.4280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 405 / 33kv Congress Nagar O/G SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9424		2.7161	2.2634	2.7161	3.1687	3.3951
2	2.9424		2.4897	2.2634	2.2634	2.9424	3.1687
3	2.7161	2.7161	2.4897	2.037	2.4897	2.7161	2.9424
4	2.4897	2.3765	2.2634	2.037	2.3765	2.7161	2.7161
5	2.4897	2.2634	2.2634	1.8107	2.2634	2.2634	2.4897
6	2.2634	2.2634	2.037	1.8107	2.2634	2.2634	2.2634
7	2.2634	2.2634	2.037	2.037	2.2634	2.2634	2.2634
8	1.358	2.2634	2.037	2.2634	2.2634		2.4897
9	2.7161	2.4897	2.037	2.4897	2.2634	2.4897	2.7161
10	2.9424	2.6886	2.4897	2.9424	2.9424	2.9424	3.1687
11	3.6214	3.1687	2.4897	3.1687	3.3951	3.6214	3.8477
12	3.8477	3.3951	2.4897	3.6214	3.6214	3.8477	4.0741
13	4.0741	3.8477	2.4897	3.6214	3.8477	4.0741	4.0741
14	4.3004	3.8477	2.4897	3.6214	4.0741	4.3004	4.3004
15	4.3004	4.0741	2.7161	3.8477	2.4897	4.5268	4.7531
16	4.5268	4.3004	2.4897	3.8477	2.4897	4.3004	4.7531
17	4.0741	4.0741		2.2634	3.8477	4.3004	4.5268
18	3.8477	3.8477	2.4897	3.3951	3.8477	4.0741	4.3004
19	3.8477	4.0741	2.4897	3.6214	3.8477	3.8477	4.3004
20	3.6214	3.3951	1.1317	3.3951	3.8477	3.8477	4.3004
21	3.3951	2.7161	1.1317	3.1687	3.6214	3.6214	4.0741
22	3.3951	2.7161	2.7161	2.9424	3.3951	3.3951	3.6214
23	3.3951	2.9424	2.7161	3.1687	3.3951	3.6214	3.8477
24	3.1687	3.3951	2.7161	2.4897	2.9424	3.3951	3.6214
Max	4.5268	4.3004	2.7161	3.8477	4.0741	4.5268	4.7531
Min	1.358	2.2634	1.1317	1.8107	2.2634	2.2634	2.2634
Avg	3.2725	3.1418	2.3224	2.8386	3.0320	3.4148	3.5837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 201 / 11KV A.I.R.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.3392	1.1389	.9808	1.1763	1.358	1.4901
2	1.4146	1.2449	1.1203	.9431	1.1203	1.3203	1.4901
3	1.3203	1.1694	1.0269	.9431	1.1203	1.226	1.4146
4	1.226	1.1317	1.0269	.8676	1.0269	1.1317	1.4003
5	1.1317	1.094		.8676	.9335	1.5123	1.3203
6	1.094	1.094	.9335	.7888	.9335	1.3443	1.1203
7	.9997	.9431	.8962	.9054	.8962	1.419	1.0456
8	.9709	.9054	.8215	1.0087	.8865	1.3817	.9997
9	.9522	.9997	.8215		.9896	1.3443	1.0185
10	1.0829	1.1317	.8962	1.0374	1.1694	1.419	1.226
11	1.307	1.226		1.1506	1.2071	1.5123	1.3769
12	1.3817	1.3014		1.2637	1.2071	1.5497	1.5278
13	1.419	1.39		1.2449	1.3203	1.475	1.4901
14	1.419	1.4335		1.2449	1.358	1.5089	1.4575
15		1.5466	.9896	1.3957	1.3203	1.5844	1.6598
16	1.5123	1.5466	.9335	1.3203	1.4146	1.6221	1.6598
17	1.4335	1.4937	.9054		1.4335		1.5844
18	1.3014	1.3443	.9431		1.226		1.4335
19	1.358	1.4377	.9808	1.2637	1.3203		1.3769
20	1.2826	1.1576	.8779	1.226	1.3769		1.358
21	1.3014	1.0456	.9054	1.1694	1.358		1.3769
22	1.2826	1.0829	.9808	1.2637	1.4146		1.5089
23	1.358	1.1016	1.0185	1.2637	1.4335		1.6032
24	1.4712	1.3392	1.1389	1.0185	.1188	1.4523	
Max	1.5123	1.5466	1.1389	1.3957	1.4335	1.6221	1.6598
Min	.9522	.9054	.8215	.7888	.1188	1.1317	.9997
Avg	1.2798	1.2292	.9661	1.1032	1.1567	1.4213	1.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 202 / 11 KV KALIMATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.3375	1.3256	1.1694	1.4377	1.6221	1.6221
2	1.4146	1.3392	1.307	1.1694	1.307	1.5089	1.6221
3	1.4146	1.2826	1.2136	1.094	1.307	1.4146	1.5089
4	1.3203	1.226	1.1203	1.094	1.2136	1.3392	1.4937
5	1.226	1.1694	1.0269	1.094	1.2449	2.0165	1.4146
6	1.226	1.1317	.9896	1.1317	1.2323	1.8111	1.307
7	1.1694	1.1317	.9896	1.2071	1.251	1.9418	1.3443
8	.2427	1.1694	1.0082	1.3203	1.251	1.8671	1.2696
9	1.4563	1.3957	1.1016		1.3817	1.7924	1.475
10	1.4937	1.4335	1.1203	1.4335	1.5844	1.7177	1.6787
11	1.6617	1.6787		1.5278	1.6975	1.8673	1.8861
12	1.8484	1.905		1.7541	1.8296	1.8298	1.9427
13	1.8858	1.8484		1.5844	1.7918	1.9805	2.0182
14	1.9978	1.9805		1.6975	1.8484	1.869	2.0748
15	2.0911	1.9805	1.4377	1.9239	1.9239	2.1691	2.1502
16	2.1285	2.0182	1.2449	1.9239	1.9204	2.1125	2.1502
17	2.0182	1.8671	1.2254	1.6409	1.9616		2.1502
18	1.7164	1.7924	1.2637		1.905		2.0182
19	1.7541	1.9605	1.4146	1.7918	2.0748		1.8107
20	1.6598	1.531		1.6598	1.905		1.8107
21	1.5655	1.4563		1.6409	1.8673		1.6598
22	1.6221	1.4377	1.4266	1.5466	1.8484		1.773
23	1.5466	1.2193	1.3352	1.5123	1.8296		1.773
24	1.5089	1.4146	1.3256	1.2071	1.4377	1.7353	
Max	2.1285	2.0182	1.4377	1.9239	2.0748	2.1691	2.1502
Min	.2427	1.1317	.9896	1.094	1.2136	1.3392	1.2696
Avg	1.5616	1.5295	1.2154	1.4602	1.6272	1.7997	1.7371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 203 / 11 KV ITI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0373			.0377	.0373
2		.0377	.0373		.0373		.0373
3		.0377	.0373	.0377		.0377	.0373
4		.0377	.0373	.0377	.0373	.0377	.0373
5		.0343	.0373	.0377	.0373	.0934	.0373
6		.0377	.0373	.0377	.0373	.0747	.0373
7		.0377	.0373	.0377	.0373	.056	.0373
8		.0377	.0373	.0377	.0373		.0373
9		.0377	.0373		.0373	.0373	.0373
10			.0373	.0566	.0377	.0373	.0377
11		.0377		.0943	.0943	.0373	.0943
12		.0377		.0943	.0943	.0373	.0943
13		.0377		.0943		.0943	.0857
14	.0934	.0377			.0943	.0943	.0943
15	.0934	.0366	.0373		.0943	.0943	.0943
16	.0934	.0377	.0373	.0943	.0943	.0943	.0857
17	.0943	.0373	.0377	.0943	.0943		.0943
18	.0566	.0373	.0377		.0943		.0754
19	.0377	.0373	.0377	.0377	.0566		.0377
20	.0343	.0373	.0366	.0377	.0377		.0377
21	.0343	.0373		.0377	.0377		.0377
22	.0377	.0373		.0377	.0377		.0377
23	.0377			.0373	.0377		.0377
24		.0377	.0373	.0377	.0373	.0377	
Max	.0943	.0377	.0377	.0943	.0943	.0943	.0943
Min	.0343	.0343	.0366	.0373	.0373	.0373	.0373
Avg	.0613	.0374	.0373	.0545	.0573	.0601	.0557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 204 / SARAF COURT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.3961	.3018	.3361	.3584	.4338
2	.415	.3395	.3772	.3018	.1867	.3206	.4294
3	.3772	.3206	.3734	.3018	.1867	.3018	.3734
4	.3772	.2829	.2801	.3018	.1867	.2829	.3734
5	.3018	.2829	.2801	.2641	.2241	.8589	.2801
6	.3018	.2829	.2427	.2641	.2241	.8029	.2829
7	.3018	.2401	.2427	.2641	.2241	.8029	.2614
8	.2614	.2452	.2614	.2452	.2241	.7468	
9	.2987	.3018	.2614	.3018	.2801	.5415	.2801
10	.4668	.4338	.2614	.4338	.5281	.5041	.4715
11	.7095	.6602		.6224	.6413	.4527	.679
12	.7468	.6979		.7133	.7922	.4527	.7922
13	.8215	.7922		.7922	.7545	.8488	.7922
14	.8962	.7922		.7922	.8676	.8865	.8299
15	.8962	.7316	.4108	.8488	.8299	.8865	.8488
16	.8962	.811	.3206	.8488	.7922	.8488	.8676
17	.8488	.7468	.3584	.7167	.8299		.8676
18	.7733	.7468	.3206		.7733		.7922
19	.811	.7655	.3772	.7356	.8299		.8676
20	.7167	.5601	.3395	.6001	.7167		.7733
21	.5658	.4294	.3395	.4715	.5847		.6036
22	.4715	.3734	.3658	.3961	.4527		.4904
23	.4715	.3174	.3292	.3921	.4527		.4904
24	.4527	.4338	.3921	.3018	.3361	.3961	
Max	.8962	.811	.4108	.8488	.8676	.8865	.8676
Min	.2614	.2401	.2427	.2452	.1867	.2829	.2614
Avg	.5664	.4986	.3265	.4875	.5106	.6055	.5855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 207 / SUBSTATION FEEDER

Feeder KV- 11 / OUTGOING

DATE	12-JUN-18
HR	Load (MW)
10	.1509
Max	.1509
Min	.1509
Avg	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 401 / 33KV CHHATRAPATI i/c
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3385	3.2253	2.8567	2.4897	2.999	3.3951	3.5648
2	3.2253	2.9424	2.8006	2.3594	2.6595	3.1687	3.5648
3	3.1121	2.8292	2.6326	2.3765	2.6595	2.999	3.3385
4	2.9424	2.6595	2.4646	2.32	2.3525	2.7726	3.3385
5	2.6595	2.6029	2.2405	2.2634	2.4086	4.481	3.0556
6	2.6029	2.5463	2.1285	2.32	2.4086	4.0329	2.7726
7	2.4897	2.3765	2.1285	2.4331	2.3525	4.201	2.6886
8	1.4563	2.3765	2.1285	2.6029	2.3525	3.9769	2.5206
9	2.6886	2.7161	2.1845	2.6595	2.6886	3.6408	2.8006
10	3.0247	2.9081	2.2965	2.9424	3.3385	3.6408	3.3951
11	3.6408	3.5648		3.3951	3.6214	3.8089	4.0175
12	3.9769	3.9043		3.8477	3.9043	3.8649	4.357
13	4.0889	4.0741		3.7346	3.9609	4.4702	4.4136
14	4.313	4.2438		3.8477	4.1872	4.5268	4.5833
15	4.537	4.3004	2.8567	4.2438	4.1872	4.7531	4.7531
16	4.537	4.4136	2.4646	4.1872	4.3004	4.6965	4.7531
17	4.4136	4.0889	2.5463	2.4331	4.3004		4.5833
18	3.8477	3.8649	2.5463		4.0175		4.3004
19	3.9609	4.145	2.8292	3.8477	4.3004		4.0741
20	3.678	3.2487	1.3014	3.5648	4.0175		3.9609
21	3.4517	2.9127	1.3014	3.3385	3.8477		3.678
22	3.3951	2.8567	2.8858	3.2253	3.7912		3.7912
23	3.3951	2.9127	2.6886		3.7346		3.9043
24	3.4517	3.2253	2.8567	2.5463	2.999	3.6214	
Max	4.537	4.4136	2.8858	4.2438	4.3004	4.7531	4.7531
Min	1.4563	2.3765	1.3014	2.2634	2.3525	2.7726	2.5206
Avg	3.4261	3.2891	2.4069	3.0445	3.3912	3.8853	3.7482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 402 / 33KV SITABUILD I/C
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18
HR	Load (MW)
17	.0509
Max	.0509
Min	.0509
Avg	.0509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 201 / 11 KV BANK OF MAHARASHATRA
FDR Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)
1		.0943
2		.0943
3		.0943
4		.0943
5		.0943
6		.0943
7		.0943
8		.0943
9		.0943
10		.1509
11		.2829
12		.3772
13		.415
14		.415
15		.415
16		.3961
17		.3395
18		.3206
19	.3961	.3395
20	.3961	.3018
21	.3206	.1886
22	.2641	.2075
23	.1886	.1886
24		.0943
Max	.3961	.415
Min	.1886	.0943
Avg	.3131	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 202 / 11KV REGENT -I o/g
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8776	.8002	.7167	.811	.8764	.8676
2	.8192	1.6058	.8002	.7167	.7922	.8192	.8676
3	.8192	1.6058	.8002	.7167	.7545	.8192	.8488
4	.8192	1.5684	.7811	.6979	.7545	.8192	.8488
5	.8192	1.5684	.7621	.7167	.7545	.8002	.8299
6	.7621	1.4564	.743	.7356	.7356	.8002	.811
7	.8002	1.531	.743	.7356	.7545	.8002	.8299
8	.7733	1.4936	.743	.7356	.7922	.8383	.8299
9	.7922	.7655	.7621	.7545	.8488	.8192	.8676
10	.9335	.8215	.7621	.8865	.9619	.9145	1.0185
11	1.1883	1.0185	.8029	1.1812	1.226	1.1883	1.2765
12	1.3203	1.0669	.8775	1.2574	1.2449	1.2449	1.3336
13	1.3203	1.105	.8775	1.2955	1.2637	1.3014	1.3336
14	1.3392	1.105	.8962	1.3146	1.2826	1.2637	1.3146
15	1.3957	1.094		1.3527	1.2637	1.3203	1.3717
16	1.3392	1.0562	.8589	1.2765	1.2637	1.2637	1.4098
17	1.3203	1.0562	1.7178	1.2574	1.2449	1.2637	1.2955
18	1.1763	1.105	.8676	1.0456	1.1812	1.1317	1.1883
19	1.1016	1.1622	.9242	1.0642	1.1431	1.094	1.1694
20	1.0642	1.086	.9242	.9709	1.1241	1.1694	1.1241
21	1.0269	.9526	.8676	.9149	1.0669	1.0751	1.0562
22		.8764	.7922	.9149	1.0098	.9808	1.0185
23	.8589	.8573	.7733	.8402	.9335	.9242	.9808
24	.9526	.8402	.7811	.7545	1.6058	.9335	.9054
Max	1.3957	1.6058	1.7178	1.3527	1.6058	1.3203	1.4098
Min	.7621	.7655	.743	.6979	.7356	.8002	.811
Avg	1.0244	1.1531	.8547	.9522	1.0339	1.0192	1.0582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 203 / 11 KV SANSKRUTIK SANKUL SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.168	.0943	.0943	.1494	.1698	.1698
2	.1509	.168	.0943	.0943	.1494	.1698	.1509
3	.1509	.1494	.0943	.0943	.1307	.1698	.1509
4	.132	.1494	.0934	.0943	.0934	.1698	.1509
5	.132	.1494	.0943	.0943	.1494	.1509	.1509
6	.1509	.168	.0943	.0943	.0934	.132	.1886
7	.132	.0934	.0943	.0943	.0934	.132	.1509
8	.2641	.2614	.1132	.2641	.4854	.2641	.2263
9	.3395		.1886	.3206	.7095	.3395	.3395
10	.4338	.3734	.2614	.415	.4527	.4527	.4715
11	.5658	.4904	.2614	.4904	.5847	.5847	.6224
12	.5847	.5093	.2614	.5658	.6036	.6224	.6602
13	.6413	.5415	.2987	.6413	.6036	.6413	.679
14	.6224	.547	.3734	.5658	.6224	.6602	.6602
15	.6979	.5658	.362	.6413	.6224	.6602	.7167
16	.7356	.6036	.3921	.6413	.679	.6602	.6602
17	.6224	.5658	.3361	.6413	.6413	.6413	.679
18	.5601	.5658	.2829		.6979	.6413	.6602
19	.6348	.6602	.3772		.6979	.7167	.6602
20	.5228	.5281	.3395		.547	.6036	.547
21	.3734	.3584	.2829		.3772	.3961	.415
22		.2829	.2641		.3018	.3395	.3395
23	.1867	.1698	.1698	.168	.2075	.1886	.2263
24	.1509	.168	.0943	.0943	.1494	.1698	.1886
Max	.7356	.6602	.3921	.6413	.7095	.7167	.7167
Min	.132	.0934	.0934	.0943	.0934	.132	.1509
Avg	.3885	.3581	.2216	.3215	.4101	.4032	.4110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 204 / 11 KV UNIVERSITY LIBRARY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5228	.4854	.4338	.5041	.5415	.5658
2	.5415	.4854	.4854	.415	.4854	.4854	.5658
3	.5228	.4854	.4481	.415	.4668	.4668	.5281
4	.5041	.4854	.4294	.3961	.4481	.4481	.5281
5	.4854	.4668	.4108	.3961	.4481	.4294	.5093
6	.4481	.4108	.4108	.3772	.4294	.4294	.4904
7	.4294	.4108	.3921	.415	.4108	.4294	.4527
8	.4904	.4108	.4108	.4715	.4854	.4854	.5847
9	.6036	.4854	.5041	.547	.7095	.5788	.6979
10	.7655	.6535	.4854	.7922	.7733	.8589	.8676
11	.9431	.8299	.4854	.8962	.9619	1.0185	.9896
12	.9997	.8402	.4854	.9149	.9619	1.094	1.0082
13	1.094	.9335	.4668	1.0082	.9808	1.0562	1.1389
14	1.094	.9709	.5041	.9709	1.0562	1.0185	1.1389
15	1.1128	.9619	.4854	1.0642	1.0562	1.1317	1.1389
16	1.1694	.9431	.4108	1.0456	.9808	1.0185	1.0829
17	1.094	.9242	.4668	.9335	.9619	1.0374	1.0642
18	.8962	.8589	.415	.8589	.9522	.9431	.9997
19	.6908	.8402	.4715	.8402	.8589	.9054	.9997
20	.6908	.7095	.415	.6697	.7282	.7356	.8402
21	.6161	.5415	.4527	.5415	.6161	.6224	.7167
22		.5041	.4338	.5041	.5975	.6224	.6979
23	.5601	.5041	.4715	.5415	.5601	.5658	.6413
24	.5975	.5601	.5228	.4527	.4854	.5601	.6224
Max	1.1694	.9709	.5228	1.0642	1.0562	1.1317	1.1389
Min	.4294	.4108	.3921	.3772	.4108	.4294	.4527
Avg	.7352	.6558	.4562	.6625	.7050	.7284	.7862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 205 / 11 KV APANA BHANDAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5975	.5068	.415	.5068	.543	.7167
2	.4938	.5601	.4887	.415	.4481	.5249	.7167
3	.4755	.5228	.4887	.3961	.4108	.4887	.679
4	.4572	.5041	.4572	.3961	.4108	.4706	.6602
5	.439	.4854	.4207	.3961	.3921	.4525	.6224
6	.4024	.4481	.4024	.3772	.4108	.439	.5658
7	.3841	.4294	.4024	.3961	.3921	.4207	.5093
8	.3961	.4108	.4024	.3395	.4108	.4163	.5281
9	.415	.4294	.3982	.415	.4108	.4163	1.358
10	.4024	.4481	.4163	.4527	.811	.4706	.4527
11	.4338	.5093	.5041	.4706	.5281	.5658	.5249
12	.5658	.6154	.4668	.5611	.6413	.6413	.6154
13	.5658	.6154	.4668	.6154	.6413	.6602	.6878
14	.6224	.6878	.5228	.6335	.6602	.7733	.7059
15	.679	.7167	.503	.6697	.7167	.8865	.7421
16	.7922	.6602		.6878	.7167	.9431	.7316
17	.7733	.6413	.5228	.6697	.7167	.8676	.7421
18	.6908	.6878	.547	.7095	.6878	.8676	.6602
19	.7842	.8145	.6224	.7468	.7602	.9431	.7545
20	.7282	.7421	.6036	.4405	.7783	.9431	.695
21	.6908	.6154	.5658	.6348	.6878	.8865	.7545
22	.6348	.5611	.4904	.6161	.6335	.7733	.6979
23	.5975	.543	.4527	.5601	.6335	.7733	.679
24	.6219	.5975	.4887	.4527	.4854	.5792	.7545
Max	.7922	.8145	.6224	.7468	.811	.9431	1.358
Min	.3841	.4108	.3982	.3395	.3921	.4163	.4527
Avg	.5672	.5768	.4844	.5195	.5788	.6561	.6898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 206 / 11 KV LANDMARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2801	.2829	.3395	.2987	.3206	.3018
2	.2641	.2427	.2641	.3018	.2801	.3206	.3018
3	.2641	.2427	.2829	.2829	.2715	.3206	.3018
4	.2641	.2427	.2829	.2829	.2801	.3206	.3018
5	.2641	.2614	.2641	.2829	.2801	.3018	.3018
6	.2641	.2427	.2641	.2641	.2987	.2829	.2829
7	.2829	.2427	.2641	.2641	.3361	.2829	.3018
8	.2829	.2614	.2641	.3395	.3361	.3395	.3395
9	.3584	.3174	.2829	.4527		.415	.4338
10	.6979	.7095	.4338	.7545	.7733	.7167	.7733
11	1.1317	.8865	.7468	1.0185	1.0562	1.0374	1.1506
12	1.1317	.9997	.7842	1.0751	1.1694	1.094	1.226
13	1.1128	1.0374	.8402	1.1506	1.1506	1.1694	1.2071
14	1.1128	1.1128	.7888	1.1128	1.1506	1.226	1.226
15	1.1506	1.1317	.9335	1.1694	1.2071	1.2071	
16	1.2071	1.094	.8589	1.1694	1.1506	1.2637	1.226
17	1.1506	1.094	.8775	1.0751	1.2071	1.2071	1.2449
18	1.0269	1.1128	.8676	1.0269	1.1128	1.094	1.1694
19	1.0456	1.0562	.8676	.9522	1.094	1.1317	1.0374
20	1.0082	.9431	.9054	.9149	1.0562	1.0562	.9997
21	.8145	.8676	.8488	.8589	1.0185	.9997	1.0185
22		.6979	.6413	.6908	.7356	.7167	.7733
23	.3734	.4527	.4527	.3801	.5658	.4904	.415
24	.3395	.3174	.2829	.3395	.3361	.4715	.3395
Max	1.2071	1.1317	.9335	1.1694	1.2071	1.2637	1.2449
Min	.2641	.2427	.2641	.2641	.2715	.2829	.2829
Avg	.6875	.6603	.5659	.6875	.7463	.7411	.7249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 207 / 11 KV Poonam Mall-Bhgwa SHEDDABLE URBAN
Ghar- Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0082	.905	.8676	.9522	1.1222	1.2449
2	1.0242	.9335	.8869	.811	.9335	1.0498	1.1694
3	1.0059	.8962	.8326	.7922	.8962	.9955	1.1317
4	.9877	.8589	.8048	.7922	.8215	.9593	1.094
5	.9694	.8402	.7865	.7545	.7842	.905	1.0185
6	.8779	.7655	.7133	.7167	.7842	.8779	.9431
7	.8413	.7282	.6767	.7167	.7842	.7865	.9054
8	.9054	.7095	.695	.7545	.7842	.8326	.8676
9	.9054	.7655	.724	.8488	.7468	.905	.9997
10	.9877	.8589	.7964	1.0185	1.094	1.0498	1.1506
11	1.3957	1.1317	.9709	1.1222	1.2449	1.3392	1.3213
12	1.4901	1.3575	1.1389	1.3575	1.5089	1.5278	1.5023
13	1.4146	1.3394	1.0456	1.4118	1.5089	1.4712	1.5746
14	1.5089	1.3394	1.0642	1.2851	1.5278	1.6409	1.6651
15	1.5466	1.4712	1.1389	1.4118	1.5089	1.6221	1.647
16	1.6409	1.4712	.9335	1.4299	1.5466	1.6787	1.6278
17	1.5089	1.4712	.9149	1.3394	1.5089	1.5089	1.6108
18	1.363	1.3937	.9808	1.2883	1.448	1.6032	1.5089
19	1.251	1.5565	.9997	1.363	1.448	1.5844	1.5089
20	1.3443	1.267	.9808	1.2883	1.448	1.5089	1.4998
21	1.2136	1.0679	1.0374	1.251	1.4299	1.4335	1.4523
22	1.1389	.9619	.9808	1.1949	1.2851	1.3957	1.4712
23	1.0642	.9412	.9619	1.086	1.2851	1.3203	1.3203
24	1.2071	1.0642	.9412	.9431	1.0082	1.2127	1.358
Max	1.6409	1.5565	1.1389	1.4299	1.5466	1.6787	1.6651
Min	.8413	.7095	.6767	.7167	.7468	.7865	.8676
Avg	1.1954	1.0916	.9129	1.0769	1.1787	1.2638	1.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 208 / 11 KV ETERNITY MALL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1307	.2772	.2452	.2241	.2772	.2829
2	.1478	.1307	.1663	.1886	.1867	.1663	.1698
3	.1478	.112	.1478	.1509	.1494	.1663	.1509
4	.1478	.112	.1478	.1509	.1307	.1478	.1509
5	.1478	.112	.1478	.132	.1307	.1294	.132
6	.1294	.112	.1294	.1132	1.2323	.1294	.1132
7	.1294	.112	.1294	.1132	.112	.1294	.1132
8	.132	.112	.1478	.132	.1867	.1294	.1132
9	.2829	.2614	.2772	.2641	.1867	.2772	.2641
10	.3881	.3547	.2957	.3018	.3018	.3142	.3206
11	.4715	.5281	.8215	.462	.3961	.4527	.499
12	.679	.7207	.5788	.6653	.679	.679	.6838
13	.6173	.7392	.6348	.6838	.6979	.7167	.7207
14	.6602	.6653	.6535	.7023	.6602	.6602	.7023
15	.811	.7733	.6535	.7392	.7167	.6413	.7207
16	.8488	.7545	.6348	.6838	.6979	.7167	.7392
17	.8299	.7545	.5228	.6653	.6413	.6979	.7577
18	.6348	.6283	.547	.5601	.6468	.6602	.6602
19	.6908	.7392	.6413	.5973	.7392	.7356	.7545
20	.6722	.6838	.5847	.5975	.7023	.679	.7023
21	.6535	.5544	.5847	.5788	.6099	.6602	.679
22	.5228	.4805	.5093	.4668	.499	.547	.679
23	.4481	.4066	.3772	.3361	.3696	.415	.4527
24	.2772	.3174	.3326	.2641	.2801	.3142	.3018
Max	.8488	.7733	.8215	.7392	1.2323	.7356	.7577
Min	.1294	.112	.1294	.1132	.112	.1294	.1132
Avg	.4455	.4290	.4143	.4081	.4657	.4351	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 209 / 11 KV CARE HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.8589	.7207	.6602	.7282	.8316	.811
2	.7947	.8029	.7023	.6413	.7095	.7947	.8676
3	.7392	.7282	.6468	.6224	.6908	.7577	.8488
4	.7023	.6908	.6468	.6224	.6348	.7207	.811
5	.6653	.6535	.6283	.6036	.6908	.6838	.7922
6	.6468	.6722	.6283	.5658	.6348	.6653	.7356
7	.6283	.6722	.5914	.6224	.6161	.6838	.6979
8	.6602	.6908	.6099	.7167	.6908	.7023	.7545
9	.7545	.7468	.6468	.7545		.7947	.8488
10	.9425	.9709	.6283	.8488	1.0374	.961	1.0185
11	1.1883	1.1317	.7095	1.0719	1.1506	1.2071	1.2382
12	1.3203	1.1643	.7655	1.1827	1.2637	1.2637	1.3491
13	1.4712	1.2752	.7842	1.2382	1.3203	1.3392	1.4045
14	1.4523	1.2752	.7468	1.2567	1.3769	1.4901	1.4784
15	1.5089	1.2637	.7842	1.2752	1.358	1.4523	1.386
16	1.4901	1.2449	.6722	1.2012	1.3203	1.3957	1.386
17	1.2449	1.1883	.6161	1.2012	1.2826	1.3014	1.3491
18	1.2323	1.0903	.6224	.9389	1.1273	1.2071	1.226
19	1.1016	1.1088	.6413	.9896	1.1088	1.1128	1.1883
20	1.0456	.9795	.6413	.9709	1.0903	1.1506	1.0534
21	.9335	.8501	.6602	.9149	.9795	1.0185	1.0374
22	.8962	.7947	.6413	.8589	.9425	1.0751	1.0562
23	.9522	.8501	.679		.9979	1.094	1.0562
24	.8871	.9149	.7762	.6979	.7468	.8686	.9619
Max	1.5089	1.2752	.7842	1.2752	1.3769	1.4901	1.4784
Min	.6283	.6535	.5914	.5658	.6161	.6653	.6979
Avg	1.0037	.9425	.6746	.8894	.9782	1.0238	1.0565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 211 / 11 KV AJMERA - SHEDDABLE URBAN
 NARESHCHANDRA Feeder KV- 11 /
 OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4668	.4338	.3395	.3921	.4715
2	.4527	.4294	.415	.3395	.3734	.4527
3	.4338	.4294	.3961	.3395	.3547	.4527
4	.415	.4108	.3772	.3206	.3547	.4527
5	.415	.3921	.3772	.3206	.3547	.4338
6	.3772	.3921	.3584	.3206	.3547	.415
7	.3772	.3734	.3584	.3584		.415
8	.3961	.3734	.3772	.3772	.3734	.4715
9	.5281	.4481	.415	.4338		
10	.6224	.5601	.4338	.5281	.6413	
11	.8865	.7922	.5415	.8402	.9431	
12	1.3203	1.1883	.7655	1.1883	1.2826	
13	1.4146	1.2826	.8402	1.3203	1.358	
14	1.4335	1.2826	.8589	1.4146	1.3957	
15	1.5278	1.358	.9054	1.4712	1.4146	
16	1.5655	1.3392	.7655	1.4335	1.4523	
17	1.4901	1.358	.8029	1.3769	1.3957	
18	1.419	1.3203	.7922	1.307	1.3769	
19	1.419	1.4901	.8676	1.307	1.4901	
20	1.3443	1.3014	.8299	1.251	1.4523	
21	1.0456	.9997	.679	1.0829	1.2071	
22	.6348	.6413	.5093	.6722	.7545	
23	.5788	.5658	.4527	.5415	.679	
24	.5281	.4668	.4527	.3772	.4108	.5281
Max	1.5655	1.4901	.9054	1.4712	1.4901	.5281
Min	.3772	.3734	.3584	.3206	.3547	.415
Avg	.8790	.8192	.5836	.8026	.9005	.4548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 212 / 11kv ANAND TALKIES 4 POLE SHEDDABLE URBAN
STRU Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8775	.7282	.7167	.7468	.8962	1.3769
2	.8775	.8402	.7282	.679	.7095	.8589	1.2826
3	.8402	.8029	.7282	.6413	.6722	.8029	1.2071
4	.8775	.7468		.6224	.6722	.7655	1.1694
5	.7468	.7282	.6535	.5847	.6535	.7282	1.1317
6	.7282	.6535	.6348	.5093	.6161	.6908	1.0562
7	.6722	.6535	.5788	.5281	.5788	.6908	.9997
8	.679	.5975	.5788	.5093	.5788	.6908	1.0374
9	.7167	.5788	.6348	.6224			
10	.7842	.6722	.6535	.679	.679		1.2449
11	.9054	.8676	.6161	.8589	.7922		1.643
12	1.0374	.9149	.7282	.9709	.9054		1.9978
13	1.0751	.9709	.7282	1.0642	1.0185		2.2032
14	1.1883	.9709	.7655	.9709	1.0562	1.4901	2.2592
15	1.226	1.0185	.7842	1.0456	1.0562		2.4086
16	1.1883	.9997	.6722	1.1016	1.094	2.4143	2.4086
17	1.1883	1.1317	.6722	1.0829	1.0751	2.3954	2.3525
18	1.0829	1.0829	.7167	.7059	1.0642	2.2634	2.2257
19	1.1576	1.1763	.7733	1.1389	1.1576	2.4143	2.4709
20	1.1203	1.0349	.7733	1.0498	1.1576	2.4143	2.3899
21	1.0082	.8686	.7545	.9709	1.0456	2.1313	2.2068
22	.9149	.7655	.679	.8215	.9896	1.7541	1.7918
23	.8962	.7842	.7545	.8215	.9896	1.5655	1.6032
24	.9149	.8775	.7842		.7655	.9335	1.4712
Max	1.226	1.1763	.7842	1.1389	1.1576	2.4143	2.4709
Min	.6722	.5788	.5788	.5093	.5788	.6908	.9997
Avg	.9468	.8590	.7009	.8129	.8728	1.4389	1.7364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 213 / 11KV Regent II o/g

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4668	.4108	.3206	.3734	.4668	.4715
2	.4668	.4294	.3921	.3018	.3174	.4668	.4715
3	.4481	.4294	.3921	.3018	.2987	.4294	.4527
4	.4294	.4108	.3734	.3018	.3361	.3921	.4338
5	.4294	.4108	.3361	.2829	.3174	.3547	.4338
6	.3734	.3547	.3361	.2829	.3174	.3361	.3961
7	.3547	.3547	.3174	.3018	.3547	.3361	.3584
8	.3395	.3361	.2987	.2829	.2987	.3361	.3772
9	.3395		.3174	.3206		.3734	.3395
10	.4527	.4481	.3361	.3772	.5093	.4108	1.0185
11	.7922	.679		.7468	.7922	.8488	.7842
12	1.0562	.9335		1.0456	1.0751	1.094	1.1203
13	1.1317	.9896		1.1389	1.0751	1.1694	1.1763
14	1.1506	1.1016		1.2136	1.1694	1.1317	1.307
15	1.2449	1.094		1.2323	1.1506	1.1883	1.307
16	1.226	1.0751	.4854	1.1576	1.1317	1.1883	1.251
17	1.3392	1.1883	.6908	1.1203	1.1506	1.3014	1.307
18	1.1949	1.1949	.7545	1.1389	1.1389	1.2826	1.2449
19	1.2127	1.3256	.8676	1.1576	1.2696	1.3203	1.3203
20	1.1576	1.1016	.7356	1.1576	1.2136	1.2637	1.2136
21	.9149	.7282	.6036	.8869	1.0082	1.0374	1.094
22	.5415	.4481	.3961	.5041	.5975	.5847	.6001
23	.5041	.4108	.3772	.4481	.5228	.5658	.5658
24	.5228	.4854	.4294	.3206	.3961	.5041	.5281
Max	1.3392	1.3256	.8676	1.2323	1.2696	1.3203	1.3203
Min	.3395	.3361	.2987	.2829	.2987	.3361	.3395
Avg	.7545	.7129	.4658	.6810	.7311	.7660	.8155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 227 / 11 KV BAJAJ NGR FDR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.567	.5415	.4163	.4668	.5068	.6697
2	.5975	.567	.4854	.3982	.4481	.5068	.6401
3	.5601	.5316	.4854	.3982	.4481	.4706	.5973
4	.5415	.4961	.4481	.362	.4108	.4706	.543
5	.4108	.4252	.4294	.362	.4108	.4344	.4887
6	.4294	.4075	.3921	.3439	.3734	.3982	.4525
7	.3734	.3898	.3921	.3439	.3361	.3801	.4344
8	.3982	.3721	.3734	.3439	.3658	.3982	.4024
9	.4163	.4075	.3921	.362	.3921		.4207
10	.5601		.4163	.4572	.4344		.4572
11	.695	.6535	.4525	.5228	.6154	.8589	.6516
12	.7499	.7095	.4344	.5601	.6697	.7468	.7133
13	.7133	.6535	.4525	.5788	.6878	.7468	.695
14	.7682	.7282	.4163	.6161	.6516	.8029	.7865
15	.7602	.7468	.4344	.6908	.6878	.8215	.8048
16	.8413	.7655	.362	.6535	.724	.8402	.8048
17	.8145	.7655	.4163	.6722	.6697	.7468	.8048
18	.6556	.6535	.4887	.5975	.7059	.7316	.7095
19	.691	.7655	.4706	.6161	.6878	.7133	.7468
20	.6379	.7282	.4706	.6161	.6335	.6767	.7468
21	.6024	.5415	.4525	.6161	.6154	.6767	.6908
22	.6089	.5601	.4706	.543	.6516	.6767	.695
23	.6201	.5415	.4344	.5415	.6516	.6767	.7468
24	.6335	.5847	.5415	.4163	.4854	.6516	.6767
Max	.8413	.7655	.5415	.6908	.724	.8589	.8048
Min	.3734	.3721	.362	.3439	.3361	.3801	.4024
Avg	.6115	.5896	.4439	.5012	.5510	.6333	.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 228 / 11 KV SHRADHANANDPETH FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.7762	.6348	.5601	.6722	.7468	.924
2	.7842	.7762	.6348	.5601	.5975	.6722	.8962
3	.7468	.7087	.6161	.5228	.5601	.6535	.8402
4	.7095	.6838	.5975	.5228	.5228	.6535	.7468
5	.6722	.6099	.5975	.5228	.4854	.6348	.6535
6	.5788	.5729	.5788	.4854	.4668	.5788	.5975
7	.5601	.5175	.5041	.4668	.5041	.5415	.5788
8	.5487	.499	.5415	.4854	.5601	.5601	.5415
9	.6036	.5544	.5041	.5788	.6348	.5788	.6535
10	.7468		.5788	.7468	.7499	.7655	.8215
11	.9709	.7842	.6161	.9335	.9149	.9522	.9709
12	1.0082	.8402	.6535	.9709	.9522	.9709	1.0642
13	1.0082	.9149	.6535	1.0269	.9896	1.0456	1.1016
14	1.1389	1.0082	.6348	1.0269	1.0269	1.1203	1.1763
15	1.2136	1.0269	.6908	1.0642	1.0642	1.1763	1.2696
16	1.2323	1.0082	.5788	1.0829	1.1016	1.2323	1.251
17	1.2382	1.0082	.6161	.9709	1.1389	1.0829	1.1763
18	1.0059	.9709	.6722	.9709	1.0642	1.1016	1.1389
19	1.0608	1.1016	.7468	1.0082	1.0829	1.1389	1.1576
20	.9877	1.0642	.7468	.9522	1.1016	1.1389	1.1576
21	.8779	.7468	.6908	.8775	.9896	1.0829	1.0642
22	.8779	.7282	.6722	.7842	.9149	1.0456	1.0456
23	.8501	.7282	.6161	.8029	.9335	1.0082	1.1576
24	.8596	.7947	.7282	.5975	.7655	.8589	.9709
Max	1.2382	1.1016	.7468	1.0829	1.1389	1.2323	1.2696
Min	.5487	.499	.5041	.4668	.4668	.5415	.5415
Avg	.8785	.8010	.6294	.7717	.8248	.8892	.9565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 229 / 11KV VASANT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0377	.0566	.0377	.0566	.0377	.0377
2	.0566	.0377	.0377	.0377	.0566	.0377	.0377
3	.0566	.0377	.0377	.0377	.0566	.0377	.3584
4	.0566	.0377	.0377	.0377	.0566	.0377	.0377
5	.0566	.0377	.0377	.0377	.0566	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377		.0377	.0377	.0377	.0377	.0377
11	.0754	.0566	.0377	.0566	.0566	.0566	.0566
12	.0747	.0754	.0377	.0566	.0566	.0566	.0566
13	.0754	.0754	.0377	.0566	.0566	.0566	.0566
14	.0754	.0754	.0377	.0566	.0566	.0566	.0566
15	.0754	.0754	.0377	.0566	.0566	.0754	.0566
16	.0754	.0754	.0566	.0566	.0566	.0754	.0566
17	.0754	.0566	.0377	.0566	.0566	.0754	.0566
18	.0377	.0566	.0377	.056	.0377	.0566	.0377
19	.0377	.0566	.0377	.0377	.0377	.0566	.0377
20	.0566	.0566	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0566	.0377	.0377	.0566	.0377
22	.0566	.0377	.0566	.0566	.0377	.0566	.0377
23	.0566	.0377	.0566	.0566	.0377	.0566	.0377
24	.0566	.0377	.0566	.0377		.0377	.0377
Max	.0754	.0754	.0566	.0566	.0566	.0754	.3584
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0565	.0508	.0432	.0463	.0484	.0503	.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 232 / 11KV AATH RASTA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3658	.3361	.2801	.2801	.3696	.4108
2	.3734	.3658	.3174	.2614	.2801	.3326	.4108
3	.3361	.3326	.3174	.2614	.2614	.3326	.3734
4	.3361	.3292	.2987	.2427	.2614	.2957	.3361
5	.3174	.2926	.2987	.2427	.2427	.2772	.3174
6	.2987	.2926	.2801	.2054	.2427	.2772	.2987
7	.2427	.2743	.2427	.2241	.2241	.2402	.2801
8	.2801	.2561	.2427	.2427	.2614	.2772	.2801
9	.2987	.2743	.2614	.2801	.3174	.2957	.3361
10	.4108		.2801	.3361	.3547	.3511	.4108
11	.5041	.4668	.2987	.4294	.462	.4854	.5359
12	.5788	.4854	.3174	.4668	.4805	.4854	.5975
13	.5788	.5228	.3361	.4668	.4805	.5601	.6161
14	.6161	.5041	.3361	.4854	.499	.5975	.6161
15	.6535	.5041	.3361	.5041	.5175	.6348	.6348
16	.6908	.5415	.2987	.5228	.5175	.6161	.6348
17	.6283	.5228	.2987	.5041	.5359	.5601	.6161
18	.5121	.4854	.3547	.5041	.5175	.5228	.5788
19	.567	.5788	.4108	.5041	.499	.5788	.6161
20	.5304	.5228	.4108	.4854	.5175	.5975	.5975
21	.4207	.3734	.3921	.4294	.5175	.5415	.5788
22	.4207	.3361	.3174	.3734	.4066	.4668	.5359
23	.4207	.3361	.2987	.3361	.4251	.4294	.5041
24	.4108	.4024	.3361	.2801	.3361	.4066	.4294
Max	.6908	.5788	.4108	.5228	.5359	.6348	.6348
Min	.2427	.2561	.2427	.2054	.2241	.2402	.2801
Avg	.4500	.4072	.3174	.3695	.3933	.4388	.4811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 234 / 11KV Lokmat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0566	.0381	.0377	.0572	.0566	.056
2	.0572	.0566	.0381	.0377	.0572	.0566	.056
3	.0572	.0566	.0381	.0377	.0572	.0566	.0373
4	.0572	.0566	.0381	.0377	.0572	.0566	.0373
5	.0572	.0377	.0381	.0377	.0572	.0566	.0373
6	.0572	.0377	.0381	.0377	.0572	.0566	.0373
7	.0572	.0377	.0381	.0377	.0381	.0566	.0373
8	.0566	.0566	.0377	.0377	.0377	.0566	
9	.0566	.0566	.0572	.0566	.0572	.0566	.056
10	.0762		.0566	.0566	.0754	.0754	.056
11	.0747	.0762	.0566	.0566	.0754	.0762	.0754
12	.0747	.0762	.0566	.0754	.0754	.0762	.0754
13	.0934	.0762	.0566	.0762	.0754	.0762	.0754
14	.0747	.0762	.0754	.0762	.0754	.0762	.0754
15	.0934	.0762	.0754	.0762	.0754	.0762	.0754
16	.0747	.0953	.0566	.0762	.0754	.0762	.0754
17	.0754	.0762	.0566	.0762	.0754	.0762	.0754
18	.0754	.0953	.0566	.0762	.0754	.0747	.0754
19	.0754	.0762	.0566	.0762	.0754	.0747	.0566
20	.0754	.0762	.0566	.0572	.0754	.056	.0566
21	.0754	.0572	.0566	.0572	.0566	.056	.0572
22	.0566	.0572	.0377	.0566	.0566	.056	.0566
23	.0566	.0572	.0566	.0572	.0566	.056	.0566
24	.0566	.0566	.0572	.0377	.0572	.0566	.056
Max	.0934	.0953	.0754	.0762	.0754	.0762	.0754
Min	.0566	.0377	.0377	.0377	.0377	.056	.0373
Avg	.0676	.0644	.0512	.0561	.0639	.0645	.0588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 202 / 11KV SHANKAR NAGAR I/C
Feeder KV- 11 / INCOMING

SHEDDABLE URBAN

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0559		1.7177	1.358	1.5655	1.9616	2.2361
2	1.8673		1.7177	1.2449	1.4335	1.8107	2.1807
3	1.7918		1.7737	1.2449	1.4335	1.773	1.9959
4			1.7177	1.226	1.358	1.773	1.7741
5			1.6804	1.226	1.358	1.7541	1.6817
6			1.2883	1.2071	1.2637	1.5278	1.6263
7			1.2071	1.1883	1.2071	1.3957	1.4969
8		1.3203	1.2936	1.1883	1.2826	1.3203	1.4415
9		1.3443	1.262	1.3957	1.46	1.4523	1.6078
10		1.4901	1.4083	1.5089	1.6263	1.6244	1.6263
11		1.5844	1.4969	1.5364	1.7741	1.7177	1.8111
12		1.8107	1.5339	1.7193	1.9774	1.9231	1.9605
13		1.8861	1.4815	1.8665	2.0144	2.1068	2.1845
14		1.9427	1.5893	1.885	2.0144	2.2361	2.2965
15		2.037	1.8111	1.9753	2.0911	2.3101	2.4832
16		2.0182	1.2936	2.0668	2.0911	2.4025	2.2779
17		2.0725	1.3306	1.7924	1.3914	2.1992	2.3285
18		1.9044	1.386	1.7737	1.9404	1.9589	2.1068
19		1.9791	1.5708	1.8671	2.1582	2.1437	2.2314
20		2.1502	1.5912	1.8298	2.1253	2.2177	2.2916
21		1.7164	1.5729	1.8296	2.1807	2.2361	2.2916
22		1.7551	1.5278	1.8673	2.2822	2.3655	2.5766
23		1.7177	1.5278	1.9239	2.2257	2.5579	2.5019
24	2.2445		1.7918	1.5089	1.6221	2.2068	2.4764
Max	2.2445	2.1502	1.8111	2.0668	2.2822	2.5579	2.5766
Min	1.7918	1.3203	1.2071	1.1883	1.2071	1.3203	1.4415
Avg	1.9899	1.7956	1.5238	1.5929	1.7449	1.9573	2.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 223 / 11KV LAXMI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.7545	.6348	.547	.6036	.7733	.9425
2	.7545	.7545	.6348	.4904	.5658	.7545	.9145
3	.7167	.7468	.6348	.4904	.5658	.7167	.7865
4		.7468	.6348	.4904	.5281	.7167	.7316
5	.6036	.6535	.5228	.4904	.5281	.679	.695
6	.547	.5601	.5093	.4715	.4715	.5658	.6516
7	.6036	.5415	.4706	.4715	.5281	.547	.5792
8	.5281	.4854	.5487	.4715	.5175	.4908	.543
9	.5093	.4854	.5121	.5281	.5175	.547	
10	.5847	.4904	.543	.547	.5729	.5788	
11	.6626	.5658	.5552	.5487	.6283	.5788	.7282
12	.6626	.6413	.5552	.5853	.6767	.6722	.7842
13	.7922	.6413	.5611	.6584	.7207	.7316	.8215
14	.8688	.7356	.5611	.6401	.7133	.8048	.8215
15	.905	.7316	.6036	.7392	.7392	.8048	.823
16	.9877	.7545	.4835	.7682	.7577	.8501	.8413
17	.8507	.7922	.5359	.6413	.7207	.8131	.8871
18	.7265	.7356	.5359	.6161	.7133	.695	.7865
19	.788	.7545	.6161	.6908	.823	.8048	.8596
20	.8417	.7922	.6154	.6979	.8048	.8779	.8962
21	.8775	.6979	.5792	.6722	.8048	.9145	.924
22	.8215	.5544	.5316	.6979	.8865	.961	1.0719
23	.8215	.6468	.5847	.7356	.9242	1.0164	1.1273
24	.9054	.7842	.6908	.5847	.6413	.8676	1.0164
Max	.9877	.7922	.6908	.7682	.9242	1.0164	1.1273
Min	.5093	.4854	.4706	.4715	.4715	.4908	.543
Avg	.7465	.6686	.5690	.5948	.6647	.7401	.8288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 224 / 11KV ABHYANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.7468	.7095	.4904	.6036	.7356	.7783
2	.6805	.7468	.7095	.4715	.5658	.6602	.7421
3	.679	.7468	.7095	.4715	.5658	.6602	.7164
4		.7468	.7167	.4715	.5281	.6602	.6268
5	.6224	.7095	.5228	.4715	.5281	.679	.5731
6	.6224	.5601	.4854	.4527	.4904	.5658	.5373
7	.5847	.5093	.4525	.4527	.4527	.4527	.5014
8	.4715	.4904	.443	.4338	.4527	.4161	.4656
9	.4715	.5041	.4607	.4715	.4755	.4715	
10	.6001	.5847	.4854	.5847	.6036	.6348	
11	.7186	.6036	.5258	.567	.6838	.6908	.6348
12	.7973	.7733	.567	.6584		.7655	.7095
13	.8238	.7733	.5316	.6805	.7392	.8238	.7468
14	.8507	.7922	.567	.7577	.7602	.8954	.9431
15	.905	.7733	.6089	.7682	.7682	.9412	.9896
16	.5792	.7545	.4733	.7682	.7682	.9511	.8871
17	.8596	.7545	.4887	.7545	.8048	.8779	.8962
18	.7499	.7545	.5194	.7545	.7421	.7682	.7865
19	.7975	.7922	.6219	.7468	.8682	.8145	.8596
20	.7455	.8865	.6135	.7468	.8238	.8238	.8688
21	.7712	.6224	.5959	.7545	.8596	.8145	.8507
22	.8215	6.8953	.6224	.7545	.8865	.8869	.9145
23	.8589	.6767	.6036	.7545	.8865	.9511	1.1273
24	.811	.8029	.7023	.5847	.6224	.8299	.8688
Max	.905	6.8953	.7167	.7682	.8865	.9511	1.1273
Min	.4715	.4904	.443	.4338	.4527	.4161	.4656
Avg	.7215	.9584	.5723	.6176	.6730	.7404	.7738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 225 / 11KV SHIVAJI NAGAR(NAGPUR)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2241	.2614	.1886	.2452	.2743	.3511
2	.2572	.2241	.2614	.1715	.2263	.2401	.3511
3	.2572	.2241	.2614	.1715	.1886	.2401	.3326
4		.2241	.2614	.1543	.1886	.2401	.2294
5	.2058	.2263	.2241	.1543	.1715	.2401	.2374
6	.2058	.2427	.1867	.1372	.1663	.2229	.2534
7	.1886	.2054	.1417	.1372	.1402	.2058	.2195
8	.1886	.168	.1595	.1372	.1595	.1402	.2218
9	.1715	.168	.1417	.1543	.2402	.1734	
10	.181	.1715	.181	.1372	.1848	.3361	
11	.181	.1715	.181	.1848	.2033	.2263	.2054
12	.181	.1543	.181	.2195	.2195	.1867	.2241
13	.181	.1886		.2218	.2218	.2218	.2427
14	.2534			.2149	.2218	.2402	.2801
15	.2587			.2218	.2241	.2402	.2987
16	.2743	.2058	.1848	.2218		.2772	.2587
17	.2507	.2229	.1463	.2054	.2218	.2402	.2402
18	.1949	.1886	.1663	.2054	.2172	.2195	.2587
19	.2303	.2229	.1848	.2427	.2378	.2743	.2926
20	.2507	.2229	.2012	.2263	.2743	.2957	.2957
21	.1707	.208	.2195	.2241	.2957	.2957	.3142
22	.2614	.2218	.2075	.2229	.3206	.3292	.3696
23	.3174	.2402	.2263	.2401	.2452	.3881	.3881
24	.3086	.3174	.2587	.2058	.2229	.3086	
Max	.3174	.3174	.2614	.2427	.3206	.3881	.3881
Min	.1707	.1543	.1417	.1372	.1402	.1402	.2054
Avg	.2288	.2111	.2018	.1917	.2190	.2524	.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 227 / 11KV CIIMS HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.112	.1029	.1029	.1372	.1417
2		.1307	.112	.1029	.1029	.1214	.1357
3		.1307	.112	.1029	.1029	.12	.1134
4		.1307	.112	.1029	.1075	.12	.1134
5		.112	.112	.1029	.1097	.1227	.1147
6		.112	.1132	.1029	.104	.1417	.1357
7		.1307	.128	.1029	.128	.1646	.1646
8		.168	.1097	.12	.1254	.1734	.1886
9	.2058	.1867	.128	.2058	.2263	.2229	
10	.2477	.2058	.1663	.2058	.2641	.2241	
11	.2641	.2058	.1848	.2195	.2614	.2241	.2427
12	.3395	.2058	.1886	.2241	.3395	.2987	.2427
13	.3395	.2572	.1867	.2858	.3395	.3048	.2614
14	.3395	.2401	.1867	.2667	.3048	.2641	.2614
15	.3048	.2572	.1829	.2561	.3429	.2641	.2987
16	.3395	.2572	.1387	.2829			.2641
17	.3048	.2743	.1478	.2054	.2667	.2667	.3048
18	.2667	.208	.1478	.2054	.2477	.2667	.2667
19	.2096	.1886	.1478	.1867	.2075	.2263	.2054
20	.2286	.2058	.12	.168	.1867	.1886	.2075
21	.2263	.1543	.1433	.168	.1886	.1829	.1848
22	.1867	.1646	.1029	.1543	.1715	.1629	.1867
23	.1494	.124	.1132	.1372	.1543	.1612	.1848
24	.1715	.1307	.1075	.1029	.1029	.1543	.1829
Max	.3395	.2743	.1886	.2858	.3429	.3048	.3048
Min	.1494	.112	.1029	.1029	.1029	.12	.1134
Avg	.2578	.1797	.1377	.1715	.1951	.1962	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 201 / 11 KV Switching campus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4118	1.267	1.0029	.924	1.0608	1.3306	1.3676
2	1.3394	1.1641	.985	.8779	1.0719	1.2567	1.3676
3	1.3394	1.1104	.9492	.8501	1.0349	1.1888	1.2936
4		1.0277	.9134	.8215	1.0242	1.0974	1.1706
5		.9922	.3403	.7922	.9979	1.0242	1.134
6		.8775	.8059	.7468	.9145	.8501	1.1088
7		.7522	.7522	.7023	.8779	.7973	.9877
8		.7499	.6984	.6653	.8686	.7265	.9511
9		.7499	.7421	.7682	.8501	.8063	.9145
10		.8413	.7421	.7602	.823	.8328	.9328
11	.8413	.8501	.8326	.7602	.9593	.8859	.9511
12	.8954	.9145	.724	.8326	.9328	.9694	1.0349
13	.9671	.9877	.8688	.9511	.9877	.9877	1.0719
14	1.0974		.8596	1.0242	.9877	1.0791	1.2197
15	1.1706	1.1203	.8059	1.0498	1.0242	1.0974	1.2012
16	1.2437	1.1458	.7343	1.0534	.9922	1.0498	1.3676
17	1.262	1.1576	.7421	.924	.9877	1.1157	1.2012
18	1.2936		.7499	.9511	.9774	1.2936	1.0719
19	1.3306		.8316	.9877	1.0208	1.3676	1.1222
20	1.3535		.8589	1.0349	1.1403	1.46	1.2803
21	1.3535		.924	1.1088	1.2489	1.5708	1.2803
22	1.3306		.9335	1.0974	1.2851	1.5708	1.4266
23	1.3969	1.1104	.9145	1.0164	1.4449	1.4784	1.5708
24	1.4661	1.3394	1.0924	.9335	1.086	1.3717	1.423
Max	1.4661	1.3394	1.0924	1.1088	1.4449	1.5708	1.5708
Min	.8413	.7499	.3403	.6653	.823	.7265	.9145
Avg	1.2408	1.0088	.8252	.9014	1.0250	1.1337	1.1855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 202 / 11 kv gokulpeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4207	.3582	.2926	.439	.4207	.8131
2	.4163	.4031	.3582	.2772	.4435	.3801	.7762
3	.3982	.3814	.3582	.2561	.4251	.3258	.7392
4		.3814	.3189	.2427	.4066	.3224	.6653
5		.3641	.3189	.2195	.3696	.3224	.6283
6		.3155	.3189	.2054	.3326	.2957	.5914
7		.2774	.2743	.2012	.2957	.2926	.6219
8		.2686	.2561	.1848	.2926	.2561	.6584
9		.3403	.2743	.3174	.3109	.3403	.6584
10		.394	.3224	.4066	.3292	.4477	.7023
11	.439	.4024	.394	.5304	.5611	.4887	.8871
12	.6626	.4805	.4163	.5194	.6401	.6516	1.3676
13	.6984	.5487	.4525	.6626	.7133	.6878	1.4083
14	.724		.4887	.6984	.7133	.7316	1.4415
15	.8145	.7095	.4706	.724	.6653	.7421	.7392
16	.7316	.7316	.3721	.695	.6219	.7059	.7947
17	.7421	.7392	.3582	.6036	.6838	.6697	.7577
18	.7164		.3658	.5487	.6283	.7316	.7392
19	.6984		.4805	.5914	.7682	.8131	.7682
20	.6805		.5228	.6283	.7133	.8871	.7865
21	.7164		.5121	.6653	.6878	.924	.7059
22	.6878		.5121	.6219	.543	.924	.5611
23	.4733	.3898	.4435	.5487	.4887	.8871	.4572
24	.4784	.4382	.394	.3292	.4435	.4572	.8501
Max	.8145	.7392	.5228	.724	.7682	.924	1.4415
Min	.3982	.2686	.2561	.1848	.2926	.2561	.4572
Avg	.6194	.4437	.3892	.4571	.5215	.5711	.7966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 203 / 11 KV Dharampeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.037	.037	.0366	.0366	.0373	.037
2	.0366	.0366	.0185	.0343	.0366	.0373	.037
3	.0366	.0366	.0183	.0351	.037	.037	.037
4		.0362	.0362	.0358	.037	.037	.0185
5		.0362	.0362	.0366	.037	.037	.0183
6		.0179	.0358	.0373	.037	.0366	.0185
7		.0181	.0354	.0358	.037	.0362	.0366
8		.0179	.0354	.0366	.0366	.0354	.0366
9		.0179	.0362	.0358	.0366	.0914	.0366
10		.0362	.0358	.1075	.037	.1097	.037
11	.0924	.0366	.0532	.1417	.1629	.1646	.1646
12	.1629	.0739	.0895	.1612	.181	.2195	.2218
13	.181	.0914	.1075	.1595	.181	.2149	.2033
14	.1829		.0914	.1612	.1991	.2378	.2033
15	.2012	.1097	.0914	.197		.2353	.2033
16	.2195	.1478	.0543	.1646	.1595	.1991	.2033
17	.1646	.1494	.0709	.1646	.1646	.1991	.2218
18	.1848		.0732	.1848	.1829	.2012	.1848
19	.1848		.1109	.1848	.2218	.2195	.2218
20	.1478		.112	.2033	.1848	.2195	.2033
21	.1478		.0924	.2033	.128	.1848	.1294
22	.1097		.0924	.0732	.0905	.1848	.0724
23	.0549	.0549	.0549	.0732	.0747	.1478	.0554
24	.037	.037	.0362	.0366	.0739	.0373	.037
Max	.2195	.1494	.112	.2033	.2218	.2378	.2218
Min	.0366	.0179	.0183	.0343	.0366	.0354	.0183
Avg	.1283	.0551	.0606	.1059	.1032	.1317	.1099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 204 / 11 KV Bajaj Nagar

SHEDDABLE URBAN

switching Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.0914	.0747	.0739	.0934	.0739
2	.1109	.0924	.0747	.0732	.0739	.0934	.0739
3	.0924	.0732	.0747	.0554	.0739	.0747	.0739
4		.0732	.0739	.0549	.0739	.0747	.0366
5		.0732	.0924	.0373	.0739	.0747	.0366
6		.0732	.0747	.0373	.0739	.0754	.0366
7		.0724	.0924	.037	.0732	.0747	.037
8		.0934	.056	.0373	.0732	.0739	.0366
9		.0747	.0554	.0914	.0732	.0924	.0366
10		.0747	.056	.0914	.0732	.1086	.0366
11	.1463	.0747	.0739	.1097	.1663	.1448	.1463
12	.1433	.0924	.0554	.1109	.1433	.1629	.1478
13	.1629	.0924	.0554	.1433	.1612	.1646	.1294
14	.1629		.0739	.1629	.1791	.1646	.1478
15	.1829	.1294	1.7372	.1829	.1595	.1646	.1478
16	.2195	.1097	.0554	.1663	.1463	.1646	.1294
17	.1646	.1109	.0739	.1663	.1463	.1463	.1294
18	.1663		.0732	.1646	.1294	.1478	.112
19	.1478		.0924	.1463	.112	.1109	.1097
20	.1478		.0914	.1086	.112	.0739	.112
21	.1109		.1109	.1097	.1109	.0732	.1109
22	.0732		.112	.1097	.0934	.0732	.1132
23	.1109	.112	.1109	.0732	.1132	.037	.112
24	.1109	.1109	.1109	.0732	.0732	.112	.0732
Max	.2195	.1294	1.7372	.1829	.1791	.1646	.1478
Min	.0732	.0724	.0554	.037	.0732	.037	.0366
Avg	.1408	.0913	.1487	.1007	.1076	.1073	.0916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 205 / 11 KV Incommer from

SHEDDABLE URBAN

Shankar Na Feeder KV- 11 /
INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8823	1.7372	1.4685	1.3169	1.6632	1.8107	2.2916
2	1.7909	1.6655	1.3969	1.2936	1.6632	1.7558	2.2916
3	1.7193	1.5238	1.3253	1.2696	1.5729	1.5927	2.3228
4		1.4529	1.2894	1.2071	1.4632	1.4661	2.0144
5		1.382	1.2536	1.1949	1.4784	1.3937	1.885
6		1.1999	1.182	1.1576	1.39	1.1827	1.8296
7		1.134	1.0679	1.0974	1.3535	1.1462	1.6827
8		1.0679	1.0136	1.0719	1.2752	1.0387	1.6827
9		1.0974	1.0498	1.1949	1.2752	1.2226	1.6827
10		1.1946	1.1041	1.2012	1.2803	1.4327	1.7187
11	1.3352	1.2071	1.1765	1.2382	1.7375	1.5384	2.396
12	1.8625	1.3306	1.3032	1.3032	1.7741	1.8473	1.0349
13	2.0814	1.4937	1.3575	1.9022	2.0485	1.957	2.7721
14	2.1948		1.4118	2.0668	2.0668	2.0119	2.9199
15	2.3411	1.7002	1.3213		1.9936	2.0668	2.2361
16	2.4691	2.0119	1.1584	1.9774	1.9387	2.0485	2.8645
17	2.2497	2.0328	1.1765	1.829	1.9022	1.9936	2.2361
18	2.384		1.1888	1.848	1.8107	2.4025	2.0328
19	2.4025		1.3306	1.8823	1.957	2.5503	2.0485
20	2.3655		1.3535	1.9774	2.0485	2.6337	2.1948
21	2.3655		1.5154	2.1807	1.9728	2.7435	2.0851
22	2.1948		1.531	2.0328	1.8823	2.7435	2.0119
23	1.8267	1.6118	1.4266	1.885	1.957	2.5503	2.1622
24	1.9547	1.773	1.5402	1.3676	1.7002	1.9022	2.4691
Max	2.4691	2.0328	1.5402	2.1807	2.0668	2.7435	2.9199
Min	1.3352	1.0679	1.0136	1.0719	1.2752	1.0387	1.0349
Avg	2.0835	1.4787	1.2893	1.5433	1.7169	1.8763	2.1194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 201 / 11 KV CAMPUS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.5251	.4443	.483	.823	.644	.5525
2	.9012	.5041	.4342	.4923	.8048	.5944	.5239
3	.6241	.4925	.4218	.5285	.7865	.6192	.4858
4	.6954	.4733	.4191	.4793	.7682	.6478	.4572
5	.724	.4527	.3982	.4793	.7762	.5487	.4572
6	.5761	.4588	.4191	.4458	.7316	.6089	.4477
7	.4201	.3269	.4191	.3772	.3414	.5281	.2949
8	.447	.3601	.3704	.3174	.3704	.4441	.3429
9	.6024	.2686	.2894	.2743	.3584	.3841	.3067
10	.3395	.2865	.2987	.2987	.2785	.298	.3102
11	.3807	.3018	.3174	.3081	.3313	.3715	.3492
12	.3963	.3401	.2987	.3292	.3313	.381	.3749
13	.4001	.3692	.3174	.3475	.3841	.3789	.4207
14	.4287	.3906	.3267	.3475	.3582	.3768	.4207
15	.439	.4275	.3595	.8215	.3768	.4029	.6668
16	.4664	.4557	.3109	.7468	.5325	.3772	.4477
17	.426	.4544	.2743	.3828	.5201	.3601	.4574
18	.3982	.3361	.4601	.4039	.4954	.3567	.4081
19	.5335	.5014	.4561	.823	.5407	.447	.5247
20	.4938	.5373	.7682	.4746	.9328	.5053	.535
21	.4938	.4973	.5281	.4746	.7042	1.0242	.5868
22	.9896	.5135	.5258	.8596		.5716	.7087
23	1.0269		.4954	.8962	.6916	.5906	.6192
24	1.0791	.6173	.4458	.503	.8589	.6287	1.1576
Max	1.0791	.6173	.7682	.8962	.9328	1.0242	1.1576
Min	.3395	.2686	.2743	.2743	.2785	.298	.2949
Avg	.5809	.4300	.4083	.4956	.5694	.5037	.4940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 202 / 11 KV HINDUSTAHAN COLOANY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3933	.2389	.2332	.1555	.2926	.2229	.2881
2	.2858	.2389	.2256	.1555	.2561	.192	.2743
3	.2477	.2435	.2115	.1448	.2378	.16	.2606
4	.216	.2267	.2143	.144	.2378	.1515	.2401
5	.216	.2987	.2	.1635	.2195	.1494	.2267
6	.2103	.1715	.1882	.1486	.2033	.16	.2164
7	.2286	.1715	.2107	.1383	.1894	.1635	.1947
8	.2027	.2027	.1932	.2241	.1387	.176	.1783
9	.2561	.1882	.1882	.2054	.1715	.1814	.1669
10	.2115	.1833	.2027	.2614	.192	.1783	.1709
11	.192	.1808	.1692	.1783	.1867	.1947	.1915
12	.2058	.1814	.1833	.1659	.1635	.1947	.1915
13	.2	.184	.1692	.1659	.176	.2	.189
14	.2073	.184	.1715	.1362	.7167	.1886	.189
15	.2092	.2202	.1623	.2614	.1787	.217	.216
16	.216	.2012	.1635	.2427	.1858	.2105	.1859
17	.217	.2164	.1692	.2614	.1858	.2229	.1976
18	.2286	.2364	.2572	.1758	.192	.1886	.2202
19	.2073	.1972	.2195	.2743	.1829	.2012	.217
20	.2103	.2225	.1739	.2743	.2105	.2012	.2332
21	.2987	.2201	.1486	.2042	.3292	.3292	.2298
22	.3734	.2143	.176	.2926		.2172	.221
23	.2553	.2267	.176	.2987	.2389	.2401	.2542
24	.4024	.2553	.2267	.156	.2801	.2263	.2743
Max	.4024	.2987	.2572	.2987	.7167	.3292	.2881
Min	.192	.1715	.1486	.1362	.1387	.1494	.1669
Avg	.2455	.2127	.1931	.2012	.2333	.1986	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 203 / 11 KV NIT-GOKULPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.1016	.8962	.5573	.823	1.1765	1.2071
2	1.134	1.0829	.8775	.5182	.7865	1.134	1.1157
3	***	1.0269	.8589	.5182	.7682	1.0974	1.0608
4	.8962	.9709	.8402	.4793	.7499	1.0608	.9877
5	.7888	.8962	.8215	.415	.7316	.9877	.9328
6	.823	.8029	.7468	.4087	.6767	.7499	.8145
7	.7316	.7095	.6908	.4024	.5853	.6516	.695
8	.6767	.6722	.6908	.5975	.6584	.6661	.6767
9	.6767	.7282	.6908	.6908	.695	.6767	.6584
10	.8589	.7468	.7468	.7095	.7655	.7655	.8215
11	.9522	.8962	.7655	.8962	.9709	.9709	1.0456
12	1.251	1.1203	.8775	1.0456	1.1576	1.1389	1.2136
13	1.2883	1.2136	.8962	1.1576	1.0642	1.3817	1.363
14	1.4003	1.2136	1.0082	1.1576	1.251	1.3443	
15	1.4937	1.363	1.0082	1.1949	1.2323		1.4003
16	1.5684	1.3392	.8589	1.2136	1.2986	1.4563	1.4377
17	1.4563	1.3392	.8775	1.2883	1.262	1.4003	1.5123
18	1.3443	1.2826	.6607	1.2071	1.2437	1.3169	1.363
19	1.4377	1.4998	.7644	1.2803	1.3717	1.4083	1.531
20	1.4003	1.386	.7385	1.3169	1.3717	1.4632	1.4563
21	1.3256	1.1643	.9012	1.2254	1.2517	1.4449	1.4377
22	1.2136	1.0242	.958	1.0791	1.2254	1.2986	1.363
23	1.251	1.0242	.0648	1.1016	1.1888	1.3817	1.4563
24	1.262	1.1763	.9877	.6192	.9709	1.1317	1.3256
Max	11.0471	1.4998	1.0082	1.3169	1.3717	1.4632	1.531
Min	.6767	.6722	.0648	.4024	.5853	.6516	.6584
Avg	1.5603	1.0742	.8012	.8783	1.0042	1.1350	1.1685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 204 / 11KV BULDI
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	1.6057	1.643	1.0774	1.5912	1.5729	1.5729
2	1.6221	1.6057	1.643	1.065	1.5912	1.5546	1.5729
3	1.5546	1.6057	1.643	1.065	1.6278	1.5546	1.5746
4	1.6032	1.643	1.643	1.0774		1.5729	1.5912
5	1.5912	1.6244	1.6617	1.0898	1.6278	1.5912	1.6095
6	1.5912	1.643	1.6617	1.1022	1.6278	1.5912	1.6095
7	1.5912	1.6617	1.6617	1.153	1.6278	1.6278	1.6095
8	1.5089	1.643	1.6804	1.643	1.6095	1.5912	1.6095
9	1.5729	1.6244	1.6617	1.6057	1.5912	1.5912	1.5729
10	1.5497	1.587	1.6617	1.5684	1.5684	1.587	1.5684
11	1.5497	1.587	1.643	1.5684	1.5684	1.5684	1.5497
12	1.5497	1.5684	1.643	1.5684	1.587	1.5684	1.5497
13	1.5497	1.587	1.643	1.5684	1.5684	1.587	1.5497
14	1.5497	1.5684	1.643	1.5684		1.5684	1.5123
15	1.5123	1.5684	1.6244	1.5684	1.5684	1.5497	1.531
16	1.531	1.6032	1.643	1.5684	1.5364	1.5684	1.531
17	1.5497	1.6032	1.643	1.5684	1.4403	1.5684	1.531
18	1.5497	1.6221	1.153	1.5708	1.5546	1.5364	1.531
19	1.5684	1.5546	1.3413	1.5546	1.4403	1.5364	1.5497
20	1.587	1.5912	1.3916	1.5912	1.4575	1.5546	1.5684
21	1.587	1.6095	1.0682	1.5912	1.5565	1.5565	1.587
22	1.6057		1.1869	1.5912	1.5565	1.5729	1.5684
23	1.6057	1.5912	1.1736	1.6244	1.5729	1.6057	1.587
24	1.5546	1.6057	1.6095	1.0774	1.6244	1.5565	1.6057
Max	1.6221	1.6617	1.6804	1.643	1.6278	1.6278	1.6095
Min	1.5089	1.5546	1.0682	1.065	1.4403	1.5364	1.5123
Avg	1.5670	1.6045	1.5403	1.4178	1.5679	1.5722	1.5684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 209 / 11 KV HILLTOP -I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4921	.5053	.4212	.4344	.5853	.503	.5041
2	.5716	.4923	.4085	.3467	.5487	.4778	.4561
3	.5792	.4864	.3957	.322	.5175	.4334	.4081
4	.5068	.4268	.3957	.3096	.2778	.4201	.3662
5	.4816	.3902	.3829	.2347	.2477	.3715	.3426
6	.4365	.3344	.3319	.2601	.2279	.3201	.3189
7	.362	.2892	.2804	.2641	.2641	.3144	.2881
8	.2761	.2721	.2766	.2362	.2561	.2629	.2972
9	.4024	.2936	.2848	.2481	.2673	.2881	.2892
10	.3109	.2601	.2641	.2481	.2481	.2724	.2557
11	.3239	.2881	.2881	.2481	.2717	.3467	.3022
12	.3144	.3001	.2717	.2515	.2629	.3048	.2789
13	.3241	.3071	.2717	.2743	.2905	.322	.3426
14	.2881	.3254	.2835	.2743	.3086	.3601	.3597
15	.3597	.337	.3071	.4854	.3086	.3658	.3887
16	.3757	.3662	.2362	.4854	.3467	.378	.3647
17	.3536	.3658	.2481	.4668	.2972	.3201	.3658
18	.3549	.3628	.4287	.3269	.322	.2972	.3536
19	.4134	.4668	.3481	.567	.3715	.2667	.4016
20	.4405	.4451	.3601	.4212	.4582	.4934	.4489
21	.6722	.4252	.4146	.4595	.4582	.7059	.5106
22	.5258	.4464	.4344	.6584	.5155	.5365	.5449
23	.7842	.4599	.3757	.6722	.4801	.5573	.567
24	.823	.5106	.434	.3368	.6348	.503	.5573
Max	.823	.5106	.4344	.6722	.6348	.7059	.567
Min	.2761	.2601	.2362	.2347	.2279	.2629	.2557
Avg	.4489	.3815	.3393	.3680	.3653	.3926	.3880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 210 / 11 KV University Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1014	.0686	.0766	.0648	.1075	.0743	.1052
2	.1054	.112	.0766	.0619	.1075	.0686	.1052
3	.1014	.112	.0766	.0648	.1075	.0686	.1052
4	.1029	.112	.0766	.0619	.1097	.0572	.1052
5	.0789	.112	.0766	.0648	.1086	.0619	.1052
6	.0903	.0934	.0638	.0619	.0914	.0619	.0876
7	.0602	.0934	.061	.0619	.0905	.0629	.0914
8	.1097	.0943	.0629	.0934	.0732	.0777	.0876
9	.128	.112	.0619	.1307	.0905	.0686	.1227
10	.1286	.0867	.06	.168	.189	.1362	.1395
11	.2801	.096	.096	.3547	.2244	.2848	.2673
12	.2934	.156	.1181	.3921	.2515	.4294	.2789
13	.2934	.1654	.1063	.2515	.2673	.2972	.2953
14	.2934	.1395	.1063	.2401	.2515	.2972	.2698
15	.2515	.1278	.1063	.3734	.2401	.2629	.2972
16	.2629	.1991	.0945	.3734	.2601	.2717	.2652
17	.2073	.3258	.0827	.3174	.2105	.2058	.3201
18	.1067	.1629	.084	.1646	.1143	.1991	.2241
19	.0934	.128	.084	.128	.0867	.128	.1307
20	.0934	.128	.0777	.128	.1132	.128	.1307
21	.112	.1463	.0869	.128	.088	.1463	.1494
22	.0777	.1097	.0892	.1097	.084	.1463	.1307
23	.112	.1097	.0777	.112	.0777	.08	.112
24	.1132	.0686	.1097	.0777	.112	.0743	.0743
Max	.2934	.3258	.1181	.3921	.2673	.4294	.3201
Min	.0602	.0686	.06	.0619	.0732	.0572	.0743
Avg	.1499	.1275	.0838	.1660	.1440	.1537	.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 214 / 11KV TELANGKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9709	.7842	.4334	.7499	.9511	.9694
2	.8573	.9149	.7655	.4405	.7316	.9145	.9145
3	.9145	.8589	.7468	.421	.695	.8573	.8688
4	.8596	.8215	.7468	.3963	.6584	.823	.8413
5	.7316	.7655	.7282	.3839	.6401	.7316	.7602
6	.695	.7095	.6161	.3715	.6036	.695	.695
7	.5853	.5975	.5601	.3467	.567	.6036	.6219
8	.5487	.5975	.5975	.5228	.5359	.583	.5853
9	.6036	.5601	.5415	.5228	.6036	.5853	.5853
10	.6722	.5788	.5975	.6535	.6722	.6535	.6908
11	.7468	.6348	.5788	.6722	.6722	.6908	.7468
12	.8215	.6908	.5788	.7095	.7655	.7282	.8029
13	.8589	.7282	.5788	.7468	.7655	.8402	.8775
14	.9522	.8029	.6535	.7655		.8589	.8962
15	1.0269	.8402	.6722	.8029	.8215	.8962	.9896
16	1.0456	.823	.5041	.7842	.823	.8215	1.0082
17	.8775	.7947	.5415	.7655	.7682	.8215	.9149
18	.7842	.7392	.3721	.7133	.7682	.7682	.8215
19	.8589	.8413	.4664	.7865	.8048	.7682	.8962
20	.8589	.8048	.4401	.8048	.8779	.823	.9522
21	.8775	.7499	.4458	.7865	.905	.9145	.9709
22	.9149	.7865	.6584	.823	.9694	1.2071	1.0456
23	.9709	.7682	.4527	.8215	.8916	1.0642	1.1389
24	1.0059	1.0082	.8048	.4401	.8402	.9088	1.1016
Max	1.0456	1.0082	.8048	.823	.9694	1.2071	1.1389
Min	.5487	.5601	.3721	.3467	.5359	.583	.5853
Avg	.8341	.7662	.6013	.6214	.7448	.8129	.8623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 215 / 11KV TILAK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8589	.7282	.4706	.7499	.9145	.905
2	.823	.8215	.7282	.483	.7316	.905	.8779
3	1.0059	.7655	.7095	.4801	.7133	.823	.823
4	.7682	.7655	.7095	.4572	.695	.8596	.7682
5	.7316	.7468	.7095	.4582	.6838	.7499	.7316
6	.7059	.7095	.5975	.4087	.6468	.6767	.6767
7	.6584	.6908	.6348	.4087	.6401	.6584	.6722
8	.7133	.6348	.6348	.6348	.6838	.6859	.695
9	.7373	.7468	.6722	.7655	.7499	.7186	.8048
10	.8962		.6722	.7655	.9335	.9709	.9896
11	1.0642	1.0456	.8029	.9149	.9896	1.1016	1.1763
12	1.1016	1.1016	.8775	.9335	1.0456	1.1576	1.1763
13	1.1203	1.1203	.8402	1.0269	1.0456	1.1949	1.1576
14	1.1949	1.1016	.9709	.9709	1.1949	1.1576	1.1949
15	1.2696	1.2323	.9709	1.1016	1.1949	1.2696	1.363
16	1.363	1.2197	.8402	1.1763	1.1888	1.2883	1.4003
17	1.251	1.1273	.7842	1.1389	1.0608	1.2883	1.363
18	1.1389	1.0903	.5571	1.0903	1.0288	1.2254	1.2696
19	1.1389	1.1706	.5401	1.0791	1.1888	1.1888	1.2883
20	1.0829	.9877	.5521	1.0059	1.0974	1.1157	1.2696
21	.9149	.8596	.5281	.8962	.9877	1.0059	1.0829
22	.9335	.823	.442	.823	.9214	1.0425	1.0456
23	.9522	.823	.5182	.8589	.9511	1.0642	1.0642
24	1.0082	.9522	.7865	.503	.8029	.9511	1.0082
Max	1.363	1.2323	.9709	1.1763	1.1949	1.2883	1.4003
Min	.6584	.6348	.442	.4087	.6401	.6584	.6722
Avg	.9779	.9302	.7003	.7855	.9136	1.0006	1.0335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 201 / 11KV VNIT(nagpur)

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119		1.5893	1.419	1.5708	2.0165	2.2405
2	1.9753		1.5893	1.2567	1.5278	1.8671	2.0911
3	1.9387		1.5154	1.1458	1.4523	1.7551	1.8671
4			1.4563	1.0719	1.3769	1.6804	1.7737
5			1.3817	1.0349	1.3014	1.5684	1.7353
6			1.251	.9979	1.226	1.419	1.5844
7		1.6644	1.307	1.0349	1.2071	1.363	1.4335
8		1.2986	1.2323	1.1576	1.2826	1.3817	1.3203
9		1.363	1.3256	1.4563	1.423	1.4937	1.475
10		1.5123	1.3256	1.5684	1.5466	1.6244	1.6617
11		1.7177	1.4563	1.7002		1.643	1.8858
12		1.7924	1.475	1.6632	1.8673	1.8858	2.0538
13		1.9418	1.4003	1.848	1.9231	1.9418	2.1658
14		1.9231	1.4937	1.848	2.0182	2.1658	2.3525
15		2.1098	1.5684	1.9418	1.9805	2.3152	2.4832
16		2.2405	1.3443	2.0165	2.0165	2.2405	2.4646
17		2.0883	1.2323	1.922	1.9959	2.0725	2.3152
18		1.9589	1.307	1.8107	1.885	1.9239	2.1472
19		2.0513	1.4784	1.8861	1.922	2.0559	2.2218
20		2.0698	1.5154	1.8861	2.1658	2.1879	2.2405
21		1.6632	1.4784	1.8107	2.1253	2.1472	2.2405
22		1.7372	1.5684	1.8861	2.1658	2.2634	2.3899
23		1.7556	1.531	1.8111	2.2965	2.4086	2.5393
24	2.268		1.6632	1.5123	1.6632	2.0911	2.3712
Max	2.268	2.2405	1.6632	2.0165	2.2965	2.4086	2.5393
Min	1.9387	1.2986	1.2323	.9979	1.2071	1.363	1.3203
Avg	2.0485	1.8169	1.4369	1.5703	1.7365	1.8963	2.0439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 202 / 11KV SHANKAR NGR

SHEDDABLE URBAN

SWIT.INOMER Feeder KV- 11 /
INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.7558	1.46	1.3443	1.4784	1.7737	2.2634
2	1.7558	1.7193	1.4045	1.2567	1.4146	1.6804	2.1472
3	1.7558	1.6095	1.3491	1.1088	1.3203	1.587	1.9605
4		1.4998	1.307	1.1458	1.226		1.8671
5		1.39	1.251	1.0719	1.1506	1.3817	1.7353
6		1.1888	1.1949	1.1088	1.0751	1.1949	1.5844
7		1.1157	1.0456	.961	1.0562	1.1576	1.4712
8		1.0791	1.0456	1.0456	1.0562	1.0456	1.4146
9		1.2696	1.0642	1.1949	1.0534	1.2696	1.5123
10		1.643	1.2136	1.3443	1.4335	1.419	1.9044
11	1.6991	1.5684	1.2696	1.4784		1.6991	2.3339
12	1.9231	1.7364	1.2883	1.7926	1.8484	1.8858	2.6139
13	2.0911	1.9231	1.363	1.922	1.9791	2.0165	2.838
14	2.1285	1.9418	1.475	1.885	1.9239	2.0165	2.8753
15	2.3011	2.0538	1.4937	1.9605	2.0182	2.1658	2.2405
16	2.3899	2.0165	1.1949	2.0165	2.0165	2.1658	2.3525
17	2.2177	1.9404	1.1949	1.9404	1.922	2.0351	2.2965
18	1.922	1.848	1.307	1.8861	1.8296	2.7161	2.0165
19	1.9774	1.9959	1.4415	1.9993	1.922	2.6217	2.1098
20	1.9774	2.0698	1.4969	1.9993	2.0725	2.7538	2.2032
21	1.8665	1.6817	1.5339	1.8861	1.9959	2.5953	2.0911
22	1.8296	1.5893	1.419	1.7541	1.9418	2.4897	2.0165
23	1.829	1.6263	1.4377	1.7002	2.0165	2.5019	2.0911
24	1.9387	1.8107	1.6078	1.307	1.5524	1.9418	2.3712
Max	2.3899	2.0698	1.6078	2.0165	2.0725	2.7538	2.8753
Min	1.6991	1.0791	1.0456	.961	1.0534	1.0456	1.4146
Avg	1.9655	1.6697	1.3274	1.5462	1.6219	1.9180	2.0963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 203 / 11KV RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8048	.6653	.5975	.6653	.8402	.9522
2	.8413	.7865	.6468	.5544	.679	.8029	.8775
3	.8048	.7499	.5914	.5544	.6413	.7842	.8402
4	.7682	.7316	.5788	.5175	.6036	.7468	.7655
5	.7316	.695	.5601	.5175	.5658	.7095	.7167
6	.695	.5853	.5228	.5175	.5281	.6161	.679
7	.6584	.6401	.5041	.462	.5658	.5601	.6036
8	.6036	.6219	.5228	.5601	.6036	.5975	.6602
9	.6722	.6535	.6161	.5975	.6161	.7095	.7468
10	.7655	.6908	.5975	.6535	.7356	.7095	.7842
11	.9709	.8962	.6908	.8316		.6535	.9522
12	1.1389	1.0082	.7282	.961	.9997	.7468	1.0829
13	1.1389	1.0456	.7842	.9979	1.0269	1.1576	1.1576
14	1.1576	1.1203	.7655	.9979	1.0562	1.1949	1.251
15	1.2696	1.1203	.7655	1.0829	1.094	1.2696	1.251
16	1.363	1.1949	.6722	1.1203	1.1389	1.2323	1.2883
17	1.2752	1.1458	.7095	1.1088	1.1827	1.2323	1.307
18	1.0534	1.0534	.7468	1.0562	1.1088	1.1317	1.1763
19	1.1273	1.1088	.8131	1.0562	1.1088	1.226	1.2696
20	1.1088	1.0903	.8501	1.0562	1.1576	1.1506	1.1949
21	.9795	.8686	.7392	.9431	1.0903	1.1016	1.1016
22	.9425	.7762	.7095	.9054	1.0456	1.1317	1.0829
23	.9328	.7392	.6535	.8131	.9896	1.1016	1.1203
24	1.0242	.8413	.6838	.5975	.7392	.9335	.9896
Max	1.363	1.1949	.8501	1.1203	1.1827	1.2696	1.307
Min	.6036	.5853	.5041	.462	.5281	.5601	.6036
Avg	.9542	.8737	.6716	.7942	.8671	.9308	.9938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 204 / 11KV DANDIGE LAYOUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5853	.462	.4481	.5544	.6348	.6348
2	.5853	.5853	.462	.4435	.5658	.5601	.5975
3	.5487	.5487	.4805	.4251	.5281	.5415	.5601
4	.5121	.4938	.4854	.4251	.5281	.5228	.5415
5	.5121	.5121	.4668	.4251	.4904	.4854	.5281
6	.4755	.4755	.4854	.4066	.4527	.4481	.5093
7	.439	.439	.3734	.3696	.4527	.4108	.4904
8	.439	.4024	.3734	.3921	.4904	.4481	.5093
9	.6535	.6161	.5415	.5975	.5788		.6722
10	.7282	.6722	.5788	.6722	.6979		.7655
11	.8402	.7468	.5601	.7392		.8962	.8589
12	.8962	.8962	.6161	.8131	.8676	.9149	.9335
13	.9709	.9522	.6722	.8131	.8962	.9522	.9709
14	.9896	.9149	.6348	.8871	.9242	.9522	.9896
15	1.0269	.9149	.7095	.8962	.9054	.9709	1.0082
16	1.0829	.9335	.5788	.9335	.9522	.9709	1.0269
17	1.0349	.9055	.5975	.8131	.9425	1.0082	1.0456
18	.8501	.8501	.6535	.7922	.8871	.9619	.9896
19	.8131	.9055	.7023	.8488	.9425	.9242	.9149
20	.8059	.8501	.7392	.8299	.9335	.9808	1.0082
21	.7392	.6653	.6653	.6602	.8131	.8962	.8215
22	.7207	.6653	.6161	.7545	.7655	.8676	.8402
23	.6584	.5359	.6161	.5914	.6722	.7095	.8029
24	.6401	.5853	.5175	.4668	.5914	.6348	.6722
Max	1.0829	.9522	.7392	.9335	.9522	1.0082	1.0456
Min	.439	.4024	.3734	.3696	.4527	.4108	.4904
Avg	.7312	.6938	.5662	.6435	.7145	.7587	.7788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 205 / 11KV SMG HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2195	.1663	.1867	.2033	.2241	.2427
2	.2012	.1829	.1663	.1663	.2075	.2054	.2427
3	.2012	.1829	.1848	.1478	.1886	.1867	.2054
4	.1829	.2012	.1867	.1478	.1886	.1867	.2054
5	.1829	.1829	.1867	.1478	.1886	.1867	.1886
6	.1829	.2012	.1867	.1478	.1886	.1867	.2263
7	.1829	.1646	.2054	.1478	.2075	.1867	.2641
8	.1829	.1829	.1867	.168	.1886	.1867	.2641
9	.2427	.2241	.2054	.2054	.2427	.2241	.3547
10	.2402	.2241	.2241	.2614	.3018	.2614	.2987
11	.2614	.2987	.1867	.2218		.2987	.3174
12	.2614	.2614	.168	.2402	.3018	.2241	.2987
13	.2801	.2614	.1867	.2402	.2614	.2218	.3547
14	.2614	.2987	.1867	.2772	.2263	.2241	.3734
15	.3174	.2987	.168	.2801	.2829	.2614	.3361
16	.3547	.2241	.168	.3174	.2987	.2427	.3361
17	.3142	.2218	.2054	.2957	.2587	.2241	.3174
18	.2772	.2218	.168	.2452	.2587	.3395	.3174
19	.2772	.2218	.1663	.2641	.2587	.2829	.3361
20		.2033	.9055	.2263	.2241	.2641	.2614
21	.2033	.1848	.1478	.2452	.3142	.2427	.2614
22	.2033	.1663	.168	.2452	.2241	.2829	.3174
23	.2195	.1848	.168	.2402	.2614	.2427	.2614
24	.1829	.2012	.1848	.1494	.2402	.2241	.2241
Max	.3547	.2987	.9055	.3174	.3142	.3395	.3734
Min	.1829	.1646	.1478	.1478	.1886	.1867	.1886
Avg	.2354	.2173	.2115	.2173	.2399	.2338	.2836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 206 / 11KV DHARAMPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3658	.3696	.3547	.4435	.5228	.5415
2	.5121	.4572	.3696	.3326	.4527	.4668	.5041
3	.3292	.4755	.3696	.3326	.415	.4481	.4854
4	.3292	.439	.3734	.3142	.3772	.4294	.4481
5	.2926	.4024	.3361	.2957	.3395	.3921	.415
6	1.1706	.3841	.3174	.2957	.3018	.3547	.3961
7	.2561	.3109	.2987	.2587	.3018	.3734	.3772
8	1.4266	.3109	.2987	.3361	.3018	.3547	.3584
9	1.643	.3547	.3174	.2987	.3174	.3547	.3174
10	2.1253	.4108	.3734	.4481	.4904	.4854	.4668
11	.6722	.5788	.4108	.6099		.6653	.6722
12	.7468	.7282	.3921	.7392	.7167	.8215	.8589
13	.8775	.7842	.4481	.8131	.7468	.8402	.9335
14	.9149	.7655	.5415	.7392	.8299	.8962	.8775
15	.8589		.5975	.8402	.8488	.9709	.9709
16	.9709	.7842	.4668	.8215	.8775	.9522	1.0269
17	.961	.7762	.4481	.8131	.8871	.8589	.9522
18	.7577	.7577	.4668	.7545	.8131	.7922	.9149
19	.8871	.8131	.5914	.8299	.8131	.8488	.8775
20	.8316	.7577	.5175	.7545	.8589	.8676	.8775
21	.7577	.5914	.5544	.679	.7023		.7842
22	.6468	.5175	.4854	.5658	.6348	.679	.7095
23	.6401	.4805	.4668	.5914	.5975	.6348	.6722
24	.6219	.5853	.4435	.4294	.4805	.6348	.5975
Max	2.1253	.8131	.5975	.8402	.8871	.9709	1.0269
Min	.2561	.3109	.2987	.2587	.3018	.3547	.3174
Avg	.8241	.5579	.4273	.5520	.5890	.6367	.6681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 208 / 11KV TRIKONI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2012	.1294	.168	.2218	.2241	.2427
2	.2195	.1829	.1109	.1478	.2263	.2054	.2427
3	.2195	.1829	.1109	.1478	.2263	.2241	.2054
4	.2012	.1829	.112	.1478	.1886	.2241	.2054
5	.1829	.1829	.1307	.1294	.1886	.2241	.2075
6	.1829	.1646	.1494	.1294	.1886	.2241	.2263
7	.1829	.1829	.1307	.1109	.2263	.2241	.2263
8	.1848	.1646	.112	.1494	.1886	.2054	.2263
9	.1867	.1867	.2054	.168	.2402	.2614	.2054
10	.3326	.2054	.2054	.2427	.2829	.2427	.2801
11	.4854	.3734	.2614	.3696		.4854	.4481
12	.6348	.5228	.3174	.037	.547	.4854	.5415
13	.6161	.5228	.3547	.5914	.5601	.5975	.5975
14	.6348	.4108	.3734	.5544	.5847	.5601	.6348
15	.6535	.5415	.3734	.5975	.6036	.6348	.5975
16	.7095	.5228	.3174	.5601	.5975	.6161	.6722
17	.6099	.5175	.2241	.5175	.5914	.6348	.6722
18	.5175	.4805	.2054	.4904	.5729	.6413	.5975
19	.4854	.5175	.2587	.4904	.5914	.5658	.5788
20	.4805	.4435	.2587	.4527	.4854	.5093	.5415
21	.4066	.2957		.3772	.4251	.4481	.4481
22	.2587	.2218	.2054	.2829	.3174	.3395	.2987
23	.2561	.2033	.168	.2218	.2987	.2987	.2987
24	.2195	.2195	.1478	.168	.2218	.2614	.2614
Max	.7095	.5415	.3734	.5975	.6036	.6413	.6722
Min	.1829	.1646	.1109	.037	.1886	.2054	.2054
Avg	.3784	.3179	.2114	.3022	.3728	.3891	.3940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 209 / 11 kv Hill Top II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.1888	1.0349	.8402	.961	1.2323	1.307
2	1.2437	1.1523	1.0164	.7762	.9242	1.1203	1.2696
3	1.2071	1.134	.9979	.7392	.8676	1.0117	1.1576
4	1.0974	1.0242	.9709	.7023	.8299	1.0642	1.1016
5	1.0608	.9877	.8962	.6838	.7922	.9896	1.0562
6	.7682	.8413	.8029	.6838	.7545	.8215	.9431
7	.8048	.7499	.7468	.6653	.7167	.7468	.7922
8	.7316	.7133	.7095	.6348	.679	.7282	.7356
9	.7468	.7095	.5415	.6722	.7095	.7282	.7282
10	.7392	.6722	.7282	.7095	.7356	.7468	.7468
11	.7282	.6908	.7095	.6468		.5601	.7468
12	.7842	.8215	.6722	.6838	.7167	.6161	.7655
13	.8402	.8402	.7282	.7392	.7468	.8215	.8215
14	.9709	.9149	.7842	.7762	.811	.9149	.9149
15	1.0456	.9522	.8029	.8775	.8865	.9709	1.0269
16	1.6804	.9709	.6535	.8402	.8962	1.0082	1.0456
17	1.0164	.961	.6036	.7577	.8501	.9149	.9522
18	.8501	.9055	.6908	.8488	.8131	.8865	.8775
19	1.0164	1.0349	.9055	1.0185	.924	.9431	.9896
20	1.0719	1.0534	.9055	1.0374		1.094	1.1016
21	1.1273	.924	.924	1.094	1.1273	1.1949	1.2136
22	1.2197	.9795	.9335	1.1317	1.2696	1.3392	1.363
23	1.2803	1.0719	.9522	1.1088	1.363	1.4377	1.5123
24	1.4083	1.262	1.0903	.8775	1.0349	1.307	1.419
Max	1.6804	1.262	1.0903	1.1317	1.363	1.4377	1.5123
Min	.7282	.6722	.5415	.6348	.679	.5601	.7282
Avg	1.0300	.9398	.8250	.8144	.8822	.9666	1.0245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 214 / 11KV SHIVAJI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.9877	.8501	.7468	.8316	1.0456	1.1763
2		.9328	.8131	.7023	.7922	1.0269	1.0269
3		.8962	.8316	.7023	.7356	.9335	.9335
4		.8048	.7842	.6653	.6979	.8962	.9149
5			.7282	.6283	.6602	.8215	.8676
6	.7133	.6767	.6535	.6283	.6224	.7282	.7545
7	.6767	.6401	.8029	.5729	.6224	.6348	.7167
8	.2012	.6036	.5975	.5228	.5847	.6161	.6224
9	.6722	.5601	.5788	.5975	.6348	.6161	.6161
10	.6283	.5975	.6348	.6161	.6602	.6535	.6535
11	.7282	.8215	.6908	.7577		.7842	.7655
12	.8962	.9522	.7282	.7947	.8676	.9149	.8589
13	.9709	.8589	.6908	.8316	.8589	.8402	.8775
14	.9709	.8676	.6908	.8871	.9242	.9709	.9335
15	1.0642	.9522	.8029	1.0082	.9808	1.0269	.9709
16	1.2323	1.0269	.6348	1.0082	.9709	.2987	.9522
17	1.1088	1.0534	.6348	.961	.9425	1.0082	1.0829
18	.9795	.961	.7282	.9808	.9055	.9054	.9709
19	1.0164	.9795		1.0185	.9055	.9619	.9335
20	.9795	.924	.7577	.9054	1.0269	.9997	1.0269
21	.9979	.8501	.7577	.8676	1.0349	1.0269	1.0642
22	.924	.8402	.7468	.9054	1.0456	1.1883	1.1203
23	1.0242	.8871	.7842	.961	1.1949	1.251	1.2883
24	1.1157	1.0608	.9055	.7842	.8686	1.1203	1.2136
Max	1.2323	1.0608	.9055	1.0185	1.1949	1.251	1.2883
Min	.2012	.5601	.5788	.5228	.5847	.2987	.6161
Avg	.8944	.8580	.7316	.7939	.8421	.8862	.9309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 217 / 11KV ALANKAR TALKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1523	1.0974	.924	.8215	.924	1.1203	1.251
2	1.134	.9877	.924	.7762	.8865	1.0269	1.1203
3	1.0974	.9694	.924	.7762	.8299	1.0082	1.0269
4	.9877	.9511	.8962	.7392	.7733	.9709	.9709
5	.9511	.8779	.8402	.7023	.7356	.8962	.9431
6	.823	.8048	.7468	.6838	.6979	.8029	.8676
7	.7316	.7316	.6535	.6283	.6401	.7095	.7545
8	.7316	.695	.6722	.6722	.7167	.6722	.7545
9	.7655	.7095	.6722	.8029	.7468	.8775	.7842
10	.9425	.9149	.7282	.8962	.9242	.9335	.9896
11	1.0456	.9149	.7655	.9425		1.0829	1.1763
12	1.1949	1.0642	.8589	1.0534	1.1883	1.251	1.2323
13	1.307	1.1016	.8215	1.1273	1.2696	1.2883	1.2323
14	1.363	1.1949	.9149		1.226	1.3443	1.3256
15	1.4377	1.251	.8775	1.2136	1.2637	1.3817	1.475
16	1.5123	1.307	.7468	1.2136	1.2883	1.419	1.5123
17	1.4415	1.2197	.7655	1.2012	1.2382	1.3256	1.3817
18	1.1827	1.1273	.7842	1.094	1.1458	1.3203	1.307
19	1.2382	1.2382	.9979	1.1694	1.2567	1.3014	1.2883
20	1.1827	1.2382	.961	1.1128	1.2323	1.3014	1.363
21	1.1088	1.1088	.961	1.094	1.2197	1.2883	1.2883
22	1.1827	.9795	.9335	1.1317	1.2696	1.3203	1.363
23	1.1888	.9979	.9335	1.0719	1.2696	1.307	1.4937
24	1.2254	1.1157	.9979	.8589	1.0164	1.1763	1.251
Max	1.5123	1.307	.9979	1.2136	1.2883	1.419	1.5123
Min	.7316	.695	.6535	.6283	.6401	.6722	.7545
Avg	1.122	1.0249	.8459	.9471	1.0330	1.1302	1.1730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 218 / 11KV MADHUMADHAV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2378	.2402	.2241	.2218	.2614	
2	.2561	.2195	.2218	.1848	.2263	.2641	
3	.2195	.2195	.1848	.1848	.2075	.2427	
4	.2195	.2012	.1867	.1848	.2075	.2427	
5	.2012	.2012	.1867	.1663	.1886	.2241	
6	.2012	.1829	.1867	.1663	.1886	.2241	
7	.2012	.1646	.1867	.1663	.2075	.2241	
8	.2012	.2012	.1867	.1867	.2263	.2241	
9	.2614	.2241	.1867	.2614	.2801	.2801	
10	.3511	.2054	.2427	.3361	.3584	.3734	
11	.5041	.4481	.2614	.462		.5415	
12	.5975	.5601	.2801	.5729	.5658	.5975	
13	.6348	.5788	.2987	.6099	.5975	.6161	
14	.6348	.5601	.3361	.5544	.6224	.6348	
15	.7282	.5601	.3734	.6161	.6224	.6535	.7282
16	.7468	.5601	.2801	.6161	.5975	.7282	.6722
17	.6283	.5729	.2801	.6283	.6099		.6722
18	.5914	.5359	.3174	.5658	.5359		.6348
19	.5729	.6099	.3142	.5658	.5359		.6722
20	.499	.4805	.3142		.5228		.6161
21	.4251	.3511	.3142	.415	.4435		.5041
22	.3696	.2772	.2801	.3395	.3174		.3921
23	.3292	.2772	.2427	.2587	.3174		.3734
24	.2926	.2561	.2587	.2054	.2218	.3174	
Max	.7468	.6099	.3734	.6283	.6224	.7282	.7282
Min	.2012	.1646	.1848	.1663	.1886	.2241	.3734
Avg	.4135	.3619	.2567	.3683	.3836	.3912	.5850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 219 / POONAM CENTRAL MALL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.1109	.112	.1109	.112	.112
2	.1097		.1109	.1109	.1132	.112	.112
3	.1097	.1097	.1109	.1109	.1132	.112	
4	.1097	.1097	.112	.1109	.1132	.112	.112
5	.1097	.1097	.112	.1109	.1132	.112	.1132
6	.1097	.1097	.112	.1109	.1132	.112	.1132
7	.1097	.1097	.112	.1109	.1132	.112	.1132
8	.1097	.1097	.112	.112	.1132	.112	.1132
9	.112	.112	.112	.112	.112	.112	.112
10	.1109	.112	.112	.112	.1132	.112	.112
11	.3547	.2987	.2241	.2218		.2427	.2614
12	.5415	.5415	.5415	.5359	.547	.5228	.5601
13	.5228	.5228	.5041	.5175	.499	.5228	.5415
14	.5228	.5228	.5041	.5175	.5093	.5175	.5228
15	.5041	.5228	.5041	.5415	.5281	.5228	.5415
16	.5601	.5415	.5228	.5228	.5228	.5415	.5228
17	.5175	.5544	.5041	.4805	.499	.5228	.5228
18	.4805	.5359	.5041	.4904	.499	.5847	.5041
19	.5175	.5914	.5729	.4904	.5175	.6036	.5041
20	.499	.5914	.5729	.4904	.5041	.5847	.5228
21	.4805	.5544	.5544	.5093	.4805	.5228	.5041
22	.5914	.5544	.5601	.4904	.4854	.4904	.4668
23	.1097	.1109	.112	.1109	.112	.112	.112
24	.1097	.1097	.1109	.112	.1109	.112	.112
Max	.5914	.5914	.5729	.5415	.547	.6036	.5601
Min	.1097	.1097	.1109	.1109	.1109	.112	.112
Avg	.3088	.3280	.3087	.2977	.3019	.3135	.3135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164840 / 33 KV VNIT

Feeder No / Name : 201 / 11 KV VNIT EXPRESS FDR
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5041	.4904	.415	.4527	.4715	5.1303
2	.4904	.5041	.4854	.3961	.415	.4527	.5093
3	.4904	.5041	.4854	.3961	.415	.415	.5093
4	.4904	.5041		.3772	.415	.415	.4715
5	.4527	.5041		.3772	.415	.415	.4715
6	.3961	.5041	.3772	.3772	.3772	.3772	.4527
7	.4527	.3921	.4108	.3772	.3772	.3772	.4527
8	.4715	.3921	.4338	.3961	.415	.3961	.4527
9	.4715	.4108	.4294	.5093	.415	.4338	
10	.6602	.415	.4527	.547	.5788	.5601	
11	.811	.4904	.4481	.5975	.6979	.6535	.7356
12	.5487	.5093	.4854	.7167	.7167	.8029	.7733
13	.7733	.4904	.4668	.7356	.7356	.811	.7842
14	.8676	.5093	.4294	.6979	.6979	.7545	.7733
15	.8676	.5281	.5041		.0168	.7733	.8215
16	.9054	.547	.4715			.811	.2926
17	.8676	.5658	.5658	.8029	.3109	.8299	.3439
18	.7922	.5281	.4527	.5788	.2402	.2561	.2561
19	.7282	.5601	.4904	.5601	.2033	.2353	.2402
20	.5788	.5281	.4668	.5093	.2012	.2149	.2195
21	.5847	.4904	.4527	.5093	.2012	.2126	.197
22	.5228	.4715	.4527	.4904	.5093	.2103	.5281
23	.5228	.4715	.4338	.4904	.4904	.547	
24	.547	.5041	.4715	.4338	.4715	.4715	.5228
Max	.9054	.5658	.5658	.8029	.7356	.8299	5.1303
Min	.3961	.3921	.3772	.3772	.0168	.2103	.197
Avg	.6168	.4929	.4617	.5132	.4247	.4957	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 201 / 11 KV SHASTRI LAY OUT SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.182	.9694	.7499	.8779	1.0974	1.2803
2	1.086	1.0029	.9328	.7316	.8413	1.0425	1.1888
3	1.0317	.9313	.8779	.7133	.8048	.9694	1.1157
4	.9412	.8417	.823	.7133	.7682	.9145	1.0242
5	.8326	.8059	.7682	.695	.7316	.8596	.9511
6	.788	.7442	.695	.6584	.695	.7865	.8413
7	.7087	.7011	.695		.6584	.7499	.8048
8	.7087	.7362	.6584	.695	.695	.7682	.7682
9	.7164	.6733	.6401	.7682	.7682	.7865	.8048
10	.7682	.7087	.7164	.724	.7964	.7602	.7602
11	.8413	.8059	.7059	.7602	.8145	.8869	.905
12	.8779	.9231	.7343	.8688	.8869	.905	.9593
13	.9877	.9412	.7059	.905	.905	.8869	1.0608
14	1.0059	1.0498	.7602	.8145	.905	1.0679	1.2071
15	1.134	1.0974	.7783	.9231	.9412	1.1222	1.2437
16	1.2437	1.0608	.6626	.9412	1.0317	1.1403	1.2437
17	1.0608	1.0425	.6697	.8688	.9877	1.0498	1.1706
18	.8962	.9593	.7701	.8869	.9231	.9774	1.0317
19	1.0242	1.134	.8413	.9593	1.0387	1.0208	1.0679
20	1.0608	1.0631	.8413	.9774	1.1222	1.1403	1.2127
21	1.0242	.9134	.8413	.9774	1.1403	1.1765	1.2127
22	1.0608	.9412	.823	.9593	1.1706	1.2986	1.3717
23	1.1584	.9877	.8413	1.0242	1.3352	1.4266	1.5181
24	1.267	1.1765	.9877	.7865	.9511	1.262	1.3717
Max	1.267	1.182	.9877	1.0242	1.3352	1.4266	1.5181
Min	.7087	.6733	.6401	.6584	.6584	.7499	.7602
Avg	.9743	.9343	.7808	.8305	.9079	1.0040	1.0882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 202 / 11 KV BHENDE LAYOUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5746	1.4864	1.3169	1.0242	1.2071	1.6278	
2	1.5565	1.4685	1.262	.9877	1.1706	1.5546	1.7193
3	1.448	1.3611	1.1888	.9511	1.134	1.4815	1.6278
4	1.3575	1.2536	1.1157	.9145	1.0608	1.4266	1.5364
5	1.1946	1.1104	1.0608	.8779	1.0059	1.3169	1.4266
6	1.0566	.9745	.9694	.8413	.9511	1.0974	1.1888
7	.9391	.8939	.8779	.823	.8779	1.0425	1.0242
8	.9214	.8939	.8413	.823	.8962	.9694	1.0242
9	.8954	.815	.8413	.9328	.9328	.9511	.9328
10	.6584	.8682	.8954	.8688	.8869	.8688	.9412
11	.8596	.9134	.905	.8145	.905	.905	.9412
12	.9145	.9231	.8954	.8145	.8688	.8869	1.0317
13	.9511	.9774	.8869	.8326	.9412	.9593	1.0425
14	1.0242	1.0498	.9774	.8326	.9593	1.086	1.1706
15	1.2071	1.134	1.0136	.9231	1.0498	1.1765	1.3169
16	1.2437	1.2254	.8238	.9955	1.0498	1.2308	1.3352
17	1.1523	1.2071	.7602	.9774	1.0791	1.1584	1.1888
18	.9328	1.0498	.9313	.9231	.9593	1.0317	1.086
19	1.1523	1.2489	1.0059	1.1403	1.1462	1.1283	1.1584
20	1.2986	1.2048	1.0791	1.267	1.3575	1.3394	1.4118
21	1.3352	1.182	1.1523	1.3032	1.448	1.5023	1.5746
22	1.4632	1.267	1.134	1.3394	1.5729	1.7558	1.8473
23	1.5746	1.2986	1.134	1.4083	1.7375	1.9387	2.1033
24	1.7556	1.5927	1.3535	1.0974	1.3169	1.7375	1.9753
Max	1.7556	1.5927	1.3535	1.4083	1.7375	1.9387	2.1033
Min	.6584	.815	.7602	.8145	.8688	.8688	.9328
Avg	1.1861	1.1416	1.0176	.9881	1.1048	1.2572	1.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 203 / 11 KV DIN DAYAL NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5746	1.4685	1.2803	1.0791	1.1706	1.5546	1.7193
2	1.5023	1.379	1.2254	1.0425	1.134	1.4815	1.6095
3	1.4299	1.2894	1.1706	1.0059	1.0791	1.39	1.5181
4	1.3213	1.1641	1.1157	.9694	1.0425	1.3169	1.39
5	1.1765	1.0745	1.0608	.9328	1.0059	1.2071	1.2986
6	1.0387	.9922	.9877	.8779	.9877	1.0608	1.1523
7	1.0099	.9465	.8962	.9145	.8779	.9877	1.0608
8	.9922	.9816	.9694	.9145	.9694	1.0608	1.0242
9	1.0208	.9568	.9877	.9877	1.0242	1.0242	1.0974
10	1.0608	1.0099	1.0029	1.0317	1.0317	1.0679	1.1765
11	1.134	1.0566	1.0136	1.0136	1.1222	1.1403	1.1584
12	1.2071	1.1041	1.0387	1.1041	1.1403	1.1765	1.3032
13	1.262	1.1584	1.0679	1.1584	1.1222	1.2127	1.4449
14	1.2803	1.2489	1.086	1.1222	1.1946	1.3394	1.4998
15	1.39	1.3352	1.086	1.1946	1.2127	1.3756	1.5729
16	1.4632	1.4083	.9134	1.2127	1.267	1.4118	1.5912
17	1.3717	1.3352	.9231	1.2127	1.2803	1.4299	1.4632
18	1.2437	1.2851	1.0029	1.2127	1.2127	1.2308	1.3213
19	1.5546	1.5565	1.2254	1.4299	1.4148	1.3969	1.5384
20	1.4998	1.5061	1.2986	1.4661	1.5384	1.5565	1.6651
21	1.4815	1.3611	1.2986	1.5023	1.5384	1.647	1.7556
22	1.5546	1.3937	1.3169	1.4661	1.6827	1.7558	1.8642
23	1.6108	1.4083	1.1706	1.39	1.6827	1.9022	2.0119
24	1.7556	1.5384	1.3717	1.1523	1.262	1.6827	1.8107
Max	1.7556	1.5565	1.3717	1.5023	1.6827	1.9022	2.0119
Min	.9922	.9465	.8962	.8779	.8779	.9877	1.0242
Avg	1.3307	1.2483	1.1046	1.1414	1.2081	1.3504	1.4603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 204 / 11 KV JAITALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6089	.5853	.4755	.5487	.7133	.7682
2	.6878	.6089	.5487	.4755	.5121	.6767	.7133
3	.6154	.5731	.5121	.4572	.5121	.6401	.6584
4	.543	.5373	.4755	.439	.4755	.5853	.6036
5	.5249	.5194	.4755	.4207	.4572	.5487	.5487
6	.4835	.4784	.4572	.4024	.439	.5121	.4938
7	.4607	.4207	.3658	.3658	.4024	.439	.4755
8	.4252	.3681	.3841	.3658	.4024	.4572	.4572
9	.4477	.4075	.4024	.439	.4572	.4938	.4938
10	.439	.4252	.4477	.3982	.4344	.4344	.4887
11	.439	.4298	.4706	.4344	.4525	.4706	.5068
12	.4755	.4887	.4656	.4344		.5068	.5068
13	.4938	.4887	.4706	.4525	.4706	.5249	.5487
14	.5487	.543	.4887	.4344	.5068	.5611	.5853
15	.5853	.567	.4887	.4706	.4887	.5792	.6401
16	.6401	.5853	.394	.4887	.4887	.5973	.6219
17	.5487	.567	.4163	.4344	.5304	.5611	.6401
18	.4938	.5249	.4119	.4706	.4887	.5249	.5792
19	.6401	.6335	.5121	.5792	.591	.5731	.6335
20	.6219	.6201	.5304	.6154	.7059	.7059	.7421
21	.6219	.5731	.5487	.6335	.7059	.7602	.7602
22	.6584	.5792	.5304	.6516	.7499	.8413	.823
23	.6878	.6219	.4938	.6219	.7865	.8779	.9694
24	.7964	.6516	.6219	.5121	.567	.7499	.8413
Max	.7964	.6516	.6219	.6516	.7865	.8779	.9694
Min	.4252	.3681	.3658	.3658	.4024	.4344	.4572
Avg	.5668	.5342	.4791	.4780	.5293	.5973	.6292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 205 / 11 KV TRIMURTI NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	1.1104	.9328	.7865	.9145	1.134	1.3352
2	1.1041	1.0566	.9145	.7499	.8779	1.0425	1.262
3	1.0498	.985	.8596	.7316	.8413	.9877	1.1706
4	.9774	.9134	.823	.7133	.823	.9328	1.0974
5	.905	.8775	.7682	.695	.7682	.8596	.9877
6	.8596	.815	.7316	.695	.7316	.823	.8779
7	.815	.8063	.7316	.6584	.695	.823	.8779
8	.7796	.7537	.695	.7316	.7499	.8048	.8596
9	.8417	.8505	.7499	.7865	.823	.823	.8779
10	.8779	.8682	.8238	.7964	.7964	.8688	.8145
11	.8413	.8417	.8145	.7602	.8507	.8688	.8688
12	.8779	.8869	.8417	.8145	.8688	.8688	.9231
13	1.0242	.905	.8145	.8688	.8326	.9231	.9511
14	1.0059	.9412	.8507	.8507	.9231	1.0136	1.0974
15	1.0791	1.0425	.8688	.8869	.905	1.0498	1.134
16	1.0974	1.0059	.7164	.9231	.8869	1.0136	1.134
17	.9877	1.0059	.7059	.8688	.9145	.9774	1.0791
18	.8779	.9412	.7343	.8145	.8507	.905	.9593
19	1.0425	1.1041	.8413	.9593	.9492	.9492	1.0317
20	1.134	1.0277	.9511	1.0317	1.086	1.1403	1.2308
21	1.134	.8954	.9511	1.1041	1.1946	1.2489	1.2851
22	1.2071	.9593	.9511	1.0317	1.267	1.39	1.4449
23	1.2489	1.0242	.9145	1.0791	1.3535	1.4632	1.5546
24		1.2489	1.0059	.8596	.9511	1.2803	1.4083
Max	1.2489	1.2489	1.0059	1.1041	1.3535	1.4632	1.5546
Min	.7796	.7537	.695	.6584	.695	.8048	.8145
Avg	.9984	.9528	.8330	.8416	.9106	1.0080	1.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 206 / 11 KV KHAMLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5203	1.4148	1.262	1.0242	1.1706	1.4815	1.6095
2	1.4299	1.379	1.2071	.9877	1.134	1.4083	1.5364
3	1.3756	1.2894	1.1888	.9511	1.0974	1.3352	1.4815
4	1.2851	1.1999	1.1157	.9145	1.0608	1.1888	1.39
5	1.2127	1.4327	1.0608	.8962	1.0059	1.1523	1.2803
6	1.0924	.9745	.9877	.8779	.9511	1.0974	1.0974
7	1.0454	.964	.8962		.9511	1.0059	.9511
8	1.0099	.964	.9328	.9511	.9511	1.0059	1.0242
9	1.0387	.9568	.8962	.9328	1.0059	1.0059	1.0425
10	1.0974	.9745	.9313	1.0317	1.086	1.1222	1.1765
11	1.2071	1.1283	.9955	1.086	1.1222	1.1584	1.1946
12	1.262	1.1765	1.0208	1.1765	1.2127	1.2308	1.3032
13	1.2986	1.1765	1.0498	1.1584	1.1584	1.267	1.3535
14	1.3535	1.2127	1.0498	1.1584	1.2127	1.267	1.4083
15	1.4266	1.2986	1.0136	1.2127	1.267	1.3756	1.4998
16	1.4998	1.3352	.8596	1.2308	1.2851	1.4299	1.5729
17	1.4632	1.3352	.8507	1.4118	1.3535	1.3937	1.4998
18	1.3169	1.3032	.9313	1.3394	1.2851	1.3394	1.3937
19	1.5729	1.6289	1.2437	1.5565	1.4864	1.576	1.7194
20	1.5546	1.5415	1.2071	1.5927	1.6289	1.5927	1.6651
21	1.4815	1.2894	1.1706	1.4661	1.5203	1.5746	1.5746
22	1.4083	1.2308	1.1157	1.448	1.4842	1.6278	1.6289
23	1.4299	1.262	1.0974	1.3535	1.5729	1.701	1.7375
24	1.5927	1.5203	1.262	1.0608	1.2803	1.5364	1.701
Max	1.5927	1.6289	1.262	1.5927	1.6289	1.701	1.7375
Min	1.0099	.9568	.8507	.8779	.9511	1.0059	.9511
Avg	1.3323	1.2495	1.0561	1.1660	1.2202	1.3281	1.4101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 207 / 11 KV AMEYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9593	.985	.8413	.695	.8048	1.0242	1.134
2	.9774	.9313	.8048	.6584	.7682	.9877	1.0608
3	.9593	.8417	.7865	.6584	.7316	.9328	.9877
4	.905	.8059	.7133	.6219	.695	.8596	.9145
5	.8326	.7701	.6767	.5853	.6584	.8048	.8596
6	.7343	.7011	.6219	.567	.6219	.7316	.7682
7	.6733	.6485	.6036		.6219	.7499	.7133
8	.6379	.631	.6036	.5853	.6036	.6767	.695
9	.6626	.6201	.6584	.6036	.6401	.4207	.695
10	.6584	.6024	.6447	.6335	.6516	.3982	.6878
11	.7499	.6626	.6878	.6154	.7602		.7964
12	.7682	.724	.6626	.724	.7602	.905	.8145
13	.7682	.7602	.6697	.7602	.7964	.8688	.9145
14	.8596	.7964	.7059	.724	.7602	.8688	.9694
15	.9145	.7682	.7059	.7421	.7964		1.0059
16	.9328	.8048	.5731	.7783	.7964	.905	.9511
17	.823	.8048	.6154	.7421	.8048	.8145	.8596
18	.7682	.724	.6447	.7421	.7602	.7602	.7602
19	.8596	.905	.7682	.8688	.8417	.8775	.905
20	.9877	.8682	.823	.9231	.9955	.9955	1.0498
21	.9511	.8238	.823	.8869	1.0317	1.086	1.086
22	1.0242	.8326	.823	.9231	1.086	1.1523	1.1584
23	1.0317	.8962	.7682	.9145	1.1523	1.262	1.3352
24	1.1584	1.0317	.8596	.7133	.8779	1.1157	1.2803
Max	1.1584	1.0317	.8596	.9231	1.1523	1.262	1.3352
Min	.6379	.6024	.5731	.567	.6036	.3982	.6878
Avg	.8582	.7892	.7119	.7246	.7924	.8726	.9334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 208 / 11 KV JAYPRAKASH NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.3611	1.1888	.9328	1.0608	1.4815	1.829
2	1.3937	1.3432	1.1157	.8962	1.0242	1.39	1.7193
3	1.267	1.2536	1.0608	.8596	.9877	1.3352	1.5912
4	1.1765	1.1641	1.0059	.823	.9511	1.2254	1.4998
5	1.0317	1.0387	.9328	.7865	.8962	1.134	1.4083
6	.8596	.8328	.7865	.7316	.823	.8962	.9877
7	.9036	.8764	.7682	.823	.7865	.8413	.8596
8	.8505	.8238	.823	.823	.8962	.9145	.9877
9	.8059	.7796	.823	.8048	.8413	.8596	.8779
10	.7682	.7796	.8417	.724	.8145	.7783	.7783
11	.8048	.7343	.8869	.7783	.7783	.8145	.7783
12	.8413	.8869	.8417	.7783	.7783	.8145	.8326
13	.8962	.8688	.8145	.8326	.8326	.8869	.9593
14	.9145	.9593	.8869	.7602	.8507	.9774	1.0974
15	1.1157	1.0608	.9412	.8507	.8326	1.1222	1.2071
16	1.1523	1.0242	.7522	.9231	.8869	1.1403	1.2437
17	1.134	1.0425	.8326	.8507	.8779	1.0679	1.1157
18	.8596	.9231	.8238	.8688	.8507	.9231	.9955
19	1.0791	1.1706	.9511	1.0317	1.086	1.0208	1.1584
20	1.1706		.9877	1.1403	1.3213	1.3032	1.267
21	1.2803	1.0745	1.0425	1.1584	1.3575	1.3937	1.4299
22	1.3717	1.1403	1.0974	1.2127	1.4998	1.5912	1.6651
23	1.5023	1.262	.9694	1.2437	1.6644	1.829	1.5364
24	1.6289	1.5023	1.2803	1.0059	1.2803	1.6461	1.8107
Max	1.6289	1.5023	1.2803	1.2437	1.6644	1.829	1.829
Min	.7682	.7343	.7522	.724	.7783	.7783	.7783
Avg	1.0955	1.0392	.9356	.9017	.9991	1.1411	1.2348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 210 / 11 KV TELECOM NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.0029	.8596	.695	.8048	1.0608	1.2254
2	1.1946	.9671	.8048	.6584	.7499	.9877	1.1706
3	.9955	.8954	.7682	.6584	.7133	.9328	1.0974
4	.9231	.8238	.7316	.6219	.6584	.8596	1.0242
5	.8507	.7522	.7133	.6036	.6219	.8048	.9328
6	.7701	.691	.695	.5853	.6036	.7316	.7865
7	.7265	.6836	.6584	.6401	.6584	.6767	.7316
8	.691	.6135	.5853	.5853	.6401	.6767	.6401
9	.6268	.6201	.6036	.6219	.6036		.6401
10	.6584	.5847	.6626	.6154	.6154		.6516
11	.6219	.6447	.6335	.5611	.6335		.7059
12	.6401	.6516	.6268	.5792	.6154	.9955	.6697
13	.6767	.6154	.6516	.6697	.5973	.8145	.7499
14	.7682	.6697	.6335	.5973	.6335	.8326	.8596
15	.823	.8048	.6516	.7059	.724	.8869	.9511
16	.8596	.7865	.591	.6697	.7421	.8869	.9511
17	.8413	.7964	.5792	.724	.7133	.8688	.8779
18	.7316	.724	.6447	.7421	.6878	.9412	.8507
19	.7865	.8413	.7316	.7602	.8059	.8775	.8688
20	.9145	.815	.7499	.7964	.9412	1.0136	.9593
21	.8962	.788	.7316	.8326	.9231	1.086	1.0679
22	1.0242	.8326	.7682	.8869	1.0608	1.2437	1.2851
23	1.1222	.9511	.7499	.9328	1.1888	1.4266	1.39
24	1.2489	1.086	.8962	.7499	.8596	1.134	1.4449
Max	1.2489	1.086	.8962	.9328	1.1888	1.4266	1.4449
Min	.6219	.5847	.5792	.5611	.5973	.6767	.6401
Avg	.8563	.7767	.6967	.6872	.7415	.9399	.9388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 211 / 11 KV Prasad Nagar FDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0633	1.8267	1.5181	1.2803	1.4998	2.0302	2.3045
2	1.9185	1.773	1.4632	1.2437	1.4449	1.9387	2.1765
3	1.8461	1.6834	1.4083	1.2254	1.3717	1.8656	2.0668
4	1.6289	1.5402	1.3535	1.1888	1.3169	1.7558	1.9204
5	1.4842	1.4327	1.2986	1.1888	1.2437	1.6278	1.8107
6	1.3611	1.2403	1.2071	1.1706		1.3535	1.4998
7	1.2403	1.2094	1.1523	1.0974	1.6095	1.2986	1.3535
8	1.2403	1.1568	1.1888	1.1523	1.3169	1.2437	1.4083
9	1.2894	1.1871	1.1888	1.2254	1.3717	1.3169	1.3535
10	1.3352	1.2226	1.182	1.3032	1.267	1.3032	1.4118
11	1.3535	1.2536	1.267	1.267	1.3937	1.4118	1.448
12	1.4632	1.3394	1.1999	1.3032	1.3032	1.3756	1.4661
13	1.5181	1.3394	1.2489	1.3032	1.3394	1.4661	1.5729
14	1.5912	1.4661	1.2851	1.3394	1.4299	1.5565	1.8107
15	1.7558	1.5546	1.267	1.3756	1.448	1.7194	1.9387
16	1.829	1.6461		1.448	1.5203	1.7375	1.9753
17	1.4998	1.5546	1.1041	1.3394	1.5181	1.6108	1.7558
18	1.4266	1.4118	1.2536	1.4661	1.4299	1.448	1.5746
19	1.5546	1.7194	1.3717	1.5746	1.6476	1.6834	1.7737
20	1.7375	1.5061	1.4632	1.647	1.8823	1.8642	1.9909
21	1.7741	1.4148	1.4266	1.6289	1.9909	1.9728	2.0814
22	1.957	1.5565	1.4632	1.6651	2.0668	2.2497	2.3529
23	1.9909	1.6095	1.4266	1.7375	2.1765	2.4691	2.5606
24	2.1719	1.9909	1.6827	1.3535	1.6095	2.1582	2.4508
Max	2.1719	1.9909	1.6827	1.7375	2.1765	2.4691	2.5606
Min	1.2403	1.1568	1.1041	1.0974	1.2437	1.2437	1.3535
Avg	1.6263	1.4848	1.3226	1.3552	1.5304	1.6857	1.8358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 401 / 33 Kv Hingna-II to
 Trimurti Feeder KV- 33 /
 OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		8.6008					
9	6.2243						
11			6.1614				
12		6.8336	6.2174				
13		6.6095					
14		7.5057	6.4415				
15		7.8418	6.3855				
16		8.0659					
17		7.8418	5.4893		7.5617	8.1219	
18				7.1696	7.1696		7.8978
19		8.9621			8.3459	8.4019	8.9621
20				8.514		9.2981	
21		7.5617					10.0823
22		7.7858		8.4019	9.7462	10.5304	10.9785
24				6.6204			
Max	6.2243	8.9621	6.4415	8.514	9.7462	10.5304	10.9785
Min	6.2243	6.6095	5.4893	6.6204	7.1696	8.1219	7.8978
Avg	6.2243	7.7609	6.1390	7.6765	8.2059	9.0881	9.4802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 202 / 11 KV KACHOREPATIL FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8048	.6767	.5853	.6584	.8299	.9145
2	.8048	.7682	.6767	.5853	.6219	.811	.8779
3	.7682	.7316	.6401	.5487	.6219	.7922	.823
4	.7316	.6584	.6219	.5487	.5853	.7316	.7316
5	.695	.5853	.6036	.5121	.5853	.695	.695
6	.5853	.567	.5304	.4755	.5487	.6584	.6219
7	.5487	.567	.8779	.5121	.4755	.5121	.567
8	.5853	.5853	.4938	.5304	.5304	.5121	.543
9	.5121	.5487	.4938	.4904	.5304	.5487	.5487
10	.5487	.567	.5121	.4715	.4572	.5487	.5304
11	.5121	.567	.4938	.4715	.4938	.5068	.5487
12	.567	.6036	.4938	.5121	.5121	.543	.6219
13	.567	.6036	.5487	.5658	.567	.5973	.6219
14	.6036	.6401	.5487	.5281	.5487	.5973	.6767
15	.6401	.6584	.5487	.547	1.8107	.6335	.6584
16	.6767	.6767	.439	.6036	.6036	.6878	.695
17	.6219	.6219	.4572	.6036	.7167	.6335	.6878
18	.567	.5973	.4938	.5853		.543	.5853
19	.6584	.695	.5853	.6036	.6413	.5611	.6878
20	.7316	.6036	.6584	.695	.7167		.7964
21	.7682	.6036	.6219	.7133	.8488	.8145	.8507
22	.823	.6219	.6219	.7316	1.0608	.9145	.9412
23	.8413	.695	.6036	.7316	.9242	.9877	1.0136
24	.8962	.8413	.7133	.6036	.695	.8676	.9412
Max	.8962	.8413	.8779	.7316	1.8107	.9877	1.0136
Min	.5121	.5487	.439	.4715	.4572	.5068	.5304
Avg	.6706	.6422	.5815	.5732	.6850	.6751	.7158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 205 / 11 KV SOMALWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0485	1.9753	1.5844	1.4266	1.5729	1.9239	2.1399
2	2.0119	1.9387	1.4083	1.3717	1.5364	1.8484	2.0119
3	1.9204	1.8656	1.358	1.3169	1.4998	1.7918	1.7375
4	1.829	1.7924	1.2826	1.2254	1.4632	1.5655	
5	1.6461	1.6461	1.1506	1.2254	1.3717	1.5278	
6	1.3352	1.4266	1.2254	1.1157	1.1888	1.3769	
7	1.3717	1.2803	1.262	1.1888	1.2071	1.358	1.2986
8	1.3169	1.2803	1.2127	1.2071	1.2254	1.3203	1.39
9	1.3717	1.2986	1.262	1.3203	1.2986	1.4266	1.4815
10	1.39	1.4266	1.2437	1.3203	1.3756	1.4083	1.4815
11	1.5546	1.4632	1.3169	1.3769	1.4449	1.4632	1.5546
12	1.5746	1.7193	1.39	1.3817	1.4998	1.4815	1.6461
13	1.5912	1.6461	1.3535	1.4146	1.5181	1.701	1.7558
14	1.6644	1.6827	1.39	1.5089	1.5364	1.7741	1.8839
15	1.7924	1.7193	1.39	1.4998	1.5729	1.9022	1.9753
16	1.9022	1.7924	1.0608	1.5466	1.5364	1.9387	1.9936
17	1.8473	1.7558	1.134	1.6461	1.6032	1.7741	1.957
18	1.5912	1.5655	1.2254	1.5364	1.6032	1.5729	1.7924
19	1.829	1.7193	1.6095	1.7558	1.7164	1.701	1.8656
20	1.9204	1.7741	1.6827	1.7193	1.8673		2.0119
21	1.9022	1.3957	1.6095	1.7193	1.9239	1.9387	2.1765
22	1.9753	1.5364	1.6461	1.7193	1.9993	2.1033	2.3045
23	2.0485	1.5546	1.4815	1.7924	1.9239	2.3594	2.4143
24	2.1948	2.0668	1.6598	1.4632	1.6278	2.1125	2.2131
Max	2.1948	2.0668	1.6827	1.7924	1.9993	2.3594	2.4143
Min	1.3169	1.2803	1.0608	1.1157	1.1888	1.3203	1.2986
Avg	1.7346	1.6384	1.3725	1.4499	1.5464	1.7117	1.8612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 206 / 11 KV KARVE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.2715	1.0608	.8954	.9671	1.3203	1.4632
2	1.3717	1.2536	.9694	.8596	.9313	1.3014	1.3717
3	1.3169	1.1641		.8238	.8954	1.226	1.2986
4	1.2803	1.1104		.788	.8238	1.1157	1.1888
5	1.0974	1.0745		.788	.8238	1.0608	1.0242
6	.9511	.9492	.9671	.7522	.8059	.8962	.9511
7	.8962	.8954	.8596	.7164	.7343	.8048	.8775
8		.8417	.8048	.7164	.788	.8413	.8962
9	.8954	.8238	.788	.7733	.8059	.8417	.8238
10	.8238	.8238	.8059	.7922	.7701		.8596
11	.8775	.8954	.8238	.8865	.8417	.985	.8238
12	1.0029	1.0566	.9134	.8962	.9492	1.0387	.9492
13	.985	.985	.9134	.9431	.9313	.9671	1.0608
14	1.0566	1.0208	.8954	.9808	.9492	1.0208	1.1283
15	1.1283	1.0208	.8954	.9619	.8869	1.1283	1.1641
16	1.1462	1.0387	.6805	.9619	.9313	1.0924	1.1462
17	1.0924	1.0425	.7522	.7164	.9619	1.0208	1.1283
18	.8954	.9694	.8059	.8417	.9431	.8954	.9671
19	1.0924	1.1523	.9671	.9671	1.094	1.0387	1.0924
20	1.182	1.0242	1.0208	1.0924	1.226		1.2536
21	1.1999	1.0029	1.0387	1.0387	1.3203	1.3535	1.4506
22	1.3073	1.0924	1.0208	1.1283	1.4266	1.4506	1.4506
23	1.379	1.2071	1.0387	1.182	1.5466	1.5565	1.6118
24	1.6297	1.3611	1.1706	.9492	1.0387	1.3957	1.5181
Max	1.6297	1.3611	1.1706	1.182	1.5466	1.5565	1.6118
Min	.8238	.8238	.6805	.7164	.7343	.8048	.8238
Avg	1.1319	1.0449	.9139	.8938	.9747	1.1069	1.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 207 / 11KV CARGO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.3203	1.643	1.3957	1.3203	1.2826	1.3957
2	1.4146	1.2826	1.7164	1.3957	1.2826	1.3014	1.3392
3	1.358	1.226	1.6644	1.358	1.226	1.2449	1.2637
4	1.3203	1.1694	1.1949	1.358	1.1694	1.2071	
5	1.3203	1.1317	1.1949	1.3957	1.1317	1.226	1.1888
6	1.2449	1.0751	1.4712	1.1694	1.094	.9997	1.2071
7	1.2449	1.094	1.4335	1.1128	1.1317	1.0562	1.1694
8	1.2071	1.2637	1.3014	1.1883	1.2071	1.0562	1.2449
9	1.358	1.3203	1.4335	1.0751	1.226	1.1506	1.3392
10	1.4523	1.2637	1.3957	1.1694	1.1883	1.3769	1.226
11	1.4712	1.2637	1.1317	1.3014	1.2071	1.3769	1.3392
12	1.4901	1.3203		1.307	1.3014	1.4335	1.4523
13	1.4523	1.2071	1.094	1.2826	1.3203	1.3957	1.4712
14	1.4712	1.2826	1.1317	1.226	1.3203	1.3957	1.3203
15	1.3769	1.3203	1.226	1.094	1.3392	1.0562	1.4146
16	1.2449	1.1883	1.2449	1.2449	1.4335	1.3014	1.5466
17	1.2826	1.3769	1.2449	1.2449	1.3203	1.3014	1.3014
18	1.3392	1.3957	1.2449	1.1506	1.3014	1.3957	1.4335
19	1.6409	1.6975	1.5655	1.5089	1.4712	1.4712	1.5089
20	1.5089	1.4335	.9997	1.4712	1.6221		1.6975
21	1.7164	1.4335	1.5089	1.4712	1.6221	1.5912	1.5278
22	1.6221	1.5684	1.5089	1.4712	1.5844	1.6221	1.5278
23	1.5278	.1339	1.3769	1.3392	1.4901	1.4712	1.6598
24	1.5655	1.3769	1.4937	1.3957	1.3203	1.358	1.4335
Max	1.7164	1.6975	1.7164	1.5089	1.6221	1.6221	1.6975
Min	1.2071	.1339	.9997	1.0751	1.094	.9997	1.1694
Avg	1.4209	1.2561	1.3574	1.2970	1.3180	1.3075	1.3917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 403 / 33 Khapari- chichbhawan-I

Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3755	5.1029	4.0724	3.5294	3.9095	5.2058	
2	5.1583	4.9954	3.8009	3.4208	3.8009	5.036	
3	4.9954	4.7782	2.7149	3.2579	3.6923	4.7531	
4	4.6696	4.5068	2.552	3.095	3.5294	4.2353	
5	4.1267	4.1267		3.095	3.3665	4.0181	
6	3.5837	3.7466	3.4751	2.9321	3.1493	3.5837	
7	3.5837	3.4751	3.3122	3.095	3.2036	3.4208	
8	3.5117	3.4208	3.2036	3.1493	3.2579	3.4385	3.5837
9	3.1493	3.3122	3.2579	3.2819	3.3665	3.5837	3.638
10	3.3665	3.4208	3.2922	3.3385	3.3665	2.6606	3.5837
11	3.5837	3.638	3.3122	3.5082	3.5294	3.7466	3.7466
12	3.8009	4.181	3.5294	3.4208	3.6923	2.4977	3.9638
13	3.9638	3.9638	3.5837	3.678	3.7466	4.3439	4.2353
14	4.1267	4.0724	3.5837	3.7912	3.8009		4.6639
15	4.4525	4.1267	3.5294	3.8477		4.6153	4.8325
16	4.6696	4.2896	2.8532	3.7912	3.8009	4.6696	4.8325
17	4.6153	4.3439	3.1276	3.638	4.0175	4.3439	4.7239
18	3.8552	3.9095	3.3471	3.638	3.9609	3.9095	4.3439
19	4.5068	4.561	3.9095	4.1267	4.357	4.2896	4.6696
20	4.8325	4.8868	4.0724	4.3982	4.9794		5.1583
21	4.8868	3.7466	4.0181	4.3439	5.2058		5.647
22	5.1583	4.0724	3.9638	4.3982	5.2652		5.9728
23	5.3212	4.2353	3.8552	4.561	5.9414		6.5158
24	5.9185	5.3212	4.3439	3.6923	4.1701	5.6019	6.0814
Max	5.9185	5.3212	4.3439	4.561	5.9414	5.6019	6.5158
Min	3.1493	3.3122	2.552	2.9321	3.1493	2.4977	3.5837
Avg	4.3838	4.1764	3.5091	3.6262	3.9613	4.1028	4.7172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 404 / 33 Kv Khapri- Chichbhawan-
II Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4298	5.1583	4.6696	4.3982		6.1111	
2	5.2669	4.9411	4.561	4.3439	4.7239	6.1111	
3	5.104	4.7239	4.6965	4.2896	4.561	5.6019	
4	4.8325	4.4525	3.9638	4.0724	4.2896	5.104	
5	4.4525	4.0181		4.0724	4.1267	4.8325	
6	4.0724	3.8552	3.8552	3.8009	3.9095	4.2353	
7	3.9638	3.7466	3.7466	3.8009	3.9095	4.0181	
8	3.9506	3.9095	3.5665	4.0181	4.1267	3.9095	4.3982
9	3.8009	3.8552	3.9095	3.9043	4.0724	4.1267	4.3982
10	4.0181	3.6923	3.8552	4.5833	3.6923	4.1267	4.2896
11	3.9095	3.9638	3.638	4.8663	3.7466	4.181	4.2896
12	4.0181	4.0181	3.5294		3.9095	3.2579	4.561
13	4.1267	3.9638	3.5294	3.9043	3.9638	4.5068	4.8325
14	4.3439	4.0724	3.8009	4.1307	4.5068	4.7239	4.9954
15	4.5068	4.2353	3.8552	4.1307		4.6696	5.3755
16	4.6153	4.3982	2.4434	4.4702	4.8285	5.1583	5.5384
17	4.5068	4.4525	3.6923	4.2353	4.9228	4.8325	5.2126
18	4.0724	4.2896	3.9095	4.181	4.5833	4.7782	4.9411
19	4.7239	5.1583	4.3982	4.9954	5.1492	4.9954	5.3212
20	4.8868	5.104	4.0181	5.2126	5.8848		6.1357
21	5.104	4.2896	4.2896	5.3212	6.0545	6.0271	6.2443
22	5.2126	4.5068	4.2896	5.3755	6.3529		6.6787
23	5.487	4.6153	4.5068	5.3224	6.5638		7.5474
24	5.8642	5.2669	4.6153	4.4525	5.048	6.4506	6.8959
Max	5.8642	5.2669	4.6965	5.3755	6.5638	6.4506	7.5474
Min	3.8009	3.6923	2.4434	3.8009	3.6923	3.2579	4.2896
Avg	4.5946	4.3620	3.9713	4.4297	4.6785	4.8456	5.3915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 201 / 11KV GAYATRI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.5175	.462	.3658	.4435	.5544	.8596
2	.5729	.4805	.4251	.3658	.4251	.5175	.7499
3	.5359	.462	.4066	.3475	.4066	.499	.695
4	.5175	.4435	.3881	.3475	.3881	.4805	.6401
5	.4805	.4251	.3881	.3292	.3696	.462	.5304
6	.4251	.3881	.3511	.3292	.3511	.4066	.4207
7	.3881	.3881	.3511	.2926	.3696	.3696	.4024
8	.3696		.3142	.2743	.2957	.3511	.3475
9	.3696	.3511	.3475	.3475	.3142	.3511	.3475
10	.3511	.3696	.3841	.3841	.3511	.4066	.3841
11	.3109	.3696	.3658	.3841	.3511	.3881	
12	.3658	.4251	.3658	.3475	.3142	.4066	.3475
13	.3841	.4251	.3658	.3658	.3696	.462	.4572
14	.4207	.499	.3841	.3841	.3142	.499	.4938
15	.4938	.499	.3658	.439	.4251	.499	.5853
16	.5121	.5914	.3109	.4207	.5175	.5544	.6219
17	.4755	.499	.3475	.3841	.499	.4805	.5487
18	.4435	.462	.3841	.3696	.4435	.4435	.5304
19		.5544	.4024	.3881	.4805	.4805	.5304
20	.499	.499	.4066	.4805	.5359	.5175	.567
21	.499	.4435	.4024	.5175	.5729	.5729	.6036
22	.5359	.462	.439	.5175	.6099	.6283	.6722
23	.5914	.499	.4024	.4805	.6468	.7392	.7762
24		.5544	.3841		.462	.7207	
Max	.6099	.5914	.462	.5175	.6468	.7392	.8596
Min	.3109	.3511	.3109	.2743	.2957	.3511	.3475
Avg	.4615	.4612	.3810	.3853	.4274	.4913	.5505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 202 / 11 KV IT PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.499	.3772	.3547	.499	.5175	.6413
2	.462	.4668	.3772	.3547	.462	.4805	.6979
3	.4435	.4294	.3584	.3361	.4066	.4435	.7356
4	.4251	.3921	.3584	.3361	.3696	.4066	.7545
5	.4066	.3511	.3584	.3174	.3326	.3881	.7762
6	.4066	.3696	.3395	.3174	.3511	.3696	.8299
7	.3696	.3511	.3206	.3174	.3326	.3696	.415
8	.5729		.3206	.5228	.499	.4435	.5847
9	.924	.6099	.3395	.8402	.7577	.9055	.9619
10	1.2382	.6838	.3584	1.2136	1.1643	1.2936	1.2826
11	1.3352	.7655	.415	1.1888	1.4045	1.3491	
12	1.39	.8029	.3961	1.2883	1.2936	1.423	1.4266
13	1.4449	.8589	.415	1.3256	1.4784	1.46	1.5181
14	1.4083	.8962	.4338	1.3817	1.2936	1.5339	1.4632
15	1.5729	.8589	.3961	1.5181	1.423	1.6263	1.5181
16	1.0164	.9335	.3584	1.4998	1.4045	1.6448	1.5912
17	1.5181	.8501	.3772	1.3535	1.4415	1.5524	1.5546
18	1.2936	.7842	.3772	1.1827	1.46	1.5154	1.4449
19	1.1273	.6535	.3395	1.0534	1.1458	1.3491	1.2803
20	.8871	.5601	.3395	.8501	.9795	.9795	.9328
21	.7023	.3921	.3395	.6838	.7207	.7577	.7865
22	.6468	.3734	.3475	.6468	.6653	.7023	.6516
23	.6283	.3734	.3292	.6283	.6283	.5729	.6979
24		.5359	.3658			.5914	
Max	1.5729	.9335	.4338	1.5181	1.4784	1.6448	1.5912
Min	.3696	.3511	.3206	.3174	.3326	.3696	.415
Avg	.9000	.5996	.3641	.8483	.8919	.9448	1.0248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 203 / 11 KV SUBHASH NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3676	1.3306	1.0719	.9328	1.1088	1.3676	1.4266
2	1.3121	1.2567	1.0349	.9145	1.0719	1.3121	1.0791
3	1.2752	1.2012	1.0349	.8779	1.0349	1.2567	.9877
4	1.2197	1.1458	1.0164	.8596	1.0164	1.2012	.9328
5	1.1643	1.0903	1.0164	.823	.9979	1.1458	.8962
6	1.0164	.961	.8686	.8048	.9055	.9425	.8596
7	.8316	.8501	.8316	.7133	.7577	.8871	.8779
8	.7947		.8131	.7133	.7947	.8316	.8779
9	.8871	.7762	.7865	.823	.8131	.8501	.8779
10	.9055	.8316	.7865	.8962	.9055	.961	.9877
11	1.0059	.9425	.7499	.9328	1.0349	1.1088	
12	1.0791	.9795	.8048	.9694	1.0164	1.0534	1.134
13	1.2071	.9795	.8779	1.0425	1.0349	1.1458	1.2071
14	1.1157	1.0534	.8779	1.0242	1.0164	1.2012	1.2437
15	1.1523	1.0349	.8413	1.0791	1.0164	1.2382	1.3169
16	1.2254	1.1458	.7316	1.0425	1.0719	1.3121	1.2803
17	1.2254	1.1088	.7133	.9877	1.0719	1.0903	1.262
18	1.0719	1.0349	.823	1.0534	1.0164	1.0903	1.1706
19	1.2567	1.2382	1.0059	1.1827	1.2382	1.1827	1.2254
20	1.3491	1.1643	1.0608	1.2197	1.3121	1.2936	1.2437
21	1.3306	1.1088	1.0608	1.2197	1.2936	1.3676	1.3717
22	1.3676	1.1273	1.0608	1.2752	1.423	1.46	1.5123
23	1.423	1.1088	1.0242	1.2012	1.4784	1.5524	1.5893
24		1.4045	.9694		1.1458	1.5154	
Max	1.423	1.4045	1.0719	1.2752	1.4784	1.5524	1.5893
Min	.7947	.7762	.7133	.7133	.7577	.8316	.8596
Avg	1.1558	1.0815	.9109	.9821	1.0657	1.1820	1.1527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 204 / 11 KV PERSISTENT FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.1478	.1463	.1663	.1663	.128
2	.1478	.1478	.1478	.1463	.1663	.1663	.128
3	.1478	.1478	.1478	.1463	.1663	.1663	.1294
4	.1478	.1478	.1478	.1463	.1663	.1663	
5	.1478	.1478	.1478	.1463	.1663	.1663	.128
6	.1478	.1478	.1478	.1463	.1478	.1478	.128
7	.1848	.1478	.1478	.1463	.1663	.1478	.1829
8	.1848		.1294	.1646	.2033	.2033	.1829
9	.2402	.1663	.1463	.2561	.2587	.2957	.3109
10	.3511	.1848	.1463	.3292	.3142	.2957	.3109
11	.3841	.2218	.1463	.3696	.3326	.3326	
12	.4024	.2033	.1463	.4207	.3511	.3511	.3841
13	.3841	.2218	.1646	.3841	.4066	.4066	.4024
14	.4572	.2218	.1463	.4024	.3511	.4066	.4207
15	.3658	.2218	.1646	.3841	.3511	.4066	.3841
16	.4207	.2033	.1463	.3475	.3511	.462	.3841
17	.4024	.1848	.1646	.3841	.3881	.499	.4207
18	.3696	.1848	.1646	.3326	.3696	.3511	.4207
19	.4066	.1848	.1646	.3142	.3511	.3881	.3841
20	.3142	.1478	.1646	.2587	.2587	.2957	.3109
21	.2402	.1478	.1646	.2218	.2033	.2218	.2195
22	.1663	.1478	.1463	.1848	.1663	.1663	.2054
23	.1663	.1478	.1463	.1663	.1478	.1663	.1663
24		.1663	.128		.1663	.1478	
Max	.4572	.2218	.1646	.4207	.4066	.499	.4207
Min	.1478	.1478	.128	.1463	.1478	.1478	.128
Avg	.2751	.1735	.1506	.2585	.2549	.2718	.2730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 205 / 11 KV SHEWALKAR GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4251	.3696	.3292	.3696	.4805	.4938
2	.462	.4066	.3696	.3292	.3511	.462	.4207
3	.4435	.4066	.3696	.3292	.3326	.4251	.4024
4	.4251	.3881	.3881	.3292	.3142	.4066	.3841
5	.4251	.3696	.3881	.3292	.3142	.3881	.3292
6	.4435	.3881	.3511	.3292	.3511	.4066	.2561
7	.3696	.3881	.3511	.2926	.3696	.3511	.3841
8	.3881		.3326	.3109	.3326	.3511	.3475
9	.3696	.3511	.3292	.3658	.3511	.3511	.3658
10	.4066	.3326	.3475	.3658	.4251	.462	.4024
11	.5121	.3881	.3109	.4755	.4805	.5175	
12	.5121	.4066	.3109	.4207	.5175	.5175	.5487
13	.5121	.3511	.3142	.4938	.4805	.5175	.5121
14	.5121	.3881	.3292	.4572	.5175	.5175	.5121
15	.5853	.462	.3292	.4755	.499	.5359	.5487
16	.5853	.462	.2743	.5121	.499	.5729	.567
17	.6036	.4251	.2743	.4755	.5175	.5544	.567
18	.4805	.4066	.3475	.4435	.499	.4805	.5304
19	.462	.462	.3292	.4435	.499	.4805	.4938
20	.4805	.4251	.3475	.3881	.499	.462	.4572
21	.4066	.3696	.3292	.4251	.499	.462	.5304
22	.4435	.3696	.3658	.4251	.499	.5175	.5601
23	.4435	.3696	.3475	.3696	.5175	.5175	.6099
24		.4435	.3292		.3696	.499	.5175
Max	.6036	.462	.3881	.5121	.5175	.5729	.6099
Min	.3696	.3326	.2743	.2926	.3142	.3511	.2561
Avg	.4675	.3993	.3390	.3963	.4335	.4682	.467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 206 / 11KV ATREY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8686	.7947	.6468	.5487	.6468	.8316	.9145
2	.8316	.7392	.6283	.5304	.6283	.7762	.8596
3	.7762	.7023	.5914	.5304	.6099	.7207	.7865
4	.7207	.6468	.5729	.5121	.5914	.6838	.7499
5	.6653	.6099	.5729	.4938	.5544	.6283	.6219
6	.5914	.5544	.5175	.4755	.462	.5544	.567
7	.5359	.5175	.462	.4572	.4805	.5175	.5487
8	.5729		.4805	.4755	.5359	.5544	.5853
9	.5544	.5359	.4938	.6219	.6283	.5729	.6219
10	.6653	.5544	.5487	.6401	.6468	.6838	.6401
11	.7133	.7762	.6036	.7316	.8316	.8131	
12	.823	.8131	.6219	.695	.8871	.8131	.823
13	.8596	.8501	.6219	.8413	.9055	.8686	.8962
14	.9877	.9425	.6767	.8596	.8871	.924	1.0425
15	1.0608	.961	.7316	.9328	1.0534	.9979	1.0425
16	1.0974	.9425	.5853	.9328	.924	1.0164	.9145
17	1.0791	.9055	.6036	.823	.924	.9425	.8962
18	.8686	.8501	.6219	.8316	.8316	.8316	.8413
19	.961	.9425	.7316	.8686	.9425	.924	.8413
20	.924	.8316	.6767	.8501	.961	.9979	.8962
21	.8131	.7392	.7133	.8131	.9055	.9425	.9877
22	.7947	.6653	.6219	.7577	.8501	1.0164	1.0269
23	.8316	.7023	.6036	.7392	.961	.9979	1.0719
24		.8501	.5853		.6653	.8871	.9795
Max	1.0974	.961	.7316	.9328	1.0534	1.0164	1.0719
Min	.5359	.5175	.462	.4572	.462	.5175	.5487
Avg	.8085	.7577	.6047	.694	.7631	.8124	.8328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 207 / 11 KV GOPAL NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	.9979	.8686	.6584	.8131	1.0719	1.1888
2	1.0534	.9425	.8316	.6401	.7762	1.0164	1.1523
3	.9979	.8871	.7762	.6219	.7207	.961	1.0791
4	.924	.8316	.7392	.6036	.6838	.9055	1.0059
5	.8501	.7762	.7207	.5853	.6653	.8316	.9145
6	.7947	.8131	.6838	.5853	.6468	.7762	.8048
7	.7392	.6838	.6653	.6036	.6468	.5201	.7316
8	.6468		.6653	.6219	.6468	.6838	.7133
9	.924	.6099	.6838	.6584	.6653	.7392	.6767
10	1.2382	.6468	.6468	.6036	.6838	.7023	.7499
11	.7577	.7392	.7282	.6584	.6468	.7762	.7865
12	.8131	.7577	.6653	.6516	.7023	1.0719	.7499
13	.8686	.8131	.7577	.7059	.7762	.9055	.9328
14	.8962	.924	.8131	.7602	.8316	.9425	1.0136
15	.924	.9425	.7392	.8507	.7947	.9795	1.0679
16	1.0059	.9425	.6468	.7602	.8501	1.0164	1.0317
17	.961	.9055	.6697	.7964	.8316	.9425	.9774
18	.8316	.8871	.7059	.8131	.7947	.8316	.9511
19	1.0349	1.0534	.823	.9055	.9425	1.0164	1.0242
20	1.0349	.9795	.8413	.9795	1.0903	1.1088	1.1888
21	1.0349	.8871	.823	.9425	1.1458	1.1458	1.1888
22	1.0534	.8871	.823	.9795	1.1458	1.2197	1.251
23	1.0903	.961	.7499	.924	1.2012	1.3121	1.4045
24		1.0349	.695		.8501	1.2567	
Max	1.2382	1.0534	.8686	.9795	1.2012	1.3121	1.4045
Min	.6468	.6099	.6468	.5853	.6468	.5201	.6767
Avg	.9384	.8654	.7401	.7352	.8147	.9472	.9820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 210 / 11 KV NAVNIRMAN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9055	.8501	.7207	.5487	.6468	.8871	.8962
2	.8686	.8131	.6838	.5304	.6283	.8501	.8048
3	.8131	.7762	.6468	.5121	.6099	.8131	.7499
4	.7762	.7392	.6283	.4938	.5914	.7392	.695
5	.7392	.6838	.5914	.4755	.5544	.6838	.6584
6	.6468	.5729	.5359	.4755	.5175	.5914	.6036
7	.6283	.5914	.5544	.5121	.5544	.5914	.567
8	.6099		.5359	.5487	.6099	.6099	.6401
9	.6099	.5914	.5729	.6401	.6468	.6653	.6767
10	.6838	.6099	.5853	.567	.6283	.7207	.6767
11	.7499	.6838	.5853	.695	.7023	.7023	
12	.8048	.7207	.6036	.7133	.7392	.7762	.7865
13	.8048	.7207	.5853	.7133	.7577	.7947	.823
14	.8779	.8316	.6653	.695	.7392	.8501	.9145
15	.9328	.8686	.6219	.7682	.7947	.8871	.9877
16	.9877	.9055	.5487	.8413	.8316	.961	1.0059
17	.9145	.8686	.5853	.8048	.7947	.9055	.9511
18	.8316	.8131	.6219	.8501	.8501	.8686	.8596
19	.9795	.961	.695	.924	.961	.9795	.9877
20	.9425	.8501	.7133		.9979	.9979	1.0608
21	.8871	.7577	.7133		1.1643	.9979	.9877
22	.8871	.7947	.7133	.8501	.9795	1.0534	1.0829
23	.924	.7577	.6219	.7947	.9979	1.0349	1.1643
24		.8871	.5853		.6838	.9795	
Max	.9877	.961	.7207	.924	1.1643	1.0534	1.1643
Min	.6099	.5729	.5359	.4755	.5175	.5914	.567
Avg	.8176	.7673	.6215	.6645	.7492	.8309	.8446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 401 / 33 Kv Hingna-I to IT park

Feeder KV- 33 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5927	5.4298	4.6399	3.9209	4.6153	5.7013	6.4746
2	5.5927	5.104	4.5268	5.4332	4.3982	5.4841	5.8162
3	5.3212	4.9411	4.3004	3.7529	4.269	5.1583	5.487
4	5.104	4.6153	4.2438	3.6969	4.0181	4.8325	5.2126
5	4.7782	4.3439	4.2438	3.4019	3.8552	4.6153	4.7737
6	4.3439	4.2135	3.8477	3.3471	3.638	4.1267	4.0055
7	3.9638	3.8009	3.6214	3.3471	3.5837	3.9095	4.0604
8	4.0724		3.5648	3.5665	3.9363	3.9095	4.225
9	4.561		3.678	4.5931	4.3439	4.6153	4.8788
10	5.2126		3.9043	4.9383	4.9954	5.3755	5.3224
11	5.7105	4.7782	3.9609	5.3772	5.647	5.8642	6.154
12	6.2809	4.9954	4.0175	5.5441	5.7659	6.2094	6.2649
13	6.6204	5.104	4.1872	5.8768		6.4072	6.7638
14	6.653	5.647	4.357	5.9322	6.0431	6.733	6.7084
15	7.041	5.7013	4.257	6.4312	6.0431	7.0045	7.4291
16	7.3525	5.9728	3.6408	6.3758	6.3758	7.3303	7.54
17	7.1519	5.5927	3.7912	5.9877	6.4312	6.8416	7.2074
18	6.0271	5.4887	4.1307	5.7556	6.2094	6.3758	6.7638
19		6.0545	4.4445	5.9185	6.4615	6.5975	4.6719
20	6.3649	5.4887	1.0974	5.8099	6.5158	6.5975	6.653
21	5.8099	4.8663	4.4993	5.5384	6.4072	6.3758	6.5975
22	5.8099	4.8663	4.4993	5.5384	6.2443	6.7084	6.8747
23	5.9728	4.9228	4.225	5.2126	6.4072	6.8193	7.0965
24	5.8642	5.7556	5.048		4.7782	6.5975	
Max	7.3525	6.0545	5.048	6.4312	6.5158	7.3303	7.54
Min	3.9638	3.8009	1.0974	3.3471	3.5837	3.9095	4.0055
Avg	5.7044	5.1278	4.0303	5.0129	5.2601	5.8413	5.9557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 201 / 11 KV Ekatmata Nagar SHEDDABLE URBAN
Feeder Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.848	.7766	.6495	.5413	.6134	.8299	.885
2	.8119	.7405	.6495	.5398	.5954	.7758	.8299
3	.7578	.7217	.6321	.5052	.5599	.7397	.7758
4	.7217	.6856	.6141	.5052	.5238	.7036	.7217
5	.6495	.6134	.5238	.4871	.4877	.6315	.6856
6	.5774	.5238	.4877	.433	.4696	.5593	.5593
7	.4691	.4871	.4877	.433	.433	.4691	.5232
8	.433	.4515	.4154	.3969	.415	.433	.4691
9	.4511	.4154	.3973	.3969	.415	.433	.433
10	.415	.4515	.433	.3789	.415	.4871	.4691
11	.433	.4335	.433	.415	.415	.4511	.4691
12	.4696	.4154	.4511	.415	.415	.4696	.4871
13	.4154	.5057	.433	.415	.3789	.5413	.5593
14	.5413	.5418	.4511	.433	.4871	.5593	.6134
15	.6141	.5599	.4511	.4691	.5052	.5954	.5774
16	.6134	.596	.3789	.5052	.5052	.6134	.5774
17	.5232	.5413	.3969	.3789	.4871	.5052	.5232
18	.4154	.4877	.3969	.3969	.4511	.4871	.4691
19	.5593	.6141	.4871	.4871	.5052	.5052	.4691
20	.6315	.5954	.5593	.6141	.7217	.6676	.6683
21	.6676	.5774	.5413	.6676	.7758	.7578	.7036
22	.7586	.6315	.5774	.6856	.866	.866	.8128
23	.8128	.6676	.5774	.7036	.8841	.9382	.866
24	.885	.8128	.6495	.5774	.6495	.848	.9211
Max	.885	.8128	.6495	.7036	.8841	.9382	.9211
Min	.415	.4154	.3789	.3789	.3789	.433	.433
Avg	.6031	.5770	.5031	.4909	.5406	.6195	.6279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 202 / 11 KV SANGHARSH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4459	1.2963	1.037	.9269	1.037	1.4074	1.5386
2	1.3347	1.2593	1.0185	.8898	1.0185	1.3333	1.483
3	1.2976	1.1481	1	.8527	.963	1.2606	1.3903
4	1.2235	1.1111	1	.8157	.9259	1.2049	1.3162
5	1.1308	1.0556	.9259	.7971	.8704	1.0566	1.2235
6	.9269	.8889	.8333	.7415	.7963	.9083	.9454
7	.8157	.7593	.7407	.6674	.7222	.8157	.8713
8	.723	.7593	.7222	.6303	.7222	.76	.7971
9	.7415	.7037	.6852	.6859	.7593		.8157
10	.7971	.8148	.7971	.7786	.8148		.9083
11	.9139	.8519	.8342	.7963	.8704		.9259
12	.8333	.8333	.8342	.8519	.8889	1.1308	.9259
13	.8704	.8889	.8342	.8157	.8333	1.0381	1
14	.9444	.9259	.8898	.8527	.8704	1.1123	1.0926
15	1.0741	1	.8342	.9269	.9074	1.1493	1.1852
16	.9259	1.0556	.6674	.8704	.963	1.1123	1.1852
17	.9259	.963	.6674	.76	.8898	.9825	1.0741
18	.7778	.8157	.7786	.8898	.8704	.8713	.9074
19	1.037	1.0185	.9269	1.001	.9825	.9083	1.0741
20	1.1667	.5191	.964	1.1296	1.2606	1.2235	1.3333
21	1.1667		1.0196	1.1667	1.3347	1.3532	1.4259
22	1.3148		1.0381	1.2037	1.463	1.5757	1.6111
23	1.3889	.9269	1.0196	1.2222	1.5185	1.7055	1.7407
24	1.5201	1.3889	1.0937	.964	1.1296	1.5185	1.6684
Max	1.5201	1.3889	1.0937	1.2222	1.5185	1.7055	1.7407
Min	.723	.5191	.6674	.6303	.7222	.76	.7971
Avg	1.0540	.9538	.8817	.8849	.9755	1.1632	1.1850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 204 / 11 KV Shivangaon feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3261	.308		.1993	.2355	.308	.308
2	.308	.2899		.1993	.2355	.308	.308
3	.308	.2899		.1993	.2355	.2899	.308
4	.2899	.2718		.1993	.2174	.2718	.2899
5	.2718	.2718		.1812	.2174	.2537	.2718
6	.2355	.2174		.1812	.1993	.2174	.2355
7	.2174	.1993		.1812	.1812	.1812	.2174
8	.1812	.1812		.1812	.1812	.1812	.1812
9	.1812	.1993		.1812	.1631	.1812	.2174
10	.1993	.1993		.1812	.1631	.1812	.2174
11	.1846	.1812	.1631	.1449	.1812	.1812	.1812
12	.2174	.1812	.1631	.1631	.1812	.1812	.1993
13	.2174	.1993	.1449	.1812	.1993	.1812	.2174
14	.2537	.2174		.1993	.1993	.2537	.2718
15	.2718	.2355	.1993	.2174	.2174	.2537	.2537
16	.2537	.2537	.1631	.1993	.1993	.2537	.2718
17	.2537	.2174	.1449	.1812	.1993	.2174	.2174
18	.1812	.2174	.1812	.1812	.1812	.2174	.2174
19	.2174	.2355	.1812	.2355	.1993	.1993	.2174
20	.2537	.1993	.2174	.2355	.2899	.2718	.308
21	.2718	.1812	.2174	.2537	.308	.308	.308
22	.308	.1993	.2174	.2537	.3261	.3443	.3261
23	.308		.2174	.2718	.3261	.3443	.3443
24	.3261	.308		.1993	.2537	.308	.3261
Max	.3261	.308	.2174	.2718	.3261	.3443	.3443
Min	.1812	.1812	.1449	.1449	.1631	.1812	.1812
Avg	.2515	.2284	.1842	.2001	.2204	.2454	.2589